

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 48

Regarding South Texas Project, Units 1 and 2

Draft Report for Comment

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>. Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and Title 10, "Energy," in the *Code of Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents
U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250
2. The National Technical Information Service
Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: U.S. Nuclear Regulatory Commission
Office of Administration
Publications Branch
Washington, DC 20555-0001

E-mail: DISTRIBUTION.RESOURCE@NRC.GOV
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

DISCLAIMER: This report was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product, or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 48

Regarding South Texas Project, Units 1 and 2

Draft Report for Comment

Manuscript Completed: November 2012

Date Published: November 2012

COMMENTS ON DRAFT REPORT

Any interested party may submit comments on this report for consideration by the NRC staff. Comments may be accompanied by additional relevant information or supporting data. Please specify the report number NUREG-1437, Supplement 48, in your comments, and send them by the end of the comment period specified in the *Federal Register* notice announcing the availability of this report.

Addresses: You may submit comments by any one of the following methods. Please include Docket ID **NRC-2010-0375** in the subject line of your comments. Comments submitted in writing or in electronic form will be posted on the NRC website and on the Federal rulemaking website <http://www.regulations.gov>.

Federal Rulemaking Website: Go to <http://www.regulations.gov> and search for documents filed under Docket ID **NRC-2010-0375**. Address questions about NRC dockets to Carol Gallagher at 301-492-3668 or by e-mail at Carol.Gallagher@nrc.gov.

Mail comments to: Cindy Bladey, Chief, Rules, Announcements, and Directives Branch (RADB), Division of Administrative Services, Office of Administration, Mail Stop: TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Faxes may be sent to RADB at 301-492-3446.

For any questions about the material in this report, please contact Tam Tran, NRC Environmental Project Manager, at 1-800-368-5642, extension 3617, or by e-mail at tam.tran@nrc.gov

Please be aware that any comments that you submit to the NRC will be considered a public record and entered into the Agencywide Documents Access and Management System (ADAMS). Do not provide information you would not want to be publicly available.

ABSTRACT

This supplemental environmental impact statement has been prepared in response to an application submitted by STP Nuclear Operating Company (STPNOC) to renew the operating licenses for South Texas Project (STP), Units 1 and 2, for an additional 20 years.

This supplemental environmental impact statement (SEIS) includes the preliminary analysis that evaluates the environmental impacts of the proposed action and alternatives to the proposed action. Alternatives considered include: new nuclear generation, natural gas-fired combined-cycle generation, supercritical coal-fired generation, combination alternative, purchased power, and not renewing the license (the no-action alternative).

The U.S. Nuclear Regulatory Commission's (NRC's) preliminary recommendation is that the adverse environmental impacts of license renewal for STP are not great enough to deny the option of license renewal for energy planning decisionmakers. This recommendation is based on the following:

- the analysis and findings in NUREG-1437, Volumes 1 and 2, *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*;
- the Environmental Report submitted by STPNOC;
- consultation with Federal, state, local, and tribal government agencies;
- the NRC's environmental review; and
- consideration of public comments received during the scoping process.

TABLE OF CONTENTS

ABSTRACT.....	iii
TABLE OF CONTENTS.....	v
FIGURES.....	x
TABLES.....	xi
EXECUTIVE SUMMARY.....	xv
ABBREVIATIONS AND ACRONYMS.....	xxi
1.0 PURPOSE AND NEED FOR ACTION.....	1-1
1.1 Proposed Federal Action.....	1-1
1.2 Purpose and Need for the Proposed Federal Action.....	1-1
1.3 Major Environmental Review Milestones.....	1-1
1.4 Generic Environmental Impact Statement.....	1-3
1.5 Supplemental Environmental Impact Statement.....	1-5
1.6 Cooperating Agencies.....	1-5
1.7 Consultations.....	1-5
1.8 Correspondence.....	1-6
1.9 Status of Compliance.....	1-6
1.10 References.....	1-6
2.0 AFFECTED ENVIRONMENT.....	2-1
2.1 Facility Description.....	2-1
2.1.1 Reactor and Containment Systems.....	2-1
2.1.2 Radioactive Waste Management.....	2-1
2.1.3 Nonradiological Waste Management.....	2-4
2.1.4 Plant Operation and Maintenance.....	2-6
2.1.5 Power Transmission System.....	2-6
2.1.6 Cooling and Auxiliary Water Systems.....	2-7
2.1.7 Facility Water Use and Quality.....	2-9
2.2 Surrounding Environment.....	2-12
2.2.1 Land Use.....	2-13
2.2.2 Air Quality and Meteorology.....	2-13
2.2.3 Geologic Environment.....	2-15
2.2.4 Surface Water Resources.....	2-17
2.2.5 Groundwater Resources.....	2-19
2.2.6 Aquatic Resources.....	2-23
2.2.7 Terrestrial Resources.....	2-38
2.2.8 Protected Species and Habitats.....	2-47
2.2.9 Socioeconomics.....	2-58
2.2.10 Historic and Archaeological Resources.....	2-70

Table of Contents

2.3	Related Federal and State Activities	2-72
2.4	References	2-73
3.0	ENVIRONMENTAL IMPACTS OF REFURBISHMENT	3-1
3.1	References	3-3
4.0	ENVIRONMENTAL IMPACTS OF OPERATION.....	4-1
4.1	Land Use	4-1
4.2	Air Quality	4-1
4.3	Surface Water Resources	4-2
4.3.1	Generic Surface Water Issues.....	4-2
4.3.2	Surface Water Use Conflicts—Plants Using Makeup Water from a Small River with Low Flow	4-2
4.4	Groundwater Resources	4-5
4.4.1	Generic Groundwater Issues.....	4-5
4.4.2	Groundwater Use Conflicts.....	4-6
4.4.3	Groundwater Quality	4-9
4.5	Aquatic Resources.....	4-11
4.5.1	Generic Aquatic Ecology Issues.....	4-11
4.5.2	Entrainment and Impingement.....	4-12
4.5.3	Thermal Shock	4-22
4.5.4	Mitigation.....	4-25
4.6	Terrestrial Resources.....	4-25
4.7	Protected Species and Habitats	4-26
4.8	Human Health.....	4-33
4.8.1	Generic Human Health Issues.....	4-33
4.8.2	Radiological Impacts of Normal Operations.....	4-33
4.8.3	Microbiological Organisms	4-37
4.8.4	Electromagnetic Fields—Acute Effects.....	4-38
4.8.5	Electromagnetic Fields—Chronic Effects.....	4-39
4.9	Socioeconomics.....	4-40
4.9.1	Generic Socioeconomic Issues	4-40
4.9.2	Housing.....	4-40
4.9.3	Public Services—Public Utilities	4-41
4.9.4	Public Services—Transportation	4-41
4.9.5	Offsite Land Use	4-42
4.9.6	Historic and Archaeological Resources	4-43
4.9.7	Environmental Justice	4-45
4.10	Evaluation of New and Potentially Significant Information	4-51
4.11	Cumulative Impacts	4-52
4.11.1	Land Use.....	4-53
4.11.2	Air Quality	4-53
4.11.3	Water Resources.....	4-55

4.11.4 Aquatic Resources	4-59
4.11.5 Terrestrial Resources	4-62
4.11.6 Human Health	4-64
4.11.7 Socioeconomics	4-66
4.11.8 Historic and Archaeological Resources	4-67
4.11.9 Summary of Cumulative Impacts.....	4-68
4.12 References.....	4-69
5.0 ENVIRONMENTAL IMPACTS OF POSTULATED ACCIDENTS.....	5-1
5.1 Design Basis Accidents.....	5-1
5.2 Severe Accidents	5-2
5.3 Severe Accident Mitigation Alternatives	5-3
5.3.1 Overview of Severe Accident Mitigation Alternative Process.....	5-3
5.3.2 Estimate of Risk	5-3
5.3.3 Potential Plant Improvements.....	5-8
5.3.4 Evaluation of Risk Reduction and Costs of Improvements.....	5-9
5.3.5 Cost Benefit Comparison.....	5-9
5.3.6 Conclusions.....	5-11
5.4 References	5-12
6.0 ENVIRONMENTAL IMPACTS OF THE URANIUM FUEL CYCLE, WASTE MANAGEMENT, AND GREENHOUSE GAS EMISSIONS	6-1
6.1 The Uranium Fuel Cycle	6-1
6.2 Greenhouse Gas Emissions	6-3
6.2.1 Existing Studies.....	6-3
6.3 References	6-9
7.0 ENVIRONMENTAL IMPACTS OF DECOMMISSIONING	7-1
7.1 Decommissioning.....	7-1
7.2 References	7-2
8.0 ENVIRONMENTAL IMPACTS OF ALTERNATIVES	8-1
8.1 New Nuclear Generation.....	8-4
8.1.1 Air Quality	8-5
8.1.2 Surface Water Resources	8-6
8.1.3 Groundwater Resources.....	8-7
8.1.4 Aquatic Ecology	8-8
8.1.5 Terrestrial Ecology	8-9
8.1.6 Human Health	8-9
8.1.7 Land Use.....	8-10
8.1.8 Socioeconomics	8-10
8.1.9 Transportation	8-11
8.1.10 Aesthetics	8-11
8.1.11 Historic and Archaeological Resources	8-12

Table of Contents

8.1.12	Environmental Justice	8-13
8.1.13	Waste Management	8-14
8.1.14	Summary of Impacts of New Nuclear Generation	8-14
8.2	Natural Gas Fired Combined Cycle Generation	8-14
8.2.1	Air Quality	8-16
8.2.2	Surface Water Resources	8-18
8.2.3	Groundwater Resources.....	8-19
8.2.4	Aquatic Ecology	8-19
8.2.5	Terrestrial Ecology	8-20
8.2.6	Human Health	8-21
8.2.7	Land Use.....	8-21
8.2.8	Socioeconomics	8-22
8.2.9	Transportation	8-22
8.2.10	Aesthetics	8-23
8.2.11	Historic and Archaeological Resources	8-23
8.2.12	Environmental Justice	8-24
8.2.13	Waste Management	8-25
8.2.14	Summary of Impacts for the NGCC Generation Alternative	8-25
8.3	Supercritical Coal Fired Generation	8-26
8.3.1	Air Quality	8-28
8.3.2	Surface Water Resources	8-31
8.3.3	Groundwater Resources.....	8-31
8.3.4	Aquatic Ecology	8-32
8.3.5	Terrestrial Ecology	8-33
8.3.6	Human Health	8-33
8.3.7	Land Use.....	8-34
8.3.8	Socioeconomics	8-35
8.3.9	Transportation	8-35
8.3.10	Aesthetics	8-36
8.3.11	Historic and Archaeological Resources	8-36
8.3.12	Environmental Justice	8-37
8.3.13	Waste Management	8-38
8.3.14	Summary of Impacts for the Supercritical Coal-Fired Generation Alternative.....	8-38
8.4	Combination Alternative	8-39
8.4.1	Air Quality	8-40
8.4.2	Surface Water Resources	8-43
8.4.3	Groundwater Resources.....	8-44
8.4.4	Aquatic Ecology	8-44
8.4.5	Terrestrial Ecology	8-45
8.4.6	Human Health	8-46
8.4.7	Land Use.....	8-46

Table of Contents

8.4.8	Socioeconomics	8-47
8.4.9	Transportation	8-48
8.4.10	Aesthetics	8-49
8.4.11	Historic and Archaeological Resources	8-49
8.4.12	Environmental Justice	8-50
8.4.13	Waste Management	8-51
8.4.14	Summary of Impacts of the Combination Alternative	8-51
8.5	Purchased Power.....	8-52
8.5.1	Air Quality	8-53
8.5.2	Surface Water and Groundwater Resources	8-53
8.5.3	Terrestrial and Aquatic Ecology.....	8-53
8.5.4	Human Health	8-54
8.5.5	Land Use.....	8-54
8.5.6	Socioeconomics (including transportation and aesthetics).....	8-54
8.5.7	Historic and Archaeological Resources	8-54
8.5.8	Environmental Justice	8-54
8.5.9	Waste Management	8-55
8.5.10	Summary of Impacts of the Purchased Power Alternative	8-55
8.6	Alternatives Considered but Dismissed.....	8-55
8.6.1	Offsite Nuclear , Gas , and Coal Fired Capacity	8-56
8.6.2	Energy Conservation and Energy Efficiency.....	8-56
8.6.3	Wind Power.....	8-57
8.6.4	Solar Power.....	8-58
8.6.5	Hydroelectric Power	8-59
8.6.6	Wave and Ocean Energy	8-59
8.6.7	Geothermal Power	8-59
8.6.8	Municipal Solid Waste	8-60
8.6.9	Biomass	8-61
8.6.10	Biofuels	8-61
8.6.11	Oil Fired Power	8-62
8.6.12	Fuel Cells	8-62
8.6.13	Delayed Retirement.....	8-62
8.7	No Action Alternative	8-63
8.7.1	Air Quality	8-63
8.7.2	Surface Water Resources	8-63
8.7.3	Groundwater Resources.....	8-63
8.7.4	Aquatic Ecology	8-64
8.7.5	Terrestrial Ecology	8-64
8.7.6	Human Health	8-64
8.7.7	Land Use.....	8-64
8.7.8	Socioeconomics	8-64

Table of Contents

8.7.9	Transportation	8-64
8.7.10	Aesthetics and Noise	8-65
8.7.11	Historic and Archaeological Resources	8-65
8.7.12	Environmental Justice	8-65
8.7.13	Waste Management	8-65
8.7.14	Summary of Impacts of No Action Alternative.....	8-65
8.8	Alternatives Summary	8-66
8.9	References	8-68
9.0	CONCLUSION	9-1
9.1	Environmental Impacts of License Renewal.....	9-1
9.2	Comparison of Alternatives	9-1
9.3	Resource Commitments.....	9-2
9.3.1	Unavoidable Adverse Environmental Impacts	9-2
9.3.2	Short Term Versus Long Term Productivity.....	9-2
9.3.3	Irreversible and Irretrievable Commitments of Resources	9-3
9.4	Recommendations	9-3
10.0	LIST OF PREPARERS.....	10-1
11.0	LIST OF AGENCIES, ORGANIZATIONS, AND PERSONS TO WHOM COPIES OF THIS SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT ARE SENT.....	11-1
12.0	INDEX.....	12-1
	APPENDIX A. COMMENTS RECEIVED ON THE STP ENVIRONMENTAL REVIEW	A-1
	APPENDIX B. NATIONAL ENVIRONMENTAL POLICY ACT ISSUES FOR LICENSE RENEWAL OF NUCLEAR POWER PLANTS.....	B-1
	APPENDIX C. APPLICABLE REGULATIONS, LAWS, AND AGREEMENTS	C-1
	APPENDIX D. CONSULTATION CORRESPONDENCE	D-1
	APPENDIX E. CHRONOLOGY OF ENVIRONMENTAL REVIEW CORRESPONDENCE.....	E-1
	APPENDIX F. NRC STAFF EVALUATION OF SEVERE ACCIDENT MITIGATION ALTERNATIVES	F-1

Figures

Figure 1–1.	Environmental Review Process	1-2
Figure 1–2.	Environmental Issues Evaluated For License Renewal	1-4
Figure 2–1.	Surface Water Bodies and Groundwater Wells in Vicinity of STP (STPNOC 2011b).....	2-11
Figure 2–2.	The STP Site and 1975 to 1976 Aquatic Ecology Sampling Location (NRC 2011b).....	2-27
Figure 2–3.	The STP Site and 2007 to 2008 Aquatic Ecology Sampling Locations from Segment C through the Upstream Portion of Segment B (NRC 2011b).....	2-28
Figure 2–4.	The STP Site and 2007 to 2008 Aquatic Ecology Sampling Locations from the Downstream Portion of Segment B through Segment A (NRC 2011b)	2-29

Figure 2–5. Most Commonly Recorded Christmas Bird Count Species, 2007 through 2011 (Audubon 2011)..... 2-41

Figure 2–6. STP 50-mi (80-km) Radius Map (STPNOC 2010b) 2-45

Figure 2–7. STP 6-mi (10-km) Radius Map (STPNOC 2010b) 2-46

Figure 4–1. Species Richness of Aquatic Species Captured in Trawl Surveys from 1974, 1983, and 2007 through 2008..... 4-21

Figure 4–2. 2010 Census Minority Block Groups Within a 50 mi Radius of STP 4-47

Figure 4–3. Census 2010 Low Income Block Groups Within a 50 mi Radius of STP..... 4-49

Tables

Table 2–1. Macroinvertebrates Collected in the Colorado River by Gear Type, 2007 to 2008..... 2-31

Table 2–2. Fish Collected in the Colorado River by Gear Type, 2007 to 2008 2-32

Table 2–3. Species Richness (number of species) in Three River Segments by Gear Type..... 2-33

Table 2–4. Fish and Invertebrates Collected in the MCR by Gill Nets, Seines, and Trawls, 2007 to 2008..... 2-35

Table 2–5. Fish and Invertebrates Collected in the MCR by Plankton Tows, 2007 to 2008..... 2-36

Table 2–6. Birds Observed in High Numbers for One Christmas Count Year, 2007 through 2011 2-40

Table 2–7. Birds Documented on the STP Site, 2007 through 2008..... 2-42

Table 2–8. Species Listed Under the ESA 2-47

Table 2–9. NMFS Species of Concern 2-51

Table 2–10. Ecoregion 5 Species with Designated EFH 2-54

Table 2–11. State listed Species 2-57

Table 2–12. STP, Employee Residence by County..... 2-59

Table 2–13. Housing in Brazoria and Matagorda Counties in 2010 2-59

Table 2–14. Brazoria and Matagorda County City Public Water Supply Systems (in mgd)..... 2-60

Table 2–15. Major Commuting Routes in the Vicinity of STP, 2010 AADT 2-61

Table 2–16. Population and Percent Growth in Brazoria and Matagorda Counties from 1970 to 2010 and Projected for 2020 to 2050..... 2-63

Table 2–17. Demographic Profile of the Population in the STP Two County Socioeconomic ROI in 2010 2-63

Table 2–18. Seasonal Housing in Counties Located within 50 mi of STP..... 2-64

Table 2–19. Migrant Farm Workers and Temporary Farm Labor in Counties Located within 50 mi of STP 2-65

Table 2–20. Major Industries in Matagorda County 2-66

Table 2–21. Major Industries in ROI..... 2-66

Table 2–22. Estimated Income Information for STP ROI..... 2-67

Table 2–23. Comparison of STP Owner Payments with Taxing District Property Tax 2-68

Table of Contents

Table 2–24. STP, Units 1 and 2, Owner Payments to Other Taxing Districts in Matagorda.....	2-70
Table 3–1. Category 1 Issues Related to Refurbishment	3-1
Table 3–2. Category 2 Issues Related to Refurbishment	3-2
Table 4–1. Land Use Issues.....	4-1
Table 4–2. Air Quality Issues	4-2
Table 4–3. Surface Water Resources Issues	4-2
Table 4–4. Surface Water Withdrawals and Usage for Calendar Years 2003–2010 for STP, Units 1 and 2	4-4
Table 4–5. Groundwater Resources Issues	4-5
Table 4–6. Projected Drawdown and Change in Drawdown in Feet for the Deep Chicot Aquifer for Selected Distances	4-7
Table 4–7. Aquatic Resource Issues.....	4-11
Table 4–8. Number (per 100 m3) of Macrozooplankton and Ichthyoplankton Collected in Plankton Samples in Front of the RMPF from 1984 and 1985	4-14
Table 4–9. Invertebrates and Fish Impinged at the RMPF during 1983–1984 Studies	4-15
Table 4–10. Aquatic Species Collected during Entrainment Sampling in the MCR’s CWIS for Units 1 and 2, 2007–2008	4-16
Table 4–11. Aquatic Species Collected during Impingement Sampling in the MCR’s CWIS for Units 1 and 2, 2007–2008	4-17
Table 4–12. Terrestrial Resources Issues Identified in the GEIS.....	4-26
Table 4–13. Protected Species Issues Identified in the GEIS.....	4-26
Table 4–14. Effect Determinations for Federally Listed Species.....	4-27
Table 4–15. Human Health Issues. Table B 1 of Appendix B to Subpart A of 10 CFR Part 51 contains more information on these issues.	4-33
Table 4–16. Socioeconomics during the Renewal Term.....	4-40
Table 4–17. Summary of Cumulative Impacts on Resource Areas.....	4-68
Table 5–1. Issues Related to Postulated Accidents Two issues related to postulated accidents are evaluated under the National Environmental Protection Act (NEPA) in the license renewal review—DBAs and severe accidents.....	5-1
Table 5–2. STP Core Damage Frequency for Internal Events.....	5-5
Table 5–3. STP Core Damage Frequency for Fire Events	5-6
Table 5–4. STP Core Damage Frequency for Seismic Events	5-6
Table 5–5. STP Core Damage Frequency for Other External Events.....	5-7
Table 5–6. Breakdown of Population Dose by Containment Release Mode	5-8
Table 5–7. Phase II SAMA List (Cost-Benefit) for STP	5-10
Table 6–1. Issues Related to the Uranium Fuel Cycle and Waste Management	6-1
Table 6–2. Nuclear Greenhouse Gas Emissions Compared to Coal	6-5
Table 6–3. Nuclear Greenhouse Gas Emissions Compared to Natural Gas.....	6-6
Table 6–4. Nuclear Greenhouse Gas Emissions Compared to Renewable Energy Sources.....	6-7
Table 7–1. Table 7–1. Issues Related to Decommissioning	7-1

Table 8–1. Expected Annual Emissions from the Largest Stationary Sources of Emissions..... 8-6

Table 8–2. Summary of Environmental Impacts of the New Nuclear Alternative Compared to Continued Operation of STP, Units 1 and 2 8-14

Table 8–3. Summary of Environmental Impacts of the NGCC Alternative Compared to Continued Operation of STP 8-25

Table 8–4. Summary of Environmental Impacts of the Supercritical Coal Fired Alternative Compared to Continued Operation of STP, Units 1 and 2..... 8-38

Table 8–5. Summary of Environmental Impacts of the Combination Alternative Compared to Continued Operation of STP, Units 1 and 2 8-52

Table 8–6. Summary of Environmental Impacts of the Purchased Power Alternative Compared to Continued Operation of STP, Units 1 and 2 8-55

Table 8–7. Summary of Environmental Impacts of the No Action Alternative Compared to Continued Operation of STP, Units 1 and 2..... 8-65

Table 8–8. Summary of Environmental Impacts of Proposed Action and Alternatives..... 8-67

Table 10–1. List of Preparers 10-1

Table A–1. Individuals Providing Comments During the Scoping Comment Period..... A-1

Table B–1. Summary of Issues and Findings B-1

Table C–1. Licenses and Permits..... C-1

Table C–2. Federal, State, and Local Laws and Other Requirements C-2

Table D–1. Consultation Correspondence..... D-1

Table E–1. Environmental Review Correspondence E-1

Table F–1. STP Core Damage Frequency for Internal Events..... F-4

Table F–2. STP Core Damage Frequency for Fire Events F-5

Table F–3. STP Core Damage Frequency for Seismic Events F-5

Table F–4. STP Core Damage Frequency for Other External Events..... F-6

Table F–5. Breakdown of Population Dose by Containment Release Mode..... F-7

Table F–6. STP PRA Historical Summary F-9

Table F–7. SAMA Cost-Benefit Screening Analysis for STP F-26

Table F–8. SAMA Cost-Benefit Screening Analysis for STP Using Conservative Source Terms..... F-31

Table F–9. SAMA Cost-Benefit Screening Analysis for STP Using Updated Fire and Seismic Risk Analysis and Conservative Source Terms..... F-32

EXECUTIVE SUMMARY

BACKGROUND

By letter dated October 25, 2010, STP Nuclear Operating Company (STPNOC) submitted an application to the U.S. Nuclear Regulatory Commission (NRC) to issue renewed operating licenses for South Texas Project (STP), Units 1 and 2, for an additional 20-year period.

Pursuant to Title 10, Part 51.20(b)(2) of the *Code of Federal Regulations* (10 CFR 51.20(b)(2)), the renewal of a power reactor operating license requires preparation of an environmental impact statement (EIS) or a supplement to an existing EIS. In addition, 10 CFR 51.95(c) states that the NRC shall prepare an EIS, which is a supplement to the Commission's NUREG-1437, *Generic Environmental Impact Statement (GEIS) for License Renewal of Nuclear Plants* (GEIS).

Upon acceptance of STPNOC's application, the NRC staff began the environmental review process described in 10 CFR Part 51 by publishing a notice of intent to prepare a supplemental EIS (SEIS) and conduct scoping. In preparation of this SEIS for STP, the NRC staff performed the following:

- conducted public scoping meetings on March 2, 2011, in Bay City, Texas;
- conducted a site audit at the plant in July 2011;
- reviewed STPNOC's Environmental Report (ER) and compared it to the GEIS;
- consulted with other agencies;
- conducted a review of the issues following the guidance set forth in NUREG-1555, *Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*; and
- considered public comments received during the scoping process.

PROPOSED ACTION

STPNOC initiated the proposed Federal action—issuing renewed power reactor operating licenses—by submitting an application for license renewal of STP, for which the existing licenses (NPF-76 and NPF-80) for STP, Units 1 and 2, will expire on August 20, 2027, and December 15, 2028, respectively. The NRC's Federal action is the decision whether or not to renew the licenses for an additional 20 years.

PURPOSE AND NEED FOR ACTION

The purpose and need for the proposed action (issuance of a renewed license) is to provide an option that allows for power generation capability beyond the term of the current nuclear power plant operating license to meet future system generating needs. Such needs may be determined by other energy-planning decisionmakers, such as State, utility, and—where authorized—Federal (other than NRC). This definition of purpose and need reflects the NRC's recognition that, unless there are findings in the safety review required by the Atomic Energy Act or findings in the National Environmental Policy Act (NEPA) environmental analysis that would lead the NRC to reject a license renewal application, the NRC does not have a role in the

Executive Summary

energy-planning decisions of whether a particular nuclear power plant should continue to operate.

If the renewed license is issued, the appropriate energy-planning decisionmakers, along with STPNOC, will ultimately decide if the reactor units will continue to operate based on factors such as the need for power. If the operating licenses are not renewed, then the facility must be shut down on or before the expiration dates of the current operating licenses—August 20, 2027, and December 15, 2028.

ENVIRONMENTAL IMPACTS OF LICENSE RENEWAL

The SEIS evaluates the potential environmental impacts of the proposed action. The environmental impacts from the proposed action are designated as SMALL, MODERATE, or LARGE. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- The environmental impacts associated with the issue is determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts, except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal.
- Mitigation of adverse impacts associated with the issue is considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

SMALL: Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE: Environmental effects are sufficient to alter noticeably, but not to destabilize, important attributes of the resource.

LARGE: Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

For Category 1 issues, no additional site-specific analysis is required in this SEIS unless new and significant information is identified. Chapter 4 of this report presents the process for identifying new and significant information. Site-specific issues (Category 2) are those that do not meet one or more of the criterion for Category 1 issues; therefore, an additional site-specific review for these non-generic issues is required, and the results are documented in the SEIS. The NRC staff has reviewed STPNOC's established process for identifying and evaluating the significance of any new and significant information on the environmental impacts of license renewal of STP. Neither STPNOC nor NRC identified information that is both new and significant related to Category 1 issues that would call into question the conclusions in the GEIS. This conclusion is supported by NRC's review of the applicant's ER, other documentation relevant to the applicant's activities, the public scoping process and substantive comments raised, and the findings from the environmental site audit conducted by the NRC staff. Further, the NRC staff did not identify any new issues applicable to STP that have a significant environmental impact. The NRC staff, therefore, relies upon the conclusions of the GEIS for all Category 1 issues applicable to STP.

Table ES-1 summarizes the Category 2 issues applicable to STP, if any, as well as the NRC staff's findings related to those issues. If the NRC staff determined that there were no Category 2 issues applicable for a particular resource area, the findings of the GEIS, as documented in Appendix B to Subpart A of 10 CFR Part 51, stand.

Table ES–1. NRC Conclusions Relating to Site-Specific Impacts of License Renewal

Resource Area	Relevant Category 2 Issues	Adverse Impacts
Land Use	None	SMALL
Air Quality	None	SMALL
Surface Water Resources	Surface water use conflicts	SMALL
Groundwater Resources	Groundwater use conflicts	SMALL
Aquatic Resources	Entrainment & impingement of fish & shellfish	SMALL
	Heat shock	SMALL
Terrestrial Resources	None	SMALL
Protected Species	Threatened or endangered species	SMALL
Human Health Issues	Electromagnetic fields—acute effects (electric shock vs. chronic effects)	SMALL to MODERATE
	Microbiological organisms	SMALL
Socioeconomics	Housing Impacts	SMALL
	Public services (public utilities)	SMALL
	Offsite land use	SMALL
	Public services (public transportation)	SMALL
	Historic & archaeological resources	SMALL

With respect to environmental justice, the NRC staff has determined that there would be no disproportionately high and adverse impacts to these populations from the continued operation of STP during the license renewal period. Additionally, the NRC staff has determined that no disproportionately high and adverse human health impacts would be expected in special pathway receptor populations in the region as a result of subsistence consumption of water, local food, fish, and wildlife.

SEVERE ACCIDENT MITIGATION ALTERNATIVES

Since STPNOC had not previously considered alternatives to reduce the likelihood or potential consequences of a variety of highly uncommon, but potentially serious, accidents at STP, 10 CFR 51.53(c)(3)(ii)(L) requires that STPNOC evaluate severe accident mitigation alternatives (SAMAs) in the course of the license renewal review. SAMAs are potential ways to reduce the risk or potential impacts of uncommon, but potentially severe accidents, and they may include changes to plant components, systems, procedures, and training.

The NRC staff reviewed the ER's evaluation of potential SAMAs. Based on the staff's review, the NRC staff concluded that none of the potentially cost beneficial SAMAs relate to adequately managing the effects of aging during the period of extended operation. Therefore, they need not be implemented as part of the license renewal, pursuant to 10 CFR Part 54.

ALTERNATIVES

The NRC staff considered the environmental impacts associated with alternatives to license renewal. These alternatives include other methods of power generation and not renewing the

Executive Summary

STP operating licenses (the no-action alternative). Replacement power options considered were as follows:

- new nuclear generation,
- natural gas-fired combined-cycle generation,
- supercritical coal-fired generation,
- combination alternative, and
- purchased power.

The NRC staff initially considered many additional alternatives for analysis as alternatives to license renewal of STP; these were later dismissed due to technical, resource availability, or commercial limitations that currently exist and that the NRC staff believes are likely to continue to exist when the existing STP licenses expire. The no-action alternative by the NRC staff, and the effects it would have, were also considered. Where possible, the NRC staff evaluated potential environmental impacts for these alternatives located both at the STP site and at some other unspecified alternate location. Alternatives considered, but dismissed, were as follows:

- offsite nuclear-, gas-, and coal-fired capacity,
- energy conservation and energy efficiency,
- wind power,
- solar power,
- hydroelectric power,
- wave and ocean energy,
- geothermal power,
- municipal solid waste,
- biomass,
- biofuels,
- oil-fired power,
- fuel cells, and
- delayed retirement.

The NRC staff evaluated each alternative using the same impact areas that were used in evaluating impacts from license renewal.

RECOMMENDATION

The NRC's preliminary recommendation is that the adverse environmental impacts of license renewal for STP are not great enough to deny the option of license renewal for energy-planning decisionmakers. This recommendation is based on the following:

- analysis and findings in the GEIS,
- ER submitted by STPNOC,
- consultation with Federal, state, local, and tribal government agencies,

- the NRC staff's own independent review, and
- consideration of public comments received during the scoping process.

ABBREVIATIONS AND ACRONYMS

AADT	average annual daily traffic
ABWR	advanced boiling-water reactor
ac	acre
ac-ft	acre-foot
ACHP	Advisory Council on Historic Preservation
ADAMS	Agencywide Documents Access and Management System
AEA	Atomic Energy Act of 1954
AEO	Annual Energy Outlook
AFW	auxiliary feedwater
ALARA	as low as is reasonably achievable
AMP	aging management program
AOC	averted offsite property damage costs
AOSC	averted onsite costs
APE	area of potential effect
AQCR	air quality control region
ASME	American Society of Mechanical Engineers
ATWS	anticipated transient without scram
BACT	best available control technology
BEG	Bureau of Economic Geology
BGS	below ground surface
BMP	best management practice
Bq/l	becquerels per liter
BTU	British thermal unit
C	Celsius
CAA	Clean Air Act
CAES	compressed air energy storage
CAPS	Missouri Census Data Center Circular Area Profiling System
CCW	component cooling water
CDF	core damage frequency
CDM	control drive mechanism

Abbreviations and Acronyms

C_{eq}	carbon equivalent
CET	containment event tree
CFR	<i>U.S. Code of Federal Regulations</i>
cfs	cubic feet per second
CLB	current licensing basis
cm	centimeter
CO ₂	carbon dioxide
COE	cost of enhancement
COL	combined license
Corps	U.S. Army Corps of Engineers
CPGCD	Coastal Plains Groundwater Conservation District
CWA	Clean Water Act
CWIS	cooling water intake structure
DBA	design-basis accident
dBA	decibel A-weighting
DG	diesel generator
DMR	discharge monitoring report
DOE	U.S. Department of Energy
DSEIS	draft supplemental environmental impact statement
DSHS	Department of State Health Services
DWS	drinking water standard
ECP	essential cooling pond
ECW	essential cooling water
ECWIS	essential cooling water intake structure
EFH	essential fish habitat
EIA	Energy Information Administration
EIS	environmental impact statement
ELF	extremely low frequency
EMF	electromagnetic field
EO	Executive Order
EOE	Encyclopedia of Earth
EPA	U.S. Environmental Protection Agency
EPCRA	Emergency Planning and Community Right-to-Know Act

Abbreviations and Acronyms

EPRI	Electric Power Research Institute
EPZ	emergency planning zone
ER	Environmental Report
ERCOT	Electric Reliability Council of Texas
ESA	Endangered Species Act
ESRP	environmental standard review plan
F	Fahrenheit
F&O	facts and observations
FES	final environmental statement
FIP	Federal Implementation Plan
FM	Farm-to-Market
FR	<i>Federal Register</i>
FRN	<i>Federal Register</i> Notice
FSAR	final safety analysis report
FSEIS	final supplemental environmental impact statement
ft	foot
ft ³	cubic foot
ft/s	feet per second
FWS	U.S. Fish and Wildlife Service
g	gram
gal	gallon
GCBO	Gulf Coast Bird Observatory
GCC	global climate change
GE	General Electric
GEA	Geothermal Energy Association
GEIS	generic environmental impact statement
GHG	greenhouse gas
GIWW	Gulf Intercoastal Waterway
GL	generic letter
GMFMC	Gulf of Mexico Fishery Management Council
gpd	gallons per day
gpm	gallons per minute
GWMS	gaseous waste management system

Abbreviations and Acronyms

ha	hectare
HAP	hazardous air pollutant
HARC	Houston Advanced Research Center
hr	hour
HVAC	heating, ventilation, and air conditioning
Hz	hertz
IAEA	International Atomic Energy Agency
IEEE	Institute of Electrical and Electronics Engineers, Inc.
IES	Institute of Educational Sciences
IGCC	integrated gasification combined cycle
in.	inch
IPA	integrated plant assessment
IPCC	Intergovernmental Panel on Climate Change
IPE	individual plant examination
IPEEE	individual plant examination of external events
ISD	independent school district
ISEPA	Iowa Stored Energy Plant Agency
ISLOCA	interfacing system loss-of-coolant accident
kg	kilogram
km	kilometer
km ²	square kilometer
kV	kilovolt
kWh	kilowatt hour
L/min	liters per minute
lb	pound
LCRA	Lower Colorado River Authority
LCRWPG	Lower Colorado River Water Planning Group
LERF	large early release frequency
LLNL	Lawrence Livermore National Laboratory
LLW	low-level waste
LOCA	loss-of-coolant accident

Abbreviations and Acronyms

LOOP	loss of offsite power
LRA	license renewal application
LWPS	liquid waste processing system
m	meter
m ³	cubic meter
m ³ /s	cubic meters per second
mA	milliampere
MAAP	Modular Accident Analysis Program
MACCS2	MELCOR Accident Consequence Code System 2
MACR	maximum averted cost-risk
MBTA	Migratory Bird Treaty Act
MCR	main cooling reservoir
MDC	main drainage channel
mg/l	milligrams per liter
mgd	millions of gallons per day
mGy	milligray
mi	mile
min	minute
MIT	Massachusetts Institute of Technology
mm	millimeter
MMI	Modified Mercalli Intensity
MMS	U.S. Minerals Management Service
mo	month
mrad	millirad
mrem	millirem
MSA	Magnuson-Stevens Fishery Conservation and Management Act
MSL	mean sea level
mSv	millisievert
MT	metric ton
MW	megawatt
MWd	megawatt day
MWe	megawatt electric
MWt	megawatt thermal

Abbreviations and Acronyms

NAAQS	National Ambient Air Quality Standards
NASS	National Agriculture Statistics Service
NCES	National Center for Education Statistics
NEA	Nuclear Energy Agency
NEI	Nuclear Energy Institute
NEPA	National Environmental Policy Act
NESC	National Electrical Safety Code
NETL	National Energy Technology Laboratory
NGCC	natural gas-fired combined-cycle
NHPA	National Historic Preservation Act
NIEHS	National Institute of Environmental Health Sciences
NMFS	National Marine Fisheries Service
NPCC	Northwest Power and Conservation Council
NPDES	National Pollutant Discharge Elimination System
NRC	U.S. Nuclear Regulatory Commission
NRCS	Natural Resources Conservation Service
NREL	National Renewable Energy Laboratory
NRHP	National Register of Historic Places
NRR	Office of Nuclear Reactor Regulation
NWS	National Weather Service
OECD	Organization for Economic Co-operation and Development
OMB	Office of Management and Budget
OPSB	Ohio Power and Siting Board
PACR	potential averted cost-risk
pCi/L	picocuries per liter
PDP	positive displacement pump
PGA	peak ground acceleration
PM ₁₀	particulate matter, ≤10 μm
PM _{2.5}	particulate matter, ≤2.5 μm
PNNL	Pacific Northwest National Laboratory
POST	Parliamentary Office of Science and Technology
PRA	probabilistic risk assessment
PSD	prevention of significant deterioration

Abbreviations and Acronyms

PWR	pressurized-water reactor
RAI	request for additional information
RCB	reactor containment building
RCP	reactor coolant pump
RCRA	Resources Conservation and Recovery Act
RCS	reactor coolant system
rem	roentgen equivalent man
REMP	Radiological Environmental Monitoring Program
RG	regulatory guide
RMPF	reservoir makeup pumping facility
RMTS	risk managed technical specification
ROI	region of influence
ROW	right-of-way
RPC	replacement power costs
RRW	risk reduction worth
RTC	Report to Congress
SAMA	severe accident mitigation alternative
SAR	safety analysis report
SAWS	San Antonio Water System
SBDG	standby diesel generator
SCR	selective catalytic reduction
SEIS	supplemental environmental impact statement
SER	safety evaluation report
SG	steam generator
SGTR	steam generator tube rupture
SHPO	State Historic Preservation Office
SIP	State Implementation Plan
SNL	Sandia National Laboratory
SOARCA	State-of-the-Art Reactor Consequence Analysis
SPDES	State Pollutant Discharge Elimination System
SSC	system, structure, and component
SSE	safe shutdown earthquake
STP	South Texas Project

Abbreviations and Acronyms

STPNOC	South Texas Project Nuclear Operating Company
Sv	sievert
SWPS	solid waste processing system
TAC	Texas Administrative Code
TCEQ	Texas Commission on Environmental Quality
TCPA	Texas Comptroller of Public Accounts
TDS	total dissolved solids
THC	Texas Historical Commission
TMMSN	Texas Marine Mammal Stranding Network
TPDES	Texas Pollutant Discharge Elimination System
TPWD	Texas Parks and Wildlife Department
tpy	tons per year
TS	technical specification
TSC	Technical Support Center
TSECO	Texas State Energy Conservation Office
TSHA	Texas State Historical Association
TSP	total suspended particles
TSWGW	Texas Saltwater and Fishing Guides Web
TWDB	Texas Water Development Board
USCB	U.S. Census Bureau
USGS	U.S. Geological Survey
VOC	volatile organic compound
WEG	Wild Earth Guardians
WMA	Wildlife Management Area
WOE	weight-of-evidence
WSEC	White Stallion Energy Center
yr	year

1

1.0 PURPOSE AND NEED FOR ACTION

2 Under the U.S. Nuclear Regulatory Commission's (NRC's) environmental protection regulations
3 in Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR 51)—which implement the
4 National Environmental Policy Act (NEPA)—issuance of a new nuclear power plant operating
5 license requires the preparation of an environmental impact statement (EIS).

6 The Atomic Energy Act of 1954 (AEA) specifies that licenses for commercial power reactors can
7 be granted for up to 40 years. NRC regulations (10 CFR 54.31) allow for an option to renew a
8 license for up to an additional 20 years. The initial 40-year licensing period was based on
9 economic and antitrust considerations rather than on technical limitations of the nuclear facility.

10 The decision to seek a license renewal rests entirely with nuclear power facility owners and,
11 typically, is based on the facility's economic viability and the investment necessary to continue
12 to meet NRC safety and environmental requirements. The NRC makes the decision to grant or
13 deny license renewal based on whether the applicant has demonstrated that the environmental
14 and safety requirements in the agency's regulations can be met during the period of extended
15 operation.

16 **1.1 Proposed Federal Action**

17 STP Nuclear Operating Company (STPNOC) initiated the proposed Federal action by
18 submitting an application for license renewal of South Texas Project (STP), Units 1 and 2, for
19 which the existing licenses (NPF-76 and NPF-80) expire on August 20, 2027, and
20 December 15, 2028, respectively. The NRC's Federal proposed action is the decision whether
21 to renew the licenses for an additional 20 years.

22 **1.2 Purpose and Need for the Proposed Federal Action**

23 The purpose and need for the proposed action (issuance of a renewed license) is to provide an
24 option that allows for power generation capability beyond the term of a current nuclear power
25 plant operating license to meet future system generating needs, as such needs may be
26 determined by other energy-planning decisionmakers. This definition of purpose and need
27 reflects the NRC's recognition that, unless there are findings in the safety review required by the
28 AEA or findings in the NEPA environmental analysis that would lead the NRC to reject a license
29 renewal application (LRA), the NRC does not have a role in the energy-planning decisions of
30 State regulators and utility officials as to whether a particular nuclear power plant should
31 continue to operate.

32 If the renewed license is issued, State regulatory agencies and STPNOC will ultimately decide
33 whether the plant will continue to operate based on factors such as the need for power or other
34 matters within the State's jurisdiction or the purview of the owners. If the operating license is
35 not renewed, then the facility must be shut down on or before the expiration dates of the current
36 operating licenses—August 20, 2027, and December 15, 2028, respectively.

37 **1.3 Major Environmental Review Milestones**

38 STPNOC submitted an Environmental Report (ER) (STPNOC 2010b) as part of its LRA
39 (STPNOC 2010a) in October 2010. After reviewing the LRA and ER for sufficiency, the NRC
40 staff published a *Federal Register* Notice of Acceptability and Opportunity for Hearing
41 (76 FRN 2426) on January 13, 2011. Then, on January 31, 2011, the NRC published another

Purpose and Need for Action


1 notice in the *Federal Register* (76 FR 5410) on the intent to conduct scoping, thereby beginning
2 the 60-day scoping period.

3 The NRC staff held two public scoping meetings on March 2, 2011, in Bay City, Texas. The
4 comments received during the scoping process are presented in their entirety in “Environmental
5 Impact Statement Scoping Process, Summary Report, South Texas Project, Units 1 and 2, Bay
6 City,” published in 2012 (NRC 2012). The staff presents comments considered to be within the
7 scope of the environmental license renewal review and the NRC responses in Appendix A of
8 this supplemental environmental impact statement (SEIS).

9 In order to independently verify information provided in the ER, the NRC staff conducted a site
10 audit at STP, Units 1 and 2, in July 2011. During the site audit, the staff met with plant
11 personnel, reviewed specific documentation, toured the facility, and met with interested Federal,
12 State, and local agencies. A summary of that site audit and the attendees is contained in the
13 Audit Summary Report, published in August 2011 (NRC 2011).

14 Upon completion of the scoping period and site audit, the NRC staff compiled its findings in this
15 draft SEIS (Figure 1–1). This document is made available for public comment for 45 days.
16 During this time, the staff will host public meetings and collect public comments. Based on the
17 information gathered, it will amend the draft SEIS findings, as necessary, and publish the final
18 SEIS for license renewal.

19 **Figure 1–1. Environmental Review Process**



20 The NRC has established a license renewal review process that can be completed in a
21 reasonable period with clear requirements to assure safe plant operation for up to an additional
22 20 years of plant life. The NRC staff conducts the safety review simultaneously with the
23 environmental review. The staff documents the findings of the safety review in a safety
24 evaluation report (SER). The findings in the SEIS and the SER are both factors in the NRC’s
25 decision to either grant or deny the issuance of a renewed license.

1 **1.4 Generic Environmental Impact Statement**

2 The NRC staff performed a generic assessment of the environmental impacts associated with
 3 license renewal to improve the efficiency of its license renewal review. The *Generic*
 4 *Environmental Impact Statement for License Renewal of Nuclear Power Plants* (GEIS),
 5 NUREG-1437 (NRC 1996, 1999), documented the results of the staff's systematic approach to
 6 evaluate the environmental consequences of renewing the licenses of individual nuclear power
 7 plants and operating them for an additional 20 years. The staff analyzed in detail and resolved
 8 those environmental issues that could be resolved generically in the GEIS.

9 The GEIS establishes 92 separate issues for the NRC staff to independently verify. Of these
 10 issues, the NRC staff determined that 69 are generic to all plants (Category 1) while 21 issues
 11 do not lend themselves to generic consideration (Category 2). Two other issues remain
 12 uncategorized (environmental justice and chronic effects of electromagnetic fields). The staff
 13 evaluated these issues on a site-specific basis (along with the Category 2 issues). Appendix B
 14 provides the list of all 92 issues.

15 For each potential environmental issue, in the GEIS, the NRC staff performs the following:

- 16 • describes the activity that affects the environment,
- 17 • identifies the population or resource that is affected,
- 18 • assesses the nature and magnitude of the impact on the affected population
 19 or resource,
- 20 • characterizes the significance of the effect for both beneficial and adverse
 21 effects,
- 22 • determines whether the results of the analysis apply to all plants, and
- 23 • considers whether additional mitigation measures would be warranted for
 24 impacts that would have the same significance level for all plants.

25 The NRC's standard of significance for impacts was established using the Council on
 26 Environmental Quality (CEQ) terminology for "significant." The NRC established three levels of
 27 significance for potential impacts—SMALL, MODERATE, and LARGE, as defined below.

28 **SMALL:** Environmental effects are not
 29 detectable or are so minor that they will neither
 30 destabilize nor noticeably alter any important
 31 attribute of the resource.

32 **MODERATE:** Environmental effects are
 33 sufficient to alter noticeably, but not to destabilize,
 34 important attributes of the resource.

35 **LARGE:** Environmental effects are clearly noticeable and are sufficient to destabilize important
 36 attributes of the resource.

37 The GEIS includes a determination of whether the analysis of the environmental issue could be
 38 applied to all plants and whether additional mitigation measures would be warranted
 39 (Figure 1–2). Issues are assigned a Category 1 or a Category 2 designation. As set forth in the
 40 GEIS, Category 1 issues are those that meet the following criteria:

Significance indicates the importance of likely environmental impacts and is determined by considering two variables: **context** and **intensity**.

Context is the geographic, biophysical, and social context in which the effects will occur.


Intensity refers to the severity of the impact, in whatever context it occurs.

Purpose and Need for Action

- 1 • The environmental impacts associated with the issue have been determined
- 2 to apply either to all plants or, for some issues, to plants having a specific
- 3 type of cooling system or other specified plant or site characteristics.
- 4 • A single significance level (i.e., SMALL, MODERATE, or LARGE) has been
- 5 assigned to the impacts (except for collective offsite radiological impacts from
- 6 the fuel cycle and from high-level waste and spent fuel disposal).
- 7 • Mitigation of adverse impacts associated with the issue has been considered
- 8 in the analysis, and it has been determined that additional plant-specific
- 9 mitigation measures are likely not to be sufficiently beneficial to warrant
- 10 implementation.

Figure 1–2. Environmental Issues Evaluated For License Renewal

*In the GEIS, 92 issues were evaluated.
A site-specific analysis is required for 23 of those 92 issues*



14 For generic issues (Category 1), no additional site-specific analysis is required in this SEIS
 15 unless new and significant information is identified. The process for identifying new and
 16 significant information is presented in Chapter 4. Site-specific issues (Category 2) are those
 17 that do not meet one or more of the criteria of Category 1 issues; therefore, additional

1 site-specific review for these issues is required. The results of that site-specific review are
2 documented in the SEIS.

3 In summary, the NRC staff evaluated 92 issues in the GEIS. Based on the findings of the GEIS,
4 a site-specific analysis is required for 23 of those 92 issues and is addressed in the SEIS.

5 **1.5 Supplemental Environmental Impact Statement**

6 The SEIS presents an analysis that considers the environmental effects of the continued
7 operation of STP, Units 1 and 2, alternatives to license renewal, and mitigation measures for
8 minimizing adverse environmental impacts. Chapter 8 contains analysis and comparison of the
9 potential environmental impacts from alternatives while Chapter 9 presents the preliminary
10 recommendation to the NRC (the Commission) on whether or not the environmental impacts of
11 license renewal are so great that preserving the option of license renewal would be
12 unreasonable. The final recommendation will be made after consideration of comments
13 received on this draft SEIS during the public comment period.

14 In the preparation of this SEIS for STP, Units 1 and 2, the NRC staff carried out the following
15 activities:

- 16 • reviewed the information provided in the STPNOC's ER;
- 17 • consulted with other Federal, State, local agencies, and Tribal nations;
- 18 • conducted an independent review of the issues during site audit; and
- 19 • considered the public comments received for the review (during the scoping
20 process and, subsequently, on this draft SEIS).

21 New information can be identified from many
22 sources, including the applicant, the NRC, other
23 agencies, or public comments. If a new issue is
24 revealed, it is first analyzed to determine whether
25 it is within the scope of the license renewal
26 environmental evaluation. If the new issue is not
27 addressed in the GEIS, the NRC staff would determine the significance of the issue and
28 document the analysis in the SEIS.

New and significant information either identifies a significant environmental issue that was not covered in the GEIS or was not considered in the analysis in the GEIS and leads to an impact finding that is different from the finding presented in the GEIS.

29 **1.6 Cooperating Agencies**

30 During the scoping process, no Federal, State, or local agencies were identified as cooperating
31 agencies in the preparation of this SEIS.

32 **1.7 Consultations**

33 The Endangered Species Act of 1973, as amended; the Magnuson–Stevens Fisheries
34 Management Act of 1996, as amended; and the National Historic Preservation Act of 1966
35 require that Federal agencies consult with applicable State and Federal agencies and groups
36 prior to taking action that may affect endangered species, fisheries, or historic and
37 archaeological resources, respectively. The NRC consulted with the following agencies and
38 groups (Appendix D to this SEIS includes copies of consultation documents):

- 39 • Advisory Council on Historic Preservation (ACHP),
- 40 • National Marine Fisheries Service (NMFS),

Purpose and Need for Action

- 1 • State Historic Preservation Office (SHPO),
- 2 • U.S. Fish and Wildlife Service (USFWS),
- 3 • Ysleta del Sur Pueblo,
- 4 • Alabama-Coushatta Tribe,
- 5 • Kiowa Tribe of Oklahoma,
- 6 • Comanche Nation,
- 7 • Tonkawa Tribe of Oklahoma,
- 8 • Apalachicola Creek,
- 9 • Lipan Apache Tribe of Texas,
- 10 • Lipan Apache Band of Texas,
- 11 • Tap Pulam-Coahuiltecan Nation,
- 12 • Kickapoo Traditional Council,
- 13 • Pamaque Clan of Coahuila Y Tejas, and
- 14 • Apalachicola Band of Creek Indians.

15 **1.8 Correspondence**

16 During the course of the environmental review, the NRC staff contacted Federal, State, regional,
17 local, and Tribal agencies listed in Section 1.7. Appendix E contains a chronological list of all
18 documents sent and received during the environmental review.

19 In addition, Chapter 11 provides a list of persons who requested and received a copy of this
20 SEIS.

21 **1.9 Status of Compliance**

22 STPNOC is responsible for complying with all NRC regulations and other applicable Federal,
23 State, and local requirements. Appendix H of the GEIS describes some of the major applicable
24 Federal statutes.

25 There are numerous permits and licenses issued by Federal, State, and local authorities for
26 activities at STP, Units 1 and 2. Appendix C contains further discussion by the staff about
27 status of compliance. Regarding Coastal Zone Management Act (CZMA) compliance status,
28 pursuant to Section 506.11(13) of Texas Administrative Code, STPNOC has obtained and
29 maintained satisfactorily a consistency certification in accordance with the CZMA (Section 2.3
30 contains further discussion about CZMA compliance status for STP license renewal).

31 **1.10 References**

32 10 CFR 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental protection
33 regulations for domestic licensing and related regulatory functions.”

34 10 CFR 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for renewal
35 of operating licenses for nuclear power plants.”

- 1 76 FR 2426. U.S. Nuclear Regulatory Commission. “Notice of Acceptance for Docketing of the
 2 Application and Notice of Opportunity for Hearing Regarding Renewal of Facility Operating
 3 License Numbers NPF–76 and NPF–80 for an Additional 20-Year Period, STP Nuclear
 4 Operating Company, South Texas Project, Units 1 and 2.” *Federal Register*. Volume 76(9):
 5 2426–2428. January 13, 2011.
- 6 76 FRN 5410. U.S. Nuclear Regulatory Commission. “STP Nuclear Operating Company;
 7 Notice of Intent To Prepare an Environmental Impact Statement and Conduct the Scoping
 8 Process for South Texas Project, Units 1 and 2.” *Federal Register*. Volume 76(20):
 9 5410–5411. January 31, 2011.
- 10 [AEA] Atomic Energy Act of 1954, as amended. 42 U.S.C. §2011, et seq.
 11 Endangered Species Act of 1973, as amended. 16 U.S.C. §1531, et seq.
 12 Magnuson–Stevens Fishery Conservation and Management Act, as amended.
 13 16 U.S.C. §1801 et seq.
- 14 [NEPA] National Environmental Policy Act of 1969, as amended. 42 U.S.C. §4321, et seq.
 15 National Historic Preservation Act of 1966. 16 U.S.C. §470, et seq.
- 16 [NRC] U.S. Nuclear Regulatory Commission. 1996. *Generic Environmental Impact Statement*
 17 *for License Renewal of Nuclear Plants*. Washington, DC: NRC. NUREG-1437. May 1996.
 18 ADAMS Nos. ML040690705 and ML040690738.
- 19 [NRC] U.S. Nuclear Regulatory Commission. 1999. Section 6.3, Transportation, Table 9.1,
 20 Summary of findings on NEPA issues for license renewal of nuclear power plants. In: *Generic*
 21 *Environmental Impact Statement for License Renewal of Nuclear Plants*. Washington, DC:
 22 NRC. NUREG-1437, Volume 1, Addendum 1. August 1999. ADAMS No. ML040690720.
- 23 [NRC] U.S. Nuclear Regulatory Commission. 2011. Summary of site audit related to the
 24 review of the license renewal application for South Texas Project, Units 1 and 2.
 25 August 4, 2011. ADAMS No. ML11196A005.
- 26 [NRC] U.S. Nuclear Regulatory Commission. 2012. Environmental Impact Statement Scoping
 27 Process, Summary Report, South Texas Project, Units 1 and 2, Bay City, TX. Washington, DC:
 28 NRC. 2012. ADAMS No. ML11153A082.
- 29 [STPNOC] South Texas Plant Nuclear Operating Company. 2010a. “South Texas Project,
 30 Units 1 and 2, Docket Nos. STN 50–498, STN 50–499, License Renewal Application.”
 31 October 25, 2010. ADAMS No. ML103010257.
- 32 [STPNOC] South Texas Plant Nuclear Operating Company. 2010b. “South Texas Project,
 33 Applicant’s Environmental Report—Operating License Renewal Stage, South Texas Project
 34 Units 1 & 2.” September 2010. ADAMS No. ML103010263.

2.0 AFFECTED ENVIRONMENT

South Texas Project (STP) is located in Matagorda County, Texas, approximately 70 mi (110 km) south-southwest of Houston. The plant consists of two reactor units. Each nuclear reactor is a pressurized-water reactor (PWR) with steam generators producing steam that turns turbines to generate electricity. For purposes of the evaluation in this report, the “affected environment” is the environment that currently exists at and around STP. Because existing conditions are at least partially the result of past construction and operation at the plant, the impacts of these past and ongoing actions and how they have shaped the environment are presented here. The facility and its operation are described in Section 2.1, and the affected environment is presented in Section 2.2.

2.1 Facility Description

STP is a two-unit, nuclear-powered steam electric generating facility that began commercial operation in August 1988 (Unit 1) and June 1989 (Unit 2). The nuclear reactor for each unit is a Westinghouse PWR, producing a reactor core rated thermal power of 3,853 megawatts-thermal (MWt). The nominal net electrical capacity is 1,250 megawatts-electric (MWe). In this supplemental environmental impact statement (SEIS), the use of “STP” is referring to the site where the existing “STP, Units 1 and 2” are located. The use of “STPNOC” is referring to the applicant (STP Nuclear Operating Company) who submitted the license renewal application (LRA). The use of “STP, Units 1 and 2” is referring to the distinction between the existing reactor units and the proposed new reactor units, “STP, Units 3 and 4.”

2.1.1 Reactor and Containment Systems

The nuclear steam supply system at STP is a four-loop Westinghouse PWR. The reactor core heats water, which is pumped to four steam generators where the heat boils the water on the shell-side into steam that is routed to the turbines. The steam turns the turbines, which are connected to the electrical generator. The Units 1 and 2 steam generators were replaced in 2008 and 2009, respectively, with new Westinghouse steam generators.

The nuclear fuel is low-enriched uranium dioxide with enrichments less than 5 percent by weight uranium-235 and fuel burnup levels with a batch average of approximately 45,000 megawattdays (MWd) per metric ton uranium at discharge. Maximum burnup would not exceed 60,000 MWd per metric ton uranium. STP operates on an 18-month refueling cycle.

The reactor, steam generators, and related systems are enclosed in a containment building. The containment building is a post-tensioned, reinforced concrete cylinder with a slab base and a hemispherical dome. A welded steel liner is attached to the inside face of the concrete shell to ensure a high degree of leak tightness. In addition, the 4-ft (1.2-m)-thick concrete walls serve as a radiation shield.

2.1.2 Radioactive Waste Management

STP uses liquid, gaseous, and solid waste processing systems to collect and treat, as needed, radioactive materials that are produced as by-products of plant operations. These materials are produced in the form of

By design, the operation of nuclear power plants is expected to result in small releases of radiological effluents (gaseous, liquid, and solid) through controlled processes. However, releases must meet stringent NRC and EPA regulatory limits.

Affected Environment

1 (a) activation products resulting from irradiation of reactor water and impurities, principally
2 metallic corrosive products, therein and (b) fission products resulting from their migration
3 through the fuel cladding. Radioactive materials in liquid and gaseous effluents (controlled
4 releases from STP) are reduced to levels that ensure compliance with NRC radiation protection
5 regulations in Title 10, Part 20, of the *U.S. Code of Federal Regulations* (10 CFR Part 20), and
6 they are as low as is reasonably achievable (ALARA), in accordance with Appendix I to
7 10 CFR Part 50.

8 Reactor fuel assemblies that have exhausted some of their fissile uranium content (related to
9 the ability to sustain nuclear criticality chain reaction) are referred to as spent fuel (or used fuel).
10 Spent fuel assemblies are removed from the reactor core and replaced by new fuel assemblies
11 during routine refueling outages, typically every 18 months. The spent fuel assemblies are then
12 stored in the spent fuel pool.

13 Systems used at STP to process radioactive liquid, gaseous, and solid wastes are described in
14 the following sections.

15 **2.1.2.1 Radioactive Gaseous Waste System**

16 The objectives of the gaseous waste management system (GWMS) are to process and control
17 the release of radioactive gaseous effluents into the environment to be within the requirements
18 of 10 CFR Part 20 and to be consistent with the ALARA guidelines set forth in Appendix I to
19 10 CFR Part 50. The GWMS also removes fission product gases from the reactor coolant
20 system and from equipment and piping (i.e., reduces the amount of radioactivity from the gases
21 before they are released into the environment). The GWMS is designed so that radiation
22 exposure to plant workers is within NRC dose limits in 10 CFR 20.1201 and ALARA.

23 The GWMS processes the waste gas to control and limit the amount of radioactive noble gas
24 and iodine released into the environment. An inlet header water removal system removes water
25 vapor and heat from the gas stream prior to processing the gas through charcoal beds. The
26 charcoal beds are designed to delay the passage of the gases, which allows for radioactive
27 decay of the noble gases and adsorption of radioiodine as the gas stream moves through the
28 charcoal beds. At the end of the charcoal bed, the gas is filtered by high efficiency filters to
29 remove charcoal dust. There is also a radiation monitor that measures the radioactivity in the
30 waste gas and can automatically terminate the release in the event radioactivity exceeds
31 predetermined levels.

32 The primary sources of radioactive gas in the plant are as follows:

- 33 • the turbine generator building process vents,
- 34 • the auxiliary feedwater pump turbine exhaust, which is vented directly to the
35 atmosphere through the isolation valve cubicle process vent,
- 36 • the reactor containment building ventilation system,
- 37 • the mechanical auxiliary building,
- 38 • the fuel handling building ventilation system, and
- 39 • the reactor coolant gases.

40 **2.1.2.2 Radioactive Liquid Waste System**

41 The function of STPNOC's liquid waste processing system (LWPS) is to collect and process
42 radioactive liquid wastes to reduce radioactivity and chemical concentrations to levels
43 acceptable for discharge to the environment or to recycle the liquids for use in plant systems.

1 The principal objectives of the LWPS are to collect liquid wastes that may contain radioactive
 2 material and to maintain sufficient processing capability so that liquid waste may be discharged
 3 to the environment below the regulatory limits of 10 CFR Part 20 and consistent with the
 4 ALARA guidelines in Appendix I to 10 CFR Part 50.

5 Sources of liquid waste sent to the LWPS include floor drains, equipment drains, laundry and
 6 hot shower drains, and contaminated wastes from plant systems and components. Processing
 7 of the liquid waste is performed using several different methods including filtration,
 8 demineralization, evaporation, or a combination of the three methods.

9 Liquid releases from the plant are made in accordance with NRC radiation protection standards
 10 in 10 CFR Part 20 and the ALARA guidelines set forth in Appendix I to 10 CFR Part 50. The
 11 waste is routed through a monitor that measures the radioactivity and can automatically
 12 terminate the release in the event radioactivity exceeds predetermined levels. The liquid waste
 13 is discharged into the main cooling reservoir (MCR). The entire MCR is within the STP site
 14 boundary, and the public is prohibited from access to the MCR.

15 **2.1.2.3 Radioactive Solid Waste Processing Systems**

16 The solid waste processing system (SWPS) is designed to process, package, and store the
 17 solid radioactive wastes generated by plant operations until they are shipped off site to a vendor
 18 for further processing or for permanent disposal at a licensed burial facility or both. The SWPS
 19 is designed to meet the following objectives:

- 20 • to collect process, package, temporary store, and prepare the waste for
21 shipment;
- 22 • to maintain radiation exposures to plant personnel within the dose limits of
23 10 CFR Part 20.1201 and ALARA;
- 24 • to package and transport the waste in compliance with NRC regulations
25 10 CFR Parts 61 and 71 and the U.S. Department of Transportation
26 regulations 49 CFR Parts 170 through 179; and
- 27 • to stabilize wet waste using either an onsite or offsite system from a qualified
28 vendor.

29 The permanently installed portion of the SWPS is located within the mechanical-electrical
 30 auxiliary building. Identical systems containing the following major subsystems are used for
 31 STP, Units 1 and 2:

- 32 • Concentrate storage tank and transfer subsystem—This subsystem includes
33 a 5,000-gallon storage tank equipped with a mixer, heat tracing, and level
34 controls to prevent overflows. The applicant states that this system is
35 currently not in use.
- 36 • Spent resin transfer subsystem—This system is used to transfer spent resin
37 filter media to a vendor-supplied processing system.
- 38 • Expended cartridge filter transfer subsystem—This system handles filter
39 cartridges used to process radioactive liquid wastes. The system uses
40 shielding and long-handled tools to safely handle the filters for insertion into a
41 shielded cask that will be transported to a disposal facility.
- 42 • Overhead crane subsystem—This is a remotely operated 7 ½-ton overhead
43 bridge crane with automatic grapples to move loaded containers from the

Affected Environment

1 storage areas to the truck loading area and to stabilize wet waste using either
2 an onsite or offsite system from a qualified vendor.

3 • Dry active waste area—This area is used to sort and package dry active
4 waste. The waste is typically sent to an offsite vendor for volume reduction
5 prior to disposal.

6 • Chemical addition subsystem—This subsystem provides chemical
7 adjustment of liquids to maintain pH control for efficient processing.

8 • Vendor-supplied onsite subsystem—This subsystem consists of control
9 panels used to control dewatering pumps, fill and dewatering heads, level
10 controls, and monitoring instruments.

11 Radioactive waste is stored within plant buildings until it is shipped off site for further processing
12 by a vendor or disposal or both. The storage areas have restricted access and shielding to
13 reduce radiation rates to plant workers. The radioactive waste is divided into high activity and
14 low activity storage areas. Separation of the high activity storage area from the building exterior
15 by the low activity area provides for a reduction in radiation levels to plant workers in the truck
16 loading area.

17 The Texas Low-Level Radioactive Waste Disposal Compact Facility, located in Andrews
18 County, Texas, opened on November 10, 2011. The facility is licensed by the State of Texas to
19 dispose of Class A, B, and C low-level waste (LLW). This LLW disposal facility is available to
20 STP for the disposal of its LLW. With the availability of this disposal facility, the current LLW
21 handling and storage facilities are expected to be adequate to handle LLW waste generated
22 during the license renewal term.

23 In the event of an interruption in LLW disposal capability, STP has the ability to store its waste
24 on site. STP has an onsite staging facility, located west of STP Unit 2. This facility can provide
25 a staging area for the waste for up to 5 years of operation of both reactor units.

26 **2.1.3 Nonradiological Waste Management**

27 STP generates nonradioactive wastes as part of routine plant maintenance, cleaning activities,
28 and plant operations. In general, Resources Conservation and Recovery Act (RCRA) waste
29 regulations governing the disposal of solid and hazardous waste are contained in
30 40 CFR Parts 239 through 299. Specifically, 40 CFR Parts 239 through 259 contain regulations
31 for solid (nonhazardous) waste, and 40 CFR Parts 260 through 279 contain regulations for
32 hazardous waste. RCRA, Subtitle C, establishes a system for controlling hazardous waste from
33 “cradle to grave,” and RCRA, Subtitle D, encourages states to develop comprehensive plans to
34 manage nonhazardous solid waste and mandates minimum technological standards for
35 municipal solid waste landfills. Texas State RCRA regulations are administered by the Texas
36 Commission on Environmental Quality (TCEQ) and address the identification, generation,
37 minimization, transportation, and final treatment, storage, or disposal of hazardous and
38 nonhazardous waste.

39 **2.1.3.1 Nonradioactive Waste Streams**

40 STP generates solid waste, defined by the RCRA, as part of routine plant maintenance,
41 cleaning activities, and plant operations. Texas administers the RCRA Program in Texas
42 Administrative Code (TAC) 335.

43 EPA classifies certain nonradioactive wastes as hazardous based on characteristics including
44 ignitability, corrosivity, reactivity, or toxicity (hazardous wastes are listed in 40 CFR Part 261).
45 State-level regulators may add wastes to EPA’s list of hazardous wastes. RCRA supplies

1 standards for the treatment, storage, and disposal of hazardous waste for hazardous waste
2 generators (regulations are available in 40 CFR Part 262).

3 EPA recognizes the following main types of the hazardous waste generators (40 CFR 260.10)
4 based on the quantity of the hazardous waste produced:

- 5 • large quantity generators that generate 2,200 lb (1,000 kg) per month or more
6 of hazardous waste, more than 2.2 lb (1 kg) per month of acutely hazardous
7 waste, or more than 220 lb (100 kg) per month of acute spill residue or soil;
- 8 • small quantity generators that generate more than 220 lb (100 kg) but less
9 than 2,200 lb (1,000 kg) of hazardous waste per month; and
- 10 • conditionally exempt small quantity generators that generate 220 lb (100 kg)
11 or less per month of hazardous waste, 2.2 lb (1 kg) or less per month of
12 acutely hazardous waste, or less than 220 lb (100 kg) per month of acute spill
13 residue or soil.

14 TCEQ recognizes STP as a small quantity generator of hazardous wastes under TAC 335. STP
15 hazardous wastes include waste oil, grease, electrohydraulic fluid, adhesives, liquid paint, and
16 solvent for fuel blending and thermal energy recovery. Used oil diesel fuels and used oil filters
17 are sent to a recycling vendor for re-processing. Lead-acid batteries are returned, when
18 possible, to the original manufacturer for recycling or are shipped to a registered battery
19 recycler.

20 EPA classifies several hazardous wastes as universal wastes; these include batteries,
21 pesticides, mercury-containing items, and fluorescent lamps. TCEQ has incorporated EPA's
22 regulations (40 CFR Part 273) regarding universal wastes in TAC 335.261. Universal wastes
23 produced by STP are disposed of or recycled in accordance with TCEQ regulations.

24 Conditions and limitations for wastewater discharge by STP are specified in Texas Pollution
25 Discharge Elimination System (TPDES) Permit No. WQ0001908000. In 2009, STP applied for
26 a renewal of this wastewater discharge permit and, at the writing of this supplemental
27 environmental impact statement (SEIS), continues to work with TCEQ on its renewal.

28 Radioactive liquid waste is addressed in Section 2.1.2 of this SEIS. Section 2.2.4 gives more
29 information about STP TPDES permit and permitted discharges, including a discussion of the
30 staff's request for information about the STP TPDES permit status.

31 The Emergency Planning and Community Right-to-Know Act (EPCRA) requires applicable
32 facilities to supply information about hazardous and toxic chemicals to local emergency planning
33 authorities and EPA (42 USC 11001). On October 17, 2008, EPA finalized several changes to
34 the Emergency Planning (Section 302), Emergency Release Notification (Section 304), and
35 Hazardous Chemical Reporting (Sections 311 and 312) regulations (63 FR 31268). STP is
36 subject to Federal EPCRA reporting requirements; thus, STP submits an annual Section 312
37 (Tier II) report on hazardous substances to local emergency response agencies.

38 **2.1.3.2 Pollution Prevention and Waste Minimization**

39 The EPA encourages the use of environmental management systems (EMSs) for organizations
40 to assess and manage the environmental impacts associated with their activities, products, and
41 services in an efficient and cost-effective manner. The EPA defines an EMS as "a set of
42 processes and practices that enable an organization to reduce its environmental impacts and
43 increase its operating efficiency." EMSs help organizations fully integrate a wide-range of
44 environmental initiatives, establish environmental goals, and create a continuous monitoring
45 process to help meet those goals. The EPA Office of Solid Waste especially advocates the use

Affected Environment

1 of EMSs at RCRA-regulated facilities to improve environmental performance, compliance, and
2 pollution prevention (EPA 2010a).

3 Related to the use of EMSs, STP has waste minimization measures in place currently, as
4 verified during the STP site visit conducted by NRC in July 2011. In support of nonradiological
5 waste-minimization efforts, EPA's Office of Prevention and Toxics has established a
6 clearinghouse that supplies information about waste management and technical and operational
7 approaches to pollution prevention (EPA 2010c). The EPA clearinghouse can be used as a
8 source for additional opportunities for waste minimization and pollution prevention at STP, as
9 appropriate.

10 **2.1.4 Plant Operation and Maintenance**

11 Maintenance activities conducted at STP include inspection, testing, and surveillance to
12 maintain the current licensing basis (CLB) of the facility and to ensure compliance with
13 environmental and safety requirements. Various programs and activities currently exist at STP
14 to maintain, inspect, test, and monitor the performance of facility equipment. These
15 maintenance activities include inspection requirements for reactor vessel materials, boiler and
16 pressure vessel inservice inspection and testing, the Maintenance Structures Monitoring
17 Program, and maintenance of water chemistry.

18 Additional programs include those carried out to meet technical specification (TS) surveillance
19 requirements, those implemented in response to the NRC generic communications, and various
20 periodic maintenance, testing, and inspection procedures. Certain program activities are carried
21 out during the operation of the unit, while others are carried out during scheduled refueling
22 outages. Nuclear power plants must periodically discontinue the production of electricity for
23 refueling, periodic inservice inspection, and scheduled maintenance. STP operates on an
24 18-month refueling cycle.

25 **2.1.5 Power Transmission System**

26 Nine 345-kV lines were constructed specifically to connect STP to the regional power grid.
27 These lines share transmission line corridors and are owned by four service providers:
28 American Electric Power Texas Central Company, CenterPoint Energy, City of Austin, and CPS
29 Energy. This section summarizes each line and discusses vegetative maintenance procedures.
30 Below, the common name for each line appears first, followed by its Electric Reliability Council
31 of Texas (ERCOT) name in parentheses. The discussion of the power transmission system is
32 adapted from the ER (STPNOC 2010b), the COL application (STPNOC 2010d), STPNOC's
33 October 2011 response to requests for additional information (STPNOC 2011f), or information
34 gathered at NRC's July 2011 environmental site audit.

35 **2.1.5.1 Transmission Line Descriptions**

36 Velasco Line (DOW 18 and DOW 27). The Velasco Line is a 45-mi (72-km)-long, double-circuit
37 line that extends east from the STP site to the Velasco substation in Brazoria County. Its
38 corridor is 100 ft (30 m) wide. CenterPoint Energy owns and operates this line.

39 Blessing Line (Blessing 44). The Blessing line extends west and then north from the STP site
40 for 15 mi (24 km) to its termination point at the Blessing substation in Matagorda County. Its
41 corridor is 100 ft (30 m) wide. American Electric Power Texas Central Company owns and
42 operates this line.

43 Hillje Line (Hillje 64). The Hillje line extends 20 mi (32 km) northwest from the STP site to the
44 Hillje substation in Wharton County. Its corridor is 400 ft (120 m) wide and is shared with the

1 remaining lines discussed in this section. For simplification, this corridor will be referred to as
 2 the Hillje corridor in this section. CenterPoint Energy owns and operates the Hillje Line.

3 Hillje W.A. Parrish Loop (WAP 39). The Hillje W.A. Parrish Loop is one of two 20-mi (32-km)
 4 connector lines that join the STP site to a pre-existing (and out of scope) transmission line, the
 5 W.A. Parrish-to-Lon Hill Line. The Hillje W.A. Parrish Loop travels along the Hillje corridor.
 6 CenterPoint Energy owns and operates this line.

7 Hillje Lon Hill Loop (White Point 39). The Hillje Lon Hill Loop is the second of two 20-mi (32-km)
 8 connector lines that join the STP site to a pre-existing (and out of scope) transmission line, the
 9 W.A. Parrish-to-Lon Hill Line. The line travels along the Hillje corridor, and CenterPoint Energy
 10 owns and operates this line.

11 Holman Line (Hillje 44). The Holman Line travels through the Hillje corridor and then extends
 12 northwest for an additional 75 mi (121 km) to the Holman substation in Fayette County. The
 13 total length of the line is 95 mi (153 km). Beyond the Hillje corridor, the corridor is 100 ft (30 m)
 14 wide. CenterPoint Energy owns and operates the portion of the line within the Hillje corridor,
 15 and the City of Austin owns and operates the remaining length of the line.

16 Skyline Line (Elm Creek 27). The Skyline Line travels through the Hillje corridor, extends west
 17 an additional 119 mi (192 km) to the Elm Creek substation in Guadalupe County, and then
 18 extends an additional 29 mi (47 km) to the Skyline substation in Bexar County. The total length
 19 of the line is 168 mi (271 km). Beyond the Hillje corridor, this line's corridor is 100 ft (30 m)
 20 wide. CPS Energy owns and operates the full length of this line.

21 Hill Country Line (Elm Creek 18). The Hill Country line follows the same corridor path as the
 22 Skyline Line. However, the Hill Country line extends an additional 12 mi (19 km) from the
 23 Skyline substation (where the Skyline Line terminates) to the Hill Country Substation in Bexar
 24 County. The total length of this line is 180 mi (290 km).

25 White Point Loop (White Point 39). The White Point Loop is a connector line that joins the STP
 26 site to the Lon Hill Line. This line is 10 mi (16 km) long and travels along a 100-ft (30-m) wide
 27 corridor. American Electric Power Texas Central Company owns and operates this line.

28 **2.1.5.2 Transmission Line Maintenance**

29 American Electric Power Texas Central
 30 Company, CenterPoint Energy, City of Austin,
 31 and CPS Energy use an integrated vegetative
 32 management program that combines manual,
 33 mechanical, biological, and chemical control
 34 techniques to maintain proper clearance from
 35 transmission lines and structures. The degree
 36 and type of clearance varies by line voltage and the type, growth rate, and branching
 37 characteristics of trees and vegetation. The majority of the in-scope transmission lines traverse
 38 agricultural land and grasslands. Therefore, maintenance activities are minimal. Those areas
 39 that are not already cultivated or developed in some other way are maintained to promote
 40 herbaceous vegetation, which includes shrubs, bushes, and other low-growing groundcover.

A transmission line right-of-way (ROW) is a strip of land used to construct, operate, maintain, and repair transmission line facilities. The transmission line is usually centered in the ROW. The width of a ROW depends on the voltage of the line and the height of the structures. ROWs must typically be clear of tall-growing trees and structures that could interfere with a powerline.

41 **2.1.6 Cooling and Auxiliary Water Systems**

42 STP uses a cooling pond-based heat-dissipation system that withdraws and discharges cooling
 43 water to the MCR. STPNOC intermittently withdraws and discharges makeup water from the
 44 lower Colorado River to raise the water level and maintain water quality within the MCR. Unless

Affected Environment

1 otherwise cited, the NRC staff drew information about STPNOC's cooling and auxiliary water
2 systems from the TPDES Permit (TCEQ 2005) and the applicant's ER (STPNOC 2010b).

3 Circulating Water System. Water is intermittently drawn from the lower Colorado River through
4 the Reservoir Makeup Pumping Facility (RMPF) to the MCR. The RMPF is located on the west
5 bank of the lower Colorado River and consists of four makeup pumps with a total current
6 capacity of approximately 269,000 gallons per minute (gpm) (600 cubic feet per second (cfs) or
7 $17 \text{ m}^3/\text{s}$). STPNOC intermittently draws water from the Colorado River to replace water lost in
8 the MCR due to evaporation and seepage. This is depending on weather (patterns of rainfall in
9 the river basin), water quality conditions in the MCR, Colorado River flows, operational
10 considerations, and TPDES restrictions.

11 The RMPF withdraws water through a 406-ft (124-m) long intake structure located parallel to the
12 shoreline. Water flows through a coarse trash rack with 4-in. (10-cm) openings and into
13 traveling water screens (STPNOC 2010d). Each traveling screen is 10-ft (3-m) wide and has a
14 mesh size of 3/8 in. (9.5 mm) (STPNOC 2010d, 2010e). A handling and bypass system on the
15 traveling screens collects fish caught on the screens and returns them via a sluice downstream
16 to the river (STPNOC 2010d). Water that passes through the traveling screens goes into a
17 siltation basin, across a sharp-crested weir, and into the pumping station. The water is then
18 pumped into the northeast corner of the MCR through two buried 108-in. (274-cm) diameter
19 pipelines.

20 The MCR is a 7,000-ac (2,833-ha) engineered impoundment enclosed by a 12.4-mi (20-km)
21 embankment that consists of a clay fill and is lined with a "soil-cement" to prevent erosion
22 (located adjacent to and south of STP, Units 1 and 2; see Figure 2-1). At the maximum normal
23 operating pool of 49 ft (15 m) above mean sea level (MSL), the reservoir contains approximately
24 202,700 ac-ft (250 million m^3) of water. The normal operating level is 47 ft (14.3 m) above MSL
25 due to a procedural limit for a two-unit operation.

26 Water flows from the MCR to the main condensers as water is suctioned by four circulating
27 water pumps located within the cooling water intake structure (CWIS). Water then passes to a
28 common distribution header for the condensers for both units. In the condenser, the circulating
29 water absorbs waste heat. Heated water is discharged to the MCR through a discharge
30 structure. Each unit circulates 906,957 gpm (3,433 cfs or $97.2 \text{ m}^3/\text{s}$) for circulating water flow
31 (STPNOC 2009a).

32 Dikes within the MCR slow the flow of cooling water from the circulating water system discharge
33 structure to the CWIS. As the heated water circulates in the MCR, the heat is gradually
34 dissipated to the environment through evaporation, conduction, and long-wave radiative cooling.

35 To maintain water chemistry and quality within the MCR, STPNOC discharges water from the
36 MCR to the Colorado River. Discharge from the MCR enters the Colorado River along the west
37 bank through a series of seven 36-in. (91-cm) pipes directed downstream at an angle of
38 45 degrees from the shore. The discharge structures are 2 mi (3 km) downstream of the RMPF.

39 The pipes entering the river are spaced 250 ft (76 m) apart. STPNOC's TPDES permit limits the
40 daily discharge to 144 mgd (5.45 million m^3/d) and shall not exceed 12.5 percent of the flow of
41 the Colorado River at the discharge point (TCEQ 2005). The TPDES permit also prohibits
42 STPNOC from discharging wastewater when the Colorado River adjacent to the plant is less
43 than 800 cfs ($22.7 \text{ m}^3/\text{s}$). The Texas Administrative Code limits the daily average temperature
44 to 95 °F (35 °C) and daily maximum temperature to 97 °F (36 °C) (STPNOC 2010b). STPNOC
45 has discharged to the Colorado River once during the operation of STP in 1997 as part of a
46 system test (STPNOC 2010b).

1 Auxiliary Cooling Water and Essential Cooling Water Systems. The MCR supplies the auxiliary
2 cooling water system with cooling water for nonsafety-related systems. Water travels from the
3 MCR to the auxiliary cooling water system through a separate bay in the MCR intake structure
4 and then heated water discharges to the MCR. The design flow rate is 23,600 gpm (52.6 cfs or
5 $1.5 \text{ m}^3/\text{s}$).

6 The essential cooling pond (ECP) supplies the essential cooling water system with cooling
7 water for safety-related systems. The ECP is approximately 46 ac (19 ha). Three groundwater
8 wells are the primary makeup to the ECP. The design flowrate is 19,280 gpm (43 cfs or
9 $1.2 \text{ m}^3/\text{s}$). After going through the essential cooling water system, the water is discharged to the
10 ECP, which is the ultimate heat sink. STPNOC discharges water from the ECP to the MCR to
11 maintain water chemistry.

12 **2.1.7 Facility Water Use and Quality**

13 STP, Units 1 and 2, use water systems that include the circulating water systems (CWSs), the
14 freshwater and service water systems, the potable and sanitary water systems, and the auxiliary
15 cooling water and essential cooling water systems (ECWSs) (see Section 2.1.6). STP uses a
16 cooling pond to reject waste heat from normal operations to the atmosphere. The 7,000-ac
17 (2,830-ha) MCR is located adjacent to and south of STP, Units 1 and 2 (see Figure 2–1). The
18 MCR has a spillway near its southeast corner for the discharge of excess water from the MCR
19 to the Colorado River during heavy precipitation events. The MCR also has a buried discharge
20 pipe that runs for 1.1 mi (1.8 km), adjacent to the spillway discharge channel, which ends at a
21 seven-port outfall. This is STPNOC's combined outfall (001) under STPNOC's TPDES permit.
22 This pipe allows for the discharge of blowdown (i.e., water high in dissolved solids) from the
23 MCR to the Colorado River. The MCR spillway is seldom used, and the blowdown pipeline has
24 only been used as part of a test in 1997. The MCR has a normal maximum operating level of
25 49 ft (15 m) above MSL for a four-unit operation, but it currently operates under a procedural
26 limit of 47 ft (14 m) above MSL for a two-unit operation (STPNOC 2010b).

27 The RMPF diverts water from the Colorado River to the MCR to replenish water lost due to
28 evaporation and seepage. The RMPF is located on the Colorado River to the east of the
29 operating units and delivers water to the MCR through two buried 108-in. (274-cm) diameter
30 makeup water lines. As currently configured (e.g., screens and pumps), the intake structure has
31 a pumping capacity of 269,000 gpm (600 cfs or $17 \text{ m}^3/\text{s}$).

32 In addition to the water supply from the Colorado River, STPNOC maintains five groundwater
33 supply wells at STP as the source for the freshwater and service water systems (including the
34 demineralizer system), potable and sanitary water systems, the firewater storage tanks, the
35 Nuclear Support Center cooling tower, and fire protection for the Nuclear Training Facility.
36 Three of the five onsite wells provide water to the service system and the fire water storage
37 tanks, and one well each supports the Nuclear Support Center cooling tower and the Nuclear
38 Training Facility (STPNOC 2010b).


39 The auxiliary cooling water system draws cooling water for nonsafety-related systems from the
40 MCR. Heated water from this system returns to the MCR. The design flow rate of this system
41 is 23,600 gpm (53 cfs or $1.5 \text{ m}^3/\text{s}$). The essential cooling water system (ECWS) draws cooling
42 water for safety-related systems from the ECP. Heated water from this system returns to the
43 ECP. The design flow rate for this system is 19,280 gpm (43 cfs or $1.2 \text{ m}^3/\text{s}$). Makeup to the
44 ECP is from one of the three groundwater wells providing service water and fire water storage.
45 The ECP also is equipped with the capability to discharge blowdown to the MCR to maintain
46 water chemistry (STPNOC 2010b).

Affected Environment

- 1 A description of surface water resources at STP and vicinity is provided in Section 2.2.4, and a
- 2 description of the groundwater resources is presented in Section 2.2.5. The following sections
- 3 further describe the water use from these resources.

1
2

Figure 2–1. Surface Water Bodies and Groundwater Wells in Vicinity of STP (STPNOC 2011b)



Affected Environment

1 **2.1.7.1 Surface Water Use**

2 Feedwater for the STP, Units 1 and 2, CWS is supplied by the MCR, with makeup water for the
3 MCR diverted from the lower Colorado River using the RMPF, as previously described. The
4 RMPF was designed to accommodate operations of four units at the STP site. Currently, the
5 RMPF has 269,000 gpm (600 cfs or 17 m³/s) of installed pumping capacity to support the
6 operation of Units 1 and 2. The MCR also supplies water to the auxiliary cooling water systems,
7 which provide cooling for nonsafety-related systems (STPNOC 2010b).

8 Through a Certificate of Adjudication issued by the Texas Water Commission, STPNOC has
9 priority water rights through the lower Colorado River Authority to use 102,000 ac-ft/yr
10 (126 million m³/yr) of water from the lower Colorado River. STP can withdraw river water up to
11 a maximum rate of 540,000 gpm (1,200 cfs or 34.4 m³/s). However, STPNOC's diversions are
12 limited to 55 percent of the flow of the lower Colorado River that is in excess of a 300-cfs
13 (8.5-m³/s) base flow at the diversion point. This is intended to protect freshwater inflows to
14 Matagorda Bay during low flow conditions. The Certificate of Adjudication also provides rights
15 for an additional 20,000 ac-ft (24.7 million m³) of water for operation of STP, Units 1 and 2.
16 Should sufficient water not be available from the lower Colorado River to maintain the MCR at
17 or above an elevation of 27 ft (8.2 m) above MSL, stored water would be released by the lower
18 Colorado River Authority from sources (i.e., Highland Lakes) upstream of Bay City Dam
19 (STPNOC 2009b, 2010b).

20 To operate STP, Units 1 and 2, STPNOC diverted an average of 37,850 ac-ft (46.7 million m³)
21 of water per year from the Colorado River between 2003 and 2010. STPNOC's diversion during
22 this period ranged from zero in 2003, due to low flow restrictions, to 72,464 ac-ft
23 (89.4 million m³) during 2009 (STPNOC 2010b, 2011b).

24 **2.1.7.2 Groundwater Use**

25 Groundwater is withdrawn at STP via five onsite wells to supply the freshwater and service
26 water systems, potable and sanitary water systems, and fire protection storage tanks and to
27 provide makeup water for the ECWS (see Section 2.1.7).

28 The five water-supply wells (see Figure 2–1) were installed during construction of STP, Units 1
29 and 2, and all are completed in the Deep Chicot Aquifer, as further described in Section 2.2.5.
30 These wells range in depth below ground surface (BGS) from 600 to 700 ft (183 to 213 m) and
31 have design capacities between 200 and 500 gpm (760 to 1,890 L/min) (NRC 2011b;
32 STPNOC 2010b). STP holds a permit from the Coastal Plains Groundwater Conservation
33 District to withdraw 9,000 ac-ft (11.1 million m³) of groundwater over an approximately 3-year
34 permit period (CPGCD 2011). This is a pumping rate of approximately 1,860 gpm (7,040 L/min)
35 or 3,000 ac-ft/yr (3.7 million m³/yr). Based on data from 2001 through 2010, STPNOC's total
36 annual groundwater production ranged from 682 to 863 gpm (2,580 to 3,270 L/min) or 1,100 to
37 1,392 ac-ft/yr (1.4 to 1.7 million m³/yr) and averaged 768 gpm (2,910 L/min) or 1,239 ac-ft/yr
38 (1.5 million m³/yr) (STPNOC 2010b, 2010d, 2011b).

39 **2.2 Surrounding Environment**

40 Sections 2.2.1 through 2.2.10 provide general descriptions of the environment near STP as
41 background information. They also provide detailed descriptions, where needed, to support the
42 analysis of potential environmental impacts of operation during the renewal term, as discussed
43 in Sections 3 and 4.

1 **2.2.1 Land Use**

2 STP is located in Matagorda County, 8 mi (3.2 km) north-northwest of Matagorda and sits
3 between Farm-to-Market Road (FM) 1095 to the west and the Colorado River to the east. The
4 STP site is located on approximately 12,220 ac (4,945 ha). The operations area, consisting of
5 the reactor buildings, support facilities, and transmission ROWs occupies approximately 65 ac
6 (26 ha); the ECP, approximately 46 ac (19 ha); and the MCR, an additional 7,000 ac (2,833 ha).
7 Another 1,700 ac (688 ha) is natural low land habitat. The rest of the site is mostly undeveloped
8 land; a portion of which, east of the MCR, is leased for cattle grazing (STPNOC 2010b).

9 Onsite facilities include the two reactor and steam generator containment buildings, various
10 buildings auxiliary to the reactors such as warehouses, a chemical storage building, switchyard,
11 fuel handling buildings, radioactive waste building, training center, outdoor firing range,
12 administrative buildings, and miscellaneous supporting buildings (STPNOC 2010b).

13 Nearby communities include Matagorda, approximately 8 mi (13 km) north-northwest; Palacios,
14 11 mi (18 km) north-northwest; and Bay City, 13 mi (21 km) southeast. The western bank of the
15 Colorado River forms the eastern STP property boundary. A 13-acre (5-ha) park, developed by
16 the lower Colorado River Authority (LCRA) and operated by Matagorda County, is located on
17 FM 521 on the west side of the Colorado River. The Port of Bay City terminal is located
18 approximately 5 mi (8 km) north-northeast of the STP site.

19 **2.2.2 Air Quality and Meteorology**

20 STP is located in Matagorda County, a coastal county located on the Gulf of Mexico in the
21 southeastern portion of Texas. There are 10 climatic divisions of Texas, with Matagorda County
22 falling into the Gulf Coastal Plain, primarily a combination of prairies and marshes. The climate
23 for this region is classified as maritime subtropical, which is marked by relatively short, mild
24 winters; long, hot summers; and mild springs and falls. The Azores high-pressure system is the
25 source of maritime tropical air masses much of the year. During the winter months, occasional
26 cold continental air masses displace the maritime air. The STP site is flat with no topographic
27 features that would cause the local climate to deviate significantly from the regional climate.
28 While tornadoes and floods are the primary weather hazards in the rest of the State, the Gulf
29 Coastal Plain is most vulnerable to hurricanes.

30 The closest first-order National Weather Service (NWS) station representative of the STP site is
31 Victoria, Texas, located about 53 mi (85.3 km) to the west of the site. The NWS station at
32 Corpus Christi, Texas, about 100 mi (161.0 km) to the southwest, is also representative of the
33 site due to its proximity to the coast. Summer climate extends from May through September,
34 with the highest average temperatures occurring during July and August, which are 83.8 °F
35 (28.8 °C) and 83.7 °F (28.7 °C), respectively. The winter climate extends from December
36 through February, with the coldest weather occurring in January at 55.7 °F (13.2 °C) on
37 average. The fall climate occurs in October and November, with average temperatures of
38 72.6 °F (22.6 °C) and 64.6 °F (18.1 °C) respectively. The spring climate at STP extends from
39 March to April, with average temperatures of 65.4 °F (18.6 °C) and 70.2 °F (21.2 °C),
40 respectively. The Gulf of Mexico can modify outbreaks of polar air masses such that
41 temperatures below 32 °F (0 °C) may occur, on average, less than four times per year.

42 **2.2.2.1 Air Quality**

43 Matagorda County is within the Metropolitan Houston–Galveston Intrastate Air Quality Control
44 Region (AQCR). Other counties in the region include Austin, Brazoria, Chambers, Colorado,
45 Fort Bend, Galveston, Harris, Liberty, Montgomery, Walker, Waller, and Wharton Counties
46 (40 CFR 81.38).

Affected Environment

1 The EPA regulates six criteria pollutants under the National Ambient Air Quality Standards
2 (NAAQS)—carbon monoxide, lead, nitrogen dioxide, ozone, sulfur dioxide, and particulate
3 matter. Matagorda County is designated as unclassified or in attainment for all NAAQS criteria
4 pollutants. However, the counties of Brazoria, Chambers, Fort Bend, Galveston, Harris, Liberty,
5 Montgomery, and Waller are classified as “[N]onattainment[/]Severe” (40 CFR 81.344) for the
6 8-hour ozone standard. These counties are located northeast or north-northeast of Matagorda
7 County, with the closest being Brazoria County, located approximately 21 mi northeast of the
8 STP site. All other counties in this AQCR are designated as unclassified or in attainment with
9 respect to the NAAQS criteria pollutants.

10 STP has many stationary emission sources, such as standby emergency diesel generators, an
11 auxiliary boiler to furnish steam for start-up when the nuclear steam supply is unavailable, and
12 several petroleum fuel storage tanks. STP submits a report of air emissions to TCEQ annually.
13 Actual total emissions from all sources at STP from 2004 to 2010 were 62.86 tons per year
14 (tpy), 58.15 tpy, 56.24 tpy, 47.07 tpy, 60.68 tpy, 59.97 tpy, and 65.37 tpy, respectively. With the
15 exception of volatile organic compounds (VOC), the highest emissions were reported in 2004,
16 with 1.11 tpy of particulate matter, 12.41 tpy of carbon monoxide, 46.62 tpy of oxides of
17 nitrogen, and 0.78 tons per year of sulfur dioxide. The highest VOC emissions were reported in
18 2009 and were 2.07 tpy. There are no plans for refurbishment of structures or components at
19 the STP site for license renewal. Therefore, there are no changes to expected air emissions
20 associated with license renewal (STPNOC 2010b, 2012a)

21 Mandatory Class I Federal Areas, where visibility is an important value, are listed in
22 40 CFR Part 81, Subpart D. There are no mandatory Class I Federal areas within 50 mi
23 (81 km) of the STP site. The closest Class I area to STP is the Big Bend National Park located
24 in west Texas, which is over 500 mi (805 km) west of the STP site. Due to the significant
25 distance from the site and prevailing wind direction, no adverse impacts on Class I areas are
26 anticipated from STP operation. Furthermore, there are no expected additional air emissions
27 associated with license renewal (no new emission sources).

28 STP has had a Meteorological Monitoring Program on site since July 1973. The initial
29 measurements were to provide the onsite meteorological information required for licensing of
30 STP, Units 1 and 2. Measurements have continued in support of the existing STP, Units 1
31 and 2, operations. The primary meteorological tower is approximately 1.5 mi (2.4 km) to the
32 east of STP, Units 1 and 2. Its instruments include wind speed and direction and temperature
33 sensors at 10 m (33 ft) and 60 m (197 ft) above ground, dew point temperature at 10 m (33 ft)
34 above ground, and precipitation and solar radiation near ground level. A 10 m (33 ft) backup
35 meteorological tower is located about 0.4 mi (0.6 km) south of the primary tower.
36 Instrumentation on the backup tower consists of wind speed and direction and temperature at
37 10 m (33 ft).

38 **2.2.2.2 Meteorology**

39 Wind at the STP site is consistent with the dominant influence of the Azores high-pressure
40 system and the coastal location of the site. Seasonal variation of the prevailing directions
41 shows a predominance of southeasterly winds except in January, July, and August, when south
42 winds prevail, and November and December, when northerly winds prevail. The coastal
43 location of the site leads to typical onshore (southeast) winds during the day and offshore winds
44 at night.

45 Precipitation at the STP site ranges from about 2 in. (5.1 cm) per month in February, peaking to
46 about 4 to 5 in. (10.2 to 12.7 cm) per month in May and June and again in September and
47 October. Snow occurs during more than 50 percent of the winters, but snowfall is generally
48 limited to trace amounts. STP can experience severe weather in the form of thunderstorms,

1 tornadoes, and tropical storms. Thunderstorms are the most frequent severe weather events.
2 They occur on an average of about 55 days per year at the Victoria NWS station and about
3 31 days per year at Corpus Christi NWS station. The majority of the thunderstorms occur from
4 the months of May through September. It is likely that the frequency of thunderstorms at the
5 STP site is closer to that of the Corpus Christi NWS station than the Victoria NWS station due to
6 Corpus Christi's proximity to the coastline. Tropical cyclones, including hurricanes and tropical
7 storms, pass near the STP site an average of about once every other year, and an average of
8 about two to three hurricanes pass near the site every 10 years. Nine hurricanes have made
9 landfall between Corpus Christi and Galveston since 1950, the most recent being hurricanes
10 Humberto in 2007 and Ike in 2008. Tornadoes are the least frequent of these extreme weather
11 events.

12 **2.2.3 Geologic Environment**

13 This section describes the current geologic environment of the STP site and vicinity including
14 landforms, geology, soils, and seismic setting.

15 Physiography. STP is located within the Coastal Prairies portion of the Texas Gulf Coastal
16 Plains physiographic province. The Coastal Prairies subprovince is a broad band paralleling the
17 Texas Gulf coasts (BEG 1996). The topography in the immediate vicinity of the site is
18 characterized by a relatively flat coastal plain with elevations generally ranging from 20 to 30 ft
19 (6 to 9 m) above MSL, with an average elevation of 23 ft (7 m) above MSL across STP
20 (NRC 2011b; STPNOC 2009a).

21 One unique topographic feature in the region is the presence of "pimple mounds," which can be
22 seen throughout the Texas coastal area. These round or elliptical features are typically about
23 2 ft (0.6 m) high and 50 ft (15 m) or less in diameter. They are most frequently associated with
24 low-lying, poorly drained areas or bodies of water. These mounds are not restricted to a
25 specific soil series or type, but they occur on many different types of soils with various moisture
26 contents and have no connection to deeper sediments. Although many theories have been
27 proposed for their origin, their structure indicates that they result from normal sedimentary
28 deposition in calm water environments (STPNOC 2009a).

29 Geology. STP sits on the Beaumont depositional plain, one of several such surfaces trending
30 northeast-southwest along the Texas Gulf coasts that formed during the Pleistocene Age
31 (i.e., between approximately 12,000 and 2.6 million years ago), due to changes in sea level
32 associated with coastal subsidence and inland geologic uplift. This plain reflects the uppermost
33 surface of a sequence of Quaternary Age sediments approximately 3,000 ft (910 m) thick that
34 were deposited by ancient river systems and in deltas. Test borings indicate such sediments
35 are present to a depth of at least 2,619 ft (798 m) beneath the site with ages of no more than
36 700,000 years. Nevertheless, there has been little modification of this depositional plain since
37 the uppermost Beaumont Formation was deposited approximately 70,000 years ago. Today,
38 this plain is crossed by the very shallow but relatively wide (4 mi or 6.6 km) Colorado River
39 valley, which the river has meandered back and forth across over time (STPNOC 2009a).

40 The uppermost geologic unit across and underlying the STP site is the Beaumont Formation,
41 which is estimated to extend to a depth of 1,400 ft (430 m). The top 125 ft (38 m) of this unit is
42 comprised of silt, sandy silt, and fine- to medium-grained sand, interbedded with clay. Clay
43 predominates below 125 ft (38 m). Lenses of moderately dense to very dense reddish-brown to
44 gray silty sand are found in the clay layers. Along the eastern boundary of the site, Holocene
45 (recent) Age alluvial age sediments, which range up to 50 ft (15 m) thick, overlie the Beaumont
46 Formation. In addition, Holocene sand, silt, and clay deposits are found in the Colorado River
47 meander belt and floodplain east of the plant site. While finer sediments (silt, clay) were

Affected Environment

1 generally deposited in low areas, sand was deposited as point bars or sheet deposits during
2 flood stages (STPNOC 2009a).

3 No geologic (tectonic) faults capable of producing earthquakes have been identified in the STP
4 region, and no unstable subsurface materials or conditions (e.g., salt domes) have been
5 identified at the plant site. The closest tectonic faults are located approximately 85 mi (140 km)
6 northwest of the STP site in association with the Ouachita geologic province. Many “growth”
7 faults have been mapped at depth in the STP site area and extensively studied through
8 geophysical data. Common across the Texas Gulf coasts, these features are thought to arise
9 from gravity-related processes associated with the consolidation, slumping, and creeping of
10 sediments during and after being deposited. At STP, nearly all of these features are confined to
11 strata at depths of at least 5,000 ft (1,520 m) BGS in Oligocene age strata comprised of the
12 massive marine shales of the Anahuac Formation. This indicates that the growth faults are at
13 least as old as the strata in which they are found (i.e., as old as 26 million years) and further
14 indicates that they are depositional and not tectonic in nature (STPNOC 2009a).

15 Soils. Soil unit mapping by the National Resources Conservation Service (NRCS) identifies the
16 natural soils across the STP main plant complex as Laewest clay, 0 to 1 percent slopes, with
17 areas of Dacosta sandy clay loam, 0 to 1 percent slopes, to the east and north of the main plant
18 complex. These units are deep (greater than 80 in. (200 cm)), moderately well drained soils,
19 which developed from clayed clayey fluviomarine deposits. Both soils are prime farmland where
20 otherwise not committed to developed uses (7 CFR 675.5). The soils have some limitations for
21 site development due to shrink-swell from high expansive clay content and a slight erosion
22 hazard (NRCS 2011).

23 Overall, the plant area excavation consisted of a large open-cut excavation covering the
24 footprint of both units to a depth of approximately 40 ft (12 m) BGS. Excavations for the two
25 reactor containment buildings (RCBs) extended deeper to nearly 70 ft (21 ft) BGS. These
26 excavations penetrated the shallow aquifer zone (see Section 2.2.5 for details), requiring
27 groundwater dewatering during construction. The excavated area was backfilled to the
28 foundation elevations and to within 18 in. (46 cm) of surface grade with clean, well-graded,
29 medium-to-coarse sand. The total amount of Category I structural backfill used for Units 1
30 and 2 was approximately 1.6 million tons (1.45 million MT) (STPNOC 2009a).

31 Seismic Setting. The central Texas Gulf coast is a region of very low historical seismicity and
32 very low seismic risk (USGS 2011a). No earthquakes have been recorded within a radius of
33 62 mi (100 km) of STP. Within a radius of 124 mi (200 km), only seven earthquakes have been
34 recorded. The closest event was a magnitude 2.7 event with an epicenter 70 mi (113 km)
35 northwest of STP (USGS 2011b).

36 Site and regional studies across the Gulf coasts have concluded that the geologic strata in
37 which the previously described growth faults are known to occur are not capable of storing
38 strain energy sufficient to produce earthquakes larger than about magnitude 4.0 or shaking
39 greater than Modified Mercalli Intensity (MMI) IV or both. Historically, earthquake activity in the
40 region attributed to growth faulting has been of magnitude 1.5 or less (microseismic). Further,
41 as reported in the applicant’s updated final safety analysis report (FSAR), no earthquakes are
42 known to have occurred or been felt at the STP site. Nevertheless, larger earthquakes have
43 occurred along the Gulf coasts. The largest historical earthquake in the Gulf coasts region
44 occurred in October 1930 near Donaldsonville, Louisiana, approximately 320 mi (515 km)
45 east-northeast of the STP site. Although not recorded on instruments, its epicenter and effects
46 were based on historical accounts. It is believed to have occurred in the upper basement rock
47 rather than in the overlying strata and produced shaking of MMI of V to VI at its epicenter
48 (STPNOC 2009a). USGS information provides an estimated magnitude of 4.2 with a

1 conservative MMI of VI for this event (USGS 2011c). Nevertheless, the 1930 Donaldsonville
2 earthquake was used as one of the bases to establish the safe shutdown earthquake (SSE) for
3 STP where an earthquake producing shaking of MMI VI at the surface was assumed to occur in
4 basement rock directly beneath the site. The maximum vibratory (peak) ground acceleration
5 (PGA) associated with an MMI VI earthquake is about 0.07 g (i.e., force of acceleration relative
6 to that of Earth's gravity, "g"). Nonetheless, because 0.07 g is below the minimum PGA value in
7 10 CFR Part 100, Appendix A, 0.10 g was adopted for the SSE (STPNOC 2009a).

8 For the purposes of comparing the SSE with a more contemporary measure of predicted
9 earthquake ground motion for the site, the NRC staff also reviewed current PGA data from the
10 U.S. Geological Survey (USGS) National Seismic Hazard Mapping Project. The PGA value
11 cited is based on a 2 percent probability of exceedance in 50 years. This corresponds to an
12 annual frequency (chance) of occurrence of about 1 in 2,500 or 4×10^{-4} per year. For STP, the
13 calculated PGA is approximately 0.03 g (USGS 2008).

14 **2.2.4 Surface Water Resources**

15 The STP site is situated on the west bank of the lower Colorado River, approximately 13 mi
16 (21 km) southwest of Bay City, Texas, and 10 mi (16 km) north of Matagorda Bay. The STP site
17 is approximately 12,200 ac (4,940 ha) in size, the majority of which is occupied by the 7,000-ac
18 (2,830-ha) MCR. This reservoir is formed by approximately 12.4 mi (20 km) of embankment
19 consisting of clay fill that is constructed above natural ground elevation. The MCR also has 7 mi
20 (11 km) of internal baffles (raised berms) to enhance the circulation of cooling water
21 (STPNOC 2010b).

22 As described in Sections 2.1.6 and 2.1.7, the MCR is part of the closed-loop cooling system for
23 the normal operations of STP, Units 1 and 2. The CWSs of STP, Units 1 and 2, discharge
24 heated water to the MCR, where rejected heat is dissipated mostly via evaporation. To
25 replenish the waters lost to evaporation, the RMPF supplies makeup water from the lower
26 Colorado River. The pumps in the RMPF are operated intermittently consistent with Colorado
27 River flow conditions, operational considerations, and permit restrictions.

28 **2.2.4.1 Surface Water Hydrology**

29 The Colorado River Basin is approximately 42,318 mi² (109,600 km²) in area (NRC 2011b).
30 STP is located at lower Colorado River Mile 14.6 upstream from Matagorda Bay. The river is
31 tidally influenced in the vicinity of the STP site, and this tidal influence extends as far as 32 mi
32 (51 km) upstream from Matagorda Bay under conditions of low flow. The extent of tidal
33 influence depends on tidal fluxes at the mouth of the river, freshwater inflow down the river, and
34 other conditions. In addition, saltwater may move as far as 24 mi (39 km) upstream of
35 Matagorda Bay, along the bottom of the Colorado River (STPNOC 2010b). The mean annual
36 discharge measured at the USGS gauge near Bay City for water years 1949 through 2010 is
37 2,620 cfs or 1.17 million gpm (74.1 m³/s) (USGS 2011d). August is the low-flow month, and
38 June is the high-flow month (NRC 2011b).

39 Texas experiences frequent droughts, primarily caused by the formation of a stationary
40 high-pressure system called the Bermuda High. Multi-year droughts have occurred in the past
41 in the Colorado River Basin; for example, annual discharges during 1951 to 1956, 1962 to 1967,
42 1983 to 1986, and 1988 to 1991 ranged from 23 to 48 percent, 21 to 79 percent, 25 to
43 72 percent, and 21 to 78 percent of the mean annual discharge, respectively (NRC 2011b). Of

Affected Environment

1 the 56 years of data reported by USGS from 1949 to 2010 water years,¹ the annual discharge
2 was less than the mean annual discharge during 26 years.

3 In the Colorado River Basin, the LCRA operates six dams that impound six Highland Lakes,
4 having a combined water storage capacity of 2.18 million ac-ft (2,690 million m³). The LCRA
5 operates the Colorado River and Lakes Buchanan and Travis as a single system for water
6 supply in the lower Colorado River Basin, including for STP (see Section 2.1.7.1). Water from
7 the lakes is released when the flow in the river is insufficient to meet downstream water rights
8 (NRC 2011b).

9 Other noteworthy surface water features at STP include Little Robbins Slough, an intermittent
10 stream, which originates approximately 2 mi (3.2 km) northwest of the STP site; it has a
11 drainage area of approximately 4 mi² (10.4 km²). During construction for Units 1 and 2, the
12 original course of Little Robbins Slough was relocated along the west portion of the MCR
13 embankment. Currently, the relocated Little Robbins Slough flows south along the west MCR
14 embankment, turns east at the southwest corner of the MCR embankment, and rejoins its
15 original course approximately 1 mi (1.6 km) east of the southwest corner of the MCR
16 embankment (NRC 2011b) (see Figure 2–1).

17 Kelly Lake is a 34-ac (14-ha) natural water body located north of the northeast edge of the MCR
18 embankment and is fed by a small catchment area to its north. The ECP, which serves as the
19 ultimate heat sink for STP, Units 1 and 2, is located east of the power block and comprises
20 another 46 ac (19 ha) of land (NRC 2011b; STPNOC 2010b).

21 **2.2.4.2 Surface Water Quality and Effluents**

22 In support of maintaining the quality of waters of the State and in establishing designated uses
23 of surface waters, TCEQ has designated the segment of the lower Colorado River
24 (Segment 1401, Colorado River Tidal), adjacent to STP, for use in primary contact recreation
25 and for high aquatic life use, as well as for general and fish consumption uses applicable to all
26 surface waters (30 TAC 1-307). The numeric water quality criteria specified for the river
27 segment include a minimum 24-hour mean dissolved oxygen at any point of 4.0 mg/L, a pH
28 range of 6.5 to 9.0 units, an indicator bacteria count of 35 colonies per 100 milliliters (mL), and a
29 maximum temperature of 95 °F (35 °C) (NRC 2011b; TCEQ 2011).

30 The lower Colorado River Authority has a water quality monitoring station on the lower Colorado
31 River at Selkirk Island, located approximately 0.7 mi (1.1 km) downstream from the STPNOC's
32 RMPF. For the period of October 1982 through November 2008, dissolved oxygen levels
33 ranged from 0 to 13.5 mg/L with an average of 6.5 mg/L, pH ranged from 6.6 to 9.8 units with an
34 average of 7.9, and water temperatures ranged from 43.5 to 92.1 °F (6.4 to 33.4 °C) with an
35 average of 72.5 °F (22.5 °C). Between 1994 and 2001, fecal coliform ranged from 0 to
36 13,000 colonies per 100 mL, with an average of 391 colonies per 100 mL (NRC 2011b).

37 Texas' draft 2010 Clean Water Act, Section 303(d), list of impaired waters proposes to continue
38 the listing of the tidal lower Colorado River as impaired by bacteria; it was first listed for bacteria
39 exceedances in 2006 (based on best available information). The other surface water bodies
40 near the STP site—including Little Robbins Slough, West Branch of the Colorado River, and
41 Kelly Lake—are not on the Section 303(d) list (NRC 2011b; TCEQ 2011).

42 Wastewater discharges from STP are governed by a TCEQ-issued TPDES permit. This is the
43 Texas equivalent of a National Pollutant Discharge Elimination System permit. STPNOC's

¹ For statistical calculations, the USGS does not use years during which data are incomplete. For calculating the annual statistics for Colorado River stream flow at Bay City, the USGS did not use water years 1996 through 2000 and 2009.

1 current TPDES permit (No. WQ0001908000) was issued by TCEQ with an effective date of
2 July 27, 2005; the permit expired on December 1, 2009. However, STPNOC submitted a permit
3 renewal application to the State on June 2, 2009, which the TCEQ accepted as administratively
4 complete on July 13, 2009. Consequently, STPNOC's TPDES permit remains valid and in
5 effect (i.e., administratively continued) until a new permit is issued (STPNOC 2011d;
6 TCEQ 2009). Regarding Water Quality Certification requirements under Section 401 of the
7 Clean Water Act, TCEQ issued a waiver to STPNOC with respect to renewal of STPNOC's
8 NRC operating licenses as STP discharges are otherwise subject to TPDES permitting
9 requirements (STPNOC 2012b).

10 The site's TPDES permit sets effluent limitations for site discharges to the Colorado River from
11 the MCR via outfall 001 including comingled recirculated cooling water, MCR blowdown,
12 stormwater, and makeup water from Colorado River. This also includes limits on several
13 "previously monitored" effluent streams or internal outfalls that discharge to the MCR and
14 identified as outfall numbers 101, 201, 401, 501, and 601. Additionally, the permit covers
15 discharges from other miscellaneous sources such as MCR relief wells, MCR spillway gate
16 leakage, and from groundwater monitoring wells that may flow to the Colorado River, to the
17 West Branch of the Colorado River, to Little Robbins Slough, and to the East Fork of Little
18 Robbins Slough, as appropriate (TCEQ 2005).

19 In addition to limitations on specific pollutants and on discharge temperature, the current
20 TPDES permit requires that the discharge from outfall 001 not exceed 12.5 percent of the flow
21 of the Colorado River at the discharge point and prohibits discharges from outfall 001 when river
22 flow adjacent to the plant is less than 800 cfs (23 m³/s). It also imposes an average daily
23 discharge flow limit of 144 million gallons per day (mgd) (585,000 m³/day) (TCEQ 2005). As
24 noted above (and previously in Section 2.1.7), the MCR is equipped with a blowdown discharge
25 pipeline to reduce the level of dissolved solids in the circulating water. While this blowdown
26 pipeline has only been used once before, it may be necessary to discharge from the MCR via
27 outfall 001 in the future to maintain proper circulating water chemistry (STPNOC 2010b).

28 The NRC staff's review of the last 3 years of TPDES discharge monitoring reports submitted by
29 STPNOC to the TCEQ revealed no exceedances of TPDES effluent limitations. Further,
30 STPNOC has not received any Notices of Violation, nonconformance notifications, or related
31 infractions associated with the site's TPDES permit or related to other water quality matters
32 within the past 5 years (STPNOC 2011e).

33 **2.2.5 Groundwater Resources**

34 **2.2.5.1 Site Description and Hydrogeology**

35 Underlying the STP site is a wedge of southeasterly dipping sedimentary deposits. Three
36 depositional environments are evident—continental (alluvial plain), transitional (delta, lagoon,
37 beach), and marine (continental shelf). As further discussed in Section 2.2.3, oscillations of the
38 ancient shoreline and other processes have resulted in overlapping mixtures of sediments.
39 Numerous local aquifers exist in the thick sequences of alternating and interfingering beds of
40 clay, silt, sand, and gravel, which yield groundwater ranging in quality from fresh to saline
41 (Ryder 1996; STPNOC 2010d).

42 The USGS identified the aquifers underlying the STP site as the Texas coastal lowlands aquifer
43 system, and it divides the aquifer system into hydrogeologic units or permeable zones A
44 through E (Ryder and Ardis 2002). Within the State of Texas, both the Texas Water
45 Development Board and the LCRA refer to the aquifer system as both the Gulf Coast Aquifer
46 system and the coastal lowlands aquifer system, and they use hydrogeologic unit names rather

Affected Environment

1 than letters to describe the aquifer system (TWDB 2006, 2007; Young et al. 2007). Common
2 hydrogeologic unit names, from shallow to deep, are as follows (STPNOC 2010d):

- 3 • Chicot Aquifer,
- 4 • Evangeline Aquifer,
- 5 • Burkeville Confining Unit,
- 6 • Jasper Aquifer,
- 7 • Catahoula Confining Unit, and
- 8 • Vicksburg–Jackson Confining Unit.

9 This SEIS adopts the naming convention used by the State of Texas. The aquifers underlying
10 the site are located in the Holocene-aged alluvium and the Pleistocene-aged Beaumont,
11 Montgomery, Bentley Formations, and Willis Sands that make up the Chicot Aquifer
12 (NRC 2011b). In descending order from the land surface, the aquifers of interest are the Upper
13 Shallow Chicot Aquifer, the Lower Shallow Chicot Aquifer, and the Deep Chicot Aquifer. The
14 Upper and Lower Shallow Chicot aquifers exhibit semi-confined behavior with some movement
15 of groundwater between them. Local to STP, Units 1 and 2, this communication between the
16 upper and lower zones is also a result of the excavation of the semi-confining material
17 separating the two zones during construction of the units. The top of the Upper Shallow Chicot
18 Aquifer is designated at approximately 15 to 30 ft (4.6 to 9.1 m) BGS, and its base is at about
19 50 ft (15 m) BGS. The Lower Shallow Chicot Aquifer lies between 50 and 150 ft (15 to 46 m)
20 BGS (NRC 2011b). The depth to groundwater within this shallow aquifer system lies at
21 approximately 15 to 20 ft (4.6 to 6.1 m) BGS (MACTEC 2009). The upper surface of the Deep
22 Chicot Aquifer is between 250 and 300 ft (76 to 91 m) BGS. The approximate depth where
23 groundwater has a total dissolved solids (TDS) concentration of more than 10,000 mg/L defines
24 the base of the Deep Chicot Aquifer. Beneath the STP site, the Chicot Aquifer thickness is
25 somewhat greater than 1,000 ft (305 m). The Upper Shallow Chicot Aquifer exhibits a
26 somewhat higher potentiometric head than the Lower Shallow Chicot Aquifer, and groundwater
27 moves from the Upper into the Lower Shallow Chicot Aquifer through the confining zone that
28 separates them. The Deep Chicot Aquifer is separated from the Lower Chicot Aquifer by 100 to
29 150 ft (30 to 46 m) of low-conductivity confining zone sediments (NRC 2011b).

30 Recharge to the Chicot Aquifers underlying the STP site occurs to the northwest of the site, and
31 discharge occurs generally to the east, south, and southeast of the site. The Shallow Chicot
32 Aquifer outcrops at the land surface, is recharged a few miles northwest of the STP site in
33 Matagorda County, and discharges to the Colorado River alluvium near the site. The Deep
34 Chicot Aquifer outcrops and is recharged farther north and northwest in Wharton County. It
35 discharges into Matagorda Bay and the Colorado River estuary approximately 5 mi (8 km)
36 southeast of the STP site. In the upland areas of the aquifer watersheds, where the aquifer
37 sediments are exposed at the land surface, infiltration from irrigation also contributes to
38 recharge of both the Shallow and Deep Chicot aquifers. The Colorado River is a gaining stream
39 where the Shallow and Deep Chicot aquifers discharge to the river (NRC 2011b). The alluvial
40 aquifer adjacent to the river also undergoes bank storage, whereby water is retained in and
41 discharged from the permeable alluvium of the river bank, with the rise and fall of the Colorado
42 River.

43 Additionally, the MCR, as described in Section 2.1.7, is unlined and acts as a local recharge
44 source for the Upper Shallow Chicot Aquifer. A series of 770 relief wells surround the MCR
45 embankment and collect and discharge some of the seepage from the MCR and otherwise
46 relieve hydrostatic pressure on the outer slope and toe of the embankment. Analyses

1 presented in the updated FSAR for STP, Units 1 and 2 (STPNOC 2009a), estimate total
2 seepage from the MCR into the Upper Shallow Chicot Aquifer at 3,530 gpm or 5,700 ac-ft/yr
3 (7 million m³/yr). These analyses also estimate that 68 percent of the seepage (2,390 gpm or
4 3,850 ac-ft/yr (4.7 million m³/yr)) from the MCR would be captured by the relief well system for
5 an MCR maximum pool elevation of 49 ft (14.9 m) above MSL. More recent simulations of the
6 MCR indicate approximately 50 percent capture (NRC 2011b).

7 Groundwater quality and aquifer yields dictate that the Deep Chicot Aquifer is the primary
8 source of groundwater in the region. STP wells completed in the Deep Chicot Aquifer and used
9 for groundwater production at the site are described in Section 2.1.7.2 (see also Figure 2-1).
10 The nearest offsite public water supply wells are located in the communities of Selkirk and
11 Exotic Isle, which are located adjacent to the STP site eastern boundary. Wells for these
12 communities are approximately 1 mi (1.6 km) from the nearest STP production well, Well 7, and
13 3.75 mi (6 km) from STP, Units 1 and 2 (see Figure 2-1). Two non-public water supply wells
14 used for livestock watering are located about 1,800 ft (549 m) north of STP Well 5 and 2,230 ft
15 (680 m) west of STP Well 6. They are completed to depths of 500 and 400 ft (152 and 122 m)
16 and have screened intervals of 200 to 300 ft (61 to 91 m), respectively, above the screened
17 intervals of the STP production wells (STPNOC 2010b).

18 Groundwater use from the Gulf Coast Aquifer system increased between 1940 and the
19 mid-1980s. One cause was rice irrigation, and Matagorda County was among the counties
20 where this occurred. As a result of subsidence issues and substantial increases in pumping lift,
21 groundwater use has declined in the region. The Texas Water Development Board forecasts a
22 decline in groundwater use from the Gulf Coast Aquifer through 2030. Matagorda County is
23 projected to see a net decrease of 48 percent, with pumping decreasing from 21,528 gpm
24 (81,490 L/min) or 31 mgd in 1985 to 11,111 gpm (42,060 L/min) or 16 mgd in 2030 (Ryder and
25 Ardis 2002). Decreased usage, consistent with this estimate, occurred through the year 2000;
26 however, drought periods since then have resulted in an increase in groundwater usage.

27 Established under Texas State law (Water Code, Title 2, Subtitle E, Chapter 36), the Coastal
28 Plains Groundwater Conservation District (CPGCD), which has the same boundaries as
29 Matagorda County, has the authority and responsibility to define the modeled available
30 groundwater in the district, to define the amount of groundwater being used in the district, and to
31 issue permits based on the available groundwater resource. The NRC staff interviewed the
32 manager of the CPGCD in July 2011 and learned that the current modeled available
33 groundwater in the district (i.e., Matagorda County) is 46,000 ac-ft (57 million m³) annually or
34 28,522 gpm (107,970 L/min), and the current usage is 36,000 ac-ft (44 million m³) or
35 22,322 gpm (84,500 L/min). Annual permitted groundwater withdrawals for the period 2008
36 through 2010 (i.e., permits are issued for a 3-year period) were 51,285 ac-ft/yr (63.2 million m³)
37 or 31,800 gpm (120,400 L/min) (NRC 2011b). Groundwater use in the largely agricultural
38 region encompassing STP fluctuates with the availability of surface water (e.g., with the
39 occurrence of drought). Thus, annual permits that total in excess of the modeled available
40 groundwater, an annual average value, is not unexpected. As presented in Section 2.1.7.2,
41 annual average groundwater use by STP, Units 1 and 2 (i.e., 768 gpm), represents
42 approximately 2.7 percent of the modeled available groundwater quantity in Matagorda County
43 and 3.4 percent of current usage.

44 **2.2.5.2 Groundwater Quality**

45 The Shallow Chicot Aquifer exhibits poor water quality and low productivity, and it is used in the
46 vicinity of the STP site primarily for livestock watering. However, occasional domestic use is not
47 precluded. Of 12 wells completed in the Shallow Chicot Aquifer within 10 mi (16 km) of the STP

Affected Environment

1 site, 9 wells have TDS concentrations above the EPA secondary drinking water standard (DWS)
2 of 500 mg/L (STPNOC 2010b).

3 As noted above, the MCR is unlined and acts as a local recharge source for the Upper Shallow
4 Chicot Aquifer. Therefore, locally to the STP site, the MCR also influences the groundwater
5 quality of the Upper Shallow Chicot Aquifer. A maximum tritium concentration of
6 17,410 picocuries per liter (pCi/L) was reported for MCR waters in 1996 (STPNOC 2010b).

7 While 50 to 68 percent of the MCR seepage into the aquifer is estimated to be removed by the
8 series of 770 relief wells surrounding the MCR embankment, the remainder of the MCR waters
9 seep into the aquifer, migrate downgradient, and discharge to the Colorado River southeast of
10 the STP site. Monitoring of relief wells and monitoring wells around the MCR has shown that
11 tritium from the MCR arrived at relief wells approximately 2 years after plant startup in 1988. It
12 arrived at monitoring wells south of the MCR (wells MW-235 and MW-251) in 1999 and 2000
13 and at monitoring wells west of the MCR (wells MW-258 and MW-259) in 2006
14 (STPNOC 2007, 2011a). Since its first detection, the concentration of tritium in relief wells
15 increased to a peak of approximately 7,500 pCi/L in 1999 and now varies between 5,000 and
16 6,000 pCi/L. Since its first detection in 2000, the concentration of tritium in MW-251, which is
17 located south of the MCR, peaked in 2001 and then declined somewhat, remaining close to the
18 concentrations in the relief wells since then (i.e., 5,000 to 6,000 pCi/L). Since its first detection
19 in 2006, the concentration of tritium in monitoring wells west of the MCR has increased, peaked,
20 and remained steady since 2009 at around 2,500 pCi/L. Monitoring wells to the west of the
21 MCR include wells slightly beyond the site boundary, which were observed by the NRC staff
22 during the site audit. These wells are showing tritium levels consistent with those inside the site
23 boundary. Sampling stations south of the MCR and on private property (MW-245 and MW-269)
24 showed no detectable tritium in 2009 (STPNOC 2010a). All observed values for tritium are
25 below the EPA primary DWS of 20,000 pCi/L (40 CFR Part 141).

26 The 2006 annual environmental operating report (STPNOC 2007) presents information
27 generated from sampling 18 groundwater wells outside the STP, Units 1 and 2, protected area
28 and from sampling 16 groundwater wells within the STP, Units 1 and 2, protected area.
29 Sampling of wells within the protected area resulted from STPNOC's participation in the Nuclear
30 Energy Institute's (NEI's) Groundwater Protection Initiative. During site characterization for
31 STPNOC's application for proposed Units 3 and 4, 28 groundwater observation wells were
32 installed in 2006, and an additional 26 observation wells were installed in 2008
33 (STPNOC 2010d). Since 2006, additional wells have been installed and added to the
34 Environmental Monitoring Program to further characterize plumes within the protected area and
35 originating from the MCR. For example, during 2008, three additional wells were installed in the
36 protected area, and two additional wells were installed outside the protected area.

37 In 2006, sampling of wells completed in the Shallow Chicot Aquifer within the protected area
38 provided eight positive results for tritium, all below the EPA primary DWS of 20,000 pCi/L
39 (40 CFR Part 141). Eight wells had no detectable tritium. The results were attributed to
40 seepage of MCR water into the Shallow Chicot Aquifer and underground pipe failures within the
41 protected area. Two of these wells showed relatively higher values of tritium at 15,000 pCi/L
42 and 1,250 pCi/L (STPNOC 2007). Tritium concentrations in the location of the high value in
43 2006 decreased to 1,500 pCi/L by 2010. Individual wells exhibiting lower concentrations have
44 shown trends upward over individual years and over the period from 2005 through 2010.
45 However, well sampling within the protected area through 2010 (STPNOC 2011a) continues to
46 show concentrations well below the EPA DWS for tritium.

47 In response to the NEI initiative, STPNOC commissioned a report on the groundwater within the
48 protected area (MACTEC 2009). Three sources of tritium in groundwater beneath the protected

1 area were identified: (1) seepage from the MCR, (2) leaks from the TDS pipeline, and
2 (3) discharge from the turbine steam trap drain or steam condensate lines of each reactor. The
3 first potential source is limited in concentration to the tritium levels in the MCR and subsequent
4 decay in the groundwater pathway from the reservoir. The second source is described as
5 having a maximum tritium concentration of 80,000 pCi/L (MACTEC 2009). The third source is
6 described as having a maximum tritium concentration of less than 90,000 pCi/L
7 (STPNOC 2011d). Within the protected area, the highest tritium concentration in groundwater
8 was approximately 15,000 pCi/L in 2006 (STPNOC 2010b). The highest tritium concentration in
9 the tendon galleries that circle the RCBs was less than 20,000 pCi/L in 2010 (STPNOC 2011d).
10 The latter measurement may be indicative of tritium concentrations in groundwater resulting
11 from discharge from the steam condensate lines. STPNOC has evaluated releases inside the
12 protected area and concluded that no release is occurring from an unidentified pathway, no
13 radioactive material is being released off site, and there is no impact on drinking water or on
14 public health and safety (STPNOC 2011a).

15 The monitoring program has observed tritium in the shallow aquifer for several years in wells to
16 the south of the MCR. The tritium movement is consistent with simulations conducted during
17 licensing of STP, Units 1 and 2, and shows concentrations below the EPA DWS. In 2010, the
18 monitoring program (STPNOC 2011a) results indicated stable tritium concentrations in
19 groundwater wells surrounding the MCR. Higher levels reported in recent years are consistent
20 with drought conditions and low MCR water levels. From the latest STP groundwater
21 monitoring data, the peak groundwater tritium concentration in 2010 was 6,600 pCi/L—well
22 below the EPA DWS of 20,000 pCi/L (STPNOC 2011b).

23 Based on groundwater data from 2006 through 2008 presented in the FSAR for proposed STP,
24 Units 3 and 4 (STPNOC 2010c), the piezometer head gradient from the existing STP, Units 1
25 and 2, to the site boundary to the east is approximately 3 ft (0.9 m), and the distance is
26 approximately 1 mi (1.6 km) (5,280 ft or 1,609 m). Representative values for saturated
27 hydraulic conductivity and effective porosity of the lower shallow aquifer are 72 ft/day (22 m/day)
28 and 0.31, respectively. The lower shallow aquifer is the more likely pathway for releases in the
29 vicinity of the RCBs to offsite receptors (see Section 2.2.5.1) (NRC 2011b). Using these data,
30 the travel time from STP, Units 1 and 2, to the site boundary is approximately 100 years. Such
31 a travel time within the shallow aquifer presents adequate time for tritium source concentrations
32 to decay (i.e., tritium has a 12.3 year half-life) to levels below the EPA DWS.

33 **2.2.6 Aquatic Resources**

34 **2.2.6.1 Colorado River and Matagorda Bay**

35 The Colorado River extends approximately 862 mi (1,387 km) from the high plains to the coastal
36 marshes in Matagorda County. It is one of the largest river systems within the State of Texas.
37 The drainage area for the lower Colorado River basin includes approximately 22,700 mi²
38 (58,792 km²), from Lake O.H. Ivie in Mills County, Texas, to Matagorda Bay (TWDB 2007).

39 STP is located in the Texas coastal plain physiographic province. The section of the Colorado
40 River near STP is a diverse, fluvial system that meanders through the coastal plain providing
41 sediments and nutrients to Matagorda Bay (ENSR 2008c). The river in this area is generally
42 surrounded by steep banks. Little vegetation can grow on the steep banks, but some
43 bottomland forests and wetlands occur on land adjacent to the river (ENSR 2008c).

44 The Colorado River is tidally influenced near STP, which means that saltwater from Matagorda
45 Bay and the Gulf of Mexico regularly flows upstream and mixes with freshwater from the river.
46 During periods of low flow, the salinity can reach as high as 20 parts per thousand (ppt) near
47 STP (ENSR 2008c). Flow from the gulf and bay influences the aquatic community near STP by

Affected Environment

1 transporting organisms and increasing the salinity in the river. The distribution and density of
2 aquatic plants and animals living in tidally influenced rivers is often determined by salinity
3 concentrations.

4 Environmental History. Freshwater flow between the Colorado River and Matagorda Bay has
5 important ecological implications. Flow from the Colorado River can increase the biological
6 productivity within Matagorda Bay by providing freshwater, soil, and debris, which can facilitate
7 the growth of marsh habitats. Saltwater flow from the bay to the river can influence the species
8 distribution and diversity within the river by transporting organisms up the river and providing
9 habitat (e.g., higher salinity) for estuarine and marine organisms.

10 Various development projects have influenced the flow between the Colorado River and
11 Matagorda Bay in the past 100 years. Prior to the 1920s, the Colorado River flowed directly into
12 Matagorda Bay. In an attempt to control flooding, the U.S. Army Corps of Engineers (USACE)
13 dredged a channel down the middle of Matagorda Bay (Holtcamp 2006). The USACE lined the
14 channel with the dredged mud, which divided the bay into an eastern and western portion. As a
15 result of the lined channel, the water from the Colorado River then flowed directly into the Gulf
16 of Mexico (ENSR 2008c).

17 Dredging projects in the 1950s and 1990s reestablished flow between the Colorado River and
18 Matagorda Bay. In the 1950s, the USACE dredged the Tiger Island Channel through the west
19 side of Matagorda Bay, re-establishing flow between the river and the bay. In part because of
20 ecological importance for freshwater to reach the bay, the USACE conducted a series of
21 dredging projects to increase the flow from the river to the bay in the 1990s (Holtcamp 2006). In
22 1990, the USACE constructed a deeper river diversion channel northwest of the Tiger Island
23 Channel. In 1991, the USACE constructed two dams to divert the river flow, including one
24 across the Tiger Island Channel (called the Tiger Island Cut Dam, recently renamed to Parker's
25 Cut) and a diversion dam across the river channel on Matagorda Peninsula. By July 1992, the
26 Colorado River flowed directly into Matagorda Bay, through the Gulf Intracoastal Waterway
27 (GIWW) and the newly constructed diversion channel. Wilber and Bass (1998) determined that
28 the changes in freshwater inflow to Matagorda Bay over time, and the changes to flow from the
29 Gulf of Mexico into the Colorado River, have likely influenced the aquatic communities
30 historically in the river and bay.

31 Common Taxa. The most comprehensive studies of the aquatic community within the lower
32 Colorado River near STP are studies conducted as part of the licensing processes for STP,
33 Units 1, 2, 3, and 4. Below is a brief summary of the aquatic surveys conducted near STP.
34 Although the owner of the STP site has changed over time, the owner is referred to as STPNOC
35 for simplicity purposes below.

- 36 • 1973 to 1974: STPNOC sampled phytoplankton (microscopic floating
37 photosynthetic organisms), zooplankton (small animals that float, drift, or
38 weakly swim in the water column, including fish and invertebrate eggs and
39 larvae), juvenile and adult macroinvertebrates (invertebrates visible without a
40 microscope), and juvenile and adult fish (HPLC 1974). NRC (1975)
41 summarized these results in the final environmental statement for the
42 construction of STP, Units 1 and 2.
- 43 • 1975 to 1976 and 1983 to 1984: Due to the usually wet conditions during the
44 1973 to 1974 surveys, STPNOC conducted additional fish surveys in the
45 Colorado River in 1975 to 1976 and 1983 to 1984 (McAden 1984, 1985).
46 NRC (1986) summarized these results in the final environmental statement
47 for the operation of STP, Units 1 and 2.

- 2007 to 2008: In support of STPNOC's application to build and operate STP, Units 3 and 4, STPNOC sampled macroinvertebrates and fish within the Colorado River near STP (ENSR 2008c; STPNOC 2011d). NRC (2011b) summarized these results in its final EIS for the proposed construction and operation of STP, Units 3 and 4.

Since the Colorado River diversion project, which increased the flow between the Colorado River and Matagorda Bay, species diversity and the number of estuarine-marine species increased in the Colorado River near STP (NRC 2011b). Because of this change, the summary of aquatic organisms focuses on the most current studies. An analysis of the change in the aquatic community since the beginning of STP operations is provided in Section 4.5.2.

Phytoplankton: Phytoplankton are microscopic floating photosynthetic organisms that form the basis of the food chain. Phytoplankton play key ecosystem roles in the distribution, transfer, and recycling of nutrients and minerals. STPNOC most recently surveyed the phytoplankton community in the summer of 1973 in the lower Colorado River and an adjacent stretch of GIWW. STPNOC collected 524 taxa, representing six major divisions (NRC 1975, 2011b). Diatoms and cyanobacteria (blue-green algae) dominated the phytoplankton community. Diatoms were more numerous at the bottom-water samples, and cyanobacteria and dinoflagellates were predominant in the water column.

Zooplankton: Zooplankton are small animals that float, drift, or weakly swim in the water column. Zooplankton include, among other forms, fish eggs and larvae with limited swimming ability, larvae of benthic invertebrates, medusoid forms of hydrozoans, copepods, shrimp, and krill (order Euphausiids).

STPNOC surveyed the lower Colorado River and an adjacent stretch of GIWW in 1973 to 1974 for macrozooplankton (HPLC 1974). STPNOC collected 319 zooplankton species, which included protozoans (101 species), rotifers (75 species), copepods (31 species), and cladocerans (27 species) (NRC 1975). The survey showed that the zooplankton community structure changed based on salinity, such that during periods of higher salinity (e.g., low river flow and strong incoming tides), species diversity increased at upstream stations.

STPNOC most recently surveyed macrozooplankton in 1975 to 1976 and 1983 to 1984 at five stations in the lower Colorado River (Figure 2–2). The abundance and occurrence of invertebrate eggs and larvae were greatest downstream (Station 5); these decreased in fresher water upstream (NRC 1986). In the 1975 to 1976 samples, both freshwater and estuarine-marine decapod larvae dominated the macrozooplankton community from May to September, and estuarine-marine decapod larvae dominated the community from October to December (NRC 1986). The abundance and diversity of decapod larvae were lowest from January through April, when the copepod *Acartia tonsa* was most prevalent (NRC 1986). In 1983, the most abundant macrozooplankton were cladocerans, Malacostraca species, and copepods (NRC 1986). In 1984, the most abundant macrozooplankton were immature stages of the Harris mud crab (*Rhithropanopeus harrissi*), ghost shrimp (*Callinassa* spp.), and jellyfish (family Cnidaria) (NRC 1986).

STPNOC also collected commercially important species, including early life stages of blue crab (*Callinectes sapidus*), white shrimp (*Litopenaeus setiferus*), and brown shrimp (*Farfantepenaeus aztecus*, formerly known as *Penaeus aztecus*). In general, the density of these species was greatest in higher salinity water (e.g., in the salt wedge or further downstream), and lower densities occurred near the STP site (NRC 1975, 1986).

STPNOC most recently collected ichthyoplankton (fish eggs and larvae) in 1975 to 1976 and 1983 to 1984 at five stations in the lower Colorado River (Figure 2–2). NRC (1986) reported the

Affected Environment


1 highest densities of ichthyoplankton from May to October 1975 and March to April 1976.
2 Densities of ichthyoplankton was highest in higher salinity waters (NRC 1986). The most
3 common species were often estuarine or marine species, such as Gulf menhaden (*Brevoortia*
4 *patronus*), bay anchovy (*Anchoa mitchelli*), Atlantic croaker (*Micropogonia undulatus*), and
5 naked goby (*Gobiosoma bosc*) (NRC 1986). In early May and August, when the salinity
6 dropped in the Colorado River, the abundance of ichthyoplankton shifted to freshwater drum
7 (*Aplodinotus grunniens*) and cyprinid species (NRC 1986). At the sampling station next to the
8 RMPF, STPNOC collected three species (bay anchovy, darter goby (*Ctenogobius boleosoma*),
9 and naked goby), which were three of the most commonly collected species in the survey along
10 the lower Colorado River.

11 Survey results suggest that the lower Colorado River near STP is an estuarine nursery ground
12 for many commercially important species including Gulf menhaden, Atlantic croaker, sand
13 seatrout (*Cynoscion arenarius*), spotted seatrout (*C. nebulosus*), spot croaker (*Leiostomus*
14 *xanthurus*, also called spot), sheepshead (*Archosargus probatocephalus*), pigfish (*Orthopristis*
15 *chrysopterus*), black drum (*Pogonias cromis*), red drum (*Sciaenops ocellatus*), and southern
16 flounder (*Paralichthys dentatus*) (NRC 1986).

17 *Adult and Juvenile Macroinvertebrates:* STPNOC sampled adult and juvenile
18 macroinvertebrates in 1975 to 1976 at eight sampling stations in the Colorado River
19 (Figure 2–2). In 1983 to 1984, STPNOC sampled at Station 2, which is closest to the RMPF
20 (Figure 2–2). In 2007 to 2008, STPNOC sampled along a 9-mi (14-km) stretch of the lower
21 Colorado River extending from the GIWW north to the FM 521 bridge (Figure 2–3 and
22 Figure 2–4). Within this portion of the river, STPNOC divided the area into three 3-mi (5-km)
23 segments and randomly sampled each segment monthly from June 2007 through May 2008.
24 Within each month, STPNOC collected samples during a 2-day period randomly selected each
25 month. STPNOC collected samples if the river flow was 5,000 cfs or less to reduce variability in
26 sampling conditions.

1
2

Figure 2–2. The STP Site and 1975 to 1976 Aquatic Ecology Sampling Location (NRC 2011b)




3

Affected Environment

1
2
3


Figure 2-3. The STP Site and 2007 to 2008 Aquatic Ecology Sampling Locations from Segment C through the Upstream Portion of Segment B (NRC 2011b)



4

1
2
3

Figure 2-4. The STP Site and 2007 to 2008 Aquatic Ecology Sampling Locations from the Downstream Portion of Segment B through Segment A (NRC 2011b)



Affected Environment

1 All studies used seines and trawls to sample macroinvertebrates. In 2007 to 2008, STPNOC
2 also used gill nets and hoop nets primarily to capture fish (ENSR 2008c). However, STPNOC
3 collected a few macroinvertebrates in gill nets and hoop nets; therefore, the methodology and
4 results of these sampling programs is presented below. ENSR (2008c) used the four different
5 types of gear to capture a variety of taxa in terms of size (or life stage) and habitat location
6 (e.g., open water vs. benthic). The information below describes the sampling gear used in the
7 2007 to 2008 study within each of the three sampling segments (segments A, B, and C)
8 (Figure 2–3 and Figure 2–4):

- 9 • Trawls: STPNOC conducted two tows, each for 10 minutes, with a 6.1-m
10 (20-ft) otter trawl fitted with a 3.5-cm (1.4-in.) stretched mesh and doors
11 (i.e., otter boards) measuring 46 cm by 91 cm (18 in. by 36 in.) attached to
12 each wing of the net. The trawl was designed to capture benthic or demersal
13 fishes and macroinvertebrates.
- 14 • Gill nets: STPNOC set one gill net perpendicular to the shoreline. It set the
15 net within 1 hour of sunset and retrieved it at sunrise the following morning.
16 The gill net was 33-m (108-ft) long, 1.2-m (3.9-ft) deep, and consisted of
17 10.2-cm (4-in.) stretched monofilament mesh. It was designed to capture
18 adult fish using shoreline habitats.
- 19 • Hoop nets: STPNOC placed one set of hoop nets within 1 hour of sunset and
20 retrieved them at sunrise the following morning. Hoop nets consisted of a
21 multi-chambered conical net that was 3.6-m (12-ft) long with one 1-m (3-ft)
22 diameter hoop at the beginning, followed by smaller hoops, and covered with
23 2.5-cm (1-in.) stretched mesh netting. Each hoop net had wings that were
24 7.5-m (25-ft) long by 1.8-m (5.9-ft) deep and comprised of 5-cm (2-in.)
25 stretched mesh. Hoop nets were designed to capture sub-adult fish using
26 shoreline habitats.
- 27 • Seines: STPNOC conducted two seine pulls per month for 15.2 m (50 ft)
28 parallel to the shoreline. Seines were comprised of a 19-mm (0.75-in.) mesh
29 net that measured 18.3-m (60-ft) long and 1.8-m (6-ft) deep. In the center
30 was a 1.8 m (6 ft) by 1.8 m (6 ft) by 1.8 m (6 ft) bag that was covered in
31 13-mm (0.5-in.) stretched mesh. Seines were designed to capture
32 macroinvertebrates and juvenile and sub-adult fishes using shoreline
33 habitats.

34 The most abundant invertebrate species in the 1975 to 1976 and 1983 to 1984 studies were
35 river and white shrimp (McAden et al. 1984, NRC 1986). At Station 1, the most upriver station
36 near STP, brown shrimp was the most abundant species in trawl samples, and blue crabs were
37 the most abundant species in seine samples (NRC 2011b). At Station 2, which is closest to the
38 RMPF, STPNOC collected river shrimp, white shrimp, blue crabs, and crayfish (NRC 1986).

39 In the 2007 to 2008 study, ENSR (2008c) reported the most common species to be white
40 shrimp (30 percent), grass shrimp (*Palaemonetes pugio*) (29 percent), brown shrimp
41 (7 percent), and blue crab (4 percent) (Table 2–1). ENSR (2008c) collected macroinvertebrates
42 most often in the river segment with the highest salinity (segment A) and least often in the river
43 segment with the lowest salinity (segment C) (Figure 2–3 and Figure 2–4). ENSR (2008c)
44 reported the greatest density of macroinvertebrates and fish during the following periods:

- 45 • Trawls: October through January,
- 46 • Gill Nets: September through December and March through May,

- 1 • Hoop Nets: October through February and April through June, and
- 2 • Seines: January through April.

3 Brown, pink (*Farfantepenaeus brasiliensis*), and white shrimp are of commercial importance in
 4 the vicinity of the STP site (TPWD 2002; USACE 2007). STPNOC observed various life stages
 5 of brown and white shrimp in all three studies (NRC 1986; STPNOC 2008c). STPNOC only
 6 observed pink shrimp during the 1984 to 1985 studies (NRC 1986).

7 **Table 2–1. Macroinvertebrates Collected in the Colorado River**
 8 **by Gear Type, 2007 to 2008**

Common Name	Scientific Name	Seine	Gill Net	Hoop Net	Trawl	Total	% of Total
Atlantic brief squid	<i>Lolliguncula brevis</i>	1	0	0	30	31	<1
Atlantic seabob	<i>Xiphopenaeus kroyeri</i>	0	0	0	127	127	2
Blue crab	<i>Callinectes sapidus</i>	190	2	3	77	272	4
Brown shrimp	<i>Farfantepenaeus aztecus</i>	264	0	0	192	456	7
Grass shrimp	<i>Palaemonetes pugio</i>	1,762	0	0		1,762	29
white shrimp	<i>Litopenaeus setiferus</i>	584	0	0	2,870	3,454	30
Other		11	0	1	12	24	<1
Total invertebrates		2,812	2	4	3,308	6,126	

Source: ENSR 2008c

9 **Adult and Juvenile Fish:** STPNOC sampled adult and juvenile fish in 1975 to 1976 at eight
 10 sampling stations in the Colorado River (Figure 2–3). In 1983 to 1984, STPNOC sampled at
 11 Station 2, which is closest to the RMPF (Figure 2–3). In 2007 to 2008, STPNOC sampled along
 12 a 9-mi (14-km) stretch of the lower Colorado River extending from the GIWW north to the
 13 FM 521 bridge (Figure 2–3 and Figure 2–4). All studies used seines and trawls to sample fish.
 14 In 2007 to 2008, STPNOC also used gill nets, hoop nets, and trawls (ENSR 2008c).
 15 ENSR (2008c) followed the same methodology described above for the macroinvertebrate
 16 sampling.

17 The most abundant fish species in the 1974 to 1975 study were Gulf menhaden, bay anchovy,
 18 Atlantic croaker, and striped mullet (*Mugil cephalus*) (NRC 1986). All of these species, except
 19 for menhaden, were most abundant at sampling stations furthest down the river (NRC 1986).
 20 Similarly, STPNOC only collected many of the commercially important estuarine species
 21 (e.g., red drum and southern flounder) at the most downstream station, Station 5. The density
 22 of menhaden, on the other hand, was greatest at the most upstream station, Station 1.

23 In the 2007 to 2008 study, STPNOC (2008c) reported the most common species to be Gulf
 24 menhaden (35 percent), striped mullet (14 percent), black drum (*Pogonia cromis*) (12 percent),
 25 and Atlantic croaker (9 percent) (Table 2–2). All other species comprised 3 percent or less of
 26 the total fish collected. ENSR (2008c) collected fish most often in the river segments with the
 27 highest salinity (segments A and B) and least often in the river segment with the lowest salinity
 28 (segment C) (Figure 2–3 and Figure 2–4).

Affected Environment

1 **Table 2–2. Fish Collected in the Colorado River by Gear Type, 2007 to 2008**

Common Name	Scientific Name	Seine	Gill Net	Hoop Net	Trawl	Total	% of Total
Atlantic croaker	<i>Micropogonias undulatus</i>	562	1	0	482	1,045	9
Bay anchovy	<i>Anchoa mitchilli</i>	24	0	0	264	288	2
Black drum	<i>Pogonias cromis</i>	1	1	1	1,360	1,363	12
Blue catfish	<i>Ictalurus furcatus</i>	51	22	3	677	753	6
Channel catfish	<i>Ictalurus punctatus</i>	22	0	2	6	30	<1
Gafftopsail catfish	<i>Bagre marinus</i>	0	9	0	183	192	2
Gizzard shad	<i>Dorosoma cepedianum</i>	8	0	2	52	62	<1
Gulf menhaden	<i>Brevoortia patronus</i>	2,960	5	2	1,076	4,043	35
Hardhead catfish	<i>Ariopsis felis</i>	0	1	1	252	254	2
Red drum	<i>Sciaenops ocellatus</i>	8	8	38	25	79	<1
Sailfin molly	<i>Poecilia latipinna</i>	150	0	0	0	150	1
Sand seatrout	<i>Cynoscion arenarius</i>	22	5	0	294	321	3
Sharptail goby	<i>Oligolepis acutipennis</i>	39	0	0	0	39	<1
Sheepshead	<i>Archosargus probatocephalus</i>	14	1	6	48	69	<1
Sheepshead minnow	<i>Cyprinodon variegatus</i>	79	0	0	7	86	<1
Silver perch	<i>Bairdiella chrysoura</i>	0	0	0	350	350	3
Smallmouth buffalo	<i>Ictiobus bubalus</i>	0	32	5	0	37	<1
Spot croaker	<i>Leiostomus xanthurus</i>	88	0	1	156	245	2
Spotted seatrout	<i>Cynoscion nebulosus</i>	0	4	0	53	57	<1
Star drum	<i>Stellifer lanceolatus</i>	0	0	0	86	86	<1
Striped mullet	<i>Mugil cephalus</i>	1,676	0	1	1	1,678	14
White mullet	<i>Mugil curema</i>	181	0	0	2	183	2
Other		109	15	33	78	235	2
Total Fish		5,994	104	95	5,452	11,645	

Source: ENSR 2008c

2 *Species Richness:* In the 2007 to 2008 studies, ENSR (2008c) calculated the species richness,
3 or number of fish and macroinvertebrate species collected, within each river segment and for
4 each type of sampling gear. ENSR (2008c) reported the highest species richness in the river
5 segment with the highest salinity (segment A) for trawl, seine, and gill net samples (Table 2–3).
6 The species richness was similar across all three-river segments for hoop net samples
7 (Table 2–3).

1 **Table 2–3. Species Richness (number of species) in Three River Segments by Gear Type**

Gear Type	River Segment		
	A	B	C
Trawl	37	29	24
Seine	38	35	22
Gill nets	14	12	9
Hoop nets	11	12	12

Source: ENSR 2008c

2 STPNOC's studies in the 1970s and 1980s also found greater species diversity and density
3 further downstream in higher salinity waters (NRC 1975, 1986). NRC (1975) attributed the
4 lower density and diversity near the STP site to the relatively large and frequent fluctuations in
5 salinity. Downstream areas, on the other hand, exhibit relatively stable salinity, which allows for
6 the establishment of a variety of estuarine and marine species assemblages.

7 **2.2.6.2 Onsite aquatic features**

8 STP is located approximately 23 ft (7 m) above MSL on a site with relatively flat topography.
9 Water covers approximately 58 percent of the 12,220 ac (4,945 ha) STP site (STPNOC 2010b).
10 The onsite aquatic features include the MCR, the ECP, several sloughs, drainage areas,
11 wetlands, and Kelly Lake.

12 Construction activities for STP, Units 1 and 2, extensively altered several aquatic features on
13 the STP site. For example, during the building of the MCR, STPNOC removed up to 65 percent
14 of the drainage area for Little Robbins Slough in the southern part of the site (NRC 1975).
15 STPNOC also created a new channel for the slough, which is the same as the current
16 configuration (NRC 2011b). The reconfiguration of Little Robbins Slough reduced the annual
17 freshwater runoff into onsite marshes and marshes south of the STP site. Reduced flow can
18 displace freshwater species and reduce the quality of nursery grounds for estuarine-dependent
19 organisms (NRC 1975). As a result of seepage flow from the MCR into the slough, NRC (1986)
20 estimated the total long-term average annual reduction of freshwater input into the marshes to
21 be 6 percent. NRC (1986) concluded that, at this rate, the reduction in flow of freshwater from
22 the slough into the marshes, and any subsequent changes in salinity or nutrient input, were not
23 expected to alter the structure and function of the upper marsh aquatic community (NRC 1986).

24 Below is a description of the main aquatic features currently located on the STP site.

25 Main Cooling Reservoir. The MCR is a 7,000-ac (2,833-ha), man-made impoundment that is
26 the normal heat sink for waste heat generated during operations of STP, Units 1 and 2.
27 STPNOC maintains the water level and quality (e.g., total dissolved solids) in the MCR by
28 pumping water from the Colorado River through the RMPF, as described in Section 2.1.6. A
29 variety of aquatic organisms currently inhabit the MCR (ENSR 2008a; STPNOC 2010b).
30 Aquatic organisms were likely introduced into the MCR when small life stages (e.g., eggs or
31 larvae) or species were entrained during the initial filling and subsequent refilling of the MCR.

32 ENSR (2008a) collected samples of the aquatic community within the MCR four times a year
33 from May 2007 through April 2008. ENSR (2008a) sampled the aquatic community at fixed
34 stations within five regions of the MCR. Each region was varying distance from the cooling
35 water discharge and CWIS. ENSR (2008a) used four different types of gear to capture a variety
36 of taxa in terms of size (or life stage) and habitat location (e.g., open water vs. benthic).
37 ENSR (2008a) used the following gear types within each region that was sampled:

Affected Environment

- 1 • Trawls: STPNOC conducted five tows, each for 10 minutes, with a 6.1-m
2 (20-ft) otter trawl fitted with a 3.5-cm (1.4-in.) stretched mesh and doors
3 (i.e., otter boards) measuring 46 cm by 91 cm (18 in. by 36 in.) attached to
4 each wing of the net. The trawl was designed to capture benthic or demersal
5 fishes and macroinvertebrates.
- 6 • Gill nets: STPNOC set three gill nets within 1 hour of sunset and retrieved
7 them at sunrise the following morning. Gill nets were 91.4-m (300-ft) long,
8 3.0-m (10-ft) deep, and consisted of four separate panels measuring
9 approximately 22.9-m (75-ft) in length and comprised of 2.5, 5.1, 7.6, and
10 10.2-cm (1, 2, 3, and 4-in.) stretched mesh connected in ascending order.
11 The grill nets were designed to capture adult fish using open water surface
12 habitats.
- 13 • Seines: STPNOC conducted one seine pull per sampling event. Seines
14 were comprised of 6.4-mm (0.25-in.) mesh net and measured 30.5-m (100-ft)
15 long and 3.0-m (10-ft) deep. Seines were designed to capture small
16 macroinvertebrates and fish using shoreline habitats.
- 17 • Plankton nets: STPNOC conducted three oblique plankton tows through all
18 depths of water per sampling event. It used a low speed Henson plankton
19 net with a with a dimension of 30-cm (12-in.) mouth width by 120-cm (47-in.)
20 length and covered with mesh size of 0.363 mm (0.014 in.). Plankton nets
21 were designed to capture pelagic ichthyoplankton, invertebrate larvae, and
22 small invertebrates.

23 ENSR (2008a) collected 11,605 fish and invertebrates using gill nets, seines, and trawls (Table
24 2–4). ENSR (2008a) identified 25 species of fish and invertebrates. Threadfin shad (*Dorosoma*
25 *petenense*) was the most commonly collected species, representing 62 percent of all fish and
26 invertebrates collected using gill nets, seine pulls, or trawls. Other commonly collected species
27 include inland silverside (*Menidia beryllina*) (18 percent), rough silverside (*Membras martinica*)
28 (12 percent), and blue catfish (*Ictalurus furcatus*) (3 percent) (ENSR 2008a). Blue crab was the
29 most commonly collected invertebrate, and it comprised less than 1 percent of the total
30 organisms collected using gill nets, seines, and trawls.

31 ENSR (2008a) collected a total of 5,362 organisms using plankton nets (Table 2–5). Greater
32 than 99 percent of the organisms collected were invertebrates (crustaceans), and less than
33 1 percent was ichthoplankton (fish eggs and larvae). The most common species (84 percent of
34 all plankton net samples) collected were Harris mud crab larvae (ENSR 2008a). ENSR (2008a)
35 collected two fish taxa—clupeid shad (*Clupeidae* spp.) and gobi (*Gobiidae* spp.).

36 The fish and invertebrates collected in the MCR suggest that a robust aquatic community has
37 developed in the MCR. This community is more representative of an estuarine river rather than
38 a freshwater impoundment, likely because the source of fish and invertebrates is from the
39 Colorado River during filling of the MCR.

40 While a diverse aquatic community exists in the MCR, its organisms no longer contribute to the
41 riverine ecosystem because they are separate from the Colorado River. In addition, the
42 organisms are not available for harvest, and there is no public access or use of the MCR. The
43 USACE has determined that the MCR is not waters of the U.S. (USACE 2009), and TCEQ has
44 stated that the MCR is not waters of the State (TCEQ 2007).

1
2**Table 2–4. Fish and Invertebrates Collected in the MCR by Gill Nets, Seines, and Trawls, 2007 to 2008.**

Common Name Fish	Scientific Name	Gill Net	Seine	Trawl	Total	% of Total
Atlantic croaker	<i>Micropogonias undulatus</i>	17		86	103	<1
Black drum	<i>Pogonias cromis</i>	26			26	<1
Blue catfish	<i>Ictalurus furcatus</i>	308	35	50	393	3
Bluegill	<i>Lepomis macrochirus</i>		31		31	<1
Channel catfish	<i>Ictalurus punctatus</i>	3	21	6	30	<1
Common carp	<i>Cyprinus carpio carpio</i>	97		9	106	<1
Freshwater drum	<i>Aplodinotus grunniens</i>	7	3	39	49	<1
Gizzard shad	<i>Dorosoma cepedianum</i>		45	28	73	<1
Gulf menhaden	<i>Brevoortia patronus</i>	4		1	5	<1
Inland silverside	<i>Menidia beryllina</i>		2,068		2,068	18
Ladyfish	<i>Elops saurus</i>	36	1		37	<1
Gray (mangrove) snapper	<i>Lutjanus griseus</i>	2			2	<1
Naked goby	<i>Gobiosoma bosc</i>		3		3	<1
Needlefish	<i>Strongylura exilis</i>		1		1	<1
Pinfish	<i>Lagodon rhomboides</i>		3	1	4	<1
Red drum	<i>Sciaenops ocellatus</i>	1			1	<1
Rough silverside	<i>Membras martinica</i>		1,362		1,362	12
Sheepshead minnow	<i>Cyprinodon variegatus</i>		4		4	<1
Smallmouth buffalo	<i>Ictiobus bubalus</i>	2			2	<1
Spotted gar	<i>Lepisosteus oculatus</i>		1	2	3	<1
Striped mullet	<i>Mugil cephalus</i>	1	41		42	<1
Threadfin shad	<i>Dorosoma petenense</i>		6,463	768	7,231	62
White mullet	<i>Mugil curema</i>		7		7	<1
Invertebrates						<1
Blue crab	<i>Callinectes sapidus</i>	11	2	6	19	<1
Rangia clam	<i>Rangia cuneata</i>			3	3	<1
Total		515	10,091	999	11,605	

Source: ENSR 2008a

Affected Environment

1 **Table 2–5. Fish and Invertebrates Collected in the MCR by Plankton Tows,**
 2 **2007 to 2008**

Common Name Fish	Taxa	Total	% of Total
Clupeid shad	Clupeidae spp.	15	<1
Gobi	Gobiidae spp.	2	<1
Invertebrates			
Water flea	Cladocera spp.	8	<1
Amphipods	Amphipoda spp.	1	<1
Copepods	Copepoda spp.	22	<1
Fish lice	Branchiura spp.	1	<1
Decapods	Panopeidae spp.	539	10
Harris mud crab	<i>Rhithropanopeus harrissi</i>	4,582	85
Decapod zoea	Decapoda spp.	153	3
Brachyuran decapod	<i>Brachyura</i> spp.	29	1
Mysid shrimp	<i>Mysida</i> spp.	2	<1
Bivalvia	Bivalvia spp.	3	<1
Unidentified		5	<1
Total		5,362	

Source: ENSR 2008a

3 Essential Cooling Pond. The ECP is a 46-ac (19-ha) cooling pond and serves as the ultimate
 4 heat sink for Units 1 and 2. ENSR (2002) conducted a survey of the ECP and indentified two
 5 fish species: sailfin molly (*Poecilia latipinna*) and sheepshead minnow (*Cyprinodon variegates*).
 6 ENSR (2002) captured fewer fish near the discharge structure compared to elsewhere in the
 7 ECP. ENSR (2007, 2008c) identified sailfin molly and sheepshead minnow in the main
 8 drainage channel (MDC) and the Colorado River, and ENSR (2008a) indentified sheepshead
 9 minnow in the MCR.

10 Other Aquatic Features. Other onsite aquatic features include the Little Robbins Slough,
 11 wetlands, Kelly Lake, and drainage areas.

12 Little Robbins Slough is a stream that flows across the site, from the northwest corner, along the
 13 western edge of the MCR embankment, and then out the southwest corner. This water flow is
 14 critical to the function and structure of the marshes both on site and south of the site (Mad
 15 Island Wildlife Management Area (WMA) and Clive Runnells Family Mad Island Marsh
 16 Preserve). These marshes provide nursery grounds for juvenile fish and shellfish. The water
 17 from Little Robbins Slough eventual flows into the GIWW.

18 Kelly Lake is located in the northeast edge of the MCR embankment (STPNOC 2010d). The
 19 lake covers approximately 34 ac (14 ha) and is primarily fed by drainage areas but may also
 20 receive groundwater discharge (STPNOC 2010d). The NRC staff is not aware of any aquatic
 21 ecology surveys of Kelly Lake (NRC 1975, 1986, 2011b; STPNOC 2010b).

1 The STP site also includes numerous drainage areas, many of which are man-made ditches
2 (NRC 2011b). NRC (1975, 1986) included a description of the prevalent aquatic communities
3 on the STP site in drainage areas. The most common species from these studies include the
4 following: grass shrimp (*Palaemonetes kadiakensis*; also known as Mississippi grass shrimp),
5 crayfish (possibly of several genera), blue crab, red shiner (*Cyprinella lutrensis*), mosquitofish
6 (*Gambusia affinis*), silverband shiner (*Notropis shumardi*), sailfin molly, green sunfish (*Lepomis*
7 *cyanellus*), warmouth (*L. gulosus*), bluegill (*L. macrochirus*), white crappie (*Pomoxis annularis*),
8 tidewater silverside (*Menidia peninsulae*), striped mullet, and several species of killifish (Family
9 Cyprinodontidae, likely *Lucania* spp. and *Fundulus* spp.). NRC (1975, 1986) reported aquatic
10 invertebrates, such as the early life stages of midges, beetles, mayflies, biting midges,
11 dragonflies, and damselflies. The fish and invertebrates found in drainage areas are common
12 species along the Texas coastline, and most are generally tolerant of salinity and water
13 temperature fluctuations (Hassan-Williams and Bonner 2009; NRC 1975, 1986, 2011b;
14 STPNOC 2010d; Thomas et al. 2007).

15 More recently, ENSR (2007) conducted a rapid bio-assessment of the MDC. The MDC is a
16 150-m (492-ft) unlined channel that runs north of the proposed STP, Units 3 and 4, power block,
17 crosses the existing railroad track, and eventually joins the Little Robbins Slough west of the
18 MCR (ENSR 2007; NRC 2011b). STPNOC relocated the MDC further north of the proposed
19 STP, Units 3 and 4, power block as part of STPNOC's proposal to build Units 3 and 4
20 (STPNOC 2010e). There is no continual flow of water in the MDC. Saturated soils and possible
21 groundwater support shallow pooled areas. Water depth increases during rain events, and
22 water drains into Little Robbins Slough during high flows (ENSR 2007; NRC 2011b).

23 ENSR (2007) conducted the survey using seine nets and followed a modified version of EPA's
24 rapid bioassessment protocols (Barbour et al. 1999). ENSR (2007) identified 11 fish taxa,
25 2 invertebrate taxa, and 1 turtle. The three most common species were largemouth bass
26 (*Micropterus salmoides*), mosquitofish, and sailfin mollies. Other species included other sunfish
27 species (reardear sunfish (*Lepomis microlophus*), pumpkinseed (*L. gibbosus*), and bluegill),
28 killifish (Bayou killifish (*undulus pulverous*), Gulf killifish (*Fundulus grandis*), sheepshead
29 minnows), gobies (*Gobiidae*), inland silverside, crayfish (several genera occur in the area,
30 e.g., *Procambarus* spp.), grass shrimp, and red eared slider (*Chrysemys scripta*). Similar to the
31 fish and invertebrates that inhabited drainages areas in 1970s and 1980s, the taxa found in the
32 MDC are common species along the Texas coastline, and most are generally tolerant of salinity
33 and water temperature fluctuations (Barbour et al. 1999; Ross 2001; STPNOC 2010d).

34 **2.2.6.3 Transmission Lines**

35 Power generated from STP during the proposed license renewal term would be transmitted
36 using existing transmission line corridors. The transmission corridors pass through forested,
37 agricultural, and grasslands typical of the Texas coastal prairie (STPNOC 2010b). The water
38 bodies crossed by the transmission corridors include small rivers, small streams, agricultural
39 ponds, drainage areas, and wetlands (NRC 1975). The NRC staff is not aware of any aquatic
40 surveys conducted along these corridors. The staff's review of the terrain along the Hillje
41 transmission line during a pre-application site visit for the proposed STP, Units 3 and 4, did not
42 indicate any notable aquatic features within that region of the corridor (NRC 2008a). Observed
43 water bodies included wetlands and small ponds. Aquatic species in the water bodies along the
44 transmission corridors are likely similar to those communities typically found along the coastal
45 plain and are likely tolerant to temporary changes in water quality (NRC 2011b;
46 STPNOC 2010d).

1 **2.2.7 Terrestrial Resources**

2 STP Ecoregion. Beginning in the 1980s, the USGS, EPA, the Commission for Environmental
3 Cooperation, and various other Federal agencies and interagency groups have begun
4 delineating North American ecoregions to provide a common geographical framework by which
5 to assess and manage the environment. Ecoregions are divided into Levels I through IV; Level I
6 encompasses large areas of land and is the broadest category, while Level IV is the most
7 specific. Ecoregions are delineated by many factors to include location, climate, vegetation,
8 hydrology, terrain, wildlife, and land use. The STP site lies within the following Level I through
9 IV ecoregions:

- 10 • Level I: Great Plains,
- 11 • Level II: Texas–Louisiana Coastal Plains,
- 12 • Level III: Western Gulf Coastal Plain, and
- 13 • Level IV: Floodplains and Low Terraces.

14 The Great Plains cover the majority of the midwestern states and are broadly characterized by a
15 subhumid to semiarid climate, shortgrass and tallgrass prairie, and little topographic relief
16 (EOE 2008). Within the Great Plains, the Texas-Louisiana Coastal Plains contain flat coastal
17 plains, barrier islands, dunes, beaches, bays estuaries, and tidal marshes (Wiken et al. 2011).
18 Historically, tallgrass prairie dominated the region. Within these coastal plains, STP lies within
19 the floodplains and low terraces of the Western Gulf Coastal Plain, a 50- to 90-mi (80- to
20 140-km) wide strip of flat land adjacent to the Gulf of Mexico (Griffith et al. 2007). The Western
21 Gulf Coastal Plain comprises 1,743 ac (705 ha), with an elevation range of 5 to 200 ft (2 to
22 60 m) above MSL (Griffith et al. 2007). The terrain is relatively flat, and grasslands dominate
23 undeveloped areas. Inland regions contain some forested land and savannah lies inland, but
24 the majority of this ecoregion is used as cropland for rice, cotton, and soybeans (Griffith et
25 al. 2007). Other natural features include sloughs, natural levees, and alluvial terraces, as well
26 as low gradient streams.

27 Natural habitats include deciduous bottomland forest and swamps. Maintained lands include
28 cropland and pastureland. Common bottomland tree species include pecan (*Carya illinoensis*),
29 water oak (*Quercus nigra*), southern live oak (*Q. virginiana*), and elm (*Ulmus* spp.) (Griffith et
30 al. 2007). Baldcypress (*Taxodium distichum*), black hickory (*C. texana*), post oak (*Q. stellata*)
31 and winged elm (*U. alata*) also grow in this region but are not as common (Griffith et al. 2007).
32 Coastal marshes contain cordgrass (*Spartina* spp.), saltgrass (*Distichlis spicata*), needlerush
33 (*Juncus* spp.), and saltmarsh bulrush (*Scirpus paludosus*) (Wiken et al. 2011). Common wildlife
34 species include white-tailed deer (*Odocoileus virginianus*), ocelots (*Leopardus pardalis*),
35 jaguarondi (*Puma yagouaround*), coyote (*Canis latrans*), ringtail cat (*Bassariscus astutus*),
36 armadillo (*Asypus novemcinctus*), peccary (*Pecari tajacu*), swamp rabbit (*Sylvilagus aquaticus*),
37 American alligator (*Alligator mississippiensis*), ferruginous pygmy-owl (*Glaucidium brasilianum*),
38 green jay (*Cyanocorax yncas*), Altamira oriole (*Icterus gularis*), Attwater's prairie-chicken
39 (*Tympanuchus cupido attwater*), whooping cranes (*Grus americana*), and various species of
40 ducks and geese (Wiken et al. 2011).

41 STP Site. The STP site occupies about 12,220 ac (4,950 ha) immediately west of the Colorado
42 River and approximately 10 mi (16 km) from the river's confluence with Matagorda Bay
43 (STPNOC 2010b). Of that 12,220 ac (4,950 ha), the MCR occupies 7,000 ac; the STP
44 buildings, warehouses, and infrastructure occupy about 300 ac (120 ha); and the ECP occupies
45 46 ac (19 ha). The remaining land is undeveloped and includes bottomland, agricultural and
46 pastureland, wetlands, mixed grasslands, and shrub scrub. ENSR conducted an ecological

1 survey of the STP site between 2006 and 2008. The NRC staff derived the majority of the
2 information presented in this section from this assessment.

3 Along the Colorado River, on the eastern boundary of the STP site, lies about 1,176 ac (476 ha)
4 of bottomland forested habitat that contains a mixture of trees, shrubs, and grasses. Dominant
5 tree species include sugarberry (*Celtis laevigata*), pecan, cottonwood (*Populus* spp.), water oak,
6 southern live oak, American elm (*Ulmus americana*), willow (*Salix* spp.), and Chinese tallow
7 (*Sapium sebifera*). Common shrub species include yaupon (*Ilex vomitoria*), Chinese privet
8 (*Ligustrum sinense*), McCartney rose (*Rosa meizeli*), and American beautyberry (*Callicarpa*
9 *americana*). Grassy areas contain woodoats (*Chasmanthium latifolium*), carpet grass
10 (*Axonopus affinis*), crab grass (*Digitaria* spp.), broomsedge, and Bermuda grass (*Cynodon*
11 *dactylon*). Another 53-ac (21-ha) forested area lies on the STP site north of the heavy haul
12 road. The dominant species are the same as in the larger bottomland area (ENSR 2008b).

13 Within the west and north of the developed portion of the site lies 976 ac (395 ha) of scrub
14 shrub. Sea-myrtle (*Baccharis halimifolia*), goldenrod (*Solidago* spp.), ragweed (*Ambrosia* spp.),
15 aster (*Aster* spp.), southern dewberry (*Rubus trivialis*), peppervine (*Ampelopsis arborea*), and
16 sumpweed (*Iva annua*) are the most common vegetation (ENSR 2008b).

17 About 486 ac (197 ha) of the site is mixed grasslands, some of which STPNOC regularly mows
18 or maintains. Common grass species in these areas include angleton bluestem (*Dichanthium*
19 *aristatum*), King Ranch bluestem (*Bothriochloa ischaemum* var. *songarica*), and bristle grass
20 (*Setaria* spp.) (ENSR 2008b).

21 Many wetlands exist on the site, some of which the USACE has determined to be jurisdictional
22 wetlands. The non-jurisdictional wetlands include Kelly Lake and a 110-ac (45-ha) managed
23 wetland along the northern portion of the site.

24 Kelly Lake is a 34-ac (14-ha) natural water body within the northeast corner of the site along the
25 MCR embankment. It is fed by a small catchment area north of the lake. At least two drainages
26 flow into the lake, and one drainage flows south along the east side of the MCR embankment
27 and exits the lake (NRC 2011b). Cattail (*Typha* spp.) and arrowhead (*Sagittaria* spp.) surround
28 Kelly Lake (NRC 2011b).

29 The 110-ac (45-ha) managed wetland is part of the larger Texas Prairie Wetland Project, a
30 series of at least 35,000 ac (14,100 ha) of wetlands along the Gulf coasts that have been set
31 aside or restored through a partnership with Ducks Unlimited, the Texas Parks and Wildlife
32 Department, the U.S. Fish and Wildlife Service, the U.S. Department of Agriculture, and private
33 landowners (Ducks Unlimited 2006). This wetland provides forage and wintering habitat for
34 waterfowl, wading birds, and shorebirds (STPNOC 2010b). Houston Lighting and Power
35 Company (HPLC), on behalf of STP, signed an agreement in October 1996 with Ducks
36 Unlimited to manage and restore or enhance this portion of the STP property as part of the
37 Texas Prairie Wetlands Project (Ducks Unlimited and HPLC 1996). As part of the agreement,
38 HPLC committed to developing and managing the 110 ac (45 ha) to provide seasonal or
39 semi-permanent wetland habitat for wintering migratory birds and other wetland-dependent
40 wildlife (Ducks Unlimited and HPLC 1996). HPLC also built multiple impoundments to create
41 foraging habitat (Ducks Unlimited and HPLC 1996).

42 The jurisdictional wetlands include 29 small wetlands within the northern portion of the site,
43 most of which are ditches or depression wetlands (USACE 2009). The largest delineated
44 wetland is 3.78 ac (1.53 ha), and 16 of the delineated wetlands are less than 0.5 ac (0.2 ha)
45 (ENSR 2008b). In total, jurisdictional wetlands cover 17.6 ac (7.1 ha) (USACE 2009).
46 Dominant wetland vegetation includes spikerush (*Eleocharis* spp.), cattail (*Typha* spp.), water
47 hyssop (*Bacopa monnieri*), knotgrass (*Polygonum* spp.), bushy bluestem (*Andropogon*

Affected Environment

1 *glomeratus*), sea-myrtle, and rattlebox (*Crotalaria* spp.) (ENSR 2008b). Additionally, the
 2 USACE has designated 24,639 linear feet (7,510 linear meters) of non-wetland areas as
 3 jurisdictional waters.

4 The most common wildlife on the site include white-tailed deer, rabbit (*Silvilgus* spp.), squirrel
 5 (*Sciurus* spp.), and feral hogs (*Sus scrofa*) (STPNOC 2010b). Cardinals (*Cardinalis cardinalis*),
 6 mourning doves (*Zenaida macroura*), bobwhite quail (*Colinus virginianus*), red-winged
 7 blackbirds (*Agelaius phoeniceus*), grackles (*Quiscalus* spp.), black vultures (*Coragyps atratus*),
 8 and turkey vultures (*Cathartes aura*) are the most common birds. Wading birds, such as great
 9 blue heron (*Ardea herodias*), great egret (*Ardea alba*), roseate spoonbill (*Ajaia ajaja*), white ibis
 10 (*Eudocimus albus*), and little blue heron (*Egretta caerulea*), are common near Kelly Lake, the
 11 MCR, and other water features (STPNOC 2010b). American alligators, discussed in more detail
 12 in Section 2.2.7, regularly inhabit the site. Other common reptiles include the copperhead
 13 snake (*Agkistrodon contortrix contortrix*), cottonmouth snake (*A. piscivorus*), eastern hog-nosed
 14 snake (*Heterodon platirhinos*), eastern racer (*Coluber constrictor*), corn snake (*Elaphe guttata*),
 15 eastern rat snake (*E. obsoleta*), diamondback watersnake (*Nerodia rhombifer rhombifer*),
 16 eastern box turtle (*Terrapene carolina*), ornate box turtle (*T. ornata*), snapping turtle (*Chelydra*
 17 *serpentina*), red-eared pond slider (*Trachemys scripta elegans*), green anole (*Anolis*
 18 *carolinensis*), and five-lined skink (*Eumeces fasciatus*) (NRC 2011b).


19 Each year, Matagorda County hosts a Christmas Bird Count, a volunteer bird count organized
 20 by the Audubon Society that runs from December 14 through January 5 of each year. The
 21 count centers on Mad Island and encompasses about 113,000 ac (45,700 ha) within a 15-mi
 22 (24-km) radius. Because the STP site lies near the southern terminus of the Central Flyway, a
 23 great diversity of birds inhabit or pass through the site and surrounding region, and the region
 24 provides important stopover and wintering habitat for migrating birds. During the 2010 to 2011
 25 bird count, participants recorded 231 different bird species (Audubon 2011). Within the past
 26 5 years of bird count data, red-winged blackbirds (*Agelaius phoeniceus*) and brown-headed
 27 cowbirds (*Molothrus ater*) accounted for the overwhelming majority (70 and 19 percent,
 28 respectively) of recorded observations. Figure 2–5 identifies the most commonly observed
 29 species in the past 5 years of Christmas Bird Counts. The birds in this figure were of the top
 30 10 most commonly recorded species for at least 2 years out of the past five Christmas Bird
 31 Counts. In addition to the bird species in Figure 2–5, six additional species appeared in the top
 32 10 recorded species for only one data year. Table 2–6 lists these species and the year and
 33 number of each.

34 **Table 2–6. Birds Observed in High Numbers for One Christmas Count Year,**
 35 **2007 through 2011**

Species	Year Recorded Within Top 10 Most Common Species	# of Individuals Recorded
American white pelican	2009–2010	1,700
blackbird spp.	2010–2011	5,115
lesser scaup	2010–2011	85,438
redhead	2008–2009	15,005
Ross's goose	2009–2010	2,537
sandhill crane	2008–2009	10,000

Source: Audubon 2011

Figure 2-5. Most Commonly Recorded Christmas Bird Count Species, 2007 through 2011 (Audubon 2011)



Affected Environment

- 1 In addition to the data available from the Christmas Bird Counts, ENSR conducted a bird survey
- 2 in 2006 and 2007 on the STP site as part of the STP, Units 3 and 4, COL application.
- 3 Table 2–7 lists the bird species that ENSR observed on the STP site during this survey and the
- 4 types of habitats or areas of the site in which each was associated.

5 **Table 2–7. Birds Documented on the STP Site, 2007 through 2008**

Species	Common Name	Habitat Type or Area Observed	Trans-Gulf Migrant^(a)
<i>Agelaius phoeniceus</i>	red-winged blackbird	grassland/scrub-shrub	
<i>Anhinga anhinga</i>	anhinga	MCR	
<i>Ardea herodias</i>	great blue heron	wetland/MCR	
<i>Bubulcus ibis</i>	cattle egret	grassland/wetlands	
<i>Buteo jamaicensis</i>	red-tailed hawk	grassland/scrub-shrub	
<i>Buteo lineatus</i>	red-shouldered	grassland/scrub-shrub	
<i>Caracara cheriway</i>	crested caracara	grassland	
<i>Cathartes aura</i>	turkey vulture	grassland/scrub-shrub/developed	
<i>Charadrius vociferus</i>	killdeer	grassland/developed	
<i>Circus cyaneus</i>	northern harrier	grassland/scrub-shrub	
<i>Colinus virginianus</i>	northern bobwhite	grassland/scrub-shrub	
<i>Coragyps atratus</i>	black vulture	grassland/scrub-shrub/developed	
<i>Corvus brachyrhynchos</i>	American crow	grassland/scrub-shrub	
<i>Cyanocitta cristata</i>	bluejay	scrub-shrub	
<i>Dendrocygna bicolor</i>	fulvous whistling-duck	wetland	
<i>Egretta caerulea</i>	little blue heron	wetlands	
<i>Egretta thula</i>	snowy egret	wetland/MCR	
<i>Egretta tricolor</i>	tri-colored heron	wetland/MCR	
<i>Eudocimus albus</i>	white ibis	grassland/wetlands	
<i>Fulica americana</i>	American coot	wetlands	
<i>Gelochelidon nilotica</i>	gull-billed tern	MCR	
<i>Geothlypis trichas</i>	common yellowthroat	scrub-shrub	x
<i>Haliaeetus leucocephalus</i>	bald eagle	river shoreline	
<i>Hirundo rustica</i>	barn swallow	grassland/developed	x
<i>Leucophaeus atricilla</i>	laughing gull	MCR/developed	
<i>Megaceryle alcyon</i>	belted kingfisher	wetlands	x

Species	Common Name	Habitat Type or Area Observed	Trans-Gulf Migrant ^(a)
<i>Mimus polyglottos</i>	northern mockingbird	MCR/developed	
<i>Molothrus ater</i>	brown-headed cowbird	grassland/scrub-shrub/developed	
<i>Nycticorax nycticorax</i>	black-crowned night-heron	grassland/scrub-shrub	
<i>Pandion haliaetus</i>	osprey	wetland	
<i>Pelecanus erythrorhynchos</i>	American white pelican	MCR	
<i>Pelecanus occidentalis</i>	brown pelican	MCR	
<i>Petrochelidon pyrrhonota</i>	cliff swallow	MCR	x
<i>Platalea ajaja</i>	roseate spoonbill	MCR	
<i>Progne subis</i>	purple martin	grassland/scrub-shrub/developed	x
<i>Quiscalus major</i>	boat-tailed grackle	grassland/scrub-shrub/developed	
<i>Sturnella magna</i>	eastern meadowlark	grassland/scrub-shrub	
<i>Turdus migratorius</i>	American robin	grassland	
<i>Tyrannus forficatus</i>	scissor-tailed flycatcher	grassland/scrub-shrub	x
<i>Zenaida macroura</i>	mourning dove	grassland/developed	

^(a) Birds that cross the Gulf of Mexico from the Yucatan Peninsula to the Gulf coasts

Source: ENSR 2008b; NRC 2011b

- 1 Waterbirds nest on the ends “Y” dike that directs water flow in the MCR. STPNOC first
- 2 observed nesting on the MCR dikes in 1986 (STPNOC 2010d). The dominate nesting species
- 3 include laughing gulls (*Leucophaeus atricilla*) (53 percent) and gull-billed terns (*Gelochelidon*
- 4 *nilotica*) (31 percent), which account for a collective 84 percent of the 1,200 to 1,600 nests per
- 5 year (STPNOC 2010d). Seven additional bird species nest on the dikes with typically fewer
- 6 than 100 nests each (STPNOC 2010d).
- 7 Transmission Line Corridors. The transmission lines traverse mostly agricultural lands, as well
- 8 as forests and grasslands in 12 counties. The habitat is typical of that described previously
- 9 under “STP ecoregion.” The corridors do not cross any designated critical habitat, Federal or
- 10 State parks, wildlife preserves, refuges, or sanctuaries (STPNOC 2010b).
- 11 Parks and Wildlife Preserves. Many parks and wildlife preserves provide valuable terrestrial
- 12 habitat to native migrating birds. Those in the vicinity of STP are discussed briefly below.
- 13 The Brazos Bend State Park is a 5,000-ac (2,000-ha) park located about 35 mi (56 km)
- 14 northeast of the STP site. The Texas Parks and Wildlife Department established this park in
- 15 1976. Natural habitats include the Brazos River floodplains, upland coastal prairie, bottomland
- 16 hardwood forest, seasonal freshwater marshes, and oxbow lakes (TPWD 2011a). The park is
- 17 home to over 300 species of birds, 21 species of reptiles and amphibians, 17 species of
- 18 mammals, 39 species of dragonflies, and 500 species of plants (TPWD 2011a).

Affected Environment


1 The Mad Island Marsh Preserve lies about 4 mi (6 km) southwest of STP. This preserve is
2 situated on West Matagorda Bay around Mad Island Lake and encompasses a total of 7,063 ac
3 (2,860 ha) (GCBO 2011). The preserve includes coastal prairie, freshwater wetlands, tidal
4 saltwater wetlands, and shrubland. The Gulf Coast Bird Observatory has recorded over
5 300 species of birds within the preserve, including sandhill cranes (*Grus canadensis*), cinnamon
6 teal (*Anas cyanoptera*), blue-winged teal (*A. discors*), northern pintail (*A. acuta*), Canada goose
7 (*Branta canadensis*), and snow goose (*Chen caerulescens*) (GCBO 2011). Many habitat
8 restoration and enhancement projects within this preserve—including prescribed burns, erosion
9 control, and rotational cattle grazing in limited areas—continue to enhance the value of the
10 habitat.

11 The Texas Parks and Wildlife Department manages the 7,200-ac (2,900-ha) Mad Island Wildlife
12 Management Area, which lies about 3 mi (5 km) south of STP (TPWD 2011d). The State of
13 Texas purchased this parcel of land to preserve coastal wetland habitat for wintering waterfowl.
14 The management area contains brackish marsh and coastal prairies and provides habitat for a
15 wide variety of wildlife

16 The U.S. Fish and Wildlife Service (FWS) manages the Big Boggy National Wildlife Refuge,
17 which lies about 10 mi (16 km) southwest of STP (FWS 2011c). Figure 2–6 and Figure 2–7
18 show the STP 50-mi (80-km) radius map (STPNOC 2010b) and STP 6-mi (10-km) radius map
19 (STPNOC 2010b), respectively. The FWS established this 4,526-ac (1,832-ha) refuge in 1983
20 to protect saltmarsh habitat for migratory birds. Within the refuge, Dressing Point Island in East
21 Matagorda Bay is an important rookery for brown pelicans, roseate spoonbills, white ibis, snowy
22 egrets, and other colonial nesting birds.


1

Figure 2-6. STP 50-mi (80-km) Radius Map (STPNOC 2010b)



1

Figure 2-7. STP 6-mi (10-km) Radius Map (STPNOC 2010b)



2

1 **2.2.8 Protected Species and Habitats**

2 This section discusses species and habitats that are:

- 3 • Federally protected under the Endangered Species Act (ESA) of 1973, as
4 amended;
- 5 • designated as a species of concern under the National Marine Fisheries
6 Service (NMFS)’s Species of Concern Program;
- 7 • Federally protected under the Bald and Golden Eagles Protection Act of
8 1940, as amended;
- 9 • Federally protected under the Migratory Bird Treaty Act of 1918 (MBTA), as
10 amended;
- 11 • Federally protected under the Magnuson–Stevens Fishery Conservation and
12 Management Act (MSA), as amended;
- 13 • Federally protected under the Marine Mammal Protection Act (MMPA) of
14 1972, as amended; or
- 15 • State-protected under Title 5, *Wildlife and Plant Conservation*, Chapter 68,
16 *Endangered Species*, and Chapter 88, *Endangered Plants*, of the State of
17 Texas’s Statutes.

18 **2.2.8.1 Species and Habitats Protected Under the Endangered Species Act**

19 The FWS and the NMFS jointly administer the ESA. The FWS manages the protection of and
20 recovery effort for listed terrestrial and freshwater species, while the NMFS manages the
21 protection of and recovery effort for listed marine and anadromous species. Table 2–8 identifies
22 species under the FWS and NMFS’s jurisdiction that occur in Matagorda County, in which STP
23 is located, or within one of the 12 counties through which the transmission line corridors
24 traverse.

25 **Table 2–8. Species Listed Under the ESA**

Species	Common Name	Status ^(a)		Potential Occurrence ^(b)	
		Federal	State	Matagorda County	T-line Counties
Amphibians					
<i>Bufo houstonensis</i>	Houston toad	E	E		x
<i>Eurycea nana</i>	San Marcos salamander	T	T		x
<i>Typhlomolge rathbuni</i>	Texas blind salamander	E	E		x
Arachnids					
<i>Cicurina baronia</i>	Robber Baron Cave meshweaver	E	-		x
<i>Cicurina madla</i>	Madla Cave meshweaver	E	-		x
<i>Cicurina venii</i>	braken bat cave meshweaver	E	-		x
<i>Cicurina vespera</i>	Government Canyon bat cave meshweaver	E	-		x

Affected Environment

Species	Common Name	Status ^(a)		Potential Occurrence ^(b)	
		Federal	State	Matagorda County	T-line Counties
<i>Neoleptoneta microps</i>	Government Canyon bat cave spider	E	-		x
<i>Texella cokendolpheri</i>	Cokendolpher cave harvestman	E	-		x
Birds					
<i>Charadrius melodus</i>	piping plover	T	T	x	x
<i>Dendroica chrysoparia</i>	golden-cheeked warbler	E	E		x
<i>Falco femoralis septentrionalis</i>	northern aplomado falcon	E	E	x	x
<i>Grus americana</i>	whooping crane	E	E	x	x
<i>Tympanuchus cupido attwateri</i>	Attwater's greater prairie-chicken	E	E		x
<i>Vireo atricapilla</i>	black-capped vireo	E	E		x
Crustaceans					
<i>stygobromus pecki</i>	Peck's cave amphipod	E	-		x
Fish					
<i>Etheostoma fonticola</i>	fountain darter	E	E		x
<i>Gambusia georgei</i>	San Marcos gambusia	E	E		x
<i>Pristis pectinata</i>	smalltooth sawfish	E	E	x	
<i>Pristis pristis</i>	largetooth sawfish	E	-	x	
Insects					
<i>Batrisodes venyivi</i>	helotes mold beetle	E	-		x
<i>Heterelmis comalensis</i>	Comal Springs riffle beetle	E	-		x
<i>Rhadine exilis</i>	unnamed beetle	E	-		x
<i>Rhadine infernalis</i>	unnamed beetle	E	-		x
<i>Stygoparnus comalensis</i>	Comal Springs dryopid beetle	E	-		x
Mammals					
<i>Balaenoptera borealis</i>	sei whale	E	-	x	
<i>Balaenoptera musculus</i>	blue whale	E	-	x	
<i>Balaenoptera physalus</i>	finback whale	E	E	x	
<i>Herpailurus yaguarondi cacomitli</i>	Gulf coast jaguarundi	E	E		x
<i>Leopardus pardalis</i>	ocelot	E	E	x	x
<i>Megaptera novaeangliae</i>	humpback whale	E	E	x	

Species	Common Name	Status ^(a)		Potential Occurrence ^(b)	
		Federal	State	Matagorda County	T-line Counties
<i>Physeter macrocephalus</i>	sperm whale	E	-	x	
<i>Trichechus manatus</i>	West Indian manatee	E	E	x	
Plants					
<i>Spiranthes parksii</i>	Navasota ladies' tresses	E	E		x
<i>Spiranthes parksii</i>	Texas wild rice	E	E		x
Reptiles					
<i>Alligator mississippiensis</i> ^(c)	American alligator	T(SA)	-	x	x
<i>Caretta caretta</i>	loggerhead sea turtle	T	T	x	
<i>Chelonia mydas</i>	green sea turtle	T	T	x	
<i>Dermochelys coriacea</i>	leatherback sea turtle	E	E	x	
<i>Eretmochelys imbricata</i>	hawksbill sea turtle	E	E	x	
<i>Lepidochelys kempii</i>	Kemp's ridley sea turtle	E	E	x	

^(a) E=endangered; P=proposed; T=threatened; T(SA)=threatened due to similarity of appearance; - = not listed

^(b) The STP site is located in Matagorda County. The transmission lines associated with the STP site traverse Matagorda County as well as Bexar, Brazoria, Colorado, DeWitt, Fayette, Gonzales, Guadalupe, Jackson, Lavaca, Wharton, and Wilson Counties.

^(c) The American alligator is designated as threatened due to its similarity of appearance with the American crocodile (*Crocodylus acutus*).

Sources: FWS 2011a, 2011b; NMFS 2011c; NRC 2011b; STPNOC 2010b; TPWD 2011c, 2011f

1 STPNOC has observed one Federally listed species on the STP site since the facility began
 2 operating—the American alligator (*Alligator mississippiensis*) (STPNOC 2010b). The FWS has
 3 designated the American alligator as “threatened due [to] similarity of appearance” with the
 4 threatened American crocodile (*Crocodylus acutus*). Additionally, two delisted species occur on
 5 the site—the bald eagle (*Haliaeetus leucocephalus*) and the brown pelican (*Pelecanus*
 6 *occidentalis*). This section also discusses in more detail the piping plover (*Charadrius*
 7 *melodus*), whooping crane (*Grus americana*), ocelot (*Leopardus pardalis*), and Gulf coast
 8 jagaurundi (*Herpailurus yaguarondi cacomitli*). None of these four species occur on the STP
 9 site (STPNOC 2010b), but the FWS has designated piping plover as critical habitat along
 10 Matagorda Bay about 7 mi (11 km) south of the STP site. Additionally, the FWS identified the
 11 whooping crane, ocelot, and Gulf coast jagaurundi as species of interest in its correspondence
 12 with the NRC (FWS 2011b). The NRC staff did not identify any proposed species or proposed
 13 critical habitat in the vicinity of the STP site or along the transmission line corridors during its
 14 environmental review.

15 American Alligator. The FWS listed the American alligator in 1967 under the Endangered
 16 Species Preservation Act of 1966, the predecessor regulation to the ESA. Following
 17 reclassification actions in several states, the FWS declared the species fully recovered in 1987
 18 and reclassified it as “threatened due to similarity of appearance” to the American crocodile
 19 (*Crocodylus acutus*) throughout the remainder of the species’ range (52 FR 21059). American
 20 alligators inhabit coastal swamps from North Carolina southward and around the Gulf of Mexico

Affected Environment

1 as far west as Texas (Audubon 2004). They also inhabit coastal flatlands as far north as
2 Arkansas (Audubon 2004).

3 Alligators inhabit the wetlands on the STP site as well as the MCR (STPNOC 2010b). During a
4 1987 to 1988 ecological study, Baker and Greene (1989) observed small numbers of alligators
5 near Kelly Lake, the south drainage canal, Little Robins Slough, and the various dikes
6 associated with the MCR. In 2007 through 2008, ENSR (2008b) did not observe any Federally
7 listed species during a threatened and endangered species survey. However, ENSR conducted
8 this survey during the winter months, during which time alligators are less active and likely seek
9 refuge in swamps and wetlands near the STP site that provide more shelter.

10 Piping Plover and Designated Critical Habitat. Piping plover is a Federally and State-listed
11 threatened species that winters along the Gulf of Mexico coast. A recent study of the taxonomy
12 of the species (Miller et al. 2009) confirmed genetic uniqueness of only two subspecies—
13 Atlantic (*C.m. melodus*) and Interior (*C.m. circumcinctus*). The FWS recognizes three distinct
14 population segments in its ESA rulemakings—the Atlantic Coast, the Great Lakes, and the
15 Northern Great Plains populations (FWS 2009). The Atlantic Coast population is *C.m. melodus*,
16 while the Great Lakes and Northern Great Plains populations are *C.m. circumcinctus*.

17 The Texas coast provides wintering habitat for all three distinct population segments between
18 September and March. Piping plovers inhabit wide, flat, open, sandy beaches and nest in small
19 creeks and wetlands (FWS 2011d) such as those found along the Texas coast.

20 STPNOC (2010b) reported that it has not observed the species on the STP site; however, the
21 species inhabits the nearby shoreline of Matagorda Bay and the Gulf of Mexico.

22 STP is in close proximity to four units of designated piping plover critical habitat. The closest
23 critical habitat unit is TX-26, Colorado River Diversion Delta, which consists of 13 ac (5 ha) that
24 follow the shore of the northeast corner of West Matagorda Bay from Culver Cut to Dog Island
25 Reef (66 FR 36038). This unit is about 7 mi (11 km) south of the STP site boundary. It includes
26 roosting areas and is infrequently inundated by seasonal winds. The other three units are
27 (66 FR 36038):

- 28 (1) TX-23, West Matagorda Peninsular Beach—769 ac (311 ha) of Gulf of Mexico
29 shoreline from the Matagorda Ship Channel jetties to the old Colorado River channel,
- 30 (2) TX-25, West Matagorda Bay and Eastern Peninsula Flats—575 ac (232 ha) following
31 the bayside of Matagorda Peninsula from Maverick Slough southwest for 3 mi
32 (5 km), and
- 33 (3) TX-27, East Matagorda Bay and Matagorda Peninsular Beach West—728 ac
34 (295 ha) of Gulf of Mexico shoreline from the mouth of the Colorado River northeast
35 along the peninsula for 14 mi (23 km).

36 Within these units, only the areas that contain “primary constituent elements” (the physical and
37 biological landscape features that a species requires to survive and reproduce) are considered
38 critical habitat (FWS 2000). Therefore, buildings, marinas, parking lots, and other developed
39 areas do not constitute critical habitat.

40 Other Federally Listed Species. In addition to the species discussed above, in its
41 correspondence with the NRC, the FWS (2011b) provided information and recommendations
42 concerning three additional Federally listed species—the whooping crane, the ocelot, and the
43 Gulf coast jaguarundi.

44 The whooping crane migrates to the Texas coast between late October and mid-November and
45 generally stays through late March to mid-April before returning to breeding grounds in Canada
46 (FWS 2011b). Whooping cranes fly relatively high when migrating (1,000 to 6,000 ft (300 to

1 1,800 m) in altitude) but will fly lower when searching for stopover habitat (FWS 2011b). The
 2 species is present in Matagorda County as well as all counties through which the transmission
 3 lines traverse. However, the whooping crane has not been observed on the STP site and is
 4 unlikely to use the inland habitat on the site (NRC 2011b).

5 The ocelot and the Gulf coast jaguarundi inhabit dense, low brush. The ocelot requires 70 to
 6 90 percent canopy cover, while the Gulf coast jaguarundi tolerates more open habitat
 7 (FWS 2011b). The ocelot historically occurred throughout southern Texas but is now restricted
 8 to southern Edwards Plateau and along the Coastal Plain (TPWD 2011e). The Gulf coast
 9 jaguarundi's available habitat has also diminished, and the cat now only occurs in the Rio
 10 Grande Valley within Cameron and Willacy Counties (TPWD 2011b). Neither of these species
 11 occurs on the STP site nor are they likely to occur along the transmission line corridors since
 12 the transmission lines pass through mostly agricultural lands. Additionally, since the
 13 transmission line corridors have been maintained for early successional habitat since their
 14 construction, they do not provide suitable habitat for either the ocelot or Gulf coast jaguarundi.

15 For the remaining Federally listed species that appear in Table 2–8, the FWS (2011b) did not
 16 note any of the remaining species under its jurisdiction either to occur on the STP site or to
 17 potentially be affected by the proposed license renewal. Though some of the marine species
 18 under NMFS's jurisdiction listed in Table 2–8 may occur in Matagorda Bay, none of these
 19 species would occur in the Colorado River due to their habitat requirements. Additionally,
 20 STPNOC (2010b) did not report occurrences of any of these species on the STP site.
 21 Therefore, these species are not discussed in detail.

22 **2.2.8.2 Species Designated as NMFS Species of Concern**

23 The NMFS established a Species of Concern Program and species of concern list in 2004 to
 24 distinguish between candidate species under the ESA and other species that the NMFS
 25 identifies as potentially at risk but for which no ESA listing action has been initiated
 26 (69 FR 19975). The NMFS defines “species of concern” as “those species about which the
 27 NMFS has some concerns regarding threats to continued existence and population status, but
 28 for which insufficient information is available to initiate listing actions under the ESA
 29 (NMFS 2011d).”

30 The term “species of concern” does not appear in either the ESA or its implementing
 31 regulations; therefore, it does not carry any procedural or substantive protections under the
 32 ESA. Only the NMFS, and not the FWS, maintains a Species of Concern Program and species
 33 of concern list. Species of concern in the vicinity of STP appear in Table 2–9.

34 **Table 2–9. NMFS Species of Concern**

Species	Common Name	Area of Concern ^(a)	Habitat
Anthrozoa			
<i>Oculina varicosa</i>	ivory tree coral	Atlantic Ocean—West Indies, Bermuda, North Carolina, Florida, Gulf of Mexico, Caribbean	inhabit shallow subtidal waters, limestone rubble and ledges, and soft-bottom sloping habitats from 2–152 m in depth
Fish			
<i>Carcharhinus obscurus</i>	dusky shark	Atlantic Ocean; Gulf of Mexico; Pacific	surf zone to waters 400 m deep; not commonly found in estuaries due to salinity requirements

Affected Environment

Species	Common Name	Area of Concern ^(a)	Habitat
<i>Carcharias taurus</i>	sand tiger shark	Atlantic Ocean; Gulf of Mexico	surf zone to depths of 25 m; shallow bays; around coral reefs
<i>Epinephelus drummondhayi</i>	speckled hind	Atlantic Ocean—North Carolina to Gulf of Mexico	offshore rocky bottoms with depths of 25–183 m; most common between 60–120 m
<i>Epinephelus nigritus</i>	warsaw grouper	Atlantic Ocean—Maine southward to Gulf of Mexico	continental shelf reefs in waters 76–219 m deep
<i>Fundulus jenkinsi</i>	saltmarsh topminnow	Atlantic Ocean—TX, LA, MS, AL, FL	small, tidal marshes with salinity of 1–4 ppt

^(a) Areas of concern are specified by the NMFS species of concern list (NMFS 2011e).

Sources: 75 FR 25174; Aronson et al. 2008; Musick et al. 2007; NMFS 2011c; NRC 2011b; Pollard and Smith 2005; Wai and Huntsman 2006a, 2006b; WEG 2010

- 1 Ivory Tree Coral. The ivory tree coral (*Oculina varicosa*) inhabits marine waters from Cape
2 Hatteras, North Carolina, through the Gulf of Mexico and the Caribbean. However, it is only an
3 NMFS species of concern along the eastern U.S. coast from North Carolina through Florida.
4 Most of the species' population is concentrated off east-central Florida, where it occurs in its
5 deep-water form and creates thicket-type structures. The species may occur in Matagorda Bay
6 in its shallow form, in which the coral forms a symbiotic relationship with zooxanthellae. The
7 shallow form reproduces in July and August via broadcast spawning. Ivory tree coral
8 suspension feeds on planktonic organisms and provides refuge for over 300 species of
9 invertebrates. (NMFS 2010d)
- 10 Sand Tiger Shark. The sand tiger shark (*Carcharias taurus*) is a species of concern in the
11 western Atlantic and northern Gulf of Mexico, though the species is globally distributed in all
12 warm and temperate seas and oceans except the eastern Pacific. Tiger sharks mature at about
13 6 ft (1.9 m) in length and reach up to 10.4 ft (3.18 m) in length. Individuals are generally solitary
14 but occur in schools for feeding, courtship, mating, and birthing. Females give birth to one or
15 two pups every other year. Sand tiger sharks migrate toward the equator in fall and winter and
16 move poleward during the summer. They prey on bony fishes, small sharks, rays, squid, crabs,
17 and lobster. (NMFS 2010e)
- 18 Saltmarsh Topminnow. The saltmarsh topminnow (*Fundulus jenkinsi*) is a species of concern in
19 the coastal waters of Texas, Louisiana, Mississippi, Alabama, and Florida. Saltmarsh
20 topminnow occur in estuaries, coastal salt marshes, and back water sloughs and tolerate water
21 with salinities of 1 to 20 ppt (NMFS 2009). Females grow up to 60 mm (2.4 in.) in length and
22 males grow to 50 mm (1.9 in.) (NMFS 2009). The NMFS (2009) reports that no information on
23 reproductive behavior or diet is available for this species.
- 24 Other Species of Concern. The dusky shark (*Carcharhinus obscurus*), speckled hind
25 (*Epinephelus drummondhayi*), and warsaw grouper (*Epinephelus nigritus*) are unlikely to occur
26 in Matagorda Bay due to their habitat requirements.
- 27 In addition to the species already discussed, the NMFS (2011c) listed the night shark as a
28 species of concern occurring in the vicinity of STP. However, the NMFS (2010c) removed the
29 night shark from its species of concern list in 2010. It most often occurs in waters 50 to 100 m
30 (160 to 330 ft) deep, but it can inhabit waters as deep as 600 m (2,000 ft) (Santana et al. 2006).
31 Because of its depth requirements, the night shark is unlikely to occur in Matagorda Bay.

1 **2.2.8.3 Species Protected Under the Bald and Golden Eagles Protection Act**

2 The Bald and Golden Eagle Protection Act prohibits anyone from taking bald eagles (*Haliaeetus*
3 *leucocephalus*) or golden eagles (*Aquila chrysaetos*), including their nests or eggs, without an
4 FWS-issued permit. The term “take” in the Act is defined as to “pursue, shoot, shoot at, poison,
5 wound, kill, capture, trap, collect, molest, or disturb” (50 CFR 22.3). “Disturb” means to take
6 action that causes injury to an eagle; decreases its productivity by interfering with breeding,
7 feeding, or sheltering behavior; or results in nest abandonment (50 CFR 22.3).

8 Bald eagles are present year-round throughout Texas. Breeding populations primarily inhabit
9 the eastern half of the State and the coastal counties from Rockport to Houston
10 (Campbell 2003). During ecological surveys associated with the COL application for STP,
11 Units 3 and 4, ENSR (2007) listed bald eagles as one of the bird species observed on the STP
12 site. An active bald eagle nest lies near the site’s eastern boundary in remote woodlands along
13 the Colorado River (NRC 2011b). STPNOC (2010c) first observed this nest site in 2004. A
14 second bald eagle nest lies within 6 mi of the STP site (NRC 2011b).

15 **2.2.8.4 Species Protected Under the Migratory Bird Treaty Act**

16 The FWS administers the MBTA, which prohibits anyone from taking native migratory birds or
17 their eggs, feathers, or nests. The MBTA definition of a “take” differs from that of the ESA and
18 is defined as “to pursue, hunt, shoot, wound, kill, trap, capture, or collect, or any attempt to carry
19 out these activities” (50 CFR 10.12). Unlike a take under the ESA, a take under the MBTA does
20 not include habitat alteration or destruction. The MBTA protects 1,007 migratory bird species
21 (75 FR 9282). Of these 1,007 species, the FWS allows for the legal hunting of 58 species as
22 game birds (FWS undated). Within Texas, the Texas Parks and Wildlife Department manages
23 migratory bird hunting seasons and associated licenses for ducks, geese, coot, rail, gallinules,
24 snipe, woodcock, doves, and sandhill cranes. All Federally and State-listed bird species that
25 appear in Table 2–8 and Table 2–11 are protected under the MBTA. MBTA-protected-bird
26 species that commonly occur near the STP site are discussed in Section 2.2.6. Additionally, all
27 U.S.-native bird species that belong to the families, groups, or species listed in 10 CFR 10.13
28 are protected under the MBTA.

29 **2.2.8.5 Species Protected Under the Marine Mammal Protection Act**

30 The MMPA established a moratorium on the direct or indirect taking of all species of marine
31 mammals in the U.S. The MMPA defines a “take” to mean “to hunt, harass, capture, or kill.”
32 The NMFS (for whales, dolphins, porpoises, seals, and sea lions) and FWS (for walrus,
33 manatees, otters, and polar bears) may issue take permits for takes that are incidental to
34 commercial fishing, scientific research, and other nonfishing activities.

35 Under the MMPA, the NMFS and FWS manage marine mammals by identifying the “optimum
36 sustainable population” level for each species. Those species whose populations have fallen
37 below the optimum sustainable level are considered “depleted.” Within the Gulf of Mexico,
38 29 marine mammals occur (NMFS 2011b; TMMSN 2011). Of these, only the bottlenose dolphin
39 (*Tursiops truncatus*) occurs within Matagorda Bay due to the bay’s shallow depth. Bottlenose
40 dolphins inhabit pelagic waters along the continental shelf and may migrate into bays, estuaries,
41 and river mouths (NMFS 2011a). Those bottlenose dolphins found in Matagorda Bay are part of
42 the Northern Gulf of Mexico Bay, Sound, and Estuarine Stock. According to NMFS’s 2010 stock
43 assessment (NMFS 2010a), the status of this stock is unknown because the most recent
44 population estimates are eight or more years old, but this stock is not considered depleted. The
45 NMFS estimates the larger Northern Gulf of Mexico Coastal stock to be 4,191 individuals as of
46 2007 (NMFS 2011a).

1 **2.2.8.6 Species Protected Under the Magnuson–Stevens Act**

2 The Gulf of Mexico Fishery Management Council (GMFMC) has designated the lower Colorado
 3 River, the GIWW, and Matagorda Bay as essential fish habitat (EFH) for many species in
 4 accordance with the MSA. These waters are collectively referred to as part of Ecoregion 5 in
 5 the GMFMC’s *Final EIS for the Generic Essential Fish Habitat Amendment for Gulf of Mexico*
 6 fishery management plans (GMFMC 2004).

7 Table 2–10 lists those species with designated EFH within Ecoregion 5 and specifies which of
 8 those species’ life stages have the potential to occur in the vicinity of STP based on each
 9 stage’s life history requirements.

10 **Table 2–10. Ecoregion 5 Species with Designated EFH**

Species	Common Name	Fishery Management Plan	EFH Life Stages in Ecoregion 5 ^(a)	Life Stages in the Vicinity of STP ^(b)
<i>Scomberomorus cavalla</i>	king mackerel	coastal migratory pelagic	all stages	juveniles
<i>Scomberomorus maculatus</i>	Spanish mackerel	coastal migratory pelagic	all stages	all stages
<i>Lutjanus griseus</i>	mangrove snapper	reef fish	all stages	all stages
<i>Sciaenops ocellatus</i>	red drum	red drum	all stages	all stages
<i>Farfantepenaeus aztecus</i>	brown shrimp	shrimp	all stages	larvae, juveniles
<i>Farfantepenaeus duorarum</i>	pink shrimp	shrimp	all stages	larvae, juveniles
<i>Litopenaeus setiferus</i>	white shrimp	shrimp	all stages	larvae, juveniles
<i>Menippe adina</i>	Gulf stone crab	stone crab	all stages	all stages

^(a) “All stages” indicates that egg, larvae, juvenile, and adult EFH are present.

^(b) The species’ life stages that do not occur in the vicinity of STP were eliminated based on depth or salinity requirements or both, which are presented in GMFMC’s *Final EIS for the Generic Essential Fish Habitat Amendment for Gulf of Mexico* fishery management plans (GMFMC 2004).

11 A brief discussion of each EFH species appears below. This section summarizes information
 12 on each species from the GMFMC’s *Final EIS for the Generic Essential Fish Habitat*
 13 *Amendment for Gulf of Mexico* fishery management plans (GMFMC 2004) unless otherwise
 14 noted.

15 King and Spanish Mackerel. King mackerel (*Scomberomorus cavalla*) and Spanish mackerel
 16 (*Scomberomorus maculates*) occur in the Gulf of Mexico. Concentrated populations of king
 17 mackerel occur in the coastal waters of South Florida and Louisiana, and the most concentrated
 18 population of Spanish mackerel is off the coast of Florida. Adults of both species generally
 19 inhabit reefs and coastal waters with salinity ranging from 32 to 36 ppt. Spanish mackerel
 20 prefer waters of up to 75 m (250 ft) and will occasionally inhabit estuaries. King mackerel
 21 inhabit waters up to 200 m (660 ft), though they most often occupy waters less than 80 m
 22 (260 ft). Adult king mackerel eat jacks, snappers, grunts, halfbeaks, penaeid shrimp, squid,
 23 and—less commonly—crustaceans and mollusks. Spanish mackerel eat clupeids, engraulids,
 24 carangids, and squid. Predators of both species include pelagic sharks, little tunny, and
 25 dolphin.

1 King mackerel spawn over the outer continental shelf from May to October, while Spanish
2 mackerel spawn over the inner continental shelf. Both species' eggs are pelagic and buoyant.
3 King mackerel larvae inhabit the middle and outer continental shelf, while Spanish mackerel
4 larvae move to the inner continental shelf. Larvae consume smaller larval fish such as
5 carangids, clupeids, and engraulids. Young tuna and dolphins prey upon king mackerel larvae.
6 Juveniles inhabit both offshore and estuarine waters and eat smaller fish and invertebrates.
7 Little tunny, dolphin, and other pelagic fish prey on juveniles.

8 Mangrove Snapper. Larval, juvenile, and adult mangrove snapper (*Lutjanus griseus*) primarily
9 occupy inshore habitats, such as estuaries and continental shelf waters up to 180 m (590 ft) in
10 depth. They inhabit waters about 32 km (20 mi) offshore and inshore waters through freshwater
11 creeks and rivers. Mangrove snappers use a wide variety of habitats, including mangrove,
12 sandy grassbeds, and coral reefs. Mangrove snapper spawn pelagic eggs off shore near reefs
13 from June to August. As larvae grow, they move inshore toward estuarine habitats, especially
14 those with dense beds of *Halodule* and *Syringodium* sea grasses. As with adults, juveniles
15 inhabit marine, estuarine, and riverine habitats. Juveniles and adults are most often found near
16 mangroves, where they forage on small fish and crustaceans (Croker 1962; Patillo et al. 1997).
17 Patillo et al. (1997) indicated that only adults and juvenile stages occur within Matagorda Bay
18 and that even these stages are rare.

19 Red Drum. Red drum (*Sciaenops ocellatus*) occur throughout the Gulf of Mexico in shallow
20 estuarine waters up to about 40 m (130 ft) off shore. They inhabit a variety of substrates,
21 including seagrass, sand, mud, and oyster reefs, and can tolerate freshwater through high
22 salinity waters. Red drum move to deep offshore waters in the fall where they spawn in inlet
23 and bay mouths. Eggs hatch in the Gulf, and larvae make their way into estuaries where they
24 remain until maturity. Larvae feed exclusively on mysids, amphipods, and shrimp. Juveniles
25 most often inhabit shallow, protected waters with grassy or muddy bottoms and feed on crabs,
26 shrimp, and small fish. As red drum grow, they shift more of their diet to crabs and eat less fish.
27 Predators include many larger fish species, such as spot (*Leiostomus xanthurus*) and Atlantic
28 croaker (*Micropogon undulates*), sharks, amberjacks (*Seriola* spp.), and other large piscivorous
29 fish. Patillo et al. (1997) indicated that all life stages of red drum were common in Matagorda
30 Bay.

31 Brown, White, and Pink Shrimp. Brown shrimp (*Farfantepenaeus aztecus*) inhabit rivers,
32 estuaries, and offshore Gulf waters to depths of 100 m (330 ft). Adults spawn in spring and
33 summer months in waters at least 18 m deep and of temperatures between 17 and 29 °C
34 (63 to 84 °F). Eggs are demersal, and larvae are pelagic and feed on planktonic algae and
35 zooplankton. On flood tides, larvae and juveniles move into estuaries with shallow waters and
36 submerged aquatic vegetation. They are tolerant of a wide-range of salinities and have been
37 recorded as occurring in waters from 0 to 70 ppt. Adults inhabit Gulf waters from mean low tide
38 to the continental shelf in areas with silt, muddy sand, or sandy substrate.

39 White shrimp (*Litopenaeus setiferus*) inhabit shallower waters than brown shrimp—generally
40 only out to a depth of 40 m (130 ft) but most often less than 27 m (89 ft). They spawn in waters
41 of 9 to 34 m (30 to 110 ft) in spring, summer, and fall. On flood tides, larvae and juveniles move
42 into estuaries with muddy or peat bottoms and significant amounts of detritus. Juvenile white
43 shrimp are often more highly associated with marsh edges, and they feed on sand, detritus,
44 organic matter, mollusk fragments, ostracods, copepods, and insect larvae. Similar to brown
45 shrimp, white shrimp emigrate from rivers and estuaries to deeper Gulf waters as adults.

46 Pink shrimp (*Farfantepenaeus duorarum*) occupy deeper waters (up to 110 m (360 ft)) than
47 either the brown or white shrimp. They spawn year-round at depths of 22 to 47 m (72 to 150 ft)
48 and temperatures from 19.6 to 30.6 °C (67.3 to 87.1 °F). Post-larvae migrate to estuaries on

Affected Environment

1 the flood tides at night in the spring and fall. They inhabit seagrass and mangrove habitats
2 where they burrow into sand and shell mud substrate and return to the water column to feed at
3 night. Juveniles eat a wide variety of organisms, including red and blue-green algae, diatoms,
4 dinoflagellates, polychaetes, nematodes, shrimp, mysids, copepods, isopods, amphipods,
5 mollusks, forams, and fish. Adults move from estuaries into Gulf waters with sand and shell
6 substrate. They are most abundant in waters with depths of 9 to 48 m (30 to 160 ft).

7 Gulf Stone Crab. The Gulf stone crab (*Menippe adina*) occupies bottom habitats from less than
8 1 m (3 ft) (shoreline) to depths of 61 m (200 ft). Adults seek out habitat in which they can
9 burrow under the surface, including rock ledges, coral heads, seagrass patches, oyster bars,
10 rock jetties, and artificial reefs. Adults feed mainly on oysters (Wilber 1989). Females maintain
11 eggs on their abdomen until they hatch and become planktonic. As they metamorphose to
12 larvae, they become epibenthic and settle to areas providing cover such as rubble and seagrass
13 beds. Juveniles inhabit the bottom of the water column but do not burrow. Both adults and
14 juveniles can tolerate salinities up to 33 ppt. Juveniles feed on small mollusks, worms, and
15 crustaceans. Larvae require higher salinities of 30 to 35 ppt and warm water (greater than
16 86 °F (30 °C)) for optimum growth and survival. All life stages of Gulf stone crab are considered
17 common throughout the year in Matagorda Bay (Patillo et al. 1997).

18 EFH Species Identified During STP Aquatic Studies. This section briefly discusses EFH
19 species in STP aquatic studies. Section 4.5 discusses these studies in detail. Of the nine
20 species with designated EFH, two species (brown and white shrimp) have appeared in STP
21 impingement or entrainment samples. ENSR (2008a) collected mangrove snapper via gill net,
22 but this species has not appeared in impingement or entrainment samples. Additionally,
23 ENSR (2008a) observed red drum, but ENSR did not collect this species in impingement and
24 entrainment samples or with any of the sample gears.

25 McAden et al. (1984, 1985) conducted studies to estimate entrainment impacts by collecting
26 surface plankton samples in front of the RMPF. McAden et al. (1984, 1985) also conducted
27 impingement studies by washing all organisms off two intake screens and filtering them through
28 a dip net. Section 4.5 discusses this study's methods in more detail. McAden et al. undertook
29 this study to confirm the accuracy of pre-operational entrainment and impingement loss
30 predictions for 1975 through 1976. McAden (1984) collected the post-larval stage of brown and
31 white shrimp sporadically in very low densities. Post-larval white and brown shrimp appeared in
32 Colorado River plankton net, trawl, and seine samples sporadically and in very low densities
33 (McAden et al. 1983). McAden et al. (1983, 1984) also collected white shrimp in plankton net
34 samples in the siltation basin. White shrimp appeared in impingement samples in both 1983
35 (16 individuals) and 1984 (4 individuals) in very low numbers (McAden et al. 1983, 1984).
36 Brown shrimp did not appear in impingement samples in either year.

37 In 2007 and 2008, ENSR (2008a) conducted impingement and entrainment studies at the CWIS
38 on the MCR from May 2007 through April 2008 as part of the STP, Units 3 and 4, COL
39 application. Section 4.5 discusses this study's methods. During the study, ENSR (2008a)
40 collected two mangrove snappers via gill net in the MCR. In October 2007, mangrove snappers
41 accounted for 2 percent of the fish in trawl samples. The species was not present, or accounted
42 for less than 1 percent of trawl samples, for all other sample months. ENSR noted that several
43 large schools of red drum were observed during the study, but none were collected in any of the
44 sample gears during the study. Of the shrimp species, ENSR (2008a) collected white shrimp
45 and brown shrimp in entrainment samples. These species made up 3 percent and less
46 than 1 percent of total samples, respectively. ENSR did not collect any king mackerel, Spanish
47 mackerel, pink shrimp, or Gulf stone crab in any of the study samples.

1 **2.2.8.7 Species Protected Under State of Texas Statutes**

2 The Texas legislature authorized the TPWD to establish a list of State-endangered species
 3 in 1973, for animals, and in 1988, for plants. Title 5, *Wildlife and Plant Conservation*,
 4 Chapter 68, *Endangered Species*, of the State of Texas’s Statutes prohibits individuals from
 5 capturing, trapping, taking, or killing as well as possessing, selling, or distributing listed animal
 6 species. Chapter 88, *Endangered Plants*, prohibits individuals from collecting or selling listed
 7 plants obtained from public land without a TPWD-issued permit. Table 2–11 contains
 8 State-listed species that have the potential to occur on the STP site or along the transmission
 9 line corridors. Additionally, all Federally listed species that appear in Table 2–9 are
 10 State-protected as well.

11 **Table 2–11. State-listed Species**

Species	Common Name	State Status ^(a)	Potential Occurrence ^(b)	
			Onsite	Along T-line ROWs
Amphibians				
<i>Eurycea latitans</i>	Cascade Caverns salamander	T		x
<i>Eurycea tridentifera</i>	comal blind salamander	T		x
Birds				
<i>Buteo albicaudatus</i>	white-tailed hawk	T	x	x
<i>Buteo albonotatus</i>	zone-tailed hawk	T		x
<i>Egretta rufescens</i>	reddish egret	T	x	x
<i>Falco peregrinus anatum</i>	American peregrin falcon	T	x	x
<i>Falco peregrinus tundrius</i>	arctic peregrin falcon	T	x	x
<i>Haliaeetus leucocephalus</i>	bald eagle	T	x	x
<i>Mycteria americana</i>	wood stork	T	x	x
<i>Pelecanus occidentalis</i>	brown pelican	E	x	x
<i>Plegadis chihi</i>	white-faced ibis	T	x	x
<i>Sterna fuscata</i>	sooty tern	T	x	x
Fish				
<i>Cycleptus elongatus</i>	blue sucker	T	x	x
<i>Satan eurystomus</i>	widemouth blindcat	T		x
<i>Trogloglanis pattersoni</i>	toothless blindcat	T		x
Mollusks				
<i>Lampsilis bracteata</i>	Texas fatmucket	T		x
<i>Quadrula aurea</i>	golden orb	T		x
<i>Quadrula houstonensis</i>	smooth pimpleback	T	x	x

Affected Environment

Species	Common Name	State Status ^(a)	Potential Occurrence ^(b)	
			Onsite	Along T-line ROWs
<i>Quadrula petrina</i>	Texas pimpleback	T		x
<i>Truncilla macrodon</i>	Texas fawnsfoot	T	x	
Reptiles				
<i>Cemophora coccinea lineri</i>	Texas scarlet snake	T	x	x
<i>Crotalus horridus</i>	timber (canebrake) rattlesnake	T	x	x
<i>Drymarchon melanurus erebennus</i>	Texas indigo snake	T		x
<i>Gopherus berlandieri</i>	Texas tortoise	T	x	x
<i>Liochlorophis vernalis</i>	smooth green snake	T	x	
<i>Macrochelys temminckii</i>	alligator snapping turtle	T		x
<i>Phrynosoma cornutum</i>	Texas horned lizard	T	x	x

^(a) E=endangered; T=threatened

^(b) The STP site is located in Matagorda County. The transmission lines associated with the STP site traverse Matagorda County as well as Bexar, Brazoria, Colorado, DeWitt, Fayette, Gonzales, Guadalupe, Jackson, Lavaca, Wharton, and Wilson Counties.

Sources: NRC 2011b; STPNOC 2010b; TPWD 2011c, 2011f

1 **2.2.9 Socioeconomics**

2 This section describes current socioeconomic factors that have the potential to be directly or
3 indirectly affected by changes in operations at STP, Units 1 and 2. STP, and the communities
4 that support it, can be described as a dynamic socioeconomic system. The communities
5 provide the people, goods, and services required to operate the nuclear power plant. Power
6 plant operations, in turn, provide wages and benefits for people and dollar expenditures for
7 goods and services. The measure of a communities' ability to support STP, Units 1 and 2,
8 operations depends on the ability of the community to respond to changing environmental,
9 social, economic, and demographic conditions.

10 The socioeconomic region of influence (ROI) is defined by the area where STP, Units 1 and 2,
11 employees and their families reside, spend their income, and use their benefits, thereby
12 affecting the economic conditions of the region. The ROI consists of a two-county area
13 (Brazoria and Matagorda Counties), where approximately 84 percent of STP employees reside.

14 STPNOC employs a permanent workforce of approximately 1,378 workers at STP, Units 1
15 and 2, with approximately 84 percent living in Brazoria and Matagorda Counties (see
16 Table 2–12) (STPNOC 2010b). Of the remaining 16 percent of the workforce, most are divided
17 among 18 counties across Texas and other states, with numbers ranging from 1 to
18 62 employees per county. Given the residential locations of STP, Units 1 and 2, employees, the
19 most significant impacts of plant operations are likely to occur in Brazoria and Matagorda
20 Counties. The focus of the socioeconomic impact analysis in this SEIS is, therefore, on the
21 impacts of continued STP, Units 1 and 2, operations on these two counties.

1

Table 2–12. STP, Employee Residence by County

County	# of Employees	% of Total
Brazoria	298	22
Matagorda	851	62
Fort Bend	54	4
Wharton	62	4
Other	96	7
Other states	17	1
Total	1,378	100

Source: STPNOC 2010b

2 Refueling outages at STP, Units 1 and 2, normally occur at 18-month intervals. During refueling
3 outages, site employment increases by as many as 1,350 temporary workers for approximately
4 1 to 2 months (STPNOC 2010b). Most of these workers are assumed to be located in the same
5 geographic areas as STP, Units 1 and 2, employees. The following sections describe the
6 housing, public services, offsite land use, visual aesthetics and noise, population demography,
7 and the economy in the ROI surrounding STP, Units 1 and 2.

8 **2.2.9.1 Housing**

9 Table 2–13 lists the total number of occupied and vacant housing units, vacancy rates, and
10 median value in the two-county ROI. According to American Community Survey, there were
11 approximately 138,000 housing units in the socioeconomic region, of which approximately
12 117,000 were occupied. The median value of owner-occupied housing units in Brazoria and
13 Matagorda Counties were \$146,700 and \$90,400 respectively. Brazoria County had a lower
14 vacancy rate (12.6 percent) than Matagorda County, which had a 27.9 percent vacancy rate
15 (USCB 2011).

16

Table 2–13. Housing in Brazoria and Matagorda Counties in 2010

	Brazoria	Matagorda	ROI
Total units	118,813	18,827	137,640
Occupied housing units	103,828	13,568	117,396
Vacant units	14,985	5,259	20,244
Vacancy rate (%)	12.6	27.9	14.7
Median value (\$)*	146,700	90,400	118,550

Key: * estimated

Source: USCB 2010

17 **2.2.9.2 Public Services**

18 Water Supply. Brazoria and Matagorda Counties are located in southeastern Texas.
19 Information about municipal water suppliers in these counties, their permitted capacities or
20 maximum design yields or both, reported annual peak usage, and population served are
21 presented in Table 2–14. The Texas Water Development Board (TWDB) divided Texas into

Affected Environment

1 16 water-planning regions (Region A through Region P). Brazoria County is located in
 2 Region H, while Matagorda County is located in Region K.

3 Brazoria County is 1 of 15 counties located in Region H, which includes the Houston
 4 metropolitan area. Over 20 percent of the State's 2010 population resides in Region H. As
 5 seen in Table 2–14, the city of Pearland serves the largest population at 56,877 and has the
 6 highest average daily consumption (11.0 mgd), while the city of Clute serves the smallest at
 7 10,737 and has the lowest average daily consumption (0.361 mgd). Alvin serves 15 less people
 8 than Angleton but consumes slightly more water daily (EPA 2010).

9 Matagorda County is 1 of 14 counties located in Region K. Bay City, located approximately
 10 19.5 mi (31.4 km) north-northeast of STP, serves a population of 19,263 from a groundwater
 11 source with an average daily consumption of 2.41 mgd (EPA 2010).

12 STP withdraws potable water primarily from the deep-confined aquifer within the Beaumont
 13 Fountain. In 2009, STP withdrew 368,766,200 gal (1,395,931,917.5 liters) of water from five
 14 active onsite groundwater wells, of which 5 percent was used for sanitary and drinking
 15 purposes. STPNOC is permitted to withdraw an average of 2.7 mgd (STPNOC 2010b).

16 **Table 2–14. Brazoria and Matagorda County City Public Water**
 17 **Supply Systems (in mgd)**

Water Supplier	Primary Water Source	Average Daily Demand (mgd)	System Capacity (mgd)	Population Served
Brazoria County				
Alvin	GW	2.18	8.74	19,152
Angleton	SW	2.05	5.47	19,167
Clute	SW	0.36	2.08	10,373
Freeport	SW	1.40	0.00 (production vs. purchased)	12,708
Lake Jackson	SW	3.10	6.69	25,890
Pearland	SW	11.00	15,26	56,877
Matagorda County				
Bay City	GW	2.41	8.86	19,263

Surface Water = SW, Groundwater = GW

Source: EPA 2010

18 Education. Brazoria County has eight school districts consisting of 4 pre-kindergarten,
 19 43 elementary, 23 middle/junior high/intermediate, 15 high schools, 10 alternative, 1 charter,
 20 and 1 grade 9 school. During the 2009 to 2010 school year, enrollment was 60,251
 21 (NCES 2011).

22 Matagorda County has five districts consisting of 8 pre-kindergarten, 8 elementary,
 23 4 middle/junior high/intermediate, 4 high schools, and 1 alternative school. During the 2009 to
 24 2010 school year, enrollment was 7,185 (NCES 2011).

25 Transportation. STP is located in an area severed by U.S. highways, FMs, and county roads.
 26 Within 50 miles of STP, there are no interstate highways; however, there are two U.S. highways
 27 (U.S. 59 and U.S. 87). U.S. 59 runs northeast to southwest connecting Fort Bend, Wharton,

1 Jackson, and Victoria Counties. U.S. 87 runs northwest to southeast connecting Victoria and
 2 Calhoun County.

3 STP can be accessed by FM 521, which runs east and west. FM 521 is accessible by several
 4 FM and State highways, which would be most commonly commuted by STP workers. Workers
 5 traveling from the east side of Matagorda County and all of Brazoria County would likely take
 6 TX-60 south and exit at FM 521. Workers commuting from the north would likely travel on
 7 TX-35 west, exiting on to FM 1468 south or FM 1095 south. Workers arriving from the west are
 8 likely to travel on TX-35 east, exiting onto FM 521 east.

9 Table 2–15 lists commuting routes to STP and average annual daily traffic (AADT) volume
 10 values. The AADT values represent traffic volumes for a 24-hour period factored by both day of
 11 week and month of year.

12 **Table 2–15. Major Commuting Routes in the Vicinity of STP, 2010 AADT**

Roadway & Location	AADT ^(a)
TX-60 South from Bay City to FM 521 West	2,400–3,000
FM 2078 West to FM 2668 South	310
FM 2668 South from Bay City to FM 521 West	1,050–2,200
FM 1468 South from TX-35 to FM 521 East	700–940
FM 1095 South from TX-35 to FM 521 East	390–630
FM 2853 South to FM 521 East	510–580
FM 521 West from TX-60	1,600–2,500
FM 521 East from FM 1095	1,150

^(a) All AADTs represent traffic volume during the average 24-hour day during 2010.

Key: FM = Farm-to-Market; TX = Texas

Source: TXDOT 2011

13 **2.2.9.3 Offsite Land Use**

14 Offsite land use conditions in Brazoria and Matagorda Counties are described in this section.
 15 Approximately 84 percent of the STP permanent workforce lives in these two counties. Within
 16 the region of STP, approximately 61 percent of the land is agricultural, 18 percent forest,
 17 10 percent rangeland, 5 percent wetland, 2.5 percent urban or developed land, 2 percent
 18 freshwater bodies, and less than 1 percent barren land (STPNOC 2010d).

19 Brazoria County occupies approximately 1,350 mi² (3,496 km²) (USCB 2010). Agricultural land
 20 is principally used as pasture (52.8 percent) and cropland (35.2 percent). Livestock (mostly
 21 cattle and calves) comprise 45 percent of the total market value of agricultural products
 22 (livestock and crop product) sold in the county while crop sales comprise the remaining
 23 55 percent (mostly grains, dry beans and peas, nursery, and floriculture). The number of farms
 24 in Brazoria increased about 5 percent from 2002 to 2007. Farmland acreage in the county
 25 decreased 14 percent during the same period, and the average size of a farm decreased
 26 18 percent to 205 ac (82 ha) (NASS 2009).

27 Matagorda County occupies approximately 1,100 mi² (2,849 km²) (USCB 2010). Agricultural
 28 land is principally used as pasture (51.08 percent) and cropland (40.63 percent). Crop sales
 29 (mostly nursery, greenhouse, floriculture, and sod) comprise 57 percent of the market value of

Affected Environment

1 agricultural products sold from Matagorda County. Livestock sales (agricultural products of
2 mostly cattle and calves) comprise the remaining 43 percent. The number of farms in
3 Matagorda County decreased from 2002 to 2007 by 9 percent. The number of farmland acres
4 decreased by 7 percent; however, the average size of farms increased by 2 percent from 625 ac
5 to 640 ac (NASS 2009).

6 Even though population growth is projected to continue, there is ample urban and rural land to
7 accommodate the anticipated growth over the next 20 years. However, agriculture will continue
8 to be the major land use outside urban areas.

9 **2.2.9.4 Visual Aesthetics and Noise**

10 The STP site boundary encloses approximately
11 12,220 ac, with site buildings, operations area,
12 support facilities, and transmission ROWs
13 occupying approximately 65 ac. Approximately
14 7,046 ac are occupied by other STP features, the
15 ECP, and the MCR (STPNOC 2010b).

The EPA generally uses 55 decibels (dBA) as the noise threshold level to protect against excess noise during outdoor activities. However, according to EPA, this threshold does “not constitute a standard, specification, or regulation,” but it was intended to provide a basis for State and local governments establishing noise standards.

16 The site includes approximately 1,700 ac of
17 undeveloped natural lowland habitat, with characteristics of the Texas Coastal Plain Province,
18 and the land surrounding the site is used for ranchland and farmland (STPNOC 2010b). STP is
19 situated on low elevation, generally less than 60 feet MSL, with open prairie habitat interspersed
20 with creek and river drainages flowing toward the Gulf coasts marshes. Trees are rare but can
21 be found along streams and in oak groves (STPNOC 2010d). Given the flat nature of the land,
22 the STP reactors are a prominent feature of the area, and the MCR is visible from the southeast
23 along the Colorado River as well as other points around the site.

24 Noise from nuclear plant operations can be detected off site. Sources of noise at STP include
25 the turbines and large pump motors. Given the industrial nature of the station, noise emissions
26 from the station are generally nothing more than an intermittent minor nuisance. However,
27 noise levels may sometimes exceed the 55 dBA level that EPA uses as a threshold level to
28 protect against excess noise during outdoor activities (EPA 1974). However, according to EPA,
29 this threshold does “not constitute a standard, specification, or regulation,” but it was intended to
30 provide a basis for State and local governments establishing noise standards.

31 **2.2.9.5 Demography**

32 According to 2000 Census information, an estimated 35,291 people lived within 20 mi (32 km) of
33 STP, which equates to a population density of 36 persons per square mile (STPNOC 2010b).
34 This translates to a Category 1, “most sparse,” population density using the GEIS measure of
35 sparseness (i.e., less than 40 persons per square mile and no community with 25,000 or more
36 people within 20 mi). Based on the GEIS proximity matrix, the STP proximity population density
37 is classified as Category 2 (no city with 100,000 or more people and less than 50 persons per
38 square mile within 50 mi). Therefore, with STP regional population classifications of sparseness
39 Category 1 and proximity Category 2, STP lies in a low-population area.

40 Table 2–16 shows population projections and growth rates from 1970 to 2050 in Brazoria and
41 Matagorda Counties in Texas. The growth rate in Brazoria County showed an increase in
42 population of nearly 30 percent between 2000 and 2010. Conversely, Matagorda County
43 showed a 3.3 percent decrease in population between 2000 and 2010. Both county populations
44 are projected to increase each decade through 2050.

1
2

Table 2–16. Population and Percent Growth in Brazoria and Matagorda Counties from 1970 to 2010 and Projected for 2020 to 2050

Year	Brazoria	% Change	Matagorda	% Change
1970	108,312	N/A	27,913	N/A
1980	169,587	56.6	37,828	35.5
1990	191,707	13.0	36,928	-2.4
2000	241,767	26.1	37,957	2.8
2010	313,166	29.5	36,702	-3.3
2020	349,474	11.6	40,789	11.1
2030	397,663	13.8	42,559	4.3
2040	445,852	12.1	44,330	4.2
2050	494,041	10.8	46,101	4.0

Source: USCB (2011) provided the population data for 1970 through 2010. The data forecast for 2020 through 2050 was calculated.

3
4
5
6
7

Demographic Profile. The 2010 demographic profiles of the two-county ROI population are presented in Table 2–17. In 2010, minorities (race and ethnicity combined) comprised 47.4 percent of the total two-county population. The minority population is largely Hispanic or Latino (28.8 percent) with the next largest minority population being Black or African American (11.7 percent).

8
9

Table 2–17. Demographic Profile of the Population in the STP Two-County Socioeconomic ROI in 2010

	Brazoria	Matagorda	ROI
Total population	313,166	36,702	349,868
Race (not Hispanic or Latino)—% of total population			
White	53.2	47.4	52.6
Black or African American	11.8	11.1	11.7
American Indian & Alaska Native	0.3	0.3	0.3
Asian	5.4	1.9	5.1
Native Hawaiian & Other Pacific Islander	0.0	0.0	0.0
Some other race	0.2	0.1	0.1
Two or more races	1.4	0.9	1.4
Ethnicity			
Hispanic or Latino	86,646	14,047	100,717
% of total population	27.7	38.3	28.8

Affected Environment

	Brazoria	Matagorda	ROI
Total minority	146,492	19,302	165,794
% minority	46.8	52.6	47.4

Source: USCB 2010

1 Transient Population. Within 50 mi (80 km) of STP, colleges and recreational opportunities
 2 attract daily and seasonal visitors who create demand for temporary housing and services. In
 3 2010, there were approximately 11,118 students attending colleges and universities within 50 mi
 4 (80 km) of STP (IES 2010).

5 In 2000, 1.7 percent of all housing units were considered temporary housing for seasonal,
 6 recreational, or occasional use in Brazoria County. By comparison, seasonal housing
 7 accounted for 12.9 percent of total housing units in Matagorda County (USCB 2010). Calhoun
 8 and Jackson Counties have the highest percent of temporary housing for seasonal, recreational,
 9 or occasional use, at 17.1 and 18.5 percent, respectively (USCB 2010). Table 2–18 provides
 10 information on seasonal housing for the nine counties located all or partly within 50 mi of STP.

11 **Table 2–18. Seasonal Housing in Counties Located within 50 mi of STP**

County ^(a)	Housing Units	Vacant Housing Units: For Seasonal, Recreational, or Occasional Use	%
Texas			
Brazoria	90,628	1,496	1.7
Calhoun	10,238	1,757	17.1
Colorado	9,431	634	6.7
Fort Bend	115,991	5,076	4.4
Jackson	6,545	1,209	18.5
Lavaca	9,657	377	3.9
Matagorda	18,611	2,407	12.9
Victoria	32,945	261	0.8
Wharton	16,606	291	1.8
Total	310,652	13,508	7.5

^(a) Counties within 50 mi (80 km) of STP with at least one block group located within the 50-mi (80 km) radius

Source: USCB 2010

12 Migrant Farm Workers. Migrant farm workers are individuals whose employment requires travel
 13 to harvest agricultural crops. These workers may or may not have a permanent residence.
 14 Some migrant workers follow the harvesting of crops, particularly fruit, throughout rural areas of
 15 the U.S. Others may be permanent residents near the STP site who travel from farm to farm
 16 harvesting crops.

17 Migrant workers may be members of minority or low-income populations. Because they travel
 18 and can spend a significant amount of time in an area without being actual residents, migrant
 19 workers may be unavailable for counting by census takers. If uncounted, these workers would
 20 be “underrepresented” in USCB minority and low-income population counts.

1 Information on migrant farm and temporary labor was collected in the 2007 Census of
 2 Agriculture. Table 2–19 provides information on migrant farm workers and temporary farm labor
 3 (less than 150 days) within 50 mi of the STP. According to the 2007 Census of Agriculture,
 4 approximately 6,513 farm workers were hired to work for less than 150 days and were
 5 employed on 2,233 farms within 50 mi of the STP. The county with the largest number of
 6 temporary farm workers (1,176) on 396 farms was Wharton County, Texas (NASS 2011).

7 In the 2002 Census of Agriculture, farm operators were asked for the first time whether or not
 8 they hired any migrant workers, defined as a farm worker whose employment required travel
 9 that prevented the migrant worker from returning to his or her permanent place of residence the
 10 same day. In the 50-mi radius of STP, 185 farms reported hiring migrant workers in the 2007
 11 Census of Agriculture. Lavaca and Wharton Counties reported the most farms (35 and 31,
 12 respectively) with hired migrant workers, followed by Brazoria and Fort Bend County, with
 13 28 and 25 farms, respectively (NASS 2011).

14 According to the 2007 Census of Agriculture estimates, 1,001 temporary farm workers (those
 15 working fewer than 150 days per year) were employed on 414 farms in Brazoria County, and
 16 754 temporary farm workers were employed on 247 farms in Matagorda County, respectively
 17 (NASS 2011).

18 **Table 2–19. Migrant Farm Workers and Temporary Farm Labor in Counties**
 19 **Located within 50 mi of STP**

County ^(a)	Number of Farms with Hired Farm Labor ^(b)	Number of Farms Hiring Workers for Less Than 150 Days	Number of Farm Workers Working for Less Than 150 days ^(b)	Number of Farms Reporting Migrant Farm Labor ^(b)
Texas				
Brazoria	414	332	1,001	28
Calhoun	66	54	143	4
Colorado	372	319	853	23
Fort Bend	299	230	621	25
Jackson	200	164	408	12
Lavaca	475	410	925	35
Matagorda	247	208	754	16
Victoria	252	216	632	11
Wharton	396	300	1,176	31
Total	2,721	2,233	6,513	185

^(a) Counties within 50 mi of STP with at least one block group located within the 50-mi radius

^(b) Table 7. Hired Farm Labor—Workers and Payroll: 2007 Census of Agriculture

Source: NASS 2009

20 **2.2.9.6 Economy**

21 Employment and Income. Between 2000 and 2010, the civilian labor force in Brazoria County
 22 increased 34.5 percent from 112,798 to 151,791. Matagorda County also increased during that

Affected Environment

1 time, 5.6 percent from 16,434 to 17,365 (USCB 2010). Major industries in Matagorda County
 2 are presented in Table 2–20.

3 According to 2008 through 2010 American Community Survey 3-Year Estimates, educational,
 4 health, and social services industry employs the most workers in the socioeconomic ROI
 5 (22.5 percent) followed by wholesale trade (16.7 percent). A list of employment by industry in
 6 the ROI is presented in Table 2–21.

7 **Table 2–20. Major Industries in Matagorda County**

Company Name	Type of Business
STPNOC	Electricity generation
Lyondell Basell	High density polyethylene resins
Valerus Compressors	Compressor fabrication
McAda Drilling Fluids	Oilfield support
OXEA Corporation	Chemical products
Celanese	Chemical products
Henderson Fabrication	Steel fabrication

Source: Matagorda County EDC 2007

8 **Table 2–21. Major Industries in ROI**

Industry	Brazoria	Matagorda	Total	%
Total employed civilian workers	142,741	15,080	157,821	
Agriculture, forestry, fishing & hunting, & mining	3,677	1,560	5,237	3.3
Construction	14,889	1,274	16,163	10.2
Manufacturing	17,962	1,422	19,384	12.3
Wholesale trade	4,638	310	26,299	16.7
Retail trade	13,694	2,273	15,967	10.1
Transportation, warehousing, & utilities	7,362	1,643	9,005	3.8
Information	2,382	219	2,601	1.6
Finance, insurance, real estate, rental, & leasing	7,061	458	7,519	4.8
Professional, scientific, management, administrative, & waste management services	15,182	812	15,994	10.1
Educational, health, & social services	32,613	2,887	35,500	22.5
Arts, entertainment, recreation, accommodation, & food services	9,196	960	10,156	6.4
Other services (except public administration)	7,758	802	8,560	5.4
Public administration	6,057	460	6,517	4.1

Source: USCB 2010

1 Estimated income information for the STP ROI is presented in Table 2–22. According to the
 2 USCB, people living in Brazoria County had a higher median household and per capita income
 3 than the State average, while Matagorda had a lower median household and per capita income
 4 (UCSB 2010). An estimated 10.6 and 19.2 percent of the population in Brazoria and Matagorda
 5 Counties were living below the official poverty level, respectively. The State of Texas as a
 6 whole had a higher percentage of persons living below the poverty level (17 percent) than
 7 Brazoria County, but lower than Matagorda County. The percentage of families living below the
 8 poverty level in Brazoria County (8.2 percent) was lower than the State of Texas average
 9 (13.2 percent), but Matagorda County (17.4 percent) was higher than the State average
 10 (UCSB 2010).

11 **Table 2–22. Estimated Income Information for STP ROI**

	Brazoria	Matagorda	Texas
Median household income (dollars) ^(a)	66,221	41,586	49,585
Per capita income (dollars) ^(a)	27,381	23,138	24,671
Individuals living below the poverty level (percent)	10.6	19.2	17
Families living below the poverty level (percent)	8.2	17.4	13.2

^(a) In 2008 inflation-adjusted dollars

Source: USCB 2011

12 Unemployment. According to the USCB’s 2006 through 2008 American Community Survey
 13 3-Year Estimates, the unemployment rates in Brazoria and Matagorda Counties were 4.0 and
 14 8.1 percent, respectively, in comparison to the unemployment rate of 4.8 percent for the State of
 15 Texas (USCB 2010).

16 Taxes. All privately owned property in Texas is subject to taxation by the county and school
 17 district in which it is located, unless specifically exempted by the Texas Constitution. Most
 18 private property owners in Texas also pay property taxes to local jurisdictions like cities and
 19 special districts within whose boundaries they reside. As such, property tax revenues are the
 20 major tax revenue source for counties and cities and the sole source of tax revenue for school
 21 districts. Exemptions from these standard practices are governed by the State, while county
 22 appraisal districts determine the value of properties with local jurisdictions setting the tax rates.
 23 After assessment, private property owners then make a consolidated payment to the County
 24 Tax Assessor, who retains the county’s portion and distributes the special district funds to the
 25 special districts, as appropriate (STPNOC 2010b).

26 STPNOC, owner of STP, Units 1 and 2, pays the majority of property taxes to the following
 27 taxing jurisdictions: Matagorda County, Matagorda County Hospital District, Navigation
 28 District #1, Drainage District #3, Palacios Seawall District, and the Coastal Plains Groundwater
 29 District (STPNOC 2010b). Table 2–23 presents each district’s total property tax levies, STP
 30 payments, and the proportion of the total constituted by STP. STP payments represent a major
 31 portion of property tax revenues for each of the districts, ranging from 22 percent to 75 percent
 32 in the various districts from 2004 to 2008. From 2003 to 2007, in Matagorda County specifically
 33 (excluding special districts within the county), STP property tax payments to Matagorda County
 34 alone have represented approximately one-third of the county’s total revenues (total revenues
 35 include property tax payments and other sources). In 2001, STPNOC negotiated an agreement
 36 with Matagorda County (to begin in 2002) to remit a county service fee in lieu of property taxes
 37 to the county, with a revenue cap of \$6.1 million. STPNOC has a similar agreement with the

Affected Environment

1 local hospital district, capped at \$2.6 million, to compensate the hospital for its extensive
 2 support of STPNOC's emergency response requirements (STPNOC 2010b).

3 **Table 2–23. Comparison of STP Owner Payments with Taxing District Property Tax**

Year ^(a)	Taxing District	Property Tax Levy(\$) ^(b)	Total STP	
			Payments(\$) ^(c)	% of Property Tax Levy
2003	Matagorda County ^(d)	8,214,934	6,100,000	74.3
	Matagorda County Hospital ^(d)	4,126,692	2,461,132	59.6
	Navigation District #1	459,261	360,394	78.5
	Drainage District #3	288,179	249,859	86.7
	Palacios Seawall	499,121	411,000	82.3
	Coastal Plains Groundwater	137,930	45,264	32.8
	Total	13,726,117	9,627,649	70.1
2004	Matagorda County ^(d)	8,122,946	6,100,000	75.1
	Matagorda County Hospital ^(d)	5,254,940	2,526,807	48.1
	Navigation District #1	413,867	360,410	87.1
	Drainage District #3	287,909	249,869	86.8
	Palacios Seawall	433,674	411,018	94.8
	Coastal Plains Groundwater	136,040	45,266	33.3
	Total	14,649,376	9,693,370	66.2
2005	Matagorda County ^(d)	8,191,213	6,100,000	74.5
	Matagorda County Hospital ^(d)	5,613,566	2,343,558	41.7
	Navigation District #1	370,191	251,822	68.0
	Drainage District #3	254,311	203,684	80.1
	Palacios Seawall	329,155	223,926	68.0
	Coastal Plains Groundwater	141,239	31,628	22.4
	Total	14,899,675	9,154,618	61.4
2006	Matagorda County ^(d)	9,038,864	6,100,000	67.5
	Matagorda County Hospital ^(d)	5,753,331	2,567,253	44.6
	Navigation District #1	486,645	342,148	70.3

Year ^(a)	Taxing District	Property Tax Levy(\$) ^(b)	Total STP	
			Payments(\$) ^(c)	% of Property Tax Levy
	Drainage District #3	242,142	200,299	82.7
	Palacios Seawall	327,813	230,162	70.2
	Coastal Plains Groundwater	153,850	39,422	25.6
	Total	16,002,645	9,479,284	59.2
2007	Matagorda County ^(d)	9,785,561	6,100,000	62.3
	Matagorda County Hospital ^(d)	6,236,490	2,600,000	41.7
	Navigation District #1	519,472	377,347	72.6
	Drainage District #3	229,254	190,125	82.9
	Palacios Seawall	276,122	200,131	72.5
	Coastal Plains Groundwater	166,556	45,019	27.0
	Total	17,213,455	9,512,622	55.3
2008	Matagorda County ^(d)	10,968,961	6,100,000	55.6
	Matagorda County Hospital ^(d)	7,035,468	2,600,000	37.0
	Navigation District #1	547,517	405,019	74.0
	Drainage District #3	246,398	202,883	82.3
	Palacios Seawall	276,565	203,844	73.7
	Coastal Plains Groundwater	187,828	48,454	25.8
	Total	19,262,737	9,560,200	49.6
	6-Year Total	95,754,005	57,027,743	59.6

^(a) Year levy and rate are for the following budget year. STP, Units 1 and 2, owners pay the standard millage rate for the special districts.

^(b) Total levies for 2003–2007 are from the Texas Comptroller of Public Accounts, Annual Property Tax Reports for Tax Years 2003, 2004, 2005, and 2006, as well as 2007 Property Tax Rates and Taxes. Total levies for 2008 are from the Matagorda County Tax Office.

^(c) For 2003–2006, tax payments are based on estimates from the Matagorda County Tax Office. For 2007 and 2008, estimated payments are based on actual NRG property tax statements.

^(d) Payments to Matagorda County and the Matagorda County Hospital District are based on an agreement between those entities and STPNOC, which sets a fixed amount to be paid each year.

Note: Totals may not add due to rounding.

Source: STPNOC 2010b

- 1 In addition to tax payments to the districts discussed above, STP pays taxes to other districts
- 2 within Matagorda County for undeveloped portions of the STP plant site that lie within other

Affected Environment

1 taxing districts and for other STP-related property within the county. The receiving districts are
 2 the Port of Bay City Conservation and Reclamation District, Drainage Districts 1 and 2, and the
 3 City of Bay City. Per State of Texas tax law, STP also pays taxes to three of the five
 4 independent school districts (ISDs) in Matagorda County—Matagorda, Bay City, and Tidehaven.
 5 Table 2–24 shows these payments. These payments represent a small proportion of those
 6 districts’ total levies in comparison to the percentages of the main district payments shown
 7 above.

8 **Table 2–24. STP, Units 1 and 2, Owner Payments to Other Taxing Districts in Matagorda**

Special District ^(a)	2007			2008		
	STP Owner Payments (\$)	District’s Est. Total Levy, 2007 (\$)	STP as % of Total	STP Owner Payments (\$)	District’s Est. Total Levy, 2008 (\$)	STP as % of Total
Port of Bay City	3,097	723,680	0.43	5,080	388,907	0.61
Conservation & Reclamation District	468	112,458	0.42	774	130,055	0.60
Matagorda ISD	74,943	2,525,549	2.97	75,038	2,677,920	2.80
Drainage District #1	6,419	1,607,005	0.40	6,179	1,681,062	0.37
Drainage District #2	2,000	342,514	0.58	6,278	419,134	1.50
Bay City ISD	0	12,840,989	-	1,942	14,265,846	0.01
Tidehaven ISD	22,837	5,029,792	0.45	79,465	6,541,043	1.21
City of Bay City	0	2,746,295	-	747	3,050,691	0.02
Total	111,771	25,925,282	0.43	175,502	29,599,657	0.59

^(a) “Other” = Taxing districts (Special District) other than Matagorda County; Matagorda County Hospital; Navigation District #1; Palacios Seawall District; Coastal Plains Groundwater District; and Drainage District #3.

Source: STPNOC 2010b

9 STP is located in the Electric Reliability Council of Texas region, a deregulated area that is not
 10 set to change in the foreseeable future. As such, STPNOC’s future taxation will continue to be
 11 based on the market value of the site and agreements with the county regarding service fees in
 12 lieu of property taxes (STPNOC 2010b).

13 **2.2.10 Historic and Archaeological Resources**

14 In accordance with 36 CFR 800.8(c), the NRC has elected to use the National Environmental
 15 Policy Act of 1969, as amended (NEPA), process to comply with the obligations under
 16 Section 106 of the National Historic Preservation Act (NHPA). In addition, NUREG-1555
 17 (NRC 2000) provides guidance to staff on how to conduct historic and cultural resource analysis
 18 in its environmental reviews.

19 In the context of NHPA, the NRC has determined that the area of potential effect (APE) for a
 20 license renewal action is the area at the power plant site and its immediate environment that
 21 may be affected by post–license renewal and land-disturbing activities associated with the
 22 proposed action (NRC 2011e). The APE may extend beyond the immediate environs in
 23 instances where post–license renewal and land-disturbing activities or refurbishment activities

1 specifically related to license renewal may potentially have an effect on historic properties
2 (NRC 2011e).

3 Cultural Background. Substantial archaeological records indicate that there was prehistoric
4 occupation of the STP area. During the Paleoindian era (pre-7800 B.C.), the earliest inhabitants
5 of Texas were the Clovis and Folsom peoples, which are typically associated with the hunting of
6 the extinct mammoth and bison, respectively. The Early Archaic era (7800 B.C. to 6000 B.C.)
7 represents a time when inhabitants became more settled, and numerous distinctive triangular
8 points and barbed specimens are noted from this era. The Middle Archaic period (6000 B.C.
9 to 2500 B.C.) reflects a diversity of stone tools and shell middens, while the Late Archaic era
10 (2500 B.C. to 700 B.C.) is marked by distinctive projectile points and stone tools. The
11 Late Prehistoric era (700B.C. to 1500 A.D.) is noted for the introduction of the bow and arrow
12 and pottery (NRC 2011b).

13 Hundreds of tribes inhabited Texas, and historians have a difficult time tracing their origin
14 because there are few written records from this period (University of Texas at Austin 2011).
15 The historic period can be traced to the 1500s, when the Spanish and French explored the
16 Texas Coast. With the arrival of the Europeans, there were many changes for the native
17 peoples. Diseases destroyed many populations, and several tribes fled to and from the area
18 that makes up the State of Texas today. Matagorda County was created in 1837, soon after
19 Texas gained its independence from Mexico (NRC 2011b). Today, there are three indigenous
20 groups living within the Texas borders that are listed among the Nation's many Federally
21 recognized tribes—the Alabama–Coushatta Tribe in East Texas; the Ysleta del Sur Pueblo, or
22 Tigua, in far West Texas; and the Kickapoo Traditional Tribe in southwest Texas along the
23 Texas–Mexico border (THC 2011). Other recognized tribes maintain ties to their ancestors'
24 homelands in the State of Texas and monitor sites throughout the State that are important to
25 their tribe and their history (THC 2011). Further cultural background is documented in the NRC
26 EIS (2011b) for the review of the STP, Units 3 and 4, combined license application.

27 Historic and Archaeological Resources at the STP Site. This section discusses the known
28 historic and archaeological resources at the STP site and in the surrounding area. The
29 following information was used to identify the historic and archaeological resources at the STP
30 site:

- 31 • original construction FES (NRC 1975);
- 32 • original ER (HL&P 1975), which included the Texas Archaeological Survey
33 Report (Hall and Ford 1973);
- 34 • original operation EIS (NRC 1986);
- 35 • STP, Units 3 and 4, ER, Revision 4 (STPNOC 2010d);
- 36 • STP, applicant's ER, operating license renewal stage, STP, Units 1 and 2
37 (STPNOC 2010b);
- 38 • EIS for COLs for STP, Units 3 and 4 (NRC 2011b);
- 39 • audit report regarding STP LRA—cultural resources (NRC 2011g);
- 40 • STP, RAI responses (STPNOC 2011g);
- 41 • consultation with THC (Texas Historical Commission); and
- 42 • consultation with tribes.

Affected Environment

1 In the early 1970s, the Texas Archaeological Survey conducted cultural resources investigations
2 of the STP site and surrounding area. The investigations included a literature review, a
3 pedestrian survey, and limited subsurface testing (NRC 2011b; STPNOC 2010b, 2010d). The
4 construction of STP, Units 1 and 2, was completed in the 1980s, and much of the site had been
5 heavily disturbed by construction activities and the creation of the reservoir.

6 STP identified three cultural resource sites within 10 mi of the STP site. Cultural resources
7 site 41MG48 is approximately 5 mi from the northeast boundary of the STP site and is
8 described as a late 19th century artifact scatter associated with homesteading Artifacts
9 consisted of ceramic, glass, and metal with manufacturing dates between 1890 and 1910. STP
10 reported that a homestead was established in the 1890s and dissolved in 1946. Cultural
11 resource investigations concluded that the site was not significant and that no further work on
12 the site was needed.

13 The closest recorded site is 41MG49, and it is approximately 4 mi from the northeastern
14 boundary of the STP site. Site 41MG49 was originally reported in the license renewal ER as
15 having no site form record (STPNOC 2010b). In July 2011, STP revisited the information and
16 discovered the missing site form record for site 41MG49 that described it as a shell midden with
17 no associated artifacts(STPNOC 2011g). Cultural resource investigations concluded that the
18 site was significant and should be studied further if the site were to be affected.

19 Site 41MG112 is approximately 5 mi from the northeastern boundary of the STP site and is
20 described as a dismantled historic farmstead dating to the mid-20th century. Cultural resource
21 investigations concluded that the site was not significant and that no further work on the site
22 was needed (STPNOC 2011g). These three sites (41MG48, 41MG49, and 41MG112) are
23 located outside of the. There are no recorded historic or archaeological resources on the STP
24 site.

25 STP identified a potential historic gravesite in its ER (STPNOC 2010b) located on the southeast
26 corner of the STP site. The NRC staff reviewed information during the environmental audit for
27 cultural resources at the STP site and discussed the status and protection of the historic
28 gravesite with STP environmental staff (NRC 2011g). STP staff had interviewed descendants of
29 the former property owner and confirmed the presence of a historic grave from the late 1800s;
30 however, this gravesite is not recorded and little is known about it (STPNOC 2011g).

31 **2.3 Related Federal and State Activities**

32 The NRC reviewed the possibility that activities of other Federal agencies might impact the
33 renewal of the operating license for STP. There are no Federal projects that would make it
34 necessary for another Federal agency to become a cooperating agency in the preparation of
35 this draft Supplemental EIS. There are no known American Indian lands within 50 mi of STP.
36 Federally owned facilities within 50 mi of STP include (NRC 2011b):

- 37 • Big Boggy—administered by the FWS—is a 5,000-ac national wildlife refuge
38 that borders Matagorda Bay and is approximately 9 mi southeast of the STP
39 site.
- 40 • San Bernard—administered by the FWS—is a 45,311-ac national wildlife
41 refuge that contains coastal prairies and salt marshes in southern Matagorda
42 and Brazoria Counties.

43 The NRC is required under Section 102(2)(C) of NEPA to consult with and obtain the comments
44 from any Federal agency that has jurisdiction by law or special expertise with respect to any
45 environmental impact involved in the subject matter of the EIS. For example, during the course

1 of preparing this DSEIS, the NRC consulted with the FWS and the NMFS. A complete list of
2 key consultation correspondences is listed in Appendix D.

3 Regarding Coastal Zone Management Act (CZMA) compliance status, pursuant to
4 Section 506.11(13) of Texas Administrative Code, STP license renewal falls within the definition
5 of Federal agency action:

6 A federal license or permit that a federal agency may issue that represents the
7 proposed federal authorization, approval, or certification needed by the applicant
8 to begin an activity. An action to renew, amend, or modify an existing license or
9 permit shall not be considered an action subject to the CMP [Coastal
10 Management Program] if the action only extends the time period of the existing
11 authorization without authorizing new or additional work or activities, would not
12 increase pollutant loads to coastal waters or result in relocation of a wastewater
13 outfall to a critical area, or is not otherwise directly relevant to the policies in
14 §501.14 of this title (relating to Policies for Specific Activities and Coastal Natural
15 Resource Areas).

16 In addition, in a letter dated January 29, 2010, the Coastal Coordination Council that
17 administers the CZMA compliance in Texas explained:

18 The project [STP] was undertaken before Texas had a federally approved [CMP]
19 and based on information provided in the [STPNOC's] letter dated
20 December 2, 2009, it has been determined that there are no significant
21 unresolved consistency issues. Therefore, pursuant to Section 506.11(13), this
22 project is consistent with the CMP goals and policies.

23 Hence, for license renewal purpose, STPNOC has obtained and maintained a consistency
24 certification in accordance with the CZMA.

25 **2.4 References**

26 10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, "Standards for
27 protection against radiation."

28 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic licensing of
29 production and utilization facilities."

30 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental
31 protection regulations for domestic licensing and related regulatory functions."

32 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for
33 renewal of operating licenses for nuclear power plants."

34 10 CFR Part 61. *Code of Federal Regulations*, Title 10, *Energy*, Part 61, "Licensing
35 requirements for land disposal of radioactive waste."

36 10 CFR Part 71. *Code of Federal Regulations*, Title 10, *Energy*, Part 71, "Packaging and
37 transportation of radioactive material."

38 30 TAC 1-307. Texas Administrative Code, Title 30, *Environmental Quality*, Part 1, "Texas
39 Commission on Environmental Quality," Chapter 307, "Texas Surface Water Quality Standards."

40 31 TAC 10-356. Texas Administrative Code, Title 31, *Natural Resources and Conservation*,
41 Part 10, "Texas Water Development Board," Chapter 356, "Groundwater Management."

42 36 CFR Part 800. *Code of Federal Regulations*. Title 36, *Parks, Forests, and Public Property*,
43 Part 800, "Protection of historic properties."

Affected Environment

- 1 40 CFR Part 81. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 81,
2 “Designation of areas for air quality planning purposes.”
- 3 40 CFR Part 141. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 141,
4 “National primary drinking water regulations.”
- 5 40 CFR Part 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190,
6 “Environmental radiation protection standards for nuclear power operations.”
- 7 50 CFR Part 10. *Code of Federal Regulations*, Title 50, *Wildlife and Fisheries*, Part 10,
8 “General provisions.”
- 9 50 CFR Part 22. *Code of Federal Regulations*, Title 50, *Wildlife and Fisheries*, Part 22, “Eagle
10 permits.”
- 11 52 FR 21059. U.S. Fish and Wildlife Service. Endangered and threatened wildlife and plants;
12 reclassification of the American alligator to threatened due to similarity of appearance
13 throughout the remainder of its range. *Federal Register* 52(107):21059–21064. June 4, 1987.
14 Available at <http://ecos.fws.gov/docs/federal_register/fr1263.pdf> (accessed June 21, 2011).
- 15 66 FR 36038. U.S. Fish and Wildlife Service. Endangered and threatened wildlife and plants;
16 final determination of critical habitat for wintering piping plovers. *Federal Register*
17 66(132):36038–36143. July 10, 2001.
- 18 69 FR 19975. National Oceanic and Atmospheric Administration. Endangered and threatened
19 species; establishment of species of concern list, addition of species to species of concern list,
20 description of factors for identifying species of concern, and revision of candidate species list
21 under the Endangered Species Act. *Federal Register* 69(73):19975–19979. April 15, 2004.
22 Available at <<http://www.nmfs.noaa.gov/pr/pdfs/fr/fr69-19975.pdf>> (accessed June 21, 2011).
- 23 75 FR 25174. National Marine Fisheries Service. Endangered and threatened wildlife and
24 plants; proposed listing for the largemouth sawfish. *Federal Register* 75(88):25174–25184.
25 May 7, 2010.
- 26 75 FR 9282. U.S. Fish and Wildlife Service. General provisions—revised list of migratory birds.
27 *Federal Register* 75(39):9282–9314. March 1, 2010.
- 28 Aronson R, Bruckner A, Moore J, Precht B, Weil E. 2008. “*Oculina varicosa*.” Available at
29 <<http://www.iucnredlist.org/apps/redlist/details/133165/0>> (accessed June 28, 2011).
- 30 [Audubon] Audubon Corkscrew Swamp Sanctuary. 2004. “American Alligator.” Available at
31 <<http://www.corkscrew.audubon.org/wildlife/alligators.html>> (accessed June 21, 2011).
- 32 [Audubon] Audubon Society. 2011. “Christmas Bird Count Database for Matagorda
33 County-Mad Island Marsh, 2009-2010.” Available at
34 <http://audubon2.org/cbchist/count_table.html> (accessed September 16, 2011).
- 35 Baker WB, Green GN. 1989. *1987-1988 Special Ecological Study for the South Texas Project*.
36 Houston, TX: Houston Light & Power Company. 46 p. ADAMS No. ML11256A057.
- 37 [BEG] Bureau of Economic Geology. 1996. “Physiographic Map of Texas.” The University of
38 Texas at Austin. Available at
39 <<http://www.beg.utexas.edu/UTopia/images/pagesizemaps/physiography.pdf>> (accessed
40 September 20, 2011).
- 41 Campbell L. 2003. *Endangered and Threatened Animals of Texas: Their Life History and*
42 *Management*. Austin, TX: Texas Parks and Wildlife Department. 127 p. Available at
43 <http://www.tpwd.state.tx.us/publications/pwdpubs/media/pwd_bk_w7000_0013.pdf> (accessed
44 September 7, 2011).

- 1 Clean Air Act of 1963, as amended. 42 U.S.C. §7401 et seq.
- 2 Clean Water Act of 1972, as amended. 33 U.S.C. §1251 et seq.
- 3 [CPGCD] Coastal Plains Groundwater Conservation District. 2011. Operating Permit, Permit
4 No. OP-04122805. Bay City, TX. ADAMS No. ML11256A058.
- 5 Croker R. 1962. Growth and food of the gray snapper, *Lutjanus griseus*, in the Everglades
6 National Park. *Transactions of the American Fisheries Society* 91(4):379–383.
- 7 DeVries D, Grimes CB, Lang KL, White DB. 1990. Age and growth of king and Spanish
8 mackerel larvae and juveniles from the Gulf of Mexico and U.S. South Atlantic Bight.
9 *Environmental Biology of Fishes* 29(1990):135–143.
- 10 Ducks Unlimited. 2006. “Ducks Unlimited and Partners Conserve 35,000 Acres Along the
11 Texas Gulf Coast.” Available at
12 <<http://www.ducks.org/news-media/texas-prairie-wetlands-project>> (accessed September 14,
13 2011).
- 14 Ducks Unlimited and [HLPC] Houston Power and Lighting Company. 1996. *Wetland
15 Development Agreement for the Texas Prairie Wetland Project Gulf Coast Joint Venture*.
16 October 23, 1996. ADAMS No. ML11256A057.
- 17 Endangered Species Act of 1973, as amended. 16 U.S.C. §1531 et seq.
- 18 [ENSR] ENSR Corporation. 2008a. *Aquatic Ecology—Main Cooling Reservoir and Circulating
19 Water Intake Structure Study, Unit 3 and 4, Licensing Project*. Prepared for STP Nuclear
20 Operating Company. Houston, TX: ENSR. 53 p. ADAMS No. ML11256A057.
- 21 [ENSR] ENSR Corporation. 2008b. *Ecological Survey Report—Threatened and Endangered
22 Species*. Prepared for STP Nuclear Operating Company. Houston, TX: ENSR. 32 p. ADAMS
23 No. ML080660150.
- 24 [ENSR] ENSR Corporation. 2008c. *Aquatic Ecology – Colorado River Monitoring Report,
25 Units 3 and 4 Licensing Project*. Houston, Texas. ADAMS No. ML081750196.
- 26 [EOE] Encyclopedia of Earth. 2008. “Great Plains Ecoregion.” Updated October 16, 2008.
27 Available at <[http://www.eoearth.org/article/Great_Plains_ecoregion_\(CEC\)](http://www.eoearth.org/article/Great_Plains_ecoregion_(CEC))> (accessed
28 September 13, 2011).
- 29 [EPA] U.S. Environmental Protection Agency. 1974. *Information on Levels of Environmental
30 Noise Requisite to Protect Public Health and Welfare with an Adequate Margin of Safety*.
31 Washington, DC: EPA. Report 550/9-74-004. Available at
32 <<http://www.nonoise.org/library/levels74/levels74.htm>> (accessed May 9, 2011).
- 33 [EPA] U.S. Environmental Protection Agency. 2010a. “Office of Solid Waste.” Available at
34 <<http://www.epa.gov/osw>> (accessed December 2010).
- 35 [EPA] U.S. Environmental Protection Agency. 2010b. “Safe Drinking Water Information System
36 (SDWIS), County Search, Brazoria and Matagorda County, Texas.” Available at
37 <http://iaspub.epa.gov/enviro/sdw_form_v2.create_page?state_abbr=TX> (accessed
38 June 2011).
- 39 [EPA] U.S. Environmental Protection Agency, 2010c, “Waste Environmental Management
40 Systems,” Available at <<http://www.epa.gov/osw/inforesources/ems/index.htm>> (accessed
41 December 2010).

Affected Environment

- 1 [EPA] U.S. Environmental Protection Agency. 2011. "Green Book: Currently Designated
2 Non-attainment Areas for All Criteria Pollutants." August 30, 2011. Available at
3 <<http://epa.gov/oaqps001/greenbk/ancl.html>> (accessed November 17, 2011).
- 4 [FMNH] Florida Museum of Natural History. 2009. "Ichthyology at the Florida Museum of
5 Natural History, Education, Biological Profiles: King Mackerel." Available at
6 <<http://www.flmnh.ufl.edu/fish/gallery/descript/kingmackerel/kingmackerel.html>> (accessed
7 September 9, 2011). ADAMS No. ML100600370.
- 8 [HL&P] Houston Light & Power Company. 1975. *Final Environmental Report for Construction*
9 *of STP, Units 1 & 2.*
- 10 [FWS] U.S. Fish and Wildlife Service. 2000. "Critical Habitat: What Is It?" May 2000.
11 Available at
12 <<http://www.fws.gov/verobeach/images/pdflibrary/Critical%20Habitat%20Fact%20Sheet.pdf>>
13 (accessed June 21, 2011).
- 14 [FWS] U.S. Fish and Wildlife Service. 2009. *Piping Plover (Charadrius melodus) 5-Year*
15 *Review: Summary and Evaluation.* Hadley, MA and Lansing, MI: FWS. September 2009.
16 214 p. Available at
17 <http://www.fws.gov/midwest/endangered/recovery/5yr_rev/pdf/PipingPlover5yr2009.pdf>
18 (accessed June 21, 2011).
- 19 [FWS] U.S. Fish and Wildlife Service. 2011a. "Find Endangered Species: Species By County
20 Report for Bexar, Brazoria, Colorado. DeWitt, Fayette, Gonzales, Guadalupe, Jackson, Lavaca,
21 Matagorda, Wharton, and Wilson Counties." Available at <<http://www.fws.gov/endangered/>>
22 (accessed May 19, 2011).
- 23 [FWS] U.S. Fish and Wildlife Service. 2011b. Letter from AM Strand, Field Supervisor, to
24 T Tran, Project Manager, NRC. Subject: Reply to request for species list for South Texas
25 license renewal review. June 2, 2011. ADAMS No. ML11173A241.
- 26 [FWS] U.S. Fish and Wildlife Service. 2011c. "Big Boggy National Wildlife Refuge." Available
27 at <<http://www.fws.gov/refuges/profiles/index.cfm?id=21542>> (accessed September 27, 2011).
- 28 [FWS] U.S. Fish and Wildlife Service. 2011d. "Piping Plover Fact Sheet." March 9, 2011.
29 Available at <<http://www.fws.gov/midwest/endangered/pipingplover/pipingpl.html>> (accessed
30 21 June 2011).
- 31 [FWS] U.S. Fish and Wildlife Service. Undated. "Migratory Birds & Habitat Programs:
32 Migratory Bird Treaty Act." Available at <<http://www.fws.gov/pacific/migratorybirds/mbta.htm>>
33 (accessed May 19, 2011).
- 34 [GCBO] Gulf Coast Bird Observatory. 2011. "Clive Runnells Family Mad Island Marsh
35 Preserve." Available at <<http://www.gcbo.org/html/madisland.pdf>> (accessed September 27,
36 2011).
- 37 [GMFMC] Gulf of Mexico Fishery Management Council. 2004. *Final Environmental Impact*
38 *Statement for the Generic Essential Fish Habitat Amendment to the Following Fishery*
39 *Management Plans of the Gulf of Mexico (GOM): Shrimp, Red Drum, Reef Fish, Stone Crab,*
40 *Coral and Coral Reef, Spiny Lobster, and Coastal Migratory Pelagic Resources.* Tampa, FL:
41 GMFMC. March 2004. 682 p. Available at
42 <<http://www.gulfcouncil.org/beta/gmfmcweb/downloads/Final%20EFH%20EIS.pdf>> (accessed
43 September 7, 2011).
- 44 Griffith G, Bryce S, Omernik J, Rogers A. 2007. *Ecoregions of Texas.* Project report to Texas
45 Commission on Environmental Quality. Corvallis, OR: Dynamac Corporation. December 2007.

- 1 134 p. Available at <ftp://ftp.epa.gov/wed/ecoregions/tx/TXeco_Jan08_v8_Cmprsd.pdf>
2 (accessed September 12, 2011).
- 3 Institute of Educational Science (IES). 2010. "College Opportunities Online Locator." Zip
4 Code 77414. October 2010. Available at <<http://nces.ed.gov/ipeds/cool/RefineSearch.aspx>>
5 (accessed January 2011).
- 6 [MACTEC] MACTEC Engineering and Consulting, Inc. 2009. *Conceptual Site Model for Units 1*
7 *and 2, Groundwater Protection Initiative, South Texas Project Electric Generating Station.*
8 Wadsworth, TX: MACTEC Engineering and Consulting, Inc. Revision 1. May 20, 2009.
9 ADAMS No. ML11256A058.
- 10 [Matagorda County EDC] Matagorda County Economic Development Corporation. 2007.
11 "Community Profile." Available at <<http://www.mcedc.net/index.php>> (accessed April 2012).
- 12 McAden DC, Greene GN, Baker WB Jr. 1984. *Colorado River Entrainment and Impingement*
13 *Monitoring Program Phase Two Studies. Report #1.* Prepared for STP Nuclear Operating
14 Company. October 1984. 58 p. ADAMS No. ML11256A057.
- 15 McAden DC, Greene GN, Baker WB Jr. 1985. *Colorado River Entrainment and Impingement*
16 *Monitoring Program Phase Two Studies. Report #2.* Prepared for STP Nuclear Operating
17 Company. October 1984. 30 p. ADAMS No. ML11256A057.
- 18 Miller MP, Haig SM, Gratto-Trevor CL, Mullins TD. 2009. Molecular population genetic
19 structure in the piping plover. U.S. Geological Survey Open File Report 2009–1032. 30 p.
20 Available at <<http://pubs.usgs.gov/of/2009/1032/pdf/OFR20091032.pdf>> (accessed
21 June 21, 2011).
- 22 Musick JA, Grubbs RD, Baum J, Cortés E. 2007. "Carcharhinus obscurus." Available at
23 <<http://www.iucnredlist.org/apps/redlist/details/3852/0>> (accessed June 28, 2011).
- 24 National Environmental Policy Act of 1969, as amended. 42 U.S.C. §4321 et seq.
- 25 National Historic Preservation Act of 1966. 16 U.S.C. §470 et seq.
- 26 [NCES] National Center for Education Statistics. 2010. "Search for Public School Districts."
27 Available at <<http://www.nces.ed.gov/ccd/districtsearch/>> (accessed June 2011).
- 28 [NMFS] National Marine Fisheries Service. 2009. "Species of Concern: Saltmarsh
29 Topminnow." January 16, 2009. Available at
30 <http://www.nmfs.noaa.gov/pr/pdfs/species/saltmarsh_topminnow_detailed.pdf> (accessed
31 September 7, 2011).
- 32 [NMFS] National Marine Fisheries Service. 2010a. "Bottlenose Dolphin (*Tursiops truncatus*
33 *truncatus*): Northern Gulf of Mexico Bay, Sound, and Estuarine Stocks." November 2010.
34 Available at <<http://www.nmfs.noaa.gov/pr/pdfs/sars/ao2010dobn-gmxb.pdf>> (accessed
35 27 June 2011).
- 36 [NMFS] National Marine Fisheries Service. 2010b. Letter from M Croom, Assistant Regional
37 Administrator for Habitat Conservation, to Johnson, Rulemaking and Directives Branch Chief,
38 NRC. Subject: Concurrence with EFH Assessment for STP, Units 3 and 4. ADAMS
39 No. ML101190379.
- 40 [NMFS] National Marine Fisheries Service. 2010c. Memorandum from RE Crabtree, Southeast
41 Regional Administrator, to J Lecky, Office of Protected Resources Director. Subject: Removal
42 of night shark from species of concern list. July 22, 2010. Available at
43 <http://www.nmfs.noaa.gov/pr/pdfs/species/night_shark_dm.pdf> (accessed June 28, 2011).

Affected Environment

- 1 [NMFS] National Marine Fisheries Service. 2010d. "Species of Concern: Ivory Tree Coral."
2 February 23, 2010. Available at
3 <http://www.nmfs.noaa.gov/pr/pdfs/species/ivorytreecoral_detailed.pdf> (accessed
4 June 28, 2011).
- 5 [NMFS] National Marine Fisheries Service. 2010e. "Species of Concern: Sand Tiger Shark."
6 February 23, 2010. Available at
7 http://www.nmfs.noaa.gov/pr/pdfs/species/sandtigershark_detailed.pdf (accessed
8 August 12, 2012).
- 9 [NMFS] National Marine Fisheries Service. 2011a. "Bottlenose Dolphin (*Tursiops truncatus*)."
10 Available at <<http://www.nmfs.noaa.gov/pr/species/mammals/cetaceans/bottlenosedolphin.htm>>
11 (accessed June 27, 2011).
- 12 [NMFS] National Marine Fisheries Service. 2011b. "Cetaceans: Whales, Dolphins, and
13 Porpoises." Available at <<http://www.nmfs.noaa.gov/pr/species/mammals/cetaceans/>>
14 (accessed May 19, 2011).
- 15 [NMFS] National Marine Fisheries Service. 2011c. E-mail from T Mincey, Program Analyst, to
16 T Tran, Project Manager, NRC. Subject: List of species under NMFS jurisdiction.
17 March 3, 2011. ADAMS No. ML110690848.
- 18 [NMFS] National Marine Fisheries Service. 2011d. "Proactive Conservation Program: Species
19 of Concern." January 20, 2011. Available at <<http://www.nmfs.noaa.gov/pr/species/concern/>>
20 (accessed March 30, 2011).
- 21 [NMFS] National Marine Fisheries Service. 2011e. "Species of Concern List." Available at
22 <<http://www.nmfs.noaa.gov/pr/species/concern/#list>> (accessed June 28, 2011).
- 23 [NRC] U.S. Nuclear Regulatory Commission. 1975. *Final Environmental Statement Related to*
24 *the Proposed South Texas Project Units 1 & 2*. Washington, DC: NRC. NUREG-75/019.
- 25 [NRC] U.S. Nuclear Regulatory Commission. 1986. *Final Environmental Statement Related to*
26 *the Operation of South Texas Project, Units 1 & 2*. Washington, DC: NRC. NUREG-1171.
27 August 1986. ADAMS No. ML11172A080.
- 28 [NRC] U.S. Nuclear Regulatory Commission. 1996. *Generic Environmental Impact Statement*
29 *for License Renewal of Nuclear Plants*. Washington, DC: NRC. NUREG-1437. May 1996.
30 ADAMS Nos. ML040690705 and ML040690738.
- 31 [NRC] U.S. Nuclear Regulatory Commission. 1999. Section 6.3—Transportation, Table 9.1,
32 Summary of findings on NEPA issues for license renewal of nuclear power plants. In: *Generic*
33 *Environmental Impact Statement for License Renewal of Nuclear Plants*. Washington, DC:
34 NRC. NUREG-1437, Volume 1, Addendum 1. August 1999. ADAMS No. ML04069720.
- 35 [NRC] U.S. Nuclear Regulatory Commission. 2000. *Environmental Standard Review Plan:*
36 *Standard Review Plans for Environmental Reviews for Nuclear Power Plants*. Washington, DC:
37 NRC. NUREG-1555.
- 38 [NRC] U.S. Nuclear Regulatory Commission. 2008. South Texas Project Units 3 and 4 COL
39 Site Audit and Scoping Trip Report. February 3-8, 2008. ADAMS No. ML081010440.
- 40 [NRC] U.S. Nuclear Regulatory Commission. 2011a. E-mail from B Martin, THC, to TK O'Neil,
41 PNNL. Subject: STP license renewal—SHPO meeting. May 2, 2011. ADAMS
42 No. ML11259A029.
- 43 [NRC] U.S. Nuclear Regulatory Commission. 2011b. *Environmental Impact Statement for*
44 *Combined Licenses (COLs) for South Texas Project Electric Generating Station, Units 3 and 4*.

- 1 Washington, DC: NRC. NUREG-1937, Volumes 1 and 2. ADAMS Nos. ML11049A000 and
2 ML11049A001.
- 3 [NRC] U.S. Nuclear Regulatory Commission. 2011c. *Essential Fish Habitat Assessment for*
4 *South Texas Project Electric Generating Station Units 3 and 4*. Washington, DC: NRC. Final
5 Report. ADAMS No. ML11049A001.
- 6 [NRC] U.S. Nuclear Regulatory Commission. 2011d. Letter from BM Pham, NRC, to DL Klima,
7 Advisory Council on Historic Preservation. Subject: South Texas Project, Units 1 and 2, license
8 renewal application review. January 27, 2011. ADAMS No. ML110200002.
- 9 [NRC] U.S. Nuclear Regulatory Commission. 2011e. Letter from BM Pham, NRC, to M Wolfe,
10 Texas Historical Commission. Subject: South Texas Project, Units 1 and 2, license renewal
11 application review (track no. 201002271). February 17, 2011. ADAMS No. ML110190549.
- 12 [NRC] U.S. Nuclear Regulatory Commission. 2011f. Letter from D Wrona, Branch Chief, to M
13 Orms M, FWS. Subject: Request for concurrence on list of Federally protected species.
14 February 16, 2011. ADAMS No. ML110190429.
- 15 [NRC] U.S. Nuclear Regulatory Commission. 2011g. Letter from T Tran, NRC, to GT Powell,
16 STPNOC. Subject: Audit report regarding South Texas Project license renewal application—
17 cultural resources. July 18, 2011. ADAMS No. ML11173A304.
- 18 [NRCS] Natural Resources Conservation Service. 2011, “Web Soil Survey, Soil Map—
19 Matagorda County, Texas, Map Unit Description—Matagorda County, Texas.” April 12, 2011.
20 Available at <<http://websoilsurvey.nrcs.usda.gov/app>> (accessed October 9, 2011).
- 21 Patillo ME, Czapl TE, Nelson DM, Monaco ME. 1997. *Distribution and Abundance of Fishes*
22 *and Invertebrates in Gulf of Mexico Estuaries*. Volume 2, Species Life History Summaries.
23 ELMR Reort No. 11. Silver Spring, MD: NOAA/NOS Strategic Environmental Assessments
24 Division.
- 25 Pollard D, Smith A. 2005. “Carcharias taurus.” Available at
26 <<http://www.iucnredlist.org/apps/redlist/details/3854/0>> (accessed June 28, 2011).
- 27 Ryder, PD. 1996. *Ground Water Atlas of the United States, Oklahoma, Texas*. Washington,
28 DC: U.S. Geological Survey. Available at <http://pubs.usgs.gov/ha/ha730/ch_e/index.html>
29 (accessed August 31, 2011).
- 30 Ryder, PD, Ardis, AF. 2002. *Hydrology of the Texas Gulf Coast Aquifer Systems, Regional*
31 *Aquifer-Systems Analysis-Gulf Coast Plain*. Reston, VA: U.S. Geological Survey. U.S.
32 Geological Survey Professional Paper 1416-E.
- 33 Santana FM, Lessa R, Carlson J. 2006. “Carcharhinus signatus.” Available at
34 <<http://www.iucnredlist.org/apps/redlist/details/60219/0>> (accessed June 28, 2011).
- 35 [STPNOC] South Texas Project Nuclear Operating Company. 2007. *2006 Annual*
36 *Environmental Operating Report, South Texas Project Electric Generating Station*. Bay City,
37 TX: STPNOC. April 2007. ADAMS No. ML071270211.
- 38 [STPNOC] South Texas Project Nuclear Operating Company. 2008. Letter from Gregory
39 Gibson, STPNOC, to NRC Document Control Desk. Subject: Response to RAI. July 15, 2008,
40 No. ML082040684.
- 41 [STPNOC] South Texas Project Nuclear Operating Company. 2009a. *Updated Final Safety*
42 *Analysis Report Units 1 and 2*. Bay City, TX: STPNOC. Revision 15. ADAMS No.
43 ML103220222.

Affected Environment

- 1 [STPNOC] South Texas Project Nuclear Operating Company. 2009b. *Water Conservation*
2 *Plan, STP Nuclear Operating Company, South Texas Project Electric Generating Station,*
3 *Certificate of Adjudication 14-5437 A.* May 1, 2009. Revision 2. ADAMS No. ML11256A058.
- 4 [STPNOC] South Texas Project Nuclear Operating Company. 2010a. *2009 Annual*
5 *Environmental Operating Report, South Texas Project Electric Generating Station.* Bay City,
6 TX: STPNOC. April 2010. ADAMS No. ML101260530.
- 7 [STPNOC] South Texas Project Nuclear Operating Company. 2010b. *South Texas Project,*
8 *Units 1 and 2, License Renewal Application.* Bay City, TX: STPNOC. Appendix E,
9 "Environmental Report." September 2010. ADAMS No. ML103010263.
- 10 [STPNOC] South Texas Project Nuclear Operating Company. 2010c. *South Texas Project,*
11 *Units 3 and 4, Combined License Application.* Bay City, TX: STPNOC. Part 2, "Final Safety
12 Analysis Report," Revision 4. ADAMS No. ML102860517.
- 13 [STPNOC] STP Nuclear Operating Company. 2010d. South Texas Project, Units 3 and 4,
14 Combined License Application. Bay City, TX: STPNOC. Part 3, "Environmental Report,"
15 Revision 4. ADAMS No. ML102860592.
- 16 [STPNOC] South Texas Project Nuclear Operating Company (STPNOC). 2010e. Letter from
17 Mark McBurnett, STPNOC, to NRC Document Control Desk. Subject: Additional Information
18 Regarding Draft Environmental Impact Statement. September 9, 2010. ADAMS
19 No. ML102600127.
- 20 [STPNOC] South Texas Project Nuclear Operating Company. 2011a. 2010 Annual
21 Environmental Operating Report, South Texas Project Electric Generating Station. Bay City,
22 TX: STPNOC. April 2011. ADAMS Nos. ML111250423 and ML111250429.
- 23 [STPNOC] South Texas Project Nuclear Operating Company. 2011b. Letter from AW Harrison,
24 Manager Licensing, to NRC Document Control Desk. Subject: Transmittal of documents to
25 support review of the STP LRA. TAC Nos. ME 4938 and ME 5122. STP Letter
26 No. NOC-AE-11002720. August 31, 2011. ADAMS Nos. ML11256A056 and ML11256A059.
- 27 [STPNOC] South Texas Project Nuclear Operating Company. 2011c. Letter from GT Powell,
28 STPNOC, to NRC Document Control Desk. Subject: Response to RAI for the review of the
29 STP LRA. July 5, 2011. ADAMS No. ML11193A016.
- 30 [STPNOC] South Texas Project Nuclear Operating Company. 2011d. Letter from GT Powell,
31 Vice President, STPNOC, to NRC Document Control Desk. Subject: Response to RAI for the
32 STP LRA. TAC Nos. ME4938 and ME5122. STP Letter No. NOC-AE-11002719.
33 September 6, 2011. ADAMS No. ML11255A211.
- 34 [STPNOC] South Texas Project Nuclear Operating Company. 2011e. Letter from GT Powell,
35 Vice President, STPNOC, NRC Document Control Desk. Subject: Response to RAI for the
36 review of the STP LRA. TAC Nos. ME4938 and ME5122. STP Letter No. NOC-AE-11002723.
37 September 12, 2011. ADAMS No. ML11259A014.
- 38 [STPNOC] South Texas Project Nuclear Operating Company. 2011f. Letter from GT Powell,
39 STPNOC, to NRC Document Control Desk. Subject: Response to RAI for the review of the
40 STP LRA. October 18, 2011. ADAMS No. ML11298A085.
- 41 [STPNOC] South Texas Project Nuclear Operating Company. 2011g. Letter from GT Powell,
42 Vice President, STPNOC, NRC Document Control Desk. Subject: response to RAI for the
43 review of the LRA. July 5, 2011. ADAMS No. ML11193A074.

- 1 [STPNOC] South Texas Project Nuclear Operating Company. 2012a. *South Texas Project,*
2 *Units 1 and 2, Clarification of Information.* Bay City, TX: STPNOC. January 10, 2012. ADAMS
3 No. ML12011A188.
- 4 [STPNOC] South Texas Project Nuclear Operating Company. 2012b. Letter from GT Powell,
5 Vice President, STPNOC, NRC Document Control Desk. Subject: response to RAI for the
6 review of the LRA. March 12, 2012. ADAMS No. ML12079A014.
- 7 [TCEQ] Texas Commission on Environmental Quality. 2005. STPNOC TPDES Permit
8 No. WQOOO 1908000, Permit to Discharge Wastes. July 21, 2005. ADAMS
9 No. ML11256A057.
- 10 [TCEQ] Texas Commission on Environmental Quality. 2009. Letter from L Lancaster, Team
11 Leader Application Review and Processing Team, TCEQ, to SL Dannhardt, STPNOC. Subject:
12 Declaration of Administrative Completeness, STPNOC, Permit No. WQ0001908000 (EPA ID
13 No. TX0064947) (RN102395654), Type of Authorization: Renewal. July 13, 2009. ADAMS
14 No. ML11255A211.
- 15 [TCEQ] Texas Commission on Environmental Quality. 2011. "Draft 2010 Texas Integrated
16 Report for Clean Water Act Sections 305(b) and 303(d)." March 8, 2011. Available at
17 <<http://www.tceq.texas.gov/waterquality/assessment/10twqi/10twqi>> (accessed
18 October 20, 2011).
- 19 Texas Historical Commission. 2011. "Celebrate Native American Heritage in November."
20 Available at <<http://www/thc/.state.tx.us/news/whatsnewstories/wnamnth.shtml>> (accessed
21 October 28, 2011).
- 22 Texas Water Code, Title 2, *Water Administration*, Chapter 36, *Groundwater Conservation*
23 *Districts.* Available at <<http://www.twdb.state.tx.us/gwr/gcd/gcdhome.htm>> (accessed
24 July 2012).
- 25 [TMMSN] Texas Marine Mammal Stranding Network. 2011. "The Gulf of Mexico's Marine
26 Mammals." January 2, 2011. Available at
27 <<http://www.sci.tamucc.edu/tmmsn/29Species/marine.html>> (accessed May 19, 2011).
- 28 [TPWD] Texas Parks and Wildlife Department. 2011a. "Brazos Bend State Park." Available at
29 <http://www.tpwd.state.tx.us/spdest/findadest/parks/brazos_bend/> (accessed
30 September 27, 2011).
- 31 [TPWD] Texas Parks and Wildlife Division. 2011b. "Jaguarundi." Available at
32 <[http://www.tpwd.state.tx.us/publications/pwdpubs/media/pwd_bk_w7000_0013_jaguarundi.](http://www.tpwd.state.tx.us/publications/pwdpubs/media/pwd_bk_w7000_0013_jaguarundi.pdf)
33 pdf> (accessed September 7, 2011).
- 34 [TPWD] Texas Parks and Wildlife Division. 2011c. Letter from A Turner, Wildlife Habitat
35 Assessment Program, to B Pham, Branch Chief, NRC. Subject: Reply to request for species
36 list for South Texas license renewal. April 20, 2011. ADAMS No. ML11119A009.
- 37 [TPWD] Texas Parks and Wildlife Department. 2011d. "Mad Island." Available at
38 <http://www.tpwd.state.tx.us/huntwild/hunt/wma/find_a_wma/list/?id=39> (accessed
39 September 27, 2011).
- 40 [TPWD] Texas Parks and Wildlife Division. 2011e. "Ocelot (*Leopardus pardalis*)." Available at
41 <<http://www.tpwd.state.tx.us/huntwild/wild/species/ocelot/>> (accessed 7 September 2011).
- 42 [TPWD] Texas Parks and Wildlife Division. 2011f. "Rare, Threatened, and Endangered
43 Species of Texas for Bexar, Brazoria, Colorado, DeWitt, Fayette, Gonzales, Guadalupe,
44 Jackson, Lavaca, Matagorda, Wharton, and Wilson Counties." Available at

Affected Environment

- 1 <<http://gis.tpwd.state.tx.us/TpwEndangeredSpecies/DesktopDefault.aspx>> (accessed
2 May 19, 2011).
- 3 [TSHA] Texas State Historical Association. 2011. "Texas Almanac: Population History of
4 Counties from 1850–2010." Available at <<http://www.texasalmanac.com/topics/population>>
5 (accessed January 2011).
- 6 [TSWGW] Texas Saltwater and Fishing Guides Web. 2005. "King Mackerel (Kingfish)."
7 Available at <<http://www.txsaltwaterfishingguides.com/FishFacts/kingfish.htm>> (accessed
8 September 9, 2011). ADAMS No. ML100600370.
- 9 [TWDB] Texas Water Development Board. 2006. *Aquifers of the Gulf Coast of Texas*. Austin,
10 TX: TWDB. Report 365. February 2006. Available at
11 <[http://www.twdb.state.tx.us/publications/reports/GroundWaterReports/GWReports/R365/
12 AGCindex.htm](http://www.twdb.state.tx.us/publications/reports/GroundWaterReports/GWReports/R365/AGCindex.htm)> (accessed August 31, 2011).
- 13 [TWDB] Texas Water Development Board. 2007. *State Water Plan—Water for Texas 2007*.
14 Austin, TX: TWDB Document No. GP-8-1. Volume 1. January 2007. Available at
15 <<http://www.twdb.state.tx.us/wrpi/swp/swp.asp>> (accessed August 31, 2011).
- 16 [TXDOT] Texas Department of Transportation. 2011. "District Traffic Maps—2010." Available
17 at <http://ftp.dot.state.tx.us/pub/txdot-info/tpp/traffic_counts/2010/ykm_base.pdf> (accessed
18 April 2011).
- 19 University of Texas at Austin. 2011. "Texas Beyond History." Available at
20 <<http://www.texasbeyondhistory.net/faq/index.html#9>> (accessed October 28, 2011).
- 21 [USACE] U.S. Army Corps of Engineers. 2009. Letter from K Jaynes, Compliance
22 Section Chief, Galveston District, to R Kiesling, STPNOC. Subject: Jurisdictional wetlands on
23 the South Texas site. May 14, 2009. ADAMS No. ML11256A057.
- 24 [USCB] U.S. Census Bureau. 2010. "American FactFinder, Census 2000 and 2006–2008,
25 3-Year Estimate, American Community Survey, State and County QuickFacts on Brazoria and
26 Matagorda Counties. Housing Characteristics for 2000 and 2006–2008, 3-Year Estimate.
27 Profile of Selected Economic Characteristics: 2000 and 2010." Available at
28 <<http://factfinder.census.gov> and <http://quickfacts.census.gov>> (accessed January 2011).
- 29 [USDA NASS] U.S. Department of Agriculture National Agricultural Statistics Service. 2009.
30 "2007 Census of Agriculture, Volume 1, Chapter 2, Table 1 and Table 7." December 2009.
31 Available at
32 <[http://www.agcensus.usda.gov/Publications/2007/Full_Report/Volume_1,_Chapter_2_County_
33 Level/Texas/index.asp](http://www.agcensus.usda.gov/Publications/2007/Full_Report/Volume_1,_Chapter_2_County_Level/Texas/index.asp)> (accessed June 2011).
- 34 [USGS] U.S. Geological Survey. 2008. "Geologic Hazards Team Interactive Map Server,
35 National Seismic Hazard Maps—2008." April 23, 2008. Available at <<http://gldims.cr.usgs.gov>>
36 (accessed September 20, 2011).
- 37 [USGS] U.S. Geological Survey. 2011a. "Circular Area Earthquake Search, NEIC: Earthquake
38 Search Results, U.S. Geological Survey Earthquake Database." (search parameters:
39 Significant U.S. Earthquakes (1569–1989) Database, Latitude 28.7951 N, Longitude -96.04900
40 W, Radius 550 km). October 4, 2010. Available at
41 <http://earthquake.usgs.gov/earthquakes/eqarchives/epic/epic_circ.php> (accessed
42 September 20, 2011).
- 43 [USGS] U.S. Geological Survey. 2011b. "Circular Area Earthquake Search, NEIC: Earthquake
44 Search Results, U.S. Geological Survey Earthquake Database." (search parameters:
45 USGS/NEIC (PDE) 1973 Database, Latitude 28.7951 N, Longitude -96.04900 W, Radius

- 1 200 km). October 4, 2010. Available at
2 <http://earthquake.usgs.gov/earthquakes/eqarchives/epic/epic_circ.php> (accessed
3 September 20, 2011).
- 4 [USGS] U.S. Geological Survey. 2011c. "Texas Earthquake Information, Seismicity Map of
5 Texas, Seismic Hazard Map of Texas." Available at
6 <<http://earthquake.usgs.gov/earthquakes/states/index.php?regionID=43>> (accessed
7 September 20, 2011).
- 8 [USGS] U.S. Geological Survey. 2011d. "USGS Surface-Water Annual Statistics for the
9 Nation, USGS 08162500, Colorado River Near Bay City, TX." Available at
10 <http://waterdata.usgs.gov/nwis/annual/?referred_module=sw&site_no=08162500&por_08162500_1=1460,00060,1,1948,2011&year_type=W&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list> (accessed
11 August 31, 2011).
- 14 Wai CN, Huntsman G. 2006a. "Epinephelus drummondhayi." Available at
15 <<http://www.iucnredlist.org/apps/redlist/details/7854/0>> (accessed June 28, 2011).
- 16 Wai CN, Huntsman G. 2006b. "Hyporthodus nigrurus." Available at
17 <<http://www.iucnredlist.org/apps/redlist/details/7860/0>> (accessed June 28, 2011).
- 18 [WEG] Wild Earth Guardians. Petition to list the saltmarsh topminnow (*Fundulus jenkinsi*) under
19 the U.S. Endangered Species Act. September 3, 2010. Available at
20 <<http://sero.nmfs.noaa.gov/pr/esa/Candidate%20Spp/Saltmarsh%20Topminnow%20Petition-1.pdf>>
21 (accessed June 28, 2011).
- 22 Wiken E, Nava FJ, Griffith G. 2011. *North American Terrestrial Ecoregions—Level III*.
23 Montreal, Canada: Commission for Environmental Cooperation. 149 p. Available at
24 <ftp://ftp.epa.gov/wed/ecoregions/pubs/NA_TerrestrialEcoregionsLevel3_Final-2june11_CEC.pdf>
25 (accessed September 12, 2011).
- 26 Wilber, D. 1989. Reproductive biology and distribution of stone crabs (*Xanthidae*, *menippe*) in
27 the hybrid zone on the northeastern Gulf of Mexico. *Marine Ecology Progress*
28 *Series* 52(1989):235-244.
- 29 Young, SC, Kelly, V, Budge, T, Deeds, N. 2007. *FINAL Development of the LSWP*
30 *Groundwater Flow Model for the Chicot and Evangeline Aquifers in Colorado, Wharton, and*
31 *Matagorda Counties*. Austin, TX: URS Corporation, INTERA, and Baer Engineering and
32 Consulting. Available at
33 <http://www.lcra.org/library/media/public/docs/lswp/findings/URS_Mitigation_report_final.pdf>.
34 ADAMS No. ML100471604.

1

3.0 ENVIRONMENTAL IMPACTS OF REFURBISHMENT

2 Facility owners or operators may need to undertake or, for economic or safety reasons, may
 3 choose to perform refurbishment activities in anticipation of license renewal or during the license
 4 renewal term. The major refurbishment class of activities characterized in the *Generic*
 5 *Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS) (NRC 1996) is
 6 intended to encompass actions that typically take place only once in the life of a nuclear plant, if
 7 at all. Examples of these activities include, but are not limited to, replacement of boiling-water
 8 reactor recirculation piping and pressurized-water reactor steam generators. These actions
 9 may have an impact on the environment beyond those activities occurring during normal
 10 operations for which the activities require evaluation, depending on the type of action and the
 11 plant-specific design. Table 3–1 lists the environmental issues associated with refurbishment
 12 that the U.S. Nuclear Regulatory Commission (NRC) staff (the staff) determined to be
 13 Category 1 issues in the GEIS.

14
15

Table 3–1. Category 1 Issues Related to Refurbishment

Issue	GEIS Section(s)
Surface water quality, hydrology, and use (for all plants)	
Impacts of refurbishment on surface water quality	3.4.1
Impacts of refurbishment on surface water use	3.4.1
Aquatic ecology (for all plants)	
Refurbishment	3.5
Groundwater use and quality	
Impacts of refurbishment on groundwater use and quality	3.4.2
Land use	
Onsite land use	3.2
Human health	
Radiation exposures to the public during refurbishment	3.8.1
Occupational radiation exposures during refurbishment	3.8.2
Socioeconomics	
Public services: public safety, social services, and tourism and recreation	3.7.4; 3.7.4.3; 3.7.4.4; 3.7.4.6
Aesthetic impacts (refurbishment)	3.7.8

Table source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51

16
17
18

Table 3–2 lists environmental issues related to refurbishment that the NRC staff determined to be plant-specific or inconclusive in the GEIS. These issues are Category 2 issues. The

Environmental Impacts of Refurbishment

1 definitions of Category 1 and 2 issues can be found in Section 1.4 of this supplemental
 2 environmental impact statement (SEIS).

3 **Table 3–2. Category 2 Issues Related to Refurbishment**

Issue	GEIS Section(s)	10 CFR 51.53(c)(3)(ii) Subparagraph
Terrestrial resources		
Refurbishment impacts	3.6	E
Threatened or endangered species (for all plants)		
Threatened or endangered species	3.9	E
Air quality		
Air quality during refurbishment (non-attainment and maintenance areas)	3.3	F
Socioeconomics		
Housing impacts	3.7.2	I
Public services: public utilities	3.7.4.5	I
Public services: education (refurbishment)	3.7.4.1	I
Offsite land use (refurbishment)	3.7.5	I
Public services, transportation	3.7.4.2	J
Historic and archaeological resources	3.7.7	K
Environmental justice		
Environmental justice ^(a)	Not addressed	Not addressed

^(a) Guidance related to environmental justice was not in place at the time the NRC prepared the GEIS and the associated revision to 10 CFR Part 51. If an applicant plans to undertake refurbishment activities for license renewal, the applicant's Environmental Report (ER) and the staff's SEIS must address environmental justice.

Table source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51

4
 5 Table B.2 of the GEIS identifies systems, structures, and components (SSCs) that are subject to
 6 aging and might require refurbishment to support continued operation during the license
 7 renewal period of a nuclear facility. In preparation for its license renewal application, South
 8 Texas Project Nuclear Operating Company (STPNOC) performed an evaluation of these SSCs
 9 pursuant to Section 54.21 of Title 10, *Energy*, of the *Code of Federal Regulation* (10 CFR 54.21)
 10 to identify the need to undertake any major refurbishment activities that would be necessary to
 11 support the continued operation of South Texas Project (STP) during the proposed 20-year
 12 period of extended operation.

13 In the ER, STPNOC indicated that, in accordance with 10 CFR Part 54, STPNOC has submitted
 14 an integrated plant assessment (IPA) addressing the aging management of SSC for license
 15 renewal. The IPA does not identify the need to undertake any major refurbishment activities
 16 that are necessary to support continued operation of STP during the period of extended

1 operation (STPNOC 2010). Furthermore, STPNOC indicated that it has replaced the steam
2 generator and reactor heads to meet the operational needs under the current license.
3 Therefore, the staff does not assess refurbishment activities in this SEIS.

4 **3.1 References**

5 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
6 protection regulations for domestic licensing and related regulatory functions.”

7 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for
8 renewal of operating licenses for nuclear power plants.”

9 [NRC] U.S. Nuclear Regulatory Commission. 1975. *Final Environmental Statement Related to*
10 *The Proposed South Texas Project, Units 1 and 2*. Washington, DC: NRC. NUREG-75/019.
11 March 1975. ADAMS No. ML11174A118

12 [NRC] U.S. Nuclear Regulatory Commission. 1996. *Generic Environmental Impact Statement*
13 *for License Renewal of Nuclear Plants*. Washington, DC: NRC. NUREG-1437. May 1996.
14 ADAMS Nos. ML040690705 and ML040690738.

15 [NRC] U.S. Nuclear Regulatory Commission. 1999. Section 6.3, Transportation, Table 9.1,
16 Summary of findings on NEPA issues for license renewal of nuclear power plants. In: *Generic*
17 *Environmental Impact Statement for License Renewal of Nuclear Plants*. Washington, DC:
18 NRC. NUREG-1437, Volume 1, Addendum 1. August 1999. ADAMS No. ML04069720.

19 [STPNOC] South Texas Plant Nuclear Operating Company. 2010b. “South Texas Project,
20 Applicant’s Environmental Report—Operating License Renewal Stage, South Texas Project
21 Units 1 & 2.” September 2010. ADAMS No. ML103010263.

4.0 ENVIRONMENTAL IMPACTS OF OPERATION

This chapter addresses potential environmental impacts related to the period of extended operation of South Texas Project (STP). These impacts are grouped and presented according to resource. Generic issues (Category 1) rely on the analysis presented in the *Generic Environmental Impact Statement (GEIS) for License Renewal of Nuclear Plants* (NRC 1996, 1999). Site-specific issues (Category 2) have been analyzed for STP. However, some issues are not applicable to STP because of site characteristics or plant features. Section 1.4 of this supplemental environmental impact statement (SEIS) provides an explanation of the criteria for Category 1 and Category 2 issues, as well as the definitions of SMALL, MODERATE, and LARGE.

4.1 Land Use

Onsite land use issues that could be affected by license renewal are listed in Table 4–1. As discussed in the GEIS, onsite land use and powerline right-of-way conditions are expected to remain unchanged during the license renewal term at all nuclear plants; thus, impacts would be SMALL. These issues, therefore, were classified as Category 1 issues. Section 2.2.1 of this SEIS describes the land use conditions at STP.

The NRC staff reviewed and evaluated South Texas Project Nuclear Operating Company's (STPNOC's) Environmental Report (ER) (STPNOC 2010b), scoping comments, and other available data on STP, Units 1 and 2, were reviewed and evaluated for new and significant information. The review included an audit conducted by the NRC staff at the STP site. No new and significant information was identified during this review that would change the conclusions presented in the GEIS. Therefore, for these Category 1 issues, impacts during the renewal term are not expected to exceed those discussed in the GEIS.

Table 4–1. Land Use Issues

Issue	GEIS Section	Category
Onsite land use	4.5.3	1
Powerline right-of-way	4.5.3	1

Source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51

4.2 Air Quality

Section 2.2.2 of this SEIS describes the meteorology and air quality in the vicinity of the STP site.

The air quality issue applicable to STP during the renewal term is discussed below and listed in Table 4–2. The GEIS did not identify any Category 2 issues related to air quality. The NRC staff did not identify any new and significant information during the review of the applicant's ER (STPNOC 2010), the staff's site audit, the scoping process, or the evaluation of other available information. Therefore, there are no impacts related to these issues beyond those discussed in the GEIS. For these issues, the GEIS concluded that the impacts are SMALL, and additional site-specific mitigation measures are unlikely to be sufficiently beneficial to warrant implementation.

1

Table 4–2. Air Quality Issues

Issue	GEIS Section	Category
Air quality effects of transmission lines	4.5.2	1

Source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51

2

4.3 Surface Water Resources

3

The surface water use, hydrology, and surface water quality issues potentially applicable to STP, Units 1 and 2, are discussed in the following sections and listed in Table 4–3. Surface water-related aspects and conditions relevant to STP, Units 1 and 2, are described in Sections 2.1.7.1 and 2.2.4 of this SEIS.

4

5

6

7

Table 4–3. Surface Water Resources Issues

Issues	GEIS Section	Category
Altered current patterns at intake & discharge structures	4.2.1.2.1	1
Altered salinity gradients	4.2.1.2.2	1
Discharge of chlorine or other biocides	4.2.1.2.4	1
Discharge of sanitary wastes & minor chemical spills	4.2.1.2.4	1
Discharge of other metals in wastewater	4.2.1.2.4	1
Water use conflicts (plants with cooling towers & cooling ponds using makeup water from a small river with low flow)	4.3.2.1	2

Source: STPNOC 2010b, 2011b and Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51

8

4.3.1 Generic Surface Water Issues

9

10

11

12

13

14

15

16

NRC did not identify any new and significant information with regard to Category 1 (generic) surface water issues based on review of the ER (STPNOC 2010b), the public scoping process, or as a result of the environmental site audit. The NRC staff also reviewed other sources of information such as various permits and data reports. As a result, no information or impacts related to these issues were identified that would change the conclusions presented in the GEIS. Therefore, it is expected that there would be no impacts related to these Category 1 issues during the renewal term beyond those discussed in the GEIS. For these surface water issues, the GEIS concludes that the impacts are SMALL.

17

18

4.3.2 Surface Water Use Conflicts—Plants Using Makeup Water from a Small River with Low Flow

19

20

21

22

23

24

For nuclear power plants using cooling towers or cooling ponds that are supplied with makeup water from a small river, the potential impact on the flow of the river and related impacts on instream and riparian ecological communities is considered a Category 2 issue; thus, it requires a plant-specific assessment. The requirement for this assessment is specified by 10 CFR 51.53(c)(3)(ii)(A), which also defines a small river as one whose annual flow rate is less than 3.15×10^{12} ft³/yr (9×10^{10} m³/yr) or 100,000 cfs (2,820 m³/s). STP, Units 1 and 2, has a

1 closed-cycle heat-dissipation system that uses a cooling pond, the main cooling reservoir
2 (MCR), with makeup water supplied from a small river, the lower Colorado River, with a mean
3 annual discharge equivalent to $82.6 \times 10^9 \text{ ft}^3/\text{yr}$ ($23.4 \times 10^8 \text{ m}^3/\text{yr}$) or 2,620 cfs ($74.1 \text{ m}^3/\text{s}$).
4 Therefore, an assessment of the impact of the proposed action on the flow of the river is
5 required.

6 In the State of Texas, water use is regulated by the Texas Water Code. Surface water belongs
7 to the State (Water Code, Title 2, Subtitle B, Chapter 11, Section 11.021). The right to use
8 surface waters of the State can be acquired in accordance with the provisions of the Texas
9 Water Code, Chapter 11. Because the Colorado River Basin is currently heavily appropriated
10 (used or obligated for use), future water users in this basin would likely obtain surface water by
11 purchasing or leasing existing appropriations. The Texas Water Development Board (TWDB)
12 uses 16 planning regions, the Regional Water Planning Areas (or regions), to plan and finance
13 water supply projects. The regions prepare plans within their areas that are compiled into the
14 State Water Plan. The most recent plan was adopted by the TWDB in November 2006
15 (TWDB 2007). For this SEIS, the staff reviewed the best available information for its analysis.
16 Currently, the State of Texas is in the 2011 to 2016 planning cycle. The regions have compiled
17 the 2011 Regional Water Plans. The 2012 State Water Plan has been released for public
18 comment (TWDB 2011). The STP site is located in the Lower Colorado Regional Water
19 Planning Group (LCRWPG), or Region K.

20 STPNOC owns water rights from the lower Colorado River to operate power reactors on the
21 STP site. The waters of the Colorado River for STPNOC's use are adjudicated (administered or
22 allotted) via a water right secured in 1989 (STPNOC 2010b). An agreement between the Lower
23 Colorado River Authority (LCRA) and STPNOC specifies the conditions related to STPNOC's
24 withdrawal (diversion) of water from the Colorado River. STPNOC is allowed to withdraw
25 102,000 ac-ft/yr (126 million m^3/yr) from the Colorado River at a maximum withdrawal rate of
26 1,200 cfs ($34.4 \text{ m}^3/\text{s}$) or 540,000 gpm. However, STPNOC is limited to withdrawing 55 percent
27 of the river flow that exceeds 300 cfs ($8.5 \text{ m}^3/\text{s}$) or 135,000 gpm (STPNOC 2009a;
28 TCEQ 2009a). In other words, STPNOC is limited in its ability to withdraw water from the
29 Colorado River during low flow conditions (i.e., 55 percent of the river flow at the volumetric flow
30 rate that exceeds 300 cfs).

31 STPNOC's historical withdrawals of surface water from the Colorado River for plant operations
32 are summarized in Table 4-4.

33

1 **Table 4–4. Surface Water Withdrawals and Usage for Calendar Years 2003–2010**
 2 **for STP, Units 1 and 2**

Calendar Year	Water Withdrawal (ac-ft) ^(a)	Water Use (ac-ft)
2003	0	27,800
2004	62,374	37,963
2005	5,694	35,383
2006	50,012	37,912
2007	58,740	39,403
2008	10,303	38,186
2009	72,464	38,008
2010	43,213	37,893

^(a) To convert ac-ft to m³, multiply by 1,233.5. To convert ac-ft to gal, multiply by 325,851.

Source: STPNOC 2010b, 2011b

3 Between 2003 and 2010, STPNOC withdrew an average of 37,850 ac-ft/yr (46.7 million m³/yr)
 4 from the Colorado River and consumed an average of 36,569 ac-ft/yr (45.1 million m³/yr) to
 5 support the operations of STP, Units 1 and 2. For a given year, withdrawals from the lower
 6 Colorado River can be significantly less or more than corresponding water use because of rules
 7 for water withdrawal specified in the LCRA–STPNOC contract (right to purchase or use), which
 8 are based on river flow and meteorological conditions that affect evaporation from the MCR. In
 9 2003, STPNOC withdrew no water from the Colorado River but consumptively used 27,800 ac-ft
 10 (34.3 million m³). The following year, STPNOC had to withdraw 62,374 ac-ft (76.9 million m³) of
 11 river water to cover the 37,963 ac-ft (46.8 million m³) of consumption and to replenish the MCR
 12 storage (the MCR functions and specifications are described in Section 2.1.6). The average,
 13 minimum, and maximum yearly withdrawals from the lower Colorado River over the
 14 2003 to 2010 period are 36, 0, and 71 percent of the STPNOC annual water rights of
 15 102,000 ac-ft (126 million m³).

16 The LCRWPG adopted its 2011 Region Plan in July 2010 (LCRWPG 2010). The LCRWPG
 17 estimated that the total water demand in Region K would increase from 1,086,692 ac-ft/yr
 18 (1.34 billion m³/yr) in 2010 to 1,382,534 ac-ft/yr (1.71 billion m³/yr) in 2060, mainly due to a
 19 projected doubling of the population of Region K over the timeframe. The LCRWPG estimated
 20 that the water available to Region K would decline from 1,331,715 ac-ft/yr (1.64 billion m³/yr) in
 21 2010 to 1,289,453 ac-ft/yr (1.59 billion m³/yr) in 2060. The LCRWPG estimated that region-wide
 22 water shortages would be 297,000 and 367,000 ac-ft/yr (366 and 453 million m³/yr) in 2030 and
 23 2060, respectively (LCRWPG 2010). To estimate shortages, the LCRWPG used the following
 24 conservative assumptions:

- 25 • Available water would be that during a historical drought of record.
- 26 • All water rights would be used fully and simultaneously.
- 27 • Interruptible water from LCRA and municipal return flows to the Colorado
 28 River would not be available.

29 These assumptions are conservative because they minimize water availability and maximize
 30 water use, thereby maximizing potential shortages.

1 The region plans to address shortages by using a variety of strategies. These water
 2 management strategies include use of municipal return flows, conservation, reuse, new water
 3 storage facilities, aquifer storage of surface water, new groundwater supply development,
 4 saltwater desalination, and intra-region transfer of water from areas with surplus. The LCRWPG
 5 estimated that the implementation of all water management strategies could yield an additional
 6 349,862 to 610,750 ac-ft/yr (432 to 754 million m³/yr) to meet the estimated shortages
 7 (LCRWPG 2010).

8 During the past 5 years, withdrawals from the lower Colorado River to support the operations of
 9 STP, Units 1 and 2, have averaged 46,946 ac-ft/yr (57.9 million m³/yr), which is equivalent to
 10 2.5 percent of the mean annual discharge of 2,620 cfs (74.1 m³/s) or approximately
 11 1.89 million ac-ft/yr (2.3 billion m³/yr) for the river. The average withdrawal for STP, Units 1
 12 and 2, is 3.5 and 3.6 percent of the water available to Region K in 2010 and 2060, respectively.
 13 The 2060 projection is based on the assumption that no implementation of any strategies to
 14 augment (or to change) regional water supply would have taken place. STPNOC's water right
 15 of 102,000 ac-ft/yr (126 million m³/yr) is accounted for in the Region K plan. The LCRWPG has
 16 evaluated several strategies that can be used to meet shortages that may occur during
 17 conditions similar to the drought of record when all existing water rights are fully and
 18 simultaneously used. Therefore, NRC concludes that continued operation of STP, Units 1
 19 and 2, as supported by the currently held water rights, would have no substantial effect on water
 20 supplies in the region. NRC further concludes that the impact on surface water resources and
 21 downstream water availability in the lower Colorado River from continued withdrawals during the
 22 license renewal term would be SMALL.

23 **4.4 Groundwater Resources**

24 The groundwater use and quality issues applicable to STP, Units 1 and 2, are discussed in the
 25 following sections and listed in Table 4–5 for Category 1 (generic) and Category 2 (site-specific)
 26 issues. Groundwater resources-related aspects and conditions relevant to STP, Units 1 and 2,
 27 are described in Sections 2.1.7.2 and 2.2.5 of this SEIS.

28 **Table 4–5. Groundwater Resources Issues**

Issues	GEIS Section	Category
Groundwater use conflicts (potable and service water & dewatering; plants that use >100 gpm)	4.8.1.1, 4.8.1.2	2
Groundwater use conflicts (plants using cooling towers withdrawing makeup water from a small river)	4.8.1.3	2
Groundwater quality degradation (saltwater intrusion)	4.8.2.1	1
Groundwater quality degradation (cooling ponds in salt marshes)	4.8.3	1

29 **4.4.1 Generic Groundwater Issues**

30 Section 2.2.5 of this SEIS discusses groundwater use and quality at STP. NRC did not identify
 31 any new and significant information with regard to Category 1 (generic) groundwater issues
 32 based on review of the ER (STPNOC 2010b), the public scoping process, or as a result of the
 33 environmental site audit. The NRC staff also reviewed other sources of information, such as
 34 applicable permits and data reports, as listed in the reference section of this SEIS chapter. The
 35 staff provides a list of STP permits for operation (status of compliance) in Appendix C. As a

Environmental Impacts of Operation

1 result, no information or impacts related to these issues were identified that would change the
2 conclusions presented in the GEIS. Therefore, it is expected that there would be no impacts
3 related to these Category 1 issues during the renewal term beyond those discussed in the
4 GEIS. For these groundwater issues, the GEIS concludes that the impacts are SMALL.

5 **4.4.2 Groundwater Use Conflicts**

6 This section presents the NRC staff's review of plant-specific (Category 2) groundwater use
7 conflict issues, as listed in Table 4–5.

8 **4.4.2.1 Plants Using Greater Than 100 gpm of Groundwater**

9 For nuclear power plants that pump more than 100 gpm (380 L/min) of groundwater from onsite
10 wells, the potential groundwater use conflict with nearby groundwater users is considered a
11 Category 2 issue that requires a plant-specific assessment, as specified in
12 10 CFR 51.53(c)(3)(ii)(C).

13 As described in Section 2.1.7.2, onsite groundwater production at STP has averaged 768 gpm
14 (2,910 L/min) or 1,239 ac-ft/yr (1.5 million m³/yr) annually over the 10-year period from 2001
15 through 2010. STP has a permit for five production wells completed in the Deep Chicot Aquifer
16 to withdraw at a combined rate of approximately 1,860 gpm (7,040 L/min) or 3,000 ac-ft/yr
17 (3.7 million m³/yr). Of the five production wells, wells 5, 6, and 7 (as described in
18 Section 2.1.7.2) feed a common header (a single collection point) that delivers water to be
19 chlorinated, filtered, and stored for use by the service water system and the fire protection
20 system. Each of these three wells has a design capacity of 500 gpm (1,890 L/min) at a depth of
21 700 ft (210 m). The service water system includes the demineralizer system and the potable
22 water supply for the plant. The common header supplied by the three production wells is also
23 the primary source for makeup water to the essential cooling pond (ECP). Well 8, with a design
24 capacity of 250 gpm (950 L/min) at a depth of 600 ft (180 m), supplies the Nuclear Support
25 Center chill water for the building cooling tower. The Nuclear Training Facility (NTF) well, with a
26 design capacity of 200 gpm (760 L/min) and a depth of 600 ft (180 m), provides fire protection
27 water to the NTF (STPNOC 2010b).

28 Because the annual average withdrawal rate from these sources for service water and fire
29 protection water is greater than 100 gpm (380 L/min), this is a Category 2 issue for the STP site.
30 All five STP production wells (5, 6, 7, 8, and NTF) are located relatively near the STP site
31 boundary, as shown in Figure 2–1. Coastal Plains Groundwater Conservation District (CPGCD)
32 rules require that wells of 7-in. (18-cm) diameter or greater completed on adjacent lands with
33 different owners must be spaced a minimum of 2,500 ft (760 m) from any other permitted or
34 registered well (CPGCD 2010). Therefore, drawdown at 2,500 ft (760 m) well spacing is
35 relevant to the evaluation of potential conflicts with neighboring wells.

36 The applicant performed an analysis of drawdown using the Theis non-equilibrium well
37 equations (E.E. Johnson, Inc. 1966). Using representative hydraulic properties, the applicant
38 calculated drawdowns of 20.0 and 20.7 ft (6.1 and 6.3 m) in the Deep Chicot Aquifer after
39 40 and 60 years, respectively, for a neighboring well located 2,500 ft (760 m) from an STP
40 production well pumped at 500 gpm (1,890 L/min) (STPNOC 2011c). The projected change in
41 drawdown during the additional 20 years of operation is less than 1 ft (0.3 m). The NRC staff
42 checked and confirmed the applicant's drawdown estimates, as presented in Table 4–6. To
43 more completely evaluate the potential change in drawdown, the NRC staff also calculated
44 drawdown at distances of 1 and 5 mi (1.6 and 8 km).

45

Table 4–6. Projected Drawdown and Change in Drawdown in Feet for the Deep Chicot Aquifer for Selected Distances

Distance ^(a)	Aquifer Drawdown ft (m)		Change in Drawdown ft (m)
	40 years	60 years	
2,500 ft (760 m)	20 ft (6.1 m) ^(b)	20.7 ft (6.3 m) ^(b)	0.7 ft (0.2 m)
1 mi (1.6 km)	17.4 ft (5.3 m)	18.1 ft (5.5 m)	0.7 ft (0.2 m)
5 mi (8 km)	11.8 ft (3.6 m)	12.5 ft (3.8 m)	0.7 ft (0.2 m)

^(a) All projections assume a saturated hydraulic conductivity of 33,245 gallons per day per foot (gpd/ft), coefficient of storage of 0.00022 (dimensionless), and a pumping rate of 500 gpm (1,890 L/min).

^(b) This is based on STPNOC 2011c. Remaining drawdown values are based on NRC staff analyses.

3 The STP ER for proposed Units 3 and 4 reproduced a map showing the potentiometric surface
 4 (the water level that would rise in a well) in the Deep Aquifer in Matagorda County in 1967
 5 (STPNOC 2010c). It shows the potentiometric head (hydraulic pressure) to be between 0 and
 6 10 ft (3 m) below mean sea level (MSL) at the STP site. The Deep Aquifer potentiometric
 7 surface in 2005 reveals the potentiometric head on the site boundary near wells 5 and 6 to be
 8 as great as 55 ft (17 m) below MSL. Well 5 was completed in 1975, and well 6 was completed
 9 in 1977. By 2005, these wells had been in service for approximately 30 years, and drawdown
 10 was approximately 50 ft (15 m) below MSL. Piezometers completed in the Deep Chicot Aquifer
 11 at the site (STPNOC 2010c) indicate a steady response pumping activity since the late 1990s,
 12 with one piezometer relatively near production well 5 showing a near constant piezometric head
 13 of 50 ft (15 m) below MSL. The elevation of the upper surface of the Deep Chicot Aquifer is
 14 between 250 to 300 ft (76 to 91 m) below ground surface or approximately 220 to 270 ft
 15 (67 to 83 m) below MSL. Thus, the steady drawdown observed at the site ensures ample
 16 confining pressure remains in the Deep Chicot Aquifer. The drawdown observed suggests that
 17 a well located near the STP site boundary and one of the STP production wells could require a
 18 pumping lift (differential pressure applied by a pump) of approximately 50 ft (15 m) over
 19 conditions in 1967. This is the additional vertical distance that water would have to be pumped
 20 to the surface. However, the majority of this drawdown and associated pumping lift has been
 21 identified as regional drawdown resulting from groundwater development to the north of the STP
 22 site, as reflected in historical well and piezometer water well mapping (STPNOC 2009c).

23 The NRC staff's analysis of drawdown using representative hydraulic properties and review of
 24 field data reveals that drawdown near STP production wells could influence the pumping lift of
 25 groundwater wells on neighboring properties. However, the drawdown at STP production wells
 26 from 40 years of pumping is estimated to be approximately 20 ft (6.1 m), and continued
 27 operation for an additional 20 years beyond the current license period would increase drawdown
 28 by less than 1 ft (0.3 m). This finding is influenced by local and regional groundwater use
 29 regulation as discussed above and in Section 2.2.5. The projected increase in drawdown of
 30 less than 1 ft (0.3 m) is a negligible impact on neighboring wells and landowners. Therefore, the
 31 NRC staff concludes that groundwater use conflicts from STP groundwater withdrawals during
 32 the license renewal term would be SMALL.

33 **4.4.2.2 Plants Using Cooling Towers or Cooling Ponds and Withdrawing Makeup Water**
 34 **from a Small River**

35 Nuclear power plants using cooling towers or cooling ponds that are supplied with makeup
 36 water from a small river (as defined in Section 4.3.2) require a plant-specific assessment due to
 37 the potential impact on alluvial aquifers. The requirement for this assessment is specified by

Environmental Impacts of Operation

1 10 CFR 51.53(c)(3)(ii)(A). This potential impact to groundwater is considered a Category 2
2 issue. The GEIS established this groundwater aspect as Category 2 because consumptive use
3 of water withdrawn from a small river could adversely affect groundwater aquifer recharge. Low
4 river flow conditions are of particular interest.

5 STP, Units 1 and 2, is dependent on the lower Colorado River as the primary water source for
6 the 7,000-ac (2,830-ha) MCR. Systems that have a groundwater source (e.g., service water,
7 fire protection) also discharge to the MCR. The lower Colorado River meets the NRC definition
8 of a small river. As noted in Section 2.2.5.1, the Shallow Chicot Aquifer discharges to the
9 Colorado River southeast of the STP site. There is a relatively narrow band of an alluvial
10 aquifer separating the Shallow Chicot Aquifer from the Colorado River. With the rise and fall of
11 the Colorado River, the alluvial aquifer experiences bank storage. This refers to a condition
12 such that when groundwater in the alluvial aquifer is higher than the river stage, the alluvial
13 aquifer discharges to the river. Similarly, when river stage is higher than groundwater in the
14 alluvial aquifer, the alluvial aquifer is recharged by the river. In general, the lower Colorado
15 River is a gaining stream (sustained by groundwater discharges) near the STP site. This is
16 because the Shallow Chicot Aquifer discharges to the alluvial aquifer, and the alluvial aquifer
17 discharges to the Colorado River. During high river stage and local to the river shore, the
18 groundwater elevation would increase in the alluvial and Shallow Chicot Aquifer, resulting in
19 recharge to the aquifers. During low river stage, the Shallow Chicot Aquifer and the alluvial
20 aquifer would resume discharging to the river.

21 Near the STP site, the Shallow Chicot Aquifer is used primarily for livestock watering because of
22 its low yields to wells and relatively poor quality. The Deep Chicot Aquifer is separated
23 hydraulically from the Shallow Chicot Aquifer by a 100- to 150-ft (30- to 46-m) thick confining
24 unit, and it is the primary source of groundwater for the region due to high aquifer yields and
25 good quality.

26 STPNOC is limited in its ability to divert water from the lower Colorado River during periods of
27 low flow and can do so only after confirming the Colorado River flow at the U.S. Geological
28 Survey (USGS) Bay City gaging station supports the withdrawal of surface water in accordance
29 with STPNOC's Certificate of Adjudication for water use, as discussed in Section 2.1.7.1 and
30 Section 4.3.2 (STPNOC 2009d, 2010b).

31 In summary, the following staff findings are relevant to the issue of groundwater use conflicts on
32 alluvial aquifers from STP continued operations:

- 33 • The alluvial aquifer is limited to a relatively narrow band between the
34 Colorado River and the Shallow Chicot Aquifer.
- 35 • The Colorado River is normally a gaining stream with the alluvial aquifer and
36 Shallow Chicot Aquifer discharging to the river. During periods of low river
37 flow, the alluvial aquifer and Shallow Chicot Aquifer would discharge to the
38 river (the normal situation for a gaining stream).
- 39 • The Shallow Chicot Aquifer is used for watering livestock and other low-yield,
40 poor-quality applications and would not be substantially influenced by the
41 bank storage effects of alluvial aquifer recharge and discharge.
- 42 • The Deep Chicot Aquifer is the primary groundwater supply in the region, and
43 it discharges to the lower Colorado River estuary and Matagorda Bay
44 approximately 5 mi (8 km) downstream of STP (discussed in Section 2.2.5).

- 1 • STP is limited through its Certificate of Adjudication and management plan
2 regarding diversion of lower Colorado River water during low flow (discussed
3 in Section 2.1.7.1 and Section 4.3.2).

4 Based on the information above, the NRC staff concludes that continued withdrawals of surface
5 water (the Colorado River) for the operation of STP, Units 1 and 2, during low-flow periods
6 would have a SMALL impact on recharge to the alluvial aquifer during the license renewal term.

7 **4.4.3 Groundwater Quality**

8 As described in Section 4.4.1, the NRC staff did not identify any new and significant information
9 with regard to Category 1 (generic) groundwater issues. As part of its assessment, the staff
10 specifically reviewed information relating to the current state of knowledge regarding
11 groundwater quality downgradient of the MCR and underlying the STP protected area, as
12 summarized below.

13 Elevated concentrations of tritium have been observed in groundwater adjacent to the MCR and
14 in groundwater underlying the protected area of STP, Units 1 and 2, as described in
15 Section 2.2.5.2. The MCR is unlined and water from the reservoir seeps into the Upper Shallow
16 Aquifer. Systems within the protected area have released liquids containing tritium to
17 groundwater.

18 Regarding non-radioactive contaminants in the MCR, total dissolved solids (TDS) is an indicator
19 contaminant. The NRC staff anticipates that seepage from the MCR to the Upper Shallow
20 Aquifer would initially have the same TDS concentration as the MCR. STPNOC's estimate of
21 the median TDS concentration in the MCR from operation of STP, Units 1 and 2, is
22 approximately 2,000 mg/L (NRC 2011b). Locally, groundwater from the Shallow Aquifer is
23 described as being slightly saline because TDS concentrations are above 1,000 mg/L
24 (i.e., slightly saline waters have TDS ranges of 1,000 to 3,000 mg/L). Onsite wells completed in
25 the Shallow Chicot Aquifer have an average TDS concentration of 1,200 mg/L
26 (STPNOC 2010c). Accordingly, the Shallow Aquifer is used locally to water livestock, and it is
27 not a freshwater supply. The NRC staff concludes that given a long-term local increase of TDS
28 concentration to 2,000 mg/L, the groundwater TDS concentration would remain in the range
29 associated with slightly saline waters. Thus, the potential future TDS level is consistent with the
30 existing groundwater quality and its current use as a source of water for livestock. Any impacts
31 from this change in groundwater quality would be localized because the groundwater plumes
32 originating from the MCR are local to the STP site and the region immediately downgradient of
33 the site to the lower Colorado River.

34 Regarding radioactive contaminants in the MCR, tritium is an indicator contaminant. Tritium
35 releases occur to the Upper Shallow Chicot Aquifer from the MCR via seepage through the
36 reservoir floor. Historical monitoring data for the MCR water (inside the MCR) show a peak
37 tritium concentration of 17,410 picocuries per liter (pCi/L) in 1996 and values less than
38 14,000 pCi/L since then (STPNOC 2010b, 2010c). A relief well monitored since 1995 showed a
39 peak tritium concentration of 7,672 pCi/L in 1998 and values less than 7,000 pCi/L since then.
40 Tritium activity in an onsite monitoring well completed in the Shallow Chicot Aquifer shows a
41 peak in year 2000 of approximately 8,000 pCi/L and lower values before and after (NRC 2011b).
42 Monitoring shows that levels of tritium in the Shallow Chicot Aquifer around the MCR originate
43 from the liquids discharged to the MCR and are below the EPA primary drinking water standard
44 (DWS) of 20,000 pCi/L (40 CFR Part 141). The staff also concludes that tritium concentrations
45 in the Shallow Chicot Aquifer, resulting from seepage from the MCR, are bounded by the tritium
46 concentration in the MCR waters. Thus, the observed peak tritium concentration of

Environmental Impacts of Operation

1 17,410 pCi/L, and more recent levels of 14,000 pCi/L, ensures that tritium concentrations in
2 groundwater downgradient of the MCR will be below the EPA primary DWS. Further, as noted
3 in Section 2.2.5.2, the Deep Chicot Aquifer is separated from the Shallow Chicot Aquifer by a
4 zone of predominantly clay material 100 to 150 ft (30 to 46 m) thick. The Deep Chicot Aquifer is
5 the primary source of groundwater for the region, and tritium has not been detected in the Deep
6 Chicot Aquifer (MACTEC 2009).

7 As a result of STPNOC's participation in the Nuclear Energy Institute's (NEI) Groundwater
8 Protection Initiative (NEI 2007), data exist on tritium levels in groundwater, and a report was
9 issued that compiled all information about groundwater and releases to groundwater in the STP,
10 Units 1 and 2, protected area (MACTEC 2009). A peak tritium concentration around
11 15,000 pCi/L was observed in the Upper Shallow Chicot Aquifer beneath the protected area in
12 2006. Sampling at the location of that peak concentration has shown a continuous decline in
13 tritium concentration with a concentration of 1,500 pCi/L observed in 2010. All measured tritium
14 levels in groundwater within the protected area are below the EPA primary DWS
15 (i.e., 20,000 pCi/L) (see Section 2.2.5.2).

16 Three possible sources of tritium in groundwater within the protected area have been identified
17 as seepage from the MCR, leaks of the TDS pipeline system, and discharge to the ground from
18 the turbine steam trap drains or steam condensate lines. Tritium levels in groundwater
19 originating in the MCR are bounded, as described above, and will be less than the EPA primary
20 DWS. STPNOC has noted that the TDS pipeline system and the steam condensate line
21 releases could have a maximum tritium concentration of less than 90,000 pCi/L
22 (STPNOC 2011c). Releases to groundwater in the vicinity of the Units 1 and 2 reactors move
23 downward from the Upper into the Lower Shallow Chicot Aquifer and then laterally to the east
24 and southeast in the Lower Shallow Chicot Aquifer to the STP site boundary (NRC 2011b). As
25 described in Section 2.2.5.2, the groundwater travel time from the protected area to the STP site
26 boundary east of the protected area is approximately 100 years. This represents over
27 8 half-lives of tritium decay; therefore, releases at the maximum level would decay to
28 concentrations below the EPA primary DWS before leaving the STP site. The NRC staff has
29 evaluated the releases inside the protected area, as well as relevant groundwater monitoring
30 data. The staff concludes that no release is occurring from an unidentified pathway (based on
31 accounting of releases from available records), and there is no substantial adverse impact on
32 drinking water (the staff evaluates human health issues in Section 4.8).

33 In addition to the foregoing, the following staff findings are relevant to the issue of groundwater
34 quality impacts:

- 35 • Groundwater in the Shallow Chicot Aquifer will remain slightly saline and
36 suitable to its current use for watering livestock.
- 37 • Tritium levels in the Shallow Chicot Aquifer resulting from seepage from the
38 MCR will not exceed the EPA primary DWS.
- 39 • Tritium has not been detected in the Deep Chicot Aquifer, which is the
40 primary groundwater source in the region.
- 41 • Tritium levels in the Shallow Chicot Aquifer resulting from leaks and
42 discharges inside the STP protected area are currently below the EPA DWS,
43 and long-term tritium levels leaving the STP site from such releases would be
44 below the EPA DWS.

45 In conclusion, based on this information—including the staff's review of seepage from the MCR
46 and the review of releases of liquids containing tritium within the protected area of STP, Units 1

1 and 2—the NRC staff concludes that groundwater contaminant plumes have not altered current
 2 groundwater use in the region downgradient of the STP site. The staff further concludes that
 3 groundwater-quality impacts would remain SMALL during the license renewal term.

4 **4.5 Aquatic Resources**

5 Sections 2.1.6 and 2.2.5 describe the STP cooling system and aquatic environment.
 6 Section 2.2.7.1 describes the protected aquatic resources that could occur in the vicinity of STP
 7 and associated transmission lines. Category 1 and Category 2 issues related to aquatic
 8 resources applicable to STP are discussed below and listed in Table 4–7.

9 **Table 4–7. Aquatic Resource Issues**

Issues	GEIS Section	Category
For all plants		
Accumulation of contaminants in sediments or biota	4.2.1.2.4	1
Entrainment of phytoplankton & zooplankton	4.2.2.1.1	1
Cold shock	4.2.2.1.5	1
Thermal plume barrier to migrating fish	4.2.2.1.6	1
Distribution of aquatic organisms	4.2.2.1.6	1
Premature emergence of aquatic insects	4.2.2.1.7	1
Gas supersaturation (gas bubble disease)	4.2.2.1.8	1
Low dissolved oxygen in the discharge	4.2.2.1.9	1
Losses from predation, parasitism, & disease among organisms exposed to sublethal stresses	4.2.2.1.10	1
Stimulation of nuisance organisms	4.2.2.1.11	1
For Plants with Cooling Pond Heat-Dissipation Systems		
Entrainment of fish & shellfish in early life stages	4.1.2	2
Impingement of fish & shellfish	4.1.3	2
Heat shock	4.1.4	2

10 **4.5.1 Generic Aquatic Ecology Issues**

11 The NRC staff did not identify any new and significant information related to the Category 1
 12 issues listed above during the review of STPNOC’s ER, the site audit, or the scoping process
 13 that would change the conclusions presented in the GEIS (the NRC staff also reviewed other
 14 sources of information, such as applicable permits and data reports, as listed in the reference
 15 section of this SEIS chapter). Therefore, there is no impact related to these issues beyond
 16 those discussed in the GEIS. For these issues, the GEIS concluded that the impacts are
 17 SMALL. Additional site-specific mitigation measures are unlikely to be sufficiently beneficial to
 18 warrant implementation.

1 **4.5.2 Entrainment and Impingement**

2 Entrainment and impingement of aquatic organisms are site-specific (Category 2) issues for
3 assessing the impacts of license renewal at plants with cooling pond heat-dissipation systems.
4 Entrainment is the taking in of organisms with a plant's cooling water intake. The organisms
5 involved are generally of small size, dependent on the screen mesh size, and include phyto-
6 and zooplankton, fish eggs and larvae, shellfish larvae, and many other forms of aquatic life.
7 Impingement is the entrapment of organisms against the cooling water intake screens.

8 A particular species can be subject to both impingement and entrainment if some individuals are
9 impinged on screens while others pass through and are entrained (EPA 1977). Section 316(b)
10 of the Clean Water Act (CWA) (33 *United States Code* (U.S.C.) §1326(b)) requires that “[a]ny
11 standard established pursuant to Section 1311 of this title or Section 1316 of this title and
12 applicable to a point source shall require that the location, design, construction, and capacity of
13 cooling water intake structures reflect the best technology available for minimizing adverse
14 environmental impact.”

15 At STP, organisms maybe impinged or entrained at two locations. Organisms that inhabit the
16 lower Colorado River may be impinged or entrained when water is drawn through the reservoir
17 makeup pumping facility (RMPF) from the Colorado River into the MCR. Organisms that inhabit
18 the MCR may be impinged or entrained when water is drawn through the cooling water intake
19 structure (CWIS) from the MCR to the cooling water system.

20 The adverse environmental impacts of cooling water intakes occur through both impingement
21 and entrainment. Heat, physical stress, or chemicals used to clean the cooling system may kill
22 or injure the entrained organisms. Exhaustion, starvation, asphyxiation, descaling, and physical
23 stresses may kill or injure impinged organisms. STPNOC survey data in the MCR indicate that
24 entrained organisms from the lower Colorado River can survive the stresses of the intake
25 system at the RMPF and colonize the MCR (ENSR 2008a, 2008b). However, entrainment and
26 colonization of the MCR removes these organisms from the rest of the ecosystem in the region.
27 Entrained organisms that pass through the CWIS into the plant's cooling system are subject to
28 mechanical, thermal, and toxic stresses. Therefore, survival is unlikely.

29 Because impingement and entrainment are fundamentally linked, the NRC staff determined that
30 effects of each should be assessed using an integrated approach. The NRC staff employed a
31 weights-of-evidence (WOE) approach to evaluate the effects of impingement and entrainment
32 on the aquatic resources in the lower Colorado River and the MCR. NRC employed this
33 approach because EPA recommends a WOE approach for ecological risk assessments
34 (EPA 1998). WOE is a useful tool due to the complex nature of assessing risk (or impact), and
35 NRC has employed this approach in other evaluations of the effects of nuclear power plant
36 cooling systems on aquatic communities (NRC 2010, 2011i).

37 Menzie et al. (1996) defines WOE as “the process by which multiple measurement endpoints
38 are related to an assessment endpoint to evaluate whether significant risk of harm is posed to
39 the environment.” In this modified WOE approach, the NRC staff examined five lines of
40 evidence to determine if operation of the STP cooling system has the potential to cause adverse
41 impacts to fish and shellfish near STP. The first line of evidence is impingement and
42 entrainment studies at the RMPF during the initial filling and subsequent intermittent withdraw of
43 water from the Colorado River to the MCR (McAden 1984, 1985). The second line of evidence
44 is impingement and entrainment studies at the CWIS from 2007 through 2008 during the
45 withdraw of water from the MCR through the circulating water system for STP, Units 1 and 2
46 (ENSR 2008a). The third line of evidence includes engineering designs and operational

1 procedures to limit impingement and entrainment. The fourth line of evidence includes reviews
2 by other regulatory agencies, such as EPA and the Texas Commission on Environmental
3 Quality (TCEQ). The fifth line of evidence includes survey data of fish and shellfish populations
4 prior to and during operations within the Colorado River.

5 *Line of Evidence Number 1: Impingement and Entrainment Studies on the Colorado River*

6 The NRC staff evaluated the potential impacts from impingement and entrainment during water
7 withdrawal from the Colorado River by examining impingement and entrainment studies
8 from 1983 to 1984. McAden et al. (1984, 1985) conducted studies at the RMPF when STPNOC
9 initially filled the MCR with Colorado River water. NRC (1986) assessed the environmental
10 impacts of impingement and entrainment for the initial operating license for STP, Units 1 and 2.

11 McAden et al. (1984, 1985) conducted studies to estimate entrainment impacts by collecting
12 surface plankton samples in front of the RMPF. McAden used a hand-towed 0.5-m
13 (20-in. mouth diameter) ichthyoplankton net with 0.5-mm (0.02-in.) square mesh and swept the
14 hand tow parallel to the front wall of the pump structure. The most commonly collected species
15 included the zoeae and juveniles of Harris mud crabs (*Rhithropanopeus harrisi*), river shrimp
16 (*Macrobrachium ohione*), and white shrimp (*Litopenaeus setiferus*), as shown in Table 4–8.
17 McAden collected the eggs and larvae of two fish species—bay anchovy (*Anchoa mitchilli*) and
18 mosquito fish (*Gambusia affinis*). McAden also conducted plankton tows in the Colorado River
19 near the RMPF. The most commonly collected species of fish eggs and larvae included bay
20 anchovy, Gulf menhaden (*Brevoortia patronus*), and Atlantic croaker (*Micropogonias undulatus*).
21 Section 2.2.5.1 provides addition details regarding fish egg and larvae sampling in the Colorado
22 River.

23 Based on the entrainment study by McAden et al. (1984, 1985), NRC (1986) estimated that
24 entrainment losses would be approximately 10 percent of the organisms passing the RMPF.
25 This value represents the loss of organisms in the influence of the tidal flow in the river and
26 does not represent the entire populations of those species in the lower Colorado River.

27 NRC (1986) determined that the systems along the Texas Gulf coasts and the area influenced
28 by the RMPF are not unique. In addition, NRC (1986) determined that species commonly
29 caught in near the RMPF by McAden are ubiquitous (widespread or common) and abundant
30 along the Texas and Gulf coasts. The reproductive potential (fecundity) for these species is
31 high; therefore, the larvae entrained are a small portion of the total larvae produced by adult
32 females for most species (NRC 2011b). In addition, most makeup water withdrawal would
33 occur during high river flow conditions, which is when the salinity and concentrations of
34 estuarine and marine organisms would be lowest. Therefore, NRC (1986) concluded that
35 entrainment losses for the species collected by McAden (1984, 1985) would not constitute a
36 significant impact to their respective populations.

37 ENSR Corporation (2008a) indicates that many individuals of numerous species survived
38 entrainment at the RMPF and inhabit the MCR. While these organisms survived entrainment,
39 the entrainment, overall, has led to a loss of the organisms in the Colorado River, and these
40 organisms no longer contribute to the riverine ecosystem.

41

1 **Table 4–8. Number (per 100 m³) of Macrozooplankton and Ichthyoplankton Collected in**
 2 **Plankton Samples in Front of the RMPF from 1984 and 1985**

Common Name	Scientific Name	Aug-83 ^(a)	Sept-83 ^(b)	Sept-84 ^(c)	Total	% of Total
bay anchovy	<i>Anchoa mitchilli</i>	51.3	0	0	51.3	1
bivalves-juveniles	Pelecypoda	10.3	28.3	0	38.6	1
blue crab-juvenile	<i>Callinectes sapidus</i>	62.8	14.1	0	76.9	2
crabs-megalopa	<i>Callinectes spp.</i>	115	0	0	115	3
glass shrimp	<i>Palaemonetes paludosus</i>	0	14.9	0	14.9	<1
Harris mud crab	<i>Rhithropanopeus harrisi</i>	184.9	1,461.4	695.9	2,342.2	60
mosquito fish	<i>Gambusia affinis</i>	23.3	14.9	0	38.2	1
ghost shrimp	<i>Callinassa spp.</i>	0	0	51.4	51.4	1
river shrimp	<i>Macrobrachium ohione</i>	609.3	29	0	638.3	16
white shrimp	<i>Litopenaeus setiferus</i>	222.2	312.8	0	535	14
unidentified fish spp.		0	0	12.9	12.9	<1
Total		1,279.1	1,875.4	760.2	3,914.7	

^(a) Samples collected on August 9–10, 1983, at 1100, 1640, 2230, and 0450

^(b) Samples collected on September 15–16, 1983, at 1100, 1705, 2250, and 0545

^(c) Samples collected on September 6, 1984, at 0020, 0500, 1030, and 1615

Source: McAden 1984, 1985

3 McAden et al. (1984, 1985) also conducted impingement studies by washing all organisms off
 4 two intake screen and filtering them through a dip net with a 0.25-in (6.4-mm) mesh. Each
 5 sample period was 30 minutes. McAden (1984, 1985) collected three samples within 24 hours
 6 during each week that pumping occurred. The most commonly impinged species included blue
 7 crab (61 percent), river shrimp (18 percent), and white shrimp (10 percent), as shown in Table
 8 4–9. Impinged fish included one crevalle jack (*Caranx hippos*), one green sunfish (*Lepomis*
 9 *cyanellus*), and one inland silverside (*Menidia beryllina*). Because the impingement study
 10 collected so few fish, NRC (1986) predicted the most likely fish to be impinged based on size
 11 (which is related to swim speed) and the density and abundance of the species near the RMPF.
 12 NRC (1986) predicted Gulf menhaden to be the most commonly impinged species (65 percent),
 13 followed by Atlantic croaker (16 percent), bay anchovy (10 percent), and striped mullet
 14 (8 percent). NRC (1986) concluded that impingement losses would have a minor effect on the
 15 biota of the Colorado River because the commonly impinged species are ubiquitous, abundant
 16 habitat for these species occurs along the Texas and Gulf coasts, and the design elements of
 17 the RMPF would reduce impingement losses.

18 STPNOC has not conducted impingement and entrainments studies on the Colorado River
 19 since its 1983 to 1984 study (STPNOC 2010b, 2010c). Since 1984, the U.S. Army Corps of
 20 Engineers (USACE) completed the mouth of the Colorado River project, increasing the flow
 21 between the Colorado River and Matagorda Bay (USACE 2005; Wilber and Bass 1998). As
 22 discussed below in the aquatic survey section (line of evidence number 5), the diversity of
 23 aquatic species and the presence of estuarine-marine species has increased since the 1970s.

1 However, ENSR (2008b) found that the majority of the species most likely to be impinged
 2 (e.g., Gulf menhaden, Atlantic croaker, and striped mullet) continue to be the most common
 3 species of fish collected around the RMPF and would likely continue to be the most common
 4 species impinged during the license renewal term.

5 **Table 4–9. Invertebrates and Fish Impinged at the RMPF during 1983–1984 Studies**

Common Name	Scientific Name	July-83 ^(a)	Aug-83 ^(b)	Sept-83 ^(c)	Sept-84 ^(d)	Total	% of Total
blue crab	<i>Callinectes sapidus</i>	69	44	4	6	123	61
crevalle jack	<i>Caranx hippos</i>	1	0	0	0	1	<1
glass shrimp	<i>Palaemonetes paludosus</i>	14	1	0	0	15	7
grass shrimp	<i>Palaemonetes kadiakensis</i>	1	1	0	0	2	1
green sunfish	<i>Lepomis cyanellus</i>	1	0	0	0	1	<1
inland silverside	<i>Menidia beryllina</i>	1	0	0	0	1	<1
pink shrimp	<i>Farfantepenaeus brasiliensis</i>	0	0	0	1	1	<1
Palaemonidae shrimp	Palaemonidae spp.	2	0	0	0	2	1
river shrimp	<i>Macrobrachium ohione</i>	28	4	1	4	37	18
white shrimp	<i>Litopenaeus setiferus</i>	0	3	13	4	20	10
Total		117	53	18	15	203	

(a) Samples collected on July 13–14, 1983, at 1329, 2100, and 0511; July 21–22, 1983, at 1315, 2110, 0505; and July 27–28, 1983, at 1400, 2230, and 0626.

(b) Samples collected on August 9–10, 1983, at 1300, 2100, and 0500.

(c) Samples collected on September 15–16, 1983, at 1414, 2205, and 0615.

(d) Samples collected on September 5–6, 1984, at 1910, 0300, and 1104.

Source: McAden 1984, 1985

6 *Line of Evidence Number 2: Impingement and Entrainment Studies on the Main Cooling*
 7 *Reservoir*

8 STP conducted impingement and entrainment studies at the CWIS on the MCR in May 2007
 9 through April 2008 (ENSR 2008a). The objective of the study was “to characterize the aquatic
 10 species within the MCR, and to evaluate impingement and entrainment impacts to establish, to
 11 the extent possible, relationships between the presence of aquatic organisms and the current
 12 (STP, Units 1 and 2) intake design and operating parameters” (ENSR 2008a).

13 ENSR (2008a) collected entrainment samples over a 24-hour period, twice per month from May
 14 through September and once per month from October through April. ENSR collected
 15 entrainment samples by placing 0.363-mm (0.014-in.) plankton nets behind the trash bars at the
 16 CWIS. ENSR pumped water from a depth of approximately 12 ft (3.7 m) through a buffering
 17 chamber at flows up to 10,800 gallons per hour or 180 gpm. ENSR operated the pumps four

Environmental Impacts of Operation

- 1 times per day, for approximately 2 hours per event, for a volume of 100 m³ (3,500 ft³) of water
 2 per 24-hour period.
- 3 ENSR (2008a) collected 207,696 organisms representing nine different fish families and
 4 12 different classes of invertebrates (Table 4–10). The most commonly impinged taxa included
 5 Harris mud crab (68 percent) and unidentified decapod zoea (or free swimming larvae)
 6 (15 percent). Ichthyoplankton, or fish eggs and larvae, comprised less than 1 percent of all
 7 entrained organisms. ENSR reported the highest entrainment rates from April through June and
 8 the lowest from December through March. Entrainment of threadfin shad and mud crabs was
 9 highest in late spring and summer, and entrainment of silversides was highest in summer.

10 **Table 4–10. Aquatic Species Collected during Entrainment**
 11 **Sampling in the MCR’s CWIS for Units 1 and 2, 2007–2008**

Common Name	Taxon	Total Number	% of Total
Finfish			
anchovy	<i>Anchoa</i> spp.	30	<1
clupeid	Clupeidae	544	<1
fish egg		418	<1
goby	Gobiidae	61	<1
perch-like fish	Perciformes	6	<1
naked goby	<i>Gobiosoma bosc</i>	5	<1
needlefish	Belonidae	3	<1
silversides	Atherinidae	201	<1
wrasse	Labridae	3	<1
Invertebrates			
amphipod	Amphipoda	145	<1
bivalve	Mollusca	1	<1
brachyuran decapod (zoea)	Brachyura	353	<1
copepod	Copepoda	6,588	3
decapod (mud crabs)	Panopeidae	10,798	5
decapod (zoea)	Decapoda	31,919	15
fish lice	Copepoda	399	<1
harpacticoid copepod	Copepoda	12,212	6
Harris mud crab	<i>Rhithropanopeus harrisii</i>	140,192	68
insect	Insecta	24	<1
midge	Diptera	110	<1
mite or ticks	Acari	12	<1
mysid shrimp	Mysida	2,660	1
polychaete	Annelida	4	<1
seed shrimp	Ostracoda	78	<1

Common Name	Taxon	Total Number	% of Total
shrimp	Caridea	1	<1
tongue biters	Isopoda	16	<1
water flea	Cladocera	800	<1
unidentified		113	<1
Total		207,696	

Source: ENSR 2008a

- 1 ENSR (2008a) collected impingement samples over a 24-hour period, twice per month from
2 May through September and once per month from October through April. ENSR collected
3 samples by placing a metal-framed net fitted with a 0.25-in. (6.4-mm) nylon mesh net within the
4 sluiceway that connects the CWIS screen wash system and the debris basket.
- 5 ENSR (2008a) collected a total of 3,982 organisms representing 25 finfish and 7 invertebrate
6 species (Table 4–11). The most commonly impinged species includes threadfin shad
7 (*Dorosoma petenense*) (42 percent), blue crab (24 percent), mud crab (24 percent), Atlantic
8 croaker (5 percent), and white shrimp (3 percent). Blue crab impingement was highest during
9 the months of May, June, and July, and threadfin shad impingement was highest during the
10 months of January and March. ENSR did not report any other temporal trends for individual
11 species or all species combined.

12 **Table 4–11. Aquatic Species Collected during Impingement**
13 **Sampling in the MCR’s CWIS for Units 1 and 2, 2007–2008**

Common Name	Scientific Name	Total Number	% of Total
Finfish			
American eel	<i>Anguilla rostrata</i>	1	<1
Atlantic croaker	<i>Micropogonias undulatus</i>	182	5
bay anchovy	<i>Anchoa mitchilli</i>	3	<1
bay whiff	<i>Citharichthys spilopterus</i>	2	<1
black drum	<i>Pogonias cromis</i>	2	<1
blue catfish	<i>Ictalurus furcatus</i>	6	<1
bluegill	<i>Lepomis macrochirus</i>	9	<1
channel catfish	<i>Ictalurus punctatus</i>	4	<1
common carp	<i>Cyprinus carpio carpio</i>	2	<1
freshwater drum	<i>Aplodinotus grunniens</i>	5	<1
freshwater goby	<i>Ctenogobius shufeldti</i>	2	<1
gizzard shad	<i>Dorosoma cepedianum</i>	2	<1
goby	<i>Gobiidae spp.</i>	8	<1
Gulf menhaden	<i>Brevoortia patronus</i>	2	<1

Environmental Impacts of Operation

Common Name	Scientific Name	Total Number	% of Total
inland silverside	<i>Menidia beryllina</i>	5	<1
ladyfish	<i>Elops saurus</i>	1	<1
naked goby	<i>Gobiosoma bosc</i>	13	<1
needlefish	<i>Strongylura exilis</i>	2	<1
rough silverside	<i>Membras martinica</i>	2	<1
sand seatrout	<i>Cynoscion arenarius</i>	3	<1
sharptail goby	<i>Oligolepis acutipennis</i>	2	<1
sheepshead	<i>Archosargus probatocephalus</i>	1	<1
speckled worm eel	<i>Myrophis punctatus</i>	1	<1
spot croaker	<i>Leiostomus xanthurus</i>	1	<1
threadfin shad	<i>Dorosoma petenense</i>	1,668	42
Invertebrates			
blue crab	<i>Callinectes sapidus</i>	944	24
brown shrimp	<i>Farfantepenaeus aztecus</i>	10	<1
grass shrimp	<i>Palaemonetes pugio</i>	33	<1
lesser blue crab	<i>Callinectes similis</i>	3	<1
Harris mud crab	<i>Rhithropanopeus harrisi</i>	953	24
river shrimp	<i>Macrobrachium ohione</i>	3	<1
white shrimp	<i>Litopenaeus setiferus</i>	106	3
Other			
flat-headed snake	<i>Tantilla gracilis</i>	1	<1
Total		3,982	

Source: ENSR 2008a

1 *Line of Evidence Number 3: Engineered Design and Operational Conditions*

2 EPA recently published a proposed rule that describes multiple approaches to reduce
3 impingement and entrainment mortality at existing cooling water intake structures. These
4 approaches include flow reduction, or reducing the total amount of water withdrawn; intake
5 velocity; technologies to exclude organisms and to collect and return organisms to the water
6 body; and intake location and timing of withdrawals (76 FR 22174). The RMPF on the Colorado
7 River and the CWIS on the MCR incorporate several of these approaches.

8 Flow Reduction. Reducing the intake flow reduces the amount of water withdrawn from water
9 bodies to be cycled through the cooling system, which likely reduces the amount of aquatic
10 organisms that would be drawn through the intake structure and subject to impingement and
11 entrainment. STP uses a cooling pond-based heat-dissipation system that withdraws and
12 discharges cooling water to the MCR. The MCR is similar to a closed-cycle cooling system

1 since the water in the reservoir continues to circulate from the MCR, into the plant, and back
2 again. STP intermittently draws water from the Colorado River to compensate for water loss
3 from evaporation and seepage from the MCR. Depending on the quality of the makeup water,
4 closed-cycle recirculating cooling water systems can reduce consumptive water use by
5 96 to 98 percent of the amount that the facility would use if it employed a once-through cooling
6 system (69 FR 41576).

7 Reduced Intake Velocity. Water velocity associated with the intake structure greatly influences
8 the rate of impingement and entrainment. The higher the approach or through-screen velocity
9 or both, the greater the number of organisms impinged or entrained. At an approach velocity of
10 0.5 ft/s (0.15 m/s) or less, most fish can swim away and escape from the intake current
11 (66 FR 65274). The maximum design approach velocity in front of the traveling screens at the
12 RMPF is approximately 0.5 ft/s, based on a maximum pumping rate of approximately
13 538,000 gpm (2,040 m³/min) (STPNOC 2008a, 2008c, 2010c).

14 Technologies to exclude organisms and to collect and return organisms to the water body. The
15 RMPF has several technologies that help exclude organisms from becoming impinged or
16 entrained. The RMPF has coarse trash racks with 4-in. (10-cm) spacing between bars, which
17 would impede larger organisms from entering the intake system (STPNOC 2010c). After
18 passing through trash racks, water flows through traveling screens with a 3/8 in. (9.5 mm) mesh
19 (STPNOC 2010c). The space between the trash racks and the traveling screens allow fish to
20 swim downstream and exit the intake structure (STPNOC 2010c). Fish collected or washed
21 from the traveling screens can also return to the river via a sluice and fish bypass pipe. The
22 discharge point of the fish bypass system is at the downstream end of the intake structure,
23 approximately 2 ft (0.6 m) below normal water elevation (STPNOC 2010c).

24 During high-flow conditions, the accumulation of debris on the traveling screens is too high to
25 open the fish bypass system, and screenwash discharge is directed to the sluice trench catch
26 baskets rather than back to the river. Generally, the fish bypass system is closed when river
27 flows are greater than 4,000 cfs (100 m³/s), and the system is occasionally closed when flows
28 are greater than 2,000 cfs (60 m³/s), which has occurred from 2001 to 2006, 7 percent of the
29 time (STPNOC 2008a, 2008c, 2010c). Operators at the RMPF are required to monitor for
30 increased impingement rates on the traveling screens, and operators evaluate relevant
31 factors—such as river flow, salinity, and observations of impingement—to determine whether
32 pumping should continue (STPNOC 2008a, 2008c, 2010c).

33 Intake Location and Time of Withdrawals. Location of the intake system is another design factor
34 that can affect impingement and entrainment because water drawn from areas with lower
35 biological productivity is less likely to include organisms that could be impinged or entrained.
36 The RMPF is located on the Colorado River, which is designated as a tidal stream and includes
37 essential fish habitat (EFH) for Federally managed fish and shellfish species (GMFMC 2004).
38 Locating intake systems in such areas with sensitive biological productivity can negatively affect
39 aquatic life (69 FR 41576). However, the area of the river where the RMPF is situated has
40 fewer organisms and less species richness than the downstream segment of the river, closer to
41 the GIWW (ENSR 2008b).

42 STPNOC designed the RMPF to position the traveling intake screens parallel to the flow in the
43 river, or “flush” to the river bank with no projecting structures that create eddies and
44 countercurrents that would cause entrapment (NRC 1986; STPNOC 2010c). Most organisms
45 likely to be entrained or entrapped would occur in higher densities in the main river channel.
46 They are less likely to be removed from the river by an intake facility sited on the shoreline
47 (NRC 2011b). Entrapment of aquatic organisms in a restricted area (e.g., in the sedimentation

Environmental Impacts of Operation

1 basin between the RMPF intake screens and the pumps and in the MCR) can lead to
2 congregation of the organisms, and, if environmental conditions change, the organisms may be
3 harmed. Under such conditions, entrapment can increase impingement of aquatic organisms.

4 Operational procedures for the RMPF also minimize impingement and entrainment because
5 STPNOC intermittently draws water from the Colorado River for Units 1 and 2, and pumping
6 occurs during periods of lower biological productivity. For example, STPNOC (2010b) noted
7 that most withdrawals would occur during periods of high river flow. Pumping at high-flow
8 conditions minimizes impacts to aquatic organisms in the water column because the organisms
9 are likely to remain in the river flow and unlikely to be caught in the influence of the water being
10 pumped into the RMPF located on the shoreline (STPNOC 2008a, 2008c, 2010b, 2010c). In
11 addition, periods of high river flow (fall through spring) generally correlate with lower biological
12 productivity when less young and estuarine-marine organisms are present (NRC 1986;
13 STPNOC 2010b). During the 2007 to 2008 aquatic ecology studies in the Colorado River, fish
14 density (as expressed in the catch per unit effort) was lowest during high river flow conditions
15 and when salinity was lowest (ENSR 2008b; STPNOC 2008a, 2008c). Salinity can be an
16 indicator of an influx of estuarine species moving up the river from the GIWW.

17 *Line of Evidence 4: Other Regulatory Reviews*

18 Section 316(b) of the CWA requires that the location, design, construction, and capacity of
19 cooling water intake structures reflect the best technology available for minimizing adverse
20 environmental impacts. As part of STPNOC's original National Pollutant Discharge Elimination
21 System (NPDES) permit application, in a letter dated June 28, 1982, STPNOC provided EPA
22 with detailed information on the design and operation of the RMPF (STPNOC 2010b). Based
23 on this information, EPA concluded that "the intake structure is approved by Best Available
24 Technology in accordance with Section 316(b) of the CWA" (EPA 1985).

25 TCEQ has administered STPNOC's Texas Pollutant Discharge Elimination System (TPDES)
26 permit since 1998, when EPA delegated authority to the State of Texas to administer the State's
27 permit program. STPNOC submitted a TPDES permit renewal application by letter dated
28 May 24, 2007. Included in this application was a description of how the cooling water system is
29 a closed-cycle recirculating system and, as such, meets the best available technology standard
30 for minimizing adverse environmental impacts (STPNOC 2010b). For example, STPNOC noted
31 that the MCR recycles water for heat-dissipation and is not a water of the U.S. or a water of the
32 State. TCEQ Water Quality Division concurred that the STP cooling system operates as a
33 closed-cycle recirculating system and that the MCR is not a water of the State (TCEQ 2007).
34 Neither EPA nor the State of Texas has requested additional studies from STPNOC in regards
35 to a 316(b) determination (STPNOC 2010b).


36 *Line of Evidence Number 5: STP Survey Data on the Colorado River*

37 Impingement and entrainment from current operations of the RMPF have removed individuals
38 from the Colorado River ecosystem. One method to determine the impacts to aquatic resources
39 from operation of the RMPF is to compare the species abundance and diversity prior to and
40 during operations. ENSR (2008b) compared the aquatic community in the Colorado River using
41 the results of field studies from 1974 (HPLC 1974), 1983 and 1984 (McAden 1984, 1985), and
42 2007 through 2008 (ENSR 2008b). The 1970s studies were conducted in support of the
43 construction permit for STP, Units 1 and 2. McAden (1984, 1985) conducted studies in support
44 of the operating license for STP, Units 1 and 2. ENSR (2008b) sampled portions of the
45 Colorado River in support of the combined license (COL) for proposed Units 3 and 4.
46 Section 2.2.5.1 provides additional details of these studies. Because the sampling locations
47 and gear types varied with each study, it can be difficult to determine whether changes over

1 time are due to plant operations, other anthropogenic or environmental changes, or study
 2 methods.

3 ENSR (2008b) compared species richness from trawl surveys conducted in 1974, 1983,
 4 and 2007 through 2008. Species richness was generally higher in 2007 through 2008
 5 compared to earlier surveys (ENSR 2008b), as shown in Figure 4–1. For example, species
 6 richness in Segment C, which is closest to the RMPF, increased from 12 in the 1974 study to
 7 24 in 2007 through 2008 study. Because STPNOC gathered data for only 2 or 3 years in each
 8 segment of the river, it is unclear whether the change in diversity is part of a long-term temporal
 9 change or whether the physical conditions in the river (e.g., lower salinity in the 1970s), or
 10 another variable, contributed to the different levels of diversity in 1974 compared to 2007 and
 11 2008.

12 **Figure 4–1. Species Richness of Aquatic Species Captured in Trawl Surveys**
 13 **from 1974, 1983, and 2007 through 2008**



14 ENSR (2008b) calculated the Jaccard coefficients of community similarity to determine
 15 similarities between the samples collected over time in similar reaches of the lower Colorado
 16 River based on the presence or absence of taxa. For this measure, as the coefficient
 17 approaches 1.0, the more taxa in the two samples are the same. Conversely, as the coefficient
 18 approaches 0, the samples have fewer taxa in common. For samples collected in the area
 19 closest to the RMPF (Segment C), the Jaccard coefficient was 0.36, when comparing
 20 2007 to 2008 samples to 1974 samples, and 0.37, when comparing 2007 to 2008 samples to
 21 1983 to 1984 samples. Similar comparisons with seine data resulted in coefficient values
 22 of 0.31 (for 1974) and 0.33 (for 1983 to 1984). ENSR (2008b) also compared trawl data
 23 throughout all river segments for 1974 and 2007 to 2008 data, which resulted in a Jaccard
 24 coefficient of 0.44. These results suggest low to moderate similarity of the species collected
 25 in 1974 and 1983 through 1984 compared to 2007 through 2008.

Environmental Impacts of Operation

1 The results of ENSR (2008b) suggest that the current aquatic community is different and may
2 be slightly more diverse than the aquatic community inhabiting the Colorado River during the
3 start of operations for STP, Units 1 and 2. ENSR (2008b) observed changes in diversity near
4 the RMPF as well as further downstream, which would be less likely to be impacted by STP
5 operations. The increase in flow between the Colorado River and Matagorda Bay has likely
6 contributed to the changes in community structure and the increase in species diversity of
7 aquatic species by providing passage for saltwater and estuarine species from the lower
8 Colorado River to Matagorda Bay (NRC 2011b). Based on the information from the latest
9 survey data and what is known about the design of the RMPF, the operation of the RMPF does
10 not appear to have noticeably altered populations of the species currently found in the river.

11 *Conclusion*

12 The NRC staff examined five lines of evidence to determine if impingement and entrainment
13 have the potential to cause adverse impacts to fish and shellfish near STP. The first line of
14 evidence includes impingement and entrainment studies at the RMPF during the initial filling
15 and subsequent intermittent withdraw of water from the Colorado River to the MCR
16 (McAden 1984, 1985). The second line of evidence includes impingement and entrainment
17 studies at the CWIS from 2007 through 2008 during the withdraw of water from the MCR
18 through the circulating water system (ENSR 2008a). The third line of evidence includes
19 engineering designs and operational procedures to limit impingement and entrainment. The
20 fourth line of evidence includes reviews by other regulatory agencies, such as EPA and the
21 TCEQ. The fifth line of evidence includes survey data of fish and shellfish populations prior to
22 and during operations within the Colorado River.

23 STPNOC conducted limited studies of impingement, entrainment, and aquatic monitoring at the
24 RMPF in the lower Colorado River. However, in considering the best available information for
25 the staff's analysis, the results and conclusions of earlier impingement and entrainment studies
26 and evaluations, such as McAden (1983, 1984) and NRC (1986), are likely still applicable
27 because the most commonly impinged species are still common in the area near the RMPF
28 (ENSR 2008b). Additionally, the design features of the RMPF that minimize losses of
29 organisms would not change during the period of extended operations. In addition, EPA (1985)
30 has concluded that the design of the RMPF reflects best available technology for minimizing
31 adverse environmental impacts. Based on the information from current and historical surveys,
32 impingement and entrainment studies, and the design of the RMPF and the cooling system,
33 operation of the STP cooling system does not appear to have noticeably altered populations of
34 the species currently found in the river. Therefore, the NRC staff concludes that the impact from
35 entrainment and impingement by the STP cooling water system on aquatic resources is SMALL.

36 **4.5.3 Thermal Shock**

37 For plants with cooling pond heat-dissipation systems, NRC's GEIS (1996) lists the effects of
38 heat shock as an issue requiring plant-specific, Category 2, evaluation before license renewal.
39 The NRC (1996) made impacts on fish and shellfish resources resulting from heat shock a
40 site-specific issue because of continuing concerns about thermal discharge effects and the
41 possible need to modify thermal discharges in the future in response to changing environmental
42 conditions.

43 Information considered in this analysis includes STPNOC's TDPES permit, modeling of the
44 thermal plume, the type of cooling system (cooling pond heat-dissipation system in this case),
45 and other information. To perform this evaluation, the NRC staff (a) reviewed the STPNOC's

1 ER (STPNOC 2010b), STPNOC's TPDES permit (TCEQ 2005), and thermal plume modeling
2 results (NRC 2011b) and (b) performed an audit at the STP site.

3 As described in Section 2.2.3, STP discharge to the Colorado River is permitted under its
4 TPDES permit (TCEQ 2005). The permit allows the average daily discharge to be 144 million
5 gallons per day (gpd). The TPDES permit also limits the daily average temperature to 95 °F
6 and the daily maximum temperature to 97 °F. TCEQ based these limits on site-specific (or
7 segment-specific) TCEQ water quality rise standards for Segment 1401, Colorado River Tidal,
8 at Title 30, Chapter 307.10, Appendix A, pursuant to the Texas Administrative Code. The
9 TPDES permit also prohibits discharges that would exceed 12.5 percent of the flow of the
10 Colorado River at the discharge point or when the flow in the Colorado River adjacent to STP is
11 less than 800 cfs. An EPA online database indicated that STP has had no CWA formal
12 enforcement actions or violations related to discharge temperature in the last 5 years
13 (STPNOC 2011c). Neither EPA nor TCEQ has required STPNOC to seek a 316(a) variance or
14 conduct studies in support of a 316(a) variance (STPNOC 2010b).

15 STPNOC operating procedures limit the blowdown flow rates and the number of discharge ports
16 to be used during discharge events (STPNOC 2010b). For example, operators may open two to
17 seven blowdown valves, depending on the blowdown rate (STPNOC 2010b). STPNOC
18 procedures prescribe a range of allowable blowdown rates, from 80 to 308 cfs, depending on
19 the Colorado River flow (STPNOC 2010b).

20 NRC (2011b) modeled the potential thermal plume from discharges to the Colorado River based
21 on the continued operations of STP, Units 1 and 2, as well as the operation of proposed Units 3
22 and 4. While this SEIS solely pertains to continued operation of STP, Units 1 and 2, the results
23 of NRC's (2011b) modeling study are presented for the following reasons:

- 24 • During operations of Units 3 and 4, discharge from all four units would mix in
25 the MCR, and STPNOC would operate a single outfall to discharge water
26 from the MCR (STPNOC 2010c).
- 27 • The same TPDES permit would cover Units 1 through 4 (STPNOC 2010c).
- 28 • Modeling the thermal plume based on four-unit operation bounds the
29 potential impacts from continued operations of STP, Units 1 and 2.

30 NRC (2011b) determined that the maximum thermal plume dimensions would occur during the
31 greatest difference in temperatures between the MCR water and the water in the river (20.4 °F),
32 highest MCR discharge rate through seven ports (44 cfs per port, for a total of 308 cfs discharge
33 rate), and the minimal flow in the Colorado River where the discharge would be equal to
34 12.5 percent of the total flow in the river (2,464 cfs). NRC (2011b) modeled these conditions
35 using a CORMIX (U.S. EPA computer code) mixing-zone model to determine the likely water
36 temperature increases, the likely duration and frequency of discharge, and the dimensions of
37 the thermal plume. The model indicated that a portion of the Colorado River would remain at
38 ambient water temperature, allowing mobile aquatic organisms to avoid the thermal plume by
39 passing the plume on the bottom of the river and throughout much of the water column. For
40 example, during the maximum expected thermal plume dimensions, the thermal plume that is
41 5 °F (2.8 °C) above ambient conditions reaches the bottom of the river from the last port of the
42 discharge pipe to 120 ft (37 m) downstream, and the plume extends approximately 25 percent
43 across the width of the river. In that part of the river, the benthic invertebrate species
44 (e.g., grass (*Palaemonetes pugio*), white, and brown shrimp) would be able to move along the
45 bottom of the river on the far side of the discharge structure without passing through the
46 elevated temperature plume. Approximately 120 ft (37 m) downstream of the last port of the

Environmental Impacts of Operation

1 discharge pipe, the positive buoyancy of the warmer water causes the plume to rise to the
2 surface of the river. NRC (2011b) predicted the surface of the river to have an elevated
3 temperature across the entire width of the river from approximately 1,060 ft (323 m) from the
4 last port of the discharge pipe to about 4,400 ft (1,341 m) downstream from the ports. As the
5 plume rises to the surface and extends from bank to bank, however, a portion of the water
6 column would remain at ambient river temperatures and would allow mobile organisms—such
7 as foraging fish (e.g., Gulf menhaden, black drum (*Pogonias cromis*), spotted seatrout
8 (*Cynoscion nebulosus*), striped mullet)—to move up and downstream.

9 Less mobile organisms would not be able to swim away to avoid the thermal plume, such as
10 eggs, larvae, and mollusks. The most common juvenile and adult species collected in
11 Segment B, where the plume could reach across the river at the surface, include Gulf
12 menhaden, grass shrimp, black drum, white shrimp, and striped mullet (ENSR 2008b). The
13 overall impact to these species from the effects of the thermal plume would be unlikely to
14 noticeably alter these populations because these organisms have a high fecundity, and the
15 number of organisms lost would be insignificant compared to their population in the lower
16 Colorado River.

17 NRC's (2011b) simulation models the discharge plume based on four-unit operations, which
18 would likely be larger and occur more often than the discharge from continued operations of
19 STP, Units 1 and 2. For example, STPNOC has discharged to the Colorado River once during
20 the operation of STP, Units 1 and 2, in 1997, as part of a system test (STPNOC 2010b). For
21 four-unit operations, STPNOC estimated that water from the MCR would be discharged to the
22 Colorado River as frequently as once every 11 days and could be continuous for as much as
23 75 days (NRC 2011b). NRC (2011b) determined that STPNOC's discharge operating policy
24 would rarely result in discharges from the MCR that would create a thermal plume during times
25 when river water quality is poor.

26 The STP cooling system also limits thermal impacts to the MCR and the Colorado River. STP
27 uses a cooling pond-based heat-dissipation system that withdraws and discharges cooling
28 water to the MCR. The MCR is similar to a closed-cycle cooling system since the water in the
29 reservoir continues to circulate from the MCR, into the plant, and back again. STP discharges
30 to the Colorado River to maintain water chemistry and quality within the MCR. Because the
31 water within the MCR is reused, discharges are generally less frequent than other types of
32 cooling systems, such as once-through cooling systems.

33 After reviewing the status of STPNOC's TPDES permit, modeling of the thermal plume, and the
34 type of cooling system at STP, the NRC staff concludes that the level of thermal impacts to the
35 aquatic community due to renewing the STP operating license is SMALL. The thermal plume is
36 unlikely to noticeably impact aquatic resources near STP for the following reasons:

- 37 • STPNOC's TPDES permits limit the amount and timing of discharges.
- 38 • Modeling studies indicate that mobile aquatic species could avoid the thermal
39 plume by swimming at a lower depth or different side of the river.
- 40 • Species or life-stages that are less mobile organisms would not be able to
41 swim away to avoid the thermal plume, such as eggs, larvae, and mollusks.
42 However, most species observed in this area generally have high fecundity,
43 and the number of organisms lost would be insignificant compared to their
44 population in the lower Colorado River.

- 1 • Cooling water is not regularly discharged into the Colorado River since STP
2 uses a cooling pond-based heat-dissipation system that reuses water from
3 the MCR.

4 **4.5.4 Mitigation**

5 The design of the RMPF and operating procedures mitigate potential impingement, entrainment,
6 and thermal shock to aquatic organisms in the lower Colorado River as follows:

- 7 • Flow Reduction—STPNOC reduces the flow rate, or amount of water
8 withdrawn from the Colorado River, by reusing water in the MCR.
- 9 • Reduced Intake Velocity—At an approach velocity of 0.5 ft/s or less, most fish
10 can swim away and escape from the intake current (66 FR 65274). The
11 maximum design approach velocity in front of the traveling screens at the
12 RMPF is approximately 0.5 ft/s, based on a maximum pumping rate of
13 approximately 538,000 gpm (STPNOC 2008, 2010c).
- 14 • Technologies to Exclude Organisms and to Collect and Return Organisms to
15 the Water Body—The RMPF has coarse trash racks, traveling screens, and a
16 fish bypass system (STPNOC 2010c).
- 17 • Intake Location—The RMPF is situated in a portion of the lower Colorado
18 River that has lower density of many fish and invertebrates and overall lower
19 species richness than further downstream, closer to the GIWW
20 (ENSR 2008b).
- 21 • Time of Withdraws—Operational procedures for the RMPF also minimize
22 impingement and entrainment because STPNOC intermittently draws water
23 from the Colorado River for Units 1 and 2, and pumping occurs during
24 periods of lower biological productivity (e.g., periods of high river flow and
25 lower salinity).

26 Additional details regarding these mitigation measures are described above, in Section 4.5.1.

27 **4.6 Terrestrial Resources**

28 The issues related to terrestrial resources applicable to STP are listed in Table 4–12. There is
29 no Category 2 issue related to terrestrial resources. The NRC staff did not identify any new and
30 significant information during the review of STPNOC’s ER, the staff’s site audit, the scoping
31 process, or the evaluation of other available information (e.g., applicable permits and data
32 reports as listed in the reference section of this SEIS chapter). Therefore, there is no impact
33 related to these issues beyond those discussed in the GEIS. For these issues and consistent
34 with the GEIS, the NRC staff concludes that the impacts to terrestrial resources are SMALL, and
35 additional site-specific mitigation measures are unlikely to be sufficiently beneficial to warrant
36 implementation.

37

1 **Table 4–12. Terrestrial Resources Issues Identified in the GEIS**

Issue	GEIS Section	Category
Cooling tower impacts on crops & ornamental vegetation	4.3.4	1
Cooling town impacts on native plants	4.3.5.1	1
Bird collisions with cooling towers	4.3.5.2	1
Powerline right-of-way management (cutting herbicide application)	4.5.6.1	1
Bird collisions with powerlines	4.5.6.1	1
Impacts of electromagnetic fields on flora & fauna (plants, agricultural crops, honeybees, wildlife, livestock)	4.5.6.3	1
Floodplains & wetland on powerline right-of-way	4.5.7	1

Source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51

2 **4.7 Protected Species and Habitats**

3 Section 2.2.7 of this SEIS describes protected species and habitats in the vicinity of the STP
 4 site. Table 4–13 lists the one Category 2 issue related to protected species and habitats that is
 5 applicable to STP.

6 **Table 4–13. Protected Species Issues Identified in the GEIS**

Issue	GEIS Section	Category
Threatened or endangered species	4.1	2

Source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51

7 This site-specific, or Category 2 issue, requires consultation with the appropriate agencies to
 8 determine whether threatened or endangered species are present and whether they would be
 9 adversely affected by continued operation of STP during the license renewal term. In the case
 10 of STP, the U.S. Fish and Wildlife Service (FWS) is responsible for terrestrial and freshwater
 11 species listed under the Endangered Species Act (ESA), the Bald and Golden Eagles Act, and
 12 the Migratory Bird Treaty Act (MBTA). The National Marine Fisheries Service (NMFS) is
 13 responsible for marine and anadromous species listed under the ESA and the
 14 Magnuson–Stevens Fishery Conservation and Management Act (MSA) and those species that
 15 have been designated as NMFS Species of Concern. The Texas Parks and Wildlife Division is
 16 responsible for species protected by the State of Texas Statutes. Descriptions of protected
 17 species and habitats appear in Section 2.2.8.

18 Listed Species Protected Under the Endangered Species Act. The NRC staff corresponded
 19 with both the FWS and NMFS to determine impacts to Federally listed species and to decide
 20 whether to initiate Section 7 consultation as a result of the proposed STP license renewal. The
 21 NRC developed a list of Federally listed species within the vicinity of STP and requested
 22 concurrence on this list in a February 16, 2011, letter (NRC 2011f). The FWS responded to this
 23 request on June 2, 2011, with an updated list and recommendations concerning specific species
 24 (FWS 2011). Specific species for which FWS had concerns are discussed in Section 2.2.8.1.

- 1 The NRC sent a similar letter to the NMFS on February 16, 2011 (NRC 2011h). The NMFS
 2 responded to this letter in an e-mail dated March 3, 2011 (NMFS 2011) and provided the NRC
 3 with a list of Federally listed species under its jurisdiction in Texas.
 4 Table 4–14 provides the NRC’s ESA effect determinations for each Federally listed species
 5 identified in Section 2.2.8.1.

6 **Table 4–14. Effect Determinations for Federally Listed Species**

Species	ESA Effect Determination	Justification for Determination
Amphibians		
Houston toad (<i>Bufo houstonensis</i>)	unlikely to adversely affect	The species potentially occurs on the STP site or along the t-line corridors, but the proposed action would not result in measurable or detectable impacts or reach the scale at which a take occurs.
San Marcos salamander (<i>Eurycea nana</i>)	unlikely to adversely affect	The species potentially occurs on the STP site or along the t-line corridors, but the proposed action would not result in measurable or detectable impacts or reach the scale at which a take occurs.
Texas blind salamander (<i>Typhlomolge rathbuni</i>)	unlikely to adversely affect	The species potentially occurs on the STP site or along the t-line corridors, but the proposed action would not result in measurable or detectable impacts or reach the scale at which a take occurs.
Arachnids		
Robber Baron Cave meshweaver (<i>Cicurina baronia</i>)	no effect	This species occurs in underground caves in counties through which the t-lines cross. However, t-line maintenance activities would not affect this species.
Madla Cave meshweaver (<i>Cicurina madla</i>)	no effect	This species occurs in underground caves in counties through which the t-lines cross. However, t-line maintenance activities would not affect this species.
braken bat cave meshweaver (<i>Cicurina venii</i>)	no effect	This species occurs in underground caves in counties through which the t-lines cross. However, t-line maintenance activities would not affect this species.
Government Canyon bat cave meshweaver (<i>Cicurina vespera</i>)	no effect	This species occurs in underground caves in counties through which the t-lines cross. However, t-line maintenance activities would not affect this species.
Government Canyon bat cave spider (<i>Neoleptoneta microps</i>)	no effect	This species occurs in underground caves in counties through which the t-lines cross. However, t-line maintenance activities would not affect this species.

Environmental Impacts of Operation

Species	ESA Effect Determination	Justification for Determination
Cokendolpher cave harvestman (<i>Texella cokendolpheri</i>)	no effect	This species occurs in underground caves in counties through which the t-lines cross. However, t-line maintenance activities would not affect this species.
Birds		
piping plover (<i>Charadrius melodus</i>)	unlikely to adversely affect	The species occurs in the action area, but the proposed action would not result in measurable or detectable impacts or reach the scale at which a take occurs.
golden-cheeked warbler (<i>Dendroica chrysoparia</i>)	unlikely to adversely affect	This species occurs in counties through which the t-lines cross. However, t-line maintenance would not result in any measurable or detectable impacts or reach the scale at which a take occurs.
northern aplomado falcon (<i>Falco femoralis septentrionalis</i>)	unlikely to adversely affect	This species occurs Matagorda County and in counties through which the t-lines cross. However, continued STP site operation and maintenance and t-line maintenance would not result in any measurable or detectable impacts or reach the scale at which a take occurs.
whooping crane (<i>Grus americana</i>)	unlikely to adversely affect	This species occurs Matagorda County and in counties through which the t-lines cross. However, continued STP site operation and maintenance and t-line maintenance would not result in any measurable or detectable impacts or reach the scale at which a take occurs.
Attwater's greater prairie-chicken (<i>Tympanuchus cupido attwateri</i>)	unlikely to adversely affect	This species occurs in counties through which the t-lines cross. However, t-line maintenance would not result in any measurable or detectable impacts or reach the scale at which a take occurs.
black-capped vireo (<i>Vireo atricapilla</i>)	unlikely to adversely affect	This species occurs in counties through which the t-lines cross. However, t-line maintenance would not result in any measurable or detectable impacts or reach the scale at which a take occurs.
Crustaceans		
Peck's cave amphipod (<i>stygobromus pecki</i>)	no effect	This species occurs in two underground springs: Comal Springs and Hueco Springs. The t-lines do not cross or run near these springs.

Species	ESA Effect Determination	Justification for Determination
Fish		
fountain darter (<i>Etheostoma fonticola</i>)	no effect	This species only occurs in the San Marcos and Comal rivers. T-line maintenance would not affect this species because none of the t-lines crosses these rivers.
San Marcos gambusia (<i>Gambusia georgei</i>)	no effect	This species only occurs in the San Marcos River. T-line maintenance would not affect this species because none of the t-lines cross this river.
smalltooth sawfish (<i>Pristis pectinata</i>)	no effect	The species does not occur in the Colorado River or any of the water bodies crossed by the t-lines.
largetooth smallfish (<i>Pristis pristis</i>)	no effect	The species does not occur in the Colorado River or any of the water bodies crossed by the t-lines.
Insects		
helotes mold beetle (<i>Batrisodes venyivi</i>)	no effect	This species occurs in underground caves in counties through which the t-lines cross. However, t-line maintenance activities would not affect this species.
Comal Springs riffle beetle (<i>Heterelmis comalensis</i>)	no effect	This species occurs in two underground springs: Comal Springs and Fern Bank Springs. The t-lines do not cross or run near these springs.
unnamed beetle (<i>Rhadine exilis</i>)	no effect	This species occurs in underground caves in counties through which the t-lines cross. However, t-line maintenance activities would not affect this species.
unnamed beetle (<i>Rhadine infernalis</i>)	no effect	This species occurs in underground caves in counties through which the t-lines cross. However, t-line maintenance activities would not affect this species.
Comal Springs dryopid beetle (<i>Stygoparnus comalensis</i>)	no effect	This species occurs in surface water in two springs: Comal Springs and Fern Bank Springs. The t-lines do not cross or run near these springs.
Mammals		
sei whale (<i>Balaenoptera borealis</i>)	no effect	The species does not occur in the Colorado River or any of the water bodies crossed by the t-lines.
blue whale (<i>Balaenoptera musculus</i>)	no effect	The species does not occur in the Colorado River or any of the water bodies crossed by the t-lines.

Environmental Impacts of Operation

Species	ESA Effect Determination	Justification for Determination
finback whale (<i>Balaenoptera physalus</i>)	no effect	The species does not occur in the Colorado River or any of the water bodies crossed by the t-lines.
Gulf coast jaguarundi (<i>Herpailurus yaguarondi cacomitli</i>)	no effect	The species does not occur on the STP site and is unlikely to occur along the t-line corridors due to habitat preferences.
ocelot (<i>Leopardus pardalis</i>)	no effect	The species does not occur on the STP site and is unlikely to occur along the t-line corridors due to habitat preferences.
humpback whale (<i>Megaptera novaeangliae</i>)	no effect	The species does not occur in the Colorado River or any of the water bodies crossed by the t-lines.
sperm whale (<i>Physeter macrocephalus</i>)	no effect	The species does not occur in the Colorado River or any of the water bodies crossed by the t-lines.
West Indian manatee (<i>Trichechus manatus</i>)	no effect	The species does not occur in the Colorado River or any of the water bodies crossed by the t-lines.
Plants		
Navasota ladies' tresses (<i>Spiranthes parksii</i>)	no effect	This species occurs in small-scale canopy openings of forests. Thus, this species is unlikely to be in t-line corridors, and t-line maintenance would not affect the species.
Texas wild rice (<i>Spiranthes parksii</i>)	no effect	This species is an aquatic plant found in the San Marcos River. T-line maintenance would not affect this species because none of the t-lines cross this river.
Reptiles		
American alligator (<i>Alligator mississippiensis</i>)	unlikely to adversely affect	This species occurs on the STP site and may occur along t-line corridors. However, continued STP site operation and maintenance and t-line maintenance would not result in any measurable or detectable impacts or reach the scale at which a take occurs.
loggerhead sea turtle (<i>Caretta caretta</i>)	no effect	The species does not occur in the action area.
green sea turtle (<i>Chelonia mydas</i>)	no effect	The species does not occur in the action area.
leatherback sea turtle (<i>Dermochelys coriacea</i>)	no effect	The species does not occur in the action area.
hawksbill sea turtle (<i>Eretmochelys imbricata</i>)	no effect	The species does not occur in the action area.

Species	ESA Effect Determination	Justification for Determination
Kemp's ridley sea turtle (<i>Lepidochelys kempii</i>)	no effect	The species does not occur in the action area.

1 Based on a review of the ER, the information provided by the FWS, and the NRC staff's
 2 independent review of available information, the NRC staff concludes that the proposed license
 3 renewal would have no effect on 31 of the 41 Federally listed species that occur in Matagorda
 4 County or in one of the counties through which the transmission line corridors traverse. The
 5 NRC staff concludes that the proposed license renewal may affect, but is unlikely to adversely
 6 affect, the remaining 10 species. Of these 10 species, only the American alligator
 7 (*Alligator mississippiensis*) has been observed on the site since STP began operating. There
 8 are three amphibian and six bird species that have not been observed on the site but have the
 9 potential to occur in areas of suitable habitat on the STP site or along the transmission line
 10 corridors. Continued operation and maintenance of the site will not involve any new changes to
 11 operation (e.g., construction, refurbishment, or ground-disturbing activities) or changes to
 12 existing land use conditions in either natural or developed areas. Thus, continued operation of
 13 STP would have no direct or indirect adverse effects to these species. Furthermore, the
 14 continued operation of STP during the license renewal term would preserve the existing habitats
 15 on the STP site. Therefore, this could result in beneficial effects to the 10 species discussed
 16 above.

17 The majority of the transmission line corridors traverse agricultural and range lands, which
 18 require minimal maintenance activities. Thus, continued operation and maintenance of the
 19 transmission lines would not result in habitat alteration. Herbicide application could create
 20 potential adverse effects by exposing these species to chemicals. However, these effects
 21 would be insignificant (i.e., those impacts that would never reach the scale where a take might
 22 occur) or discountable (i.e., those impacts that cannot be meaningfully measured, detected, or
 23 evaluated). The NRC staff did not identify any adverse effects associated with either STP site
 24 operation and maintenance or transmission line corridor maintenance that could reasonably be
 25 attributed to the proposed license renewal. However, because these species have the potential
 26 to occur in the area, the NRC staff conservatively has concluded that the proposed action may
 27 affect, but is unlikely to adversely affect, these species.

28 Designated Critical Habitat Protected Under the Endangered Species Act. The STP site is in
 29 close proximity to four units of designated piping plover (*Charadrius melodus*) critical habitat,
 30 the closest of which lies 7 mi (11 km) south of the STP site boundary along the shoreline of
 31 West Matagorda Bay. Because continued operation and maintenance of the STP site would
 32 involve no onsite or offsite disturbances, the proposed license renewal would result in no direct
 33 or indirect effects to piping plover critical habitat. The transmission line corridors do not occur
 34 near any of the four parcels of designated critical habitat. Thus, the NRC staff concludes that
 35 the proposed license renewal would have no effect on designated piping plover critical habitat.

36 Proposed Species and Proposed Critical Habitat Protected Under the Endangered Species Act.
 37 The NRC staff did not identify any Federally proposed species or proposed critical habitat within
 38 the action area during its review. Additionally, in its correspondence with NRC, the FWS (2011)
 39 and NMFS (2011) did not identify any proposed species or proposed critical habitat. Thus, the
 40 NRC staff concludes that the proposed license renewal would have no effect on Federally
 41 proposed species or proposed critical habitat.

42 Species Designated as NMFS Species of Concern. Though some of the species of concern
 43 listed in Section 2.2.8.2 occur in Matagorda Bay, none of the species of concern in the vicinity of

Environmental Impacts of Operation

1 STP occur in the Colorado River and would, therefore, not be impinged or entrained by STP
2 cooling water intake or otherwise affected by the proposed license renewal. The NRC staff
3 concludes that there is no adverse impact to any NMFS species of concern.

4 Species Protected Under the Bald and Golden Eagles Protection Act. Though bald eagles
5 occur throughout the STP region, no known nests are in close proximity to any of the STP
6 buildings, parking lots, or other structures that could be disturbed by ongoing human activity.
7 Because the proposed license renewal does not involve construction or land disturbances, no
8 bald eagle habitat would be affected by the proposed license renewal. The NRC staff
9 concludes that there is no adverse impact to the bald eagle.

10 Species Protected Under the Migratory Bird Treaty Act. As discussed in Section 2.2.8.4, a
11 variety of migratory birds inhabit the STP site and surrounding region. Because the proposed
12 license renewal does not involve construction or land disturbances, no migratory birds would be
13 affected by the proposed license renewal. The NRC staff concludes that there is no adverse
14 impact to migratory birds.

15 Species Protected Under the Marine Mammal Protection Act. Section 2.2.8.5 discusses marine
16 mammals in the vicinity of STP. None of these species occur in the Colorado River and would,
17 therefore, not be impinged or entrained by STP cooling water intake or otherwise affected by the
18 proposed license renewal. The NRC staff concludes that there is no adverse impact to any
19 marine mammals.

20 Species Protected Under the Magnuson–Stevens Act. Section 2.2.8.6 identifies species with
21 essential fish habitat (EFH) with the potential to occur in the vicinity of STP. Of these species,
22 ENSR (2008) collected the mangrove snapper and brown shrimp, white shrimp have been
23 collected during ecological studies associated with STP, and white and brown shrimp have been
24 collected during impingement or entrainment samples.

25 The NRC prepared an EFH assessment (NRC 2011c) as part of the review of the Units 3 and 4
26 COL application review. The NRC staff included the Colorado River, Matagorda Bay, and the
27 Gulf of Mexico in the scope of its analysis because construction activities for the proposed
28 Units 3 and 4 would include barge traffic. In that EFH assessment, the NRC concluded that the
29 proposed Units 3 and 4 would have minimal adverse effects on EFH. The NMFS concurred
30 with this determination in April 2010 (NMFS 2010). Because the area that would be affected by
31 the proposed license renewal is smaller than the affected area for the proposed STP, Units 3
32 and 4, and would not require any construction or changes to current operation, the NRC staff
33 concludes that the NRC's EFH assessment for the proposed STP, Units 3 and 4 (NRC 2011c),
34 bounds the analysis for the proposed license renewal of STP, and that there are no adverse
35 impacts to any EFH species.

36 Species Protected Under State of Texas Statutes. Section 2.2.8.7 discusses species protected
37 under Texas's State Statutes. Some State-listed species may occur along the transmission line
38 corridors. However, the minimal transmission line maintenance associated with the STP
39 transmission lines is unlikely to affect any State-listed species. Because the transmission line
40 corridors are well-established, continued maintenance will also not reduce or affect the amount
41 or quality of available habitat. The NRC staff concludes that there are no adverse impacts to
42 any State-listed species.

43 Conclusion. The NRC staff concludes that the impacts of the proposed STP license renewal on
44 protected species and habitats would be SMALL, as defined by the NRC for the purposes of
45 National Environmental Policy Act (NEPA) compliance.

1 **4.8 Human Health**

2 The human health issues applicable to South Texas Project are discussed below and listed in
 3 Table 4–15 for Category 1, Category 2, and uncategorized issues.

4 **Table 4–15. Human Health Issues.**
 5 *Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 contains more information on these*
 6 *issues.*

Issue	GEIS Section	Category
Radiation exposures to the public during refurbishment	3.8.1 ^(a)	1
Occupational radiation exposures during refurbishment	3.8.2 ^(a)	1
Microbiological organisms (occupational health)	4.3.6	1
Microbiological organisms (public health, for plants using lakes or canals or cooling towers or cooling ponds that discharge to a small river)	4.3.6	2
Noise	4.3.7	1
Radiation exposures to public (license renewal term)	4.6.2	1
Occupation radiation exposures (license renewal term)	4.6.3	1
Electromagnetic fields—acute effects (electric shock)	4.5.4.1	2
Electromagnetic fields—chronic effects	4.5.4.2	Uncategorized

^(a) Issues apply to refurbishment, an activity that STP does not plan to undertake.

Source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51

7 **4.8.1 Generic Human Health Issues**

8 Category 1 issues applicable to STP in regard to human health impacts are listed in Table 4–15.
 9 STPNOC stated in its ER that it was not aware of any new and significant human health issues
 10 associated with the renewal of the STP operating license. The staff has not identified any new
 11 and significant information related to human health issues associated with the operation of STP,
 12 Units 1 and 2, during the period of license renewal as a result of its independent review of
 13 STPNOC’s ER, the site audit, and the scoping process. The NRC staff also reviewed other
 14 sources of information, such as applicable permits and data reports, as listed in the reference
 15 section of this SEIS chapter. Therefore, the NRC staff concludes that, for Category 1 human
 16 health issues, there would be no impact from nonradiological issues to the public or to workers
 17 during the renewal term beyond those discussed in the GEIS.

18 **4.8.2 Radiological Impacts of Normal Operations**

19 Category 1 issues applicable to STP in regard to radiological impacts are listed in Table 4–15.
 20 Regarding the potential for new and significant radiological information, STPNOC evaluated the
 21 issue of tritium contained in groundwater on the plant site and concluded that the tritium in
 22 groundwater would not preclude the water’s current or future use; therefore, the issue is not new
 23 and significant. The staff discusses groundwater monitoring for radioactivity later in this section.
 24 In its radiological evaluation, the NRC staff determined that the issue is not new and significant.

Environmental Impacts of Operation

1 The staff has not identified any new and significant information related to human health issues
2 associated with radiation exposures during its independent review of STPNOC's ER, the site
3 audit, and the scoping process. Therefore, the NRC staff concludes that there would be no
4 impact from radiation exposures to the public or to workers during the renewal term beyond
5 those discussed in the GEIS.

6 The findings in the GEIS are as follows:

- 7 • Radiation exposures to public (license renewal term)—Based on information
8 in the GEIS, the NRC found that radiation doses to the public will continue at
9 current levels associated with normal operations.
- 10 • Occupational exposures (license renewal term)—Based on information in the
11 GEIS, the NRC found that projected maximum occupational doses during the
12 license renewal term are within the range of doses experienced during
13 normal operations and normal maintenance outages and would be well below
14 regulatory limits.

15 According to the GEIS, the impacts to human health are SMALL, and additional plant-specific
16 mitigation measures are unlikely to be sufficiently beneficial to warrant implementation. There
17 are no Category 2 issues related to radiological impacts of routine operations.

18 The information presented below is a discussion of selected radiological programs conducted at
19 STP.

20 South Texas Project Radiological Environmental Monitoring Program. STP conducts a
21 Radiological Environmental Monitoring Program (REMP) to assess the radiological impact, if
22 any, to its employees, the public, and the environment from the operations at STP, Units 1
23 and 2. The REMP measures the aquatic, terrestrial, and atmospheric environment for
24 radioactivity, as well as the ambient radiation. In addition, the REMP measures background
25 radiation (i.e., cosmic sources, global fallout, and naturally occurring radioactive material,
26 including radon). The REMP supplements the radioactive effluent monitoring program by
27 verifying that any measurable concentrations of radioactive materials and levels of radiation in
28 the environment are not higher than those calculated using the radioactive effluent release
29 measurements and transport models.

30 An annual radiological environmental operating report is issued, which contains a discussion of
31 the results of the monitoring program. The report contains data on the monitoring performed for
32 the most recent year. The REMP collects samples of environmental media to measure the
33 radioactivity levels that may be present. The media samples are representative of the radiation
34 exposure pathways that may impact the public.

35 The STP REMP is made up of four categories based on the exposure pathways to the public—
36 airborne, waterborne, ingestion, and direct radiation. The air is sampled in areas around STP
37 by measuring the levels of radioactive iodine and particulate matter on filters. For the
38 waterborne pathway, the water samples are taken from surface water, groundwater, and
39 drinking water. Also included in this pathway are sediment samples taken from the MCR and
40 the Colorado River. The ingestion pathway samples local broadleaf vegetation, agricultural
41 products, and food products. The direct exposure pathway measures environmental radiation
42 doses using thermoluminescent dosimeters.

43 In addition to the REMP, STP has an onsite Groundwater Protection Program designed to
44 monitor the onsite plant environment for detection of leaks from plant systems and pipes
45 containing radioactive liquid (STPNOC 2010). Additional information on the Groundwater

1 Protection Program is contained later in this section and in the Groundwater Quality section in
2 Chapter 2 of this document.

3 The staff reviewed the STP annual radiological environmental operating reports for 2006
4 through 2010 to look for any significant impacts to the environment or any unusual trends in the
5 data (STP 2007a, 2008d, 2009a, 2010a, 2011a). A 5-year period provides a data set that
6 covers a broad range of activities that occur at a nuclear power plant such as refueling outages,
7 non-refueling outage years, routine operation, and years where there may be significant
8 maintenance activities. Based on the staff's review, no adverse trends (i.e., steadily increasing
9 buildup of radioactivity levels) were observed, and the data showed that there was no
10 measurable impact to the environment from operations at STP.

11 Tritium Groundwater Monitoring. Nuclear industry events involving tritium prompted STP to
12 sample groundwater in the shallow aquifer near the nuclear plants in 2005.

13 In 2007, the NEI established a standard for monitoring and reporting radioactive isotopes in
14 groundwater. This standard is contained in NEI 07-07, *Industry Ground Water Protection*
15 *Initiative—Final Guidance Document* (NEI 2007). STPNOC implemented the recommendations
16 of this industry standard and has broadened the Groundwater Monitoring Program to include
17 samples collected near the nuclear plants. Results of STPNOC's Groundwater Monitoring
18 Program are contained in the annual REMP report submitted to the NRC in May of each year.
19 These reports are available for review by the public through the ADAMS electronic reading room
20 available through the NRC Web site.

21 In the 2010 REMP report, STPNOC reported that tritium was detected on site. The applicant's
22 evaluation shows that the positive results are likely due to the well's location in an area that is
23 influenced by the MCR. Other positive samples appear to be the result of discharges to the
24 ground involving water previously considered non-radioactive since only trace quantities of
25 tritium were measured. All groundwater sample containing tritium were below the EPA's
26 drinking water standard of 20,000 pCi/l (740 Becquerels per liter). Also, the data showed no
27 impact to sources of drinking water. The water samples from the onsite drinking water source
28 (a deep aquifer) and offsite sampling of the Colorado River showed only natural background
29 radiation levels (STPNOC 2011a).

30 Based on its review of the applicant's monitoring reports, the staff concludes that there are no
31 significant impacts to human health associated with tritium in the groundwater at the STP site.
32 The applicant's Groundwater Protection Program will monitor the groundwater and report the
33 results in its annual radiological environmental monitoring report. Also, NRC inspectors will
34 periodically review STPNOC's Groundwater Protection Program to ensure the program
35 continues to be effective. Additional information on the applicant's Groundwater Protection
36 Program and tritium in groundwater are in Sections 2.2.5 and 4.4.3 of this SEIS.

37 Texas Department of State Health Services Environmental Monitoring Program. The Texas
38 Department of State Health Services (DSHS) performs its own independent environmental
39 monitoring around the STP site and other nuclear facilities (i.e., research reactors, commercial
40 users of radioactive material, and the U.S. Department of Energy's (DOE's) Pantex facility)
41 located in Texas. All analyses of environmental media (i.e., soil, air, water, and vegetation) are
42 performed by its Laboratory Services Section. The State's radiation branch performs the
43 monitoring of direct radiation from a facility using TLDs.

44 The staff reviewed the State's environmental summary reports for 2005 through 2009 (the most
45 recent report available at the time of the staff's review) (TDSHS 2012). In each of the reports,
46 the State concluded that the sample data indicated no release of radioactive material to the

Environmental Impacts of Operation

1 environment that exceeded the regulatory or license limits of the DSHS or any other agency
2 such as the NRC or the DOE.

3 South Texas Project Radioactive Effluent Release Program. All nuclear plants were licensed
4 with the expectation that they would release radioactive material to both the air and water during
5 normal operation. However, NRC regulations require that radioactive gaseous and liquid
6 releases from nuclear power plants must meet radiation dose-based limits specified in
7 10 CFR Part 20 and the as low as is reasonably achievable (ALARA) criteria in Appendix I to
8 10 CFR Part 50. Regulatory limits are placed on the radiation dose that members of the public
9 can receive from radioactive effluents released by a nuclear power plant. In addition, nuclear
10 power plants are required by 10 CFR 50.36(a) to submit an annual report to the NRC, which
11 lists the types and quantities of radioactive effluents released into the environment. The
12 radioactive effluent release reports are available for review by the public through the ADAMS
13 electronic reading room available through the NRC Web site.

14 The NRC staff reviewed the annual radioactive effluent release reports for 2006 through 2010
15 (STPNOC 2007b, 2008e, 2009b, 2010d, 2011d). The review focused on the calculated doses
16 to a member of the public from radioactive effluents released from STP. The doses were
17 compared to the radiation protection standards in 10 CFR 20.1301 and the ALARA dose design
18 objectives in Appendix I to 10 CFR Part 50.

19 Dose estimates for members of the public are calculated based on radioactive gaseous and
20 liquid effluent release data and atmospheric and aquatic transport models. The 2010 annual
21 radioactive material release report (STPNOC 2011d) contains a detailed presentation of the
22 radioactive discharges and the resultant calculated doses. The following summarizes the
23 calculated dose to a member of the public located outside the STP site boundary from
24 radioactive gaseous and liquid effluents released during 2010:

- 25 • The total-body dose to an offsite member of the public from STP Unit 1
26 radioactive liquid effluents was 4.75×10^{-3} mrem (4.75×10^{-5} mSv) and
27 7.75×10^{-3} mrem (7.75×10^{-5} mSv) for Unit 2, which is well below the 3 mrem
28 (0.03 mSv) dose criterion in Appendix I to 10 CFR Part 50.
- 29 • The organ (GI-tract) dose to an offsite member of the public from STP Unit 1
30 radioactive liquid effluents was 4.79×10^{-3} mrem (4.79×10^{-5} mSv) and
31 7.78×10^{-3} mrem (7.78×10^{-5} mSv), which is well below the 10 mrem
32 (0.10 mSv) dose criterion in Appendix I to 10 CFR Part 50.
- 33 • The air dose at the site boundary from gamma radiation in gaseous effluents
34 from STP Unit 1 was 4.43×10^{-4} mrad (4.43×10^{-6} mGy) and 1.62×10^{-3} mrad
35 (1.62×10^{-5} mGy) for Unit 2, which is well below the 10 mrad (0.1 mGy) dose
36 criterion in Appendix I to 10 CFR Part 50.
- 37 • The air dose at the site boundary from beta radiation in gaseous effluents
38 from Unit 1 was 2.02×10^{-4} mrad (2.02×10^{-6} mGy) and 2.01×10^{-3} mrad
39 (2.01×10^{-5} mGy) for Unit 2, which is well below the 20 mrad (0.2 mGy) dose
40 criterion in Appendix I to 10 CFR Part 50.
- 41 • The dose to an organ (bone) from radioactive iodine, radioactive particulates,
42 and carbon-14 from Unit 1 was 2.62×10^{-1} mrem (2.62×10^{-3} mSv) and
43 2.66×10^{-1} mrem (2.66×10^{-3} mSv) for Unit 2, which is well below the 15 mrem
44 (0.15 mSv) dose criterion in Appendix I to 10 CFR Part 50.

- 1 • The highest dose from direct radiation, as measured by TLDs, to an offsite
2 member of the public was 0.65 mrem (0.0065 mSv). This dose is based on a
3 conservative assumption that an individual is located at the STP site fence
4 east of the two reactor units for the entire year.
- 5 • The staff summed the applicant's data on the individual total body doses from
6 radioactive gaseous and liquid effluents from both units and added it to the
7 dose from direct radiation to obtain the maximum all pathways dose to an
8 offsite member of the public from the operation of STP, Units 1 and 2. The all
9 pathways annual dose is 0.67 mrem (0.0067 mSv), which is well below the
10 25 mrem (0.25 mSv) dose standard in EPA's 40 CFR Part 190.

11 The staff's review of the STP Radioactive Effluent Control Program showed that radiation doses
12 to members of the public were controlled within Federal radiation protection standards
13 contained in Appendix I to 10 CFR Part 50, 10 CFR Part 20, and 40 CFR Part 190.

14 The applicant has no plans to conduct refurbishment activities during the license renewal term;
15 however, routine plant refueling and maintenance activities currently performed will continue
16 during the license renewal term. Based on the past performance of the radioactive waste
17 system to maintain the dose from radioactive effluents to be ALARA, similar performance is
18 expected during the license renewal term. Continued compliance with regulatory requirements
19 is expected during the license renewal term; therefore, the impacts from radioactive effluents
20 would be SMALL.

21 **4.8.3 Microbiological Organisms**

22 For power plants that use a cooling pond, lake, or canal or that discharge to a small river, the
23 effects of microbiological organisms on human health are listed as a Category 2 issue and
24 require plant-specific evaluation for license renewal review. This issue is applicable to STP
25 because the facility uses a cooling pond, as defined in the GEIS (NRC 1996). The cooling pond
26 (MCR) discharges to Colorado River that has the mean annual average flow of approximately
27 2,629 cfs (NRC 2011b). This meets the definition of a small river. The MCR is within the
28 confine of the STP security perimeter and is not available for public use.

29 The Category 2 designation is based on the potential for public health impacts associated with
30 thermal enhancement of *Naegleria fowleri*, a pathogenic amoeba, and other enteric pathogens
31 that could not be assessed generically. The NRC noted that impacts of nuclear plant thermal
32 discharges are considered to be of small significance if they do not enhance the presence of
33 microorganisms that are detrimental to water quality and public health (NRC 1996).

34 Microbiological organisms that grow at temperatures above 45 °C to 50 °C (113 °F to 122 °F)
35 are termed thermophilic, or heat-loving, organisms (Brock 1974). STP has TPDES permit
36 (No. WQ0001908000) to discharge to the Colorado at the daily average temperature limit of
37 95 °F and daily maximum temperature limit of 97 °F (STPNOC 2010). These limits are below
38 the temperature at which thermophilic microorganisms grow and thrive (113 °F to 122 °F).
39 Hence, the potential of waterborne disease outbreak due to discharge from the MCR to the
40 Colorado River is remote.

41 Furthermore, the TPDES permit limits the discharge to less than 12.5 percent of the river flow
42 and may not exceed 200 million gpd. It is likely that the discharge would occur during high river
43 flow periods, which are reported by the STPNOC to be during the winter and spring when the
44 river temperature is at low level.

Environmental Impacts of Operation

1 The staff asked the Texas Department of Health about any concerns the department might have
2 relative to the microorganisms in the MCR that could cause waterborne disease outbreak in the
3 area (NRC 2012). The department responded that it did not have any records of such outbreak,
4 and it is not aware of any potential concerns about outbreaks associated with the operation of
5 STP during the extended period of operation.

6 The staff concludes that the potential impacts to public health from microbiological organisms,
7 resulting from operation of the STP cooling water discharge system to the aquatic environment
8 on or near the site, are SMALL, and no further mitigations are warranted.

9 **4.8.4 Electromagnetic Fields—Acute Effects**

10 Based on the GEIS, the NRC found that electric shock resulting from direct access to energized
11 conductors or from induced charges in metallic structures has not been found to be a problem at
12 most operating plants and, generally, is not expected to be a problem during the license renewal
13 term. However, site-specific review is required to determine the significance of the electric
14 shock potential along the portions of the transmission lines that are within the scope of this
15 SEIS.

16 In the GEIS (NRC 1996), the NRC found that without a review of the conformance of each
17 nuclear plant transmission line with National Electrical Safety Code (NESC) criteria, it was not
18 possible to determine the significance of the electric shock potential (IEEE 2002). Evaluation of
19 individual plant transmission lines is necessary because the issue of electric shock safety was
20 not addressed in the licensing process for some plants. For other plants, land use in the vicinity
21 of transmission lines may have changed, or power distribution companies may have chosen to
22 upgrade line voltage. To comply with 10 CFR 51.53(c)(3)(ii)(H), the applicant must provide an
23 assessment of the impact of the proposed action on the potential shock hazard from the
24 transmission lines if the transmission lines that were constructed for the specific purpose of
25 connecting the plant to the transmission system do not meet the recommendations of the NESC
26 for preventing electric shock from induced currents.

27 STPNOC analyzed its transmission lines to identify the limiting case for each line where the
28 potential exists for the highest current-induced shock. STPNOC calculated the electric field
29 strength and induced current for each of the lines using a computer code called ACDCLINE,
30 produced by the Electric Power Research Institute. The input parameters included the design
31 features of each of the limiting-case transmission lines, and a tractor-trailer was assumed to be
32 the maximum vehicle size under the lines. STPNOC reported in its ER and in two supplemental
33 letters (STPNOC 2011c, 2011f) that there are three transmission lines (i.e., two Hill County lines
34 and one Skyline line) that exceed the NESC 5 milliamper (mA) criterion for preventing electric
35 shock from induced currents. However, STPNOC states that the configuration of these lines
36 has changed since the original plant construction. These lines are no longer directly connected
37 with STP. A substation was constructed at Elm Creek. The original Hill County and Skyline
38 transmission lines are now looped into the Elm Creek substation before proceeding to the Hill
39 County and Skyline substations. The lines pass through land that is primarily agricultural and
40 rangeland, with some forest land and lesser land-use categories. The areas are mostly remote,
41 with low population densities. The lines cross numerous county, State, and U.S. highways.

42 As reported by STPNOC in its ER, the service providers for the STP transmission lines have
43 surveillance and maintenance procedures that periodically examine the lines to ensure they
44 remain within their design criteria. These procedures include routine aerial inspections that
45 include checks for encroachments, broken conductors, broken or leaning structures, and signs
46 of trees burning, any of which would be evidence of clearance problems. Ground inspections

1 include examination for clearance, integrity of structures, and surveillance for dead or diseased
2 trees that might fall on the transmission lines. Problems noted during any inspection are
3 reported for follow-up corrective action. STPNOC has considered potential mitigation measures
4 to reduce or avoid adverse impacts from electric shock from its transmission lines, with a
5 combination of options, as follows:

- 6 • re-examining the induced current calculations for selected transmission lines
7 (for accuracy and possible safety margin identification),
- 8 • raising the transmission towers at the potentially affected road-transmission
9 line intersections,
- 10 • modifying the double-circuit lines to reduce the current-induced shock
11 potential, or
- 12 • placing caution signs under the transmission lines.

13 Based on information provided by STPNOC and potential mitigation measures (to reduce or
14 avoid adverse impacts) considered by the applicant, the staff concludes that potential impact
15 from acute electric shock during the renewal period would be SMALL to MODERATE. This
16 conclusion is based on the fact that the three transmission lines exceed the NESC 5 mA
17 criterion by a small percentage, the locations where the lines exceed the standard are in remote
18 locations or are on private property, and the applicant, in accordance with
19 10 CFR 51.53(c)(3)(iii), has considered potential mitigation measures to reduce or avoid
20 adverse impacts from electric shock.

21 **4.8.5 Electromagnetic Fields—Chronic Effects**

22 In the GEIS, the effects of chronic exposure to 60 Hz electromagnetic fields from powerlines
23 were not designated as Category 1 or 2 and will remain uncategorized until a scientific
24 consensus is reached on the health implications of these fields.

25 The potential effects of chronic exposure from these fields continue to be studied and are not
26 known at this time. The National Institute of Environmental Health Sciences (NIEHS) directs
27 related research through the DOE.

28 The NIEHS report (NIEHS 1999) contains the following conclusion:

29 The NIEHS concludes that ELF EMF (extremely low frequency electromagnetic
30 field) exposure cannot be recognized as entirely safe because of weak scientific
31 evidence that exposure may pose a leukemia hazard. In our opinion, this finding
32 is insufficient to warrant aggressive regulatory concern. However, because
33 virtually everyone in the United States uses electricity and therefore is routinely
34 exposed to ELF EMF, passive regulatory action is warranted such as continued
35 emphasis on educating both the public and the regulated community on means
36 aimed at reducing exposures. The NIEHS does not believe that other cancers or
37 non cancer health outcomes provide sufficient evidence of a risk to currently
38 warrant concern.

39 This statement is not sufficient to cause the staff to change its position with respect to the
40 chronic effects of electromagnetic fields. The staff considers the GEIS finding of “UNCERTAIN”
41 still appropriate and will continue to follow developments on this issue.

1 **4.9 Socioeconomics**

2 The socioeconomic issues applicable to STP, Units 1 and 2, are shown in Table 4–16 for
 3 Category 1, Category 2, and one uncategorized issue (environmental justice). Section 2.2.8 of
 4 this SEIS describes the socioeconomic conditions near STP, Units 1 and 2.

5 **Table 4–16. Socioeconomics during the Renewal Term**

Issues	GEIS Section	Category
Housing impacts	4.7.1	2
Public services: public safety, social services, & tourism & recreation	4.7.3, 4.7.3.3, 4.7.3.4, 4.7.3.6	1
Public services: public utilities	4.7.3.5	2
Public services: education (license renewal)	4.7.3.1	1
Offsite land use (license renewal term)	4.7.4	2
Public Services: transportation	4.7.3.2	2
Historic & archaeological resources	4.7.7	2
Aesthetic impacts (license renewal term)	4.7.6	1
Aesthetic impacts of transmission lines (license renewal term)	4.5.8	1
Environmental justice	Not addressed ^(a)	Uncategorized

(a) Guidance for implementing Executive Order 12898 and conducting an environmental justice impact analysis was not available prior to the completion of the GEIS. This issue must be addressed in plant-specific reviews.

6 **4.9.1 Generic Socioeconomic Issues**

7 The STPNOC ER, scoping comments, other available data records on STP, Units 1 and 2, were
 8 reviewed and evaluated for new and significant information. The review included a data
 9 gathering site visit to STP, Units 1 and 2 (the NRC staff also reviewed other sources of
 10 information such as applicable permits and data reports as listed in the reference section of this
 11 SEIS chapter). No new and significant information was identified during this review that would
 12 change the conclusions presented in the GEIS. Therefore, for these Category 1 issues, impacts
 13 during the renewal term are not expected to exceed those discussed in the GEIS. For STP,
 14 Units 1 and 2, the NRC staff incorporates the GEIS conclusions by reference. Impacts for
 15 Category 2 issues and the uncategorized issue (environmental justice) are discussed in
 16 Sections 4.9.2 through 4.9.7.

17 **4.9.2 Housing**

18 Appendix C of the GEIS (NRC 1996) presents a population characterization method based on
 19 two factors—sparseness and proximity. Sparseness measures population density within 20 mi
 20 (32 km) of the site, and proximity measures population density and city size within 50 mi
 21 (80 km). Each factor has categories of density and size. A matrix is used to rank the population
 22 category as low, medium, or high as shown in Figure C.1 of the GEIS.

23 According to the 2000 Census, an estimated 35,291 people lived within 20 mi (32 km) of STP,
 24 Units 1 and 2, which equates to a population density of 36 persons per square mile

1 (STPNOC 2010). This translates to a Category 1, “most sparse,” population density using the
 2 GEIS measure of sparseness (less than 40 persons per square mile and no community with
 3 25,000 or more people within 20 mi). An estimated 255,118 people live within 50 mi (80 km) of
 4 STP, Units 1 and 2, with a population density of 32 persons per square mile (STPNOC 2010).
 5 Applying the GEIS proximity measures, STP is classified as proximity Category 1 (no city with
 6 100,000 or more persons and less than 50 persons per square mile within 50 mi). Therefore,
 7 according to the sparseness and proximity matrix presented in the GEIS, rankings of
 8 sparseness Category 1 and proximity Category 1 result in the conclusion that the STP is located
 9 in a low population area.

10 Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, states that impacts on housing availability
 11 are expected to be of SMALL, MODERATE, or LARGE. MODERATE or LARGE housing
 12 impacts of the workforce associated with refurbishment may be associated with plants located in
 13 sparsely populated areas or in areas with growth control measures that limit housing
 14 development. Because (a) STPNOC has no planned refurbishment activities and (b) Brazoria
 15 County and Matagorda County are not subject to growth-control measures that would limit
 16 housing development, any changes in employment at STP would have little noticeable effect on
 17 housing availability in these counties. Since STPNOC has no plan to add non-outage
 18 employees during the license renewal period, employment levels at STP would remain relatively
 19 constant with no additional demand for permanent housing during the license renewal term.
 20 Based on this information, there would be no additional impact on housing during the license
 21 renewal term beyond what has already been experienced. Because there is no additional
 22 impact, the impact is considered to be SMALL (not MODERATE or LARGE).

23 **4.9.3 Public Services—Public Utilities**

24 Impacts on public utility services (e.g., water, sewer) are considered SMALL if the public utility
 25 has the ability to respond to changes in demand and would have no need to add or modify
 26 facilities. Impacts are considered MODERATE if service capabilities are overtaxed during
 27 periods of peak demand. Impacts are considered LARGE if additional system capacity is
 28 needed to meet ongoing demand.

29 Analysis of impacts on the public water systems considered both plant demand and
 30 plant-related population growth. Section 2.1.7 of this SEIS describes the permitted withdrawal
 31 rate and actual use of water for reactor cooling at STP, Units 1 and 2.

32 Since STPNOC has no plans to add non-outage employees during the license renewal period,
 33 employment levels at STP would remain relatively unchanged with no additional demand for
 34 public water services. Public water systems in the region are adequate to meet the demands of
 35 residential and industrial customers in the area. Therefore, there would be no additional impact
 36 to public water services during the license renewal term beyond what is currently being
 37 experienced. Because there is no additional impact, the impact is considered to be SMALL (not
 38 MODERATE or LARGE).

39 **4.9.4 Public Services—Transportation**

40 Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 states that:

41 Transportation impacts (level of service) of highway traffic generated...during the
 42 term of the renewed license are generally expected to be of SMALL significance.
 43 However, the increase in traffic associated with additional workers and the local
 44 road and traffic control conditions may lead to impacts of MODERATE or LARGE
 45 significance at some sites.

Environmental Impacts of Operation

1 The regulation in 10 CFR 51.53(c)(3)(ii)(J) requires all applicants to assess the impacts of
2 highway traffic generated by the proposed project on the level of service of local highways
3 during the term of the renewed license. Since STPNOC has no plans to add non-outage
4 employees during the license renewal period, traffic volume and levels of service on roadways
5 in the vicinity of STP, Units 1 and 2, would not change. Therefore, there would be no
6 transportation impacts during the license renewal term beyond those already being
7 experienced. Because there is no additional impact, the impact is considered to be SMALL (not
8 MODERATE or LARGE).

9 **4.9.5 Offsite Land Use**

10 Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 notes that “significant changes in land
11 use may be associated with population and tax revenue changes resulting from license
12 renewal.” Section 4.7.4 of the GEIS defines the magnitude of land-use changes as a result of
13 plant operation during the license renewal term as SMALL when there will be little new
14 development and minimal changes to an area’s land-use pattern, as MODERATE when there
15 will be considerable new development and some changes to the land-use pattern, and LARGE
16 when there will be large-scale new development and major changes in the land-use pattern.

17 Tax revenue can affect land use because it enables local jurisdictions to provide the public
18 services (e.g., transportation and utilities) necessary to support development. Section 4.7.4.1 of
19 the GEIS states that the assessment of tax-driven land-use impacts during the license renewal
20 term should consider the size of the plant’s tax payments relative to the community’s total
21 revenues, the nature of the community’s existing land-use pattern, and the extent to which the
22 community already has public services in place to support and guide development. If the plant’s
23 tax payments are projected to be small relative to the community’s total revenue, tax driven
24 land-use changes during the plant’s license renewal term would be SMALL, especially where
25 the community has pre-established patterns of development and has provided public services to
26 support and guide development. Section 4.7.2.1 of the GEIS states that if tax payments by the
27 plant owner are less than 10 percent of the taxing jurisdiction’s revenue, the significance level
28 would be SMALL. If tax payments are 10 to 20 percent of the community’s total revenue, new
29 tax-driven land-use changes would be MODERATE. If tax payments are greater than
30 20 percent of the community’s total revenue, new tax-driven land-use changes would be
31 LARGE. This would be especially true where the community has no pre-established pattern of
32 development or has not provided adequate public services to support and guide development.

33 **4.9.5.1 Population-Related Impacts**

34 Since STPNOC has no plans to add non-outage employees during the license renewal period,
35 there would be no plant operations-driven population increase in the vicinity of STP, Units 1
36 and 2. Therefore, there would be no additional population-related offsite land use impacts
37 during the license renewal term beyond those already being experienced.

38 **4.9.5.2 Tax Revenue-Related Impacts**

39 As discussed in Chapter 2, STPNOC pays property taxes for STP, Units 1 and 2, to Matagorda
40 County, Matagorda County Hospital District, Navigation District #1, Drainage District #3,
41 Palacios Seawall District, and the Coastal Plains Groundwater District. Since STPNOC started
42 making property tax payments to local jurisdictions, population levels and land use conditions in
43 Matagorda County has remained relatively unchanged (STPNOC 2010); therefore, tax revenue
44 from STP, Units 1 and 2, has had little or no effect on land use conditions within the county.

1 Since employment levels at STP, Units 1 and 2, would remain relatively unchanged with no
2 increase in the assessed value of STP, Units 1 and 2, annual property tax payments would also
3 be expected to remain relatively unchanged throughout the license renewal period. Based on
4 this information, there would be no additional tax-revenue-related offsite land use impacts
5 during the license renewal term beyond those already being experienced. Because there is no
6 additional impact, the impact is considered to be SMALL (not MODERATE or LARGE).

7 **4.9.6 Historic and Archaeological Resources**

8 The National Historic Preservation Act (NHPA) requires Federal agencies to consider the effects
9 of their undertakings on historic properties. Historic properties are defined as resources that are
10 eligible for listing on the National Register of Historic Places (NRHP). The criteria for eligibility
11 are listed in 36 CFR 60.4 and include association with significant events in history; association
12 with the lives of persons significant in the past; embodiment of distinctive characteristics of type,
13 period, or construction; and sites or places that have yielded or are likely to yield important
14 information. The historic preservation review process (Section 106 of NHPA) is outlined in
15 regulations issued by the Advisory Council on Historic Preservation (ACHP) in 36 CFR Part 800.
16 In accordance with 36 CFR 800.8(c), the NRC has elected to use the NEPA process to comply
17 with the obligations found under Section 106 of the NHPA.

18 The issuance of a renewed operating license for a nuclear power plant is a Federal action that
19 could affect historic properties on or near the nuclear plant site and transmission lines. In
20 accordance with the provisions of the NHPA, the NRC is required to make a reasonable effort to
21 identify historic properties included in or eligible for inclusion in the NRHP in the area of
22 potential effect (APE). The APE for license renewal is the nuclear power plant site,
23 transmission lines, and immediate environs. If historic properties are present, the NRC is
24 required to contact the State Historic Preservation Office (SHPO), assess the potential impact,
25 and resolve any possible adverse effects of the undertaking (license renewal) on historic
26 properties. NRC is also required to notify the SHPO if historic properties would not be affected
27 by license renewal or if no historic properties are present. The SHPO is part of the Texas
28 Historical Commission (THC) in the State of Texas. This section provides the NRC's
29 assessment of effects from the proposed license renewal action for STP, Units 1 and 2.
30 Section 2.2.10 of this SEIS provides specific historic and cultural information near the STP site.

31 On March 17, 2009, STP initiated informal consultation with the THC regarding the renewal of
32 operating licenses for STP, Units 1 and 2. STP concluded in its letter to THC that there would
33 be no effect on historic properties from license renewal and associated operation and
34 maintenance activities (STPNOC 2010b). The THC responded to STP on October 26, 2009,
35 with a determination of "No Historic Properties Affected, Project May Proceed"
36 (STPNOC 2010b). The THC response is in the form of a stamp on the last page of the STP
37 letter that was sent to the THC, which STP included in its ER for license renewal
38 (STPNOC 2010b).

39 Prior to the site audit in May 2011, NRC contacted the THC concerning license renewal for STP.
40 The staff and THC concluded there was no need to meet during the environmental audit to
41 discuss cultural resources (NRC 2011a). The THC determined that there were no known issues
42 with license renewal for STP and referred the NRC to the THC response to STP on
43 October 26, 2009, with the determination of "No Historic Properties Affected, Project May
44 Proceed" (STPNOC 2010b).

45 In accordance with 36 CFR 800.8(c), on January 27, 2011, and February 17, 2011, respectively,
46 the NRC initiated consultations on the proposed action by writing to the ACHP and SHPO

Environmental Impacts of Operation

1 (NRC 2011d, 2011e). In February 2011, the NRC initiated consultation with six Federally
2 recognized tribes: the Yselta del Sur Pueblo Tribe, Alabama-Coushatta Tribe, Kiowa Tribe of
3 Oklahoma, the Comanche Nation, Tonkawa Tribe of Oklahoma, and Kickapoo Traditional
4 Council (Appendix D contains a copy of these letters for reading convenience). Also in
5 February 2011, the NRC initiated consultation with four additional tribes: the Apalachicola Band
6 of Creek Indians, Lipan Apache Band of Texas, Pamaque Clan of Coahuila Y Tejas, and the
7 Tap Pilam-Coahuiltecan Nation (Appendix D contains a copy of these letters). In its letters, the
8 NRC provided information about the proposed action and the definition of APE. In addition, the
9 NRC indicated that the NHPA review would be integrated with the NEPA process, in
10 accordance with 36 CFR 800.8. NRC invited participation in the identification and possible
11 decisions concerning historic properties and invited participation in the scoping process. Four
12 tribes—the Apalachicola Band of Creek Indians, the Kickapoo Traditional Council, the Tonkawa
13 Tribe of Oklahoma, and the Tap Pilam-Coahuiltecan Nation—responded to the NRC with
14 scoping comments. These comments included concerns with potential accidents, requests to
15 re-survey the STP site, requests for notification if historic and cultural resources of cultural
16 significance were discovered on the STP site, and statements of no concern with the
17 undertaking. NRC responded to the tribes in October 2011 and has taken the comments into
18 consideration while preparing this SEIS (Appendix D lists copies of these letters).

19 As described in Section 2.2.10, there are no recorded archaeological sites or historic structures
20 on the STP site. STPNOC has identified a potential historic gravesite located on the southeast
21 boundary of the STP site within the APE. STP staff interviewed descendants of the former
22 property owner and confirmed the presence of a grave from the late 1800s; however, little is
23 known about the gravesite, and it is not a recorded historic and archaeological resource. The
24 NRC staff has confirmed that there are no planned ground-disturbing activities near the
25 gravesite and it would be protected from any operation and maintenance activities associated
26 with the license renewal term as the activities “would occur several miles from the [grave]site
27 and would be conducted in accordance with STP environmental compliance procedures”
28 (STPNOC 2011g).

29 STPNOC has no planned refurbishment activities associated with license renewal at the STP
30 site (STPNOC 2011g). A review of operation and maintenance activities that occur in and
31 around the STP site indicates that these activities are limited to the use of existing roads and
32 previously disturbed areas and are subject to STP environmental compliance procedures
33 (applicable to any future potential land disturbing constructions at STP).

34 For the purposes of NHPA Section 106 consultation, the NRC staff concludes a finding of no
35 effect to historic properties (36 CFR Section 800.4(d)(1)) based on the following:

- 36 • historic and cultural resources located within the APE,
- 37 • tribal input,
- 38 • STP environmental compliance procedures,
- 39 • there will be no refurbishment or ground-disturbing activities associated with
40 the relicensing of STP, Units 1 and 2,
- 41 • SHPO finding of “No Historic Properties—Affected, Project May Proceed,”
42 and
- 43 • the NRC staff’s cultural resource analysis and consultation.

1 For the purposes of the NRC staff's NEPA analysis, in consideration of the conclusion reached
2 in the NHPA Section 106 consultation, the NRC staff concludes that potential impacts on
3 historic and cultural resources related to STP license renewal would be SMALL.

4 **4.9.7 Environmental Justice**

5 Under Executive Order (EO) 12898 (59 FR 7629), Federal agencies are responsible for
6 identifying and addressing, as appropriate, disproportionately high and adverse human health
7 and environmental impacts on minority and low-income populations. In 2004, the NRC issued a
8 *Policy Statement on the Treatment of Environmental Justice Matters in NRC Regulatory and*
9 *Licensing Actions* (69 FR 52040), which states, "The Commission is committed to the general
10 goals set forth in EO 12898, and strives to meet those goals as part of its NEPA review
11 process."

12 The Council on Environmental Quality (CEQ) provides the following information in
13 *Environmental Justice: Guidance Under the National Environmental Policy Act* (CEQ 1997):

14 **Disproportionately High and Adverse Human Health Effects.**

15 Adverse health effects are measured in risks and rates that could result in latent
16 cancer fatalities, as well as other fatal or nonfatal adverse impacts on human
17 health. Adverse health effects may include bodily impairment, infirmity, illness, or
18 death. Disproportionately high and adverse human health effects occur when the
19 risk or rate of exposure to an environmental hazard for a minority or low-income
20 population is significant (as employed by NEPA) and appreciably exceeds the
21 risk or exposure rate for the general population or for another appropriate
22 comparison group.

23 **Disproportionately High and Adverse Environmental Effects.**

24 A disproportionately high environmental impact that is significant (as employed
25 by NEPA) refers to an impact or risk of an impact on the natural or physical
26 environment in a low-income or minority community that appreciably exceeds the
27 environmental impact on the larger community. Such effects may include
28 ecological, cultural, human health, economic, or social impacts. An adverse
29 environmental impact is an impact that is determined to be both harmful and
30 significant (as employed by NEPA). In assessing cultural and aesthetic
31 environmental impacts, impacts that uniquely affect geographically dislocated or
32 dispersed minority or low-income populations or American Indian tribes are
33 considered.

34 The environmental justice analysis assesses the potential for disproportionately high and
35 adverse human health or environmental effects on minority and low-income populations that
36 could result from the operation of STP during the license renewal term. In assessing the
37 impacts, the following definitions of minority individuals and populations and low-income
38 population were used (CEQ 1997):

39 **Minority individuals.**

40 Individuals who identify themselves as members of the following population
41 groups: Hispanic or Latino, American Indian or Alaska Native, Asian, Black or
42 African American, Native Hawaiian or Other Pacific Islander, or two or more
43 races, meaning individuals who identified themselves on a Census form as being
44 a member of two or more races, for example, Hispanic and Asian.

45

46

Environmental Impacts of Operation

1 **Minority populations.**

2 Minority populations are identified when (1) the minority population of an affected
3 area exceeds 50 percent or (2) the minority population percentage of the affected
4 area is meaningfully greater than the minority population percentage in the
5 general population or other appropriate unit of geographic analysis.


6 **Low-income population.**

7 Low-income populations in an affected area are identified with the annual
8 statistical poverty thresholds from the Census Bureau's Current Population
9 Reports, Series P60, on Income and Poverty.

10 Minority Population. According to 2010 Census data, 45.9 percent of the total population
11 (approximately 110,201 persons) residing within a 50-mi (80-km) radius of STP identified
12 themselves as minority individuals. The largest minority group was Hispanic or Latino (of any
13 race) (approximately 82,000 persons or 33.9 percent), followed by Black or African American
14 (approximately 23,000 persons or 9.6 percent) (CAPS 2011).

15 According to 2010 Census data, minority populations in the socioeconomic ROI (Matagorda and
16 Brazoria Counties) comprised 47.4 percent of the total two-county population as shown in
17 Table 2–17 (USCB 2011). Figure 4–2 shows minority population block groups using
18 2010 Census data for race and ethnicity within a 50-mi (80-km) radius of STP.

1 **Figure 4–2. 2010 Census Minority Block Groups Within a 50-mi Radius of STP**



Source: USCB 2012.

Environmental Impacts of Operation


1 Census block groups were considered minority population block groups if the percentage of the
2 minority population within any block group exceeded 45.9 percent (the percent of the minority
3 population within the 50-mi radius of STP). A minority population exists if the percentage of the
4 minority population within the block group is meaningfully greater than the minority population
5 percentage in the 50-mi radius. Minority population block groups are concentrated in the Bay
6 City area, El Campo, Freeport, Palacios, and Port Lavaca. Smaller concentrations of minority
7 population block groups are found in Angelton and Wharton. The nearest minority population
8 (i.e., percentage is meaningfully greater than the percentage in the 50-mi radius) to STP is
9 located in Matagorda, Texas. In Matagorda, according to the 2010 Census, approximately
10 15 percent of the Matagorda population identified themselves as minority.

11 Low-Income Population. According to 2006 through 2010 American Community Survey 5-year
12 estimates, an average of 11.4 percent of families and 14.2 percent of individuals residing in nine
13 counties—all or parts of which are located within a 50-mi radius of STP (Brazoria, Calhoun,
14 Colorado, Fort Bend, Jackson, Lavaca, Matagorda, Victoria, and Wharton)—were identified as
15 living below the Federal poverty threshold in 2010 (USCB 2010). The 2010 Federal poverty
16 threshold was \$22,314 for a family of four.

17 According to 2006 through 2010 American Community Survey 5-year estimates, the median
18 household income for Texas was \$49,646, with 16.8 percent of the State population and
19 13 percent of families living below the Federal poverty threshold in 2010 (USCB 2011).
20 Brazoria County had a lower median household income average (\$43,258) and
21 lower percentages of individuals (10.6 percent) and families (8.2 percent) living below the
22 poverty level when compared to the State average. Matagorda County had a lower household
23 income average (\$48,508) compared to the State average and higher than Brazoria County, but
24 a higher percentage of individuals (18.6 percent) and families (21.6 percent) living below the
25 poverty level when compared to Brazoria County and the State (USCB 2011).

26 Figure 4–3 shows low-income census block groups within a 50-mi (80-km) radius of STP.
27 Census block groups were considered low-income population block groups if the percentage of
28 individuals living below the Federal poverty threshold within any block group exceeded the
29 percent of the individuals living below the Federal poverty threshold within the 50-mi radius of
30 STP. Similar to the locations of minority population block groups, the majority of low-income
31 population block groups are located in the Bay City area, Freeport, Palacios, Port Lavaca, and
32 Wharton. Smaller concentrations of minority population block groups are located near Angelton.
33 The nearest low-income population to STP is located in Matagorda, Texas.

1 **Figure 4-3. Census 2010 Low-Income Block Groups Within a 50-mi Radius of STP**



Source: USCB 2012

Environmental Impacts of Operation

1 Analysis of Impacts. The NRC addresses environmental justice matters for license renewal in
2 the following ways:

- 3 • identifying the location of minority and low-income populations that may be
4 affected by the continued operation of the nuclear power plant during the
5 license renewal term,
- 6 • determining whether there would be any potential human health or
7 environmental effects to these populations and special pathway receptors,
8 and
- 9 • determining if any of the effects may be disproportionately high and adverse.

10 Figure 4–2 and Figure 4–3, above, identify the location of minority and low-income populations
11 residing within a 50-mi (80-km) radius of STP. This area of impact is consistent with the impact
12 analysis for public and occupational health and safety, which also focuses on populations within
13 a 50-mi (80-km) radius of the nuclear plant. Chapter 4 presents the assessment of
14 environmental and health impacts for each resource area. The analyses of impacts for all
15 environmental resource areas indicated that the impact from license renewal would be SMALL.

16 Potential impacts to minority and low-income populations (including migrant workers or Native
17 Americans) would mostly consist of socioeconomic and radiological effects; however, radiation
18 doses from continued operations during the license renewal term are expected to continue at
19 current levels and would remain below regulatory limits. Chapter 5 of this SEIS discusses the
20 environmental impacts from postulated accidents that might occur during the license renewal
21 term, which include both design-basis and severe accidents. In both cases, the NRC has
22 generically determined that impacts associated with design-basis accidents are SMALL
23 because nuclear plants are designed and operated to successfully withstand such accidents,
24 and the probability-weighted risks associated with severe accidents were also SMALL.

25 Therefore, based on this information and the analysis of human health and environmental
26 impacts presented in Chapters 4 and 5 of this SEIS, there would be no disproportionately high
27 and adverse impacts to minority and low-income populations from the continued operation of
28 STP during the license renewal term.

29 As part of addressing environmental justice concerns associated with license renewal, the NRC
30 also assessed the potential radiological risk to special population groups (such as migrant
31 workers or Native Americans) from exposure to radioactive material received through their
32 unique consumption and interaction with the environment patterns. These include subsistence
33 consumption of fish, native vegetation, surface waters, sediments, and local produce;
34 absorption of contaminants in sediments through the skin; and inhalation of airborne radioactive
35 material released from the plant during routine operation. This analysis is presented below.

36 Subsistence Consumption of Fish and Wildlife. The special pathway receptors analysis is an
37 important part of the environmental justice analysis because consumption patterns may reflect
38 the traditional or cultural practices of minority and low-income populations in the area, such as
39 migrant workers or Native Americans.

40 Section 4-4 of EO 12898 (1994) directs Federal agencies, whenever practical and appropriate,
41 to collect and analyze information on the consumption patterns of populations that rely
42 principally on fish or wildlife or both for subsistence and to communicate the risks of these
43 consumption patterns to the public. In this SEIS, the NRC considered whether there were any
44 means for minority or low-income populations to be disproportionately affected by examining
45 impacts to American Indians, Hispanics, migrant workers, and other traditional lifestyle special

1 pathway receptors. Special pathways take into account the levels of radiological and
2 nonradiological contaminants in native vegetation, crops, soils and sediments, groundwater,
3 surface water, fish, and game animals on or near STP.

4 The following is a summary discussion of the NRC's evaluation from Section 4.8.2 of the REMP
5 that assesses the potential impacts for subsistence consumption of fish and wildlife near the
6 STP site.

7 STPNOC has an ongoing, comprehensive REMP to assess the impact of STP operations on the
8 environment. To assess the impact of nuclear power plant operations, samples are collected
9 annually from the environment and analyzed for radioactivity. A nuclear power plant effect
10 would be indicated if the radioactive material detected in a sample was significantly larger than
11 background levels. Two types of samples are collected. The first type, control samples, is
12 collected from areas that are beyond the measurable influence of the nuclear power plant or any
13 other nuclear facility. These samples are used as reference data to determine normal
14 background levels of radiation in the environment. These samples are then compared with the
15 second type of samples, indicator samples, collected near the nuclear power plant. Indicator
16 samples are collected from areas where any contribution from the nuclear power plant will be at
17 its highest concentration. These samples are then used to evaluate the contribution of normal
18 nuclear power plant operations to radiation or radioactivity levels in the environment. An effect
19 would be indicated if the radioactivity levels detected in an indicator sample was significantly
20 larger than the control sample or background levels.

21 Samples of environmental media are collected from the aquatic and terrestrial pathways in the
22 vicinity of STP. The aquatic pathways include surface water, groundwater, drinking water, fish,
23 crab, shrimp, oyster, and shoreline sediment. The terrestrial pathways include airborne
24 particulates, food products (i.e., leafy vegetables such as cabbage and various edible greens,
25 are collected from gardens and farms in the vicinity of STP), beef, poultry, wild animal meat
26 (i.e., waterfowl, deer, rabbits, and alligator), and broadleaf vegetation. In 2010, analyses
27 performed on samples of environmental media showed no significant or measurable radiological
28 impact above background levels from normal STP operations (STPNOC 2011).

29 Conclusion. Based on the radiological environmental monitoring data from STP, the NRC finds
30 that no disproportionately high and adverse human health impacts would be expected in special
31 pathway receptor populations in the region as a result of subsistence consumption of water,
32 local food, fish, and wildlife.

33 **4.10 Evaluation of New and Potentially Significant Information**

34 The staff has not identified new and significant information on environmental issues related to
35 operation during the renewal term. The staff also determined that information provided during
36 the public comment period did not identify any new issue that requires site-specific assessment.
37 The staff reviewed the discussion of environmental impacts associated with operation during the
38 renewal term in the GEIS and has conducted its own independent review, including public
39 involvement process (e.g., public meetings) to identify issues with new and significant
40 information.

41 New and significant information is information that identifies a significant environmental issue
42 not covered in the GEIS and codified in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, or
43 information that was not considered in the analyses summarized in the GEIS and that leads to
44 an impact finding that is different from the finding presented in the GEIS and codified in
45 10 CFR Part 51.

Environmental Impacts of Operation

1 In accordance with 10 CFR 51.53(c), the ER submitted by the applicant must provide an
2 analysis of the Category 2 issues in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B.
3 Additionally, it must discuss actions to mitigate any adverse impacts associated with the
4 proposed action and environmental impacts of alternatives to the proposed action. In
5 accordance with 10 CFR 51.53(c)(3), the ER does not need to contain an analysis of any
6 Category 1 issue unless there is significant new information on a specific issue.

7 The NRC also has a process for identifying new and significant information. That process is
8 described in NUREG-1555, Supplement 1, *Standard Review Plans for Environmental Reviews*
9 *for Nuclear Power Plants, Supplement 1: Operating License Renewal* (NRC 1999b). The
10 search for new information includes:

- 11 • review of an applicant's ER and the process for discovering and evaluating
12 the significance of new information,
- 13 • review of public comments,
- 14 • review of environmental quality standards and regulations,
- 15 • coordination with Federal, State, and local environmental protection and
16 resource agencies, and
- 17 • review of the technical literature.

18 New information discovered by the staff is evaluated for significance using the criteria set forth
19 in the GEIS. For Category 1 issues where new and significant information is identified,
20 reconsideration of the conclusions for those issues is limited in scope to the assessment of the
21 relevant new and significant information; the scope of the assessment does not include other
22 facets of an issue that are not affected by the new information.

23 **4.11 Cumulative Impacts**

24 The staff considered potential cumulative impacts in the environmental analysis of continued
25 operation of STP nuclear plant during the 20-year license renewal period. Cumulative impacts
26 may result when the environmental effects associated with the proposed action are overlaid or
27 added to temporary or permanent effects associated with other past, present, and reasonably
28 foreseeable actions. Cumulative impacts can result from individually minor, but collectively
29 significant, actions taking place over a period of time. It is possible that an impact that may be
30 SMALL by itself could result in a MODERATE or LARGE cumulative impact when considered in
31 combination with the impacts of other actions on the affected resource. Likewise, if a resource
32 is regionally declining or imperiled, even a SMALL individual impact could be important if it
33 contributes to or accelerates the overall resource decline.

34 For the purposes of this cumulative analysis, past actions are those before the receipt of the
35 license renewal application. Present actions are those related to the resources at the time of
36 current operation of the power plant, and future actions are those that are reasonably
37 foreseeable through the end of plant operation including the period of extended operation.
38 Therefore, the analysis considers potential impacts through the end of the current license terms
39 as well as the 20-year renewal license term. The geographic area over which past, present,
40 and reasonably foreseeable actions would occur is dependent on the type of action considered
41 and is described below for each resource area.

42 The staff describes the incremental impacts of the proposed action (i.e., STP license renewal) in
43 Sections 4.1-4.9 of this SEIS. To evaluate cumulative impacts, the incremental impacts of the

1 proposed action are combined with other past, present, and reasonably foreseeable future
 2 actions regardless of what agency (Federal or non-Federal) or person who undertakes such
 3 actions. The staff used the information provided in the ER; responses to requests for additional
 4 information; information from other Federal, State, and local agencies; scoping comments; and
 5 information gathered during the audit at the STP site to identify other past, present, and
 6 reasonably foreseeable actions. To be considered in the cumulative analysis, the staff
 7 determined if the project would occur within the noted geographic areas of interest and within
 8 the period of extended operation, if it was reasonably foreseeable, and if there would be
 9 potential overlapping effect with the proposed project. For past actions, consideration within the
 10 cumulative impacts assessment is resource and project specific. In general, the effects of past
 11 actions are included in the description of the affected environment in Chapter 2, which serves as
 12 the baseline for the cumulative impacts analysis. However, past actions that continue to have
 13 an overlapping effect on a resource potentially affected by the proposed action are considered
 14 in the cumulative analysis.

15 Other actions and projects were identified during this review and considered in the staff's
 16 independent analysis of the potential cumulative effects. Examples of other actions and
 17 projects that were considered in this analysis include the following:

- 18 • proposed STP, Units 3 and 4,
- 19 • White Stallion Energy Center (WSEC),
- 20 • LCRA–San Antonio Water System (SAWS) Project,
- 21 • Mary Rhodes Pipeline Phase II, and
- 22 • Brazos Bend State Park, Mad Island Marsh Preserve, Mad Island Wildlife
 23 Management Area, Big Boggy National Wildlife Refuge, and the Texas Prairie
 24 Wetland Project.

25 The complete description of each of the projects and actions that were considered are listed in
 26 the discussions of the following sections.

27 **4.11.1 Land Use**

28 As discussed in Section 4.1 of this SEIS, onsite land use and powerline right-of-way conditions
 29 are expected to remain unchanged during the license renewal term for STP. Therefore,
 30 cumulative impacts of land use are SMALL.

31 **4.11.2 Air Quality**

32 This section addresses the direct and indirect effects of license renewal on air quality resources
 33 when added to the aggregate effects of other past, present, and reasonably foreseeable future
 34 actions. The geographic area considered in the cumulative air quality analysis is the county of
 35 the proposed action because air quality designations for criteria air pollutants are generally
 36 made at the county level. Counties are further grouped together based on a common air
 37 shed—known as an air quality control region (AQCR)—to provide for the attainment and
 38 maintenance of the National Ambient Air Quality Standards (NAAQS). The STP site is located
 39 in Matagorda County, Texas, which is part of the Metropolitan Houston-Galveston Intrastate
 40 AQCR (40 CFR 81.38). Additional counties in this AQCR include Austin, Brazoria, Chambers,
 41 Colorado, Fort Bend, Galveston, Harris, Liberty, Montgomery, Walker, Waller, and Wharton
 42 Counties.

Environmental Impacts of Operation

1 Section 2.2.2 summarizes the air quality designation status for Matagorda County as well as
2 other counties in the Metropolitan Houston-Galveston Intrastate AQCR. As noted in
3 Section 2.2.2, EPA regulates six criteria pollutants under the NAAQS. These pollutants are
4 carbon monoxide, lead, nitrogen dioxide, ozone, sulfur dioxide, and particulate matter.
5 Matagorda County is designated as unclassified or in attainment for all NAAQS criteria
6 pollutants. All other counties in this AQCR are designated as unclassified or in attainment with
7 respect to the NAAQS criteria pollutants, except Brazoria County, which is classified
8 nonattainment/severe relative to the 8-hour ozone standard.

9 Criteria pollutant air emissions from the STP site are presented in Section 2.2.2.1. These
10 emissions are principally from standby diesel generators and conform to Texas State air
11 emission requirements in 30 TAC 101.10 (Texas Administrative Code). Continued operations of
12 the STP site would result in annual air emissions comparable to those noted in Section 2.2.2.1.
13 Assuming an average annual emission rate of 58.62 tons per year of total emissions from all
14 sources, an additional 20 years of operation would result in approximately 1,172.4 tons
15 (1,066.9 metric tons) of total emissions from all sources. There is no planned site refurbishment
16 associated with license renewal; therefore, there are no additional air emissions beyond those
17 noted in Section 2.2.2.1 for normal operations.

18 Foreseeable projects that could contribute meaningfully to cumulative impacts to air quality
19 include the construction and operation of STP, Units 3 and 4, and the construction and
20 operation of the WSEC, a 1,320 mW coal and petroleum coke plant located about 5 mi (8 km)
21 northeast of the STP site (MCEDC 2011).

22 In September 2007, STPNOC submitted COL applications to the NRC for two new nuclear units
23 on the STP site. If approved, STPNOC would construct the new units adjacent to the currently
24 operating Units 1 and 2. Construction activities would cause some localized temporary
25 air-quality effects because of emissions and fugitive dust from operation of the earth-moving
26 and material-handling equipment. Emissions from workers' vehicles and motorized construction
27 equipment exhaust would be temporary. NRC assumed that construction crews would use
28 dust-control practices to control and reduce fugitive dust. STPNOC proposed such activities
29 during construction of proposed Units 3 and 4 (STPNOC 2010b). Section 111.145 of TCEQ's
30 regulations requires dust suppression control during the construction of facilities and parking
31 lots. Construction activities and their effect on air quality will be similar for the WSEC coal plant.
32 It is unlikely that construction of the two projects would overlap because WSEC is scheduled to
33 begin construction in 2012, 2 years earlier than the proposed construction of proposed Units 3
34 and 4.

35 During operations, two new nuclear plants would have similar air emissions, primarily from
36 backup diesel generators, to those of existing STP, Units 1 and 2. Because air emissions would
37 be similar for the new nuclear plants, the NRC expects similar air permitting conditions and
38 regulatory requirements as that for Units 1 and 2. In STPNOC's ER for Units 3 and 4, STPNOC
39 stated that "[a]ir emissions sources would be managed in accordance with Federal, Texas, and
40 local air quality control laws and regulations." Likewise, NRC assumes that the WSEC facility
41 would be operated in accordance with Federal, Texas, and local air quality control laws and
42 regulations. Effluents from power plants such as the WSEC are typically released through
43 stacks and with significant vertical velocity. Section 8.3.1 of this SEIS characterizes the impacts
44 for the emissions from similar plants as being clearly noticeable, but given existing regulatory
45 regimens, permit requirements, and emissions controls, the coal-fired plant would not
46 destabilize air quality.

1 Potential cumulative effects of global climate change (GCC) and increases in average annual
2 temperatures, higher probabilities of extreme heat events, higher occurrences of extreme
3 rainfall (intense rainfall or drought), and changes in the wind patterns could affect
4 concentrations of the air pollutants and their long-range transport because their formation
5 partially depends on the temperature and humidity and is a result of the interactions between
6 hourly changes in the physical and dynamic properties of the atmosphere, atmospheric
7 circulation features, wind, topography, and energy use (IPCC 2010).

8 The NRC staff examined the cumulative effects of the continued operation of STP, Units 1
9 and 2, the construction and operation of STP, Units 3 and 4, and the construction and operation
10 of the WSEC coal plant. The cumulative impacts on criteria pollutants from emissions of
11 effluents from the STP site and the WSEC would be noticeable, principally as a result of the
12 contribution of WSEC, but not destabilizing. The NRC staff concludes that cumulative impacts
13 from other past, present, and reasonably foreseeable future actions on air quality resources in
14 the geographic areas of interest would be MODERATE. The incremental contribution of
15 impacts on air quality resources associated with STP license renewal would be SMALL, as
16 described in Section 4.2.

17 **4.11.3 Water Resources**

18 This section addresses the direct and indirect effects of license renewal on water resources
19 when added to the aggregate effects of other past, present, and reasonably foreseeable future
20 actions. As described in Sections 4.3 and 4.4, the incremental impacts on water resources from
21 continued operations during the proposed license renewal term would be SMALL. This analysis
22 considers three geographic areas of interest. For the lower Colorado River, the geographic
23 area of interest is the drainage basin of the Colorado River and Matagorda Bay in Region K.
24 For the Shallow Chicot Aquifer, which could be affected by seepage and spills, the geographic
25 area of interest extends from recharge areas in Matagorda County to downgradient discharge
26 areas along the Colorado River. For the Deep Chicot Aquifer, the geographic area of interest
27 extends from recharge areas in Wharton County to Matagorda Bay.

28 The Colorado River and Chicot aquifers are hydraulically connected. As such, this review
29 focused on the projects and activities that would use groundwater or could affect the Chicot
30 aquifers beneath the STP site or would withdraw or discharge water to the Colorado River within
31 their respective geographic areas.

32 **4.11.3.1 Cumulative Impacts on Surface Water Resources**

33 In addition to continued operation of STP, Units 1 and 2, the NRC staff identified several other
34 past, present, and foreseeable projects (NRC 2011b). These projects include the proposed
35 STP, Units 3 and 4, the WSEC, the LCRA–SAWS Project, and the Mary Rhodes Pipeline
36 Phase II Project, in addition to the existing water use for municipal, irrigation, industrial, and
37 instream uses. NRC and USACE (2011b) also considered potential effects of GCC on water
38 supply in Region K, in which STP, Units 1 and 2, is located.

39 The projected average long-term consumptive surface-water use of proposed STP, Units 3
40 and 4, would be 37,430 ac-ft/yr (46.2 million m³/yr) at 100 percent load factor (NRC 2011b).
41 The projected consumptive use for STP, Units 3 and 4, is 2.8 and 2.9 percent of the water
42 available to Region K in 2010 and 2060, respectively. Because the incremental water use of
43 proposed STP, Units 3 and 4, is a small percentage of the water available to the region and
44 would not require additional allocation over the current water right held by STPNOC, the NRC
45 staff concludes that the incremental impact of water use for STP, Units 3 and 4, on the Colorado
46 River would be minimal.

Environmental Impacts of Operation

1 Although its future is uncertain because of continuing legal action, a water-sharing project
2 between the LCRA and the SAWS, involving Regions K and L, could affect water resources in
3 the region. An off-channel storage reservoir in Wharton County is proposed. The planned
4 project would provide 377,000 ac-ft/yr (465 million m³/yr) of water to Regions K and L, and
5 Region L would receive 150,000 ac-ft/yr (185 million m³/yr) from Region K starting in the
6 2020 decade (NRC 2011b). The LCRWPG has considered the effects of the LCRA–SAWS
7 Project while estimating the water availability in its 2011 Region Water Plan (LCRWPG 2010).

8 The WSEC is a 1,320-MW power plant, proposed to be located in Matagorda County near
9 Farm-to-Market (FM) Road 2668, 1 mi (1.6 km) south of the Port of Bay City, approximately 5 mi
10 (8 km) northeast of the STP site. On October 13, 2008, proponents for WSEC applied to LCRA
11 for a new firm water supply of 22,000 ac-ft/yr (27 million m³/yr), with the total diversion from the
12 Colorado River estimated at 29,750 ac-ft/yr (37 million m³/yr), accounting for delivery losses
13 (NRC 2011b). The total WSEC withdrawal would be 2.2 and 2.3 percent of the water available
14 to the region in 2010 and 2060, respectively. Because the incremental water withdrawal for
15 WSEC is a small percentage of the water available to the region, the NRC staff concludes that
16 the impact of WSEC withdrawal on the region's water supply would be minimal.

17 The City of Corpus Christi has a water right amounting to 35,000 ac-ft/yr (43 million m³/yr) from
18 the Colorado River (NRC 2011b). Water planning of the City of Corpus Christi indicates that the
19 city may start to use its currently unused water rights from the Colorado River by 2020 or
20 sooner, depending on demand (City of Corpus Christi 2011). Although the City of Corpus
21 Christi does not currently use its water rights from the Colorado River, these rights are
22 accounted for in Region K water availability planning. To use its water rights from the Colorado
23 River, the City of Corpus Christi would build Phase II of Mary Rhodes Pipeline from Bay City to
24 Lake Texana to tie into the existing Phase I of the pipeline that delivers water from Lake Texana
25 to the city (NRC 2011b). The City of Corpus Christi water right would represent 2.6 and
26 2.7 percent of the water available to the region in 2010 and 2060, respectively. Because the
27 incremental water withdrawal by the City of Corpus Christi is a small percentage of the water
28 available to Region K, the NRC staff concludes that the impact of the City of Corpus Christi
29 withdrawal on the region's water supply would be minimal.

30 Freshwater inflow needs for Matagorda Bay represent the only use of lower Colorado River
31 waters downstream of the STP site (NRC 2011b). The LCRA, TCEQ, Texas Parks and Wildlife
32 Department, and the TWDB estimated Matagorda Bay freshwater inflow needs (LCRA et
33 al. 2006). LCRA et al. (2006) estimated a target for freshwater inflow that would optimize
34 productivity of selected estuarine species and the critical freshwater inflow that would promote
35 repopulation of finfish and shellfish following a dry period. The average target freshwater inflow
36 was established at 118,975 ac-ft/mo (146.7 million m³/mo) or 1,972 cfs (55 m³/s). The critical
37 freshwater inflow was established at 36,000 ac-ft/mo (44 million m³/mo) or 597 cfs (17 m³/s).
38 Recommendations made in LRCA et al. (2006) with regard to inflow needs continue to be
39 reviewed by the TCEQ, and, if formally established, they could make the cited volume of surface
40 water discharge unavailable for other uses (NRC 2011b).

41 NRC and USACE (NRC 2011b) considered the U.S. Global Change Research Program's
42 (USGCRP's) most recent compilation of the state of knowledge relative to GCC effects
43 (USGCRP 2009). NRC and USACE reviewed forecasted increases in temperature and
44 decreases in precipitation for the Colorado River watershed reported by USGCRP (2009) and
45 determined that GCC could affect water supply in the Colorado River Basin by reducing surface
46 runoff and increasing evapotranspiration during the period of STP, Units 1 and 2, extended
47 operations. The USGCRP has identified that the region is likely to experience water conflicts by
48 2025 because of increasing population and potential endangered species' needs

1 (USGCRP 2009). The NRC and USACE (NRC 2011b) concluded that while the GCC-related
2 changes may not be insignificant nationally or globally, their impact on STP regional water
3 resources would not be destabilizing. Thus, the NRC staff concludes that GCC effects would
4 not substantially add to regional surface water cumulative impacts during the license renewal
5 term for STP, Units 1 and 2.

6 Historically, the waters of the Colorado River Basin have been extensively used, and the region
7 has surface water planning, allocation, and development systems in place to manage the use of
8 its limited surface water resources. The cumulative impact on surface water use in Region K
9 relative to the unaltered conditions prior to these uses, from past and present diversions and
10 reasonably foreseeable future projects, would noticeably alter but not destabilize the surface
11 water resource. Nevertheless, due to the potential impacts associated with water use conflicts
12 and maintenance of Colorado River flows to Matagorda Bay, the NRC staff concludes that
13 cumulative impacts on surface water resources during the license renewal term would be
14 MODERATE.

15 **4.11.3.2 Cumulative Impacts on Groundwater Resources**

16 Water drawn from the Shallow Chicot Aquifer in the vicinity of the STP site is slightly saline, and,
17 consequently, it is used primarily for livestock watering. Offsite livestock wells are located close
18 to the STP site boundary, and four are located on leased grazing land within the STP site
19 (i.e., between the MCR and the Colorado River) (see Section 2.2.5.1). No groundwater is
20 withdrawn from the Shallow Chicot Aquifer for use by STP, Units 1 and 2. STP operation does
21 result in seepage from the MCR entering the Upper Shallow Aquifer, and the MCR water carries
22 with it the constituents contained in plant cooling water (e.g., tritium, TDS) (NRC 2011b;
23 STPNOC 2010b). Operation of the plant has also resulted in leaks and releases to the Shallow
24 Aquifer within the protected area (e.g., the TDS line leaks and steam condensate discharge)
25 (MACTEC 2009). These releases have not substantially affected the groundwater quality within
26 the STP site, and impacts on groundwater quality off site would be less. Specifically, for the
27 Shallow Chicot Aquifer, tritium levels remain below the EPA primary DWS, and TDS
28 concentrations remain within the range defining a slightly saline groundwater. Because of the
29 reasons presented above, the NRC staff concludes that cumulative impacts on groundwater use
30 and quality during the license renewal term, related to the Shallow Chicot Aquifer, would be
31 SMALL.

32 In contrast, water drawn from the Deep Chicot Aquifer is of higher quality. Aside from the
33 existing STP-owned groundwater wells completed in the Deep Chicot Aquifer that supply STP,
34 Units 1 and 2, the closest wells to the STP site completed in the Deep Chicot Aquifer are the
35 public water supply wells in the communities of Selkirk and Exotic Isle, which are located
36 adjacent to the STP site eastern boundary (see Section 2.2.5). Wells for these communities are
37 approximately 1 mi (1.6 km) from the nearest STP production well and 3.75 mi (6 km) from STP,
38 Units 1 and 2. Review of other existing or planned projects in the surrounding area indicates
39 groundwater use by Equistar Chemicals LP's Matagorda facility, the OXEA Corporation Bay City
40 Plant, and the municipal water supply for Bay City. The shortest distance from this group of
41 facilities to STP is approximately 5 mi (8 km) (NRC 2011b).

42 Groundwater used at STP, Units 1 and 2, is from the Deep Chicot Aquifer. Public water
43 supplies and other large-scale industrial users also draw from this aquifer. As noted in
44 Section 4.4.2.1, there has been a regional drawdown in the Deep Aquifer in the vicinity of the
45 STP site. By 1980, a regional drawdown of approximately 35 ft (11 m) was attributed to
46 groundwater development to the north of the STP site (STPNOC 2009a). Proposed STP,
47 Units 3 and 4, would also use the groundwater from the production wells at the STP site.

Environmental Impacts of Operation

1 Groundwater use by STP, Units 1 and 2, is 768 gpm (2,910 L/min) for normal operations (see
2 Section 2.1.7.2). Groundwater use by the proposed STP, Units 3 and 4, is 975 gpm
3 (3,690 L/min) for normal operations. These rates represent 2.4 and 3.1 percent, respectively, of
4 the annual rate of groundwater use permitted by the CPGCD in Matagorda County during the
5 2008 to 2010 permit period (NRC 2011b). Based on the best available information, other than
6 the proposed STP, Units 3 and 4, there are no other foreseeable nearby new projects with a
7 substantial demand for groundwater. The aquifer drawdown projections from STP well pumping
8 for selected distances are shown in Table 4–6 and discussed in Section 4.4.2.1. Potential
9 impacts of drawdown from STP operations on other groundwater users, and from other users'
10 pumping on STP, would be minimal because the Deep Chicot Aquifer remains confined, and
11 changes in pumping lift over the 20-year renewal period would not be substantial.

12 Because of higher groundwater use in the past, subsidence has been an issue in the STP
13 region. The USGS (Ryder and Ardis 2002) has described subsidence in Matagorda County as
14 less than 1 ft (0.3 m) since 1900 over most of the region, with somewhat higher subsidence of
15 1.5 ft (0.46 m) noted in western Matagorda County. STPNOC has observed a subsidence rate
16 of less than 0.1 in. (0.25 cm) to about 0.2 in. (0.50 cm) per year during construction and through
17 STP, Units 1 and 2, operations in 1993 (STPNOC 2008b). The updated final safety analysis
18 report (UFSAR) for STP, Units 1 and 2, projected regional subsidence from 1973 through 2020
19 to be between 2.5 and 3 ft (0.76 and 0.9 m) based on a projected regional groundwater decline
20 of 87 ft (26.5 m) and subsidence coefficients derived from regional observations
21 (STPNOC 2009c). To minimize the potential for subsidence, STPNOC spaced its main
22 production wells (i.e., wells 5, 6, and 7) over 5,000 ft (1,520 m) apart and distributes the
23 pumping rates among them. All groundwater users in Matagorda County operate their wells
24 under the rules of the CPGCD (2009). The purpose of the CPGCD is to provide for conserving,
25 preserving, protecting, and recharging the groundwater to control subsidence and prevent the
26 waste and pollution of the groundwater resource. Groundwater use under the rules of the
27 CPGCD minimizes the potential for excessive drawdown, saltwater intrusion, or land
28 subsidence impacts to arise and affect neighboring groundwater users (CPGCD 2009). Current
29 observations of drawdown are consistent with the drawdown projected in the UFSAR for STP,
30 Units 1 and 2, and subsidence projections are consistent with observations. These potential
31 impacts are greatest on site where they are monitored. As noted in Section 4.3.2.1, drawdown
32 at STP production wells is currently in equilibrium with the surrounding groundwater aquifer, and
33 continued operation of STP wells for an additional 20 years beyond the current license would
34 increase drawdown by less than 1 ft (0.3 m). Additional subsidence resulting from this change
35 in drawdown during the license renewal term would be minimal.

36 Operation of STP, Units 1 and 2, does not adversely affect groundwater quality in the Deep
37 Chicot Aquifer because of the low-conductivity layer between 100 and 150 ft (30 and 46 m) thick
38 that separates and isolates the Shallow Chicot Aquifer from the Deep Chicot Aquifer. Similarly,
39 because of the hydraulic isolation of the Deep Chicot Aquifer from the Shallow Chicot Aquifer
40 and any releases at the land surface, other nearby groundwater users are also not adversely
41 affecting groundwater quality in the Deep Chicot Aquifer. Groundwater drawdown at the STP
42 production wells is great enough to reverse the regional gradient and draw groundwater in the
43 Deep Chicot Aquifer from beneath the STP site into the production wells. Thus, if any releases
44 from the plant were to move from the Shallow to the Deep Chicot Aquifer, the contamination
45 would likely be drawn to and intercepted by STP groundwater production wells (NRC 2011b).

46 With regard to the Deep Chicot Aquifer, because of the reasons presented above, the NRC staff
47 concludes that cumulative impacts on groundwater use and quality during the license renewal
48 term would be SMALL.

1 4.11.4 Aquatic Resources

2 This section addresses the direct and indirect effects of license renewal on aquatic resources
3 when added to the aggregate effects of other past, present, and reasonably foreseeable future
4 actions. The geographic area considered in this analysis includes the STP site and the portion
5 of the lower Colorado River basin within influence of STP operations, including Matagorda Bay.

6 The benchmark for assessing cumulative impacts on aquatic resources takes into account the
7 preoperational environment, as recommended by EPA (1999) for its review of NEPA
8 documents:

9 Designating existing environmental conditions as a benchmark may focus the
10 environmental impact assessment too narrowly, overlooking cumulative impacts
11 of past and present actions or limiting assessment to the proposed action and
12 future actions. For example, if the current environmental condition were to serve
13 as the condition for assessing the impacts of relicensing a dam, the analysis
14 would only identify the marginal environmental changes between the continued
15 operation of the dam and the existing degraded state of the environment. In this
16 hypothetical case, the affected environment has been seriously degraded for
17 more than 50 years with accompanying declines in flows, reductions in fish
18 stocks, habitat loss, and disruption of hydrologic functions. If the assessment
19 took into account the full extent of continued impacts, the significance of the
20 continued operation would more accurately express the state of the environment
21 and thereby better predict the consequences of relicensing the dam.

22 Sections 2.2.5 and 2.2.7 of this SEIS present an overview of the history and factors that led to
23 the current condition of the aquatic features on the STP site, the Colorado River, and Matagorda
24 Bay. Since the 1920s, development and redirection of the lower Colorado River has affected
25 the water quality, water chemistry, and aquatic resources. These alterations have increased the
26 freshwater input to Matagorda Bay and marine and estuarine inputs to the lower Colorado River,
27 resulting in a change in salinity. Anthropogenic activities has decreased available habitat for
28 some species and increased available habitat for others. For example, construction and
29 development projects have reduced the area available for aquatic organisms to navigate
30 through the Colorado River and Matagorda Bay due to erosion, habitat modification, and habitat
31 fragmentation. Overall, species richness and diversity have increased in the lower Colorado
32 River near STP (from the GIWW to navigation mile marker 8) based on surveys in 2007 to 2008
33 compared to similar surveys in 1983 to 1984 (ENSR 2008b; NRC 1986, 2011b;
34 STPNOC 2010b). The change in the aquatic community could be due to differences in study
35 methods (e.g., differences in sampling protocol over time), environmental conditions
36 (e.g., variance in weather conditions during the two sampling efforts), or from human activities
37 (e.g., the river diversion projects that has increased the marine and estuarine flow into the lower
38 Colorado River).

39 Many natural and anthropogenic activities can influence the current and future aquatic biota in
40 the area surrounding STP. Potential biological stressors include continued entrainment,
41 impingement, and potential heat shock from STP, Units 1 and 2 (if the license renewal is
42 granted), as described in Section 4.5, construction and operation of STP, Units 3 and 4, other
43 water use projects, urbanization, fishing, and GCC, as described below.

44 Construction and Operations of STP, Units 3 and 4. In 2007, STPNOC submitted an application
45 to the NRC to construct and operate two additional nuclear reactors on the STP site, referred to
46 in this SEIS as STP, Units 3 and 4. In 2011, NRC published its final EIS evaluating the
47 environmental impacts of the proposed construction and operations of Units 3 and 4
48 (NRC 2011b). This project would have overlapping impacts with the continued operations of

Environmental Impacts of Operation

1 Units 1 and 2. For example, all four units would draw water from the MCR, which need to be
2 filled higher than current levels (STPNOC 2010c). STPNOC would draw the additional makeup
3 water from the Colorado River through the RMPF. Species impinged and entrained would be
4 similar to those impinged and entrained during operations of Units 1 and 2. Past impingement
5 and entrainment studies and NRC evaluations of such studies concluded that impacts to the
6 important species would be insignificant and minor, primarily because the density of organisms
7 in the vicinity is rather low and the species are ubiquitous in the region (McAden 1984, 1985;
8 NRC 1986, 2011b). Additionally, the design and operation of the RMPF minimize impacts on
9 aquatic biota, as described in Section 4.5.2. Therefore, impacts from operation of the RMPF
10 (impingement, entrainment, and entrapment) for four units are unlikely to destabilize aquatic
11 resources in the lower Colorado River.

12 Operation of the four units would also affect aquatic resources in the MCR. Higher intake levels
13 to provide cooling water for four units would increase impingement and entrainment at the
14 CWISs in the MCR. The two discharges from the four units would increase the water
15 temperature in the MCR. Aquatic organisms in the MCR would either avoid or acclimate to the
16 new conditions. Because the aquatic community in the MCR is isolated from the onsite water
17 bodies and the Colorado River, these impacts would not noticeably alter the aquatic resources
18 within the geographic area of interest.

19 Operation of two additional units would increase the frequency and duration of discharges from
20 the MCR into the Colorado River. STPNOC would manage discharges, as needed, based on
21 water quality in the MCR and TPDES permit conditions (STPNOC 2010b). Chemical releases
22 from discharging into the Colorado River are expected to be below the criteria for protection of
23 aquatic life (TCEQ 2005). NRC (2011b) determined that under certain conditions, such as poor
24 river water quality, the size and configuration of the thermal plume could impede passage of the
25 aquatic organisms in the Colorado River, including species that are of commercial and
26 recreational importance and species that are Federally managed and have designated essential
27 fish habitat. NRC (2011b) concluded that the foraging behavior and high fecundity of such
28 aquatic organisms suggest that the effects from the thermal plume would not noticeably alter or
29 destabilize the populations or aquatic community in the lower Colorado River.

30 NRC (2011b) concluded that the impacts to aquatic resources from other construction and
31 operational activities of all four units would not noticeably alter or destabilize aquatic resources.
32 These impacts include additional seepage from the MCR that could influence flow to Little
33 Robbins Slough and wetlands, increased non-permeable surfaces (e.g., parking lots and
34 buildings) that would change the flow of stormwater into the drainages on site, maintenance
35 dredging in the Colorado River, shoreline restoration activities along the Colorado River, and
36 disturbances from vessel traffic to marine mammals (NRC 2011b).

37 Other Water Use Projects. Future projects near STP that would withdraw or redirect significant
38 quantities of the Colorado River include the proposed LCRA–SAWS Project, WSEC, and
39 municipal use (TWDB 2006; WSEC 2011).

40 The LCRA–SAWS Project is projected to generate 150,000 ac-ft of new water supplies by 2060
41 through conjunctive use of groundwater from the Gulf Coast Aquifer and surface water supplies
42 from the Colorado River (TWDB 2006). LCRA–SAWS (2009) will evaluate impacts to aquatic
43 habitat in the Colorado River with and without the proposed project. WSEC, a proposed
44 coal-fired generating plant, would withdraw approximately 22,000 ac-ft per year of water from
45 the lower Colorado River (WSEC 2011). LCRA included water use from WSEC growth in its
46 water supply resource plan for Region K, Matagorda County. Other sources of water use
47 included in water supply estimates include increases in municipal use due to population,

1 manufacturing, mining, irrigation, transfer of water via the proposed Mary Rhodes Pipeline II,
2 and other categories (TWBD 2006). From 2010 to 2040, the plan estimates an annual increase
3 of 12 percent without the WSEC Project and 80 percent with the WSEC Project (LCRA 2008).

4 These projects have the potential to change the freshwater contribution in the river within the
5 vicinity of STP by redirecting the flow or by withdrawing a significant amount of freshwater.
6 Changes in flow of saltwater into the river could change the habitat (or salinity) for many
7 species. In response, estuarine-marine species would likely become more abundant if the
8 salinity increases whereas freshwater species would likely become more abundant if the salinity
9 decreases. The Colorado River diversion project, which increased the flow between the
10 Colorado River and Matagorda Bay, resulting in an increase in salinity near the STP site, likely
11 influenced the shift in aquatic communities near STP towards estuarine-marine species
12 (ENSR 2008b; NRC 1975, 1986, 2011b).

13 Urbanization and Development. Residential or industrial development in the vicinity of STP site
14 can affect aquatic resources. Increased urbanization and population growth, while projected to
15 be low in comparison to other locations in Texas (NRC 2011b), would still lead to increased
16 development along the shores of the Colorado River that can contribute to cumulative impacts
17 in the lower Colorado River basin through habitat loss and nonpoint source pollution. Future
18 activities could lead to increased water needs, nonpoint and point source water pollution, vessel
19 traffic on the waterways, and maintenance dredging.

20 Proposed future power generation facilities to support increased energy usage, including WSEC
21 and the Victoria County Station, may require the development of new transmission systems in
22 the geographic area of interest. The WSEC may be required to add additional transmission
23 capabilities within the vicinity for its power transmission, but that information is currently not
24 available to evaluate (WSEC 2011). If WSEC or Victoria County Station build new transmission
25 corridors, they would likely have a minor effect on aquatic species assuming the owners
26 consider aquatic resource when routing transmission lines and employ best management
27 practices (BMPs) during construction and maintenance activities.

28 STPNOC would use existing transmission corridors to support power transmission from
29 proposed Units 3 and 4 and during the period of extended operations for Units 1 and 2.
30 STPNOC (2010b, 2010c) would employ vegetation maintenance and control along existing and
31 future corridors, which would not be expected to increase and contribute to cumulative effects
32 (NRC 2011b).

33 Fishing. Commercial and recreational fishing in the Colorado River and Matagorda Bay would
34 likely continue to increase in the future. The region is recognized for recreational fishing of
35 many species, and fishing would likely increase with increased urbanization in the vicinity.
36 Matagorda Bay is one of the recognized regions in Texas for commercial fishing, primarily
37 associated with the shrimp industry (TPWD 2002), although these fisheries are not significant
38 contributors to employment in the region (NRC 2011b). In efforts to improve the fisheries in the
39 area, TPWD has designated the “most eastern half of the eastern arm of Matagorda Bay” as a
40 finfish and shellfish nursery, closing the area to commercial fishing and commercial harvesting
41 of oysters (LCRA et al. 2006). A freshwater inflow needs study for Matagorda Bay has identified
42 several alternatives associated with water management strategies designed to improve
43 commercial fishing opportunities (LCRA et al. 2006). If management strategies do not improve
44 sustainability of fisheries, increased fishing pressures could result in overall decreased
45 biological productivity for the Colorado River and Matagorda Bay.

46 Climate Change. In addition to direct anthropogenic activities, GCC could impose additional
47 stressors on aquatic communities. The presence of natural environmental stressors (e.g., short-

Environmental Impacts of Operation

1 or long-term changes in precipitation or temperature) would contribute to the cumulative
2 environmental impacts to the Colorado River and Matagorda Bay. GCC could lead to
3 decreased precipitation, increased sea levels, varying freshwater inflow, increased
4 temperatures, increased storm surges, greater intensity of coastal storms, and increased
5 nonpoint source pollution from runoff during these storms (GCRP 2009; Montagna et al. 1995;
6 Nielsen-Gammon 1995). Such changes could directly affect habitat for aquatic communities by
7 altering the flow of freshwater, water quality, salinity, and dissolved oxygen levels. Habitat
8 alterations could result in changes to community structure, species abundance, and species
9 diversity. These kinds of changes occurred in the vicinity of STP with the diversion of the
10 Colorado River into the Gulf and Matagorda Bay since the 1920s (NRC 2011b).

11 GCC could also slow efforts to restore nursery habitats in Matagorda Bay. The Colorado River
12 diversion project increased the flow of freshwater into the bay in an effort to improve habitat for
13 wetlands, oyster reefs, and other nursery grounds (USACE 2009). However, LCRA et al. (2006)
14 indicated slower than expected results and showed that more freshwater inflow into the bay is
15 needed to increase biological productivity in the bay. The effects of rising sea level, which
16 would increase salinity in the bay, would likely be counterproductive to the current efforts to
17 increase freshwater flows into the Bay. Changes in water quality in Matagorda Bay and the
18 lower Colorado River could create areas that are hypoxic (low in dissolved oxygen) and lead to
19 further stress on aquatic communities (Montagna et al. 1995). These stressors would result in
20 shifts in species ranges, habitats, and migratory behaviors and also alter ecosystem processes
21 (GCRP 2009).

22 Conclusion. Past, present and reasonably foreseeable future activities exist in the geographic
23 area of interest that could contribute to cumulative effects to aquatic ecological resources.
24 Future development of industries that compete for water in the Colorado River, such as WSEC,
25 as well as management of water budgets across the State of Texas through diversion projects
26 like the LCRA–SAWS Project and the Mary Rhodes Pipeline Phase II Project, would likely affect
27 aquatic resources in the lower Colorado River. Such actions in combination with other direct
28 and indirect anthropogenic and natural environmental stressors, including GCC, would
29 cumulatively lead to effects on the aquatic communities that would noticeably alter important
30 attributes such as species range, habitat availability, ecosystem processes, migratory corridors
31 and behavior, species diversity, and species abundance. The NRC staff concludes that
32 cumulative impacts from past, present, and reasonably foreseeable actions to aquatic resources
33 in the geographic area of interest would be MODERATE. The incremental impact from
34 continued operations of Units 1 and 2 during the period of extended operation would be SMALL.

35 **4.11.5 Terrestrial Resources**

36 Historic Conditions. Section 2.6 discusses the ecoregion in which the STP site lies—the
37 Western Gulf Coastal Plain—which is dominated by tallgrass and shortgrass prairie.
38 Historically, these prairies covered about 6.5 million ac (2.6 million ha) within Texas. During the
39 past century, urban and industrial development and agricultural expansions have fragmented
40 the natural habitat. In the late 1800s, ranchers introduced large numbers of cattle to the region.
41 Livestock grazing continues to be a major land use, but the majority of land has been altered for
42 cultivation of rice, sugarcane, forage, and grain. By the 1980s, Diamond and Smeins (1984)
43 estimated that less than one percent of Texas’s native coastal prairie grasslands remained in a
44 relatively pristine state.

45 The Texas Gulf coasts historically contained abundant and diverse wetlands. Approximately
46 30 percent of the coastal prairies along the Texas Gulf coasts were once wetlands
47 (TPWD 2010). Human activities, including landscape alteration for agricultural, industrial, or

1 urban uses, continue to significantly threaten remaining wetland habitats (TPWD 2005). In
 2 addition, decreased precipitation, sea-level rise, more frequent high-intensity storm surges, and
 3 increased temperatures resulting from GCC have contributed to wetland losses (GCRP 2009).
 4 Nonetheless, rice fields, prairie wetlands, and coastal marshes continue to provide important
 5 habitat for waterfowl and many other wildlife species. TPWD (2005) identified the Gulf coasts
 6 and associated grassland prairies, wetlands, marshes, and agriculture as one of the most
 7 important wintering areas for North America's waterfowl populations.

8 On the immediate site, STPNOC cleared land for, built, and filled the 7,000-ac (2,800-ha) MCR
 9 and cleared an additional 300 ac (120 ha) for the facility's buildings, parking lots, roads, and
 10 other infrastructure.

11 In the region surrounding the STP site, construction of many industrial facilities and wastewater
 12 treatment plants have resulted in the loss of terrestrial habitat. These facilities include:

- 13 • the Formosa Plastics Corporation plant,
- 14 • the Texas Liquid Fertilizer Company,
- 15 • the Alcoa aluminum plant,
- 16 • the Equistar Chemical LP's Matagorda facility, and
- 17 • the OXEA Corporation's chemical plant.

18 Other Projects. Many projects near the STP site could affect the terrestrial environment in the
 19 future. These projects are discussed in this section.

20 Chemicals Inc. has a specialty chemical plant near STP. The plant's 107.5-ac (44-ha) site is
 21 located about 5 mi (8 km) south of Bay City (Chemicals Inc. 2011).

22 About 5 mi (8 km) northeast of the STP site, a 1,200-ac (490-ha) tract of land is the site for the
 23 WSEC, a 1,320-net-mW coal and petroleum coke plant (MCEDC 2011). The TCEQ granted the
 24 project its air quality permit in September 2010. The status of the facility's wastewater permit is
 25 uncertain. Coal-fired plants are a major source of air pollution in the U.S. because they release
 26 sulfur dioxide, nitrogen oxides, mercury, carbon dioxide, and particulates. Nitrous oxides and
 27 sulfur dioxides combine with water to form acid rain, which can lead to erosion and changes in
 28 soil pH levels. Mercury deposits onto soil and surface water, which may then be taken up by
 29 terrestrial and aquatic plant or animal species and poses the risk of bioaccumulation.

30 In September 2007, STPNOC submitted COL applications to the NRC for two new nuclear units
 31 on the STP site. If approved, STPNOC would construct the new units adjacent to the currently
 32 operating Units 1 and 2. As a result, about 540 ac (220 ha) would be disturbed. Of this, the
 33 new reactors, the associated buildings and infrastructure, and a new heavy haul road would
 34 occupy 300 ac (120 ha), and the remaining 240 ac (100 ha) would only be temporarily disturbed
 35 for temporary buildings, construction equipment storage, and material laydown (NRC 2011b).
 36 The majority of land that would be disturbed is currently maintained or mowed grasslands,
 37 shrub-scrub habitat, or used for existing industrial activities. The new units would require
 38 additional transmission lines to transfer power to the regional electric grid. However, STPNOC
 39 would not create any new or expand any existing transmission line corridors (NRC 2011b). In
 40 the NRC's EIS regarding the proposed new STP units, the NRC (2011b) concluded that impacts
 41 to the terrestrial environment would be SMALL for this proposed action.

42 Development of the proposed Mary Rhodes Pipeline Phase II Project would likely also
 43 contribute to regional habitat loss and fragmentation. Potential cumulative impacts resulting
 44 from construction and operation of the proposed water transport line would be similar to those

Environmental Impacts of Operation

1 impacts from constructing and maintaining new transmission line corridors and include habitat
2 fragmentation, creation of early successional habitat, and displacement of certain wildlife
3 species.

4 For projects listed above, construction and operation would impact wildlife by increasing noise
5 and traffic, which could alter behavior or cause a shift in habitat use in undisturbed land
6 bordering construction areas. Birds in the immediate area would be more likely collide with tall
7 structures and construction equipment. However, construction impacts would be short-term and
8 relatively minor. Hence, the impacts would not destabilize the environment.

9 Urbanization and Habitat Fragmentation. As the region surrounding the STP site becomes
10 more developed, habitat fragmentation will increase. Species that require larger ranges,
11 especially predators, will likely suffer reductions in their populations. In contrast, herbivores will
12 experience less predation pressure, and their populations are likely to increase. Edge species
13 will likely benefit from the fragmentation, while species that require interior forest or swamp
14 habitat will likely suffer. The transmission line corridors established for STP transmission lines
15 represent habitat fragmentation, though many of these corridors pass through cultivated land
16 that has already been converted from its native habitat or shrub-scrub habitat, which was
17 minimally altered during transmission line construction. Habitat fragmentation of surrounding
18 areas may increase the value of the network of wetlands within the Texas Prairie Wetlands
19 Project—110 ac of which is set aside on the STP site—because this land will not experience
20 fragmentation or other human-induced impacts.

21 Parks and Wildlife Preserves. The FWS and State have set many lands in the STP region aside
22 as parks, preserves, or management areas. These include:

- 23 • Brazos Bend State Park,
- 24 • Mad Island Marsh Preserve,
- 25 • Mad Island Wildlife Management Area,
- 26 • Big Boggy National Wildlife Refuge, and
- 27 • the Texas Prairie Wetland Project, for which 110 ac (45 ha) on the STP site is
28 set aside.

29 Section 2.2.6 of this SEIS describes these parks and preserves in more detail. These areas will
30 continue to provide valuable habitat to native wildlife, migratory birds, and native prairie and
31 marsh vegetation. Both the National Wildlife Refuge Network and the Texas Prairie Wetland
32 Project are ongoing efforts. In the future, FWS and Ducks Unlimited will continue to acquire
33 lands for these projects.

34 Conclusion. The NRC staff examined the cumulative effects of the construction of STP,
35 neighboring energy projects, continued urbanization and habitat fragmentation, and nearby
36 parks and wildlife preserves. The NRC staff concludes that the minimal terrestrial impacts on
37 the continued STP operations would not contribute to the overall decline in the condition of
38 terrestrial resources. The NRC staff believes that the cumulative impacts of other and future
39 actions during the term of license renewal on terrestrial habitat and associated species, when
40 added to past, present, and reasonably foreseeable future actions, would be MODERATE.

41 **4.11.6 Human Health**

42 Radiological Impacts. The radiological dose limits for protection of the public and workers have
43 been developed by the NRC and EPA to address the cumulative impact of acute and long-term

1 exposure to radiation and radioactive material. These dose limits are codified in
2 10 CFR Part 20 and 40 CFR Part 190. For the purpose of this analysis, the area within a 50-mi
3 (80.4-km) radius of STP was included. The REMP conducted by STPNOC in the vicinity of the
4 STP site measures radiation and radioactive materials from all sources (i.e., hospitals and other
5 licensed users of radioactive material); therefore, the monitoring program measures cumulative
6 radiological impacts. Within the 50-mi (80-km) radius of the STP site, there are currently no
7 other nuclear power reactors or uranium fuel cycle facilities.

8 Radioactive effluent and environmental monitoring data for the 5-year period from 2006 to 2010
9 were reviewed as part of the cumulative impacts assessment. In Section 4.8.1 of this SEIS, the
10 NRC staff concluded that impacts of radiation exposure to the public and workers (occupational)
11 from operation of STP during the renewal term are SMALL. The NRC and the State of Texas
12 would regulate any future actions in the vicinity of the STP site that could contribute to
13 cumulative radiological impacts.

14 As stated in its ER, the applicant stores its spent nuclear fuel in its spent fuel pool. The
15 applicant estimates that there is adequate capacity in its spent fuel pool to store spent fuel until
16 2025. For reactor operations past that date, STPNOC plans to install a dry fuel storage system
17 at the STP site for the storage of its spent fuel. The installation and monitoring of this facility will
18 be governed by NRC requirements in 10 CFR Part 72, "Licensing Requirements for the
19 Independent Storage of Spent Nuclear Fuel, High-Level Radioactive Waste, and
20 Reactor-Related Greater Than Class C Waste." Radiation from this projected storage facility as
21 well as from the operation of STP, Units 1 and 2, are required to be within the radiation dose
22 limits in 10 CFR Part 20, 40 CFR Part 190, and 10 CFR Part 72. The NRC performs periodic
23 inspections of every licensed dry fuel storage facility to verify its compliance with all licensing
24 and regulatory requirements. Currently, the applicant has not submitted an application to the
25 NRC for the dry fuel storage system, so no further information is available.

26 In September 2007, STPNOC applied to the NRC for a COL pursuant to the requirements of
27 10 CFR Part 52 for the construction and operation of two additional reactors at the STP site.
28 STPNOC submitted information on the site and surrounding area to NRC in its application for
29 the COL. The NRC reviewed the COL application and issued the final EIS (NRC 2011b), which
30 analyzed the impacts on the surrounding communities and natural resources to determine if the
31 STP site is suitable to support two additional reactor units (proposed Units 3 and 4). The NRC
32 also evaluated the cumulative impacts of the operation of four reactor units and considered the
33 possible life extension of STP, Units 1 and 2, for 20 years. In the final EIS, the NRC staff
34 concludes that cumulative radiological impacts would be SMALL.

35 In addition, pursuant to 10 CFR Part 20 and 40 CFR Part 190, the cumulative radiological
36 impacts from STP, Units 1 and 2, the possible projected dry fuel storage system, and two
37 additional reactor units are required to meet the acceptable radiation dose limits (protecting
38 human health) specified in these regulations. EPA regulation (40 CFR 190) limits the total dose
39 to an offsite individual near STP from "all uranium fuel cycle facilities and all pathways," located
40 at STP. Furthermore, the STP REMP would monitor the buildup of radioactivity in the
41 environment to effectively ensure that the levels remain acceptable. Based on this information,
42 the staff concludes that cumulative radiological impacts would be SMALL.

43 Electromagnetic Fields Impacts. For electromagnetic fields impacts on human health, the staff
44 determined that not all of the STP transmission lines are operating within design specifications
45 and meet current NESC criteria. In Section 4.8.4, the NRC staff determined that the potential
46 impacts from STP transmission lines were SMALL to MODERATE. However, STP addressed
47 the issue of acute shock by providing the staff with potential actions it is considering to mitigate

Environmental Impacts of Operation

1 the impacts. Therefore, the staff concludes that the transmission lines are not expected to
2 significantly affect the overall potential for electric shock from induced currents within the
3 analyzed area of interest.

4 With respect to the effects of chronic exposure to ELF-EMF, as discussed in Section 4.8.5, the
5 GEIS finding of “uncertain” is appropriate to STP.

6 For the reasons listed above, the staff concludes that the cumulative impacts of continued
7 operation of the STP transmission lines and other transmission lines in the affected area would
8 be SMALL to MODERATE.

9 Microorganisms Impacts. In the environmental review for the proposed Units 3 and 4, the NRC
10 staff determined that other projects (e.g., the Mary Rhodes Pipeline Phase II Project) would use
11 or divert river water upstream of STP. These projects, depending on the magnitude and without
12 mitigation measures, could reduce freshwater river flow and increase the ambient river water
13 temperature (Neuces River Authority 2001; TWDB 2006b; WSEC 2009). Therefore, this
14 cumulative effect on Colorado River conditions could be favorable for an increased presence of
15 thermophilic microorganisms and, subsequently, increase the risk of public exposure to potential
16 harmful microorganisms (thermophilic). However, based on past data on waterborne diseases
17 from recreational water activities in Texas and the discharging limits on STP, cumulative
18 impacts to human health due to exposure to microorganisms in the Colorado River would likely
19 be minimal (CDC 2009; TDSHS 2010). Hence, the staff concludes that cumulative impacts to
20 human health due to exposure to microorganisms in the Colorado River would be SMALL.

21 **4.11.7 Socioeconomics**

22 This section addresses socioeconomic factors that have the potential to be directly or indirectly
23 affected by changes in operations at STP in addition to the aggregate effects of other past,
24 present, and reasonably foreseeable future actions. The primary geographic area of interest
25 considered in this cumulative analysis is Brazoria and Matagorda Counties, where
26 approximately 84 percent of STP employees reside (see Table 2–12). This is where the
27 economy, tax base, and infrastructure would most likely be affected since STP workers and
28 their families reside, spend their income, and use their benefits within these counties.

29 As discussed in Section 4.9 of this SEIS, continued operation of STP during the license renewal
30 term would have no impact on socioeconomic conditions in the region beyond those already
31 experienced. Since STPNOC has no plans to hire additional workers during the license renewal
32 term, overall expenditures and employment levels at STP would remain relatively constant with
33 no additional demand for permanent housing and public services. In addition, since
34 employment levels and tax payments would not change, there would be no population or tax
35 revenue-related land use impacts. Based on this information and other information presented in
36 Chapter 4 of this SEIS, there would be no additional contributory effect on socioeconomic
37 conditions in the future from the continued operation of STP during the license renewal term
38 beyond what is currently being experienced.

39 Environmental Justice. The environmental justice cumulative impact analysis assesses the
40 potential for disproportionately high and adverse human health and environmental effects on
41 minority and low-income populations that could result from past, present, and reasonably
42 foreseeable future actions including STP operations during the renewal term. Adverse health
43 effects are measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human
44 health. Disproportionately high and adverse human health effects occur when the risk or rate of
45 exposure to an environmental hazard for a minority or low-income population is significant and
46 exceeds the risk or exposure rate for the general population or for another appropriate

1 comparison group. Disproportionately high environmental effects refer to impacts or risk of
2 impact on the natural or physical environment in a minority or low-income community that are
3 significant and appreciably exceed the environmental impact on the larger community. Such
4 effects may include biological, cultural, economic, or social impacts. Some of these potential
5 effects have been identified in resource areas presented in Chapter 4 of this SEIS. Minority and
6 low-income populations are subsets of the general public residing in the area, and all would be
7 exposed to the same hazards generated from STP operations.

8 Based on the information discussed in this section, and the analysis of human health and
9 environmental impacts presented in Chapters 4 and 5, it is unlikely there would be any
10 disproportionately high and adverse contributory effect on minority and low-income populations
11 from the continued operation of STP and other reasonably foreseeable future actions during the
12 license renewal term.

13 **4.11.8 Historic and Archaeological Resources**

14 This section addresses the direct and indirect effects of license renewal on historic and cultural
15 resources when added to the aggregate effects of other past, present, and reasonably
16 foreseeable future actions. The geographic area considered in this analysis is the APE
17 associated with the proposed undertaking, as described in Section 2.2.9.

18 Before construction of STP, the area was largely undisturbed and contained archaeological
19 sites. In the early 1970s, the Texas Archaeological Survey conducted cultural resources
20 investigations of the STP site and surrounding area. The investigations included a literature
21 review, a pedestrian survey, and limited subsurface testing (NRC 2011b;
22 STPNOC 2010b, 2010c). The construction of STP was completed in the 1980s, and much of
23 the site had been heavily disturbed by construction activities including the construction of the
24 MCR. Section 2.2.10 presents an overview of the existing historic and archaeological resources
25 located on the STP site. As described in Section 4.9.6, no cultural resources would be affected
26 by relicensing activities associated with the STP site.

27 Past land development has resulted in impacts on, and the loss of cultural resources near and
28 at, the STP site. The impacts from other past, present, and reasonably foreseeable projects
29 were reviewed to analyze overlapping impacts that might affect cultural resources. Direct
30 impacts would occur if archaeological sites in the APE are physically removed or disturbed. The
31 following projects are located within the geographic area considered for cumulative impacts:

- 32 • construction and operation of STP, Units 3 and 4,
- 33 • transmission lines, and
- 34 • future urbanization.

35 Construction and operation of STP, Units 3 and 4, transmission lines, and future urbanization
36 have the potential to result in impacts on cultural resources through inadvertent discovery during
37 ground-disturbing activities. However, based on the best available information, there are no
38 known historic or archaeological resources on the STP site. In addition, STPNOC has
39 environmental compliance procedures in place for cultural resource protection and inadvertent
40 discovery and has stated the construction and operation activities would not affect the
41 unrecorded gravesite on the STP site (STPNOC 2011g). Future urbanization near STP would
42 be required to comply with applicable State and Federal laws regarding protection of cultural
43 and archaeological resources, and any impacts would be mitigated accordingly.

Environmental Impacts of Operation

1 Based on this information, the NRC staff finds that the continued operation of STP during the
2 license renewal term would not incrementally contribute to cumulative impacts on historic and
3 archaeological resources within STP and in the surrounding area. Therefore, the cumulative
4 impacts on historic and archaeological resources during the license renewal term would be
5 SMALL.

6 4.11.9 Summary of Cumulative Impacts

7 The staff considered the potential impacts resulting from the operation of STP during the period
8 of extended operation and other past, present, and reasonably foreseeable future actions near
9 STP. The preliminary determination is that the potential cumulative impacts would range from
10 SMALL to MODERATE, depending on the resource. Table 4–17 summarizes the cumulative
11 impacts on resources areas.

12 **Table 4–17. Summary of Cumulative Impacts on Resource Areas**

Resource Area	Cumulative Impact
Air quality	The NRC staff examined the cumulative effects of the continued operation of STP, Units 1 and 2, the construction and operation of STP, Units 3 and 4, and the construction and operation of the nearby WSEC coal plant. The cumulative impacts on criteria pollutants from emissions of effluents from the STP site and the WSEC would be noticeable (but not destabilizing), principally as a result of the contribution of WSEC. In addition, cumulative effects of GCC would contribute to the degradation of air quality resources in the geographic areas of interest (i.e., AQCR). For these reasons, the cumulative impacts on air quality during the license renewal term would be MODERATE.
Water resources	<p>Waters of the Colorado River Basin have been extensively used, and the region has surface water planning, allocation, and development systems in place to manage the use of its limited surface water resources. Nevertheless, because of the potential impacts associated with water use conflicts and maintenance of Colorado River flows to Matagorda Bay, the cumulative impacts on surface water resources during the license renewal term would be MODERATE.</p> <p>Because of the effective controls by the CPGCD on water use and because the STP operational leaks have not substantially affected the groundwater quality within the STP site, the cumulative impacts on groundwater resources during the license renewal term would be SMALL.</p>
Aquatic ecology	Future development of industries that compete for water in the Colorado River, such as WSEC, as well as management of water budgets across the State of Texas through diversion projects like the LCRA–SAWS Project and the Mary Rhodes Pipeline Phase II Project would likely affect aquatic resources in the lower Colorado River. Such actions, in combination with other direct and indirect anthropogenic and natural environmental stressors—including GCC—would cumulatively lead to effects on the aquatic communities that would noticeably alter important attributes, such as species range, habitat availability, ecosystem processes, migratory corridors and behavior, species diversity, and species abundance. For these reasons, the cumulative impacts on aquatic ecology during the license renewal term would be MODERATE.

Resource Area	Cumulative Impact
Terrestrial ecology	The staff examined the cumulative effects of the construction at STP (e.g., proposed STP, Units 3 and 4), neighboring projects, continued urbanization and habitat fragmentation, and nearby parks and wildlife preserves. The staff concludes that the minimal terrestrial impacts on the continued STP operations would not contribute to the overall decline in the condition of terrestrial resources. For these reasons, the cumulative impacts on terrestrial ecology during the license renewal term would be MODERATE.
Human health	The radiological dose limits for protection of the public and workers have been developed by the NRC and EPA to address the cumulative impact of acute and long-term exposure to radiation and radioactive material. The NRC and the State of Texas would regulate any future actions in the vicinity of the STP site that could contribute to cumulative radiological impacts. In addition, the cumulative radiological impacts from operation of STP, Units 1 and 2, the projected dry fuel storage system, and two additional reactor units would be required to meet the radiation dose limits in 10 CFR Part 20 and 40 CFR Part 190. For these reasons, cumulative radiological impacts during the license renewal term would be SMALL.
Socioeconomics	<p>Since STPNOC has no plans to hire additional workers during the license renewal term, employment levels at STP would remain relatively constant, with no additional demand for housing, public utilities, public services, or increased traffic. Based on this information and other information presented in Chapter 4 of this SEIS, there would be no additional contributory effect on socioeconomic conditions in the future from the continued operation of STP during the license renewal term beyond what is currently being experienced (i.e., no cumulative impact).</p> <p>As discussed in Section 4.11.7, there would also be no disproportionately high and adverse impacts to minority and low-income populations from the continued operation of STP during the license renewal term.</p>
Historic & archaeological resources	As described in Sections 4.9.6 and 4.11.8, the continued operation of STP during the license renewal term would not incrementally contribute to the cumulative impacts on historic and archaeological resources within STP and in the surrounding area. Therefore, the cumulative impacts on historic and archaeological resources during the license renewal term would be SMALL.

1 **4.12 References**

- 2 10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, “Standards for
3 protection against radiation.”
- 4 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic licensing of
5 production and utilization facilities.”
- 6 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
7 protection regulations for domestic licensing and related regulatory functions.”
- 8 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for
9 renewal of operating licenses for nuclear power plants.”
- 10 36 CFR Part 60. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,
11 *Part 60*, “National register of historic places.”

Environmental Impacts of Operation

- 1 36 CFR Part 800. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,
2 Part 800, “Protection of historic properties.”
- 3 40 CFR Part 141. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 141,
4 “National primary drinking water regulations.”
- 5 40 CFR Part 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190,
6 “Environmental radiation protection standards for nuclear power operations.”
- 7 59 FR 7629. Executive Order 12898. Federal actions to address environmental justice in
8 minority populations and low-income populations. *Federal Register* 59(32):7629–7634.
9 February 16, 1994.
- 10 66 FR 65274. U.S. Environmental Protection Agency. National pollutant discharge elimination
11 system: regulations addressing cooling water intake structures for new facilities; final rule.
12 *Federal Register*. December 18, 2001.
- 13 69 FR 41576. U.S. Environmental Protection Agency. National pollutant discharge elimination
14 system—final regulations to establish requirements for cooling water intake structures at phase
15 ii existing facilities; final rule. *Federal Register*. July 9, 2004.
- 16 69 FR 52040. U.S. Nuclear Regulatory Commission. Policy statement on the treatment of
17 environmental justice matters in NRC regulatory and licensing actions. *Federal Register*.
18 69(163):52040–52048. August 24, 2004.
- 19 76 FR 22174. U.S. Environmental Protection Agency. National pollutant discharge elimination
20 system—cooling water intake structures at existing facilities and Phase I facilities.
21 *Federal Register*. April 20, 2011.
- 22 [AEC] U.S. Atomic Energy Commission. 1975. *Final Environmental Statement Related to*
23 *Operation of South Texas Project, Units 1 and 2. Houston Lighting & Power Company, City*
24 *Public Service Board of San Antonio, Central Power and Light Company, City of Austin, Docket*
25 *Nos. 50-498 and 50-499*. Washington, DC: Directorate of Licensing. March 1975. ADAMS
26 No. ML11172A200.
- 27 [CAPS] Missouri Census Data Center Circular Area Profiling System. Version 10C. Using Data
28 from Summary File 1, 2010 Census Summary of Census Tracts in a 50-mi radius around the
29 South Texas Project (28.97 Lat., -96.04Long.). March 2012.
- 30 [CEQ] Council on Environmental Quality. 1997. “*Environmental Justice: Guidance Under the*
31 *National Environmental Policy Act*.” December 10, 1997. Available at
32 <http://www.epa.gov/compliance/ej/resources/policy/ej_guidance_nepa_ceq1297.pdf>
33 (accessed on April 6, 2012). ADAMS No. ML082520150.
- 34 Chemicals Inc. 2011. “Growing in Matagorda County.” Available at
35 <<http://www.chemicalsinc.com/Bay%20City%20Fact%20Sheet%20Rev.pdf>> (accessed
36 27 September 2011).
- 37 City of Corpus Christi. 2009. *Garwood Pipeline Project, Project Update 2009*. Corpus Christi,
38 TX: Water Department. October 2, 2009. Available at
39 <<http://www.cctexas.com/files/g17/GarwoodCouncilPresentation100209.pdf>> (accessed
40 31 August 2011).
- 41 City of Corpus Christi. 2011. *Lake Texana & Mary Rhodes Pipeline II*. Corpus Christi, TX:
42 Water Department. Available at
43 <<http://cctexas.com/water/resources/MaryRhodesPipeline.html>> (accessed 21 October 2011).

- 1 [USACE] U.S. Army Corps of Engineers. 2005. *Galveston District Projects, Mouth of the*
2 *Colorado River*. Galveston, TX: U.S. Army Corps of Engineers, Galveston District. Available at
3 <<http://www.swg/usace.army.mil/items/coloradoriver/MOC/asp>> (accessed 16 December 2009).
4 ADAMS No. ML100601372.
- 5 [CPGCD] Coastal Plains Groundwater Conservation District. 2010. *Rules of the Coastal Plains*
6 *Groundwater Conservation District*. Bay City, TX: CPGCD. February 4, 2010. Available at
7 <<http://www.coastalplainsgcd.com/>> (accessed 21 October 2011).
- 8 [CPGCD] Coastal Plains Groundwater Conservation District. 2011. *Operating Permit, Permit*
9 *No. OP-04122805*. Bay City, TX: CPGCD. February 24, 2011. ADAMS No. ML11256A058.
- 10 Diamond DD, Smeins FE. 1984. Remnant grassland vegetation and ecological affinities of the
11 upper coastal prairie of Texas. *Southwestern Naturalist* 29(3):321–334.
- 12 Edward E. Johnson, Inc. 1966. *Ground Water and Wells, A Reference Book for the Water-Well*
13 *Industry*. Saint Paul, MN: Edward E. Johnson, Inc.
- 14 [ENSR] ENSR Corporation. 2008a. *Aquatic Ecology—Main Cooling Reservoir and Circulating*
15 *Water Intake Structure Study, Unit 3 and 4 Licensing Project*. Houston, TX. ADAMS
16 No. ML090860875.
- 17 [ENSR] ENSR Corporation. 2008b. *Aquatic Ecology—Colorado River Monitoring Report,*
18 *Unit 3 and 4 Licensing Project*. Houston, TX. ADAMS No. ML081750196.
- 19 [EPA] Environmental Protection Agency. 1977. *Guidance for Evaluating the Adverse Impact of*
20 *Cooling Water Intake Structures on Aquatic Environment*. Washington, DC: Office of Water
21 *Enforcement, Permits Division. Section 316(b). May 1, 1977. 408 p.*
- 22 [EPA] Environmental Protection Agency. 1985. *Authorization to Discharge Under the National*
23 *Pollutant Discharge Elimination System*. Permit No. TX0064947.
- 24 [EPA] Environmental Protection Agency. 1998. *Guidelines for Ecological Risk Assessment*.
25 Washington, DC: Risk Assessment Forum. EPA/630/R-95/002F.
- 26 [EPA] Environmental Protection Agency. 1999. *Consideration of Cumulative Impacts in EPA*
27 *Review of NEPA Documents*. Washington, DC: Office of Federal Activities (2252A).
28 EPA-315-R-99-002.
- 29 [FWS] U.S. Fish and Wildlife Service. 2011. Letter from AM Strand, Field Supervisor, to
30 T Tran, Project Manager, NRC. Subject: Reply to request for species list for South Texas
31 license renewal review. June 2, 2011. ADAMS No. ML11173A241.
- 32 Gulf of Mexico Fishery Management Council (GMFMC). 2004. *Final Environmental Impact*
33 *Statement for the Generic Amendment to the Following Fishery Management Plans of the Gulf*
34 *of Mexico: Shrimp Fishery of the Gulf of Mexico, Red Drum Fishery of the Gulf of Mexico, Reef*
35 *Fish Fishery of the Gulf of Mexico, Stone Crab Fishery of the Gulf of Mexico, Coral and Coral*
36 *Reef Fishery of the Gulf of Mexico, Spiny Lobster Fishery of the Gulf of Mexico and South*
37 *Atlantic; Coastal Migratory Pelagic Resources of the Gulf of Mexico and South Atlantic*. Tampa,
38 FL.
- 39 Institute of Electrical and Electronics Engineers, Inc. (IEEE). 2002. National Electrical Safety
40 Code.
- 41 Intergovernmental Panel on Climate Change (IPCC). 2010. "IPCC Fourth Assessment Report:
42 Working Group II Report—Impacts, Adaptation and Vulnerability." Available at
43 <<http://www.ipcc.ch/ipccreports/ar4-wg2.htm>> (accessed April 2012).

Environmental Impacts of Operation

- 1 Karl, TR, et al., eds., *Global Climate Change Impacts in the United States*, New York, NY: U.S.
2 Global Change Research Program, Cambridge University Press. Available at
3 <<http://downloads.globalchange.gov/usimpacts/pdfs/climate-impacts-report.pdf>>. ADAMS
4 No. ML100580077.
- 5 [LCRA] Lower Colorado River Authority. 2008. *Water Supply Resource Plan: Water Demand*
6 *Projections for Municipal and Industrial Needs*. Austin, TX. Available at
7 <<http://www.lcra.org/library/media/public/docs/water/wsrp/WSRPDecember2008report.pdf>>
8 (accessed 13 June 2011).
- 9 [LCRA et al.] Lower Colorado River Authority (LCRA), Texas Commission on Environmental
10 Quality (TCEQ), Texas Parks and Wildlife (TPWD), and Texas Water Development Board
11 (TWDB). 2006. *Matagorda Bay Freshwater Inflow Needs Study. August 2006*. Available at
12 <http://www.lcra.org/library/media/public/docs/water/wmp/FINS_Final_Report.pdf> (accessed
13 31 August 2011).
- 14 [LCRA–SAWS] Lower Colorado River Authority and San Antonio Water System. 2009.
15 “Colorado River Flow Relationships to Aquatic Habitat and State Threatened Species: Blue
16 Sucker.” Available at
17 <http://www.lcra.org/library/media/public/docs/lswp/scopes/BIO_AH_2009_Scope.pdf>
18 (accessed 12 September 2011).
- 19 [LCRWPG] Lower Colorado River Water Planning Group. 2010. *2011 Region K Water Plan*.
20 Prepared for Texas Water Development Board. July 2010. Available at
21 <http://www.twdb.state.tx.us/wrpi/rwp/3rdRound/2011_RWP/RegionK/> (accessed
22 31 August 2011).
- 23 [MACTEC] MACTEC Engineering and Consulting, Inc. 2009. *Conceptual Site Model for Units 1*
24 *and 2, Groundwater Protection Initiative, South Texas Project Electric Generating Station*.
25 *Wadsworth, TX: MACTEC Engineering and Consulting, Inc. Revision 1. May 20, 2009.*
26 ADAMS No. ML11256A058.
- 27 McAden DC, Greene GN, Baker, WB. 1984. *Colorado River Entrainment and Impingement*
28 *Monitoring Program, Phase Two Studies*. Ecology Division, Environmental Protection
29 Department, Houston Lighting & Power Company. Report 1. October 1984. ADAMS
30 No. ML11256A057.
- 31 McAden DC, Greene GN, Baker WB. 1985. *Colorado River Entrainment and Impingement*
32 *Monitoring Program, Phase Two Studies*. Ecology Division, Environmental Protection
33 Department, Houston Lighting & Power Company. Report 2. April 1985. ADAMS
34 No. ML11256A057.
- 35 [MCEDC] Matagorda County Economic Development Corporation. 2011. “Matagorda County
36 Project Status Updates for 19-Sept-2011.” Available at
37 <<http://www.mcedc.net/news.php?op=view&id=155>> (accessed 27 September 2011).
- 38 Menzie C, Henning MH, Cura J, Finkelstein K, Gentile J, Maughan J, Mitchell D, Petron S,
39 Potocki B, Svirsky S, Tyler P. 1996. Report of the Massachusetts Weight-of-Evidence
40 Workshop: A weight-of-evidence approach for evaluating ecological risks. *Human and*
41 *Ecological Risk Assessment* 2:227–304.
- 42 Montagna PA, Brenner J, Gibeaut J, Morehead S. 1995. Coastal Impacts. In: North GR,
43 Schmandt J, Clarkson J, editors. *The Impact of Global Warming on Texas*. Austin, TX:
44 University of Texas Press.

- 1 National Environmental Policy Act of 1969, as amended. 42 U.S.C. §4321, et seq.
- 2 National Historic Preservation Act of 1966, as amended. 16 U.S.C. §470, et seq.
- 3 [NEI] Nuclear Energy Institute. 2007. *Industry Groundwater Protection Initiative—Final*
 4 *Guidance Document*. Washington, DC: NEI. NEI 07-07. August 2007. ADAMS
 5 No. ML072600290.
- 6 [NIEHS] National Institute of Environmental Health Sciences. 1999. *NIEHS Report on Health*
 7 *Effects from Exposure to Power-Line Frequency Electric and Magnetic Fields*. Triangle Park,
 8 NC: NIEHS. Publication No. 99-4493. 80 p. Available at
 9 <<http://www.niehs.nih.gov/about/materials/niehsreport.pdf>>.
- 10 Nielsen-Gammon, JW. 1995. The Changing Climate of Texas. In: North GR, Schmandt J,
 11 Clarkson J, editors. *The Impact of Global Warming on Texas*. Austin, TX: University of Texas
 12 Press.
- 13 [NMFS] National Marine Fisheries Service. 2010. Letter from M Croom, Assistant Regional
 14 Administrator for Habitat Conservation, to Johnson, Rulemaking and Directives Branch Chief,
 15 NRC. Subject: Concurrence with EFH assessment for STP, Units 3 and 4. ADAMS
 16 No. ML101190379.
- 17 [NMFS] National Marine Fisheries Service. 2011. E-mail from T. Mincey, Program Analyst, to
 18 T. Tran, Project Manager, NRC. Subject: South Texas Project Federally listed species. March
 19 3, 2011. ADAMS No. ML110690848.
- 20 [NRC] U.S. Nuclear Regulatory Commission. 1975. *Final Environmental Statement Related to*
 21 *the Proposed South Texas Project, Units 1 and 2*. Washington, DC: NRC. NUREG-75/019.
- 22 [NRC] U.S. Nuclear Regulatory Commission. 1986. *Final Environmental Statement Related to*
 23 *the Operation of South Texas Project, Units 1 and 2*. Washington, DC: NRC. NUREG-1171.
- 24 [NRC] U.S. Nuclear Regulatory Commission. 1996. *Generic Environmental Impact Statement*
 25 *for License Renewal of Nuclear Plants*. Washington, DC: NRC. NUREG-1437. May 1996.
 26 ADAMS Nos. ML040690705 and ML040690738.
- 27 [NRC] U.S. Nuclear Regulatory Commission. 1999. Section 6.3—Transportation, Table 9.1,
 28 Summary of findings on NEPA issues for license renewal of nuclear power plants. In: *Generic*
 29 *Environmental Impact Statement for License Renewal of Nuclear Plants*. Washington, DC:
 30 NRC. NUREG-1437, Volume 1, Addendum 1. August 1999. ADAMS No. ML04069720.
- 31 [NRC] U.S. Nuclear Regulatory Commission. 2010. *Final Supplemental Environmental Impact*
 32 *Statement Regarding Indian Point Generating, Units 2 and 3*. Washington, DC: Office of
 33 Nuclear Reactor Regulation. NUREG-1437, Supplement 38.
- 34 [NRC] U.S. Nuclear Regulatory Commission. 2011a. E-mail from B Martin, THC, to TK O’Neil,
 35 PNNL. Subject: STP license renewal—SHPO meeting. May 2, 2011. ADAMS
 36 No. ML11259A029.
- 37 [NRC] U.S. Nuclear Regulatory Commission. 2011b. *Environmental Impact Statement for*
 38 *Combined Licenses (COLs) for South Texas Project Electric Generating Station, Units 3 and 4*.
 39 Washington, DC: NRC. NUREG-1937, Volumes 1 and 2. ADAMS Nos. ML11049A000 and
 40 ML11049A001.
- 41 [NRC] U.S. Nuclear Regulatory Commission. 2011c. *Essential Fish Habitat Assessment for*
 42 *South Texas Project Electric Generating Station, Units 3 and 4*. Washington, DC: NRC. Final
 43 Report. ADAMS No. ML11049A001.

Environmental Impacts of Operation

- 1 [NRC] U.S. Nuclear Regulatory Commission. 2011d. Letter from BM Pham, NRC, to DL Klima,
2 Advisory Council on Historic Preservation. Subject: South Texas Project, Units 1 and 2, license
3 renewal application review. January 27, 2011. ADAMS No. ML110200002.
- 4 [NRC] U.S. Nuclear Regulatory Commission. 2011e. Letter from BM Pham, NRC, to M Wolfe,
5 Texas Historical Commission. Subject: South Texas Project, Units 1 and 2, license renewal
6 application review. February 17, 2011. ADAMS No. ML110190549.
- 7 [NRC] U.S. Nuclear Regulatory Commission. 2011f. Letter from D Wrona, Branch Chief, to M
8 Orms, FWS. Subject: Request for concurrence on list of Federally protected species.
9 February 16, 2011. ADAMS No. ML110190429.
- 10 [NRC] U.S. Nuclear Regulatory Commission. 2011g. Letter from T Tran, NRC, to GT Powell,
11 STPNOC. Subject: Audit report regarding South Texas Project license renewal application—
12 cultural resources. July 18, 2011. ADAMS No. ML11173A304.
- 13 [NRC] U.S. Nuclear Regulatory Commission. 2011h. Letter from B. Pham, Branch Chief, NRC,
14 to D. Bernhart, Assistant Southeast Regional Administrator for Protected Resources, NMFS.
15 Subject: Request for list of Federally protected species and important habitats within the area
16 under evaluation for the South Texas Project, Units 1 and 2, license renewal application review.
17 February 16, 2011. ADAMS No. ML110190434.
- 18 [NRC] U.S. Nuclear Regulatory Commission (NRC). 2011i. Draft Supplemental Environmental
19 Impact Statement Regarding Seabrook Station. NUREG-1437, Supplement 46. Office of
20 Nuclear Reactor Regulation. Washington, DC. July 31, 2011. ADAMS No. ML11213A024.
- 21 [NRC] U.S. Nuclear Regulatory Commission. 2012. E-mail from T. Tran, Project Manager,
22 NRC, to L. Gaul, PhD, MPH, Epidemiologist, Emerging and Acute Infectious Diseases Branch,
23 TDSHS. Subject: NEPA consultation, waterborne outbreak. May 4, 2012. ADAMS No.
24 ML12128A061.
- 25 Ryder PD, Ardis AF. 2002. *Hydrology of the Texas Gulf Coast Aquifer Systems, Regional*
26 *Aquifer-Systems Analysis-Gulf Coast Plain*. Reston, VA: U.S. Geological Survey. U.S.
27 Geological Survey Professional Paper 1416-E.
- 28 [STPNOC] South Texas Project Nuclear Operating Company. 2007a. *South Texas Project,*
29 *Units 1 and 2. 2006 Annual Environmental and Annual Radiological Environmental Operating*
30 *Reports*. Wadsworth, TX. ADAMS No. ML071270211.
- 31 [STPNOC] South Texas Project Nuclear Operating Company. 2007b. *South Texas Project,*
32 *Units 1 and 2. Radioactive Effluent Release Report for 2006*. Wadsworth, Texas. ADAMS
33 No. ML071280681.
- 34 [STPNOC] South Texas Project Nuclear Operating Company. 2008a. Letter from G Gibson,
35 STPNOC, to NRC Document Control Desk. Subject: Response to RAIs. July 15, 2008.
36 ADAMS No. ML082040684.
- 37 [STPNOC] South Texas Project Nuclear Operating Company. 2008b. Letter from G Gibson,
38 STPNOC, to NRC Document Control Desk. Subject: South Texas Project, Units 3 and 4,
39 Docket Nos. 52-012 and 52-013, Response to RAIs. July 2, 2008. ADAMS No. ML081970465.
- 40 [STPNOC] South Texas Project Nuclear Operating Company. 2008c. Letter from S Head,
41 STPNOC, to NRC Document Control Desk. Subject: Response to RAIs. December 18, 2008.
42 ADAMS No. ML090860873.

- 1 [STPNOC] South Texas Project Nuclear Operating Company. 2008d. *South Texas Project,*
2 *Units 1 and 2. 2007 Annual Environmental and Annual Radiological Environmental Operating*
3 *Reports.* Wadsworth, TX. ADAMS No. ML081280093.
- 4 [STPNOC] South Texas Project Nuclear Operating Company (STPNOC). 2008e. *South Texas*
5 *Project, Units 1 and 2. Radioactive Effluent Release Report for 2007.* Wadsworth, TX. ADAMS
6 No. ML081300023.
- 7 [STPNOC] South Texas Project Nuclear Operating Company. 2009a. *South Texas Project,*
8 *Units 1 and 2. 2008 Annual Environmental and Annual Radiological Environmental Operating*
9 *Reports.* Wadsworth, TX. ADAMS No. ML091310066.
- 10 [STPNOC] South Texas Project Nuclear Operating Company. 2009b. *South Texas Project,*
11 *Units 1 and 2. Radioactive Effluent Release Report for 2008.* Wadsworth, TX. ADAMS
12 No. ML091200487.
- 13 [STPNOC] South Texas Project Nuclear Operating Company. 2009c. *Updated Final Safety*
14 *Analysis Report Units 1 and 2.* Bay City, TX: STPEGS. Revision 15. April 29, 2010. ADAMS
15 No. ML103220222.
- 16 [STPNOC] South Texas Project Nuclear Operating Company. 2009d. *Water Conservation*
17 *Plan, STP Nuclear Operating Company, South Texas Project Electric Generating Station,*
18 *Certificate of Adjudication 14-5437 A.* Revision 2. May 1, 2009. ADAMS No. ML11256A058.
- 19 [STPNOC] South Texas Project Nuclear Operating Company. 2010a. *South Texas Project,*
20 *Units 1 and 2. 2009 Annual Environmental and Annual Radiological Environmental Operating*
21 *Reports.* Wadsworth, TX. ADAMS No. ML101260530.
- 22 [STPNOC] South Texas Project Nuclear Operating Company. 2010b. *South Texas Project,*
23 *Units 1 and 2, License Renewal Application.* Bay City, TX: STPNOC. "Environmental Report."
24 September 2010. ADAMS No. ML103010263.
- 25 [STPNOC] South Texas Project Nuclear Operating Company. 2010c. *South Texas Project,*
26 *Units 3 and 4, License Renewal Application.* Bay City, TX: STPNOC. Part 3, "Environmental
27 Report." Revision 4. ADAMS No. ML102860592.
- 28 [STPNOC] South Texas Project Nuclear Operating Company. 2010d. *South Texas Project,*
29 *Units 1 and 2. Radioactive Effluent Release Report for 2009.* Wadsworth, TX. ADAMS
30 No. ML101090091.
- 31 [STPNOC] South Texas Project Nuclear Operating Company. 2011a. *South Texas Project,*
32 *Units 1 and 2. 2010 Annual Environmental and Annual Radiological Environmental Operating*
33 *Reports.* Wadsworth, TX. ADAMS No. ML111250429.
- 34 [STPNOC] South Texas Project Nuclear Operating Company. 2011b. Letter from AW Harrison,
35 Manager Licensing, to NRC Document Control Desk. Subject: Transmittal of documents to
36 support review of the STP LRA. TAC Nos. ME 4938 and ME 5122. STP Letter No.
37 NOC-AE-11002720. August 31, 2011. ADAMS Nos. ML11256A056 and ML11256A059.
- 38 [STPNOC] South Texas Project Nuclear Operating Company. 2011c. Letter from G.T. Powell,
39 Vice President, STPNOC, to NRC Document Control Desk. Subject: Response to RAI for the
40 STP LRA. TAC Nos. ME4938 and ME5122. STP Letter No. NOC-AE-11002719.
41 September 6, 2011. ADAMS No. ML11255A211.
- 42 [STPNOC] South Texas Project Nuclear Operating Company. 2011d. *South Texas Project,*
43 *Units 1 and 2. Radioactive Effluent Release Report for 2010.* Wadsworth, TX. ADAMS
44 No. ML11124A121.

Environmental Impacts of Operation

- 1 [STPNOC] South Texas Project Nuclear Operating Company. 2011e. Letter from GT Powell,
2 Vice President, STPNOC, to U.S. Nuclear Regulatory Commission, Document Control Desk.
3 Subject: Response to RAI for the STP LRA. TAC Nos. ME4938 and ME5122. STP Letter No.
4 NOC-AE-11002723. September 12, 2011. ADAMS No. ML11259A014.
- 5 [STPNOC] South Texas Project Nuclear Operating Company. 2011f. Letter from D.W.
6 Rencurrel, Senior Vice President, STPNOC, to U.S. Nuclear Regulatory Commission,
7 Document Control Desk. Subject: Response to Requests for Additional Information for the
8 South Texas Project License Renewal Application (TAC Nos. ME4938 and ME5122) (STP
9 Letter Number NOC-AE-1002761). November 17, 2011. ADAMS No. ML11333A094.
- 10 [STPNOC] South Texas Project Nuclear Operating Company. 2011g. Letter from G.T. Powell,
11 Vice President, STPNOC, to U.S. Nuclear Regulatory Commission, Document Control Desk.
12 Subject: Response to Requests for Additional Information for the South Texas Project License
13 Renewal Application (TAC Nos. ME4938 and ME5122) (STP Letter Number NOC-AE-1
14 1002691). July 5, 2011. ADAMS No. ML11193A074.
- 15 [TCEQ] Texas Commission on Environmental Quality. 2005. TPDES Permit
16 No. WQ0001908000. Austin, TX.
- 17 [TCEQ] Texas Commission on Environmental Quality. 2007. Letter from K Holligan, TCEQ, to
18 RA Gangluff, STPNOC. Subject: Cooling water intake structures Phase II rules; South Texas
19 Project Electric Generating Station, TPDES Permit No. WQ000 1908000. June 27, 2007.
20 ADAMS No. ML 11256A057.
- 21 [TCEQ] Texas Commission on Environmental Quality. 2009. *Amendment to Certificate of*
22 *Adjudication, Certificate of Adjudication 14-5437 A*. March 17, 2009. ADAMS
23 No. ML11256A058.
- 24 [TDSHS] Texas Department of State Health Services. "Radiation Branch Environmental
25 Monitoring Summary Reports." Available at
26 <<http://www.dshs.state.tx.us/radiation/publications.shtm>>.
- 27 Texas Water Code, Title 2, *Water Administration*, Subtitle B, "Water Rights," Chapter 11, "Water
28 Rights." Available at <<http://www.statutes.legis.state.tx.us/Docs/WA/htm/WA.11.htm>>.
- 29 [TPWD] Texas Parks and Wildlife Department. 2002. *Executive Summary: The Texas Shrimp*
30 *Fishery. A report to the Governor and the 77th Legislature of Texas*. Texas Parks and Wildlife
31 Department. September 2002.
- 32 [TPWD] Texas Parks and Wildlife Department. 2005. *Land and Water Resources Conservation*
33 *and Recreation Plan*. Austin, TX: TPWD. 137 p. Available at
34 <http://www.tpwd.state.tx.us/publications/pwdpubs/pwd_pl_e0100_0867/> (accessed
35 26 September 2011).
- 36 [TPWD] Texas Parks and Wildlife Department. 2010. "Prairie Pothole and Marsh Wetlands."
37 Available at <<http://www.texaswetlands.org/prairie.htm>> (accessed 26 September 2011).
- 38 [TWDB] Texas Water Development Board. 2006. *Water for Texas—2007*. Austin, TX: TWDB.
39 Volume II. Available at
40 <[http://www.twdb.state.tx.us/publications/reports/State_Water_Plan/2007/2007StateWaterPlan/
41 CHAPTER%202_REGIONAL%20K%20FINAL%20112706.pdf](http://www.twdb.state.tx.us/publications/reports/State_Water_Plan/2007/2007StateWaterPlan/CHAPTER%202_REGIONAL%20K%20FINAL%20112706.pdf)> (accessed 13 June 2011).
- 42 [TWDB] Texas Water Development Board. 2007. *State Water Plan—Water for Texas 2007*.
43 Austin, TX: TWDB. Document No. GP-8-1. Volume 1. January 2007. Available at
44 <<http://www.twdb.state.tx.us/wrpi/swp/swp.asp>> (accessed 31 August 2011).

- 1 [TWDB] Texas Water Development Board. 2011. "Water Resources Planning and
2 Information, 2012 Draft State Water Plan & Public Comments." Available at
3 <<http://www.twdb.state.tx.us/wrpi/swp/draft.asp>> (accessed 21 October 2011).
- 4 [USCB] U.S. Census Bureau. 2010. "*American FactFinder, Census 2000 and 2007–2009,*
5 *3-Year Estimate, American Community Survey.* State and County QuickFacts on Lucas,
6 Ottawa, Sandusky and Wood Counties, Ohio. Housing Characteristics for 2000 and 2006–
7 2008, 3-Year Estimate." Available at <<http://factfinder.census.gov>> and
8 <<http://quickfacts.census.gov>> (accessed April 2011).
- 9 [USCB] U.S. Census Bureau. 2011. "American FactFinder, 2006–2010 American Community
10 Survey 5-year estimates and Data Profile Highlights information on Brazoria, Calhoun, Fort
11 Bend, Jackson, Matagorda, Victoria, and Wharton Counties and State of Texas." Available at
12 <<http://factfinder.census.gov> and <http://quickfacts.census.gov>> (accessed March 2012).
- 13 [USGCRP] U.S. Global Research Program. 2009. *Global Climate Change Impacts in the*
14 *United States.* New York, NY: Cambridge University Press. Available at
15 <<http://downloads.globalchange.gov/usimpacts/pdfs/climate-impacts-report.pdf>> (accessed
16 31 August 2011).
- 17 Wilber D.H. and R. Bass. 1998. "Effect of the Colorado River Diversion on Matagorda Bay
18 Epifauna." *Estuarine, Coastal and Shelf Science* (1998) 47:309–318.

5.0 ENVIRONMENTAL IMPACTS OF POSTULATED ACCIDENTS

This chapter describes the environmental impacts from postulated accidents that might occur during the period of extended operation. The term “accident” refers to any unintentional event outside normal plant operations that results in a release, or the potential for a release, of radioactive materials into the environment. Two classes of postulated accidents are evaluated in the generic environmental impact statement (GEIS)—design-basis accidents (DBAs) and severe accidents (Table 5–1).

Table 5–1. Issues Related to Postulated Accidents

Two issues related to postulated accidents are evaluated under the National Environmental Protection Act (NEPA) in the license renewal review—DBAs and severe accidents.

Issues	Category
DBAs	1
Severe accidents	2

5.1 Design Basis Accidents

In order to receive U.S. Nuclear Regulatory Commission (NRC) approval to operate a nuclear power facility, an applicant for an initial operating license must submit a safety analysis report (SAR) as part of its application. The SAR presents the design criteria and design information for the proposed reactor and comprehensive data on the proposed site. The SAR also discusses various hypothetical accident situations and the safety features that are provided to prevent and mitigate accidents. The NRC staff (staff) reviews the application to determine if the plant design meets the NRC’s regulations and requirements and includes, in part, the nuclear plant design and its anticipated response to an accident.

DBAs are those accidents that both the applicant and the staff evaluate to ensure that the plant can withstand normal and abnormal transients and a broad spectrum of postulated accidents, without undue hazard to the health and safety of the public. Many of these postulated accidents are not expected to occur during the life of the plant but are evaluated to establish the design basis for the preventive and mitigative safety systems of the nuclear power plant. The acceptance criteria for DBAs are described in Title 10 of the *Code of Federal Regulations* (CFR) Part 50 (10 CFR Part 50) and 10 CFR Part 100.

The environmental impacts of DBAs are evaluated during the initial licensing process, and the ability of the plant to withstand these accidents is demonstrated to be acceptable before issuance of the operating license. The results of these evaluations are found in applicant documentation such as the applicant’s final safety analysis report (FSAR), the staff’s safety evaluation report (SER), the final environmental statement (FES), and Section 5.1 of this supplemental environmental impact statement (SEIS). An applicant is required to maintain the acceptable design and performance criteria throughout the life of the nuclear power plant, including the period of extended operation. The consequences for these events are evaluated for the hypothetical maximum exposed individual; as such, changes in the plant environment will not affect these evaluations. Because of the requirements that continuous acceptability of the consequences and aging management programs (AMPs) be in effect for the period of extended operation, the environmental impacts, as calculated for DBAs, should not differ significantly from initial licensing assessments over the life of the plant, including the period of extended operation. Accordingly, the design of the plant, relative to DBAs during the period of extended

Environmental Impacts of Postulated Accidents

1 operation, is considered to remain acceptable; therefore, the environmental impacts of those
2 accidents were not examined further in the GEIS.

3 The Commission has determined that the environmental impacts of DBAs are of SMALL
4 significance for all nuclear power plants because the plants were designed to successfully
5 withstand these accidents. Therefore, for the purposes of license renewal, DBAs are
6 designated as a Category 1 issue. The early resolution of the DBAs (i.e., successfully withstand
7 these accidents) makes them a part of the current licensing basis (CLB) of the plant. The CLB
8 of the plant is to be maintained by the applicant under its current license; therefore, in
9 accordance with 10 CFR 54.30, it is not subject to review under license renewal.

10 No new and significant information related to the South Texas Project (STP) was identified
11 during the review of the South Texas Project Nuclear Operating Company, LLC (STPNOC)
12 Environmental Report (ER) (STPNOC 2010), site audit (NRC 2011), the scoping process
13 (NRC 2012), or evaluation of other available information. Therefore, there are no impacts
14 related to these issues beyond those discussed in the GEIS.

15 **5.2 Severe Accidents**

16 Severe nuclear accidents are those that are more severe than DBAs because they could result
17 in substantial damage to the reactor core, whether or not there are serious offsite
18 consequences. In the GEIS, the staff assessed the impacts of severe accidents during the
19 period of extended operation, using the results of existing analyses and site-specific information
20 to conservatively predict the environmental impacts of severe accidents for each plant during
21 the period of extended operation.

22 Severe accidents initiated by external phenomena (e.g., tornadoes, floods, earthquakes, fires,
23 and sabotage) have not traditionally been discussed in quantitative terms in FESs and were not
24 specifically considered for the STP site in the GEIS (NRC 1996). However, the GEIS did
25 evaluate existing impact assessments, including beyond design basis earthquakes, at existing
26 plants—performed by NRC and by the industry at 44 nuclear plants in the U.S. In addition, the
27 GEIS for license renewal performed a discretionary analysis of sabotages of plant systems in
28 connection with license renewal. In the GEIS, the Commission concludes that the risk from
29 sabotage and beyond design-basis earthquakes at existing plants is small and that the risks
30 from other external events are adequately addressed by a generic consideration of internally
31 initiated severe accidents (NRC 1996).

32 Based on information in the GEIS, the Commission found that:

33 The probability weighted consequences of atmospheric releases, fallout onto
34 open bodies of water, releases to groundwater, and societal and economic
35 impacts from severe accidents are small for all plants. However, alternatives to
36 mitigate severe accidents must be considered for all plants that have not
37 considered such alternatives.

38 The staff identified no new and significant information related to postulated accidents (DBAs and
39 severe accidents) during the review of the STP ER (STPNOC 2010), site audit (NRC 2011), the
40 scoping process (NRC 2012), or evaluation of other available information. Therefore, there are
41 no impacts related to these issues beyond those discussed in the GEIS. However, in
42 accordance with 10 CFR 51.53(c)(3)(ii)(L), the staff has reviewed severe accident mitigation
43 alternatives (SAMAs) for STP. The results of the review are discussed in Section 5.3.

1 **5.3 Severe Accident Mitigation Alternatives**

2 Section 10 CFR 51.53(c)(3)(ii)(L) requires that license renewal applicants consider alternatives
3 to mitigate severe accidents if the staff has not previously evaluated SAMAs for the applicant's
4 plant in an environmental impact statement (EIS) or related supplement or in an environmental
5 assessment. The purpose of this consideration is to ensure that plant changes (e.g., hardware,
6 procedures, and training) with the potential for improving severe accident safety performance
7 are identified and evaluated. SAMAs have not been previously considered for STP; therefore,
8 the remainder of Chapter 5 addresses those alternatives.

9 **5.3.1 Overview of Severe Accident Mitigation Alternative Process**

10 This section presents a summary of the SAMA evaluation for STP conducted by STPNOC, and
11 the staff's review of that evaluation. The staff performed its review with contract assistance from
12 Pacific Northwest National Laboratory. The staff's review is available in full in Appendix F of this
13 SEIS, and the STPNOC's SAMA evaluation is available in full in Attachment F of STPNOC's ER
14 (LRA Appendix E).

15 STPNOC conducted the SAMA evaluation for STP with a four-step approach. In the first step,
16 STPNOC quantified the level of risk associated with potential reactor accidents using the plant-
17 specific probabilistic risk assessment (PRA) and other risk models.

18 In the second step, STPNOC examined the major risk contributors and identified possible ways
19 (SAMAs) of reducing that risk. Common ways of reducing risk are changes to components,
20 systems, procedures, and training.

21 In the third step, STPNOC estimated the benefits and the costs associated with each of the
22 candidate SAMAs. Estimates were made of how much each SAMA could reduce risk. Those
23 estimates were developed in terms of dollars, in accordance with NRC guidance for performing
24 regulatory analyses. STPNOC also estimated the costs of implementing the candidate SAMAs.

25 Finally, in the fourth step, STPNOC compared the cost and benefit of each of the remaining
26 SAMAs to determine whether the SAMA was cost beneficial, meaning the benefits of the SAMA
27 were greater than the cost (a positive cost benefit).

28 **5.3.2 Estimate of Risk**

29 STPNOC submitted an assessment of SAMAs for STP as part of the ER (STPNOC 2010). This
30 assessment was based on the most recent STP PRA available at that time, a plant-specific
31 offsite consequence analysis performed using the MELCOR Accident Consequence Code
32 System 2 (MACCS2) computer code, and insights from the STP individual plant examination
33 (IPE) and individual plant examination of external events (IPEEE) (HL&P 1992).

34 Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA
35 analysis. The first is the STP Level 1 and Level 2 PRA model, which is an updated version of
36 the IPE (HL&P 1992) which, in turn, was an update of the earlier model completed for the
37 purpose of supporting changes in certain STP technical specifications (NRC 1994). The second
38 is a supplemental analysis of offsite consequences and economic impacts (essentially a Level 3
39 PRA model) developed specifically for the SAMA analysis. The SAMA analysis is based on the
40 most recent STP Level 1 and Level 2 PRA model available at the time of the ER, referred to as
41 the STP_REV6 model. The scope of the Level 1 model includes internal and external initiating
42 events.

Environmental Impacts of Postulated Accidents

- 1 The following results are based upon the STP model of record (STP_REV6), as presented in
2 the ER (STPNOC 2010). The impact of the sensitivity analysis to updated fire and seismic data
3 on the total core damage frequency (CDF) is provided in Appendix F, Sections F.2.2 (risk
4 estimates) and F.6.2 (cost-benefit evaluation) of this SEIS.
- 5 The STP CDF is approximately 6.4×10^{-6} per year for both internal and external events as
6 determined from quantification of the Level 1 PRA model. The CDF is based on the risk
7 assessment for internally initiated events, which includes internal flooding, and external events,
8 which includes fire, seismic events, external flooding, and tornado events. The internal events
9 CDF is approximately 3.9×10^{-6} per year, and the external events CDF is approximately 2.5×10^{-6}
10 per year. The external events CDF includes contributions of approximately 1.0×10^{-6} per year
11 due to fire events, 7.3×10^{-8} per year due to seismic events, and 1.4×10^{-6} per year due to other
12 external events (STPNOC 2010).
- 13 When determined from the sum of the containment event tree (CET) sequences, or Level 2
14 PRA model, the CDF is approximately 6.2×10^{-6} per year (within acceptable approximation) for
15 both internal and external events. The 6.2×10^{-6} value derived from the CET was used as the
16 baseline CDF in the SAMA evaluations (STPNOC 2010).
- 17 The breakdown of CDF by initiating event is provided in Table 5–2, Table 5–3, Table 5–4, and
18 Table 5–5 for internal, fire, seismic, and other external events, respectively (STPNOC 2011).
19

1

Table 5–2. STP Core Damage Frequency for Internal Events

Initiating event ^(a)	CDF (per year)	% Contribution to internal events to total CDF CDF^(b, c)	% Contribution to total CDF
Loss of all offsite power	9.6×10^{-7}	25	15
Loss of 345 kV offsite power	6.3×10^{-7}	16	10
Steam generator tube rupture (SGTR)	4.4×10^{-7}	11	7
Excessive loss-of-coolant accident (LOCA)	3.2×10^{-7}	8	5
Steam line break outside containment	2.8×10^{-7}	7	4
Loss of electrical auxiliary building heating, ventilation, and air conditioning (HVAC)	2.6×10^{-7}	7	4
Turbine trip	1.8×10^{-7}	5	3
Partial loss of main feedwater	1.5×10^{-7}	4	2
Reactor coolant pump (RCP) seal LOCA	1.5×10^{-7}	4	2
Interfacing system LOCA	1.3×10^{-7}	3	2
Loss of DC busses	9.7×10^{-8}	2	2
Small LOCAs	7.5×10^{-8}	2	1
Reactor trip	6.5×10^{-8}	2	1
Other internal events	3.6×10^{-7}	9	6
Total CDF (internal events)	3.9×10^{-6}	100	64

^(a) The impact of the sensitivity analysis to updated fire and seismic data on the total CDF is not included in these results. Section F.2.2 provides a discussion of these impacts.

^(b) Obtained from CDF given in ER Table F.2-1 (STPNOC 2010) divided by the total internal events CDF of 3.89×10^{-6} .

^(c) May not total to 100 percent due to round off.

2

Environmental Impacts of Postulated Accidents

1

Table 5–3. STP Core Damage Frequency for Fire Events

Fire initiator description ^(a)	CDF (per year)	% Contribution to fire CDF ^(b, c)	% Contribution to total CDF
Fire zone 047 scenario X	4.0×10^{-7}	39	6
Fire zone 071 scenario X	2.1×10^{-7}	21	3
Fire zone 047 scenario B	1.8×10^{-7}	18	3
Control room fire scenario 18	1.2×10^{-7}	12	2
Fire zone 047 scenario BC	6.4×10^{-8}	6	1
Control room fire scenario 23	2.6×10^{-8}	3	0.4
Fire zone 147 scenario O	1.1×10^{-8}	1	0.2
Control room fire scenario 10	1.0×10^{-9}	<1	<0.1
Total CDF (fire events)	1.0×10^{-6}	100	16

^(a) The impact of the sensitivity analysis to updated fire and seismic data on the total CDF is not included in these results. Section F.2.2 provides a discussion of these impacts.

^(b) Obtained from CDF given in ER Table F.2-1 (STPNOC 2010) divided by fire events CDF of 1.02×10^{-6} .

^(c) May not total to 100 percent due to round off.

2

Table 5–4. STP Core Damage Frequency for Seismic Events

Initiating event^(a)	CDF (per year)	% Contribution to seismic CDF ^(b, c)	% Contribution to total CDF
Seismic event, 0.4g acceleration	4.1×10^{-8}	55	0.6
Seismic event, 0.6g acceleration	2.1×10^{-8}	28	0.3
Seismic event, 0.2g acceleration	9.8×10^{-9}	13	0.2
Seismic event, 0.1g acceleration	2.1×10^{-9}	3	<0.1
Total CDF (seismic events)	7.3×10^{-8}	100	1.1

^(a) The impact of the sensitivity analysis to updated fire and seismic data on the total CDF is not included in these results. Section F.2.2 provides a discussion of these impacts.

^(b) Obtained from CDF given in ER Table F.2-1 (STPNOC 2010) divided by seismic events CDF of 7.31×10^{-8} .

^(c) May not total to 100 percent due to round off.

3

1

Table 5–5. STP Core Damage Frequency for Other External Events

Initiating event ^(a)	CDF (per year)	% Contribution to other external events CDF ^(b, c)	% Contribution to total CDF
Tornado induced failure of switchyard and essential cooling pond (ECP)	1.1×10^{-6}	79	17
Essential cooling water (ECW) failure due to breach of main cooling reservoir (MCR)	2.9×10^{-7}	21	5
External flooding scenarios 2–6	9.5×10^{-9}	<1	0.2
Flood induced loss of offsite power (LOOP)	2.1×10^{-9}	<1	<0.1
Total CDF (other external events)	1.4×10^{-6}	100	22

^(a) The impact of the sensitivity analysis to updated fire and seismic data on the total CDF is not included in these results. See Section F.2.2 for a discussion of these impacts.

^(b) Obtained from CDF given in ER Table F.2-1 (STPNOC 2010) divided by other external events CDF of 1.41×10^{-6} .

^(c) May not total to 100 percent due to round off.

2 As shown in Table 5–2, internal events contribute about 61 percent of the total CDF. The two
 3 LOOP events—“Loss of All Offsite Power” and “Loss of 345 kV Offsite Power”—are the largest
 4 contributors to the internal event CDF.

5 As shown in Table 5–5, the CDF for other external events make up the next largest contributor
 6 (about 22 percent) of the total CDF. The “Tornado Induced Failure of Switchyard and Essential
 7 Cooling Pond (ECP)” and “Essential Cooling Water (ECW) Failure due to Breach of Main
 8 Cooling Reservoir (MCR)” are the largest contributors in this group.

9 As shown in Table 5–3, fire events make up the next largest contributor (about 16 percent) of
 10 the total CDF. The “Fire Zone 047 Scenario X” and “Fire Zone 071 Scenario X” are the largest
 11 contributors. Seismic events make up a small contribution of about 1 percent to the total STP
 12 CDF. Station blackout contributes about 35 percent (2.2×10^{-6} per year) of the total CDF while
 13 anticipated transients without scram (ATWS) contribute about 4 percent (2.8×10^{-7} per year) to
 14 the total CDF (STPNOC 2011).

15 In the ER, STPNOC estimated the dose to the population within 80 km (50 mi) of the STP site to
 16 be approximately 0.0174 person-Sievert (Sv) (1.74 person-roentgen equivalent man (rem)) per
 17 year. The breakdown of the total population dose by containment release mode is summarized
 18 in Table 5–6. Large early releases, with induced SGTR and interfacing systems loss of coolant
 19 accident (ISLOCA), are the dominant contributors to the population dose risk at STP. Small
 20 early releases with pre-existing small containment failure and late releases with no sprays are
 21 also significant contributors to the population dose risk.

22

1 **Table 5–6. Breakdown of Population Dose by Containment Release Mode**

Containment release mode ^(a)	Population dose (person-rem ^(b) per year)	% Contribution
Large early releases (<3 hrs)	0.68	39
Small early releases (<3 hrs)	0.59	34
Late releases (>3 hrs)	0.42	24
Intact containment	0.05	3
Total	1.74	100

^(a) The impact of the sensitivity analysis to updated fire and seismic data on the release category frequency is not included in these results. Section F.2.2 provides a discussion of these impacts.

^(b) One person-rem=0.01 person-Sv

2 The staff has reviewed STPNOC’s data and evaluation methods and concludes that the quality
 3 of the risk analyses is adequate to support an assessment of the risk reduction potential for
 4 candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on the CDFs and
 5 offsite doses reported by STPNOC.

6 **5.3.3 Potential Plant Improvements**

7 STPNOC’s process for identifying potential plant improvements (SAMAs) consisted of the
 8 following elements:

- 9 • review of the dominant cutsets and most significant basic events from the
 10 current, plant-specific PRA,
- 11 • review of potential plant improvements identified in the STP IPE and IPEEE,
- 12 • review of SAMA candidates identified for license renewal applications for
 13 representative PWR plants, and
- 14 • review of other industry documentation discussing potential plant
 15 improvements.

16 Based on this process, an initial set of 21 candidate SAMAs, referred to as Phase I SAMAs,
 17 were identified. In Phase I of the evaluation, STPNOC performed a qualitative screening of the
 18 initial list of SAMAs and eliminated SAMAs from further consideration using the following
 19 criteria:

- 20 • The SAMA is not applicable to STP due to design differences.
- 21 • The SAMA has already been implemented at STP or would achieve results
 22 that have already been achieved at STP by other means.
- 23 • The SAMA has estimated implementation costs that would exceed the dollar
 24 value associated with eliminating all severe accident risk at STP.

25 Based on this screening, 16 SAMAs were eliminated, leaving 5 SAMAs for further evaluation. A
 26 detailed cost-benefit analysis was performed for each of the 5 SAMAs in the Phase II analysis.

27 STPNOC calculated the risk reduction that would be attributable to each candidate SAMA
 28 (assuming SAMA implementation) and re-quantified the risk value. The difference between the
 29 base risk value and the SAMA-reduced risk value is the averted risk, or the value of
 30 implementing the SAMA. STPNOC used this information in conjunction with the cost estimates

1 for implementing each SAMA to perform a detailed cost-benefit comparison. STPNOC
2 performed additional analyses to evaluate how the SAMA results would change if certain key
3 parameters were changed, including re-assessing the cost-benefit calculations using the
4 95th percentile level of the failure probability distributions. The results of the uncertainty
5 analysis are discussed in the ER, Attachment F, Section F.7. Based on the results of this
6 SAMA analysis, none of the SAMAs have a positive net value, even when the 95th percentile
7 PRA results were considered. Therefore, no SAMAs are being considered for implementation
8 as part of license renewal (STPNOC 2010). The staff's concerns regarding SAMAs were
9 provided to STPNOC in RAIs (NRC 2011). The staff's RAIs did not result in the identification of
10 any potentially cost-beneficial SAMAs (STPNOC 2011). STPNOC's SAMA analyses and the
11 NRC's review are discussed in more detail in the following sections.

12 The NRC staff concludes that STPNOC used a systematic and comprehensive process for
13 identifying potential plant improvements for STP and that the set of SAMAs evaluated in the ER,
14 together with those evaluated in response to the NRC staff's inquiries, is reasonably
15 comprehensive and, therefore, is acceptable.

16 **5.3.4 Evaluation of Risk Reduction and Costs of Improvements**

17 STPNOC estimated the costs of implementing the 21 SAMAs through the development of
18 site-specific cost estimates and use of other applicants' estimates for similar improvements.
19 The costs were developed on a site basis (i.e., two units). If the cost estimate was for a single
20 unit, based on other applicants' estimates for similar improvements, then the cost estimate was
21 multiplied by two to derive the costs on a site basis. The site-specific cost estimates
22 conservatively did not include contingency costs associated with unforeseen implementation
23 obstacles or the cost of replacement power during extended outages required to implement the
24 modifications (STPNOC 2010). The cost estimates that were based on other applicants'
25 estimates did not account for inflation, which is considered another conservatism.

26 STPNOC performed additional analyses to evaluate the impact of parameter choices and
27 uncertainties on the results of the SAMA assessment. In this process, one additional SAMA
28 was identified for detailed cost-benefit analysis.

29 The staff reviewed STPNOC's basis for calculating the risk reduction for the various plant
30 improvements and concludes that the rationale and assumptions for estimating risk reduction
31 are reasonable and generally conservative (i.e., the estimated risk reduction is higher than what
32 would actually be realized). Accordingly, the staff based its estimates of averted risk for the
33 various SAMAs on STPNOC's risk reduction estimates.

34 **5.3.5 Cost-Benefit Comparison**

35 The methodology used by STPNOC to perform the Cost-Benefit Comparison in the Phase II
36 analysis was based on NRC's guidance for performing a cost-benefit analysis (i.e.,
37 NUREG/BR-0184, *Regulatory Analysis Technical Evaluation Handbook* (NRC 1997)). The
38 guidance involves determining the net value for each SAMA. If the net value of a SAMA is
39 negative, the cost of implementing the SAMA is larger than the benefit associated with the
40 SAMA, and it is not considered cost-beneficial. Revision 4 of NUREG/BR-0058 states that two
41 sets of estimates should be developed, one at a 3 percent discount rate and one at a 7 percent
42 discount rate (NRC 2004). STPNOC provided a base set of results using the 7 percent discount
43 rate and a sensitivity study using the 3 percent discount rate. These results are presented in
44 Table 5–7 as the total benefit baseline and total benefit baseline with uncertainty. Table 5–7
45 lists (a) the assumptions considered to estimate the risk reduction for each of the evaluated
46 SAMAs, (b) the estimated risk reduction in terms of percent reduction in CDF and population

Environmental Impacts of Postulated Accidents

1 dose, and (c) the estimated total benefit (present value) of the averted risk. The estimated
 2 benefits reported in Table 5–7 reflect the combined benefit in both internal and external events.
 3 There are six SAMAs listed in Table 5–7. The associated initiated events for these six SAMAs
 4 are:

- 5 • cable spreading room fire,
- 6 • ISLOCA,
- 7 • SGTR,
- 8 • loss of reactor coolant system (RCS) water seal,
- 9 • loss of standby diesel generator (SBDG) HVAC, and
- 10 • loss of essential cooling water intake structure (ECWIS) HVAC, respectively.

11 The staff reviewed the bases for the applicant’s cost estimates. For certain improvements, the
 12 staff also compared the cost estimates to estimates developed elsewhere for similar
 13 improvements, including estimates developed as part of other applicants’ analyses of SAMAs
 14 for operating reactors. The staff reviewed the costs and has found them to be reasonable and
 15 generally consistent with estimates provided in support of other plants’ analyses. The staff
 16 agrees that the costs of the SAMAs evaluated would be higher than the associated benefits
 17 when they are considered independently.

18 **Table 5–7. Phase II SAMA List (Cost-Benefit) for STP**

SAMA ^(a)	Assumptions	% Risk reduction		Total benefit (\$)		Cost (\$)
		CDF ^(b)	Population dose (% dose reduction)	Baseline (internal + external)	Baseline with uncertainty ^(b)	
3b ^(c) —Install fire wrap on positive displacement pump (PDP) cables in cable spreading room.	Eliminate failure of the PDP due to a fire in the cable spreading room.	<1	<1	3K	4K	800K
4—Develop procedures to isolate component cooling water (CCW) inside containment.	Eliminate failure of the operator action to isolate CCW.	2	10	27K	43K	100K

Environmental Impacts of Postulated Accidents

SAMA ^(a)	Assumptions	% Risk reduction		Total benefit (\$)		Cost (\$)
		CDF ^(b)	Population dose (% dose reduction)	Baseline (internal + external)	Baseline with uncertainty ^(b)	
10—Enhance procedures to ensure the steam generators (SGs) are filled or maintain filled in SGTR events to scrub fission products.	Reassign a portion of the SGTR CDF contribution for the large early release category (7.48E-06 per year) and late release category (1.35E-07 per year) to the small early release category and intact containment release category, respectively.	0	2	3K	5K	100K
12—Enhance procedures to prevent clearing of RCS cold leg water seals.	Reassign the induced SGTR CDF contribution (2.4E-09 per year) for sequences in which offsite power is available from the large early release category to the intact containment release category.	0	0	<1K	<1K	100K
13—Develop procedures to open doors or use portable fans for alternate SBDG room cooling.	Eliminate failure of the operator action to provide SBDG room cooling.	<1	0	1K	2K	100K
15—Develop emergency procedures for alternate ECWIS room cooling.	Eliminate failure of the operator action to provide ECWIS room cooling.	1	2	8K	12K	100K

^(a) SAMAs in bold are potentially cost-beneficial.

^(b) Baseline benefits increased by a factor of 1.6 to account for uncertainties, which is discussed further in Section F.6.2.

^(c) SAMA 3b retained for Phase II analysis based on results of uncertainty analysis, which is discussed further in Section F.6.2.

1 **5.3.6 Conclusions**

2 The NRC staff reviewed the STPNOC’s analysis. The staff concludes that the methods used
3 and the implementations of those methods were sound. The treatment of SAMA benefits and
4 costs supports the general conclusion that the SAMA evaluations performed by STPNOC are
5 reasonable and sufficient for the license renewal submittal.

Environmental Impacts of Postulated Accidents

1 The staff agrees with STPNOC's conclusion that none of the candidate SAMAs are potentially
2 cost beneficial. This conclusion is based on the generally conservative treatment of costs and
3 benefits. This conclusion is consistent with the low residual level of risk indicated in the STP
4 PRA and the fact that STPNOC has already implemented the plant improvements identified
5 from the IPE and IPEEE.

6 **5.4 References**

7 10 CFR Part 50. *Code of Federal Regulations*, Title 10, Energy, Part 50, "Domestic Licensing of
8 Production and Utilization Facilities."

9 10 CFR Part 51. *Code of Federal Regulations*, Title 10, Energy, Part 51, "Environmental
10 protection regulations for domestic licensing and related regulatory functions."

11 10 CFR Part 54. *Code of Federal Regulations*, Title 10, Energy, Part 54, "Requirements for
12 Renewal of Operating Licenses for Nuclear Power Plants."

13 10 CFR Part 100. *Code of Federal Regulations*, Title 10, Energy, Part 100, "Reactor Site
14 Criteria."

15 [HL&P] Houston Lighting and Power Company. 1992. "South Texas Project Electric
16 Generating Station Level 2 Probabilistic Safety Assessment and Individual Plant Examination."
17 August 1992. (ADAMS Nos. ML0617001702, ML0617001790, ML0617001850).

18 [NRC] U.S. Nuclear Regulatory Commission. 1994. Letter from Suzanne C. Black, Director, to
19 William T. Cottle, Houston Lighting & Power Company. Subject: Issuance of Amendment
20 Nos. 59 and 47 to Facility Operating License Nos. NPF-76 and NPF-80 and Related Relief
21 Request—South Texas Project, Units 1 and 2 (TAC Nos. M76048 and M76049).
22 February 17, 1994. ADAMS No. ML021300134.

23 [NRC] U.S. Nuclear Regulatory Commission. 1996. Generic Environmental Impact Statement
24 for License Renewal of Nuclear Plants. Washington, DC. NRC NUREG-1437. May 1996.
25 ADAMS Nos. ML040690705 and ML040690738.

26 [NRC] U.S. Nuclear Regulatory Commission. 1997. Regulatory Analysis Technical Evaluation
27 Handbook. Washington, DC. NRC. NUREG/BR-0184. January 1997. ADAMS
28 No. ML050190193.

29 [NRC] U.S. Nuclear Regulatory Commission. 2004. Regulatory Analysis Guidelines of the U.S.
30 Nuclear Regulatory Commission. Washington, DC. NRC NUREG/BR-0058, Rev. 4. July 2000.
31 ADAMS No. ML003738939.

32 [NRC] U.S. Nuclear Regulatory Commission. 2011. Summary of site audit related to the review
33 of the license renewal application for South Texas Project, Units 1 and 2. August 4, 2011.
34 ADAMS No. ML11196A005.

35 [NRC] U.S. Nuclear Regulatory Commission. 2012. Environmental Impact Statement Scoping
36 Process, Summary Report, South Texas Project, Units 1 and 2, Bay City, TX. Washington, DC.
37 NRC. 2012. ADAMS No. ML11153A082.

38 [STPNOC] South Texas Project Nuclear Operating Company. 2010. "South Texas Project,
39 Applicant's Environmental Report—Operating License Renewal Stage, South Texas Project
40 Units 1 & 2." September 2010. ADAMS No. ML103010263.

41 [STPNOC] South Texas Project Nuclear Operating Company. 2011. Letter from G.T. Powell,
42 STPNOC, to U.S. Nuclear Regulatory Commission Document Control Desk, Subject: South
43 Texas Project Units 1 and 2, Docket Nos. STN 50-498, STN 50-499, Response to Request for

Environmental Impacts of Postulated Accidents

- 1 Additional Information on South Texas Project License Renewal Application (TAC No. ME4938).
2 July 5, 2011. ADAMS No. ML11193A016.
- 3 [STPNOC] South Texas Project Nuclear Operating Company. 2011b. Letter from G.T. Powell,
4 STPNOC, to U.S. Nuclear Regulatory Commission Document Control Desk, Subject: South
5 Texas Project Units 1 and 2, Docket Nos. STN 50-498, STN 50-499, Response to Request for
6 Additional Information on South Texas Project License Renewal Application (TAC No. ME4938).
7 August 23, 2011. ADAMS No. ML11250A067.
- 8 [STPNOC] South Texas Project Nuclear Operating Company. 2012b. Letter from D.W.
9 Rencurrel, STPNOC, to U.S. Nuclear Regulatory Commission Document Control Desk, Subject:
10 South Texas Project Units 1 and 2, Docket Nos. STN 50-498, STN 50-499, Clarification to
11 Supplemental Response to Request for Additional Information on South Texas Project License
12 Renewal Application—SAMA (TAC Nos. ME4938 and ME5122). February 16, 2012. ADAMS
13 No. ML12053A259.

1 **6.0 ENVIRONMENTAL IMPACTS OF THE URANIUM FUEL CYCLE,**
 2 **WASTE MANAGEMENT, AND GREENHOUSE GAS EMISSIONS**

3 This chapter addresses issues related to the uranium fuel cycle, solid waste management, and
 4 greenhouse gas (GHG) emissions during the proposed 20-year period of extended operation.

5 **6.1 The Uranium Fuel Cycle**

6 The uranium fuel cycle includes uranium mining and milling, the production of uranium
 7 hexafluoride, isotopic enrichment, fuel fabrication, reprocessing of irradiated fuel, transportation
 8 of radioactive materials, and management of low-level wastes and high-level wastes related to
 9 uranium fuel cycle activities. The generic potential impacts of the radiological and
 10 non-radiological environmental impacts of the uranium fuel cycle and transportation of nuclear
 11 fuel and wastes are described in detail in NUREG-1437, *Generic Environmental Impact*
 12 *Statement (GEIS) for License Renewal of Nuclear Plants* (NRC 1996, 1999) based, in part, on
 13 the generic impacts given in Table S-3, “Table of Uranium Fuel Cycle Environmental Data,”
 14 located at Title 10, Part 51.51, of the *Code of Federal Regulations* (10 CFR 51.51), and in
 15 10 CFR 51.52(c), Table S-4, “Environmental Impact of Transportation of Fuel and Waste to and
 16 from One Light-Water-Cooled Nuclear Power Reactor.”

17 In the GEIS, the U.S. Nuclear Regulatory Commission (NRC) staff identified nine Category 1
 18 issues related to the fuel cycle and waste management, which appear in Table 6-1. There are
 19 no Category 2 issues related to the fuel cycle and waste management.

20 **Table 6-1. Issues Related to the Uranium Fuel Cycle and Waste Management**

Issues	GEIS Sections	Category
Offsite radiological impacts (individual effects from other than the disposal of spent fuel & high-level waste)	6.1; 6.2.1; 6.2.2.1; 6.2.2.3; 6.2.3; 6.2.4; 6.6	1
Offsite radiological impacts (collective effects)	6.1; 6.2.2.1; 6.2.3; 6.2.4; 6.6	1
Offsite radiological impacts (spent fuel and high-level waste disposal)	6.2.2.1; 6.2.2.2; 6.2.3; 6.2.4	1
Nonradiological impacts of the uranium fuel cycle	6.1; 6.2.2.6; 6.2.2.7; 6.2.2.8; 6.2.2.9; 6.2.3; 6.2.4; 6.6	1
Low-level waste storage & disposal	6.1; 6.2.2.2; 6.4.2; 6.4.3; 6.4.3.1; 6.4.3.2; 6.4.3.3; 6.4.4; 6.4.4.1; 6.4.4.2; 6.4.4.3; 6.4.4.4; 6.4.4.5; 6.4.4.5.1; 6.4.4.5.2; 6.4.4.5.3; 6.4.4.5.4; 6.4.4.6; 6.6	1
Mixed waste storage & disposal	6.4.5.1; 6.4.5.2; 6.4.5.3; 6.4.5.4; 6.4.5.5; 6.4.5.6; 6.4.5.6.1; 6.4.5.6.2; 6.4.5.6.3; 6.4.5.6.4; 6.6	1
Onsite spent fuel	6.1; 6.4.6; 6.4.6.1; 6.4.6.2; 6.4.6.3; 6.4.6.4; 6.4.6.5; 6.4.6.6; 6.4.6.7; 6.6	1
Nonradiological waste	6.1; 6.5; 6.5.1; 6.5.2; 6.5.3; 6.6	1
Transportation	6.1; 6.3.1; 6.3.2.3; 6.3.3; 6.3.4; 6.6, Addendum 1	1

Environmental Impacts of the Uranium Fuel Cycle,
Waste Management, and Greenhouse Gas Emissions

1 The issue, “offsite radiological impacts (spent fuel and high-level waste disposal),” from
2 Table 6-1, is not evaluated in this environmental impact statement (EIS), as explained later in
3 this section. For the term of license renewal, the NRC staff did not identify any new and
4 significant information related to the remaining uranium fuel cycle and waste management
5 issues listed in Table 6-1 during its review of the STP Nuclear Operating Company (STPNOC)
6 Environmental Report (STPNOC 2010), the site visit, and the scoping process. Therefore, there
7 are no impacts related to these issues beyond those discussed in the GEIS. For these
8 Category 1 issues, the GEIS concludes that the impacts are SMALL, except for the offsite
9 radiological impacts (collective effects) from the uranium fuel cycle and waste management,
10 which the NRC concluded are acceptable.

11 However, the offsite radiological impacts resulting from spent fuel and high-level waste disposal,
12 that will occur after the reactors have been permanently shut down, are addressed in the
13 Commission’s Waste Confidence Decision Rule (WCD), 10 CFR 51.23. In 2010, the
14 Commission revised the WCD (i.e., WCD Update) to reflect information gained based on
15 experience in the storage of spent nuclear fuel and the increased uncertainty in the siting and
16 construction of a permanent geologic repository for the disposal of spent nuclear fuel.

17 On June 8, 2012, the United States Court of Appeals for the District of Columbia Circuit
18 (New York v. NRC, 681 F.3d 471 (D.C. Cir. 2012)), in response to a legal challenge to the
19 WCD, vacated the NRC’s WCD Update (75 *Federal Register* (FR) 81,032 and 75 FR 81,037).
20 The court decision was based on grounds relating to aspects of the National Environmental
21 Policy Act (NEPA). The court decision held that the WCD Update is a major Federal action
22 necessitating either an EIS or a finding of no significant environmental impact (FONSI), and the
23 Commission’s evaluation of the risks associated with the storage of spent nuclear fuel for at
24 least 60 years beyond the licensed life for reactor operation is deficient.

25 In response to the court’s ruling, the Commission, in CLI-12-16 (NRC 2012), determined that it
26 would not issue licenses dependent upon the WCD until the issues identified in the court’s
27 decision are appropriately addressed. In CLI-12-16, the Commission also noted that this
28 determination extends only to final license issuance; all current licensing reviews and
29 proceedings should continue to move forward.

30 In addition, the Commission directed (SRM-COMSECY-12-0016) the NRC staff to proceed with
31 a rulemaking that includes the development of an EIS to support an updated WCD within
32 24 months (by September 2014). The Commission indicated that the EIS used to support the
33 revised rule should build on the information already documented in various NRC studies and
34 reports on the impacts associated with the storage of spent nuclear fuel that were developed as
35 part of the 2010 WCD Update. It should primarily focus additional analyses on the deficiencies
36 identified in the D.C. Circuit’s decision. The NRC considers the WCD to be a generic issue that
37 is best addressed through rulemaking and that the NRC rulemaking process provides an
38 appropriate forum for public review and comment on both the draft EIS and the proposed WCD.

39 The updated rule and supporting EIS will provide the necessary NEPA analyses of waste
40 confidence-related human health and environmental issues. As directed by the Commission,
41 the NRC will not issue a renewed license prior to the resolution of waste confidence-related
42 issues. This will ensure that there would be no irretrievable or irreversible resource
43 commitments or potential harm to the environment before waste confidence impacts have been
44 addressed.

45 If the results of the WCD EIS identify information that requires a supplement to this EIS, the
46 NRC staff will perform any appropriate additional NEPA review for those issues before the NRC
47 makes a final licensing decision.

1 **6.2 Greenhouse Gas Emissions**

2 This section discusses the potential impacts from GHGs emitted from the nuclear fuel cycle.
3 The GEIS does not directly address these emissions, and its discussion is limited to an
4 inference that substantial carbon dioxide emissions may occur if coal- or oil-fired alternatives to
5 license renewal are carried out.

6 **6.2.1 Existing Studies**

7 Since the development of the GEIS, the relative volumes of GHGs emitted by nuclear and other
8 electricity generating methods have been widely studied. However, estimates and projections
9 of the carbon footprint of the nuclear power lifecycle vary depending on the type of study done.
10 Additionally, considerable debate also exists among researchers on the relative effects of
11 nuclear and other forms of electricity generation on GHG emissions. Existing studies on GHG
12 emissions from nuclear power plants generally take two different forms:

- 13 (1) qualitative discussions of the potential to use nuclear power to reduce GHG
14 emissions and mitigate global warming, and
- 15 (2) technical analyses and quantitative estimates of the actual amount of GHGs
16 generated by the nuclear fuel cycle or entire nuclear power plant life cycle and
17 comparisons to the operational or life cycle emissions from other energy generation
18 alternatives.

19 Qualitative Studies. The qualitative studies consist primarily of broad evaluations, large-scale
20 public policy evaluations, or investment evaluations of whether an expansion of nuclear power is
21 likely to be a technically, economically, or politically workable means of achieving global GHG
22 reductions. Studies found by the staff during the subsequent literature search include the
23 following:

- 24 • Evaluations to determine if investments in nuclear power in developing
25 countries should be accepted as a flexibility mechanism to assist
26 industrialized nations in achieving their GHG reduction goals under the Kyoto
27 Protocols (IAEA 2000; NEA 2002; Schneider 2000). Ultimately, the parties to
28 the Kyoto Protocol did not approve nuclear power as a component under the
29 clean development mechanism (CDM) due to safety and waste disposal
30 concerns (NEA 2002).
- 31 • Analyses developed to assist governments, including the U.S. Government,
32 in making long-term investment and public policy decisions in nuclear power
33 (Hagen et al. 2001; Keepin 1988; MIT 2003).

34 Although the qualitative studies sometimes reference and critique the existing quantitative
35 estimates of GHGs produced by the nuclear fuel cycle or life cycle, their conclusions generally
36 rely heavily on discussions of other aspects of nuclear policy decisions and investment such as
37 safety, cost, waste generation, and political acceptability. Therefore, these studies are typically
38 not directly applicable to an evaluation of GHG emissions associated with the proposed license
39 renewal for a given nuclear power plant.

40 Quantitative Studies. A large number of technical studies, including calculations and estimates
41 of the amount of GHGs emitted by nuclear and other power generation options, are available in
42 the literature and were useful to the staff's efforts in addressing relative GHG emission levels.
43 Examples of these studies include—but are not limited to—Mortimer (1990),

Environmental Impacts of the Uranium Fuel Cycle, Waste Management, and Greenhouse Gas Emissions

1 Andseta et al. (1998), Spadaro (2000), Storm van Leeuwen and Smith (2008), Fritsche (2006),
2 Parliamentary Office of Science and Technology (POST) (2006), Atomic Energy Authority
3 (AEA) (2006), Weisser (2006), Fthenakis and Kim (2007), and Dones (2007).

4 Comparing these studies and others like them is difficult because the assumptions and
5 components of the lifecycles the authors evaluate vary widely. Examples of areas in which
6 differing assumptions make comparing the studies difficult include the following:

- 7 • energy sources that may be used to mine uranium deposits in the future,
- 8 • reprocessing or disposal of spent nuclear fuel,
- 9 • current and potential future processes to enrich uranium and the energy
10 sources that will power them,
- 11 • estimated grades and quantities of recoverable uranium resources,
- 12 • estimated grades and quantities of recoverable fossil-fuel resources,
- 13 • estimated GHG emissions other than carbon dioxide, including the
14 conversion to carbon dioxide equivalents per unit of electric energy produced,
- 15 • performance of future fossil-fuel power systems,
- 16 • projected capacity factors for alternatives means of generation, and
- 17 • current and potential future reactor technologies.

18 In addition, studies may vary with respect to whether all or parts of a power plant's lifecycle are
19 analyzed (i.e., a full lifecycle analysis will typically address plant construction, operations,
20 resource extraction (for fuel and construction materials), and decommissioning, whereas a
21 partial lifecycle analysis primarily focuses on operational differences).

22 In the case of license renewal, a GHG analysis for that portion of the plant's lifecycle (operation
23 for an additional 20 years) would not involve GHG emissions associated with construction
24 because construction activities have already been completed at the time of relicensing. In
25 addition, the proposed action of license renewal would also not involve additional GHG
26 emissions associated with facility decommissioning because that decommissioning must occur
27 whether the facility is relicensed or not. However, in some of the above-mentioned studies, the
28 specific contribution of GHG emissions from construction, decommissioning, or other portions of
29 a plant's lifecycle cannot be clearly separated from one another. In such cases, an analysis of
30 GHG emissions would overestimate the GHG emissions attributed to a specific portion of a
31 plant's lifecycle. Nonetheless, these studies supply some meaningful information with respect
32 to the relative magnitude of the emissions among nuclear power plants and other forms of
33 electric generation, as discussed in the following sections.

34 In Table 6–2, Table 6–3, and Table 6–4, the staff presents the results of the above-mentioned
35 quantitative studies to supply a weight-of-evidence evaluation of the relative GHG emissions
36 that may result from the proposed license renewal as compared to the potential alternative use
37 of coal-fired, natural gas-fired, and renewable generation. Most studies from Mortimer (1990)
38 onward suggest that uranium ore grades and uranium enrichment processes are leading
39 determinants in the ultimate GHG emissions attributable to nuclear power generation. These
40 studies show that the relatively lower order of magnitude of GHG emissions from nuclear power,
41 when compared to fossil-fueled alternatives (especially natural gas), could potentially disappear
42 if available uranium ore grades drop sufficiently while enrichment processes continued to rely on
43 the same technologies.

1 Summary of Nuclear Greenhouse Gas Emissions Compared to Coal. Considering that coal
2 fuels the largest share of electricity generation in the U.S. and that its burning results in the
3 largest emissions of GHGs for any of the likely alternatives to nuclear power generation,
4 including South Texas Project (STP), most of the available quantitative studies focused on
5 comparisons of the relative GHG emissions of nuclear to coal-fired generation. The quantitative
6 estimates of the GHG emissions associated with the nuclear fuel cycle (and, in some cases, the
7 nuclear lifecycle), as compared to an equivalent coal-fired plant, are presented in Table 6–2.
8 The staff considered the best available information for its independent analysis. Although the
9 following chart does not include all existing studies, it gives an illustrative range of estimates
10 developed by various sources.

11 **Table 6–2. Nuclear Greenhouse Gas Emissions Compared to Coal**

Source	GHG Emission Results
Mortimer (1990)	Nuclear—230,000 tons CO ₂ ^(a) Coal—5,912,000 tons CO ₂ Note: Future GHG emissions from nuclear to increase because of declining ore grade.
Andseta et al. (1998)	Nuclear energy produces 1.4% of the GHG emissions compared to coal. Note: Future reprocessing and use of nuclear-generated electrical power in the mining and enrichment steps are likely to change the projections of earlier authors, such as Mortimer (1990).
Spadaro (2000)	Nuclear—2.5–5.7 g C _{eq} /kWh Coal—264–357 g C _{eq} /kWh
Fritsche (2006) (Values estimated from graph in Figure 4)	Nuclear—33 g C _{eq} /kWh Coal—950 g C _{eq} /kWh
POST (2006) (Nuclear calculations from AEA 2006)	Nuclear—5 g C _{eq} /kWh Coal—>1,000 g C _{eq} /kWh Note: Decrease of uranium ore grade to 0.03% would raise nuclear to 6.8 g C _{eq} /kWh. Future improved technology and carbon capture and storage could reduce coal-fired GHG emissions by 90%.
Weisser (2006) (Compilation of results from other studies)	Nuclear—2.8–24 g C _{eq} /kWh Coal—950–1,250 g C _{eq} /kWh

^(a) CO₂ is carbon dioxide.

12 **6.2.1.2 Summary of Nuclear Greenhouse Gas Emissions Compared to Natural Gas**

13 The quantitative estimates of the GHG emissions associated with the nuclear fuel cycle (and, in
14 some cases, the nuclear lifecycle), as compared to an equivalent natural gas-fired plant, are
15 presented in Table 6–3. In considering the best available information for its independent
16 analysis, the staff noted that the following chart does not include all existing studies; however, it
17 gives an illustrative range of estimates developed by various sources.

1 **Table 6–3. Nuclear Greenhouse Gas Emissions Compared to Natural Gas**

Source	GHG Emission Results
Spadaro (2000)	Nuclear—2.5–5.7 g C _{eq} /kWh Natural Gas—120–188 g C _{eq} /kWh
Storm van Leeuwen & Smith (2008)	Nuclear fuel cycle produces 20–33% of the GHG emissions compared to natural gas (at high ore grades). Note: Future nuclear GHG emissions to increase because of declining ore grade.
Fritsche (2006) (Values estimated from graph in Figure 4)	Nuclear—33 g C _{eq} /kWh Cogeneration Combined Cycle Natural Gas—150 g C _{eq} /kWh
POST (2006) (Nuclear calculations from AEA 2006)	Nuclear—5 g C _{eq} /kWh Natural Gas—500 g C _{eq} /kWh Note: Decrease of uranium ore grade to 0.03% would raise nuclear to 6.8 g C _{eq} /kWh. Future improved technology and carbon capture and storage could reduce natural gas GHG emissions by 90%.
Weisser (2006) (Compilation of results from other studies)	Nuclear—2.8–24 g C _{eq} /kWh Natural Gas—440–780 g C _{eq} /kWh
Dones (2007)	Author critiqued methods and assumptions of Storm van Leeuwen and Smith (2005) and concluded that the nuclear fuel cycle produces 15–27% of the GHG emissions of natural gas.

2 Summary of Nuclear Greenhouse Gas Emissions Compared to Renewable Energy Sources.
3 The quantitative estimates of the GHG emissions associated with the nuclear fuel cycle, as
4 compared to equivalent renewable energy sources, are presented in Table 6–4. Calculation of
5 GHG emissions associated with these sources is more difficult than the calculations for nuclear
6 energy and fossil fuels because of the large variation in efficiencies due to their different
7 sources and locations. For example, the efficiency of solar and wind energy is highly dependent
8 on the location in which the power generation facility is installed. Similarly, the range of GHG
9 emissions estimates for hydropower varies greatly, depending on the type of dam or reservoir
10 involved (if used at all). Therefore, the GHG emissions estimates for these energy sources
11 have a greater range of variability than the estimates for nuclear and fossil-fuel sources. As
12 noted in Section 6.2.1.2, the following chart gives an illustrative range of estimates developed
13 by various sources.

Table 6–4. Nuclear Greenhouse Gas Emissions Compared to Renewable Energy Sources

Source	GHG Emission Results
Mortimer (1990)	Nuclear—230,000 tons CO ₂ Hydropower—78,000 tons CO ₂ Wind power—54,000 tons CO ₂ Tidal power—52,500 tons CO ₂ Note: Future GHG emissions from nuclear are expected to increase because of declining ore grade.
Spadaro (2000)	Nuclear—2.5–5.7 g C _{eq} /kWh Solar PV—27.3–76.4 g C _{eq} /kWh Hydroelectric—1.1–64.6 g C _{eq} /kWh Biomass—8.4–16.6 g C _{eq} /kWh Wind—2.5–13.1 g C _{eq} /kWh
Fritsche (2006) (Values estimated from graph in Figure 4)	Nuclear—33 g C _{eq} /kWh Solar PV—125 g C _{eq} /kWh Hydroelectric—50 g C _{eq} /kWh Wind—20 g C _{eq} /kWh
POST (2006) (Nuclear calculations from AEA 2006)	Nuclear—5 g C _{eq} /kWh Biomass—25–93 g C _{eq} /kWh Solar PV—35–58 g C _{eq} /kWh Wave/Tidal—25–50 g C _{eq} /kWh Hydroelectric—5–30 g C _{eq} /kWh Wind—4.64–5.25 g C _{eq} /kWh Note: Decrease of uranium ore grade to 0.03% would raise nuclear to 6.8 g C _{eq} /kWh.
Weisser (2006) (Compilation of results from other studies)	Nuclear—2.8–24 g C _{eq} /kWh Solar PV—43–73 g C _{eq} /kWh Hydroelectric—1–34 g C _{eq} /kWh Biomass—35–99 g C _{eq} /kWh Wind—8–30 g C _{eq} /kWh
Fthenakis & Kim (2007)	Nuclear—16–55 g C _{eq} /kWh Solar PV—17–49 g C _{eq} /kWh

^(a) CO₂ is carbon dioxide.

Conclusion. The sampling of data presented in Table 6–2, Table 6–3, and Table 6–4 demonstrates the challenges of any attempt to determine the specific amount of GHG emission attributable to nuclear energy production sources, as different assumptions and calculation methods will yield differing results. The differences and complexities in these assumptions and analyses will further increase when they are used to project future GHG emissions. Nevertheless, several conclusions can be drawn from the information presented.

First, the various studies show a general consensus that nuclear power currently produces fewer GHG emissions than electrical generation based on fossil fuel. For example, the GHG emissions from a complete nuclear fuel cycle currently range from 2.5 to 55 grams of carbon equivalent per Kilowatt hour (g C_{eq}/kWh), as compared to the use of coal plants (264 to 1,250 g C_{eq}/kWh) and natural gas plants (120 to 780 g C_{eq}/kWh). The studies also give estimates of GHG emissions from five renewable energy sources based on current technology. These estimates included solar-photovoltaic (17 to 125 g C_{eq}/kWh), hydroelectric

Environmental Impacts of the Uranium Fuel Cycle,
Waste Management, and Greenhouse Gas Emissions

1 (1 to 64.6 g C_{eq}/kWh), biomass (8.4 to 99 g C_{eq}/kWh), wind (2.5 to 30 g C_{eq}/kWh), and tidal
2 (25 to 50 g C_{eq}/kWh). The range of these estimates is wide, but the general conclusion is that
3 current GHG emissions from the nuclear fuel cycle are of the same order of magnitude as from
4 these renewable energy sources.

5 Second, the studies show no consensus on future relative GHG emissions from nuclear power
6 and other sources of electricity. There is substantial disagreement among the various authors
7 about the GHG emissions associated with declining uranium ore concentrations, future uranium
8 enrichment methods, and other factors, including changes in technology. Similar disagreement
9 exists about future GHG emissions associated with coal and natural gas for electricity
10 generation. Even the most conservative studies conclude that the nuclear fuel cycle currently
11 produces fewer GHG emissions than sources based on fossil fuel and is expected to continue to
12 do so in the near future. The primary difference between the authors is the projected cross-over
13 date (the time at which GHG emissions from the nuclear fuel cycle exceed those sources based
14 on fossil fuel) or whether cross-over will actually occur.

15 Considering the current estimates and future uncertainties, it appears that GHG emissions
16 associated with the proposed STP relicensing action are likely to be lower than those
17 associated with energy sources based on fossil fuel. The staff bases this conclusion on the
18 following rationale:

- 19 • As shown in Table 6–2 and Table 6–3, the current estimates of GHG
20 emissions from the nuclear fuel cycle are far below those for energy sources
21 based on fossil fuel.
- 22 • License renewal of a nuclear power plant like STP may involve continued
23 GHG emissions due to uranium mining, processing, and enrichment, but will
24 not result in increased GHG emissions associated with plant construction or
25 decommissioning (as the plant will have to be decommissioned at some point
26 whether the license is renewed or not).
- 27 • Few studies predict that nuclear fuel cycle emissions will exceed those of
28 fossil fuels within a timeframe that includes the STP periods of extended
29 operation. Several studies suggest that future extraction and enrichment
30 methods, the potential for higher-grade resource discovery, and technology
31 improvements could extend this timeframe.

32 With respect to comparison of GHG emissions among the proposed STP license renewal action
33 and renewable energy sources, it appears likely that there will be future technology
34 improvements and changes in the type of energy used for mining, processing, and constructing
35 facilities of all types. Currently, the GHG emissions associated with the nuclear fuel cycle and
36 renewable energy sources are within the same order of magnitude. Because nuclear fuel
37 production is the most significant contributor to possible future increases in GHG emissions
38 from nuclear power—and because most renewable energy sources lack a fuel component—it is
39 likely that GHG emissions from renewable energy sources would be lower than those
40 associated with STP at some point during the period of extended operation.

41 The staff also supplies an additional discussion about the contribution of GHG to cumulative air
42 quality impacts in Section 4.11.2 of this supplemental environmental impact statement (SEIS).

1 **6.3 References**

- 2 10 CFR 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental Protection
3 Regulations for Domestic Licensing and Related Regulatory Functions.”
- 4 10 CFR 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for Renewal
5 of Operating Licenses for Nuclear Power Plants.”
- 6 [AEA] AEA Technology. 2006. “Carbon Footprint of the Nuclear Fuel Cycle, Briefing Note.”
7 East Kilbride, UK: British Energy Group. March 2006. Available at
8 <http://www.british-energy.com/documents/carbon_footprint.pdf> (accessed on April 5, 2012).
- 9 Andseta S, Thompson MJ, Jarrell JP, Pendergast DR. 1998. CANDU Reactors and
10 Greenhouse Gas Emissions. *Proceedings of the 19th Annual Conference, Canadian Nuclear*
11 *Society*; 1998 October 18-21; Toronto, Ontario. Available at
12 <<http://www.computare.org/Support%20documents/Publications/Life%20Cycle.htm>> (accessed
13 on April 5, 2012).
- 14 Dones R. 2007. *Critical Note on the Estimation by Storm Van Leeuwen JW and Smith P of the*
15 *Energy Uses and Corresponding CO₂ Emissions for the Complete Nuclear Energy Chain.*
16 Villigen, Switzerland: Paul Sherer Institute. April 2007. Available at
17 <<http://gabe.web.psi.ch/pdfs/Critical%20note%20GHG%20PSI.pdf>> (accessed on
18 April 5, 2012).
- 19 Fritsche UR. 2006. *Comparison of Greenhouse-Gas Emissions and Abatement Cost of*
20 *Nuclear and Alternative Energy Options from a Life-Cycle Perspective.* Freiburg, Germany:
21 Oko-Institut. January 2006. Available at <<http://www.oeko.de/oekodoc/315/2006-017-en.pdf>>
22 (accessed on April 5, 2012)
- 23 Fthenakis VM, Kim HC. 2007. Greenhouse-gas emissions from solar-electric and nuclear
24 power: A life cycle study. *Energy Policy* 35(4):2549–2557.
- 25 [IAEA] International Atomic Energy Agency. 2000. *Nuclear Power for Greenhouse Gas*
26 *Mitigation under the Kyoto Protocol: The Clean Development Mechanism (CDM).* Vienna,
27 Austria: IAEA. November 2000. Available at
28 <<http://www.iaea.org/Publications/Booklets/GreenhouseGas/greenhousegas.pdf>> (accessed on
29 April 5, 2012).
- 30 Mortimer N. 1990. World warms to nuclear power. *SCRAM Safe Energy Journal*
31 Dec 89/Jan 90. Available at <http://www.no2nuclearpower.org.uk/articles/mortimer_se74.php>
32 (accessed on April 5, 2012).
- 33 [NEA and OECD] Nuclear Energy Agency and the Organization for Economic Co-operation and
34 Development. 2002. *Nuclear Energy and the Kyoto Protocol.* Paris, France: OECD. Available
35 at <<http://www.nea.fr/ndd/reports/2002/nea3808-kyoto.pdf>> (accessed on April 5, 2012).
- 36 [NRC] U.S. Nuclear Regulatory Commission. 1996. *Generic Environmental Impact Statement*
37 *for License Renewal of Nuclear Plants.* NUREG-1437, Volumes 1 and 2, Washington, DC.
- 38 [NRC] U.S. Nuclear Regulatory Commission. *Code Manual for MACCS2: Volume 1, User's*
39 *Guide.* Washington, DC. NRC. NUREG/CR-6613. May 1998. ADAMS No. ML063550020.
- 40 [NRC] U.S. Nuclear Regulatory Commission. 1999. *Generic Environmental Impact Statement*
41 *for License Renewal of Nuclear Plants*, Main Report, “Section 6.3, Transportation, Table 9.1,
42 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
43 Report.” NUREG-1437, Volume 1, Addendum 1, Washington, DC.

Environmental Impacts of the Uranium Fuel Cycle,
Waste Management, and Greenhouse Gas Emissions

- 1 [NRC] U.S. Nuclear Regulatory Commission. 2012. Commission, Memorandum and Order
2 CLI-12-16, ADAMS No. ML12220A094.
- 3 [POST] Parliamentary Office of Science and Technology. 2006. Carbon footprint of electricity
4 generation. *Postnote* 268. October 2006. Available at
5 <<http://www.parliament.uk/documents/post/postpn268.pdf>> (accessed on April 5, 2012).
- 6 Schneider M. 2000. *Climate Change and Nuclear Power*. Gland, Switzerland: WWF-World
7 Wildlife Fund for Nature. April 2000. Available at
8 <<http://assets.panda.org/downloads/fullnuclearreprotwwf.pdf>> (accessed on April 5, 2012).
- 9 Spadaro JV, Langlois L, Hamilton B. 2000. "Greenhouse Gas Emissions of Electricity
10 Generation Chains: Assessing the Difference." Vienna, Austria: International Atomic Energy
11 Agency. Available at
12 <<http://www.iaea.org/Publications/Magazines/Bulletin/Bull422/article4.pdf>>.
- 13 [STPNOC] STP Nuclear Operating (STPNOC). 2010. *License Renewal Application, South
14 Texas Project, Units 1 and 2*, Appendix E, Applicant's Environmental Report, Operating License
15 Renewal Stage. ADAMS No. ML103010257.
- 16 Storm van Leeuwen JW, Smith P. 2008. *Nuclear Power—The Energy Balance*. Chaam,
17 Netherlands: Ceedata Consultancy. February 2008. Available at <<http://www.stormsmith.nl/>>
18 (accessed on April 5, 2012).
- 19 Weisser D. 2006. A guide to life-cycle greenhouse gas (GHG) emissions from electric supply
20 technologies. *Energy* 32(9): 1543–1559. Available at
21 <[http://www.iaea.org/OurWork/ST/NE/Pess/assets/GHG_manuscript_pre-print_
22 versionDanielWeisser.pdf](http://www.iaea.org/OurWork/ST/NE/Pess/assets/GHG_manuscript_pre-print_versionDanielWeisser.pdf)> (accessed on April 5, 2012).

7.0 ENVIRONMENTAL IMPACTS OF DECOMMISSIONING

Environmental impacts from the activities associated with the decommissioning of any reactor before or at the end of an initial or renewed license are evaluated in Supplement 1 of NUREG-0586, *Final Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities Regarding the Decommissioning of Nuclear Power Reactors* (NRC 2002). The U.S. Nuclear Regulatory Commission (NRC) staff's (the staff's) evaluation of the environmental impacts of decommissioning—presented in NUREG-0586, Supplement 1—notes a range of impacts for each environmental issue.

Additionally, the incremental environmental impacts associated with decommissioning activities resulting from continued plant operation during the renewal term are discussed in NUREG-1437, *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS) (NRC 1996, 1999). The GEIS includes a determination of whether the analysis of the environmental issue could be applied to all plants and whether additional mitigation measures would be warranted. Issues were then assigned a Category 1 or a Category 2 designation. Section 1.4 of this supplemental environmental impact statement (SEIS) explains the criteria for Category 1 and Category 2 issues and defines the impact designations of SMALL, MODERATE, and LARGE. The staff analyzed site-specific issues (Category 2) for South Texas Project (STP) and assigned them a significance level of SMALL, MODERATE, or LARGE, or not applicable to STP because of site characteristics or plant features. There are no Category 2 issues related to decommissioning.

7.1 Decommissioning

Table 7–1 lists the Category 1 issues in Table B–1 of Title 10 of the *Code of Federal Regulations* (CFR) Part 51, Subpart A, Appendix B, that are applicable to STP decommissioning following the renewal term.

Table 7–1. Issues Related to Decommissioning

Issues	GEIS Sections	Category
Radiation doses	7.3.1; 7.4	1
Waste management	7.3.2; 7.4	1
Air quality	7.3.3; 7.4	1
Water quality	7.3.4; 7.4	1
Ecological resources	7.3.5; 7.4	1
Socioeconomic impacts	7.3.7; 7.4	1

Decommissioning would occur whether STP were shut down at the end of its current operating license or at the end of the period of extended operation. There are no site-specific issues related to decommissioning.

A brief description of the staff's review and the GEIS conclusions, as codified in Table B-1, 10 CFR Part 51, for each of the issues follows:

Environmental Impacts of Decommissioning

1 Radiation Doses. Based on information in the GEIS, the NRC noted that “[d]oses to the public
2 will be well below applicable regulatory standards regardless of which decommissioning method
3 is used. Occupational doses would increase no more than 1 person-rem (1 person-mSv)
4 caused by buildup of long-lived radionuclides during the license renewal term.”

5 Waste Management. Based on information in the GEIS, the NRC noted that
6 “[d]ecommissioning at the end of a 20-year license renewal period would generate no more
7 solid wastes than at the end of the current license term. No increase in the quantities of
8 Class C or greater than Class C wastes would be expected.”

9 Air Quality. Based on information in the GEIS, the NRC noted that “[a]ir quality impacts of
10 decommissioning are expected to be negligible either at the end of the current operating term or
11 at the end of the license renewal term.”

12 Water Quality. Based on information in the GEIS, the NRC noted that “[t]he potential for
13 significant water quality impacts from erosion or spills is no greater whether decommissioning
14 occurs after a 20-year license renewal period or after the original 40-year operation period, and
15 measures are readily available to avoid such impacts.”

16 Ecological Resources. Based on information in the GEIS, the NRC noted that
17 “[d]ecommissioning after either the initial operating period or after a 20-year license renewal
18 period is not expected to have any direct ecological impacts.”

19 Socioeconomic Impacts. Based on information in the GEIS, the NRC noted that
20 “[d]ecommissioning would have some short-term socioeconomic impacts. The impacts would
21 not be increased by delaying decommissioning until the end of a 20-year relicense period, but
22 they might be decreased by population and economic growth.”

23 The staff has not found any new and significant information during its independent review of
24 South Texas Project Nuclear Operating Company’s (STPNOC’s) Environmental Report (ER)
25 (STPNOC 2010), the site audit, the scoping process, or its evaluation of other available
26 information. Therefore, the NRC staff concludes that there are no impacts related to these
27 issues, beyond those discussed in the GEIS (NRC 1996, 1999). For all of these issues, the
28 NRC staff concluded in the GEIS that the impacts are SMALL, and additional plant-specific
29 mitigation measures are not likely to be sufficiently beneficial to be warranted.

30 **7.2 References**

31 10 CFR 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental protection
32 regulations for domestic licensing and related regulatory functions.”

33 [NRC] U.S. Nuclear Regulatory Commission. 1996. *Generic Environmental Impact Statement*
34 *for License Renewal of Nuclear Plants*. Washington, DC: NRC. NUREG-1437. May 1996.
35 ADAMS Nos. ML040690705 and ML040690738.

36 [NRC] U.S. Nuclear Regulatory Commission. 1999. Section 6.3, Transportation, Table 9.1,
37 Summary of findings on NEPA issues for license renewal of nuclear power plants. In: *Generic*
38 *Environmental Impact Statement for License Renewal of Nuclear Plants*. Washington, DC:
39 NRC. NUREG-1437, Volume 1, Addendum 1. August 1999. ADAMS No. ML04069720.

40 [NRC] U.S. Nuclear Regulatory Commission. 2002. *Final Generic Environmental Impact*
41 *Statement on Decommissioning of Nuclear Facilities Regarding the Decommissioning of Nuclear*

- 1 *Power Reactors*. Washington, DC. NRC. NUREG-0586, Supplement 1. November 2002.
- 2 ADAMS No. ML023470304 and ML023500295.
- 3 [STPNOC] South Texas Plant Nuclear Operating Company. 2010. "South Texas Project,
- 4 Applicant's Environmental Report—Operating License Renewal Stage, South Texas Project
- 5 Units 1 & 2." September 2010. ADAMS No. ML103010263.

8.0 ENVIRONMENTAL IMPACTS OF ALTERNATIVES

The National Environmental Policy Act (NEPA) requires the consideration of a range of reasonable alternatives to the proposed action in an environmental impact statement (EIS). In this case, the proposed action is whether to issue renewed licenses for South Texas Project (STP), Units 1 and 2, which will allow the plant to operate for 20 years beyond the current license expiration dates. A license is just one of many authorizations that an applicant must obtain in order to operate its nuclear plant. Energy-planning decisionmakers and the owners of the nuclear power plant ultimately decide if the plant will operate. Economic and environmental considerations play a primary role in this decision. The U.S. Nuclear Regulatory Commission's (NRC's) responsibility is to ensure the safe operation of nuclear power facilities, not to formulate energy policy or encourage or discourage the development of alternative power generation (or replacement power alternatives).

The license renewal process is designed to assure safe operation of the nuclear power plant during the license renewal term. Under the NRC's environmental protection regulations in Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR Part 51), which implement Section 102(2) of NEPA, renewal of a nuclear power plant operating license requires the preparation of an EIS.

To support the preparation of these EISs, the NRC prepared the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS)*, NUREG-1437, in 1996. The license renewal GEIS was prepared to assess the environmental impacts of continued nuclear power plant operations during the license renewal term. The intent was to determine which environmental impacts would result in essentially the same impact at all nuclear power plants and which ones could result in different levels of impacts at different plants and would require a plant-specific analysis to determine the impacts. For those issues that could not be generically addressed, the NRC develops a plant-specific supplemental environmental impact statement (SEIS) to the GEIS.

NRC regulations in 10 CFR 51.71(d) for license renewal require that a SEIS do the following:

Consider and weigh the environmental effects of the proposed action [license renewal]; the environmental impacts of alternatives to the proposed action; and alternatives available for reducing or avoiding adverse environmental effects.

While the GEIS reached generic conclusions regarding many environmental issues associated with license renewal, it did not determine which alternatives are reasonable or reach conclusions about site-specific environmental impact levels. As such, the NRC must evaluate environmental impacts of alternatives on a site-specific basis.

As stated in Chapter 1 of this SEIS, alternatives to renewing STPNOC's operating licenses must meet the purpose and need for the proposed action. They must "provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license to meet future system generating needs, as such needs may be determined by State, utility, and, where authorized, Federal (other than NRC) [decisionmakers]."

The NRC ultimately makes no decision about which alternative (or the proposed action) to carry out because that decision falls to the appropriate energy-planning decisionmakers.

Environmental Impacts of Alternatives

1 Comparing the environmental effects of these
2 alternatives will help the NRC decide if the adverse
3 environmental impacts of license renewal are great
4 enough to deny the option of license renewal for
5 energy-planning decisionmakers
6 (10 CFR 51.95(c)(4)). If the NRC acts to issue a
7 renewed license, all of the alternatives, including the
8 proposed action, will be available to energy-planning
9 decisionmakers. If NRC decides not to renew the
10 license (or takes no action at all), then
11 energy-planning decisionmakers may no longer elect
12 to continue operating STP and will have to resort to
13 another alternative—which may or may not be one of
14 the alternatives considered in this section—to meet
15 their energy needs now being satisfied by STP.

16 In evaluating alternatives to license renewal, the NRC
17 considered energy technologies or options currently
18 in commercial operation, as well as some
19 technologies not currently in commercial operation
20 but likely to be commercially available by the time the
21 current STP operating licenses expire. The current operating licenses for STP, Units 1 and 2,
22 will expire on August 20, 2027, and December 15, 2028, respectively. The NRC's analysis
23 assumed that an alternative must be available (able to be constructed, permitted, and
24 connected to the grid) by the time the current STP licenses expire.

25 NRC eliminated alternatives that cannot meet future system needs by providing the amounts of
26 baseload power equivalent to the STP current generating capacity (2,500 megawatts electric
27 (MWe)) and whose costs or benefits do not justify inclusion in the range of reasonable
28 alternatives from detailed studies. NRC evaluated the remaining alternatives, which are
29 discussed in-depth in this section. Each alternative eliminated from detailed study is briefly
30 discussed, and a basis for its removal is provided at the end of this section. In total, 18 energy
31 technology options and alternatives to the proposed action were considered (see text box) and
32 then narrowed to the 5 alternatives considered in Sections 8.1 through 8.5. The no-action
33 alternative is considered in Section 8.7.

34 The GEIS presents an overview of some energy technologies but does not reach any
35 conclusions about which alternatives are most appropriate. Since 1996, many energy
36 technologies have evolved significantly in capability and cost, while regulatory structures have
37 changed to either promote or impede development of particular alternatives.

38 As a result, the analyses include updated information from the following sources:

- 39 • Energy Information Administration (EIA),
- 40 • other offices within the Department of Energy (DOE),
- 41 • U.S. Environmental Protection Agency (EPA),
- 42 • Electric Reliability Council of Texas (ERCOT),
- 43 • industry sources and publications, and
- 44 • information submitted by the applicant in the STP Nuclear Operating
45 Company's (STPNOC) Environmental Report (ER).

Alternatives Evaluated In-Depth:

- new nuclear,
- natural gas-fired combined-cycle (NGCC),
- supercritical coal,
- combination alternative (NGCC, wind, and energy efficiency and conservation), and
- purchased power.

Other Alternatives Considered:

- offsite nuclear-, gas-, or coal- generation,
- energy efficiency and conservation,
- wind power,
- solar power,
- hydroelectric power,
- wave and ocean energy,
- geothermal power,
- municipal solid waste,
- biomass,
- biofuels,
- oil-fired power,
- fuel cells, and
- delayed retirement.

1 The evaluation of each alternative considers the
 2 environmental impacts across several impact
 3 categories: air quality, groundwater use and
 4 quality, surface water use and quality, aquatic
 5 resources, terrestrial resources, human health,
 6 land use, socioeconomics, transportation,
 7 aesthetics, archaeological and historic resources,
 8 environmental justices, and waste management. A
 9 three-level standard of significance—SMALL,
 10 MODERATE, or LARGE—is used to indicate the
 11 intensity of environmental effects for each
 12 alternative undergoing in-depth evaluation. The
 13 order of presentation is not meant to imply
 14 increasing or decreasing level of impact. Nor does
 15 it imply that an energy-planning decisionmaker
 16 would select one or another alternative.

17 For each alternative where it is feasible to do so,
 18 the NRC considers the environmental effects of
 19 locating the alternative at the existing STP site, as
 20 well as at an alternate site. Selecting the existing
 21 plant site allows for the maximum use of existing
 22 transmission and cooling system infrastructures
 23 and minimizes the overall environmental impact.

24 In addition, to ensure that the alternatives analysis was consistent with State or regional energy
 25 policies, the NRC reviewed energy relevant statutes, regulations, and policies. The NRC also
 26 considered the current generation capacity mix and electricity production data within the
 27 ERCOT service area, in which STP, Units 1 and 2, are located. ERCOT is one of eight regional
 28 reliability councils in North America and operates under the reliability and safety standards set
 29 by the North American Electric Reliability Council (STPNOC 2010a). ERCOT is the
 30 independent system operator for the electric grid for most of Texas and manages the flow of
 31 electric power to approximately 23 million Texas customers, representing 85 percent of the
 32 State’s electric load and 75 percent of the State’s land area. ERCOT is unique because it is
 33 located entirely within the boundaries of the State of Texas. As such, the NRC considered the
 34 current generation capacity mix and electricity production data within the ERCOT service area in
 35 the evaluation of reasonable alternatives. In 2010, electric generators in ERCOT had an
 36 installed generating capacity of approximately 84,400 MWe. This capacity included units fueled
 37 by natural gas (57 percent), coal (23 percent), wind (12 percent), nuclear (6 percent), and other
 38 sources (2 percent). In 2010, the electric generators in ERCOT provided approximately
 39 319 million megawatt-hours of electricity. Electricity produced was dominated by coal
 40 (40 percent) followed by natural gas (38 percent), nuclear (13 percent), wind (8 percent), and
 41 other sources (1 percent) (ERCOT 2011a).

42 Sections 8.1 through 8.5 describe the environmental impacts of alternatives to license renewal.
 43 These alternatives include a new nuclear generation option in Section 8.1; a new NGCC in
 44 Section 8.2; a new coal-fired plant in Section 8.3; a combination alternative of NGCC, wind, and
 45 energy conservation and efficiency in Section 8.4; and purchased power in Section 8.5. In
 46 Section 8.6, alternatives considered but eliminated from detailed study are briefly discussed.
 47 Finally, the environmental effects that may occur if the NRC takes no action and does not issue
 48 renewed licenses for STP are described in Section 8.7. Section 8.8 summarizes, in detail, the
 49 impacts of each of the alternatives considered.

Energy Outlook

Each year, the EIA—part of the DOE—issues its updated Annual Energy Outlook (AEO). AEO 2011, affirms that natural gas, renewable, and coal are likely to fuel most new electrical capacity through 2035, with some growth in nuclear capacity (EIA 2011a), although all projections are subject to future developments in fuel price, electrical demand, and regulatory changes.

“Natural gas-fired plants account for 60 percent of capacity additions between 2010 and 2035 in the AEO2011 Reference case, compared with 25 percent for renewables, 11 percent for coal-fired plants, and 3 percent for nuclear. Escalating construction costs have the largest impact on capital-intensive technologies, including nuclear, coal, and renewables. However, Federal tax incentives, State energy programs, and rising prices for fossil fuels increase the competitiveness of renewable and nuclear capacity. In contrast, uncertainty about future limits on GHG [greenhouse-gas] emissions and other possible environmental regulations reduces the competitiveness of coal-fired plants....” (EIA 2011a).

1 **8.1 New Nuclear Generation**

2 In this section, the NRC staff evaluates the environmental impacts of a new nuclear generation
3 option at the STP site.

4 The NRC considers the construction of two new nuclear plants to be a reasonable alternative to
5 STP license renewal for Units 1 and 2 because nuclear generation currently provides baseload
6 power in the ERCOT region, ERCOT expects additional nuclear generation in the future, and
7 the technology to provide nuclear generation is readily available (ERCOT 2011a). In addition,
8 on September 30, 2007, STPNOC submitted combined license (COL) applications to construct
9 and operate two new advanced boiling water reactor (ABWR) nuclear plants (Units 3 and 4) on
10 the STP site (NRC 2011). In its ER for Units 3 and 4, STPNOC's schedule included 5 years
11 from when NRC issues its licenses to when commercial operations could begin
12 (STPNOC 2010b). Therefore, there is sufficient time for STPNOC to prepare and submit an
13 application and build and operate two new nuclear units before the licenses for Units 1 and 2
14 expire in 2027 and 2028, respectively. This section presents the environmental impacts of the
15 new nuclear generation alternative, which includes constructing and operating two new nuclear
16 plants at the STP site.

17 In evaluating the new nuclear alternative, based on best available information, the NRC
18 presumed that new reactors would be installed on the STP site, allowing for the maximum use
19 of existing ancillary facilities such as the transmission and cooling systems. The NRC further
20 presumed that the new reactors would be two ABWR reactors similar to what the NRC analyzed
21 in its environmental analysis for Units 3 and 4 in its final EIS (NRC 2011). As of
22 September 2012, NRC is continuing to review the STP application for Units 3 and 4. While the
23 licenses have not been granted as of September 2012, the NRC staff is using the results from
24 its final EIS for Units 3 and 4 because it provides a site-specific analysis of two new nuclear
25 plants at the STP site.

26 For the purpose of this analysis, each of the two ABWR reactors would have a net electrical
27 output of approximately 1,300 MWe, which is slightly more than the generating capacity
28 (2,500-MWe capacity) of STP, Units 1 and 2 (STPNOC 2010a). STPNOC (2010a) estimated
29 that the power block and ancillary facilities (excluding the cooling-water system) for the new
30 reactors would require approximately 540 ac (219 ha) and that sufficient contiguous acreage
31 was available on the STP site. Because the heat-rejection demands are similar for Units 1
32 and 2 and proposed Units 3 and 4, the NRC estimated that the existing cooling system—
33 including the existing intake and discharge structures on the main cooling reservoir (MCR) and
34 the Colorado River—would meet the heat-rejection demands of the two new reactors without
35 any modifications. In STPNOC's ER for Units 3 and 4, STPNOC assumed minor modifications
36 would be required to increase operations from two units to four units at the STP site. For the
37 purposes of this analysis, the two new reactors would replace Units 1 and 2 rather than add two
38 new units to the site; therefore, it is unlikely that modification would be required. Construction
39 materials would be delivered via rail, truck, or barge. To accommodate such shipments,
40 STPNOC would need to dredge near the current barge slip, and the rail spur would require
41 upgrades (STPNOC 2010b).

42 NRC assumed that construction of two new nuclear units at the STP site would generally follow
43 the same timeframe as that described in STPNOC's ER for the construction of Units 3 and 4.
44 This schedule included 12 months for site preparation, 45 months after NRC issues the licenses
45 to complete construction and fuel loading, 6 months from fuel loading to initial power generation
46 for Unit 3, and an additional 12 months for Unit 4 (STPNOC 2010b).

1 The NRC also considered the installation of multiple small and modular reactors at the STP site
2 as an alternative to renewing the licenses for STP, Units 1 and 2. NRC established the
3 Advanced Reactor Program in the Office of New Reactors due to considerable interest in small
4 and modular reactors along with anticipated license applications by vendors. As of
5 September 2012 (based on best available information), NRC has not received any applications.
6 Because there are no applications to construct and operate small modular reactors on a
7 commercial scale, this analysis focused on nuclear generation by larger nuclear units.

8 **8.1.1 Air Quality**

9 As discussed in Section 2.2.2.1, the STP site is located in central Matagorda County, Texas, at
10 the southern edge of the Metropolitan Houston-Galveston Intrastate Air Quality Control Region
11 (40 CFR 81.38). The Corpus Christi-Victoria Intrastate Air Quality Control Region
12 (40 CFR 81.136) lies immediately south and west of Matagorda County. EPA has designated
13 all of the counties in these Air Quality Control Regions adjacent to the STP site as in compliance
14 with the National Ambient Air Quality Standards (40 CFR 81.344) except Brazoria County to the
15 north; Brazoria County is classified Nonattainment/Severe relative to the 8-hour ozone standard
16 (EPA 2011b).

17 Construction activities would cause some localized temporary air effects as a result of
18 equipment emissions and fugitive dust from the operation of the earth-moving and
19 material-handling equipment. Emissions from workers' vehicles and motorized construction
20 equipment exhaust would be temporary. Construction crews would use dust-control practices to
21 control and reduce fugitive dust, as proposed for Units 3 and 4 (STPNOC 2010b), and because
22 §111.145 of the Texas Commission for Environmental Quality's (TCEQ) regulations require dust
23 suppression control during the construction of facilities and parking lots.

24 During operations, two new nuclear plants would have similar air emissions to those of existing
25 STP, Units 1 and 2, and those expected from proposed Units 3 and 4; air emissions would be
26 primarily from backup diesel generators. Because air emissions would be similar for the new
27 nuclear plants, the NRC expects similar air permitting conditions and regulatory requirements as
28 that for Units 3 and 4. In STPNOC's ER for Units 3 and 4, STPNOC stated that "[a]ir emissions
29 sources would be managed in accordance with Federal, Texas, and local air quality control laws
30 and regulations." Permitting would likely include a prevention of significant deterioration (PSD)
31 review and an operating permit from TCEQ.

32 STPNOC estimated air emissions during the operation of Units 3 and 4 as part of its COL
33 application (NRC 2011; STPNOC 2010b). The largest stationary sources of emissions would be
34 from three standby diesel generators and a single combustion turbine generator, each of which
35 would be operated about 4 hours per month. Table 8-1 lists the expected annual emissions
36 from these sources. NRC assumed that there would be similar air emissions from two new
37 nuclear units.

38

1
2

Table 8–1. Expected Annual Emissions from the Largest Stationary Sources of Emissions

	Diesel Generators (lb/yr)	Combustion Turbine (lb/yr)
Particulates	2,500	44
Sulfur Oxides	9,200	3,800
Carbon Monoxide	9,200	1,800
Hydrocarbons	6,100	120
Nitrogen Oxides	57,900	4,000

Source: STPNOC 2010b

3 The operation of nuclear power plants involves the emission of some greenhouse gases,
 4 primarily carbon dioxide. NRC (2011) estimated that the total carbon footprint for actual plant
 5 operations of Units 3 and 4 for 40 years is on the order of 650,000 metric tons (MT)
 6 (720,000 tons) of carbon dioxide equivalent (an emissions rate of about 16,000 MT
 7 (18,000 tons) annually, averaged over the period of operation). Periodic testing of diesel
 8 generators and other activities during plant operations accounts for about 60 percent of the
 9 total, or about 190,000 MT (210,000 tons) for each unit. Workforce transportation accounts for
 10 the most of the remaining 40 percent, or about 130,000 MT (140,000 tons) for each unit.
 11 NRC (2011) based these carbon footprint estimates on information included in Appendix I of the
 12 final EIS and emissions data contained in the ER for Units 3 and 4 (STPNOC 2010b).
 13 Equipment maintenance and measures taken to mitigate transportation impacts, such as
 14 properly maintained asphalt or concrete roads and appropriate speed limits (STPNOC 2010b),
 15 would also reduce carbon dioxide emissions, while reducing other emissions. For example,
 16 STPNOC (2010b) states that fugitive dust generated by the commuting workforce would be
 17 minimized by properly maintaining hard-surfaced access roads and setting appropriate speed
 18 limits.

19 Subpart P of 40 CFR Part 51 contains the visibility protection regulatory requirements, including
 20 the review of new sources to be constructed in attainment or unclassified areas and that may
 21 affect visibility in any Federal Class I area. If a new nuclear plant were located close to a
 22 mandatory Class I area, additional air pollution control requirements may be required. As noted
 23 in Section 2.2.2.1, there are no Mandatory Class I Federal areas within 100 mi (161 km) of the
 24 STP site where visibility is an important value.

25 Because construction and operations of two new nuclear units at the STP site would not
 26 noticeably alter air quality, air quality impacts would be SMALL.

27 **8.1.2 Surface Water Resources**

28 The NRC presumes that two new nuclear units would be designed to maximize use of existing
 29 facilities, including the existing intake and discharge structures on the MCR and the Colorado
 30 River. STPNOC did not propose using any surface water during the construction of Units 3
 31 and 4 (NRC 2011); therefore, NRC expects that none would be used during construction for the
 32 new nuclear alternative.

33 Impacts to surface water quality could result from dredging activities in the Colorado River near
 34 the reservoir makeup pumping facility (RMPF) and the barge slip. Dredging can disturb
 35 sediments and potentially increase turbidity near and downstream of the dredged site. The
 36 NRC staff (NRC 2011) determined that the hydrological alterations resulting from site
 37 development would be localized and temporary. Permits and certifications from the U.S. Army

1 Corps of Engineers (USACE) and other agencies would require the implementation of best
2 management practices (BMPs) to minimize impacts.

3 Runoff from construction areas would be controlled under a State-issued Texas Pollutant
4 Discharge Elimination System (TPDES) general permit that would require implementation of a
5 stormwater pollution prevention plan and associated BMPs to prevent or significantly mitigate
6 soil erosion and contamination of stormwater runoff from construction activities. Runoff from
7 construction areas would be limited to the duration of the construction.

8 During normal operations, STPNOC would intermittently withdraw and discharge water from and
9 to the Colorado River to maintain the water quality and quantity in the MCR (NRC 2011). This
10 would continue to occur in accordance with STPNOC's existing water rights and a new or
11 revised State-issued TPDES permit, respectively, under this alternative. Water use would be
12 similar to that of Units 1 and 2. The NRC staff (NRC 2011) estimated current water use for
13 Units 1 and 2 during normal operations to be 3 percent of Texas Water Development Board
14 (TWDB)-estimated Region K water supplies in 2010 (TWDB 2007). Therefore, the impact on
15 surface water use in the Colorado River basin would be minimal.

16 In consideration of the information above, the impacts on surface water use and quality from
17 construction and operations under the new nuclear generation alternative would be SMALL.

18 **8.1.3 Groundwater Resources**

19 The NRC presumes that the two new nuclear units would use existing ancillary facilities at the
20 STP site, including use of the onsite groundwater production wells. To build Units 3 and 4,
21 STPNOC (2010b) proposed withdrawing groundwater from the Deep Aquifer during
22 construction. The NRC staff (NRC 2011) determined that STPNOC's projected drawdown
23 during building activities and the current presence of a sufficient confining head would maintain
24 the Deep Aquifer as a confined aquifer. For construction of the new nuclear units under this
25 alternative, it is assumed that STPNOC's existing wells would be used to supply the relatively
26 small amounts of water (i.e., up to 491 gpm (1,860 L/min)) required for potable and sanitary
27 uses, concrete production, dust suppression and soil compaction, and other uses during
28 construction of the new units (NRC 2011).

29 Excavation for the new reactor foundations could extend to depths of approximately 70 ft (21 m)
30 below ground surface (BGS), and dewatering of the Upper and Lower Shallow Chicot aquifers
31 would be required. However, slurry walls and wells were proposed for use to minimize potential
32 adverse effects from dewatering both on site and off site (NRC 2011). Further, application of
33 BMPs in accordance with a State-issued National Pollutant Discharge Elimination System
34 (NPDES) general permit, including appropriate waste management and spill prevention
35 practices, would prevent or minimize any groundwater quality impacts during construction.

36 During operations of Units 3 and 4, STPNOC proposed to use groundwater for power block
37 operational uses, fire protection systems, and potable and sanitary systems, and to use the
38 existing onsite groundwater production wells at STP. However, one or more additional wells
39 could also be installed to decrease pumping rates at existing wells and to better distribute
40 drawdown impacts in the Deep Aquifer and ensure sufficient withdrawal capacity under
41 STPNOC's existing groundwater permit (NRC 2011). Groundwater use for operation of the two
42 replacement units was presumed to be somewhat higher than for existing STP, Units 1 and 2,
43 but well within the groundwater operating permit held by STPNOC. The groundwater operating
44 permit issued by the Coast Plains Groundwater Conservation District (see Section 2.1.7.2) is for
45 approximately 1,860 gpm (7,040 L/min); STP, Units 1 and 2, use approximately 768 gpm
46 (2,910 L/min) of groundwater; and the new units would require approximately 975 gpm
47 (3,690 L/min) under normal operating conditions (NRC 2011). The NRC concludes that

Environmental Impacts of Alternatives

1 groundwater use and quality impacts are likely to be similar to those observed for STP, Units 1
2 and 2.

3 Based on this information, the overall impact on groundwater use and quality from construction
4 and operations under the new nuclear generation alternative would be SMALL.

5 **8.1.4 Aquatic Ecology**

6 The NRC presumed that two new nuclear units would be designed to maximize use of existing
7 facilities, including the existing intake and discharge structures on the MCR and the Colorado
8 River.

9 Construction activities for two new reactors (such as construction of heavy haul roads and the
10 power blocks) could affect drainage areas or other onsite aquatic features due to site runoff.
11 NRC assumed that STPNOC would install temporary and permanent erosion and sediment
12 control measures to minimize the flow of disturbed soils into ditches and wetlands. Such BMPs
13 would likely be described in a Texas Pollutant Discharge Elimination System (TPDES) general
14 permit relating to stormwater discharges for construction activities.

15 To bring new materials to the site, NRC assumed construction crews would dredge near the
16 barge slip on the Colorado River to transport some materials using barges, which are activities
17 that STPNOC (2010b) proposed for the construction of Units 3 and 4. Permits and certifications
18 from the USACE and other agencies would require the implementation of BMPs to minimize
19 impacts. NRC (2011) determined that such activities would be temporary and unlikely to cause
20 noticeable impacts to aquatic resources.

21 Plant operators would withdraw water from the Colorado River to maintain the proper water
22 quality and quantity in the MCR during operations of two new ABWR units. Aquatic organisms
23 would be impinged and entrained as water is drawn through the RMPF. Biota most vulnerable
24 to entrainment and impingement would be the same as those described in Section 4.5 during
25 the period of continued operations for Units 1 and 2. The low approach velocity at the RMPF
26 (less than or equal to approximately 0.5 ft/s), the use of a pond-based heat-dissipation cooling
27 system, the population status of biota most likely to be impinged and entrained, and the
28 reproductive potential of fish and shellfish most vulnerable to impingement and entrainment
29 would result in minimal adverse impacts to the aquatic ecosystem in the Colorado River near
30 STP.

31 Plant operators would discharge water from the MCR to the Colorado River to maintain water
32 quality within the MCR. Discharge impacts would be similar to those described in Section 4.5
33 for continued operations of STP, Units 1 and 2. Discharges are unlikely to noticeably impact
34 aquatic resources near STP for the following reasons:

- 35 • STPNOC's TPDES permit would limit the amount and timing of discharges.
- 36 • Modeling studies indicate that mobile aquatic species could avoid the thermal
37 plume by swimming at a lower depth or different side of the river (NRC 2011).
- 38 • Species or life-stages that are less mobile organisms would not be able to
39 swim away to avoid the thermal plume, such as eggs, larvae, and mollusks.
40 However, most species observed in this area generally have high fecundity,
41 and the number of organisms lost would be insignificant compared to their
42 population in the lower Colorado River.

- 1 • Cooling water would not be regularly discharged into the Colorado River
2 because STP uses a cooling pond-based heat-dissipation system that reuses
3 water from the MCR.

4 The NRC staff determined that the impacts to aquatic resources on the STP site and in the
5 Colorado River would be SMALL because modifications on site and to the river, such as
6 dredging, would be temporary, and impingement, entrainment, and heat shock would not
7 noticeably impact aquatic resources.

8 **8.1.5 Terrestrial Ecology**

9 STPNOC (2010a) estimated that the power block and ancillary facilities (excluding the
10 cooling-water system) for the new reactors would require approximately 540 ac (219 ha).
11 Construction activities, such as building the heavy haul road and new facilities, would
12 permanently convert approximately 300 ac (121 ha) (STPNOC 2010b). Construction would
13 likely affect a variety of habitats and land uses, including industrial land (buildings, parking
14 areas, and mowed-maintained fields), drainage ditches, scattered small palustrine wetlands,
15 scrub-shrub habitat, and mixed grassland habitat where abandoned farm lands previously
16 existed prior to construction of Units 1 and 2 (NRC 2011; STPNOC 2010b). Most of these areas
17 have been mildly to extensively disturbed during the construction and operations of Units 1
18 and 2 and other human activities. After the completion of the new units, plant operators would
19 likely grade, landscape, and replant the areas used for temporary building support
20 (STPNOC 2010b). The majority of permanently affected areas would be maintained land (e.g.,
21 mowed) or other industrial areas. NRC (2011) determined that the change in habitat availability
22 would unlikely increase fragmentation of onsite habitats available for wildlife. STPNOC would
23 likely implement BMPs to minimize impacts to wetlands. STPNOC would be required to comply
24 with the USACE 404 permits (NRC 2011).

25 Construction activities could also adversely affect onsite wildlife through noise, increased light
26 pollution, and increased traffic. However, NRC (2011) determined that these impacts would be
27 temporary and minor.

28 STPNOC (2010b) did not observe Federally or State-listed threatened or endangered species,
29 critical habitat, or suitable habitats in the proposed disturbance area for Units 3 and 4.
30 NRC (2011) determined that the impacts to special status species from the construction and
31 operation of Units 3 and 4 would be negligible.

32 Because many construction-related impacts would be temporary, and because the majority of
33 long-term construction impacts would occur within previously disturbed areas, impacts on
34 terrestrial resources would be SMALL.

35 **8.1.6 Human Health**

36 The human health effects from two new nuclear power plants would be similar to those of the
37 existing STP, Units 1 and 2, and the proposed Units 3 and 4 (NRC 2011). Human health issues
38 related to construction would be equivalent to those associated with the construction of any
39 major complex industrial facility and would be controlled to acceptable levels through the
40 application of BMPs and STPNOC's compliance with Federal and State worker protection
41 regulations. Human health impacts from operation of the new nuclear reactors would be
42 equivalent to those associated with continued operation of the existing reactors and the
43 proposed Units 3 and 4 (NRC 2011).

44 Both continuous and intermittent noise impacts can be expected at offsite locations, including at
45 the closest residences. However, confining noise-producing activities to core hours of the day

Environmental Impacts of Alternatives

1 (7:00 a.m. to 6:00 p.m.) and notifying potentially affected parties beforehand of such events
2 would control noise impacts to acceptable levels. Noise impacts would be of short duration and
3 would be SMALL.

4 Based on the above information, human health impacts for the construction and operation of
5 two new nuclear units would be SMALL.

6 **8.1.7 Land Use**

7 The GEIS generically evaluates the impacts of constructing and operating various replacement
8 power plant alternatives on land use, both on and off each plant site. The analysis of land use
9 impacts focuses on the amount of land area that would be affected by the construction and
10 operation of a new nuclear power plant at the STP site.

11 STPNOC (2010a) estimated that the power block and ancillary facilities (excluding the
12 cooling-water system) for the two new reactors would require approximately 540 ac (219 ha)
13 and that sufficient contiguous acreage was available on the STP site. A sufficient amount of
14 land is available on site, and most of the area is already in industrial use. Therefore, onsite land
15 use impacts from the construction and operation of two new reactors at the STP site would be
16 SMALL.

17 The amount of land required to mine uranium and fabricate nuclear fuel to support the new
18 nuclear alternative would be similar to the amount of land required to support STP, Units 1
19 and 2, although an additional amount of land would be required to support uranium fuel
20 requirements during the license renewal term. According to GEIS estimates, approximately
21 2,560 ac (1,036 ha) would be needed for the mining and processing of uranium fuel during the
22 operating life of the new nuclear plant. Overall, offsite land use impacts from two new nuclear
23 reactors would be SMALL.

24 **8.1.8 Socioeconomics**

25 Socioeconomic impacts are defined in terms of changes to the demographic and economic
26 characteristics and social conditions of a region. For example, the number of jobs created by
27 the construction and operation of a power plant could affect regional employment, income, and
28 expenditures.

29 Two types of jobs would be created by this alternative: (1) construction jobs, which are
30 transient, short in duration, and less likely to have a long-term socioeconomic impact; and
31 (2) power plant operation jobs, which have the greater potential for permanent, long-term
32 socioeconomic impacts. Workforce requirements for the construction and operation of the new
33 nuclear generation alternative were evaluated to measure their possible effects on current
34 socioeconomic conditions.

35 STPNOC estimated a construction workforce of up to 5,950 (maximum) workers would be
36 required to build Units 3 and 4 at the STP site (STPNOC 2010b). The relative economic
37 impacts of this many workers on the local economy and tax base would vary, with the greatest
38 impacts occurring in the communities where the majority of construction workers would reside
39 and spend their income. As a result, local communities could experience a short-term economic
40 "boom" from increased tax revenue and income generated by construction expenditures and the
41 increased demand for temporary (rental) housing and business services. Some construction
42 workers could relocate to Matagorda and surrounding counties in order to be closer to the
43 construction work site. However, given the proximity of STP to the Houston metropolitan area,
44 many construction workers could commute to the STP site, thereby lessening the need for

1 additional rental housing near STP. After completing the installation of the two new reactor
2 units, local communities could experience a return to pre-construction economic conditions.

3 Based on this information, and given the magnitude of the estimated number of workers,
4 socioeconomic impacts during construction in communities near the STP site could range from
5 SMALL to LARGE.

6 STPNOC also estimated that STP, Units 3 and 4, would require 733 operations workers and an
7 additional 1,100 workers during refueling outages (STPNOC 2010b). The number of operation
8 workers would include some of the 1,378 workers from STP, Units 1 and 2. Socioeconomic
9 impacts during operations could range from SMALL to MODERATE as the STP site transitions
10 to the new reactor units. The potential reduction in overall employment at STP could affect
11 property tax revenue and income in local communities and businesses. In addition, the
12 permanent housing market could also experience increased vacancies and decreased prices if
13 operations workers and their families move out of the region.

14 **8.1.9 Transportation**

15 Transportation impacts associated with the construction and operation of a new two-unit nuclear
16 power plant would consist of commuting workers and truck deliveries of construction materials
17 and equipment to the power plant site. During periods of peak construction activity, up to
18 5,950 workers could be commuting daily to the STP site (STPNOC 2010b). Workers
19 commuting to the STP site would primarily use two-lane roads. The volume of traffic on these
20 roads, and especially Farm-to-Market (FM) 521, would increase substantially. In addition to
21 commuting workers, trucks would be transporting construction materials and equipment to the
22 worksite, further increasing the amount of traffic on local roads. The increase in vehicular traffic
23 would peak during shift changes, resulting in temporary levels of service impacts and delays at
24 intersections. Some power plant components and materials could also be delivered by train or
25 barge (STPNOC 2010a). Train deliveries could cause additional traffic delays at railroad
26 crossings. Based on this information, traffic-related transportation impacts during construction
27 could range from MODERATE to LARGE.

28 Traffic-related transportation impacts would be greatly reduced after completing the installation
29 of the two new reactor units. Transportation impacts would include daily commuting by the
30 operating workforce, equipment and materials deliveries, and the removal of commercial waste
31 material to offsite disposal or recycling facilities by truck. During reactor operations, the
32 estimated number of operations workers commuting to and from STP would be 733 workers
33 (STPNOC 2010b). Traffic-related transportation impacts would be less than current operations
34 because the new units would employ approximately half as many workers as STP, Units 1
35 and 2. However, overall transportation impacts (related to plant operating workers and potential
36 Units 1 and 2 decommissioning workers) would range from SMALL to MODERATE during
37 power plant operations.

38 **8.1.10 Aesthetics**

39 The analysis of aesthetic impacts focuses on the degree of contrast between the new nuclear
40 alternative and the surrounding landscape and the visibility of the new power plant. The new
41 power block would look very similar to the STP, Units 1 and 2, power block.

42 During construction, all of the clearing and excavation would occur on the STP site. These
43 activities may be visible from offsite roads, particularly FM 521. Since the STP site already
44 appears industrial, construction of the new units would appear similar to onsite activities during
45 refueling outages.

Environmental Impacts of Alternatives

1 During reactor operations, the visual appearance of the STP site would not change since the
2 power block for the new nuclear reactors would look virtually identical to the existing STP,
3 Units 1 and 2, power block. Adding two new reactor units would increase the overall size of the
4 existing STP facility if STP, Units 1 and 2, remained. Given the industrial appearance of the
5 STP site and the similarity of the new units to the existing units, the new reactor units would
6 blend in with the surroundings. In addition, the amount of noise generated during reactor
7 operations would be the same as those generated during STP, Units 1 and 2, operations, which
8 consists predominantly of the noise from routine industrial processes and communications. In
9 general, aesthetic changes would be limited to the immediate vicinity of the STP site, and any
10 impacts would be SMALL.

11 **8.1.11 Historic and Archaeological Resources**

12 Cultural resources are the indications of human occupation and use of the landscape, as
13 defined and protected by a series of Federal laws, regulations, and guidelines. Prehistoric
14 resources are physical remains of human activities that predate written records; they generally
15 consist of artifacts that may alone or collectively yield information about the past. Historic
16 resources consist of physical remains that postdate the emergence of written records; in the
17 U.S., they are architectural structures or districts, archaeological objects, and archaeological
18 features dating from 1492 and later. Ordinarily, sites less than 50 years old are not considered
19 historic, but exceptions can be made for such properties if they are of particular importance,
20 such as structures associated with the development of nuclear power (e.g., Shippingport Atomic
21 Power Station) or Cold War themes. American Indian resources are sites, areas, and materials
22 important to American Indians for religious or heritage reasons. Such resources may include
23 geographic features, plants, animals, cemeteries, battlefields, trails, and environmental features.
24 The cultural resource analysis encompassed the power plant site and adjacent areas that could
25 potentially be disturbed by the construction and operation of replacement plant alternatives.

26 The potential for historic and archaeological resources can vary greatly depending on the
27 location of the proposed site. To consider a project's effects on historic and archaeological
28 resources, any affected areas would need to be surveyed to identify and record historic and
29 archaeological resources, identify cultural resources (e.g., traditional cultural properties), and
30 develop possible mitigation measures to address any adverse effects from ground-disturbing
31 activities.

32 As described in Section 2.2.10, much of the STP site has been previously disturbed by the
33 construction of STP, Units 1 and 2. In addition, in preparation for the COL application for
34 Units 3 and 4, STPNOC conducted a cultural resources assessment of the STP site. STPNOC
35 reviewed existing information for the STP site and the area within a 10-mi (16-km) radius.
36 STPNOC concluded that any cultural resource sites that may have existed on site would no
37 longer retain their integrity because the area was heavily disturbed during the construction of
38 Units 1 and 2 (STPNOC 2010b). In December 2006, STPNOC reported these findings to the
39 SHPO at the Texas Historical Commission. The SHPO concurred that there would be no
40 impacts to historic properties in January 2007 (STPNOC 2006; THC 2007).

41 There is a low potential for cultural resources to be located in previously undisturbed portions of
42 the STP site. However, if the new nuclear units were to be sited within undisturbed areas or
43 within areas of known cultural sensitivity (historic grave site located on the property and
44 described in Section 2.2.10), these areas would need to be surveyed by a professional
45 archaeologist to identify and develop possible mitigation measures to address any adverse
46 effects from project activities. NRC assumes STPNOC would follow similar procedures to those
47 described in the final EIS for STP, Units 3 and 4, if any historic or cultural resources were
48 discovered during ground-disturbing activities associated with building the new units

1 (NRC 2011). In the final EIS for STP, Units 3 and 4, the staff concludes that the cumulative
2 impacts to historic and archaeological resource would be SMALL.

3 The NRC staff determined that the impact of new nuclear plants at the STP site on historic and
4 archaeological resources would be SMALL for the following reasons:

- 5 • NRC (2011) and STPNOC (2010a, 2010b) did not identify any cultural
6 resources that could be affected by Units 3 and 4.
- 7 • The SHPO determined that construction for Units 3 and 4 would not affect
8 cultural and historic resources.
- 9 • STPNOC has established environmental compliance procedures for new
10 ground-disturbing activities.

11 **8.1.12 Environmental Justice**

12 The environmental justice impact analysis evaluates the potential for disproportionately high and
13 adverse human health and environmental effects on minority and low-income populations that
14 could result from the construction and operation of a new power plant. Adverse health effects
15 are measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human health.
16 Disproportionately high and adverse human health effects occur when the risk or rate of
17 exposure to an environmental hazard for a minority or low-income population is significant and
18 exceeds the risk or exposure rate for the general population or for another appropriate
19 comparison group. Disproportionately high environmental effects refer to impacts or risk of
20 impact on the natural or physical environment in a minority or low-income community that are
21 significant and appreciably exceed the environmental impact on the larger community. Such
22 effects may include biological, cultural, economic, or social impacts. Some of these potential
23 effects have been identified in resource areas discussed in this SEIS. For example, increased
24 demand for rental housing during power plant construction could disproportionately affect
25 low-income populations. Minority and low-income populations are subsets of the general public
26 living near the STP site, and all are exposed to the same hazards generated from constructing
27 and operating two new nuclear plants. Section 4.9.7, "Environmental Justice," presents
28 demographic information about minority and low-income populations residing in the vicinity of
29 the STP site.

30 Potential impacts to minority and low-income populations from the construction and operation of
31 a new nuclear power plant at the STP site would mostly consist of environmental and
32 socioeconomic effects (e.g., noise, dust, traffic, employment, and housing impacts). Noise and
33 dust impacts during construction would be short-term and primarily limited to onsite activities.
34 Minority and low-income populations residing along site access roads would be directly affected
35 by increased commuter vehicle and truck traffic. However, because of the temporary nature of
36 construction, these effects would only occur at certain hours of the day and are unlikely to be
37 high and adverse. Increased demand for rental housing during construction could also affect
38 low-income populations living near STP. However, given the proximity of STP to the Houston
39 metropolitan area, many construction workers could commute to the STP site, thereby lessening
40 the need for additional rental housing.

41 Based on this information, and the analysis of human health and environmental impacts
42 presented in this SEIS, the construction and operation of a new nuclear power plant would not
43 have disproportionately high and adverse human health and environmental effects on minority
44 and low-income populations residing in the vicinity of the STP site.

1 **8.1.13 Waste Management**

2 During the construction stage of the new nuclear plants, land clearing and other construction
 3 activities would generate waste that could be recycled, disposed of on site, or shipped to an
 4 offsite waste disposal facility. Because the new nuclear plants would be constructed on the
 5 previously disturbed STP site, the amounts of waste produced during land clearing would be
 6 reduced.

7 During the operational stage, normal plant operations, routine plant maintenance, and cleaning
 8 activities would generate nonradioactive waste as well as mixed waste, low-level waste, and
 9 high-level waste. Quantities of nonradioactive waste (discussed in Section 2.3.1 of this SEIS)
 10 and radioactive waste (discussed in Section 6.1 of this SEIS) generated by Units 1 and 2 would
 11 be comparable to that generated by the new nuclear plants.

12 According to the GEIS (NRC 1996), the generation and management of solid nonradioactive
 13 and radioactive waste during the period of renewed licenses are not expected to result in
 14 significant environmental impacts. Two new nuclear plants would generate waste streams
 15 similar to the two existing nuclear plants. Based on this information, waste impacts would be
 16 SMALL for two new nuclear plants located at the STP site.

17 **8.1.14 Summary of Impacts of New Nuclear Generation**

18 Table 8–2 summarizes the environmental impacts of the new nuclear alternative compared to
 19 continued operation of STP.

20 **Table 8–2. Summary of Environmental Impacts of the New Nuclear Alternative**
 21 **Compared to Continued Operation of STP, Units 1 and 2**

Category	New Nuclear Generation (proposed infrastructure)	Continued STP Operation
Air quality	SMALL	SMALL
Surface water	SMALL	SMALL
Groundwater	SMALL	SMALL
Aquatic resources	SMALL	SMALL
Terrestrial resources	SMALL	SMALL
Human health	SMALL	SMALL to MODERATE
Land use	SMALL	SMALL
Socioeconomics	SMALL to LARGE	SMALL
Transportation	MODERATE to LARGE	SMALL
Aesthetics	SMALL	SMALL
Historic & archaeological	SMALL	SMALL
Waste management	SMALL	SMALL

22 **8.2 Natural Gas-Fired Combined-Cycle Generation**

23 In this section, the NRC staff evaluates the environmental impacts of natural gas-fired
 24 combined-cycle (NGCC) generation at the STP site.

1 Natural gas accounted for 38 percent of all electricity generated in the ERCOT service area in
2 2010, accounting for the second greatest share of electrical power (ERCOT 2011a).
3 Development of new natural gas-fired plants may be affected by perceived or actual action to
4 limit greenhouse gas emissions, although they produce markedly fewer greenhouse gases per
5 unit of electrical output than coal-fired plants. Natural gas-fired plants are a feasible,
6 commercially available option for providing electrical generating capacity beyond STPNOC's
7 current license expiration. NRC examined NGCC because NGCC can operate with high
8 thermal efficiency (approximately 60 percent for some units) and is capable of economically
9 providing baseload power. Therefore, NRC considered NGCC generation a reasonable
10 alternative to STP license renewal.

11 NGCC plants differ significantly from coal-fired boilers and existing nuclear plants. NGCC
12 plants derive the majority of their electrical output from a gas-turbine cycle and then generate
13 additional power—without burning any additional fuel—through a second, steam-turbine cycle.
14 The first gas turbine stage (similar to a large jet engine) burns natural gas, which turns a
15 driveshaft that powers an electric generator. The exhaust gas from the gas turbine is still hot
16 enough to boil water to steam. Ducts carry the hot exhaust to a heat-recovery steam generator,
17 which produces steam to drive a steam turbine and produce additional electrical power. The
18 combined-cycle approach is significantly more efficient than any one cycle on its own; thermal
19 efficiency can exceed 60 percent. Because the NGCC alternative derives much of its power
20 from a gas turbine cycle, and because it wastes less heat than the existing STP units, it requires
21 significantly less cooling water than the coal-fired alternative or the existing STP.

22 To replace the 2,500 MWe power that STP generates, NRC considered four hypothetical
23 gas-fired units, each with a net capacity of 640 MWe. For purposes of this analysis, the
24 hypothetical units would be similar to General Electric's (GE's) H-class gas fired combined-cycle
25 units. While any number of commercially available combined-cycle units could be installed in a
26 variety of combinations to replace the power currently produced by STP, GE's H-class units are
27 highly efficient models that would be used to minimize environmental impacts. Other
28 manufacturers, like Siemens, offer similarly high efficiency models.

29 GE's H-class combined-cycle generating units operate at a heat rate of 5,690 British thermal
30 units per kilowatt hours (BTU/kWh), or nearly 60 percent thermal efficiency (GE 2011). As
31 noted above, this NGCC alternative would require much less cooling water than STP because
32 the NGCC units operate at a higher thermal efficiency and because they require much less
33 water for steam cycle condenser cooling. Therefore, the NRC staff assumed that the existing
34 cooling water system, including the intakes and discharges on the MCR and the Colorado River,
35 would be sufficient for this alternative.

36 Construction of onsite visible structures would include the natural gas turbine buildings and
37 heat-recovery steam generators (which may be enclosed in a single building), exhaust stacks,
38 and, if necessary, equipment associated with a natural gas pipeline, such as a compressor
39 station. The NGCC alternative at the STP site would use the existing STP transmission system.
40 Based on GEIS estimates, the plant would require approximately 312 ac (126 ha), which
41 includes a new pipeline that would run approximately 2 mi (3 km) from the STP site to an
42 existing pipeline.

43 This 2,560 MWe NGCC plant would consume 110 billion cubic feet (ft³) (3,111 million cubic
44 meters (m³)) of natural gas annually, assuming an average heat content of 1,029 BTU/ft³
45 (EIA 2009). Natural gas would be extracted from the ground through wells, then treated to
46 remove impurities (like hydrogen sulfide), and blended to meet pipeline gas standards before
47 being piped through the state pipeline system to the plant site. This NGCC alternative would

Environmental Impacts of Alternatives

1 produce relatively little waste, primarily in the form of spent catalysts used for emissions
2 controls.

3 To build the NGCC plant, site crews would clear vegetation from the site, prepare the site
4 surface, and begin excavation before other crews begin actual construction on the plant or any
5 associated infrastructure, including the 2 mi (3 km) pipeline. The NGCC alternative at the STP
6 site would use the existing STP transmission system. Construction materials would be
7 delivered via rail spur, truck, or barge. For the proposed construction of Units 3 and 4,
8 STPNOC proposed dredging near the current barge slip and upgrading the existing rail spur to
9 accommodate shipments of construction materials (STPNOC 2010b). The NRC staff finds this
10 to be reasonable and assumed that dredging and rail spur upgrades would be required for the
11 NGCC alternative.

12 **8.2.1 Air Quality**

13 As discussed in Section 2.2.2.1, the STP site is located in central Matagorda County, Texas, at
14 the southern edge of the Metropolitan Houston-Galveston Intrastate Air Quality Control Region
15 (40 CFR 81.38). The Corpus Christi-Victoria Intrastate Air Quality Control Region
16 (40 CFR 81.136) lies immediately south and west of Matagorda County. EPA has designated
17 all of the counties in these Air Quality Control Regions adjacent to the STP site as in compliance
18 with the National Ambient Air Quality Standards (40 CFR 81.344) except Brazoria County to the
19 north; Brazoria County is classified Nonattainment/Severe relative to the 8-hour ozone standard
20 (EPA 2011b).

21 Construction activities would cause some localized temporary air quality effects because of
22 emissions and fugitive dust from operation of earth-moving and material-handling equipment.
23 Emissions from workers' vehicles and motorized construction equipment would be temporary.
24 NRC assumed that construction crews would use dust-control practices to control and reduce
25 fugitive dust. STPNOC proposed such activities during construction of proposed Units 3 and 4
26 (STPNOC 2010b), and §111.145 of TCEQ's regulations require dust suppression control during
27 the construction of facilities and parking lots.

28 A new NGCC plant would qualify as a new major-emitting industrial facility and would be subject
29 to PSD requirements under the Clean Air Act (CAA) (EPA 2011c). The NGCC plant would need
30 to comply with the standards of performance for electric utility steam generating units set forth in
31 40 CFR Part 60 Subpart KKKK. The plant would also require an operating permit from TCEQ.
32 In STPNOC's ER for Units 3 and 4, STPNOC stated that "[a]ir emissions sources would be
33 managed in accordance with Federal, Texas, and local air quality control laws and regulations."
34 Likewise, NRC assumed that the NGCC plant would also operate in accordance with Federal,
35 Texas, and local air quality control laws and regulations.

36 Subpart P of 40 CFR Part 51 contains the visibility protection regulatory requirements, including
37 the review of new sources that would be constructed in the attainment or unclassified areas and
38 may affect visibility in any Federal Class I area. If an NGCC alternative was located close to a
39 mandatory Class I area, additional air pollution control requirements would be required. As
40 noted in Section 2.2.2.1, there are no mandatory Class I Federal areas within 50 mi of the STP
41 site.

42 The NRC projects the following emissions based on data published by the EIA, EPA, and on
43 performance characteristics and emissions controls:

- 44 • sulfur oxides—192 tons (174 MT) per year,
- 45 • nitrogen oxides—839 tons (761 MT) per year,

- 1 • carbon dioxide—6,068,000 tons (5,995,000 MT) per year,
- 2 • carbon monoxide—847 tons (768 MT) per year,
- 3 • total suspended particles (TSP)—373 tons (338 MT) per year, and
- 4 • particulate matter $\leq 10 \mu\text{m}$ or PM_{10} —373 tons (338 MT) per year.

5 **8.2.1.1 Sulfur Oxide and Nitrogen Oxide**

6 A new NGCC plant would have to comply with Title IV of the CAA (42 USC 7651) reduction
7 requirements for sulfur oxides and nitrogen oxides, which are the main precursors of acid rain
8 and the major cause of reduced visibility. Title IV establishes maximum sulfur oxide and
9 nitrogen oxide emission rates from existing plants and a system of sulfur oxide emission
10 allowances that can be used, sold, or saved for future use by new plants. In addition, in
11 August 2011, EPA published the Cross-State Air Pollution Rule, which included reductions of
12 sulfur oxides and nitrogen oxides in Texas. According to the rule, NGCC plants would need to
13 comply with the new reductions by 2012.

14 As stated above, the new NGCC alternative would produce 192 tons (174 MT) per year of sulfur
15 oxides and 839 tons (761 MT) per year of nitrogen oxides based on the use of the dry low-
16 nitrogen oxide combustion technology and use of the selective catalytic reduction (SCR) to
17 significantly reduce nitrogen oxide emissions. The new plant would be subjected to the
18 continuous monitoring requirements for sulfur oxides and nitrogen oxides, as specified in
19 40 CFR Part 75. The current State Implementation Plan (SIP) for Texas includes a cap and
20 trade program for sulfur and nitrogen oxides. To operate the NGCC plant, sulfur dioxide
21 allowance would need to be purchased from the open market or an existing fossil-fired plant
22 would need to be shut down and those credits would need to be applied to the new plants
23 (STPNOC 2010a). Thus, provided the plant operator is able to purchase sufficient allowances
24 to operate, the NGCC alternative would not add to the net regional sulfur or nitrogen oxide
25 emissions, although it might do so locally.

26 **8.2.1.2 Greenhouse Gases**

27 The new plant would release greenhouse gases, such as carbon dioxide and methane. The
28 plant would be subjected to the continuous monitoring requirements for carbon dioxide, as
29 specified in 40 CFR Part 75. The NGCC plant would emit approximately 6.1 million tons
30 (approximately 6.0 million MT) per year of carbon dioxide emissions.

31 On July 12, 2012, EPA issued a final rule tailoring the applicability criteria that determine which
32 stationary sources and modification to existing projects become subject to permitting
33 requirements for greenhouse emissions under the PSD and Title V Programs of the CAA
34 (77 FR 41051). According to the Tailoring Rule, greenhouse gases are a regulated new source
35 review pollutant under the PSD major source permitting program if the source is otherwise
36 subject to PSD (for another regulated new source review pollutant) and has a greenhouse gas
37 potential to emit equal to or greater than 75,000 tons (68,000 MT) per year of carbon dioxide
38 equivalent (“carbon dioxide equivalent” adjusting for different global warming potentials for
39 different greenhouse gases). Such sources would be subject to best available control
40 technology (BACT), although EPA has yet to determine BACT for greenhouse gases.

41 EPA issued a Federal Implementation Plan (FIP) on May 3, 2011, to permit greenhouse
42 gas-emitting sources in states that do not have measures to lower greenhouse gases in their
43 SIP. Because Texas has not updated its SIP to include greenhouse gases, EPA will be the
44 official permitting authority for greenhouse gas-emitting sources in Texas if the SIP is not
45 updated before the NGCC plant begins operations.

1 **8.2.1.3 Particulates**

2 The new NGCC alternative would produce 373 tons (338 MT) per year of TSP, all of which
3 would be emitted as PM₁₀. STPNOC (2010a) indicated that all PM₁₀ emissions would be
4 particulate matter, ≤2.5 μm or PM_{2.5}. DOE (2007) evaluated the emissions from a hypothetical
5 560 MWe NGCC unit using BACT to meet the emission requirements of the 2006 New Source
6 Performance Standards. DOE concluded that emissions from particulates would be negligible
7 because NGCC uses natural gas as fuel; therefore, NGCC plants would not require emissions
8 controls equipment or features to reduce these emissions.

9 During the construction of an NGCC plant, onsite activities would also generate fugitive dust.
10 Vehicles and motorized equipment would create exhaust emissions during the construction
11 process. These impacts would be intermittent and short-lived; however, to minimize dust
12 generation, construction crews would use applicable dust-control measures, as described
13 above.

14 **8.2.1.4 Hazardous Air Pollutants**

15 In December 2000, EPA issued regulatory findings (65 FR 79825) on emissions of hazardous
16 air pollutants (HAPs) from electric utility steam-generating units, which said that natural
17 gas-fired plants emit HAPs such as arsenic, formaldehyde, and nickel and stated the following:

18 Also in the utility RTC (Report to Congress), the EPA indicated that the impacts
19 due to HAP emissions from natural gas-fired electric utility steam generating
20 units were negligible based on the results of the study. The Administrator finds
21 that regulation of HAP emissions from natural gas-fired electric utility steam
22 generating units is not appropriate or necessary.

23 As a result of EPA's conclusion, the NRC staff finds no significant air quality effects from HAPs.

24 **8.2.1.5 Conclusion**

25 Based on this information, the overall air quality impacts of a new NGCC plant located at the
26 STP site would be SMALL to MODERATE. Impacts would not be noticeable for sulfur and
27 nitrogen oxides because the Texas SIP requires a Cap and Trade Program, and there would be
28 no net increase in sulfur and nitrogen oxide emissions. Based on analyses from DOE (2007)
29 and EPA (2000, 65 FR 79825), TSPs and HAPs would have negligible impacts. Greenhouse
30 gas emissions would be noticeable; carbon dioxide emissions would be two orders of magnitude
31 larger than the threshold in EPA's tailoring rule for greenhouse gas (75,000 tons or 68,000 MT)
32 per year of carbon dioxide equivalent), which would trigger a regulated new source review.

33 **8.2.2 Surface Water Resources**

34 STPNOC did not propose using any surface water during the construction of Units 3 and 4
35 (NRC 2011). As a new NGCC plant would occupy a much smaller footprint relative to new
36 nuclear units, and its construction would entail less extensive excavation and earthwork, NRC
37 expects that surface water would not be used during construction for the NGCC alternative.

38 Some temporary impacts to surface water quality may result from dredging activities in the
39 Colorado River near the barge slip and from increased sediment loading in stormwater runoff
40 from active construction areas. Due to the short-term nature of the dredging activities, the
41 hydrologic alterations and sedimentation would be localized and temporary. Dredging would
42 also be conducted under a permit from the USACE requiring the implementation of BMPs to
43 minimize impacts. Runoff from construction areas would be controlled under a State-issued
44 TPDES general permit that would require implementation of a stormwater pollution prevention

1 plan and associated BMPs to prevent or significantly mitigate soil erosion and contamination of
2 stormwater runoff from construction activities.

3 For facility operations, the NGCC alternative would require much less cooling water than STP,
4 Units 1 and 2, and consumptive water use would be much less. It is expected that use of the
5 existing intake and discharge infrastructure on the MCR and the Colorado River would be
6 sufficient to support this alternative. Surface water withdrawals would be subject to, and would
7 remain well within, STPNOC's existing water rights, and effluent discharges and stormwater
8 discharges associated with industrial activity would subject to a revised State-issued TPDES
9 permit under this alternative.

10 In consideration of the above, the impacts on surface water use and quality from construction
11 and operations under the NGCC alternative would be SMALL.

12 **8.2.3 Groundwater Resources**

13 Construction-related ground disturbance and excavation work would be substantially less than
14 that described for the new nuclear alternative. Although groundwater dewatering of foundation
15 excavations for a new NGCC plant would likely be required, slurry walls and wells were
16 proposed for use to minimize potential adverse effects from dewatering both on site and off site
17 (NRC 2011). Application of BMPs in accordance with a state-issued NPDES general permit,
18 including appropriate waste management and spill prevention practices, would prevent or
19 minimize any groundwater quality impacts during construction.

20 STPNOC assumed that a fossil-fuel-fired generation facility would be located adjacent to the
21 STP, Units 1 and 2, site to use the existing infrastructure, including continued use of existing
22 onsite groundwater production wells at STP. Groundwater use for construction of a new NGCC
23 plant would be substantially less than the volume required for new nuclear units under this
24 alternative by virtue of the smaller footprint involved for excavation, earthwork, and structural
25 work. This would encompass such uses as potable and sanitary uses, concrete production,
26 dust suppression and soil compaction, and other uses.

27 For NGCC plant operations, NRC assumed that the NGCC alternative would entail the same
28 relative ratio of groundwater use to surface water use as that used at STP, Units 1 and 2. This
29 includes the use of groundwater for freshwater and service water makeup, potable and sanitary
30 uses, and fire protection. Consequently, it is expected that total groundwater usage and
31 associated aquifer effects would likely be much less under this alternative than those under
32 current STP operations. This is because of the fewer number of auxiliary systems requiring
33 groundwater and the much smaller workforce under the NGCC alternative.

34 Based on this information, the overall impact on groundwater use and quality from construction
35 and operations under the NGCC alternative would be SMALL.

36 **8.2.4 Aquatic Ecology**

37 Construction activities for the NGCC alternative (such as construction of heavy haul roads and
38 the power blocks) could affect drainage areas or other onsite aquatic features. NRC assumed
39 that the plant operator would install temporary and permanent erosion and sediment control
40 measures to minimize the flow of disturbed soils into ditches and wetlands. Such BMPs would
41 likely be described in a TPDES general permit relating to stormwater discharges for construction
42 activities. To bring new materials to the site, NRC assumed the plant operator would dredge
43 near the barge slip to transport some materials using barges. Permits and certifications from
44 the USACE and other agencies would require the implementation of BMPs to minimize impacts.

Environmental Impacts of Alternatives

1 Due to the short-term nature of the dredging activities, the hydrological alterations to aquatic
2 habitats would be localized and temporary.

3 During operations, the NGCC alternative would require less cooling water to be withdrawn from
4 the Colorado River than STP, Units 1 and 2, requires. Therefore, the number of fish and other
5 aquatic organisms affected by impingement and entrainment would be less for an NGCC
6 alternative than for those associated with license renewal. The NGCC alternative would also
7 discharge less thermal effluent because less cooling water would be required. STPNOC's
8 TPDES permit limits the daily discharge to 144 million gpd and shall not exceed 12.5 percent of
9 the flow of the Colorado River at the discharge point (TCEQ 2005). STPNOC has discharged to
10 the Colorado River once during the operation of STP in 1997 as part of a system test
11 (STPNOC 2010a). Because the thermal discharge would be smaller than STP, Units 1 and 2,
12 the number of fish and other aquatic organisms affected by heat shock would be less for an
13 NGCC alternative than for those associated with license renewal.

14 The NGCC plant emission has specific impacts to the aquatic ecology. The cooling system for
15 a new NGCC plant would have similar chemical discharges as STP, but the air emissions from
16 the NGCC plant would emit particulates that would settle onto the river surface and introduce a
17 new source of pollutants that would not exist if STP continued operating. However, the flow of
18 the Colorado River would dissipate pollutants, which would decrease the concentration of
19 pollutants and minimize the exposure of fish and other aquatic organisms to pollutants.

20 Construction activities would require BMPs; dredging would be short-term; the surface water
21 withdrawal and discharge for this alternative would be less than for STP, Units 1 and 2; and
22 pollutants would dissipate within the Colorado River (minimizing exposure concentrations to
23 aquatic resources). Therefore, impacts on aquatic ecology would be SMALL.

24 **8.2.5 Terrestrial Ecology**

25 Constructing the NGCC alternative would require approximately 312 ac (126 ha), which includes
26 a new pipeline that would run approximately 2 mi (3 km) from the STP site to an existing
27 pipeline. These land disturbances form the basis for impacts on terrestrial ecology.

28 If the NGCC alternative was constructed at the STP site, construction would likely affect a
29 variety of habitats and land uses, including industrial land (buildings, parking areas, and
30 mowed-maintained fields), drainage ditches, scattered small palustrine wetlands, scrub-shrub
31 habitat, and mixed grassland habitat where abandoned farm lands previously existed prior to
32 construction of Units 1 and 2. Most of these areas have been mildly to extensively disturbed
33 during the construction and operation of Units 1 and 2 and other human activities. After the
34 completion of the new units, the plant operator would likely grade, landscape, and replant the
35 areas used for temporary building support, which is similar to what STPNOC proposed to do
36 after completion of proposed new nuclear Units 3 and 4 (STPNOC 2010b). The majority of
37 permanently affected areas would be maintained (e.g., mowed) and industrial areas. The plant
38 operator would likely implement BMPs to minimize impacts to wetlands, and the plant operator
39 would be required to comply with the USACE 404 permits. Construction activities could also
40 adversely affect onsite wildlife through noise, increased light pollution, and increased traffic.
41 However, these impacts would be temporary and minor.

42 Gas extraction and collection would also affect terrestrial ecology in offsite gas fields, although
43 much of this land is likely already disturbed by gas extraction, and the incremental effects of this
44 alternative on gas field terrestrial ecology are difficult to gauge.

45 Construction of the 2-mi (3-km) natural gas pipeline could also increase habitat fragmentation.
46 To the extent possible, STPNOC would route the pipeline through previously disturbed areas

1 (STPNOC 2010a). Threatened and endangered species may also be affected by construction
2 of the natural gas pipeline. Long-linear projects, such as pipelines, can often be sited to avoid
3 sensitive areas. Once construction is completed, impacts would be minimal, especially in
4 previously disturbed areas.

5 Because many construction-related impacts would be temporary, and because the majority of
6 long-term construction impacts would occur within previously disturbed areas, impacts on
7 terrestrial resources would be SMALL.

8 **8.2.6 Human Health**

9 An NGCC plant would emit criteria air pollutants, but generally in smaller quantities than a
10 coal-fired plant (except nitrogen oxide, which requires additional controls to reduce emissions).
11 The human health effects of NGCC generation are generally low, although in Table 8–2 of the
12 GEIS (NRC 1996), the NRC identified cancer and emphysema as potential health risks from
13 natural gas-fired plants. Nitrogen oxide emissions contribute to ozone formation, which in turn
14 contributes to human health risks. Emission controls on this NGCC alternative maintain
15 nitrogen oxide emissions well below air quality standards established for the purposes of
16 protecting human health, and emissions trading or offset requirements mean that overall
17 nitrogen oxide in the region would not increase. Health risks to workers may also result from
18 handling spent catalysts that may contain heavy metals.

19 Overall, human health risks to occupational workers and to members of the public from NGCC
20 plant emissions sited at the STP site would likely be SMALL.

21 Noise during plant operations would be limited to industrial processes and communications.
22 Pipelines delivering natural gas fuel could be audible off site near compressor stations. Pipeline
23 companies would need to adhere to local ordinances regarding maximum noise levels during
24 construction and at compressor stations. Therefore, impacts from noise would likely be SMALL.

25 **8.2.7 Land Use**

26 The GEIS generically evaluates the impact of constructing and operating various replacement
27 power plant alternatives on land use, both on and off each plant site. The analysis of land use
28 impacts focuses on the amount of land area that would be affected by the construction and
29 operation of a four-unit NGCC plant at the STP site.

30 Based on scaled GEIS estimates and information provided by STPNOC in its ER, approximately
31 312 ac (126 ha) of land would be needed to support an NGCC alternative to replace STP. This
32 amount of land use would include other plant structures and associated infrastructure, such as
33 the new 2-mi (3-km) pipeline, and is unlikely to exceed 312 ac (126 ha), excluding land for
34 natural gas wells and collection stations.

35 In addition to onsite land requirements, land would be required off site for natural gas wells and
36 collection stations. Scaling from GEIS estimates, approximately 9,600 ac (3,885 ha) would be
37 required for wells and collection stations to bring the gas to the plant. Gas well and collection
38 stations could noticeably alter land use in those areas, although most of this land requirement
39 would occur in areas where gas extraction already occurs.

40 The elimination of uranium fuel for STP could partially offset offsite land requirements. Scaling
41 from GEIS estimates approximately 2,560 ac (1,036 ha) would not be needed for mining and
42 processing uranium during the operating life of the plant. Overall land-use impacts from the
43 natural gas alternative (considering the amount of additional offsite land needed for NGCC gas

Environmental Impacts of Alternatives

1 pipeline infrastructure and gas well and collection station development) could range from
2 SMALL to MODERATE.

3 **8.2.8 Socioeconomics**

4 Socioeconomic impacts are defined in terms of changes to the demographic and economic
5 characteristics and social conditions of a region. For example, the number of jobs created by
6 the construction and operation of a power plant could affect regional employment, income, and
7 expenditures. Two types of jobs would be created by this alternative: (1) construction-related
8 jobs, which are transient, short in duration, and less likely to have a long-term socioeconomic
9 impact; and (2) power plant operation jobs, which have the greater potential for permanent,
10 long-term socioeconomic impacts. Workforce requirements for the construction and operation
11 of the NGCC alternative were evaluated to measure their possible effects on current
12 socioeconomic conditions.

13 Scaling from GEIS estimates, the construction workforce would peak at 3,200 workers.
14 STPNOC projected a maximum construction workforce of 2,028 workers (STPNOC 2010a).
15 STPNOC's estimate appears reasonable; therefore, it is used in this analysis. The relative
16 economic impact of this many workers on the local economy and tax base would vary, with the
17 greatest impacts occurring in the communities where the majority of construction workers would
18 reside and spend their income. As a result, local communities could experience a short-term
19 economic "boom" from increased tax revenue and income generated by construction
20 expenditures and the increased demand for temporary (rental) housing and business services.
21 Some construction workers could relocate to Matagorda and surrounding counties in order to be
22 closer to the construction work site. However, given the proximity of STP to the Houston
23 metropolitan area, many construction workers could commute to the STP site, thereby lessening
24 the need for additional rental housing near STP.

25 After completing the installation of the four-unit NGCC plant, local communities could
26 experience a return to pre-construction economic conditions. Based on this information, and
27 given the number of workers, socioeconomic impacts during construction in communities near
28 the STP site could range from SMALL to MODERATE.

29 Scaling from GEIS estimates, the plant operation workforce would be 400 workers. STPNOC
30 estimated a plant operations workforce of approximately 97 workers. The STPNOC estimate
31 appears to be reasonable and is consistent with trends toward lowering labor costs by reducing
32 the size of plant operations workforces. The amount of property taxes paid under the NGCC
33 alternative may increase if additional land is required off site to support this alternative.
34 Socioeconomic impacts during operations could range from SMALL to MODERATE as the STP
35 site transitions to the new NGCC power plant. The potential reduction in overall employment at
36 STP could affect property tax revenue and income in local communities and businesses. In
37 addition, the permanent housing market could also experience increased vacancies and
38 decreased prices if operations workers and their families move out of the region.

39 **8.2.9 Transportation**

40 Transportation impacts associated with construction and operation of a four-unit, NGCC plant
41 would consist of commuting workers and truck deliveries of construction materials to the STP
42 site. During periods of peak construction activity, up to 2,028 workers could be commuting daily
43 to the site (STPNOC 2010a). Workers commuting to the STP site would primarily use two-lane
44 roads. The volume of traffic on these roads, and especially FM 521, would increase
45 substantially. In addition to commuting workers, trucks would be transporting construction
46 materials and equipment to the worksite, thus increasing the amount of traffic on local roads.

1 The increase in vehicular traffic would peak during shift changes, resulting in temporary levels of
2 service impacts and delays at intersections. Pipeline construction and modification to existing
3 natural gas pipeline systems could also have a temporary impact. Some power plant
4 components and materials could also be delivered by train or barge. Train deliveries could
5 cause additional traffic delays at railroad crossings. Based on this information, traffic-related
6 transportation impacts during construction could range from SMALL to MODERATE.

7 Traffic-related transportation impacts would be greatly reduced after completing the installation
8 of the new NGCC units. Transportation impacts would include daily commuting by the operating
9 workforce, equipment and materials deliveries, and the removal of commercial waste material to
10 offsite disposal or recycling facilities by truck. During operations, the estimated number of
11 operations workers commuting to and from STP would be 97 workers (STPNOC 2010a). Since
12 fuel is transported by pipeline, the transportation infrastructure would experience little to no
13 increased traffic from plant operations. Traffic-related transportation impacts would be
14 considerably less than current operations because the new NGCC power plant would employ
15 far fewer workers than STP, Units 1 and 2. Overall, transportation impacts would be SMALL
16 during plant operations.

17 **8.2.10 Aesthetics**

18 The analysis of aesthetic impacts focuses on the degree of contrast between the NGCC
19 alternative and the surrounding landscape and the visibility of the NGCC plant. During
20 construction, all of the clearing and excavation would occur on the STP site. These activities
21 may be visible from offsite roads, particularly FM 521. Since the STP site already appears
22 industrial, construction of the NGCC power plant would appear similar to onsite activities during
23 refueling outages.

24 The four NGCC units could be approximately 100 ft (30 m) tall, with two exhaust stacks up to
25 175 ft (53 m) tall. The facility would be visible off site during daylight hours, and some
26 structures may require aircraft warning lights. The power plant would be smaller and less
27 noticeable than STP, Units 1 and 2, which has a reactor building height of approximately 250 ft
28 (76 m) (STPNOC 2010b). Noise generated during NGCC power plant operations would be
29 limited to routine industrial processes and communications. Pipelines delivering natural gas fuel
30 could be audible off site near gas compressor stations.

31 In general, given the industrial appearance of the STP site, the new NGCC power plant would
32 blend in with the surroundings if the existing STP, Units 1 and 2, remains. Aesthetic changes
33 would be limited to the immediate vicinity of the existing STP site, and any impacts would be
34 SMALL.

35 **8.2.11 Historic and Archaeological Resources**

36 The same considerations, discussed in Section 8.1.11, for the impact of the construction of a
37 new nuclear plant on historic and archaeological resources apply to the construction activities
38 that would occur on the STP site for an NGCC plant. As described in Section 2.2.10, much of
39 the STP site has been previously disturbed by the construction of STP, Units 1 and 2. In
40 addition, in preparation for the COL application for Units 3 and 4, STPNOC conducted a cultural
41 resources assessment of the STP site. STPNOC reviewed existing information for the STP site
42 and the area within a 10-mi (16-km) radius. STPNOC concluded that any cultural resource sites
43 that may have existed on site would no longer retain their integrity because the area was heavily
44 disturbed during the construction of Units 1 and 2 (STPNOC 2010b). In December 2006,
45 STPNOC reported these findings to the SHPO at the Texas Historical Commission. The SHPO

Environmental Impacts of Alternatives

1 concurred, in January 2007, that there would be no impacts to historic properties
2 (STPNOC 2006; THC 2007).

3 There is a low potential for cultural resources to be located in previously undisturbed portions of
4 the STP site. However, if the NGCC units were to be sited within undisturbed areas or within
5 areas of known cultural sensitivity (historic grave site located on the property and described in
6 Section 2.2.10), these areas would need to be surveyed by a professional archaeologist to
7 identify and develop possible mitigation measures to address any adverse effects from project
8 activities. NRC assumes the plant operator would follow similar procedures to those described
9 in the final EIS for STP, Units 3 and 4 (NRC 2011), if the plant operator discovered any historic
10 or cultural resources during ground-disturbing activities associated with building the new units.

11 Studies would be needed for all areas of potential disturbance at the proposed plant site and
12 along associated corridors where new construction would occur (e.g., the new 2-mi pipeline,
13 roads, transmission corridors, rail lines, or other rights-of-way (ROWs)). In most cases,
14 long-linear projects can be sited to avoid areas of greatest sensitivity.

15 The NRC staff determined that the impact of the NGCC alternative at the STP site on historic
16 and archaeological resources would be SMALL for the following reasons:

- 17 • NRC (2011) and STPNOC (2010a, 2010b) did not identify any cultural
18 resources that could be affected by Units 3 and 4.
- 19 • The SHPO determined that construction for Units 3 and 4 would not affect
20 cultural and historic resources.
- 21 • Long-linear projects (e.g., pipelines) can usually be sited to avoid sensitive
22 areas.
- 23 • NRC assumes that the plant operator would follow environmental compliance
24 procedures for new ground-disturbing activities.

25 **8.2.12 Environmental Justice**

26 The environmental justice impact analysis evaluates the potential for disproportionately high and
27 adverse human health, environmental, and socioeconomic effects on minority and low-income
28 populations that could result from the construction and operation of a new power plant. As
29 previously discussed in Section 8.1.12, such effects may include human health, biological,
30 cultural, economic, or social impacts. Some of these potential effects have been identified in
31 resource areas discussed in this SEIS. For example, increased demand for rental housing
32 during plant construction could disproportionately affect low-income populations. Minority and
33 low-income populations are subsets of the general public living near the STP site, and all are
34 exposed to the same hazards generated from constructing and operating a new NGCC plant.
35 Section 4.9.7, "Environmental Justice," presents demographic information about minority and
36 low-income populations residing in the vicinity of the STP site.

37 Potential impacts to minority and low-income populations from the construction and operation of
38 a new NGCC plant at the STP site would mostly consist of environmental and socioeconomic
39 effects (e.g., noise, dust, traffic, employment, and housing impacts). Noise and dust impacts
40 during construction would be short-term and primarily limited to onsite activities. Minority and
41 low-income populations residing along site access roads would be directly affected by increased
42 commuter vehicle and truck traffic. However, because of the temporary nature of construction,
43 these effects would only occur during certain hours of the day and are unlikely to be high and
44 adverse. Increased demand for rental housing during construction could also affect low-income
45 populations living near STP. However, given the proximity of STP to the Houston metropolitan

1 area, many construction workers could commute to the STP site, thereby lessening the
2 additional need for rental housing.

3 Based on this information, and the analysis of human health and environmental impacts
4 presented in this SEIS, the construction and operation of a new NGCC power plant would not
5 have disproportionately high and adverse human health and environmental effects on minority
6 and low-income populations residing in the vicinity of the STP site.

7 **8.2.13 Waste Management**

8 During the construction stage of the NGCC generation alternative, land clearing and other
9 construction activities would generate waste that could be recycled, disposed of on site, or
10 shipped to an offsite waste disposal facility. Because the alternative would be constructed on or
11 near the previously disturbed STP site, the amounts of waste produced during land clearing
12 would be reduced.

13 During the operational stage, spent SCR catalysts, which are used to control nitrogen oxide
14 emissions from the NGCC plants, would make up the majority of the waste generated by this
15 alternative.

16 According to the GEIS (NRC 1996), an NGCC plant would generate minimal waste. Waste
17 impacts would therefore be SMALL for an NGCC alternative located at the STP site.

18 **8.2.14 Summary of Impacts for the NGCC Generation Alternative**

19 Table 8–3 summarizes the environmental impacts of the NGCC alternative compared to
20 continued operation of STP.

21 **Table 8–3. Summary of Environmental Impacts of the NGCC Alternative**
22 **Compared to Continued Operation of STP**

Category	Natural Gas Combined-Cycle Generation	Continued STP Operation
Air quality	SMALL to MODERATE	SMALL
Surface water	SMALL	SMALL
Groundwater	SMALL	SMALL
Aquatic resources	SMALL	SMALL
Terrestrial resources	SMALL	SMALL
Human health	SMALL	SMALL to MODERATE
Land use	SMALL to MODERATE	SMALL
Socioeconomics	SMALL to MODERATE	SMALL
Transportation	SMALL to MODERATE	SMALL
Aesthetics	SMALL	SMALL
Historic & archaeological	SMALL	SMALL
Waste management	SMALL	SMALL

1 **8.3 Supercritical Coal-Fired Generation**

2 In this section, the NRC staff evaluates the environmental impacts of supercritical coal-fired
3 generation at the STP site.

4 Coal-fired generation accounted for 40 percent of all electricity generated in the ERCOT service
5 area in 2010, accounting for the greatest share of electrical power (ERCOT 2011a).

6 Furthermore, the EIA projects that coal-fired power plants will account for the greatest share of
7 capacity additions through 2035—more than natural gas, nuclear, or renewable generation
8 options (EIA 2011a). Development of new coal-fired plants may be affected by perceived or
9 actual action to limit greenhouse gas emissions. TCEQ has recently granted permits to several
10 recently proposed coal-fired plants (TCEQ 2011). Supercritical coal-fired plants are feasible,
11 commercially available options for providing electrical generating capacity beyond STPNOC's
12 current license expiration. Therefore, NRC considered supercritical coal fired-generation a
13 reasonable alternative to STP license renewal.

14 Supercritical technologies are increasingly common in new coal-fired plants. Supercritical
15 facilities operate at higher temperatures and pressures than most existing coal-fired plants. At
16 the critical point, there is no change of state when pressure is increased or if heat is added. For
17 states above the critical point, the steam is supercritical. Operating at higher temperatures and
18 pressures allows the supercritical coal-fired alternative to operate at a higher thermal efficiency
19 than subcritical coal-fired power plants. While supercritical facilities are more expensive to
20 construct, they consume less fuel for a given output, reducing environmental impacts. Based on
21 technology forecasts from EIA, the NRC staff expects that a new, supercritical coal-fired plant
22 would operate at a heat rate of 8,740 Btu/kWh (EIA 2011b).

23 In a supercritical coal-fired power plant, burning coal heats pressurized water. As the
24 supercritical steam and water mixture moves through plant pipes to a turbine generator, the
25 pressure drops. The mixture flashes to steam. The heated steam expands across the turbine
26 stages, which then spin and turn the generator to produce electricity. After passing through the
27 turbine, any remaining steam is condensed back to water in the plant's condenser.

28 To replace the 2,500 MWe of power that STP generates, the NRC staff considered four
29 hypothetical coal-fired units, each with a net capacity of 640 MWe. The hypothetical coal-fired
30 plant would require a similar amount of water as STP, Units 1 and 2. Therefore, the NRC staff
31 assumed that the existing cooling water system, including the intakes and discharges on the
32 MCR and the Colorado River, would be sufficient for this alternative. The coal-fired alternative
33 at the STP site would also use the existing STP transmission system.

34 The hypothetical 2,560 MWe power plant would consume 11.4 million tons (10.4 MT) of coal
35 annually, based an average heat content of 8,200 British thermal units per pound (Btu/lb)
36 (STPNOC 2010a). EPA (2011a) reported that the majority of coal plants within the ERCOT
37 region use subbituminous coal. The other coal plants used lignite or combined subbituminous
38 coal with lignite. While lignite is the most common type of coal found in Texas, NRC assumed
39 that the hypothetical coal plant for this alternative would use subbituminous coal because when
40 combusted, it releases lower levels of Federal CAA criteria pollutants, such as carbon dioxide,
41 nitrous oxides, sulfuric oxides, and particulate matter (TCPA 2008).

42 Texas coal plants commonly use Power River Basin coal (STPNOC 2010a; TCPA 2008). Given
43 current coal mining operations in Wyoming, the coal used in this alternative would likely be
44 mined in surface mines, then mechanically processed and washed, before being transported—
45 likely by rail—to the power plant site. Limestone for scrubbers would also likely arrive by rail
46 (STPNOC 2010a). This coal-fired alternative would produce roughly 446,000 tons
47 (405,000 MT) of ash, and 43 percent (193,000 tons (175,000 MT)) of the ash would be recycled

1 for beneficial use (STPNOC 2010a). STPNOC (2010a) estimated that approximately
2 88,000 tons (80,000 MT) of scrubber sludge would be disposed of on site each year, which was
3 based on an assumed annual lime usage of approximately 107,000 tons (97 MT).
4 Approximately 200 ac (81 ha) would be required to dispose of the ash and scrubber waste on
5 site over a 40-year plant life (STPNOC 2010a).

6 Construction of onsite visible structures would include the boilers and heat-recovery steam
7 generators (which may be enclosed in a single building), exhaust stacks, and an electrical
8 switchyard. Based on GEIS estimates, the plant would require approximately 4,629 ac
9 (1,873 ha) of land. STPNOC (2010a) estimates that 353 ac (143 ha) of land would be required.
10 This estimate appears reasonable; therefore, it is used for this analysis.

11 To build the coal-fired alternative, site crews would clear the plant site of vegetation, prepare the
12 site surface, and begin excavation before other crews begin actual construction on the plant and
13 any associated infrastructure. Construction materials would be delivered via rail spur, truck, or
14 barge. For the proposed construction of Units 3 and 4, STPNOC proposed dredging near the
15 current barge slip and upgrading the existing rail spur to accommodate shipments of
16 construction materials (STPNOC 2010b). The NRC staff finds this to be reasonable and
17 assumed that dredging and rail spur upgrades would be required for the coal-fired alternative.

18 The NRC also considered an integrated gasification combined cycle (IGCC) coal-fired plant.
19 IGCC is an emerging technology for generating electricity with coal that combines modern coal
20 gasification technology with both gas turbine and steam turbine power generation. The
21 technology is cleaner than conventional pulverized coal plants because major pollutants can be
22 removed from the gas stream before combustion. The IGCC alternative also generates less
23 solid waste than the pulverized coal-fired alternative. The largest solid waste stream produced
24 by IGCC installations is slag, a black, glassy, sand-like material that is potentially a marketable
25 byproduct. The other large-volume byproduct produced by IGCC plants is sulfur, which is
26 extracted during the gasification process and can be marketed rather than placed in a landfill.
27 IGCC units do not produce ash or scrubber wastes. In spite of the preceding advantages, the
28 NRC concluded in the final EIS for the proposed Units 3 and 4 (NRC 2011) that a new IGCC
29 plant is not a reasonable alternative for the following reasons:

- 30 • IGCC plants are more expensive than comparable pulverized coal plants
31 (NETL 2007).
- 32 • The few existing IGCC plants in the U.S. have considerably smaller capacity
33 (approximately 250 MWe each) than STP, Units 1 and 2.
- 34 • System reliability of existing IGCC plants has been lower than pulverized coal
35 plants.
- 36 • The existing IGCC plants have had an extended (though ultimately
37 successful) operational testing period (NPCC 2005).
- 38 • A lack of overall plant performance warranties for IGCC plants has hindered
39 commercial financing (NPCC 2005).

40 At present, the NRC continues to find this determination reasonable. While the capacity of
41 some of the proposed IGCC plants has grown slightly, most proposed IGCC plants are still
42 considerable smaller than STP, Units 1 and 2. For example, on September 27, 2011, DOE
43 approved a loan to Summit Texas Clean Energy, LLC, for a 400 MWe IGCC plant to be built
44 west of Midland-Odessa, Texas (DOE 2011a). Although NRC considered an IGCC plant as an
45 alternative for the Shearon Harris license renewal SEIS, whose license would also have expired
46 in 2027, the Shearon Harris nuclear plant is much smaller than STP, Units 1 and 2 (955 MWe

Environmental Impacts of Alternatives

1 as compared to 2,500 MWe) (NRC 2008). Because of the small capacity of proposed IGCC
2 plants, the NRC did not find IGCC to be a reasonable alternative for STP, Units 1 and 2. For
3 these reasons, IGCC plants are not considered further in this SEIS.

4 **8.3.1 Air Quality**

5 Air quality impacts from coal-fired generation can be substantial because it emits a significant
6 quantity of sulfur oxides, nitrogen oxides, particulates, carbon monoxide, and HAPs such as
7 mercury; however, many of these pollutants can be effectively controlled by various
8 technologies.

9 As discussed in Section 2.2.2.1, STP is located in central Matagorda County, Texas, at the
10 southern edge of the Metropolitan Houston–Galveston Intrastate Air Quality Control Region
11 (40 CFR 81.38). The Corpus Christi–Victoria Intrastate Air Quality Control Region
12 (40 CFR 81.136) lies immediately south and west of Matagorda County. EPA has designated
13 all of the counties in these Air Quality Control Regions adjacent to the STP site as in compliance
14 with the National Ambient Air Quality Standards (40 CFR 81.344) except Brazoria County to the
15 north; Brazoria County is classified Nonattainment/Severe relative to the 8-hour ozone standard
16 (EPA 2011b).

17 Construction activities would cause some localized temporary air-quality effects because of
18 emissions and fugitive dust from operation of the earth-moving and material-handling
19 equipment. Emissions from workers' vehicles and motorized construction equipment exhaust
20 would be temporary. NRC assumed that construction crews would use dust-control practices to
21 control and reduce fugitive dust. STPNOC proposed such activities during construction of
22 proposed Units 3 and 4 (STPNOC 2010b), and §111.145 of TCEQ's regulations require dust
23 suppression control during the construction of facilities and parking lots.

24 A new coal-fired plant would qualify as a new major-emitting industrial facility and would be
25 subject to PSD requirements of the CAA (EPA 2011c). The coal-fired plant would need to
26 comply with the standards of performance for electric utility steam generating units set forth in
27 40 CFR Part 60 Subpart Da and GG. The plant would also require an operating permit from
28 TCEQ. In STPNOC's ER for Units 3 and 4, STPNOC stated that "[a]ir emissions sources would
29 be managed in accordance with Federal, Texas, and local air quality control laws and
30 regulations." Likewise, NRC assumed that the coal-fired plant would be operated in accordance
31 with Federal, Texas, and local air quality control laws and regulations.

32 Subpart P of 40 CFR Part 51 contains the visibility protection regulatory requirements, including
33 the review of new sources that would be constructed in the attainment or unclassified areas and
34 may affect visibility in any Federal Class I area. If a coal-fired alternative was located close to a
35 mandatory Class I area, additional air pollution control requirements would be required. As
36 noted in Section 2.2.2.1, there are no mandatory Class I Federal areas within 50 mi (80 km) of
37 the STP site.

38 The emissions from the coal-fired alternative at the STP site, projected by the NRC staff based
39 on published EIA data, EPA emission factors, and based on performance characteristics for this
40 alternative and likely emission controls, would be:

- 41 • sulfur oxides—3,260 tons (2,958 MT) per year,
- 42 • nitrogen oxides—2,869 tons (2,595 MT) per year,
- 43 • carbon monoxide—784 tons (711 MT) per year,

- 1 particulate matter PM₁₀—446 tons (405 MT) per year, and
- 2 particulate matter PM_{2.5}—223 tons (202 MT) per year.

3 **8.3.1.1 Sulfur Oxides**

4 The coal-fired alternative at the STP site would likely use wet, limestone-based scrubbers to
5 remove sulfur oxides. EPA indicates that this technology can remove more than 95 percent of
6 sulfur oxides from flue gases. The staff projects total sulfur oxide emissions would be
7 3,260 tons (2,958 MT) per year. Sulfur oxide emissions from a new coal-fired power plant
8 would be subject to the requirements of the CAA (42 U.S.C. § 7651 et seq.). These regulations
9 were enacted to reduce emissions of sulfur dioxide and nitrogen oxide, the two principal
10 precursors of acid rain, by restricting emissions of these pollutants from power plants. The
11 current SIP for Texas includes a Cap and Trade Program for sulfur dioxide. To operate the
12 coal-fired plant, the plant operator would have to purchase sulfur dioxide allowances from the
13 open market or shut down existing fossil-fired plant(s) and apply the credits to the new plant
14 (STPNOC 2010a). Thus, provided the plant operator is able to purchase sufficient allowances
15 to operate, the coal-fired alternative would not add to net regional sulfur dioxide emissions,
16 although it might do so locally.

17 In addition, in August 2011, EPA published the Cross-State Air Pollution Rule, which included
18 reductions of sulfur dioxide in Texas. According to the rule, coal-fired plants would need to
19 comply with the new reductions by 2012.

20 **8.3.1.2 Nitrogen Oxides**

21 A coal-fired alternative at the STP site would most likely employ various available nitrogen
22 oxide-control technologies, which can be grouped into two main categories—combustion
23 modifications and post-combustion processes. Combustion modifications include low-nitrogen
24 oxide burners, overfire air, reburning, flue gas recirculation, and operational modifications.
25 Post-combustion processes include SCR, selective noncatalytic reduction, and hybrid
26 processes. Effective combination of the combustion modifications and post-combustion
27 processes reduces nitrogen oxide emissions by up to 95 percent (EPA 1998). STPNOC
28 indicated in its ER that it would use low-nitrogen oxide burners, overfire air, selective catalytic
29 reduction, and scrubbers to reduce nitrogen oxide emissions from this alternative
30 (STPNOC 2010a). Assuming the use of such technologies at the STP site, nitrogen oxide
31 emissions after scrubbing would be approximately 2,869 tons (2,595 MT) annually.

32 Section 407 of the CAA establishes technology-based emission limitations for nitrogen oxide
33 emissions. A new coal-fired power plant would be subject to the new source performance
34 standards for such plants as indicated in 40 CFR 60.44 Subpart Da(a)(1). This regulation limits
35 the discharge of any gases that contain nitrogen oxides to 200 nanograms (ng) of nitrogen
36 oxides per joule (J) of gross energy output (equivalent to 1.6 pounds per megawatt-hours
37 (lb/MWh), based on a 30-day rolling average.

38 The current SIP for Texas includes a Cap and Trade Program for nitrogen oxides. To operate
39 the coal-fired plant, the plant operator would have to purchase nitrogen oxide allowances from
40 the open market or shut down existing fossil-fired plant(s) and apply the credits to the new plant
41 (STPNOC 2010a). Thus, provided the plant operator is able to purchase sufficient allowances
42 to operate, the coal-fired alternative would not add to net regional nitrogen oxide emissions,
43 although it might do so locally.

44 **8.3.1.3 Greenhouse Gases**

45 A coal-fired plant would also have carbon dioxide emissions during operations, as well as during
46 coal mining, processing, and transportation. The coal-fired plant would emit between

Environmental Impacts of Alternatives

1 19.3 million tons (17.5 million MT) and 19.9 million tons (18.1 million MT) of carbon dioxide per
2 year from coal combustion, depending on the type and quality of the coal burned.

3 On July 12, 2012, EPA issued a final rule tailoring the applicability criteria that determine which
4 stationary sources and modification to existing projects become subject to permitting
5 requirements for greenhouse emissions under the PSD and Title V Programs of the CAA
6 (77 FR 41051). According to the Tailoring Rule, greenhouse gases are a regulated new source
7 review pollutant under the PSD major source permitting program if the source is otherwise
8 subject to PSD (for another regulated new source review pollutant) and has a greenhouse gas
9 potential to emit equal to or greater than 75,000 tons (68,000 MT) per year of carbon dioxide
10 equivalent (“carbon dioxide equivalent” adjusting for different global warming potentials for
11 different greenhouse gases). Such sources would be subject to BACT, although EPA has yet to
12 determine BACT for greenhouse gases.

13 EPA issued a Federal Implementation Plan (FIP) on May 3, 2011, to permit greenhouse
14 gas-emitting sources in states that do not have measures to lower greenhouse gases in their
15 SIP. Because Texas has not updated its SIP to include greenhouse gases, EPA will be the
16 official permitting authority for greenhouse gas-emitting sources in Texas if the SIP is not
17 updated before the coal-fired plant begins operations.

18 **8.3.1.4 Particulates**

19 The new coal-fired power plant would use fabric filters to remove particulates from flue gases
20 (STPNOC 2010a). The fabric filters would remove 99.9 percent of PM (STPNOC 2010a). EPA
21 notes that filters are capable of removing in excess of 99 percent of PM and that sulfur dioxide
22 scrubbers further reduce PM emissions (EPA 2008); therefore, the NRC staff believes the
23 STPNOC removal factor is appropriate. Based on this information, the new supercritical
24 coal-fired plant would emit approximately 446 tons (405 MT) per year of particulate matter
25 having an aerodynamic diameter less than, or equal to, 10 microns (PM₁₀) annually. In addition,
26 coal burning would also result in approximately 223 tons (202 MT) of particulate matter with an
27 aerodynamic diameter of 2.5 microns or less (PM_{2.5}). Coal-handling equipment would introduce
28 fugitive dust emissions when fuel is being transferred to onsite storage and then reclaimed from
29 storage for use in the plant.

30 During the construction of a coal-fired plant, onsite activities would also generate fugitive dust.
31 Vehicles and motorized equipment would create exhaust emissions during the construction
32 process. These impacts would be intermittent and short-lived; however, to minimize dust
33 generation, construction crews would use applicable dust-control measures, as described
34 above.

35 **8.3.1.5 Carbon Monoxide**

36 Based upon EPA emission factors (EPA 1998), the NRC staff estimates that total carbon
37 monoxide emissions would be approximately 784 tons (711 MT) per year.

38 **8.3.1.6 Conclusion**

39 While the GEIS analysis mentions global warming from carbon dioxide emissions and acid rain
40 from sulfur and nitrogen oxide emissions as potential impacts, it does not quantify emissions
41 from coal-fired power plants; however, the GEIS analysis does imply that air impacts would be
42 substantial (NRC 1996). The above analysis shows that emissions of air pollutants—including
43 sulfur oxides, nitrogen oxides, carbon monoxide, particulates, and carbon dioxide—exceed
44 those produced by the existing nuclear power plant, as well as those of the other alternatives
45 considered in this section. The NRC analysis for a coal-fired alternative suggests that impacts
46 from the coal-fired alternative would have clearly noticeable effects, but given existing regulatory

1 regimens, permit requirements, and emissions controls, the coal-fired alternative would not
2 destabilize air quality. Based on this information, the overall air quality impacts of a new
3 coal-fired plant located at the STP site would be MODERATE.

4 **8.3.2 Surface Water Resources**

5 STPNOC did not propose using any surface water during the construction of Units 3 and 4
6 (NRC 2011). As a new coal-fired plant would occupy a smaller footprint relative to new nuclear
7 units, its construction would enable less extensive excavation and earthwork than new nuclear
8 units.

9 However, onsite construction of an engineered solid waste disposal facility (landfill), totaling
10 200 ac (80 ha), would also be required for disposal of coal ash and air pollution control scrubber
11 sludge from 20 years of operations. The combined acreage of the coal-fired plant and ash
12 disposal facility would slightly exceed that required for the new nuclear generation alternative.
13 Nevertheless, NRC would still expect that surface water would not be used to support
14 construction activities under this alternative.

15 As for the aforementioned replacement-power alternatives, some temporary impacts to surface
16 water quality may result from dredging activities in the Colorado River near the barge slip and
17 from increased sediment loading in stormwater runoff from active construction areas. Due to
18 the short-term nature of the dredging activities, the hydrologic alterations and sedimentation
19 would be localized and temporary. Dredging would also be conducted under a permit from the
20 USACE requiring the implementation of BMPs to minimize impacts. Runoff from construction
21 areas, including construction of the disposal facility, would be controlled under a State-issued
22 TPDES general permit that would require implementation of a stormwater pollution prevention
23 plan and associated BMPs to prevent or significantly mitigate soil erosion and contamination of
24 stormwater runoff from construction activities.

25 During operations, the coal-fired alternative would require a similar amount of cooling water as
26 STP, Units 1 and 2. Because a similar amount of cooling water would be required, NRC
27 expects that the existing intake and discharges on the MCR and the Colorado River would be
28 sufficient to support this alternative. Surface water withdrawals would be subject to, and would
29 remain well within, STPNOC's existing water rights, and effluent discharges and stormwater
30 discharges associated with industrial activity would be subject to a revised State-issued TPDES
31 permit under this alternative. In accordance with the applicable TPDES permit, implementation
32 of a stormwater pollution prevention plan for industrial activities would address stormwater
33 run-on and runoff issues associated with coal storage and handling, as well as other stockpiles
34 (e.g., lime) at the plant. These requirements would also encompass the handling, storage, and
35 disposal of coal ash and scrubber wastes so as to mitigate the potential water quality impacts of
36 contaminated runoff and infiltration.

37 In consideration of the information above, the impacts on surface water use and quality from
38 construction and operations under the coal-fired generation alternative would be SMALL.

39 **8.3.3 Groundwater Resources**

40 Construction-related ground disturbance and excavation work would be somewhat less than
41 that described for the new nuclear alternative, mainly due to a reduction in deep excavation
42 work and less intensive structural work. However, construction and excavation for a coal ash
43 and scrubber residue disposal facility would have additional potential impacts on groundwater.
44 Although groundwater dewatering of foundation excavations for a new coal-fired plant would
45 likely be required, slurry walls and wells were proposed for use to minimize potential adverse

Environmental Impacts of Alternatives

1 effects from dewatering both on site and off site (NRC 2011). Construction of the coal ash and
2 scrubber residue disposal facility would have to be carefully managed and sited to minimize the
3 need for construction dewatering due to the shallow depth of groundwater across many areas of
4 the STP site. Application of BMPs in accordance with a state-issued NPDES general permit,
5 including appropriate waste management and spill prevention practices, would prevent or
6 minimize groundwater quality impacts during construction.

7 STPNOC assumed that a fossil-fuel-fired generation facility would be located adjacent to the
8 STP, Units 1 and 2, site to use the existing infrastructure, including continued use of the existing
9 onsite groundwater production wells at STP. Groundwater use for construction of a new
10 coal-fired plant is expected to be similar to the volume required for new nuclear units under this
11 alternative. This would encompass such uses as potable and sanitary uses, concrete
12 production, dust suppression and soil compaction, and other uses.

13 For coal-fired plant operations, NRC assumed that the coal-fired generation alternative would
14 entail the same relative ratio of groundwater use to surface water use as that used at STP,
15 Units 1 and 2. This includes the use of groundwater for freshwater and service water makeup,
16 potable and sanitary uses, and fire protection. It is expected that total groundwater usage and
17 associated aquifer effects would likely be less than those under current STP operations. This is
18 because of the fewer number of auxiliary systems requiring groundwater and the smaller
19 workforce under the coal-fired generation alternative.

20 Disposal of coal ash and air pollution control scrubber wastes in an onsite landfill would have
21 the potential to impact groundwater quality due to the generation and infiltration of leachate to
22 the environment. NRC assumes that any disposal facility would incorporate a liner to prevent
23 infiltration and would be operated with a leachate monitoring and collection system and ambient
24 groundwater monitoring system. These systems and measures would ensure that facility
25 operations would not impact groundwater quality. Operation of the facility would also be subject
26 to a state-issued landfill permit.

27 Based on this information, the overall impact on groundwater use and quality from construction
28 and operations under the coal-fired generation alternative would be SMALL.

29 **8.3.4 Aquatic Ecology**

30 Construction activities for the coal-fired alternative (such as construction of heavy haul roads
31 and the power blocks) could affect drainage areas or other onsite aquatic features due to site
32 runoff. NRC assumed that the plant operator would install temporary and permanent erosion
33 and sediment control measures to minimize the flow of disturbed soils into ditches and
34 wetlands. Such BMPs would likely be described in a TPDES general permit relating to
35 stormwater discharges for construction activities. To bring new materials to the site, NRC
36 assumed the plant operator would dredge near the barge slip to transport some materials using
37 barges. Permits and certifications from the USACE and other agencies would require the
38 implementation of BMPs to minimize impacts. Due to the short-term nature of the dredging
39 activities, the hydrological alterations to aquatic habitats would be localized and temporary.

40 During operations, the coal-fired alternative would require a similar amount of cooling water to
41 be withdrawn from the Colorado River at STP, Units 1 and 2, and the thermal discharge would
42 also be similar to STP, Units 1 and 2. Therefore, the number of fish and other aquatic
43 organisms affected by impingement, entrainment, and heat shock would be similar for a
44 coal-fired alternative as for license renewal. The cooling system for a new coal-fired plant would
45 have similar chemical discharges as STP, but the air emissions from the coal-fired plant would
46 emit particulates that would settle onto the river surface and introduce a new source of
47 pollutants that would not exist if STP continued operating. However, the flow of the Colorado

1 River would dissipate pollutants, which would decrease the concentration of pollutants and
2 minimize the exposure of fish and other aquatic organisms to pollutants.

3 Construction activities would require BMPs; dredging would be short-term; the surface water
4 withdrawal and discharge for this alternative would be less than for STP, Units 1 and 2; and
5 pollutants would dissipate with the Colorado River (minimizing exposure concentrations to
6 aquatic resources). Therefore, impacts on aquatic ecology would be SMALL.

7 **8.3.5 Terrestrial Ecology**

8 Coal-fired operations would affect terrestrial ecology both on the STP site and in offsite coal
9 mining areas.

10 If the coal-fired alternative is constructed at the STP site, construction would likely affect a
11 variety of habitats and land uses, including industrial land (buildings, parking areas, and
12 mowed-maintained fields), drainage ditches, scattered small palustrine wetlands, scrub-shrub
13 habitat, and mixed grassland habitat where abandoned farm lands previously existed prior to
14 construction of Units 1 and 2. Most of these areas have been mildly to extensively disturbed
15 during the construction and operations of Units 1 and 2 and other human activities. After the
16 completion of the new units, construction crews would likely grade, landscape, and replant the
17 areas used for temporary building support, which is similar to what STPNOC proposed to do
18 after completion of proposed new nuclear Units 3 and 4 (STPNOC 2010b). The majority of
19 permanently affected areas would be maintained (e.g., mowed) and industrial areas. The plant
20 operator would likely implement BMPs to minimize impacts to wetlands. The plant operator
21 would be required to comply with the USACE's 404 permits. Construction activities could also
22 adversely affect onsite wildlife through noise, increased light pollution, and increased traffic.
23 However, these impacts would be temporary and minor.

24 Coal mining would affect terrestrial resources at offsite coals mines, although much of this land
25 is likely already disturbed by mining, and the incremental effects of this alternative on coal mine
26 terrestrial ecology are difficult to gauge.

27 STPNOC estimates that 253,000 tons of coal ash and 88,000 tons of scrubber sludge would be
28 disposed of on site annually (STPNOC 2010a). Over a 40-year period, this would require
29 approximately 200 ac for land disposal (STPNOC 2010a). As described above, these areas
30 could affect terrestrial ecology, especially if they are located in habitats that are currently used
31 by wildlife on the STP site. Once the disposal area is reclaimed, the habitats may be useable
32 by wildlife that inhabits open areas.

33 Deposition of acid rain resulting from nitrogen or sulfur oxide emissions, and the deposition of
34 other pollutants, can also affect terrestrial ecology both on and off site. Given the emission
35 regulations discussed in Section 8.3.1, air deposition impacts may be noticeable but are unlikely
36 to be destabilizing.

37 Because of the potential habitat disturbances and potential pollutant deposition, impacts to
38 terrestrial resources from a coal-fired alternative would be MODERATE.

39 **8.3.6 Human Health**

40 Coal-fired power plants introduce worker risks from coal and limestone mining, coal and
41 limestone transportation, plant operations, and disposal of coal combustion and scrubber
42 wastes. In addition, there are public risks from the inhalation of stack emissions (as addressed
43 in Section 8.3.1) and the secondary effects of eating foods grown in areas subject to deposition
44 from plant stacks.

Environmental Impacts of Alternatives

1 Human health risks of coal-fired power plants are described, in general, in Table 8–2 of the
2 GEIS (NRC 1996). Cancer and emphysema, as a result of the inhalation of toxins and
3 particulates, are identified as potential health risks to occupational workers and members of the
4 public (NRC 1996). The human health risks of coal-fired power plants, both to occupational
5 workers and to members of the public, are greater than those of the current STP due to
6 exposures to chemicals such as mercury; sulfur oxides; nitrogen oxides; radioactive elements,
7 such as uranium and thorium contained in coal and coal ash; and polycyclic aromatic
8 hydrocarbon (PAH) compounds, including benzo(a)pyrene.

9 Regulations restricting emissions—enforced by EPA or state agencies—have acted to
10 significantly reduce potential health effects but do not entirely eliminate them. These agencies
11 also impose site-specific emission limits as needed to protect human health. Even if the
12 coal-fired alternative were located in a non-attainment area, emission controls and trading or
13 offset mechanisms could prevent further regional degradation; however, local effects could be
14 visible. Many of the byproducts of coal combustion responsible for health effects are largely
15 controlled, captured, or converted in modern power plants (as described in Section 8.3.1),
16 although some level of health effects may remain.

17 Aside from emission impacts, the coal-fired alternative introduces the risk of coal pile fires, and
18 for those plants that use coal combustion liquid and sludge waste impoundments, the release of
19 the waste due to a failure of the impoundment. Although there have been several instances of
20 this occurring in recent years, these types of events are still relatively rare.

21 Despite the range of potential threats to human health, extensive health-based regulations exist
22 to mitigate the risks to workers and the public. As a result, the NRC staff expects human health
23 impacts to be characterized as SMALL.

24 Noise during construction activities and from plant operations may be detectable off site. The
25 plant operator would need to adhere to local ordinances regarding maximum noise levels during
26 construction and operations. Therefore, impacts from noise would likely be SMALL.

27 **8.3.7 Land Use**

28 The GEIS generically evaluates the impact of constructing and operating various replacement
29 power plant alternatives on land use, both on and off each plant site. The analysis of land use
30 impacts focuses on the amount of land area that would be affected by the construction and
31 operation of a supercritical coal-fired generation at the STP site.

32 Based on scaled GEIS estimates, the plant would require approximately 4,629 ac (1,873 ha) of
33 land. STPNOC estimates that 353 ac (143 ha) of land would be required (STPNOC 2010a).
34 This estimate appears reasonable; therefore, it is used for this analysis. STPNOC estimates
35 that an additional 200 ac (80 ha) of land area would be required on site for waste disposal
36 (STPNOC 2010a). Land would also be required on site for frequent coal and limestone
37 deliveries by rail or barge.

38 Offsite land use impacts would occur from coal mining, in addition to land use impacts from the
39 construction and operation of the new power plant. Scaling from GEIS estimates, approximately
40 59,906 ac (24,244 ha) of land could be affected by mining coal and waste disposal to support
41 the coal-fired alternative during its operational life (NRC 1996); however, most of the land in
42 existing coal mining areas has already experienced some level of disturbance. The elimination
43 of the need for uranium mining to supply fuel for the STP would partially offset this offsite land
44 use impact. Scaling from GEIS estimates, approximately 2,560 ac (1,036 ha) would not be
45 needed for mining and processing uranium during the operating life of the plant.

1 Since a substantial amount of onsite land at the STP site would be converted for coal and
2 limestone delivery and waste disposal, land use impacts would be MODERATE.

3 **8.3.8 Socioeconomics**

4 As previously discussed, socioeconomic impacts are defined in terms of changes to the
5 demographic and economic characteristics and social condition of a region. For example, the
6 number of jobs created by the construction and operation of a power plant could affect regional
7 employment, income, and expenditures. Two types of jobs would be created by this alternative:
8 (1) construction jobs, which are transient, short in duration, and less likely to have a long-term
9 socioeconomic impact; and (2) power plant operation jobs, which have the greater potential for
10 permanent, long-term socioeconomic impacts. Workforce requirements of power plant
11 construction and operation for the coal-fired alternative were determined to measure their
12 possible effects on current socioeconomic conditions.

13 Scaling from GEIS estimates, the construction workforce would peak at 6,808 workers.
14 STPNOC projected a peak construction workforce of 3,955 employees (STPNOC 2010a).
15 STPNOC's estimate appears reasonable; therefore, it is used in this analysis. The relative
16 economic impact of this many workers on the local economy and tax base would vary, with the
17 greatest impacts occurring in the communities where the majority of construction workers would
18 reside and spend their income. As a result, local communities could experience a short-term
19 "boom" from increased tax revenue and income generated by construction expenditures and the
20 increased demand for temporary (rental) housing and business services. Some construction
21 workers could relocate to Matagorda and surrounding counties in order to be closer to the
22 construction work site. However, given the proximity of STP to the Houston metropolitan area,
23 many construction workers could commute to the STP site, thereby lessening the need for
24 additional rental housing near STP.

25 After completing the installation of the supercritical coal-fired power plant, local communities
26 could experience a return to pre-construction economic conditions. Based on this information,
27 and given the number of workers, socioeconomic impacts during construction in communities
28 near the STP site could range from SMALL to MODERATE.

29 Scaling from GEIS estimates, the plant operation workforce would be 681 workers. STPNOC
30 estimated a plant operation workforce of approximately 348 workers. The STPNOC estimate
31 appears to be reasonable and is consistent with trends toward lowering labor costs by reducing
32 the size of plant operations workforces. The amount of property taxes paid under the coal-fired
33 alternative may increase if additional land is required off site to support this alternative.
34 Socioeconomic impacts during operations could range from SMALL to MODERATE as the STP
35 site transitions to the new supercritical coal-fired power plant. The potential reduction in overall
36 employment at STP could affect property tax revenue and income in local communities and
37 businesses. In addition, the permanent housing market could also experience increased
38 vacancies and decreased prices if operations workers and their families move out of the region.

39 **8.3.9 Transportation**

40 Transportation impacts associated with construction and operation of a four-unit, coal-fired plant
41 would consist of commuting workers and truck deliveries of construction materials to the STP
42 site. During periods of peak construction activity, up to 3,955 workers could be commuting daily
43 to the site (STPNOC 2010a). Workers commuting to the STP site would primarily use two-lane
44 roads. The volume of traffic on these roads, especially FM 521, would increase substantially.
45 In addition to commuting workers, trucks would be transporting construction materials and
46 equipment to the worksite, thus increasing the amount of traffic on local roads. The increase in

Environmental Impacts of Alternatives

1 vehicular traffic would peak during shift changes, resulting in temporary levels of service
2 impacts and delays at intersections. Some power plant components and materials could also
3 be delivered by train or barge. Train deliveries could cause additional traffic delays at railroad
4 crossings. Based on this information, traffic-related transportation impacts during construction
5 could range from MODERATE to LARGE.

6 Traffic-related transportation impacts would be greatly reduced after completing the installation
7 of the coal-fired units. Transportation impacts would include daily commuting by the operating
8 workforce, equipment and materials deliveries, and the removal of commercial waste material to
9 offsite disposal or recycling facilities by truck. During operations, the estimated number of
10 operations workers commuting to and from the STP site would be 348 workers. Frequent
11 deliveries of coal and limestone by rail would add to the overall transportation impact by causing
12 traffic delays at railroad crossings. Onsite coal storage would make it possible to receive
13 several trains per day. Limestone delivered by rail could also add additional traffic (though
14 considerably less traffic than that generated by coal deliveries). Traffic-related transportation
15 impacts would be considerably less than current operations because the new supercritical
16 coal-fired power plant would employ far fewer workers than STP, Units 1 and 2. Overall,
17 transportation impacts would be SMALL during power plant operations.

18 **8.3.10 Aesthetics**

19 The analysis of aesthetic impacts focuses on the degree of contrast between the coal-fired
20 alternative and the surrounding landscape and the visibility of the coal-fired power plant. During
21 construction, all of the clearing and excavation would occur on the STP site. These activities
22 may be visible from offsite roads, particularly FM 521. Since the STP site already appears
23 industrial, construction of the coal-fired power plant would appear similar to onsite activities
24 during refueling outages.

25 The coal-fired alternative would be up to 200 ft (61 m) tall with an exhaust stack up to 500 ft
26 (152 m), which may be visible off site in daylight hours. The coal-fired plant, however, would be
27 shorter and less noticeable than the current STP reactor building, which has a height of
28 approximately 250 ft (76 m) (STPNOC 2010b). Lighting on plant structures may be detectable
29 off site. Noise generated during power plant operations would be limited to routine industrial
30 processes and communications.

31 In general, given the industrial appearance of the STP site, the new coal-fired power plant would
32 blend in with the surroundings if the existing STP, Units 1 and 2, remains. Aesthetic changes
33 would be limited to the immediate vicinity of the existing STP site, and any impacts would be
34 SMALL.

35 **8.3.11 Historic and Archaeological Resources**

36 The same considerations, discussed in Section 8.1.11, for the impact of the construction of a
37 new nuclear plant on historic and archaeological resources apply to the construction activities
38 that would occur on the STP site for a coal-fired plant. As described in Section 2.2.10, much of
39 the STP site has been previously disturbed by the construction of STP, Units 1 and 2. In
40 addition, in preparation for the COL application for Units 3 and 4, STPNOC conducted a cultural
41 resources assessment of the STP site. STPNOC reviewed existing information for the STP site
42 and the area within a 10-mi (16-km) radius. STPNOC concluded that any cultural resource sites
43 that may have existed on site would no longer retain their integrity because the area was heavily
44 disturbed during the construction of Units 1 and 2 (STPNOC 2010b). In December 2006,
45 STPNOC reported these findings to the SHPO at the Texas Historical Commission. The SHPO

1 concurred, in January 2007, that there would be no impacts to historic properties
2 (STPNOC 2006; THC 2007).

3 There is a low potential for cultural resources to be located in previously undisturbed portions of
4 the STP site. However, if the coal-fired units were to be sited within undisturbed areas or within
5 areas of known cultural sensitivity (historic grave site located on the property and described in
6 Section 2.2.10), these areas would need to be surveyed by a professional archaeologist to
7 identify and develop possible mitigation measures to address any adverse effects from project
8 activities. NRC assumes the plant operator would follow similar procedures to those described
9 in the final EIS for STP, Units 3 and 4 (NRC 2011), if the plant operator discovered any historic
10 or cultural resources during ground-disturbing activities associated with building the new units.

11 The NRC staff determined that the impact of the coal-fired alternative at the STP site on historic
12 and archaeological resources would be SMALL for the following reasons:

- 13 • NRC (2011) and STPNOC (2010a, 2010b) did not identify any cultural
14 resources that could be affected by Units 3 and 4.
- 15 • The SHPO determined that construction for Units 3 and 4 would not affect
16 cultural and historic resources.
- 17 • NRC assumes that the plant operator would follow environmental compliance
18 procedures for new ground-disturbing activities.

19 **8.3.12 Environmental Justice**

20 The environmental justice impact analysis evaluates the potential for disproportionately high and
21 adverse human health, environmental, and socioeconomic effects on minority and low-income
22 populations that could result from the construction and operation of a new power plant. As
23 previously discussed in Section 8.1.12, such effects may include human health, biological,
24 cultural, economic, or social impacts. Some of these potential effects have been identified in
25 resource areas discussed in this SEIS. For example, increased demand for rental housing
26 during plant construction could disproportionately affect low-income populations. Minority and
27 low-income populations are subsets of the general public residing in the vicinity of the STP site,
28 and all are exposed to the same hazards generated from constructing and operating a new
29 coal-fired plant. Section 4.9.7, "Environmental Justice," presents demographic information
30 about minority and low-income populations residing in the vicinity of the STP site.

31 Potential impacts to minority and low-income populations from the construction and operation of
32 a new coal-fired plant at the STP site would mostly consist of environmental and socioeconomic
33 effects (e.g., noise, dust, traffic, employment, and housing impacts). Noise and dust impacts
34 during construction would be short-term and primarily limited to onsite activities. Minority and
35 low-income populations residing along site access roads would be directly affected by increased
36 commuter vehicle and truck traffic. However, because of the temporary nature of construction,
37 these effects would only occur during certain hours of the day and are unlikely to be high and
38 adverse. Increased demand for rental housing during construction could affect low-income
39 populations living near STP. However, given the proximity of the STP site to the Houston
40 metropolitan areas, many construction workers could commute to the STP site, thereby
41 lessening the additional need for rental housing.

42 Based on this information, and the analysis of human health and environmental impacts
43 presented in this SEIS, the construction and operation of a new coal-fired power plant would not
44 have disproportionately high and adverse human health and environmental effects on minority
45 and low-income populations residing in the vicinity of the STP site.

Environmental Impacts of Alternatives

1 8.3.13 Waste Management

2 During the construction stage of the coal-fired alternative, land clearing and other construction
3 activities would generate waste that could be recycled, disposed of on site, or shipped to an
4 offsite waste disposal facility. Because the alternative would be constructed on or near the
5 previously disturbed STP site, the amounts of waste produced during land clearing would be
6 reduced.

7 Coal combustion generates several waste streams including ash (a dry solid) and sludge (a
8 semi-solid by-product of emission control system operation). This coal-fired alternative would
9 produce roughly 446,000 tons (405,000 MT) of ash, and 43 percent (193,000 tons
10 (175,000 MT)) of the ash would be recycled for beneficial use (STPNOC 2010a).
11 STPNOC (2010a) estimated that approximately 88,000 tons (80,000 MT) of scrubber sludge
12 would be disposed of on site each year, which was based on an assumed annual lime usage of
13 approximately 107,000 tons (97 MT). Approximately 200 ac (81 ha) would be required to
14 dispose of the ash and scrubber waste on site over a 40-year plant life (STPNOC 2010a). All
15 waste disposal would occur on site.

16 The impacts from waste generated during operation of this coal-fired alternative would be
17 MODERATE because the impacts would be clearly visible but would not destabilize important
18 resources.

19 8.3.14 Summary of Impacts for the Supercritical Coal-Fired Generation Alternative

20 Table 8–4 provides a summary of the environmental impacts of the supercritical coal-fired
21 alternative compared to continued operation of STP.

22 **Table 8–4. Summary of Environmental Impacts of the Supercritical Coal-Fired**
23 **Alternative Compared to Continued Operation of STP, Units 1 and 2**

	Supercritical Coal-Fired Generation	Continued STP Operation
Air quality	MODERATE	SMALL
Surface water	SMALL	SMALL
Groundwater	SMALL	SMALL
Aquatic resources	SMALL	SMALL
Terrestrial resources	MODERATE	SMALL
Human health	SMALL	SMALL to MODERATE
Land use	MODERATE	SMALL
Socioeconomics	SMALL to MODERATE	SMALL
Transportation	SMALL to LARGE	SMALL
Aesthetics	SMALL	SMALL
Historic & archaeological	SMALL	SMALL
Waste management	MODERATE	SMALL

1 **8.4 Combination Alternative**

2 In this section, the NRC staff evaluates the environmental impacts of a combination of
3 alternatives. This combination includes 640 MWe supplied by one NGCC unit similar to the
4 units identified in Section 8.2, 1,620 MWe supplied by wind energy projects, and 300 MWe of
5 energy conservation and efficiency (also known as demand-side management). Because wind
6 is an intermittent resource, wind energy projects would be interconnected to one another on the
7 transmission grid, and the NGCC unit could be used, if needed, to be a baseload resource.
8 Interconnecting wind farms through the transmission grid increase the probability that at least
9 one site experiences sufficient wind to produce electricity. Thus, as more sites are added to the
10 transmission grid, the interconnected wind farms provide electricity that is comparable to a
11 single wind farm providing near constant deliverable wind power. Archer and Jacobson (2007)
12 looked at 19 wind energy sites in the southeast, including 2 sites in Texas, and determined that
13 the 19 interconnected wind farms could guarantee 312 kWe of power for 79 percent of time.
14 Based on this data, NRC assumed that to provide 1,620 MWe of wind energy, the installed
15 capacity would need to be at least 7,714 MWe. NRC included this contribution from wind power
16 because Texas has significant wind energy resources and leads the Nation in wind-powered
17 generation capacity. As of June 30, 2011, the installed wind capacity in Texas was
18 10,135 MWe (DOE 2011b). In addition, wind energy projects totaling 36,124 MWe are currently
19 under ERCOT's review (ERCOT 2011a), and the installed wind capacity in Texas has been
20 increasing annually by 500 MWe to 3,000 MWe in each of the past 7 years (DOE 2011b).
21 Therefore, NRC considers 1,620 MWe of wind energy (with an installed capacity of 7,714 MWe)
22 to be a reasonable amount by the time the STP licenses expire in 2027 and 2028. Section 8.6.3
23 discusses the status of wind energy technology and implementation in greater detail.

24 NRC assumed that one new NGCC unit of the type described in Section 8.2 would be
25 constructed and installed at the STP site with a total capacity of 640 MWe. The appearance of
26 an NGCC unit would be similar to that of the full NGCC alternative considered in Section 8.2,
27 although only one unit would be constructed. The NRC estimates that it would require about
28 one-fourth of the space necessary for the alternative considered in Section 8.2 and that
29 construction and operational effects would scale accordingly.

30 NRC assumed that the wind turbines could be constructed at multiple sites scattered over large
31 distances to minimize the likelihood that all sites would be exposed to the same weather events
32 at the same time. Some of these sites could potentially be offshore, although no turbines
33 currently operate offshore anywhere in the U.S. NRC assumed that the contribution from
34 offshore wind energy would be relatively small because offshore wind capacity of the magnitude
35 analyzed in this alternative exceeds by a factor of 10 or more the amount of offshore wind
36 projected by the EIA for the entire U.S. by the year 2035 (EIA 2011a). Assuming each turbine
37 has a capacity of 2 MWe, construction and operation of approximately 3,877 turbines would be
38 required. In addition, new transmission lines would likely be needed to connect the wind energy
39 projects to one another and the distribution system.

40 STPNOC estimated that a utility-scale wind plant requires 60 ac of land per MWe of installed
41 capacity in open, flat terrain (STPNOC 2010a). Approximately 462,900 ac (187,300 ha) of land
42 would be required for the installed capacity of 7,714 MWe. A small percentage of this area
43 would be occupied by turbines, access roads, and other infrastructure, with the rest of the area
44 potentially available for compatible other uses, such as agriculture. For example, NREL (2009)
45 estimates that 0.7 ha (1.7 ac) of land would be temporarily disturbed per MWe of installed
46 capacity and that 0.3 ha (0.7 ac) of land would be permanently disturbed per MWe of installed
47 capacity. For this alternative, approximately 2,185 ac (884 ha) would be temporarily disturbed,
48 and 937 ac (379 ha) would be permanently disturbed.

Environmental Impacts of Alternatives

1 For the combination alternative, the NRC assumed that an Energy Efficiency and Conservation
2 Program would replace 300 MWe of current STP output. As discussed in Section 8.6.2,
3 beginning in 2009, all electric transmission and distribution utilities within the ERCOT market—
4 including CPS Energy and Austin Energy (two of the owners of STP, Units 1 and 2)—were
5 required to implement energy efficiency and conservation programs to reduce their customers'
6 energy consumption by a minimum of 20 percent of the utility's annual growth in 2009,
7 25 percent in 2012, and 30 percent in 2013 and beyond. CPS Energy and Austin Energy
8 currently implement programs to promote energy efficiency and conservation. The 300 MWe
9 reduction in energy use for this alternative would be beyond the required energy efficiency and
10 conservation programs currently implemented by CPS Energy and Austin Energy. No major
11 construction would be necessary for the energy efficiency and conservation component of the
12 combination alternative.

13 **8.4.1 Air Quality**

14 As discussed in Section 2.2.2.1, the STP site is located in central Matagorda County, Texas, at
15 the southern edge of the Metropolitan Houston–Galveston Intrastate Air Quality Control Region
16 (40 CFR 81.38). The Corpus Christi–Victoria Intrastate Air Quality Control Region
17 (40 CFR 81.136) lies immediately south and west of Matagorda County. EPA has designated
18 all of the counties in these Air Quality Control Regions adjacent to the STP site as in compliance
19 with the National Ambient Air Quality Standards (40 CFR 81.344) except Brazoria County to the
20 north; Brazoria County is classified Nonattainment/Severe relative to the 8-hour ozone standard
21 (EPA 2011b).

22 Construction activities for both the NGCC plant and wind energy components would cause
23 some localized temporary air quality effects because of equipment emissions and fugitive dust
24 from operation of earth-moving and material-handling equipment. Emissions from workers'
25 vehicles and motorized construction equipment exhaust would be temporary. NRC assumed
26 that construction crews would use dust-control practices to control and reduce fugitive dust
27 because § 111.145 of TCEQ's regulations require dust suppression control during the
28 construction of facilities and parking lots. Impacts from wind turbine installation would be
29 spread across multiple locations, but these impacts would be short in duration. In its
30 programmatic final EIS, which analyzed the impacts of offshore wind projects generically within
31 U.S. waters, U.S. Minerals Management Service (MMS, which is currently Bureau of Ocean
32 Energy Management) determined that construction of offshore wind projects could result in air
33 quality impacts, mainly from fugitive dust emissions, and emissions of sulfur dioxide and ozone
34 precursors (MMS 2007).

35 New air emission sources in Texas must comply with Federal, Texas, and local air quality
36 control laws. The NGCC component of this combination alternative would qualify as a new
37 major-emitting industrial facility and would be subject to PSD requirements under CAA
38 (EPA 2011c). The NGCC unit would need to comply with the standards of performance for
39 electric utility steam generating units set forth in 40 CFR Part 60 Subpart KKKK. The plant
40 would also require an operating permit from TCEQ.

41 Subpart P of 40 CFR Part 51 contains the visibility protection regulatory requirements, including
42 the review of new sources that would be constructed in the attainment or unclassified areas and
43 may affect visibility in any Federal Class I area. If an NGCC plant was located close to a
44 mandatory Class I area, additional air pollution control requirements would be required. As
45 noted in Section 2.2.2.1, there are no mandatory Class I Federal areas within 50 mi of the STP
46 site.

1 The NRC projects the following emissions, assuming a maximum of 640 MWe power from the
2 NGCC component of this combination alternative based on data published by the EIA, EPA, and
3 on performance characteristics and emissions controls:

- 4 • sulfur oxides—50 tons (46 MT) per year,
- 5 • nitrogen oxides—219 tons (199 MT) per year,
- 6 • carbon dioxide—1,727,000 tons (1,567,000 MT) per year,
- 7 • carbon monoxide—222 tons (201 MT) per year,
- 8 • TSP—97 tons (88 MT) per year, and
- 9 • particulate matter PM₁₀—97 tons (88 MT) per year.

10 During operations, the wind energy projects would not produce emissions. However, workforce
11 transportation and eventual decommissioning could result in carbon dioxide emissions.

12 For the Energy Efficiency and Conservation Program, the GEIS notes that the environmental
13 impacts are likely to be centered on indoor air quality (NRC 1996). This is due to increased
14 weatherization of the home in the form of extra insulation and reduced air turnover rates from
15 the reduction in air leaks. However, the actual impact is highly site-specific and not yet
16 well-established.

17 **8.4.1.1 Sulfur Oxide and Nitrogen Oxide**

18 The new NGCC plant would have to comply with Title IV of the CAA (42 USC 7651) reduction
19 requirements for sulfur and nitrogen oxides, which are the main precursors of acid rain and the
20 major cause of reduced visibility. Title IV establishes maximum sulfur and nitrogen oxide
21 emission rates from existing plants and a system of sulfur oxide emission allowances that can
22 be used, sold, or saved for future use by new plants. In addition, in August 2011, EPA
23 published the Cross-State Air Pollution Rule, which included reductions of sulfur and nitrogen
24 oxides in Texas. According to the rule, NGCC plants would need to comply with the new
25 reductions by 2012.

26 As stated above, the new NGCC plant would produce 50 tons (46 MT) per year of sulfur oxides
27 and 219 tons (199 MT) per year of nitrogen oxides based on the use of the dry low-nitrogen
28 oxide combustion technology and use of SCR to significantly reduce nitrogen oxide emissions.
29 The new plant would be subjected to the continuous monitoring requirements for sulfur and
30 nitrogen oxides. The current SIP for Texas includes a Cap and Trade Program for sulfur and
31 nitrogen oxide emissions. To operate the NGCC plant, the plant operator would have to
32 purchase sulfur dioxide allowances from the open market or shut down existing fossil-fired
33 plant(s) and apply the credits to the new plant (STPNOC 2010a). Thus, provided the plant
34 operator is able to purchase sufficient allowances to operate, the NGCC portion of this
35 alternative would not add to net regional sulfur dioxide or nitrogen oxide emissions, although it
36 might do so locally.

37 **8.4.1.2 Greenhouse Gases**

38 The new plant would release greenhouse gases, such as carbon dioxide and methane. The
39 plant would be subjected to the continuous monitoring requirements for carbon dioxide, as
40 specified in 40 CFR Part 75. The NGCC plant would emit approximately 1.7 million tons
41 (approximately 1.6 million MT) per year of carbon dioxide emissions.

42 On July 12, 2012, EPA issued a final rule tailoring the applicability criteria that determine which
43 stationary sources and modification to existing projects become subject to permitting
44 requirements for greenhouse emissions under the PSD and Title V Programs of the CAA

Environmental Impacts of Alternatives

1 (77 FR 41051). According to the Tailoring Rule, greenhouse gases are a regulated new source
2 review pollutant under the PSD major source permitting program if the source is otherwise
3 subject to PSD (for another regulated new source review pollutant) and has a greenhouse gas
4 potential to emit equal to or greater than 75,000 tons (68,000 MT) per year of carbon dioxide
5 equivalent (“carbon dioxide equivalent” adjusting for different global warming potentials for
6 different greenhouse gases). Such sources would be subject to BACT, although EPA has yet to
7 determine BACT for greenhouse gases.

8 EPA issued a FIP on May 3, 2011, to permit greenhouse gas-emitting sources in states that do
9 not have measures to lower greenhouse gases in their SIP. Because Texas has not updated its
10 SIP to include greenhouse gases, EPA will be the official permitting authority for greenhouse
11 gas-emitting sources in Texas if the SIP is not updated before the NGCC plant begins
12 operations.

13 **8.4.1.3 Particulates**

14 The new NGCC plant would produce 97 tons (88 MT) per year of TSP, all of which would be
15 emitted as PM₁₀. STPNOC (2010a) indicated that all PM₁₀ emissions would be PM_{2.5}.
16 DOE (2007) evaluated the emissions from a hypothetical 560 MWe NGCC unit using BACT to
17 meet the emission requirements of the 2006 New Source Performance Standards. DOE
18 concluded that emissions from particulates would be negligible because NGCC use natural gas
19 as fuel; therefore, NGCC plants would not require emissions controls equipment or features to
20 reduce these emissions.

21 **8.4.1.4 Hazardous Air Pollutants**

22 In December 2000, EPA issued regulatory findings (65 FR 79825) on emissions of HAPs from
23 electric utility steam-generating units, which said that natural gas-fired plants emit HAPs such as
24 arsenic, formaldehyde, and nickel, and stated the following:

25 Also in the utility RTC (Report to Congress), the EPA indicated that the impacts
26 due to HAP emissions from natural gas-fired electric utility steam generating
27 units were negligible based on the results of the study. The Administrator finds
28 that regulation of HAP emissions from natural gas-fired electric utility steam
29 generating units is not appropriate or necessary.

30 As a result of EPA’s conclusion, the NRC staff finds no significant air quality effects from HAPs
31 from the NGCC component of this alternative. The wind and energy efficiency and conservation
32 components of this alternative release no HAPs.

33 **8.4.1.5 Conclusion**

34 Based on the NRC staff’s analysis, the overall air quality impacts of a combination alternative
35 that includes a new NGCC plant located at the STP site, wind energy projects, and the Energy
36 Efficiency and Conservation Program would be SMALL to MODERATE. Emissions from the
37 wind energy projects and the Energy Efficiency and Conservation Program would not be
38 noticeable. Emissions from the NGCC portion of this alternative would be noticeable for
39 greenhouse gases; carbon dioxide emissions would be two orders of magnitude larger than the
40 threshold in EPA’s tailoring rule for greenhouse gas (75,000 tons (68,000 MT) per year of
41 carbon dioxide equivalent) that would trigger a regulated new source review. Impacts would not
42 be noticeable for sulfur and nitrogen oxides because the Texas SIP requires a Cap and Trade
43 Program, and there would be no net increase in sulfur and nitrogen oxide emissions. Based on
44 analyses from DOE (2007) and EPA (2000, 65 FR 79825), TSPs and HAPs from the NGCC unit
45 would have negligible impacts.

1 **8.4.2 Surface Water Resources**

2 STPNOC did not propose using any surface water during the construction of Units 3 and 4
3 (NRC 2011). Because a single NGCC unit occupies a smaller footprint, and its construction
4 would entail substantially less excavation and earthwork at the STP site as compared to Units 3
5 and 4, NRC expects that surface water would not be used during construction for the NGCC
6 component of this alternative.

7 As further described in Section 8.5.2 for the NGCC alternative, some temporary impacts to
8 surface water quality may result from dredging activities in the Colorado River near the barge
9 slip and from increased sediment loading in stormwater runoff from active construction areas.
10 These activities would be conducted under a permit from the USACE requiring the
11 implementation of BMPs to minimize impacts. Runoff from construction areas would be
12 controlled under a State-issued TPDES general permit that would require implementation of a
13 stormwater pollution prevention plan and associated BMPs.

14 Small amounts of water would be required during the construction phase for each of the
15 3,877 wind turbines for dust suppression and compaction during site clearing and for concrete
16 production for pad and piling construction, as appropriate. Although surface water from nearby
17 water bodies may be used for pad site construction at some locations, it is likely that water
18 would be procured from offsite sources and trucked to the point of use on an as needed basis.
19 Use of ready-mix concrete would also reduce the need for onsite use of nearby water sources.

20 Further, the installation of land-based wind turbines would require installation of access roads
21 and possibly transmission lines (especially for turbine sites not already proximal to transmission
22 line corridors). Access road construction would also require some water for dust suppression
23 and roadbed compaction and would have the potential to result in soil erosion and stormwater
24 runoff from cleared areas. Water would likely be trucked to the point of use from offsite
25 locations along with road construction materials. Construction activities would be conducted in
26 accordance with State-issued TPDES or equivalent permits for stormwater discharges
27 associated with construction activity, which would require the implementation of appropriate
28 BMPs to prevent or mitigate water quality impacts.

29 Construction of offshore wind turbines, including the offshore foundation and pilings, associated
30 anchoring devices, undersea cables, and onshore support installation (e.g., transformers) would
31 also have the potential to cause water quality impacts due to soil and sediment erosion and
32 runoff. Most notably, potential impacts would include disturbance of marine sediments from pile
33 driving and erection of cofferdams for the wind turbine superstructures. Nevertheless, such
34 water quality impacts would be temporary, and activities would be conducted in accordance with
35 USACE and other applicable permits and requiring the use of BMPs to minimize impacts.

36 For facility operations, the NGCC component of this alternative would require about one-fourth
37 of the water required by the NGCC alternative. It is expected that use of the existing intake and
38 discharge infrastructure on the MCR and the Colorado River would be sufficient to support the
39 NGCC plant. Surface water withdrawals would be subject to, and would remain well within,
40 STPNOC's existing water rights, and effluent discharges and stormwater discharges associated
41 with industrial activity would be subject to a revised State-issued TPDES permit under this
42 alternative. To support operations of individual wind turbine installations, only very small
43 amounts of water would be used to periodically clean turbine blades and motors as part of
44 routine servicing. It would be expected that water would be trucked to the point of use and
45 procured from nearby sources.

46 Implementation of the Energy Efficiency and Conservation Program component of this
47 alternative would likely entail little or no impact on surface water resources.

Environmental Impacts of Alternatives

1 In consideration of the information above, the impacts on surface water use and quality from
2 construction and operations under the combination alternative would be SMALL.

3 **8.4.3 Groundwater Resources**

4 For the single NGCC plant at the STP site, construction-related ground disturbance and
5 excavation work would be substantially less than that described for the NGCC alternative.
6 Although groundwater dewatering of foundation excavations for a new NGCC plant would likely
7 be required, slurry walls and wells were proposed for use to minimize potential adverse effects
8 from dewatering both on site and off site (NRC 2011). Groundwater dewatering, where
9 required, for installation of wind turbines on land, would be minimal due to the small footprint of
10 foundation structures. For all construction activities, appropriate BMPs, including spill
11 prevention practices, would be employed during wind turbine construction to prevent or
12 minimize impacts on groundwater quality.

13 For NGCC plant operations, NRC assumed that the NGCC alternative would entail the same
14 relative ratio of groundwater use to surface water use as that used at STP, Units 1 and 2. As
15 such, for a single NGCC unit, groundwater use would be about one-fourth of the water required
16 by the NGCC alternative and easily supported by existing onsite groundwater production wells
17 at STP. Little or no groundwater use would be expected for operation of wind turbines.

18 Implementation of the Energy Efficiency and Conservation Program component of this
19 alternative would likely entail little or no impact on groundwater resources.

20 Based on this information, the overall impact on groundwater use and quality from construction
21 and operations under the combination alternative would be SMALL.

22 **8.4.4 Aquatic Ecology**

23 Construction activities for the NGCC plant and land-based wind power projects (such as
24 construction of heavy haul roads and support facilities) could affect drainage areas or other
25 onsite aquatic features due to site runoff. NRC assumed that the plant operator would install
26 temporary and permanent erosion and sediment control measures to minimize the flow of
27 disturbed soils into ditches and wetlands. Such BMPs would likely be described in a TPDES
28 general permit relating to stormwater discharges for construction activities.

29 To bring new materials to the STP site for the NGCC plant, NRC assumed the plant operator
30 would dredge near the barge slip to transport some materials using barges. Permits and
31 certifications from the USACE and other agencies would require the implementation of BMPs to
32 minimize impacts. Due to the short-term nature of the dredging activities, the hydrological
33 alterations to aquatic habitats would be localized and temporary.

34 During operations, the NGCC plant would require approximately one-fourth of the cooling water
35 to be withdrawn from the Colorado River than the NGCC alternative analyzed in Section 8.2,
36 and the thermal discharge would similarly be smaller. Therefore, the number of fish and other
37 aquatic organisms affected by impingement, entrainment, and thermal impacts would be less for
38 the combination alternative than for license renewal and the NGCC alternative. The cooling
39 system for a new NGCC plant would have similar chemical discharges as STP, but the air
40 emissions from the NGCC plant would emit particulates that would settle onto the river surface
41 and introduce a new source of pollutants that would not exist if STP continued operating.
42 However, the flow of the Colorado River would dissipate pollutants, which would minimize the
43 exposure of fish and other aquatic organisms to pollutants.

1 Construction and operation of offshore wind projects could affect aquatic communities. In its
2 programmatic final EIS, MMS determined that construction and operations could have moderate
3 impacts to aquatic organisms due to pile driving for installation of the structures, removal of
4 structures by cutting or the use of explosives, and vessel traffic to and from the site
5 (MMS 2007). Organisms most likely to be affected would be marine mammals, sea turtles, and
6 fish due to noise from pile driving and vessel traffic as well as benthic organisms and habitats
7 that are directly affected during site preparation. Siting offshore wind projects away from
8 biologically productive areas could minimize such impacts. During operations, impacts from a
9 spill as a consequence of a vessel collision could be moderate to major (MMS 2007).

10 Because little water use would be required as part of the Energy Efficiency and Conservation
11 Program component of this alternative, impacts from the Energy Efficiency and Conservation
12 Program on aquatic resources would likely be minimal.

13 Because of the potential habitat disturbances and noticeable impacts on aquatic organisms
14 during construction and operation of offshore wind projects, impacts on aquatic resources from
15 the combination alternative would be SMALL to MODERATE. Impacts from the NGCC portion
16 of the alternative and Energy Efficiency and Conservation Program would not be noticeable
17 because less water withdrawal and discharge would be required than for STP, Units 1 and 2. In
18 addition, for the NGCC portion of the alternative, the construction activities would require BMPs,
19 dredging would be short-term, and pollutants would dissipate without the Colorado River
20 (minimizing exposure concentrations to aquatic resources).

21 **8.4.5 Terrestrial Ecology**

22 Constructing the NGCC plant would require approximately 92 ac (37 ha), which includes a new
23 pipeline that would run approximately 2 mi (3 km) from the STP site to an existing pipeline.
24 These estimates are based on GEIS scaling factors and details provided by STPNOC in its ER
25 (STPNOC 2010a). Impacts on terrestrial ecology from onsite construction of the one NGCC unit
26 would be less than the impacts described for the four-unit NGCC alternative, which are
27 described in Section 8.2.

28 STPNOC estimated that a utility-scale wind plant requires 60 ac of land per MWe of installed
29 capacity in open, flat terrain (STPNOC 2010a). Approximately 462,900 ac (187,300 ha) of land
30 would be required for the installed capacity of 7,714 MWe. Of this area, approximately 2,186 ac
31 (884 ha) would be temporarily disturbed during construction activities, and 937 ac (379 ha)
32 would be permanently disturbed during operations. The permanently disturbed area would be
33 filled with turbines, access roads, and other infrastructure, and the rest of the area would
34 potentially be available for compatible other uses, such as agriculture (ranch, pasture, or
35 cropland).

36 Impacts on terrestrial ecology from construction of the wind projects, including new transmission
37 lines, could include loss of terrestrial habitat, an increase in habitat fragmentation, and
38 corresponding increase in edge habitat, which may affect threatened and endangered species.
39 Construction and operations of wind power projects could result in increased mortality of birds
40 flying along the Trans-Gulf migratory route and might also cause increased mortality of
41 migratory and resident bats. Offshore wind power development would also affect avian and
42 aquatic resources. MMS (2007) determined that populations of marine and coastal birds as well
43 as migrating inland birds may experience minor to potentially major impacts due to turbine
44 collisions offshore and that endangered species would be the most impacted.

45 For this combination alternative, construction of the (a) 2-mi (3-km) natural gas pipeline and
46 (b) transmission lines to connect the wind projects to distribution systems could result in habitat
47 fragmentation and avian collisions with transmission lines. Depending on the length of new

Environmental Impacts of Alternatives

1 transmission lines, impacts could potentially destabilize attributes of the terrestrial ecosystem
2 because the transmission lines could permanently convert forested or cover habitats into open,
3 maintained areas. To the extent possible, STPNOC would route the pipeline through previously
4 disturbed areas (STPNOC 2010a). Threatened and endangered species may also be affected
5 by construction of the natural gas pipeline and new transmission lines. Long-linear projects,
6 such as pipelines and transmission lines, can often be sited to avoid sensitive areas.

7 Because no construction would occur for the Energy Efficiency and Conservation Program,
8 impacts from the Energy Efficiency and Conservation Program on terrestrial resources would
9 likely be minimal. Wind energy projects could have a noticeable impact on avian and bat
10 communities because wind energy projects in the Trans-Gulf migratory route could result in
11 increased mortality of migratory and resident birds and bats. Building new transmission lines
12 would also increase habitat fragmentation. Offshore wind power could also result in increased
13 mortality of coastal birds. Based on this information, impacts on terrestrial resources would be
14 MODERATE.

15 **8.4.6 Human Health**

16 The human health risks from a combination of alternatives include the effects already discussed
17 in Section 8.2.6 for the NGCC plant. However, the effects would be slightly less since one,
18 rather than four, NGCC unit would be constructed and operated. For wind power, the GEIS
19 notes that, except for a potential small number of occupational injuries, routine operations would
20 not affect human health. For the Energy Efficiency and Conservation Program, the GEIS notes
21 that the environmental impacts are likely to be centered on indoor air quality (NRC 1996). This
22 is due to increased weatherization of the home in the form of extra insulation and reduced air
23 turnover rates from the reduction in air leaks. However, the actual impact is highly site-specific
24 and not yet well-established. Overall, human health risks to occupational workers and to
25 members of the public from the combination alternative would likely be SMALL.

26 Noise during operations of NGCC plant would be limited to industrial processes and
27 communications. Pipelines delivering natural gas fuel could be audible off site near compressor
28 stations. Pipeline companies would need to adhere to local ordinances regarding maximum
29 noise levels during construction and at compressor stations. Noise from the wind energy project
30 would be audible in the immediate area but would likely be unobtrusive. Some noise impacts
31 could occur in instances of energy conservation and efficiency upgrades to major building
32 systems, but this impact would be intermittent and short-lived. Therefore, impacts from noise
33 would likely be SMALL.

34 **8.4.7 Land Use**

35 The GEIS generically evaluates the impact of constructing and operating various replacement
36 power plant alternatives on land use, both on and off each plant site. The analysis of land-use
37 impacts focuses on the amount of land area that would be affected by the construction and
38 operation of a single-unit NGCC plant at the STP site, wind energy projects, and energy
39 conservation and efficiency.

40 Based on scaled GEIS estimates, constructing the single-unit NGCC unit would require
41 approximately 92 ac (37 ha) at the STP site. This amount of land use would include other plant
42 structures and associated infrastructure, such as the new 2-mi (3-km) pipeline, and is unlikely to
43 exceed 92 ac (37 ha), excluding land for natural gas wells and collection stations.

44 In addition to onsite land requirements, land would be required off site for natural gas wells and
45 collection stations. Scaling from GEIS estimates, approximately 2,400 ac (970 ha) would be

1 required for wells and collection stations to bring the natural gas to the power plant. Most of this
2 land requirement would occur on land where natural gas extraction already occurs.

3 STPNOC estimated that utility-scale, land-based wind energy projects would require 60 ac of
4 land per MWe of installed capacity in open, flat terrain (STPNOC 2010a). Approximately
5 462,900 ac (187,300 ha) of land would be required for the installed capacity of 7,714 MWe. Of
6 this area of land, approximately 2,186 ac (884 ha) would be temporarily disturbed during
7 construction activities, and 937 ac (379 ha) would be permanently used for each wind turbine
8 during operations. Land used for the wind energy projects would be filled with turbines, access
9 roads, and other infrastructure, and the rest of the land area between the turbines would be
10 available for other uses, such as agriculture (ranch, pasture, or cropland).

11 Offshore wind energy projects would need to avoid impeding navigation. For both land-based
12 and offshore wind projects, new electrical transmission systems would need to be built to
13 connect the wind energy projects to the electric distribution system.

14 The elimination of uranium fuel for STP could partially offset offsite land requirements for other
15 energy projects. Scaling from GEIS estimates, approximately 2,560 ac (1,036 ha) would no
16 longer be needed for the mining and processing of uranium.

17 The land use impacts of the Energy Efficiency and Conservation Program would be minimal.
18 The rapid replacement and disposal of older inefficient appliances and other equipment would
19 generate waste material and could increase the size of landfills; however, given the time for
20 program development and implementation, the cost of replacements, and the average life of
21 equipment, the replacement process would probably be gradual. More efficient appliances and
22 equipment would replace older equipment (especially in the case of frequently replaced items,
23 such as light bulbs). In addition, many items (such as home appliances and industrial
24 equipment) have recycling value and would not be disposed of in landfills.

25 The wind energy portion of this combination alternative would require a substantial amount of
26 open land, although only a small portion would be used for wind turbines, access roads, and
27 infrastructure. Therefore, land use impacts from the combination alternative could range from
28 SMALL to MODERATE.

29 **8.4.8 Socioeconomics**

30 As previously discussed, socioeconomic impacts are defined in terms of changes to the
31 demographic and economic characteristics and social conditions of a region. For example, the
32 number of jobs created by the construction and operation of a new NGCC plant and wind power
33 projects could affect regional employment, income, and expenditures. Two types of jobs would
34 be created by this alternative: (1) construction jobs, which are transient, short in duration, and
35 less likely to have a long-term socioeconomic impact; and (2) power plant and wind energy
36 operation jobs, which have the greater potential for permanent, long-term socioeconomic
37 impacts. Workforce requirements for the construction and operation of the combination
38 alternative were evaluated to measure their possible effects on current socioeconomic
39 conditions.

40 Based on GEIS estimates, the construction workforce would be up to 800 (maximum) workers
41 for the NGCC plant. Scaling from STPNOC's estimates, the estimated construction workforce
42 would be up to 507 (maximum) workers (STPNOC 2010a). STPNOC's estimate appears
43 reasonable; therefore, it is used in this analysis. STPNOC did not provide a construction
44 workforce estimate for wind energy projects. In Exelon Generation Company's, LLC (Exelon)
45 ER for Limerick Generating Station, Exelon estimated a construction workforce of 200 for
46 approximately half the amount of wind capacity needed for this combination alternative

Environmental Impacts of Alternatives

1 (Exelon 2011). This estimate includes both land-based and offshore wind energy projects.
2 Scaling from this estimate, wind energy projects could require a construction workforce of up to
3 400 workers. The relative economic impacts of this many workers on the local economy and tax
4 base would vary, with the greatest impacts occurring in the communities where the majority of
5 construction workers would reside and spend their income. As a result, local communities could
6 experience a short-term economic “boom” from increased tax revenue and income generated by
7 construction expenditures and the increased demand for temporary (rental) housing and
8 business services. Some construction workers could relocate to Matagorda and surrounding
9 counties in order to be closer to the construction work sites. However, given the proximity of
10 STP to the Houston and other metropolitan areas, workers could commute to the various
11 construction sites, thereby lessening the need for additional rental housing near STP.

12 After completing the installation of the single NGCC unit and wind turbines, local communities
13 could experience a return to pre-construction economic conditions. Based on this information,
14 and the given number of workers, socioeconomic impacts during construction in communities
15 near the STP site and wind farms could be SMALL, due to the small number of workers needed
16 to construct the NGCC plant and because the wind energy project workers would be spread
17 throughout the service region.

18 Scaled from GEIS estimates, the single-unit NGCC power plant operation workforce would be
19 100 workers. Based on STPNOC’s estimates, the maximum NGCC operation workforce would
20 be 23 workers (STPNOC 2010a). STPNOC’s estimate appears reasonable; therefore, it is used
21 in this analysis. STPNOC did not provide an operations workforce estimate for wind energy
22 projects. In Exelon’s ER for the Limerick Generating Station, Exelon estimated a wind energy
23 workforce of 50 workers for approximately half the amount of wind capacity needed for this
24 combination alternative (Exelon 2011). This estimate includes both land-based and offshore
25 wind energy projects. Scaling from this estimate, wind energy projects could require an
26 operations workforce of up to 100 workers. The amount of property taxes paid under the
27 combination alternative may increase if additional land is required off site to support this
28 alternative. As noted in the GEIS, an Energy Conservation and Efficiency Program would also
29 create jobs for additional workers (NRC 1996). Socioeconomic impacts during operations could
30 range from SMALL to MODERATE as the STP site transitions to the new, single-unit NGCC
31 power plant. The reduction in overall employment at STP could affect property tax revenue and
32 income in local communities and businesses. In addition, the permanent housing market could
33 also experience increased vacancies and decreased prices if operations workers and their
34 families move out of the region.

35 **8.4.9 Transportation**

36 Construction and operation of an NGCC plant at the STP site and wind energy projects
37 throughout the region would increase the number of vehicles on the roads near these facilities.
38 During construction, cars and trucks would deliver workers, materials, and equipment to the
39 worksites. Traffic volumes on local roads near these worksites would noticeably increase and
40 peak during shift changes resulting in temporary levels of service impacts and delays at
41 intersections. Transporting components of wind turbines via roadways could also have a
42 noticeable impact on traffic conditions, and this effect is likely to be spread over a large area.
43 Pipeline construction and modification to existing natural gas pipeline systems could also have a
44 temporary impact. Based on this information, traffic-related transportation impacts during
45 construction could range from SMALL to MODERATE depending on the location of the wind
46 energy sites, road capacities, and traffic volumes.

47 Traffic volumes on local roads near construction sites after the installation of the NGCC and
48 wind turbines would be noticeably reduced. Given the small number of workers needed to

1 operate the energy projects in this combination alternative, the levels of service impacts on local
2 roads during shift changes would be SMALL. In addition, wind energy project operation workers
3 would be spread across the service region, and any traffic-related transportation effects from the
4 energy efficiency alternative would also be widely distributed. Therefore, overall transportation
5 impacts for this combination alternative during operations would be SMALL.

6 **8.4.10 Aesthetics**

7 The analysis of aesthetic impacts focuses on the degree of contrast between the surrounding
8 landscape and the visibility of the NGCC plant and wind energy projects. In general, aesthetic
9 changes would be limited to the immediate vicinity of the STP site and wind energy projects.

10 Aesthetic impacts from the NGCC plant component of the combination alternative would be
11 essentially the same as those described for the NGCC alternative in Section 8.2.10, except
12 there would be one unit rather than four units. During construction, all of the clearing and
13 excavation would occur on the STP site. These activities may be visible from offsite roads,
14 particularly FM 521. Since the STP site already appears industrial, construction of the NGCC
15 power plant would appear similar to onsite activities during refueling outages. Power plant
16 infrastructure would be smaller and less noticeable than STP containment and turbine buildings.
17 Noise during plant operations would be limited to industrial processes and communications.
18 Pipelines delivering natural gas fuel could be audible off site near gas compressor stations. In
19 general, aesthetic changes due to the construction and operation of the single-unit NGCC would
20 be limited to the immediate vicinity of the STP site and would be SMALL.

21 The wind energy projects would have the greatest visual impact. Approximately 3,877 wind
22 turbines at over 300 ft (100 m) tall would be spread across multiple land-based sites covering
23 462,900 ac (187,300 ha). The turbines would dominate the view and would likely become the
24 major focus of attention. Offshore wind projects would also be visible because of the height and
25 size of the wind turbine generators (MMS 2007). Depending on their location, the aesthetic
26 impacts from the construction and operation of the wind energy projects would be MODERATE
27 to LARGE.

28 Impacts from the Energy Conservation and Efficiency Program would be SMALL because it
29 would not require any visible changes to existing infrastructure.

30 **8.4.11 Historic and Archaeological Resources**

31 The same considerations, discussed in Section 8.2.11, for the impact of the construction of a
32 four-unit NGCC plant on historic and archaeological resources apply to the construction
33 activities that would occur on the STP site for a new one-unit NGCC plant. As described in
34 Section 2.2.10, much of the STP site has been previously disturbed by the construction of STP,
35 Units 1 and 2. In addition, in preparation for the COL application for Units 3 and 4, STPNOC
36 conducted a cultural resources assessment of the STP site. STPNOC reviewed existing
37 information for the STP site and the area within a 10-mi (16-km) radius. STPNOC concluded
38 that any cultural resource sites that may have existed on site would no longer retain their
39 integrity because the area was heavily disturbed during the construction of Units 1 and 2
40 (STPNOC 2010b). In December 2006, STPNOC reported these findings to the SHPO at the
41 Texas Historical Commission. The SHPO concurred, in January 2007, that there would be no
42 impacts to historic properties (STPNOC 2006; THC 2007).

43 There is a low potential for cultural resources to be located in previously undisturbed portions of
44 the STP site. However, if the NGCC unit was to be sited within undisturbed areas or within
45 areas of known cultural sensitivity (historic grave site located on the property and described in

Environmental Impacts of Alternatives

1 Section 2.2.10), these areas would need to be surveyed by a professional archaeologist to
2 identify and develop possible mitigation measures to address any adverse effects from project
3 activities. NRC assumes the plant operator would follow similar procedures to those described
4 in the final EIS for STP, Units 3 and 4 (NRC 2011), should the plant operator discover any
5 historic or cultural resources during ground-disturbing activities associated with building the new
6 units.

7 Studies would be needed for all areas of potential disturbance at the proposed plant site, wind
8 project locations, and along associated corridors where new construction would occur (e.g., the
9 new 2-mi pipeline, roads, transmission corridors, rail lines, or other ROWs). Any affected areas
10 would need to be surveyed to identify and record historic and archaeological resources, identify
11 cultural resources (e.g., traditional cultural properties), and develop possible mitigation
12 measures to address any adverse effects from ground-disturbing activities. In most cases,
13 long-linear projects (e.g., pipelines) can be sited to avoid areas of greatest sensitivity.

14 Construction of wind energy projects could affect cultural resource because areas
15 approximately 15 to 25 ft (4.6 to 6 m) in diameter would be excavated. Wind turbines can likely
16 be sited to avoid sensitive areas because the disturbed area is a small portion of the total
17 amount of area required. In addition, wind turbines within the viewshed of traditional cultural
18 properties and historic properties could have noticeable impacts to cultural and historic
19 resources. Proper siting may be able to mitigate these potential impacts.

20 The NRC staff determined that the impact on historic and archaeological resources from the
21 NGCC portion of the combination alternative would be SMALL for the following reasons:

- 22 • NRC (2011) and STPNOC (2010a, 2010b) did not identify any cultural
23 resources that could be affected by Units 3 and 4.
- 24 • The SHPO determined that construction for Units 3 and 4 would not affect
25 cultural and historic resources.
- 26 • Long-linear projects (e.g., pipelines) can usually be sited to avoid sensitive
27 areas.
- 28 • NRC assumes that the plant operator would follow environmental compliance
29 procedures for new ground-disturbing activities.

30 Depending on the resource richness of the site chosen for the wind energy projects, the impacts
31 could range between SMALL to MODERATE. Impacts to historic and archaeological resources
32 from implementing the Energy Efficiency and Conservation Program would be SMALL and
33 would unlikely affect land use or historical or cultural resources elsewhere in Texas. Therefore,
34 the overall impacts on historic and archaeological resources from the combination alternative
35 could range from SMALL to MODERATE.

36 **8.4.12 Environmental Justice**

37 The environmental justice impact analysis evaluates the potential for disproportionately high and
38 adverse human health and environmental effects on minority and low-income populations that
39 could result from the construction and operation of a new NGCC power plant at the STP site,
40 wind energy projects, and the Energy Efficiency and Conservation Program. As previously
41 discussed in Section 8.1.12, such effects may include human health, biological, cultural,
42 economic, or social impacts. Some of these potential effects have been identified in resource
43 areas discussed in this SEIS. For example, increased demand for rental housing during plant
44 construction could disproportionately affect low-income populations. Minority and low-income
45 populations are subsets of the general public living near the STP site and wind energy project

1 sites, and all are exposed to the same hazards generated from constructing and operating an
2 NGCC plant and wind energy projects. Section 4.9.7, "Environmental Justice," presents
3 demographic information about minority and low-income populations residing in the vicinity of
4 the STP site.

5 Potential impacts to minority and low-income populations from the construction and operation of
6 a new NGCC plant at the STP site and wind energy projects would mostly consist of
7 environmental and socioeconomic effects (e.g., noise, dust, traffic, employment, and housing
8 impacts). Noise and dust impacts during construction would be short-term and primarily limited
9 to onsite activities. Minority and low-income populations residing along site access roads would
10 be directly affected by increased commuter vehicle and truck traffic. However, because of the
11 temporary nature of construction, these effects would only occur during certain hours of the day
12 and are unlikely to be high and adverse. Increased demand for rental housing during
13 construction of the NGCC and wind energy projects could also affect low-income populations
14 living near STP and wind energy project sites. Given the proximity of STP to the Houston
15 metropolitan area, many construction workers could commute to the STP and wind energy
16 project sites, thereby lessening the additional need for rental housing near STP.

17 Low-income populations could benefit from weatherization and insulation in an Energy
18 Conservation and Efficiency Program. This could have a greater beneficial effect on
19 low-income populations than the general population because low-income households generally
20 experience greater home energy burdens than the average household.

21 Based on this information, and the analysis of human health and environmental impacts
22 presented in this SEIS, the combination alternative would not create disproportionately high and
23 adverse human health and environmental effects on minority and low-income populations.

24 **8.4.13 Waste Management**

25 During the construction stage for the NGCC plant and wind projects, land clearing and other
26 construction activities would generate wastes that could be recycled, disposed of on site, or
27 shipped to the offsite waste disposal facility. During the operational stage, spent SCR catalysts,
28 which control nitrogen oxide emissions from the NGCC plant, would make up the majority of the
29 waste generated by this alternative.

30 There would be an increase in wastes generated during installation or implementation of energy
31 conservation measures, such as appropriate disposal of old appliances, installation of control
32 devices, and modifications of buildings. New and existing recycling programs would help to
33 minimize the amount of generated waste.

34 The NRC concludes that overall waste impacts from the combination alternative would be
35 SMALL.

36 **8.4.14 Summary of Impacts of the Combination Alternative**

37 Table 8–5 summarizes the environmental impacts of the combination alternative compared to
38 continued operation of the STP.

39

Environmental Impacts of Alternatives

1 **Table 8–5. Summary of Environmental Impacts of the Combination Alternative**
 2 **Compared to Continued Operation of STP, Units 1 and 2**

Category	Combination Alternative	Continued STP Operation
Air quality	SMALL to MODERATE	SMALL
Surface water	SMALL	SMALL
Groundwater	SMALL	SMALL
Aquatic resources	SMALL to MODERATE	SMALL
Terrestrial resources	MODERATE	SMALL
Human health	SMALL	SMALL to MODERATE
Land use	SMALL to MODERATE	SMALL
Socioeconomics	SMALL to MODERATE	SMALL
Transportation	SMALL to MODERATE	SMALL
Aesthetics	SMALL to LARGE	SMALL
Historic & archaeological	SMALL to MODERATE	SMALL
Waste management	SMALL	SMALL

3 **8.5 Purchased Power**

4 Under the purchased power alternative, STPNOC would purchase 2,500 MWe of electricity from
 5 other power generators. No new generating capacity would be built and operated by STPNOC.
 6 In its ER, STPNOC assumed that purchased power is a reasonable alternative for the following
 7 reasons:

- 8 • A wholesale electricity market currently exists in the ERCOT region.
- 9 • ERCOT implements rules to anticipate and meet electricity demands and
 10 promote competition among electricity suppliers.
- 11 • Most of ERCOT's retail customers can choose a supplier to purchase
 12 electricity.

13 If STPNOC purchased electricity, the source of all generated electricity would be within the
 14 ERCOT region because ERCOT operates wholly within the State of Texas and does not
 15 interconnect with neighboring reliability regions for the purpose of importing or exporting power
 16 (STPNOC 2010a). In 2010, electricity produced within the ERCOT region was dominated by
 17 coal (40 percent), followed by natural gas (38 percent), nuclear (13 percent), wind (8 percent),
 18 and other sources (1 percent) (ERCOT 2011a). As of April 2011, new energy projects under
 19 ERCOT's review included 36,124 MWe of wind power (58 percent); 12,954 MWe of natural
 20 gas-fired generation (21 percent); 5,900 MWe of nuclear power (9 percent); 4,075 MWe of
 21 coal-fired generation (7 percent); 1,454 MWe solar power (2 percent); 150 MWe of
 22 biomass-fired generation (less than 1 percent); and 1,980 MWe of other resources (3 percent)
 23 (ERCOT 2011a). Based on current and likely future electric generation, NRC assumed that the
 24 purchased power would likely come from a mixture of coal, natural gas, wind, and nuclear
 25 energy.

26 Because the purchased power would be limited to resources available within the ERCOT
 27 region, new energy generation facilities may need to be built to supply the electricity.

1 Construction impacts would be similar to those described under the new nuclear, coal, natural
2 gas, and wind alternatives described in the previous sections. In addition to the construction
3 impacts described in Sections 8.1 through 8.3, there could be additional impacts if new plants
4 are built on greenfield sites. For example, impacts to aquatic and terrestrial resources and
5 historical and cultural resources are likely to be greater due to land clearing of previously
6 undisturbed areas. Additional impacts would also occur from construction of support
7 infrastructure, like transmission lines and roads. Furthermore, the community would not be
8 familiar with the appearance of a power facility, which would change the region's aesthetic
9 character. Workers skilled in power plant or wind farm operations may not be available near a
10 greenfield site.

11 During operations, impacts from new nuclear, coal-fired, and natural gas-fired plants and wind
12 energy projects would be similar to that described under the new nuclear, coal, natural gas, and
13 wind alternatives described in the previous sections. Impacts from the operations of existing
14 coal- and natural gas-fired plants would likely be greater than the operations of new plants
15 because older plants are more likely to be less efficient and without modern emissions controls.
16 Air quality impacts from the combination of all sources would likely be greater than license
17 renewal because a large portion of the purchased power would likely be from coal- and natural
18 gas-fired plants.

19 While purchased power is a reasonable alternative, the potential impacts of constructing and
20 operating new power generating facilities is addressed elsewhere in this chapter. In general,
21 the impacts would likely be greater than license renewal due to potential new construction and
22 because continued operation of older plants could result in higher emissions. Ultimately, the
23 impacts would depend on the mix of sources used to supply the 2,500 MWe of electricity.
24 Below is a brief summary of the impacts for each resource area.

25 **8.5.1 Air Quality**

26 New and existing nuclear plants and wind farms would not have noticeable impacts on air
27 quality. New and existing natural gas- and coal-fired plants would have noticeable impacts on
28 air quality; both natural gas- and coal-fired plants emit higher amounts of nitrogen oxides, sulfur
29 oxides, PM, HAPs, carbon monoxide, carbon dioxide, and mercury as compared to STP, Units 1
30 and 2. The impacts on air quality would be SMALL to MODERATE.

31 **8.5.2 Surface Water and Groundwater Resources**

32 New and existing nuclear, coal-fired, and natural gas-fired plants and wind energy projects
33 would not have noticeable impacts on water resources assuming all energy generating facilities
34 operate within their associated water quality and water use permits. The impacts on surface
35 water and groundwater resources would be SMALL.

36 **8.5.3 Terrestrial and Aquatic Ecology**

37 New and existing natural gas-fired and nuclear plants would not have noticeable impacts on
38 aquatic and terrestrial resources assuming plants are built in areas that avoid sensitive species
39 and habitats. New, land-based wind energy projects would not have noticeable impacts on
40 aquatic resources assuming projects are built in areas that avoid sensitive species and habitats.
41 New wind energy projects would have noticeable impacts on avian and bat communities and
42 new offshore wind energy projects could have noticeable impacts on fish, whales, turtles,
43 benthic organisms, and other marine life. New and existing coal-fired plants would have
44 noticeable impacts on terrestrial communities primarily due to the deposition of ash and other

Environmental Impacts of Alternatives

1 pollutants and because of the extent of terrestrial habitat disturbance associated with coal
2 mining. The impacts on terrestrial and aquatic ecology would be SMALL to MODERATE.

3 **8.5.4 Human Health**

4 New and existing nuclear, coal-fired, and natural gas-fired plants and wind energy projects
5 would have SMALL impacts on human health due to the extent of regulations to protect public
6 health.

7 **8.5.5 Land Use**

8 Purchased power from existing power plants would not cause any land use changes. New
9 power plants would likely be constructed at existing power plant sites. Purchased power from
10 coal- and natural gas-fired plants could have a noticeable impact on land use due to the amount
11 of land required for coal mining and gas drilling. New wind energy projects would have a
12 noticeable land use impact because of the large amount of land required for wind farms. Land
13 use impacts would be SMALL to MODERATE.

14 **8.5.6 Socioeconomics (including transportation and aesthetics)**

15 Purchased power from existing power plants would not have any socioeconomic impact
16 because there would be no change in power plant operations or workforce. Construction of new
17 electrical power generating facilities could cause noticeable short-term socioeconomic and
18 transportation impacts due to the number of construction workers required to build the new
19 power plant. Traffic volumes would increase on local roads during shift changes.

20 Wind energy projects would have the greatest visual impact; wind turbines would dominate the
21 view and would likely become the major focus of attention.

22 The impacts would be SMALL to LARGE.

23 **8.5.7 Historic and Archaeological Resources**

24 Purchased power from existing power plants would not have any impact on historic and
25 archaeological resources. In addition, ground-disturbing maintenance activities during
26 operations also have the potential to affect historic and archaeological resources.

27 Construction of new nuclear, coal-fired, and natural gas-fired plants and wind energy projects
28 could affect archaeological and historic resources. Archaeological surveys would need to be
29 conducted prior to any excavations at proposed power plant sites. After surveys are completed,
30 sensitive resource areas could be avoided or mitigated prior to construction. The overall
31 impacts on historic and archaeological resources would be SMALL to MODERATE.

32 **8.5.8 Environmental Justice**

33 Low-income populations could be disproportionately affected by increased utility bills due to the
34 cost of purchased power. However, programs are available to assist low-income families in
35 paying for increased electrical costs.

36 Potential impacts to minority and low-income populations from the construction and operation of
37 new power plants would mostly consist of environmental and socioeconomic effects (e.g., noise,
38 dust, traffic, employment, and housing impacts). Noise and dust impacts during construction
39 would be short-term and primarily limited to onsite activities. Minority and low-income
40 populations residing along site access roads would be directly affected by increased commuter

1 vehicle and truck traffic. However, because of the temporary nature of construction, these
 2 effects would only occur during certain hours of the day and are unlikely to be high and adverse.
 3 Increased demand for rental housing during construction could also affect low-income
 4 populations living near the construction site. However, workers could commute to the
 5 construction site, thereby lessening the need for additional rental housing near the construction
 6 sites. Based on this information, and the analysis of human health and environmental impacts
 7 presented in this section, the purchased power alternative could disproportionately affect
 8 low-income populations, but these effects would not be high and adverse.

9 **8.5.9 Waste Management**

10 New and existing nuclear and natural gas-fired plants and wind energy projects would not have
 11 noticeable impacts. However, new and continued generation of coal-fired plants would have
 12 noticeable impacts due to the accumulation of ash and scrubber sludge. The overall impacts on
 13 waste management would range from SMALL to MODERATE.

14 **8.5.10 Summary of Impacts of the Purchased Power Alternative**

15 Table 8–6 summarizes the environmental impacts of the purchased power alternative compared
 16 to continued operation of the STP.

17 **Table 8–6. Summary of Environmental Impacts of the Purchased Power Alternative**
 18 **Compared to Continued Operation of STP, Units 1 and 2**

Category	Purchased Power	Continued STP Operation
Air quality	SMALL to MODERATE	SMALL
Surface water & groundwater	SMALL	SMALL
Aquatic & terrestrial resources	SMALL to MODERATE	SMALL
Human health	SMALL	SMALL to MODERATE
Land use	SMALL to MODERATE	SMALL
Socioeconomics (including transportation & aesthetics)	SMALL to LARGE	SMALL
Historic & archaeological	SMALL to MODERATE	SMALL
Waste management	SMALL to MODERATE	SMALL

19 **8.6 Alternatives Considered but Dismissed**

20 Alternatives to license renewal that were considered and eliminated from detailed study are
 21 presented in this section. These alternatives were eliminated due to technical, resource
 22 availability, or current commercial limitations. Many of these limitations would continue to exist
 23 when the current STP licenses expire. NRC evaluated an alternative of wind energy in
 24 combination with an NGCC plant and energy efficiency and conservation programs in
 25 Section 8.4. The evaluations of wind technology and energy conservation and efficiency
 26 appearing in this section are as discrete alternatives.

1 **8.6.1 Offsite Nuclear-, Gas-, and Coal-Fired Capacity**

2 While nuclear-, gas-, and coal-fired power generating alternatives like those considered in
3 Sections 8.1 through 8.3, respectively, could be constructed offsite, the impacts would be
4 greater than constructing these facilities and making use of existing infrastructure at the STP
5 site. Additional impacts would occur from the construction of new water intake and discharge
6 structures, as well as other support infrastructure, including transmission lines and roads that
7 are already present on the STP site. Furthermore, the community around STP is already
8 familiar with the appearance of a power generating facility, and it is an established part of the
9 region's character. Workers skilled in power plant operations may not be available in other
10 locations. However, support infrastructure and skilled power-plant workers may be available
11 near existing industrial sites, but remediation may also be necessary in order to make the site
12 ready for redevelopment. In short, an existing power plant site would present the best location
13 for a new replacement power facility.

14 **8.6.2 Energy Conservation and Energy Efficiency**

15 Though often used interchangeably, energy conservation and energy efficiency are different
16 concepts. Energy efficiency means deriving a similar level of services by using less energy
17 while energy conservation indicates a reduction in energy consumption. Both fall into a larger
18 category known as demand-side management. Demand-side management measures address
19 energy end uses—unlike energy supply alternatives discussed in previous sections.
20 Demand-side management can include measures that do the following:

- 21 • shift energy consumption to different times of the day to reduce peak loads,
- 22 • interrupt certain large customers during periods of high demand,
- 23 • interrupt certain appliances during high demand periods,
- 24 • replace older, less efficient appliances, lighting, or control systems, and
- 25 • encourage customers to switch from gas to electricity for water heating and
26 other similar measures that utilities use to boost sales.

27 Unlike other alternatives to license renewal, the GEIS notes that conservation is not a discrete
28 power-generating source; nonetheless, it represents an option that states and utilities may use
29 to reduce their need for power generation capability, so the NRC addressed it in the GEIS
30 (NRC 1996).

31 In 2010, the Public Utility Commission of Texas approved Substantive Rule § 25.181, which
32 requires all electric transmission and distribution utilities within the ERCOT market, including
33 CPS Energy and Austin Energy (two of the owners of STP, Units 1 and 2), to use demand-side
34 management to reduce their customers' energy consumption by a minimum of 20 percent of the
35 utility's annual growth. The rule further requires a minimum of 25 percent reduction in 2012 and
36 30 percent in 2013 and beyond.

37 CPS Energy and Austin Energy implement programs to promote demand-side management.
38 These programs include load curtailment incentives during periods of peak demand; rebates
39 and financial incentives for commercial, industrial, and residential customers for installation of
40 energy-efficient appliances and equipment; and the adoption of updated energy codes for new
41 building construction (STPNOC 2010a). Demand-side management programs from other Texas
42 utilities would also help offset the 2,500 MWe produced by STP because STPNOC sells power
43 produced at STPNOC into the ERCOT interconnection (STPNOC 2010a).

1 Because Substantive Rule § 25.181 already requires annual 30 percent reductions in energy
2 consumption from demand-side management, it is unlikely that additional increases in energy
3 efficiency in the State of Texas will have grown enough to offset the loss of 2,500 MWe
4 produced by STP by the time the licenses expire in 2027 and 2028. Because of this, the NRC
5 staff has not evaluated energy conservation and efficiency as a discrete alternative to license
6 renewal. NRC evaluated an alternative with energy efficiency and conservation programs in
7 combination with an NGCC plant and wind energy in Section 8.4.

8 **8.6.3 Wind Power**

9 Texas has significant wind energy resources and leads the Nation in wind-powered generation
10 capacity (DOE 2011b). As discussed in Section 8.4, as of June 30, 2011, the installed wind
11 capacity in Texas was 10,135 MWe (DOE 2011b). Wind resource areas in the Texas
12 Panhandle, along the Gulf coasts south of Galveston and in the mountain passes and ridgetops
13 of the Trans-Pecos region, offer some of the greatest wind power potential in the U.S. The
14 Roscoe Wind Farm in Texas is the largest wind farm in the world with a total capacity of
15 781.5 MWe spread across approximately 100,000 ac (40,470 ha) in four counties near Roscoe
16 in central Texas.

17 Newer wind turbines typically operate at approximately a 36 percent annual capacity factor
18 (DOE 2008). Wind turbines generally can serve as an intermittent power supply (NPCC 2005).
19 Wind power might serve as a means of providing baseload power (a) if it is combined with
20 energy storage mechanisms, such as pumped hydroelectric or compressed air energy storage
21 (CAES), (b) if many wind farms are interconnected to one another on the transmission grid, as
22 described in Section 8.4, or (c) if another readily dispatchable power source is used when wind
23 power is unavailable (e.g., hydropower).

24 EIA is not projecting any growth in pumped storage capacity through 2035 (EIA 2011a). As
25 described below, the potential for new hydroelectric development in Texas is limited. Therefore,
26 NRC concludes that the use of pumped storage in combination with wind turbines to generate
27 2,500 MWe is unlikely in the ERCOT region or Texas.

28 A CAES plant is another potential storage mechanism that could potentially serve as means for
29 wind to provide baseload power. A CAES plant consists of motor-driven air compressors that
30 use low cost off peak electricity to compress air into an underground storage medium. During
31 high electricity demand periods, the stored energy is recovered by releasing the compressed air
32 through a combustion turbine to generate electricity (NPCC 2009). Only two CAES plants are
33 currently in operation. A 290-MWe plant near Bremen, Germany, began operating in 1978, and
34 a 110-MWe plant located in McIntosh, Alabama, has been operating since 1991. Both facilities
35 use salt caverns (Succar and Williams 2008). A CAES plant requires suitable geology, such as
36 an underground cavern for energy storage, which would likely be available in Texas due to the
37 presence of salt domes. A 268-MWe CAES plant coupled to a wind farm, the Iowa Stored
38 Energy Park, had been proposed for construction near Des Moines, Iowa. The facility would
39 have used a porous rock storage reservoir for the compressed air (Succar and Williams 2008).
40 However, the project has been cancelled due to geologic concerns (ISEPA 2011). Other pilot,
41 demonstration, prototype, and research projects involving CAES have been announced,
42 including projects in Texas and throughout the U.S. Norton Energy Storage is proposing to
43 construct a CAES plant that would provide up to 2,700 MWe of storage capacity in Norton, Ohio
44 (OPSB 2011). Projects such as the Conoco-Phillips and General Compression venture may
45 use compressed air storage directly without the combustion of fuel such as natural gas.
46 However, NRC is not aware of a CAES project coupled with wind generation that is providing
47 baseload power. Therefore, NRC concludes that the use of CAES in combination with wind
48 turbines to generate 2,500 MWe in the ERCOT region is unlikely.

Environmental Impacts of Alternatives

1 A significant challenge for new wind power facilities is that wind farms can be built more quickly
2 than transmission lines. It can take a year to build a wind farm, but 5 years to build the
3 transmission lines needed to send power to cities. Moreover, wind power developers are
4 reluctant to build where transmission lines do not yet exist, and utilities are equally reluctant to
5 install transmission in areas that do not yet have power generators (TSECO 2008). Archer and
6 Jacobson (2007) examined whether wind projects interconnected to one another on the
7 transmission grid could provide a source of baseload power, as described in Section 8.4. This
8 study determined that interconnecting wind farms through the transmission grid increases the
9 probability that at least one site experiences sufficient wind to produce electricity. Thus, as
10 more sites are added to the transmission grid, the interconnected wind farms provide electricity
11 that is comparable to a single wind farm providing near constant deliverable wind power.
12 However, due to the amount of new transmission lines required and the cost limitations of
13 building new transmission lines, it is unlikely that sufficient transmission lines could be built to
14 interconnect sufficient wind projects to provide 2,500 MWe of baseload power (with an installed
15 capacity of at least 12,000 MWe).

16 Offshore Wind. Wind data suggest there is potential for offshore wind farms along the coast of
17 Texas, although project costs likely limit the future potential of large-scale projects (NRC 2011;
18 Southern and GIT 2007). Southern Company and the Georgia Institute of Technology (GIT)
19 studied the viability of offshore wind turbines in the southeast and determined that offshore
20 project costs would run approximately 50 to 100 percent higher than land-based systems. Also,
21 based on current prices for wind turbines, the 20-year levelized cost of electricity produced from
22 an offshore wind farm would be above the current production costs from existing power
23 generation facilities. In addition, the current commercially available offshore wind turbines are
24 not built to withstand major hurricanes above a Category 3 or a 1-minute sustained wind speed
25 of 124 mph. Additional details on the limitations of offshore wind power as a source of baseload
26 power is described in the final EIS for STP, Units 3 and 4 (NRC 2011).

27 The National Renewable Energy Laboratory (NREL) issued a report that identified offshore wind
28 projects in the southeast (NREL 2010). The report identified the proposed Coastal Point Energy
29 Project (also called the Galveston Wind Project) off the Texas coast near Galveston
30 (approximately 9 mi from shore), which is anticipated to have a capacity of 300 MWe
31 (NREL 2010). No other wind energy projects were identified by NREL off the coast of Texas or
32 its adjoining State (Louisiana).

33 Conclusion. Although wind power is an important energy resource in the ERCOT region and
34 Texas, NRC concludes that a wind energy facility at or in the vicinity of the STP site or
35 elsewhere in the ERCOT region would not currently be a reasonable alternative to license
36 renewal. NRC evaluated an alternative of wind energy in combination with an NGCC plant and
37 energy efficiency and conservation programs in Section 8.4.

38 **8.6.4 Solar Power**

39 Solar technologies use the sun's energy to produce electricity at a utility scale. Solar energy
40 can be converted to electricity using solar thermal technologies or photovoltaics. Solar thermal
41 technologies employ concentrating devices to create temperatures suitable for power
42 production. Concentrating thermal technologies are currently less costly than photovoltaics for
43 bulk power production.

44 The ERCOT region receives 3.5 to 7.0 kWh/m²/day of direct solar radiation (STPNOC 2010a).
45 Solar power constituted less than 1 percent of electricity produced in the ERCOT region during
46 2010 (ERCOT 2011a). As of April 2011, applications for energy projects under review at
47 ERCOT included 1,454 MWe of proposed solar projects (ERCOT 2011a).

1 As described in the GEIS, solar power is intermittent (i.e., it does not work at night and cannot
2 serve baseload when the sun is not shining), and the efficiency of collectors varies greatly with
3 weather conditions. Therefore, solar power by itself would not be able to provide baseload
4 power as an alternative to Units 1 and 2. Rather, a solar-powered alternative would require
5 energy storage or backup power supply from other sources to potentially supply baseload power
6 during periods when the sun is not shining. Potential storage mechanisms include pumped
7 storage, CAES, molten salt storage, or thermal storage. As described above in Section 8.6.3
8 and in STP, Units 3 and 4, EIS (NRC 2011), storage possibilities in this region of Texas are
9 limited. NRC is not aware of any storage facility coupled with solar generation that is providing
10 baseload power.

11 For the term of license renewal, because solar energy is an intermittent resource, and the
12 amount of solar capacity required to replace Units 1 and 2 far exceeds existing and planned
13 amounts of future solar power generation within ERCOT and exceeds storage potential (if
14 CAES or pumped storage were used), NRC does not consider solar energy to be a reasonable
15 alternative to license renewal.

16 **8.6.5 Hydroelectric Power**

17 Hydropower constituted less than 1 percent of electricity produced in the ERCOT region during
18 2010 (ERCOT 2011a). EIA's reference case in its *Update Annual Energy Outlook 2011* projects
19 that U.S. electricity production from hydropower plants will remain essentially stable through
20 2035 (EIA 2011a). Idaho National Energy and Environmental Laboratory (1998) estimated that
21 1,234 MWe of undeveloped potential hydroelectric resources at 89 sites occur throughout the
22 State of Texas. Given that the available hydroelectric potential in the State of Texas constitutes
23 less than one-tenth of the generating capacity of STP, the NRC staff did not evaluate
24 hydropower as a reasonable alternative to license renewal.

25 **8.6.6 Wave and Ocean Energy**

26 Wave and ocean energy has created considerable interest in recent years. Ocean waves,
27 currents, and tides are often predictable and reliable. Ocean currents flow consistently, while
28 tides can be predicted months and years in advance with well-known behavior in most coastal
29 areas. Most of these technologies are in relatively early stages of development. The potential
30 for wave and ocean energy in Texas is limited because the Gulf of Mexico is shallow and
31 semi-enclosed (TCPA 2008). Because most technologies are relatively undeveloped (and none
32 are developed on the scale of STP), and because the Gulf of Mexico has limited potential for
33 wave and ocean energy, the NRC did not consider wave and ocean energy as a reasonable
34 alternative to STP license renewal.

35 **8.6.7 Geothermal Power**

36 Hydrothermal resources, reservoirs of steam or hot water that can be used for electrical
37 generation, are available primarily in the western states, including Hawaii, Alaska, California,
38 Utah, and Nevada (TCPA 2008). This type of geothermal energy has an average capacity
39 factor of 90 percent and can be used for baseload power where available. Geothermal systems
40 have a relatively small footprint and minimal emissions (MIT 2006). However, Texas does not
41 have the sort of readily accessible, high-temperature hydrothermal resource (Virtus 2008).

42 Lower-temperature geothermal resources (90 °F to 160 °F) occur in the central part of Texas
43 and along the Rio Grande. In the technical report (TCPA 2008), Texas Comptroller of Public
44 Accounts (TCPA) suggests that such areas could provide low-temperature applications, such as
45 space heating. Other uses could also include greenhouse cultivation, aquaculture, crop drying,

Environmental Impacts of Alternatives

1 and milk pasteurization. The potential for hot dry rock geothermal power in Texas is presently
2 unknown (Virtus 2008).

3 Geopressured-geothermal power plants use existing, deep oil and gas wells to access hot fluids
4 that have been co-produced from oil and gas exploration, such as geopressured reservoirs of
5 hot water and natural gas or hot wastewater from deep oil and gas wells. This technology has
6 future potential in Texas because hydrocarbon exploration and production industries have data
7 on the thermal characteristics in existing wells and because areas with sufficient geothermal
8 energy may exist where deep oil and gas wells exists (TCPA 2008). Current data suggest that
9 wells 16,000 ft (4,877 m) or deeper in the ERCOT region contain high-temperature fluid (250 °F
10 (121 °C) or greater), and some wells are above 400 °F (204 °C) (STPNOC 2010a). In addition,
11 transmission lines are located near many of the existing wells (TCPA 2008).

12 In 1989, DOE operated a test geopressured-geothermal power plant at Pleasant Bayou,
13 approximately 60 mi (97 km) northwest of STP. The 1 MW binary power plant operated for
14 6 months and produced approximately 3,500 MWh of electricity (TCPA 2008). GEA (2007)
15 estimates that electric power production potential from oil and gas wells in Texas could produce
16 400 MWe in the near-term to over 2,000 MWe once the technology is refined and more
17 widespread. Even if the oil and gas wells produced 2,000 MWe, this output would not be
18 sufficient to make up for the 2,500 MWe produced by STP, Units 1 and 2. Additional capital and
19 significant investment is required to develop and operate geopressured-geothermal power
20 plants to produce a sufficient amount of baseload power.

21 As of 2008, no geothermal projects produced electricity on a commercial scale in Texas
22 (TCPA 2008), but some potential exists for geopressured-geothermal power plants and
23 low-temperature projects at smaller scales. Energy companies, Texas State Energy
24 Conservation Office, and Southern Methodist University are currently assessing Texas's
25 potential for various forms of geothermal technology. A significant amount of investment would
26 be required for geothermal energy to be used in Texas (TCPA 2008). Given the immature
27 status of geothermal technology and the limited resource availability in Texas, the NRC
28 concludes that geothermal energy is not a reasonable alternative to STP license renewal.

29 **8.6.8 Municipal Solid Waste**

30 Municipal-solid-waste combustors use three types of technologies—mass burn, modular, and
31 refuse-derived fuel. Mass burning is used most frequently in the U.S. and involves little sorting,
32 shredding, or separation. Consequently, toxic or hazardous components present in the waste
33 stream are combusted, and toxic constituents are exhausted to the air or become part of the
34 resulting solid wastes. Currently, approximately 86 waste-to-energy plants operate in the U.S.
35 These plants have a generating capacity of 2,572 MWe, or an average of 30 MWe per plant
36 (Michaels 2010). More than 85 average-sized plants would be necessary to provide the same
37 level of output as STP.

38 Estimates in the GEIS suggest that the overall level of construction impact from a waste-fired
39 plant would be approximately the same as that for a coal-fired power plant. Additionally,
40 waste-fired plants have the same or greater operational impacts than coal-fired technologies
41 (including impacts on the aquatic environment, air, and waste disposal). The initial capital costs
42 for municipal solid-waste plants are greater than for comparable steam-turbine technology at
43 coal-fired facilities or at wood-waste facilities because of the need for specialized waste
44 separation and handling equipment (NRC 1996).

45 The decision to burn municipal waste to generate energy is driven by the need for an alternative
46 to landfills rather than energy considerations. The use of landfills as a waste disposal option is
47 likely to increase as energy prices increase; however, it is possible that municipal waste

1 combustion facilities may become attractive again if there is a need for an alternative to landfills
2 or an introduction of other regulatory incentives.

3 Given the small average installed size of municipal solid-waste plants and the unfavorable
4 regulatory environment, the NRC staff does not consider municipal solid-waste combustion to
5 be a reasonable alternative to STP license renewal.

6 **8.6.9 Biomass**

7 Using biomass for energy consists of the direct burning of plant or animal matter, including
8 wood waste, mill waste, agricultural residues, and energy crops. Biomass fuel provided less
9 than 1 percent of electricity produced in the ERCOT region during 2010 (ERCOT 2011a). As of
10 April 2011, applications for energy projects under review at ERCOT included 150 MW of
11 proposed biomass-fuel projects (ERCOT 2011a). In Texas, the Red River Army Depot cofires
12 biomass with fossil fuels (DOE 2004).

13 Biomass resources in Texas include crops (e.g., cotton, corn, and some soybeans), forests
14 (especially in east Texas), and agricultural wastes (e.g., cattle manure, poultry litter, rice straw,
15 peanut shells, cotton gin trash, and corn stover) (TCPA 2008). Houston Advanced Research
16 Center estimated that Texas agricultural wastes could potentially produce 418.9 MWe
17 (HARC 2008).

18 In NUREG-1437, the NRC staff determined that a wood-burning facility can provide baseload
19 power and operate with an average annual capacity factor of around 70 to 80 percent and with
20 20 to 25 percent efficiency (NRC 1996). The fuels required are variable and site-specific. A
21 significant impediment to the use of wood waste to generate electricity is the high cost of fuel
22 delivery and high construction cost per megawatt of generating capacity. The larger woodwaste
23 power plants typically produce 40 to 50 MWe. Estimates in NUREG-1437 suggest that the
24 overall level of construction impacts per megawatt of installed capacity would be approximately
25 the same as that for a coal-fired plant, although facilities using wood waste for fuel would be
26 built at smaller scales (NRC 1996). Similar to coal-fired plants, wood waste plants require large
27 areas for fuel storage and processing and involve the same type of combustion equipment.

28 One of the largest wood-fired biomass power plants began operations in June 2012 in Sacul,
29 Texas (Southern 2012). The 100 MWe wood-fired biomass power plant uses logging residue as
30 its main fuel source. It also uses urban wood waste (TCPA 2008). The plant owner, Southern
31 Power, estimated that the plant will require approximately 1 million tons of biomass per year,
32 which it plans to procure within a 75-mi (121-km) radius of the project site (Southern 2009).
33 Nearly 26 similarly sized facilities would be necessary to replace STP, Units 1 and 2.

34 Because of uncertainties associated with obtaining sufficient wood, wood waste, agricultural
35 waste, or other biomass to fuel a baseload power plant, the ecological impacts of large-scale
36 timber cutting (e.g., soil erosion and loss of wildlife habitat), and the relatively small size of wood
37 generation plants, the NRC staff does not consider biomass fuel to be a reasonable alternative
38 to STP license renewal.

39 **8.6.10 Biofuels**

40 Biofuels include biomass that has been refined into a liquid fuel, such as ethanol, or gasified
41 (including crops and wood waste). The use of biofuels has increased during the past decade
42 (TCPA 2008). However, the biofuels are primarily used in the transportation sector, and limited
43 projects have been completed to use biofuels for energy generation.

Environmental Impacts of Alternatives

1 In the GEIS, the NRC staff indicated that none of the biofuel technologies progressed to the
2 point of being competitive on a large scale or of being reliable enough to replace a baseload
3 plant such as STP. After reevaluating current technologies, the NRC staff finds biofuel-fired
4 alternatives as still unable to reliably replace the STP capacity. For this reason, the NRC staff
5 does not consider biofuels to be a reasonable alternative to STP license renewal.

6 **8.6.11 Oil-Fired Power**

7 The EIA (2009) projects that oil-fired plants will account for very few of new generation capacity
8 constructed in the U.S. during the 2011 to 2028 time period. Furthermore, EIA does not project
9 that oil-fired power will account for any significant additions to capacity (EIA 2009).

10 The variable costs of oil-fired generation are greater than those of nuclear or coal-fired
11 operations, and oil-fired generation has greater environmental impacts than natural gas-fired
12 generation. In addition, EIA expects future increases in oil prices will make oil-fired generation
13 increasingly more expensive (EIA 2009). The high cost of oil has prompted a steady decline in
14 its use for electricity generation. Thus, the NRC staff does not consider oil-fired generation as a
15 reasonable alternative to STP license renewal.

16 **8.6.12 Fuel Cells**

17 Fuel cells oxidize fuels without combustion and its environmental side effects. Power is
18 produced electrochemically by passing a hydrogen-rich fuel over an anode and passing air (or
19 oxygen) over a cathode and then separating the two by an electrolyte. The only byproducts
20 (depending on fuel characteristics) are heat, water, and carbon dioxide. Hydrogen fuel can
21 come from a variety of hydrocarbon resources by subjecting them to steam under pressure.
22 Natural gas is typically used as the source of hydrogen.

23 At the present time, fuel cells are not technologically competitive with other alternatives for
24 large-scale electricity generation. In addition, fuel cell units are likely to be small (the EIA (2009)
25 reference plant is 10 MWe). While it may be possible to use a distributed array of fuel cells to
26 provide an alternative to STP, it would be extremely costly to do so. Accordingly, the NRC staff
27 does not consider fuel cells to be a reasonable alternative to STP license renewal.

28 **8.6.13 Delayed Retirement**

29 STPNOC is not aware of any of ERCOT's electric generating plants currently proposed or
30 planning for retirement, and additional capacity within the ERCOT region is not expected
31 (STPNOC 2010a). Electric generating plants that may be retired by 2028 are likely to be older,
32 less efficient, and without modern emissions controls. As a result, delayed retirement is not a
33 reasonable alternative to license renewal.

34 In response to the requirements to reduce levels of sulfur dioxide in Texas as a part of the
35 Cross-State Air Pollution Rule, ERCOT analyzed the impact of the reliability of the ERCOT grid
36 (ERCOT 2011b). In this analysis, ERCOT noted that several facilities may need to idle during
37 portions of the year. ERCOT did not state that any facilities would permanently close.
38 Statements from power generation companies, such as Luminant, also suggest that facilities
39 may need to remain idle in order to comply with the Cross-State Air Pollution Rule
40 (Luminant 2011). The NRC is not aware of any facilities that are currently being proposed for
41 permanent closure as a result of the Cross-State Air Pollution Rule.

1 **8.7 No-Action Alternative**

2 This section examines the environmental effects that would occur if NRC takes no action. No
3 action in this case means that NRC denies renewed operating licenses for STP, and the
4 licenses expire at the end of the current terms, in 2027 and 2028. If NRC denies the renewed
5 operating licenses, the plants will shut down at or before the end of the current licenses. After
6 shutdown, plant operators will initiate decommissioning in accordance with 10 CFR 50.82.

7 The NRC staff notes that the no-action alternative is the only alternative that is considered
8 in-depth that does not satisfy the purpose and need for this SEIS because it neither provides
9 power generation capacity nor does it meet the needs currently met by STP or the alternatives
10 evaluated in Sections 8.1 through 8.5. Assuming that a need currently exists for the power
11 generated by STP, the no-action alternative would require the appropriate energy-planning
12 decisionmakers to rely on an alternative (or combination of them) to replace the capacity of STP
13 or reduce the need for power.

14 This section addresses only those impacts that arise directly as a result of plant shutdown. The
15 environmental impacts from decommissioning and related activities have been addressed in
16 several other documents, including the *Final Generic Environmental Impact Statement on*
17 *Decommissioning of Nuclear Facilities*, NUREG-0586, Supplement 1 (NRC 2002); Chapter 7 of
18 the license renewal GEIS (NRC 1996); and Chapter 7 of this SEIS. These analyses either
19 directly address or bound the environmental impacts of decommissioning whenever STPNOC
20 ceases operating STP. In addition, the environmental impacts from potential replacement
21 power alternatives are addressed in Sections 8.1 to 8.5.

22 The NRC staff notes that, even with renewed operating licenses, STP will eventually shut down,
23 and the environmental effects addressed in this section will occur at that time. Since these
24 effects have not otherwise been addressed in this SEIS, the impacts will be addressed in this
25 section. As with decommissioning effects, the NRC staff expects the shutdown effects to be
26 similar whether they occur at the end of the current licenses or at the end of renewed licenses.

27 **8.7.1 Air Quality**

28 When the STP stops operating, there will be a reduction in emissions from activities related to
29 plant operation, such as use of diesel generators and employee vehicles. In Chapter 4, the
30 NRC staff determined that these emissions would have a SMALL impact on air quality during
31 the renewal term; therefore, if emissions decrease, the impact to air quality would also decrease
32 and would be SMALL.

33 **8.7.2 Surface Water Resources**

34 The rate of consumptive use of surface water would decrease as STP is shut down and the
35 reactor cooling system continues to remove the heat of decay. Wastewater discharges would
36 also be reduced considerably. Shutdown would reduce the impacts on surface water use and
37 quality and would remain SMALL.

38 **8.7.3 Groundwater Resources**

39 The use of groundwater would diminish as the plant workforce is drawn down and operations
40 requiring groundwater cease. Some consumption of groundwater would continue to support the
41 operation of service water and fire protection systems and to meet the potable and sanitary
42 needs of the reduced workforce prior to decommissioning. Overall impacts would be less than
43 during operations and would remain SMALL.

Environmental Impacts of Alternatives

1 **8.7.4 Aquatic Ecology**

2 If STP were to cease operating, impacts to aquatic ecology would decrease, as the plant would
3 withdraw and discharge less water than it does during operations. Therefore, fewer organisms
4 would be subject to the impingement, entrainment, and heat shock. Shutdown would reduce
5 the impacts to aquatic ecology and would remain SMALL.

6 **8.7.5 Terrestrial Ecology**

7 Terrestrial ecology impacts would remain SMALL. No additional land disturbances on or off site
8 would occur.

9 **8.7.6 Human Health**

10 Human health risks would be smaller following plant shutdown. The plant, which is currently
11 operating within regulatory limits, would emit less gaseous and liquid radioactive material to the
12 environment. In addition, following shutdown, the variety of potential accidents at the plant
13 (radiological or industrial) would be reduced to a limited set associated with shutdown events
14 and fuel handling and storage. In Chapter 4 of this SEIS, the NRC staff concluded that the
15 impacts of continued plant operation on human health would be SMALL. In Chapter 5, the NRC
16 staff concluded that the impacts of accidents during operation were SMALL. Therefore, as
17 radioactive emissions to the environment decrease, and as likelihood and variety of accidents
18 decrease following shutdown, the NRC staff concludes that the risk to human health following
19 plant shutdown would be SMALL.

20 Noise caused by plant operations would cease; therefore, impacts from noise would be SMALL.

21 **8.7.7 Land Use**

22 STP shutdown would not affect onsite land use. Plant structures and other facilities would
23 remain in place until decommissioning. Most transmission lines connected to STP would
24 remain in service after the plant stops operating. Maintenance of most existing transmission
25 lines would continue as before. Impacts on land use from plant shutdown would be SMALL.

26 **8.7.8 Socioeconomics**

27 STP shutdown would have an impact on socioeconomic conditions in the region around STP.
28 Should the plant shut down, there would be immediate socioeconomic impact from loss of jobs
29 (some, though not all, of the 1,378 employees would begin to leave), and tax payments may be
30 reduced. As the majority of STP employees reside in Brazoria and Matagorda, socioeconomic
31 impacts from plant shutdown would be concentrated in these counties, with a corresponding
32 reduction in purchasing activity and tax contributions to the regional economy. Revenue losses
33 from STP operations would directly affect Matagorda County and other local taxing districts and
34 communities closest to, and most reliant on, the nuclear plant's tax revenue. The impact of the
35 job loss, however, may not be as noticeable given the amount of time required to decontaminate
36 and decommission existing facilities and the proximity of STP to the Houston metropolitan area.
37 The socioeconomic impacts of plan shutdown (which may not entirely cease until after
38 decommissioning) would, depending on the jurisdiction, range from SMALL to MODERATE.

39 **8.7.9 Transportation**

40 Traffic volumes on the roads in the vicinity of STP would be reduced after plant shutdown. Most
41 of the reduction in traffic volume would be associated with the loss of jobs at the plant.

1 Deliveries to the plant would be reduced until decommissioning. Transportation impacts would
2 be SMALL as a result of plant shutdown.

3 **8.7.10 Aesthetics and Noise**

4 Plant structures and other facilities would remain in place until decommissioning. Therefore,
5 aesthetic and noise impacts of plant closure and the termination of operations would be SMALL.

6 **8.7.11 Historic and Archaeological Resources**

7 Impacts from the no-action alternative on historic and archaeological resources would be
8 SMALL because no additional land disturbances would occur on or off the STP site.

9 **8.7.12 Environmental Justice**

10 Impacts to minority and low-income populations would depend on the number of jobs and the
11 amount of tax revenues lost by communities in the immediate vicinity of the plant after STP
12 ceases operations. Closure of STP would reduce the overall number of jobs (there are currently
13 1,378 people employed at the facility) and tax revenue for social services attributed to nuclear
14 plant operations. Minority and low-income populations in the vicinity of STP could experience
15 some socioeconomic effects from plant shutdown, but these effects would unlikely be high and
16 adverse. See Appendix J of NUREG-0586, Supplement 1, *Final Generic Environmental Impact
17 Statement on Decommissioning of Nuclear Facilities Regarding the Decommissioning of
18 Nuclear Power Reactors* (NRC 2002), for additional discussion of these impacts.

19 **8.7.13 Waste Management**

20 If the no-action alternative were implemented, the generation of high-level waste would stop,
21 and generation of low-level and mixed waste would decrease. Impacts from implementation of
22 the no-action alternative are expected to be SMALL.

23 **8.7.14 Summary of Impacts of No-Action Alternative**

24 Table 8–7 provides a summary of the environmental impacts of the no-action alternative
25 compared to continued operation of STP.

26 **Table 8–7. Summary of Environmental Impacts of the No-Action**
27 **Alternative Compared to Continued Operation of STP, Units 1 and 2**

Category	No-action Alternative	Continued STP Operation
Air quality	SMALL	SMALL
Surface water	SMALL	SMALL
Groundwater	SMALL	SMALL
Aquatic resources	SMALL	SMALL
Terrestrial resources	SMALL	SMALL
Human health	SMALL	SMALL to MODERATE
Land use	SMALL	SMALL
Socioeconomics	SMALL to MODERATE	SMALL

Environmental Impacts of Alternatives

Category	No-action Alternative	Continued STP Operation
Transportation	SMALL	SMALL
Aesthetics	SMALL	SMALL
Historic & archaeological	SMALL	SMALL
Waste management	SMALL	SMALL

1 **8.8 Alternatives Summary**

2 In this chapter, the NRC staff considered the following alternatives to STP license renewal: new
3 nuclear generation; NGCC generation; supercritical coal-fired generation; a combination
4 alternative of natural gas, wind, and energy efficiency and conservation; and a purchased-power
5 alternative. No action by NRC and its effects were also considered. The impacts for STP
6 license renewal and for all alternatives to STP license renewal are summarized in Table 8–8.

7 In conclusion, the environmentally preferred alternative is the license renewal of STP. All other
8 alternatives capable of meeting the needs currently served by STP entail potentially greater
9 impacts than the proposed action of license renewal of STP. In order to make up the lost
10 generation if license renewal is denied, the no-action alternative necessitates the
11 implementation of one or a combination of alternatives, all of which have greater impacts than
12 the proposed action. Hence, the NRC staff concludes that the no-action alternative will have
13 environmental impacts greater than or equal to the proposed license renewal action.

14

Table 8-8. Summary of Environmental Impacts of Proposed Action and Alternatives

Alternative	Impact Area									
	Air Quality	Groundwater and Surface water	Aquatic and Terrestrial Resources	Human Health	Land Use	Socioeconomics (including Transportation & Aesthetics)	Archaeological & Historic Resources	Waste Management		
License renewal	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL	SMALL	SMALL		
New nuclear at STP site	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL to LARGE	SMALL	SMALL		
NGCC at the STP site	SMALL to MODERATE	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL	SMALL		
Supercritical coal at STP site	MODERATE	SMALL	SMALL to MODERATE	SMALL	MODERATE	SMALL to LARGE	SMALL	MODERATE		
Combination of alternatives	SMALL to MODERATE	SMALL	SMALL to MODERATE	SMALL	SMALL to MODERATE	SMALL to LARGE	SMALL to MODERATE	SMALL to MODERATE		
Purchased power	SMALL to MODERATE	SMALL	SMALL to MODERATE	SMALL	SMALL to MODERATE	SMALL to LARGE	SMALL to MODERATE	SMALL to MODERATE		
No-action alternative	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL		

1 **8.9 References**

- 2 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
3 protection regulations for domestic licensing and related regulatory functions.”
- 4 65 FR 79825. U.S. Environmental Protection Agency. Regulatory finding on the emissions of
5 hazardous air pollutants from electric utility steam generating units. *Federal Register*
6 65(245): 79825–79831. December 20, 2000.
- 7 Archer CL, Jacobson MZ. 2007. Supplying baseload power and reducing transmission
8 requirements by interconnecting wind farms. *Journal of Applied Meteorology and*
9 *Climatology* 46: 1701–1717.
- 10 [DOE] U.S. Department of Energy. 2004. *Biomass Cofiring in Coal-Fired Boilers*.
11 Washington, DC: Federal Energy Management Program/DOE. DOE/EE-0288. Available at
12 <http://www1.eere.energy.gov/femp/pdfs/fta_biomass_cofiring.pdf> (accessed
13 21 November 2011).
- 14 [DOE] U.S. Department of Energy. 2007. *Cost and Performance Baseline for Fossil Energy*
15 *Plants*. DOE/NETL-2007/1281. Volume 1. May 2007.
- 16 [DOE] U.S. Department of Energy. 2008. *20% Wind Energy by 2030: Increasing Wind*
17 *Energy’s Contribution to U.S. Electricity Supply*. Washington, DC: DOE.
18 DOE/GO-102008-2567. ADAMS No. ML100700550.
- 19 [DOE] U.S. Department of Energy. 2011a. “Innovative Texas Clean Coal Project Takes Major
20 Step Forward as DOE Issues Record of Decision.” September 27, 2011. Available at
21 <[http://www.fossil.energy.gov/news/techlines/2011/11053-Texas_Clean_Coal_Project_Moves_](http://www.fossil.energy.gov/news/techlines/2011/11053-Texas_Clean_Coal_Project_Moves_For.html)
22 [For.html](http://www.fossil.energy.gov/news/techlines/2011/11053-Texas_Clean_Coal_Project_Moves_For.html)> (accessed 21 November 2011).
- 23 [DOE] U.S. Department of Energy. 2011b. “Wind Powering America: U.S. Installed Wind
24 Capacity.” June 30, 2011. Available at
25 <http://www.windpoweringamerica.gov/wind_installed_capacity.asp> (accessed
26 20 October 2011).
- 27 [EIA] Energy Information Administration. 2009. *Annual Energy Outlook 2009 With Projections*
28 *to 2030*. Washington, DC: EIA. DOE/EIA 0383(2009). Available at
29 <[http://www.eia.doe.gov/oiaf/archive/aeo09/pdf/0383\(2009\).pdf](http://www.eia.doe.gov/oiaf/archive/aeo09/pdf/0383(2009).pdf)> (accessed
30 17 November 2011).
- 31 [EIA] Energy Information Administration. 2011a. *Annual Energy Outlook for 2011 with*
32 *Projections to 2035*. Washington, DC: DOE/EIA. DOE/EIA-0383(2011). April 11, 2011.
33 Available at <<http://www.eia.gov/forecasts/aeo/index.cfm>> (accessed 16 August 2011).
- 34 [EIA] Energy Information Administration. 2011b. *Assumptions to the Annual Energy Outlook*
35 *2011*. Washington, DC: DOE/EIA. July 2011.
- 36 [EPA] U.S. Environmental Protection Agency. 1998. *Compilation of Air Pollutant Emission*
37 *Factors*. Washington, DC: EPA. Volume 1, Section 1.1.
- 38 [EPA] U.S. Environmental Protection Agency. 2008. *New Source Review (NSR)*. ADAMS
39 No. ML083450073.
- 40 [EPA] U.S. Environmental Protection Agency. 2011a. “Clean Energy: eGRID.” Available at
41 <<http://www.epa.gov/cleanenergy/energy-resources/egrid/index.html>> (accessed
42 17 October 2011).

- 1 [EPA] U.S. Environmental Protection Agency. 2011b. "Green Book: Currently Designated
2 Nonattainment Areas for All Criteria Pollutants." August 30, 2011. Available at
3 <<http://epa.gov/oaqps001/greenbk/ancl.html>> (accessed 17 November 2011).
- 4 [EPA] U.S. Environmental Protection Agency. 2011c. "New Source Review." July 22, 2011.
5 Available at <<http://www.epa.gov/nsr/>> (accessed 17 November 2011).
- 6 [ERCOT] Electric Reliability Council of Texas. 2011a. "ERCOT Quick Facts." Available at
7 <<http://www.ercot.com/about/profile/>> (accessed 18 August 2011).
- 8 [ERCOT] Electric Reliability Council of Texas. 2011b. "Impacts of the Cross-State Air Pollution
9 Rule on the ERCOT System." September 1, 2011. Available at:
10 <http://www.ercot.com/content/news/presentations/2011/ERCOT_CSAPR_Study.pdf>
11 (accessed 17 November 2011).
- 12 [Exelon] Exelon Generation Company, LLC. 2011. *Operating License Renewal Stage—*
13 *Limerick Generating Station, Units 1 and 2.*
- 14 [GE] General Electric. 2011. "Gas Turbine and Combined Cycle Products." Available at
15 <http://www.ge-energy.com/products_and_services/index.jsp> (accessed 17 October 2011).
- 16 [GEA]. Geothermal Energy Association 2007. *An Assessment of Geothermal Resource*
17 *Development Needs in the Western United States.* Washington, DC: GEA. January 2007.
18 Available at <<http://www.geo-energy.org/reports/States%20Guide.pdf>> (accessed
19 12 October 2011).
- 20 [HARC] Houston Advanced Research Center. 2008. *Combined Heat and Power Potential*
21 *using Texas Agricultural Wastes.* The Woodlands, Texas: HARC. January 2008. Available at
22 <http://www.seco.cpa.state.tx.us/zzz_re/re_biomass_chp-report2008.pdf> (accessed
23 19 October 2011).
- 24 [ISEPA] Iowa Stored Energy Plant Agency. 2011. "Iowa Stored Energy Park Project
25 Terminated." July 28, 2011. Available at
26 <<http://www.isepa.com/ISEP%20Press%20Release.pdf>> (accessed 16 November 2011).
- 27 Luminant. 2011. "Luminant Announces Facility Closures, Job Reductions in Response to EPA
28 Rule; Company Forced to Take Difficult Steps; Files Suit to Protect Jobs, Reliability." Available
29 at <<http://www.luminant.com/news/spotlight/detail.aspx?FtID=23>> (accessed
30 16 November 2011).
- 31 Michaels T. 2010. *The 2010 ERC [Energy Recovery Council] Directory of Waste-to-Energy*
32 *Plants.* Washington, DC: ERC (formerly Integrated Waste Services Association).
33 December 2010. Available at <http://www.wte.org/userfiles/file/ERC_2010_Directory.pdf>
34 (accessed 30 November 2011).
- 35 [MIT]. Massachusetts Institute of Technology. 2006. "The Future of Geothermal Energy:
36 Impact of Enhanced Geothermal Systems (EGS) on the United States in the 21st Century: An
37 Assessment by an MIT-Led Interdisciplinary Panel." Available at
38 <http://geothermal.inel.gov/publications/future_of_geothermal_energy.pdf> (accessed
39 30 November 2011).
- 40 [MMS]. U.S. Department of the Interior, Minerals Management Service. 2007. *Programmatic*
41 *EIS for Alternative Energy Development and Production and Alternate Uses of facilities on the*
42 *Outer Continental Shelf.* Washington, DC: MMS. Report MMS 2007-046.
- 43 [NETL] National Energy Technology Laboratory. 2007. *Cost and Performance Baseline for*
44 *Fossil Energy Plants, Volume 1: Bituminous Coal and Natural Gas to Electricity.*
45 Washington, DC: DOE/NETL. DOE/NETL-2007/1281. ADAMS No. ML100640755.

Environmental Impacts of Alternatives

- 1 [NRC] U.S. Nuclear Regulatory Commission. 1996. *Generic Environmental Impact Statement*
2 *for License Renewal of Nuclear Plants*. Washington, DC: NRC. NUREG-1437. May 1996.
3 ADAMS Nos. ML040690705 and ML040690738.
- 4 [NRC] U.S. Nuclear Regulatory Commission. 1999. Section 6.3–Transportation, Table 9.1,
5 Summary of findings on NEPA issues for license renewal of nuclear power plants. In: *Generic*
6 *Environmental Impact Statement for License Renewal of Nuclear Plants*. Washington, DC:
7 NRC. NUREG-1437, Volume 1, Addendum 1. August 1999. ADAMS No. ML04069720.
- 8 [NRC] U.S. Nuclear Regulatory Commission. 2002. *Final Generic Environmental Impact*
9 *Statement on Decommissioning of Nuclear Facilities Regarding the Decommissioning of*
10 *Nuclear Power Reactors*. Washington, DC: NRC. NUREG-0586, Supplement 1.
11 November 2002. ADAMS Nos. ML023470304 and ML023500295.
- 12 [NRC] U.S. Nuclear Regulatory Commission. 2008. *Generic Environmental Impact Statement*
13 *for License Renewal of Nuclear Power Plants: Regarding Shearon Harris Nuclear Power Plant,*
14 *Unit 1*. Washington, DC: NRC. NUREG-1437, Supplement 33.
- 15 [NRC] U.S. Nuclear Regulatory Commission. 2011. *Environmental Impact Statement for the*
16 *Combined Licenses (COLs) for South Texas Project Electric Generating Station, Units 3 and 4*.
17 Washington, DC: NRC. NUREG-1937. February 2011. ADAMS No. ML11049A000.
- 18 [NPCC]. Northwest Power and Conservation Council. 2005. *The Fifth Northwest Electric*
19 *Power and Conservation Plan, Volume 3*. Portland, OR. Available at
20 <<http://www.nwcouncil.org/energy/powerplan/5/Volume3.pdf>> (accessed 30 November 2011).
- 21 [NPCC]. Northwest Power and Conservation Council. 2009. *Draft Northwest 6th Power Plan*.
22 Portland, OR. Available at <<http://www.nwppc.org/energy/powerplan/6/default.htm>> (accessed
23 30 November 2011).
- 24 [NREL]. National Renewable Energy Laboratory. 2009. *Land-Use Requirements of Modern*
25 *Wind Power Plants in the United States*. Golden, CP: NREL. Technical
26 Report NREL/TP-6A2-45834. August 2009.
- 27 [NREL]. National Renewable Energy Laboratory. 2010. *Large-Scale Offshore Wind Power in*
28 *the United States; Assessment of Opportunities and Barriers*. Golden, CO: NREL. Technical
29 Report NREL/TP-500-40745.
- 30 [OMB] U.S. Office of Management and Budget. 2007. *Detailed Information on the Low Income*
31 *Home Energy Assistance Program Assessment*. ADAMS No. ML082880730.
- 32 [OPSB] Ohio Power and Siting Board. 2011. “99-1626-EL-BGN: Norton Compressed Air
33 Energy Storage, Summit County.” Available at
34 <[http://www.opsb.ohio.gov/opsb/index.cfm/cases/99-1626-el-bgn-norton-energy-storage-](http://www.opsb.ohio.gov/opsb/index.cfm/cases/99-1626-el-bgn-norton-energy-storage-compressed-air-energy-storage/)
35 [compressed-air-energy-storage/](http://www.opsb.ohio.gov/opsb/index.cfm/cases/99-1626-el-bgn-norton-energy-storage-compressed-air-energy-storage/)> (accessed 30 November 2011).
- 36 [Southern] Southern Company. 2009. *Southern Company Breaks Ground on Biomass Plant*.
37 Atlanta, GA: Southern Company. November 10, 2009. ADAMS No. ML100700543.
- 38 [Southern] Southern Company. 2012. “Southern Company Highlights.” Available at
39 http://www.southerncompany.com/smart_energy/smart_power_highlights.html (accessed 5
40 September 2012).
- 41 [Southern and GIT] Southern Company and Georgia Institute of Technology. 2007. *Southern*
42 *Winds: Summary Project Report 2007, A Study of Wind Power Generation Potential off the*
43 *Georgia Coast*. Atlanta, GA: GIT. Available at
44 <<http://www.energy.gatech.edu/research/Summary-Southern-Winds.pdf>> (accessed
45 28 November 2011).

- 1 [STPNOC] South Texas Project Nuclear Operating Company. 2006. Letter from SL Dannhardt,
 2 STPNOC, to B Martin, THC. Subject: South Texas Project, Units 3 and 4. December 12, 2006.
 3 ADAMS No. ML092100145.
- 4 [STPNOC] South Texas Project Nuclear Operating Company. 2010a. *Operating License*
 5 *Renewal Stage South Texas Project, Units 1 and 2*. September 2010. ADAMS
 6 No. ML103010257.
- 7 [STPNOC] South Texas Project Nuclear Operating Company. 2010b. *South Texas Project,*
 8 *Units 3 and 4, Combined License Application*. Bay City, TX: STPNOC. Part 3, “Environmental
 9 Report,” Revision 4. ADAMS No. ML102860592.
- 10 Succar S, Williams RH. 2008. *Compressed Air Energy Storage: Theory, Resources, and*
 11 *Applications for Wind Power*. Princeton, NJ: Princeton University Energy Systems Analysis
 12 Group. Available at <<http://www.princeton.edu/~ssuccar/caesReport.html>> (accessed
 13 17 October 2011).
- 14 [TCEQ] Texas Commission on Environmental Quality. 2005. *TPDES Permit*
 15 *No. WQ0001908000*. Austin, TX.
- 16 [TCEQ] Texas Commission on Environmental Quality. 2011. “Status of Air Permits and Permit
 17 Applications.” Available at
 18 <http://www.tceq.texas.gov/permitting/air/nav/air_status_permits.html> (accessed
 19 26 October 2011).
- 20 [TCPA]. Texas Comptroller of Public Accounts. 2008. *The Energy Report 2008*. Austin, TX.
 21 Available at <<http://www.window.state.tx.us/specialrpt/energy/>> (accessed 17 October 2011).
- 22 [THC]. Texas Historical Commission. 2007. Response from WA Martin for FL Oaks, THC, to
 23 SL Dannhardt, STPNOC. Stamped Reply: “No Historic Properties Affected Project May
 24 Proceed.” January 19, 2007. ADAMS No. ML092100145.
- 25 [TSECO]. Texas State Energy Conservation Office. 2008. *Wind Energy Transmission*.
 26 Austin, TX. ADAMS No. ML100700550.
- 27 [TWDB] Texas Water Development Board. 2007. *State Water Plan—Water for Texas 2007*.
 28 Austin, TX: TWDB. Document No. GP-8-1.
- 29 [Virtus] Virtus Energy. 2008. *Texas Renewable Energy Assessment: Geothermal*. Austin, TX.
 30 Available at <http://www.vera.com/re_b_psd0c_07.htm> (accessed 17 October 2011).

9.0 CONCLUSION

1

2 This supplemental environmental impact statement (SEIS) contains the environmental review of
3 STP Nuclear Operating Company's (STPNOC's) application for renewed operating licenses for
4 South Texas Project, Units 1 and 2 (STP) as required by Title 10 of the *U.S. Code of Federal*
5 *Regulations* (CFR) Part 51 (10 CFR Part 51), the U.S. Nuclear Regulatory Commission's
6 (NRC's) regulations that implement the National Environmental Policy Act (NEPA). This chapter
7 presents conclusions and recommendations from the site-specific environmental review of STP
8 and summarizes site-specific environmental issues of license renewal that the NRC staff (staff)
9 identified during the review. Section 9.1 summarizes the environmental impacts of license
10 renewal; Section 9.2 presents a comparison of the environmental impacts of license renewal
11 and energy alternatives; Section 9.3 discusses unavoidable impacts of license renewal, energy
12 alternatives, and resource commitments; and Section 9.4 presents conclusions and NRC staff
13 (staff) recommendations.

14 **9.1 Environmental Impacts of License Renewal**

15 Based on the staff's review of site-specific environmental impacts of license renewal presented
16 in this SEIS, the staff concludes that issuing renewed licenses would have mostly SMALL
17 impacts. The site-specific review included 12 Category 2 issues and 2 uncategorized issues.
18 The staff considered mitigation measures for each Category 2 issue, as applicable. The staff
19 concluded that no additional mitigation measure is warranted.

20 Additionally, the staff independently reviewed STPNOC's SAMA. The staff agrees with
21 STPNOC's conclusion that none of the candidate SAMAs are potentially cost-beneficial.

22 The staff also considered cumulative impacts of past, present, and reasonably foreseeable
23 future actions, regardless of what agency (Federal or non-Federal) or person undertakes them.
24 The staff concluded in Section 4.11 that cumulative impacts would be SMALL to MODERATE
25 depending on the resource area. However, except for the electromagnetic fields-acute effects,
26 the incremental contribution from STP during the period of extended operation would be
27 SMALL.

28 **9.2 Comparison of Alternatives**

29 In the conclusion to Chapter 8, the staff considered the following alternatives to STP license
30 renewal:

- 31 • new nuclear generation,
- 32 • natural gas-fired combined-cycle generation (NGCC),
- 33 • supercritical coal-fired generation,
- 34 • combination alternative (the combination includes 640 MWe supplied by one
35 NGCC unit; 1,620 MWe supplied by wind energy projects; and 300 MWe of
36 energy conservation and efficiency, also known as demand-side
37 management), and
- 38 • purchased power.

39 In addition, the staff also considered many other alternatives that were subsequently dismissed
40 for reasons of technical, resource availability, or commercial limitations.

Conclusion

1 As summarized in Table 8–7, the staff concluded that the alternatives of supercritical coal at
2 STP, purchased power, or combination alternative would have environmental impacts ranging
3 from SMALL to LARGE. The alternatives of new nuclear at STP, NGCC at STP, and the
4 no-action alternative would have impacts ranging from SMALL to MODERATE. In comparison
5 to other alternatives, the STP license renewal alternative would have mostly SMALL impacts in
6 all areas of the environmental analysis. Based on the staff’s independent review, the staff
7 concluded that the STP license renewal is the environmentally preferred alternative.

8 **9.3 Resource Commitments**

9 **9.3.1 Unavoidable Adverse Environmental Impacts**

10 Unavoidable adverse environmental impacts are impacts that would occur after implementation
11 of all workable mitigation measures. Carrying out any of the energy alternatives considered in
12 this SEIS, including the proposed action, would result in some unavoidable adverse
13 environmental impacts.

14 Minor unavoidable adverse impacts on air quality would occur due to emission and release of
15 various chemical and radiological constituents from power plant operations. Nonradiological
16 emissions resulting from power plant operations are expected to comply with U.S.
17 Environmental Protection Agency (EPA) emissions standards, though the alternative of
18 operating a fossil-fueled power plant in some areas may worsen existing attainment issues.
19 Chemical and radiological emissions would not exceed the national emission standards for
20 hazardous air pollutants.

21 During nuclear power plant operations, workers and members of the public would face
22 unavoidable exposure to radiation and hazardous and toxic chemicals. Workers would be
23 exposed to radiation and chemicals associated with routine plant operations and the handling of
24 nuclear fuel and waste material. Workers would have higher levels of exposure than members
25 of the public, but doses would be administratively controlled and would not exceed standards or
26 administrative control limits. In comparison, the alternatives involving the construction and
27 operation of a non-nuclear power generating facility would also result in unavoidable exposure
28 to hazardous and toxic chemicals to workers and the public.

29 The generation of spent nuclear fuel and waste material, including low-level radioactive waste,
30 hazardous waste, and nonhazardous waste would be unavoidable. Hazardous and
31 nonhazardous wastes would be generated at non-nuclear power generating facilities. Wastes
32 generated during plant operations would be collected, stored, and shipped for suitable
33 treatment, recycling, or disposal in accordance with applicable Federal and state regulations.
34 Due to the costs of handling these materials, power plant operators would be expected to carry
35 out all activities and optimize all operations in a way that generates the smallest amount of
36 waste possible.

37 **9.3.2 Short-Term Versus Long-Term Productivity**

38 The operation of power generating facilities would result in short-term uses of the environment,
39 as described in Chapters 4, 5, 6, 7, and 8. “Short-term” is the period of time that continued
40 power generating activities take place.

41 Power plant operations require short-term use of the environment and commitment of resources
42 and commit certain resources (e.g., land and energy), indefinitely or permanently. Certain
43 short-term resource commitments are substantially greater under most energy alternatives,
44 including license renewal, than under the no-action alternative because of the continued

1 generation of electrical power and the continued use of generating sites and associated
2 infrastructure. During operations, all energy alternatives entail similar relationships between
3 local short-term uses of the environment and the maintenance and enhancement of long-term
4 productivity.

5 Air emissions from power plant operations introduce small amounts of radiological and
6 nonradiological constituents to the region around the plant site. Over time, these emissions
7 would result in increased concentrations and exposure, but they are not expected to impact air
8 quality or radiation exposure to the extent that public health and long-term productivity of the
9 environment would be impaired.

10 Continued employment, expenditures, and tax revenues generated during power plant
11 operations directly benefit local, regional, and state economies over the short term. Local
12 governments investing project-generated tax revenues into infrastructure and other required
13 services could enhance economic productivity over the long term.

14 The management and disposal of spent nuclear fuel, low-level radioactive waste, hazardous
15 waste, and nonhazardous waste requires an increase in energy and consumes space at
16 treatment, storage, or disposal facilities. Regardless of the location, the use of land to meet
17 waste disposal needs would reduce the long-term productivity of the land.

18 Power plant facilities are committed to electricity production over the short term. After
19 decommissioning these facilities and restoring the area, the land could be available for other
20 future productive uses.

21 **9.3.3 Irreversible and Irretrievable Commitments of Resources**

22 This section describes the irreversible and irretrievable commitment of resources that have
23 been noted in this SEIS. Resources are irreversible when primary or secondary impacts limit
24 the future options for a resource. An irretrievable commitment refers to the use or consumption
25 of resources that are neither renewable nor recoverable for future use. Irreversible and
26 irretrievable commitment of resources for electrical power generation include the commitment of
27 land, water, energy, raw materials, and other natural and man-made resources required for
28 power plant operations. In general, the commitment of capital, energy, labor, and material
29 resources are also irreversible.

30 The implementation of any of the energy alternatives considered in this SEIS would entail the
31 irreversible and irretrievable commitment of energy, water, chemicals, and—in some cases—
32 fossil fuels. These resources would be committed during the license renewal term and over the
33 entire life cycle of the power plant, and they would be unrecoverable.

34 Energy expended would be in the form of fuel for equipment, vehicles, and power plant
35 operations and electricity for equipment and facility operations. Electricity and fuel would be
36 purchased from offsite commercial sources. Water would be obtained from existing water
37 supply systems. These resources are readily available, and the amounts required are not
38 expected to deplete available supplies or exceed available system capacities.

39 **9.4 Recommendations**

40 The NRC's preliminary recommendation is that the adverse environmental impacts of license
41 renewal for STP are not great enough to deny the option of license renewal for energy-planning
42 decisionmakers. The NRC staff based this recommendation on the following:

Conclusion

- 1 • the analysis and findings in NUREG-1437, Volumes 1 and 2, *Generic*
- 2 *Environmental Impact Statement for License Renewal of Nuclear Plants*,
- 3 • the Environmental Report (ER) submitted by STPNOC,
- 4 • consultation with Federal, state, and local agencies,
- 5 • the NRC's environmental review, and
- 6 • consideration of public comments received during the scoping process.

10.0 LIST OF PREPARERS

This supplemental environmental impact statement (SEIS) was prepared by members of the Office of Nuclear Reactor Regulation (NRR) with assistance from other U.S. Nuclear Regulatory Commission (NRC) organizations and contract support from Pacific Northwest National Laboratory (PNNL). Table 10–1 lists the NRC staff who contributed to the development of the SEIS. PNNL provides contract support for cultural resource, hydrology, and severe accident mitigation alternative (SAMA) reviews.

Table 10–1. List of Preparers

Name	Affiliation	Function or Expertise
NRC		
D. Wrona	NRR	Management oversight
B. Pham	NRR	Management oversight
A. Imboden	NRR	Management oversight
T. Tran	NRR	Project management
A. BeBault	NRR	Socioeconomic, environmental justice, land use, and terrestrial
S. Klementowicz	NRR	Human health
K. Folk	NRR	Hydrology and alternatives
M. Moser	NRR	Aquatic and marine ecology and alternatives
B. Balsam	NRR	Aquatic and marine ecology and terrestrial
A. Travers	NRR	Cultural resource
J. Rikhoff	NRR	Socioeconomic, environmental justice, and land use
W. Rautzen	NRR	Air quality and meteorology (climatology)
J. Dozier	NRR	SAMA
National Laboratory Personnel ^(a)		
S. Short	PNNL	SAMA
R. Schmitt	PNNL	SAMA
C. Kincaid	PNNL	Hydrology
R. Prasad	PNNL	Hydrology
T. O’Neil	PNNL	Cultural resource

^(a) PNNL is operated by Battelle for the U.S. Department of Energy.

1 **11.0 LIST OF AGENCIES, ORGANIZATIONS, AND PERSONS TO**
 2 **WHOM COPIES OF THIS SUPPLEMENTAL ENVIRONMENTAL IMPACT**
 3 **STATEMENT ARE SENT**

Name	Affiliation
D. Klima	Advisory Council on Historic Preservation
O. Sylestine	Tribal Nation—Alabama—Coushatta Tribe
B. Horse	Tribal Nation—Kiowa Tribe of Oklahoma
R. Toahty	Tribal Nation—Comanche Nation
M. Orms	U.S. Fish & Wildlife Service
D. Bernhart	National Marine Fisheries Service
K. Boydston	Texas Parks & Wildlife Department
M. Wolfe	State Historic Preservation Officer
A. Street	Tribal Nation—Tonkawa Tribe of Oklahoma
M. Blount	Tribal Nation—Apalachicola Band of Creek Indians
B. Barcena Jr.	Tribal Nation—Lipan Apache Tribe of Texas
D. Romero Jr.	Tribal Nation—Lipan Apache Band of Texas
J. Mendoza	Tribal Nation—Pamaque Clan of Coahuila Y Tejas
R. Hernandez	Tribal Nation—Tap PilamCoahuiltecan Nation
J. Garza Jr.	Tribal Nation—Kickapoo Traditional Council
J. Loera	Tribal Nation—Ysleta del Sur Pueblo
N. Hudgins	Coastal Plains Groundwater Conservation District
L. Gaul	Texas Department of State Health Services
EIS Scoping Participant*	Affiliation & Address
N. McDonald	Matagorda County Judge 1700 7th Street, Room 301, Bay City, TX 77414
J. Gibean	Matagorda County Resident 25000 Hwy 35 South, Palacios, TX 77465
S. Dancer	S.T.A.R.E PO Box 209, Blessing, TX 77419
R. Malachowski	McDonalds PO Box 1110, Bay City, TX 77404
M. Butter	Matagorda County Economic Development Corporation 2200 7th Street, Suite 302, Bay City, TX 77414

List of Agencies, Organizations, and Persons to Whom Copies of This Supplemental Environmental Impact Statement Are Sent

L. Bracken	Realtor 2055 Ave F, Bay City, TX 77414
B. Watts	Matagorda County EMC 2200 7th St, Bay City, TX 77414
M. B. Johnston	Palacios City PO Box 782, Palacios, TX 77465
A. Acosta	Matagorda Advocate Victoria Matagorda Advocate Newspaper
C. Dunohue	WCJC Nuke Program 2919 Ave J, Bay City, TX 77414
M. Crews	Matagorda County Resident 2200 Golden Ave, Bay City, TX 77414
C. Corporon	South Texas Project Nuclear Operating Company 2608 Wofford Rd, Bay City, TX 77414
K. Hadden	SEED Coalition 1303 San Antonio Suite 100, Austin, TX 78701
D. Kile	U.S. Congressman Ron Paul 122 W Way Suite 301, Lake Jackson, TX 77566
A. Moore	Bay City Public Library 1100 7th Street, Bay City, TX 77414
EIS Filing Section	U.S. Environmental Protection Agency 1200 Pennsylvania Ave NW, Washington, D.C. 20004

* requested to be on the mailing list

12.0 INDEX

accidents, xiii, xviii, 4-44, 4-50, 5-1, 5-2, 5-3, 8-64, A-4, A-16, B-8, F-16, F-28

Advisory Council on Historic Preservation (ACHP), xxii, 1-5, 4-43, E-1,

aesthetic, 4-45, 8-11, 8-12, 8-23, 8-36, 8-49, 8-53, 8-65

alternatives, v, xviii, xix, 1-5, 4-52, 4-61, 5-2, 5-3, 6-3, 6-4, 6-5, 8-1, 8-2, 8-3, 8-10, 8-12, 8-21, 8-30, 8-31, 8-34, 8-39, 8-46, 8-53, 8-55, 8-56, 8-62, 8-63, 8-66, 8-67, 9-1, 9-2, 9-3, 10-1, A-1, A-4, A-5, A-7, A-8, A-11, B-8, F-1, F-2, F-22, F-23, F-32

archaeological resources, xviii, 1-5, 2-71, 2-72, 3-2, 4-40, 4-67, 4-68, 4-69, 8-12, 8-13, 8-23, 8-24, 8-36, 8-37, 8-49, 8-50, 8-54, 8-65, B-8, D-1

biota, 4-11, 4-14, 4-59, 4-60, 8-8, A-14, B-2

boiling water reactor (BWR), A-16, F-21

burnup, 2-1, B-10

chronic effects, xviii, 1-3, 4-33, 4-39, B-7

Clean Air Act (CAA), xxii, 8-16, 8-17, 8-26, 8-28, 8-29, 8-30, 8-40, 8-41

closed-cycle cooling, 4-18, 4-24, B-4, B-5

Coastal Zone Management Act (CZMA), 1-6, 2-73

cooling system, xvii, 1-4, 2-17, 4-11, 4-12, 4-18, 4-20, 4-22, 4-24, 8-3, 8-4, 8-8, 8-20, 8-32, 8-44, 8-63, B-3, B-4, F-7

core damage frequency, xxii, 5-4-5-7, 5-9-5-11, F-1-F-9, F-11, F-13-F-16, F-20-F-23, F-26-F-30, F-33

Council on Environmental Quality (CEQ), 1-3, 4-45, 4-70

critical habitat, 2-43, 2-49, 2-50, 2-74, 4-31, 8-9, C-5

cultural resources, 2-71, 2-72, 2-79, 4-43, 4-44, 4-45, 4-67, 4-74, 8-12, 8-13, 8-23, 8-24, 8-36, 8-37, 8-49, 8-50, 8-53, C-1

Decommissioning, viii, xiii, 7-1, 7-2, 8-63, 8-65, 8-70, B-10

design-basis accident, xxiii, 4-50, 5-1, B-8

discharges, 2-5, 2-7-2-9, 2-17-2-19, 2-20, 4-8, 4-10, 4-18, 4-22-4-24, 4-35-4-37, 4-60, 8-8, 8-15, 8-19, 8-20, 8-26, 8-31, 8-32, 8-43, 8-44, 8-63, B-2, B-3, C-3

dose, 2-2, 2-3, 4-36, 4-37, 4-64, 4-65, 4-69, 5-7, 5-8, 5-10, A-14, B-6, B-8, F-1, F-6, F-7, F-16-F-19, F-21, F-23, F-26-F-28

education, 3-2, 4-40, A-9, A-10, A-11, B-7

electromagnetic fields, 1-3, 4-26, 4-39, 4-65, 9-1, B-5, B-7

Endangered Species Act (ESA), xii, xxiv, 2-47, 2-49, 2-50, 2-51, 2-53, 4-26, 4-27

entrainment, 2-56, 4-12, 4-13, 4-15, 4-16, 4-18-4-20, 4-22, 4-25, 4-32, 4-59, 4-60, 8-8, 8-9, 8-20, 8-32, 8-44, 8-64, B-2, B-3

essential fish habitat, xii, xxiii, 2-54, 2-56, 2-77, 4-19, 4-32, 4-73,

Generic Environmental Impact Statement (GEIS), xiii, xvi, xvii, xix, xxiv, 1-3, 1-4, 1-5, 1-6, 2-62, 3-1, 3-2, 4-1, 4-2, 4-5, 4-6, 4-8, 4-11, 4-25, 4-26, 4-33, 4-34, 4-38-4-42, 4-51, 4-52, 4-66, 5-1, 5-2, 6-1, 6-2, 6-3, 7-1, 7-2, 8-1, 8-2, 8-10, 8-14, 8-15, 8-21, 8-22, 8-25, 8-27, 8-34, 8-35, 8-41, 8-45-8-48, 8-56, 8-59, 8-60, 8-62, 8-63, A-1, B-8

greenhouse gases, 8-6, 8-15, 8-17, 8-30, 8-41, 8-42,

groundwater, 2-9, 2-10, 2-12, 2-16, 2-19-2-23, 2-36, 2-37, 2-60, 3-1, 4-5-4-11, 4-33, 4-34, 4-35, 4-51, 4-55, 4-57, 4-58, 4-60, 4-68, 5-2, 8-3, 8-7, 8-8, 8-19, 8-31, 8-32, 8-44, 8-53, 8-55, 8-63, B-4, B-5, B-8, C-1

hazardous waste, 2-4, 2-5, 9-2, 9-3, C-4, C-3, C-4

heat shock, 4-22, 4-59, 8-9, 8-20, 8-32, 8-64, B-3

high-level waste, xvii, 1-4, 6-1, 6-2, 8-14, 8-65, A-18, B-8, B-9, B-10

impingement, xviii, 2-56, 4-12–4-15, 4-17–4-20, 4-22, 4-25, 4-32, 4-59, 4-60, 8-8, 8-9, 8-20, 8-32, 8-44, 8-64, B-2, B-3

low-level waste, xxv, 2-4, 6-1, 8-14, B-9

maximum occupational doses, 4-34, B-7

mitigation, xvii, xviii, xxviii, 1-3, 1-4, 1-5, 4-1, 4-11, 4-25, 4-34, 4-39, 4-66, 5-2, 7-1, 7-2, 8-12, 8-24, 8-37, 8-50, 9-1, 9-2, 10-1, E-5, F-1, F-14

mixed waste, 8-14, 8-65, B-9

National Environmental Policy Act (NEPA), xiii, xvi, xxvii, 1-1, 1-7, 2-70, 2-72, 2-78, 3-3, 4-32, 4-43, 4-44, 4-45, 4-59, 4-71, 4-73, 4-74, 5-1, 6-2, 6-9, 7-2, 8-1, 8-70, 9-1, B-1, B-9, E-7

National Marine Fisheries Service (NMFS), xxvii, 1-5, 2-47, 2-74, 2-77, 2-78, 4-26, 4-73, 11-1, D-1, D-2

National Pollutant Discharge Elimination System (NPDES), xxvii, 4-20, 8-7, 8-19, 8-32, B-2, C-1, C-3

no-action alternative, v, xix, 8-2, 8-63, 8-65, 8-66, 9-2

nonattainment, 4-54

once-through cooling, 4-19, 4-24, B-2, B-3

radon, 4-34, B-8

reactor, xvi, xvii, xxii, xxvii, xxviii, 2-1, 2-2, 2-4, 2-6, 2-13, 2-16, 2-23, 3-1, 3-3, 4-37, 4-41, 4-65, 4-69, 5-1, 5-2, 5-3, 5-10, 6-2, 6-4, 7-1, 8-4, 8-7, 8-11, 8-12, 8-23, 8-36, 8-63, A-14, A-16, A-17, B-4, B-8, F-16, F-18, F-29

refurbishment, 2-14, 2-70, 3-1, 3-2, 4-31, 4-33, 4-37, 4-41, 4-44, 4-54, B-1, B-2, B-4–B-8, C-3, F-28

salinity gradients, 4-2, B-1

scoping, v, xvi, xvii, xx, 1-2, 1-5, 4-1, 4-2, 4-5, 4-11, 4-25, 4-33, 4-34, 4-40, 4-44, 4-53, 5-2, 6-2, 7-2, 9-4, A-1, A-4, E-1–E-4

Severe Accident Mitigation Alternatives (SAMA), xiii, xiv, xxviii, 5-3, 5-4, 5-8, 5-9,

5-10, 5-11, 5-13, 9-1, 10-1, F-1, F-2, F-3, F-7, F-8, F-11, F-12, F-14–F-35, F-37

severe accidents, xiii, xviii, 4-50, 5-1, 5-2, 5-3, A-16, B-8, F-13, F-27, F-28, F-29

solid waste, xix, xxix, 2-1, 2-2, 2-3, 2-4, 6-1, 7-2, 8-2, 8-27, 8-31, 8-60, A-8, B-10, C-1

spent fuel, xvii, 1-4, 2-2, 4-65, 6-1, 6-2, A-12, A-18, B-8, B-9, B-10

State Historic Preservation Officer (SHPO), xxviii, 1-6, 2-78, 4-43, 4-44, 4-73, 8-12, 8-13, 8-23, 8-24, 8-36, 8-37, 8-49, 8-50, E-2

State Pollutant Discharge Elimination System, xxviii, C-1

surface water, 2-10, 2-18, 2-21, 3-1, 4-2, 4-3, 4-5, 4-8, 4-9, 4-29, 4-34, 4-50, 4-51, 4-56, 4-57, 4-60, 4-63, 4-68, 8-3, 8-6, 8-7, 8-18–8-20, 8-31–8-33, 8-43, 8-44, 8-53, 8-63, B-1, B-4, C-1

transmission lines, 2-7, 2-43, 2-49, 2-51, 2-58, 4-2, 4-11, 4-31, 4-32, 4-38–4-40, 4-43, 4-61, 4-63–4-67, 8-39, 8-43, 8-45, 8-46, 8-53, 8-56, 8-58, 8-60, 8-64, B-6, B-8

tritium, 2-22, 2-23, 4-9, 4-10, 4-33, 4-35, 4-57, A-14, A-17

U.S. Department of Energy (DOE), xxiii, 4-35, 4-36, 4-39, 8-2, 8-3, 8-18, 8-27, 8-39, 8-42, 8-57, 8-60, 8-61, 8-68, 8-69

U.S. Environmental Protection Agency (EPA), xxiii, 2-1, 2-4–2-6, 2-14, 2-22, 2-23, 2-37, 2-38, 2-60, 2-62, 2-75, 2-76, 2-81, 4-9, 4-10, 4-12, 4-13, 4-18, 4-20, 4-22, 4-23, 4-35, 4-37, 4-54, 4-57, 4-59, 4-64, 4-65, 4-69, 4-71, 8-2, 8-5, 8-16–8-18, 8-26, 8-28–8-30, 8-34, 8-40, 8-41, 8-42, 8-68, 8-69, 9-2, A-14, A-15, A-17, C-1–C-5

U.S. Fish and Wildlife Service (FWS), 1-6

uranium, 2-1, 2-2, 4, 5, 18, 19, 4-65, 6-1, 6-2, 6-4–6-8, 8-10, 8-21, 8-34, 8-47, A-4, A-5, A-18, A-19, B-8, B-9, B-10

wastewater, 2-5, 2-8, 2-73, 4-2, 4-63, 8-60, B-2, C-3

Yucca Mountain project, B-10

APPENDIX A
COMMENTS RECEIVED ON THE STP ENVIRONMENTAL REVIEW

1 COMMENTS RECEIVED ON THE STP ENVIRONMENTAL REVIEW

2 A.1 Comments Received During the Scoping Period

3 The scoping process began on January 31, 2011, with the publication of the U.S. Nuclear
4 Regulatory Commission's (NRC's) Notice of Intent to conduct scoping in the *Federal Register*
5 (76 FR 5410). The scoping process included two public meetings held at the Bay City Civic
6 Center in Bay City, Texas, on March 2, 2011. Approximately 60 members of the public attended
7 the meetings. After the NRC's prepared statements pertaining to the license renewal process,
8 the meetings were open for public comments. Attendees provided oral statements that were
9 recorded and transcribed by a certified court reporter. Any written statements submitted at the
10 public meeting are documented in the transcript of the meetings. Transcripts of the two
11 meetings are an attachment to the Scoping Meeting Summary, dated May 19, 2011
12 (Agencywide Documents Access and Management System (ADAMS) No. ML110770661). In
13 addition to the comments received during the public meetings, comments were also received
14 electronically and through the mail.

15 Each commenter was given a unique identifier, so every comment could be traced back to its
16 author. Table A-1 identifies the individuals who provided comments applicable to the
17 environmental review and the Commenter ID associated with each person's set of comments.
18 The individuals are listed in the order in which they spoke at the public meeting and in numerical
19 order for the comments received by letters or e-mails.

20 Specific comments were categorized and consolidated by topic. Comments with similar specific
21 objectives were combined to capture the common essential issues raised by participants.
22 Comments fall into one of the following general groups:

- 23 • Specific comments that address environmental issues within the purview of
24 the NRC environmental regulations related to license renewal. These
25 comments address Category 1 (generic) or Category 2 (site-specific) issues
26 identified in NUREG-1437, *Generic Environmental Impact Statement for*
27 *License Renewal of Nuclear Plants* (GEIS) or issues not addressed in the
28 GEIS. The comments also address alternatives to license renewal and
29 related Federal actions.
- 30 • General comments in support of or opposed to nuclear power or license
31 renewal or comments regarding the renewal process, the NRC's regulations,
32 and the regulatory process.
- 33 • Comments that address issues that do not fall within or are specifically
34 excluded from the purview of NRC environmental regulations related to
35 license renewal. These comments typically address issues such as the need
36 for power, emergency preparedness, security, current operational safety
37 issues, and safety issues related to operation during the renewal period.

38 **Table A-1. Individuals Providing Comments During the Scoping Comment Period**

Commenter	Commenter ID	Affiliation (if stated)	ADAMS No.
Randy Weber	STP 1	State Representative	ML110840441
Judge Nate McDonald	STP 2	Matagorda County judge and local emergency response official	ML110840441

Appendix A

Commenter	Commenter ID	Affiliation (if stated)	ADAMS No.
Mark Bricker	STP 3	Bay City Mayor	ML110840441
Ron Paul's office	STP 4	U.S. congressman	ML110840441
Ed Halpin	STP 5	STP CEO	ML110840441
Carolyn Thames	STP 6	Bay city council member	ML110840441
Don Booth	STP 7	Director local 211 Pipefitter union of 3,000	ML110840441
Cheryl Stewart	STP 8	Bay City Community Development Corporation board member and Bay City Historic Commission	ML110840441
David Dunham	STP 9	Matagorda County resident	ML110840441
Owen Bludau	STP 10	Director of Matagorda County Economic Development Corporation	ML110840441
Kesha Rogers	STP 11	Congressional candidate for 22nd Congressional District	ML110840441
James Lovett	STP 12		ML110840441
D. C. Dunham	STP 13	Bay City Community Development Corporation	ML110840441
Willie Rollins	STP 14	Matagorda County resident	ML110840441
Ian Overton	STP 15	LaRouche PAC organizer	ML110840441
John Corder	STP 16	Brazoria County resident	ML110840433
Judge Nate McDonald	STP 17	Matagorda County judge	ML110840433
Mitch Thames	STP 18	Chamber of Commerce, emergency response public information officer	ML110840433
Tim Powell	STP 19	STP Vice President	ML110840433
Ken Head	STP 20		ML110840433
Mike Bolin	STP 21		ML110840433
John Corder	STP 22	Brazoria County resident	ML110840433
Casey Kile	STP 23	Bay City Babe Ruth (local sport organization)	ML110840433
Robert Singleton	STP 24	Austin resident	ML110840433
Karen Hadden	STP 25	Executive director of SEED Coalition	ML110840433
Bobby Head	STP 26	Matagorda County resident	ML110840433
Tom Kovar	STP 27	Bay City resident	ML110840433
Vicki Adams	STP 28	Superintendent Palacios ISD	ML110730188
Eva Esparza	STP 29	Austin resident	ML110960078
Darby Riley	STP 30	San Antonio resident	ML110960079
Kamala Platt	STP 31		ML110960080
Marion Mlotok	STP 32	Austin resident	ML110960081
Karen Seal	STP 33	Lacoste resident	ML110960082

Commenter	Commenter ID	Affiliation (if stated)	ADAMS No.
Kassandra Levay	STP 34	San Antonio resident	ML110960083
Unknown	STP 35		ML110960084
T. Burns	STP 36	Midland resident	ML110960086
Jolly Clark	STP 37		ML110960087
Dale Bulla	STP 38		ML110960088
William Stout	STP 39		ML110960089
C. J. Keudell	STP 40	Austin resident	ML110960090
Tarek Tonsson	STP 41		ML110960091
Carol Geiger	STP 42		ML110960092
Veryan and Greg Thompson	STP 43		ML110960093
Robert Singleton	STP 44		ML110960094
Karen Hadden	STP 45	SEED Coalition	ML110960095
Alan Apurim	STP 46		ML110960096
Brandi Clark Burton	STP 47	Austin resident	ML110960097
Carol Geiger	STP 48	Austin resident	ML110960098
Eric Lane	STP 49	San Antonio resident	ML110960099
Jenna Findley	STP 50		ML111010476
Margaret Reed	STP 51	Austin resident	ML111010477
Scott and Cyndy Reynolds	STP 52		ML111010478
Jennifer Meador	STP 53	Austin resident	ML111010604
Joy Malacara	STP 54	Austin resident	ML111010479
Melanie and David Winters	STP 55		ML111010506
J. R. Rhode	STP 56		ML111010507
Christine Fry	STP 57		ML111010508
Leona Slodge	STP 58	Austin resident	ML111010509
Carolyn Campbell	STP 59	Austin resident	ML111010510
Bryan Dunlap and Todd Rinehart	STP 60		ML111010517
Peggy Cravens	STP 61	Austin resident	ML111010518
Shannon Jurak	STP 62	Austin resident	ML111010519
Thomas Nelms	STP 63		ML111010520
T. Nelms	STP 64		ML111010521
Peggy Pryor	STP 65	Andrews resident	ML110960077
Edmund Kelley	STP 66	Austin resident	ML11105A023
Maria Hogan	STP 67		ML11105A020

Appendix A

Commenter	Commenter ID	Affiliation (if stated)	ADAMS No.
Randy Weber	STP 1 (letter, also captured in public meeting transcript)	Texas State Representative	ML11108A059
Beth Larsen	STP 68	Austin resident	ML11119A007
Dzan Nguyen	STP 69	Austin resident	ML11119A008
John Trimble	STP 70	Austin resident	ML11119A010
Aguilar family	STP 71		ML11119A011
Juan Aguilar	STP 72		ML11119A012
Douglas McArthur	STP 73	Austin resident	ML11119A013
Shawn Tracy	STP 74		ML11119A014
Kelly Simon	STP 75	Austin resident	ML11119A015
N/A	STP 76		ML11119A016
Judy Moore	STP 77		ML11119A017
Cynthia Gebhardt	STP 78		ML11119A018
Rory Holcomb	STP 79	Austin resident	ML11119A019
N/A	STP 80		ML11119A020

1 Comments received during the scoping comment period applicable to this environmental review
 2 are presented in this section along with the NRC response. The comments that are general or
 3 outside the scope of the environmental review for South Texas Project (STP) license renewal
 4 are not included here but can be found in the Scoping Summary Report (ADAMS
 5 No. ML11153A082). To maintain consistency with the Scoping Summary Report, the unique
 6 identifier used in that report for each set of comments is retained in this Appendix A.

7 Applicable scoping comments are grouped in the following categories and presented in the
 8 following order:

- 9 • alternatives to license renewal of STP,
- 10 • socioeconomic impact of STP,
- 11 • water usage,
- 12 • human health,
- 13 • postulated accidents,
- 14 • terrestrial or aquatic ecology, and
- 15 • uranium fuel cycle and waste management.

16 **A.1.1 Alternatives to License Renewal of STP, Units 1 and 2**

17 The original sources for the comments in this category (alternatives to license renewal) can be
 18 found at the back of the Scoping Summary Report and are labeled with the following identifiers:
 19 12-2, 15-1, 24-3, 25-5, 26-2, 27-2, 27-4, 29-2, 30-1, 31-2, 32-3, 35-2, 36-6, 38-2, 39-3, 40-2,
 20 43-3, 45-3, 46-3, 47-4, 49-2, 51-2, 52-2, 53-2, 54-3, 55-2, 57-2, 59-2, 60-3, 61 2, 62-2, 69-2,
 21 73-2, 74-1, 77-2, 79-2, and 80-2. These comments are extracted from the original sources.

1 Comment 12-2: Several nations have nuclear energy policies. These policies are all variations
2 on one theme: one, oil is not a dependable source of energy, it can be interrupted at any time
3 and it is not feasible to store more than a few months worth of reserve supply; two, nuclear
4 energy is the only source of energy, other than wind and solar—which I hope come along in the
5 future but at the present have to be considered in the development stage—nuclear energy is the
6 only source of energy that can produce large quantities of energy without dumping large
7 quantities of carbon dioxide into the atmosphere.

8 Yes, the natural gas plant is better than the coal plant, and I'm not particularly in favor of a coal
9 plant in Matagorda County, but natural gas is contributing to global warming, and we cannot
10 afford to build any more of it than we have to.

11 I'm a strong supporter of nuclear energy; I'm a strong supporter of renewing these. In due
12 course, I will be a strong supporter of Units 3 and 4. Thank you.

13 Comment 15-1: And, I think that it's probably best, when talking about the environmental
14 benefits of nuclear power, to compare it with the environmental problems that other forms of
15 power offer. So for example, the amount of energy in one pellet of uranium, about the size of
16 my fingernail here, is equivalent in energy to about 30 barrels of oil or 6.15 tons of coal, or
17 23 1/2 tons of dry wood.

18 When you start going into other examples of energy, such as wind or solar, the amount of return
19 gets even worse because the amount of radiant heat coming down from the sun is only about
20 200 watts per square meter, and the amount of land area and the cost of building and
21 maintaining solar panels or windmills is far, far greater than the actual benefit you get from
22 them, not to mention that windmills kill birds by the dozen and solar panels, with their polarized
23 lights, kill insects by the countless numbers.

24 Comment 24-3: Nuclear power was also always intended to be a bridge technology. We're
25 always going to find something better, and what we could do right now instead of re-license
26 these is make an investment in renewables which could have, in terms of jobs, just as much of
27 an impact as extending the life of this plant or building new units.

28 The other thing about switching forms of energy is that you can create jobs locally that are going
29 to be exclusively locally. Nuclear power, a lot of the jobs that are generated are going to be
30 foreign manufacturing jobs. The components for these plants are built off site; they don't really
31 generate that much for your local economy.

32 There are new and exciting technologies that we could be counting on. For example, there's an
33 Australian company called EnviroMission that's just about to open a project in Arizona. What it
34 is; it's a tower, just a tower, covered around the base with thick plastic. What it does is it
35 captures the heat of the sun; the heated air rises up a chimney and turns a turbine. It's basically
36 the only moving part, so the turbine and then the generators from it.

37 The cool thing about it is that it continues to generate electricity even at night because the heat
38 of the ground continues to make this temperature differential, and the air continues up the
39 chimney, and the turbines continue to turn.

40 This is the kind of thing that can be built and provide localized power. In West Texas, for
41 example, we could build these things and not have to ship the power across the State. We
42 could actually use it to provide energy where it's built.

43 Comment 25-5: A big issue is need for power. Right now in the legal case involving Units 3
44 and 4, the Atomic Safety and Licensing Board has agreed to hear a contention that is one of
45 omission. There was a failure to analyze what alternatives were there in terms of looking at
46 energy efficiency. Building codes in particular are going to be saving; they've been adopted,

Appendix A

1 going to be saving some 2,200 megawatts of power in Texas. We need to look at whether the
2 power is needed and then we need to look at how else it could be generated.

3 And, certainly[,] jobs are crucially important in every community. We realize that that's
4 important here. I think it's time to look at what are the options in terms of transition, what other
5 kinds of ways to generate electricity could occur here; I think there are many and to start looking
6 at training and what other options exist.

7 Comment 26-2: Randy Weber was here last week. He's our State representative. He got over
8 in the next room and he said that Texas is growing by 113,000 people a month. Wow. We're
9 outgrowing all the states combined. We're getting more people into Texas. He says if we keep
10 growing the way we are, that by 2015 we're going to have to have five new nuclear plants, or
11 16 coal plants, or 28 gas plants, or 3,000 windmills if the windmills agree to turn 24-7-365. You
12 know that's not going to happen.

13 Would I like to see all of our power generated totally clean[?] Yes, I would. It's not realistic, not
14 with what we have as today's knowledge.

15 Comment 27-2: You have to have electricity and you have to have a lot of it. I wish I could
16 afford Austin's 16 percent. But, you have to have a lot of electricity nowadays because of the
17 way the population is, and if you look at the last 40-50 years of power generation, of gas-fired
18 plants or coal-fired plants and how hazardous they are to the environment and people, then I
19 think you [cannot] help but realize how safe nuclear power is. The Government has been using
20 it to power their vehicles in the military for a long time.

21 Comment 29-2: There are safer alternative technologies that can replace the energy generated
22 by these reactors.

23 Comment 30-1: Well before 2027, we should have outgrown the need for nuclear power with
24 clean alternative energy and conservation [and] efficiency ...

25 Comment 31-2: I urge the denial of the relicensing of the STP. As a San Antonio resident, I
26 value my community and know that we are committed to renewables and conservation, much
27 better paths to the future on a sustainable planet.

28 Comment 32-3: We should be investing in solar and wind and dismantling our aging reactors.

29 Comment 35-2: There are cheaper and renewable ways to get our power, and I would love to
30 see Texas lead the way in these fields. Not continue to lead us down a dead end road with
31 nuclear power.

32 Comment 36-6: STP does not displace [carbon dioxide] emissions. Other, truly renewable
33 energy sources are much more highly developed now and can replace STP. By scheduled
34 renewal, nuclear energy will be totally unnecessary.

35 Comment 38-2: We need to move toward heavy development of solar and wind regardless of
36 the cost[—]they would be so much safer (and most likely cheaper in the long run, considering
37 [(lacking of or merit of)] all the waste and other negatives of solar).

38 Comment 39-3: Safer, cleaner alternative ways to generate the same power (in essence[,] to
39 boil water) exist today and should be used and funded, just like the Nuclear and Petroleum
40 industries have been subsidized by the U.S. Government to the tune of BILLIONS of dollars
41 annually.

42 Comment 40-2: At this point in time, I feel that the U.S. should move away from nuclear and oil
43 as primary energy sources. Let's develop more renewable options.

1 Comment 43-3: Here in Texas, we have a wonderful abundance of sun as well as wind, neither
2 depend[e]nt on other countries. We should be making use of these natural resources[,] which
3 are safer, reduce use of scarce water, and [cannot] be used as political weapons.

4 Comment 45-3: Safer, cleaner alternative ways to generate the same power exist today and
5 should be used. We should not be subjected to worrying about radioactive contamination—just
6 to generate electricity. We should not have to worry about terrorists attacking a radioactive
7 energy generation source, and we don't have these worries with solar, geothermal, natural gas,
8 or wind power. These forms of energy generation, combined with energy efficiency and
9 ever-improving methods of storage, could easily replace the electricity generated by Units 1
10 [and] 2. When these units have been down due to problems or fuel replacement, it did not
11 cause problems with the grid or lead to blackouts. We can replace the generation of these units
12 with safer, cleaner technologies.

13 Comment 46-3: For alternative energy sources, and a way to get the USA off foreign oil
14 dependence that is costing us both in trade balance and military costs, see the downloadable
15 document describing achievable ecological solutions for all these needs:

16 <http://phoenixprojectfoundation.us/uploads/USA Article V SHE Document.pdf>

17 Thank you for your hard work and consideration of these issues. Please be sure to keep me
18 informed as this regulatory process proceeds.

19 Comment 47-4: We have safer and cleaner ways to generate the same power—THAT is where
20 our money and attention need to be directed.

21 Comment 49-2: There are safer, cleaner alternatives to generate the same power that exists
22 today, and we should commit the country to use them.

23 Comment 51-2: Safer, cleaner alternative ways to generate the same power exist today and
24 should be used. Studies have found that energy efficiency and renewable energy sources,
25 which are abundant in Texas, could replace the power generated by these two old nuclear
26 reactors.

27 Comment 52-2: NOW is the time to make a commitment to safer and renewable energy
28 sources.

29 Comment 53-2: Safer, cleaner alternative ways to generate the same power exist today and
30 should be used. Studies have found that energy efficiency and renewable energy sources,
31 which are abundant in Texas, could replace the power generated by these two old nuclear
32 reactors.

33 Comment 54-3: There are safer, cleaner alternative ways to generate the same power available
34 today, and these should be used instead of nuclear energy.

35 Comment 55-2: Safer, cleaner alternative ways to generate the same power exist today and
36 should be used. Studies have found that energy efficiency and renewable energy sources,
37 which are abundant in Texas, could replace the power generated by these two old nuclear
38 reactors.

39 Comment 57-2: I believe there are alternative ways to generate power and support a more
40 ...[uncertain handwriting].

41 Comment 59-2: There are safer, cleaner alternative ways to generate power!

42 Comment 60-3: Texas is ready for a new way to power our lives; give Texa[s] a chance for a
43 cleaner, safer power of energy ...

Appendix A

1 Comment 61-2: There are safer, cleaner alternative ways to generate the same power that
2 exist today and should be used.

3 Comment 62-2: Safer, cleaner alternative ways to generate the same power exist today and
4 should be used.

5 Comment 69-2: Safer, cleaner alternative ways to generate the same power exist today and
6 should be used.

7 Comment 73-2: Rather than pushing for more water-consuming nuclear power plants, Texas
8 needs to focus more on the development of renewable energy sources such as wind and solar.

9 While many promises are made as to the safety of nuclear power, recent history demands we
10 not place too much reliance on them. Some things do not readily lend themselves to
11 engineering solutions. I believe nuclear power is one of those things, and thus I am opposed to
12 the requested re-licensing.

13 Comment 74-1: To ensure the safety of my family and other Texas families, I believe the
14 re-licensing of these two reactors for an additional [20] years should be halted for safety
15 reasons. There are safer and cleaner alternatives than outdated reactors. These alternatives
16 (solar, wind, etc.) should be strongly considered.

17 Comment 77-2: There are safer and cleaner ways to generate power today that we need to
18 support and use. Renewable energy sources are everywhere in Texas and could replace more
19 dangerous sources if funded and supported. Another factor to think about is the huge amount
20 of water used in the reactors. The water from the Colorado River is needed to farming, cattle
21 and families. Are we not just creating another problem by using energy sources that use so
22 much water?

23 Comment 79-2: Safer, cleaner alternative ways to generate the same power exist today and
24 should be used. Studies have found that energy efficiency and renewable energy sources,
25 which are abundant in Texas, could replace the power generated by these two old nuclear
26 reactors.

27 Comment 80-2: Safer, cleaner alternative ways to generate the same power exist today and
28 should be used. Studies have found that energy efficiency and renewable sources, which are
29 abundant in Texas, could replace the power generated by these two old nuclear reactors.

30 **Response:** *These comments provide input (or data) for the staff's environmental analysis of*
31 *the alternatives to license renewal, including the alternative of not renewing the operating*
32 *license—also known as the “no-action” alternative. In Chapter 8 of this supplemental*
33 *environmental impact statement (SEIS), the staff evaluated the alternatives to license renewal.*
34 *These include new nuclear generation, natural-gas-fired combined-cycle generation,*
35 *supercritical coal-fired generation, combination alternative, and purchased power. In addition, in*
36 *Chapter 8 of this SEIS, the staff considered many other options that were subsequently*
37 *dismissed for reasons of technical, resource availability, or commercial limitations. These*
38 *include offsite nuclear, gas and coal-fired capacity; energy conservation and energy efficiency;*
39 *wind power; solar power; hydroelectric power; wave and ocean energy; geothermal power;*
40 *municipal solid waste; biomass; biofuels; oil-fired power; fuel cells; and delayed retirement.*

41 **A.1.2 Socioeconomic Impact of STP, Units 1 and 2**

42 The original sources for the comments in this category (socioeconomic) can be found at the
43 back of the Scoping Summary Report and are labeled with the following identifiers: 1-2, 3-1,
44 5-2, 6-2, 8-1, 9-1, 10-1, 13-1, 14-1, 20-2, 23-1, and 24-1. These comments are extracted from
45 the original sources.

1 Comment 1-2: STP is the largest employer in Matagorda County with more than
2 1,200 employees and for 30 years has been a key part of the county and local communities.
3 The company's employees are active in the local community, serving on school boards,
4 chambers and in civic and service organizations.

5 For over 20 years, [the] existing [STP] units have supplied safe, clean and reliable energy to
6 more than 2 million Texas homes while also providing permanent, well-paying jobs. The facility
7 is a recognized industry leader in production, reliability and safety, as well as being focused and
8 committed to the safety of its employees and the surrounding communities.

9 Comment 3-1: With that being stated, STP makes it obvious. STP is the largest employer to
10 the county, their employees stay active in numerous organizations, and many serve as elected
11 officials. They have a very high importance to safety as well as the environment. Their
12 employees set the standard for their industry. Just last October, STP was named one of
13 America's safest companies, the first nuclear facility to ever be honored with that award.

14 In 2008, STP started its educational incentive program as part of its workforce development
15 efforts. It represents a \$4.2 million investment that provides great opportunities for well-paying
16 jobs in this community. For over 20 years, the facility has produced safe, reliable energy to the
17 citizens of Texas, and for the past [7] consecutive years, STP has produced more electricity
18 than any other two-unit nuclear plant in the country.

19 The license extension of STP will continue to provide jobs and economic benefits to our local
20 community.

21 Comment 5-2: Our employees try to contribute and try to continue to do what they can to
22 improve life within this community by serving, as the judge said, on various boards and
23 providing leadership positions, and we're thankful that you give us that opportunity.

24 Comment 6-2: During the record low temperatures when there were problems in Texas with
25 other sources of power, our local plant didn't have any problems keeping the power generating
26 for Texans.

27 The culture of continuing improvement for all aspects of power generation overflows in the
28 community. STP[NOC]'s contributions to our local charities, our chambers of commerce and
29 civic groups provide the commitment to our future and our joint success. They give both time
30 and money to make sure Matagorda County is the best in all of Texas.

31 Comment 8-1: My name is Cheryl Stewart, and I'm on the Bay City Community Development
32 Corporation Board and also the Historic Commission, and I'm here today to inform you of the
33 many ways that I have personally seen STP impact our community in a positive way.

34 STP contributed \$100,000 to the Center for Energy Development and currently provides staffing
35 to train our community's young adults. STP employees have been strong leaders in our
36 strategic planning for the future of this community with our Bay City Matagorda United Plan.
37 STP employees have also invested in the renovation of our historic downtown district and its
38 beautification efforts. I have also served with STP employees on various community boards
39 and have witnessed firsthand their dedication, their desire to be good neighbors, and their
40 commitment to our community.

41 I am sure that our community would experience a huge loss without the involvement and
42 support of STP.

43 Comment 9-1: The importance of STP to that future [cannot] be overemphasized. My employer
44 is an educational partner with STP and their contribution to the future of our community through
45 support of education is unprecedented in my 20 years of higher education experience.

Appendix A

1 Comment 10-1: STP personifies the best type of economic development project that a
2 community could want. It's created a large number of jobs that have been filled with highly
3 educated and highly skilled workers. It pays wages far above the county average. It's greatly
4 enhanced the tax base of Matagorda County and to the taxing entities in whose location it is
5 situation. It makes significant annual financial contributions to civic, educational, and
6 promotional programs benefitting all of the county. It has created and funded a major
7 grow-your-own technical education program, providing good career opportunities for all of our
8 local youth. Its employee and their families are extensively involved in all aspects of our
9 community and political life, and, by so doing, they make Matagorda County a much better
10 place in which to live for all the rest of us.

11 Comment 13-1: And have you ever wondered what Bay City and Matagorda County would be
12 like if we didn't have South Texas Nuclear Operating Company [STPNOC] here? There isn't a
13 day that goes by that we don't run into or communicate with STP employees. They're involved
14 throughout our community, and I really have a hard time imagining what it would be like here
15 without them because they're such a huge asset to our community.

16 And, of course, we love to show off our assets, and I'm proud to say that every time I meet
17 someone I always talk about we're the home of a nuclear power plant, because I'm just really
18 proud of that. And, because of that, I've also invited all of our surrounding economic
19 development associates to come and visit STP because I want them to see the high level of
20 security and safety that they operate in every day. And, I've got them actually scheduled next
21 month, so Mr. Halpin, hopefully you can stop by and say hello.

22 But, as an economic developer and resident of Matagorda County, I'm very thankful to have
23 such a great asset in our community, and they will not only have a positive impact but an
24 excellent impact on our taxes, community development, and our environmental justice.

25 Comment 14-1: I don't have a lot of knowledge on technical skills about nuclear energy, so I'm
26 just going to limit my comments to the social environmental impact that STP has had on this
27 community.

28 Matagorda County, like many rural communities, over the years has suffered from brain drain,
29 where your best and your brightest tend to leave and seek their fortunes other places. Well,
30 STP has helped to reverse that trend in Matagorda County. Not only does it provide great
31 paying jobs for our youth that even go off to college and return to become productive citizens in
32 this community, they have reduced the amount of exodus of kids leaving this community in the
33 first place with the creation of the Center for Energy Development where we can now grow our
34 own.

35 The social environmental impact of that, just in and of itself, has been tremendous. If we were
36 to track the intellectual scale of Matagorda County within the last 20 years, you can begin to see
37 that if you start off with the census of 2000, the number of high school graduated individuals in
38 Matagorda County represented about one-third, another group of individuals that did not have a
39 high school diploma represented another third. So effectively, basically, two-thirds of the
40 population of Matagorda County had a high school diploma or less.

41 If you begin to look at the recent trend since the [STP] has been in this community, you can see
42 that trend reversing and the numbers of educated citizens of this community going up.

43 When I returned to Matagorda County several years ago, I became actively involved in a lot of
44 the nonprofit organizations. The premier nonprofit organization for this community was United
45 Way, but at that time, unfortunately, United Way was under poor leadership and dysfunctional.

1 Thanks to the leadership of two employees from STP, one by the name of Gerald Wilson,
 2 another by the name of Chris Johnson, who took the leadership of the United Way and made it
 3 the organization that it is today that's supporting over 30 other non-profit organizations in this
 4 community, there are others that could talk more eloquently about the economic impact of STP,
 5 but the ancillary benefit of its employees serving on nonprofit boards, and not to mention our
 6 faith-based communities through their tithes, their offerings that support churches and other
 7 community-based organizations, that contribution is almost immeasurable.

8 Comment 20-2: What should you focus on? Obviously, our environmental concerns are a huge
 9 part of this. I'm [with] the Convention and Visitors Bureau, and one of our main focuses is
 10 bringing tourists down to Matagorda County to see what we have to offer.

11 Comment 23-1: And I'd just like to say that, on behalf of Babe Ruth, we're very grateful for
 12 everything STP does for us as an organization. They're a major sponsor in all of our events.
 13 Over the last [10] years, we've hosted [4] regional tournaments and [11] or [12] state
 14 tournaments, and without STP[NOC]'s support, we would never have been able to participate in
 15 those tournaments or even host those tournaments.

16 On the economic standpoint, Mr. Head said earlier last year we hosted a regional tournament.
 17 We had five states come to visit Bay City, over 400 visitors in town, over 100,000 new dollars
 18 just last year, and without STP supporting that, we wouldn't have been able to host that
 19 tournament. So, we'd like to thank them.

20 Not only do they help us monetarily with our tournaments, but their employees also volunteer
 21 with us, and we'd like to thank them for their employees and letting them volunteer.

22 Over the last [10] years, like I said, we've hosted about 15 tournaments and probably half a
 23 million new dollars in Matagorda County over the last [10] years.

24 Comment 24-1: You may ask why I'd want to come down from Austin to talk to you. Well,
 25 Austin is a 16 percent partner in [Units 1 and 2], and if you look back over the history of the
 26 project, we've got a lot less reason to celebrate this plant than may be some people who live
 27 here do. I'm not going to talk a lot about jobs, but I'm going to wrap up with that tonight.

28 But, Austin's experience with [Units] 1 and 2 was a nightmare. We had it thrust upon us by
 29 politicians who were determined to continue to take public votes until we bought a share of the
 30 plant. We tried to get out of the plant at one point, tried to sell our 16 percent share, and
 31 [cannot].

32 The problem was at its worst in the '90s when 42 cents out of every dollar that we paid on a
 33 utility bill was going for debt service at NRG. For our 16 percent share, we were paying almost
 34 half of our utility bill for debt service on the project.

35 **Response:** *These comments provided input (or data) for the staff's environmental analysis of*
 36 *the socioeconomic impacts of STP on local and regional communities. The comments include*
 37 *socioeconomic-related items such as taxes, employment, education, tourism, and public and*
 38 *civic services.*

39 *The socioeconomic impacts of renewing the STP operating license and alternatives to license*
 40 *renewal are discussed in Sections 2.2.9, 4.9, 8.1.8, 8.2.8, 8.3.8, 8.4.8, 8.5.8, and 8.7.8 of this*
 41 *SEIS.*

42 **A.1.3 Water Usage**

43 The original sources for the comments in this category (water usage) can be found at the back
 44 of the Scoping Summary Report and are labeled with the following identifiers: 25-4, 29-3, 32-2,

Appendix A

1 36-5, 37-3, 39-4, 40-3, 41-2, 45-4, 47-2, 51-3, 53-3, 54-2, 55-3, 59-3, 60-2, 62-4, 63-2, 64-3,
2 67-2, 71-2, 75-2, 77-2, and 80-4. These comments are extracted from the original sources.

3 Comment 25-4: There is a problem with the leaking main cooling reservoir [MCR], which was
4 described and documented in the license application for Units 3 and 4. There needs to be
5 tracking of where the water is going. Is it reaching the Gulf, where is it going, what is it doing?
6 That should be part of the re-licensing study and analysis.

7 Water use is an increasing issue. Up until this point, the highest use that I know of through
8 researchers looking at this is 49 percent of the Colorado River has been used for cooling
9 purposes, and I know a couple of summers ago there was a lot of pumping going on to refill the
10 reservoir when it got kind of low.

11 It's a problem for those of us in Austin. The Colorado River water has to serve a lot of
12 purposes. Rice farmers need it; we're going to need it for many, many purposes, recreation,
13 fishing on our end. And, Lake Travis levels were at an all-time low several years ago. Every
14 single dam on the whole lake was closed; you couldn't put a boat in.

15 And, we would like to see something shift to where this much water was no longer required.
16 Certainly, you're still going to have to still cool spent fuel rods and so on and so forth, but it is a
17 question when you look at continuing the reactors' life.

18 Comment 29-3: Vast water consumption requirements for these reactors add a hidden cost to
19 taxpayers, farmers, ranchers and other industries. As water becomes more scarce in Texas,
20 this becomes a very high risk should there be a meltdown like Japan.

21 Comment 32-2: We have been suffering for many years from drought conditions here in Texas.
22 Given the huge amount of water needed for normal operation and to avert nuclear catastrophe,
23 we would be better served to use the little water we have for agriculture and residential use.

24 Comment 36-5: STP requires a large amount of cooling water to operate, critical, as seen in
25 Japan. Texas is facing more and more serious water shortages, as population rises and global
26 warming effects take place. The need for water for other purposes than STP will grow. STP
27 should relinquish its water use and shut down.

28 Comment 37-3: Vast consumption of water use, largely Colorado River water, which is
29 increasingly needed for drinking water, livestock, and farming. The [MCR] is leaking out the
30 bottom. How and when will this be repaired? Climate change—rising temperatures could affect
31 whether there is enough cool water to cool the reactors.

32 Comment 39-4: Vast consumption of water use, largely Colorado River water, which is
33 increasingly needed for drinking water, livestock, and farming in an era of more frequent and
34 lengthy periods of drought. The [MCR] is leaking out of the bottom: How and when will this be
35 repaired? Climate change considerations: The rising atmospheric temperatures could affect
36 whether there is enough cool water to cool the reactors.

37 Comment 40-3: Also, as you know, nuclear power supplies require a lot of water for cooling
38 purposes. Once again, the State of Texas is experienced drought in 98 [percent] of its counties.
39 Let's save the water for agricultural purposes.

40 Comment 41-2: The reactors consume vast quantities of water; use largely from the Colorado
41 River; water that is needed for drinking water.

42 Comment 45-4: These reactors consume vast quantities of water use, largely Colorado River
43 water, which is increasingly needed for drinking water, livestock, and farming. Drought is
44 expected to increase in our region. We are concerned that there will not be adequate water to
45 cool the reactors in an emergency or that the water will not be cool enough to effectively cool

- 1 the reactors. Some U.S. reactors have had to shut down due to high water temperatures, and
2 this could [result in a] scenario [that] could worsen with climate change impacts, leaving us with
3 a dangerous situation and a shortage of power during intense heat waves.
- 4 The [MCR] is leaking out the bottom, as documented in the license application for STP 3 [and]
5 4. The reactors should not be relicensed when this serious condition remains unresolved. How
6 and when will this be repaired? What studies have been done by the NRC on this serious
7 problem? How can relicensing even be considered until this situation is corrected? Where is
8 the water going, and how extensive is the radioactivity that may be leaking into the Gulf of
9 Mexico [or the] Colorado River [or both]?
- 10 Comment 47-2: We have limited access to freshwater that can be used for this facility. The
11 priority should be for drinking water, livestock, and farming. I understand that the [MCR] is
12 leaking out the bottom. How and when will this be repaired?
- 13 Comment 51-3: These reactors consume vast quantities of water use, largely from the
14 Colorado River, water that is needed for drinking water, livestock, and farming.
- 15 Comment 53-3: These reactors consume vast quantities of water use, largely from the
16 Colorado River, water that is needed for drinking water, livestock, and farming.
- 17 Comment 54-2: The reactors would affect the Austin area by consuming vast quantities of our
18 drinking water from the Colorado River ...
- 19 Comment 55-3... these reactors consume vast quantities of water use, largely from the
20 Colorado River, water that is needed for drinking water, livestock and farming;
- 21 Comment 59-3: Leave the Colorado River for other purposes—drinking, livestock, and farming.
- 22 Comment 60-2: Please help protect Americans, Texans, and all human beings that come into
23 contact with the Texas Colorado River from having it depleted by renewing these reactors
24 licenses[,] to continue consuming vast quantities. Protect the waterways from being poisoned in
25 the event of emergencies at nuclear plants.
- 26 Comment 62-4: These reactors consume large quantities of water use, largely from the
27 Colorado River, water that is needed for drinking water, livestock, and farming.
- 28 Comment 63-2: Too much water is used to cool the reactors! Too much water is used. It's
29 dangerous.
- 30 Comment 64-3: Too much water is wasted! There goes the drinking water; all gone and toxic!
31 Please do not relicense these two reactors.
- 32 Comment 67-2: The vast amount of water taken up by these reactors is very much needed for
33 other purposes.
- 34 Comment 71-2: Nuclear reactors use large quantities of water, water that could be used for
35 drinking, livestock, and farming.
- 36 Comment 75-2: These reactors consume vast quantities of water use, largely from the
37 Colorado River[:;] water that is needed for drinking water, livestock[:;] and farming.
- 38 Comment 77-2: There are safer and cleaner ways to generate power today that we need to
39 support and use. Renewable energy sources are everywhere in Texas and could replace more
40 dangerous sources if funded and supported. Another factor to think about is the huge amount
41 of water used in the reactors. The water from the Colorado River is needed [for] farming,
42 cattle[:;] and families. Are we not just creating another problem by using energy sources that
43 use so much water?

Appendix A

1 Comment 80-4: These reactors consume vast quantities of water use, largely from the
2 Colorado River[;] water that is needed for drinking water, livestock, and farming.

3 **Response:** *These comments provided input (or data) for the staff's environmental analysis of*
4 *water resource impacts of STP on local and regional communities. These comments raise*
5 *concerns about the water usage from the Colorado River and leakage from the MCR. The staff*
6 *discusses water usage impacts in Sections 2.2.4, 2.2.5, 4.3, 4.4, 8.1.2, 8.1.3, 8.2.2, 8.2.3, 8.3.2,*
7 *8.3.3, 8.4.2, 8.4.3, 8.5.2, 8.7.2, and 8.7.3 of this SEIS.*

8 **A.1.4 Human Health**

9 The original sources for the comments in this category (human health or Radiation Impact) can
10 be found at the back of the Scoping Summary Report and are labeled with the following
11 identifiers: 25-1, 29-4, 36-3, and 45-6. These comments are extracted from the original
12 sources.

13 Comment 25-1: I also have concerns about the re-licensing of reactors 1 and 2. I think there
14 are a number of issues that need to be looked at carefully during this process and bearing
15 worker safety in mind. One of them is tritium, and basically, there has been tritium showing up
16 in wells on the site. This needs to be looked into thoroughly, as well as tritium in the Colorado
17 River, and documented, measured, carefully analyzed to see if it's safe to continue down this
18 path at this point in time.

19 Comment 29-4: There is currently a leak in the bottom. What are the health implications to
20 wildlife and people of this leak? When will it be fixed? They have not repaired this, how can they
21 be trusted for another 20 years?

22 Comment 36-3: I have heard the news reports that the leakage of plutonium and cesium is not
23 a cause for concern. As a physician interested in this area, I know that this is ridiculous. I
24 remember how much polonium [alpha emitter] was required to assassinate a Russian person in
25 the UK.

26 Comment 45-6: We are concerned about increasing tritium levels in wells [on site] and in the
27 Colorado River. Extensive testing should occur for all organisms in the region, and exposure of
28 whooping cranes to tritium and other radionuclides should be examined since they are an
29 endangered species and their winter grounds are only 35 miles from the STP site.

30 **Response:** *These comments provided input (or data) for the staff's environmental analysis of*
31 *human health and environmental impacts related to possible radioactive leaks from STP.*

32 *To ensure that STP is operated safely, the NRC licenses the plant to operate, licenses the plant*
33 *operators, and establishes license conditions for the safe operation. The NRC provides*
34 *continuous oversight of STP through its reactor oversight process (ROP) to verify that*
35 *operations are in accordance with NRC regulations. The NRC has full authority to take*
36 *necessary actions to protect public health and safety and the environment, and it may demand*
37 *immediate STPNOC actions, up to and including a plant shutdown.*

38 *Radiation doses to members of the public from the current operations of STP are evaluated in*
39 *the SEIS in Section 4.8.2. In that section, the staff reviewed the radioactive releases from STP*
40 *(i.e., radioactive gaseous and liquid effluents, radiation from radioactive waste storage buildings,*
41 *radiological impacts from refueling and maintenance activities, and tritium leaks) and the results*
42 *of STPNOC's radiological environmental monitoring program (REMP) (i.e., analysis of air, water*
43 *(surface, ground, and drinking), sediment, vegetation, and aquatic and terrestrial biota for*
44 *radioactivity). Based on its review, the staff concluded that the radiological impacts to members*
45 *of the public were within NRC's and U.S. Environmental Protection Agency's (EPA's) dose*

1 standards, and there were no radiological effects to the environment and non-human species
2 (i.e., local biota) from plant operation.

3 The staff also evaluated the STP REMP. The REMP quantifies the environmental impacts
4 associated with radioactive releases from the plant. The REMP monitors the environment over
5 time, starting before the plant operates to establish background radiation levels and throughout
6 its operating lifetime to monitor radioactivity in the local environment. The REMP provides a
7 mechanism for determining the levels of radioactivity in the environment to ensure that any
8 accumulation of radionuclides released into the environment will not become significant as a
9 result of plant operations. Based on the review of several years of data, the staff concluded that
10 there were no measurable impacts to the environment as a result of radioactive releases from
11 STP.

12 In summary, the NRC provides continuous oversight of STP through its ROP to verify that they
13 are being operated in accordance with NRC regulations. STP is required to maintain its
14 radioactive effluent release program in compliance with NRC regulations and consistent with
15 EPA standards. The NRC will continue to inspect STPNOC's compliance with radioactive
16 effluent.

17 **A.1.5 Postulated Accidents**

18 The original sources for the comments in this category can be found at the back of the Scoping
19 Summary Report and are labeled with the following identifiers: 25-3, 37-2, 39-2, 42-1, 45-2, and
20 48-1. These comments are extracted from the original sources.

21 Comment 25-3: [I]n 1982, there was a study done for the [NRC] called the [CRAC 2] Study. It
22 found that if there were an accident—and they were looking at Units 1 and 2—that there would
23 be 18,000 early deaths. They would also be followed by thousands of cancers. That study has
24 not been updated. The population in some of this region has grown, and it needs to be looked
25 at again to find out what is the reality of the situation today, and that needs to be compared to
26 other ways of generating electricity.

27 Comment 37-2: Risks of an accident, fires, or explosions at one or more reactors at the site,
28 risks that could increase with aging reactors NRC's 1982 CRAC 2 study found that there could
29 be 18,000 early deaths if a serious accident occurred at the STP site.

30 Comment 39-2: Risks of an accident, fires, or explosions at one or more reactors at the site,
31 risks that could increase with aging reactors. [NRC's] 1982 CRAC 2 study found that there
32 could be 18,000 early deaths if a serious accident occurred at the STP site.

33 Comment 42-1: The [license renewal application (LRA)] is inadequate because it: (a) fails to
34 adequately address the applicant's capacity to deal with fires and explosions that cause a loss
35 of large areas of the plant—the mitigative strategies for addressing fires and explosions are
36 inadequate to address the consequences of events such as the impacts of large commercial
37 aircraft crashing into the reactors or related facilities, (b) fails to describe the means that would
38 be used to determine radiation exposures to fire and explosion responders, and (c) fails to
39 describe the means that would be used to protect fire and explosion responders from excessive
40 radiation exposures.

41 Comment 45-2: We are all too aware of the fact that meltdowns can and do happen, and a
42 recent Union of Concerned Scientists report notes that there were 14 near misses in the U.S. in
43 2010. NRC's 1982 CRAC 2 study found that there could be 18,000 early deaths if a serious
44 accident occurred at the ST(N)P site, followed by thousands of cancers.

Appendix A

1 Comment 48-1: The [LRA] is inadequate because it: (a) fails to adequately address the
2 applicant's capacity to deal with fires and explosions that cause a loss of large areas of the
3 plant—the mitigative strategies for addressing fires and explosions are inadequate to address
4 the consequences of events such as the impacts of large commercial aircraft crashing into the
5 reactors or related facilities, (b) fails to describe the means that would be used to determine
6 radiation exposures to fire and explosion responders, and (c) fails to describe the means that
7 would be used to protect fire and explosion responders from excessive radiation exposures

8 **Response:** *These comments provided input (or data) on various aspects of severe accidents*
9 *associated with fire and explosion hazards, ranging from the applicability of results from earlier*
10 *NRC consequence studies (e.g., CRAC) to emergency management operation. The*
11 *evaluations of STPNOC's severe accident analysis are discussed in Section 5.2 of this SEIS.*

12 *The NRC and the global nuclear research and safety community have done extensive research*
13 *over the past three decades evaluating reactor accidents and how they could affect the public.*
14 *Earlier studies (e.g., NUREG/CR-2239, Technical Guidance for Siting Criteria Development,*
15 *commonly referred to as the 1982 Siting Study or CRAC 2 Study) had uncertainties and*
16 *conservatisms and did not include information on current plant design, operation, accident*
17 *management strategies, emergency preparedness procedures, or post-9/11 enhancements to*
18 *mitigative measures. Earlier work was also limited by both computer hardware and software*
19 *available at that time. Researchers attempted to overcome these limitations by simplifying*
20 *some estimates or assumptions concerning possible damage to the reactor core, the possible*
21 *radioactive contamination that could be released, and possible failures of the reactor vessel and*
22 *containment buildings. These efforts led to overestimates in the results, particularly in the*
23 *1982 Siting Study (or CRAC 2 Study) report. This report was meant to assist the NRC staff in*
24 *considering regulations for choosing nuclear power plant locations, but it has been regularly*
25 *misinterpreted and misused as an estimate of accident consequences. Since those early*
26 *studies, information from both NRC and cooperative foreign research has greatly increased our*
27 *understanding of the timing and magnitude of possible radioactive releases from potential*
28 *accidents at nuclear power plants.*

29 *The NRC established a research project in 2006 to update its assessment of severe reactor*
30 *accident scenarios and their potential consequences to human health. This research project,*
31 *titled "State-of-the-Art Reactor Consequence Analyses (SOARCA)," was designed to develop*
32 *best estimates of the public health effects that might result from a radiological release during a*
33 *nuclear power plant accident. The SOARCA project used state-of-the-art computer codes to*
34 *calculate accident progression and offsite consequences for important scenarios at two plants,*
35 *Peach Bottom, a boiling-water reactor (BWR), and Surry, a pressurized-water reactor (PWR).*
36 *These codes have been continuously updated to incorporate decades of experimental research.*
37 *The SOARCA project had cooperation from the licensees of these plants to model them in great*
38 *detail as they exist in their current state and include operator action timelines based on*
39 *plant-specific procedures. The project also modeled the use of additional equipment and*
40 *strategies required by the NRC following the terrorist attacks of September 11, 2001, to further*
41 *improve each plant's capability to mitigate events involving a loss of large areas of the plant*
42 *caused by fire and explosions.*

43 *SOARCA results show that when operators are successful in using available onsite equipment*
44 *during the accidents analyzed in SOARCA, they can either (a) prevent the reactor from melting*
45 *or (b) delay or reduce releases of radioactive material to the environment. Even if operators are*
46 *unsuccessful in stopping the accident, SOARCA shows that the accidents progress more slowly*
47 *and release much smaller amounts of radioactive material than calculated in the 1982 Siting*
48 *Study or CRAC 2 Study. Therefore, public health consequences from severe nuclear reactor*
49 *accident scenarios are smaller than previously calculated. The delayed releases calculated*

1 *provide more time for emergency response actions, such as evacuating or sheltering. All*
 2 *modeled scenarios in SOARCA showed essentially zero early fatalities. In contrast, the*
 3 *1982 Siting Study calculated 92 mean early fatalities for Peach Bottom, 45 for Surry, and*
 4 *6.5¹ (not 18,000)² for STP conditional on the occurrence of a hypothetical large source term*
 5 *being released. In addition, in SOARCA, the calculated individual long-term risks of dying from*
 6 *cancer from exposure to radiation from these accidents are very small—millions of times lower*
 7 *than the general risk of dying from cancer in the U.S. from all causes.*

8 *Because STP and the Surry plant studied in SOARCA are both Westinghouse-designed PWRs*
 9 *with large dry containments, the insights gained from the SOARCA project regarding accident*
 10 *progression and offsite health consequences can generally be applied to the STP site.*

11 *More information regarding the SOARCA project is available on NRC's Web site at*
 12 *<http://www.nrc.gov/about-nrc/regulatory/research/soar.html>.*

13 **A.1.6 Terrestrial or Aquatic Ecology**

14 The original sources for the comments in this category can be found at the back of the Scoping
 15 Summary Report and are labeled with the following identifiers: 18-1, 20-3, 44-2, and 45-7.
 16 These comments are extracted from the original sources.

17 Comment 18-1: I want to touch on two aspects of the review. One is going to be the
 18 environmental aspect. It's very important when you talk about Matagorda County—and I'll do
 19 just a little bit of a commercial—we have a very, very sensitive area in that we have the
 20 freshwater from our Colorado River, two bays, estuaries, as well as the Gulf of Mexico. We are
 21 the North American Christmas bird count winner about [11] out of the last [12] years. It was
 22 foggy one morning, and we missed some of those birds. But, as you see that as we've got such
 23 a great ecological area here the whole time Units 1 and 2 have been operating. So, we're very,
 24 very proud of the fact that the [STPNOC], with Units 1 and 2, continues to operate in a strong
 25 fashion while our environment is protected.

26 Comment 20-3: What should you focus on? Obviously, our environmental concerns are a huge
 27 part of this. I'm [with] the Convention and Visitors Bureau, and one of our main focuses is
 28 bringing tourists down to Matagorda County to see what we have to offer. Good thing one of
 29 our sights to see is STP, as well as all around STP we have tons of fishing, birding, we have
 30 farm lands and everything else, and from what I've seen, there have been no concerns with
 31 those at all, as I grew up fishing right below STP on the Colorado River. And, I would like to
 32 thank STP for providing that to me, providing the safe waters and the safe grounds for me to do
 33 that on.

34 Comment 44-2: In addition, the existing South Texas units need to be evaluated to see if they
 35 will need to be modified to meet the newly proposed cooling water requirements that the [EPA]
 36 announced this week.

37 Comment 45-7: We are concerned about increasing tritium levels in wells [on site] and in the
 38 Colorado River. Extensive testing should occur for all organisms in the region, and exposure of
 39 whooping cranes to tritium and other radionuclides should be examined since they are an
 40 endangered species and their winter grounds are only 35 miles from the STP site.

¹ The 1982 Siting Study calculated 5.2 mean early fatalities for STP for the SST1 source term. This value is based upon a standard 1,120 MWe PWR. When corrected for the actual electrical output (1410 MWe), the result is 6.5 mean early fatalities.

² The 1982 Siting Study calculated 18,000 early fatalities as the 99th percentile value conditional upon the SST1 source term release, assuming New York City meteorology and Indian Point population and wind rose as well as no evacuation. This was included as a sensitivity to show the effect of evacuation distance on early fatalities and was not meant to be a realistic estimate of the offsite health consequences of a severe nuclear reactor accident.

Appendix A

1 **Response:**

2 *These comments provided input (or data) for the staff's environmental analysis of the ecology*
3 *impacts of STP. The staff discusses these impacts in Sections 2.2.6, 2.2.7, 4.5, 4.6, 4.8, 8.1.4,*
4 *8.1.5, 8.2.4, 8.2.5, 8.3.4, 8.3.5, 8.4.4, 8.4.5, 8.5.3, 8.7.4, and 8.7.5 of this SEIS.*

5 **A.1.7 Uranium Fuel Cycle and Waste Management**

6 The original sources for the comments in this category can be found at the back of the Scoping
7 Summary Report and are labeled with the following identifiers: 29-5, 32-4, 33-2, 34-1, 36-2,
8 37-4, 39-5, 43-2, 45-5, 46-2, 47-3, 49-3, 51-4, 53-4, 54-4, 55-4, 59-4, 61-4, 62-5, 63-3, 64-2,
9 69-4, 71-3, 75-3, 77-3, 79-3, 80-5. These comments are extracted from the original sources. In
10 summary, these comments express concerns about transportation of radioactive materials,
11 long-term stewardship of nuclear waste, and uranium mining.

12 Comment 29-5: Whose backyard is the waste being transported through? [In] whose backyard
13 is the waste being dumped?

14 Comment 32-4: Lastly, there is no way this can be justified as a result of the lack of safe
15 storage for thousands and thousands of years of the nuclear waste. Please reject the renewal
16 applications. The danger to our citizens is too great.

17 Comment 33-2: Uranium mining is a health issue. Nuclear waste remains a serious threat to
18 future generations as well as the current population.

19 Comment 34-1: Please do not approve the licensing. Nuclear waste is too dangerous.

20 Comment 36-2: I also know, from following WCS in Andrews, Texas, that there is no safe
21 disposal for LLRW [low-level radioactive waste], and still no safe disposal for the high-level
22 waste fuel rods such as are melting in Japan today.

23 Comment 37-4: There is no adequate solution for radioactive waste, so it makes sense to stop
24 generating more.

25 Comment 39-5: There is no adequate solution for radioactive waste, so it makes sense to stop
26 generating more.

27 Comment 43-2: As we have seen in the last few weeks, nuclear energy is not as safe as made
28 out to be, and there are too many problems with disposal that have not been solved.

29 Comment 45-5: It is time to stop generating more radioactive waste since there is no safe
30 storage and disposal solution, even after attempts have been made for some [60] years.
31 Relicensing would the creation of waste. There may not be enough room for even the so-called
32 [LLRW] at the planned West Texas radioactive waste dump, since there is an attempt to allow
33 Out of Compact waste[,] and the volume and curies limits may be reached long before all STP
34 waste could be shipped. There is still no "high-level" repository for spent fuel rods.

35 Comment 46-2: I'm opposed to their continuation for all the usual reasons that any kind of
36 accident and even a Category 4 or 5 hurricane-induced storm surge could remove external
37 supports such as cooling ponds or water access (and who knows what hammering debris-laden
38 waves on top of the storm surge could do), plus disposal of nuclear waste—no human
39 technology is foolproof and totally isolated for thousands of years!

40 Comment 47-3: At the most fundamental level[,] we cannot justify generating more radioactive
41 waste when there is no adequate solution for dealing with it.

42 Comment 49-3: Every nuclear power plant is a potential disaster waiting to happen[,] and every
43 nuclear power plant is a long-term disaster by the toxic waste they generate.

- 1 Comment 51-4: There is no adequate solution for radioactive waste, so it makes no sense to
2 continue generating more.
- 3 Comment 53-4: There is no adequate solution for radioactive waste[,] so it makes no sense to
4 continue generating more.
- 5 Comment 54-4: There is no adequate solution for radioactive waste, so it makes no sense to
6 continue generating more.
- 7 Comment 55-4: [T]here is no adequate solution for radioactive waste, so it makes no sense to
8 continue generating more.
- 9 Comment 59-4: Until there is an adequate solution for radioactive waste, we should not
10 continue to generate more.
- 11 Comment 61-4: There is no adequate solution for radioactive waste, so it makes no sense to
12 continue generating more.
- 13 Comment 62-5: There is no adequate solution for radioactive waste, so it makes no sense to
14 continue generating more.
- 15 Comment 63-3: What about waste? Radioactive waste is terrible to contend with.
- 16 Comment 64-2: Too much water is wasted! Way too much [water] daily to cool it!
17 These [...] dangerous radioactive waste! Is not safe. What are you going to do with the
18 radioactive waste?
- 19 Comment 69-4: There is no adequate solution for radioactive waste, so it makes no sense to
20 continue generating more.
- 21 Comment 71-3: There is no solution for the disposal of radioactive waste, so it makes no sense
22 to continue generating more.
- 23 Comment 75-3: There is no adequate solution for radioactive waste, so it makes no sense to
24 continue generating more.
- 25 Comment 77-3: Radioactive waste is and will continue to be a big problem[,] so why would we
26 go in that direction. Leadership and creating thinking is needed at this moment in history.
27 Please be part of solving problems and not adding new problems.
- 28 Comment 79-3: There is no adequate solution for radioactive waste, so it makes no sense to
29 continue generating more.
- 30 Comment 80-5: There is no adequate solution for radioactive waste, so it makes no sense to
31 continue generating more.
- 32 **Response:** *These comments raise concerns about the uranium fuel cycle and waste*
33 *management. The staff addresses the environmental impacts of the uranium fuel cycle and*
34 *waste management in Chapter 6 of this SEIS.*

APPENDIX B
NATIONAL ENVIRONMENTAL POLICY ACT ISSUES FOR LICENSE
RENEWAL OF NUCLEAR POWER PLANTS

1 **NATIONAL ENVIRONMENTAL POLICY ACT ISSUES FOR LICENSE**
 2 **RENEWAL OF NUCLEAR POWER PLANTS**

3 The table in this appendix summarizes the National Environmental Policy Act (NEPA) issues for
 4 license renewal of nuclear power plants identified in Table B–1 in Appendix B, Subpart A, to
 5 Title 10 Part 51 of the *Code of Federal Regulations* (10 CFR Part 51). Data supporting this
 6 table are contained in NUREG-1437, *Generic Environmental Impact Statement for License*
 7 *Renewal of Nuclear Plants*. Throughout this supplemental environmental impact statement
 8 (SEIS), “generic” issues are also referred to as Category 1 issues, and “site-specific” issues are
 9 also referred to as Category 2 issues.

10 **Table B–1. Summary of Issues and Findings**

Issue	Type of Issue	Finding
Surface Water Quality, Hydrology, and Use		
Impacts of refurbishment on surface water quality	Generic	SMALL. Impacts are expected to be negligible during refurbishment because best management practices are expected to be employed to control soil erosion and spills.
Impacts of refurbishment on surface water use	Generic	SMALL. Water use during refurbishment will not increase appreciably or will be reduced during plant outage.
Altered current patterns at intake and discharge structures	Generic	SMALL. Altered current patterns have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Altered salinity gradients	Generic	SMALL. Salinity gradients have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Altered thermal stratification of lakes	Generic	SMALL. Generally, lake stratification has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Temperature effects on sediment transport capacity	Generic	SMALL. These effects have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Scouring caused by discharged cooling water	Generic	SMALL. Scouring has not been found to be a problem at most operating nuclear power plants and has caused only localized effects at a few plants. It is not expected to be a problem during the license renewal term.
Eutrophication	Generic	SMALL. Eutrophication has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Discharge of chlorine or other biocides	Generic	SMALL. Effects are not a concern among regulatory and resource agencies, and are not expected to be a problem during the license renewal term.

Appendix B

Issue	Type of Issue	Finding
Discharge of sanitary wastes and minor chemical spills	Generic	SMALL. Effects are readily controlled through National Pollutant Discharge Elimination System (NPDES) permit and periodic modifications, if needed, and are not expected to be a problem during the license renewal term.
Discharge of other metals in wastewater	Generic	SMALL. These discharges have not been found to be a problem at operating nuclear power plants with cooling-tower-based heat-dissipation systems and have been satisfactorily mitigated at other plants. They are not expected to be a problem during the license renewal term.
Water use conflicts (plants with once-through cooling systems)	Generic	SMALL. These conflicts have not been found to be a problem at operating nuclear power plants with once-through heat-dissipation systems.
Water use conflicts (plants with cooling ponds or cooling towers using makeup water from a small river with low flow)	Site-specific	SMALL OR MODERATE. The issue has been a concern at nuclear power plants with cooling ponds and at plants with cooling towers. Impacts on instream and riparian communities near these plants could be of moderate significance in some situations. See §51.53(c)(3)(ii)(A).
Aquatic Ecology		
Refurbishment	Generic	SMALL. During plant shutdown and refurbishment, there will be negligible effects on aquatic biota because of a reduction of entrainment and impingement of organisms or a reduced release of chemicals.
Accumulation of contaminants in sediments or biota	Generic	SMALL. Accumulation of contaminants has been a concern at a few nuclear power plants but has been satisfactorily mitigated by replacing copper alloy condenser tubes with those of another metal. It is not expected to be a problem during the license renewal term.
Entrainment of phytoplankton and zooplankton	Generic	SMALL. Entrainment of phytoplankton and zooplankton has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.
Cold shock	Generic	SMALL. Cold shock has been satisfactorily mitigated at operating nuclear plants with once-through cooling systems, has not endangered fish populations, or been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds, and is not expected to be a problem during the license renewal term.
Thermal plume barrier to migrating fish	Generic	SMALL. Thermal plumes have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Distribution of aquatic organisms	Generic	SMALL. Thermal discharge may have localized effects but is not expected to affect the larger geographical distribution of aquatic organisms.
Premature emergence of aquatic insects	Generic	SMALL. Premature emergence has been found to be a localized effect at some operating nuclear power plants but has not been a problem and is not expected to be a problem during the license renewal term.

Issue	Type of Issue	Finding
Gas supersaturation (gas bubble disease)	Generic	SMALL. Gas supersaturation was a concern at a small number of operating nuclear power plants with once-through cooling systems but has been satisfactorily mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.
Low dissolved oxygen in the discharge	Generic	SMALL. Low dissolved oxygen has been a concern at one nuclear power plant with a once-through cooling system but has been effectively mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	Generic	SMALL. These types of losses have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Stimulation of nuisance organisms (e.g., shipworms)	Generic	SMALL. Stimulation of nuisance organisms has been satisfactorily mitigated at the single nuclear power plant with a once-through cooling system where previously it was a problem. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.
Aquatic Ecology (for Plants with Once-Through and Cooling-Pond Heat-Dissipation Systems)		
Entrainment of fish and shellfish in early life stages	Site-specific	SMALL, MODERATE, OR LARGE. The impacts of entrainment are small at many plants but may be moderate or even large at a few plants with once-through and cooling-pond cooling systems. Further, ongoing efforts in the vicinity of these plants to restore fish populations may increase the numbers of fish susceptible to intake effects during the license renewal period, such that entrainment studies conducted in support of the original license may no longer be valid. See §51.53(c)(3)(ii)(B).
Impingement of fish and shellfish	Site-specific	SMALL, MODERATE, OR LARGE. The impacts of impingement are small at many plants but may be moderate or even large at a few plants with once-through and cooling-pond cooling systems. See §51.53(c)(3)(ii)(B).
Heat shock	Site-specific	SMALL, MODERATE, OR LARGE. Because of continuing concerns about heat shock and the possible need to modify thermal discharges in response to changing environmental conditions, the impacts may be of moderate or large significance at some plants. See §51.53(c)(3)(ii)(B).
Aquatic Ecology (for Plants with Cooling-Tower-Based Heat-Dissipation Systems)		
Entrainment of fish and shellfish in early life stages	Generic	SMALL. Entrainment of fish has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Impingement of fish and shellfish	Generic	SMALL. The impingement has not been found to be a problem at operating nuclear power plants with this type of cooling system and is

Appendix B

Issue	Type of Issue	Finding
		not expected to be a problem during the license renewal term.
Heat shock	Generic	SMALL. Heat shock has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.
Groundwater Use and Quality		
Impacts of refurbishment on groundwater use and quality	Generic	SMALL. Extensive dewatering during the original construction on some sites will not be repeated during refurbishment on any sites. Any plant wastes produced during refurbishment will be handled in the same manner as in current operating practices and are not expected to be a problem during the license renewal term.
Groundwater use conflicts (potable and service water; plants that use <100 gallons per minute (gpm))	Generic	SMALL. Plants using less than 100 gpm are not expected to cause any groundwater use conflicts.
Groundwater use conflicts (potable and service water, and dewatering plants that use >100 gpm)	Site-specific	SMALL, MODERATE, OR LARGE. Plants that use more than 100 gpm may cause groundwater use conflicts with nearby groundwater users. See §51.53(c)(3)(ii)(C).
Groundwater use conflicts (plants using cooling towers withdrawing makeup water from a small river)	Site-specific	SMALL, MODERATE, OR LARGE. Water use conflicts may result from surface water withdrawals from small water bodies during low flow conditions which may affect aquifer recharge, especially if other groundwater or upstream surface water users come online before the time of license renewal. See §51.53(c)(3)(ii)(A).
Groundwater use conflicts (Ranney wells)	Site-specific	SMALL, MODERATE, OR LARGE. Ranney wells can result in potential groundwater depression beyond the site boundary. Impacts of large groundwater withdrawal for cooling tower makeup at nuclear power plants using Ranney wells must be evaluated at the time of application for license renewal. See §51.53(c)(3)(ii)(C).
Groundwater quality degradation (Ranney wells)	Generic	SMALL. Groundwater quality at river sites may be degraded by induced infiltration of poor-quality river water into an aquifer that supplies large quantities of reactor cooling water. However, the lower quality infiltrating water would not preclude the current uses of groundwater and is not expected to be a problem during the license renewal term.
Groundwater quality degradation (saltwater intrusion)	Generic	SMALL. Nuclear power plants do not contribute significantly to saltwater intrusion.
Groundwater quality degradation (cooling ponds in salt marshes)	Generic	SMALL. Sites with closed-cycle cooling ponds may degrade groundwater quality. Because water in salt marshes is brackish, this is not a concern for plants located in salt marshes.

Issue	Type of Issue	Finding
Groundwater quality degradation (cooling ponds at inland sites)	Site-specific	SMALL, MODERATE, OR LARGE. Sites with closed-cycle cooling ponds may degrade groundwater quality. For plants located inland, the quality of the groundwater in the vicinity of the ponds must be shown to be adequate to allow continuation of current uses. See §51.53(c)(3)(ii)(D).
Terrestrial Ecology		
Refurbishment impacts	Site-specific	SMALL, MODERATE, OR LARGE. Refurbishment impacts are insignificant if no loss of important plant and animal habitat occurs. However, it cannot be known whether important plant and animal communities may be affected until the specific proposal is presented with the license renewal application. See §51.53(c)(3)(ii)(E).
Cooling tower impacts on crops and ornamental vegetation	Generic	SMALL. Impacts from salt drift, icing, fogging, or increased humidity associated with cooling tower operation have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Cooling tower impacts on native plants	Generic	SMALL. Impacts from salt drift, icing, fogging, or increased humidity associated with cooling tower operation have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Bird collisions with cooling towers	Generic	SMALL. These collisions have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.
Cooling pond impacts on terrestrial resources	Generic	SMALL. Impacts of cooling ponds on terrestrial ecological resources are considered to be of small significance at all sites.
Powerline right-of-way (ROW) management (cutting and herbicide application)	Generic	SMALL. The impacts of ROW maintenance on wildlife are expected to be of small significance at all sites.
Bird collisions with powerlines	Generic	SMALL. Impacts are expected to be of small significance at all sites.
Impacts of electromagnetic fields on flora and fauna	Generic	SMALL. No significant impacts of electromagnetic fields on terrestrial flora and fauna have been identified. Such effects are not expected to be a problem during the license renewal term.
Floodplains and wetland on powerline ROW	Generic	SMALL. Periodic vegetation control is necessary in forested wetlands underneath powerlines and can be achieved with minimal damage to the wetland. No significant impact is expected at any nuclear power plant during the license renewal term.
Threatened and Endangered Species		
Threatened or endangered species	Site-specific	SMALL, MODERATE, OR LARGE. Generally, plant refurbishment and continued operation are not expected to adversely affect threatened or endangered species. However, consultation with appropriate agencies would be needed at the time of license renewal

Appendix B

Issue	Type of Issue	Finding
		to determine whether or not threatened or endangered species are present and whether or not they would be adversely affected. See §51.53(c)(3)(ii)(E).
Air quality		
Air quality during refurbishment (non-attainment and maintenance areas)	Site-specific	SMALL, MODERATE, OR LARGE. Air quality impacts from plant refurbishment associated with license renewal are expected to be small. However, vehicle exhaust emissions could be cause for concern at locations in or near non-attainment or maintenance areas. The significance of the potential impact cannot be determined without considering the compliance status of each site and the number of workers expected to be employed during the outage. See §51.53(c)(3)(ii)(F).
Air quality effects of transmission lines	Generic	SMALL. Production of ozone and oxides of nitrogen is insignificant and does not contribute measurably to ambient levels of these gases.
Land Use		
Onsite land use	Generic	SMALL. Projected onsite land use changes required during refurbishment and the renewal period would be a small fraction of any nuclear power plant site and would involve land that is controlled by the applicant.
Powerline ROW	Generic	SMALL. Ongoing use of powerline ROWs would continue with no change in restrictions. The effects of these restrictions are of small significance.
Human Health		
Radiation exposures to the public during refurbishment	Generic	SMALL. During refurbishment, the gaseous effluents would result in doses that are similar to those from current operation. Applicable regulatory dose limits to the public are not expected to be exceeded.
Occupational radiation exposures during refurbishment	Generic	SMALL. Occupational doses from refurbishment are expected to be within the range of annual average collective doses experienced for pressurized-water reactors and boiling-water reactors. Occupational mortality risk from all causes including radiation is in the mid-range for industrial settings.
Microbiological organisms (occupational health)	Generic	SMALL. Occupational health impacts are expected to be controlled by continued application of accepted industrial hygiene practices to minimize exposure to workers.
Microbiological organisms (public health) (plants using lakes or canals, or cooling towers or cooling ponds that discharge to a small river)	Site-specific	SMALL, MODERATE, OR LARGE. These organisms are not expected to be a problem at most operating plants except possibly at plants using cooling ponds, lakes, or canals that discharge to small rivers. Without site-specific data, it is not possible to predict the effects generically. See §51.53(c)(3)(ii)(G).

Issue	Type of Issue	Finding
Noise	Generic	SMALL. Noise has not been found to be a problem at operating plants and is not expected to be a problem at any plant during the license renewal term.
Electromagnetic fields—acute effects (electric shock)	Site-specific	SMALL, MODERATE, OR LARGE. Electrical shock resulting from direct access to energized conductors or from induced charges in metallic structures have not been found to be a problem at most operating plants and generally are not expected to be a problem during the license renewal term. However, site-specific review is required to determine the significance of the electric shock potential at the site. See §51.53(c)(3)(ii)(H).
Electromagnetic fields—chronic effects	Uncategorized	UNCERTAIN. Biological and physical studies of 60-hertz electromagnetic fields have not found consistent evidence linking harmful effects with field exposures. However, research is continuing in this area and a consensus scientific view has not been reached.
Radiation exposures to public (license renewal term)	Generic	SMALL. Radiation doses to the public will continue at current levels associated with normal operations.
Occupational radiation exposures (license renewal term)	Generic	SMALL. Projected maximum occupational doses during the license renewal term are within the range of doses experienced during normal operations and normal maintenance outages, and would be well below regulatory limits.
Socioeconomic Impacts		
Housing impacts	Site-specific	SMALL, MODERATE, OR LARGE. Housing impacts are expected to be of small significance at plants located in a medium or high population area and not in an area where growth control measures that limit housing development are in effect. Moderate or large housing impacts of the workforce associated with refurbishment may be associated with plants located in sparsely populated areas or in areas with growth control measures that limit housing development. See §51.53(c)(3)(ii)(I).
Public services: public safety, social services, and tourism and recreation	Generic	SMALL. Impacts to public safety, social services, and tourism and recreation are expected to be of small significance at all sites.
Public services: public utilities	Site-specific	SMALL OR MODERATE. An increased problem with water shortages at some sites may lead to impacts of moderate significance on public water supply availability. See §51.53(c)(3)(ii)(I).
Public services: education (refurbishment)	Site-specific	SMALL, MODERATE, OR LARGE. Most sites would experience impacts of small significance but larger impacts are possible depending on site- and project-specific factors. See §51.53(c)(3)(ii)(I).
Public services: education (license renewal term)	Generic	SMALL. Only impacts of small significance are expected.
Offsite land use (refurbishment)	Site-specific	SMALL OR MODERATE. Impacts may be of moderate significance at plants in low population areas. See §51.53(c)(3)(ii)(I).

Appendix B

Issue	Type of Issue	Finding
Offsite land use (license renewal term)	Site-specific	SMALL, MODERATE, OR LARGE. Significant changes in land use may be associated with population and tax revenue changes resulting from license renewal. See §51.53(c)(3)(ii)(I).
Public services: transportation	Site-specific	SMALL, MODERATE, OR LARGE. Transportation impacts (level of service) of highway traffic generated during plant refurbishment and during the term of the renewed license are generally expected to be of small significance. However, the increase in traffic associated with the additional workers and the local road and traffic control conditions may lead to impacts of moderate or large significance at some sites. See §51.53(c)(3)(ii)(J).
Historic and archaeological resources	Site-specific	SMALL, MODERATE, OR LARGE. Generally, plant refurbishment and continued operation are expected to have no more than small adverse impacts on historic and archaeological resources. However, the National Historic Preservation Act requires the Federal agency to consult with the State Historic Preservation Officer to determine whether or not there are properties present that require protection. See §51.53(c)(3)(ii)(K).
Aesthetic impacts (refurbishment)	Generic	SMALL. No significant impacts are expected during refurbishment.
Aesthetic impacts (license renewal term)	Generic	SMALL. No significant impacts are expected during the license renewal term.
Aesthetic impacts of transmission lines (license renewal term)	Generic	SMALL. No significant impacts are expected during the license renewal term.
Postulated Accidents		
Design basis accidents	Generic	SMALL. The staff has concluded that the environmental impacts of design-basis accidents are of small significance for all plants.
Severe accidents	Site-specific	SMALL. The probability weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to groundwater, and societal and economic impacts from severe accidents are small for all plants. However, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives. See §51.53(c)(3)(ii)(L).
Uranium Fuel Cycle and Waste Management		
Offsite radiological impacts (individual effects from other than the disposal of spent fuel and high-level waste)	Generic	SMALL. Offsite impacts of the uranium fuel cycle have been considered by the Commission in Table S-3 of this part. Based on information in the GEIS, impacts on individuals from radioactive gaseous and liquid releases including radon-222 and technetium-99 are small.
Offsite radiological impacts (collective effects)	Generic	The 100-year environmental dose commitment to the U.S. population from the fuel cycle, high-level waste, and spent fuel disposal excepted, is calculated to be about 14,800 person rem, or 12 cancer fatalities, for each additional 20-year power reactor operating term. Much of this, especially the contribution of radon releases from mines and tailing piles, consists of tiny doses summed over large

Issue	Type of Issue	Finding
		<p>populations. This same dose calculation can theoretically be extended to include many tiny doses over additional thousands of years as well as doses outside the United States. The result of such a calculation would be thousands of cancer fatalities from the fuel cycle, but this result assumes that even tiny doses have some statistical adverse health effect which will not ever be mitigated (for example no cancer cure in the next thousand years), and that these doses projected over thousands of years are meaningful; however, these assumptions are questionable. In particular, science cannot rule out the possibility that there will be no cancer fatalities from these tiny doses. For perspective, the doses are very small fractions of regulatory limits, and even smaller fractions of natural background exposure to the same populations.</p> <p>Nevertheless, despite all the uncertainty, some judgment as to the regulatory NEPA implications of these matters should be made and it makes no sense to repeat the same judgment in every case. Even taking the uncertainties into account, the Commission concludes that these impacts are acceptable in that these impacts would not be sufficiently large to require the NEPA conclusion, for any plant, that the option of extended operation under 10 CFR Part 54 should be eliminated. Accordingly, while the Commission has not assigned a single level of significance for the collective effects of the fuel cycle, this issue is considered Category 1 (Generic).</p>
Offsite radiological impacts (spent fuel and high-level waste disposal)	Generic	Chapter 6 of this SEIS provides further discussion of these impacts.
Nonradiological impacts of the uranium fuel cycle	Generic	SMALL. The nonradiological impacts of the uranium fuel cycle resulting from the renewal of an operating license for any plant are found to be small.
Low-level waste storage and disposal	Generic	<p>SMALL. The comprehensive regulatory controls that are in place and the low public doses being achieved at reactors ensure that the radiological impacts to the environment will remain small during the term of a renewed license. The maximum additional onsite land that may be required for low-level waste storage during the term of a renewed license and associated impacts will be small.</p> <p>Nonradiological impacts on air and water will be negligible. The radiological and nonradiological environmental impacts of long-term disposal of low-level waste from any individual plant at licensed sites are small. In addition, the Commission concludes that there is reasonable assurance that sufficient low-level waste disposal capacity will be made available when needed for facilities to be decommissioned consistent with NRC decommissioning requirements.</p>
Mixed waste storage and disposal	Generic	SMALL. The comprehensive regulatory controls and the facilities and procedures that are in place ensure proper handling and storage, as well as negligible doses and exposure to toxic materials for the public and the environment at all plants. License renewal will not increase the small, continuing risk to human health and the environment posed by mixed waste at all plants. The radiological and nonradiological environmental impacts of long-term disposal of mixed waste from any individual plant at licensed sites are small. In addition, the

Appendix B

Issue	Type of Issue	Finding
		Commission concludes that there is reasonable assurance that sufficient mixed waste disposal capacity will be made available when needed for facilities to be decommissioned consistent with NRC decommissioning requirements.
Onsite spent fuel	Generic	SMALL. The expected increase in the volume of spent fuel from an additional 20 years of operation can be safely accommodated on site with small environmental effects through dry or pool storage at all plants if a permanent repository or monitored retrievable storage is not available.
Nonradiological waste	Generic	SMALL. No changes to generating systems are anticipated for license renewal. Facilities and procedures are in place to ensure continued proper handling and disposal at all plants.
Transportation	Generic	SMALL. The impacts of transporting spent fuel enriched up to 5 percent uranium-235 with average burnup for the peak rod to current levels approved by NRC up to 62,000 megawatt days per metric-ton uranium and the cumulative impacts of transporting high-level waste to a single repository, such as Yucca Mountain, Nevada are found to be consistent with the impact values contained in 10 CFR 51.52(c), Summary Table S-4, "Environmental Impact of Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor." If fuel enrichment or burnup conditions are not met, the applicant must submit an assessment of the implications for the environmental impact values reported in §51.52.
Decommissioning		
Radiation doses	Generic	SMALL. Doses to the public will be well below applicable regulatory standards regardless of which decommissioning method is used. Occupational doses would increase no more than 1 man-rem caused by buildup of long-lived radionuclides during the license renewal term.
Waste management	Generic	SMALL. Decommissioning at the end of a 20-year license renewal period would generate no more solid wastes than at the end of the current license term. No increase in the quantities of Class C or greater than Class C wastes would be expected.
Air quality	Generic	SMALL. Air quality impacts of decommissioning are expected to be negligible either at the end of the current operating term or at the end of the license renewal term.
Water quality	Generic	SMALL. The potential for significant water quality impacts from erosion or spills is no greater whether decommissioning occurs after a 20-year license renewal period or after the original 40-year operation period, and measures are readily available to avoid such impacts.
Ecological resources	Generic	SMALL. Decommissioning after either the initial operating period or after a 20-year license renewal period is not expected to have any direct ecological impacts.
Socioeconomic impacts	Generic	SMALL. Decommissioning would have some short-term socioeconomic impacts. The impacts would not be increased by delaying decommissioning until the end of a 20-year relicense period, but they might be decreased by population and economic growth.

Issue	Type of Issue	Finding
Environmental Justice		
Environmental justice	Uncategorized	NONE. The need for and the content of an analysis of environmental justice will be addressed in plant-specific reviews.

Table source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

APPENDIX C
APPLICABLE REGULATIONS, LAWS, AND AGREEMENTS

1 **APPLICABLE REGULATIONS, LAWS, AND AGREEMENTS**

2 The Atomic Energy Act (AEA) authorizes the U.S. Nuclear Regulatory Commission (NRC) to
3 enter into agreement with any state to assume regulatory authority for certain activities. For
4 example, in accordance with Section 274 of the AEA, as amended, beginning on March 1, 1963,
5 the State of Texas assumed regulatory responsibility over the following nuclear material usages:

- 6 • byproduct materials as defined in Section 11e.(1) of the Act,
- 7 • byproduct materials as defined in Section 11e.(2) of the Act,
- 8 • source materials, and
- 9 • special nuclear materials in quantities not sufficient to form a critical mass.

10 The Texas Department of State Health Services–Radiation Program administers the Texas
11 Agreement State Program.

12 In addition to implementing some Federal programs, state legislatures develop state laws, which
13 are subject to applicable Federal statutes and regulations. State laws supplement, as well as
14 implement, Federal laws for protection of air, water quality, and groundwater. State legislation
15 may address solid waste management programs, locally rare or endangered species, and
16 historic and cultural resources.

17 The Clean Water Act (CWA) allows for primary enforcement and administration through state
18 agencies, provided the state program is at least as stringent as the Federal program. The state
19 program must conform to the CWA and to the delegation of authority for the Federal National
20 Pollutant Discharge Elimination System (NPDES) Program from the U.S. Environmental
21 Protection Agency (EPA) to the state. In accordance with the CWA, for surface water, the
22 primary mechanism to control water pollution is the requirement that directs dischargers
23 (e.g., point source dischargers) to obtain an NPDES permit or, in the case of states where the
24 authority has been delegated from EPA, a State Pollutant Discharge Elimination System
25 (SPDES) permit.

26 **C.1 Federal and State Environmental Requirements**

27 Certain environmental requirements may have been delegated to state authorities for
28 implementation, enforcement, or oversight by the applicable Federal agencies in exercising the
29 agencies’ regulations. Table C–1 provides a list of STP licenses and permits needed for
30 compliance with the major requirements of the Texas environmental laws that affect the license
31 renewal of South Texas Project (STP). These licenses and permits are addressed in this
32 supplemental environmental impact statement (SEIS), pursuant to the NRC ESRP, Section 1.3,
33 “Compliance and Consultations.”

34 **Table C–1. Licenses and Permits.**

Permit	Number	Dates	Responsible Agency
License to operate STP, Unit 1	NPF-76	Issued: 3/22/1988 Expires: 8/20/2027	NRC
License to operate STP, Unit 2	NPF-80	Issued: 12/16/1988 Expires: 12/15/2028	NRC

Appendix C

Permit	Number	Dates	Responsible Agency
Hazardous materials shipments registration	0622110 550 067S	Issued: 6/29/2011 Expires: 6/30/2012	U.S. Department of Transportation
Permits for maintenance, dredging (barge slip)	10570	Issued: 11/4/2004 Expires: 12/31/2014	U.S. Army Corps of Engineers (USACE)
Permits for maintenance, dredging (intake)	SWG-1992-02707	Issued: 7/21/2009 Expires: 12/31/2019	USACE
Texas Pollutant Discharge Elimination System Permit	WQ0001908000	Issued: 4/5/2012 Expires: 12/1/2014	TCEQ
Air Permit (auxiliary boilers)	7410	Issued: 12/23/2004 Expires: 12/23/2014	TCEQ
Air Permit (emission sources)	0801	Issued: 1/18/2011 Expires: 1/18/2016	TCEQ
Registration of Industrial and Hazardous Waste	30651, EPA ID No. TXD020810503	Issued: 8/16/1976 Expires: Not applicable	TCEQ
Potable Water System	Texas Commission on Environmental Quality (TCEQ) ID No. 1610103/1610051	Issued: Not applicable Expires: Not applicable	TCEQ

Source: STP License Renewal Application (STPNOC 2010).

1 **C.2 References**

2 Several operating permit applications may be prepared and submitted. Regulatory approval or
 3 permits or both would be received prior to license renewal approval by the NRC. As a
 4 convenient source of references of environmental requirements, Table C–2 lists representative
 5 Federal, state, and local approvals by the responsible agencies applicable to license renewal.

6 **Table C–2. Federal, State, and Local Laws and Other Requirements.**

7 *STP is subject to other requirements regarding various aspects of their environmental program.*
 8 *Representatives of those requirements are briefly described below.*

License, Permit, or Other Required Approval (or Submittal)	Responsible Agency	Authority	Relevance
Air Quality Protection			
Required for sources that are not exempt and are major sources, affected sources subject to the Acid Rain Program, sources subject to new source performance standards, or sources subject to National Emission Standards for Hazardous Air Pollutants	U.S. EPA or TCEQ	Texas Air Pollution Control Regulation—TX Administrative Code, Title 30	Nuclear Power plants are subject to 40 CFR Part 61, Subpart H, “National Emissions Standards for Emissions of Radionuclides,” which is included in the terms and conditions of the Title V Operating Permit.

License, Permit, or Other Required Approval (or Submittal)	Responsible Agency	Authority	Relevance
Water Resources Protection			
NPDES Permit—Construction Site Stormwater—required before making point source discharges of storm water from a construction project that disturbs more than 2 ha (5 ac) of land	U.S. EPA or TCEQ	CWA (33 USC 1251 et seq.); 40 CFR Part 122	Any plant refurbishment involving construction of more than 2 ha (5 ac) of land would require a Stormwater Pollution Prevention Plan and Construction Site Storm Water Discharge Permit.
NPDES Permit—Industrial Facility Stormwater—required before making point source discharges of storm water from an industrial site	U.S. EPA or TCEQ	CWA (33 USC 1251 et seq.); 40 CFR Part 122	Stormwater would be discharged from the nuclear power plants during operations. Stormwater would discharge through existing outfalls covered by a permit.
NPDES Permit—Process Water Discharge—required before making point source discharges of industrial process wastewater	U.S. EPA or TCEQ	CWA (33 USC 1251 et seq.); 40 CFR Part 122	Processed industrial wastewater would be discharged through existing outfalls covered by the permit.
Spill Prevention Control and Countermeasures Plan—required for any facility that could discharge diesel fuel in harmful quantities into navigable waters or onto adjoining shorelines	U.S. EPA or TCEQ	CWA (33 USC 1251 et seq.); 40 CFR Part 112	A Spill Prevention Control and Countermeasures Plan is required at nuclear power plants storing large volumes of diesel fuel or other petroleum products or both.
CWA, Section 401, Water Quality Certification—required to be submitted to the agency responsible for issuing any Federal license or permit to conduct an activity that may result in a discharge of pollutants into waters of a state	U.S. EPA or TCEQ	CWA, Section 401 (33 USC 1341);	Certification for operation of a nuclear power plant may require a Federal license or permit (e.g., a CWA, Section 404, Permit or a CWA, Section 401, Water Quality Certification).
New Underground Storage Tanks System Registration—required within 30 days of bringing a new underground storage tank system into service	U.S. EPA or TCEQ	Resources Conservation and Recovery Act (RCRA), as amended, Subtitle I (42 USC 6991a-6991i); 40 CFR §280.22	This registration is required if new underground storage tank systems would be installed during refurbishment at a nuclear power plant.
Above Ground Storage Tank Permit—required to install, remove, repair, or alter any stationary tank for the storage of flammable or combustible liquids	Applicable State Fire Marshal		This permit is required if new above-ground diesel fuel storage tanks would be installed during refurbishment at a nuclear power plant. In accordance with STP ER, there is no refurbishment.
Waste Management & Pollution Prevention			
Registration and Hazardous Waste	U.S. EPA or	RCRA, as	Generators of hazardous waste

Appendix C

License, Permit, or Other Required Approval (or Submittal)	Responsible Agency	Authority	Relevance
Generator Identification Number—required before a person who generates over 100 kg (220 lb) per calendar month of hazardous waste ships the hazardous waste off site	TCEQ	amended (42 USC 6901 et seq.), Subtitle C	must notify EPA that the wastes exist and require management in compliance with RCRA.
Hazardous Waste Facility Permit—required if hazardous waste will undergo nonexempt treatment by the generator; be stored on site for longer than 90 days by the generator of 1,000 kg (2,205 lb) or more of hazardous waste per month; be stored on site for longer than 180 days by the generator of between 100 and 1,000 kg (220 and 2,205 lb) of hazardous waste per month; be disposed of on site; or be received from off site for treatment or disposal	U.S. EPA or TCEQ	RCRA, as amended (42 USC 6901 et seq.), Subtitle C	Hazardous wastes are usually not disposed of on site at nuclear power plants. Hazardous wastes generated on site are not generally stored for more than 90 days. However, should a nuclear power plant store wastes on site for greater than 90 days for characterization, profiling, or scheduling for treatment or disposal, a Hazardous Waste Facility Permit would be required.
Emergency Planning & Response			
List of Material Safety Data Sheets—submission required for hazardous chemicals (as defined in 29 CFR Part 1910) that are stored on site in excess of their threshold quantities	State and local emergency planning agencies (State Emergency Response Commission or SERC)	Emergency Planning and Community Right-to-Know Act of 1986 (EPCRA), Section 311 (42 USC 11021); 40 CFR §370.20	Nuclear power plant operators are required to submit List of Material Safety Data Sheets to state and local emergency planning agencies.
Annual Hazardous Chemical Inventory Report—submission required when hazardous chemicals have been stored at a facility during the preceding year in amounts that exceed threshold quantities	State and local emergency response agencies (SERC); local fire department	EPCRA, Section 312 (42 USC 11022); 40 CFR §370.25	If hazardous chemicals have been stored at a nuclear power plant during the preceding year in amounts that exceed threshold quantities, plant operators would be required to submit an Annual Hazardous Chemical Inventory Report.
Notification of On-Site Storage of an Extremely Hazardous Substance—submission required within 60 days after onsite storage begins of an extremely hazardous substance in a quantity greater than the threshold planning quantity	State and local emergency response agencies (SERC)	EPCRA, Section 304 (42 USC 11004); 40 CFR §355.30	If an extremely hazardous substance stored at a nuclear power plant in a quantity greater than the threshold planning quantity, plant operators would prepare and submit the Notification of On-Site Storage of an Extremely Hazardous Substance.
Annual Toxics Release Inventory Report—required for facilities that have 10 or more full-time	U.S. EPA or TCEQ	EPCRA, Section 313 (42 USC 11023);	If required, nuclear power plant operators would prepare and submit a Toxics Release

License, Permit, or Other Required Approval (or Submittal)	Responsible Agency	Authority	Relevance
employees and are assigned certain standards		40 CFR Part 372	Inventory Report to EPA.
Industrial Classification codes.			
Transportation of Radioactive Wastes and Conversion Products Packaging, Labeling, and Routing Requirements for Radioactive Materials—required for packages containing radioactive materials that will be shipped by truck or rail	U.S. Department of Transportation	Hazardous Material Transportation Act (HMTA) (49 USC 1501 et seq.); AEA, as amended (42 USC 2011 et seq.); 49 CFR Parts 172, 173, 174, 177, and 397	When shipments of radioactive materials are made, nuclear power plant operators would comply with U.S. Department of Transportation packaging, labeling, and routing requirements.
Biotic Resource Protection			
Threatened and Endangered Species Consultation—required between the responsible Federal agencies and affected states to ensure that the project is unlikely to jeopardize the continued existence of any species listed at the Federal or state level as endangered or threatened or result in destruction of critical habitat of such species	U.S. Fish and Wildlife Service (FWS) and other applicable state agencies (listed in Appendix D of this SEIS)	Endangered Species Act of 1973, as amended (16 USC 1531 et seq.)	The NRC would consult with the FWS and state agencies regarding the impact of license renewal on threatened or endangered species or their critical habitat.
CWA, Section 404, (Dredge and Fill) Permit—required to place dredged or fill material into waters of the U.S., including areas designated as wetlands, unless such placement is exempt or authorized by a Nationwide permit or a regional permit (A notice must be filed if a Nationwide or regional permit applies.)	USACE	CWA (33 USC 1251 et seq.); 33 CFR Parts 323 and 330	Any dredging or placement of fill material into wetlands within the jurisdiction of the USACE at a nuclear power plant would require a Section 404 permit.
Cultural Resources Protection			
Archaeological and Historical Resources Consultation—required before a Federal agency approves a project in an area where archaeological or historic resources might be located	State Historic Preservation Officer or Tribal Historic Preservation Officer or both (listed in Appendix D of this SEIS)	National Historic Preservation Act of 1966, as amended (16 USC 470 et seq.); Archaeological and Historical Preservation Act of 1974 (16 USC 469-469c-2); Antiquities Act of	The NRC would consult with the State or Tribal Historic Preservation Officers or both and applicable Indian tribes (e.g., tribes that have historical ties to the land) regarding the impacts of license renewal and the results of archaeological and architectural surveys of nuclear power plant site.

Appendix C

License, Permit, or Other Required Approval (or Submittal)	Responsible Agency	Authority	Relevance
		1906 (16 USC 431 et seq.); Archaeological Resources Protection Act of 1979, as amended (16 USC 470aa-mm)	

1

APPENDIX D
CONSULTATION CORRESPONDENCE

CONSULTATION CORRESPONDENCE

D.1 Background

The Endangered Species Act of 1973, as amended; the Magnuson–Stevens Fisheries Management Act of 1996, as amended; and the National Historic Preservation Act of 1966 (NHPA) require that Federal agencies consult with applicable state and Federal agencies and groups before taking action that may affect threatened or endangered species, essential fish habitat, or historic and archaeological resources, respectively. Table D–1 contains a list of correspondence between the NRC and other agencies in compliance with these Federal acts.

Table D–1. Consultation Correspondence

Author	Recipient	Date of Letter/Email
NRC (B. Pham)	Advisory Council on Historic Preservation (D. Klima)	January 27, 2011 (ML110190591)
NRC (B. Pham)	Tribal Nation—Ysleta del Sur Pueblo (J. Loera)	February 9, 2011 (ML110190385)
NRC (B. Pham)	Tribal Nation—Alabama–Coushatta Tribe (O. Sylestine)	February 9, 2011 (ML110190418)
NRC (B. Pham)	Tribal Nation—Kiowa Tribe of Oklahoma (B. Horse)	February 9, 2011 (ML110390244)
NRC (B. Pham)	Tribal Nation—Comanche Nation (R. Toahty)	February 9, 2011 (ML110390265)
NRC (B. Pham)	U.S. Fish & Wildlife Service (M. Orms)	February 16, 2011 (ML110190429)
NRC (B. Pham)	National Marine Fisheries Service (D. Bernhart)	February 16, 2011 (ML110190434)
NRC (B. Pham)	Texas Parks & Wildlife Department (K. Boydston)	February 16, 2011 (ML110190571)
NRC (B. Pham)	State Historic Preservation Officer (M. Wolfe)	February 17, 2011 (ML110190549)
NRC (B. Pham)	Tribal Nation—Tonkawa Tribe of Oklahoma (A. Street)	February 17, 2011 (ML110390321)
NRC (B. Pham)	Tribal Nation—Apalachicola Band of Creek Indians (M. Blount)	February 17, 2011 (ML110390321)
NRC (B. Pham)	Tribal Nation—Lipan Apache Tribe of Texas (B. Barcena Jr.)	February 17, 2011 (ML110390321)
NRC (B. Pham)	Tribal Nation—Lipan Apache Band of Texas (D. Romero Jr.)	February 17, 2011 (ML110390321)
NRC (B. Pham)	Tribal Nation—Pamaque Clan of Coahuila Y Tejas (J. Mendoza)	February 17, 2011 (ML110390321)
NRC (B. Pham)	Tribal Nation—Tap Pilam-Coahuiltecan Nation (R. Hernandez)	February 17, 2011 (ML110390321)

Appendix D

Author	Recipient	Date of Letter/Email
NRC (B. Pham)	Tribal Nation—Kickapoo Traditional Council (J. Garza Jr.)	February 23, 2011 (ML110240161)
Tribal Nation— Tonkawa Tribe of Oklahoma (M. Allen)	NRC (Chief, Rules, Announcements, & Directives Branch)	February 15, 2011 (ML110490057)
National Marine Fisheries Service (T. Mincey)	NRC (T. Tran)	March 3, 2011 (ML110690848)
Tribal Nation— Apalachicola Band of Creek Indians (M. Blount)	NRC (Chief, Rules, Announcements, & Directives Branch)	March 7, 2011 (ML110750424)
Tribal Nation— Kickapoo Traditional Council (J. Garza Jr.)	NRC (Chief, Rules, Announcements, & Directives Branch)	April 1, 2011 (ML110980503)
Tribal Nation—Tap Pilam—Coahuiltecan Nation (R. Hernandez)	NRC (Chief, Rules, Announcements, & Directives Branch)	April 1, 2011 (ML11111A134)
Texas Parks & Wildlife Department (A. Turner)	NRC (B. Pham)	April 20, 2011 (ML11119A009)
U.S. Fish & Wildlife Service (M. Orms)	NRC (T. Tran)	June 2, 2011 (ML11173A235)
State Historic Preservation Officer (Bill Martin)	NRC (T. Tran)	September 13, 2011 (ML11259A029)
NRC (D. Wrona)	Tribal Nation—Kickapoo Traditional Council (J. Garza Jr.)	November 17, 2011 (ML11269A011)
NRC (D. Wrona)	Tribal Nation— Tonkawa Tribe of Oklahoma (M. Allen)	November 17, 2011 (ML11269A015)
NRC (D. Wrona)	Tribal Nation—Tap Pilam—Coahuiltecan Nation (R. Hernandez)	November 29, 2011 (ML11269A112)
NRC (D. Wrona)	Tribal Nation—Apalachicola Band of Creek Indians (M. Blount)	January 19, 2012 (ML11269A063)

D.2 Consultation Correspondence

The following pages contain copies of the letters listed in Table D–1.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

January 27, 2011

Mr. Don L. Klima, Director
Advisory Council on Historic Preservation
Office of Federal Agency Programs
1100 Pennsylvania Ave, NW, Suite 803
Washington, DC 20004

SUBJECT: SOUTH TEXAS PROJECT, UNITS 1 AND 2, LICENSE RENEWAL
APPLICATION REVIEW

Dear Mr. Klima:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing an application to renew the operating license for South Texas Project (STP), Units 1 and 2, which are located in Matagorda County, Texas. STP is operated by STP Nuclear Operating Company (STPNOC). The application dated October 25, 2010, for renewal was submitted by STPNOC, pursuant to NRC requirements of Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54). The NRC has established that, as part of the staff review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8, the SEIS will include analyses of potential impacts to historic and cultural resources. A draft SEIS is scheduled for publication in 2011, and will be provided to you for review and comment.

If you have any questions or require additional information, please contact the Project Manager, Mr. Tam Tran, at 301-415-3617 or Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to be "Bo Pham", written over a horizontal line.

Bo Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

cc: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 9, 2011

Javier Loera
Tribal Historic and Preservation Officer (THPO)
Ysleta del Sur Pueblo
119 S. Old Pueblo Rd.
P.O. Box 17579
El Paso, Texas 79917

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE SOUTH TEXAS PROJECT,
UNITS 1 AND 2, LICENSE RENEWAL APPLICATION REVIEW

Dear Javier Loera:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2, located in Matagorda, Texas. STP is in close proximity to lands that may be of interest to the Ysleta del Sur Pueblo. As described below, the NRC process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Section 51.28(b) of Title 10 of the *Code of Federal Regulations* (10 CFR), the NRC invites the Ysleta del Sur Pueblo to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for STP, Units 1 and 2, will expire on August 20, 2027, and December 15, 2028, respectively. STPNOC submitted its application for renewal of the STP, Units 1 and 2, operating licenses by letter dated October 25, 2010.

The NRC is gathering information for a STP, Units 1 and 2, site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the STP, Units 1 and 2, site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the STP, Units 1 and 2, Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2).

J. Loera

- 2 -

The NRC will hold two public scoping meetings for the South Texas Project license renewal site-specific supplement to the GEIS on March 2, 2011, at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 9:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

The license renewal application is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams/web-based.html>. The accession number for the license renewal application is ML103010256. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's Public Document Room reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr.resource@nrc.gov.

The STP, Units 1 and 2, license renewal application is also available on the Internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/south-texas-project.html>. In addition, the Bay City Public Library, located at 1100 7th Street, Bay City, TX 77414, has agreed to make the application available for public inspection.

The GEIS, which assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Ysleta del Sur Pueblo may have to offer on the scope of the environmental review by April 1, 2011. Written comments should be submitted by mail to the Chief, Rules, Announcements, and Directives Branch, Division of Administrative Services, Mail Stop TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC at <http://www.regulations.gov> referencing documents filed under Docket ID NRC-2010-0375. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and provide you a copy.

The NRC will issue the draft supplemental environmental impact statement (SEIS) for public comment (anticipated publication in 2012), and will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS.

Appendix D

J. Loera

- 3 -

The issuance of the final SEIS for STP, Units 1 and 2, is planned for 2012. If you need additional information regarding the environmental review process, please contact Tam Tran, Environmental Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to be 'Bo M. Pham', with a long horizontal line extending to the right.

Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:
As stated

cc w/encls.: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 9, 2011

Chief Oscola Clayton Sylestine
Alabama-Coushatta Tribe
Route 3, Box 659
Livingston, TX 77351

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE SOUTH TEXAS PROJECT,
UNITS 1 AND 2, LICENSE RENEWAL APPLICATION REVIEW

Dear Chief Sylestine:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2, located in Matagorda, Texas. STP is in close proximity to lands that may be of interest to the Alabama-Coushatta Tribe as described below; the NRC process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Section 51.28(b) of Title 10 of the *Code of Federal Regulations* (10 CFR), the NRC invites the Alabama-Coushatta Tribe to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for STP, Units 1 and 2, will expire on August 20, 2027, and December 15, 2028, respectively. STPNOC submitted its application for renewal of the STP, Units 1 and 2, operating licenses by letter dated October 25, 2010.

The NRC is gathering information for a STP, Units 1 and 2, site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the STP, Units 1 and 2, site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the STP, Units 1 and 2, Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2).

The NRC will hold two public scoping meetings for the South Texas Project license renewal site-specific supplement to the GEIS on March 2, 2011, at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 9:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

The license renewal application is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams/web-based.html>. The accession number for the license renewal application is ML103010256. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's Public Document Room reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr_resource@nrc.gov.

The STP, Units 1 and 2, license renewal application is also available on the Internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/south-texas-project.html>. In addition, the Bay City Public Library, located at 1100 7th Street, Bay City, TX 77414, has agreed to make the application available for public inspection.

The GEIS, which assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Alabama-Coushatta Tribe may have to offer on the scope of the environmental review by April 1, 2011. Written comments should be submitted by mail to the Chief, Rules, Announcements, and Directives Branch, Division of Administrative Services, Mail Stop TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC at <http://www.regulations.gov> referencing documents filed under Docket ID NRC-2010-0375. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and provide you a copy.

The NRC will issue the draft supplemental environmental impact statement (SEIS) for public comment (anticipated publication date in 2012), and will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS.

O. Sylestine

- 3 -

The issuance of the final SEIS for STP, Units 1 and 2, is planned for 2012. If you need additional information regarding the environmental review process, please contact Tam Tran, Environmental Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,



Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:
As stated

cc w/encls.: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 9, 2011

Mr. Billy Evans Horse
Chairman of the Kiowa Tribe
Kiowa Tribe of Oklahoma
P.O. Box 369
Carnegie, OK 73015

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE SOUTH TEXAS PROJECT,
UNITS 1 AND 2, LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Horse:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2, located in Matagorda, Texas. STP is in close proximity to lands that may be of interest to the Kiowa Tribe of Oklahoma. As described below, the NRC process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Section 51.28(b) of Title 10 of the *Code of Federal Regulations* (10 CFR), the NRC invites the Kiowa Tribe of Oklahoma to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for STP, Units 1 and 2, will expire on August 20, 2027, and December 15, 2028, respectively. STPNOC submitted its application for renewal of the STP, Units 1 and 2, operating licenses by letter dated October 25, 2010.

The NRC is gathering information for a STP, Units 1 and 2, site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the STP, Units 1 and 2, site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the STP, Units 1 and 2, Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2).

B. Horse

- 2 -

The NRC will hold two public scoping meetings for the South Texas Project license renewal site-specific supplement to the GEIS on March 2, 2011, at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 9:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

The license renewal application is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams/web-based.html>. The accession number for the license renewal application is ML103010256. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's Public Document Room reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr_resource@nrc.gov.

The STP, Units 1 and 2, license renewal application is also available on the Internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/south-texas-project.html>. In addition, the Bay City Public Library, located at 1100 7th Street, Bay City, TX 77414, has agreed to make the application available for public inspection.

The GEIS, which assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Kiowa Tribe of Oklahoma may have to offer on the scope of the environmental review by April 1, 2011. Written comments should be submitted by mail to the Chief, Rules, Announcements, and Directives Branch, Division of Administrative Services, Mail Stop TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC at <http://www.regulations.gov> referencing documents filed under Docket ID NRC-2010-0375. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and provide you a copy.

The NRC will issue the draft supplemental environmental impact statement (SEIS) for public comment (anticipated publication in 2012), and will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS.

Appendix D

B. Horse

- 3 -

The issuance of the final SEIS for STP, Units 1 and 2, is planned for 2012. If you need additional information regarding the environmental review process, please contact Tam Tran, Environmental Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, consisting of several loops and a long horizontal stroke extending to the right.

Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:
As stated

cc w/encls.: Distribution via Listserv



UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 WASHINGTON, D.C. 20555-0001

February 9, 2011

Ms. Ruth Toahy
 NAGPRA Coordinator
 Comanche Nation
 NAGPRA and Historic Preservation Program
 Comanche National Museum
 701 NW Ferris
 Lawton, OK 73507

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE SOUTH TEXAS PROJECT,
 UNITS 1 AND 2, LICENSE RENEWAL APPLICATION REVIEW

Dear Ms. Toahy:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2, located in Matagorda, Texas. STP is in close proximity to lands that may be of interest to the Comanche Nation. As described below, the NRC process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Section 51.28(b) of Title 10 of the *Code of Federal Regulations* (10 CFR), the NRC invites the Comanche Nation to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for STP, Units 1 and 2, will expire on August 20, 2027, and December 15, 2028, respectively. STPNOC submitted its application for renewal of the STP, Units 1 and 2, operating licenses by letter dated October 25, 2010.

The NRC is gathering information for a STP, Units 1 and 2, site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the STP, Units 1 and 2, site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the STP, Units 1 and 2, Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2).

The NRC will hold two public scoping meetings for the South Texas Project license renewal site-specific supplement to the GEIS on March 2, 2011, at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 9:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

The license renewal application is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams/web-based.html>. The accession number for the license renewal application is ML103010256. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's Public Document Room reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr_resource@nrc.gov.

The STP, Units 1 and 2, license renewal application is also available on the Internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/south-texas-project.html>. In addition, the Bay City Public Library, located at 1100 7th Street, Bay City, TX 77414, has agreed to make the application available for public inspection.

The GEIS, which assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Comanche Nation may have to offer on the scope of the environmental review by April 1, 2011. Written comments should be submitted by mail to the Chief, Rules, Announcements, and Directives Branch, Division of Administrative Services, Mail Stop TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC at <http://www.regulations.gov> referencing documents filed under Docket ID NRC-2010-0375. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and provide you a copy.

The NRC will issue the draft supplemental environmental impact statement (SEIS) for public comment (anticipated publication in 2012), and will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS.

R. Toahty

- 3 -

The issuance of the final SEIS for STP, Units 1 and 2, is planned for 2012. If you need additional information regarding the environmental review process, please contact Tam Tran, Environmental Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,



Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:
As stated

cc w/encls.: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 16, 2011

Ms. Mary Orms
U.S. Fish and Wildlife Service (USFWS)
c/o TAMU – Corpus Christi
6300 Ocean Drive
Corpus Christi, TX 78412

**SUBJECT: REQUEST FOR LIST OF FEDERALLY PROTECTED SPECIES AND
IMPORTANT HABITATS WITHIN THE AREA UNDER EVALUATION FOR THE
SOUTH TEXAS PROJECT, UNITS 1 AND 2, LICENSE RENEWAL
APPLICATION REVIEW**

Dear Ms. Orms:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2. STP is located in Matagorda County in Texas, approximately 70 miles South-Southwest of Houston. The application for renewal was submitted by STPNOC in a letter dated October 25, 2010, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54). The NRC has established that, as part of the staff's review of any nuclear power plant license renewal application, a site-specific Supplemental Environmental Impact Statement (SEIS) to its *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, must be prepared under 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969, as amended. In the SEIS for STP, the NRC staff will consider the proposed action of whether or not to renew STP's operating license for an additional 20 years beyond the initial 40-year licensing period. The SEIS will include an analysis of pertinent environmental issues, impacts to endangered or threatened species, impacts to marine resources and habitats and impacts to other fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

The STP site is approximately 12,220 acres in size and consists of approximately 46 acres of site buildings, support facilities, transmission rights-of-way, and other developed land. The remaining land includes an Essential Cooling Pond (46 acres); a Main Cooling Reservoir (7,000 acres); natural lowland habitat (1,700 acres); and other undeveloped land (3,474 acres), some of which is leased for cattle grazing. The STP site is bounded on the north, east, and south by estuarine marshland. In their license renewal application, STPNOC stated that, if renewed, STP would continue to use existing plant facilities and structures and existing power transmission facilities. No major construction or component replacement (referred to collectively in the GEIS as "refurbishment") would occur as a result of the proposed license renewal.

STP uses a cooling pond-based heat dissipation system to cool its reactor units. Heated discharge water flows from the main condensers and into the Main Cooling Reservoir, where waste heat is removed. The Colorado River supplies makeup water for the Main Cooling Reservoir. Four makeup pumps carry with a total capacity of 269,000 gallons per minute transport water from the Colorado River to a Reservoir Makeup Pumping Facility, which then

M. Orms

- 2 -

releases water to the Main Cooling Reservoir. The makeup pumps are operated intermittently as needed. The Main Cooling Reservoir also has a blowdown structure, which releases reservoir water to the Colorado River 1.1 miles downstream of STP along the west bank.

The transmission lines associated with STP include 9 345-kV lines and are depicted in the Transmission Line Map (enclosed). The associated transmission line rights-of-way extend a total distance of 336 miles and encompass approximately 4,775 acres of land. The transmission lines pass through primarily agricultural and rangeland as well as developed areas with low population densities and some forested areas. In its review, the NRC staff will consider Federally listed species and terrestrial and aquatic habitats that occur in or near the transmission line rights-of-way. Note that though the STP site is contained within Matagorda County, the transmission lines traverse an additional 14 counties, which are listed at the bottom of the Federally Listed Species Table (enclosed).

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests concurrence on the enclosed Federally Listed Species Table, which includes threatened, endangered, proposed, and candidate species that may be on or in the vicinity of the STP or its associated transmission line rights-of-way. The NRC also requests any additional information on protected species and critical habitat that may be in the vicinity of the STP if such information is available. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC staff plans to hold two public scoping meetings on March 2, 2011. The first session will be held in the afternoon and an identical session will be held later that evening. The first meeting will convene at 1:30 PM and will continue until 3:30 PM, as necessary. The second meeting will convene at 7:00 PM and will continue until 9:00 PM as necessary. Both sessions will be held at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. In addition, during the week of July 11, 2011, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is in 2012.

Appendix D

M. Orms

- 3 -

If you have any questions concerning the NRC staff's review of this license renewal application, please contact Tam Tran, License Renewal Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,



Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:

- | | |
|-----------------------------|------------------------------|
| 1. Area Map, 50-mile radius | 4. Transmission Line Map |
| 2. Area Map, 6-mile radius | 5. Federal T&E Species Table |
| 3. Site Area Map | |

cc w/encls: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 16, 2011

Mr. David Bernhart
Asst. Regional Administrator for Protected Resources
NOAA Fisheries Services (NMFS)
Southeast Region Office
263 13th Avenue South
St. Petersburg, FL 33701

SUBJECT: REQUEST FOR LIST OF FEDERALLY PROTECTED SPECIES AND
IMPORTANT HABITATS WITHIN THE AREA UNDER EVALUATION FOR THE
SOUTH TEXAS PROJECT, UNITS 1 AND 2, LICENSE RENEWAL
APPLICATION REVIEW

Dear Mr. Bernhart:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2. STP is located in Matagorda County in Texas, approximately 70 miles South-Southwest of Houston. The application for renewal was submitted by STPNOC in a letter dated October 25, 2010, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54). The NRC has established that, as part of the staff's review of any nuclear power plant license renewal application, a site-specific Supplemental Environmental Impact Statement (SEIS) to its *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, must be prepared under 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969, as amended. In the SEIS for STP, the NRC staff will consider the proposed action of whether or not to renew STP's operating license for an additional 20 years beyond the initial 40-year licensing period. The SEIS will include an analysis of pertinent environmental issues, impacts to endangered or threatened species, impacts to marine resources and habitats and impacts to other fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

The STP site is approximately 12,220 acres in size and consists of approximately 46 acres of site buildings, support facilities, transmission rights-of-way, and other developed land. The remaining land includes an Essential Cooling Pond (46 acres); a Main Cooling Reservoir (7,000 acres); natural lowland habitat (1,700 acres); and other undeveloped land (3,474 acres), some of which is leased for cattle grazing. The STP site is bounded on the north, east, and south by estuarine marshland. In their license renewal application, STPNOC stated that, if renewed, STP would continue to use existing plant facilities and structures and existing power transmission facilities. No major construction or component replacement (referred to collectively in the GEIS as "refurbishment") would occur as a result of the proposed license renewal.

STP uses a cooling pond-based heat dissipation system to cool its reactor units. Heated discharge water flows from the main condensers and into the Main Cooling Reservoir, where waste heat is removed. The Colorado River supplies makeup water for the Main Cooling Reservoir. Four makeup pumps carry with a total capacity of 269,000 gallons per minute transport water from the Colorado River to a Reservoir Makeup Pumping Facility, which then releases water to the Main Cooling Reservoir. The makeup pumps are operated intermittently as needed. The Main Cooling Reservoir also has a blowdown structure, which releases reservoir water to the Colorado River 1.1 miles downstream of STP along the west bank.

The transmission lines associated with STP include 9 345-kV lines and are depicted in the Transmission Line Map (enclosed). The associated transmission line rights-of-way extend a total distance of 336 miles and encompass approximately 4,775 acres of land. The transmission lines pass through primarily agricultural and rangeland as well as developed areas with low population densities and some forested areas. In its review, the NRC staff will consider Federally listed species and terrestrial and aquatic habitats that occur in or near the transmission line rights-of-way. Note that though the STP site is contained within Matagorda County, the transmission lines traverse an additional 14 counties, which are listed at the bottom of the Federally Listed Species Table (enclosed).

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests concurrence on the enclosed Federally Listed Species Table, which includes threatened, endangered, proposed, and candidate species that may be on or in the vicinity of the STP or its associated transmission line rights-of-way. The NRC also requests any additional information on protected species and critical habitat that may be in the vicinity of the STP if such information is available. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC staff plans to hold two public scoping meetings on March 2, 2011. The first session will be held in the afternoon and an identical session will be held later that evening. The first meeting will convene at 1:30 PM and will continue until 3:30 PM, as necessary. The second meeting will convene at 7:00 PM and will continue until 9:00 PM as necessary. Both sessions will be held at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. In addition, during the week of July 11, 2011, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is in 2012.

D. Bernhart

- 3 -

If you have any questions concerning the NRC staff's review of this license renewal application, please contact Tam Tran, License Renewal Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,



Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:

- | | |
|-----------------------------|------------------------------|
| 1. Area Map, 50-mile radius | 4. Transmission Line Map |
| 2. Area Map, 6-mile radius | 5. Federal T&E Species Table |
| 3. Site Area Map | |

cc w/encls: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 16, 2011

Ms. Kathy Boydston
Habitat Assessment Program Manager
Texas Parks and Wildlife Department
4200 Smith School Road
Austin, TX 78744

SUBJECT: REQUEST FOR LIST OF STATE-PROTECTED SPECIES AND IMPORTANT
HABITATS WITHIN THE AREA UNDER EVALUATION FOR THE SOUTH
TEXAS PROJECT, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION
REVIEW

Dear Ms. Boydston:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2. STP is located in Matagorda County, approximately 70 miles south-southwest of Houston. The application for renewal was submitted by STPNOC in a letter dated October 25, 2010, pursuant to Title 10 of the *Code of Federal Regulations Part 54* (10 CFR Part 54). The NRC has established that, as part of the staff's review of any nuclear power plant license renewal application, a site-specific Supplemental Environmental Impact Statement (SEIS) to its *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, will be prepared under 10 CFR Part 51, the NRC's regulation that implements the National Environmental Policy Act (NEPA) of 1969, as amended. The SEIS includes an analysis of pertinent environmental issues, impacts to endangered or threatened species, impacts to marine resources and habitats, and impacts to other fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

For the purpose of license renewal, STPNOC stated that STP, Units 1 and 2, operating under renewed licenses, would use existing plant facilities and transmission (also, the license renewal application preparation did not identify the need to undertake any major refurbishment or replacement actions to maintain the functionality of the STP systems, structures, and components during the period of extended operation). STP, Units 1 and 2, site is bounded on the north, east, and south by estuarine marshland, veined with man-made ditches and tidal creeks. Approximately 7,000 acres of the site real estate consists of the Main Cooling Reservoir (MCR) and it is a main geographical feature of the site.

STP, Units 1 and 2, are pressurized-water reactors. STP uses the 7,000-acre MCR, with makeup water from the Colorado River, as the ultimate heat sink for its cooling system. Makeup water from the Colorado River is pumped and piped into the MCR from the Reservoir Makeup Pumping Facility (RMPF) by means of four makeup pumps with a total capacity of 269,000 gallons per minute. The makeup pumps are operated intermittently as needed and dictated by local hydrology and meteorological condition. The MCR also has a blowdown structure to relieve reservoir water to the Colorado River.

K. Boydston

- 2 -

As a part of the SEIS preparation, the application transmission line rights-of-way will be reviewed. The applicant's transmission lines (in-scope) consist of mainly 345-kV lines (note: there is a 138-kV line to bring emergency power to STP) that tie STP electrical system to the grid. These lines of interest are captured in the "Transmission Line Map" (enclosed). Please note that though the STP project site is contained within Matagorda County, the transmission lines associated with the site traverse an additional 14 counties that are listed at the bottom of Table 1, enclosure 5. For these counties, the NRC will only be considering protected species whose ranges may overlap with the transmission line rights-of-way. Typically, the rights-of-way are 100 to 400 feet wide.

To support the SEIS preparation process, the NRC requests a list of State-protected species and important habitats that may be in the vicinity of STP, Units 1 and 2, site and its associated transmission line rights-of-way. The applicant, STP Nuclear Operating Company (STPNOC), corresponded with your office on March 17, 2009. The correspondence includes "Table 1, Protected Species in Texas Counties Containing STP, Units 1 and 2, Project Facilities and Transmission Lines." In the correspondence, STPNOC requested a response from your office by April 16, 2009. To avoid any duplication of effort, you may provide us with your response to STPNOC on this item previously, if available, rather than compiling a new list. If any information is not current, please provide any applicable updates. The March 17, 2009, letter from STPNOC is enclosed for your reference. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

The NRC staff plans to hold two public NEPA scoping meetings on March 2, 2011. The first session will be held in the afternoon and an identical session will be held later that evening. The first meeting will convene at 1:30 PM and will continue until 3:30 PM, as necessary. The second meeting will convene at 7:00 PM and will continue until 9:00 PM, as necessary. Both sessions will be held at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. In addition, during the week of July 11, 2011, the NRC plans to conduct a site audit. You and your staff are invited to attend both the public meetings and the site audit. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is in 2012.

Appendix D

K. Boydston

- 3 -

For questions concerning the review of this license renewal application, please contact Tam Tran, License Renewal Project Manager, at 301-415-3617 or via email, Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read 'Bo M. Pham', with a long horizontal line extending to the right.

Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:

1. Area Map, 50-mile radius
2. Area Map, 6-mile radius
3. Site Area Map
4. Transmission Line Map
5. Letter from Applicant to State Agency

cc w/encls: Distribution via Listserv



UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 WASHINGTON, D.C. 20555-0001

February 17, 2011

Mark Wolfe, State Historic Preservation Officer (SHPO)
 Texas Historical Commission
 P.O. Box 12276
 Austin, TX 78711-2276

SUBJECT: SOUTH TEXAS PROJECT, UNITS 1 AND 2, LICENSE RENEWAL
 APPLICATION REVIEW (TRACK NUMBER 201002271)

Dear Mr. Wolfe:

The U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing an application submitted by South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for South Texas Project (STP), Units 1 and 2. STP is located in Matagorda County Texas. The application for renewal was submitted by STPNOC in a letter dated October 25, 2010, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54). The NRC has established that, as part of the staff's review of any nuclear power plant license renewal application, a site-specific Supplemental Environmental Impact Statement (SEIS) to its *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*, NUREG-1437, will be prepared under 10 CFR Part 51, the NRC's regulation that implements the National Environment Policy Act of 1969, as amended (NEPA). The NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966, as amended (NHPA) with NEPA in accordance with 36 CFR 800.8(c).

In the context of the NHPA, the staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land-disturbing operations or projected refurbishment activities associated with the proposed action. The APE may extend beyond the immediate environs in those instances where post-license renewal land-disturbing operations or projected refurbishment activities specifically related to license renewal may potentially have an effect on known or proposed historic sites. This determination is made irrespective of ownership or control of the lands of interest. The SEIS will include an analysis of pertinent environmental issues and analyses of potential impacts to historic and cultural resources.

For the purpose of license renewal, STPNOC stated that STP, Units 1 and 2, operating under renewed licenses, would use existing plant facilities and transmission. Please see the enclosed maps and pictures, which show the area under review.

The staff plans to hold two public environmental scoping meetings on March 2, 2011, at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. The first meeting will convene at 1:30 PM and will continue until 3:30 PM, as necessary. The second meeting will convene at 7:00 PM with a repeat of the overview portions of the first meeting and will continue until 9:00 PM, as necessary. In addition, during the week of July 11, 2011, the staff plans to conduct a site audit at South Texas Project. You and your staff are invited to attend both the site audit and the public meetings. Your office will receive a copy of the draft SEIS along with a request for comments. The publication date for the draft SEIS is scheduled for 2012.

Appendix D

M. Wolfe

- 2 -

The STP, Units 1 and 2, license renewal application is available at:
<http://www.nrc.gov/reactors/operating/licensing/renewal/applications/south-texas-project.html>

If you have any questions concerning the staff's review of this license renewal application, please contact Tam Tran, Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to be 'Bo M. Pham', with a long horizontal line extending to the right.

Bo M. Pham, Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:

1. Area Map, 50-mile radius
2. Area Map, 6-mile radius
3. Site Area Map
4. Transmission Line Map

cc w/encls: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 17, 2011

Mr. Anthony E. Street
Tribal President
Tonkawa Tribe of Oklahoma
1 Rush Buffalo Road
Tonkawa, OK 74653

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE SOUTH TEXAS PROJECT,
UNITS 1 AND 2, LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Street:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2, located in Matagorda, Texas. STP is in close proximity to lands that may be of interest to the Tonkawa Tribe of Oklahoma. As described below, the NRC process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Section 51.28(b) of Title 10 of the *Code of Federal Regulations* (10 CFR), the NRC invites the Tonkawa Tribe of Oklahoma to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for STP, Units 1 and 2, will expire on August 20, 2027, and December 15, 2028, respectively. STPNOC submitted its application for renewal of the STP, Units 1 and 2, operating licenses by letter dated October 25, 2010.

The NRC is gathering information for a STP, Units 1 and 2, site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the STP, Units 1 and 2, site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the STP, Units 1 and 2, Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2).

Appendix D

A. Street

- 2 -

The NRC will hold two public scoping meetings for the South Texas Project license renewal site-specific supplement to the GEIS on March 2, 2011, at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 9:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

The license renewal application is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams/web-based.html>. The accession number for the license renewal application is ML103010256. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's Public Document Room reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr.resource@nrc.gov.

The STP, Units 1 and 2, license renewal application is also available on the Internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/south-texas-project.html>. In addition, the Bay City Public Library, located at 1100 7th Street, Bay City, TX 77414, has agreed to make the application available for public inspection.

The GEIS, which assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Tonkawa Tribe of Oklahoma may have to offer on the scope of the environmental review by April 1, 2011. Written comments should be submitted by mail to the Chief, Rules, Announcements, and Directives Branch, Division of Administrative Services, Mail Stop TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC at <http://www.regulations.gov> referencing documents filed under Docket ID NRC-2010-0375. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and provide you a copy.


The NRC will issue the draft supplemental environmental impact statement (SEIS) for public comment (anticipated publication in 2012), and will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS.

A. Street

- 3 -

The issuance of the final SEIS for STP, Units 1 and 2, is planned for 2012. If you need additional information regarding the environmental review process, please contact Tam Tran, Environmental Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to be 'Bo M. Pham', written over a horizontal line.

Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:
As stated

cc w/encls.: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 17, 2011

Apalachicola Band of Creek Indians
113 N. First Street
Mabank, TX 75147

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE SOUTH TEXAS PROJECT,
UNITS 1 AND 2, LICENSE RENEWAL APPLICATION REVIEW

Dear Principal Chief Mary Sixwomen Blount:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2, located in Matagorda, Texas. STP is in close proximity to lands that may be of interest to the Apalachicola Band of Creek Indians. As described below, the NRC process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Section 51.28(b) of Title 10 of the *Code of Federal Regulations* (10 CFR), the NRC invites the Apalachicola Band of Creek Indians to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for STP, Units 1 and 2, will expire on August 20, 2027, and December 15, 2028, respectively. STPNOC submitted its application for renewal of the STP, Units 1 and 2, operating licenses by letter dated October 25, 2010.

The NRC is gathering information for a STP, Units 1 and 2, site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the STP, Units 1 and 2, site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the STP, Units 1 and 2, Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2).

Apalachicola Band of Creek Indians - 2 -

The NRC will hold two public scoping meetings for the South Texas Project license renewal site-specific supplement to the GEIS on March 2, 2011, at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 9:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

The license renewal application is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams/web-based.html>. The accession number for the license renewal application is ML103010256. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's Public Document Room reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr_resource@nrc.gov.

The STP, Units 1 and 2, license renewal application is also available on the Internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/south-texas-project.html>. In addition, the Bay City Public Library, located at 1100 7th Street, Bay City, TX 77414, has agreed to make the application available for public inspection.

The GEIS, which assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Apalachicola Band of Creek Indians may have to offer on the scope of the environmental review by April 1, 2011. Written comments should be submitted by mail to the Chief, Rules, Announcements, and Directives Branch, Division of Administrative Services, Mail Stop TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC at <http://www.regulations.gov> referencing documents filed under Docket ID NRC-2010-0375. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and provide you a copy.


The NRC will issue the draft supplemental environmental impact statement (SEIS) for public comment (anticipated publication in 2012), and will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS.

Appendix D

Apalachicola Band of Creek Indians - 3 -

The issuance of the final SEIS for STP, Units 1 and 2, is planned for 2012. If you need additional information regarding the environmental review process, please contact Tam Tran, Environmental Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read 'Bo M. Pham', with a long horizontal line extending to the right.

Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:
As stated

cc w/encls.: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 17, 2011

Bernard F. Barcena Jr., Chairman
Lipan Apache Tribe of Texas
PO Box 8888
Corpus Christi, TX 78426

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE SOUTH TEXAS PROJECT,
UNITS 1 AND 2, LICENSE RENEWAL APPLICATION REVIEW

Dear Chairman Bernard F. Barcena Jr.:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2, located in Matagorda, Texas. STP is in close proximity to lands that may be of interest to the Lipan Apache Tribe of Texas. As described below, the NRC process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Section 51.28(b) of Title 10 of the *Code of Federal Regulations* (10 CFR), the NRC invites the Lipan Apache Tribe of Texas to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for STP, Units 1 and 2, will expire on August 20, 2027, and December 15, 2028, respectively. STPNOC submitted its application for renewal of the STP, Units 1 and 2, operating licenses by letter dated October 25, 2010.

The NRC is gathering information for a STP, Units 1 and 2, site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the STP, Units 1 and 2, site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the STP, Units 1 and 2, Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2).

The NRC will hold two public scoping meetings for the South Texas Project license renewal site-specific supplement to the GEIS on March 2, 2011, at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 9:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

The license renewal application is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams/web-based.html>. The accession number for the license renewal application is ML103010256. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's Public Document Room reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr_resource@nrc.gov.

The STP, Units 1 and 2, license renewal application is also available on the Internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/south-texas-project.html>. In addition, the Bay City Public Library, located at 1100 7th Street, Bay City, TX 77414, has agreed to make the application available for public inspection.

The GEIS, which assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Lipan Apache Tribe of Texas may have to offer on the scope of the environmental review by April 1, 2011. Written comments should be submitted by mail to the Chief, Rules, Announcements, and Directives Branch, Division of Administrative Services, Mail Stop TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC at <http://www.regulations.gov> referencing documents filed under Docket ID NRC-2010-0375. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and provide you a copy.

The NRC will issue the draft supplemental environmental impact statement (SEIS) for public comment (anticipated publication in 2012), and will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS.

B. Barcena

- 3 -

The issuance of the final SEIS for STP, Units 1 and 2, is planned for 2012. If you need additional information regarding the environmental review process, please contact Tam Tran, Environmental Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to be 'Bo M. Pham', with a long horizontal line extending to the right.

Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:
As stated

cc w/encls.: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 17, 2011

Daniel Romero Jr
General Council Chairman
Lipan Apache Band of Texas
1306 S. 9th Avenue
Edinburgh, TX 78539

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE SOUTH TEXAS PROJECT,
UNITS 1 AND 2, LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Daniel Romero Jr.:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2, located in Matagorda, Texas. STP is in close proximity to lands that may be of interest to the Lipan Apache Band of Texas. As described below, the NRC process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Section 51.28(b) of Title 10 of the *Code of Federal Regulations* (10 CFR), the NRC invites the Lipan Apache Band of Texas to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for STP, Units 1 and 2, will expire on August 20, 2027, and December 15, 2028, respectively. STPNOC submitted its application for renewal of the STP, Units 1 and 2, operating licenses by letter dated October 25, 2010.

The NRC is gathering information for a STP, Units 1 and 2, site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the STP, Units 1 and 2, site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the STP, Units 1 and 2, Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2).

D. Romero Jr.

- 2 -

The NRC will hold two public scoping meetings for the South Texas Project license renewal site-specific supplement to the GEIS on March 2, 2011, at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 9:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

The license renewal application is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams/web-based.html>. The accession number for the license renewal application is ML103010256. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's Public Document Room reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr.resource@nrc.gov.

The STP, Units 1 and 2, license renewal application is also available on the Internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/south-texas-project.html>. In addition, the Bay City Public Library, located at 1100 7th Street, Bay City, TX 77414, has agreed to make the application available for public inspection.

The GEIS, which assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Lipan Apache Band of Texas may have to offer on the scope of the environmental review by April 1, 2011. Written comments should be submitted by mail to the Chief, Rules, Announcements, and Directives Branch, Division of Administrative Services, Mail Stop TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC at <http://www.regulations.gov> referencing documents filed under Docket ID NRC-2010-0375. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and provide you a copy.

The NRC will issue the draft supplemental environmental impact statement (SEIS) for public comment (anticipated publication in 2012), and will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS.


Appendix D

D. Romero Jr.

- 3 -

The issuance of the final SEIS for STP, Units 1 and 2, is planned for 2012. If you need additional information regarding the environmental review process, please contact Tam Tran, Environmental Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to be 'Bo M. Pham', written over a horizontal line.

Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:
As stated

cc w/encls.: Distribution via Listserv



UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 WASHINGTON, D.C. 20555-0001

February 17, 2011

J.R. Mendoza, Chief Speaker
 Pamaque Clan of Coahuila Y Tejas
 Spanish Colonial Indian Missions Inc.
 3631 Callaghan Road #614
 San Antonio, TX 78228

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE SOUTH TEXAS PROJECT,
 UNITS 1 AND 2, LICENSE RENEWAL APPLICATION REVIEW

Dear J.R. Mendoza:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2, located in Matagorda, Texas. STP is in close proximity to lands that may be of interest to the Pamaque Clan of Coahuila Y Tejas. As described below, the NRC process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Section 51.28(b) of Title 10 of the *Code of Federal Regulations* (10 CFR), the NRC invites the Pamaque Clan of Coahuila Y Tejas to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for STP, Units 1 and 2, will expire on August 20, 2027, and December 15, 2028, respectively. STPNOC submitted its application for renewal of the STP, Units 1 and 2, operating licenses by letter dated October 25, 2010.

The NRC is gathering information for a STP, Units 1 and 2, site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the STP, Units 1 and 2, site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the STP, Units 1 and 2, Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2).

The NRC will hold two public scoping meetings for the South Texas Project license renewal site-specific supplement to the GEIS on March 2, 2011, at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 9:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

The license renewal application is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams/web-based.html>. The accession number for the license renewal application is ML103010256. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's Public Document Room reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr.resource@nrc.gov.

The STP, Units 1 and 2, license renewal application is also available on the Internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/south-texas-project.html>. In addition, the Bay City Public Library, located at 1100 7th Street, Bay City, TX 77414, has agreed to make the application available for public inspection.

The GEIS, which assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that Pamaque Clan of Coahuila Y Tejas may have to offer on the scope of the environmental review by April 1, 2011. Written comments should be submitted by mail to the Chief, Rules, Announcements, and Directives Branch, Division of Administrative Services, Mail Stop TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC at <http://www.regulations.gov> referencing documents filed under Docket ID NRC-2010-0375. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and provide you a copy.

The NRC will issue the draft supplemental environmental impact statement (SEIS) for public comment (anticipated publication in 2012), and will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS.

J. Mendoza

- 3 -

The issuance of the final SEIS for STP, Units 1 and 2, is planned for 2012. If you need additional information regarding the environmental review process, please contact Tam Tran, Environmental Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to be 'Bo M. Pham', with a long horizontal line extending to the right.

Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:
As stated

cc w/encls.: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 17, 2011

Raymond Hernandez
Cultural Preservation Officer
Tap Pilam-Coahuiltecan Nation
American Indians in Texas
1313 Guadalupe Street, Suite 104
San Antonio, Texas 78207

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE SOUTH TEXAS PROJECT,
UNITS 1 AND 2, LICENSE RENEWAL APPLICATION REVIEW

Dear Cultural Preservation Officer Raymond Hernandez:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2, located in Matagorda, Texas. STP is in close proximity to lands that may be of interest to the Tap Pilam-Coahuiltecan Nation. As described below, the NRC process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Section 51.28(b) of Title 10 of the *Code of Federal Regulations* (10 CFR), the NRC invites the Tap Pilam-Coahuiltecan Nation to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for STP, Units 1 and 2, will expire on August 20, 2027, and December 15, 2028, respectively. STPNOC submitted its application for renewal of the STP, Units 1 and 2, operating licenses by letter dated October 25, 2010.

The NRC is gathering information for a STP, Units 1 and 2, site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the STP, Units 1 and 2, site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the STP, Units 1 and 2, Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2).

R. Hernandez

- 2 -

The NRC will hold two public scoping meetings for the South Texas Project license renewal site-specific supplement to the GEIS on March 2, 2011, at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 9:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

The license renewal application is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams/web-based.html>. The accession number for the license renewal application is ML103010256. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's Public Document Room reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr_resource@nrc.gov.

The STP, Units 1 and 2, license renewal application is also available on the Internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/south-texas-project.html>. In addition, the Bay City Public Library, located at 1100 7th Street, Bay City, TX 77414, has agreed to make the application available for public inspection.

The GEIS, which assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Tap Pilam-Coahuiltecan Nation may have to offer on the scope of the environmental review by April 1, 2011. Written comments should be submitted by mail to the Chief, Rules, Announcements, and Directives Branch, Division of Administrative Services, Mail Stop TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC at <http://www.regulations.gov> referencing documents filed under Docket ID NRC-2010-0375. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and provide you a copy.

The NRC will issue the draft supplemental environmental impact statement (SEIS) for public comment (anticipated publication in 2012), and will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS.


Appendix D

R. Hernandez

- 3 -

The issuance of the final SEIS for STP, Units 1 and 2, is planned for 2012. If you need additional information regarding the environmental review process, please contact Tam Tran, Environmental Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read 'Bo M. Pham', with a long horizontal line extending to the right.

Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:
As stated

cc w/encls.: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 23, 2011

Juan Garza Jr., Chairman
Kickapoo Traditional Council
HCR1 Box 9700
Eagle Pass, TX 78852

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE SOUTH TEXAS PROJECT,
UNITS 1 AND 2, LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Garza:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2, located in Matagorda, Texas. STP is in close proximity to lands that may be of interest to the Kickapoo Traditional Council. As described below, the NRC process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Section 51.28(b) of Title 10 of the *Code of Federal Regulations* (10 CFR), the NRC invites the Kickapoo Traditional Council to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966 through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years if NRC requirements are met. The current operating license for STP, Units 1 and 2, will expire on August 20, 2027, and December 15, 2028, respectively. STPNOC submitted its application for renewal of the STP, Units 1 and 2, operating licenses by letter dated October 25, 2010.

The NRC is gathering information for a STP, Units 1 and 2, site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the STP, Units 1 and 2, site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the STP, Units 1 and 2, Site Layout (Enclosure 1) and Transmission Line Map (Enclosure 2).

The NRC will hold two public scoping meetings for the South Texas Project license renewal site-specific supplement to the GEIS on March 2, 2011, at the Bay City Civic Center, Main Hall, Room 100, 201 Seventh Street, Bay City, TX 77414. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 3:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 9:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

The license renewal application is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams/web-based.html>. The accession number for the license renewal application is ML103010256. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's Public Document Room reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr_resource@nrc.gov.

The STP, Units 1 and 2, license renewal application is also available on the Internet at <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/south-texas-project.html>. In addition, the Bay City Public Library, located at 1100 7th Street, Bay City, TX 77414, has agreed to make the application available for public inspection.

The GEIS, which assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, can also be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Kickapoo Traditional Council may have to offer on the scope of the environmental review by April 1, 2011. Written comments should be submitted by mail to the Chief, Rules, Announcements, and Directives Branch, Division of Administrative Services, Mail Stop TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC at <http://www.regulations.gov> referencing documents filed under Docket ID NRC-2010-0375. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and provide you a copy.

The NRC will issue the draft supplemental environmental impact statement (SEIS) for public comment (anticipated publication in 2012), and will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft SEIS will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS.

J. Garza

- 3 -

The issuance of the final SEIS for STP, Units 1 and 2, is planned for 2012. If you need additional information regarding the environmental review process, please contact Tam Tran, Environmental Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, consisting of a large, stylized 'B' followed by a horizontal line extending to the right.

Bo M. Pham, Branch Chief
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:
As stated

cc w/encls.: Distribution via Listserv

16FR0410

PUBLIC SUBMISSION

As of: February 16, 2011
Received: February 15, 2011
Status: Pending_Post
Tracking No.: 80befbe9
Comments Due: April 01, 2011
Submission Type: Web

Docket: NRC-2010-0375
Notice of Receipt and Availability of Application for Renewal of Facility Operating License

Comment On: NRC-2010-0375-0003
STP Nuclear Operating Company; Notice of Intent to Prepare an Environmental Impact Statement and Conduct the Scoping Process for South Texas Project, Units 1 and 2

Document: NRC-2010-0375-DRAFT-0001
Comment on FR Doc # 2011-01904

Submitter Information

Name: Miranda Allen
Address:
 1 Rush Buffalo Road
 Tonkawa, OK, 74653
Organization: Tonkawa Tribe of Oklahoma
Government Agency Type: Tribal
Government Agency: Tonkawa Tribe of Oklahoma

RECEIVED

FEB 16 AM 10:3

RULES AND REGULATIONS

General Comment

Date: February 15, 2011

Regarding the request for comments concerning the South Texas Project, Units 1 and 2, license renewal application review.

The Tonkawa Tribe has no specifically designated historical or cultural sites identified in the above listed project area. However if any human remains, funerary objects, or other evidence of historical or cultural significance is inadvertently discovered then the Tonkawa Tribe would certainly be interested in proper disposition thereof. We appreciate notification by your office of the many projects on-going, and as always the Tonkawa Tribe is willing to work with your representatives in any manner to uphold the provisions of NAGPRA to the extent of our capability.

Respectfully,

*NSI Review Complete
- N.D. - ADM-013*

*FRFDS = ADM-03
(add = 17-11 Tran (TXT 1))*

NRR-PMDAPEm Resource

From: Teletha Mincey [Teletha.Mincey@noaa.gov]
Sent: Thursday, March 03, 2011 1:29 PM
To: Tran, Tam
Subject: South Texas Project <a e>
Attachments: Texas.pdf

Hello:

In response to NRC's letter dated February 16, 2011, attached is a listing of species under the National Marine Fisheries Service's jurisdiction. Also, please checkout the website below for further information. Thank you.

<http://sero.nmfs.noaa.gov/pr/pr.htm>

--

Teletha Mincey
Program Analyst
NOAA Fisheries
Southeast Region
263 13th Ave S
St. Petersburg, FL 33701-5505
(727) 551-5772 - Direct Line
(727) 824-5309 - Fax



01/31/2011
Letter 5410
(3)

RULES AND DIRECTIVES
SECTION

MAR 15 AM 7:45

APALACHICOLA CREEK INDIANS
113 N FIRST STREET, MABANK, TX 75147

903-880-0240 Email Sixwomen@apalachicolacreek.com

RECEIVED

Chief, Rules, Announcements, and Directives Branch
Division of Administrative Services
Mail Stop TWB-05-B01M
US Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Monday, March 7, 2011

Subject: Apalachicola Council Comments On South Texas Project, Units 1 and 2, License Renewal Application

Dear Branch Chief,

Thank you this opportunity to review and comment letter dated February 17, 2011. The Apalachicola Elder Council find this an important task as we have suffered historic and cultural losses despite existing promises under Environmental Policy Law. Therefore, we preface our comments with the following preamble:

Whereas the Apalachicola Town known as Red Ground Town, Econchatta Micco the Chief, was destroyed by the U.S. Army Corps of Engineers to build the Jimi Woodruff Dam in 1957 located at the confluence of the Flint, Chattahoochee and Apalachicola Rivers in Alabama, Georgia and Florida, and

Whereas, the Apalachicola Indian Cemetery, previously located on Indian Hill near the City of Livingston in Polk County, Texas, was excavated by approval of the Trinity River Authority in 1969 sending the remains of our Apalachicola ancestors and Hereditary Chief John Blount to the bottom of the Trinity River thence to the Gulf of Mexico and without protection and guarantees of the Environmental Protection Act, and

Whereas the Apalachicola Creek Indians have been in Texas since 1834 and have suffered cultural and historic losses in modern times despite legislative protections, we admit our comments today are sincere but tempered by painful experience. None the less, we cling to the hope that the Nuclear Regulation Agency will do no further harm to any Texas Residents, to the general environment we call home or to the historical and cultural sites not previously or thoroughly examined by non Native Anthropologists and literary scholars.

Review Complete

E-REDS-ADM-03

**TRADITIONAL
COUNCIL**

CHAIRMAN
Juan Garza, Jr., Kisisika

SECRETARY
Jesus Anico, Chakodata

TREASURER
Rogelio Elizondo, Apichicuea

MEMBERS
David J. Gonzalez, Kikekideah
Nanate Hernandez, Nanatea

KICKAPOO

**TRADITIONAL
TRIBE OF TEXAS**

HCR 1 Box 9700
Eagle Pass, Texas 78852



Traditional Council

1/31/2011
76 FR 5410
27

April 1, 2011

Chief, Rules, Announcements, and Directives Branch,
Division of Administrative Services,
Mail Stop TWB-05-B01M,
US Nuclear Regulatory Commission,
Washington, DC 20555-0001

RECEIVED

APR 11 2011 11:22 AM

RECEIVED

Re: **REQUEST FOR COMMENTS CONCERNING THE SOUTH TEXAS
PROJECT, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION REVIEW**

Dear Sir(s):

Thank you for your letter dated on February 23, 2011, regarding your request for comments concerning the South Texas Project, Units 1 and 2; License Application Review.

Thank you for advising us about the proposed action. The Kickapoo Nation values its traditions and customs so we appreciate your taking the time to ask for our input in this matter. By keeping the lines of communication open we can peacefully co-exist yet attend to our respective businesses.

We do not have any comments or questions regarding said project, as we are unaware of any tribal sites in this area, therefore it does not affect our interests in any way. Furthermore, the Kickapoo Traditional Tribe of Texas wishes you success in your endeavor.

Should you have any further questions please do not hesitate to contact us.

Juan Garza, Jr., Chairman

E-RDS = ADM-03



Tap Pilam
Coahuiltecan Nation
1313 Guadalupe Street
San Antonio, Texas 78207

April 1, 2011

Tap Pilam Coahuiltecan
Tribal Council

Tribes

Pa-nam-a Payaya
Raymond Hernandez
coahtexo@hctc.net

Pompopa
Mickey Killian
pakawan@satx.rr.com

Venados
Teodoso Herrera
VENADO5@aol.com

Auteca Paguame
Ramon Vasquez y Sanchez
xagukai@txdirect.net

Pampopa
Casanova

Chief, Rules, Announcements, and Directive Branch
Division of Administrative Services
Mail Stop TWB-05-B01M
United States Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Re: Docket ID NRC-2010-0305

To whom it may concern:

The Tap Pilam Coahuiltecan Nation is grateful for the opportunity to provide comments concerning the South Texas Project (STP), Units 1 and 2, license renewal application review.

We are concerned with the renewal of this license because of the project's location and proximity to historical French and Spanish colonial settlements. Our ancestral relatives were brought into these settlements, and we their descendants continue to have deep cultural roots and ties to the land.

More specifically, we are concerned that archeological data of a third site, as mentioned in Attachment D of the Applicant's Environmental Report (September 2010) is missing from the records. Before any consideration is given to the renewal of this license, we recommend that a new archeological investigation to this third site be conducted.

In a global context, a nuclear disaster similar to the one occurring in Japan would make our deep cultural roots and ties to the land inaccessible for an undetermined length of time. We want to be assured that adequate safeguards are in place in order to prevent a repeat of the tragedy in Japan. For example, in Japan there were no alternate sources of power to run the water pumps that would cool off the reactors which caused radiation to leak and contaminate the surrounding areas for miles. This would be disastrous not only to our cultural heritage, but to all the people of South Texas.

It is our intention to continue researching how our Nation's families and culture will be impacted by the renewal of the license. In conjunction with upcoming public meetings and publication, we intend to continue providing input and comments.

Re: Docket ID NRC-2010-0305

Page 2

Once again we are grateful for your thoughtfulness of our cultural roots and ties to the land, including the abovementioned comments, before approving a license renewal to the STP Units 1 and 2.

Respectfully submitted,
Raymond Hernandez
Cultural Preservation Officer
Tap Pilam-Coahuiltecan Nation
American Indians in Texas
1313 Guadalupe Street, Suite 104
San Antonio, Texas 78207



Life's better outside.*

Commissioners

- Peter M. Holt
Chairman
San Antonio
- T. Dan Friedkin
Vice-Chairman
Houston
- Mark E. Bivins
Amarillo
- Ralph H. Duggins
Fort Worth
- Antonio Falcon, M.D.
Rio Grande City
- Karen J. Hixon
San Antonio
- Dan Allen Hughes, Jr.
Beeville
- Margaret Martin
Boerne
- S. Reed Morian
Houston
- Lee M. Bass
Chairman-Emeritus
Fort Worth

Carter P. Smith
Executive Director

12/1/2011
76 FR 5410
61

April 20, 2011

Bo M. Pham
Branch Chief
Projects Branch 1
Division of License Renewal
US Nuclear Regulatory Commission
Washington, D.C. 20555-0001

RECEIVED

APR 27 AM 11:15

RE: Proposed license renewal of the South Texas Project Units 1 & 2, Matagorda County, Texas.

Dear Mr. Pham:

The Texas Parks and Wildlife Department (TPWD) has received your request for information regarding potential impacts to threatened and endangered species and for information on other issues of concern relating to the project referenced above. Under section 12.0011 of the Texas Parks and Wildlife Code, TPWD is charged with "providing recommendations that will protect fish and wildlife resources to local, state, and federal agencies that approve, permit, license, or construct developmental projects" and "providing information on fish and wildlife resources to any local, state, and federal agencies or private organizations that make decisions affecting those resources."

The U.S. Nuclear Regulatory Commission (NRC) is reviewing an application submitted by the South Texas Project Nuclear Operating Company (STPNOC) for the renewal of the operating license for the South Texas Project (STP), Units 1 and 2. STP is located in Matagorda County, approximately 70 miles south-southwest of Houston.

For the purpose of license renewal, STPNOC stated that STP, Units 1 and 2, operating under renewed licenses, would use existing plant facilities and transmission lines and that no new construction or changes in operation are proposed. In addition, the license renewal application preparation did not identify the need to undertake any major refurbishment or replacement actions to maintain the functionality of the STP systems, structures, and components during the period of extended operation.

Based upon the project description, TPWD does not anticipate significant adverse impacts to rare, threatened or endangered species, or other fish and wildlife resources. However, if the project scope changes and new construction becomes proposed as part of the license renewal process, TPWD requests the opportunity to provide additional comments.

TPWD County Lists

To aid in the preparation of the Supplemental Environmental Impact Statement for the proposed relicensing project, TPWD recommends the use of the county list for rare species in Matagorda County. The TPWD county lists for rare species may be obtained from the following link: <http://gis.tpwd.state.tx.us/TpwEndangeredSpecies/DesktopDefault.aspx>. These lists provide information regarding rare species that have potential to occur within each county.

4200 SMITH SCHOOL ROAD
AUSTIN, TEXAS 78744-3291
512.389.4800

www.tpwd.state.tx.us

To manage and conserve the natural and cultural resources of Texas and to provide hunting, fishing and outdoor recreation opportunities for the use and enjoyment of present and future generations.

ONSI Review Complete

To... also = ADM-013


E-RIDS = ADM-0

Call - T. Pham (TXT1)

Mr. Bo M. Pham
April 20, 2011
Page 2 of 2

TPWD appreciates the opportunity to work with the Nuclear Regulatory Commission to ensure these projects are developed in the most environmentally sensitive manner as is possible. If you have any questions regarding our comments, please contact Amy Turner at (361) 576-0022.

Sincerely,



Amy Turner
Wildlife Habitat Assessment Program
Wildlife Division

/ajt:15906



United States Department of the Interior

FISH AND WILDLIFE SERVICE

Ecological Services
c/o TAMU-CC, Campus Box 338
6300 Ocean Drive
Corpus Christi, Texas 78412

June 2, 2011

Mr. Tam Tran
License Renewal Project Manager
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Consultation No. 21430-2007-I-0082

Dear Mr. Tran:

Thank you for your June 1, 2011, telephone call regarding the South Texas Project Nuclear Operating Company's (STPNOC) operating license renewal application for Units 1 and 2 in Matagorda County, Texas. The nuclear plant, Units 1 and 2, and 9 associated 345-kV transmission lines that cross an additional 14 counties current exist are in operation. The facility applied for a renewal in October 2010, and has requested an additional 20 years beyond the initial 40-year licensing period. No new discharge or construction is proposed and the Nuclear Regulatory Commission is in the process of preparing a supplemental Environmental Impact Statement and submitted a species list for the U.S. Fish and Wildlife Service's (Service) review and concurrence.

The Service has reviewed and corrected the list (see enclosed list) and provides the following additional comments. The STPNOC is located in Matagorda County; however, the transmission lines traverse a total of 15 counties. The 15 counties are within three Service Field Offices' areas of responsibility. The Clear Lake Field Office will be the lead office because the plant is located in Matagorda County; however, for any future potential expansions, construction of new transmission lines and/or maintenance and improvements to existing lines please contact the following offices for counties within their area of responsibility.

Clear Lake Ecological Services Field Office - Matagorda, Brazoria, Wharton, Fayette, Colorado
Corpus Christi Ecological Field Office - Victoria, Jackson, DeWitt, Karnes, Wilson, Gonzales, Lavaca
Austin Ecological Services Field Office - Guadalupe, Bexar, Comal
Phone numbers for the respective offices are as follows: 281-286-8282, 361-994-9005, 512-490-0057.

Additional recommendations are also provided for various species.

Whooping crane

All 15 counties are within the whooping crane migratory corridor and some are in the critical wintering grounds of the endangered whooping crane (*Grus americana*) (see Figure 1). Whooping cranes use a variety of habitats including marsh, tidal flats, uplands, and barrier islands and roost in waters less than 10 inches. Whooping cranes usually arrive on the Texas coast between late-October and mid-November and spend almost six months on the wintering grounds. As spring approaches, they leave for the breeding grounds in Canada normally between March 25 and April 15 with the last birds usually gone by May 1st (occasional stragglers may stay into mid-May).

Usually, whooping crane migration flights are generally at altitudes of between 1,000 and 6,000 feet, but they fly at lower altitudes when seeking stopover habitats. They will often make low flights up to two miles from a stopover site to forage late in the day or in early morning. They may also interrupt migration flights to drink and/or forage in agricultural fields or wetlands for brief periods and may be at low altitudes during mid-day. Whooping cranes are largely opportunistic in their use of stopover sites along the Central Flyway, and will use sites with available habitat when weather or diurnal conditions require a break in migration. The Service recommends that: 1) project construction should be complete prior to the spring and autumn migration of late March to early May and mid-September to mid-November, respectively and 2) if equipment above 15 feet is proposed for use during construction or maintenance, please mark and/or lie cranes/equipment down during night time hours and periods of low visibility and 3) for all existing and future transmission lines we recommend the lines be marked with bird diverters to minimize impacts to whooping cranes from collisions during flight.

Ocelot and Gulf coast jaguarundi

Clearing/removal of the surrounding vegetation may particularly affect listed species in the area, including the ocelot and the Gulf coast jaguarundi. Both these endangered cats require dense brush cover; however information from Mexico indicates that the jaguarundi may be more tolerant of open areas. In Texas, the ocelots occur in dense shrubland. Although the ocelot's prime habitat needs are 70 to 90% canopy coverage, it will utilize a lesser degree of cover for hunting areas, and as protected corridors for travel. Roads, narrow water bodies, and rights-of-way, brushy fencelines, watercourses and other brush strips connecting areas of habitat are important for the ocelot. Any cat sightings and road mortalities should be reported immediately to the Service. Both the ocelot and Gulf coast jaguarundi are crepuscular and are active/travel during the dawn to dusk hours; noise and bright lighting used for night construction could dissuade these cats in their movements and should not be used. When assessing impacts to cats the project should be evaluated for loss of habitat, loss of connectivity, construction noise and lights during construction and/or operation.

Bald eagle

The bald eagle has been removed from the Federal Endangered and Threatened list (rule effective August 8, 2007). However, protections provided to the bald eagle under the Bald and Golden Eagle Protection (BGEPA) and the Migratory Bird Treaty Act (MBTA) will continue to remain in place after the species is delisted. Both Federal laws prohibit "take," and the BGEPA prohibits disturbance as a form of "take" as well. To help provide more clarity on the management of the bald eagle after delisting, the Service published a regulatory definition of "disturb" (72 FR 31132), and the Final National Bald Eagle Management Guidelines (72 FR 31156). The management guidelines and further information on the bald eagle may be viewed at <http://www.fws.gov>. The bald eagle may occur in Colorado, Brazoria, Matagorda, Wharton, Fayette, Victoria, Jackson, DeWitt, Gonzales, Guadalupe, Lavaca, and Comal counties.

Migratory Birds

The Migratory Bird Treaty Act implements various treaties and conventions for the protection of migratory birds. Under the Act, taking, killing or possessing migratory birds is unlawful. Many may nest in trees, brush areas or other suitable habitat. The Service recommends activities requiring vegetation removal or disturbance avoid the peak nesting period of March through August to avoid destruction of individuals, nests or eggs. If project activities must be conducted during this time, we recommend surveying for nests prior to commencing work. If a nest is found, and if possible, the Service recommends a buffer of vegetation (= 50m for songbirds, > 100m for wading birds, and > 180m for terns, skimmers and birds of prey) remain around the nest until young have fledged or the nest is

abandoned. A list of migratory birds may be viewed at <http://migratorybirds.fws.gov/intrnltr/mbta/proposedbirdlist.pdf> or <http://federalregister.gov/a/2010-3294>.

Under the Migratory Bird Treaty Act (MBTA) it is unlawful to “pursue, hunt, take, capture, kill, attempt to take, capture or kill, possess, at any time, or in any manner, any migratory bird (e.g. waterfowl, shorebirds, birds of prey, song birds, etc.) included in the terms of this Convention...for the protection of migratory birds...or any part, nest, or egg of any such bird.” Section 1.1307(a)(3) of the Commission's Rules requires a licensee to file an environmental assessment (EA) for the Commission's review and approval if a licensee's proposed facilities are to be located in an area that: (i) may affect listed threatened or endangered species or designated critical habitats; or (ii) are likely to jeopardize the continued existence of any proposed endangered or threatened species or likely to result in the destruction or adverse modification of proposed critical habitats, as determined by the Secretary of the Interior pursuant to the Endangered Species Act of 1973. See 47 C.F.R. 1.1307(a)(3).

Brown Pelican

The brown pelican has been removed from the threatened and endangered list (rule effective December 17, 2009), however, is being monitored for 5 years. It is protected under the Migratory Bird Treaty Act and may occur in Brazoria and Matagorda counties.

Mountain Plover and Black Bear

The mountain plover is not longer being proposed as threatened and the black bear is not found within any of the counties under review.

State Listed Species

The State of Texas protects certain species. Please contact the Texas Parks and Wildlife Department (Endangered Resources Branch), 4200 Smith School Road, Austin, Texas 78744 (telephone 512/389-8021) for information concerning fish, wildlife, and plants of State concern or visit their website at <http://www.tpwd.state.tx.us/nature/endang/animals/mammals/>.

Wetlands and Wildlife Habitat

Wetlands and riparian zones provide valuable fish and wildlife habitat as well as contribute to flood control, water quality enhancement, and groundwater recharge. Wetland and riparian vegetation provides food and cover for wildlife, stabilizes banks and decreases soil erosion. These areas are inherently dynamic and very sensitive to changes caused by such activities as overgrazing, logging, major construction, or earth disturbance. Executive Order 11990 asserts that each agency shall provide leadership and take action to minimize the destruction, loss or degradation of wetlands, and to preserve and enhance the natural and beneficial value of wetlands in carrying out the agency's responsibilities. Construction activities near riparian zones should be carefully designed to minimize impacts. If vegetation clearing is needed in these riparian areas, as is true with this project, they should be re-vegetated with native wetland and riparian vegetation to prevent erosion or loss of habitat. We recommend minimizing the area of soil scarification and initiating incremental re-establishment of herbaceous vegetation at the proposed work sites. Denuded and/or disturbed areas should be re-vegetated with a mixture of native legumes and grasses. Species commonly used for soil stabilization are listed in the Texas Department of Agriculture's (TDA) Native Tree and Plant Directory, available from TDA at P.O. Box 12847, Austin, Texas 78711. To prevent and/or minimize soil erosion and compaction associated with construction activities, avoid any unnecessary clearing of vegetation, and follow established rights-of-way whenever possible. All machinery and petroleum products should be

stored outside the floodplain and/or wetland area during construction to prevent possible contamination of water and soils. No permanent structures should be placed in the 100-year floodplain.

If your project will involve filling of a wetland or riparian area it may require a Clean Water Act Section 404 permit from the U.S. Army Corps of Engineers. For permitting requirements please contact the U.S. Corps of Engineers, District Engineer, P.O. Box 1229, Galveston, Texas 77553-1229, (409) 766-3002.

Beneficial Landscaping


In accordance with Executive Order 13112 on Invasive Species and the Executive Memorandum on Beneficial Landscaping, where possible, any landscaping associated with project plans should be limited to seeding and replanting with native species. A mixture of grasses and forbs appropriate to address potential erosion problems and long-term cover should be planted when seed is reasonably available. Although Bermuda grass is listed in seed mixtures, this species and other introduced species should be avoided as much as possible. The Service also recommends the use of native trees, shrubs, and herbaceous species that are adaptable, drought tolerant and conserve water.

Service Response

Please note that the Service strives to respond to requests for project review within 30 days of receipt, however, this time period is not mandated by regulation. Responses may be delayed due to workload and lack of staff. Failure to meet the 30-day timeframe does not constitute a concurrence from the Service that the proposed project will not have impacts to threatened and endangered species.

We thank you for your concern for endangered and threatened species, migratory birds, and other wildlife resources, and we appreciate the opportunity to comment and review the proposed action and species list. If we can be of further assistance or if you have any questions about these comments; please contact Mary Orms at 361/994-9005, extension 246 or at Mary_Orms@fws.gov. Please refer to the Service Consultation number listed above in any future correspondence regarding this project.

Sincerely,


for Allan M. Strand
Field Supervisor

cc: Moni Belton, Clear Lake Ecological Services Field Office, Houston, TX
Bill Seawell, Austin Ecological Services Field Office, Austin, TX

Attachments




Figure 1. Whooping Crane Migratory Corridor

**Federally Listed Species Potentially Occurring On and In The Vicinity of the South Texas Project Site
and Its Associated Transmission Line Rights-of-Way**

Scientific Name	Common Name	Federal Status	County(Counties) of Occurrence
Amphibians			
<i>Bufo houstonensis</i>	Houston Toad	E	Colorado, Lavaca
<i>Eurycea nana</i>	San Marcos salamander	T	Bexar, Comal
<i>Typhlomolge rathbuni</i>	Texas blind salamander	E	Bexar, Comal
Arachnids			
<i>Cicurina baronia</i>	Robber baron cave meshweaver	E	Bexar
<i>Cicurina madla</i>	Madla's cave meshweaver	E	Bexar
<i>Cicurina venii</i>	Braken bat cave meshweaver	E	Bexar
<i>Cicurina vespera</i>	Government Canyon bat cave meshweaver	E	Bexar
<i>Neoleptoneta microps</i>	Government Canyon bat cave spider	E	Bexar
<i>Texella cokendolpheri</i>	Cokendolpher cave harvestman	E	Bexar
Birds			
<i>Charadrius melodus</i>	piping plover	T	Brazoria, Matagorda
<i>Dendroica chrysoparia</i>	golden-cheeked warbler	E	Bexar, Comal
<i>Falco femoralis septentrionalis</i>	northern aplomado falcon	E	Matagorda
<i>Tympanuchus cupido attwateri</i>	Attwater's greater prairie-chicken	E	Colorado, Victoria
<i>Vireo atricapilla</i>	black-capped vireo	E	Bexar, Comal
<i>Grus americana</i>	whooping crane	E	Bexar, Comal, Colorado, Brazoria, Matagorda, Wharton, Fayette, Victoria, Jackson, DeWitt, Karnes, Wilson, Gonzales, Guadalupe, Lavaca
Crustaceans			
<i>Stygobromus pecki</i>	Peck's cave amphipod	E	Bexar, Comal
Fish			
<i>Etheostoma fonticola</i>	fountain darter	E	Bexar, Comal
<i>Gambusia georgei</i>	San Marcos gambusia	E	Bexar, Comal
Flowering Plants			
<i>Zizania texana</i>	Texas wild rice	E	Bexar, Comal
<i>Spiranthes parksii</i>	Navasota ladies' tresses	E	Fayette
Insects			
<i>Heterelmis comalensis</i>	Comal Springs riffle beetle	E	Bexar, Comal
<i>Rhadine exilis</i>	unnamed ground beetle	E	Bexar
<i>Rhadine infernalis</i>	unnamed ground beetle	E	Bexar
<i>Stygoparnus comalensis</i>	Comal Springs dryopid beetle	E	Bexar, Comal
<i>Batrisodes venyivi</i>	Helotes mold beetle	E	Bexar
Mammals			
<i>Herpailurus yagouaroundi cacomitli</i>	Gulf Coast jaguarondi	E	Karnes
<i>Leopardus pardalis</i>	ocelot	E	Karnes

Appendix D

<i>Trichechus manatus</i>	West Indian manatee	E	Jackson
Reptiles			
<i>Caretta caretta</i>	loggerhead sea turtle	T	Brazoria, Matagorda
<i>Chelonia mydas</i>	green sea turtle	T	Brazoria, Matagorda
<i>Dermochelys coriacea</i>	leatherback sea turtle	E	Brazoria, Matagorda
<i>Eretmochelys imbricate</i>	hawksbill sea turtle	E	Brazoria, Matagorda
<i>Lepidochelys kempii</i>	Kemp's ridley sea turtle	E	Brazoria, Matagorda

From: Bill Martin [<mailto:Bill.Martin@thc.state.tx.us>]
Sent: Monday, May 02, 2011 12:24 PM
To: O'Neil, Tara
Cc: Tran, Tam; Travers, Allison; Leigh, Kimberly D
Subject: RE: STP License Renewal - SHPO Meeting

OK, Tara. Thanks!

From: O'Neil, Tara [<mailto:tara.oneil@pnl.gov>]
Sent: Monday, May 02, 2011 2:11 PM
To: Bill Martin
Cc: Tran, Tam; Travers, Allison; Leigh, Kimberly D
Subject: STP License Renewal - SHPO Meeting

Bill,

This is a follow-up email to document our phone conversation just a few minutes ago. We determined at this point in time that there is no need for the NRC to meet with the Texas Historical Commission (THC) regarding cultural resources at the STP site for the license renewal project action (track number 201002271).

The NRC will conduct the cultural resources environmental audit the week of May 23, 2011 for South Texas Project Units 1 & 2. We will contact you after the audit, if we have questions or concerns.

We will check the THC website in a few weeks for tribal consultation guidance.

Thank you,

Tara O'Neil
Archaeologist

Tara K. O'Neil

Appendix D

From: Tran, Tam [<mailto:Tam.Tran@nrc.gov>]
Sent: Thursday, April 28, 2011 10:10 AM
To: Bill Martin
Cc: Leigh, Kimberly D; O'Neil, Tara; Travers, Allison
Subject: RE: track number

Hello,

I appreciate the opportunity to talk with you this week about the South Texas Project (STP), units 1 and 2, license renewal. As stated in the attached letter of consultation to SHPO of February 17, 2011, the staff planned to conduct an audit at the STP site and would like to invite your office to attend this review. The cultural audit portion of this review is now scheduled for the week of May 23-26. If meeting at the STP site is not feasible, the staff would like to visit your office during the May 23-26 week, for consultation as follow:

- Discuss NRC's licensing action, schedule, opportunities to participate in the NEPA process, and process for completing Section 106 and any questions or issues the SHPO may have concerning cultural resources (follow-up of the February 17, 2011 letter introducing the project and NRC plan to coordinate compliance with Section 106 of the National Historic Preservation Act with NEPA, in accordance with 36 CFR 800.8c)
- Discuss specific information inquiry concerning known cultural resource surveys and sites that may be of concern in the affected area for STP license renewal
- Discuss information inquiry about which affected Tribes and interested parties who have historical ties to the area, as it relates to STP license renewal
- Discuss SHPO concurrence in the STP letter dated March 17, 2009 requesting concurrence that there would be no effect to historic properties, from the license renewal and associated operation and maintenance activities (SHPO responded with "stamping" concurring that no historic properties affected and license renewal may proceed, dated 10/26/2009)
- Discuss the staff's confirmatory review by checking the SHPO Texas Historic Sites Atlas that can be accessed remotely

If the consultation will be at your office in Austin, the staff will drive from the STP site to Austin for this purpose during the May 23-26 week; hence, please let us know which date would be feasible for this meeting. Alternatively, please let us know if you have other suggestions.

Thanks/Tam



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 17, 2011

Juan Garza Jr., Chairman
Kickapoo Traditional Council
HCR1 Box 9700
Eagle Pass, TX 78852

SUBJECT: SOUTH TEXAS PROJECT, UNITS 1 AND 2, LICENSE RENEWAL
ENVIRONMENTAL REVIEW

Dear Chairman Juan Garza Jr.:

The U.S. Nuclear Regulatory Commission (NRC) would like to thank you for your letter dated April 1, 2011, in response to the NRC's request for comments regarding the proposed license renewal of South Texas Project (STP) and the associated environmental review. The NRC values the importance of establishing and maintaining open lines of communication with the Kickapoo Tribal Council. For your information, the draft Supplemental Environmental Impact Statement for license renewal of STP is scheduled to be published in 2012 and will be provided to you for comment.

If at any time you have questions or concerns regarding the STP environmental review process, please contact Tam M. Tran, Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "D. J. Wrona", with a checkmark-like flourish at the end.

David J. Wrona, Chief
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

cc: Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 17, 2011

Mr. Don L. Patterson, Tribal President
Attention: Miranda Allen
Tonkawa Tribe of Oklahoma
1 Rush Buffalo Road
Tonkawa, OK 74653

SUBJECT: SOUTH TEXAS PROJECT, UNITS 1 AND 2, LICENSE RENEWAL
ENVIRONMENTAL REVIEW

Dear Mr. Don L. Patterson,

The U.S. Nuclear Regulatory Commission (NRC) would like to thank you for your letter dated February 15, 2011, in response to this agency's request for comments concerning the proposed license renewal of South Texas Project (STP) and the associated environmental review. The NRC values the importance of establishing and maintaining open lines of communication with the Tonkawa Tribe of Oklahoma.

In response to your comment, the NRC will notify the Tonkawa Tribe if any information about human remains, funerary objects, or other evidence of historical or cultural significance are discovered during the STP license renewal environmental review. For your information, the draft Supplemental Environmental Impact Statement for license renewal of STP is scheduled to be published 2012 and will be provided to you for comment.

If at any time you have questions or concerns regarding the STP environmental review process, please contact Tam M. Tran, Project Manager, at 301-415-3617, or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "D. J. Wrona".

David J. Wrona, Chief
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos 50-498 and 50-499

cc: Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 29, 2011

Raymond Hernandez
Cultural Preservation Officer
Tap Pilam-Coahuiltecan Nation
American Indians in Texas
1313 Guadalupe Street, Suite 104
San Antonio, TX 78207

SUBJECT: SOUTH TEXAS PROJECT, UNITS 1 AND 2, LICENSE RENEWAL
ENVIRONMENTAL REVIEW

Dear Mr. Hernandez:

The U.S. Nuclear Regulatory Commission (NRC) would like to thank you for your letter dated April 1, 2011, sent in response to the NRC's request for comments concerning the proposed license renewal of South Texas Project (STP) and the associated environmental review. The NRC values the importance of establishing and maintaining open lines of communication with the Tap Pilam-Coahuiltecan Nation. Accordingly, the NRC would like to address the concerns identified in your comment letter.

In your letter, you raised a concern about missing archaeological data in the applicant's environmental report (ER). In response, the NRC issued a request for additional information (RAI), and the STP Nuclear Operating Company has provided the NRC (documented in the enclosed letter dated July 5, 2011) with additional data and documentation on the three cultural sites mentioned in Attachment D of the ER. The NRC finds the new data to be sufficient for both the National Environmental Policy Act (NEPA) review and National Historic Preservation Act (NHPA) Section 106 review. In addition, the environmental review will consider the potential effects on historical French and Spanish colonial settlements from activities associated with STP operation during the period of extended operation. The staff will document its review in Sections 2, 4, and 8 of the draft Supplemental Environmental Impact Statement (DSEIS).

In response to your concern about "a nuclear disaster similar to the one occurring in Japan" and the prospect of inaccessibility "to the cultural roots and ties to the land," the NRC is responsible for licensing and regulating the operation of nuclear power plants to ensure the protection of public health and safety and the environment. The safe operation of nuclear power plants is not limited to license renewal. The NRC ensures safe operation of nuclear power plants on an ongoing basis at every nuclear power plant. The NRC performs safety inspections throughout the operating life of the plant, whether during the current or renewed operating license period.

Appendix D

R. Hernandez

- 2 -

For your information, the NRC near-term task force review of insights from the Fukushima Dai-ichi accident is documented in a report entitled "Recommendations for Enhancing Reactor Safety in the 21st Century." This report can be found on the internet at: <http://pbadupws.nrc.gov/docs/ML1118/ML111861807.pdf>.

On July 12, 2011, the task force issued this report (ML111861807) and then the NRC staff presented its recommendations to the Commission on July 19, 2011. As part of the short-term review, the task force concluded that, while improvements [safety enhancements] are expected to be made as a result of the lessons learned from the events in Japan, the continued operation of nuclear power plants and licensing activities for new plants do not pose an imminent risk to public health and safety. In the meantime, the NRC will continue to oversee and monitor nuclear power plants to ensure that U.S. reactors remain safe. Additional information about what the NRC is doing to ensure the continued protection of health and safety at U.S. nuclear power plants following the events in Japan can be found at <http://www.nrc.gov/japan/japan-info.html>.

Again, thank you for your comments. These and other comments received during the public scoping period will be addressed in the DSEIS for license renewal of STP. The DSEIS is scheduled to be published in 2012 and will be provided to you for comment. If you need additional information regarding the STP environmental review process or this letter, please contact Tam Tran, Project Manager, at 301-415-3617 or by e-mail at Tam.Tran@nrc.gov.

Sincerely,



David J. Wrona, Chief
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure:
As stated

cc w/encl.: Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

January 19, 2012

Mary Sixwomen Blount
Principle Chief
Apalachicola Creek Indians
113 N First Street
Mabank, TX 75147

SUBJECT: SOUTH TEXAS PROJECT, UNITS 1 AND 2, LICENSE RENEWAL
ENVIRONMENTAL REVIEW

Dear Ms. Blount:

The U.S. Nuclear Regulatory Commission (NRC) thanks you for your letter dated March 7, 2011, in response to the NRC's request for comments in the letter dated February 17, 2011, concerning the environmental review of the South Texas Project (STP) license renewal. The NRC values the importance of establishing and maintaining open lines of communication with the Apalachicola Creek Indians. Accordingly, the NRC would like to address some of your concerns regarding compliance with National Environmental Policy Act (NEPA).

You informed the NRC about your interviews of tribal members living in the general area of the STP and provided comments. The NRC responds to your comments as follows:

- In response to your comment concerning hiring a Native American Anthropologist familiar with the migratory habits of Texas/Louisiana tribes, the NRC notes that a qualified expert on Native American (Archeologist) is a part of the NRC team who is conducting the environmental review in accordance with NEPA requirements to comply with the National Historic Preservation Act (NHPA) Section 106. Chapter 2 of the draft Supplemental Environmental Impact Statement (DSEIS) will describe the known cultural resources at the STP site. When published, Chapter 4 of the DSEIS will describe impacts to known cultural resources at the STP site as a result of license renewal.
- In response to your comment concerning the impacts to the residents in the area who are poor and non-white, impacts to all low-income and minority individuals living within a 50-mile radius will be considered as a part of the staff's review in accordance with NEPA requirements. Chapter 4.9 of the DSEIS will document the staff's review.

M. Sixwomen Blount

- 2 -

Again, thank you for your comments. These and other comments received during the public scoping period will be addressed in the DSEIS for license renewal of STP. The DSEIS is scheduled for 2012 and will be provided to you for comment. If you need additional information regarding the STP environmental review process or this letter, please contact Tam Tran, Project Manager, at 301-415-3617, or by e-mail at Tam.Tran@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "D. J. Wrona".

David J. Wrona, Chief
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

cc: Listserv

APPENDIX E
CHRONOLOGY OF ENVIRONMENTAL REVIEW CORRESPONDENCE

1 CHRONOLOGY OF ENVIRONMENTAL REVIEW CORRESPONDENCE

2 This appendix contains a chronological listing of correspondence between the U.S. Nuclear
3 Regulatory Commission (NRC) and external parties as part of its environmental review for the
4 South Texas Project (STP). All documents, with the exception of those containing proprietary
5 information, are available electronically from the NRC's Public Electronic Reading Room, which
6 is found on the Internet at the following web address: <http://www.nrc.gov/reading-rm.html>.
7 From this site, the public can gain access to the NRC's Agencywide Documents Access and
8 Management System (ADAMS), which provides text and image files of NRC's public
9 documents. The ADAMS accession number for each document is included below.

10 E.1 Environmental Review Correspondence

11 Table E–1 lists the environmental review correspondence in date order beginning with the
12 request by South Texas Project Nuclear Operating Company (STPNOC) to renew the operating
13 licenses for STP.

14 **Table E–1. Environmental Review Correspondence**

Date	Correspondence Description	ADAMS No.
10/25/10	STP, Units 1 and 2, Transmittal of LRA	ML103010257
11/4/10	Press Release-10-202, "NRC Announces Availability of License Renewal Application for South Texas Project Nuclear Power Plant"	ML103081029
11/23/10	Maintenance of Reference Materials at the Bay City Public Library for the Review of STP License Renewal Application	ML103090389
11/23/10	Receipt and availability of the LRA For STP, Units 1 and 2 (LTR)	ML103020399
12/9/10	Project Manager Change for the License Renewal of STP, Units 1 and 2 (TAC No. ME4936)	ML103410524
1/6/11	Acceptance of LRA for STP, Units 1 and 2	ML103440610
1/7/11	Determination of acceptability and sufficiency for docketing, proposed review schedule, and opportunity for a hearing regarding the application from STPNOC for renewal of the operating licenses for STP electric gene	ML103420531
1/7/11	Notice of acceptance for docketing of the application and notice of opportunity for hearing regarding renewal of facility operating license numbers NPF-76 and NPF-80 for an additional 20-year period STPNOC, STP	ML103420650
1/13/11	Press Release-11-009: "NRC Announces Opportunity for Hearing on Application to Renew Operating Licenses for South Texas Project Nuclear Power Plant"	ML110130500
1/21/11	Notice of intent to prepare an environmental impact statement (EIS) and conduct scoping process for license renewal for STP, Units 1 and 2	ML103490511
1/25/11	3/2/11—forthcoming meeting to discuss the license renewal process and environmental scoping for STP, Units 1 and 2, LRA review	ML103510697
1/27/11	STP, Units 1 and 2, LRA review (ACHP)	ML110190591
1/31/11	Comment (44) of Edmund E. Kelley, opposing STP, Units 1 and 2, LRA review	ML11105A023
1/31/11	Comment (51) of Juan Aguilar, on behalf of self, opposed to relicensing of STP, Units 1 and 2	ML11119A011

Appendix E

Date	Correspondence Description	ADAMS No.
1/31/11	Comment (52) of Juan Aguilar, on behalf of self, opposing STP, Units 1 and 2, relicensing application	ML11119A012
1/31/11	Comment (54) of Shawn Tracy, on behalf of self, opposing STP, Units 1 and 2, relicensing application	ML11119A014
2/7/11	Press Release-11-017: "NRC to Meet with Public March 2 for Input on South Texas Project Nuclear Plant Environmental Review for License Renewal"	ML110380405
2/9/11	Comanche Nation—request for comments concerning the STP, Units 1 and 2, LRA review	ML110390265
2/9/11	Kiowa Tribe of Oklahoma—Request for comments concerning the STP, Units 1 and 2, LRA review	ML110390244
2/9/11	Ysleta del Sur Pueblo—Request for comments concerning the STP, Units 1 and 2, LRA review	ML110190385
2/9/11	Alabama-Coushatta Tribe—Request for comments concerning the STP, Units 1 and 2, LRA review	ML110190418
2/15/11	Comment (1) of Miranda Allen, on behalf of the Tonkawa Tribe of Oklahoma on request for comments concerning the STP, Units 1 and 2, LRA review	ML110490057
2/16/11	Request for list of Federally protected species and important habitats within the area under evaluation for the STP, Units 1 and 2, license renewal (FWS)	ML110190429
2/16/11	Request for list of Federally protected species and important habitats within the area under evaluation for the STP, Units 1 and 2, LRA review (NMFS)	ML110190434
2/16/11	Request for list of state-protected species and important habitats within the area under evaluation for the STP, Units 1 and 2, LRA review (Texas Parks and Wildlife Department)	ML110190571
2/17/11	Request for comments concerning the STP, Units 1 and 2, LRA review (Tribes)	ML110390321
2/17/11	STP, Units 1 and 2, LRA online reference portal	ML110610201
2/17/11	STP, Units 1 and 2, LRA review (SHPO)	ML110190549
2/23/11	Kickapoo Traditional Council—Request for comments concerning the STP, Units 1 and 2, LRA review	ML110240161
2/28/11	Comment (46) of Randy K. Weber, on behalf of Texas House of Representatives, supporting license renewal for STP, Units 1 and 2	ML11108A059
2/28/11	Schedule for the conduct of review of the STP, Units 1 and 2, LRA	ML110340478
3/3/11	3/3/11—NRR e-mail capture—STP (NMFS)	ML110690848
3/7/11	Comment (3) of Mary Sixwomen Blount, on behalf of Apalachicola Creek Indians, on STP, Units 1 and 2, LRA	ML110750424
3/11/11	Comment (2) of Vicki Adams, approving notice of intent to prepare an EIS and conduct the scoping process for STP, Units 1 and 2	ML110730188
3/14/11	Declaration of Karen Hadden on behalf of SEED Coalition	ML110740852
3/14/11	Declaration of Susan Dancer on behalf of SEED Coalition	ML110740850
3/14/11	Notice of appearance of Susan Dancer on behalf of SEED Coalition	ML110740851
3/14/11	Petition for leave to intervene and request for hearing of SEED Coalition and Susan Dancer	ML110740848
3/16/11	Referral memorandum of the Secretary to the Board regarding license application request for STPNOC, STP, Units 1 and 2	ML110750603

Date	Correspondence Description	ADAMS No.
3/17/11	Referral memorandum of the Secretary to the Board regarding license application request for STPNOC, STP, Units 1 and 2 (reissued)	ML110760289
3/17/11	STP, Units 1 and 2, LRA online reference portal	ML110620203
3/23/11	Establishment of Atomic Safety and Licensing Board in the matter of STPNOC, STP, Units 1 and 2, license renewal	ML110820735
3/24/11	Comment (31) of Jennifer Meador, opposing relicensing of STP, Units 1 and 2	ML111010604
3/28/11	Comment (34) of unknown individual, supporting nuclear power and relicensing of STP, Units 1 and 2	ML111010507
3/28/11	Comment (37) of Carolyn Campbell, opposing STP, Units 1 and 2, relicensing (NRC-2010-0375)	ML111010510
3/28/11	Comment (48) of Beth Ann Larsen, on behalf of self, opposing STP, Units 1 and 2, relicensing application	ML11119A007
3/28/11	Comment (49) of Dzan Nguyen, opposed to relicensing STP, Units 1 and 2	ML11119A008
3/28/11	Comment (55) of Kelly Simon, on behalf of self, opposing relicensing of STP nuclear reactors	ML11119A015
3/28/11	Comment (58) of Cynthia Gebhardt, on behalf of self, opposing STP, Units 1 and 2, relicensing application	ML11119A018
3/28/11	Comment (59) of Rory Holcomb, on behalf of self, opposing STP, Units 1 and 2, relicensing application	ML11119A019
3/29/11	Comment (4) of Julie Sharp, on behalf of National Park Service, in regards to STPNOC STP with determination that no park units will be affected	ML110910179
3/30/11	Comment (32) Of Joy Malacara, opposing relicensing of STP, Units 1 and 2	ML111010479
3/30/11	Comment (33) of Melanie and David Winters, opposing STP, Units 1 and 2, relicensing	ML111010506
3/30/11	Comment (35) of Christine Fry, opposing STP, Units 1 and 2, relicensing (NRC-2010-0375)	ML111010508
3/30/11	Comment (36) of Leona A. Slodge, opposing STP, Units 1 and 2, relicensing	ML111010509
3/30/11	Comment (39) of B. Dunlap and T. Rinehart, opposing relicensing of STP, Units 1 and 2	ML111010517
3/30/11	Comment (40) of Peggy Cravens, opposing the relicensing of STP, Units 1 and 2	ML111010518
3/30/11	Comment (53) of Douglas S. McArthur, opposing relicensing of STP	ML11119A013
3/30/11	Comment (6) of Eva Esparza, opposing STPNOC's notice of intent to prepare an EIS and conduct the scoping process for STP, Units 1 and 2	ML110960078
3/30/11	Comment (60) of unknown individual on behalf of self, opposing relicensing of STP, Units 1 and 2, for an additional 20 years	ML11119A020
3/30/11	Comment (7) of Darby Riley, regarding notice of intent to prepare an EIS and conduct the scoping process for STP, Units 1 and 2	ML110960079
3/30/11	Comment (38) of Melanie Sallis, opposing the relicensing of STP, Units 1 and 2	ML11273A082
3/31/11	Comment (10) of Karen Seal, opposing the licensing of STP, Units 1 and 2	ML110960082
3/31/11	Comment (5) of Peggy Pryor, opposing STP plants	ML110960077
3/31/11	Comment (8) of Kamala Platt, opposing STP relicensing	ML110960080

Appendix E

Date	Correspondence Description	ADAMS No.
3/31/11	Comment (9) of Marion Mlotok, opposing the renewal of STP, Units 1 and 2	ML110960081
4/1/11	Comment (11) of Kassandra Levay, opposing STPNOC's notice of intent to prepare an EIS and conduct the scoping process for STP, Units 1 and 2	ML110960083
4/1/11	Comment (12) of unknown individual, regarding notice of intent to prepare an EIS and conduct the scoping process for STP, Units 1 and 2	ML110960084
4/1/11	Comment (13) of T. Burns, opposing South Texas plants (NRC-2010-0375)	ML110960086
4/1/11	Comment (14) of Jolly J. Clark, opposing the relicensing of STP, Units 1 and 2	ML110960087
4/1/11	Comment (15) of Pat Bulla, regarding the decommissioning of STP, Units 1 and 2, not relicensing it	ML110960088
4/1/11	Comment (16) of William Stout, supporting the decommissioning of STP, Units 1 and 2, not relicensing it	ML110960089
4/1/11	Comment (19) of Carol Geiger, opposing the renewal of STP, Units 1 and 2, licensing	ML110960092
4/1/11	Comment (20) of Veryan Thompson, supporting STP, Units 1 and 2, decommissioning and denying its LRA	ML110960093
4/1/11	Comment (21) of Robert Singleton, opposing license extension for STP, Units 1 and 2	ML110960094
4/1/11	Comment (22) of Karen Hadden, on behalf of sustainable energy and economic development coalition, opposing relicensing of STP, Units 1 and 2	ML110960095
4/1/11	Comment (23) of Alan Alan Apurim, opposing relicensing of STP, Units 1 and 2	ML110960096
4/1/11	Comment (24) of Brandi Clark Burton, on behalf of self, opposing STP, Units 1 and 2, extending its license application renewal for public safety and environmental reasons	ML110960097
4/1/11	Comment (25) of Carol Geiger, on behalf of self, opposing STP, Units 1 and 2, extending its license application renewal	ML110960098
4/1/11	Comment (27) of Juan Garza, on behalf of Kickapoo Traditional Tribe of Texas, on the STP, Units 1 and 2, LRA review	ML110980503
4/1/11	Comment (45) of Maria Hogan, on safety standards of STP, Units 1 and 2, being followed	ML11105A020
4/1/11	Comment (47) of Miguel Acosta, on behalf of Raymond Hernandez of Tap Pilam Coahuiltecan Nation, opposing the renewal license for STP, Units 1 and 2	ML11111A134
4/4/11	Comment (17) of C.J. Keudell, opposing the relicensing of STP, Units 1 and 2	ML110960090
4/4/11	Comment (18) of Tarek Tonsson, opposing the relicensing of STP, Units 1 and 2	ML110960091
4/4/11	Comment (26) of Eric Lane, on behalf of self, opposing STP, Units 1 and 2, extending its license application renewal	ML110960099
4/5/11	Project Manager change for the license renewal of STP, Units 1 and 2 (TAC No. ME4938)	ML110872079
4/7/11	4/7/11—Notice of appearance of Steven P. Frantz (STPNOC)	ML110970467
4/7/11	4/7/11—The NRC staff's answer to petition for leave to intervene and request for hearing of SEED Coalition and Susan Dancer	ML110970659
4/7/11	STPNOC's answer opposing request for hearing and petition for leave to intervene	ML110970544

Date	Correspondence Description	ADAMS No.
4/8/11	Comment (28) of Jenna Findley, opposing STP, Units 1 and 2, relicensing (NRC-2010-0375)	ML111010476
4/8/11	Comment (29) of Margaret Reed, opposing the relicensing of STP, Units 1 and 2	ML111010477
4/8/11	Comment (30) of Scott and Cyndy Reynolds, opposing relicensing of STP Nuclear reactors	ML111010478
4/9/11	Comment (43) of Thomas Nehms, opposing the relicensing of STP, Units 1 and 2	ML111010521
4/11/11	Comment (41) of Shannon Jurak, opposing the relicensing of STP, Units 1 and 2	ML111010519
4/11/11	Comment (42) of Thomas Nelms, opposing the relicensing of STP, Units 1 and 2	ML111010520
4/20/11	Comment (61) of Amy Turner, on behalf of Texas Parks and Wildlife, on proposed license renewal of STP, Units 1 and 2, Matagorda County, TX	ML11119A009
4/26/11	Comment (50) of John Trimble, opposing relicensing of STP, Units 1 and 2 (NRC-2010-0375)	ML11119A010
4/26/11	Comment (56) of unknown individual, opposing STP, Units 1 and 2, LRA	ML11119A016
4/26/11	Comment (57) of Judy Moore, on behalf of self, opposing relicensing of STP nuclear reactors	ML11119A017
5/5/11	Notice of withdrawal of Megan Wright in the matter of STP, Units 1 and 2	ML111250147
5/8/11	Intervenors request for oral argument on contentions raised on relicensing	ML111280003
5/8/11	Petitioners' proposed amended petition for leave to intervene and request for hearing of SEED Coalition and Susan Dancer	ML111280002
5/9/11	Notice of withdrawal of Emily Monteith	ML111290341
5/11/11	Certificate of service for amended petition to intervene and request for hearing	ML111310798
5/11/11	Certificate of service for request for oral hearing	ML111310800
5/19/11	Summary of meeting with stakeholders to discuss issues related to the review of the STP, Units 1 and 2, LRA	ML110770661
5/23/11	Memorandum (notice pursuant to 10 CFR § 2.309(i))	ML111430828
5/23/11	Order (scheduling oral argument)	ML111430799
5/31/11	RAIs for the review of the STP LRA	ML11140A015
6/2/11	U.S. Fish and Wildlife Service Consultation #65533—STPNOC	ML11173A235
6/2/11	The NRC staff's answer to proposed amended petition for leave to intervene and request for hearing of SEED Coalition and Susan Dancer	ML111530393
6/2/11	STPNOC's answer opposing amended petition to intervene	ML111530425
6/13/11	Press Release-11-103: "Licensing Board to Hold Teleconference Oral Argument June 27 on South Texas Project Reactor License Renewal Application"	ML11166A046
6/17/11	5/18/11—Summary of telephone conference call held between the NRC and STP, concerning RAI pertaining to the STP LRA—severe accident mitigation alternative RAI	ML11143A166
6/17/11	RAI for the review of the STP LRA	ML11167A113
6/21/11	Plan for the environmental-related regulatory audit regarding the STP, Units 1 and 2, LRA Review (TAC Nos. ME4938 and ME4939)	ML11145A064

Appendix E

Date	Correspondence Description	ADAMS No.
6/27/11	Transcript of STPNOC's oral argument (telephone conference) on June 27, 2011, pages 1–22	ML11182B033
7/5/11	STP, Units 1 and 2, response to RAI for the review of the LRA	ML11193A074
7/5/11	STP, Units 1 and 2, response to RAI for the STP LRA	ML11193A016
7/18/11	Audit report regarding STP LRA—cultural resource	ML11173A304
7/27/11	License renewal environmental review for STP, Units 1 and 2 (open meeting/records request, CPGCD)	ML11217A017
7/28/11	Memorandum revised (notice pursuant to 10 CFR § 2.309(i))	ML11210B458
8/4/11	RAI for the review of the STP LRA (TAC Nos. ME4938 and ME5122)	ML11201A062
8/4/11	Summary of site audit related to the review of the LRA for STP, Units 1 and 2	ML11196A005
8/18/11	RAI for the review of the STP LRA (TAC Nos. ME4938 and ME512)	ML11214A207
8/22/11	Comment (63) of Sandra Horris, on behalf of Coastal Plains Groundwater Conservation District, on relicensing of STP, Units 1 and 2 (NRC-2010-0375)	ML11249A042
8/23/11	STP, Units 1 and 2, response to RAI for LRA	ML11250A067
8/23/11	Summary of telephone conference call held on July 28, 2011, between the NRC and STPNOC, concerning RAI pertaining to the STP LRA	ML11216A263
8/26/11	Memorandum and order (ruling on petition for leave to intervene and request for hearing)	ML11238A160
8/31/11	Documents to support review of the STP LRA, list of transmitted documents including copy of each document, and enclosure to NOC-AE-11002720	ML11256A057
8/31/11	Documents to support review of the STP LRA, WR–11, “A Summary of Historic and Current (past 5 years) Total Dissolved Solids Data for Groundwater Produced by STP Production Wells from the Deep Chicot Aquifer”	ML11256A059
8/31/11	Documents to support review of the STP LRA, WR–5, TCEQ ID No. 1610103/1610051, “Operation Of Public Potable Water System”	ML11256A058
8/31/11	STP, Units 1 and 2, transmittal of documents to support review of the STP LRA	ML11256A056
9/1/11	RAI for the review of the STP LRA	ML112360114
9/6/11	STP, Units 1 and 2, response to RAI for the LRA	ML11255A211
9/12/11	STP, Units 1 and 2, response to RAI for the LRA	ML11259A014
9/12/11	STP, Units 1 and 2, transmittal of document to support review of the LRA	ML11259A031
9/13/11	9/13/11—NRR e-mail capture, STP license renewal, State Historic Preservation Office meeting	ML11259A029
9/22/11	STP, Units 1 and 2, response to RAIs for LRA (TAC Nos. ME4938 and ME5122)	ML11270A060
9/28/11	RAIs for the review of the STP LRA (TAC Nos. ME4938 And ME5122)	ML11269A002
10/18/11	STP, Units 1 and 2, response to RAIs for LRA (TAC Nos. ME4938 and ME5122)	ML11298A085
10/26/11	STP, Units 1 and 2, contact information change, LRA (TAC Nos. ME4936 and ME4937)	ML11305A075
10/26/11	STP, Units 1 and 2, correction to NRC distribution list	ML11307A371
11/17/11	STP, Units 1 and 2, license renewal environmental review (Kickapoo Traditional Council)	ML11269A011

Date	Correspondence Description	ADAMS No.
11/17/11	STP, Units 1 and 2, license renewal environmental review (Tonkawa Tribe of Oklahoma)	ML11269A015
11/17/11	STP, Units 1 and 2, clarification to response to RAI for LRA (TAC Nos. ME4938 and ME5122)	ML11333A094
11/29/11	11/1/11—Summary of telephone conference call between the NRC and STPNOC concerning RAIs pertaining to the STP LRA	ML11307A381
11/29/11	STP, Units 1 and 2, license renewal environmental review (Tap Pilam-Coahuiltecan Nation)	ML11269A112
1/4/12	12/15/11—Summary of telephone conference call between NRC and STPNOC concerning RAI pertaining to the STP LRA	ML11350A222
1/10/12	STP, Units 1 and 2, clarification of Information in support of the review of the LRA	ML12011A188
1/19/12	STP, Units 1 and 2, license renewal environmental review	ML11269A063
2/14/12	1/31/12—Summary of telephone conference call held between the NRC and STPNOC concerning RAIs pertaining to the STP LRA	ML12033A134
2/16/2012	STP, Units 1 and 2, clarification to response to RAI for LRA (TAC Nos. ME4938 and ME5122)	ML12053A259
2/29/2012	RAI for the Review of the STP LRA (TAC Nos. ME4938 And ME5122)	ML12017A128
2/29/2012	1/7/12—Summary of telephone conference call between the NRC and STPNOC concerning RAIs pertaining to the STP	ML12047A285
3/12/2012	STP, Units 1 and 2, response to RAIs for LRA (TAC Nos. ME4938 and ME5122)	ML12079A014
4/17/2012	STP, Units 1 and 2, renewal of the Wastewater Discharge Permit	ML12114A198
5/8/2012	NEPA consultation—Waterborne outbreak	ML12128A061
5/18/2012	Environmental Permit Updated Status	ML12142A002

APPENDIX F
NRC STAFF EVALUATION OF SEVERE ACCIDENT MITIGATION
ALTERNATIVES

1 NRC STAFF EVALUATION OF SEVERE ACCIDENT MITIGATION 2 ALTERNATIVES

3 F.1 Introduction

4 South Texas Project Nuclear Operating Company (STPNOC) submitted an assessment of
5 severe accident mitigation alternatives (SAMAs) for the South Texas Project, Units 1 and 2,
6 (STP) as part of its Environmental Report (ER) (STPNOC 2010). This assessment was based
7 on the most recent STP probabilistic risk assessment (PRA) available at that time, a
8 plant-specific offsite consequence analysis performed using the MELCOR Accident
9 Consequence Code System 2 (MACCS2) computer code, and insights from the STP individual
10 plant examination (IPE) and individual plant examination of external events (IPEEE)
11 (HL&P 1992). In identifying and evaluating potential SAMAs, STPNOC considered SAMAs that
12 addressed the major contributors to core damage frequency (CDF) and population dose at STP,
13 as well as SAMA candidates found to be potentially cost beneficial in six other license renewal
14 applications (LRAs). STPNOC initially identified a list of 21 potential SAMAs. This list was
15 reduced to five unique SAMA candidates by eliminating SAMAs that are not applicable to STP
16 for one or more of the following reasons:

- 17 • The SAMA has design differences at STP.
- 18 • The SAMAs have already been implemented at STP.
- 19 • The SAMA has estimated implementation costs that would exceed the dollar
20 value associated with eliminating the severe accident risk at STP.

21 STPNOC assessed the costs and benefits associated with each of the potential SAMAs and
22 concluded in the ER that none of the candidate SAMAs evaluated are potentially cost beneficial.

23 As a result of the review of the SAMA assessment, the U.S. Nuclear Regulatory Commission
24 (NRC) staff (the staff) issued requests for additional information (RAIs) to STPNOC by letters
25 dated May 31, 2011 (NRC 2011a), and September 1, 2011 (NRC 2011b), and in conference
26 calls for clarification on July 28, 2011 (NRC 2011c), and January 31, 2012 (NRC 2012). Key
27 questions concerned the following:

- 28 • the historical development of the Level 1 and Level 2 PRA and model
29 changes that most impacted CDF,
- 30 • changes to STP design and operation since the version of the PRA used for
31 the SAMA analysis (referred to as the STP_REV6 model, dated 2009),
- 32 • differences between STP, Units 1 and 2, designs or operation and
33 identification of shared systems,
- 34 • the impact of open items and issues from the peer review of the PRA human
35 reliability analysis (HRA),
- 36 • the process used to map Level 1 results into the Level 2 analysis and to
37 group containment event tree (CET) end states into release categories,
- 38 • the selection of representative analysis cases,
- 39 • population assumptions used in the Level 3 analysis,
- 40 • the uncertainty analysis,

Appendix F

- 1 • the impact of new information on fire- and seismic-initiated sequences, and
- 2 • further information on the cost-benefit analysis of several specific candidate
- 3 SAMAs and low cost alternatives.

4 STPNOC submitted additional information by letters dated July 5, 2011 (STPNOC 2011a),
5 August 23, 2011 (STPNOC 2011b), January 19, 2012 (STPNOC 2012a), and
6 February 16, 2012 (STPNOC 2012b). In these responses to the RAIs, STPNOC provided:

- 7 • a listing of the PRA model changes that had the most impact on CDF,
- 8 • identification of design and operation changes since the freeze date and their
- 9 impact on PRA results,
- 10 • identification of design differences between units as well as shared systems,
- 11 • identification and an assessment of the impact of open items and issues from
- 12 the PRA reviews,
- 13 • a discussion of the process for binning the source term release categories
- 14 into release category groups,
- 15 • clarification of the bases for selecting representative analysis cases for each
- 16 release category group,
- 17 • a discussion of the uncertainty analysis,
- 18 • further details on the external events PRA models including the impact of new
- 19 information on fire and seismic sequences, and
- 20 • additional information regarding several specific SAMAs.

21 STPNOC's responses addressed the staff's concerns and did not result in the identification of
22 any potentially cost-beneficial SAMAs.

23 An assessment of the SAMAs for STP is presented in Sections F.2 through F.6.

24 **F.2 Estimate of Risk for STP**

25 STPNOC's estimates of offsite risk at STP are summarized in Section F.2.1. The summary is
26 followed by the staff's review of STPNOC's risk estimates in Section F.2.2.

27 **F.2.1 STPNOC's Risk Estimates**

28 Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA
29 analysis. The first is the STP Level 1 and Level 2 PRA model, which reflects (a) the plant
30 design configuration as of December 31, 2007, and (b) the plant data from January 1, 1998,
31 through December 31, 2007, for component failure and equipment unavailability data
32 (STPNOC 2010).

33 The second is a supplemental analysis of offsite consequences and economic impacts
34 (essentially a Level 3 PRA model) developed specifically for the SAMA analysis. The SAMA
35 analysis is based on the most recent STP Level 1 and Level 2 PRA model available at the time
36 of the ER, referred to as the STP_REV6 model. The scope of the Level 1 model includes
37 internal and external initiating events.

38 The STP CDF is approximately 6.4×10^{-6} per year for both internal and external events, as
39 determined from quantification of the Level 1 PRA model. The CDF is based on the risk

1 assessment for internally initiated events, which includes internal flooding, and external events,
2 which includes fire, seismic, external flooding, and tornado events. The internal events CDF is
3 approximately 3.9×10^{-6} per year. The external events CDF is approximately 2.5×10^{-6} per year.
4 The external events CDF includes contributions of approximately 1.0×10^{-6} per year due to fire
5 events, 7.3×10^{-8} per year due to seismic events, and 1.4×10^{-6} per year due to other external
6 events (STPNOC 2010). When determined from the sum of the CET sequences, or Level 2
7 PRA model, the CDF is approximately 6.2×10^{-6} per year for both internal and external events.
8 The 6.2×10^{-6} is used as the baseline CDF in the SAMA evaluations (STPNOC 2010).

9 Note that the above results, and those given in Tables F–1 through F–5, are based upon the
10 STP model of record (STP_REV6) as presented in the ER (STPNOC 2010) and do not include
11 STPNOC’s responses to RAIs. The RAIs consider the impact of new industry information
12 concerning internal fire and seismic initiated events. The results relating to these RAIs are
13 discussed in Sections F.2.2 and F.6.2.

14 The breakdown of CDF by initiating event is provided in Table F–1, Table F–2, Table F–3, and
15 Table F–4 for internal, fire, seismic, and other external events, respectively (STPNOC 2011a).

16 Table F–1 shows how internal events contribute about 61 percent of the total CDF. The largest
17 contributors to the internal event CDF are two loss of offsite power (LOOP) events, “Loss of All
18 Offsite Power” and “Loss of 345kV Offsite Power,” which contribute 15 percent and 10 percent,
19 respectively, to the total CDF.

20 Table F–2 shows how fire events make up the next largest contributor with about 16 percent
21 contribution to the total CDF. “Fire Zone 047 Scenario X” and “Fire Zone 071 Scenario X” are
22 the largest contributors with 6 percent and 3 percent contribution, respectively, to the total CDF.

23 Table F–3 shows how seismic events make up a small contribution of about one percent to the
24 total STP CDF. Seismic events with 0.4 g acceleration and 0.6 g acceleration are the largest
25 contributors to the seismic event CDF, contributing 0.6 percent and 0.3 percent, respectively.

26 Table F–4 shows how other external events (excluding fire and seismic) make up the next
27 largest contributor, adding up to about 22 percent of the total CDF. “Tornado Induced Failure of
28 Switchyard and Essential Cooling Pond (ECP)” and “Essential Cooling Water (ECW) Failure
29 due to Breach of Main Cooling Reservoir (MCR)” are the largest contributors, with 17 percent
30 and 5 percent contribution, respectively, to the total CDF.

31 The STP Level 2 PRA model that forms the basis for the SAMA evaluation is an updated
32 version of the IPE Level 2 model with the latest update incorporated in the 2005 Revision
33 (STP_REV5). The Level 2 model is linked to the Level 1 model by passing the status of all top
34 events previously evaluated in the Level 1 model. The Level 1 model includes the status of all
35 systems needed for the Level 2 analysis. The CET, containing only phenomenological events,
36 is then quantified using these inputs.

37 The CET considers the influence of physical and chemical processes on the integrity of the
38 containment and on the release of fission products once core damage has occurred. The
39 quantified CET sequences are binned into a set of end-states or release categories that are
40 subsequently grouped into four major release groups that provide the input to the Level 3
41 consequence analysis. The frequency of each major release group was obtained by summing
42 the frequency of the individual accident progression CET endpoints (or release categories) that
43 were binned (categorized) into the major release group. Source terms were developed for nine
44 release categories using the results of Modular Accident Analysis Program (MAAP 4.0.5)
45 computer code calculations. From these results, source terms were chosen to be
46 representative of the four major release groups (STPNOC 2011a). The results of this analysis
47 for STP are provided in Table F.3–2 of ER Attachment F (STPNOC 2010).

1

Table F-1. STP Core Damage Frequency for Internal Events

Initiating event ^(a)	CDF (per year)	% Contribution to internal events CDF ^(b, c)	% Contribution to total CDF
Loss of all offsite power	9.6×10^{-7}	25	15
Loss of 345kV offsite power	6.3×10^{-7}	16	10
Steam generator tube rupture (SGTR)	4.4×10^{-7}	11	7
Excessive loss-of-coolant accident (LOCA)	3.2×10^{-7}	8	5
Steam line break outside containment	2.8×10^{-7}	7	4
Loss of electrical auxiliary building heating, ventilation and air conditioning (HVAC)	2.6×10^{-7}	7	4
Turbine trip	1.8×10^{-7}	5	3
Partial loss of main feedwater	1.5×10^{-7}	4	2
Reactor coolant pump (RCP) seal LOCA	1.5×10^{-7}	4	2
Interfacing system LOCA (ISLOCA)	1.3×10^{-7}	3	2
Loss of DC busses	9.7×10^{-8}	2	2
Small LOCAs	7.5×10^{-8}	2	1
Reactor trip	6.5×10^{-8}	2	1
Other internal events	3.6×10^{-7}	9	6
Total CDF (internal events)	3.9×10^{-6}	100	64

^(a) The impact of the sensitivity analysis to updated fire and seismic data on the total CDF is not included in these results. Section F.2.2 provides a discussion of these impacts.

^(b) Obtained from CDF given in ER Table F.2-1 (STPNOC 2010) divided by the total internal events CDF of 3.89×10^{-6} .

^(c) May not total to 100 percent due to round off.

2

3

1

Table F–2. STP Core Damage Frequency for Fire Events

Fire initiator description ^(a)	CDF (per year)	% Contribution to fire CDF ^(b, c)	% Contribution to total CDF ^(c)
Fire zone 047 scenario X	4.0×10^{-7}	39	6
Fire zone 071 scenario X	2.1×10^{-7}	21	3
Fire zone 047 scenario B	1.8×10^{-7}	18	3
Control room fire scenario 18	1.2×10^{-7}	12	2
Fire zone 047 scenario BC	6.4×10^{-8}	6	1
Control room fire scenario 23	2.6×10^{-8}	3	0.4
Fire zone 147 scenario O	1.1×10^{-8}	1	0.2
Control room fire scenario 10	1.0×10^{-9}	<1	<0.1
Total CDF (fire events)	1.0×10^{-6}	100	16

^(a) The impact of the sensitivity analysis to update fire and seismic data on the total CDF is not included in these results. Section F.2.2 provides a discussion of these impacts.

^(b) Obtained from CDF given in ER Table F.2-1 (STPNOC 2010) divided by fire events CDF of 1.02×10^{-6} .

^(c) May not total to 100 percent due to round off.

2

Table F–3. STP Core Damage Frequency for Seismic Events

Initiating event ^(a)	CDF (per year)	% Contribution to seismic CDF ^(b, c)	% Contribution to total CDF ^(c)
Seismic event, 0.4 g acceleration	4.1×10^{-8}	55	0.6
Seismic event, 0.6 g acceleration	2.1×10^{-8}	28	0.3
Seismic event, 0.2 g acceleration	9.8×10^{-9}	13	0.2
Seismic event, 0.1 g acceleration	2.1×10^{-9}	3	<0.1
Total CDF (seismic events)	7.3×10^{-8}	100	1.1

^(a) The impact of the sensitivity analysis to updated fire and seismic data on the total CDF is not included in these results. Section F.2.2 provides a discussion of these impacts.

^(b) Obtained from CDF given in ER Table F.2-1 (STPNOC 2010) divided by seismic events CDF of 7.31×10^{-8} .

^(c) May not total to 100 percent due to round off.

3

4

1

Table F–4. STP Core Damage Frequency for Other External Events

Initiating event ^(a)	CDF (per year)	% Contribution to other external events CDF ^(b, c)	% Contribution to total CDF ^(c)
Tornado induced failure of switchyard and ECP	1.1×10^{-6}	79	17
ECW failure due to breach of MCR	2.9×10^{-7}	21	5
External flooding scenarios 2–6	9.5×10^{-9}	<1	0.2
Flood induced LOOP	2.1×10^{-9}	<1	<0.1
Total CDF (other external events)	1.4×10^{-6}	100	22

^(a) The impact of the sensitivity analysis to updated fire and seismic data on the total CDF is not included in these results. Section F.2.2 provides a discussion of these impacts.

^(b) Obtained from CDF given in ER Table F.2-1 (STPNOC 2010) divided by other external events CDF of 1.41×10^{-6} .

^(c) May not total to 100 percent due to round off.

2 The offsite consequences and economic impact analyses use the MACCS2 code to determine
3 the offsite risk impacts on the surrounding environment and public. Inputs for these analyses
4 include plant-specific and site-specific input values for core radionuclide inventory, source term
5 and release characteristics, site meteorological data, projected population distribution (within a
6 50-mi radius) for the year 2050, emergency response evacuation modeling, and economic data.
7 The core radionuclide inventory is based on a plant-specific evaluation. The inventory
8 corresponds to the end-of-cycle values for STP operating at a projected future 4,100 megawatts
9 thermal (MWt). The current licensed power is 3,835 MWt (STPNOC 2010). The magnitude of
10 the onsite impacts (in terms of cleanup and decontamination costs and occupational dose) is
11 based on information provided in NUREG/BR-0184, *Regulatory Analysis Technical Evaluation*
12 *Handbook* (NRC 1997a).

13 In the ER, the applicant estimated the dose risk to the population within 80-km (50-mi) of the
14 STP site to be approximately 0.0174 person-Sievert (Sv) (1.74 person-roentgen equivalent man
15 (rem)) per year. The breakdown of the total population dose by containment release mode is
16 summarized in Table F–5. Large early releases are the dominant contributors (39 percent) to
17 the population dose risk at STP. Small early releases (with pre-existing small containment
18 failure) and late releases (with no sprays) are also significant contributors to the population dose
19 risk.

20

1 **Table F–5. Breakdown of Population Dose by Containment Release Mode**

Containment release mode (major release category—RC) ^(a)	Population dose (person-rem ^(b) per year)	% Contribution
RC I—large early releases (<3 hrs)	0.68	39
RC II—small early releases (<3 hrs)	0.59	34
RC III—late releases (>3 hrs)	0.42	24
RC IV—intact containment	0.05	3
Total	1.74	100

^(a) The impact of the sensitivity analysis to updated fire and seismic data on the release category frequency is not included in these results. Section F.2.2 provides a discussion of these impacts.

^(b) One person-rem=0.01 person-Sv.

2 F.2.2 Review of STPNOC's Risk Estimates

3 STPNOC's determination of offsite risk at STP is based on the following three major elements of
4 analysis:

- 5 (1) the Level 1 and 2 risk models that form the bases for the 2005 model (STP_REV5)
6 reviewed by the NRC staff for the approval of the Risk Managed Technical
7 Specification (RMTS) application, which is an updated version of the 1992 IPE
8 submittal (HL&P 1992), which incorporated both internal and external events,
- 9 (2) the modifications to the STP_REV5 model that have been incorporated into the
10 current STP PRA (STP_REV6), and
- 11 (3) the MACCS2 analyses performed to translate fission product source terms and
12 release frequencies from the Level 2 PRA model into offsite consequence measures.

13 Each of these analyses was reviewed to determine the acceptability of STPNOC's risk
14 estimates for the SAMA analysis, as summarized below.

15 The first STP Level 1 PRA was completed in 1989 to support a request for revising certain STP
16 technical specifications. This was subsequently updated and extended to incorporate a Level 2
17 analysis, as documented in the STP IPE. The 1989 PRA and the IPE incorporated internal fires
18 and all external events as well as internal event initiators. The internal events and fire events
19 portions of the 1989 PRA were reviewed extensively as part of the technical specification
20 change request approval (NRC 1994a). The NRC review of the IPE (NRC 1994b) concluded
21 that the applicant met the intent of Generic Letter (GL) 88-20 (NRC 1988). Although no
22 vulnerabilities were identified in the IPE, four improvements were identified. The ER indicated
23 that all of these improvements have been implemented.

24 The internal events CDF value from the 1992 IPE (4.3×10^{-5} per year) is near the average of the
25 values reported for other 4-loop Westinghouse plants. Figure 11.6 of NUREG-1560
26 (NRC 1997b) shows that the IPE based total internal events CDF for 4-loop Westinghouse
27 plants ranges from 3×10^{-6} per year to 2×10^{-4} per year, with an average CDF for the group of
28 6×10^{-5} per year. It is recognized that other plants have updated the values for CDF subsequent
29 to the IPE submittals to reflect modeling and hardware changes. The internal events CDF result
30 for STP used for the SAMA analysis (6.4×10^{-6} per year) is somewhat lower than that for other
31 plants of similar vintage. This is considered to be reasonable due to the unique design of STP,
32 which uses three independent emergency core cooling system trains and four auxiliary

Appendix F

1 feedwater pumps as well as having a significant amount of physical separation of the redundant
2 trains.

3 There have been many revisions to the original STP PRA model. The most relevant are the
4 IPE, Revision STP_1999 and the subsequent revisions leading up to the current revision used
5 in the SAMA assessment. A breakdown of the contributors to total CDF and a description of the
6 changes made to the STP PRA, since the peer reviewed Revision STP_1999, were provided in
7 response to NRC staff RAIs (STPNOC 2011a, 2011b). These changes are summarized in
8 Table F-6. The STP_REV6 model reflects the current (as of the date of the ER submittal) STP
9 configuration and design. In response to an RAI, STPNOC stated that a review of plant design
10 and operation changes made since the last model update indicates that one modification will
11 require a PRA model revision. STPNOC does not expect this change to have a significant
12 effect on the SAMA evaluation (STPNOC 2011a). The staff reviewed the response and agreed
13 with the applicant that the prospective change to the PRA model would not have a significant
14 effect on the SAMA evaluation.

15 The STP PRA model is a single unit model rather than a model that incorporates explicit events
16 in both units. In response to an RAI, STPNOC states that the STP, Units 1 and 2, are designed
17 to be identical; therefore, the PRA model applies to both STP, Units 1 and 2 (STPNOC 2011a).
18 However, STPNOC noted that there are two differences between Units 1 and 2 resulting from
19 the phased implementation of design changes over several different refueling outages. One,
20 involving load tap changers for engineered safety features transformers, was found to have less
21 than a 0.5 percent increase in CDF and large early release frequency (LERF). The other,
22 involving the addition of hand switches for the steam generator (SG) power operated relief
23 valves in the control room, will exist for only a few months and is expected to result in a
24 decrease in CDF and LERF (temporary modification to conservatively decrease CDF).

Table F-6. STP PRA Historical Summary

PRA version	Summary of significant changes from prior model	CDF ^(a) (per year)						LERF ^(a) (per year)	
		Internal events	Seismic	Fire	External floods	Flood MCR	High wind		Total
IPE/IPEEE ^(b) (1992)	Information from IPE/IPEEE report (HL&P 1992)	4.3×10^{-5}	1.4×10^{-6}	1.4×10^{-6}	1.4×10^{-6}	1.4×10^{-6}	1.4×10^{-6}	4.4×10^{-5}	9.9×10^{-7}
STP_1999 (9/2001)	2002 WOG peer review	8.8×10^{-6}	7.3×10^{-8}	1.4×10^{-6}	1.4×10^{-8}	2.9×10^{-7}	1.1×10^{-6}	1.2×10^{-5}	5.8×10^{-7}
STP_REV4 (9/2003)	Reviewed by the NRC staff for RMTS approval Incorporated updated plant-specific train unavailability data, updated initiating events and component failure data Incorporated latest operator error modeling and improved LOOP recovery modeling Included safety injection accumulator modeling for large and medium LOCAs Included hot leg recirculation modeling for Large LOCA Removed credit for 150-ton air conditioning chillers Improved modeling of support system initiating events	6.6×10^{-6}	7.3×10^{-8}	1.0×10^{-6}	1.4×10^{-8}	2.9×10^{-7}	1.1×10^{-6}	9.1×10^{-6}	5.4×10^{-7}
STP_REV41 ^(c)	Reviewed by the NRC staff for RMTS approval Incorporated operator depressurization for small LOCA Corrected modeling error for long-term	6.6×10^{-6}	NA	NA	NA	NA	NA	9.2×10^{-6}	NA

PRA version	Summary of significant changes from prior model	CDF ^(a) (per year)						LERF ^(a) (per year)	
		Internal events	Seismic	Fire	External floods	Flood MCR	High wind		Total
STP_REV42	<p>response for medium LOCA</p> <p>Requantified frequency for inadvertent opening of one or two pressurizer safety valves</p> <p>Corrected conditional split fractions definitions to correct errors in basic event importance calculations</p> <p>Re-binned several maintenance duration data variables to correct input problems with RISKMAN version being used</p> <p>Split fault tree basic events containing several components to better reflect individual component importance.</p>	NA	NA	NA	NA	NA	NA	9.3 x 10 ⁻⁶	5.1 x 10 ⁻⁷
STP_REV5 (9/2005)	<p>Reviewed by the NRC staff for RMTS approval</p> <p>Corrected issues found during component risk ranking</p> <p>Reviewed by the NRC staff for RMTS approval</p> <p>Incorporated plant modifications, procedure changes and data update through 2004</p> <p>Incorporated modifications to Class IE vital AC system and main steam isolation valves</p> <p>Level 2 update including containment capability analysis</p> <p>Updated HIRA to use of EPRI HRA</p>	7.7 x 10 ⁻⁶	7.3 x 10 ⁻⁸	9.7 x 10 ⁻⁷	1.4 x 10 ⁻⁸	2.9 x 10 ⁻⁷	1.1 x 10 ⁻⁶	1.0 x 10 ⁻⁵	6.1 x 10 ⁻⁷

PRA version	Summary of significant changes from prior model	CDF ^(a) (per year)							LERF ^(a) (per year)	
		Internal events	Seismic	Fire	External floods	Flood MCR	High wind	Total		
STP_REV51	calculator									
STP_REV51	Added RMTS macros	7.7×10^{-6}	7.3×10^{-8}	9.7×10^{-7}	1.4×10^{-8}	2.9×10^{-7}	1.1×10^{-6}	1.0×10^{-5}	6.1×10^{-7}	
STP_REV6 (2009)	Updated equipment reliability data Updated initiating event data Updated planned maintenance data Updated treatment of operator action for interfacing system LOCA	3.9×10^{-6}	7.3×10^{-8}	1.0×10^{-6}	1.3×10^{-8}	2.9×10^{-7}	1.1×10^{-6}	6.4×10^{-6}	5.0×10^{-7}	
(1/2012) ^(d)	Updated fire analysis for impact of new information in NUREG/CR-6850 (NRC 2005) Updated seismic analysis for impact of 2008 USGS seismic hazard (USGS 2008)	6.5×10^{-6}	3.0×10^{-6}	2.2×10^{-6}	NA	NA	NA	1.1×10^{-5}	7.3×10^{-7}	

NA—Not available, and value would not impact SAMA Review

^(a) All CDF values are point estimate values unless otherwise indicated.

^(b) Total external events CDF is given as 3.2 percent of the total or 1.4×10^{-6} per year.

^(c) Based on a response to an NRC staff RAI (STPNOC 2011a), which indicated that the CDF was higher than that for STP_REV4 by 1.2 percent.

^(d) Provided for information only. The PRA version is not considered a formal update. The CDF and LERF values were provided in response to NRC RAI (STPNOC 2012a). All values are based on truncation value of 1×10^{-14} , whereas prior results are based on a truncation value of 1×10^{-12} . Values for floods and high winds are not explicitly provided but are not expected to change from prior values.

Appendix F

1 In response to the same RAI, STPNOC indicated that the only shared systems between units
2 are the common switchyard, MCR, and the ECP (STPNOC 2011a). The NRC staff concludes
3 that since there are no other shared systems, modeling of the other unit's features is not
4 required, and a single unit model is appropriate for the SAMA assessment.

5 The NRC staff noted that the STP PRA results (ER Table F.2-1) do not include any internal
6 flooding initiated sequences. The NRC staff requested additional information (NRC 2011a), and
7 STPNOC, in response, indicated that the high degree of separation between redundant
8 divisions at STP resulted in all internal flooding sequences being screened out in the IPE and
9 IPEEE (STPNOC 2011a). The NRC staff considered these sequences, as part of the RMTS
10 review, discussed below. The staff concludes that the internal flood screening remains valid.

11 The NRC staff considered the peer reviews and other assessments performed for the STP PRA
12 and the potential impact of the review findings on the SAMA evaluation. The most relevant of
13 these are the 2002 peer review of the STP_1999 model, the STP self-assessment to the
14 requirements of Regulatory Guide (RG) 1.200, *An Approach for Determining the Technical*
15 *Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities* (NRC 2007a),
16 and the NRC staff's review of the STP models REV4, REV41, REV42, and REV5 in support of
17 STPNOC's RMTS application. STPNOC stated (STPNOC 2006) that the general assessment
18 of the peer review was that the STP PRA could effectively be used to support applications
19 involving risk significance determinations supported by deterministic analyses once the items
20 noted in the element summaries and fact and observations (F&O) sheets were addressed. All
21 F&O items were incorporated into STP_REV4, the original basis for the RMTS request, with two
22 major exceptions. These exceptions were the Level 2 update and reevaluation of the internal
23 flood modeling. The resolutions of the F&Os associated with the two exceptions were
24 incorporated into STP_REV5.

25 Revision 5 was performed to ensure that the STP PRA satisfies the requirements of Capability
26 Category II of the American Society of Mechanical Engineers (ASME) PRA Standard
27 (ASME 2002, 2003, 2005), as modified by RG 1.200, Appendix B. In response to an NRC RAI
28 on the RMTS application, STPNOC provided information that described how the STP PRA
29 meets the ASME criteria (STPNOC 2007). The HRA update, incorporated into Revision 5 of the
30 PRA, was the subject of a follow-on peer review. As a result of the peer review, STPNOC found
31 the F&Os from this review to not impact the RMTS application. In addition, these F&Os would
32 be fully evaluated as part of the Revision 6 PRA (STPNOC 2007). In response to an RAI,
33 STPNOC identified the content of the 10 Level A and B F&Os and stated that a preliminary
34 review of the F&Os concluded that their resolution is not expected to have a significant impact
35 on the STP PRA model or on the SAMA analysis (STPNOC 2011a).

36 The results of the NRC staff's review of the STP PRA through Revision 5 are documented in a
37 safety evaluation report (SER) appended to the NRC's approval of the STP RMTS
38 (NRC 2007a). The staff reviewed the scope and resolution of the 2002 peer review F&Os and
39 concluded that the items were properly addressed by the applicant based on the documented
40 resolutions. Based on the applicant's assessments and the NRC staff's reviews, the staff
41 determined that the STP PRA internal events models met the requirements of RG 1.200,
42 Revision 1, and were acceptable for the RMTS application.

43 Based on the following information, the NRC staff concludes that the internal events Level 1
44 PRA model is of sufficient quality to support the SAMA evaluation:

- 45 • The STP internal events PRA model has been peer-reviewed and the peer
46 review findings were all addressed.

- 1 • The model has been reviewed by the NRC staff as part of the RMTS
2 application approval.
- 3 • STPNOC has satisfactorily addressed NRC staff questions regarding the
4 PRA.

5 The STP PRA model includes seismic, fire, high winds, floods, and other external initiating
6 events as well as internal initiating events. The updated external core damage results are
7 described in ER Section F.2.1 and included in Table F–2 and Table F–3 along with the internal
8 events results.

9 The STP IPEEE was submitted as part of the IPE in 1992 (HL&P 1992), in response to
10 Supplement 4 of GL 88-20 (NRC 1991), and was based on the external events portion of the
11 prior STP PRA submitted and reviewed by the NRC staff to support an STP license amendment
12 (NRC 1994a). No fundamental weaknesses or vulnerabilities to severe accident risk concerning
13 the external events were identified in the STP IPEEE. In a letter dated December 15, 1998
14 (NRC 1998), the NRC staff stated that on the basis of the staff’s reviews of the PRA and IPEEE
15 submittal, the staff concludes that the STP IPEEE process is capable of identifying the most
16 likely severe accidents and severe accident vulnerabilities. Therefore, the STP IPEEE has met
17 the intent of Supplement 4 to GL 88-20.

18 The STP IPEEE seismic analysis used a seismic PRA following NRC guidance (NRC 1991) and
19 used the prior 1988 probabilistic safety assessment or PSA with enhancements recommended
20 by the NRC guidance. The seismic PRA included a seismic hazard analysis, a fragility analysis,
21 a plant logic analysis, and quantification of seismic CDF and various plant damage states.

22 The seismic hazard analysis estimated the annual frequency of exceedingly different levels of
23 ground motion. The STP IPEEE used the Electric Power Research Institute (EPRI)
24 (EPRI 1989) hazard curves and provided a sensitivity study result using the Lawrence
25 Livermore National Laboratory (LLNL) (NRC 1989) curve. Four discrete accelerations (0.1 g,
26 0.2 g, 0.4 g, and 0.6 g) were used to represent the full range of possible accelerations with point
27 estimate values of the frequency for each acceleration determined from the mean exceedance
28 frequency from the hazard curves.

29 The seismic fragility for safety-related structures, equipment, and components was determined
30 from the results of an assessment of the median factor of safety against failure and its statistical
31 variability under the safe-shutdown earthquake. System and fragility analysts supported the
32 fragility analysis by plant walk downs. Fragilities for 2 structures and 18 components with
33 median capacities less than 2.0 g were included in the model. Point estimate fragilities were
34 then determined for each of the seismic initiating event accelerations evaluated.

35 The plant logic analysis determines the consequences of various structural and component
36 failures in terms of CDF and release categories. A seismic failure event tree was used to
37 represent the seismic failure impact of various plant components. The resulting seismic
38 end-states were then inputted to support front line system trees that also consider non-seismic
39 unavailabilities.

40 The seismic CDF resulting from the STP IPEEE was calculated to be 2×10^{-7} per year based on
41 the EPRI hazard curve and 2×10^{-5} per year based on the LLNL hazard curve (HL&P 1992;
42 NRC 1989). The current CDF value, based on the EPRI hazard curve, is 7×10^{-8} per year. The
43 STP IPEEE did not identify any vulnerabilities due to seismic events or any potential
44 improvements to reduce seismic risk.

45 In order to gain a perspective on the impact of the most recent USGS study of seismic hazard
46 on the STP seismic risk, the NRC staff considered the analysis published for Generic Issue 199

Appendix F

1 (NRC 2010). This analysis, using a simplified methodology and the 2008 USGS hazard curves
2 (USGS 2008), gave a seismic CDF ranging from 9×10^{-7} to 6×10^{-6} per year for STP depending
3 on spectral acceleration frequency (the peak ground acceleration or 10, 5, or 1 Hz). These
4 results range from 8 to 14 times the corresponding seismic CDF value based on the EPRI
5 hazard curves and used in the SAMA assessment in the ER.

6 In response to an NRC RAI (NRC 2011b), STPNOC updated the results of the seismic risk
7 analysis to consider recent information for the determination of the seismic hazard frequency
8 (STPNOC 2012a). The update considered the EPRI, LLNL, and the 2008 USGS hazard curves.
9 In addition, STPNOC modified the seismic model to include:

- 10 • an increase in the number of seismic initiators from 4 to 6 to incorporate
11 higher accelerations than in the original model to be compatible with the
12 USGS hazard curves which extend to 2.1 g,
- 13 • the elimination of credit for a sequence specific recovery term that was
14 non-conservatively applied in the STP_REV6 model, and
- 15 • an update to seismic fragility curves for many selected components based on
16 a review of the original calculations and a plant walkdown associated with this
17 update.

18 The result of this update yielded a seismic CDF of 3.0×10^{-6} per year based on the 2008 USGS
19 hazard curves. The NRC staff considers these hazard curves to be the most current data
20 available. The impact of these curves on the SAMA analysis was provided in response to the
21 NRC RAI and is discussed further in Sections F.3.2 and F.6.2.

22 For SAMA sensitivity consideration, STPNOC has satisfactorily addressed RAIs regarding the
23 seismic PRA (taking into account the 2008 USGS hazard curves, which are the most current
24 data available). Hence, the NRC staff concludes that the updated seismic PRA model including
25 the impact of the 2008 USGS seismic hazard curves provides an acceptable basis for
26 identifying and evaluating the benefits of SAMAs.

27 The STP IPEEE fire analysis used a fire PRA following NRC guidance (NRC 1991) and
28 represented an update of the previous 1988 PSA. These analyses involved a two-phase
29 evaluation process—a spatial interaction analysis and the fire risk assessment. In the spatial
30 interaction analysis, a large set of internal fire scenarios was identified and screened based on
31 consideration of initiation frequency, spatial propagation, impact of mitigation, and the impact on
32 components to plant safety. The resulting fire scenarios considered important were then
33 analyzed in more detail. The resulting fire induced CDF of the unscreened areas was
34 calculated to be 5×10^{-7} per year (NRC 1998).

35 The 1988 STP fire PSA was reviewed by Sandia National Laboratory (SNL). The SNL review
36 concluded that the fire analysis was acceptable. This review was updated by the NRC staff in
37 the review of the fire PRA contained in the STP IPEEE with the conclusion that the analysis
38 examined the significant initiating events and dominant accident sequences for STP
39 (NRC 1998). The IPE and IPEEE PRA was also used to support STPNOC's request for
40 changes in certain technical specifications, which was granted in 1994 (NRC 1994).

41 The fire analysis was subsequently updated in 1994 to address Thermolag® fire barrier
42 performance. This fire analysis was supported by a comprehensive plant walkdown, in
43 May 1994, by STP personnel.

44 As part of the RMTS approval process, the applicant confirmed that all of the high-level
45 requirements for a fire PRA, given in RG 1.200, Revision 1, are addressed in the STP fire PRA
46 model and supporting documentation. In response to a staff concern regarding the screening of

1 fire sequences for the RMTS application, the applicant determined that there were no screened
2 sequences that should be included in the PRA model used for the RMTS application
3 (STPNOC 2007).

4 The NRC staff's RMTS SER states that, based on STPNOC's submittal and the staff's focused
5 reviews, the STP PRA fire model addresses the technical characteristics and attributes of these
6 elements, identified in RG 1.200, Revision 1, as they relate to issues that could impact the fire
7 model's adequacy for implementation of RMTS. Therefore, the staff finds that the STP PRA fire
8 model is acceptable for the RMTS application (NRC 2007a).

9 The NRC staff noted that the STP fire PRA may underestimate fire risk since it does not
10 incorporate the latest guidance in NUREG/CR-6850, *EPRI/NRC-RES Fire PRA Methodology for*
11 *Nuclear Power Facilities* (NRC 2005), and requested that STPNOC assess the impact of this
12 updated guidance on the SAMA analysis (NRC 2011a). In response to this RAI, STPNOC
13 provided the results of an assessment of the impact of the information and insights contained in
14 NUREG/CR-6850 (NRC 2005) concerning fire ignition frequencies, hot short probabilities, and
15 fire non-suppression probabilities on the eight non-screened fire scenarios included in the
16 STP_REV6 model (STPNOC 2012a). This assessment yielded a modified fire initiated CDF of
17 2.2×10^{-6} per year, which is about 2.2 times higher than that used in the SAMA analysis. The
18 impact of this modified fire CDF on the SAMA analysis is discussed in Sections F.3.2 and F.6.2.

19 Based on the following information, the NRC staff concludes that the fire PRA model, modified
20 to address new information and insights contained in NUREG/CR-6850 (NRC 2005), provides
21 an acceptable basis for identifying and evaluating the benefits of SAMAs:

- 22 • the STP fire PRA model has been updated since the IPEEE,
- 23 • the updated fire PRA was reviewed by the NRC staff for the RMTS
24 application, and
- 25 • STPNOC has satisfactorily addressed NRC staff RAIs regarding the fire PRA.

26 The STP IPE and IPEEE analysis of high winds, floods, and other external events was based on
27 the analysis in the 1988 PSA. A wide range of external events was considered; however, no
28 vulnerabilities were identified in the STP IPEEE due to high winds, floods, and other external
29 events.

30 For high winds, the STP design is such that critical structures can withstand winds in excess of
31 360 mph without major damage. The frequency of tornado winds in excess of 360 mph was
32 determined to be 8×10^{-9} per year. Since there is considerable safety margin in the design,
33 failures would not be expected until wind speeds exceed the design value. Tornado missiles
34 were also considered and the associated risk found to be small.

35 The likelihood of the ECW intake structure being clogged by debris generated by tornados,
36 hurricanes, or MCR failure were investigated with the dominant contribution being from
37 tornados. The frequency of tornados that cause blockage and failure of the switchyard was
38 found to be 1.2×10^{-6} per year (initiating frequency), leading to the currently assessed CDF of
39 1.1×10^{-6} per year.

40 External flooding of the STP site due to storms, offsite dam breaks, and onsite dam breaks were
41 considered and evaluated in the STP IPE and IPEEE. Of all the sources affecting plant safety,
42 the source of greatest importance was found to be the MCR. Many scenarios due to MCR
43 failure that resulted in impacts to various plant equipment were evaluated with the most
44 important being MCR failure leading to ECW failure. The current MCR failure frequency is
45 3.2×10^{-7} per year (MCR failure rate), leading to the currently assessed CDF of 2.9×10^{-7} per year.

Appendix F

1 A review of transportation and nearby facility accidents confirmed that there were no severe
2 accident vulnerabilities from these accidents (transportation and nearby facility external events).
3 The total contribution to CDF from these other non-fire and non-seismic external events is
4 1.4×10^{-6} per year.

5 For the STP RMTS license amendment approval, the NRC staff also reviewed the external
6 events modeled in the STP PRA and found that the data and assumptions applied were
7 reasonable and conservative. Based on the applicant's submittals and the staff reviews, the
8 staff concluded that the STP PRA external events models complied with the guidance of
9 RG 1.200, Revision 1, and was acceptable for the RMTS application (NRC 2007b).

10 Given that the STP IPEEE external events PRA model has been reviewed by the NRC staff,
11 that the current model has been reviewed by the NRC staff as part of the RMTS approval, and
12 that STPNOC has satisfactorily addressed NRC staff questions regarding the PRA, the NRC
13 staff concludes that the external events Level 1 PRA model, combined with the results of the
14 analysis of the impacts of new fire and seismic information, is of sufficient quality to support the
15 SAMA evaluation.

16 The NRC staff reviewed the general process used by STPNOC to translate the results of the
17 Level 1 PRA into containment releases, as well as the results of the Level 2 analysis, as
18 described in the ER and in response to NRC RAIs (STPNOC 2011a). As indicated above, the
19 Level 2 STP PRA model that forms the basis for the SAMA evaluation is essentially an updated
20 version of the IPE model.

21 The Level 2 analysis is linked to the Level 1 model by extending the model to include the CET,
22 which characterizes the accident phenomena. The CET considers the influence of physical and
23 chemical processes on the integrity of the containment and on the release of fission products
24 once core damage has occurred. Conditions specifically considered on entry into the CET
25 include reactor pressure at the time of core damage, steam generator heat removal, availability
26 of water in the reactor cavity, containment isolation and bypass status, containment spray
27 operation, containment heat removal, and the initiating event.

28 The STP CET addresses events occurring prior to vessel breach (including the potential for
29 in-vessel recovery), the phenomena associated with both in-vessel and ex-vessel accident
30 progression, containment integrity challenges, and the potential for containment failure. The
31 quantified CET sequences result in 63 possible end-states (or release categories) based on
32 combinations of reactor coolant system conditions at the time of vessel breach, the availability
33 of water to cool the core debris, the availability of containment spray, and the mode and timing
34 of containment failure. These release categories are then combined into the four major release
35 groups: I—large early release, II—small early release, III—late release, and IV—intact
36 containment (STPNOC 2011a). The 15 highest frequency release categories that contribute to
37 the major release groups are described in Table F.3-5 of the ER, Attachment F
38 (STPNOC 2010).

39 Source terms were developed by the applicant for eight release categories using the results of
40 MAAP 4.0.5 computer code calculations (STPNOC 2011a). The source term for the intact
41 release category were estimated from the Wolf Creek SAMA submittal, which is acceptable to
42 the NRC staff based on both the Wolf Creek and STP plants being Westinghouse 4-loop PWR
43 plants and the intact containment release category being a small contributor to the total
44 population dose risk. The results of these analyses for STP are provided in Table F.3-2 of the
45 ER, Attachment F (STPNOC 2010).

46 Representative source terms for each of the four major release groups were then selected from
47 the source terms for the nine release categories. This was done by reviewing the relevant

1 accident frequencies and release characteristics and selecting the representative accident
2 sequence and source term that was considered the one that best represented how a change in
3 major release group frequency would be reflected in terms of consequence. The representative
4 sequences and source terms selected for the major release groups are identified along with
5 consequence results in Table F.3-6 of the ER, Attachment F (STPNOC 2010).

6 In the ER, the applicant validated the selection of representative source terms for the major
7 release groups by recalculating the base case consequences using the set of nine release
8 categories, for which source terms were available, with their associated frequencies instead of
9 the four major release groups. As shown in ER Table F.3-8, the total dose-risk consequence
10 (person-rem per year) is identical to that using the representative source terms for the four
11 major release groups. The resulting offsite economic consequence risk (dollars per year) is
12 about 18 percent higher; however, this would only increase the maximum averted cost-risk
13 (MACR), which is discussed in Section F.6.1, by about 1.5 percent, which the applicant
14 considered a very minor change (within acceptable SAMA sensitivity consideration by the staff).

15 In an RAI, the NRC staff stated that while the reduced set of four representative sequences
16 provided essentially the same result as using the full set of nine sequences, this would not
17 necessarily be true for the cost-benefit analysis of individual SAMAs (NRC 2011a). Since the
18 source terms for the representative sequences are not necessarily those that would yield the
19 largest consequence, any SAMA that impacted a release category frequency whose source
20 term is higher than that for the selected representative sequence would have its benefit
21 underestimated. In response to the RAI, STPNOC provided a sensitivity analysis using the
22 most conservative relevant available source term for each of the nine major release categories.
23 The result was an increase in population dose risk of over 300 percent to 0.0532 person-Sv per
24 year (5.32 person-rem per year) and a corresponding increase in offsite economic cost risk of
25 over 400 percent. However, while the results showed that selecting alternate conservative
26 source terms for the consequence analysis significantly increases the benefit of the SAMAs
27 evaluated, the conclusions of the SAMA analysis were unchanged (STPNOC 2011a). This is
28 discussed further in Section F.6.2.

29 The ER notes that some of the MAAP source term release fractions were still increasing based
30 on calculation times of 24 to 48 hours. A sensitivity case was run with the releases extrapolated
31 to 72 hrs. The resulting population dose risk increased by 5 percent, and the offsite economic
32 cost risk increased by 3 percent.

33 As indicated above, the current STP Level 2 PRA model is an update of the model used in the
34 IPE. No vulnerabilities were identified in the IPE back-end (i.e., Level 2) analysis. Risk-related
35 insights and improvements discussed in the IPE submittal were discussed previously. The NRC
36 staff and contractor review of the IPE Level 2 analysis concluded that the applicant has made
37 reasonable use of the PSA techniques in performing the back end analysis and that the
38 techniques employed are capable of identifying severe accident vulnerabilities (NRC 1994b).

39 The LERF model was included in the Westinghouse Owner's Group (WOG) peer review
40 discussed previously, and all F&Os have been resolved (STPNOC 2007). The NRC staff's
41 review of the RMTS application concluded that all F&Os (including those pertaining to LERF)
42 were properly addressed. As stated previously, the staff concluded that the internal events PRA
43 satisfied the guidance of RG 1.200, Revision 1 (NRC 2007b).

44 Based on the NRC staff's review of the Level 2 methodology, the staff finds that STPNOC has
45 adequately addressed NRC staff RAIs, that the LERF model has been peer reviewed and all
46 F&Os resolved, and that the LERF model was recently reviewed and found to be in
47 conformance with RG 1.200 and the ASME PRA standard.

Appendix F

1 Based on these findings and the results of the sensitivity analysis, which showed that the
2 conclusions of the SAMA analysis are not changed by using the full set of nine release
3 categories, the NRC staff concludes that the Level 2 PRA provides an acceptable basis for
4 evaluating the benefits associated with various SAMAs.

5 STPNOC used the MACCS2 code and a core inventory from a plant-specific calculation to
6 determine the offsite consequences of activity release (STPNOC 2010). STPNOC indicated
7 that the core inventory was generated using ORIGEN2.1 based on a conservative projected
8 future power of 4,100 MWt for STP.

9 The NRC staff reviewed the process used by STPNOC to extend the containment performance
10 (Level 2) portion of the PRA to an assessment of offsite consequences (essentially a Level 3
11 PRA). This included consideration of the source terms used to characterize fission product
12 releases for the applicable containment release categories and the major input assumptions
13 used in the offsite consequence analyses. Plant-specific input to the code includes the source
14 terms for each source term category and the reactor core radionuclide inventory (both
15 discussed above), site-specific meteorological data, projected population distribution within an
16 80-km (50-mi) radius for the year 2050, emergency evacuation modeling, and economic data.
17 This information is provided in Section F.3 of Attachment F to the ER (STPNOC 2010).

18 All releases were modeled as being from the top of the reactor building. The thermal content of
19 each of the releases was assumed to be the same as ambient (a non-buoyant plume).
20 Sensitivity analyses were performed for the elevation and thermal content of the releases.
21 Decreasing the release height from the top of the reactor building to ground level and
22 25 percent, 50 percent, and 75 percent of containment height decreased the population dose
23 risk by 1 to 2 percent and offsite economic cost risk by 2 to 7 percent. Increasing the release
24 heat to 1 and 10 MW for each plume segment increased the population dose risk by 0 to
25 3 percent and the offsite economic cost risk by 2 to 7 percent. Building wake effects were also
26 investigated by increasing and decreasing the wake size by a factor of two. The population
27 dose risk showed no change, and the offsite economic cost risk either showed no change or
28 increased by 1 percent. The NRC staff notes that previous SAMA analyses have shown only
29 minor sensitivities to release height, buoyancy, and building wake effects. Based on the
30 information provided, the staff concludes that the release parameters used are acceptable for
31 the purposes of the SAMA evaluation.

32 STPNOC used site-specific meteorological data for the 2006 calendar year as input to the
33 MACCS2 code. The development of the meteorological data is discussed in Section F.3.5 of
34 Attachment F to the ER. The data were collected from the onsite meteorological monitoring
35 system and the National Weather Service measurements at nearby Palacios Municipal Airport.
36 Missing meteorological data were first filled in from the onsite backup tower. Gaps in onsite
37 data were filled in from the hourly data at the Palacios Municipal Airport. Remaining data gaps
38 were to be filled in by (in order of preference) using corresponding data from the primary tower
39 60-meter level (taking the relationship between the levels as determined from immediately
40 preceding hours), interpolation (if the data gap was less than 4 hours), or using data from the
41 same hour and a nearby day of a previous year. A sensitivity analysis of available data of
42 record was completed using MACCS2 and the meteorological data for the years 2006 and 2008
43 and found that data for the year 2006 resulted in the largest dose and economic cost risk and
44 this was used for the baseline cost-benefit analysis as appropriate. The population dose risk
45 decreased by 0 to 7 percent and the offsite economic cost decreased by 2 to 11 percent for
46 years 2008 and 2007, respectively. An additional sensitivity case was completed for rainfall in
47 the last spatial segment. The base case assumed rainfall at all times. The sensitivity study
48 allowed the rainfall to follow the onsite meteorology. The resulting population dose risk
49 decreased by 23 percent, and the offsite economic cost risk decreased by 35 percent. The

1 NRC staff notes that previous SAMA analyses results have shown little sensitivity to
2 year-to-year differences in meteorological data and concludes that the use of the 2006
3 meteorological data in the SAMA analysis is reasonable.

4 The population distribution used by the applicant as input to the MACCS2 analysis was based
5 on the year 2000 census data from an updated study for the potential construction of additional
6 units (STPNOC 2009). County growth rates were applied to obtain the year 2050 population
7 (Texas State Data Center 2006). In response to an NRC RAI, the applicant stated that the total
8 population in year 2000 for the SAMA analysis was 1.4 percent higher than the SECPOP2000
9 values presented in Section 2.6.1 of the ER (STPNOC 2011a). This was due to the updated
10 study using a population based on the construction of additional units that is not included in the
11 SECPOP2000 data. SECPOP2000 is a computer coded developed for the NRC by Sandia
12 National Laboratories to calculate the population within 20 and 50 miles of the site. In the RAI
13 response, STPNOC also provided the year 2050 rosette population distribution. The transient
14 population within the emergency planning zone (EPZ), was included in the residential population
15 data for year 2000 and projected to year 2050 (STPNOC 2011a). STPNOC further clarified that
16 the sector multipliers for the major metropolitan areas within the 50-mi radius included any
17 expected high growth rates based on the county-weighted population projections
18 (STPNOC 2011a). The NRC staff considers the methods and assumptions for estimating
19 population reasonable and acceptable for purposes of the SAMA evaluation.

20 The emergency evacuation model was modeled as a single evacuation zone extending out
21 16 km (10 mi) from the plant (the EPZ). The applicant assumed that 95 percent of the
22 population would evacuate. This assumption is conservative relative to the NUREG-1150 study
23 (NRC 1990), which assumed evacuation of 99.5 percent of the population within the EPZ. The
24 evacuated population was assumed to move at an average radial speed of approximately
25 1.34 meters per second (mps) (3.0 mph) with a delayed start time of 60 minutes after
26 declaration of a general emergency for one-half the population. The evacuation speed was
27 projected to conditions associated with year 2050 by conservatively assuming that all of the
28 roads in 2007 transported traffic at their maximum throughput and that no new roads would be
29 constructed. In response to an NRC RAI, the applicant clarified that the year 2007 evacuation
30 study population was based on the exponential growth rate from year 2000 to year 2050
31 (STPNOC 2011a). Transient population was not calculated separately. A general emergency
32 declaration was assumed to occur when plant conditions degraded to a point where it was
33 judged that there was a credible risk to the public, based on STP emergency action levels.
34 Times for declaration of emergency are presented in Table F.3-4 of the ER. A sensitivity study
35 was completed where the delayed population was increased and decreased by a factor of two.
36 The population dose risk increased and decreased by 1 percent, respectively, and the offsite
37 economic cost risk showed no change. Another sensitivity study was performed for the
38 evacuation speed, where the speed was increased and decreased by a factor of two. The
39 increased evacuation speed resulted in a population dose risk decrease by 1 percent and no
40 change in offsite economic cost risk. The decreased evacuation speed resulted in a population
41 dose risk increase of 2 percent and no change in offsite economic cost risk. The NRC staff
42 concludes that the evacuation assumptions and analysis are reasonable and acceptable for the
43 purposes of the SAMA evaluation.

44 SECPOP2000 (NRC 2003) was used to access site-specific agriculture and economic data from
45 the 1997 National Census of Agriculture for each of the counties surrounding STP to a distance
46 of 80 km (50 mi). The data file accessed by SECPOP2000 for that information was modified to
47 correct two errors in the issued version. These errors are generally known as the missing notes
48 parameter error and the missing county numbers error. In response to an NRC RAI, the
49 applicant clarified that a third error associated with column formatting of regional economic data

Appendix F

1 was also corrected (STPNOC 2011a). Region-wide wealth data (i.e., farm wealth and non-farm
2 wealth) were also based on county-weighted averages for the region within 80 km (50 mi) of the
3 site using data in the 1997 National Census of Agriculture, as accessed by SECPOP2000. In
4 addition, generic economic data that applied to the region as a whole, as described in
5 Section F.3.3 of the ER, were revised from the MACCS2 sample problem input in order to
6 account for cost escalation since 1986 (the year the input was first specified). An escalation
7 factor of 1.94, representing cost escalation from 1986 to January 2009, was applied to
8 parameters describing cost of evacuating and relocating people, land decontamination, and
9 property condemnation.

10 The NRC staff concludes that the methodology used by STPNOC to estimate the offsite
11 consequences for STP, combined with the results of the sensitivity analysis associated with the
12 selection of representative source terms, provides an acceptable basis from which to proceed
13 with an assessment of risk reduction potential for candidate SAMAs. Accordingly, the NRC staff
14 based its assessment of offsite risk on the CDF and offsite doses reported by STPNOC.

15 **F.3 Potential Plant Improvements**

16 The process for identifying potential plant improvements, an evaluation of that process, and the
17 improvements evaluated in detail by STPNOC are discussed in this section.

18 **F.3.1 Process for Identifying Potential Plant Improvements**

19 STPNOC's process for identifying potential plant improvements (SAMAs) consisted of the
20 following elements:

- 21 • review of the most significant split fractions from the current, plant-specific
22 PRA,
- 23 • review of potential plant improvements identified in the STP IPE and IPEEE,
- 24 • review of cost-beneficial SAMA candidates identified in LRAs for six other
25 nuclear power plant sites, and
- 26 • review of generic SAMA candidates from Nuclear Energy Institute
27 (NEI) 05-01 (NEI 2005) to identify SAMAs that might address areas of
28 concern in the STP PRA.

29 Based on this process, an initial set of 21 candidate SAMAs, referred to as Phase I SAMAs,
30 were identified. In Phase I of the evaluation, STPNOC performed a qualitative screening of the
31 initial list of SAMAs and eliminated SAMAs from further consideration using the following
32 criteria:

- 33 • The SAMA is not applicable to STP due to design differences.
- 34 • The SAMA has already been implemented at STP or would achieve results
35 that have already been achieved at STP by other means.
- 36 • The SAMA has estimated implementation costs that would exceed the dollar
37 value associated with eliminating all severe accident risk at STP.

38 Based on this screening, 16 SAMAs were eliminated, leaving 5 SAMAs for further evaluation.
39 The results of the Phase I screening analysis are shown in Table F.5-3 of Attachment F to the
40 ER. The remaining SAMAs, referred to as Phase II SAMAs, are listed in Table F.6-1 of
41 Attachment F to the ER (STPNOC 2010). In Phase II, a detailed evaluation was performed for
42 each of the five remaining SAMA candidates, as discussed in Sections F.4 and F.6.

1 F.3.2 Review of STPNOC's Process

2 STPNOC's efforts to identify potential SAMAs included explicit consideration of potential SAMAs
3 for both internal and external events since the STP PRA incorporates all initiating events
4 including internal, fire, seismic, high winds, and floods. The initial list of SAMAs generally
5 addressed the hardware considered to be important to CDF and release category frequency
6 from risk reduction worth (RRW) perspectives at STP and included selected SAMAs from prior
7 SAMA analyses for other plants.

8 STPNOC provided a tabular listing of the Level 1 PRA split fractions sorted according to their
9 RRW (STPNOC 2010). SAMAs impacting these split fractions would have the greatest potential
10 for reducing risk. STPNOC initially identified a RRW cutoff of 1.24, which corresponds to about
11 a 24 percent change in CDF given 100-percent reliability of the SAMA. This equates to a
12 benefit of approximately \$50,000 for a single unit or \$100,000 for both units. This is stated to be
13 the minimum implementation cost associated with a procedure change. The applicant indicated
14 that, at this cutoff, only two split fractions would need to be assessed for potential SAMAs.
15 Since this would only provide limited insights into potential SAMAs, STPNOC extended the
16 Level 1 importance review to include the top 40 split fractions, which corresponds to a RRW
17 of 1.022. This is the equivalent of a two-unit benefit of approximately \$11,000. All split fractions
18 in the Level 1 listing were reviewed to identify potential SAMAs and all were addressed by one
19 or more SAMAs (STPNOC 2010).

20 STPNOC also provided and reviewed the top 40 Level 2 PRA split fractions, corresponding to a
21 RRW of 1.027, for the release categories contributing over 97 percent of the population
22 dose-risk and over 99 percent of the offsite economic cost risk. Major release categories I
23 (large-early), II (small early), and III (late) were included in this assessment. The Level 2 split
24 fractions for release Category IV (containment intact) were not included in the review to prevent
25 split fractions unimportant to dose and cost risk from biasing the importance listing. All split
26 fractions in the Level 2 listing were reviewed to identify potential SAMAs, and all were
27 addressed by one or more SAMAs (STPNOC 2010).

28 As a result of the review of the Level 1 and Level 2 split fractions, 15 SAMAs were identified.
29 The applicant reviewed the cost-beneficial Phase II SAMAs from prior SAMA analyses for five
30 Westinghouse PWR sites and one General Electric BWR site. The applicant's review identified
31 six additional SAMAs. It was determined that the other Phase II SAMAs reviewed were already
32 represented by a SAMA identified from the importance list reviews, have low potential for risk
33 reduction at STP (i.e., do not address split fractions on the importance lists), or were not
34 applicable to STP.

35 The NRC staff noted that three SAMAs that were found to be cost beneficial at Prairie Island,
36 were not addressed by STPNOC. Similarly, three SAMAs were found to be cost beneficial at
37 Indian Point, were not addressed by STPNOC (NRC 2011a). STPNOC responded to an RAI
38 indicating that the SAMAs in question had either (a) been implemented at STP or (b) the cost of
39 implementing at STP exceeded the STP MACR (STPNOC 2011a), which justifies the screening
40 of the SAMAs. The staff agrees with this assessment.

41 Wolf Creek SAMA 13, "provide an alternate fuel oil tank with gravity feed capability," was
42 considered already implemented at STP by an existing capability that requires a pump. The
43 NRC staff noted that this has less capability than a gravity system and asked STPNOC to
44 further justify the screening of this SAMA. In response to the RAI, STPNOC provided additional
45 information on fuel oil storage at STP. The current STP fuel oil transfer system uses a gravity
46 feed line between the fuel oil storage tank and the standby diesel generator (SBDG). Each
47 SBDG is supplied from its own dedicated storage tank with a 7-day fuel oil supply. The system

Appendix F

1 described in the disposition of this SAMA is necessary only to refill these dedicated fuel oil
2 storage tanks (STPNOC 2011a).

3 SAMA 16, “provide a portable engine driven instrument air compressor,” was identified from a
4 review of industry cost-beneficial SAMAs and was screened out on the basis of having an
5 excessive cost. The basis for this SAMA was Prairie Island SAMA 22, which used nitrogen
6 bottles rather than a portable air compressor. In response to a staff RAI to consider this lower
7 cost alternative, the applicant indicated that loss of instrument air was not identified as a
8 significant contributor to STP risk (STPNOC 2011a). There is only one instrument air split
9 fraction with a RRW greater than 1.000. Its RRW of 1.016 corresponds to an averted cost-risk
10 of \$8,100, which would not result in a cost-beneficial SAMA using nitrogen bottles even at the
11 95th percentile CDF.

12 STPNOC considered the potential plant improvements described in the STP IPE (HL&P 1992),
13 which included both internal and external events, in the identification of plant-specific candidate
14 SAMAs. As a result of the review of the IPE, four improvements were identified and are listed in
15 Section F.5.1.4 of Attachment F of the ER. The review of the IPE did not lead to any additional
16 SAMA candidates since the four improvements identified in the IPE have already been
17 implemented at STP (STPNOC 2010).

18 The applicant also considered the potential for cost-beneficial SAMAs that address the external
19 event contributors screened out in the IPE and IPEEE because of “low risk.” For each of the
20 screened initiator types, a potential averted cost-risk (PACR) was determined based on an
21 estimate of the event occurrence frequency and assuming that the PACR is proportional to this
22 frequency compared to the CDF. The PACR for each of the seven screened event types is
23 given in Section F.5.1.5 of the ER. All are less than the minimum implementation cost for the
24 site of \$100,000 associated with a procedure change. This assessment includes internal floods,
25 which were screened out in the IPE and IPEEE. In response to an NRC RAI, the applicant
26 indicated that a review of the internal flood screening was performed in support of the RMTS
27 license amendment with the conclusion that the earlier screening remained valid
28 (STPNOC 2011a).

29 In response to an NRC RAI, the applicant clarified that the generic list of industry-based SAMA
30 candidates provided in NEI 05-01 (NEI 2005) was used as an idea source to generate SAMAs
31 for the important contributors identified from the STP PRA (STPNOC 2011a).

32 As discussed in Section F.2.2, in response to an NRC RAI, STPNOC provided an assessment
33 of the impact of updated information concerning fire and seismic risks on the overall STP risk.
34 The postulated fire and seismic changes affect the risk profile and increase the maximum
35 possible benefit if all risks were eliminated. Because of these changes, the importance analysis
36 review for the identification of candidate SAMAs and the screening of potential SAMAs was
37 redone. This reassessment is documented in Tables 8, 9 and 10 of the January 19, 2012,
38 submittal (STPNOC 2012a). One additional SAMA (SAMA 1a—install a “seismic safe” system)
39 was identified. This SAMA is similar to SAMA 1 and includes earthquake resistant heat removal
40 systems that could operate in the event of a seismically induced station blackout (SBO). This
41 SAMA was screened as having an excessive cost.

42 Based on this information, the NRC staff concludes that the set of SAMAs evaluated in the ER,
43 together with those identified in response to NRC staff RAIs, addresses the major contributors
44 to both internal and external event CDF.

45 The NRC staff questioned the applicant about potentially lower cost alternatives to some of the
46 SAMAs evaluated (NRC 2011a, 2012a), including:

- 1 • alternate SAMA(s) for sequences that are mitigated by SAMA 1 but do not
2 need tornado protection;
- 3 • use of the Technical Support Center (TSC) diesel generator (DG) to both
4 supply the positive displacement pump (PDP) and support auxiliary feedwater
5 (AFW) operation;
- 6 • installing an alternate intake structure for the ECW either in the ECP or the
7 MCR that would minimize the likelihood of debris preventing ECW cooling or
8 using temporary and portable pumps with a movable suction that could
9 provide water to the ECW system; and
- 10 • strengthening the ECW pump seismic restraints, which was identified as
11 limiting in the fragility update, in lieu of installing the complex “seismic safe”
12 system (STPNOC 2012a).

13 In response to the RAIs, the applicant addressed the suggested lower cost alternatives and
14 determined that they were either not feasible or were not cost beneficial
15 (STPNOC 2011a, 2012b). This is discussed further in Section F.6.2.

16 The NRC staff notes that the set of SAMAs submitted is not all-inclusive since additional,
17 possibly even less expensive, design alternatives can always be postulated. However, the NRC
18 staff concludes that the benefits of any additional modifications are unlikely to exceed the
19 benefits of the modifications evaluated and that the alternative improvements would be unlikely
20 to cost less than the least expensive alternatives evaluated when the subsidiary costs
21 associated with maintenance, procedures, and training are considered.

22 The NRC staff concludes that STPNOC used a systematic and comprehensive process for
23 identifying potential plant improvements for STP, and the set of SAMAs evaluated in the ER,
24 together with those evaluated in response to NRC staff inquiries, is reasonably comprehensive
25 and, therefore, acceptable. This search included reviewing insights from the STP plant-specific
26 risk studies that included internal initiating events as well as fire, seismic, and other external
27 initiated events, and reviewing plant improvements considered in previous SAMA analyses.

28 **F.4 Risk Reduction Potential of Plant Improvements**

29 In the ER, the applicant evaluated the risk-reduction potential of the five SAMAs that were not
30 screened out in the Phase I analysis and retained for the Phase II evaluation. The SAMA
31 evaluations were performed using realistic assumptions with some conservatism.

32 STPNOC used model re-quantification to determine the potential benefits for each SAMA. The
33 CDF, population dose, and offsite economic cost reductions were estimated using the STP
34 STP_REV6 PRA model. The changes made to the model to quantify the impact of SAMAs are
35 detailed in Section F.6 of Attachment F to the ER (STPNOC 2010). Table F–7 lists the
36 assumptions considered to estimate the risk reduction for each of the evaluated SAMAs, the
37 estimated risk reduction in terms of percent reduction in CDF and population dose, and the
38 estimated total benefit (present value) of the averted risk. The estimated benefits reported in
39 Table F–7 reflect the combined benefit in both internal and external events. The determination
40 of the benefits for the various SAMAs is further discussed in Section F.6.

41 The impact of SAMA 10, “enhance procedures to ensure the SGs are filled or maintained filled
42 in SGTR events to scrub fission products,” was modeled by reassigning the SGTR CDF
43 contribution for Release Categories I (7.48×10^{-9} per year) and III (1.35×10^{-7} per year) to Release
44 Categories II and IV, respectively. In response to an NRC RAI regarding the source of these
45 values, the applicant indicated that because SAMA 10 is dependent on the availability of

Appendix F

1 secondary side makeup, only a fraction of SGTR scenarios are relevant to the SAMA 10
2 evaluation. The relevant frequencies were obtained from an examination of the PRA model's
3 results (STPNOC 2011a).

4 The NRC staff noted that the evaluation of SAMA 12, "enhance procedures to prevent clearing
5 of RCS cold leg water seals," did not consider the condition in which non-condensable gases
6 such as hydrogen are present since this condition is not modeled in the PRA. Additionally, the
7 staff noted that SBO sequences were excluded in the modeling of this SAMA because AC
8 power is needed to start an RCP. The staff asked STPNOC to assess whether these potential
9 non-conservatisms impact the SAMA analysis (NRC 2011a). In response to the RAI, the
10 applicant clarified that the scenario leading to hydrogen gas generation condition is represented
11 conservatively in the induced SGTR event scenarios. The sequences for the scenarios are
12 included in the assessment of SAMA 12 (STPNOC 2011a). The applicant further clarified that
13 excluding the SBO sequences is appropriate because:

14 (a) Induced SGTR is not an issue for SBO scenarios in which offsite power is recovered
15 in time to prevent core damage.

16 (b) Plant procedures do not instruct the operators to start the RCPs for SBO scenarios in
17 which offsite power is restored only after core damage.

18 For these reasons, the applicant concluded that the evaluation of SAMA 12 is not
19 underestimated.

20 The NRC staff has reviewed STPNOC's bases for calculating the risk reduction for the various
21 plant improvements and concludes, with the above clarifications, that the rationale and
22 assumptions for estimating risk reduction are reasonable and generally conservative (i.e., the
23 estimated risk reduction is higher than what would actually be realized). Accordingly, the NRC
24 staff based its estimates of averted risk for the various SAMAs on STPNOC's risk reduction
25 estimates.

26 **F.5 Cost Impacts of Candidate Plant Improvements**

27 STPNOC estimated the costs of implementing the 21 Phase I SAMAs through the development
28 of site-specific cost estimates and use of other applicants' estimates for similar improvements.
29 The costs were developed on a site basis (i.e., two units). If the cost estimate was for a single
30 unit based on other applicants' estimates for similar improvements, the cost estimate was
31 multiplied by two to derive the costs on a site basis. The site-specific cost estimates did not
32 include (a) contingency cost (unexpected implementation obstacles) or (b) the cost of
33 replacement power during extended outages required to implement the modifications
34 (STPNOC 2010). This approach is in accordance with NEI 05-01 and conservative. The cost
35 estimates based on other applicants' estimates did not account for inflation, which is also
36 conservative.

37 In response to an NRC RAI regarding the source of the cost estimates, the applicant replied that
38 the scope and definition of the SAMA were initially developed by the PRA analyst and then
39 reviewed and modified by the STP design staff to account for any plant-specific issues that
40 could interfere with or improve the SAMA design. The major cost contributors were then
41 identified, and their cost magnitudes were estimated by the design engineers (cost estimating is
42 a normal part of STPNOC's design engineers' functions as appropriate) (STPNOC 2011a).

43 The NRC staff reviewed the applicant's cost estimates, presented in Table F-6.1 of
44 Attachment F to the ER in response to NRC RAIs (STPNOC 2011a). For certain improvements,
45 the NRC staff compared the cost estimates to estimates developed elsewhere for similar

1 improvements, including estimates developed as part of other applicants' analyses of SAMAs,
2 for operating reactors.

3 The NRC staff noted that the estimated cost of \$7.6M for SAMA 17a, "install Westinghouse
4 RCP shutdown seals," is higher than other estimates for Westinghouse improved seals such as
5 the estimate by Tennessee Valley Authority for Watts Bar Unit 2 of \$1.1M (TVA 2010). In
6 response to the RAI, STPNOC indicated that the STP RCP seal design is different from that
7 used at Watts Bar and other Westinghouse plants (STPNOC 2011a). Because of this unique
8 design, STP would incur an entire new seal design and associated engineering costs while the
9 other plants would be able to spread the costs over a larger number of units. STPNOC
10 provided the details of the STP cost estimate, which included engineering, procedure revision,
11 modified seal housing, new seals, and installation. The NRC staff notes that even with some
12 cost savings that might be possible, not included in STPNOC's estimate, the cost is expected to
13 be well above the Watts Bar estimate and the STP MACR. The NRC staff considers STPNOC's
14 justification for the cost of implementing SAMA 17a reasonable.

15 The NRC staff also noted that the estimated cost of \$4.5M for SAMA 14, "provide capability to
16 cross-tie emergency 4 KV divisions on a single unit," seems high given that an inter-unit
17 cross-tie is already available. In response to the RAI, the applicant stated that the original intent
18 of SAMA 14 was to provide the capability to perform the cross-tie between emergency 4 KV AC
19 buses within a unit rapidly enough to prevent an RCP seal LOCA. The most effective means for
20 achieving this capability was a direct bus-to-bus connection, which does not currently exist at
21 STP. An indirect path is, however, available through an emergency transformer using existing
22 hardware. Using this path would require significant engineering and procedure development
23 costs due to the potential for creating single failure potential among multiple divisions of
24 equipment. While the estimated costs for the work associated with this alternative is not cost
25 beneficial, STPNOC also notes that the available time to prevent RCP seal failure is such that
26 navigating through the procedures and implementing the cross-tie in time to prevent seal failure
27 is unlikely (STPNOC 2011a). The NRC staff considers STPNOC's justification for the cost of
28 implementing SAMA 14 reasonable.

29 In response to an NRC RAI (STPNOC 2011a), the applicant provided the details of the cost
30 estimates for two SAMAs: SAMA 3b, "install fire wrap on PDP cables in cable spreading room,"
31 and SAMA 11, "modify fire protection system to supply containment spray headers." The
32 detailed cost estimate for SAMA 11 supports the cost used and the conclusion in the SAMA
33 analysis (as discussed in the response). For SAMA 3b, the applicant estimated the engineering
34 portion of the cost to be \$250,000 per unit, which appears high to the NRC staff. The staff notes
35 that this estimated cost may be valid due to the need to identify the PDP cables (as explained
36 by the applicant). Furthermore, if the engineering costs were reduced by \$50,000 per unit, the
37 resulting total cost of \$700,000 (\$800K minus 2x\$50K) is still well above the benefit reported for
38 this SAMA (see Table F-7). The NRC staff concludes that, with the above clarifications, the
39 cost estimates provided by STPNOC are sufficient and appropriate for use in the SAMA
40 evaluation.

Table F-7. SAMA Cost-Benefit Screening Analysis for STP

SAMA ^(a)	Assumptions	% Risk reduction		Total benefit (\$)		Cost (\$)
		CDF	Population dose	Baseline (internal + external)	Baseline with uncertainty ^(b)	
3b ^(c) —Install fire wrap on PDP cables in cable spreading room	Eliminate failure of the PDP due to a fire in the cable spreading room	<1	<1	3K	7K	800K
4—Develop procedures to isolate CCW inside containment	eliminate failure of the operator action to isolate CCW	2	10	27K	72K	100K
10—Enhance procedures to ensure the SGs are filled or maintain filled in SGTR events to scrub fission products	Reassign a portion of the SGTR CDF contribution for the large early release category (7.48E-06 per year) and late release category (1.35E-07 per year) to the small early release category and intact containment release category, respectively	0	2	3K	8K	100K
12—Enhance procedures to prevent clearing of RCS cold leg water seals	Reassign the induced SGTR CDF contribution (2.4E-09 per year) for sequences in which offsite power is available from the large early release category to the intact containment release category	0	0	<1K	<1K	100K
13—Develop procedures to open doors or use portable fans for alternate SBDG room cooling or both	Eliminate failure of the operator action to provide SBDG room cooling	<1	0	1K	3K	100K
15—Develop emergency procedures for alternate essential ECWIS room cooling	Eliminate failure of the operator action to provide ECWIS room cooling	1	2	8K	20K	100K

^(a) The impact of the sensitivity analysis to updated fire and seismic data is not included in these results. Section F.6.2 provides a discussion of these impacts.
^(b) Based on the response to NRC staff RAI 1.d (STPNOC 2011b), the NRC staff increased the baseline benefits by a factor of 2.7 to account for uncertainties.
^(c) SAMA 3b retained as a Phase II SAMA based on the results of the uncertainty analysis.

1 **F.6 Cost–Benefit Comparison**

2 STPNOC’s cost-benefit analysis and the NRC staff’s review are described in the following
3 sections.

4 **F.6.1 STPNOC’s Evaluation**

5 The methodology used by the applicant was based primarily on NRC’s guidance for performing
6 cost-benefit analysis (i.e., NUREG/BR-0184 (NRC 1997a)). The guidance involves determining
7 the net value for each SAMA according to the following formula:

$$8 \quad \text{Net Value} = (\text{APE} + \text{AOC} + \text{AOE} + \text{AOSC}) - \text{COE}$$

9 where:

10	APE	= present value of averted public exposure (\$)
11	AOC	= present value of averted offsite property damage costs (\$)
12	AOE	= present value of averted occupational exposure costs (\$)
13	AOSC	= present value of averted onsite costs (\$)
14	COE	= cost of enhancement (\$)

15 If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the
16 benefit associated with the SAMA, and it is not considered cost beneficial. STPNOC’s
17 derivation of each of the associated costs is summarized below.

18 NUREG/BR-0058 has been revised to reflect the NRC’s policy on discount rates. Revision 4 of
19 NUREG/BR-0058 states that two sets of estimates should be developed, one at 3 percent and
20 one at 7 percent (NRC 2004). The applicant provided a base set of results using the 3 percent
21 discount rate and a sensitivity study using the 7 percent discount rate (STPNOC 2010).

22 Averted Public Exposure (APE) Costs

23 The APE costs were calculated using the following formula:

$$24 \quad \text{APE} = \text{Annual reduction in public exposure } (\Delta \text{ person-rem per year})$$

$$25 \quad \quad \quad \times \text{ monetary equivalent of unit dose } (\$2,000 \text{ per person-rem})$$

$$26 \quad \quad \quad \times \text{ present value conversion factor } (15.04 \text{ based on a 20-year period}$$

$$27 \quad \quad \quad \text{with a 3-percent discount rate})$$

28 As stated in NUREG/BR-0184 (NRC 1997a), it is important to note that the monetary value of
29 the public health risk after discounting does not represent the expected reduction in public
30 health risk due to a single accident. Rather, it is the present value of a stream of potential
31 losses extending over the remaining lifetime, in this case, the renewal period, of the facility.
32 Thus, it reflects the expected annual loss due to a single accident, the possibility that such an
33 accident could occur at any time over the renewal period, and the effect of discounting these
34 potential future losses to present value. For the purposes of initial screening, which assumes
35 elimination of all severe accidents due to internal and external events, the applicant calculated
36 an APE of approximately \$52,300 for the 20-year license renewal period (STPNOC 2010).

37 Averted Offsite Property Damage Costs (AOC)

38 The AOCs were calculated using the following formula:

$$39 \quad \text{AOC} = \text{Annual CDF reduction}$$

$$40 \quad \quad \quad \times \text{ offsite economic costs associated with a severe accident (on a per event}$$

$$41 \quad \quad \quad \text{basis)}$$

$$42 \quad \quad \quad \times \text{ present value conversion factor}$$

Appendix F

1 For the purposes of initial screening, which assumes all severe accidents due to internal and
2 external events are eliminated, the applicant calculated an annual offsite economic risk of about
3 \$1,600 based on the Level 3 risk analysis. This results in a discounted value of approximately
4 \$24,400 for the 20-year license renewal period (STPNOC 2010).

5 Averted Occupational Exposure (AOE) Costs

6 The AOE costs were calculated using the following formula:

$$\begin{aligned} 7 \quad \text{AOE} = & \quad \text{Annual CDF reduction} \\ 8 & \quad \quad \quad \times \text{occupational exposure per core damage event} \\ 9 & \quad \quad \quad \times \text{monetary equivalent of unit dose} \\ 10 & \quad \quad \quad \times \text{present value conversion factor} \end{aligned}$$

11 The applicant derived the values for averted occupational exposure from information provided in
12 Section 5.7.3 of the NUREG/BR-0184 (NRC 1997a). Best estimate values provided for
13 immediate occupational dose (3,300 person-rem) and long-term occupational dose (20,000
14 person-rem over a 10-year cleanup period) were used. The present value of these doses was
15 calculated using the equations provided in the handbook in conjunction with a monetary
16 equivalent of unit dose of \$2,000 per person-rem, a real discount rate of 3 percent, and a time
17 period of 20 years to represent the license renewal period. For the purposes of initial screening,
18 which assumes all severe accidents due to internal and external events are eliminated, the
19 applicant calculated an AOE of approximately \$4,000 for the 20-year license renewal period
20 (STPNOC 2010).

21 Averted Onsite Costs

22 Averted onsite costs (AOSC) include averted cleanup and decontamination costs and averted
23 power replacement costs. Repair and refurbishment costs are considered for recoverable
24 accidents only and not for severe accidents. The applicant derived the values for AOSC based
25 on information provided in Section 5.7.6 of NUREG/BR-0184 (NRC 1997a).

26 The applicant divided this cost element into two parts—the onsite cleanup and decontamination
27 cost, also commonly referred to as averted cleanup and decontamination costs, and the
28 replacement power cost.

29 Averted cleanup and decontamination costs (ACC) were calculated using the following formula:

$$\begin{aligned} 30 \quad \text{ACC} = & \quad \text{Annual CDF reduction} \\ 31 & \quad \quad \quad \times \text{present value of cleanup costs per core damage event} \\ 32 & \quad \quad \quad \times \text{present value conversion factor} \end{aligned}$$

33 The total cost of cleanup and decontamination subsequent to a severe accident is estimated in
34 the NUREG/BR-0184 (NRC 1997a) to be $\$1.5 \times 10^9$ (undiscounted). This value was converted to
35 present costs over a 10-year cleanup period and integrated over the term of the proposed
36 license extension. For the purposes of initial screening, which assumes all severe accidents
37 due to internal and external events are eliminated, the applicant calculated an ACC of
38 approximately \$124,500 for the 20-year license renewal period (STPNOC 2010).

39 Long-term replacement power costs (RPC) were calculated using the following formula:

$$\begin{aligned} 40 \quad \text{RPC} = & \quad \text{Annual CDF reduction} \\ 41 & \quad \quad \quad \times \text{present value of replacement power for a single event} \\ 42 & \quad \quad \quad \times \text{factor to account for remaining service years for which replacement power} \\ 43 & \quad \quad \quad \text{is required} \end{aligned}$$

1 x reactor power scaling factor

2 The applicant based its calculations on the rated STP net electric output of
3 1,365 megawatt-electric (MWe) per unit and scaled up from the 910 MWe reference plant in
4 NUREG/BR-0184 (NRC 1997a). Therefore, the applicant applied a power-scaling factor of
5 1,365/910 (or STP net electric output divided by reference plant output) to determine the
6 replacement power costs. For the purposes of initial screening, which assumes all severe
7 accidents due to internal and external events are eliminated, STPNOC calculated an RPC of
8 approximately \$53,000 and an AOSC of approximately \$178,000 for the 20-year license
9 renewal period (STPNOC 2010).

10 Using the above equations, the applicant estimated the total present dollar value equivalent
11 associated with eliminating severe accidents from internal and external events at STP to be
12 about \$258,200 for a single unit, rounded to \$259,000. Because all SAMA costs and benefits
13 were provided on a site basis, the applicant doubled this value to obtain the two-unit site value
14 of \$518,000. This represents the dollar value associated with eliminating severe accident risks
15 for all internal and external events at the two STP units (referred to as the maximum averted
16 cost-risk (MACR)).

17 STPNOC's Results

18 If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA
19 was considered not to be cost beneficial. In the baseline analysis contained in the ER (using a
20 3 percent discount rate), STPNOC identified no potentially cost-beneficial SAMAs. STPNOC
21 also did not identify any potentially cost-beneficial SAMAs even after consideration of analysis
22 uncertainties.

23 **F.6.2 Review of STPNOC's Cost-Benefit Evaluation**

24 The cost-benefit analysis performed by STPNOC was based primarily on NUREG/BR-0184
25 (NRC 1997a) and discount rate guidelines in NUREG/BR-0058 (NRC 2004). The analysis was
26 executed consistently with this guidance. No SAMAs were determined to be cost beneficial in
27 STPNOC's baseline analysis in the ER.

28 The applicant considered the impact that possible increases in benefits from analysis
29 uncertainties would have on the results of the SAMA assessment. In the ER, STPNOC
30 presents the results of an uncertainty analysis of the internal and external events CDF for STP,
31 which indicates that the 95th percentile value is a factor of 1.6 greater than the mean CDF for
32 STP. The applicant considered whether any additional Phase I SAMAs might be retained for
33 further analysis if the MACR is increased by a factor of 1.6. One such SAMA was identified—
34 SAMA 3b, "install fire wrap on PDP cables in cable spreading room."

35 The applicant also considered the impact on the Phase II analysis if the estimated benefits from
36 internal and external events were increased by the 1.6 uncertainty factor. The additional
37 Phase I SAMA—SAMA 3b—was included in this sensitivity analysis. No SAMAs became cost
38 beneficial in STPNOC's analysis (STPNOC 2010).

39 In Section F.7.1 of the ER, the total CDF of 6.39×10^{-6} per year is described as being the mean
40 from the RISKMAN Monte Carlo quantification. In response to the NRC RAI on the uncertainty
41 analysis, STPNOC provided further information describing how the analysis was performed.
42 Since the quantification of the complete STP Level 1 PRA results in a large number of
43 sequences, for which an uncertainty analysis is impractical, a reduced set of sequences is used.
44 The results of the Monte Carlo analysis were then scaled so that the mean of the distribution

Appendix F

1 matched the mean of the CDF point estimates. The total CDF of 6.39×10^{-6} per year is,
2 therefore, a point estimate (STPNOC 2011a).

3 In response to an NRC RAI (NRC 2011a), STPNOC provided an uncertainty analysis that
4 indicated the 95th percentile CDF for the reduced set of sequences used is 1.59×10^{-5} per year
5 while the mean CDF and point estimate CDF for these sequences are 8.52×10^{-6} per year and
6 5.89×10^{-6} per year, respectively. The uncertainty multiplier was then revised to be the ratio of
7 the 95th percentile CDF to the point estimate, both for the reduced set of sequences, or
8 1.59×10^{-5} divided by 5.89×10^{-6} or 2.7 (STPNOC 2011b). The applicant considered whether any
9 additional Phase I SAMAs might be retained for further analysis if the MACR is increased by a
10 factor of 2.7. No additional SAMAs were identified.

11 The applicant also considered the impact on the Phase II analysis if the estimated benefits from
12 internal and external events were increased by the 2.7 uncertainty factor. No SAMAs became
13 cost beneficial in STPNOC's analysis (STPNOC 2011b).

14 The NRC staff noted that the original 1.6 uncertainty ratio developed for STP appeared to be
15 low considering the larger uncertainty bands associated with external events. The applicant
16 responded that, with the exception of seismic initiating events, probability distributions for all
17 initiating events were included in the Monte Carlo uncertainty analysis and that use of point
18 estimates for the seismic sequences was considered justified because of the small seismic CDF
19 contribution (STPNOC 2011a). However, as discussed in Section F.2.2, the seismic CDF may
20 be considerably larger than that used in the cost-benefit analyses presented in the ER.

21 Based on the following information, the NRC staff considers the use of the 2.7 uncertainty
22 multiplier for the SAMA analysis. This is consistent with the guidance provided in NEI 05-01
23 and acceptable:

- 24 • STPNOC's revised analysis used the higher uncertainty factor of 2.7, which is
25 generally higher than the 95th percentile uncertainty factor used in other
26 SAMA analyses.
- 27 • STPNOC performed a separate assessment of the impact of the higher
28 seismic CDF on the SAMA analysis.
- 29 • The increased uncertainty in seismic risk would not be expected to impact the
30 benefit of SAMAs not specifically addressing seismic failures.

31 STPNOC provided the results of additional sensitivity analyses in the ER, including use of a
32 7 percent discount rate and variations in MACCS2 input parameters. These analyses did not
33 identify any additional potentially cost-beneficial SAMAs (STPNOC 2010).

34 As discussed in Section F.2.2, the selection of representative sequences and associated source
35 terms to be used for the four major release categories could yield non-conservative risk
36 benefits. In response to an NRC RAI, the applicant provided the results of a sensitivity analysis
37 that used the most conservative relevant available source term for each of the nine major
38 release categories (STPNOC 2011a). STPNOC revised the baseline analysis using the
39 conservative source terms (using a 3 percent discount rate) and identified no potentially
40 cost-beneficial SAMAs. The NRC staff also increased the revised baseline benefits by a factor
41 of 2.7 to account for uncertainties and identified no potentially cost-beneficial SAMAs. The
42 results for the revised baseline and revised baseline with uncertainty are provided in Table F-8.

Table F–8. SAMA Cost-Benefit Screening Analysis for STP Using Conservative Source Terms

SAMA	Total benefit (\$)		Cost (\$)
	Conservative source terms revised baseline (internal + external)	Conservative source terms revised baseline with uncertainty ^(a)	
3b—Install fire wrap on PDP cables in cable spreading room	7K	18K	800K
4—Develop procedures to isolate CCW inside containment	35K	94K	100K
10—Enhance procedures to ensure the SGs are filled or maintain filled in SGTR events to scrub fission products	30K	80K	100K
12—Enhance procedures to prevent clearing of RCS cold leg water seals	<1K	<1K	100K
13—Develop procedures to open doors or use portable fans for alternate SBDG room cooling or both	4K	10K	100K
15—Develop emergency procedures for alternate ECWIS room cooling	14K	38K	100K

^(a) Based on the response to NRC RAI 1.d (STPNOC 2011b), the NRC staff increased the revised baseline benefits by a factor of 2.7 to account for uncertainties.

3 SAMAs identified primarily on the basis of the internal events analysis could provide benefits in
 4 certain external events, in addition to their benefits in internal events. Since the STP_REV6
 5 PRA model is an integrated internal and external events model, STPNOC's evaluation
 6 accounted for the potential risk reduction benefits associated with both internal and external
 7 events.

8 As discussed in Section F.2.2, the NRC staff asked STPNOC to assess the impact of the
 9 updated fire and seismic information on the SAMA analysis (NRC 2011a). In this analysis,
 10 STPNOC revised the baseline analysis using the updated fire and seismic information and
 11 increased these revised baseline analyses by 2.7 to account for uncertainties (using a 3 percent
 12 discount rate) and identified no potentially cost-beneficial SAMAs. The NRC staff also
 13 increased these revised benefits to account for the conservative source terms and identified no
 14 potentially cost-beneficial SAMAs. The results of these analyses are provided in Table F–9.

15

1
2
3

Table F-9. SAMA Cost-Benefit Screening Analysis for STP Using Updated Fire and Seismic Risk Analysis and Conservative Source Terms

SAMA	Total benefit (\$)		Cost (\$)
	Updated fire and seismic risk assessment (internal + external) with uncertainty ^(a)	Updated fire and seismic risk assessment (internal + external) with uncertainty ^(a) and conservative source terms ^(b)	
3b—Install fire wrap on PDP cables in cable spreading room	18K	44K	800K
4—Develop procedures to isolate CCW inside containment	71K	94K	100K
10—Enhance procedures to ensure the SGs are filled or maintain filled in SGTR events to scrub fission products	8K	84K	100K
12—Enhance procedures to prevent clearing of RCS cold leg water seals	3K	4K	100K
13—Develop procedures to open doors or use portable fans for alternate SBDG room cooling or both	16K	51K	100K
15—Develop emergency procedures for alternate ECWIS room cooling	22K	41K	100K

^(a) Baseline benefits increased by a factor of 2.7 to account for uncertainties (STPNOC 2012a, 2012b).
^(b) The impact of conservative source terms is obtained from the results provided in Table 2-11 of the July 5, 2011, submittal (STPNOC 2011a) compared with the results of the original submittal (STPNOC 2010).

4 As indicated in Section F.3.2, the NRC staff asked the applicant to evaluate potentially lower
5 cost alternatives to the SAMAs considered in the ER (NRC 2011a), as summarized below:

- 6 • SAMA 1, “involving using a portable AC generator for long term AFW support
7 and protecting the Technical Support Center (TSC) emergency diesel
8 generator (EDG) from tornado events,” was identified as a means of
9 mitigating a large number of important basic events. While the tornado
10 protection is important for high wind initiated sequences, many other
11 sequences would be mitigated without the cost of the tornado protection.
12 STPNOC provided the results of a cost estimate that did not include the costs
13 associated with the tornado protection. The revised cost of \$2.4 million is
14 much larger than the MACR; hence, such an alternative was determined not
15 to be cost beneficial (STPNOC 2011a).
- 16 • An additional alternate to SAMA 1 would be to use the TSC DG to both
17 supply the PDP and support AFW operation rather than requiring a portable
18 AC generator. STPNOC provide the results of a cost estimate for this
19 alternative. The revised cost of \$1.9 million remains above the MACR;

1 hence, this alternative was determined not to be cost beneficial
2 (STPNOC 2011a).

- 3 • The tornado induced failure of the switchyard and emergency cooling pond
4 could be mitigated by installing an alternate intake structure for the ECW
5 either in the ECP or the MCR that would minimize the likelihood of debris
6 preventing ECW cooling or using a temporary and portable pumps with a
7 movable suction that could provide water to the ECW system. In response to
8 the RAI, STPNOC provided the results of a cost estimate for a large surface
9 area debris cage as a less costly alternative to an additional intake structure.
10 This cost was \$828,000, which is approximately equal to the 95th percentile
11 MACR. The cost for the even less costly portable truck-mounted pump
12 alternative was given as \$350,000. While less than the MACR, this cost is
13 more than the benefit associated with eliminating the tornado initiated
14 sequence (17 percent of the total CDF), or \$143,000 at the 95th percentile;
15 hence, this alternative was determined to not be cost beneficial
16 (STPNOC 2011a).
- 17 • Strengthening ECW pump seismic restraints was identified as an alternative
18 to the SAMA 1a “seismic safe” system. While not mitigating all seismically
19 induce SBOs, it is potentially less costly than the complex “seismic safe”
20 system. STPNOC assessed the benefit of eliminating the risk to ECW pump
21 seismic failures using the Fussell-Vesely importance results and found the
22 benefit to be \$54,000 using the 2.7 uncertainty multiplier. However, it is not
23 cost beneficial because it is less than the minimum SAMA implementation
24 cost (for procedure changes) of \$100,000 (STPNOC 2012b). If adjusted to
25 incorporate the potential impact of the more conservative source terms, the
26 NRC staff estimates that the benefit could be somewhat greater
27 than \$100,000. However, based on the expected cost of strengthening the
28 seismic restraints, which would involve replacing 24 seismic bolts deeply
29 imbedded in concrete, and that the analysis conservatively assumes all of the
30 risk would be eliminated by replacing the seismic bolts, the NRC staff
31 concludes that this alternative is unlikely to be cost beneficial.

32 As indicated in Section F.4, the NRC staff questioned STPNOC on the risk reduction potential
33 for certain SAMAs (NRC 2011a, 2011b). In response to the RAIs, STPNOC addressed each
34 SAMA and addressed the staff concerns.

35 The NRC staff concludes that the costs of all of the SAMAs evaluated would be higher than the
36 associated benefits.

37 **F.7 Conclusions**

38 STPNOC compiled a list of 21 SAMAs based on a review of the most significant split fractions
39 from the plant-specific internal and external event PRA, insights from the plant-specific IPE,
40 cost-beneficial SAMAs from LRAs for other plants, and review of other industry documentation.
41 An initial qualitative screening removed SAMA candidates that:

- 42 • modified features not applicable to STP due to design differences,
- 43 • were determined to have already been implemented at STP or would achieve
44 results that have already been achieved at STP by other means, or

Appendix F

- 1 • have estimated implementation costs that would exceed the dollar value
2 associated with completely eliminating all severe accident risk at STP.

3 Based on this screening, 16 SAMAs were eliminated, leaving 5 candidate SAMAs for
4 evaluation.

5 For the remaining SAMA candidates, a cost-benefit analysis was performed, with the results
6 shown in Table F–7. The cost-benefit analyses showed that none of the SAMA candidates
7 were potentially cost beneficial in the baseline analysis. STPNOC performed additional
8 analyses to evaluate the impact of parameter choices and uncertainties on the results of the
9 SAMA assessment. In this process, one additional SAMA was identified for detailed
10 cost-benefit analysis. However, additional analyses did not result in the discovery of any of the
11 SAMA candidates being potentially cost beneficial.

12 The NRC staff reviewed the STPNOC analysis and concludes that the methods used, and the
13 implementations of those methods, were sound. The treatment of SAMA benefits and costs
14 supports the general conclusion that the SAMA evaluations performed by STPNOC are
15 reasonable and sufficient for the license renewal submittal.

16 The staff concurs with STPNOC’s conclusion that none of the candidate SAMAs are potentially
17 cost beneficial. This conclusion is based on the generally conservative treatment of costs and
18 benefits. This conclusion is consistent with the low residual level of risk indicated in the STP
19 PRA and the fact that STPNOC has already implemented the plant improvements identified
20 from the IPE and IPEEE.

21 **F.8 References**

22 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic Licensing of
23 Production and Utilization Facilities.”

24 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
25 protection regulations for domestic licensing and related regulatory functions.”

26 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for
27 Renewal of Operating Licenses for Nuclear Power Plants.”

28 10 CFR Part 100. *Code of Federal Regulations*, Title 10, *Energy*, Part 100, “Reactor Site
29 Criteria.”

30 [ASME] American Society of Mechanical Engineers. 2002. “Standard for Probabilistic Risk
31 Assessment for Nuclear Power Plant Applications.” ASME RA-S-2002, April 5, 2002.

32 [ASME] American Society of Mechanical Engineers. 2003. “Addenda to ASME RA-S-2002,
33 Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications.” ASME
34 RA-Sa-2003, December 5, 2003.

35 [ASME] American Society of Mechanical Engineers. 2005. “Addenda to ASME RA-S-2002,
36 Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications.” ASME
37 RA-Sb-2005, December 30, 2005.

38 [EPRI] Electric Power Research Institute. 1989. “Probabilistic Seismic Hazard Evaluations at
39 Nuclear Plant Sites in the Central and Eastern United States; Resolution of the Charleston
40 Earthquake Issues.” EPRI NP-6395-D, EPRI Project P101-53, Palo Alto, CA. April 1989.

41 [HL&P] Houston Lighting and Power Company. 1992. “South Texas Project Electric
42 Generating Station Level 2 Probabilistic Safety Assessment and Individual Plant Examination.”
43 August 1992. ADAMS No. ML0617001702, ML0617001790, ML0617001850.

- 1 [NEI] Nuclear Energy Institute. 2005. *Severe Accident Mitigation Alternative (SAMA) Analysis*
2 *Guidance Document*, NEI 05-01 (Rev. A). Washington, D.C. November 2005.
- 3 [NRC] U.S. Nuclear Regulatory Commission. 1988. Generic Letter 88-20, "Individual Plant
4 Examination for Severe Accident Vulnerabilities." November 23, 1988. ADAMS
5 No. ML031150465
- 6 [NRC] U.S. Nuclear Regulatory Commission. 1989. *Seismic Hazard Characterization of*
7 *69 Nuclear Plant Sites East of the Rocky Mountains*. Washington DC: NRC.
8 NUREG/CR-5250, Volume 5. 1989.
- 9 [NRC] U.S. Nuclear Regulatory Commission. 1990. *Severe Accident Risks: An Assessment*
10 *for Five U.S. Nuclear Power Plants—Final Summary Report*. Washington DC: NRC.
11 NUREG-1150, Volume 1. 1990.
- 12 [NRC] U.S. Nuclear Regulatory Commission. 1991. *Individual Plant Examination of External*
13 *Events (IPEEE) for Severe Accident Vulnerabilities*. Washington, DC: NRC. Generic Letter
14 No. 88-20, Supplement 4. June 28, 1991. ADAMS No. ML031150485
- 15 [NRC] U.S. Nuclear Regulatory Commission. 1994a. Letter from Suzanne C. Black, Director, to
16 William T. Cottle, Houston Lighting & Power Company. Subject: "Issuance of Amendment
17 Nos. 59 and 47 to Facility Operating License Nos. NPF-76 and NPF-80 and Related Relief
18 Request—South Texas Project, Units 1 and 2 (TAC Nos. M76048 and M76049)."
19 February 17, 1994. ADAMS No. ML021300134.
- 20 [NRC] U.S. Nuclear Regulatory Commission. 1994b. Memorandum to: Steven A. Varga
21 (USNRC-NRR) to M. Wayne Hodges (USNRC-RES), Subject: Review of South Texas Project
22 Individual Plant Examination (IPE) Submittal—Internal Events. December 1994.
- 23 [NRC] U.S. Nuclear Regulatory Commission. 1997a. *Regulatory Analysis Technical Evaluation*
24 *Handbook*. Washington, DC: NRC. NUREG/BR-0184. ADAMS No. ML050190193.
- 25 [NRC] U.S. Nuclear Regulatory Commission (NRC). 1997b. *Individual Plant Examination*
26 *Program: Perspectives on Reactor Safety and Plant Performance*. Washington, DC: NRC.
27 NUREG-1560. ADAMS No. ML063550244, ML063550228, and ML063470259.
- 28 [NRC] U.S. Nuclear Regulatory Commission. 1998. Letter from Thomas W. Alexion, U.S. NRC,
29 to William T. Cottle, STP Nuclear Operating Company. Subject: Review of south Texas
30 Project, Units 1 and 2 Individual Plant Examination of External Events (IPEEE) Submittal (JAC
31 Nos. M83676 and M83677). Washington, D.C. December 15, 1998.
- 32 [NRC] U.S. Nuclear Regulatory Commission. 2003. SECPOP2000: Sector Population, Land
33 Fraction, and Economic Estimation Program. Washington, DC: NRC. NUREG/CR-6525,
34 Rev. 1. August 2003. ADAMS No. ML032310279.
- 35 [NRC] U.S. Nuclear Regulatory Commission. 2004. *Regulatory Analysis Guidelines of the U.S.*
36 *Nuclear Regulatory Commission*. Washington, DC: NRC. NUREG/BR-0058, Rev. 4. ADAMS
37 No. ML003738939.
- 38 [NRC] U.S. Nuclear Regulatory Commission. 2005. *EPRI/NRC-RES Fire PRA Methodology for*
39 *Nuclear Power Facilities*. Washington, DC: NRC NUREG/CR-6850. September 2005.
- 40 [NRC] U.S. Nuclear Regulatory Commission. 2007a. Letter from Mohan C. Thadani, U.S.
41 NRC, to James J. Sheppard, STPNOC. Subject: "South Texas Project Units 1 and 2, Issuance
42 of Amendments Re: Broad-scope Risk-informed Technical Specifications Amendments (TAC
43 Nos. MD2341 and MD2342). Washington, D.C. July 13, 2007. ADAMS No. ML071780186.

Appendix F

- 1 [NRC] U.S. Nuclear Regulatory Commission. 2007b. *An Approach for Determining the*
2 *Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities.*
3 Regulatory Guide 1.200, Revision 1. Washington, D.C. January 2007. ADAMS
4 No. ML063170035.
- 5 [NRC] U.S. Nuclear Regulatory Commission. 2010. NRC Information Notice 2010-18: Generic
6 Issue 199, *Implications of Updated Probabilistic Seismic Hazard Estimates in Central and*
7 *Eastern United States on Existing Plants.* Washington, D.C. September 2, 2010. ADAMS
8 No. ML101970221.
- 9 [NRC] U.S. Nuclear Regulatory Commission. 2011a. Letter from Tam Tran, Project Manager,
10 to G. T. Powell, STPNOC. Subject: Requests for Additional Information for the Review of the
11 South Texas Project, License Renewal Application. Washington, D.C. May 31, 2011. ADAMS
12 No. ML11140A015.
- 13 [NRC] U.S. Nuclear Regulatory Commission. 2011b. Letter from Tam Tran, Project Manager,
14 to G. T. Powell, STPNOC. Subject: Requests for Additional Information for the Review of the
15 South Texas Project, License Renewal Application. September 1, 2011. ADAMS
16 No. ML112360114.
- 17 [NRC] U.S. Nuclear Regulatory Commission. 2011c. Memorandum from Tam Tran, Project
18 Manager. Subject: Summary of Telephone Conference Call Held on July 28, 2011 between the
19 U. S. Nuclear Regulatory Commission and STP Nuclear Operating Company, Concerning
20 Requests for Additional Information Pertaining to the South Texas Project, License Renewal
21 Application. August 23, 2011. ADAMS No. ML11216A263.
- 22 [NRC] U.S. Nuclear Regulatory Commission. 2012. Memorandum from Tam Tran, Project
23 Manager. Subject: Summary of Telephone Conference Call Held on January 31, 2012
24 between the U. S. Nuclear Regulatory Commission and STP Nuclear Operating Company,
25 Concerning Requests for Additional Information Pertaining to the South Texas Project, License
26 Renewal Application. February 14, 2012. ADAMS No. ML12033A134.
- 27 [STPNOC] South Texas Project Nuclear Operating Company. 2006. Letter from David W.
28 Rencurrel, STPNOC to USNRC Document Control Desk, Subject: South Texas Project Units 1
29 and 2, Docket Nos. STN 50-498, STN 50-499 Revised Broad Scope Risk-Informed Technical
30 Specification Amendment Request.” Wadsworth, Texas. June 6, 2006. ADAMS
31 No. ML061630315.
- 32 [STPNOC] South Texas Project Nuclear Operating Company. 2007. Letter from Charles T.
33 Bowman, STPNOC, to U.S. Nuclear Regulatory Commission Document Control Desk, Subject:
34 South Texas Project Units 1 and 2, Docket Nos. STN 50-498, STN 50-499, Response to NRC
35 Requests for Additional Information on STPNOC Proposed Risk Managed Technical
36 Specifications (TAC Nos. MD 2341 and MD 2342). Wadsworth, Texas. February 28, 2007.
37 ADAMS No. ML070670369.
- 38 [STPNOC] South Texas Project Nuclear Operating Company. 2009. “South Texas Project
39 Units 3 and 4 Combined License Application (COLA) (Environmental Report), Rev. 3.”
40 September 2009. ADAMS No. ML092931600.
- 41 [STPNOC] South Texas Project Nuclear Operating Company. 2010. “South Texas Project—
42 License Renewal Application, Applicant’s Environmental Report, Operating License Renewal
43 Stage, South Texas Project, Units 1 and 2.” September 2010. ADAMS No. ML103010263.
- 44 [STPNOC] South Texas Project Nuclear Operating Company. 2011a. Letter from G. T. Powell,
45 STPNOC, to U.S. Nuclear Regulatory Commission Document Control Desk, Subject: South
46 Texas Project Units 1 and 2, Docket Nos. STN 50-498, STN 50-499, Response to Request for

- 1 Additional Information on South Texas Project License Renewal Application (TAC No. ME4938).
2 July 5, 2011. ADAMS No. ML11193A016.
- 3 [STPNOC] South Texas Project Nuclear Operating Company. 2011b. "Additional Information
4 on South Texas Project License Renewal Application (TAC No. ME4938)." August 23, 2011.
5 ADAMS No. ML11250A067.
- 6 [STPNOC] South Texas Project Nuclear Operating Company. 2012a. Letter from D. W.
7 Rencurrel, STPNOC, to U.S. Nuclear Regulatory Commission Document Control Desk, Subject:
8 South Texas Project Units 1 and 2, Docket Nos. STN 50-498, STN 50-499, Supplemental
9 Response to Request for Additional Information on South Texas Project License Renewal
10 Application—SAMA (TAC Nos. ME4938 and ME5122). January 19, 2012. ADAMS
11 No. ML12030A081.
- 12 [STPNOC] South Texas Project Nuclear Operating Company. 2012b. Letter from D. W.
13 Rencurrel, STPNOC, to U.S. Nuclear Regulatory Commission Document Control Desk, Subject:
14 South Texas Project Units 1 and 2, Docket Nos. STN 50-498, STN 50-499, Clarification to
15 Supplemental Response to Request for Additional Information on South Texas Project License
16 Renewal Application—SAMA (TAC Nos. ME4938 and ME5122). February 16, 2012. ADAMS
17 No. ML12053A259.
- 18 [TVA] Tennessee Valley Authority. 2010. Letter from Masoud Bajestani, TVA, to U.S. Nuclear
19 Regulatory Commission Document Control Desk. Subject: Watts Bar Nuclear Plant (WBN)
20 Unit 2—Request for Additional Information Regarding Severe Accident Management
21 Alternatives (TAC No. MD8203). July 23, 2010. ADAMS No. ML102100588.
- 22 Texas State Data Center, 2006. Available at: <<http://txsdc.utsa.edu/>> (Accessed May 2012).
- 23 [USGS] U. S. Geological Survey. 2008. *2008 NSHM Gridded Data*. Available at:
24 <<http://earthquake.usgs.gov/hazards/products/conterminous/2008/data/#fileformat>> (Accessed
25 May 2012).

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

NUREG-1437, Supplement 48

2. TITLE AND SUBTITLE

Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS)
Supplement 48
Regarding South Texas Project, Units 1 and 2
Draft Report

3. DATE REPORT PUBLISHED

MONTH	YEAR
November	2012

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

See Chapter 10 of the report

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Division of License Renewal
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above", if contractor, provide NRC Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address.)

same as (8) above

10. SUPPLEMENTARY NOTES

Docket Numbers 50-498 and 50-499

11. ABSTRACT (200 words or less)

This supplemental environmental impact statement has been prepared in response to an application submitted by STP Nuclear Operating Company (STPNOC) to renew the operating licenses for South Texas Project (STP), Units 1 and 2, for an additional 20 years. This supplemental environmental impact statement (SEIS) includes the preliminary analysis that evaluates the environmental impacts of the proposed action and alternatives to the proposed action. Alternatives considered include: new nuclear generation, natural gas-fired combined-cycle generation, supercritical coal-fired generation, combination alternative, purchased power, and not renewing the license (the no-action alternative).

The U.S. Nuclear Regulatory Commission's (NRC's) preliminary recommendation is that the adverse environmental impacts of license renewal for STP are not great enough to deny the option of license renewal for energy planning decisionmakers. This recommendation is based on the following:

- the analysis and findings in NUREG-1437, Volumes 1 and 2, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants;"
- the environmental report submitted by STPNOC;
- consultation with Federal, State, local, and Tribal government agencies;
- the NRC's environmental review; and
- consideration of public comments received during the scoping process.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

South Texas Project
STP
STP Nuclear Operating Company
STPNOC
Supplement to the Generic Environmental Impact Statement
License Renewal
DSEIS
GEIS
National Environmental Policy Act

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, DC 20555-0001

OFFICIAL BUSINESS

**NUREG-1437
Supplement 48
Draft**

**Generic Environmental Impact Statement for License Renewal of Nuclear Plants
Regarding South Texas Project, Units 1 and 2**

November 2012