



November 27, 2012

U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, MD 20852

ATTENTION: Document Control Desk

SUBJECT: **Nine Mile Point Nuclear Station, Unit 2**
Renewed Facility Operating License No. NPF-69
Docket No. 50-410

Response to 10 CFR 50.54(f) Request for Information, Recommendation 2.3,
Seismic

- REFERENCES:**
- (a) Letter from E. J. Leeds (NRC) and M. R. Johnson (NRC) to All Power Reactor Licensees and Holders of Construction Permits in Active or Deferred Status, dated March 12, 2012, Request for Information Pursuant to Title 10 of the Code of Federal Regulations 50.54(f) Regarding Recommendations 2.1, 2.3, and 9.3, of the Near-Term Task Force Review of Insights from the Fukushima Dai-ichi Accident
 - (b) Letter from S. L. Belcher (CENG) to Document Control Desk (NRC), dated July 9, 2012, 120-Day Response to Seismic Recommendation 2.3 of 10 CFR 50.54(f) Request for Information
 - (c) Letter from D. L. Skeen (NRC) to A. P. Heymer (NEI), dated May 31, 2012, Endorsement of Electric Power Research Institute (EPRI) Draft Report 1025286, "Seismic Walkdown Guidance," ML12145A529

On March 12, 2012, the U.S. Nuclear Regulatory Commission (NRC) issued Reference (a) to all power reactor licensees. The NRC letter requests further information from addressees to support the evaluation of NRC Staff Recommendation 2.3: Seismic from the Near-Term Task Force review of the accident at the Fukushima Dai-ichi nuclear facility. Reference (a) further requested a response within 180 days of NRC's endorsement of the seismic walkdown procedure.

Reference (b), confirmed that Nine Mile Point Nuclear Station, Unit 2 will use the seismic walkdown procedure, Electric Power Research Institute (EPRI) 1025286, *Seismic Walkdown Guidance: For Resolution of Fukushima Near-Term Task Force Recommendation 2.3: Seismic*. The walkdown procedure was endorsed on May 31, 2012 in Reference (c).

Attachments 1-5 of this letter constitute the response for Nine Mile Point Nuclear Station Unit 2, including a list of areas that were unable to be inspected due to inaccessibility and the schedule to

complete the walkdowns. The results of the follow-up inspections will be submitted within 60 days after the end of the next refueling outage in Spring 2014.

Regulatory commitments in this letter are listed in Attachment 6.

If there are any questions concerning this letter, please contact Everett (Chip) Perkins at everett.perkins@cengllc.com or 410-470-3928.


Sincerely,



Mary G. Korsnick


STATE OF MARYLAND :
: **TO WIT:**
CITY OF BALTIMORE :

I, Mary G. Korsnick, state that I am the Chief Nuclear Officer of Constellation Energy Nuclear Group, LLC and that I am duly authorized to execute and file this document on behalf of this company and its subsidiary Nine Mile Point Nuclear Station, LLC. To the best of my knowledge and belief, the statements contained in this document with respect to these companies are true and correct. To the extent that these statements are not based on my personal knowledge, they are based upon information provided by employees and/or consultants of the companies. Such information has been reviewed in accordance with company practice, and I believe it to be reliable.



Subscribed and sworn before me, a Notary Public in and for the State of Maryland and City of Baltimore, this 27th day of Nov., 2012.

WITNESS my Hand and Notarial Seal:



Notary Public

My Commission Expires:

7/7/15
Date

MGK/EMT/bjd

- Attachments:
- (1) Seismic Walkdown Report
 - (2) Equipment Lists
 - (3) Walkdown Checklists
 - (4) Area Walk-By Checklist
 - (5) Inaccessible Equipment and Peer Review
 - (6) Regulatory Commitments Contained in this Correspondence



cc: B. K. Vaidya, NRC
W. M. Dean, NRC

Resident Inspector, Nine Mile Point