

Seismic Walkdown Checklist (SWC)

Equipment ID No. 300043 per 9/17/2012 ~~30S37-PANEL~~ Equip. Class¹² (20) Control Panels & Cabinets
 Equipment Description HPCI Turbine Aux Lube Oil Pump Starter
 Location: Bldg. Reactor Floor El. 88 Room, Area R3-13
 Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N
2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A
4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A
5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

300943 GM 9/17/2012
 Equipment ID No. 30S37-PANEL Equip. Class¹² (20) Control Panels & Cabinets
 Equipment Description HPCI Turbine Aux Lubr Oil Pump starter

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions





11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Noted that cabinet was open for in-progress work, but was taped to prevent full opening of front cover; judged not a seismic concern

Comments (Additional pages may be added as necessary)

N/A

Evaluated by: Janet Wiggins Date: 9/17/2012
TC 9/17/2012



Seismic Walkdown Checklist (SWC)

Equipment ID No. 30D37 Equip. Class¹² (16) Battery Chargers and Inverters

Equipment Description Static Inverter

Location: Bldg. Turbine Floor El. 135 Room, Area T3-74

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30D37 Equip. Class¹² (16) Battery Chargers and Inverters

Equipment Description Static Inverter

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

Component protected on all sides and above by cage

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

N/A

Evaluated by: *James Wiggins* Date: *9/17/2012*
X G *9/17/2012*





Seismic Walkdown Checklist (SWC)

Equipment ID No. 30P033, 30P038 & ~~30S037~~ gnr 9/10/2012 Equip. Class¹² (05) Horizontal Pumps
 Equipment Description HPCI Booster Pump, Pump, and Turbine gnr 9/10/2012
 Location: Bldg. Reactor Floor El. 88 Room, Area R3-13
 Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
Matches Dwg. # M-1-J-33-3 (Rev. 3) Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30P033, 30P038 & ~~30S037~~ g/r 9/10/2012 Equip. Class¹² (05) Horizontal Pumps

Equipment Description HPCI Booster Pump, Pump, and Turbine g/r 9/10/2012

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

· Overhead cranes in locked home positions
· Scaffolding securely mounted to structural steel

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U



Other Adverse Conditions




11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

N/A

Evaluated by: James Wiggins Date: 9/10/2012
JK JS 9/10/2012







Seismic Walkdown Checklist (SWC)

Equipment ID No. 30P036 & 30S038 Equip. Class¹² (05) Horizontal Pumps

Equipment Description RCIC Pump & Turbine

Location: Bldg. Reactor Floor El. 88 Room, Area R3-14

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? ~~Y~~ N

2. Is the anchorage free of bent, broken, missing or loose hardware? ~~Y~~ N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? ~~Y~~ N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? ~~Y~~ N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
~~Y~~ N U N/A
Matches Dwg. # M-1-G-11-5 (Rev. 5)

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? ~~Y~~ N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30P036 & 30S038 Equip. Class¹² (05) Horizontal Pumps

Equipment Description RCIC Pump & Turbine

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

gauge
Turbine governor and bearing oil temperature detector in contact w/ turbine skid; judged not to affect safety function of equipment

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

Block wall # 16-2 safety-related per PBAPS specification No. M-701, Rev. 1

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)





N/A




Evaluated by: *James Wiggins*

JK JST

Date: *9/11/2012*

9/11/2012





Seismic Walkdown Checklist (SWC)

Equipment ID No. 305037 Equip. Class¹² (00) Other
 Equipment Description HPCI Turbine
 Location: Bldg. Reactor Floor El. 88 Room, Area R3-13
 Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N *gm 9/11/2012*

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A *gm 9/11/2012*
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
Matches Dwg. # M-1-J-6-6 (Rev. 6)

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 305037 Equip. Class¹² (00) Other
Equipment Description HPCI Turbine

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

*Overhead cranes in locked home positions
Scaffolding securely mounted to structural steel*

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U


Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U


Comments (Additional pages may be added as necessary)



N/A

Evaluated by: *James Wiggins* Date: *9/11/2012*
K. As *9/11/2012*





Equipment ID: 30S037





Equipment ID: 30S037





Seismic Walkdown Checklist (SWC)

Equipment ID No. 305703 Equip. Class¹² 14 (Distribution Panel)
Equipment Description 120V Inst. Panel 304035 Transfer Switch
Location: Bldg. RB 135 Floor El. 185 Room, Area Same as 304035
Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
(Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 305203 Equip. Class¹² 14 (Distribution Panel)
 Equipment Description 120V Instr. Panel 304035 Transfer Switch

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets.

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

No II/I concerns

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A


10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions



11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Evaluated by: *[Signature]* Date: 9/25/12
[Signature] 9/25/12



Equipment ID: 30S703



Seismic Walkdown Checklist (SWC)

Equipment ID No. 30X030 Equip. Class¹² (04) Transformers

Equipment Description Load Center E134 Transformer

Location: Bldg. Reactor Floor El. 165 Room, Area R3-116

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
Anchorage in good condition.

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
*Anchorage consistent w/ calc Victoria 006-00084
 SEWS 30X30, Rev. 0*

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U
CS

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30X030 Equip. Class¹² (04) Transformers

Equipment Description Load Center E134 Transformer

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets identified

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

Masonry wall reinforcement needs to be verified. Walls 410.6-410.10 are safety related per Spec M-701, Rev. 1. 11/8/12

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Adjacent vault received.



Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Cabinets not opened because they require hand tools & cabinet is energized.

Evaluated by: *[Signature]* Date: 10/8/12
[Signature] 10/8/12



Seismic Walkdown Checklist (SWC)

Equipment ID No. 30X033 Equip. Class¹² (04) Transformers

Equipment Description Load Center E434 Transformer

Location: Bldg. Reactor Floor El. 165 Room, Area R3-41

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

Anchorage verified to be in good condition.

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A

(Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30X033 Equip. Class¹² (04) Transformers

Equipment Description Load Center E434 Transformer

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets identified

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

Need to verify ^{m.o.} adjacent masonry walls are reinforced. Lighting is secure.
(verified walls 410.6-410.10 per M-704, Rev.1)

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U


Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

~~IEEE:~~ *Old Cabinet not opened because it requires hand tools & it is energized.*

Evaluated by: *[Signature]* Date: 10/8/12
H. Ogden 10/8/2012



Equipment ID: 30X033

Seismic Walkdown Checklist (SWC)

Equipment ID No. 30X133 Equip. Class¹² (04) Transformers

Equipment Description Panel 30Y33 Transformer *g.m. 9/17/2012*

Location: Bldg. Turbine Floor El. 150 135 Room, Area T3-81 171

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors?
Mounted to block wall (see #8) Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
(Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30X133 Equip. Class¹² (04) Transformers

Equipment Description Panel 30Y33 Transformer

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

Block walls 40-11, -20 and -22 are safety-related per PBAPS Specification No. M-701, Rev. 1

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Conduit # ZB30599 is touching the top of transformer, but is supported by wall penetration and ceiling hanger; judged acceptable

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

N/A

Evaluated by: *James Wickham*

Date: *9/17/2012*

TC G/S

9/17/2012



09.12.2012 13:40




09.12.2012 13:40

Equipment ID: 30X133



09.12.2012 13:40



09.12.2012 13:40



Seismic Walkdown Checklist (SWC)

Equipment ID No. 30Y50 Equip. Class¹² (14) Distribution Panels

Equipment Description 120V AC Distribution Panel

Location: Bldg. Turbine Floor El. 150 Room, Area T3-81

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)

Mounted on @ 2 horizontal Unistrut at top & bottom. Unistrut anchored into block wall, confirmed to be safety by Spec M-701 r1. Attached to unistrut at each end via bolt anchors. Channel nut on cyc end.

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

Masonry Wall designations 48-1 and 48-3 per S-68 Rev 33.

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30Y50 Equip. Class¹² (14) Distribution Panels

Equipment Description 120V AC Distribution Panel

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? YES NO U N/A

No soft targets identified

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? YES NO U N/A

No II/H concerns

9. Do attached lines have adequate flexibility to avoid damage? YES NO U N/A


10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? YES NO U

Other Adverse Conditions


11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? YES NO U

Comments (Additional pages may be added as necessary)

Evaluated by: *Ben Fry* Date: *9/28/12*
Ray Blake *9/25/12*



Equipment ID: 30Y050



Seismic Walkdown Checklist (SWC)

Equipment ID No. 30Y35^D Equip. Class¹² (14) Distribution Panels

Equipment Description 3PPD 125V DC Distribution Panel 3C

Location: Bldg. Reactor Floor El. 135 Room, Area R3-29

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

Anchorage in good condition.

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A

J.B.M.F. 9/25/12

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 30Y⁰35 Equip. Class¹² (14) Distribution Panels

Equipment Description 3PPD 125V DC Distribution Panel 3C

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets identified.

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

No II/I concerns

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U



Other Adverse Conditions




11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Evaluated by: *Ber Fry* Date: 9/25/12

[Signature] 9/25/12





Seismic Walkdown Checklist (SWC)

Equipment ID No. 3AC65 Equip. Class¹² (18) Instruments on Racks / Not on Racks

Equipment Description RPS Instrument Rack

Location: Bldg. Reactor Floor El. 165 Room, Area R3-40

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 3AC65 Equip. Class¹² (18) Instruments on Racks / Not on Racks

Equipment Description RPS Instrument Rack

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

Temporary barriers blocked by protective fence

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U


Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

N/A

Evaluated by: *James W. Quinn* Date: *9/17/2012*
DLB *GA* *9/17/2012*



09.11.2012 10:45



09.11.2012 10:46

Equipment ID: 3AC065




09.11.2012 10:47



09.11.2012 11:09




09.11.2012 11:13




09.11.2012 11:13



09.11.2012 11:13



09.11.2012 11:13



Seismic Walkdown Checklist (SWC)

Equipment ID No. 3AEC58
3BE58 Equip. Class¹² (10) Air Handlers
BMF 9/11/12

Equipment Description RHR Room A Cooling Coil ~~B~~ A

Location: Bldg. Reactor Floor El. 9+116' Room, Area R3-5
BMF 9/11/12

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U
See Dwg. 0280-S-975 Rev. 0
2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
Detail D on Dwg indicates 5/8" bolts. Plate bears on grating w/ no bolts. PS Anchorage evaluated in PS-0922 Rev. 0 + missing bolt is acceptable.
3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A
4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A
5. Is the anchorage configuration consistent with plant documentation? (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A
See #2
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U
*BMF 10/8/12
 CB 10/8/12*

→ Configuration management issue addressed in IR# 01411581. *BMF 10/15/12*

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 3AE058 CB 9/11/12 ~~3BE58~~ Equip. Class¹² (10) Air Handlers

Equipment Description RHR Room A Cooling Coil B A

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets identified.

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

No credible II/I issues identified.

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A


10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions




11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U


Comments (Additional pages may be added as necessary)

Evaluated by: *[Signature]* Date: 9/11/12
[Signature] 9/11/12





Equipment ID: 3AE058





Equipment ID: 3AE058



Seismic Walkdown Checklist (SWC)

Equipment ID No. 3AE124 ^{3AE124} ~~3BE124~~ ^{near} HV-3-10-31550A
Equip. Class¹² (21) Tanks or Heat Exchangers (Horizontal)
Equipment Description RHR Pump 3B Seal Cooler ^{3A} ~~3B~~
Location: Bldg. Reactor Floor El. 91 Room, Area R3-6R3-5
Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A
Mild oxidation on seal cooler head is judged to not be a concern.

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
(Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 3AE124 BMF 9/11/12 ~~3BE124~~ Equip. Class¹² (21) Tanks or Heat Exchangers (Horizontal)

Equipment Description RHR Pump-3A Seal Cooler

Interaction Effects *BMF 9/11/12*

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A
No soft targets identified

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A
No I/H concerns

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Evaluated by: *Ben Fry* Date: *9/25/12*
[Signature] *9/25/12*



Equipment ID: 3AE124



Equipment ID: 3AE124



Peach Bottom Atomic Power Station Unit 3
MPR-3812, Revision 3
Correspondence No.: RS-12-173

C-121

Seismic Walkdown Checklist (SWC)

Equipment ID No. 3AE55 Equip. Class¹² (10) Air Handlers

Equipment Description RCIC Room Cooling Coil A

Location: Bldg. Reactor Floor El. 9188⁽¹⁾⁸¹² Room, Area R3-14

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
~~Matches Dwg. # S 977, Rev. 1 plus one extra bolt in one anchor plate and embedded channel instead of bolted to wall for one plate~~

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

See
Comments

gmr 9/11/2012
 gmr 9/11/2012

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 3AE55 Equip. Class¹² (10) Air Handlers

Equipment Description RCIC Room Cooling Coil A

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

Nearby scaffolding secured to structural steel

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions


11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)



gmr 9/11/2012
~~N/A~~ Anchorage does not match Dwg. S-977, Rev. 1, but as-built configuration was evaluated in calculation No. PS-0922, Rev. 0 and judged acceptable. CONFIGURATION MANAGEMENT ISSUE ADDRESSED IN IR # 1411581 ICG 1019112 10113112





Evaluated by: James Wiggins Date: 9/11/2012

KE Jt 9/11/2012




Equipment ID: 3AE055





Equipment ID: 3AE055



Seismic Walkdown Checklist (SWC)

Equipment ID No. 3AE56 Equip. Class¹² (10) Air Handlers

Equipment Description HPCI Room Cooling Coil A

Location: Bldg. Reactor Floor El. 91 88 ^{16 11 8112} Room, Area R3-13

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)

Anchorage does not match Dwg. # S-977, Rev. 1, but as-built configuration was evaluated in calculation No. PS-0922, Rev. 0 and judged acceptable. CONFIGURATION MANAGEMENT ISSUE ADDRESSED IN IR # 1411581 12C 10/9/12 + 10/11/12

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 3AE56 Equip. Class¹² (10) Air Handlers

Equipment Description HPCI Room Cooling Coil A

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

Large bare valve overhead supported on operator by vertical spring - can suspension rod suspended light nearby judged credible but not significant threat

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions





11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

N/A

Evaluated by: *James Wiggins* Date: *9/11/2012*
KE G *9/11/2012*

Equipment ID: 3AE056



Equipment ID: 3AE056



Seismic Walkdown Checklist (SWC)

Equipment ID No. 3AE57 Equip. Class¹² (10) Air Handlers

Equipment Description Core Spray Room A Cooling Coil A

Location: Bldg. Reactor Floor El. 91 Room, Area R3-9

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
ANCHORAGE DOES NOT MATCH DWG S-973, REV. 0, BUT AS-BUILT CONFIGURATION WAS EVALUATED IN CALCULATION PS-0927, REV. 0 AND JUDGED ACCEPTABLE. SEE COMMENTS 1061019.

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 3AE57 Equip. Class¹² (10) Air Handlers

Equipment Description Core Spray Room A Cooling Coil A

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets gmr 9/11/2012

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Insulated pipe touching near support frame judged significant interaction gmr 9/11/2012 Y N U *credible but not*





Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

N/A CONFIGURATION MGMT MANAGEMENT ISSUE ADDRESSED IN IR # 1411581 KB 101911Z + 1011511Z

Evaluated by: *James Wiggins* Date: *9/11/2012*
KE GE *9/11/2012*



Seismic Walkdown Checklist (SWC)

Equipment ID No. 3AP035 Equip. Class¹² (06) Vertical Pumps

Equipment Description RHR Pump A

Location: Bldg. Reactor Floor El. 91 Room, Area R3-5

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
Anchorage verified per Dwg. 6280-5-1150, Rev. 0.

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 3AP035 Equip. Class¹² (06) Vertical Pumps

Equipment Description RHR Pump A

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets identified.

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Evaluated by: *[Signature]*



Date: 9/11/12


Ben Foy

9/11/12



Equipment ID: 3AP035





Seismic Walkdown Checklist (SWC)

Equipment ID No. 3AP037 Equip. Class¹² (06) Vertical Pumps

Equipment Description Core Spray Pump A

Location: Bldg. Reactor Floor El. 88 91 Room, Area R3-9

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
Matches Dwg. #s M-3403, Rev. 1 and M-1-K-35-5 (Rev. 5) Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 3AP037 Equip. Class¹² (06) Vertical Pumps

Equipment Description Core Spray Pump A

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

Chain for hand valve HV-3-14-39037 judged credible but not significant threat

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U



Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U


Comments (Additional pages may be added as necessary)



N/A

Evaluated by: *James Wiggins* Date: *9/10/2012*
J. B. *9/10/2012*






Equipment ID: 3AP037





Equipment ID: 3AP037





Seismic Walkdown Checklist (SWC)

Equipment ID No. 3AV083 Equip. Class¹² (09) Fans

Equipment Description HPSW Pump Room Exhaust Fan

Location: Bldg. Pump Structure Floor El. 112 Room, Area P/H-9

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors?
Mounted to structural steel Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
Matches Dwg. # M-473, Rev. 13 Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 3AV083 Equip. Class¹² (09) Fans

Equipment Description HPSW Pump Room Exhaust Fan

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

No overheads

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U


Comments (Additional pages may be added as necessary)

N/A

Evaluated by: *James Wiggins* Date: *8/29/2012*
X JS *8/29/2012*



Equipment ID: 3AV083



Seismic Walkdown Checklist (SWC)

Equipment ID No. 3BC272^o bmt 8/21/12 Equip. Class¹² (20) Control Panels & Cabinets
 Equipment Description ~~HPCI Steam~~ ^B ~~Leak~~ ^{Monitor} ~~Detection~~ ^{MO} ~~Cabinet~~ 10/23/12
 Location: Bldg. Turbine Floor El. 165 Room, Area T3-100
 Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
*Mounted with 3 channels to back wall.
 No floor mounting*

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation? Y N U N/A
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. ⁰3BC272 ^{EMF 9/13/12} Equip. Class¹² (20) Control Panels & Cabinets
Equipment Description ^B~~HPCI Steam~~ ^{Monitor} ~~Leak Detection~~ ^{MO} Cabinet ^{10/23/12}

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

No soft targets

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

2'x3' ceiling tiles. No credible damage from falling ceiling tiles

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A


10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions


11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Evaluated by: *Ben Fry* Date: *9/25/12*
M. Oghbaci *9/25/12*



Equipment ID: 3BC270



Equipment ID: 3BC270



Seismic Walkdown Checklist (SWC)

Equipment ID No. 3BC65 Equip. Class¹² (18) Instruments on Racks / Not on Racks

Equipment Description RPS Instrument Rack B

Location: Bldg. Reactor Floor El. 135 Room, Area R3-29

Manufacturer, Model, Etc. (optional but recommended) _____

Instructions for Completing Checklist

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y N U

2. Is the anchorage free of bent, broken, missing or loose hardware? Y N U N/A
Interior supports are anchored to floor (concrete U2) BME 10/15/12

3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y N U N/A

4. Is the anchorage free of visible cracks in the concrete near the anchors? Y N U N/A

5. Is the anchorage configuration consistent with plant documentation?
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.) Y N U N/A

6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y N U

¹² Enter the equipment class name from Appendix B: Classes of Equipment.

Equipment ID No. 3BC⁰65 Equip. Class¹² (18) Instruments on Racks / Not on Racks

Equipment Description RPS Instrument Rack B

Interaction Effects

7. Are soft targets free from impact by nearby equipment or structures? Y N U N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y N U N/A

No II/E concerns. Overhead fixtures secure.

9. Do attached lines have adequate flexibility to avoid damage? Y N U N/A



10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y N U

Other Adverse Conditions


11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y N U

Comments (Additional pages may be added as necessary)

Evaluated by: *Ben Fyzi* Date: 9/25/12
Chris Bohannon 9/25/12



Equipment ID: 3BC065



Equipment ID: 3BC065

