

**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1807-Q3-V15 Equip. Class<sup>12</sup> 14  
 Equipment Description 120 VAC VITAL OEST PANEL 1AY2A  
 Location: Bldg. AUX Floor El. 220'0" Room, Area R118  
 Manufacturer, Model, Etc. (optional but recommended) \_\_\_\_\_

**Instructions for Completing Checklist**

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

**Anchorage**

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)?  Y  N
  
2. Is the anchorage free of bent, broken, missing or loose hardware?  Y  N  U  N/A
  
3. Is the anchorage free of corrosion that is more than mild surface oxidation?  Y  N  U  N/A
  
4. Is the anchorage free of visible cracks in the concrete near the anchors?  Y  N  U  N/A
  
5. Is the anchorage configuration consistent with plant documentation? (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)  Y  N  U  N/A
  
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?  Y  N  U

DUO AT AX3AF01-54-4 & PREVIOUS IMAGE

<sup>12</sup> Enter the equipment class name from Appendix B: Classes of Equipment.

**Seismic Walkdown Checklist (SWC)**

Equipment ID No: 1-1807-03-VIS Equip. Class<sup>12</sup>: 14

Equipment Description 120 VAC VITAL DIST PANEL 1AY2A

**Interaction Effects**

7. Are soft targets free from impact by nearby equipment or structures?  Y  N  U  N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment?  Y  N  U  N/A

9. Do attached lines have adequate flexibility to avoid damage?  Y  N  U  N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects?  Y  N  U

3/8" CLEAR TO WALL

**Other Adverse Conditions**

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment?  Y  N  U

**Comments** (Additional pages may be added as necessary)

NONE

Evaluated by: James David / JAMES DAVID Date: 9-4-2012

WJH / Winston Stewart 09/04/2012

<C4>



**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1807-Q3-VIS Equip. Class<sup>12</sup> 14

Equipment Description 120 VAC Vital Distribution Panel 1AY2A

Location: Bldg. Aux Floor El. 220'-0" Room, Area R118

Manufacturer, Model, Etc. (optional but recommended) \_\_\_\_\_

**Instructions for Completing Checklist**

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage (see SWC dated 9/04/12)

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)?  Y  N  U
  
2. Is the anchorage free of bent, broken, missing or loose hardware?  Y  N  U  N/A
  
3. Is the anchorage free of corrosion that is more than mild surface oxidation?  Y  N  U  N/A
  
4. Is the anchorage free of visible cracks in the concrete near the anchors?  Y  N  U  N/A
  
5. Is the anchorage configuration consistent with plant documentation?  Y  N  U  N/A  
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
  
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?  Y  N  U

<sup>12</sup> Enter the equipment class name from Appendix B: Classes of Equipment.

**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1807-Q3-VIS Equip. Class<sup>12</sup> 14

Equipment Description 120 VAC Vital Distribution Panel 1A72A

Interaction Effects (See SWC dated 9/04/12)

7. Are soft targets free from impact by nearby equipment or structures? Y  N  U  N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y  N  U  N/A

9. Do attached lines have adequate flexibility to avoid damage? Y  N  U  N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y  N  U

Other Adverse Conditions


11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y  N  U   
*A visual inspection of the internal components of this cabinet was performed to check for seismic adequacy to include any evidence of internal components not adequately secured, checked to ensure fastener connecting adjacent cabinets were in place, and evidence of other adverse seismic conditions. No adverse conditions were found.*


Comments (Additional pages may be added as necessary)


*None.*

Evaluated by: *José R. Hernández* / José R. Hernández Date: 9/27/12  
*LUSTO S. CHACON* / LUSTO S. CHACON Date: 9/27/12

< C.4 >









**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1807-Q3-VI3 Equip. Class<sup>12</sup> 14 (Distribution Panel)  
 Equipment Description 120 VAC, Vital Panel ICYIA  
 Location: Bldg. Control Floor El. 180' Room, Area RB55  
 Manufacturer, Model, Etc. (optional but recommended) Square D

**Instructions for Completing Checklist**

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

**Anchorage**

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)?  Y  N  U  A
  
2. Is the anchorage free of bent, broken, missing or loose hardware?  Y  N  U  A  
*Panel base welded to embed. #L  
 Fillet welds are good condition  
 stitch*
  
3. Is the anchorage free of corrosion that is more than mild surface oxidation?  Y  N  U  A  
*No corrosion at welds*
  
4. Is the anchorage free of visible cracks in the concrete near the anchors?  Y  N  U  A  
*Concrete near welds are free of visible  
 cracks.*
  
5. Is the anchorage configuration consistent with plant documentation?  Y  N  U  A  
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
  
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?  Y  N  U  A

<sup>12</sup> Enter the equipment class name from Appendix B: Classes of Equipment.

**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1807-03-VL3 Equip. Class<sup>12</sup> 14 (Distribution Panel)  
Equipment Description 120 VAC Vital Panel 1CY1A

Interaction Effects

- 7. Are soft targets free from impact by nearby equipment or structures?    Y N U N/A
  
- 8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment?    Y N U N/A
  
- 9. Do attached lines have adequate flexibility to avoid damage?    Y N U N/A
  
- 10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects?    Y N U


Other Adverse Conditions


- 11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment?    Y N U

Comments (Additional pages may be added as necessary)

None.

Evaluated by: Frank Yao / John Sun Date: 8/31/12  
Winston Stewart / WJ 08/31/2012





**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1807-03-V13 Equip. Class<sup>12</sup> 14

Equipment Description 120 VAC Vital Panel 1CY1A

Location: Bldg. Control Floor El. 180'-0" Room, Area CB55

Manufacturer, Model, Etc. (optional but recommended) \_\_\_\_\_

**Instructions for Completing Checklist**

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage (See SWCs dated 8/21/12 and 8/31/12)

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)? Y  N
  
2. Is the anchorage free of bent, broken, missing or loose hardware? Y  N  U  N/A
  
3. Is the anchorage free of corrosion that is more than mild surface oxidation? Y  N  U  N/A
  
4. Is the anchorage free of visible cracks in the concrete near the anchors? Y  N  U  N/A
  
5. Is the anchorage configuration consistent with plant documentation? Y  N  U  N/A   
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
  
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions? Y  N  U

<sup>12</sup> Enter the equipment class name from Appendix B: Classes of Equipment.

Seismic Walkdown Checklist (SWC)

Equipment ID No. 1-1807-Q3-VI3 Equip. Class<sup>12</sup> 14

Equipment Description 120 VAC Vital Panel 1CY1A

Interaction Effects (See SWCs dated 8/21/12 and 8/31/12)

7. Are soft targets free from impact by nearby equipment or structures? Y  N  U  N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y  N  U  N/A

9. Do attached lines have adequate flexibility to avoid damage? Y  N  U  N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y  N  U

Other Adverse Conditions


11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? A visual inspection of the internal components of this cabinet was performed to check for seismic adequacy to include any evidence of internal components not adequately secured, checked to ensure fasteners connecting adjacent cabinets were in place, and evidence of other adverse seismic conditions. One (1) bolt that connects the inner frame with the cabinet is missing. See "Comments" section. Y  N  U

Comments (Additional pages may be added as necessary)

There was found one (1) bolt that connects the inner frame to be missing. An evaluation of this condition needs to be performed to determine seismic adequacy. Condition report 525039 was generated for this condition.


Evaluated by: [Signature] / José R. Hernández Date: 9/27/12


[Signature] / JUSTO S. CHACON 9/27/12











Sheet: 1 of 2  
 Status:  Y  N  U

**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1807-Q3-VI2 Equip. Class<sup>12</sup> 14 (Distribution Panels)  
 Equipment Description 120 VAC Vital Panel 1BYLB  
 Location: Bldg. Control Floor El. 180' Room, Area RB 47  
 Manufacturer, Model, Etc. (optional but recommended) SQUARE D

**Instructions for Completing Checklist:**

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

**Anchorage**

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)?  Y  N  U
  
2. Is the anchorage free of bent, broken, missing or loose hardware?  Y  N  U  N/A
  
3. Is the anchorage free of corrosion that is more than mild surface oxidation?  Y  N  U  N/A
  
4. Is the anchorage free of visible cracks in the concrete near the anchors?  Y  N  U  N/A  
WELDED CONNECTION.
  
5. Is the anchorage configuration consistent with plant documentation?  Y  N  U  N/A  
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)  
AX3AF01-00054, VER. 4.0
  
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?  Y  N  U

<sup>12</sup> Enter the equipment class name from Appendix B: Classes of Equipment.

**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1807-Q3-VI2 Equip. Class<sup>12</sup> 14 (Distribution Panels)

Equipment Description 120 VAC Vital Panel 1BY1B

**Interaction Effects**

7. Are soft targets free from impact by nearby equipment or structures?  Y  N  U  N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment?  Y  N  U  N/A

9. Do attached lines have adequate flexibility to avoid damage?  Y  N  U  N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects?  Y  N  U

**Other Adverse Conditions**


11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment?  Y  N  U


**Comments** (Additional pages may be added as necessary)

FOR AREA WALK-BY CHECKLIST, SEE 1-1806-S3-DSB.  
LIGHTING FIXTURES HAVE CLOSURE SCREWS

Evaluated by: Matthew Wilkinson Date: 8/21/2012

David Volody DAVID VOLODARSKY 8/21/2012







Sheet 1 of 2  
Status:  Y  N  U

**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1907-03-VI2 Equip. Class<sup>12</sup> 14

Equipment Description 120 VAC Vital Panel 1BY1B

Location: Bldg. Control Floor El. 180'-0" Room, Area RB47

Manufacturer, Model, Etc. (optional but recommended) \_\_\_\_\_

**Instructions for Completing Checklist**

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage (See SWC dated 8/21/12)

- 1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)?  Y  N
- 2. Is the anchorage free of bent, broken, missing or loose hardware?  Y  N  U  N/A
- 3. Is the anchorage free of corrosion that is more than mild surface oxidation?  Y  N  U  N/A
- 4. Is the anchorage free of visible cracks in the concrete near the anchors?  Y  N  U  N/A
- 5. Is the anchorage configuration consistent with plant documentation?  Y  N  U  N/A   
(Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
- 6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?  Y  N  U

<sup>12</sup>Enter the equipment class name from Appendix B: Classes of Equipment.



**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1807-Q3-VIZ Equip. Class<sup>12</sup> 14

Equipment Description 120 VAC Vital Panel 1BY1B

Interaction Effects (See SWC dated 8/21/12)

7. Are soft targets free from impact by nearby equipment or structures? Y  N  U  N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y  N  U  N/A

9. Do attached lines have adequate flexibility to avoid damage? Y  N  U  N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y  N  U

Other Adverse Conditions


11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y  N  U   
 A visual inspection of the internal components of this cabinet was performed to check for seismic adequacy to include any evidence of internal components not adequately secured, checked to ensure fasteners connecting adjacent cabinets were in place, and evidence of other adverse seismic conditions. NO significant adverse conditions were found. Some minor issues are documented on the "Comments" section.


Comments (Additional pages may be added as necessary)


- Found one door hinge pin partially withdrawn and one bolt/screw missing for an isolation panel. It was judged that these conditions do not represent a seismic or operability concern for this panel. A condition report 528375 was generated to document this condition.


Evaluated by: José R. Hernández Date: 10/01/12


Justo S. Chacon JUSTO S. CHACON 10/1/12











Sheet 1 of 2  
 Status  Y  N  U

**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1807-Y3-IA11 Equip. Class<sup>12</sup> 16 (Battery Chargers and Inverters)  
 Equipment Description Vital AC Inverter 1AD111  
 Location: Bldg. Aux Floor El. 220' Room, Area R118  
 Manufacturer, Model, Etc. (optional but recommended) Ametek

**Instructions for Completing Checklist**

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

**Anchorage**

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)?  Y  N  U  N/A
  
2. Is the anchorage free of bent, broken, missing or loose hardware?  Y  N  U  N/A  
*Fillet Welds are welded to the base.*
  
3. Is the anchorage free of corrosion that is more than mild surface oxidation?  Y  N  U  N/A  
*Welds are free of corrosion*
  
4. Is the anchorage free of visible cracks in the concrete near the anchors?  Y  N  U  N/A  
*Concrete is in good condition around welds*
  
5. Is the anchorage configuration consistent with plant documentation?  Y  N  U  N/A  
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
  
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?  Y  N  U

<sup>12</sup>Enter the equipment class name from Appendix B: Classes of Equipment.

**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1807-Y3-IA1 Equip. Class<sup>12</sup> 16 (Battery Chargers and Inverters)  
 Equipment Description Vital AC Inverter 1A D111

**Interaction Effects**

7. Are soft targets free from impact by nearby equipment or structures?  Y  N  U  N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment?  Y  N  U  N/A

9. Do attached lines have adequate flexibility to avoid damage?  Y  N  U  N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects?  Y  N  U

**Other Adverse Conditions**

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment?  Y  N  U

**Comments** (Additional pages may be added as necessary)

SEE 1-1805-S3-ABB FOR AREA WALK-BY CHECKLIST (AWC).

Evaluated by: Fred Yao / [Signature] Date: 8/29/12

PARIMAL GRANDHI / P. Grandhi 8/29/2012





Sheet 1 of 2  
 Status:  N  U

**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1807-43-IA11 Equip. Class<sup>12</sup> 16

Equipment Description Vital AC Inverter 1AD1111

Location: Bldg. Avx Bldg 1012/12 Floor El. 220'0" Room, Area R118

Manufacturer, Model, Etc. (optional but recommended) \_\_\_\_\_

**Instructions for Completing Checklist**

This checklist may be used to document the results of the Seismic Walkdown of an item of equipment on the SWEL. The space below each of the following questions may be used to record the results of judgments and findings. Additional space is provided at the end of this checklist for documenting other comments.

Anchorage (See SWC dated 8/29/12)

1. Is the anchorage configuration verification required (i.e., is the item one of the 50% of SWEL items requiring such verification)?    Y  N
  
2. Is the anchorage free of bent, broken, missing or loose hardware?    Y  N  U  N/A
  
3. Is the anchorage free of corrosion that is more than mild surface oxidation?    Y  N  U  N/A
  
4. Is the anchorage free of visible cracks in the concrete near the anchors?    Y  N  U  N/A
  
5. Is the anchorage configuration consistent with plant documentation?    Y  N  U  N/A   
 (Note: This question only applies if the item is one of the 50% for which an anchorage configuration verification is required.)
  
6. Based on the above anchorage evaluations, is the anchorage free of potentially adverse seismic conditions?    Y  N  U

<sup>12</sup> Enter the equipment class name from Appendix B: Classes of Equipment.

**Seismic Walkdown Checklist (SWC)**

Equipment ID No. 1-1801-43-LA11 Equip. Class<sup>12</sup> 16

Equipment Description Vital AC Inverter IAD1111

Interaction Effects (see SWC dated 8/29/12)

7. Are soft targets free from impact by nearby equipment or structures? Y  N  U  N/A

8. Are overhead equipment, distribution systems, ceiling tiles and lighting, and masonry block walls not likely to collapse onto the equipment? Y  N  U  N/A

9. Do attached lines have adequate flexibility to avoid damage? Y  N  U  N/A

10. Based on the above seismic interaction evaluations, is equipment free of potentially adverse seismic interaction effects? Y  N  U

Other Adverse Conditions

11. Have you looked for and found no other seismic conditions that could adversely affect the safety functions of the equipment? Y  N  U   
A visual inspection of the internal components of this cabinet was performed to check for seismic adequacy to include any evidence of internal components not adequately secured, checked to ensure fasteners connecting adjacent cabinets were in place, and evidence other adverse seismic conditions.  
No significant adverse conditions were found.

Comments (Additional pages may be added as necessary)

None.

Evaluated by: [Signature] / Jose R. Hernandez Date: 9/26/12

[Signature] / Justo S. Chacon 9/26/12

