

Callaway Plant

April 22, 2013

ULNRC-05985

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555-0001

40 CFR 190

Ladies and Gentlemen:

DOCKET NUMBER 50-483 CALLAWAY PLANT UNIT 1 UNION ELECTRIC CO. FACILITY OPERATING LICENSE NPF-30 2012 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

Please find enclosed the 2012 Annual Radioactive Effluent Release Report for Callaway Plant. This report is submitted in accordance with Section 5.6.3 of the Callaway Plant Technical Specifications.

This letter does not contain new commitments.

If there are any questions, please contact Curtis Smith at (314) 225-1482.

Sincerely,

CD Amith

Curtis D. Smith Radiation Protection Manager

EMP/nls

Enclosure

ULNRC-05985 April 22, 2013 Page 2

> cc: Mr. Arthur T. Howell Regional Administrator
> U. S. Nuclear Regulatory Commission Region IV
> 1600 East Lamar Boulevard Arlington, TX 76011-4511

> > Senior Resident Inspector Callaway Resident Office U.S. Nuclear Regulatory Commission 8201 NRC Road Steedman, MO 65077

> > Mr. Fred Lyon Project Manager, Callaway Plant Office of Nuclear Reactor Regulation U. S. Nuclear Regulatory Commission Mail Stop O-8B1 Washington, DC 20555-2738

ULNRC-05985 April 22, 2013 Page 3

Index and send hardcopy to QA File A160.0761

Hardcopy:

Certrec Corporation 4150 International Plaza Suite 820 Fort Worth, TX 76109 (Certrec receives ALL attachments as long as they are non-safeguards and may be publicly disclosed.)

Electronic distribution for the following can be made via Responses and Reports ULNRC Distribution:

A. C. Heflin F. M. Diya C. O. Reasoner III L. H. Graessle S. A. Maglio T. B. Elwood C. D. Smith R. Holmes-Bobo NSRB Secretary Mr. Don King, Director (SEMA) Mr. Thomas Mohr, Senior REP Planner (SEMA) Mr. Tom Masso, REP Planner (SEMA) STARS RA Mr. John O'Neill (Pillsbury Winthrop Shaw Pittman LLP) Mr. Chris Weiberg (DNR) Enclosure to ULNRC-05985 Page 1 of 102

> Callaway Energy Center 2012 Annual Radiological Effluent Release Report

Callaway Energy Center 2012 Annual Effluent Release Report

Facility Operating License NPF-30

Docket Number 50-483



Enclosure to ULNRC-05985 Page 2 of 102

> Callaway Energy Center 2012 Annual Radiological Effluent Release Report

Callaway Energy Center 2012 Annual Radioactive Effluent Release Report

Facility Operating License NPF-30 Docket No. 50-483

1. Introduction

This Annual Radioactive Effluent Release Report (ARERR) is submitted by Union Electric Co., dba Ameren Missouri, in accordance with the requirements of 10 CFR 50.36a and Callaway Energy Center Technical Specification 5.6.3. This report is for the period January 1, 2012 to December 31, 2012.

The doses to the Member of the Public from all liquid and gaseous effluents discharged during the reporting period were small fractions of the NRC and EPA regulatory limits and the Radiological Effluent Control limits in the Offsite Dose Calculation Manual.

To maximize consistency, aid in the review by Members of the Public, and to allow easier industry- wide comparison of the data, this report is presented in the format recommended by Regulatory Guide 1.21, revision 2, *insofar as is practicable*. Callaway is committed to revision

Abstract

The Annual Radioactive Effluent Release Report covers the operation of the Callaway Energy Center during the year 2012. The report includes a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit. The report also includes an annual summary of hourly meteorological data collected during the year and an assessment of radiation dose to the Member of the Public from liquid and gaseous effluents.

1 of Regulatory Guide 1.21, and some of the information is not readily available in the format recommended by revision 2.

2. Gaseous Effluents

The quantity of radioactive material released in gaseous effluents during the reporting period is summarized in Table A-1. The quarterly and annual sums of all radionuclides discharged in gaseous effluents are reported in Tables A-1A and A-1B. All gaseous effluent releases are considered to be ground level.

The quantity of ¹⁴C released in gaseous effluents was calculated as described in EPRI Technical Report 1021106¹.

3. Liquid Effluents

The quantity of radioactive material released in liquid effluents during the reporting period is summarized in Table A-2. The quarterly and annual sums of all radionuclides discharged in liquid effluents are reported in Table A-2A. All liquid effluents were discharged in batch mode; there were no continuous liquid discharges for the reporting period. Dilution by the Missouri River, in the form of the near- field dilution factor, is utilized in the ODCM dose calculation methodology.

4. Solid Waste Storage and Shipments

The volume and activity of solid waste shipped for disposal is provided in Table A-3. Table A-3 is presented in the format of rev. 1 to Regulatory Guide 1.21 because the data is not readily available in the format recommended by rev. 2 to Regulatory Guide 1.21.

5. Dose Assessments

The annual evaluation of dose to the Member of the Public is calculated in accordance with the methodology and parameters in the ODCM and is reported in Tables A-4 and A-5.

5.1 Table A-4, Dose Assessments, 10 CFR 50, Appendix I

The dose assessments reported in Table A-4 were calculated using the methodology and parameters in the ODCM and demonstrate compliance with 10 CFR 50, Appendix I. The gamma air dose and beta air dose were calculated at the nearest Site Boundary location with the highest value of X/Q, as described in the ODCM. The maximum organ dose from gaseous effluents was calculated for the ingestion, inhalation, and ground plane pathways at the location of the nearest resident with the highest value of D/Q, as described in the ODCM. The organ dose does not include the dose from ¹⁴C, which is listed separately.

¹ Estimation of Carbon- 14 in Nuclear Power Plant Gaseous Effluents, Technical Report 1011106, Electric Power Research Institute, December, 2010.

5.2 Table A-5, EPA 40 CFR 190 Individual in the Unrestricted Area

The dose assessments reported in Table A-5 are the doses to the Member of the Public from activities within the Site Boundary plus the doses at the location of the Nearest Residence. A large portion of the residual land of the Callaway Site is managed by the State of Missouri Conservation Department as the Reform Wildlife Management Area. Pursuant to the guidance provided in Regulatory Guide 1.21, rev.2, the dose reported in Table A-5 is the sum of the dose from gaseous effluents (at the Nearest Resident location and within the Site Boundary), plus the dose contribution due to activities within the Site Boundary and the organ dose from inhalation of ¹⁴C (at the Nearest Resident location and within the Site Boundary). The dose assessments in Table A-5 demonstrate compliance with 10 CFR 20.1301(e) and 40 CFR 190.

6. Supplemental Information

6.1 Abnormal Releases or Abnormal Discharges

There were no abnormal releases or abnormal discharges during the reporting period.

6.2 Non- routine Planned Discharges

There were no non- routine planned discharges during the reporting period.

6.3 Radioactive Waste Treatment System Changes

There were no major changes to the liquid or gaseous radwaste treatment system during the reporting period.

6.4 Annual Land Use Census Changes

There were no changes identified in the locations for dose calculation. Changes in sample locations identified in the Land Use Census are described in the Annual Radiological Environmental Operating Report.

6.5 Effluent Monitoring System Inoperability

There were no effluent radiation monitors out of service for periods in excess of the Limiting Condition for Operation and associated Action statements.

6.6 Offsite Dose Calculation Manual Changes

The Offsite Dose Calculation Manual (ODCM) was revised during the reporting period. Revision 19 was issued on August 7, 2012. A complete copy of the revised ODCM is attached. Revision 19 was a general revision with major formatting changes. For clarity and as an aid to the reviewer, the marks in the margins show only those areas of substantive change. Appendix B to the ODCM provides a description of the changes.

6.7 Process Control Program Changes

APA-ZZ-01011, "Process Control Program" was revised twice during the reporting period. Revision 11, issued on September 6, 2012, aligned the PCP change and approval process with

APA-ZZ-00101, "Processing Procedures, manuals, and Desktop Instructions" and FSAR-SP Specification 16.25, "Process Control Program (PCP). Revision 12, issued on October 8, 2012, was a minor change correcting the title of APA-ZZ-00101 as referenced in the procedure. Neither change resulted in a change in the formulas, sampling, analyses, tests or determinations relative to the processing and packaging of solid radioactive waste. Documentation relative to these changes is retained in the Callaway Energy Center records.

6.8 Corrections to Previous Reports

There are no corrections to previous reports.

6.9 Other Information Related to Radioactive Effluents

Meteorological Joint Frequency Tables for the monitoring period are attached as Appendix B.

Appendix A

Tables of Quantities Released in Liquid and Gaseous Radioactive Effluents and in Solid Radioactive Waste Shipments

Tables of Doses from the Discharge of Liquid and Gaseous Radioactive Effluents

Table A-1: Gaseous Effluents- Summation of All Releases							
Summation of All Releases	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total	Estimated Uncertainty (%) ²
Fission & Activation Gases	Ci	3.04E+00	9.11E-01	2.45E-01	3.38E-01	4.53E+00	20
Avg Rel Rate	μCi/s	3.87E-01	1.16E-01	3.08E-02	4.25E-02	1.44E-01	
% of Limit	%	N/A	N/A	N/A	N/A	N/A	
¹³¹ lodine	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	23
Avg Rel Rate	μCi/s	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
% of Limit	%	N/A	N/A	N/A	N/A	N/A	
Particulates	Ci	0.00E+00	0.00E+00	6.38E-07	0.00E+00	6.38E-07	30
Avg Rel Rate	µCi/s	0.00E+00	0.00E+00	8.02E-08	0.00E+00	2.01E-08	
% of Limit	%	N/A	N/A	N/A	N/A	N/A	
Gross Alpha	Ci	2.01E-07	5.24E-08	7.72E-08	8.92E-08	4.20E-07	
³ Н	Ci	4.46E+00	8.05E+00	9.25E+00	6.31E+00	2.81E+01	14
Avg Rel Rate	μCi/s	5.68E-01	1.02E+00	1.16E+00	7.94E-01	8.86-01	
% of Limit	%	N/A	N/A	N/A	N/A	N/A	
¹⁴ C ³	Ci	3.3	3.3	3.3	3.3	13.2	

² Safety Analysis calculation 87-063-00, January 6, 1988 ^{3 14}C activity is estimated based on EPRI report TR-1021106, *Estimation of* ¹⁴C *in Nuclear Power Plant* Effluents, December, 2010.

Table A-1A	Table A-1A: Gaseous Effluents- Ground Level Release- Batch Mode						
Fission & Activation Gases	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for the year	
⁴¹ Ar	Ci	3.03E-02	1.04E-01	3.30E-02	3.80E-02	2.05E-01	
¹³³ Xe	Ci	0.00E+00	1.84E-03	3.56E-04	1.05E-03	3.25E-03	
⁸⁵ Kr	Ci	0.00E+00	1.31E-01	1.33E-01	0.00E+00	2.64E-01	
^{131m} Xe	Ci	0.00E+00	0.00E+00	2.31E-05	0.00E+00	2.31E-05	
Total	Ci	3.03E-02	2.37E-1	1.66E-01	3.90E-02	4.72E-01	
lodines & Halogens	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for the year	
Iodines & Halogens Total	Units Ci	Quarter 1 0.00E+00	Quarter 2 0.00E+00	Quarter 3 0.00E+00	Quarter 4 0.00E+00	Total for the year 0.00E+00	
Iodines & Halogens Total Particulates	Units Ci Units	Quarter 1 0.00E+00 Quarter 1	Quarter 2 0.00E+00 Quarter 2	Quarter 3 0.00E+00 Quarter 3	Quarter 4 0.00E+00 Quarter 4	Total for the year 0.00E+00 Total for the year	
Iodines & Halogens Total Particulates Total	Units Ci Units Ci	Quarter 1 0.00E+00 Quarter 1 0.00E+00	Quarter 2 0.00E+00 Quarter 2 0.00E+00	Quarter 3 0.00E+00 Quarter 3 0.00E+00	Quarter 4 0.00E+00 Quarter 4 0.00E+00	Total for the year 0.00E+00 Total for the year 0.00E+00	
Iodines & Halogens Total Particulates Total ³ H	Units Ci Units Ci Ci	Quarter 1 0.00E+00 Quarter 1 0.00E+00 2.92E-02	Quarter 2 0.00E+00 Quarter 2 0.00E+00 6.12E-01	Quarter 3 0.00E+00 Quarter 3 0.00E+00 2.39E-01	Quarter 4 0.00E+00 Quarter 4 0.00E+00 9.91E-02	Total for the year 0.00E+00 Total for the year 0.00E+00 9.79E-01	
Iodines & Halogens Total Particulates Total ³ Η Gross α	Units Ci Units Ci Ci Ci	Quarter 1 0.00E+00 Quarter 1 0.00E+00 2.92E-02 0.00E+00	Quarter 2 0.00E+00 Quarter 2 0.00E+00 6.12E-01 0.00E+00	Quarter 3 0.00E+00 Quarter 3 0.00E+00 2.39E-01 0.00E+00	Quarter 4 0.00E+00 Quarter 4 0.00E+00 9.91E-02 0.00E+00	Total for the year 0.00E+00 Total for the year 0.00E+00 9.79E-01 0.00E+00	

Table A-1B: Gaseous Effluents- Ground Level Release- Continuous Mode						
Fission &	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for
Activation						the year
Gases						
¹³³ Xe	Ci	5.18E-01	5.79E-01	3.37E-02	2.87E-01	1.42E+00
¹³⁵ Xe	Ci	1.01E-01	9.56E-02	4.52E-02	1.23E-02	2.54E-01
⁸⁵ Kr	Ci	2.39E+00	0.00E+00	0.00E+00	0.00E+00	2.39E+00
Total	Ci	3.01E+00	6.75E-01	7.88E-02	2.99E-01	4.06E+00
Iodines &	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for
Halogens						the year
133	Ci	5.33E-07	0.00E+00	0.00E+00	1.45E-06	1.98E-06
Total	Ci	5.33E-07	0.00E+00	0.00E+00	1.45E-06	1.98E-06
Particulates	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for
						the year
⁹⁹ Mo	Ci	0.00E+00	0.00E+00	3.19E-07	0.00E+00	3.19E-07
^{99m} Tc	Ci	0.00E+00	0.00E+00	3.19E-07	0.00E+00	3.19E-07
Total	Ci	0.00E+00	0.00E+00	6.38E-07	0.00E+00	6.38E-07
³ Н	Ci	4.43E+00	7.44E+00	9.02E+00	6.21E+00	2.71E+01
Gross a	Ci	2.01E-07	5.24E-08	7.72E-08	8.92E-08	4.20E-07
¹⁴ C	Ci	2.76E+00	2.76E+00	2.76E+00	2.76E+00	1.10E+01

Table A-2:	Table A-2: Liquid Effluents- Summation of All Releases							
Summation of All Liquid Releases	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total	Estimated Uncert. (%) ⁴	
Fission and Activation Products ⁵	Ci	6.11E-02	1.65E-02	7.67E-03	4.95E-03	9.02E-02	20	
Avg Diluted Conc	µCi/ml	4.45E-07	1.18E-07	4.98E-08	2.96E-08	1.51E-07		
% of Limit	%	N/A	N/A	N/A	N/A	N/A		
³ Н	Ci	5.80E+00	1.67E+01	7.89E+01	3.60E+02	4.61E+02	14	
Avg Diluted Conc	µCi/ml	4.22E-05	1.20E-04	5.12E-04	2.15E-03	7.72E-04		
% of Limit	%	N/A	N/A	N/A	N/A	N/A		
Dissolved & Entrained Gases	Ci	0.00E+00	0.00E+00	0.00E+00	2.94E-06	2.94E-06	27	
Avg Diluted Conc	µCi/ml	0.00E+00	0.00E+00	0.00E+00	1.76E-11	4.92E-12		
% of Limit	%	N/A	N/A	N/A	N/A	N/A		
Gross a	Ci	1.23E-03	1.53E-04	0.00E+00	6.50E-05	1.45E-03	29	
Avg Diluted Conc	µCi/ml	8.95E-09	1.10E-09	0.00E+00	3.89E-10	2.42E-09		
Vol Liquid Effluent ⁶	Liters	4.24E+06	4.24E+06	4.39E+06	4.24E+06	1.71E+07		
Dilution Volume ⁷	Liters	1.33E+08	1.35E+08	1.50E+08	1.63E+08	5.81E+08		
Avg river flow ⁸	m³/s	2.00e+03	2.50E+03	1.32E+03	1.24E+03	1.77E+03		

⁴ Safety Analysis calculation 87-063-00, January 6, 1988

⁵ Excludes ³H, noble gases, and gross alpha.

⁶ Primary system liquid effluent plus secondary liquid effluent, prior to dilution.

⁷ Does not include Missouri River dilution.

⁸ Average Missouri River flow for the year at the Hermann, MO monitoring station as reported by the USGS.

Table A-2A: Liquid Effluents- Batch Mode							
Fission & Activation	Units	Quarter	Quarter	Quarter	Quarter	Total for the	
Products		1	2	3	4	year	
²⁴ Na	Ci	5.02E-05	0.00E+00	0.00E+00	0.00E+00	5.02E-05	
⁵¹ Cr	Ci	1.53E-03	2.56E-04	2.34E-05	0.00E+00	1.81E-03	
⁵⁴ Mn	Ci	4.96E-05	0.00E+00	0.00E+00	0.00E+00	4.96E-05	
⁵⁸ Co	Ci	0.00E+00	6.38E-06	4.11E-06	0.00E+00	1.05E-05	
⁶⁰ Co	Ci	1.09E-02	1.64E-03	2.52E-03	6.06E-04	1.57E-02	
⁶³ Ni	Ci	8.88E-04	5.51E-04	5.25E-04	6.37E-04	2.60E-03	
¹³⁴ Cs	Ci	9.24E-05	7.00E-05	3.86E-06	0.00E+00	1.66E-04	
¹³⁷ Cs	Ci	1.07E-03	9.81E-04	5.11E-04	7.05E-05	2.63E-03	
¹³⁸ Cs	Ci	1.99E-05	0.00E+00	0.00E+00	0.00E+00	1.99E-05	
¹²⁴ Sb	Ci	3.12E-03	2.26E-04	0.00E+00	0.00E+00	3.35E-03	
¹²⁵ Sb	Ci	4.33E-02	1.27E-02	4.07E-03	3.64E-03	6.37E-02	
¹³⁹ Ba	Ci	0.00E+00	0.00E+00	1.70E-05	0.00E+00	1.70E-05	
⁹⁵ Nb	Ci	0.00E+00	0.00E+00	2.80E-06	0.00E+00	2.80E-06	
¹³² Te	Ci	1.50E-05	0.00E+00	0.00E+00	0.00E+00	1.50E-05	
Total	Ci	6.10E-02	1.65E-02	7.68E-03	4.95E-03	9.01E-02	

Table A-2A: Liquid Effluents- Batch Mode (continued)							
Dissolved & Entrained Gases	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for the year	
^{135m} Xe	Ci	0.00E+00	0.00E+00	0.00E+00	2.94E-06	2.94E-06	
Total	Ci	0.00E+00	0.00E+00	0.00E+00	2.94E-06	2.94E-06	
³ Н	Ci	5.80E+00	1.67E+01	7.89E+01	3.60E+02	4.61E+02	
Gross a	Ci	1.23E-03	1.53E-04	0.00E+00	6.50E-05	1.45E-03	

Table A-3: Solid Waste & Irradiated Fuel Shipments A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not Irradiated Fuel)

1. TYPE OF WASTE	Units	Period	Period	Est.
		Jan — Jun	Jul - Dec	Total
				Error (%)
Spent resins, filter sludges,	m ³	N/A	4.67E+00	
evaporator bottoms, etc.	Ci	N/A	2.21E+00	<u>+</u> 25%
Dry compressible waste,	m ³	1.30E+02	1.06E+02	
contaminated equip., etc.	Ci	6.39E-01	1.78E-02	<u>+</u> 25%
Irradiated components,	m ³	N/A	N/A	
control rods, etc.	Ci	N/A	N/A	<u>+</u> 25%
Other (low level secondary	m ³	1.73E+01	1.54E+01	
resin, oily waste)	Ci	4.29E-02	2.07E-03	<u>+</u> 25%

2. ESTIMATE OF MAJOR NUCLIDE COMPOSITION (by Type of Waste)								
a. Spent resins, filters, evaporator bottoms, etc.								
Nuclide	% Abundance	% Abundance Jan – Jun % Abundance						
		Ci		Ci				
¹³⁷ Cs	N/A	N/A	69.35	1.54E+00				
⁶⁰ Co	N/A	N/A	8.82	1.95E-01				
¹³⁴ Cs	N/A	N/A	6.72	1.49E-01				
⁵⁵ Fe	N/A	N/A	5.30	1.17E-01				
⁶³ Ni	N/A	N/A	4.82	1.07E-01				
b. Dry compre	ssible waste, conta	minated equipme	nt, etc.					
⁶⁰ Co	36.18	2.31E-01	36.10	6.42E-03				
⁶³ Ni	14.91	9.53E-02	14.88	2.65E-03				
¹³⁷ Cs	14.47	9.26E-02	14.46	2.57E-03				
⁵⁵ Fe	12.63	8.07E-02	12.59	2.24E-03				
⁵⁸ Co	5.58	3.56E-02	5.54	9.85E-04				
⁵¹ Cr	3.90	2.49E-02	4.09	7.26E-04				
⁹⁵ Nb	3.69	2.36E-02	3.77	6.71E-04				
⁹⁵ Zr	2.48	1.59E-02	2.47	4.39E-04				
¹³⁴ Cs	2.20	1.40E-02	2.19	3.89E-04				
⁵⁴ Mn	1.88	1.20E-02	1.87	3.32E-04				
c. Irradiated c	c. Irradiated components, control rods, etc.							
None	N/A	N/A	N/A	N/A				

Callaway Energy Center 2012 Annual Radioactive Effluent Release Report

d. Other				
Nuclide	% Abundance	Jan – Jun	% Abundance	Jul – Dec
		Ci		Ci
¹⁴⁴ Ce	72.44	3.10E-02	N/A	N/A
⁶⁰ Co	10.61	4.55E-03	34.99	7.23E-04
⁶³ Ni	N/A	N/A	14.36	2.97E-04
¹³⁷ Cs	10.19	4.37E-03	13.96	2.89E-04
⁵⁵ Fe	N/A	N/A	12.28	2.54E-04
⁵⁸ Co	4.11	1.76E-03	6.07	1.25E-04
⁵¹ Cr	N/A	N/A	5.03	1.04E-04
⁹⁵ Nb	N/A	N/A	4.50	9.30E-05
⁹⁵ Zr	N/A	N/A	2.73	5.65E-05
¹³⁴ Cs	2.65	1.14E-03	2.14	4.42E-05
⁵⁴ Mn	N/A	N/A	1.86	3.84E-05

Table A-3: Solid Waste & Irradiated Fuel Shipments (continued)

3. SOLID WASTE DISPOSITION							
Number of	Mode of	Destination	Class of Solid	Type of			
Shipments	Transport		Waste	Container			
			Shipped				
5	HITTMAN	DURATEK	A	INTERMODAL			
	TRANSPORT	SERVICES, INC.		CONTAINER			
2	HITTMAN	DURATEK ,	A	INTERMODAL			
	TRANSPORT	INC./Gallaher Rd		CONTAINER			
1	HITTMAN	DURATEK	A	B-25 LSA Metal			
	TRANSPORT	SERVICES, INC.		Boxes			
1	HITTMAN	DURATEK	A	CASK			
	TRANSPORT	SERVICES, INC					

*Sent to waste processors for volume reduction before burial.

4. SOLIDIFICATION AGENT

None used.

B. IRRADIATED FUEL SHIPMENTS (Disposition)

There were no shipments of irradiated fuel during the reporting period.

Table A-4: Dose Assessments, 10 CFR 50, Appendix I							
	Quarter	Quarter	Quarter	Quarter	Yearly		
	1	2	3	4	total		
Liquid Effluent Dose Limit, Total Body (mrem)	1.5	1.5	1.5	1.5	3		
Total Body Dose (mrem)	3.32E-03	2.91E-03	1.58E-03	7.85E-04	8.55E-03		
% Limit (%)	0.22%	0.19%	0.11%	0.05%	0.29%		
Liquid Effluent Dose Limit, Maximum Organ (mrem)	5	5	5	5	10		
Maximum Organ Dose (mrem)	4.88E-03	4.33E-03	2.31E-03	8.83E-04	1.23E-02		
% Limit (%)	0.10%	0.09%	0.05%	0.02%	0.12%		
Gaseous Effluent Dose Limit, Gamma Air (mrem)	5	5	5	5	10		
Gamma Air Dose (mrad)	2.46E-05	4.78E-05	1.44E-05	2.46E-05	1.03E-04		
% Limit (%)	0.00%	0.00%	0.00%	0.00%	0.00%		
Gaseous Effluent Dose Limit, Beta Air (mrem)	10	10	10	10	20		
Beta Air Dose (mrad)	1.95E-04	5.07E-05	1.81E-05	1.88E-05	2.79E-04		
% Limit (%)	0.00%	0.00%	0.00%	0.00%	0.00%		
Gaseous Effluent Dose Limit, Maximum Organ (mrem)	7.5	7.5	7.5	7.5	15		
Maximum organ dose ⁹ (mrem)	8.72E-04	1.57E-03	1.81E-03	1.23E-03	5.49E-03		
% Limit (%)	0.01%	0.02%	0.02%	0.02%	0.04%		
¹⁴ C Maximum organ dose (mrem) ¹⁰	2.53E-03	2.53E-03	2.53E-03	2.53E-03	1.01E-02		

 $^{^{9}}$ lodine, $^{3}\text{H},$ and particulates with greater than an 8 day half- life. 10 Not included in above totals

Table A-5: EPA 40 CFR 190 Individual in the Unrestricted Area								
	Whole Body Thyroid Max Other Organ							
Dose Limit	25 mrem	75 mrem	25 mrem					
Dose	7.71E-03	7.70E-03	1.61E-02					
% Limit	0.03%	0.01%	0.06%					

Enclosure to ULNRC-05985 Page 16 of 102

> Callaway Energy Center 2012 Annual Radiological Effluent Release Report

Appendix B Joint Frequency Tables; Totals of Hours at Each Wind Speed & Direction for the period January 1, 2012- December 31, 2012

Dispersion Parameters for the Reporting Period

Nearest Resident

Direction: NNW	
Distance: 2897 meters	
X/Q, Undecayed and Undepleted:	7.340E-07 sec/m ³
X/Q Decayed and Undepleted:	7.298E-07 sec/m ³
X/Q Decayed and Depleted:	6.081E-07 sec/m ³
D/Q Deposition rate:	3.263E-09 m ⁻²

Site Boundary

Direction: NNW	
Distance: 2200 meters	
X/Q, Undecayed and Undepleted:	1.110E-06 sec/m ³
X/Q Decayed and Undepleted:	1.106E-06 sec/m ³
X/Q Decayed and Depleted:	9.433E-07 sec/m ³
D/Q Deposition rate:	5.114E-09 m ⁻²

Stability	Class A						
		Wi	nd Speed a	t 10.00 Me	ter Level (N	IPH)	
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	10	18	5	0	0	33
NNE	0	10	8	0	0	0	18
NE	0	12	16	0	0	0	28
ENE	1	7	9	0	0	0	17
E	0	0	0	1	0	0	1
ESE	1	7	7	0	0	0	15
SE	0	8	7	1	0	0	16
SSE	0	6	22	2	0	0	30
S	0	6	12	5	0	0	23
SSW	0	5	34	4	3	0	46
SW	0	5	25	2	1	0	33
WSW	0	7	12	0	2	0	21
W	0	6	12	7	0	0	25
WNW	0	11	21	5	0	0	37
NW	0	10	36	3	0	0	49
NNW	0	7	22	1	0	0	30
Total	2	117	261	36	6	0	422
Hours of c	alm data: 1			•			
Hours of in	nvalid data:	0					

Stability (Class B						
		Wi	nd Speed a	it 10.00 Me	ter Level (N	1PH)	
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	13	19	1	0	0	33
NNE	0	11	12	1	0	0	24
NE	1	12	11	0	0	0	24
ENE	0	8	7	0	0	0	15
E	0	6	2	0	0	0	8
ESE	0	4	4	0	0	0	8
SE	0	14	16	3	0	0	33
SSE	1	11	23	2	0	0	37
S	0	8	18	5	1	0	32
SSW	0	7	24	6	2	0	39
SW	0	8	18	11	0	0	37
WSW	0	6	9	0	2	0	17
W	0	15	11	1	0	0	27
WNW	0	17	6	3	0	0	26
NW	0	9	18	1	0	0	28
NNW	0	8	18	2	0	0	28
Total	2	157	216	36	5	0	416
Hours of co	alm data: 0						

Hours of invalid data: 0

Stability	Class C						
		W	ind Speed	at 10.00 Me	e <mark>ter Level (</mark> l	MPH)	
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	20	22	0	0	0	42
NNE	1	15	17	1	0	0	34
NE	1	16	15	0	0	0	32
ENE	0	9	4	0	0	0	13
E	0	9	3	1	0	0	13
ESE	1	9	8	1	0	0	19
SE	0	17	13	2	0	0	32
SSE	0	20	24	3	0	0	47
S	0	16	29	17	0	0	62
SSW	0	18	25	11	1	0	55
SW	1	17	20	3	0	0	41
WSW	1	14	6	2	0	0	23
W	2	7	7	3	0	0	19
WNW	1	21	14	8	0	0	44
NW	0	16	16	3	0	0	35
NNW	1	24	18	0	0	0	43
Total	9	248	241	55	1	0	554
Hours of	calm data: 1	!	1			1	
Hours of	invalid data	: 0					

Callaway Energy Center 2012 Annual Radioactive Effluent Release Report

Stability	Class D						
		Wi	nd Speed a	t 10.00 Me	ter Level (N	MPH)	
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	12	98	87	17	0	0	214
NNE	17	114	60	4	0	0	195
NE	14	90	46	2	0	0	152
ENE	9	67	37	1	0	0	114
E	26	56	52	3	0	0	137
ESE	20	58	47	5	0	0	130
SE	14	105	88	12	0	0	219
SSE	14	113	113	29	0	0	269
S	18	82	124	75	4	0	303
SSW	11	54	72	40	3	0	180
SW	18	65	29	13	0	0	125
WSW	18	38	18	12	1	0	87
W	9	45	40	22	8	0	124
WNW	13	52	72	48	2	0	187
NW	15	77	74	19	0	0	185
NNW	19	103	109	18	0	0	249
Total	247	1217	1068	320	18	0	2870
Hours of c	alm data: 5				•		

Hours of invalid data: 0

Stability	Class E						
		W	ind Speed o	at 10.00 Me	eter Level (l	MPH)	
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	20	86	20	0	0	0	126
NNE	17	69	5	0	0	0	91
NE	23	56	4	0	0	0	83
ENE	20	58	5	0	0	0	83
E	16	70	13	0	0	0	99
ESE	17	97	20	0	0	0	134
SE	16	152	60	1	0	0	229
SSE	6	211	129	9	1	0	356
S	20	102	202	43	0	0	367
SSW	16	71	67	2	0	0	156
SW	19	73	25	3	0	0	120
WSW	27	47	11	1	0	0	86
W	18	61	15	2	0	0	96
WNW	32	54	21	0	0	0	107
NW	28	73	18	3	0	0	122
NNW	27	96	13	1	0	0	137
Total	322	1376	628	65	1	0	2392
Hours of a	calm data: 2	0	_I,				
Hours of i	invalid data:	0					

Stability	Class F						
		W	ind Speed	at 10.00 Me	e <mark>ter Level (</mark> l	MPH)	
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	18	24	1	0	0	0	43
NNE	27	20	0	0	0	0	47
NE	40	15	1	0	0	0	56
ENE	38	13	0	0	0	0	51
E	29	7	0	0	0	0	36
ESE	29	25	0	0	0	0	54
SE	29	110	4	0	0	0	143
SSE	39	246	33	0	0	0	318
s	31	87	12	0	0	0	130
SSW	26	58	12	0	0	0	96
SW	26	64	7	0	0	0	97
wsw	29	21	1	0	0	0	51
W	17	23	0	0	0	0	40
WNW	41	21	0	0	0	0	62
NW	30	37	0	0	0	0	67
NNW	19	46	0	0	0	0	65
Total	468	817	71	0	0	0	1356
Hours of	calm data: 2	6					
Hours of	invalid data	0:					

Callaway Energy Center 2012 Annual Radioactive Effluent Release Report

Stability	Class G						
		W	ind Speed	at 10.00 Me	eter Level (l	MPH)	
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	42	20	0	0	0	0	62
NNE	47	10	0	0	0	0	57
NE	41	7	0	0	0	0	48
ENE	13	0	0	0	0	0	13
E	10	1	0	0	0	0	11
ESE	16	4	0	0	0	0	20
SE	15	12	2	0	0	0	29
SSE	54	71	3	0	0	0	128
S	35	12	1	0	0	0	48
SSW	12	15	0	0	0	0	27
SW	21	11	0	0	0	0	32
WSW	20	6	0	0	0	0	26
W	16	2	0	0	0	0	18
WNW	28	1	0	0	0	0	29
NW	29	24	0	0	0	0	53
NNW	50	27	0	0	0	0	77
Total	449	223	6	0	0	0	678
Hours of	calm data: 4	2		. L	I	-1	
Hours of	invalid data:	0				12 8,	

Hours of good data: 8783=100% of total hours

Stability	Class A										
		Wind Speed at 60.00 Meter Level (MPH)									
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL				
N	0	8	8	12	0	0	28				
NNE	0	5	10	6	0	0	21				
NE	0	5	20	0	0	0	25				
ENE	0	4	4	5	0	0	13				
E	0	1	0	0	1	0	2				
ESE	0	7	7	0	0	0	14				
SE	0	0	14	5	0	0	19				
SSE	0	2	15	11	0	0	28				
S	0	2	12	7	1	0	22				
SSW	0	2	16	24	0	5	47				
SW	0	0	13	19	2	0	34				
WSW	0	0	8	9	1	2	20				
W	0	2	12	7	9	0	30				
WNW	0	3	14	14	7	1	39				
NW	0	3	29	19	3	2	56				
NNW	0	4	13	7	0	0	24				
Total	0	48	195	145	24	10	422				
Hours of co	alm data: 1					1					

Hours of invalid data: 0

	Wind Speed at 60.00 Meter Level (MPH)									
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL			
N	0	6	23	3	0	0	32			
NNE	0	2	16	3	0	0	21			
NE	1	4	12	3	0	0	20			
ENE	0	4	13	1	0	0	18			
E	0	3	5	0	0	0	8			
ESE	0	2	4	0	0	0	6			
SE	0	7	14	10	0	0	31			
SSE	0	7	29	5	1	0	42			
s	1	6	13	10	1	1	32			
SSW	0	1	13	13	5	2	34			
SW	0	3	15	14	9	2	43			
wsw	0	2	4	4	1	2	13			
W	0	3	18	6	2	0	29			
WNW	0	6	13	6	3	1	29			
NW	0	5	19	13	0	1	38			
NNW	0	6	9	3	2	0	20			
Total	2	67	220	94	24	9	416			

1-3	W1	ind Speed a	at 60.00 Me	ton I and (
1-3	4-7		Wind Speed at 60.00 Meter Level (MPH)										
0	T	8-12	13-18	19-24	>24	TOTAL							
	9	22	2	0	0	33							
1	11	20	4	0	0	36							
0	14	14	3	0	0	31							
0	8	7	1	0	0	16							
0	6	3	1	0	0	10							
0	3	10	2	0	0	15							
0	9	19	3	2	0	33							
0	12	22	12	2	0	48							
0	10	20	26	6	0	62							
0	12	16	16	7	1	52							
0	13	21	9	2	1	46							
1	6	10	5	0	2	24							
0	8	6	2	3	0	19							
0	11	17	8	9	3	48							
0	10	18	8	1	2	39							
1	16	17	9	0	0	43							
3	158	242	111	32	9	555							
m data: 0			1		- I								
	1 0 0 0 0 0 0 0 0 0 0 0 0 0 1 0 0 0 1 0 0 0 1 3 <i>m data: 0</i>	1 11 0 14 0 8 0 6 0 3 0 9 0 12 0 10 0 12 0 13 1 6 0 11 0 10 1 16 3 158 m data: 0	1 11 20 0 14 14 0 8 7 0 6 3 0 6 3 0 3 10 0 9 19 0 12 22 0 10 20 0 12 16 0 13 21 1 6 10 0 8 6 0 11 17 0 10 18 1 16 17 3 158 242 m data: 0 0	1 11 20 4 0 14 14 3 0 8 7 1 0 6 3 1 0 6 3 1 0 3 10 2 0 9 19 3 0 12 22 12 0 10 20 26 0 12 16 16 0 13 21 9 1 6 10 5 0 11 17 8 0 10 18 8 1 16 17 9 3 158 242 111 m data: 0 0 111 11 111	1 11 20 4 0 0 14 14 3 0 0 8 7 1 0 0 6 3 1 0 0 6 3 1 0 0 6 3 1 0 0 6 3 1 0 0 3 10 2 0 0 9 19 3 2 0 12 22 12 2 0 10 20 26 6 0 12 16 16 7 0 13 21 9 2 1 6 10 5 0 0 11 17 8 9 0 10 18 8 1 1 16 17 9 0 3 158 242 111 32	1 11 20 4 0 0 0 14 14 3 0 0 0 8 7 1 0 0 0 6 3 1 0 0 0 6 3 1 0 0 0 3 10 2 0 0 0 9 19 3 2 0 0 12 22 12 2 0 0 10 20 26 6 0 0 13 21 9 2 1 1 6 10 5 0 2 0 8 6 2 3 0 0 11 17 8 9 3 0 10 18 8 1 2 1 16 17 9 0 0 3 158 242 111 32 9							

Hours of invalid data: 0

2.6

Stability	Class D								
	Wind Speed at 60.00 Meter Level (MPH)								
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL		
N	5	48	94	42	10	0	199		
NNE	4	66	100	32	0	0	202		
NE	6	67	67	10	1	0	151		
ENE	10	34	48	13	1	0	106		
E	10	31	51	19	6	0	117		
ESE	8	33	61	27	3	1	133		
SE	11	58	79	54	7	0	209		
SSE	10	62	127	67	19	0	285		
S	8	46	90	97	42	9	292		
SSW	7	39	60	56	33	4	199		
SW	7	37	50	22	13	2	131		
WSW	3	25	27	15	9	7	86		
W	6	20	33	32	14	24	129		
WNW	5	27	49	67	38	30	216		
NW	6	27	79	65	27	2	206		
NNW	6	41	85	63	14	1	210		
Total	112	661	1100	681	237	80	2871		
Hours of a	alm data: 4	1	J			_ <u></u>	_		
Hours of i	nvalid data:	0							

Stability	Class E							
	Wind Speed at 60.00 Meter Level (MPH)							
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL	
N	4	24	73	28	0	0	129	
NNE	1	22	61	15	0	0	99	
NE	0	16	62	5	0	0	83	
ENE	2	22	56	6	0	0	86	
E	1	17	57	9	1	0	85	
ESE	6	14	100	28	0	0	148	
SE	6	10	133	91	1	0	241	
SSE	4	13	143	142	12	3	317	
S	2	9	69	196	45	6	327	
SSW	2	26	59	135	4	0	226	
SW	4	16	59	60	5	0	144	
WSW	0	14	34	23	4	0	75	
W	4	13	48	41	2	1	109	
WNW	2	11	46	49	6	0	114	
NW	3	13	70	47	7	0	140	
NNW	1	13	54	18	0	1	87	
Total	42	253	1124	893	87	11	2410	
Hours of co	alm data: 2							

Hours of invalid data: 0

Stability	Class F								
	Wind Speed at 60.00 Meter Level (MPH)								
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL		
N	1	4	32	10	0	0	47		
NNE	0	3	29	9	0	0	41		
NE	0	6	28	4	0	0	38		
ENE	0	12	38	3	0	0	53		
E	3	12	44	2	0	0	61		
ESE	3	8	48	5	0	0	64		
SE	1	17	91	35	0	0	144		
SSE	1	15	101	95	0	0	212		
S	2	19	93	70	1	0	185		
SSW	2	6	52	58	5	0	123		
SW	3	11	34	76	2	0	126		
WSW	2	5	32	18	1	0	58		
W	2	9	30	12	1	0	54		
WNW	2	8	28	20	1	0	59		
NW	3	9	36	10	0	0	58		
NNW	0	6	19	32	0	0	57		
Total	25	150	735	459	11	0	1380		
Hours of	calm data: 2	2			1				
Hours of	invalid data	: 0							

Stability	Class G				_			
	Wind Speed at 60.00 Meter Level (MPH)							
	1-3	4-7	8-12	13-18	19-24	>24	TOTAL	
N	4	5	18	19	0	0	46	
NNE	2	7	23	13	0	0	45	
NE	1	12	28	7	0	0	48	
ENE	5	16	45	17	0	0	83	
E	3	5	22	1	0	0	31	
ESE	2	11	28	1	0	0	42	
SE	3	7	9	1	0	0	20	
SSE	0	16	21	14	0	0	51	
s	3	9	42	19	0	0	73	
SSW	6	13	29	9	0	0	57	
SW	2	14	16	9	0	0	41	
wsw	1	16	18	11	0	0	46	
W	2	12	17	3	0	0	34	
WNW	6	8	14	3	0	0	31	
NW	1	17	13	8	0	0	39	
NNW	3	10	5	14	0	0	32	
Total	44	178	348	149	0	0	719	
Hours of c	alm data: 1							
Hours of in	nvalid data:	0						

Hours of good data: 8783=100% of total hours

Appendix C

APA-ZZ-01003, Callaway Energy Center Offsite Dose Calculation Manual, rev. 19 Enclosure to ULNRC-05985 Page 33 of 102





APA-ZZ-01003

OFF-SITE DOSE CALCULATION MANUAL

Revision 19
Contents

1.	PURPOSE AND SCOPE	5
2.	LIQUID EFFLUENTS	5
2.1.	Liquid Effluent Monitors	5
2.1.1.	Continuous Liquid Effluent Monitors	6
2.2.	Calculation of Liquid Effluent Monitor Setpoints	7
2.2.1.	CALCULATION OF THE ECV SUM	7
2.2.2.	CALCULATION OF THE MAXIMUM PERMISSIBLE LIQUID EFFLUENT DISCHARGE FLOW RATE	8
2.2.3.	CALCULATION OF LIQUID EFFLUENT MONITOR SETPOINT	9
2.3.	Liquid Effluent Concentration Measurements	10
2.4.	Dose due to Liquid Effluents	10
2.4.1.	THE MAXIMUM EXPOSED INDIVIDUAL	10
2.4.2.	CALCULATION OF DOSE FROM LIQUID EFFLUENTS	11
2.4.3.	SUMMARY, CALCULATION OF DOSE DUE TO LIQUID EFFLUENTS	12
2.5.	Liquid Radwaste Treatment System	12
2.6.	Dose Factors	12
3.	GASEOUS EFFLUENTS	12
3.1.	Gaseous Effluent Monitors	12
3.1.1.	CONTINUOUS RELEASE GASEOUS EFFLUENT MONITORS	13
3.1.2.	BATCH RELEASE GASEOUS EFFLUENT MONITORS	15
3.2.	Gaseous Effluent Monitor Setpoints	15
3.2.1.	TOTAL BODY DOSE RATE SETPOINT CALCULATIONS	15
3.2.2.	SKIN DOSE RATE SETPOINT CALCULATION	16
3.3.	Calculation of Dose and Dose Rate from Gaseous Effluents	17
3.3.1.	DOSE RATE FROM GASEOUS EFFLUENTS	17
3.3.2.	DOSE DUE TO GASEOUS EFFLUENTS	19
3.4.	Gaseous Radwaste Treatment System	21
3.5.	Dose Factors	22
4.	DOSE AND DOSE COMMITMENT FROM URANIUM FUEL CYCLE SOURCES	22

Enclosure
to ULNRC-05985
Page 35 of 102

4.1.	Calculation of Dose and Dose Commitment from Uranium Fuel Cycle Sources	2			
4.1.1.	IDENTIFICATION OF THE MEMBER OF THE PUBLIC 23	3			
4.1.2.	TOTAL DOSE TO THE NEAREST RESIDENT	3			
4.1.3.	TOTAL DOSE TO THE CRITICAL RECEPTOR WITHIN THE				
	SITE BOUNDARY 23	3			
5.	RADIOLOGICAL ENVIRONMENTAL MONITORING	6			
5.1	Description Of The Radiological Environmental Monitoring	-			
0.11	Program	5			
5.2.	Performance Testing Of Environmental Thermoluminescence				
	Dosimeters	5			
6	ANNULAL AVERAGE AND SHORT TERM ATMOSPHERIC				
0.	DISPERSION PARAMETERS	5			
6.1.	Atmospheric Dispersion Parameters	5			
6.1.1.	Dispersion Estimates	5			
6.1.2.	Determination of Dispersion Estimates for Special Receptor	-			
	Locations	7			
6.1.3.	Atmospheric Dispersion Parameters for Farming Areas within the	_			
	Site Boundary	/			
6.2.	Annual Meteorological Data Processing2	/			
7.	REPORTING REQUIREMENTS	3			
7.1.	Annual Radiological Environmental Operating Report	3			
7.2.	Annual Radioactive Effluent Release Report	3			
Q		2			
0.		2			
9.	RADIOACTIVE EFFLUENT CONTROLS (REC) 28	3			
10.	ADMINISTRATIVE CONTROLS	3			
10.1 <i>.</i>	Major Changes to Liquid and Gaseous Radwaste Treatment				
	Systems	Э			
10.2.	Changes to the Offsite Dose Calculation Manual (ODCM) 29)			
11.	BIBLIOGRAPHY	Э			
Table 1: Ingestion Dose Commitment Values (A _{it}) for Adult Age Group					
Table 2: Bioaccumulation Factor (Bf _i) 37					
Table 3: Dose Factor for Exposure to a Semi- Infinite Cloud of Noble Gases 38					
Table 4: Gro	pund Plane Pathway Dose Factors (R _i)	9			

Table 5: Child Inhalation Pathway Dose Factors (Ri) 4	40
Table 7: Child Grass- Goat – Milk Pathway Dose Factors (R _i)	44
Table 8: Child Meat Pathway Dose Factors (Ri)	46
Table 9: Child Vegetation Pathway Dose Factors (R _i)	48
Table 10: Highest Annual Average Atmospheric Dispersion Parameters Unit Vent	50
Table 11: Highest Annual Average Atmospheric Dispersion Parameters Radwaste	
Vent and Laundry/Decon Facility Dryer Exhaust	51
Table 12: Application of Atmospheric Dispersion Parameters for Release Permits	52
Table 13: Application of Atmospheric Dispersion Parameters Annual Radioactive	
Effluent Release Report	53
Table 14: Meteorological Data Selection Hierarchy	54
Appendix A: Methodology for Calculating Dose from ¹⁴ C in Gaseous	
Effluents	55
Appendix B: Record of Revisions	67

OFF-SITE DOSE CALCULATION MANUAL

1. Purpose and Scope

The Offsite Dose Calculation Manual (ODCM) describes the methodology and parameters used in the calculation of off-site doses resulting from radioactive gaseous and liquid effluents, in the calculation of gaseous and liquid effluent monitoring Alarm/Trip Setpoints, and in the conduct of the Radiological Environmental Monitoring Program. The ODCM also contains the Radioactive Effluent Controls and Radiological Environmental Monitoring Program required by T/S 5.5.4 and FSAR-SP Chapter 16.11.4, and descriptions of the information that should be included in the Annual Radiological Environmental Operating and Annual Effluent Release Reports required by T/S 5.6.2 and T/S 5.6.3

Compliance with the Radiological Effluent Controls limits demonstrates compliance with the limits of 10 CFR 20.1301.^{1,2,3}

The ODCM consists of two parts: FSAR-SP Chapter 16.11 which contains the Radiological Effluent Controls (RECs), and APA-ZZ-01003, which contains the methodology and parameters used to implement the RECs.

2. Liquid Effluents

2.1. Liquid Effluent Monitors

Gross radioactivity monitors which provide for automatic termination of liquid effluent releases are present on the liquid effluent lines. Flow rate measurement devices are present on the liquid effluent lines and the discharge line (cooling tower blowdown). Setpoints, precautions, and limitations applicable to the operation of the Callaway Plant liquid effluent monitors are provided in the appropriate Plant Procedures. Setpoint values are calculated to assure that alarm and trip actions occur prior to exceeding ten times the Effluent Concentration Values (ECV) limits in 10 CFR Part 20 at the release point to the Unrestricted Area. The calculated alarm and trip action setpoints for the liquid effluent line monitors and flow measuring devices must satisfy the following equation:

$$\frac{cf}{F+f} \leq C$$

Eq. 1

Where:

¹ Statements of Consideration, Federal Register, Vol. 56, No. 98, Tuesday, May 21, 1991, Subpart D, page 23374 ² 10 CFR 50.36 a (b)

³ Letter, F. J. Congel to J. F. Schmidt, dated April 23, 1991

C is the liquid effluent concentration value (ECV) implementing REC 16.11.1.1 for the site in μ Ci/ml;

c is the setpoint, in (μ Ci/mI), of the radioactivity monitor measuring the radioactivity concentration in the effluent line prior to dilution and subsequent release. The setpoint, which is inversely related to the volumetric flow of the effluent line and directly related to the volumetric flow of the dilution stream plus the effluent steam, represents a value, which, if exceeded, would result in concentrations exceeding ten times the values of 10 CFR Part 20 Appendix B, Table 2, Column 2, in the Unrestricted Area;

f is the undiluted waste flow rate as measured at the radiation monitor location, in volume per unit time, but in the same units as F, below; and

F is the dilution water flow rate setpoint as measured prior to the release point, in volume per unit time. If **F** is large compared to **f**, then $F + f \cong F$.⁴

If no dilution is provided then $c \leq C$.

The radioactive liquid waste stream is diluted by the plant discharge line prior to entry into the Missouri River. Normally, the dilution flow is obtained from the cooling tower blowdown, but should this become unavailable, the plant water treatment facility supplies the necessary dilution flow via a bypass line.

The limiting concentration which corresponds to the liquid radwaste effluent monitor setpoint is to be calculated using methodology from the expression above. Thus, the expression for determining the setpoint of the liquid radwaste effluent line monitor becomes:

$$c \leq \frac{C(F+f)}{f} (\mu Ci / ml)$$

Eq. 2

The alarm/trip setpoint calculations are based on the minimum dilution flow rate (corresponding to the dilution flow rate setpoint), the maximum effluent stream flow rate, and the actual isotopic analysis. Due to the possibility of a simultaneous release from more than one release pathway, a portion of the total site release limit is allocated to each pathway. The determination and usage of the allocation factor is discussed in Section 2.2. In the event the alarm/trip setpoint is reached, an evaluation will be performed using actual dilution and effluent flow values and actual isotopic analysis to ensure that REC 16.11.1.1 limits were not exceeded.

2.1.1. Continuous Liquid Effluent Monitors

The radiation detection monitor associated with continuous liquid effluent releases is:^{5,6}

⁴ NUREG-0133, pages AA-1 thru AA-3

⁵ FSAR-SP, Section 11.5.2.2.3.1

⁶ FSAR-SP, Section 11.5.2.2.3.4

<u>Monitor I.D.</u>	Description
BM-RE-52	Steam Generator Blowdown Discharge Monitor

The Steam Generator Blowdown discharge is not considered to be radioactive unless radioactivity has been detected by the associated effluent radiation monitor or by laboratory analysis. The sampling frequency, minimum analysis frequency, and type of analysis performed are Per FSAR-SP Table 16.11-1.

2.1.2. Radioactive Liquid Batch Release Effluent Monitors

The radiation monitor associated with the liquid effluent batch release system is:⁷

Monitor I.D.	Description
HB-RE-18	Liquid Radwaste Discharge Monitor

This effluent stream is normally considered to be radioactive. The sampling frequency, minimum analysis frequency, and the type of analysis performed are per FSAR-SP Table 16.11-1.

2.2. Calculation of Liquid Effluent Monitor Setpoints

The dependence of the setpoint, **c**, on the radionuclide distribution, yields, calibration, and monitor parameters, requires that several variables be considered in setpoint calculations.⁸

2.2.1. Calculation of the ECV Sum

The isotopic concentration of the release(s) being considered must be determined. This is obtained from the analyses required per FSAR-SP Table 16.11-1, and is used to calculate an ECV sum (ECVSUM):

$$ECVSUM = \left(\sum_{i} (C_i) / (ECV_i)\right)$$

$$i = g, a, s, t, f$$

Eq. 3

Where:

 C_g is the concentration of each measured gamma emitting nuclide observed by gamma-ray spectroscopy of the waste sample;

C_a is the concentration of ²³⁷Np, ²³⁸Pu, ^{239/240}Pu, ²⁴¹Pu, ²⁴¹Am, ²⁴²Cm, & ^{243/244}Cm, in the quarterly composite sample based on previous composite sample analyses;

⁷ FSAR-SP, Section 11.5.2.2.3.2

⁸ NUREG-0133, pages AA-1 thru AA-3

 C_s is the measured concentrations of ⁸⁹Sr and ⁹⁰Sr as determined by analysis of the quarterly composite sample based on previous composite sample analyses;

 \mathbf{C}_{t} is the measured concentration of ³H in the waste sample; and

 C_f is the measured concentration of ⁵⁵Fe & ⁶³Ni as determined by analysis of the quarterly composite sample based on previous composite sample analyses.

 ECV_g , ECV_s , ECV_a , ECV_f , and ECV_t are ten times the limiting concentrations of the appropriate radionuclides from 10 CFR 20, Appendix B, Table 2, Column 2. For dissolved or entrained noble gases, the concentration shall be limited to $2x10^{-4} \mu$ Ci/ml total activity.

For the case ECVSUM \leq 1, the monitor tank effluent concentration meets the limits of REC 16.11.1.1 without dilution and the effluent may be released at any desired flow rate. If ECVSUM > 1 then dilution is required to ensure compliance with the concentration limits of REC 16.11.1.1. If simultaneous releases are occurring or are anticipated, an allocation fraction, **N**, must be applied so that available dilution flow may be apportioned among simultaneous discharge pathways. The value of N may be any value between 0 and 1 for a particular discharge point, provided that the sum of the allocation fractions for all discharge points must be \leq 1.

2.2.2. Calculation of the Maximum Permissible Liquid Effluent Discharge Flow Rate

The maximum permissible liquid effluent discharge flow rate is calculated by:

$$f_{mox} \leq (F + f_{p}) \cdot SF \cdot N \div (ECVSUM)$$

Eq. 4

Where:

f_{max} is the maximum permissible liquid effluent discharge flow rate, (in gallons/minute);

 $\mathbf{f}_{\mathbf{p}}$ is the expected undiluted liquid effluent flow rate, in gpm;

N is the allocation fraction which apportions dilution flow among simultaneous discharge pathways (see discussion above); and

SF is the safety factor; an administrative factor used to compensate for statistical fluctuations and errors of measurements. This factor also provides a margin of safety in the calculation of the maximum liquid effluent discharge flow rate (f_{max}). The value of SF should be ≤ 1 .

F and ECVSUM are previously defined.

The dilution water supply is furnished with a flow monitor which isolates the liquid effluent discharge if the dilution flow rate falls below its setpoint value.

In the event that f_{max} is less than f_p , then the value of f_{max} is substituted into the equation for f_p , and a new f_{max} value is calculated. This substitution is performed for three iterations in order to calculate the correct value of f_{max} .

2.2.3. Calculation of Liquid Effluent Monitor Setpoint

The liquid effluent monitors are NaI(TI) based systems and respond primarily to gamma radiation. Accordingly, their setpoint is based on the total concentration of gamma emitting nuclides in the effluent:

$$c = 0.95 \cdot \left[bkg + \left[\left(\sum C_g \right) \div SF \right] \right]$$

Eq. 5

Where:

c is the monitor setpoint as previously defined, in μ Ci/ml;

bkg is the monitor background prior to discharge, in μ Ci/mI, adjusted for monitor response; and

0.95 is a factor for conservatism to ensure the monitor trips prior to exceeding the limits of REC 16.11.1.1

 $\sum C_{a}$ and **SF** are as previously defined.

The monitor's background is controlled at an appropriate limit to ensure adequate sensitivity. Utilizing the methodology of ANSI N13.10-1974, the background must be maintained at a value of less than or equal to $9\times10^{-6} \ \mu\text{Ci/ml}$ (relative to ^{137}Cs) in order to detect a change of $4\times10^{-7} \ \mu\text{Ci/ml}$ of ^{137}Cs .⁹

In the event that there is no detectable gamma activity in the effluent or if the value of $\{(\sum C_g) \div SF\}$ is less than the background of the monitor, then the monitor setpoint will be set at twice the current background of the monitor.

As previously stated, the monitor's response is dependent on the gamma emitting radionuclide distribution of the effluent. Accordingly, a database conversion factor is calculated for each release based upon the results of the gamma spectrometric analysis of the effluent sample and the measured response of the monitor to National Institute of Standards and Technology (NIST) traceable calibration sources:

$$DBCF_{c} = \left(\sum \left(C_{g}\right)\right) \div \left(CMR\right) \times \left(ECF\right)$$

Eq. 6

DBCF_c is the monitor data base conversion factor which converts count rate into concentration $(\mu Ci/ml)$;

CMR is the calculated response of the radiation monitor to the liquid effluent;

⁹ HPCI 96-005, "Calculation of Maximum Background Value for HB-RE-18"

ECF is the conversion factor for ¹³⁷Cs, which converts count rate into concentration (μ Ci/mI).

C_a is as previously defined.

The new value of the $DBCF_c$ is calculated and entered into the monitor data base prior to each discharge. A more complete discussion of the derivation and calculation of the CMR is given in HPCI 87-10.

2.3. Liquid Effluent Concentration Measurements

Liquid batch releases are discharged as a discrete volume and each release is authorized based upon the sample analysis and the dilution flow rate existing in the discharge line at the time of release. To assure representative sampling, each liquid monitor tank is isolated and thoroughly mixed by recirculation of tank contents prior to sample collection. The methods for mixing, sampling, and analyzing each batch are outlined in applicable plant procedures. The allowable release rate limit is calculated for each batch based upon the pre-release analysis, dilution flow-rate, and other procedural conditions, prior to authorization for release. The liquid effluent discharge is monitored prior to entering the dilution discharge line and will automatically be terminated if the pre-selected alarm/trip setpoint is exceeded. Concentrations are determined primarily from the gamma isotopic and ³H analyses of the liquid batch sample. For ⁸⁹Sr, ⁹⁰Sr, ⁵⁵Fe, ⁶³Ni, ²³⁷Np, ²³⁸Pu, ^{239/240}Pu, ²⁴¹Pu, ²⁴¹Am, ²⁴²Cm, & ^{243/244}Cm, the measured concentrations from the previous quarterly composite analyses are used until laboratory results become available. Composite samples are collected for each batch release and analyzed in accordance with FSAR-SP Table 16.11-1. The dose from liquids discharged as continuous releases is calculated by utilizing the last measured values of samples in accordance with FSAR-SP Table 16.11-1.

2.4. Dose due to Liquid Effluents

2.4.1. The Maximum Exposed Individual

The cumulative dose determination considers the dose contributions from the maximum exposed individual's consumption of fish and potable water, as appropriate. Normally, the adult is considered to be the maximum exposed individual.¹⁰

The Callaway Plant's liquid effluents are discharged to the Missouri River. As there are no potable water intakes within 10 miles of the discharge point,^{11,12} this pathway does not require routine evaluation. Therefore, the dose contribution from fish consumption is expected to account for more than 95% of the total man-rem dose from discharges to the Missouri River. Dose from recreational activities is expected to contribute the additional 5%, which is considered to be negligible.¹³

¹⁰ NUREG-0133, Section 4.3

¹¹ Environmental Report, OLS, Table 2.1-19

¹² FSAR-SP Section 11.2.3.3.4

¹³ FSAR-SP, Section 11.2.3.4.3

2.4.2. Calculation of Dose from Liquid Effluents

The dose contributions for the total time period $\sum_{i=1}^{m} \Delta t_i$ are calculated at least once each 31

days and a cumulative summation of the total body and individual organ doses is maintained for each calendar quarter. Dose is calculated for all radionuclides identified in liquid effluents released to Unrestricted Areas using the following expression:¹⁴

$$D_{\tau} = \sum_{i} \left[A_{i\tau} \sum_{l=1}^{m} \Delta t_{i} C_{il} F_{l} \right]$$

Eq. 7

Where:

 \mathbf{D}_{τ} is the cumulative dose commitment to the total body or any organ, τ , from the liquid

effluents for the total period
$$\sum_{l=1}^{m} \Delta t_{l}$$
 in mrem.

 Δt_i is the length of the j^{th} time period over which $C_{i,i}$ and F_i are averaged for all liquid releases, in hours. Δt_i corresponds to the actual duration of the release(s).

 $C_{i,l}$ is the average measured concentration of radionuclide, i, in undiluted liquid effluent during the time period Δt_l from any liquid release, in (μ Ci/ml).

 $A_{i\tau}$ is the site- related ingestion dose commitment factor to the total body or any organ τ for each identified principal alpha, gamma and beta emitter listed in FSAR-SP Table 16.11-1,in (mrem/hr) per (µCi/ml). The calculation of the $A_{i\tau}$ values given in Table 1 are detailed in calculation 87-001-00.

 F_{i} is the near field average dilution factor for C_{ii} during any liquid effluent release:

$$F_{l} = \frac{f_{max}}{\left(F + f_{max}\right) \cdot 89.77}$$
Eq. 8

Where:

 \mathbf{F}_{max} is the maximum undiluted effluent flow rate during the release;

F is the average dilution flow; and

89.77 is site specific applicable factor for the mixing effect of the discharge structure.^{15,16,17}

¹⁴ NUREG-0133, Section 4.3

¹⁵ NEO-54

¹⁶ UOTH 83-58

The term $C_{i,i}$ is the undiluted concentration of radioactive material in liquid waste at the common release point determined in accordance with REC 16.11.1.1, Table 16.11-1, "Radioactive Liquid Waste Sampling and Analysis Program". All dilution factors beyond the sample point(s) are included in the F_i term.

As there are currently no potable water intakes within 10 river miles of the discharge point, the drinking water pathway is not included in dose estimates to the maximally exposed individual. Should future potable water intakes be constructed within 10 river miles downstream of the discharge point, then this manual will be revised to include this pathway in dose estimates.¹⁸

2.4.3. Summary, Calculation of Dose Due to Liquid Effluents

The dose contribution for the total time period $\sum_{i=1}^{m} \Delta t_i$ is determined by calculation at least

once per 31 days and a cumulative summation of the total body and organ doses is maintained for each calendar quarter. The projected dose contribution from liquid effluents for which radionuclide concentrations are determined by periodic composite and grab sample analysis may be approximated by using the last measured value. Dose contributions are determined for all radionuclides identified in liquid effluents released to Unrestricted Areas. Nuclides which are not detected in the analyses are reported as "less than" the Minimum Detectable Activity (MDA) and are not reported as being present at the Lower Limit of Detection (LLD) for that nuclide. The "less than" values are not used in the dose calculations.

2.5. Liquid Radwaste Treatment System

The Liquid Radwaste Treatment System is described in FSAR-SP Chapter 11.2.

The Operability of the Liquid Radwaste Treatment System ensures this system will be available for use when liquids require treatment prior to their release to the environment. Operability is demonstrated through compliance with REC 16.11.1.1. and 16.11.1.2.

Projected doses due to liquid releases to Unrestricted Areas are determined each 31 days. The prior 31 day period is used to calculate compliance. This may be modified as appropriate to account for changes in radwaste treatment which may have a significant effect on the projected doses.

2.6. Dose Factors

The dose conversion factors provided in Table 1 were derived from the appropriate dose conversion factors of Regulatory Guide 1.109, Table 2.2 and other sources as necessary.¹⁹

3. Gaseous Effluents

3.1. Gaseous Effluent Monitors

¹⁷ CAR 200700053- Attachments: Phase 1 final draft

¹⁸ FSAR-SP, Section 11.2.3.3.4

¹⁹ HPCI 04-06, rev. 1

Noble gas activity monitors are present on the containment building ventilation system, plant unit ventilation system, and radwaste building ventilation system.

The alarm/trip (alarm & trip) setpoint for any gaseous effluent radiation monitor is determined based on the instantaneous noble gas total body and skin dose rate limits of REC 16.11.2.1, at the Site Boundary location with the highest annual average X/Q value.

Each gaseous monitor channel is provided with a two level system which provides sequential alarms on increasing radioactivity levels. These setpoints are designated as alert setpoints and alarm/trip setpoints.²⁰

The radiation monitor alarm/trip setpoints for each release point are based on the radioactive noble gases in gaseous effluents. It is not considered practicable to apply instantaneous alarm/trip setpoints to integrating radiation monitors sensitive to radioiodines, radioactive materials in particulate form and radionuclides other than noble gases. The exception is GL-RE-202. The only effluent released from the Laundry Decon Facility Dryer Exhaust is in the particulate form. Conservative assumptions may be necessary in establishing setpoints to account for system variables, such as the measurement system efficiency and detection capabilities during normal, anticipated, and unusual operating conditions, variability in release flow and principal radionuclides, and the time lag between alarm/trip action and the final isolation of the radioactive effluent.²¹ FSAR-SP Table 16.11-6 provides the instrument surveillance requirements, such as calibration, source checks, functional tests, and channel checks.

3.1.1. Continuous Release Gaseous Effluent Monitors

The radiation detection monitors associated with continuous gaseous effluent releases are:^{22,23}

<u>Monitor I.D.</u>	Description
GT-RE-21	Unit Vent
GH-RE-10	Radwaste Building Vent
GL-RE-202	Laundry Decon Facility Dryer Exhaust Monitor

Each of the above continuously monitors gaseous radioactivity concentrations downstream of the last point of potential influent, and therefore measures effluents and not inplant concentrations.

The unit vent monitor continuously monitors the effluent from the unit vent for gaseous radioactivity. The unit vent, via ventilation exhaust systems, continuously purges various tanks and sumps normally containing low-level radioactive aerated liquids that can potentially

²⁰ FSAR-SP Section 11.5.2.1.2

²¹ NUREG- 0133, section 5.1.1

²² FSAR-SP Section 11.5.2.3.3.1

²³ FSAR-SP Section 11.5.2.3.3.2

generate airborne activity. The exhaust systems which supply air to the unit vent are from the fuel building, auxiliary building, the access control area, the containment purge, and the condenser air discharge.

The unit vent monitor provides alarm functions only, and does not terminate releases from the unit vent.

The Radwaste Building ventilation effluent monitor continuously monitors for gaseous radioactivity in the effluent duct downstream of the exhaust filter and fans. The flow path provides ventilation exhaust for all parts of the building structure and components within the building and provides a discharge path for the waste gas decay tank release line. These components represent potential sources for the release of gaseous and air particulate and iodine activities in addition to the drainage sumps, tanks, and equipment purged by the waste processing system.

This monitor will isolate the waste gas decay tank discharge line upon a high gaseous radioactivity alarm.

The Laundry Decon Facility Dryer Exhaust Monitor continuously monitors the effluent of the dryer exhaust for particulate radioactivity during operation of the dryers. This effluent point is designed to release an insignificant quantity of radioactivity. The items to be placed in the dryers are typically washed before drying removing most of the radioactive material. The dryer effluent then passes through a HEPA filter before being sampled and released.

The Laundry Decon Facility Dryer Exhaust Monitor will secure the dryers and exhaust fans and isolate the dryer effluent upon a high radioactivity alarm or for a monitor failure.

The continuous Unit Vent and Radwaste Building Vent gaseous effluent monitor setpoints are established using the methodology described in Section 3.2. Since there are two continuous gaseous effluent release points, a fraction of the total dose rate limit (DRL) will be allocated to each release point. Neglecting the batch releases, the plant Unit Vent monitor has been allocated 0.7 DRL and the Radwaste Building Vent monitor has been allocated 0.3 DRL. These allocation factors may be changed as required to support plant operational needs, but shall not be allowed to exceed unity (i.e., 1.0). Therefore, a particular monitor reaching the setpoint would not necessarily mean the dose rate limit at the Site Boundary is being exceeded; the alarm only indicates that the specific release point is contributing a greater fraction of the dose rate limit than was allocated to the associated monitor, and will necessitate an evaluation of both systems.

For a loss of all isokinetic sampling and/or all heat tracing for the Unit Vent or Radwaste Building Vent grab samplers, one hour is allowed to restore a sampler to service. If sampling cannot be restored within one hour, all batch releases and ventilation not required for the operation of the plant should be secured. The best available sampling should be maintained during this period and normal sampling returned to service as soon as possible.

3.1.2. Batch Release Gaseous Effluent Monitors

The radiation monitors associated with batch release gaseous effluents are: 24,25,26

Monitor I.D.	<u>Description</u>
GT-RE-22, GT-RE-33	Containment Purge System
GH-RE-10	Radwaste Building Vent

The Containment Purge System continuously monitors the containment purge exhaust duct during purge operations for gaseous radioactivity. The primary purpose of these monitors is to isolate the containment purge system on high gaseous activity via the ESFAS.

The sample points are located outside the containment between the containment isolation dampers and the containment purge filter adsorber unit.

The Radwaste Building Vent monitor was previously described.

A pre-release isotopic analysis is performed for each batch release to determine the identity and quantity of the principal radionuclides. The alarm/trip setpoint(s) is adjusted accordingly to ensure that the limits of REC 16.11.2.1 are not exceeded.

3.2. Gaseous Effluent Monitor Setpoints

The alarm/trip setpoint for the Unit Vent and Radwaste Building Vent gaseous effluent monitors is determined based on the more restrictive of the total body dose rate (Eq. 9) and skin dose rate (Eq. 11) as calculated for the Site Boundary.

The alarm/ trip setpoint for the Laundry Decon Facility Exhaust Monitor is set to less than or equal to 2,000 cpm above equilibrium background. The maximum allowed background is 2,000 cpm as discussed in HPCI 99-05.

3.2.1. Total Body Dose Rate Setpoint Calculations

To ensure that the limits of REC 16.11.2.1 are met, the alarm/trip setpoint based on the total body dose rate is calculated according to:

$$S_{tb} \le D_{tb} R_{tb} F_s F_a$$

Eq. 9

Where:

 S_{tb} is the alarm/trip setpoint based on the total body dose rate (μ Ci/cc);

²⁴ FSAR-SP Section 11.5.2.3.3.2

²⁵ FSAR-SP Section 11.5.2.3.2.3

²⁶ FSAR-SP Section 11.5.2.3.2.2

 \mathbf{D}_{tb} is the REC 16.11.2.1 dose rate limit of 500 mrem/yr, conservatively interpreted as a continuous release over a one year period;

 F_s is the safety factor; a conservative factor used to compensate for statistical fluctuations and errors of measurement. (For example, $F_s = 0.5$ corresponds to a 100% variation.) Default value is $F_s = 0.1$.

 F_a is the allocation factor which will modify the required dilution factor such that simultaneous gaseous releases may be made without exceeding the limits of REC 16.11.2.1.

 R_{tb} is a factor used to convert dose rate to the effluent concentration as measured by the effluent monitor, in (μ Ci/cc) per (mrem/yr) to the total body, determined according to:

$$R_{tb} = C \div \left[\left(\overline{X/Q} \right) \sum_{i} (K_{i}Q_{i}) \right]$$
Eq. 10

Where:

C is the reading of a noble gas monitor corresponding to the sample radionuclide concentrations for the release. Concentrations are determined in accordance with FSAR-SP Table 16.11-4. The mixture of radionuclides determined via grab sampling of the effluent stream or source is correlated to a calibration factor to determine monitor response. The monitor response is based on concentration, not release rate, and is in units of (μ Ci/cc);

 $\overline{X/Q}$ is the highest calculated annual average relative concentration for any area at or beyond the Site Boundary in (sec/m³) (Table 10, Table 11, Table 12, and Table 13);

 K_i is the total body dose factor due to gamma emissions for each identified noble gas radionuclide, in (mrem/yr) per (μ Ci/m³) (Table 3); and

 \mathbf{Q}_i is the rate of release of noble gas radionuclide, i, in (µCi/sec).

Q_i is calculated as the product of the ventilation path flow rate and the measured activity of the effluent stream as determined by sampling.

3.2.2. Skin Dose Rate Setpoint Calculation

To ensure that the limits of REC 16.11.2.1 are met, the alarm/trip setpoint based on the skin dose rate is calculated according to:

$$S_s \leq D_s R_s F_s F_a$$

Eq. 11

Where:

 \mathbf{F}_{s} and \mathbf{F}_{a} are as previously defined;

 \mathbf{S}_{s} is the alarm/trip setpoint based on the skin dose rate;

 D_s is the REC 16.11.2.1 dose rate limit of 3000 mrem/yr, conservatively interpreted as a continuous release over a one year period; and

 \mathbf{R}_{s} is the factor used to convert dose rate to the effluent concentration as measured by the effluent monitor, in (μ Ci/cc) per (mrem/yr) to the skin, determined according to:

$$R_{s} = C \div \left[\left(\overline{X/Q} \right) \sum_{i} \left(L_{i} + 1.1 M_{i} \right) Q_{i} \right]$$

Eq. 12

Where:

 L_i is the skin dose factor due to beta emissions for each identified noble gas radionuclide, in (mrem/yr) per (μ Ci/m³);

1.1 is a factor of units conversion; 1 mrad air dose = 1.1 mrem skin dose; and

 \mathbf{M}_{i} is the air dose factor due to gamma emissions for each identified noble gas radionuclide, in (mrad/yr) per (μ Ci/m³).

C, $\overline{(X/Q)}$, and Q_i are previously defined.

3.3. Calculation of Dose and Dose Rate from Gaseous Effluents

3.3.1. Dose Rate from Gaseous Effluents

The following methodology is applicable to the location (Site Boundary or beyond) characterized by the values of the parameter X/Q which results in the maximum total body or skin dose rate. In the event that the analysis indicates a different location for the total body and skin dose limitations, the location selected for consideration is that which minimizes the allowable release values.²⁷

The factors K_i , L_i , and M_i relate the radionuclide airborne concentrations to various dose rates, assuming a semi-infinite cloud model.

3.3.1.1. Dose Rate from Noble Gases

The release rate limit for noble gases is determined according to the following general relationships:²⁸

$$D_{tb} = \sum_{i} \left[K_{i} Q_{i} \left(\left(\overline{X/Q} \right) \right) \right] \leq 500 \text{ mrem/yr}$$

Eq. 13

²⁷ NUREG-0133, Section 5.1.2

²⁸ NUREG-0133, Section 5.1.2

$$D_{s} = \sum_{i} \left[\left(L_{i} + 1.1 M_{i} \right) \left(\left(\overline{X/Q} \right) Q_{i} \right) \right] \leq 3000 \text{ mrem/yr}$$
Eq. 14

Where:

 \mathbf{Q}_i is the release rate of noble gas radionuclides, i, in gaseous effluents, from all vent releases in (μ Ci/sec); and

1.1 is a factor of units conversion factor; 1 mrad air dose = 1.1 mrem skin dose.

 L_i , M_i , K_i , (X/Q), D_{tb} and D_s are as previously identified.

3.3.1.2. Dose Rate from Radionuclides Other than Noble Gases

The release rate limit for ¹³¹I and ¹³³I, for ³H, and for all radioactive materials in particulate form with half-lives greater than 8 days is determined according to:²⁹

$$D_o = \sum_i R_i \left[\overline{X/Q} \right] Q_i \le 1500 \text{ mrem/yr}$$

Eq. 15

Where:

D_o is the dose rate to any critical organ, in (mrem/yr);

 \mathbf{R}_{i} is the dose parameter for radionuclides other than noble gases for the inhalation pathway for the child, based on the critical organ, in (mrem/yr) per (μ Ci/m³); and

 \mathbf{Q}_{i} is the release rate of radionuclides other than noble gases, i, in gaseous effluents, from all vent releases in (µCi/sec).

 $\overline{(\mathbf{X}/\mathbf{Q})}$ is as previously defined.

The dose parameter (R_i) includes the internal dosimetry of radionuclide, i, and the receptor's breathing rate, which are functions of the receptor's age. The child age group has been selected as the limiting age group. All radiodines are assumed to be released in elemental form.³⁰

R_i values were calculated according to:³¹

$$R_i = K'(BR) DFA_i$$

Eq. 16

²⁹ NUREG-0133, Section 5.2.1

³⁰ NUREG-0133, Section 5.2.1

³¹ NUREG-0133, Section 5.2.1.1

Where:

K' is a factor of units conversion factor: $1x10^6 \text{ pCi}/\mu\text{Ci}$;

BR is the breathing rate from Regulatory Guide 1.109, Table E-5 (m³/yr);

DFA_i is the maximum organ inhalation dose factor for the ith radionuclide, in (mrem/pCi). The total body is considered as an organ in the selection of DFA_i.^{32,33}

The results of periodic tritium, iodine and particulate samples of the Unit Vent and Radwaste Vent are used to verify the dose rate limit was not exceeded for the period during which the samples or composite samples were obtained.

3.3.2. Dose Due to Gaseous Effluents

3.3.2.1. Air Dose Due to Noble Gases

The air dose at the Site Boundary due to noble gases is calculated according to the following methodology:³⁴

During any calendar quarter, for gamma radiation:

$$D_{g} = 3.17E-08 \sum_{i} \left[M_{i} \left(\overline{X/Q} \right) Q_{i} \right] \leq 5 mrad$$
Eq. 17

During any calendar quarter, for beta radiation:

$$D_{b} = 3.17E-08 \sum_{i} \left[N_{i} \left(\overline{X/Q} \right) Q_{i} \right] \leq 10 mrad$$

Eq. 18

During any calendar year, for gamma radiation:

$$D_{g} = 3.17E-08 \sum_{i} \left[M_{i} \left(\overline{X/Q} \right) Q_{i} \right] \leq 10 mrad$$

Eq. 19

During any calendar year, for beta radiation:

$$D_{b} = 3.17E-08 \sum_{i} \left[N_{i} \left(\overline{X/Q} \right) Q_{i} \right] \leq 20 mrad$$
Eq. 20

Where:

³² Regulatory Guide 1.109, Appendix E, Table E-9

³³ ZZ-48

³⁴ NUREG-0133, Section 5.3.1

 \mathbf{D}_{g} is the air dose in mrad, from gamma radiation due to noble gases released in gaseous effluent;

 $\mathbf{D}_{\mathbf{b}}$ is the air dose in mrad, from beta radiation due to noble gases released in gaseous effluents;

 N_i is the air dose factor due to beta emissions for each identified noble gas radionuclide, i, in (mrad/yr) per (μ Ci/m³);

 \mathbf{Q}_i is the releases of noble gas radionuclides, i, in gaseous effluents, for all gaseous releases in (μ Ci). Releases are cumulative over the calendar quarter or year as appropriate. \mathbf{Q}_i is calculated as the product of the ventilation flow rate and the measured activity of the effluent stream as determined by sampling; and

3.17x10⁻⁸ is the inverse of the number of seconds per year.

 $\overline{X/Q}$ & M_i are as previously defined.

3.3.2.2. Dose Due to Radionuclides Other than Noble Gases

The dose to a Member of the Public from ¹³¹I and ¹³³I, for ³H, and all radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents released to areas at and beyond the Site Boundary, is calculated according to the following expressions:

During any calendar quarter:

$$\sum_{j} D_{l,j} \leq 7.5 mrem$$
Eq. 21

During any calendar year:

$$\sum_{j} D_{lj} \leq 15 mrem$$
Eq. 22

For each pathway, j, (i.e., for inhalation, ground plane, meat, cow- milk, goat- milk, and vegetation) D_{l,j} is calculated according to the expression:

$$D_{l,j} = 3.17E - 8\sum_{i} R_{l,i,j} \left[W_j Q_i \right]$$

Eq. 23

Where:

D_{i,j} is the dose in mrem, to a Member of the Public from radionuclides other than noble gases, from pathway j, received by organ I (including total body);

R_{I, i, j} is the dose factor for each identified radionuclide, i, in m² (mrem/yr) per (μ Ci/sec) or (mrem/yr) per (μ Ci/m³) as appropriate, for the pathway _j, and exposed organ I, appropriate to the age group of the critical Member of the Public receptor;

 W_i is the $\overline{X/Q}$ for the inhalation and tritium pathways, in sec/m³ and is the $\overline{D/Q}$ for the food and ground plane pathways, in meters⁻².

D/Q is the average relative deposition of the effluent at or beyond the Site Boundary, considering depletion of the plume during transport;

 \mathbf{Q}_{i} is the release of radioiodines, radioactive materials in particulate form, and radionuclides other than noble gases, i, in gaseous effluents, for all gaseous releases in μ Ci. Releases are cumulative over the calendar guarter or year as appropriate. Q_i is calculated as the product of ventilation flow rate and the measured activity of the effluent stream as determined by sampling; and

3.17x10⁻⁸ is the inverse of the number of seconds per year.

X/Q is as previously defined. Refer to Table 10, Table 11, Table 12, and Table 13 for applicability:

Although the annual average relative concentration X/Q and the average relative deposition

rate D/Q are generally considered to be at the approximate receptor location in lieu of the Site Boundary for these calculations, it is acceptable to consider the ingestion, inhalation, and ground plane pathways to coexist at the location of the nearest residence with the highest value of $\overline{X/Q}$.³⁵ The Total Body dose from ground plane deposition is added to the dose for each individual organ.36

3.4. Gaseous Radwaste Treatment System

The gaseous radwaste treatment system and the ventilation exhaust system are available for use whenever gaseous effluents require treatment prior to being released to the environment. The gaseous radwaste treatment system is designed to allow for the retention of all gaseous fission products to be discharged from the reactor coolant system. The retention system consists of eight (8) waste gas decay tanks. Normally, waste gases will be retained for at least 60 days prior to discharge. When practicable, waste gas decay tanks are discharged outside the growing season or at night such that ¹⁴C released from the waste gas system will not be incorporated into the ingestion pathways and will result in a lower dose to the Member of the Public. For this purpose, the growing season is defined as April 1 through November 1.³⁷ These systems will provide reasonable assurance that the releases of radioactive materials in gaseous effluents will be kept ALARA.

The Operability of the gaseous radwaste treatment system ensures this system will be available for use when gases require treatment prior to their release to the environment. Operability is demonstrated through compliance with REC 16.11.2.1, 16.11.2.2, and 16.11.2.3.

³⁷ Hammer, Gregory, R., "Climate of Missouri", monograph available from the National Climatic Data Center (NCDC) of the National Oceanic and Atmospheric Administration (NOAA), January, 2006.

³⁵ NUREG-0133, Section 5.3.1

³⁶ Regulatory Guide 1.109, Appendix C, Section 1

Projected doses (gamma air, beta air, and organ dose) due to gaseous effluents at or beyond the Site Boundary are determined each 31 days. The prior 31 day period is used to calculate compliance. This may be modified as appropriate to account for changes in radwaste treatment which may have a significant effect on the projected doses.

3.5. Dose Factors

The dose conversion factors were derived from the appropriate dose conversion factors in Regulatory Guide 1.109 and other sources as necessary.^{38,39} Particulate nuclides with a half-life of less than 8 days are not considered.^{40 90}Y, ¹⁴⁰La, and ¹⁴⁴Pr are included because the parent half-life is greater than 8 days, and equilibrium is assumed.

4. Dose and Dose Commitment from Uranium Fuel Cycle Sources

4.1. Calculation of Dose and Dose Commitment from Uranium Fuel Cycle Sources

The annual dose or dose commitment to a Member of the Public for Uranium Fuel Cycle Sources is determined as:

- Dose to the total body and internal organs due to gamma ray exposure from submersion in a cloud of radioactive noble gases, ground plane exposure, and direct radiation from the Unit, onsite storage of low-level radioactive waste, and outside storage tanks;
- Dose to skin due to beta radiation from submersion in a cloud of radioactive noble gases, and ground plane exposure;
- Thyroid dose due to inhalation and ingestion of radioiodines; and
- Organ dose due to inhalation and ingestion of radioactive material.

It is assumed that total body dose from sources of gamma radiation irradiates internal body organs at the same numerical rate.⁴¹

The dose from gaseous effluents is considered to be the summation of the dose at the individual's residence and the dose to the individual from activities within the Site Boundary.

Since the doses via liquid releases are very conservatively evaluated, there is reasonable assurance that no real individual will receive a significant dose from radioactive liquid release pathways. Therefore, only doses to individuals via airborne pathways and doses resulting from direct radiation are considered in determining compliance to 40 CFR 190.⁴²

There are no other Uranium Fuel Cycle Sources within 8 km of the Callaway Plant.

³⁸ ZZ-78

³⁹ ZZ-250

⁴⁰ Inspection Report 50-483/92002 (DRSS)

⁴¹ NUREG-0543, Section III, page 8

⁴² NUREG-0543, Section IV, page 9

4.1.1. Identification of the Member of the Public

The Member of the Public is considered to be a real individual, including all persons not occupationally associated with the Callaway Plant, but who may use portions of the plant site for recreational or other purposes not associated with the plant.⁴³ Accordingly, it is necessary to characterize this individual with respect to his utilization of areas both within and at or beyond the Site Boundary and identify, as far as possible, major assumptions which could be reevaluated if necessary to demonstrate continued compliance with 40 CFR 190 through the use of more realistic assumptions.^{44,45}

The evaluation of Total Dose from the Uranium Fuel Cycle should consider the dose to two Critical Receptors: (a) The Nearest Resident, and (b) The Critical Receptor within the Site Boundary.

4.1.2. Total Dose to the Nearest Resident

The dose to the Nearest Resident is due to plume exposure from noble gases, ground plane exposure, and inhalation and ingestion pathways. It is conservatively assumed that each ingestion pathway (meat, milk, and vegetation) exists at the location of the Nearest Resident.

It is assumed that direct radiation dose from operation of the Unit and storage of radioactive material, and dose from gaseous effluents due to activities within the Site Boundary is negligible for the Nearest Resident. The total Dose from the Uranium Fuel Cycle to the Nearest Resident is calculated using the methodology discussed in Section 3, using concurrent meteorological data for the location of the Nearest Resident with the highest value of X/Q.

The location of the Nearest Resident in each meteorological sector is determined from the Annual Land Use Census conducted in accordance with the Requirements of REC 16.11.4.2.

4.1.3. Total Dose to the Critical Receptor within the Site Boundary

The Union Electric Company has entered into an agreement with the State of Missouri Department of Conservation for management of the residual lands surrounding the Callaway Plant, including some areas within the Site Boundary. Under the terms of this agreement, certain areas have been opened to the public for low intensity recreational uses (hunting, hiking, sightseeing, etc.) but recreational use is excluded in an area immediately surrounding the plant site (refer to Figure 4.1). Much of the residual lands within the Site Boundary are leased to area farmers by the Department of Conservation to provide income to support management and development costs. Activities conducted under these leases are primarily comprised of farming (animal feed), grazing, and forestry.^{46,47,48}

⁴³ NUREG-0133, Section 3.8

⁴⁴ NUREG-0543, Section IV, page 9

⁴⁵ NUREG-0543, section III, page 6

⁴⁶ Environmental Report, OLS, Section 2.1.2.3

Based on the utilization of areas within the Site Boundary, it is reasonable to assume that the critical receptor within the Site Boundary is a farmer, and that his dose from activities within the Site Boundary is due to exposure incurred while conducting his farming activities. The current tenant has estimated that he spends approximately 1100 hours per year working in this area⁴⁹. Occupancy of areas within the Site Boundary is assumed to be averaged over a period of one year.

Any reevaluation of assumptions should consider only real receptors and real pathways using realistic assumption, and should include a reevaluation of the occupancy period at the locations of real exposure (e.g. a real individual would not simultaneously exist at each point of maximum exposure).

4.1.3.1. Total Dose to the Farmer from Gaseous Effluents

The Total Dose to the farmer from gaseous effluents is calculated for the adult age group using the methodology discussed in Section 3, utilizing concurrent meteorological data at the farmer's residence and historical meteorological data from Table 10 for activities within the Site Boundary. These dispersion parameters were calculated by assuming that the farmer's time is equally distributed over the areas farmed within the Site Boundary, and already have the total occupancy of 1100 hours/year factored into their value.⁵⁰

As a first approximation, the farmer's residence is assumed to be at the location of the Nearest Resident as shown in Table 10 and Table 11. The gaseous effluents dose at the farmer's residence is due to plume exposure from Noble Gases and the ground plane, inhalation, and ingestion pathways. For conservatism, it is acceptable to assume that all of the ingestion pathways exist at this location.

It is assumed that food ingestion pathways do not exist within the Site Boundary, therefore the gaseous effluents dose within the Site Boundary is due to plume exposure from Noble Gases and the ground plane and inhalation pathways.

4.1.3.1.1. Direct Radiation Dose

The direct radiation dose to the Member of Public due to activities within the Site Boundary is insignificant.⁵¹

⁴⁷ Environmental Report, OLS, Section 2.1.3.3.4

⁴⁸ Management Agreement for the Public Use of Lands, Exhibit A.

⁴⁹ Private communication, H.C. Lindeman & B.F.Holderness, August 6, 1986

⁵⁰ ZZ-67

⁵¹ HPCI 12-06

Enclosure to ULNRC-05985 Page 57 of 102



5. Radiological Environmental Monitoring

5.1. Description Of The Radiological Environmental Monitoring Program

The Radiological Environmental Monitoring Program is intended to act as a background data base for pre- operation and to supplement the radiological effluent release monitoring program during plant operation. Radiation exposure to the public from the various specific pathways and direct radiation can be adequately evaluated by this program.

Some deviations from the sampling frequency may be necessary due to seasonal unavailability, hazardous conditions, or other legitimate reasons. Efforts are made to obtain all required samples within the required time frame. Any deviation(s) in sampling frequency or location is documented in the Annual Radiological Environmental Operating Report.

REMP sampling locations that use meteorological sectors and or distance from the plant site were verified as described in HPCI 99-01.

Sampling, reporting, and analytical requirements are given in FSAR-SP Tables 16.11-7, 16.11-8, and 16.11-9.

Airborne, waterborne, direct radiation, and ingestion samples collected under the monitoring program are analyzed by an independent, third-party laboratory. With the exception of direct radiation, the laboratory is required to participate in an Interlaboratory Analyses Program per Reg. Guide 4.15.⁵² The laboratory participates in an Interlaboratory crosscheck program administered by Environmental Resources Associates (ERA), Mixed Analyte Performance Evaluation Program (MAPEP), or equivalent program. This participation includes all of the determinations (sample medium - radionuclide combination) that are both offered by ERA and/or MAPEP and are also included in the environmental monitoring program.

5.2. Performance Testing Of Environmental Thermoluminescence Dosimeters

Dosimeters used for monitoring of direct radiation dose in the Radiological Environmental Monitoring Program are tested for accuracy and precision to demonstrate compliance with the applicable portions of Regulatory Guide 4.13.

6. Annual Average And Short Term Atmospheric Dispersion Parameters

6.1. Atmospheric Dispersion Parameters

The dispersion values presented in Table 10 and Table 11 were determined through the analysis of on-site meteorological data collected during the three year period of May 4, 1973 to May 5, 1975 and March 16, 1978 to March 16, 1979.

6.1.1. Dispersion Estimates

The variable trajectory plume segment atmospheric transport model MESODIF-II (NUREG/-CR-0523) and the straight-line Gaussian dispersion model XOQDOQ (NUREG/CR2919) were used for determination of the long-term atmospheric dispersion

⁵² Regulatory Guide 4.15, rev. 1, section 6.3.2

ł

parameters. A more detailed discussion of the methodology and data utilized to calculate these parameters can be found elsewhere.⁵³

The Unit Vent and Radwaste Building Vent releases are at elevations of 66.5 meters and 20 meters above grade, respectively. Both release points are within the building wake of the structures on which they are located, and the Unit Vent is equipped with a rain cover which effectively eliminates the possibility of the exit velocity exceeding five times the horizontal wind speed. All gaseous releases are thus considered to be ground-level releases.⁵⁴

6.1.2. Determination of Dispersion Estimates for Special Receptor Locations Calculations utilizing the PUFF model were performed for 22 standard distances to obtain the desired dispersion parameters. Dispersion parameters at the Site Boundary and at special receptor locations were estimated by logarithmic interpolation according to:⁵⁵

$$X = X_1 \left(\frac{d}{d_1} \right)^B$$

Eq. 24

Where:

$$B = \frac{\ln (X_2 / X_1)}{\ln (d_2 / d_1)}$$
Eq. 25

X₁, **X**₂ are the atmospheric dispersion parameters at distance d_1 and d_2 , respectively, from the source. The distances d_1 and d_2 were selected such that they satisfy the relationship $d_1 < d < d_2$.

6.1.3. Atmospheric Dispersion Parameters for Farming Areas within the Site Boundary The dispersion parameters for farming areas within the Site Boundary are intended for a narrow scope application; that of calculating the dose to the current farmer from gaseous effluents while he conducts farming activities within the Site Boundary.

For the purpose of these calculations, it was assumed that all of the farmer's time, approximately 1100 hours per year, is spent on croplands within the Site Boundary, and that his time is divided evenly over all of the croplands. Fractional acreage/time - weighted dispersion parameters were calculated for each plot as described in calculation ZZ-67. The weighted dispersion parameters for each plot were summed (according to type) in order to produce a composite value of the dispersion parameters which are presented in Table 10 and Table 11. These dispersion parameters therefore represent the distributed activities of the farmer within the Site Boundary and his estimated occupancy period.

6.2. Annual Meteorological Data Processing

⁵³ FSAR-SA Section 2.3.5

⁵⁴ BLUE 1285

⁵⁵ FSAR-SA 2.3.5.2.1.2

The annual atmospheric dispersion parameters utilized in the calculation of doses for demonstration of compliance with the numerical dose objectives of 10 CFR 50, Appendix I, are determined using computer codes and models consistent with XOQDOQ.⁵⁶ These codes have been validated and verified by a qualified meteorologist prior to implementation. Multiple sensors are utilized to ensure 90% valid data recovery for the wind speed, wind direction, and ambient air temperature parameters as required by Regulatory Guide 1.23. The selection hierarchy is presented in Table 14.

The vertical height of the highest adjacent building, V, used to perform concurrent year annual average atmospheric dispersion X/Q calculations is 169.16 meters.

Meteorological Data is periodically verified to ensure valid data is being collected.

7. Reporting Requirements

7.1. Annual Radiological Environmental Operating Report

The reporting requirements for the Annual Radiological Environmental Operating Report (AREOR) have been relocated to FSAR-SP 16.11.5.1.

7.2. Annual Radioactive Effluent Release Report

The reporting requirements for the Annual Radioactive Effluent Release Report (ARERR) have been relocated to FSAR-SP 16.11.5.2. The application of atmospheric dispersion parameters in the ARERR is presented in Table 13.

8. Implementation of ODCM Methodology

The ODCM provides the mathematical relationships used to implement the Radioactive Effluent Controls. For routine effluent release and dose assessment, computer codes are utilized to implement the ODCM methodologies. These codes are evaluated in accordance with the requirements of plant operating procedures to ensure that they produce results consistent with the methodologies presented in the ODCM. Plant procedures implement the ODCM methodology.

9. Radioactive Effluent Controls (REC)

The Radioactive Effluent Controls have been relocated to FSAR-SP Chapter 16.11,"Offsite Dose Calculation Manual Radioactive Effluent Controls". The former ODCM REC numbers appear on each of the RECs in FSAR-SP Chapter 16.11, and may be used as a cross-reference between the previous and the current numbering system if necessary.

10. Administrative Controls

⁵⁶ NUREG/CR-2919

10.1. Major Changes to Liquid and Gaseous Radwaste Treatment Systems

A summary of Licensee-initiated major changes to the Radwaste Treatment Systems (liquid and gaseous) must be reported to the Commission in the Annual Radioactive Effluent Release Report (ARERR) for the period in which the evaluation was reviewed by the On-Site Review Committee (ORC). On site documentation must contain:

- A summary of the evaluation that led to the determination that the change could be made in accordance with 10 CFR 50.59;
- Sufficient detailed information to totally support the reason for the change without benefit of additional or supplemental information;
- A detailed description of the equipment, components and process involved and the interfaces with other plant systems;
- An evaluation of the change, which shows the predicted releases of radioactive materials in liquid and gaseous effluents that differ from those previously predicted in the License application and amendments thereto;
- An evaluation of the change, which shows the expected maximum exposures to a Member of the Public in the Unrestricted Area and to the general population that differ from those previously estimated in the License application and amendments thereto;
- A comparison of the predicted releases of radioactive materials, in liquid and gaseous effluents, to the actual releases for the period prior to when the changes are to be made;
- An estimate of the exposure to plant operating personnel as a result of the change; and
- Documentation of the fact that the change was reviewed and found acceptable by the ORC.

Changes to the Radwaste Treatment Systems shall become effective upon review and approval by the ORC.

10.2. Changes to the Offsite Dose Calculation Manual (ODCM)

All changes to the ODCM shall be performed pursuant to T/S AC 5.5.1

Review for each revision of the ODCM must include the Radiation Protection Department.

11. Bibliography

ANSI N13.10-1974, "Specification & Performance of On-Site Instrumentation for Continuously Monitoring Radioactivity in Effluents". (1974)

BLUE 1232, letter, "Callaway Annual Average X/Q Values and "S" Values", J. H. Smith (Bechtel Power Corporation) to D. W. Capone (Union Electric Co.), dated February 9, 1984.

BLUE 1285, letter, "Callaway Annual Average X/Q and D/Q Values", J. H. Smith (Bechtel Power Corporation), to D. W. Capone (Union Electric Co.), dated February 27, 1984.

CAR 200700053 – "Missouri River Low Flow Trend for 2006", Attachments: Phase 1 Final Draft

CDP-ZZ-00200, Appendix B, "Primary Plant Systems Tables", rev. 22

EGG-PHY-9703, "Technical Evaluation Report for the evaluation of ODCM Revision 0 (May, 1990) Callaway Plant, Unit 1", transmitted via letter, Samuel J. Collins (USNRC) to D. F. Schnell (UE), dated July 12, 1996.

EPRI TR-1021106, "Estimation of ¹⁴C in Nuclear Power Plant Effluents", December, 2010

Generic Letter 89-01, "Guidance for the Implementation of Programmatic Controls for RETS in the Administrative Controls Section of Technical Specifications and the Relocation of Procedural Details of Current RETS to the Offsite Dose Calculation Manual or Process Control Program", US Nuclear Regulatory Commission. (1989)

Hammer, Gregory, R., "Climate of Missouri", monograph available from the National Climatic Data Center (NCDC) of the National Oceanic and Atmospheric Administration (NOAA), January, 2006

HPCI 87-10, Rev. 1, "Methodology for Calculating the Response of Gross Nal(TI) Monitors to Liquid Effluent Streams". (2005)

HPCI 89-02, "Calculation of ODCM Dose Commitment Factors". (1989)

HPCI 96-05, "Calculation of Maximum Background Value for HB-RE-18". (1996)

HPCI 99-01, "Documentation of REMP Procedure Changes". (1999)

HPCI 99-05, "Calculation of Setpoint for GL-RE-202". (1999)

HPCI 04-06 (Rev. 1), "Calculation of Liquid Effluent Dose Commitment Factors (A_{it}) for the Adult Age Group". (2004)

HPCI 05-09, "Radiological Environmental Monitoring Program (REMP) Calculation of Direct Dose from RAM Storage at Stores II". (2005)

HPCI 05-10, "Radiological Environmental Monitoring Program (REMP) Calculation of Direct Dose from RAM Storage in the Radwaste Yard". (2005)

HPCI 06-01, Rev. 0, "Equipment Hatch Platform and Missile Shield Modification Direct Dose Calculation to the Member of the Public". (2006)

HPCI 10-03, "Evaluation of the 2010 Land Use Census". (2010)

HPCI 11-02, "Dose to the Member of the Public from the Release of ¹⁴C in Gaseous Effluents for 2010". (2011)

Page **30** of **72**

HPCI 12-06, "Evaluation of Direct Radiation Dose to the Member of the Public Due to Activities within the site Boundary". (2012)

IAEA Technical Reports Series no. 421, "Management of Waste Containing Tritium and Carbon- 14", 2004

Internal USNRC memo, F. J. Congel to V. L. Miller, et al, dated April 17, 1992.

Kunz, C., "Carbon-14 Discharge at Three Light- Water Reactors", *Health Physics*, vol. 49, pages 25-35, 1985

Letter, F. J. Congel to J. F. Schmidt, dated April 23, 1992.

Letter, F. J. Congel to J. F. Schmidt, dated December 9, 1991.

Letter, F. J. Congel to J. F. Schmidt, dated June 8, 1993.

Letter, F. J. Congel to J. F. Schmidt, dated September 14, 1992.

M-109-0007-06, Revision 5

Management Agreement for the Public Use of Lands, Union Electric Company and the State of Missouri Department of Conservation, December 21, 1982.

MICROSHIELD, Grove Engineering Inc.

NCRP Report 81, "Carbon-14 in the Environment", January 1985

Neeb, Karl- Heinz, *The Radiochemistry of Nuclear Power Plants with Light Water Reactors*, Walter de Gruyter, Berlin, 1997

NEO-54, memo, D. W. Capone to S. E. Miltenberger, dated January 5, 1983; Union Electric Company correspondence.

NRC Answers to 10 CFR 20 Implementation Questions

NUREG-0017, "Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Pressurized Water Reactors PWR-GALE Code," April 1985

NUREG-0133, "Preparation of Radiological Effluent Technical Specification for Nuclear Power Plants", U.S. Nuclear Regulatory Commission. (1978)

NUREG-0543, "Methods for Demonstrating LWR Compliance with the EPA Uranium Fuel Cycle Standard (40 CFR Part 190)", U. S. Nuclear Regulatory Commission. (1980)

NUREG-1301, "Offsite Dose Calculation Manual Guidance: Standard Radiological Effluent Controls for Pressurized Water Reactors, Generic Letter 89-01, Supplement No. 1", April, 1991 NUREG/CR-2919, "XOQDOQ, Computer Program For the Meteorological Evaluation of Routine Effluent Releases at Nuclear Power Stations", U.S. Nuclear Regulatory Commission. (1982)

Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purposes of Evaluating Compliance with 10 CFR Part 50, Appendix I", Revision 1, U. S. Nuclear Regulatory Commission. (1977)

Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors", Revision 1, U. S. Nuclear Regulatory Commission. (1977)

Regulatory Guide 1.21, "Measuring, Evaluating, and Reporting Radioactive Material in Liquid and Gaseous Effluents and Solid Waste", (Revision 2), U. S. Nuclear Regulatory Commission. (2009)

Regulatory Guide 4.13, "Performance, Testing, and procedural specifications for Thermoluminescence Dosimetry: Environmental Applications "(Revision 1), U. S. Nuclear Regulatory Commission. (1977)

Regulatory Guide 4.15, "Quality Assurance for Radiological Monitoring Programs (Normal Operations) – Effluent Streams and the Environment" (Revision 1), U. S. Nuclear Regulatory Commission (1979)

Statements of Consideration, Federal Register, Vol. 56, No. 98, Tuesday, May 21, 1991, Subpart D, page 23374.

TID-7004, "Reactor Shielding Design Manual", Rockwell, Theodore, Editor. (1956)

Title 10, "Energy", Chapter 1, Code of Federal Regulations, Part 20; U.S. Government Printing Office, Washington, D.C. 20402.

Title 10, "Energy", Chapter 1, Code of Federal Regulations, Part 50, Appendix I; U.S. Government Printing Office, Washington, D.C. 20402.

Title 40, "Protection of Environment", Chapter 1, Code of Federal Regulations, Part 190; U.S. Government Print Office, Washington, D.C. 20402.

Union Electric Company Callaway Plant Environmental Report, Operating License Stage

Union Electric Company Callaway Plant, Unit 1, Final Safety Analysis Report- Standard Plant

Union Electric Company Safety Analysis Calculation 87-001-00, "Dose Rate from Reactor Building to Owner Controlled Area Fence During Normal Operation". (1987)

UOTH 83-58, "Documentation of ODCM Dose Factors and Parameters". (1983)

USNRC Inspection Report 50-483/92002(DRSS), Section 5, page 5.

Westinghouse Calculation Note CN-TA-02-135, "Callaway (SCP) RSG IGOR/RETRAN Base Deck, May 16, 2003

ZZ-250, Rev. 0, "ODCM Gaseous Pathway Dose Factors for Child Age Group and Ground Plane Dose Factors". (1992)

ZZ-48, "Calculation of Inhalation and Ingestion Dose Commitment Factors for the Adult and Child". (1988)

ZZ-57, "Dose Factors for Eu-154". (1989)

ZZ-67, "Annual Average Atmospheric Dispersion Parameters". (1989)

ZZ-78, Rev. 2, "ODCM Gaseous Pathway Dose Factors for Adult Age Group". (1992)

Table 1: Ingestion Dose Commitment Values ($A_{i\tau}$) for Adult Age Group

(mrem/hr) per (μCi/ml)							
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
³Н	0.00E+00	2.26E-01	2.26E-01	2.26E-01	2.26E-01	2.26E-01	2.26E-01
⁷ Be	1.31E-02	2.98E-02	1.45E-02	0.00E+00	3.15E-02	0.00E+00	5.17E+00
²⁴ Na	4.07E+02	4.07E+02	4.07E+02	4.07E+02	4.07E+02	4.07E+02	4.07E+02
⁵¹ Cr	0.00E+00	0.00E+00	1.27E+00	7.61E-01	2.81E-01	1.69E+00	3.20E+02
⁵⁴ Mn	0.00E+00	4.38E+03	8.35E+02	0.00E+00	1.30E+03	0.00E+00	1.34E+04
⁵⁶ Mn	0.00E+00	1.10E+02	1.95E+01	0.00E+00	1.40E+02	0.00E+00	3.51E+03
⁵⁵ Fe	6.58E+02	4.55E+02	1.06E+02	0.00E+00	0.00E+00	2.54E+02	2.61E+02
⁵⁹ Fe	1.04E+03	2.44E+03	9.36E+02	0.00E+00	0.00E+00	6.82E+02	8.14E+03
⁵⁷ Co	0.00E+00	2.09E+01	3.48E+01	0.00E+00	0.00E+00	0.00E+00	5.31E+02
⁵⁸ Co	0.00E+00	8.92E+01	2.00E+02	0.00E+00	0.00E+00	0.00E+00	1.81E+03
⁶⁰ Co	0.00E+00	2.56E+02	5.65E+02	0.00E+00	0.00E+00	0.00E+00	4.81E+03
⁶³ Ni	3.11E+04	2.16E+03	1.04E+03	0.00E+00	0.00E+00	0.00E+00	4.50E+02
⁶⁵ Ni	1.26E+02	1.64E+01	7.49E+00	0.00E+00	0.00E+00	0.00E+00	4.17E+02
⁶⁴ Cu	0.00E+00	9.97E+00	4.68E+00	0.00E+00	2.51E+01	0.00E+00	8.50E+02
⁶⁵ Zn	2.32E+04	7.37E+04	3.33E+04	0.00E+00	4.93E+04	0.00E+00	4.64E+04
⁶⁹ Zn	4.93E+01	9.43E+01	6.56E+00	0.00E+00	6.13E+01	0.00E+00	1.42E+01
⁸² Br	0.00E+00	0.00E+00	2.27E+03	0.00E+00	0.00E+00	0.00E+00	2.60E+03
⁸³ Br	0.00E+00	0.00E+00	4.04E+01	0.00E+00	0.00E+00	0.00E+00	5.82E+01
⁸⁴ Br	0.00E+00	0.00E+00	5.24E+01	0.00E+00	0.00E+00	0.00E+00	4.11E-04
⁸⁵ Br	0.00E+00	0.00E+00	2.15E+00	0.00E+00	0.00E+00	0.00E+00	1.01E-15
⁸⁶ Rb	0.00E+00	1.01E+05	4.71E+04	0.00E+00	0.00E+00	0.00E+00	1.99E+04
⁸⁸ Rb	0.00E+00	2.90E+02	1.54E+02	0.00E+00	0.00E+00	0.00E+00	4.00E-09
⁸⁹ Rb	0.00E+00	1.92E+02	1.35E+02	0.00E+00	0.00E+00	0.00E+00	1.12E-11
⁸⁹ Sr	2.21E+04	0.00E+00	6.35E+02	0.00E+00	0.00E+00	0.00E+00	3.55E+03
⁹⁰ Sr	5.44E+05	0.00E+00	1.34E+05	0.00E+00	0.00E+00	0.00E+00	1.57E+04
⁹¹ Sr	4.07E+02	0.00E+00	1.64E+01	0.00E+00	0.00E+00	0.00E+00	1.94E+03
⁹² Sr	1.54E+02	0.00E+00	6.68E+00	0.00E+00	0.00E+00	0.00E+00	3.06E+03
9 ⁰ Y	5.76E-01	0.00E+00	1.54E-02	0.00E+00	0.00E+00	0.00E+00	6.10E+03
^{91m} Y	5.44E-03	0.00E+00	2.11E-04	0.00E+00	0.00E+00	0.00E+00	1.60E-02
⁹¹ Y	8.44E+00	0.00E+00	2.26E-01	0.00E+00	0.00E+00	0.00E+00	4.64E+03
⁹² Y	5.06E-02	0.00E+00	1.48E-03	0.00E+00	0.00E+00	0.00E+00	8.86E+02
⁹³ Y	1.60E-01	0.00E+00	4.43E-03	0.00E+00	0.00E+00	0.00E+00	5.09E+03
⁹⁵ Zr	2.40E-01	7.70E-02	5.21E-02	0.00E+00	1.21E-01	0.00E+00	2.44E+02
⁹⁷ Zr	1.33E-02	2.68E-03	1.22E-03	0.00E+00	4.04E-03	0.00E+00	8.30E+02
⁹⁵ Nb	4.47E+02	2.48E+02	1.34E+02	0.00E+00	2.46E+02	0.00E+00	1.51E+06
⁹⁹ Mo	0.00E+00	1.03E+02	1.96E+01	0.00E+00	2.34E+02	0.00E+00	2.39E+02
^{99m} Tc	8.87E-03	2.51E-02	3.19E-01	0.00E+00	3.81E-01	1.23E-02	1.48E+01

Table 1: Ingestion Dose Commitment Values ($A_{i\tau}$) for Adult Age Group

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
¹⁰¹ Tc	9.12E-03	1.31E-02	1.29E-01	0.00E+00	2.37E-01	6.72E-03	3.95E-14
¹⁰³ Ru	4.43E+00	0.00E+00	1.91E+00	0.00E+00	1.69E+01	0.00E+00	5.17E+02
¹⁰⁵ Ru	3.69E-01	0.00E+00	1.46E-01	0.00E+00	4.76E+00	0.00E+00	2.26E+02
¹⁰⁶ Ru	6.58E+01	0.00E+00	8.33E+00	0.00E+00	1.27E+02	0.00E+00	4.26E+03
¹⁰⁹ Cd	0.00E+00	5.55E+02	1.94E+01	0.00E+00	5.31E+02	0.00E+00	5.60E+03
^{110m} Ag	8.85E-01	8.18E-01	4.86E-01	0.00E+00	1.61E+00	0.00E+00	3.34E+02
¹¹³ Sn	5.67E+04	1.61E+03	3.26E+03	9.19E+02	0.00E+00	0.00E+00	1.69E+05
¹²² Sb	5.48E-01	1.12E-02	1.66E-01	7.73E-03	0.00E+00	2.94E-01	0.00E+00
¹²⁴ Sb	6.70E+00	1.27E-01	2.66E+00	1.63E-02	0.00E+00	5.22E+00	1.90E+02
¹²⁵ Sb	4.29E+00	4.79E-02	1.02E+00	4.36E-03	0.00E+00	3.30E+00	4.72E+01
^{127m} Te	6.48E+03	2.32E+03	7.90E+02	1.66E+03	2.63E+04	0.00E+00	2.17E+04
¹²⁷ Te	1.05E+02	3.78E+01	2.28E+01	7.80E+01	4.29E+02	0.00E+00	8.31E+03
^{129m} Te	1.10E+04	4.11E+03	1.74E+03	3.78E+03	4.60E+04	0.00E+00	5.54E+04
¹²⁹ Te	3.01E+01	1.13E+01	7.33E+00	2.31E+01	1.26E+02	0.00E+00	2.27E+01
^{131m} Te	1.66E+03	8.10E+02	6.75E+02	1.28E+03	8.21E+03	0.00E+00	8.04E+04
¹³¹ Te	1.89E+01	7.88E+00	5.96E+00	1.55E+01	8.26E+01	0.00E+00	2.67E+00
¹³² Te	2.41E+03	1.56E+03	1.47E+03	1.72E+03	1.50E+04	0.00E+00	7.38E+04
¹³⁰	2.71E+01	8.01E+01	3.16E+01	6.79E+03	1.25E+02	0.00E+00	6.89E+01
¹³¹	1.49E+02	2.14E+02	1.22E+02	7.00E+04	3.66E+02	0.00E+00	5.64E+01
¹³²	7.29E+00	1.95E+01	6.82E+00	6.82E+02	3.11E+01	0.00E+00	3.66E+00
133	5.14E+01	8.87E+01	2.70E+01	1.30E+04	1.55E+02	0.00E+00	7.97E+01
¹³⁴ j	3.81E+00	1.03E+01	3.70E+00	1.79E+02	1.64E+01	0.00E+00	9.01E-03
¹³⁵	1.59E+01	4.17E+01	1.54E+01	2.75E+03	6.68E+01	0.00E+00	4.70E+01
¹³⁴ Cs	2.98E+05	7.09E+05	5.79E+05	0.00E+00	2.29E+05	7.61E+04	1.24E+04
¹³⁶ Cs	3.12E+04	1.23E+05	8.86E+04	0.00E+00	6.85E+04	9.38E+03	1.40E+04
¹³⁷ Cs	3.82E+05	5.22E+05	3.42E+05	0.00E+00	1.77E+05	5.89E+04	1.01E+04
¹³⁸ Cs	2.64E+02	5.22E+02	2.59E+02	0.00E+00	3.84E+02	3.79E+01	2.23E-03
¹³⁹ Ba	9.29E-01	6.62E-04	2.72E-02	0.00E+00	6.19E-04	3.75E-04	1.65E+00
¹⁴⁰ Ba	1.94E+02	2.44E-01	1.27E+01	0.00E+00	8.30E-02	1.40E-01	4.00E+02
¹⁴¹ Ba	4.51E-01	3.41E-04	1.52E-02	0.00E+00	3.17E-04	1.93E-04	2.13E-10
¹⁴² Ba	2.04E-01	2.10E-04	1.28E-02	0.00E+00	1.77E-04	1.19E-04	2.87E-19
¹⁴⁰ La	1.50E-01	7.54E-02	1.99E-02	0.00E+00	0.00E+00	0.00E+00	5.54E+03
¹⁴² La	7.66E-03	3.48E-03	8.68E-04	0.00E+00	0.00E+00	0.00E+00	2.54E+01
¹⁴¹ Ce	2.24E-02	1.52E-02	1.72E-03	0.00E+00	7.04E-03	0.00E+00	5.79E+01
¹⁴³ Ce	3.95E-03	2.92E+00	3.23E-04	0.00E+00	1.29E-03	0.00E+00	1.09E+02
¹⁴⁴ Ce	1.17E+00	4.88E-01	6.27E-02	0.00E+00	2.90E-01	0.00E+00	3.95E+02
¹⁴³ Pr	5.51E-01	2.21E-01	2.73E-02	0.00E+00	1.27E-01	0.00E+00	2.41E+03

(mrem/hr) per (µCi/ml)

(mrem/hr) per (µCi/ml)							
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
¹⁴⁴ Pr	1.80E-03	7.48E-04	9.16E-05	0.00E+00	4.22E-04	0.00E+00	2.59E-10
¹⁴⁷ Nd	3.76E-01	4.35E-01	2.60E-02	0.00E+00	2.54E-01	0.00E+00	2.09E+03
¹⁵⁴ Eu	3.68E+01	4.52E+00	3.22E+00	0.00E+00	2.17E+01	0.00E+00	3.28E+03
¹⁸¹ Hf	4.00E-02	1.94E-01	1.80E-02	0.00E+00	4.18E-02	0.00E+00	2.21E+02
¹⁸⁷ W	2.96E+02	2.47E+02	8.65E+01	0.00E+00	0.00E+00	0.00E+00	8.10E+04
²³⁷ Np	3.28E+04	2.85E+03	1.33E+03	0.00E+00	9.86E+03	0.00E+00	1.90E+03
²³⁹ Np	2.85E-02	2.80E-03	1.54E-03	0.00E+00	8.74E-03	0.00E+00	5.75E+02
²³⁸ Pu	5.70E+03	8.03E+02	1.43E+02	0.00E+00	6.13E+02	0.00E+00	6.12E+02
²³⁹ Pu*	6.59E+03	8.88E+02	1.60E+02	0.00E+00	6.80E+02	0.00E+00	5.68E+02
²⁴¹ Pu	1.38E+02	7.07E+00	2.78E+00	0.00E+00	1.28E+01	0.00E+00	1.17E+01
²⁴¹ Am	4.90E+04	1.72E+04	3.24E+03	0.00E+00	2.44E+04	0.00E+00	4.44E+03
²⁴² Cm	1.23E+03	1.26E+03	8.20E+01	0.00E+00	3.72E+02	0.00E+00	4.74E+03
²⁴³ Cm**	3.82E+04	1.44E+04	2.24E+03	0.00E+00	1.05E+04	0.00E+00	4.67E+03

Table 1: Ingestion Dose Commitment Values ($A_{i\tau}$) for Adult Age Group

*Includes Pu-240 contribution

**Includes Cm-244 contribution

Enclosure to ULNRC-05985 Page 69 of 102

(pCi/kg) per (pCi/liter)								
Element	Bf _i Fish (Freshwater)		Element	Bf _i Fish (Freshwater)				
Н	9.0 E - 01		Rh	1.0 E + 01				
Be	2.0 E + 00		Ag	2.3 E + 00				
Na	1.0 E + 02		Cd	2.0 E + 02				
Cr	2.0 E + 02		Sn	3.0 E + 03				
Mn	4.0 E + 02		Sb	1.0 E + 00				
Fe	1.0 E + 02		Te	4.0 E + 02				
Со	5.0 E + 01			1.5 E + 01				
Ni	1.0 E + 02		Cs	2.0 E + 03				
Cu	5.0 E + 01		Ва	4.0 E + 00				
Zn	2.0 E + 03		La	2.5 E + 01				
Br	4.2 E + 02		Ce	1.0 E + 00				
Rb	2.0 E + 03		Pr	2.5 E + 01				
Sr	3.0 E + 01		Nd	2.5 E + 01				
Y	2.5 E + 01		Eu	2.5 E + 01				
Zr	3.3 E + 00		Hf	3.3 E + 00				
Nb	3.0 E + 04		W	1.2 E + 03				
Mo	1.0 E + 01		Np	1.0 E + 01				
Тс	1.5 E + 01		Pu	3.5 E + 00				
Ru	1.0 E + 01		Am	2.5 E + 01				
			Cm	2.5 E + 01				

Table 2: Bioaccumulation Factor (Bf_i) ^(a)

^(a) Values from Regulatory Guide 1.109, Rev. 1, Table A-1 and HPCI 04-06.
Enclosure to ULNRC-05985 Page 70 of 102

	Total Body Dose Factor	Skin Dose Factor	Gamma Air Dose Factor	Beta Air Dose Factor
Radionuclide	К _і	Li	Mi	Ni
	(mrem/yr) per (µCi/m³)	(mrem/yr) per (µCi/m³)	(mrad/yr) per (µCi/m³)	(mrad/yr) per (µCi/m³)
^{83m} Kr	7.56 E-02		1.93 E+01	2.88 E+02
^{85m} Kr	1.17E+03	1.46E+03	1.23 E+03	1.97 E+03
⁸⁵ Kr	1.61 E+01	1.34 E+03	1.72 E+01	1.95 E+03
⁸⁷ Kr	5.92 E+03	9.73 E+03	6.17 E+03	1.03 E+04
⁸⁸ Kr	1.47 E+04	2.37 E+03	1.52 E+04	2.93 E+03
⁸⁹ Kr	1.66 E+04	1.01 E+04	1.73 E+04	1.06 E+04
⁹⁰ Kr	1.56 E+04	7.29 E+03	1.63 E+04	7.83 E+03
^{131m} Xe	9.15 E+01	4.76 E+02	1.56 E+02	1.11 E+03
^{133m} Xe	2.51 E+02	9.94 E+02	3.27 E+02	1.48 E+03
¹³³ Xe	2.94 E+02	3.06 E+02	3.53 E+02	1.05 E+03
^{135m} Xe	3.12 E+03	7.11 E+02	3.36 E+03	7.39 E+02
¹³⁵ Xe	1.81 E+03	1.86 E+03	1.92 E+03	2.46 E+03
¹³⁷ Xe	1.42 E+03	1.22 E+04	1.51 E+03	1.27 E+04
¹³⁸ Xe	8.83 E+03	4.13 E+03	9.21 E+03	4.75 E+03
⁴¹ Ar	8.84 E+03	2.69 E+03	9.30 E+03	3.28 E+03

 Table 3: Dose Factor for Exposure to a Semi- Infinite Cloud of Noble Gases

Table 4: Gi	round Plane	Pathway D	Dose Factors	(R _i)
-------------	-------------	-----------	---------------------	-------------------

(m²mrem/yr) per (μCi/sec)											
Nuclide	Total Body	Skin		Nuclide	Total Body	Skin					
³ Н	0.00E+00	0.00E+00		¹¹³ Sn	1.43E+07	4.09E+07					
⁷ Be	2.24E+07	3.21E+07		¹²⁴ Sb	8.74E+08	1.23E+09					
⁵¹ Cr	4.66E+06	5.51E+06		¹²⁵ Sb	3.57E+09	5.19E+09					
⁵⁴ Mn	1.39E+09	1.63E+09		^{127m} Te	9.17E+04	1.08E+05					
⁵⁵ Fe	0.00E+00	0.00E+00		^{129m} Te	1.98E+07	2.31E+07					
⁵⁹ Fe	2.73E+08	3.21E+08		¹³⁰ l	5.51E+06	6.69E+06					
⁵⁷ Co	2.98E+08	4.37E+08		¹³¹	1.72E+07	2.09E+07					
⁵⁸ Co	3.79E+08	4.44E+08		¹³²	1.25E+06	1.47E+06					
⁶⁰ Co	2.15E+10	2.53E+10		¹³³	2.45E+06	2.98E+06					
⁶³ Ni	0.00E+00	0.00E+00		¹³⁴	4.47E+05	5.31E+05					
⁶⁵ Zn	7.47E+08	8.59E+08		135	2.53E+06	2.95E+06					
⁸⁶ Rb	8.99E+06	1.03E+07		¹³⁴ Cs	6.85E+09	8.00E+09					
⁸⁹ Sr	2.16E+04	2.51E+04		¹³⁶ Cs	1.51E+08	1.71E+08					
⁹⁰ Sr	0.00E+00	0.00E+00		¹³⁷ Cs	1.03E+10	1.20E+10					
⁹⁰ Y	5.36E+06	6.32E+06		¹⁴⁰ Ba	2.05E+07	2.35E+07					
⁹¹ Y	1.07E+06	1.21E+06		¹⁴⁰ La	1.47E+08	1.66E+08					
⁹⁵ Zr	2.45E+08	2.84E+08		¹⁴¹ Ce	1.37E+07	1.54E+07					
⁹⁵ Nb	2.50E+08	2.94E+08		¹⁴⁴ Ce	6.96E+07	8.04E+07					
¹⁰³ Ru	1.08E+08	1.26E+08		¹⁴³ Pr	0.00E+00	0.00E+00					
¹⁰⁶ Ru	4.22E+08	5.07E+08		¹⁴⁴ Pr	4.35E+07	5.00E+07					
^{110m} Ag	3.44E+09	4.01E+09		¹⁴⁷ Nd	8.39E+06	1.01E+07					
¹⁰⁹ Cd	3.76E+07	1.54E+08		¹⁵⁴ Eu	2.21E+10	3.15E+10					
			-	¹⁸¹ Hf	1.97E+08	2.82E+08					

Table 6: Child Grass- Cow – Milk Pathway Dose Factors (R_i)

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI	
³ Н	0.00E+00	1.57E+03	1.57E+03	1.57E+03	1.57E+03	1.57E+03	1.57E+03	
⁷ Be	7.50E+03	1.28E+04	8.20E+03	0.00E+00	1.25E+04	0.00E+00	7.12E+05	
⁵¹ Cr	0.00E+00	0.00E+00	1.02E+05	5.66E+04	1.55E+04	1.03E+05	5.40E+06	
⁵⁴ Mn	0.00E+00	2.10E+07	5.59E+06	0.00E+00	5.89E+06	0.00E+00	1.76E+07	
⁵⁵ Fe	1.12E+08	5.94E+07	1.84E+07	0.00E+00	0.00E+00	3.36E+07	1.10E+07	
⁵⁹ Fe	1.20E+08	1.95E+08	9.70E+07	0.00E+00	0.00E+00	5.64E+07	2.03E+08	
⁵⁷ Co	0.00E+00	3.84E+06	7.78E+06	0.00E+00	0.00E+00	0.00E+00	3.15E+07	
⁵⁸ Co	0.00E+00	1.21E+07	3.72E+07	0.00E+00	0.00E+00	0.00E+00	7.08E+07	
⁶⁰ Co	0.00E+00	4.32E+07	1.27E+08	0.00E+00	0.00E+00	0.00E+00	2.39E+08	
⁶³ Ni	2.97E+10	1.59E+09	1.01E+09	0.00E+00	0.00E+00	0.00E+00	1.07E+08	
⁶⁵ Zn	4.14E+09	1.10E+10	6.86E+09	0.00E+00	6.95E+09	0.00E+00	1.94E+09	
⁸⁶ Rb	0.00E+00	8.78E+09	5.40E+09	0.00E+00	0.00E+00	0.00E+00	5.65E+08	
⁸⁹ Sr	6.63E+09	0.00E+00	1.89E+08	0.00E+00	0.00E+00	0.00E+00	2.57E+08	
⁹⁰ Sr	1.12E+11	0.00E+00	2.84E+10	0.00E+00	0.00E+00	0.00E+00	1.51E+09	
⁹⁰ Y	3.38E+03	0.00E+00	9.05E+01	0.00E+00	0.00E+00	0.00E+00	9.62E+06	
⁹¹ Y	3.91E+04	0.00E+00	1.04E+03	0.00E+00	0.00E+00	0.00E+00	5.20E+06	
⁹⁵ Zr	3.84E+03	8.43E+02	7.51E+02	0.00E+00	1.21E+03	0.00E+00	8.80E+05	
⁹⁵ Nb	3.72E+05	1.45E+05	1.03E+05	0.00E+00	1.36E+05	0.00E+00	2.68E+08	
¹⁰³ Ru	4.29E+03	0.00E+00	1.65E+03	0.00E+00	1.08E+04	0.00E+00	1.11E+05	
¹⁰⁶ Ru	9.25E+04	0.00E+00	1.15E+04	0.00E+00	1.25E+05	0.00E+00	1.44E+06	
^{110m} Ag	2.09E+08	1.41E+08	1.13E+08	0.00E+00	2.63E+08	0.00E+00	1.68E+10	
¹⁰⁹ Cd	0.00E+00	3.86E+06	1.79E+05	0.00E+00	3.45E+06	0.00E+00	1.25E+07	
¹¹³ Sn	6.11E+08	1.26E+07	3.48E+07	9.29E+08	0.00E+00	0.00E+00	4.32E+08	
¹²⁴ Sb	1.09E+08	1.41E+06	3.81E+07	2.40E+05	0.00E+00	6.03E+07	6.80E+08	
¹²⁵ Sb	8.71E+07	6.72E+05	1.83E+07	8.07E+04	0.00E+00	4.86E+07	2.08E+08	
^{127m} Te	2.08E+08	5.61E+07	2.47E+07	4.98E+07	5.94E+08	0.00E+00	1.69E+08	
^{129m} Te	2.72E+08	7.59E+07	4.22E+07	8.76E+07	7.98E+08	0.00E+00	3.31E+08	

(m²mrem/yr) per (µCi/sec)

Table 6: Child Grass- Cow – Milk Pathway Dose Factors (R_i)

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI	
¹³⁰	1.73E+06	3.50E+06	1.80E+06	3.85E+08	5.23E+06	0.00E+00	1.64E+06	
¹³¹	1.30E+09	1.31E+09	7.46E+08	4.34E+11	2.15E+09	0.00E+00	1.17E+08	
¹³²	6.92E-01	1.27E+00	5.85E-01	5.90E+01	1.95E+00	0.00E+00	1.50E+00	
¹³³	1.72E+07	2.13E+07	8.05E+06	3.95E+09	3.54E+07	0.00E+00	8.57E+06	
¹³⁴	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
¹³⁵	5.41E+04	9.74E+04	4.61E+04	8.63E+06	1.49E+05	0.00E+00	7.42E+04	
¹³⁴ Cs	2.27E+10	3.72E+10	7.84E+09	0.00E+00	1.15E+10	4.14E+09	2.00E+08	
¹³⁶ Cs	1.01E+09	2.78E+09	1.80E+09	0.00E+00	1.48E+09	2.21E+08	9.78E+07	
¹³⁷ Cs	3.23E+10	3.09E+10	4.56E+09	0.00E+00	1.01E+10	3.62E+09	1.93E+08	
¹⁴⁰ Ba	1.17E+08	1.03E+05	6.84E+06	0.00E+00	3.34E+04	6.12E+04	5.94E+07	
¹⁴⁰ La	1.78E+02	6.23E+01	2.10E+01	0.00E+00	0.00E+00	0.00E+00	1.74E+06	
¹⁴¹ Ce	2.19E+04	1.09E+04	1.62E+03	0.00E+00	4.79E+03	0.00E+00	1.36E+07	
¹⁴⁴ Ce	1.62E+06	5.09E+05	8.67E+04	0.00E+00	2.82E+05	0.00E+00	1.33E+08	
¹⁴³ Pr	7.19E+02	2.16E+02	3.57E+01	0.00E+00	1.17E+02	0.00E+00	7.76E+05	
¹⁴⁴ Pr	5.04E+00	1.56E+00	2.53E-01	0.00E+00	8.24E-01	0.00E+00	3.35E+03	
¹⁴⁷ Nd	4.45E+02	3.61E+02	2.79E+01	0.00E+00	1.98E+02	0.00E+00	5.71E+05	
¹⁵⁴ Eu	9.43E+04	8.48E+03	7.75E+03	0.00E+00	3.73E+04	0.00E+00	1.97E+06	
¹⁸¹ Hf	6.44E+02	2.35E+03	2.91E+02	0.00E+00	4.76E+02	0.00E+00	8.66E+05	

(m²mrem/yr) per (µCi/sec)

Table 7: Child Grass- Goat – Milk Pathway Dose Factors (R_i)

(m²mrem/yr) per (μCi/sec)									
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI		
³ Н	0.00E+00	3.20E+03	3.20E+03	3.20E+03	3.20E+03	3.20E+03	3.20E+03		
⁷ Be	9.00E+02	1.53E+03	9.84E+02	0.00E+00	1.50E+03	0.00E+00	8.55E+04		
⁵¹ Cr	0.00E+00	0.00E+00	1.22E+04	6.79E+03	1.85E+03	1.24E+04	6.48E+05		
⁵⁴ Mn	0.00E+00	2.52E+06	6.71E+05	0.00E+00	7.06E+05	0.00E+00	2.11E+06		
⁵⁵ Fe	1.45E+06	7.72E+05	2.39E+05	0.00E+00	0.00E+00	4.36E+05	1.43E+05		
⁵⁹ Fe	1.56E+06	2.53E+06	1.26E+06	0.00E+00	0.00E+00	7.34E+05	2.64E+06		
⁵⁷ Co	0.00E+00	4.61E+05	9.33E+05	0.00E+00	0.00E+00	0.00E+00	3.78E+06		
⁵⁸ Co	0.00E+00	1.46E+06	4.46E+06	0.00E+00	0.00E+00	0.00E+00	8.50E+06		
⁶⁰ Co	0.00E+00	5.19E+06	1.53E+07	0.00E+00	0.00E+00	0.00E+00	2.87E+07		
⁶³ Ni	3.56E+09	1.91E+08	1.21E+08	0.00E+00	0.00E+00	0.00E+00	1.28E+07		
⁶⁵ Zn	4.97E+08	1.32E+09	8.23E+08	0.00E+00	8.34E+08	0.00E+00	2.32E+08		
⁸⁶ Rb	0.00E+00	1.05E+09	6.48E+08	0.00E+00	0.00E+00	0.00E+00	6.78E+07		
⁸⁹ Sr	1.39E+10	0.00E+00	3.97E+08	0.00E+00	0.00E+00	0.00E+00	5.39E+08		
⁹⁰ Sr	2.35E+11	0.00E+00	5.95E+10	0.00E+00	0.00E+00	0.00E+00	3.16E+09		
90Y	4.06E+02	0.00E+00	1.09E+01	0.00E+00	0.00E+00	0.00E+00	1.15E+06		
⁹¹ Y	4.69E+03	0.00E+00	1.25E+02	0.00E+00	0.00E+00	0.00E+00	6.25E+05		
⁹⁵ Zr	4.60E+02	1.01E+02	9.01E+01	0.00E+00	1.45E+02	0.00E+00	1.06E+05		
⁹⁵ Nb	4.46E+04	1.74E+04	1.24E+04	0.00E+00	1.63E+04	0.00E+00	3.21E+07		
¹⁰³ Ru	5.14E+02	0.00E+00	1.98E+02	0.00E+00	1.29E+03	0.00E+00	1.33E+04		
¹⁰⁶ Ru	1.11E+04	0.00E+00	1.38E+03	0.00E+00	1.50E+04	0.00E+00	1.73E+05		
^{110m} Ag	2.51E+07	1.69E+07	1.35E+07	0.00E+00	3.15E+07	0.00E+00	2.01E+09		
¹⁰⁹ Cd	0.00E+00	4.64E+05	2.15E+04	0.00E+00	4.14E+05	0.00E+00	1.50E+06		
¹¹³ Sn	7.33E+07	1.51E+06	4.18E+06	1.11E+08	0.00E+00	0.00E+00	5.18E+07		
¹²⁴ Sb	1.30E+07	1.69E+05	4.57E+06	2.88E+04	0.00E+00	7.24E+06	8.16E+07		
¹²⁵ Sb	1.05E+07	8.06E+04	2.19E+06	9.68E+03	0.00E+00	5.83E+06	2.50E+07		
^{127m} Te	2.50E+07	6.73E+06	2.97E+06	5.98E+06	7.13E+07	0.00E+00	2.02E+07		
^{129m} Te	3.26E+07	9.10E+06	5.06E+06	1.05E+07	9.57E+07	0.00E+00	3.98E+07		

Table 7: Child Grass-	Goat – Milk Pathwa	y Dose Factors (R _i)
-----------------------	--------------------	----------------------------------

AL 12-1-	D			The set of the			<u></u>
Nuclide	Bone	Liver	Total Body	Inyroid	Kidney	Lung	GI-LLI
¹³⁰	2.08E+06	4.20E+06	2.16E+06	4.62E+08	6.27E+06	0.00E+00	1.96E+06
¹³¹	1.57E+09	1.57E+09	8.95E+08	5.21E+11	2.58E+09	0.00E+00	1.40E+08
¹³²	8.30E-01	1.53E+00	7.02E-01	7.08E+01	2.34E+00	0.00E+00	1.80E+00
¹³³	2.06E+07	2.55E+07	9.66E+06	4.74E+09	4.25E+07	0.00E+00	1.03E+07
¹³⁴	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
¹³⁵	6.49E+04	1.17E+05	5.53E+04	1.04E+07	1.79E+05	0.00E+00	8.90E+04
¹³⁴ Cs	6.80E+10	1.12E+11	2.35E+10	0.00E+00	3.46E+10	1.24E+10	6.01E+08
¹³⁶ Cs	3.04E+09	8.35E+09	5.40E+09	0.00E+00	4.45E+09	6.63E+08	2.93E+08
¹³⁷ Cs	9.68E+10	9.27E+10	1.37E+10	0.00E+00	3.02E+10	1.09E+10	5.80E+08
¹⁴⁰ Ba	1.41E+07	1.23E+04	8.21E+05	0.00E+00	4.01E+03	7.35E+03	7.13E+06
¹⁴⁰ La	2.14E+01	7.47E+00	2.52E+00	0.00E+00	0.00E+00	0.00E+00	2.08E+05
¹⁴¹ Ce	2.63E+03	1.31E+03	1.95E+02	0.00E+00	5.75E+02	0.00E+00	1.63E+06
¹⁴⁴ Ce	1.95E+05	6.11E+04	1.04E+04	0.00E+00	3.38E+04	0.00E+00	1.59E+07
¹⁴³ Pr	8.63E+01	2.59E+01	4.28E+00	0.00E+00	1.40E+01	0.00E+00	9.31E+04
¹⁴⁴ Pr	6.05E-01	1.87E-01	3.04E-02	0.00E+00	9.89E-02	0.00E+00	4.03E+02
¹⁴⁷ Nd	5.34E+01	4.33E+01	3.35E+00	0.00E+00	2.37E+01	0.00E+00	6.85E+04
¹⁵⁴ Eu	1.13E+04	1.02E+03	9.29E+02	0.00E+00	4.47E+03	0.00E+00	2.37E+05
¹⁸¹ Hf	7.73E+01	2.81E+02	3.49E+01	0.00E+00	5.72E+01	0.00E+00	1.04E+05

(m²mrem/yr) per (µCi/sec)

Enclosure to ULNRC-05985 Page 76 of 102

(m²mrem/yr) per (μCi/sec)									
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI		
³Н	0.00E+00	2.34E+02	2.34E+02	2.34E+02	2.34E+02	2.34E+02	2.34E+02		
⁷ Be	7.38E+03	1.26E+04	8.07E+03	0.00E+00	1.23E+04	0.00E+00	7.00E+05		
⁵¹Cr	0.00E+00	0.00E+00	8.80E+03	4.88E+03	1.33E+03	8.92E+03	4.67E+05		
⁵⁴ Mn	0.00E+00	8.02E+06	2.14E+06	0.00E+00	2.25E+06	0.00E+00	6.73E+06		
⁵⁵ Fe	4.58E+08	2.43E+08	7.52E+07	0.00E+00	0.00E+00	1.37E+08	4.50E+07		
⁵⁹ Fe	3.77E+08	6.10E+08	3.04E+08	0.00E+00	0.00E+00	1.77E+08	6.35E+08		
⁵⁷ Co	0.00E+00	5.92E+06	1.20E+07	0.00E+00	0.00E+00	0.00E+00	4.85E+07		
⁵⁸ Co	0.00E+00	1.64E+07	5.03E+07	0.00E+00	0.00E+00	0.00E+00	9.59E+07		
⁶⁰ Co	0.00E+00	6.94E+07	2.05E+08	0.00E+00	0.00E+00	0.00E+00	3.84E+08		
⁶³ Ni	2.92E+10	1.56E+09	9.92E+08	0.00E+00	0.00E+00	0.00E+00	1.05E+08		
⁶⁵ Zn	3.76E+08	1.00E+09	6.23E+08	0.00E+00	6.31E+08	0.00E+00	1.76E+08		
⁸⁶ Rb	0.00E+00	5.77E+08	3.55E+08	0.00E+00	0.00E+00	0.00E+00	3.71E+07		
⁸⁹ Sr	4.82E+08	0.00E+00	1.38E+07	0.00E+00	0.00E+00	0.00E+00	1.87E+07		
⁹⁰ Sr	1.04E+10	0.00E+00	2.64E+09	0.00E+00	0.00E+00	0.00E+00	1.40E+08		
⁹⁰ Y	1.93E+05	0.00E+00	5.16E+03	0.00E+00	0.00E+00	0.00E+00	5.49E+08		
⁹¹ Y	1.80E+06	0.00E+00	4.82E+04	0.00E+00	0.00E+00	0.00E+00	2.40E+08		
⁹⁵ Zr	2.67E+06	5.86E+05	5.22E+05	0.00E+00	8.39E+05	0.00E+00	6.11E+08		
⁹⁵ Nb	4.26E+06	1.66E+06	1.18E+06	0.00E+00	1.56E+06	0.00E+00	3.07E+09		
¹⁰³ Ru	1.55E+08	0.00E+00	5.96E+07	0.00E+00	3.90E+08	0.00E+00	4.01E+09		
¹⁰⁶ Ru	4.44E+09	0.00E+00	5.54E+08	0.00E+00	6.00E+09	0.00E+00	6.91E+10		
^{110m} Ag	8.40E+06	5.67E+06	4.53E+06	0.00E+00	1.06E+07	0.00E+00	6.75E+08		
¹⁰⁹ Cd	0.00E+00	1.91E+06	8.84E+04	0.00E+00	1.70E+06	0.00E+00	6.18E+06		
¹¹³ Sn	2.18E+09	4.48E+07	1.24E+08	3.31E+09	0.00E+00	0.00E+00	1.54E+09		
¹²⁴ Sb	2.93E+07	3.80E+05	1.03E+07	6.46E+04	0.00E+00	1.62E+07	1.83E+08		
¹²⁵ Sb	2.85E+07	2.20E+05	5.97E+06	2.64E+04	0.00E+00	1.59E+07	6.81E+07		
^{127m} Te	1.78E+09	4.78E+08	2.11E+08	4.25E+08	5.07E+09	0.00E+00	1.44E+09		
^{129m} Te	1.79E+09	5.00E+08	2.78E+08	5.78E+08	5.26E+09	0.00E+00	2.19E+09		

Table 8: Child Meat Pathway Dose Factors (R_i)

(m²mrem/yr) per (µCi/sec)									
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI		
¹³⁰	3.06E-06	6.18E-06	3.18E-06	6.80E-04	9.23E-06	0.00E+00	2.89E-06		
¹³¹	1.66E+07	1.67E+07	9.47E+06	5.51E+09	2.74E+07	0.00E+00	1.48E+06		
¹³²	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
¹³³	5.70E-01	7.05E-01	2.67E-01	1.31E+02	1.17E+00	0.00E+00	2.84E-01		
¹³⁴	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
¹³⁵	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
¹³⁴ Cs	9.23E+08	1.51E+09	3.20E+08	0.00E+00	4.69E+08	1.68E+08	8.17E+06		
¹³⁶ Cs	1.62E+07	4.46E+07	2.89E+07	0.00E+00	2.38E+07	3.54E+06	1.57E+06		
¹³⁷ Cs	1.33E+09	1.28E+09	1.89E+08	0.00E+00	4.16E+08	1.50E+08	8.00E+06		
¹⁴⁰ Ba	4.39E+07	3.85E+04	2.56E+06	0.00E+00	1.25E+04	2.29E+04	2.22E+07		
¹⁴⁰ La	3.33E+02	1.17E+02	3.93E+01	0.00E+00	0.00E+00	0.00E+00	3.25E+06		
¹⁴¹ Ce	2.22E+04	1.11E+04	1.65E+03	0.00E+00	4.86E+03	0.00E+00	1.38E+07		
¹⁴⁴ Ce	2.32E+06	7.27E+05	1.24E+05	0.00E+00	4.02E+05	0.00E+00	1.89E+08		
¹⁴³ Pr	3.34E+04	1.00E+04	1.66E+03	0.00E+00	5.43E+03	0.00E+00	3.61E+07		
¹⁴⁴ Pr	5.63E+02	1.74E+02	2.83E+01	0.00E+00	9.21E+01	0.00E+00	3.75E+05		
¹⁴⁷ Nd	1.17E+04	9.48E+03	7.34E+02	0.00E+00	5.20E+03	0.00E+00	1.50E+07		
¹⁵⁴ Eu	1.12E+07	1.01E+06	9.20E+05	0.00E+00	4.43E+06	0.00E+00	2.34E+08		
¹⁸¹ Hf	4.77E+06	1.74E+07	2.15E+06	0.00E+00	3.53E+06	0.00E+00	6.41E+09		

Table 8: Child Meat Pathway Dose Factors (R_i)

Enclosure to ULNRC-05985 Page 78 of 102

(m⁻mrem/yr) per (μCi/sec)									
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI		
³Н	0.00E+00	4.01E+03	4.01E+03	4.01E+03	4.01E+03	4.01E+03	4.01E+03		
⁷ Be	3.38E+05	5.76E+05	3.70E+05	0.00E+00	5.65E+05	0.00E+00	3.21E+07		
⁵¹Cr	0.00E+00	0.00E+00	1.17E+05	6.50E+04	1.78E+04	1.19E+05	6.21E+06		
⁵⁴ Mn	0.00E+00	6.65E+08	1.77E+08	0.00E+00	1.86E+08	0.00E+00	5.58E+08		
⁵⁵ Fe	8.01E+08	4.25E+08	1.32E+08	0.00E+00	0.00E+00	2.40E+08	7.87E+07		
⁵⁹ Fe	3.98E+08	6.43E+08	3.20E+08	0.00E+00	0.00E+00	1.87E+08	6.70E+08		
⁵⁷ Co	0.00E+00	2.99E+07	6.04E+07	0.00E+00	0.00E+00	0.00E+00	2.45E+08		
⁵⁸ Co	0.00E+00	6.44E+07	1.97E+08	0.00E+00	0.00E+00	0.00E+00	3.76E+08		
⁶⁰ Co	0.00E+00	3.78E+08	1.12E+09	0.00E+00	0.00E+00	0.00E+00	2.10E+09		
⁶³ Ni	3.95E+10	2.11E+09	1.34E+09	0.00E+00	0.00E+00	0.00E+00	1.42E+08		
⁶⁵ Zn	8.13E+08	2.17E+09	1.35E+09	0.00E+00	1.36E+09	0.00E+00	3.80E+08		
⁸⁶ Rb	0.00E+00	4.52E+08	2.78E+08	0.00E+00	0.00E+00	0.00E+00	2.91E+07		
⁸⁹ Sr	3.60E+10	0.00E+00	1.03E+09	0.00E+00	0.00E+00	0.00E+00	1.39E+09		
⁹⁰ Sr	1.24E+12	0.00E+00	3.15E+11	0.00E+00	0.00E+00	0.00E+00	1.67E+10		
⁹⁰ Y	3.01E+06	0.00E+00	8.04E+04	0.00E+00	0.00E+00	0.00E+00	8.56E+09		
⁹¹ Y	1.86E+07	0.00E+00	4.99E+05	0.00E+00	0.00E+00	0.00E+00	2.48E+09		
⁹⁵ Zr	3.86E+06	8.48E+05	7.55E+05	0.00E+00	1.21E+06	0.00E+00	8.85E+08		
⁹⁵ Nb	7.48E+05	2.91E+05	2.08E+05	0.00E+00	2.74E+05	0.00E+00	5.39E+08		
¹⁰³ Ru	1.53E+07	0.00E+00	5.90E+06	0.00E+00	3.86E+07	0.00E+00	3.97E+08		
¹⁰⁶ Ru	7.45E+08	0.00E+00	9.30E+07	0.00E+00	1.01E+09	0.00E+00	1.16E+10		
^{110m} Ag	3.21E+07	2.17E+07	1.73E+07	0.00E+00	4.04E+07	0.00E+00	2.58E+09		
¹⁰⁹ Cd	0.00E+00	2.45E+08	1.14E+07	0.00E+00	2.18E+08	0.00E+00	7.94E+08		
¹¹³ Sn	1.58E+09	3.25E+07	9.00E+07	2.40E+09	0.00E+00	0.00E+00	1.12E+09		
¹²⁴ Sb	3.52E+08	4.57E+06	1.23E+08	7.77E+05	0.00E+00	1.95E+08	2.20E+09		
¹²⁵ Sb	4.99E+08	3.85E+06	1.05E+08	4.63E+05	0.00E+00	2.78E+08	1.19E+09		
^{127m} Te	1.32E+09	3.56E+08	1.57E+08	3.16E+08	3.77E+09	0.00E+00	1.07E+09		
^{129m} Te	8.41E+08	2.35E+08	1.31E+08	2.71E+08	2.47E+09	0.00E+00	1.03E+09		

Table 9: Child Vegetation Pathway Dose Factors (R_i)

(m ² mrem/yr) per (μCi/sec)									
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI		
¹³⁰	6.16E+05	1.24E+06	6.41E+05	1.37E+08	1.86E+06	0.00E+00	5.82E+05		
¹³¹	1.43E+08	1.44E+08	8.17E+07	4.76E+10	2.36E+08	0.00E+00	1.28E+07		
¹³²	9.23E+01	1.70E+02	7.80E+01	7.87E+03	2.60E+02	0.00E+00	2.00E+02		
¹³³ l	3.53E+06	4.37E+06	1.65E+06	8.12E+08	7.28E+06	0.00E+00	1.76E+06		
¹³⁴ l	1.56E-04	2.89E-04	1.33E-04	6.65E-03	4.42E-04	0.00E+00	1.92E-04		
¹³⁵ l	6.26E+04	1.13E+05	5.33E+04	9.98E+06	1.73E+05	0.00E+00	8.59E+04		
¹³⁴ Cs	1.60E+10	2.63E+10	5.55E+09	0.00E+00	8.15E+09	2.93E+09	1.42E+08		
¹³⁶ Cs	8.24E+07	2.27E+08	1.47E+08	0.00E+00	1.21E+08	1.80E+07	7.96E+06		
¹³⁷ Cs	2.39E+10	2.29E+10	3.38E+09	0.00E+00	7.46E+09	2.68E+09	1.43E+08		
¹⁴⁰ Ba	2.77E+08	2.43E+05	1.62E+07	0.00E+00	7.90E+04	1.45E+05	1.40E+08		
¹⁴⁰ La	3.36E+04	1.18E+04	3.96E+03	0.00E+00	0.00E+00	0.00E+00	3.28E+08		
¹⁴¹ Ce	6.56E+05	3.27E+05	4.86E+04	0.00E+00	1.43E+05	0.00E+00	4.08E+08		
¹⁴⁴ Ce	1.27E+08	3.98E+07	6.78E+06	0.00E+00	2.21E+07	0.00E+00	1.04E+10		
¹⁴³ Pr	1.46E+05	4.37E+04	7.23E+03	0.00E+00	2.37E+04	0.00E+00	1.57E+08		
¹⁴⁴ Pr	7.88E+03	2.44E+03	3.97E+02	0.00E+00	1.29E+03	0.00E+00	5.25E+06		
¹⁴⁷ Nd	7.15E+04	5.79E+04	4.48E+03	0.00E+00	3.18E+04	0.00E+00	9.17E+07		
¹⁵⁴ Eu	1.66E+08	1.50E+07	1.37E+07	0.00E+00	6.57E+07	0.00E+00	3.48E+09		
¹⁸¹ Hf	4.90E+05	1.79E+06	2.21E+05	0.00E+00	3.63E+05	0.00E+00	6.59E+08		

Table 9: Child Vegetation Pathway Dose Factors (R_i)

Enclosure to ULNRC-05985 Page 80 of 102

Table 10: Highest Annual Average Atmospheric Dispersion Parameters Unit Vent

Location ^(b)	Meteorological Sector	Distance (meters)	X/Q Undecayed/ undepleted (sec/m³)	X/Q Decayed/ Undepleted (sec/m ³)	X/Q Decayed/ Depleted (sec/m³)	D/Q (m ⁻²)
Site Boundary ^(a)	NNW	2200	1.0E-6	9.9E-7	8.5E-7	4.3E-9
Nearest Residence ^{(c) (d)}	NNW	2897	6.7E-7	6.6E-7	5.6E-7	2.6E-9
Farming Areas within the Site Boundary ^{(c) (e)}	N/A	N/A	2.6E-7	2.6E-7	2.4E-7	1.3E-9

(a) Values given are from FSAR-SA Table 2.3-82

(b) Data from 2002 Land Use Census

(c) Values derived⁵⁷ from FSAR-SA Table 2.3-83, using the methodology presented in Eq. 24

(d) All pathways are assumed to exist at the location of the nearest resident.

(e) These values were derived for a narrow scope application. Extreme caution should be exercised when determining their suitability for use in other applications.

Building Shape Parameter (C) = 0.5^{58}

Vertical Height of Highest Adjacent Building (V) = 66.45 meters⁵⁹

⁵⁷ Calculation ZZ-67
 ⁵⁸ BLUE 1232
 ⁵⁹ BLUE 1232

Enclosure to ULNRC-05985 Page 81 of 102

Location ^(b)	Meteorological Sector	Distance (meters)	X/Q Undecayed/ undepleted (sec/m ³)	X/Q Decayed/ Undepleted (sec/m ³)	X/Q Decayed/ Depleted (sec/m ³)	D/Q (m ⁻²)
Site Boundary ^(a)	NNW	2200	1.3E-6	1.3E-6	1.1E-6	4.3E-9
Nearest Residence ^{(c) (d)}	NNW	2897	8.5E-7	8.5E-7	7.1E-7	2.6E-9
Farming Areas Within Site Boundary ^{(c) (e)}	N/A	N/A	3.5E-7	3.5E-7	3.2E-7	1.3E-9

Table 11: Highest Annual Average Atmospheric Dispersion Parameters Radwaste Vent and Laundry/Decon Facility Dryer Exhaust

(a) Values given are from FSAR-SA Table 2.3-84

(b) Data from 2002 Land Use Census

(c) Values derived ⁶⁰ from FSAR-SA Table 2.3-81, using the methodology presented in Eq. 24

(d) All pathways are assumed to exist at the location of the nearest resident.

(e) These values were derived for a narrow scope application. Extreme caution should be exercised when determining their suitability for use in other applications.

Building Shape Parameter (C) = 0.5^{61}

Vertical Height of Highest Adjacent Building (V) = 19.96 meters⁶²

⁶⁰ Calculation ZZ-67 ⁶¹ BLUE 1232

⁶² BLUE 1232

Table 12: Application of Atmospheric Dispersion Parameters for Release Permits					
Dose Pathway	Dispersion Parameter	Controlling Age Group	REC	Controlling Location	
Noble Gas, Beta Air & Gamma Air	X/Q, decayed/undepleted (2.26 day half-life)	N/A	16.11.2.2	Site Boundary	
Noble Gas, Total Body & Skin	X/Q, decayed/undepleted (2.26 day half-life)	N/A	16.11.2.1	Site Boundary	
Inhalation	X/Q, decayed/depleted (8 day half-life)	Child	16.11.2.1 16.11.2.3	Nearest Resident Site Boundary	
Ground Plane Deposition	D/Q	N/A	16.11.2.3	Nearest Resident	
Ingestion pathways	D/Q*	Child	16.11.2.3	Nearest Resident	

*For ³H, X/Q decayed/depleted is used instead of D/Q.⁶³

⁶³ Regulatory Guide 1.109, Appendix C, Section 3.a

Table 13: Application of Atmospheric Dispersion Parameters Annual Radioactive Effluent Release Report				
Dose Pathway	Dispersion Parameter	Controlling Age Group	Dispersion Values	Controlling Location
Noble Gas,	X/Q, decayed/undepleted	Ν/Δ	Concurrent	Site Boundary
Beta Air & Gamma Air Dose	(2.26 day half-life)		concurrent	Nearest Resident
Noble Gas,	X/Q, decayed/undepleted	N/A	Concurrent	Site Boundary
Total Body & Skin Dose	(2.26 day half-life)		concurrent	Nearest Resident
			Concurrent	Farmer's Residence
			Historical	Inside Site Boundary
Ground Plana Danasitian Dasa	D/O	N/A	Concurrent	Site Boundary
Ground Plane Deposition Dose	D/Q		concurrent	Nearest Resident
			Concurrent	Farmer's Residence
			Historical	Inside Site Boundary
Inholation Doso	X/Q, decayed/depleted	Child	Concurrent	Site Boundary
	(8 day half-life)	Cilia	concurrent	Nearest Resident
		Adult	Concurrent	Farmer's Residence
			Historical	Inside Site Boundary
Ingestion Dose Pathways	D/O*	Child	Concurrent	Site Boundary
ingestion Dose Pathways	ט/ע	Ciliu	Concurrent	Nearest Resident

* For H³, X/Q, decayed/depleted is used instead of D/Q.⁶⁴

The applicability of atmospheric dispersion parameters to the calculation of dose from ¹⁴C is described in Appendix A.

⁶⁴ Regulatory Guide 1.109, Appendix C, Section 3.a

Table 14: Ivieteorological Data Selection Hierarchy	Table	14:	Meteorologica	al Data	Selection	Hierarchy
---	-------	-----	---------------	---------	-----------	-----------

Parameter	Primary	First Alternate	Second Alternate	Third Alternate
Wind Speed	10m A	10m B	60m A	60m B
Wind Direction	10m A	10m B	60m A	60m B
Air Temperature	10m A	10m B		
Wind Variability	10m A	10m B	60m A	60m B
Temp Difference	60-10m A	60-10m B		
Dew point/Relative Humidity	10m A	60m B		
Precipitation	1m			

- (a) 'A' indicates Alpha train meteorological instrumentation.
- (b) 'B' indicates Bravo train meteorological instrumentation.

Appendix A: Methodology for Calculating Dose from ¹⁴C in Gaseous Effluents

The purpose of this Appendix is to provide methodology and parameters for calculating (1) the quantity of ¹⁴C released in gaseous effluents, (2) the dose to the Member of the Public at the nearest receptor location due to ¹⁴C released in gaseous effluents, and (3) the dose from ¹⁴C released in gaseous effluents to the Member of the Public due to activities within the Site Boundary.

The quantity of ¹⁴C discharged can be estimated⁶⁵ by sample measurements, or by use of a normalized ¹⁴C source term and scaling factors based on power generation,⁶⁶ or by use of the GALE code,⁶⁷ or by use of the EPRI site specific or proxy methodologies.⁶⁸ *Any of these methodologies is acceptable for estimating the* ¹⁴C *discharged in gaseous effluents.*

Assumptions

- 1. The total quantity of ¹⁴C produced during the year is assumed to be released during the year in which it was produced.
- 2. For conservatism, it is assumed that all ¹⁴C produced is released in gaseous effluents.
- 3. The dose contribution of ¹⁴C from liquid effluents is much less than that contributed by gaseous effluents, therefore evaluation of ¹⁴C in liquid effluents is not required.⁶⁹
- 4. The dose to the Member of the Public is determined in accordance with the methodology and parameters in Regulatory Guide 1.109.
- 5. ¹⁴C has a long half- life with respect to the transit time. ¹⁴C is discharged as CH₄ or CO₂ gas and does not deplete or undergo chemical change before it reaches the receptor location. Therefore the appropriate dispersion parameter is X/Q (undecayed and undepleted).
- 6. The inhalation pathway is assumed to exist at the Nearest Residence location with the highest value of X/Q as determined by the annual Land Use Census.
- 7. The ingestion pathways are assumed to exist at the nearest receptor location with the highest value of X/Q as determined by the annual Land Use Census.
- 8. ¹⁴C is not a gamma- emitting nuclide; therefore the ground plane pathway is negligible.
- 9. It is assumed that the child age group exists at the Nearest Residence and ingestion pathway locations.
- 10. Only ¹⁴CO₂ discharged during the period of photosynthesis is considered for the ingestion pathways.
- 11. All of the ¹⁴C produced is assumed to contribute to the inhalation dose pathway, regardless of chemical form.

⁶⁵ Regulatory Guide 1.21, rev. 2, Section 1.9

⁶⁶ NCRP Report 81

⁶⁷ NUREG- 0017

⁶⁸ EPRI TR-1021106, Section 4.

⁶⁹ Regulatory Guide 1.21, rev. 2, Section 1.9

Applicable Dose Limits

10 CFR 50, Appendix I, states, "The calculated annual total quantity of all radioactive iodine and radioactive material in particulate form above background to be released from each light-water-cooled nuclear power reactor in effluents to the atmosphere will not result in an estimated annual dose or dose commitment from such *radioactive iodine and radioactive material in particulate form* for any individual in an unrestricted area from all pathways of exposure in excess of 15 millirems to any organ."⁷⁰ Radiological Effluent Control (REC) 16.11.2.3 limits the annual dose to the Member of the Public from ¹³¹*I*, ¹³³*I*, ³*H*, and particulates with half-lives greater than 8 days released in gaseous effluents to 15 mrem to any organ.^{71 14}C is released as a gas in the form of CH₄ or CO₂ and is not a radioiodine, tritium, or particulate, therefore the design objectives in 10 CFR 50, Appendix I and the limits of REC 16.11.2.3 do not apply to ¹⁴C.

10 CFR 20.1301(a)(1) limits the annual TEDE dose to the Member of the Public to 100 mrem.

40 CFR 190.10(a) limits the total annual dose from the uranium fuel cycle to the Member of the Public to 25 mrem to the whole body or any organ. 40 CFR 190 is implemented by REC 16.11.3.1. This limit includes dose from the release of gaseous effluents to areas at or beyond the Site Boundary, the dose from gaseous effluents due to activities within the Site Boundary, and the dose from direct radiation. The methodology for calculating the total annual dose from the uranium fuel cycle is provided in Section 4.

Estimation of ¹⁴C in Gaseous Effluents

¹⁴C exists in all PWR systems, and any location or system that contains tritium most likely also will contain ¹⁴C in some chemical form. Measurements of ¹⁴C concentrations in various liquid systems have been performed, and some of the reported data are included in EPRI TR-1021106.⁷² As a general rule, ¹⁴C in the primary coolant is essentially all organic with a significant fraction as a gaseous species. If the RCS liquid or gas is exposed to an oxidizing environment, such as during the forced oxidation during the shutdown evolution and during refueling outages, a slow transformation from an organic to an inorganic chemical form can occur.

Dissolved nitrogen gas and ammonia in the RCS could contribute to the ¹⁴C source term. The dissolved nitrogen could become significant in the latter stages of the fuel cycle due to the introduction of increased quantities of non-borated water for boron dilution. Callaway maintains a hydrogen gas overpressure on the RCS which effectively eliminates dissolved nitrogen gas and ammonia in the RCS, therefore the RCS ammonia concentration is assumed to be 0.

In general, ¹⁴C is produced in light water moderated nuclear power reactors by ¹⁴N(n,p)¹⁴C reactions with nitrogen impurities in the coolant and by ¹⁷O(n, α)¹⁴C reactions in the coolant. ¹⁴C produced in a nuclear power reactor can be released directly to the environment from the coolant in a gaseous form or in much smaller quantities as liquid effluents.⁷³ Kunz estimated the fraction of ¹⁴C in liquid and solid wastes at

⁷⁰ 10 CFR 50, Appendix I, section II, paragraph C

⁷¹ NUREG-1301, REC 3.11.2.3

⁷² EPRI TR-1021106, Section 4.1

⁷³ IAEA Report 421, Section 3.1.3

<5% of that in gaseous discharges⁷⁴. Regulatory Guide 1.21 states that the dose contribution from ¹⁴C in liquid discharges is insignificant and evaluation of ¹⁴C released in liquid effluents is not required.⁷⁵

The release and removal pathways from the primary coolant include VCT venting, boron dilution, inventory buildup on the letdown demineralizers and filters, and reactor coolant leakage. Letdown system removal is approximately 1 Ci/yr.⁷⁶ The ¹⁴C production balance is shown in Figure 1.



Figure 1: ¹⁴C Production Balance

Chemical Form of ¹⁴C in Gaseous Effluents

Since the PWR operates with a reducing chemical environment, most, if not all, of the ¹⁴C species initially produced are in the reduced, i.e., organic, form and contain only a single carbon atom. Possible species include methane (¹⁴CH₄), methanol (¹⁴CH₃OH), formaldehyde (H₂¹⁴C=O or the *gem*-diol H₂¹⁴C(OH)₂), and formic acid (H¹⁴COOH). In theory, the only ionic species produced will be formic acid (H¹⁴CO₂H), and some or all of the formic acid will be removed by the letdown demineralizers. Formaldehyde is soluble in water and may partially be chemisorbed on the ion exchange resin. A quasi-equilibrium is established in the coolant between the initially produced species and other possible species in the reactor coolant. The most chemically reduced species and probably the most prevalent species is ¹⁴CH₄ which partitions between the liquid and gas phases in the VCT and pressurizer.⁷⁷ The airborne ¹⁴C released from PWRs is predominantly hydrocarbons (75–95%), mainly methane (CH₄), with only a small fraction in the form of CO₂.^{78,79} Regulatory Guide 1.21 states that ¹⁴C releases in PWRs occur primarily as a mix of organic carbon and CO₂ in gaseous waste from the waste gas system.⁸⁰ NUREG-0017⁸¹

⁷⁴ Kunz, 1985

⁷⁵ Regulatory Guide 1.21, rev. 2, section 1.09

⁷⁶ EPRI TR-1021106, Section 4.1

⁷⁷ EPRI TR-1021106, Section 4.1

⁷⁸ IAEA Report 421, Section 3.1.3

⁷⁹ Neeb, section 4.2.4

⁸⁰ Regulatory Guide 1.21, rev. 2, section 1.09

⁸¹ NUREG-0017, Section 2.2.25.2

Enclosure to ULNRC-05985 Page 88 of 102

concludes that 16.4% of the ¹⁴C produced in a PWR will be released via the waste gas processing system, and the remainder, 83.6%, from the Reactor Building and the Auxiliary Building.

Due to the presence of high temperature hydrogen recombiners in the Callaway waste gas system, 100% of the ¹⁴C released through the waste gas system is assumed to be released from the waste gas decay tanks in the oxidized, i.e., inorganic form as CO_2 . The ¹⁴C released from the unit vent is assumed to be in the reduced (organic) form as CH_4 , therefore 16.4% of the ¹⁴C produced is released through the Waste Gas Decay tanks (WGDT) as CO_2 , and 83.6% is released via the Unit Vent as CH_4 .



Figure 2: ¹⁴C Gaseous Discharge Balance

¹⁴C Source Term Estimation

The neutron absorption cross section for the ${}^{17}O(n,\alpha){}^{14}C$ reaction is shown in Figure 3. The ${}^{17}O(n,\alpha){}^{14}C$ reaction has a 1/v region and a significant high energy neutron cross section. Given a constant neutron flux and target concentration, the rate of production of a species, N_a, in atoms per second is given by:

$$N_a = N_T \bullet \{(\sigma_t \bullet \phi_t) + (\sigma_e \bullet \phi_e) + (\sigma_f \bullet \phi_f)\}$$

Where:

N_a is the rate of production, atoms/sec

NT is the number of ¹⁷O or ¹⁴N target atoms per kg of coolant

 σ_t is the effective neutron cross section for thermal neutron absorption, cm²

 $\boldsymbol{\varphi}_t$ is the thermal neutron flux, n/cm²-sec

 $\pmb{\sigma}_e$ is the effective neutron cross section for epithermal energy neutron absorption, cm²

 $\pmb{\varphi}_{e}$ is the epithermal neutron flux, n/cm²-sec

 σ_{f} is the effective neutron cross section for fast neutron absorption, cm²

 φ_f is the fast neutron flux, n/cm²-sec



Figure 3: ENDF/B VII Cross Sections for ¹⁷O

Table 15: Effective Cross Section for the $^{17}O(n,\alpha)^{14}C$ Reaction in the PWR as a Function of Neutron Energy ⁸²				
Neutron Group	Group Energy	Effective Cross Section		
Thermal	≤0.625 eV	0.121 barns		
		0.0001 /		

Epithermai (E)	20.025 eV - <1 MeV	0.0291 barns
Fast (F)	≥1 MeV	0.1124 barns

The source term of each species A_i, is given by:

$$A_{a} (dps) = N_{a} \cdot \lambda_{a}$$
$$A_{a} (\mu Ci) = \frac{N_{a} \cdot \lambda_{a}}{3.7E4}$$

Where A_a is the activity of species a, N_a is the number of atoms of species a, λ_a is the decay constant of species a, in seconds. The ¹⁴C production rate from the ¹⁷O(n, α)¹⁴C reaction is calculated for the three group flux distribution according to:83

 ⁸² EPRI TR-1021106, Section 4.3.2.2
 ⁸³ EPRI TR-1021106, Section 4.3.2.1

¹⁴C production rate =
$$\frac{(1E-24 \cdot \lambda \cdot N \cdot \{(\sigma_t \varphi_t) + (\sigma_e \varphi_e) + (\sigma_f \varphi_f)\})}{3.7E4}$$

Where:

¹⁴C Production rate is ¹⁴C rate of production, µCi/sec- kg

N is the number of target atoms per unit mass of coolant (1.27E22 atoms 17 O/ kg H₂O);

 σ_t is the effective neutron cross section for thermal neutron absorption, in barns;

 $\boldsymbol{\varphi}_t$ is the thermal neutron flux, n/cm²-sec;

 σ_e is the effective neutron cross section for epithermal energy neutron absorption, in barns;

 $\boldsymbol{\varphi}_{e}$ is the epithermal neutron flux, n/cm²-sec;

 σ_{f} is the effective neutron cross section for fast neutron absorption, in barns;

 $\boldsymbol{\varphi}_{f}$ is the fast neutron flux, n/cm²-sec;

1.0E-24 is a units conversion factor, 1.0E-24 cm²/barn;

A is the ¹⁴C decay constant, 3.833E-12/sec; and

3.7E4 is a units conversion factor, 3.7E4 d/(sec- μ Ci).

The activity of ¹⁴C produced is thus the product of the production rate, the coolant mass in the active core region, and time:

 A_{C} = Production rate •coolant mass •time

Where:

 A_c is the activity of ¹⁴C produced, in μ Ci;

The *coolant mass* is the mass of water in the active core region, in kg, corrected for core average temperature and pressure;

The *time* is the time period of reactor operation, in sec;

Site Specific Parameters for ¹⁴C Source Term Estimation

The Callaway reactor is a Westinghouse Model F, four loop Pressurized Water Reactor (PWR) rated at 3565 MW_{th} . The fuel is Westinghouse Vantage+ OFA with 193 fuel assemblies. The mass of coolant in the active core region is 12,925 kg.⁸⁴ The hydrogen gas overpressure in the Volume Control Tank (VCT) effectively eliminates N₂ and NH₃ in the RCS, therefore ¹⁴C production from the ¹⁴N(n,p)¹⁴C reaction is insignificant.

The core average neutron flux, the Effective Full Power Years (EFPY), and the fuel burnup are specific to the reactor operation for the period.

⁸⁴ Westinghouse Calculation Note CN-TA-02-135, "Callaway (SCP) RSG IGOR/RETRAN Base Deck", May 16, 2003

Inhalation Dose at the Nearest Residence Location from ¹⁴C

The child age group is the critical age group for an airborne release of ¹⁴C due to higher inhalation dose factors and higher ingestion dose factors.⁸⁵ The inhalation dose for the child age group, D, is calculated according to the expression⁸⁶:

$$D_i = 3.17E4 \cdot R_a \cdot DFA_i \cdot Q_i \cdot X/Q$$

Where:

D is the dose in mrem, to a member of the public from ¹⁴C, from the inhalation pathway, received by organ j;

3.17 E4 is the number of pCi/Ci divided by the number of sec/yr;

 R_a is the breathing rate for the child age group (3700 m³/yr);⁸⁷

DFA_j is the ¹⁴C inhalation pathway dose factor for organ *j*, appropriate to the child age group (mrem/pCi). For ¹⁴C, the limiting organ is the bone. The DFA_{bone} for the child age group is 9.70E-6 mrem/pCi, and the DFA_{total body} for the child age group is 1.82E-6;⁸⁸

 Q_i is the quantity of ¹⁴C produced during the year (Ci/yr); and

X/Q is the highest calculated annual average concentration at the nearest receptor location (sec/m³).

The inhalation dose to the bone for the child age group at the Nearest Residence location is:

$$D_{bone} = 1138 \cdot Q_i \cdot X/Q$$

The inhalation dose to the total body for the child age group at the Nearest Residence location is:

$$D_{total \ body} = 213 \cdot Q_i \cdot X/Q$$

Concentration of ¹⁴C in Vegetation

The concentration of ¹⁴C in leafy vegetation is calculated by assuming that the ¹⁴C ratio to the natural carbon in the vegetation is the same as the ratio of ¹⁴C to natural carbon in the atmosphere surrounding the vegetation.⁸⁹

Only ¹⁴C released in the oxide form (CO or CO₂) is incorporated into the plant material.⁹⁰ All ¹⁴C released from the waste gas decay tanks is assumed to be in the organic form, as CO₂. The inorganic form, e.g., CH₄, is not incorporated into plant material, therefore, only the organic form, e.g., CO₂ contributes to the ingestion dose pathway. ¹⁴CO₂ released outside the growing season or at night is not incorporated into plant material and does not contribute to the dose from the ingestion pathway. ¹⁴CO₂ released during the growing season in the daytime is assumed to be incorporated into the plant material

⁸⁵ Regulatory Guide 1.109, Table E-9, and Table E-13

⁸⁶ Regulatory Guide 1.109, equations C-3 and C-4.

⁸⁷ Regulatory Guide 1.109, Table E-5

⁸⁸ Regulatory Guide 1.109, Table E-9.

⁸⁹ Regulatory Guide 1.109, Appendix C

⁹⁰ Regulatory Guide 1.109, Appendix C

Enclosure to ULNRC-05985 Page 92 of 102

and contributes to the ingestion dose pathway. The growing season in mid- Missouri is approximately April 1- November 1.⁹¹

The concentration of ¹⁴C in leafy vegetation is given by:⁹²

$$Conc_{v} = \frac{3.17E7 \cdot Q_{i} \cdot X/Q \cdot 0.11}{0.16}$$

Where:

Conc_V is the concentration of ¹⁴C in leafy vegetation grown at the nearest receptor location (pCi/kg); **3.17E7** is equal to (1E12pCi/C)(1E3g/kg)/(3.15E7 sec/yr);

 Q_i is the quantity of ¹⁴C released as CO₂ during periods of photosynthesis (Ci/yr);

X/Q is the highest calculated annual average concentration at the nearest receptor location (sec/m³);

0.11 is the fraction of total plant mass that is natural carbon, dimensionless; and

0.16 is the concentration of natural carbon in the atmosphere (g/m^3) .

Substitution of constants yields:

$$Conc_v = 2.2E7 \cdot Q_i \cdot X/Q$$

Dose from ¹⁴C in Fresh Leafy Vegetation

The leafy vegetation ingestion dose for the Child age group at the nearest receptor location is given by:⁹³

$$D = DFI \cdot f_{I} \cdot U_{a} \cdot Conc_{v}$$

Where:

D is the annual dose to the bone or total body for the child age group from ingestion of fresh leafy vegetation, (mrem/yr);

DFI is the ingestion dose conversion factor for the maximum exposed organ. For the child age group, the bone is the maximum exposed organ. The **DFI**_{bone} is 1.21E-5 mrem/pCi ingested and the **DFI**_{total body} is 2.42E-6 mrem/pCi ingested;⁹⁴

 f_l is the fraction of leafy vegetation grown in the garden at the nearest receptor location. $f_l = 1.0$;⁹⁵ and U_a is the ingestion rate of leafy vegetation. For the child age group, $U_a = 26 \text{ kg/yr}$.⁹⁶

Concentration of ¹⁴C in Milk

⁹¹ Hammer, G. R.

⁹² Regulatory Guide 1.109, equation C-8

⁹³ Regulatory Guide 1.109, equation C-13

⁹⁴ Regulatory Guide 1.109, Table E-13

⁹⁵ Regulatory Guide 1.109, Table E-15

⁹⁶ Regulatory Guide 1.109, Table E-5

Enclosure to ULNRC-05985 Page 93 of 102

The concentration of ¹⁴C in milk is determined as⁹⁷:

 $Conc_{milk} = F_m \cdot Conc_v \cdot Q_F \cdot e^{-\lambda t_f}$

Where:

Conc_{milk} is the concentration of 14 C in milk, in pCi/L;

 F_m is the average fraction of the animal's daily intake of ¹⁴C which appears in each liter of milk, in days/L. For cow milk, F_m is 1.2E-2 days/L.⁹⁸ For goat milk, F_m is 0.10 days/L;⁹⁹

Conc_V is the concentration of ¹⁴C in leafy vegetation grown at the receptor location (pCi/kg), as described above;

 Q_F is the amount of feed consumed by the animal per day, in kg/day. For cows, Q_F is equal to 50 kg/day and for goats Q_F is equal to 6 kg/day;¹⁰⁰

 t_f is the average transport time of the ¹⁴C from the feed into the milk and to the receptor (a value of 2 days is assumed): and

 λ is the radiological decay constant for ¹⁴C, 3.32E-7 days⁻¹.

Dose from ¹⁴C in Milk

The dose from ¹⁴C in milk is determined as:

$$D = DFI \cdot U_a \cdot Conc_{milk}$$

Where:

D is the annual dose to the bone or total body for the child age group from milk ingestion, (mrem/yr); *DFI* is the ingestion dose conversion factor for the maximum exposed organ. For the child age group, the bone is the maximum exposed organ. The **DFI**_{bone} is 1.21E-5 mrem/pCi ingested and the **DFI**_{total body} is 2.42E-6 mrem/pCi ingested;¹⁰¹ and

 U_a is the ingestion rate for milk. For the child age group, $U_a = 330 \text{ L/yr}$ (for both cow and goat milk).¹⁰²

⁹⁷ Regulatory Guide 1.109, equation C-10

⁹⁸ Regulatory Guide 1.109, Table E-1

⁹⁹ Regulatory Guide 1.109, Table E-2

¹⁰⁰ Regulatory Guide 1.109, Table E-3

¹⁰¹ Regulatory Guide 1.109, Table E-13

¹⁰² Regulatory Guide 1.109, Table E-5

Enclosure to ULNRC-05985 Page 94 of 102

Concentration of ¹⁴C in Meat

The concentration of ¹⁴C in meat is determined as¹⁰³:

 $Conc_{meat} = 3.1E - 2 \cdot Conc_{v} \cdot 50 \cdot e^{-(20(3.32E-7))}$

Where:

Conc_{meat} is the concentration of ¹⁴C in meat, in pCi/kg;

3.1E-02 is the stable element transfer factor, in days/kg, for beef¹⁰⁴

Conc_V is the concentration of ¹⁴C in leafy vegetation grown at the receptor location (pCi/kg), as described above;

50 kg/day is the amount of feed consumed by the beef animal per day;¹⁰⁵

20 days is the average time from slaughter to consumption¹⁰⁶: and

3.32E-7 days⁻¹ is the radiological decay constant for ¹⁴C.

Dose from ¹⁴C in Meat

The dose from ¹⁴C in meat is determined as:

$$D = DFI \cdot U_a \cdot Conc_{meat}$$

Where:

D is the annual dose to the bone or total body for the child age group from milk ingestion, (mrem/yr); *DFI* is the ingestion dose conversion factor for the maximum exposed organ. For the child age group, the bone is the maximum exposed organ. The **DFI**_{bone} is 1.21E-5 mrem/pCi ingested and the **DFI**_{total body} is 2.42E-6 mrem/pCi ingested;¹⁰⁷ and

 U_a is the ingestion rate for meat. For the child age group, $U_a = 41 \text{ kg/yr}$.¹⁰⁸

Dose to the Member of the Public from Activities within the Site Boundary

The Member of the Public performing activities within the Site Boundary is described in Section 4. The ingestion dose pathways do not exist within the Site Boundary. ¹⁴C is not a gamma- emitting nuclide; therefore the ground plane pathway is negligible.

The inhalation dose to the farmer, D, is calculated according to the expression¹⁰⁹:

¹⁰³ Regulatory Guide 1.109, equation C-12

¹⁰⁴ Regulatory Guide 1.109, Table E-1

¹⁰⁵ Regulatory Guide 1.109, Table E-3

¹⁰⁶ Regulatory Guide 1.109, Table E-15

¹⁰⁷ Regulatory Guide 1.109, Table E-13

¹⁰⁸ Regulatory Guide 1.109, Table E-5

¹⁰⁹ Regulatory Guide 1.109, equations C-3 and C-4

 $D_i = 3.17E4 \cdot R_a \cdot DFA_i \cdot Q_i \cdot X/Q \cdot 1.26E-1$

Where:

D is the dose in mrem, to a member of the public from ¹⁴C, from the inhalation pathway, received by organ j;

3.17 E4 is the number of pCi/Ci divided by the number of sec/yr;

 R_a is the breathing rate for the adult age group (8000 m³/yr);¹¹⁰

DFA_j is the ¹⁴C inhalation pathway dose factor for organ *j*, appropriate to the adult age group (mrem/pCi). For ¹⁴C, the limiting organ is the bone. The DFA_{bone} for the adult age group is 2.27E-6 mrem/pCi, and the DFA_{total body} and DFA_{thyroid} is 4.26E-7 mrem/pCi.¹¹¹

 Q_i is the quantity of ¹⁴C produced during the year (Ci/yr)

X/Q is the highest calculated annual average concentration for activities within the Site Boundary, 2.6E-7 sec/m³.

1.26E-1 is the fraction of the year the farmer performs activities within the Site Boundary (1100 hrs/8760 hrs), dimensionless

The inhalation dose to the bone for the adult age group from activities within the Site Boundary is:

$$D_{bone} = 1.89E-5 \cdot Q_i$$

The inhalation dose to the total body for the adult age group from activities within the Site Boundary is:

$$D_{total\ body} = 3.54E - 6 \cdot Q_{i}$$

The inhalation dose to the thyroid for the adult age group from activities within the Site Boundary is:

 $D_{thyroid} = 3.54E - 6 \cdot Q_i$

¹¹⁰ Regulatory Guide 1.109, Table E-5

¹¹¹ Regulatory Guide 1.109, Table E-7

Comparison of EPRI Site Specific Methodology with Regulatory Guide 1.21

Regulatory Guide 1.21 states that the following methods are acceptable for estimating the production of ¹⁴C:¹¹²

- Sampling and analysis of effluent streams
- Use of normalized ¹⁴C source term and scaling factors based on power generation, e.g., NCRP Report 81¹¹³
- Use of the PWR GALE code¹¹⁴

Callaway Plant effluents have not been sampled for ¹⁴C. NCRP Report 81, Table 3.3 states that the total ¹⁴C production rate for a PWR without reactor coolant nitrogen is 6 Ci/GW_e-yr. Assuming a conversion of 0.34 GW_e/GW_{th}, the expected ¹⁴C production rate is 2 Ci/GW_{th}-yr or 7.2 Ci/EFPY for Callaway. The PWR GALE code does not calculate the quantity of ¹⁴C produced, but instead assigns a value of 7.3 Ci/yr for every PWR without regard for power level, reactor coolant nitrogen concentration, or waste gas system design and operation. Using the EPRI methodology and the neutron flux distribution for Cycle 18, the ¹⁴C production for Callaway is 13.2 Ci/EFPY.¹¹⁵ The ¹⁴C production calculated using the EPRI methodology is therefore conservative with respect to the ¹⁴C production calculated using NCRP Report 81 and the PWR GALE code.

EPRI Proxy PWR Methodology

The average ¹⁴C production rate for Westinghouse PWRs is 3.4 Ci/ GW_{th} - yr¹¹⁶. Callaway is rated at 3.565 GW_{th} (3565 MW_{th}), therefore, the ¹⁴C production rate based on the proxy PWR is 12.1 Ci/ EFPY. The ¹⁴C production calculated using the EPRI proxy methodology is therefore conservative with respect to the ¹⁴C production calculated using NCRP Report 81 and the PWR GALE code.

¹¹² Regulatory Guide 1.21, Section 1.9

¹¹³ NCRP Report 81

¹¹⁴ NUREG-0017

¹¹⁵ HPCI 11-02

¹¹⁶ EPRI TR-1021106, Section 4.8 and Appendix D

Rev. No.	0	Date:	March 1983
Rev. No.	1	Date:	November, 1983

Revised to support the current RETS submittal and to incorporate NRC Staff comments.

Rev. No. 2 Date: March, 1984

Revised to incorporate NRC Staff comments

Rev. No. 3 Date: June, 1985

Revised to incorporate errata identified by ULNRC00803 and changes to the Environmental Monitoring Program. Incorporate results of 1984 Land Use Census.

Rev. No. 4 Date: February, 1987

Minor clarifications, incorporated 31-day projected dose methodology. Change in the utilization of areas within the Site Boundary.

Rev. No. 5 Date: January, 1988

Minor clarifications, revised descriptions of liquid and gaseous rad monitors, revised liquid setpoint methodology to incorporate monitor background, revised dose calculations for 40CFR190 requirements, Revised Table 6 and Figures 5.1A and 5.1B to refine descriptions of environmental TLD stations, incorporated description of environmental TLD testing required by Reg. Guide 4.13, revised Tables 1, 2, 4 and 5 to add additional nuclides, deleted redundant material from Chapter 6.

Rev. No. 6 Date: May, 1989

Revised methodology for calculating maximum permissible liquid effluent discharge rates and liquid effluent monitor setpoints, provided methodology for calculating liquid effluent monitors response correction factors, provided an enhanced description of controls on liquid monitor background limits, provided additional liquid and gaseous dose conversion factors and bioaccumulation factors (Tables 1, 2, 4 & 5), provided description of the use of the setpoint required by Technical Specification 4.9.4.2 during Core Alterations, added discussion of gaseous and liquid monitor setpoint selection in the event that the sample contains no detectable activity, added minimum holdup requirements for Waste Gas Decay tanks, revised dispersion parameters and accompanying description per FSAR Change Notice 88-42.

APA-ZZ-01003

Rev. No. 0 Date: August, 1989

Radiological Effluent Technical Specifications were moved from the Callaway Plant Technical Specifications to Section 9.0, Radioactive Effluent Controls, of the ODCM per NRC Generic Letter 89-01. At the same time, in order to formalize control of the entire ODCM, it was converted to APA-ZZ-01003, Offsite Dose Calculation Manual.

Rev. No. 1 Date: October, 1990

Revise Action 41 of Table 9.2-A to allow continued purging for 24 hours per Amendment 20 to operating license, issued 4/10/87.

¹¹⁷ Section numbers, table numbers, etc. refer to the numbering schema used in the particular revision.

Section 2.4.2: Changed gross alpha analysis frequency from "each batch" to a monthly composite per Table 9.3-A, and the Callaway Plant NPDES permit (reissued March 15, 1991).

Rev. No. 3 Date: June, 1993

Deleted HF-RE-45 and LE-RE-59 as effluent monitors. Revised table numbering for consistency with those in Section 9.0, deleted redundant material, incorporated 1992 Land Use Census results, moved LLD description to Attachment 1, moved REC Bases to Attachment 2. Deleted reporting requirements for solid radwaste, which are described in APA-ZZ-01011, Process Control Program. Addressed compliance with 10 CFR 20.1301. Revised the dilution flow rate to allow values other than 5000 gpm, based on dilution flow monitor setpoint. Revised "MPC" terminology to "ECV". Added Action 46 to REC 9.2 to clarify actions for inoperable mid and high range WRGM Channels. Revised references to be consistent with the revised 10 CFR 20. Added Appendix A. Revised Action 41 of Rec 9.2 and the operability requirements of GT-RE-22/33. Incorporated the revised R_i values in Tables 3.2 and 3.3. Added Section 6.2 and Table 6.5.

Rev. No. 4 Date: September, 1994

Increased the minimum channels OPERABLE requirement of REC 9.2 for GT-RE-22 & 33 from 1 channel to 2 channels. Revised Action 41 and the Bases for REC 9.2 accordingly. Incorporated the operability requirements from Tech Spec 3.9.9 into the Action statement for clarity. (Refer to CARS 199401176).

Rev. No. 5 Date: February, 1995

Removed the REMP station locations. Removed particulate nuclides with a half-life of less than 8 days from Tables 3.2-3.4 and removed ¹⁴C, ³²P, ⁶³Ni, and ^{125m}Te from Tables 2.1, 2.2, 3.2, 3.3, and 3.4. Changed the reporting frequency of the Effluent Release Report from semiannual to annual. Removed the meat, milk and vegetable pathway dispersion parameters from Tables 6.1, 6.2, and 6.3, and clarified the applicability of the dispersion parameters and dose locations in Table 6.4. Relocated REC 9.1 and 9.2 to the FSAR. Revised footnotes 3 and 7 of Table 16.11-4 to require additional sampling of the Unit Vent in the event of a reactor power transient, only if the Unit Vent noble gas activity increases by a factor of 3 or greater. Added Section 4.1.3.1.3 for determination of dose due to the on-site storage of low level radioactive waste.

Rev. No. 6 Date September, 1996

Section 2:_Added dose factors (Ait)for ^{110m} Ag, ²³⁷Np, ²³⁸Pu, ^{239/240}Pu, ²⁴¹Pu, ²⁴¹Am, ²⁴²Cm, and ^{234/244}Cm to Table 2.1, and Bioaccumulation Factors (Bf_i) for Ag, Pu, Am, and Cm to Table 2.2 due to a change in the liquid radwaste treatment process. Revised the description of the methodology for performing the 31 day dose projection in Section 2.5. Revised the maximum allowable background for HB-RE-18. Section 3: Eliminated ^{91m}Y and ^{99m}Tc from Table 3.4 (Meat Pathway) due to a half-life of < 8 days. Substituted the phrase "more restrictive" in lieu of "lesser" in Section 3.2. Revised the definition of F_a in equation 3.1. Added description of use of samples to verify dose rates in Section 3.3.1.2. Augmented the definition of q_i in Section 3.3.2.1. Edited equations 3.13 and 3.14 and added equation 3.15 to clarify dose calculations. Revised the methodology for performing the 31 day dose projection in Section 3.4. Section 4: Strengthened the discussion of the reevaluation of assumptions in Section 4.1.3. Section 6: Added new Table 6.6 to describe the selection and use of dispersion parameters during the preparation of the Effluent Release Report. Updated Tables 6.1 and 6.2 to reference the 1995 Land Use Census. There were no changes in the receptor locations. Section 8: Replaced the reference to HDP-ZZ-04500 to a more generic reference to the plant operating procedures, due to change in organizational structure and responsibilities. Section 9: (1) Eliminated 9.0.1 and 9.0.2 due to redundancy with Technical Specifications 3.0.1 and 3.0.2; (2) Revised Table 9.3-A to incorporate sampling and analysis requirements for TRU nuclides in liquid effluents; (3) Eliminated sampling of Fuel Building Exhaust from Table 16.11-4 and the associated footnotes due to

Enclosure to ULNRC-05985 Page 99 of 102

APA-ZZ-01003 Rev. 019

redundancy with Unit Vent sampling; revised the continuous sampling requirements for the gaseous batch release points consistent with plant design; revised the ³H analysis frequency for Purges from weekly to "prior to each purge"; and, (4) Revised the air sampling station location criteria on Table 9.11-A and footnote # 1, and eliminated footnote #3 in order to be less generic and more descriptive of the parameters used in determining the station locations (See CARS 199502280).Revised the location requirements for milk and vegetables. Revised description of use of baseline samples to trigger gamma isotopic analysis in footnote #4, revised requirement for location of downstream sample station in footnote #6. Revised Surveillance Requirement 9.10.2.1 to eliminate liquid effluents from the surveillance. (5) Revised REC 9.5 and REC 9.9 to eliminate exceptions for partially tested effluents being released in excess of the respective limit. Section 11: Added reference 11.14.13.Attachment 2: Revised the Bases for REC 9.10 to support the elimination of liquid effluents from Surveillance 9.10.2.1.The remaining changes are editorial in nature and have no technical impact.(This revision implements CARS 199502055, CARS 199600167, CARS 199600961, CARS 199502280, and CARS 199600986).

Rev. No. 7 Date February, 1997

Section 9: (1) REC 9.5, "Liquid Radwaste Treatment System", Action statement: Eliminated reference to COMN 1161. (2) Table 9.11-A, items 4a (milk) and 4c (vegetation): revised to required control stations in the least prevalent wind direction. (See CARS 199700166) Appendix A: revised the discussion relative to the appropriate gross alpha Effluent Concentration Value.

Rev. No. 8 Date May, 1997

Section 1: The Purpose and Scope was revised to describe the split of the ODCM into two sections Per FSAR Change Notice 95-058. Section 2: Sections 2.2 and 2.3 were revised to clarify the use of nuclide- specific alpha activity vice gross alpha activity for setpoint determination. Section 2.5 was revised to delete the description of the Liquid Radwaste Treatment System. Section 6: Tables 6.1, 6.2, and 6.3 were revised to reflect the results of the 1996 Annual Land Use Census. Section 7: The reporting requirements for the Annual Radiological Environmental Operating Report and the Effluent Release Report were relocated to the FSAR Per FSAR Change Notice 95-058. Section 9: REC's and the supporting Attachments 1 and 2 were relocated to the FSAR Per FSAR Change Notice 95-058. Appendix A: Appendix A was deleted. Editorial changes were made throughout the ODCM reflecting the relocation of the REC's to the FSAR.

Rev. No. 9 Date March, 1998

Section 2.5: Revised projected liquid dose calculation to use previous 31 day cumulative doses. Section 3.1.1: Added GL-RE-202, Laundry Decon Facility Dryer Exhaust Monitor. Added action to be taken when the particulate and/or iodine grab sampler is not operable. Section 3.2: Added setpoint calculation for GL-RE-202. Section 3.2.1 and 3.3.2.2: Changes were made to correct typographical errors and have no technical impact. Section 3.4: Revised projected gas dose calculation to use previous 31 day cumulative doses. Section 3.5: Removed the word secular from "secular equilibrium" since the equilibrium mode could be secular or transient depending on the isotope. Table 6.2: Added Laundry Decon Facility Dryer Exhaust to title of table since these will be the dispersion factors used for this release point.

Rev. No. 10 Date December 20, 1999

Section 3.1: Added explanation that GL-RE-202 only monitors particulate. Section 3.2: Changed Laundry Decon Facility Exhaust Monitor setpoint to less than or equal to 2000 cpm above equilibrium background with a maximum allowed background of 2000 cpm as calculated in HPCI 99-05. Tables 6.1, 6.2, 6.3: Updated values as calculated in HPCI 99-02. Section 5.1: Defined how REMP sample locations were determined. Removed reference to Plant Operating manual since it no longer exists.

Rev. No. 11 Date December 22, 1999

to ULNRC-05985 Page 100 of 102 Changes required to go from old Technical Specifications to Improved Technical Specifications (ITS). Technical Specification 4.9.4.2 changed to FSAR 16.11.2.4.1. Technical Specification 6.8.4.F changed to FSAR 16.11.4. Technical Specification 6.8.1.F changed to Improved Technical Specification 5.4.1. Technical Specification 6.14 changed to Improved Technical Specification 5.5.1. Technical Specification 6.8.4.E changed to Improved Technical Specification 5.5.4. Technical Specification 6.9.1.6 changed to Improved Technical Specification 5.6.2. Technical Specification 6.9.1.7 changed to Improved Technical Specification 5.6.3. Changed name of Annual Radiological Effluent Release Report to Effluent Release Report as stated in ITS. Added liquid releases are limited to 10 times the Appendix B, Table 2, Column 2 limits Per FSAR CN 98-041 supporting implementation of ITS.

Rev. No. 12 Date December 01, 2000

Enclosure

Section 2.1 and 2.2.1: Updated 10CFR20, Appendix B, Table II, Column 2 reference to the new 10CFR20 format. Corrected typo for "f", flow setpoint should be undiluted waste flow rate. Section 3.2.1: Corrected typo, default value for safety factor should be 0.1. Section 5.1: Updated crosscheck program used to EML since EPA program is no longer available. Section 6.2: Added vertical height of highest adjacent building used to perform concurrent year annual average atmospheric dispersion (X/Q) calculations and reference for this value. This information should be documented in the ODCM. Added responsibility for validation of meteorological data, since responsibility has changed from engineering to HPTS. Section 10.1.1: Revised to require a summary of Major Radwaste System changes to be included in the annual report. This was done to be consistent with FSAR 16.11.5.2.Several changes were made throughout the procedure to correct typographical errors and have no technical impact.

Rev. No. 13 Date September 19, 2002

Section 3.2: Revised to implement the approved OL 1218, Rev. 1; License Amendment no. 152 allowing equipment hatch and emergency air lock to remain open during refueling activities (FSAR CN-01-030 and CN-02-049). The amendment eliminated FSAR 16.11.2.4.1B and subsequently deleted the core alteration setpoint value 5.0 E-3 μ Ci/cc for Containment Purge Monitors GT-RE-22 and GT-RE-33. The alarm setpoints for the Containment Purge Monitors will be based on the methodology described in Section 3 of the ODCM.

Rev. No. 14 Date June 17, 2003

Revised Table 2.1 (Ingestion Dose Commitment Factor for Adult Age Group) to include dose factors for Pr-144. (CARS 200303251).Revised Section 4.1.3.1 to adjust the Farmer's residence (critical receptor) from 3830 meters in the SE sector to 2897 meters in the NNW sector. The Farmer's residence (critical receptor) was changed in 2002 to a location directly across the street from the Nearest residence. For conservatism and ease in calculation, Table 6.1 and 6.2 were revised making the distances and dispersion parameters for the Farmer's residence (critical receptor) and the Nearest residence the same. Revised section 7.2 to reference Table 6.6. Revised section 10.2.2 to remove the requirement for QA department review of the ODCM for reach revision (CARS 200304509). Added a reference to 11.14.14, Calculation HPCI 03-004 (Rev. 0), "Calculation of Liquid Effluent Dose Commitment factor for Pr-144 (A_{ir}) for the Adult Age Group", June, 2003.

Rev. No. 15 Date December 9, 2004

Reformatted references to FSAR-SP Chapter 16.11 in section 1, 2.1.1, 2.1.2, 2.2.1, 2.3, 2.4.2, 2.5, 2.6, 3.1, 3.2.1, 3.5, 5.1, 7.1, 7.2, and 9. References to ⁶³Ni were added to section 2.2.1 for the calculation of ECVSUM, section 2.3, and described in section 2.6 since it is an exception to non- gamma emitters not listed in FSAR-SP Table 16.11-1. ⁶³Ni was added to the ODCM based on previous 10 CFR 61 sample results and 2^{nd} quarter liquid composite analyses. Consolidated references listed in section 2.4.2 and 2.6 for the site related ingestion dose commitment factors (A_{ir} of Table 2.1 into HPCI 04-06, Revision 1. References to HPCIs 95-004 (Ref: 11.14.13) and 03-004 (Ref: 11.14.14) were deleted and replaced with HPCI 04-06, Revision 1 which is now listed as Ref: 11.14.13. Added ⁶³Ni and ¹²²Sb to Table 2.1- INGESTION DOSE COMMITMENT FACTOR (A_{ir}) FOR ADULT AGE GROUP. Revised the reference for Table 2.1 to 11.14.13. Corrected a typo in section 3.1.2 referring to the Radwaste Building Vent

Enclosure to ULNRC-05985

APA-ZZ-01003

Rev. 019

Page 101 of 102 system designator as GT vs. GH (CAR 200406851). References 11.19 and 11.20 were deleted in section 4.1.3.1.1. Reference 11.18 was changed to MICROSHIELD (Grove Engineering, Inc.) vs. ISOSHLD. Reference 11.24 in section 4.1.3.1.3 was corrected to 11.18. Section 5.1 and 5.2 were revised to indicate that the Radiological Environmental Monitoring Program TLDs will be processed and provided by a vendor laboratory beginning in the first guarter of 2005. Section 5.2 was revised to delete reference 11.14.10 which refers to HPCI 88-08, "Performance Testing of the Environment TLD System at Callaway Plant", August 1989. Reference 11.14.7 was corrected with HPCI 87-10 vs. 88-10. Revised Table 6.1, Note (c) to reference FSAR Table 2.3-83 vs. Table 2.3-82. Revised Table 6.1 and 6.2 Note (b) to reference data is from the 2002 Land Use Census. Changed and/or corrected the Skin dose factor (Li) units in Table 3.1 (Dose Factor for exposure to a Semi-Infinite Cloud of Noble Gases) to mrem/yr per uCi/m³. Revised section 3.3.1.2: Added units for the term BR in m³/yr. Removed paragraph in section 3.3.2.2 that describes actions for implementing the use of appropriate R_{I,i,i} values. This paragraph was taken directly from section 5.3.1 of NUREG 0133, U.S. Nuclear Regulatory Commission, "Preparation of Radiological Effluent Technical Specification for Nuclear Power Plants", USNRC NUREG-0133, Washington, D.C. 20555, October, 1978. This paragraph does not apply since the use of pathways is already considered as described in sections 4.1.2 and 4.1.3.1. Revised note (c) of Table 6.1 to reference FSAR-SA Table 2.3-83. Revised note (a) from Table 6.1 to reference FSAR-SA Table 2.3-82. In addition, revised Note (b) from Table 6.1 to reference data taken from the 2002 Land Use Census. Revised Notes (a) and (c) from Table 6.2 to reference FSAR-SA Table 2.3-84 and 2.3-81 respectively. Added a 0.95 conservatism factor to section 2.2.3 Calculation of Liquid Effluent Monitor Setpoint. This will conservatively reduce the liquid monitor setpoint to further ensure the section 4.4.1 of NUREG 0133, U.S. Nuclear Regulatory Commission, "Preparation of Radiological Effluent Technical Specification for Nuclear Power Plants", USNRC NUREG-0133, Washington, D.C. 20555, October, 1978 which states the alarm and trip setpoints for each instrument channel listed in Table 3.3-11 should be provided and should correspond to a value(s) which represents a safe margin of assurance that the instantaneous liquid release limit of 10 CFR Part 20 is not exceeded. A determination was made IAW T/S 5.5.1 that the associated changes with Revision 15 maintain the levels of radioactive effluent control required by 10 CFR 20.1302, 40 CFR 190, 10 CFR 50.36a, and 10 CFR 50 Appendix I, and not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations.

Rev. No. 16 Date **December 1, 2005**

Section 5.1 was revised to remove an invalid requirement that a third-party laboratory performing analysis specifically state the Interlaboratory Comparison (crosscheck) requirements for the Radiological Environmental Monitoring Program (REMP) contract lab. Reference 11.14.14 to Reg. Guide 4.15, Quality Assurance for Radiological Monitoring Programs (Normal Operations)- Effluent Streams and the Environment, was added to provide supporting documentation for contract lab Interlaboratory Comparison requirements. Additional information on REMP contract lab participation in Interlaboratory Comparisons was also added in section 5.1. (CAR 200500891) Revised reference 11.14.7 by adding normalization and standardization factors for radionuclides listed in Table 2.1 of the ODCM that were not included in the original calculation. Added section 4.1.3.1.4 to describe direct dose to a Member of the Public from the Old Steam Generator Storage Facility (OSGSF). Reworded step 4.1.2 to describe the sources of direct radiation from "outside storage tanks" to "storage of radioactive material". Revised section 4.1.3.1.2 to include and describe direct dose calculations in support of Modification 03-1008, Equipment Hatch Platform and Missile Shield Modification. Reference 11.14.10 was added to reference direct dose calculation to the Member of the Public from Modification 03-1008. Revised section 4.1.3.1.3 to include and describe direct dose calculations from the Radwaste Yard RAM storage and Stores II. Reference 11.19 and 11.20 were added to reference direct dose calculations to the Member of the Public from RAM storage at Stores II and the Radwaste Yard. A determination was made IAW T/S 5.5.1 that the associated changes with Revision 16 maintain the levels of radioactive effluent control required by 10 CFR 20.1302, 40 CFR 190, 10 CFR 50.36a, and 10 CFR 50 Appendix I, and not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations.

Section 2.4.1 was revised Per CAR 200701309 to state that no potable water intakes exist within 10 miles of the plant discharge point. This is due to the fact that the Annual Land Use Census ensures no newly developed potable water intakes within 10 miles of the plant discharge Per FSAR-SP Chapter 16.11.4.2c. Section 2.4.2 was revised to add reference 11.6.18 to CAR 200700053 which provides documentation of an evaluation of the site specific mixing factor for liquid effluents. Modification 06-0061 reconfigured the plant discharge terminus at the Missouri River. The modification was completed in January 2007.

Rev. No. 18 Date October 11, 2007

Revised Table 6.5 was revised to reflect upgrade/replacement of the primary meteorological tower instrumentation as per Modification Package 04-1020. Section 2.4.2 was revised to remove the discussion of the nearest municipal potable water intake downstream from the liquid effluent discharge point as being located near the city of St. Louis, Missouri, approximately 78 miles downstream. Since the Land Use Census annually verifies no potable water intakes within 10 miles – this discussion was deemed inappropriate in describing methodology for calculating dose to the public from liquid effluents. In addition, the distance referenced as not having potable water intakes downstream of the plant discharge was changed for consistency with section 2.4.1 and the Land Use Census.

Rev. No. 19 Date August, 2012

Converted to Word 2010, including appropriate formatting changes and cross-referencing for the conversion. Deleted all references to the obsolete Commitment Tracking System (COMN) and all hidden text for the obsolete hidden text referencing system. Added level of use. (CAR 201104163, Action 1) Section 3.4- Added dose reduction controls for discharge of ¹⁴C from the waste gas system and defined the growing season. Section 3.5- Deleted statement that non-gamma emitting nuclides not listed in the FSAR-SP Table 16.11.4 are not considered in dose calculations. Eliminated Sections 4.1.3.1.1, 4.1.3.1.2, 4.1.3.1.3, and 4.1.3.1.4- direct radiation dose is negligible; refer to HPCI 12-06. Section 5.2- changed to allow use of dosimeters other than TLDs. Section 6.1- Deleted discussion of short- term X/Q processing and the slope factor and deleted the associated table of 'S' factors. Section 6.2- Deleted designation of responsibilities for met data review. (CAR 201104163, Action 1) Section 10.2- changed to align with T/S 5.5.1. CAR 201104163, Action 2) Corrected the department title to align with organizational structure. (CAR 201104163, Action 1). Table 10 and Table 11- The dispersion parameters for the Farmer's residence were removed. As a first approximation, the dispersion parameters for the Nearest Residence will be used for the Farmer's residence. Appendix A- Appendix A was added to describe the calculation of the production of ¹⁴C and the calculation of dose from ¹⁴C in gaseous effluents. (CAR 201104163) ⁶³Ni was added to the gaseous effluent inhalation pathway and ingestion pathways dose factor tables. Values for ⁶³Ni are from APA-ZZ-01003, rev. 4. (CAR 201104197). Adult ingestion dose factors removed. Ingestion dose pathway removed from Table 13 for activities inside the Site Boundary.