

Appendix B

NPDES Permit

Byron Station Environmental Report

This page intentionally blank



ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

1021 North Grand Avenue East, P.O. Box 19276, Springfield, Illinois 62794-9276 • (217) 782-2879
James R. Thompson Center, 100 West Randolph, Suite 1100, Chicago, IL 60601 • (312) 814-6026

PAT QUINN, GOVERNOR

DOUGLAS P. SCOTT, DIRECTOR

217/782-0610

July 15, 2011

Exelon Generation Company, LLC
Byron Station
445- North German Church Road
Byron, IL 61010-9794

Re: Exelon Generation Company, LLC - Byron Station
NPDES Permit No. IL0048313
Modification of NPDES Permit (Without Public Notice)

Mr. Adams:

The Illinois Environmental Protection Agency received your letters dated January 24, 2011 and February 22, 2011 concerning the use of OPTISPERSE PWR6600 and the permit corrections. Our final determination is to modify the Permit as follows:

The use of OPTISPERSE PWR6600 would not be expected to cause any significant changes in effluent quality, therefore this product has been approved for use as requested.

The page numbers have been corrected.

Special Condition 21 has been corrected.

Enclosed is a copy of the modified Permit. Because the changes made in the Permit were minor, no formal Public Notice of the modification will be issued.

Should you have any questions or comments, please contact Leslie Lowry of my staff at the phone number and address above.

Sincerely,

Alan Keller, P.E.
Manager, Permit Section
Division of Water Pollution Control

SAK:LRL:48313mod.wpd

Enclosure: Modified Permit

cc: Rockford Region
Records

RECEIVED
JUL 20 2011
BY: DTS.....

Rockford • 4022 N. Main St., Rockford, IL 61104 • (815) 997-7500
Urbana • 207 S. State, Urbana, IL 62501 • (217) 699-3333
Bureau of Land • 600 S. University St., Peoria, IL 61614 • (309) 693-5465
Collinsville • 2109 Main Street, Collinsville, IL 62234 • (618) 346-9330

Des Plaines • 9311 W. Harrison St., Des Plaines, IL 60016 • (847) 294-4000
Peoria • 4435 N. University St., Peoria, IL 61614 • (309) 693-5465
Champaign • 2125 S. First St., Champaign, IL 61820 • (217) 276-5800
Mazon • 2309 W. Main St., Suite 114, Mazon, IL 62559 • (618) 993-7200

Proposed on Recycled Paper

NPDES Permit No. IL0048313

Illinois Environmental Protection Agency

Division of Water Pollution Control

1021 North Grand Avenue East

Post Office Box 19276

Springfield, Illinois 62794-9276

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

Reissued (NPDES) Permit

Expiration Date: December 31, 2015

Issue Date: January 24, 2011

Effective Date: January 24, 2011

Modification Date: July 15, 2011

Name and Address of Permittee:

Exelon Generation Company, LLC
Environmental Department
4300 Winfield Road
Warrenville, Illinois 60555-5701

Facility Name and Address:

Exelon Generation Company, LLC
Byron Nuclear Power Station
4450 North German Church Road
Byron, Illinois 61010
Ogle County

Discharge Number and Name:

001 Cooling System Blowdown
A01 Demineralizer Regenerant Waste
B01 Sewage Treatment Plant Effluent
C01 Wastewater Treatment Plant Effluent
D01 Radwaste Treatment System Effluent
E01 Stormwater Runoff Basin
F01 Intake Screen Backwash
002 Stormwater Runoff Basin Overflow
003 East Station Area Runoff
004 West Station Area Runoff

Receiving Waters:

Rock River

Woodland Creek
Woodland Creek
Unnamed Tributary to Rock River

In compliance with the provisions of the Illinois Environmental Protection Act, Title 35 of Ill. Adm. Code, Subtitle C and/or Subtitle D, Chapter 1, and the Clean Water Act (CWA), the above-named permittee is hereby authorized to discharge at the above location to the above-named receiving stream in accordance with the standard conditions and attachments herein.

Permittee is not authorized to discharge after the above expiration date. In order to receive authorization to discharge beyond the expiration date, the permittee shall submit the proper application as required by the Illinois Environmental Protection Agency (IEPA) not later than 180 days prior to the expiration date.



Alan Keller, P.E.
Manager, Permit Section
Division of Water Pollution Control

SAK:LRL:07052102.bah

NPDES Permit No. IL0048313

Effluent Limitations and Monitoring

From the modification date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

PARAMETER	LOAD LIMITS lbs/day DAF (DMF)		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		
<u>Outfall 001 – Cooling System Blowdown*</u> (Average Flow = 20.3 MGD)						

The discharge consist of:

1. Cooling Tower Blowdown
2. Non-Essential Service Water Blowdown & Strainer Backwash
3. Essential Service Water Blowdown & Strainer Backwash
4. Demineralizer Regenerant Waste (A01)
5. Sewage Treatment Plant Effluent (B01)
6. Wastewater Treatment Plant Effluent (C01)
7. Radwaste Treatment Plant Effluent (D01)
8. Stormwater Runoff Basin (E01)
9. Intake Screen Backwash
10. Secondary Steam System (Non-Radioactive) Process Water
11. Condenser Drain Discharge
12. Circulating Water Make-Up
13. Miscellaneous Drain Water
 - Chiller Condensate
 - Fire Protection System Drain Water
 - Service Water Drains
 - Closed Cooling System Drain Water

Flow (MGD)	See Special Condition 1.			Daily	Continuous
pH	See Special Condition 2.			1/Week	Grab
Temperature	See Special Condition 3 & 12.			Daily	Continuous*****
Total Residual Chlorine/ Total Residual Oxidant**			0.05	1/Week	Grab
Zinc (Total)		0.213	0.433	1/Week	Grab
Hydrazine***		0.011	0.027	Daily When Discharging	Grab
Copper (Total)****			0.071	1/Week	Grab
Chromium (Total)			0.2	1/Week	Grab
Oil/Grease		15	20	1/Week	Grab
126 Priority Pollutants	See Special Condition 8 & 15.				
Total Suspended Solids	See Special Condition 24.		Monitor Only	1/Month	Grab

* - See Special Condition 17.

** - See Special Condition 22.

*** - See Special Condition 13.

**** - See Special Condition 14.

***** - During periods of inoperability of the inline temperature instrument temperature can be measured once per day.

NPDES Permit No. IL0048313

Effluent Limitations and Monitoring

From the modification date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

PARAMETER	LOAD LIMITS lbs/day DAF (DMF)		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		
Outfall A01 – Demineralizer Regenerant Waste* (Average Flow = 0.019 MGD)						

The discharge consist of:

1. Make-Up Demineralizer Regenerant Waste
2. Condensate Polisher Sump Discharge
3. Make-Up Demineralizer Area Drains
4. Well Water Sand Filter Backwash (Alternative Route)
5. Steam Generators Cleaning Process Waste (Once Every 5 – 10 Years)
6. Temporary Demineralizer Regenerant Waste
7. Secondary Steam System (Non-Radioactive) Discharge (Alternative Route)
8. Reverse Osmosis Waste

Flow (MGD)	See Special Condition 1.				Daily	Continuous
Total Suspended Solids			15	30	1/Month	8-hour Composite**

The following metal parameter limitations and monitoring are to apply during steam generator(s) cleaning process periods:

Chromium (Hexavalent)	0.1	0.2	Daily	Grab
Chromium (Total)	1	2	Daily	Grab
Copper	0.5	1	Daily	Grab
Iron (Total)		1	Daily	Grab
Lead	0.2	0.4	Daily	Grab
Nickel	1	2	Daily	Grab
Zinc (Total)	1	2	Daily	Grab

* - See Special Condition 9.

** - Permittee may follow the sampling procedure identified as Byron Station procedure BCP-300-40 or equivalent for determination of total suspended solids by calculation from individual composites.

NPDES Permit No. IL0048313

Effluent Limitations and Monitoring

From the modification date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

PARAMETER	LOAD LIMITS lbs/day DAF (DMF)		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		
<u>Outfall B01 – Sewage Treatment Plant Effluent*</u> (DAF = 0.008 MGD)						
Flow (MGD)	See Special Condition 1.				Daily	Continuous
pH	See Special Condition 2.				2/Month	Grab
Total Suspended Solids	5.3	10.5	30	60	2/Month	24-hour Composite
BOD ₅	5.3	10.5	30	60	2/Month	24-hour Composite

* - See Special Condition 6.

NPDES Permit No. IL0048313

Effluent Limitations and Monitoring

From the modification date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

PARAMETER	LOAD LIMITS lbs/day		CONCENTRATION		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		

Outfall C01 – Wastewater Treatment Plant Effluent *
(Average Flow = 0.028 MGD)

The discharge consist of:

1. Turbine Building Floor Drain Sumps**
2. Turbine Building Fire & Oil Sump**
3. Turbine Building Equipment Drains**
4. Essential Service Water Drain Sumps**
5. Units 1 & 2 Tendon Tunnel Sumps
6. Reactor Building Roof Drains
7. Auxiliary Boiler Blowdown
8. Units 1 & 2 Diesel Fuel Storage Tank Sumps
9. Wastewater Treatment System Sand Filter Backwash
10. Well Water Sand filter Backwash
11. Steam Generator Cleaning Process Waste (Once Every 5 – 10 Years)
12. Condenser Drain Discharge (Alternative Route)
13. Secondary Steam System (Non-Radioactive) Discharge (Alternative Route)
14. Generic Metal Cleaning Activities
15. Waste Treatment Plant Oil Separator
16. Miscellaneous Non-Contaminated Drain Water
 - Chiller Condensate
 - Fire Protection System Drain Water
 - Service Water Drains
 - Closed Cooling System Drain Water

Flow (MGD)	See Special Condition 1.		Daily	Continuous
Total Suspended Solids	15	30	2/Month	24-hour Composite

The following metal parameter limitations and monitoring are to apply during steam generator(s) cleaning process periods:

Chromium (Hexavalent)	0.1	0.2	Daily	Grab
Chromium (Total)	1	2	Daily	Grab
Copper	0.5	1	Daily	Grab
Iron (Total)		1	Daily	Grab
Lead	0.2	0.4	Daily	Grab
Nickel	1	2	Daily	Grab
Zinc (Total)	1	2	Daily	Grab

* - See Special Condition 6 and Special Condition 9.

** - These waste streams may be directed to the radwaste treatment system depending on the results of the process radiation monitors.

NPDES Permit No. IL0048313

Effluent Limitations and Monitoring

From the modification date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

PARAMETER	LOAD LIMITS lbs/day DAF (DMF)		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		
<u>Outfall D01</u> – Radwaste Treatment System Effluent (Average Flow = 0.022 MGD)						
The discharge consist of:						
<ol style="list-style-type: none"> 1. Steam Generator Condensate Blowdown 2. Cooling Jacket Blowdown 3. Auxiliary Building Floor Drains 4. Laundry Waste Treatment System Drains 5. Auxiliary Building Equipment Drains 6. Radwaste Demineralizer Filter Backwash 7. Evaporator Wastewater 8. Turbine Building Floor Drain Sumps (Alternative Route) 9. Turbine Building Fire & Oil Sump (Alternative Route) 10. Turbine Building Equipment Drains (Alternative Route) 11. Essential Service Water Drain Sumps (Alternative Route) 12. Boron Recycle System Blowdown 13. Condensate Polisher Sump Discharge (Alternative Route) 14. Generic Non-Chemical Metal Cleaning Activities 15. Portable Demineralizer Discharge 16. Reactor Coolant Letdown 17. Laboratory Drains, Decon Showers, & Sample Sinks 18. Miscellaneous Drain Water <ul style="list-style-type: none"> - Chiller Condensate - Fire Protection System Drain Water - Service Water Drains - Closed Cooling System Drain Water 						
Flow (MGD)	See Special Condition 1				Daily	Continuous Discharge
Total Suspended Solids			15	30	2/Month	Tank Composite

NPDES Permit No. IL0048313

Effluent Limitations and Monitoring

From the modification date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

PARAMETER	LOAD LIMITS lbs/day		CONCENTRATION		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		

Outfall E01 – Stormwater Runoff Basin*
(Average Flow = 0.119 MGD)

The discharge consist of:

1. Parking Lot Runoff
2. Transformer Area Runoff
3. Station Area Runoff
4. Turbine Building Fire & Oil Sump
5. Steam Generators Cleaning Process Waste (Once Every 5 – 10 Years)
6. Generic Non-Chemical Metal Cleaning Activities
7. Chiller Condensate
8. Fire Protection System Drains
9. Service Water Drains
10. Closed Cooling System Drain Water

Flow (MGD)	See Special Condition 1.	2/Month	Continuous
------------	--------------------------	---------	------------

The following metal parameters limitations and monitoring are to apply during steam generator(s) cleaning process periods:

Chromium (Hexavalent)	0.1	0.2	Daily	Grab
Chromium (Total)	1	2	Daily	Grab
Copper	0.5	1	Daily	Grab
Iron (Total)		1	Daily	Grab
Lead	0.2	0.4	Daily	Grab
Nickel	1	2	Daily	Grab
Zinc (Total)	1	2	Daily	Grab

For each week in which a discharge occurs from numbers 4 – 6 listed above to the stormwater runoff basin, outfall E01 shall be monitored and limited for the following additional parameters:

Total Suspended Solids	15	30	1/Week	Grab
------------------------	----	----	--------	------

For each week in which a discharge occurs from numbers 8 – 10 listed above to the stormwater runoff basin, outfall E01 shall be monitored and limited for the following additional parameters:

Total Suspended Solids	30	100	1/Week	Grab
------------------------	----	-----	--------	------

* - See Special Condition 9 and 17.

Outfall F01 – Intake Screen Backwash
(Intermittent Discharge)

NPDES Permit No. IL0048313

Effluent Limitations and Monitoring

From the modification date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

PARAMETER	LOAD LIMITS lbs/day DAF (DMF)		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		

Outfall 002 – Stormwater Runoff Basin Overflow*
(Intermittent Discharge)

The discharge consist of:

1. Parking Lot Runoff
2. Transformer Area Runoff
3. Station Area Runoff
4. Turbine Building Fire & Oil Sump
5. Steam Generator Cleaning Process Waste (Once Every 5 – 10 Years)
6. Generic Non-Chemical Metal Cleaning Activities
7. Chiller Condensate
8. Fire Protection System Drain Water
9. Service Water Drains
10. Closed Cooling System Drain Water

Flow (MGD)	See Special Condition 1.				Measure When Discharging 1/Day When Discharging	Estimate
Oil/Grease			15	20		Grab

The following metal parameters limitations and monitoring are to apply during steam generator(s) cleaning process periods:

Chromium (Hexavalent)			0.011	0.016	Daily	Grab
Chromium (Total)			1	2	Daily	Grab
Copper			0.025	0.041	Daily	Grab
Iron (Total)				1	Daily	Grab
Lead			0.063	0.298	Daily	Grab
Nickel			0.011	0.176	Daily	Grab
Zinc (Total)			0.047	0.26	Daily	Grab

For each week in which a discharge occurs from numbers 4 – 6 listed above to the stormwater runoff basin, outfall 002 shall be monitored and limited for the following parameters:

Total Suspended Solids			15	30	1/Week	Grab
------------------------	--	--	----	----	--------	------

For each week in which a discharge occurs from numbers 8 – 10 listed above to the stormwater runoff basin, outfall 002 shall be monitored and limited for the following parameters:

Total Suspended Solids			30	100	1/Week	Grab
------------------------	--	--	----	-----	--------	------

* - See Special Condition 9 and 17.

NPDES Permit No. IL0048313

Effluent Limitations and Monitoring

From the modification date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

PARAMETER	LOAD LIMITS lbs/day DAF (DMF)		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		

Outfall 003 – East Station Area Runoff*
(Intermittent Discharge)

* - See Special Condition 16.

Outfall 004 – West Station Area Runoff*
(Intermittent Discharge)

* - See Special Condition 16.

NPDES Permit No. IL0048313

Special Conditions

SPECIAL CONDITION 1. Flow shall be measured in units of Million Gallons per Day (MGD) and reported as a monthly average and a daily maximum on the monthly Discharge Monitoring Report.

SPECIAL CONDITION 2. The pH shall be in the range 6.0 to 9.0. The monthly minimum and monthly maximum values shall be reported on the DMR form.

SPECIAL CONDITION 3. This facility meets the allowed mixing criteria for thermal discharges pursuant to 35 IAC 302.102. No reasonable potential exists for the discharge to exceed thermal water quality standards. This determination is based on a maximum temperature of 120°F. The permittee shall monitor the flow and temperature of the discharge prior to entry into the receiving water body. Monitoring results shall be reported on the monthly Discharge Monitoring Report. This permit may be modified to include formal temperature limitations should the results of the monitoring show that there is reasonable potential to exceed a thermal water quality standard. Modification of this permit shall follow public notice and opportunity for comment.

There shall be no abnormal temperature changes that may adversely affect aquatic life unless caused by natural conditions. The normal daily and seasonal temperature fluctuations which existed before the addition of heat due to other than natural causes shall be maintained.

The monthly maximum value shall be reported on the DMR form

SPECIAL CONDITION 4. The Permittee shall record monitoring results on Discharge Monitoring Report (DMR) Forms using one such form for each outfall each month.

In the event that an outfall does not discharge during a monthly reporting period, the DMR form shall be submitted with no discharge indicated.

The Permittee may choose to submit electronic DMRs (eDMRs) instead of mailing paper DMRs to the IEPA. More information, including registration information for the eDMR program, can be obtained on the IEPA website, <http://www.epa.state.il.us/water/edmr/index.html>.

The completed Discharge Monitoring Report forms shall be submitted to IEPA no later than the 28th day of the following month, unless otherwise specified by the permitting authority.

Permittees not using eDMRs shall mail Discharge Monitoring Reports with an original signature to the IEPA at the following address:

Illinois Environmental Protection Agency
Division of Water Pollution Control
Attention: Compliance Assurance Section, Mail Code #19
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276

SPECIAL CONDITION 5. Samples taken in compliance with the effluent monitoring requirements shall be taken at a point representative of the discharge, but prior to entry into the receiving stream.

SPECIAL CONDITION 6. The use or operation of this facility shall be by or under the supervision of a Certified Class K operator.

SPECIAL CONDITION 7. If an applicable effluent standard or limitation is promulgated under Sections 301(b)(2)(c) and (d), 304(b)(2), and 307(a)(2) of the Clean Water Act and that effluent standard or limitation is more stringent than any effluent limitation in the permit or controls a pollutant not limited in the NPDES Permit, the Agency shall revise or modify the permit in accordance with the more stringent standard or prohibition and shall so notify the permittee.

SPECIAL CONDITION 8. This permit authorizes the use of water treatment additives that were requested as part of this renewal. The use of any new additives, or change in those previously approved by the Agency, or if the permittee increases the feed rate or quantity of the additives used beyond what has been approved by the Agency, the permittee shall request a modification of this permit in accordance with the Standard Conditions – Attachment H. In connection with any such modification, the permittee must also submit a new letter to the Agency certifying that the facility is not using any additives containing any of the 126 priority pollutants.

The permittee shall submit to the Agency on a yearly basis a report summarizing their efforts with water treatment suppliers to find a suitable alternative to phosphorus based additives.

SPECIAL CONDITION 9. The samples taken in compliance with the steam generator(s) cleaning process monitoring requirements shall be taken at a point representative of the discharge, but prior to mixing with any other wastewater and stormwater runoff. If the permittee requires further treatment within the station's wastewater treatment system in order to comply with limits, the steam

NPDES Permit No. IL0048313

Special Conditions

generator(s) cleaning wastes shall not be co-treated with other wastewater (except for incidental amounts) unless this permit has been modified to allow for such co-treatment.

SPECIAL CONDITION 10. There shall be no discharge of polychlorinated biphenyl compounds.

SPECIAL CONDITION 11. The "Upset" defense provisions listed under 40 CFR 122.41(n) are hereby incorporated by reference.

SPECIAL CONDITION 12. In the event that the Rock River is less than 2,400 cfs and/or the temperature differential between the main river temperatures and the water quality standard is less than 3°F, daily calculations will be undertaken to demonstrate compliance with the water quality standard. Calculations shall be based upon hourly measurements, averaged over a 24-hour calendar day for river flow, main river temperature (measured as Circ Water Makeup Temperature), blowdown flow, and blowdown temperature values. In the event that a data or points are unavailable due to technical issues, the missing value shall be estimated. Results of the calculations shall be reported with the DMR on a monthly basis.

SPECIAL CONDITION 13. Outfall 001 shall be monitored for hydrazine when there is a discharge of the steam generator chemical cleaning solution and associated rinses containing hydrazine into the cooling water system. On those occasions monitoring shall be performed at outfall 001 on a daily basis using a minimum of three grab samples taken at periodic intervals during the discharge of steam generator chemical cleaning solution and associated rinses containing hydrazine. Sample collection and analysis procedures shall be in accordance with station practice for measuring hydrazine and standard methods. The quantity of hydrazine discharged in steam generator chemical cleaning solution and associated rinses to the cooling water system, the duration of this discharge to the cooling water system, and the analytical results shall be submitted with the monthly Discharge Monitoring Report. The permittee shall submit a letter to the Agency requesting a modification to this permit, if the use of hydrazine during normal steam generator lay-up is at a higher feed rate or quantity than what has been previously approved by the Agency.

SPECIAL CONDITION 14. Copper monitoring of outfall 001 shall be performed during periods when the station's copper ion system is being utilized for Zebra Mussel infestation control. In addition to monitoring the discharge from outfall 001 for copper (Total) the permittee shall measure the total mass of copper used during Zebra Mussel dosing and include that value with the Discharge Monitoring Report filed the month following the cessation of copper ion system discharge. This permit must be modified to accommodate use of the copper ion system for purposes other than Zebra Mussel control.

SPECIAL CONDITION 15. The discharge of 126 priority pollutants except for chromium and zinc (40 CFR 423, Appendix A) is prohibited in detectable amounts from cooling tower discharges if the pollutants come from cooling tower maintenance chemicals.

SPECIAL CONDITION 16.

STORM WATER POLLUTION PREVENTION PLAN (SWPPP) – for outfalls 003 & 004

- A. A storm water pollution prevention plan shall be maintained by the permittee for the storm water associated with industrial activity at this facility. The plan shall identify potential sources of pollution which may be expected to affect the quality of storm water discharges associated with the industrial activity at the facility. In addition, the plan shall describe and ensure the implementation of practices which are to be used to reduce the pollutants in storm water discharges associated with industrial activity at the facility and to assure compliance with the terms and conditions of this permit.
- B. The owner or operator of the facility shall make a copy of the plan available to the Agency at any reasonable time upon request.
- C. The permittee may be notified by the Agency at any time that the plan does not meet the requirements of this condition. After such notification, the permittee shall make changes to the plan and shall submit a written certification that the requested changes have been made. Unless otherwise provided, the permittee shall have 30 days after such notification to make the changes.
- D. The discharger shall amend the plan whenever there is a change in construction, operation, or maintenance which may affect the discharge of significant quantities of pollutants to the waters of the State or if a facility inspection required by paragraph G of this condition indicates that an amendment is needed. The plan should also be amended if the discharger is in violation of any conditions of this permit, or has not achieved the general objective of controlling pollutants in storm water discharges. Amendments to the plan shall be made within the shortest reasonable period of time, and shall be provided to the Agency for review upon request.
- E. The plan shall provide a description of potential sources which may be expected to add significant quantities of pollutants to storm water discharges, or which may result in non-storm water discharges from storm water outfalls at the facility. The plan shall include, at a minimum, the following items:

NPDES Permit No. IL0048313

Special Conditions

1. A topographic map extending one-quarter mile beyond the property boundaries of the facility, showing: the facility, surface water bodies, wells (including injection wells), seepage pits, infiltration ponds, and the discharge points where the facility's storm water discharges to a municipal storm drain system or other water body. The requirements of this paragraph may be included on the site map if appropriate.
 2. A site map showing:
 - i. The storm water conveyance and discharge structures;
 - ii. An outline of the storm water drainage areas for each storm water discharge point;
 - iii. Paved areas and buildings;
 - iv. Areas used for outdoor manufacturing, storage, or disposal of significant materials, including activities that generate significant quantities of dust or particulates.
 - v. Location of existing storm water structural control measures (dikes, coverings, detention facilities, etc.);
 - vi. Surface water locations and/or municipal storm drain locations
 - vii. Areas of existing and potential soil erosion;
 - viii. Vehicle service areas;
 - ix. Material loading, unloading, and access areas.
 3. A narrative description of the following:
 - i. The nature of the industrial activities conducted at the site, including a description of significant materials that are treated, stored or disposed of in a manner to allow exposure to storm water;
 - ii. Materials, equipment, and vehicle management practices employed to minimize contact of significant materials with storm water discharges;
 - iii. Existing structural and non-structural control measures to reduce pollutants in storm water discharges;
 - iv. Industrial storm water discharge treatment facilities;
 - v. Methods of onsite storage and disposal of significant materials;
 4. A list of the types of pollutants that have a reasonable potential to be present in storm water discharges in significant quantities.
 5. An estimate of the size of the facility in acres or square feet, and the percent of the facility that has impervious areas such as pavement or buildings.
 6. A summary of existing sampling data describing pollutants in storm water discharges.
- F. The plan shall describe the storm water management controls which will be implemented by the facility. The appropriate controls shall reflect identified existing and potential sources of pollutants at the facility. The description of the storm water management controls shall include:
1. Storm Water Pollution Prevention Personnel - Identification by job titles of the individuals who are responsible for developing, implementing, and revising the plan.
 2. Preventive Maintenance - Procedures for inspection and maintenance of storm water conveyance system devices such as oil/water separators, catch basins, etc., and inspection and testing of plant equipment and systems that could fail and result in discharges of pollutants to storm water.
 3. Good Housekeeping - Good housekeeping requires the maintenance of clean, orderly facility areas that discharge storm water. Material handling areas shall be inspected and cleaned to reduce the potential for pollutants to enter the storm water conveyance system.

NPDES Permit No. IL0048313

Special Conditions

4. Spill Prevention and Response - Identification of areas where significant materials can spill into or otherwise enter the storm water conveyance systems and their accompanying drainage points. Specific material handling procedures, storage requirements, spill clean up equipment and procedures should be identified, as appropriate. Internal notification procedures for spills of significant materials should be established.
 5. Storm Water Management Practices - Storm water management practices are practices other than those which control the source of pollutants. They include measures such as installing oil and grit separators, diverting storm water into retention basins, etc. Based on assessment of the potential of various sources to contribute pollutants, measures to remove pollutants from storm water discharge shall be implemented. In developing the plan, the following management practices shall be considered:
 - i. Containment - Storage within berms or other secondary containment devices to prevent leaks and spills from entering storm water runoff;
 - ii. Oil & Grease Separation - Oil/water separators, booms, skimmers or other methods to minimize oil contaminated storm water discharges;
 - iii. Debris & Sediment Control - Screens, booms, sediment ponds or other methods to reduce debris and sediment in storm water discharges;
 - iv. Waste Chemical Disposal - Waste chemicals such as antifreeze, degreasers and used oils shall be recycled or disposed of in an approved manner and in a way which prevents them from entering storm water discharges.
 - v. Storm Water Diversion - Storm water diversion away from materials manufacturing, storage and other areas of potential storm water contamination;
 - vi. Covered Storage or Manufacturing Areas - Covered fueling operations, materials manufacturing and storage areas to prevent contact with storm water.
 6. Sediment and Erosion Prevention - The plan shall identify areas which due to topography, activities, or other factors, have a high potential for significant soil erosion and describe measures to limit erosion.
 7. Employee Training - Employee training programs shall inform personnel at all levels of responsibility of the components and goals of the storm water pollution control plan. Training should address topics such as spill response, good housekeeping and material management practices. The plan shall identify periodic dates for such training.
 8. Inspection Procedures - Qualified plant personnel shall be identified to inspect designated equipment and plant areas. A tracking or follow-up procedure shall be used to ensure appropriate response has been taken in response to an inspection. Inspections and maintenance activities shall be documented and recorded.
- G. The permittee shall conduct an annual facility inspection to verify that all elements of the plan, including the site map, potential pollutant sources, and structural and non-structural controls to reduce pollutants in industrial storm water discharges are accurate. Observations that require a response and the appropriate response to the observation shall be retained as part of the plan. Records documenting significant observations made during the site inspection shall be submitted to the Agency in accordance with the reporting requirements of this permit.
- H. This plan should briefly describe the appropriate elements of other program requirements, including Spill Prevention Control and Countermeasures (SPCC) plans required under Section 311 of the CWA and the regulations promulgated thereunder, and Best Management Programs under 40 CFR 125.100.
- I. The plan is considered a report that shall be available to the public under Section 308(b) of the CWA. The permittee may claim portions of the plan as confidential business information, including any portion describing facility security measures.
- J. The plan shall include the signature and title of the person responsible for preparation of the plan and include the date of initial preparation and each amendment thereto.
- Construction Authorization
- K. Authorization is hereby granted to construct treatment works and related equipment that may be required by the Storm Water Pollution Prevention Plan developed pursuant to this permit.

NPDES Permit No. IL0048313

Special Conditions

This Authorization is issued subject to the following condition(s).

1. If any statement or representation is found to be incorrect, this authorization may be revoked and the permittee there upon waives all rights thereunder.
2. The issuance of this authorization (a) does not release the permittee from any liability for damage to persons or property caused by or resulting from the installation, maintenance or operation of the proposed facilities; (b) does not take into consideration the structural stability of any units or part of this project; and (c) does not release the permittee from compliance with other applicable statutes of the State of Illinois, or other applicable local law, regulations or ordinances.
3. Plans and specifications of all treatment equipment being included as part of the stormwater management practice shall be included in the SWPPP.
4. Construction activities which result from treatment equipment installation, including clearing, grading and excavation activities which result in the disturbance of one acre or more of land area, are not covered by this authorization. The permittee shall contact the IEPA regarding the required permit(s).

REPORTING

- L. The facility shall submit an annual inspection report to the Illinois Environmental Protection Agency. The report shall include results of the annual facility inspection which is required by Part G of the Storm Water Pollution Prevention Plan of this permit. The report shall also include documentation of any event (spill, treatment unit malfunction, etc.) which would require an inspection, results of the inspection, and any subsequent corrective maintenance activity. The report shall be completed and signed by the authorized facility employee(s) who conducted the inspection(s).
- M. The first report shall contain information gathered during the one year time period beginning with the effective date of coverage under this permit and shall be submitted no later than 60 days after this one year period has expired. Each subsequent report shall contain the previous year's information and shall be submitted no later than one year after the previous year's report was due.
- N. Annual inspection reports shall be mailed to the following address:

Illinois Environmental Protection Agency
Bureau of Water
Compliance Assurance Section
Annual Inspection Report
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276
- O. If the facility performs inspections more frequently than required by this permit, the results shall be included as additional information in the annual report.

SPECIAL CONDITION 17. The Agency has determined that the effluent limitations in this permit constitute BAT/BCT for storm water which is treated in the existing treatment facilities for purposes of this permit reissuance, and no pollution prevention plan will be required for such storm water. In addition to the chemical specific monitoring required elsewhere in this permit, the permittee shall conduct an annual inspection of the facility site to identify areas contributing to a storm water discharge associated with industrial activity, and determine whether any facility modifications have occurred which result in previously-treated storm water discharges no longer receiving treatment. If any such discharges are identified the permittee shall request a modification of this permit within 30 days after the inspection. Records of the annual inspection shall be retained by the permittee for the term of this permit and be made available to the Agency on request.

SPECIAL CONDITION 18. Discharge of chemical metal cleaning agents EDTA, Elimina-Ox and/or hydrazine, and associated rinses are allowed once every 5 - 10 years per unit at outfalls A01, C01, and E01.

SPECIAL CONDITION 19. Except as allowed in Special Condition No. 18 of this permit, there shall be no discharge of complexed metal bearing waste streams or associated rinses from chemical metal cleaning unless this permit has been modified to include the new discharge.

SPECIAL CONDITION 20. Exelon Generation Company's demonstration for the Byron Nuclear Power Station in accordance with Section 316(b) of the Clean Water Act was approved by IEPA by a letter dated May 15, 1989. It is determined that no additional intake monitoring or modification is being required for reissuance of this NPDES Permit.

NPDES Permit No. IL0048313

Special Conditions

SPECIAL CONDITION 21. Exelon Generation Company's Byron Nuclear Power Station has been deemed to have met the applicable national performance standards and will not be required to demonstrate further that the Rock River Intake Structure meets the specified impingement mortality and entrainment performance standards pursuant to 40 CFR 125.94(a)(1)(i). This determination was made because of the use and operation of the cooling towers. The Permittee shall request and receive a modification to this permit prior to changing the use or operation of the cooling towers. This determination does not relieve the Permittee of submitting pertinent information regarding the Rock River intake structure and cooling towers operation with the renewal application for this permit as required under 40 CFR 122.21(r)(2), (3), and (5).

SPECIAL CONDITION 22. All samples for Total Residual Chlorine/Total Residual Oxidant shall be analyzed by an applicable method contained in 40 CFR 136, equivalent in accuracy to low-level amperometric titration. Any analytical variability of the method used shall be considered when determining the accuracy and precision of the results obtained.

Discharge Monitoring Reports shall indicate whether chlorine or bromine compounds were used during the month.

SPECIAL CONDITION 23. For copper, zinc, and hydrazine a zone of initial dilution (ZID) is recognized with dimensions of 15.6 feet across the width of the river from the end-of-pipe and 15.5 feet downstream from this point. Within the ZID, 1.42:1 dilution is afforded. A mixing zone is recognized with dimensions extending 148 feet across the width of the river and 229 feet downstream. Within the mixing zone 6.1:1 dilution is afforded.

SPECIAL CONDITION 24. The influent from the Rock River and effluent from Outfall 001 shall be monitored for Total Suspended Solids on a monthly basis for two years from the effective date of this permit. After collection of all required samples, and upon written notification to the Agency the sampling may cease, unless the Agency modifies the permit to require continued sampling at some frequency.

Attachment H
Standard Conditions
Definitions

Act means the Illinois Environmental Protection Act, 415 ILCS 5 as Amended.

Agency means the Illinois Environmental Protection Agency.

Board means the Illinois Pollution Control Board.

Clean Water Act (formerly referred to as the Federal Water Pollution Control Act) means Pub. L. 92-500, as amended. 33 U.S.C. 1251 et seq.

NPDES (National Pollutant Discharge Elimination System) means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements, under Sections 307, 402, 318 and 405 of the Clean Water Act.

USEPA means the United States Environmental Protection Agency.

Daily Discharge means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurements, the "daily discharge" is calculated as the average measurement of the pollutant over the day.

Maximum Daily Discharge Limitation (daily maximum) means the highest allowable daily discharge.

Average Monthly Discharge Limitation (30 day average) means the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Discharge Limitation (7 day average) means the highest allowable average of daily discharges over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Best Management Practices (BMPs) means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the State. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Aliquot means a sample of specified volume used to make up a total composite sample.

Grab Sample means an individual sample of at least 100 milliliters collected at a randomly-selected time over a period not exceeding 15 minutes.

24-Hour Composite Sample means a combination of at least 8 sample aliquots of at least 100 milliliters, collected at periodic intervals during the operating hours of a facility over a 24-hour period.

8-Hour Composite Sample means a combination of at least 3 sample aliquots of at least 100 milliliters, collected at periodic intervals during the operating hours of a facility over an 8-hour period.

Flow Proportional Composite Sample means a combination of sample aliquots of at least 100 milliliters collected at periodic intervals such that either the time interval between each aliquot or the volume of each aliquot is proportional to either the stream flow at the time of sampling or the total stream flow since the collection of the previous aliquot.

- (1) **Duty to comply.** The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action, permit termination, revocation and reissuance, modification, or for denial of a permit renewal application. The permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirements.
- (2) **Duty to reapply.** If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. If the permittee submits a proper application as required by the Agency no later than 180 days prior to the expiration date, this permit shall continue in full force and effect until the final Agency decision on the application has been made.
- (3) **Need to halt or reduce activity not a defense.** It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
- (4) **Duty to mitigate.** The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.
- (5) **Proper operation and maintenance.** The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up, or auxiliary facilities, or similar systems only when necessary to achieve compliance with the conditions of the permit.
- (6) **Permit actions.** This permit may be modified, revoked and reissued, or terminated for cause by the Agency pursuant to 40 CFR 122.62 and 40 CFR 122.63. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
- (7) **Property rights.** This permit does not convey any property rights of any sort, or any exclusive privilege.
- (8) **Duty to provide information.** The permittee shall furnish to the Agency within a reasonable time, any information which the Agency may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also furnish to the Agency upon request, copies of records required to be kept by this permit.

Page 17

(9) **Inspection and entry.** The permittee shall allow an authorized representative of the Agency or USEPA (including an authorized contractor acting as a representative of the Agency or USEPA), upon the presentation of credentials and other documents as may be required by law, to:

- (a) Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- (b) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- (d) Sample or monitor at reasonable times, for the purpose of assuring permit compliance, or as otherwise authorized by the Act, any substances or parameters at any location.

(10) **Monitoring and records.**

- (a) Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- (b) The permittee shall retain records of all monitoring information, including all calibration and maintenance records, and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of this permit, measurement, report or application. Records related to the permittee's sewage sludge use and disposal activities shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503). This period may be extended by request of the Agency or USEPA at any time.
- (c) Records of monitoring information shall include:
 - (1) The date, exact place, and time of sampling or measurements;
 - (2) The individual(s) who performed the sampling or measurements;
 - (3) The date(s) analyses were performed;
 - (4) The individual(s) who performed the analyses;
 - (5) The analytical techniques or methods used; and
 - (6) The results of such analyses.
- (d) Monitoring must be conducted according to test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit. Where no test procedure under 40 CFR Part 136 has been approved, the permittee must submit to the Agency a test method for approval. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals to ensure accuracy of measurements.

(11) **Signatory requirement.** All applications, reports or information submitted to the Agency shall be signed and certified.

- (a) **Application.** All permit applications shall be signed as follows:
 - (1) For a corporation: by a principal executive officer of at least the level of vice president or a person or position having overall responsibility for environmental matters for the corporation;
 - (2) For a partnership or sole proprietorship: by a general partner or the proprietor, respectively; or
 - (3) For a municipality, State, Federal, or other public agency: by either a principal executive officer or ranking elected official.
- (b) **Reports.** All reports required by permits, or other information requested by the Agency shall be signed by a person described in paragraph (a) or by a duly authorized representative of that person. A person is a duly authorized representative only if:

- (1) The authorization is made in writing by a person described in paragraph (a); and

- (2) The authorization specifies either an individual or a position responsible for the overall operation of the facility, from which the discharge originates, such as a plant manager, superintendent or person of equivalent responsibility; and

- (3) The written authorization is submitted to the Agency.

(c) **Changes of Authorization.** If an authorization under (b) is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of (b) must be submitted to the Agency prior to or together with any reports, information, or applications to be signed by an authorized representative.

(d) **Certification.** Any person signing a document under paragraph (a) or (b) of this section shall make the following certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

(12) **Reporting requirements.**

(a) **Planned changes.** The permittee shall give notice to the Agency as soon as possible of any planned physical alterations or additions to the permitted facility.

Notice is required when:

- (1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source pursuant to 40 CFR 122.29 (b); or

- (2) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements pursuant to 40 CFR 122.42 (a)(1).

- (3) The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.

(b) **Anticipated noncompliance.** The permittee shall give advance notice to the Agency of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

(c) **Transfers.** This permit is not transferable to any person except after notice to the Agency.

(d) **Compliance schedules.** Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.

(e) **Monitoring reports.** Monitoring results shall be reported at the intervals specified elsewhere in this permit.

- (1) Monitoring results must be reported on a Discharge Monitoring Report (DMR).

Page 18.

- (2) If the permittee monitors any pollutant more frequently than required by the permit, using test procedures approved under 40 CFR 136 or as specified in the permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
- (3) Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Agency in the permit.
- (f) **Twenty-four hour reporting.** The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24-hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and time; and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. The following shall be included as information which must be reported within 24-hours:
- (1) Any unanticipated bypass which exceeds any effluent limitation in the permit.
 - (2) Any upset which exceeds any effluent limitation in the permit.
 - (3) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Agency in the permit or any pollutant which may endanger health or the environment.
The Agency may waive the written report on a case-by-case basis if the oral report has been received within 24-hours.
- (g) **Other noncompliance.** The permittee shall report all instances of noncompliance not reported under paragraphs (12) (d), (e), or (f), at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph (12) (f).
- (h) **Other information.** Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to the Agency, it shall promptly submit such facts or information.
- (13) **Bypass.**
- (a) Definitions.
 - (1) Bypass means the intentional diversion of waste streams from any portion of a treatment facility.
 - (2) Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
 - (b) Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs (13)(c) and (13)(d).
 - (c) Notice.
 - (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
 - (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in paragraph (12)(f) (24-hour notice).
 - (d) Prohibition of bypass.
 - (1) Bypass is prohibited, and the Agency may take enforcement action against a permittee for bypass, unless:
 - (i) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (ii) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (iii) The permittee submitted notices as required under paragraph (13)(c).
 - (2) The Agency may approve an anticipated bypass, after considering its adverse effects, if the Agency determines that it will meet the three conditions listed above in paragraph (13)(d)(1).
- (14) **Upset.**
- (a) Definition. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
 - (b) Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph (14)(c) are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
 - (c) Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated; and
 - (3) The permittee submitted notice of the upset as required in paragraph (12)(f)(2) (24-hour notice).
 - (4) The permittee complied with any remedial measures required under paragraph (4).
 - (d) Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.
- (15) **Transfer of permits.** Permits may be transferred by modification or automatic transfer as described below:
- (a) Transfers by modification. Except as provided in paragraph (b), a permit may be transferred by the permittee to a new owner or operator only if the permit has been modified or revoked and reissued pursuant to 40 CFR 122.62 (b) (2), or a minor modification made pursuant to 40 CFR 122.63 (d), to identify the new permittee and incorporate such other requirements as may be necessary under the Clean Water Act.
 - (b) Automatic transfers. As an alternative to transfers under paragraph (a), any NPDES permit may be automatically transferred to a new permittee if:

Page 19,

- (1) The current permittee notifies the Agency at least 30 days in advance of the proposed transfer date;
 - (2) The notice includes a written agreement between the existing and new permittees containing a specified date for transfer of permit responsibility, coverage and liability between the existing and new permittees; and
 - (3) The Agency does not notify the existing permittee and the proposed new permittee of its intent to modify or revoke and reissue the permit. If this notice is not received, the transfer is effective on the date specified in the agreement.
- (16) All manufacturing, commercial, mining, and silvicultural dischargers must notify the Agency as soon as they know or have reason to believe:
- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant identified under Section 307 of the Clean Water Act which is not limited in the permit, if that discharge will exceed the highest of the following notification levels:
 - (1) One hundred micrograms per liter (100 ug/l);
 - (2) Two hundred micrograms per liter (200 ug/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/l) for 2,4-dinitrophenol and for 2-methyl-4,6 dinitrophenol; and one milligram per liter (1 mg/l) for antimony.
 - (3) Five (5) times the maximum concentration value reported for that pollutant in the NPDES permit application; or
 - (4) The level established by the Agency in this permit.
 - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant which was not reported in the NPDES permit application.
- (17) All Publicly Owned Treatment Works (POTWs) must provide adequate notice to the Agency of the following:
- (a) Any new introduction of pollutants into that POTW from an indirect discharge which would be subject to Sections 301 or 306 of the Clean Water Act if it were directly discharging those pollutants; and
 - (b) Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
 - (c) For purposes of this paragraph, adequate notice shall include information on (i) the quality and quantity of effluent introduced into the POTW, and (ii) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.
- (18) If the permit is issued to a publicly owned or publicly regulated treatment works, the permittee shall require any industrial user of such treatment works to comply with federal requirements concerning:
- (a) User charges pursuant to Section 204 (b) of the Clean Water Act, and applicable regulations appearing in 40 CFR 35;
 - (b) Toxic pollutant effluent standards and pretreatment standards pursuant to Section 307 of the Clean Water Act; and
 - (c) Inspection, monitoring and entry pursuant to Section 308 of the Clean Water Act.
- (19) If an applicable standard or limitation is promulgated under Section 301(b)(2)(C) and (D), 304(b)(2), or 307(a)(2) and that effluent standard or limitation is more stringent than any effluent limitation in the permit, or controls a pollutant not limited in the permit, the permit shall be promptly modified or revoked, and reissued to conform to that effluent standard or limitation.
- (20) Any authorization to construct issued to the permittee pursuant to 35 Ill. Adm. Code 309.154 is hereby incorporated by reference as a condition of this permit.
- (21) The permittee shall not make any false statement, representation or certification in any application, record, report, plan or other document submitted to the Agency or the USEPA, or required to be maintained under this permit.
- (22) The Clean Water Act provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Clean Water Act is subject to a civil penalty not to exceed \$25,000 per day of such violation. Any person who willfully or negligently violates permit conditions implementing Sections 301, 302, 306, 307, 308, 318 or 405 of the Clean Water Act is subject to a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than one year, or both. Additional penalties for violating these sections of the Clean Water Act are identified in 40 CFR 122.41 (a)(2) and (3).
- (23) The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both.
- (24) The Clean Water Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.
- (25) Collected screening, slurries, sludges, and other solids shall be disposed of in such a manner as to prevent entry of those wastes (or runoff from the wastes) into waters of the State. The proper authorization for such disposal shall be obtained from the Agency and is incorporated as part hereof by reference.
- (26) In case of conflict between these standard conditions and any other condition(s) included in this permit, the other condition(s) shall govern.
- (27) The permittee shall comply with, in addition to the requirements of the permit, all applicable provisions of 35 Ill. Adm. Code, Subtitle C, Subtitle D, Subtitle E, and all applicable orders of the Board or any court with jurisdiction.
- (28) The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit is held invalid, the remaining provisions of this permit shall continue in full force and effect.

(Rev. 7-9-2010 bah)