

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

April 26, 2014

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555-0001

Serial No. 14-192  
SS&L/JSA R0  
Docket Nos. 50-280  
50-281  
72-2  
72-55  
License Nos. DPR-32  
DPR-37  
SNM-2501

Gentlemen:

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**SURRY POWER STATION UNITS 1 AND 2**  
**INDEPENDENT SPENT FUEL STORAGE INSTALLATION**  
**ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT**

Surry Units 1 and 2 Technical Specification 6.6.B.2 requires the submittal of an Annual Radiological Environmental Operating Report (AREOR) for Surry Power Station. Surry Independent Spent Fuel Storage Installation (ISFSI) Technical Specification Appendix C, Item 1.3.1 requires that the Surry ISFSI be included in the environmental monitoring for Surry Power Station. Accordingly, enclosed is the Surry Power Station AREOR for the period of January 1, 2013 through December 31, 2013, which includes environmental monitoring for the Surry ISFSI.

If you have any further questions, please contact Jason Eggart at 757-365-2010.

Sincerely,



Douglas C. Lawrence  
Director Safety & Licensing  
Surry Power Station

Attachment

Commitments made in this letter: None

JE215  
NM5524

Serial No. 14-192  
Docket Nos.: 50-280  
50-281  
72-2  
72-55

cc: U. S. Nuclear Regulatory Commission  
Region II  
Marquis One Tower  
245 Peachtree Center Ave., NE Suite 1200  
Atlanta, Georgia 30303-1257

Director, Nuclear Material Safety and Safeguards  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555-0001

NRC Senior Resident Inspector  
Surry Power Station

Director  
Division of Radiological Health  
109 Governor Street, Room 730  
Richmond, Virginia 23219


Serial No. 14-192  
Docket Nos.: 50-280  
50-281  
72-2  
72-55

**ATTACHMENT 1**


**2013 Annual Radiological Environmental Operating Report**

**SURRY POWER STATION UNITS 1 AND 2  
VIRGINIA ELECTRIC AND POWER COMPANY**

# Surry Power Station



## 2013 Annual Radiological Environmental Operating Report





**Dominion<sup>®</sup>**

**Dominion**  
**Surry Power Station**  
**Radiological Environmental Monitoring Program**  
**January 1, 2013 to December 31, 2013**


**Annual Radiological Environmental Operating Report**  
**Surry Power Station**

**January 1, 2013 to December 31, 2013**

**Prepared by:**   
P. F. Blount  
Health Physicist

**Reviewed by:**   
P. R. Harris  
Supervisor Radiological Analysis

**Reviewed by:**   
W. A. Terry  
Supervisor Health Physics Technical Services

**Approved by:**   
J. W. Eggart  
Manager Radiological Protection and Chemistry

## Table of Contents

PREFACE .....	4
1. EXECUTIVE SUMMARY .....	5
2. PROGRAM DESCRIPTION .....	7
2.1 Introduction .....	7
2.2 Sampling and Analysis Program .....	8
3. ANALYTICAL RESULTS .....	20
3.1 Summary of Results .....	20
3.2 Analytical Results of 2013 REMP Samples .....	28
4. DISCUSSION OF RESULTS .....	49
4.1 Gamma Exposure Rate .....	49
4.2 Airborne Gross Beta .....	50
4.3 Airborne Radioiodine .....	52
4.4 Air Particulate Gamma .....	52
4.5 Cow Milk .....	53
4.6 Food Products .....	53
4.7 Well Water .....	53
4.8 River Water .....	54
4.9 Silt .....	54
4.10 Shoreline Sediment .....	56
4.11 Fish .....	56
4.12 Oysters .....	57
4.13 Clams .....	57
4.14 Crabs .....	57
5. PROGRAM EXCEPTIONS .....	58
6. CONCLUSIONS .....	59
REFERENCES .....	61
APPENDICES .....	63
APPENDIX A: LAND USE CENSUS .....	64
APPENDIX B: SUMMARY OF INTERLABORATORY COMPARISONS .....	66

## **PREFACE**

This report is submitted as required by Technical Specification 6.6.B.2, Annual Radiological Environmental Operating Report, for Surry, Units 1 and 2, Virginia Electric and Power Company Docket Nos. 50-280 and 50-281.



## 1. EXECUTIVE SUMMARY

This document is a detailed report of the 2013 Surry Power Station Radiological Environmental Monitoring Program (REMP). Radioactivity levels from January 1 through December 31, 2013, in air, water, silt, shoreline sediment, milk, aquatic biota, food products and direct exposure pathways have been analyzed, evaluated and summarized. The REMP is designed to confirm that radiological effluent releases are As Low As is Reasonably Achievable (ALARA), no undue environmental effects occur and the health and safety of the public are protected. The program also detects any unexpected environmental processes that could allow radiation accumulations in the environment or food pathway chains.

Radiation and radioactivity in the environment are monitored within a 20-mile radius of the station. Surry Power Station personnel collect a variety of samples within this area. A number of sampling locations for each medium are selected using available meteorological, land use, and water use data. Two types of samples are obtained. The first type, control samples, is collected from areas that are beyond the measurable influence of Surry Power Station or any other nuclear facility. These samples represent normal background radiation levels. Background radiation levels can be compared to the environment surrounding the station. Indicator samples are the second sample type obtained. These samples show how much radiation is contributed to the environment by the station. Indicator samples are taken from areas close to the station where any station contribution will be at the highest concentration.

Prior to station operation, samples were collected and analyzed to determine the amount of radioactivity present in the area. The resulting values are used as a "pre-operational baseline." Analysis results from the indicator samples are compared to control sample values and the pre-operational baseline to determine if changes in radioactivity levels are attributable to station operations, or natural variation, or other causes such as the Chernobyl and Fukushima Daiichi accidents that released radioactive material to the environment.

Teledyne Brown Engineering, Inc. (TBE) provides radioanalyses for this program and Global Dosimetry Solutions, Inc. provides thermoluminescent dosimetry (TLD) services. Participation in an Interlaboratory Comparison Program provides an independent check of sample measurement precision and accuracy. Typically, radioactivity levels in the environment are so low that analysis values frequently fall below the minimum detection limits of state-of-the-art measurement methods. Because of this, the United States Nuclear Regulatory Commission (USNRC) requires that equipment used for radiological environmental monitoring must be able to detect specified minimum Lower Limits of Detection (LLDs). This ensures that analyses are as accurate as possible. The USNRC also mandates a reporting

level for radionuclides. Licensed nuclear facilities must report the radionuclide activities in those environmental samples that are equal to or greater than the specified reporting level. Environmental radiation levels are sometimes referred to as a percent of the reporting level.

Analytical results are reported for all possible radiation exposure pathways to man. These pathways include airborne, aquatic, terrestrial and direct radiation exposure. The airborne exposure pathway includes radioactive airborne iodine and particulates. The 2013 airborne results were similar to previous years. No station related radioactivity was detected and natural radioactivity levels remained at levels consistent with past years' results. Aquatic exposure pathway samples include well and river water, silt and shoreline sediments, crabs, fish, clams and oysters. Naturally occurring radionuclides such as potassium-40, thorium-228 and thorium-232 were detected at average environmental levels. No man-made radionuclides were detected in well water. This trend is consistent throughout the operational environmental monitoring program. Tritium was detected in one of eight river water samples at 5.4% of the USNRC reporting level, that sample being from the discharge canal. No other man-made radionuclides were detected in river water. Silt samples indicated the presence of cesium-137 and naturally occurring radionuclides. The cesium-137 activity was present in the control and indicator locations and is attributable to global fallout from past nuclear weapons testing and nuclear accidents such as Chernobyl. Shoreline sediment, which may provide a direct exposure pathway, contained no station related radionuclides. Naturally occurring radionuclides such as potassium-40, thorium-228 and thorium-232 were detected at average environmental levels. The terrestrial exposure pathway includes milk and food products. Iodine-131 was not detected in any 2013 milk samples and has not been detected in milk prior to or since the 1986 Chernobyl accident. Strontium-90 was also not detected in milk samples in 2013. No man-made radionuclides were detected in food product samples. Consistent with historical data, naturally occurring potassium-40 was detected in milk and food products. The direct exposure pathway measures environmental radiation doses using TLDs. TLD results have remained relatively constant over the years.

During 2013, as in previous years, the operation of Surry Power Station has created no adverse environmental effects or health hazards. The maximum total body dose calculated for a hypothetical individual at the station site boundary due to liquid and gaseous effluents released from the station during 2013 was 0.129 millirem. For reference, this dose may be compared to the 620 millirem average annual exposure to every person in the United States from natural and man-made sources. Natural sources in the environment provide approximately 50% of radiation exposure to man, while nuclear power contributes less than 0.1%. These results demonstrate compliance with federal and state regulations and also demonstrate the adequacy of radioactive effluent controls at Surry Power Station.

## 2. PROGRAM DESCRIPTION

### *2.1 Introduction*

This report documents the 2013 Surry Power Station operational Radiological Environmental Monitoring Program (REMP). The Dominion Surry Power Station is located on the Gravel Neck peninsula adjacent to the James River, approximately 25 miles upstream of the Chesapeake Bay. The site consists of two units, each with a pressurized water reactor (PWR) nuclear steam supply system and turbine generator furnished by Westinghouse Electric Corporation. Each unit is designed with a nominal gross electrical output of 910 megawatts electric (MWe). Unit 1 achieved commercial operation on December 22, 1972, and Unit 2 on May 1, 1973.

The United States Nuclear Regulatory Commission regulations (10CFR50.34a) require that nuclear power plants be designed, constructed and operated to keep levels of radioactive material in effluents to unrestricted areas As Low As is Reasonably Achievable. To ensure these criteria are met, the operating license for Surry Power Station includes Technical Specifications that address the release of radioactive effluents. In-plant monitoring is used to ensure that these release limits are not exceeded. As a precaution against unexpected or undefined environmental processes which might allow undue accumulation of radioactivity in the environment, a program for monitoring the station environs is also included in Surry Power Station Technical Specifications.

Dominion personnel are responsible for collecting the various indicator and control environmental samples. Global Dosimetry Solutions Incorporated is responsible for processing the TLDs. Teledyne Brown Engineering is responsible for sample analyses. The results of the analyses are used to determine if changes in radioactivity levels may be attributable to station operations. Measured values are compared with control values, which vary with time due to external events, such as cosmic ray bombardment, nuclear weapons test fallout and seasonal variations of naturally occurring radionuclides. Data collected prior to station operation is used to indicate the degree of natural variation to be expected. This pre-operational data is compared with data collected during the operational phase to assist in evaluating any radiological impact of station operation.

Occasionally, samples of environmental media may show the presence of man-made radionuclides. As a method of referencing the measured radionuclide concentrations in the sample media to a dose consequence to man, the data is compared to the reporting level concentrations listed in the USNRC Regulatory Guide 4.8, "Environmental Technical Specifications for Nuclear Power Plants", (December, 1975) and VPAP-2103S, Offsite Dose Calculation Manual (Surry).

These concentrations are based upon the annual dose commitment recommended by 10CFR50, Appendix I, to meet the criterion of "As Low As is Reasonably Achievable."

This report documents the results of the REMP for 2013 and satisfies the following objectives of the program:

- To provide measurements of radiation and of radioactive materials in those exposure pathways and for those radionuclides that lead to the highest potential radiation exposure of the maximum exposed member of the public resulting from station operations.
- To supplement the radiological effluent monitoring program by verifying that radioactive effluents are within allowable limits.
- To identify changes in radioactivity in the environment.
- To verify that station operations have no detrimental effect on the health and safety of the public.

## ***2.2 Sampling and Analysis Program***

Table 2-1 summarizes the 2013 sampling program for Surry Power Station. All samples listed in Table 2-1 are taken at indicator locations except those labeled "control." Dominion personnel collect all samples listed in Table 2-1.

Table 2-2 summarizes the analysis program conducted by Teledyne Brown Engineering and Global Dosimetry Solutions for Surry Power Station. All samples, with the exception of the TLDs, are shipped to Teledyne Brown Engineering, located in Knoxville, TN, for analysis. The TLDs are shipped to Global Dosimetry Solutions, located in Costa Mesa, CA, for processing.

The Surry Radiological Monitoring Locations maps (Figures 1 – 5) denote sample locations for Surry Power Station. The locations are color coded to designate sample types.

**Table 2-1**  
**SURRY - 2013**  
**RADIOLOGICAL SAMPLING STATIONS**  
**DISTANCE AND DIRECTION FROM UNIT NO. 1**

Sample Media	Location	Station	Distance			Collection Frequency	Remarks
			Miles	Direction	Degrees		
<b>Environmental TLDs</b>	Control	(00)	-	-	-	Quarterly	Onsite (Stored in a lead shield outside the protected area)
	West North West	(02)	0.2	WNW	293°	Quarterly	Site Boundary
	Surry Station Discharge	(03)	0.4	NW	321°	Quarterly	Site Boundary
	North North West	(04)	0.2	NNW	329°	Quarterly	Site Boundary
	North	(05)	0.3	N	4°	Quarterly	Site Boundary
	North North East	(06)	0.3	NNE	28°	Quarterly	Site Boundary
	North East	(07)	0.3	NE	44°	Quarterly	Site Boundary
	East North East	(08)	0.4	ENE	67°	Quarterly	Site Boundary
	East	(09)	0.3	E	89°	Quarterly	Site Boundary
	West	(10)	0.1	W	271°	Quarterly	Site Boundary
	West South West	(11)	0.4	WSW	252°	Quarterly	Site Boundary
	South West	(12)	0.3	SW	228°	Quarterly	Site Boundary
	South South West	(13)	0.3	SSW	201°	Quarterly	Site Boundary
	South	(14)	0.4	S	182°	Quarterly	Site Boundary
	South South East	(15)	0.6	SSE	157°	Quarterly	Site Boundary
	South East	(16)	0.9	SE	135°	Quarterly	Site Boundary
	Station Intake	(18)	1.6	ESE	115°	Quarterly	Site Boundary
	Hog Island Reserve	(19)	2.0	NNE	26°	Quarterly	Near Resident
	Bacon's Castle	(20)	4.5	SSW	202°	Quarterly	Apx. 5 mile
	Route 633	(21)	4.9	SW	227°	Quarterly	Apx. 5 mile
	Alliance	(22)	5.1	WSW	247°	Quarterly	Apx. 5 mile
	Surry	(23)	7.7	WSW	256°	Quarterly	Population Center
	Route 636 and 637	(24)	4.0	W	270°	Quarterly	Apx. 5 mile
	Scotland Wharf	(25)	5.0	WNW	284°	Quarterly	Apx. 5 mile
	Jamestown	(26)	6.3	NW	308°	Quarterly	Apx. 5 mile
	Colonial Parkway	(27)	3.8	NNW	333°	Quarterly	Apx. 5 mile
	Route 617 and 618	(28)	4.9	NNW	340°	Quarterly	Apx. 5 mile
	Kingsmill	(29)	4.6	N	2°	Quarterly	Apx. 5 mile
	Williamsburg	(30)	7.8	N	0°	Quarterly	Population Center
	Kingsmill North	(31)	5.5	NNE	12°	Quarterly	Apx. 5 mile
	Budweiser	(32)	5.8	NNE	27°	Quarterly	Population Center
	Water Plant	(33)	5.0	NE	46°	Quarterly	Apx. 5 mile

**Table 2-1**  
 SURRY - 2013  
 RADIOLOGICAL SAMPLING STATIONS  
 DISTANCE AND DIRECTION FROM UNIT NO. 1

Sample Media	Location	Station	Distance			Collection		Remarks
			Miles	Direction	Degrees	Frequency		
<b>Environmental TLDs</b>	BASF	(34)	5.1	ENE	70°	Quarterly	Apx. 5 mile	
	Lee Hall	(35)	7.1	ENE	75°	Quarterly	Population Center	
	Goose Island	(36)	5.1	E	90°	Quarterly	Apx. 5 mile	
	Fort Eustis	(37)	4.9	ESE	104°	Quarterly	Apx. 5 mile	
	Newport News	(38)	19.3	SE	130°	Quarterly	Population Center	
	James River Bridge	(39)	17.1	SE	142°	Quarterly	Control Location	
	Benn's Church	(40)	17.0	SSE	159°	Quarterly	Control Location	
	Smithfield	(41)	13.4	SSE	167°	Quarterly	Control Location	
	Rushmere	(42)	5.3	SSE	156°	Quarterly	Apx. 5 mile	
	Route 628	(43)	5.1	S	177°	Quarterly	Apx. 5 mile	
<b>Air Charcoal and Particulate</b>	Surry Station	(SS)	0.3	NNE	18°	Weekly	Site boundary location with highest D/Q	
	Hog Island Reserve	(HIR)	2.0	NNE	26°	Weekly		
	Bacon's Castle	(BC)	4.5	SSW	202°	Weekly		
	Alliance	(ALL)	5.1	WSW	247°	Weekly		
	Colonial Parkway	(CP)	3.8	NNW	333°	Weekly		
	BASF	(BASF)	5.1	ENE	70°	Weekly		
	Fort Eustis	(FE)	4.9	ESE	104°	Weekly		
	Newport News	(NN)	19.3	SE	130°	Weekly		
<b>River Water</b>	Surry Station Discharge	(SD)	0.4	NW	323°	Monthly		
	Scotland Wharf	(SW)	4.9	WNW	284°	Monthly	Control Location	
<b>Well Water</b>	Surry Station	(SS)	0.1	SW	227°	Quarterly	Onsite	
	Hog Island Reserve	(HIR)	2.0	NNE	28°	Quarterly		
	Construction Site	(CS)	0.3	E	87°	Quarterly		
<b>Shoreline Sediment</b>	Hog Island Reserve	(HIR)	0.6	N	7°	Semi-Annually		
	Chickahominy River	(CHIC)	11.2	WNW	301°	Semi-Annually	Control Location	
<b>Silt</b>	Chickahominy River	(CHIC)	11.2	WNW	300°	Semi-Annually	Control Location	
	Surry Station Discharge	(SD)	1.3	NNW	341°	Semi-Annually		

**Table 2-1**  
**SURRY - 2013**  
**RADIOLOGICAL SAMPLING STATIONS**  
**DISTANCE AND DIRECTION FROM UNIT NO. 1**

Sample Media	Location	Station	Distance			Collection Frequency	Remarks
			Miles	Direction	Degrees		
Milk	Colonial Parkway	(CP)	3.7	NNW	336°	Monthly	Control Location
	Williams	(WMS)	27.5	S	175°	Monthly	
	Epps	(EPPS)	4.8	SSW	200°	Monthly	
Oysters	Point of Shoals	(POS)	6.4	SSE	157°	Semi-Annually	
	Mulberry Point	(MP)	4.9	ESE	124°	Semi-Annually	
	Lawne's Creek	(LC)	2.4	SE	131°		
Clams	Chickahominy River	(CHIC)	11.2	WNW	300°	Semi-Annually	Control Location
	Surry Station Discharge	(SD)	1.3	NNW	341°	Semi-Annually	
	Jamestown Island	(JI)	3.9	NW	324°	Semi-Annually	
Fish	Surry Station Discharge	(SD)	1.3	NNW	341°	Semi-Annually	
Crabs	Surry Station Discharge	(SD)	1.3	NNW	341°	Annually	
Crops (Corn, Peanuts, Soybeans)	Brock's Farm	(BROCK)	3.8	S	183°	Annually	
	Slade's Farm	(SLADE)	3.2	S	179°	Annually	

**Table 2-2**  
**SURRY - 2013**  
**SAMPLE ANALYSIS PROGRAM**

<b>SAMPLE MEDIA</b>	<b>FREQUENCY</b>	<b>ANALYSIS</b>	<b>LLD*</b>	<b>REPORT UNITS</b>
<b>Thermoluminescent Dosimetry (TLD)</b>	Quarterly	Gamma Dose	2	mR/Std. Month
<b>Air Iodine</b>	Weekly	I-131	0.07	pCi/m <sup>3</sup>
<b>Air Particulate</b>	Weekly	Gross Beta	0.01	pCi/m <sup>3</sup>
	Quarterly (a)	Gamma Isotopic		pCi/m <sup>3</sup>
		Cs-134	0.05	
		Cs-137	0.06	
<b>River Water</b>	Quarterly Composite of monthly sample	Tritium (H-3)	2000	pCi/L
	Monthly	I-131	10	pCi/L
		Gamma Isotopic		pCi/L
		Mn-54	15	
		Fe-59	30	
		Co-58	15	
		Co-60	15	
		Zn-65	30	
		Zr-95	30	
		Nb-95	15	
		Cs-134	15	
		Cs-137	18	
		Ba-140	60	
		La-140	15	
		<b>Well Water</b>	Quarterly	Tritium (H-3)
I-131	1			
	Gamma Isotopic			pCi/L
	Mn-54		15	
	Fe-59		30	
	Co-58		15	
	Co-60		15	
	Zn-65		30	
	Zr-95		30	
	Nb-95		15	
	Cs-134		15	
	Cs-137		18	
	Ba-140		60	
	La-140		15	

*Footnotes located at end of table.*



**Table 2-2**  
**SURRY - 2013**  
**SAMPLE ANALYSIS PROGRAM**

<b>SAMPLE MEDIA</b>	<b>FREQUENCY</b>	<b>ANALYSIS</b>	<b>LLD*</b>	<b>REPORT UNITS</b>
<b>Shoreline Sediment</b>	Semi-Annually	Gamma Isotopic		pCi/kg - dry
		Cs-134	150	
		Cs-137	180	
<b>Silt</b>	Semi-Annually	Gamma Isotopic		pCi/kg - dry
		Cs-134	150	
		Cs-137	180	
<b>Milk</b>	Monthly	I-131	1	pCi/L
		Gamma Isotopic		pCi/L
		Cs-134	15	
		Cs-137	18	
	Quarterly Composite of CP monthly sample	Sr-89	NA	pCi/L
		Sr-90	NA	
<b>Oysters</b>	Semi-Annually	Gamma Isotopic		pCi/kg - wet
		Mn-54	130	
		Fe-59	260	
		Co-58	130	
		Co-60	130	
		Zn-65	260	
		Cs-134	130	
		Cs-137	150	
<b>Clams</b>	Semi-Annually	Gamma Isotopic		pCi/kg - wet
		Mn-54	130	
		Fe-59	260	
		Co-58	130	
		Co-60	130	
		Zn-65	260	
		Cs-134	130	
		Cs-137	150	
<b>Crabs</b>	Annually	Gamma Isotopic		pCi/kg - wet
		Mn-54	130	
		Fe-59	260	
		Co-58	130	
		Co-60	130	
		Zn-65	260	
		Cs-134	130	
		Cs-137	150	

*Footnotes located at end of table.*

**Table 2-2**  
**SURRY - 2013**  
**SAMPLE ANALYSIS PROGRAM**


<b>SAMPLE MEDIA</b>	<b>FREQUENCY</b>	<b>ANALYSIS</b>	<b>LLD*</b>	<b>REPORT UNITS</b>
<b>Fish</b>	Semi-Annually	Gamma Isotopic		pCi/kg - wet
		Mn-54	130	
		Fe-59	260	
		Co-58	130	
		Co-60	130	
		Zn-65	260	
		Cs-134	130	
		Cs-137	150	
<b>Food Products</b>	Annually	Gamma Isotopic		pCi/kg - wet
		I-131	60	
		Cs-134	60	
		Cs-137	80	


**Note:** This table is not a complete listing of nuclides that can be detected and reported. Other peaks that are measurable and identifiable, together with the above nuclides, are also identified and reported.

\* LLD is the Lower Limit of Detection as defined and required in the USNRC Branch Technical Position on an Acceptable Radiological Environmental Monitoring Program, Revision 1, November 1979. LLDs indicate those concentrations to which environmental samples are required to be analyzed. Actual analysis of samples may be lower than these listed values.


(a) Quarterly composites of each location's weekly air particulate samples are analyzed for gamma emitters.

NA None assigned






Graphics No. CB3308A



**Figure 3. Surry Emergency Plan Map**

<span style="color: red;">●</span> Air Sampling Stations	<span style="color: orange;">●</span> Nearest Residents
<span style="color: purple;">●</span> TLD Sampling	<span style="color: brown;">●</span> Nearest Milk Animal
<span style="color: green;">●</span> Nearest Garden	<span style="color: yellow;">●</span> Aquatic Samples

Original © 1991 by ADC of Alexandria, Inc., 6440 General Green Way, Alexandria, VA 22312. USED WITH PERMISSION. No other reproduction may be made without the written permission of ADC.



**Figure 4. Surry Emergency Plan Map**

<span style="color: red;">●</span> Air Sampling Stations	<span style="color: orange;">●</span> Nearest Residents
<span style="color: purple;">●</span> TLD Sampling	<span style="color: brown;">●</span> Nearest Milk Animal
<span style="color: green;">●</span> Nearest Garden	<span style="color: yellow;">●</span> Crop Samples


Original © 1991 by ADC of Alexandria, Inc., 6440 General Green Way, Alexandria, VA 22312. USED WITH PERMISSION. No other reproduction may be made without the written permission of ADC.

Graphics No. CB3310A

Figure 5. Surry Emergency Plan Map

- Air Sampling Stations
- Nearest Residents
- TLD Sampling
- Nearest Milk Animal
- Nearest Garden
- Aquatic Samples

Original © 1991 by ADC of Alexandria, Inc., 6440 General Green Way, Alexandria, VA 22312. USED WITH PERMISSION. No other reproduction may be made without the written permission of ADC.



### 3. ANALYTICAL RESULTS

#### *3.1 Summary of Results*

In accordance with the Surry Offsite Dose Calculation Manual (ODCM), a summary table of the analytical results has been prepared and is presented in Table 3-1. This data is presented in accordance with the format of the USNRC Branch Technical Position, "Acceptable Radiological Environmental Monitoring Program", Revision 1, November 1979. A more detailed analysis of the data is given in Section 4.



**TABLE 3-1: RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY**

Surry Power Station, Surry County, Virginia - 2013  
 Docket No. 50-280-281 Page 1 of 7

Medium or Pathway Sampled (Units)	Analysis		LLD	Indicator Locations	Location with Highest Mean			Control Locations	Non-Routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	
Direct Radiation TLD (mR/ Std Month)	Gamma	164	2	5.5 (146/152) (3.9 - 7.9)	STA-9	0.3 mi E	7.8 (4/4) (7.6 - 7.9)	5.8 (12/12) (4.3 - 7.5)	0
Air Particulate (1E-3 pCi/m3)	Gross Beta	416	10	14.0 (364/364) (4.71 - 36.0)	ALL	5.1 mi WSW	15.5 (52/52) (5.71 - 31.3)	15.2 (52/52) (6.20 - 36.7)	0
	Gamma	32							
	Be-7	32		117 (28/28) (63.8 - 166)	ALL	5.1 mi WSW	134 (4/4) (105 - 166)	119 (4/4) (92.0 - 147)	0
	K-40	32		35.1 (3/28) (21.9 - 57.5)	HIR	2.0 mi NNE	57.5 (1/4) (57.5 - 57.5)	< LLD	0
	Cs-134	32	50	< LLD	N/A		< LLD	< LLD	0
	Cs-137	32	60	< LLD	N/A		< LLD	< LLD	0
Air Iodine (1E-3 pCi/m3)	I-131	416	70	< LLD	N/A		< LLD	< LLD	0
Milk (pCi/Liter)	Strontium	4							
	Sr-89	4		< LLD	N/A		< LLD	< LLD	0
	Sr-90	4		< LLD	N/A		< LLD	< LLD	0
	Gamma	36							
	K-40	36		1328 (24/24) (977 - 1460)	CP	3.7 mi NNW	1338 (12/12) (1220 - 1460)	1302 (12/12) (1160 - 1420)	0
	Th-228	36		9.07 (1/24) (9.07 - 9.07)	WMS	27.5 mi S	16.5 (1/24) (16.5 - 16.5)	16.5 (1/12) (16.5 - 16.5)	0
	I-131	36	1	< LLD	N/A		< LLD	< LLD	0
	Cs-134	36	15	< LLD	N/A		< LLD	< LLD	0
Cs-137	36	18	< LLD	N/A		< LLD	< LLD	0	
Ba-140	36	60	< LLD	N/A		< LLD	< LLD	0	

**TABLE 3-1: RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY**

Surry Power Station, Surry County, Virginia - 2013  
 Docket No. 50-280-281 Page 2 of 7

Medium or Pathway Sampled (Units)	Analysis		LLD	Indicator Locations	Location with Highest Mean			Control Locations	Non-Routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	
<b>Milk</b> (pCi/Liter)	<b>Gamma</b>	36							
	La-140	36	15	< LLD	N/A		< LLD	< LLD	0
<hr/>									
<b>Food Products</b> (pCi/kg wet)	<b>Gamma</b>	3							
	K-40	3		7377 (3/3) (2980 - 14500)	Slade	3.2 mi S	14500 (1/1) (14500-14500)	N/A	0
	Be-7	3		201 (1/3) (201 - 201)	Brock	3.8 mi S	201 (1/3) (201 - 201)	N/A	
	Th-228	3		17.5 (2/3) (12.4 - 22.5)	Brock	3.8 mi S	22.5 (1/2) (22.5 - 22.5)		
	I-131	3	60	< LLD	N/A		< LLD	N/A	0
	Cs-134	3	60	< LLD	N/A		< LLD	N/A	0
	Cs-137	3	80	< LLD	N/A		< LLD	N/A	0
<hr/>									
<b>Well Water</b> (pCi/Liter)	<b>H-3</b>	12	2000	< LLD	N/A		< LLD	N/A	0
	<b>Gamma</b>	12							
	Mn-54	12	15	< LLD	N/A		< LLD	N/A	0
	Co-58	12	15	< LLD	N/A		< LLD	N/A	0
	Fe-59	12	30	< LLD	N/A		< LLD	N/A	0
	Co-60	12	15	< LLD	N/A		< LLD	N/A	0
	Zn-65	12	30	< LLD	N/A		< LLD	N/A	0

**TABLE 3-1: RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY**

Surry Power Station, Surry County, Virginia - 2013  
 Docket No. 50-280-281 Page 3 of 7

Medium or Pathway Sampled <i>(Units)</i>	Analysis		LLD	Indicator Locations	Location with Highest Mean			Control Locations	Non-Routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	
<b>Well Water</b> <i>(pCi/Liter)</i>	Nb-95	12	15	< LLD	N/A		< LLD	N/A	0
	Zr-95	12	30	< LLD	N/A		< LLD	N/A	0
	I-131	12	1	< LLD	N/A		< LLD	N/A	0
	Cs-134	12	15	< LLD	N/A		< LLD	N/A	0
	Cs-137	12	18	< LLD	N/A		< LLD	N/A	0
	Ba-140	12	60	< LLD	N/A		< LLD	N/A	0
	La-140	12	15	< LLD	N/A		< LLD	N/A	0
<b>River Water</b> <i>(pCi/Liter)</i>	H-3	8	2000	1610 (1/4) (1610 - 1610)	SD	0.4 mi NW	1610 (1/4) (1610 - 1610)	N/A	0
	Gamma	24							
	K-40	24		89.2 (9/12) (54.1 - 125)	SD	0.4 mi NW	89.2 (9/12) (54.1 - 125)	70.1 (5/12) (52.9 - 88.6)	0
	Ra-226	24		< LLD	SW	4.9 mi WNW	77.5 (1/12) (77.5 - 77.5)	77.5 (1/12) (77.5 - 77.5)	0
	Th-228	24		6.58 (1/12) (6.58 - 6.58)	SD	0.4 mi NW	6.58 (1/12) (6.58 - 6.58)	< LLD	0
	Mn-54	24	15	< LLD	N/A		< LLD	< LLD	0
	Co-58	24	15	< LLD	N/A		< LLD	< LLD	0
	Fe-59	24	30	< LLD	N/A		< LLD	< LLD	0
	Co-60	24	15	< LLD	N/A		< LLD	< LLD	0
	Zn-65	24	30	< LLD	N/A		< LLD	< LLD	0

**TABLE 3-1: RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY**

Surry Power Station, Surry County, Virginia - 2013  
 Docket No. 50-280-281 Page 4 of 7

Medium or Pathway Sampled <i>(Units)</i>	Analysis		LLD	Indicator Locations	Location with Highest Mean			Control Locations	Non-Routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	
<b>River Water</b> <i>(pCi/Liter)</i>	Nb-95	24	15	< LLD	N/A		< LLD	< LLD	0
	Zr-95	24	30	< LLD	N/A		< LLD	< LLD	0
	I-131	24	10	< LLD	N/A		< LLD	< LLD	0
	Cs-134	24	15	< LLD	N/A		< LLD	< LLD	0
	Cs-137	24	18	< LLD	N/A		< LLD	< LLD	0
	Ba-140	24	60	< LLD	N/A		< LLD	< LLD	0
	La-140	24	15	< LLD	N/A		< LLD	< LLD	0
<b>Silt</b> <i>(pCi/kg dry)</i>	<b>Gamma</b>	4							
	Be-7	4		1780 (1/2) (1780 - 1780)	SD	1.3 mi NNW	1780 (1/2) (1780 - 1780)	< LLD	0
	K-40	4		17800 (2/2) (15400-20200)	SD	1.3 mi NNW	17800 (2/2) (15400-20200)	18050 (2/2) (17200-18900)	0
	Cs-134	4	150	< LLD	N/A		< LLD	< LLD	0
	Cs-137	4	180	142 (2/2) (121 - 163)	SD	1.3 mi NNW	142 (2/2) (121 - 163)	206 (2/2) (175 - 206)	0
	Ra-226	4		3760 (2/2) (2210 - 5310)	SD	1.3 mi NNW	3760 (2/2) (2210 - 5310)	3040 (2/2) (2520 - 3560)	0
	Ac-228	4		384 (1/2) (384 - 384)	SD	1.3 mi NNW	384 (1/2) (384 - 384)	< LLD	
	Th-228	4		1425 (2/2) (1200 - 1650)	SD	1.3 mi NNW	1425 (2/2) (1200 - 1650)	1485 (2/2) (1290 - 1680)	0
	Th-232	4		1318 (2/2) (995 - 1640)	SD	1.3 mi NNW	1318 (2/2) (995 - 1640)	1205 (2/2) (1040 - 1370)	0

**TABLE 3-1: RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY**

Surry Power Station, Surry County, Virginia - 2013  
 Docket No. 50-280-281 Page 5 of 7

Medium or Pathway Sampled <i>(Units)</i>	Analysis		LLD	Indicator Locations	Location with Highest Mean			Control Locations	Non-Routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	
Shoreline Sediment <i>(pCi/kg dry)</i>	K-40	4		6085 (2/2) (5440 - 6730)	HIR	0.6 mi N	6085 (2/2) (5440 - 6730)	2410 (2/2) (1970 - 2850)	0
	Cs-134	4	150	< LLD	N/A		< LLD	< LLD	0
	Cs-137	4	180	< LLD	N/A		< LLD	< LLD	0
	Ra-226	4		< LLD	CHIC	11.2 mi WNW	4280 (1/2) (4280 - 4280)	4280 (1/2) (4280 - 4280)	0
	Th-228	4		223 (2/2) (131 - 314)	CHIC	11.2 mi WNW	2643 (2/2) (415 - 4870)	2643 (2/2) (415 - 4870)	0
	Th-232	4		235 (1/2) (235 - 235)	CHIC	11.2 mi WNW	2639 (2/2) (398 - 4880)	2639 (2/2) (398 - 4880)	0
Fish <i>(pCi/kg wet)</i>	Gamma	4							
	K-40	4		2370 (4/4) (2060 - 2820)	SD	1.3 mi NNW	2370 (4/4) (2060 - 2820)	N/A	0
	Mn-54	4	130	< LLD	N/A		< LLD	N/A	0
	Co-58	4	130	< LLD	N/A		< LLD	N/A	0
	Fe-59	4	260	< LLD	N/A		< LLD	N/A	0
	Co-60	4	130	< LLD	N/A		< LLD	N/A	0
	Zn-65	4	260	< LLD	N/A		< LLD	N/A	0
	Cs-134	4	130	< LLD	N/A		< LLD	N/A	0
	Cs-137	4	150	< LLD	N/A		< LLD	N/A	0

**TABLE 3-1: RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY**

Surry Power Station, Surry County, Virginia - 2013  
 Docket No. 50-280-281 Page 6 of 7

Medium or Pathway Sampled (Units)	Analysis		LLD	Indicator Locations	Location with Highest Mean			Control Locations	Non-Routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	
<b>Oysters</b> (pCi/kg wet)	<b>Gamma</b>	6							
	K-40	6		<b>728 (4/6)</b> <b>(608 - 943)</b>	<b>LC</b>	<b>2.4 mi</b> <b>SE</b>	<b>841 (2/2)</b> <b>(738 - 943)</b>	N/A	0
	Mn-54	6	130	< LLD	N/A		< LLD	N/A	0
	Fe-59	6	260	< LLD	N/A		< LLD	N/A	0
	Co-58	6	130	< LLD	N/A		< LLD	N/A	0
	Co-60	6	130	< LLD	N/A		< LLD	N/A	0
	Zn-65	6	260	< LLD	N/A		< LLD	N/A	0
	Cs-134	6	130	< LLD	N/A		< LLD	N/A	0
	Cs-137	6	150	< LLD	N/A		< LLD	N/A	0
<hr/>									
<b>Clams</b> (pCi/kg wet)	<b>Gamma</b>	6							
	K-40	6		<b>576 (2/4)</b> <b>(473 - 679)</b>	<b>J1</b>	<b>3.9 mi</b> <b>NW</b>	<b>679 (1/2)</b> <b>(679 - 679)</b>	<b>461 (1/2)</b> <b>(461 - 461)</b>	0
	Mn-54	6	130	< LLD	N/A		< LLD	< LLD	0
	Co-58	6	130	< LLD	N/A		< LLD	< LLD	0
	Fe-59	6	260	< LLD	N/A		< LLD	< LLD	0
	Co-60	6	130	< LLD	N/A		< LLD	< LLD	0
	Zn-65	6	260	< LLD	N/A		< LLD	< LLD	0
	Cs-134	6	130	< LLD	N/A		< LLD	< LLD	0
	Cs-137	6	150	< LLD	N/A		< LLD	< LLD	0

**TABLE 3-1: RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY**

Surry Power Station, Surry County, Virginia - 2013  
 Docket No. 50-280-281 Page 7 of 7

Medium or Pathway Sampled <i>(Units)</i>	Analysis		LLD	Indicator Locations	Location with Highest Mean			Control Locations	Non-Routine Reported Measurements
	Type	Total No.		Mean Range	Name	Distance Direction	Mean Range	Mean Range	
<b>Clams</b> <i>(pCi/kg wet)</i>	<b>Gamma</b>	6							
	Th-228	6		152 (1/4) (152 - 152)	JI	3.9 mi NW	152 (1/4) (152 - 152)	95.2 (1/2) (95.2 - 95.2)	0
<b>Crabs</b> <i>(pCi/kg wet)</i>	<b>Gamma</b>	1							
	K-40	1		2670 (1/1) (2670 - 2670)	SD	1.3 mi NNW	2670 (1/1) (2670 - 2670)	N/A	0
	Mn-54	1	130	< LLD	N/A		< LLD	N/A	0
	Co-58	1	130	< LLD	N/A		< LLD	N/A	0
	Fe-59	1	260	< LLD	N/A		< LLD	N/A	0
	Co-60	1	130	< LLD	N/A		< LLD	N/A	0
	Zn-65	1	260	< LLD	N/A		< LLD	N/A	0
	Cs-134	1	130	< LLD	N/A		< LLD	N/A	0
	Cs-137	1	150	< LLD	N/A		< LLD	N/A	0

### ***3.2 Analytical Results of 2013 REMP Samples***

Radiological analyses of environmental media characteristically approach and frequently fall below the detection limits of state-of-the-art measurement methods. The reported error is two times the standard deviation ( $2\sigma$ ) of the net activity. Unless otherwise noted, the overall error (counting, sample size, chemistry, errors, etc.) is estimated to be 2 to 5 times that listed. Results are considered positive when the measured value exceeds  $2\sigma$  uncertainty.

Teledyne Brown Engineering analytical methods meet the Lower Limit of Detection (LLD) requirements given in Table 2 of the USNRC Branch Technical Position, "An Acceptable Radiological Environmental Monitoring Program", (November 1979, Revision 1) and the Surry ODCM.

Data are given according to sample type as indicated below.

1. Gamma Exposure Rate
2. Air Particulates, Weekly Gross Beta Radioactivity
3. Air Particulates, Weekly I-131
4. Air Particulates, Quarterly Gamma Spectroscopy
5. Cow Milk
6. Food Products
7. Well Water
8. River Water
9. Silt
10. Shoreline Sediment
11. Fish
12. Oysters
13. Clams
14. Crabs



**TABLE 3-2: GAMMA EXPOSURE RATE**

Surry Power Station, Surry County, Virginia - 2013

mR/Std Month  $\pm$  2 Sigma

Page 1 of 1

STATION NUMBER	FIRST QUARTER	SECOND QUARTER	THIRD QUARTER	FOURTH QUARTER	AVERAGE $\pm$ 2 SIGMA
02	6.2 $\pm$ 0.6	6.1 $\pm$ 0.5	6.5 $\pm$ 1.0	6.9 $\pm$ 0.8	6.4 $\pm$ 0.7
03	6.4 $\pm$ 0.7	6.6 $\pm$ 1.5	6.5 $\pm$ 1.0	6.6 $\pm$ 0.8	6.5 $\pm$ 0.2
04	5.8 $\pm$ 0.9	5.8 $\pm$ 0.4	6.1 $\pm$ 0.6	6.3 $\pm$ 0.6	6.0 $\pm$ 0.5
05	5.9 $\pm$ 0.3	6.1 $\pm$ 0.6	6.3 $\pm$ 1.2	6.4 $\pm$ 0.7	6.2 $\pm$ 0.4
06	5.9 $\pm$ 0.4	5.9 $\pm$ 0.8	6.4 $\pm$ 1.3	6.3 $\pm$ 0.9	6.1 $\pm$ 0.5
07	5.9 $\pm$ 0.6	5.9 $\pm$ 0.4	6.4 $\pm$ 0.4	6.4 $\pm$ 1.1	6.2 $\pm$ 0.6
08	5.4 $\pm$ 0.7	5.4 $\pm$ 0.8	5.8 $\pm$ 0.9	5.8 $\pm$ 0.5	5.6 $\pm$ 0.5
09	7.8 $\pm$ 1.0	7.6 $\pm$ 1.2	7.8 $\pm$ 0.9	7.9 $\pm$ 1.1	7.8 $\pm$ 0.3
10	5.9 $\pm$ 1.0	6.2 $\pm$ 1.1	6.3 $\pm$ 1.3	6.4 $\pm$ 0.8	6.2 $\pm$ 0.4
11	5.1 $\pm$ 0.7	5.2 $\pm$ 0.2	5.3 $\pm$ 0.5	5.5 $\pm$ 0.5	5.3 $\pm$ 0.3
12	5.3 $\pm$ 0.7	5.4 $\pm$ 0.3	6.2 $\pm$ 1.8	5.9 $\pm$ 0.7	5.7 $\pm$ 0.8
13	5.7 $\pm$ 0.7	6.0 $\pm$ 1.2	6.2 $\pm$ 0.4	6.3 $\pm$ 0.8	6.1 $\pm$ 0.5
14	5.6 $\pm$ 0.7	6.0 $\pm$ 1.1	5.7 $\pm$ 1.4	6.4 $\pm$ 1.4	5.9 $\pm$ 0.7
15	5.8 $\pm$ 0.5	6.2 $\pm$ 1.4	6.4 $\pm$ 0.8	6.4 $\pm$ 0.7	6.2 $\pm$ 0.6
16	5.4 $\pm$ 0.9	5.5 $\pm$ 0.6	6.0 $\pm$ 0.5	6.0 $\pm$ 1.0	5.7 $\pm$ 0.6
18	4.6 $\pm$ 0.6	4.7 $\pm$ 0.4	4.8 $\pm$ 0.5	5.0 $\pm$ 0.7	4.8 $\pm$ 0.3
19	4.9 $\pm$ 0.8	4.8 $\pm$ 0.4	5.4 $\pm$ 0.7	5.3 $\pm$ 0.8	5.1 $\pm$ 0.6
20	4.7 $\pm$ 0.7	4.7 $\pm$ 0.5	4.9 $\pm$ 0.6	4.9 $\pm$ 0.4	4.8 $\pm$ 0.2
21	4.7 $\pm$ 0.4	4.9 $\pm$ 0.7	5.1 $\pm$ 0.9	5.3 $\pm$ 1.4	5.0 $\pm$ 0.5
22	4.3 $\pm$ 0.7	4.2 $\pm$ 0.4	4.3 $\pm$ 0.5	4.4 $\pm$ 0.9	4.3 $\pm$ 0.2
23	5.8 $\pm$ 0.9	5.9 $\pm$ 0.6	6.0 $\pm$ 0.8	6.1 $\pm$ 1.5	6.0 $\pm$ 0.3
24	4.6 $\pm$ 0.4	4.8 $\pm$ 0.6	5.0 $\pm$ 0.8	5.1 $\pm$ 0.4	4.9 $\pm$ 0.4
25	5.6 $\pm$ 0.1	6.1 $\pm$ 1.1	5.9 $\pm$ 0.6	A	5.9 $\pm$ 0.5
26	5.7 $\pm$ 0.5	5.8 $\pm$ 0.3	6.2 $\pm$ 1.3	6.3 $\pm$ 0.9	6.0 $\pm$ 0.6
27	4.6 $\pm$ 0.5	4.8 $\pm$ 0.5	5.0 $\pm$ 0.4	5.0 $\pm$ 1.2	4.9 $\pm$ 0.4
28	4.7 $\pm$ 0.5	4.8 $\pm$ 0.7	4.8 $\pm$ 0.3	4.9 $\pm$ 0.7	4.8 $\pm$ 0.2
29	4.2 $\pm$ 0.6	4.4 $\pm$ 1.0	4.5 $\pm$ 0.9	4.7 $\pm$ 0.9	4.5 $\pm$ 0.4
30	4.6 $\pm$ 0.7	5.1 $\pm$ 0.6	4.9 $\pm$ 0.4	4.9 $\pm$ 0.6	4.9 $\pm$ 0.4
31	3.9 $\pm$ 0.6	4.2 $\pm$ 0.6	4.1 $\pm$ 0.8	4.5 $\pm$ 1.9	4.2 $\pm$ 0.5
32	4.8 $\pm$ 0.4	5.1 $\pm$ 0.6	4.9 $\pm$ 0.6	5.0 $\pm$ 0.7	5.0 $\pm$ 0.3
33	4.5 $\pm$ 0.3	4.8 $\pm$ 0.4	4.6 $\pm$ 0.3	4.9 $\pm$ 0.9	4.7 $\pm$ 0.4
34	5.1 $\pm$ 0.4	5.0 $\pm$ 0.5	5.4 $\pm$ 0.7	5.4 $\pm$ 0.3	5.2 $\pm$ 0.4
35	5.5 $\pm$ 0.3	5.6 $\pm$ 0.9	5.7 $\pm$ 0.6	6.0 $\pm$ 0.4	5.7 $\pm$ 0.4
36	5.9 $\pm$ 0.6	6.0 $\pm$ 1.6	6.0 $\pm$ 0.9	6.3 $\pm$ 0.9	6.1 $\pm$ 0.3
37	4.9 $\pm$ 0.5	4.8 $\pm$ 0.7	5.2 $\pm$ 0.9	5.3 $\pm$ 1.3	5.1 $\pm$ 0.5
38	6.9 $\pm$ 1.0	7.1 $\pm$ 1.7	7.4 $\pm$ 0.9	7.4 $\pm$ 1.2	7.2 $\pm$ 0.5
39-C	4.7 $\pm$ 0.6	4.3 $\pm$ 0.2	5.0 $\pm$ 0.8	5.0 $\pm$ 0.4	4.8 $\pm$ 0.7
40-C	5.1 $\pm$ 0.5	5.1 $\pm$ 0.7	5.5 $\pm$ 0.9	5.6 $\pm$ 0.7	5.3 $\pm$ 0.5
41-C	6.8 $\pm$ 0.8	7.2 $\pm$ 1.6	7.4 $\pm$ 1.1	7.5 $\pm$ 1.0	7.2 $\pm$ 0.6
42	5.0 $\pm$ 0.7	4.9 $\pm$ 0.9	5.6 $\pm$ 1.2	5.7 $\pm$ 0.8	5.3 $\pm$ 0.8
43	4.5 $\pm$ 0.5	4.5 $\pm$ 0.8	4.8 $\pm$ 1.2	5.2 $\pm$ 1.0	4.8 $\pm$ 0.7

A - TLD found missing at collection.

**TABLE 3-3: GROSS BETA CONCENTRATION IN FILTERED AIR**

Surry Power Station, Surry County, Virginia - 2013

1.0E-3 pCi/m3 ± 2 Sigma

Page 1 of 2

COLLECTION DATE	SAMPLING LOCATIONS							
	SS	HIR	BC	ALL	CP	BASF	FE	NN-C
January 08	28.8 ± 3.23	26.0 ± 3.10	30.8 ± 3.36	31.3 ± 3.27	36.0 ± 3.51	32.6 ± 3.32	35.7 ± 3.51	36.7 ± 3.55
January 15	18.3 ± 3.25	15.8 ± 3.11	15.9 ± 3.13	21.0 ± 3.31	26.1 ± 3.61	21.3 ± 33.50	23.0 ± 3.49	19.5 ± 3.36
January 22	13.2 ± 2.74	14.7 ± 2.78	14.6 ± 2.81	17.5 ± 2.92	13.6 ± 2.79	16.3 ± 2.88	15.0 ± 2.85	18.2 ± 3.04
January 29	21.5 ± 3.18	19.4 ± 3.02	20.3 ± 3.10	21.7 ± 3.14	26.2 ± 4.02	19.0 ± 3.01	20.1 ± 3.08	25.9 ± 3.43
February 05	20.2 ± 3.12	16.2 ± 2.87	18.2 ± 3.04	24.3 ± 3.26	23.7 ± 3.86	21.8 ± 3.15	20.0 ± 3.09	20.8 ± 3.17
February 12	12.1 ± 2.80	10.50 ± 2.67	13.6 ± 2.89	15.2 ± 2.92	14.8 ± 2.96	14.5 ± 2.90	13.4 ± 2.86	15.6 ± 3.01
February 19	11.6 ± 2.71	13.0 ± 2.75	13.3 ± 2.81	17.5 ± 2.98	15.1 ± 2.91	14.3 ± 2.82	16.1 ± 2.95	17.0 ± 3.05
February 26	10.8 ± 2.72	11.2 ± 2.71	12.2 ± 2.82	10.1 ± 2.65	10.3 ± 2.72	11.0 ± 2.70	10.7 ± 2.72	11.1 ± 2.79
March 05	6.40 ± 2.33	6.69 ± 2.30	9.14 ± 2.50	9.78 ± 2.49	10.4 ± 2.56	7.87 ± 2.38	8.04 ± 2.41	8.70 ± 2.50
March 12	7.75 ± 2.39	6.75 ± 2.29	7.04 ± 2.34	7.95 ± 2.36	7.07 ± 2.33	9.10 ± 2.44	7.18 ± 2.35	11.0 ± 2.62
March 18	15.7 ± 3.59	11.4 ± 3.32	14.9 ± 3.55	13.4 ± 3.41	13.7 ± 3.47	13.8 ± 3.43	14.2 ± 3.49	16.8 ± 3.69
March 26	9.26 ± 2.32	8.96 ± 2.27	10.1 ± 2.37	12.1 ± 2.44	9.10 ± 2.30	12.7 ± 2.49	13.1 ± 2.53	11.4 ± 2.47
<b>Qtr. Avg. ± 2 s.d.</b>	<b>14.6 ± 13.07</b>	<b>13.4 ± 11.06</b>	<b>15.0 ± 12.41</b>	<b>16.8 ± 13.72</b>	<b>17.2 ± 17.62</b>	<b>16.2 ± 13.56</b>	<b>16.4 ± 15.46</b>	<b>17.7 ± 15.45</b>
April 02	5.82 ± 2.46	9.06 ± 2.62	10.1 ± 2.72	10.0 ± 2.65	8.45 ± 2.60	8.49 ± 2.57	8.35 ± 2.60	6.97 ± 2.55
April 09	13.9 ± 2.71	14.8 ± 2.73	16.3 ± 2.83	18.8 ± 2.93	17.4 ± 2.87	19.2 ± 2.94	19.6 ± 2.99	19.0 ± 2.97
April 16	12.2 ± 2.61	11.4 ± 2.54	13.0 ± 2.64	13.0 ± 2.61	12.7 ± 2.62	11.2 ± 2.54	10.8 ± 2.52	12.8 ± 2.71
April 23	9.78 ± 2.89	8.88 ± 2.80	11.3 ± 2.97	13.4 ± 3.02	9.94 ± 2.88	13.6 ± 3.04	10.3 ± 2.90	13.4 ± 3.11
April 30	12.9 ± 2.70	11.7 ± 2.61	13.5 ± 2.75	13.7 ± 2.71	11.0 ± 2.58	13.0 ± 2.67	12.0 ± 2.65	14.3 ± 2.83
May 07	6.71 ± 2.41	7.12 ± 2.41	5.42 ± 2.34	5.71 ± 2.30	5.92 ± 2.33	7.95 ± 2.46	5.79 ± 2.35	6.45 ± 2.41
May 14	8.86 ± 2.67	8.93 ± 2.64	12.4 ± 2.89	11.4 ± 2.78	7.29 ± 2.57	10.4 ± 2.72	11.0 ± 2.79	12.3 ± 2.91
May 21	13.6 ± 2.99	13.8 ± 2.95	13.8 ± 2.99	17.6 ± 3.13	13.7 ± 2.97	14.4 ± 2.99	15.9 ± 3.09	17.6 ± 3.19
May 28	8.33 ± 2.40	7.85 ± 2.35	8.50 ± 2.42	12.0 ± 2.60	6.99 ± 2.30	10.3 ± 2.51	8.66 ± 2.43	10.1 ± 2.55
June 04	9.23 ± 2.54	9.46 ± 2.51	9.48 ± 2.54	13.1 ± 2.73	12.3 ± 2.70	8.88 ± 2.48	12.6 ± 2.72	12.3 ± 2.71
June 10	7.98 ± 2.80	5.59 ± 2.59	7.96 ± 2.79	7.07 ± 2.68	7.03 ± 2.75	6.78 ± 2.65	7.27 ± 2.76	8.03 ± 2.82
June 17	12.3 ± 2.78	12.2 ± 2.73	14.4 ± 2.80	15.5 ± 2.81	16.1 ± 3.29	11.2 ± 2.58	14.1 ± 2.81	14.3 ± 2.80
June 24	8.76 ± 2.42	9.78 ± 2.44	8.33 ± 2.40	10.9 ± 2.51	8.2 ± 2.40	12.3 ± 2.61	11.7 ± 2.62	10.2 ± 2.53
<b>Qtr. Avg. ± 2 s.d.</b>	<b>10.0 ± 5.33</b>	<b>10.04 ± 5.26</b>	<b>11.1 ± 6.23</b>	<b>12.5 ± 7.38</b>	<b>10.5 ± 7.37</b>	<b>11.4 ± 6.54</b>	<b>11.4 ± 7.39</b>	<b>12.1 ± 7.58</b>

**TABLE 3-3: GROSS BETA CONCENTRATION IN FILTERED AIR**

Surry Power Station, Surry County, Virginia - 2013

1.0E-3 pCi/m3 ± 2 Sigma

Page 2 of 2

COLLECTION DATE	SAMPLING LOCATIONS							
	SS	HIR	BC	ALL	CP	BASF	FE	NN-C
July 02	9.65 ± 2.21	11.0 ± 2.31	8.85 ± 2.22	11.3 ± 2.32	12.7 ± 2.44	11.4 ± 2.33	10.9 ± 2.33	10.5 ± 2.32
July 09	7.00 ± 2.68	4.71 ± 2.41	5.73 ± 2.52	7.63 ± 2.58	6.10 ± 2.53	4.96 ± 2.44	5.11 ± 2.48	6.50 ± 2.59
July 15	6.35 ± 2.55	6.37 ± 2.53	8.26 ± 2.69	7.81 ± 2.61	7.93 ± 2.65	8.53 ± 2.68	8.17 ± 2.68	7.73 ± 2.63
July 23	10.6 ± 2.09	9.33 ± 19.8	10.8 ± 2.08	10.8 ± 2.05	11.2 ± 2.10	12.0 ± 2.14	12.3 ± 2.17	10.3 ± 2.05
July 30	13.3 ± 2.87	9.91 ± 2.62	11.4 ± 2.75	11.8 ± 2.73	10.1 ± 2.68	12.5 ± 2.80	12.1 ± 2.79	13.1 ± 2.84
August 06	18.7 ± 3.03	11.5 ± 2.58	15.3 ± 2.83	16.4 ± 2.86	11.6 ± 2.60	15.6 ± 2.82	18.0 ± 2.96	12.6 ± 2.63
August 13	16.8 ± 3.00	11.1 ± 2.64	12.8 ± 2.84	14.6 ± 2.89	12.9 ± 2.74	14.6 ± 2.84	14.9 ± 2.86	16.0 ± 2.97
August 20	8.68 ± 2.41	5.71 ± 2.16	8.03 ± 2.34	10.2 ± 2.45	8.33 ± 2.34	7.29 ± 2.26	9.66 ± 2.43	9.51 ± 2.41
August 26	14.8 ± 3.06	10.5 ± 2.73	11.4 ± 2.82	13.3 ± 2.89	12.0 ± 2.85	11.9 ± 2.84	12.6 ± 2.90	13.7 ± 2.94
September 03	21.4 ± 3.12	16.3 ± 2.82	18.3 ± 2.95	22.3 ± 3.09	19.2 ± 2.99	16.1 ± 2.83	23.3 ± 3.18	19.9 ± 2.99
September 10	23.7 ± 3.27	16.5 ± 2.84	16.1 ± 2.85	18.1 ± 2.93	17.4 ± 2.92	17.1 ± 2.89	19.9 ± 3.06	17.7 ± 2.91
September 17	26.7 ± 3.47	18.1 ± 3.00	23.4 ± 3.30	22.5 ± 3.21	19.9 ± 3.12	24.0 ± 3.29	24.0 ± 3.32	25.7 ± 3.36
September 24	14.9 ± 2.96	10.3 ± 2.63	10.2 ± 2.66	12.5 ± 2.76	9.38 ± 2.61	10.1 ± 2.62	9.78 ± 2.63	11.8 ± 2.72
<b>Qtr. Avg. ± 2 s.d.</b>	<b>14.8 ± 12.91</b>	<b>10.87 ± 8.22</b>	<b>12.4 ± 9.67</b>	<b>13.8 ± 9.7</b>	<b>12.2 ± 8.57</b>	<b>12.8 ± 9.78</b>	<b>13.9 ± 11.6</b>	<b>13.5 ± 10.57</b>
October 01	14.6 ± 2.71	9.69 ± 2.34	11.7 ± 2.51	11.5 ± 2.46	12.2 ± 2.53	11.0 ± 2.44	13.5 ± 2.62	13.6 ± 2.57
October 08	31.8 ± 3.62	21.8 ± 3.09	26.4 ± 3.35	31.2 ± 3.55	22.2 ± 3.13	28 ± 3.37	24.2 ± 3.22	27.2 ± 3.33
October 15	6.83 ± 2.51	6.65 ± 2.44	5.09 ± 2.30	8.22 ± 2.49	5.22 ± 2.30	6.39 ± 2.37	6.58 ± 2.42	6.20 ± 2.32
October 22	22.0 ± 3.22	14.8 ± 2.78	16.5 ± 2.92	16.4 ± 2.89	14.6 ± 2.79	17.4 ± 2.93	15.8 ± 2.87	17.2 ± 2.95
October 29	24.0 ± 3.30	16.1 ± 2.86	20.5 ± 3.12	23.1 ± 3.23	18.6 ± 3.02	19.5 ± 3.03	19.8 ± 3.09	23.1 ± 3.21
November 05	27.1 ± 3.37	18.3 ± 2.9	23.2 ± 3.19	26.7 ± 3.32	20.2 ± 3.03	21 ± 3.06	19.8 ± 3.02	25.3 ± 3.22
November 12	17.7 ± 2.89	11.7 ± 2.52	15.7 ± 2.79	17.9 ± 2.88	13.5 ± 2.65	15.1 ± 2.72	15.3 ± 2.74	17.9 ± 2.88
November 19	16.2 ± 2.96	9.13 ± 2.50	10.8 ± 2.64	11.6 ± 2.68	9.16 ± 2.54	9.24 ± 2.55	10.2 ± 2.62	10.5 ± 2.59
November 26	10.1 ± 2.63	8.25 ± 2.45	7.70 ± 2.45	12.4 ± 2.72	9.09 ± 2.53	9.20 ± 2.53	10.0 ± 2.60	11.6 ± 2.67
December 03	25.8 ± 3.48	14.4 ± 2.84	17.1 ± 3.02	22.4 ± 3.26	17.3 ± 3.02	15.9 ± 2.92	15.3 ± 2.91	17.6 ± 3.02
December 10	18.4 ± 3.15	11.0 ± 2.69	15.5 ± 2.98	18.3 ± 3.10	13.9 ± 2.88	14.4 ± 2.89	12.2 ± 2.80	14.7 ± 2.88
December 16	26.9 ± 3.82	17.7 ± 3.29	23.5 ± 3.64	22.1 ± 3.53	22.9 ± 3.60	18.9 ± 3.37	24.4 ± 3.68	22.9 ± 3.58
December 23	17.2 ± 3.10	11.4 ± 2.73	13.1 ± 2.92	17.0 ± 3.10	13.2 ± 2.92	10.3 ± 2.72	12.1 ± 2.86	15.1 ± 2.15
December 31	24.6 ± 2.97	15.4 ± 2.45	19.5 ± 2.67	21.8 ± 2.77	20.5 ± 2.71	18.1 ± 2.57	19.7 ± 2.67	21.1 ± 2.71
<b>Qtr. Avg. ± 2 s.d.</b>	<b>20.2 ± 14.1</b>	<b>13.3 ± 8.66</b>	<b>16.2 ± 12.3</b>	<b>18.6 ± 12.8</b>	<b>15.2 ± 10.7</b>	<b>15.3 ± 11.6</b>	<b>15.6 ± 10.7</b>	<b>17.4 ± 12.0</b>
<b>Ann. Avg. ± 2 s.d.</b>	<b>15.0 ± 13.73</b>	<b>11.90 ± 8.76</b>	<b>13.7 ± 10.95</b>	<b>15.5 ± 11.9</b>	<b>13.7 ± 12.3</b>	<b>13.9 ± 11.0</b>	<b>14.3 ± 11.8</b>	<b>15.2 ± 12.3</b>

**TABLE 3-4: IODINE-131 CONCENTRATION IN FILTERED AIR**

Surry Power Station, Surry County, Virginia - 2013

1.0E-3 pCi/m<sup>3</sup> ± 2 Sigma

Page 1 of 2

COLLECTION DATE	SAMPLING LOCATIONS							
	SS	HIR	BC	ALL	CP	BASF	FE	NN-C
January 08	14.0 ± 25.2	13.9 ± 25.0	14.2 ± 25.6	13.5 ± 24.3	-6.29 ± 24.6	-6.12 ± 2.39	-6.32 ± 24.7	-6.30 ± 24.6
January 15	3.16 ± 22.2	3.14 ± 22.1	3.16 ± 22.2	3.08 ± 21.7	-6.16 ± 24.3	-6.00 ± 23.7	-6.16 ± 24.3	-6.19 ± 24.5
January 22	5.59 ± 17.0	5.45 ± 16.6	5.55 ± 16.9	5.43 ± 16.5	12.6 ± 16.9	12.2 ± 16.3	12.5 ± 16.6	12.5 ± 16.7
January 29	-4.76 ± 16.9	-4.62 ± 16.4	-4.72 ± 16.7	-4.63 ± 16.4	3.56 ± 19.9	2.71 ± 15.1	2.72 ± 15.2	2.80 ± 15.6
February 05	2.62 ± 19.1	2.55 ± 18.7	2.64 ± 19.3	2.54 ± 18.6	-10.3 ± 21.2	-7.94 ± 16.3	-8.04 ± 16.5	-8.16 ± 16.8
February 12	±	±	±	±	±	±	±	±
February 19	-14.6 ± 13.9	-14.4 ± 13.6	-14.7 ± 13.9	-14.3 ± 13.6	-7.30 ± 15.1	-7.10 ± 14.7	-7.24 ± 15.0	-7.39 ± 15.3
February 26	6.77 ± 18.1	6.65 ± 17.7	6.82 ± 18.2	6.64 ± 17.7	-2.83 ± 16.7	-2.76 ± 16.2	-2.80 ± 16.5	-2.85 ± 16.8
March 05	-13.6 ± 21.3	-13.3 ± 20.8	-13.6 ± 21.3	-13.3 ± 20.7	7.00 ± 13.3	6.87 ± 13.1	6.94 ± 13.2	7.09 ± 13.5
March 12	0.55 ± 10.0	0.54 ± 9.80	0.55 ± 10.0	0.54 ± 9.76	7.68 ± 22.8	7.57 ± 22.5	7.69 ± 22.9	7.80 ± 23.2
March 18	-1.09 ± 15.1	-1.07 ± 14.8	-1.09 ± 15.1	-1.06 ± 14.7	6.24 ± 17.9	6.14 ± 17.6	6.22 ± 17.8	6.33 ± 18.1
March 26	-6.94 ± 11.3	-6.81 ± 11.2	-6.96 ± 11.3	-6.78 ± 11.0	9.48 ± 12.9	9.39 ± 12.7	9.45 ± 12.8	9.60 ± 13.0
April 02	-4.38 ± 17.1	-4.30 ± 16.7	-4.38 ± 17.1	-4.25 ± 16.6	-9.71 ± 21.1	-9.55 ± 20.8	-9.72 ± 21.1	-9.83 ± 21.4
April 09	-11.0 ± 22.3	-10.8 ± 21.9	-10.9 ± 22.1	-10.7 ± 21.7	9.82 ± 22.3	9.67 ± 23.0	9.81 ± 23.3	9.79 ± 23.2
April 16	-4.35 ± 12.5	-4.32 ± 12.4	-4.31 ± 12.4	-4.24 ± 12.2	0.84 ± 13.2	0.85 ± 13.3	0.85 ± 13.3	0.87 ± 13.7
April 23	-8.47 ± 20.9	-8.35 ± 20.6	-8.46 ± 20.9	-8.26 ± 20.4	14.3 ± 17.9	14.1 ± 17.7	14.3 ± 17.9	14.5 ± 18.2
April 30	-4.19 ± 18.6	-4.14 ± 18.3	-4.20 ± 18.6	-4.08 ± 18.1	-6.30 ± 16.8	-6.19 ± 16.5	-6.28 ± 16.8	-6.42 ± 17.1
May 07	9.96 ± 10.4	9.78 ± 10.2	9.98 ± 10.4	9.68 ± 10.1	-0.27 ± 10.5	-0.27 ± 10.5	-0.28 ± 10.7	-0.28 ± 10.7
May 14	-8.22 ± 12.2	-8.07 ± 12.0	-8.28 ± 12.3	-8.05 ± 12.0	-6.91 ± 15.2	-6.79 ± 14.9	-6.90 ± 15.2	-7.40 ± 15.5
May 21	-6.95 ± 22.9	-6.82 ± 22.5	-6.92 ± 22.9	-6.77 ± 22.3	4.54 ± 21.8	4.50 ± 21.6	4.55 ± 21.9	4.56 ± 21.9
May 28	-10.7 ± 22.2	-10.5 ± 21.9	-10.7 ± 22.2	-10.5 ± 21.9	16.0 ± 21.0	16.0 ± 21.0	16.1 ± 21.2	16.3 ± 21.4
June 05	-9.68 ± 15.9	-9.45 ± 15.5	-9.62 ± 15.8	-9.52 ± 15.6	-1.98 ± 11.7	-1.95 ± 11.5	-1.98 ± 11.7	-1.97 ± 11.7
June 10	10.2 ± 24.2	10.5 ± 23.7	-8.00 ± 28.9	10.4 ± 23.5	-7.03 ± 24.0	-6.76 ± 23.1	-6.97 ± 23.8	-6.96 ± 23.8
June 17	-0.08 ± 12.6	-0.08 ± 12.4	-0.08 ± 12.0	-0.08 ± 11.6	5.10 ± 15.5	4.18 ± 12.7	4.31 ± 13.1	4.23 ± 12.9
June 24	-7.35 ± 15.3	-7.19 ± 14.9	-7.36 ± 15.3	-7.16 ± 14.9	6.09 ± 13.9	5.94 ± 13.5	6.09 ± 13.9	6.09 ± 13.9

**TABLE 3-4: IODINE-131 CONCENTRATION IN FILTERED AIR**

Surry Power Station, Surry County, Virginia - 2013

1.0E-3 pCi/m3 ± 2 Sigma

Page 2 of 2

COLLECTION DATE	SAMPLING LOCATIONS							
	SS	HIR	BC	ALL	CP	BASF	FE	NN-C
July 02	11.1 ± 23.7	11.4 ± 24.3	11.6 ± 24.8	11.3 ± 24.2	4.60 ± 29.6	4.48 ± 28.8	4.56 ± 29.2	4.58 ± 29.5
July 09	-8.65 ± 25.8	-8.27 ± 24.7	-8.42 ± 25.1	-8.21 ± 24.5	-0.50 ± 23.9	-0.50 ± 23.6	-0.50 ± 23.9	-0.50 ± 24
July 15	-1.57 ± 14.4	-1.55 ± 14.3	-1.57 ± 14.4	-1.53 ± 14.1	-9.03 ± 14.1	-8.93 ± 14.0	-9.06 ± 14.1	-8.92 ± 13.9
July 23	6.48 ± 13.8	6.32 ± 13.5	6.39 ± 13.6	6.23 ± 13.3	-2.91 ± 14.5	-2.90 ± 14.4	-2.93 ± 14.6	-2.90 ± 14.4
July 30	-9.09 ± 32.1	-8.86 ± 31.3	-8.99 ± 31.8	-8.83 ± 31.2	10.7 ± 22.0	10.6 ± 21.8	10.7 ± 22.0	10.6 ± 21.8
August 06	-14.8 ± 24.1	-14.5 ± 23.6	-14.7 ± 23.9	-14.5 ± 23.6	15.4 ± 20.3	15.3 ± 20.1	15.4 ± 20.2	15.1 ± 19.8
August 13	-15.4 ± 16.6	-15.1 ± 16.3	-15.8 ± 17.0	-15.4 ± 16.6	2.44 ± 18.2	2.44 ± 18.2	2.44 ± 18.2	2.49 ± 18.5
August 20	-12.7 ± 16.0	-12.4 ± 15.6	-12.5 ± 15.7	-12.3 ± 15.5	-8.13 ± 18.4	-8.08 ± 18.3	-8.14 ± 18.5	-8.06 ± 18.3
August 26	-2.12 ± 18.5	-2.05 ± 17.9	-2.09 ± 18.2	-2.04 ± 17.8	8.35 ± 17.7	8.30 ± 17.6	8.36 ± 17.7	8.23 ± 17.5
September 03	17.5 ± 22.9	17 ± 22.3	17.3 ± 22.7	16.9 ± 22.1	-4.87 ± 20.2	-4.83 ± 20.1	-4.86 ± 20.2	-4.77 ± 19.8
September 10	19.4 ± 25.1	18.9 ± 24.5	19.2 ± 24.8	18.9 ± 24.4	31.5 ± 30.4	31.3 ± 30.2	31.5 ± 30.4	30.9 ± 29.8
September 17	-0.75 ± 16.8	-0.73 ± 16.4	-0.74 ± 16.6	-0.72 ± 16.3	1.40 ± 15.9	1.37 ± 15.6	1.39 ± 15.8	1.37 ± 15.5
September 24	6.57 ± 22.7	6.37 ± 22.1	6.47 ± 22.4	6.35 ± 22.0	-20.5 ± 22.2	-20.1 ± 21.8	-20.4 ± 22.2	-20.0 ± 21.8
October 01	14.9 ± 28.3	14.4 ± 27.4	14.6 ± 27.9	14.3 ± 27.3	-8.57 ± 29.0	-8.46 ± 28.6	-8.56 ± 28.9	-8.28 ± 28.0
October 08	24.2 ± 24.2	23.5 ± 23.4	23.9 ± 23.9	23.7 ± 23.6	-5.99 ± 24.3	-5.90 ± 23.9	-5.94 ± 24.0	-5.84 ± 23.6
October 15	-2.11 ± 11.2	-2.05 ± 10.9	-2.01 ± 10.7	-1.99 ± 10.6	-5.18 ± 10.7	-5.13 ± 10.6	-5.21 ± 10.8	-5.00 ± 10.3
October 22	22.4 ± 20.4	21.8 ± 19.8	22.2 ± 20.2	22.0 ± 20.0	12.5 ± 18.0	12.3 ± 17.8	12.4 ± 18.0	12.4 ± 17.9
October 29	-18.4 ± 39.6	-18 ± 38.6	-18.2 ± 39.2	-18.2 ± 39.0	-0.85 ± 36.3	-0.84 ± 35.7	-0.85 ± 36.3	-0.84 ± 35.6
November 05	-22.8 ± 35.1	-22.4 ± 34.5	-22.9 ± 35.3	-22.5 ± 34.6	-3.72 ± 40.1	-3.69 ± 39.9	-3.72 ± 40.2	-3.57 ± 38.6
November 12	1.30 ± 20.4	1.28 ± 20.0	1.30 ± 20.4	1.28 ± 20.2	0.73 ± 20.1	0.72 ± 19.9	0.72 ± 19.9	0.72 ± 19.8
November 19	-3.68 ± 18.1	-3.57 ± 17.5	-3.63 ± 17.8	-3.62 ± 17.8	-5.05 ± 21.8	-5.04 ± 21.7	-5.08 ± 21.9	-4.92 ± 21.2
November 26	-5.84 ± 39.0	-5.67 ± 37.8	-5.77 ± 38.5	-5.70 ± 38.0	-0.67 ± 41.0	-0.66 ± 40.8	-0.67 ± 41.1	-0.65 ± 40.3
December 03	4.55 ± 32.9	4.43 ± 32.0	4.49 ± 32.4	4.42 ± 31.9	-7.08 ± 33.4	-7.01 ± 33.0	-7.08 ± 33.3	-6.99 ± 32.9
December 10	-14.0 ± 25.7	-13.6 ± 24.9	-13.8 ± 25.5	-13.7 ± 25.2	-16.1 ± 20.0	-15.9 ± 19.8	-16.2 ± 20.0	-15.7 ± 19.5
December 16	-28.4 ± 29.8	-27.6 ± 29.0	-28.1 ± 29.5	-27.6 ± 29.0	-19.7 ± 28.8	-19.4 ± 28.4	-19.6 ± 28.7	-19.3 ± 28.2
December 24	17.0 ± 30.4	16.6 ± 29.7	17.5 ± 31.3	17.3 ± 30.8	-10.3 ± 28.5	-10.2 ± 28.1	-10.3 ± 28.4	-10.1 ± 27.9
December 31	-30.8 ± 43.0	-30.2 ± 42.3	-30.2 ± 42.1	-29.8 ± 41.6	-25.9 ± 33.4	-25.6 ± 33.0	-25.8 ± 33.3	-25.3 ± 32.7

**TABLE 3-5: GAMMA EMITTER CONCENTRATION IN FILTERED AIR**

Surry Power Station, Surry County, Virginia - 2013

1.0E-3 pCi/m3 ± 2 Sigma

Page 1 of 1

SAMPLING LOCATIONS	NUCLIDE	FIRST QUARTER	SECOND QUARTER	THIRD QUARTER	FOURTH QUARTER	AVERAGE ± 2 SIGMA
SS	Cs-134	-0.52 ± 0.53	-0.36 ± 0.88	-0.15 ± 0.57	0.31 ± 0.57	
	Cs-137	0.05 ± 0.38	0.31 ± 0.75	0.09 ± 0.60	-0.21 ± 0.51	
	Be-7	104 ± 25.3	130 ± 26.9	129 ± 24.5	146 ± 26.1	127 ± 34.7
	K-40		21.9 ± 13.2			21.9 ± 13.2
HIR	Cs-134	0.16 ± 0.56	1.02 ± 0.95	0.58 ± 0.77	-0.10 ± 1.17	
	Cs-137	0.00 ± 0.37	0.17 ± 0.94	-0.49 ± 0.68	0.22 ± 1.09	
	Be-7	63.8 ± 22.8	106 ± 25.9	97.0 ± 19.9	77.3 ± 27.8	86 ± 38.1
	K-40			57.7 ± 15.8		57.7 ± 15.8
BC	Cs-134	1.12 ± 0.92	1.94 ± 1.11	-0.15 ± 0.80	-0.81 ± 0.87	
	Cs-137	-0.13 ± 0.66	-0.21 ± 1.00	0.32 ± 0.58	-0.12 ± 0.85	
	Be-7	105 ± 22.4	126 ± 30.1	153 ± 29.1	102 ± 26.3	122 ± 47.1
ALL	Cs-134	-1.25 ± 0.66	0.21 ± 0.59	-0.05 ± 0.61	0.89 ± 0.89	
	Cs-137	-0.20 ± 0.59	0.57 ± 0.74	0.08 ± 0.60	0.45 ± 0.86	
	Be-7	120 ± 30.3	166 ± 26.5	105 ± 22.7	143 ± 28.6	134 ± 53.4
	K-40				25.8 ± 15.5	25.8 ± 15.5
CP	Cs-134	1.79 ± 1.39	-0.26 ± 0.54	1.06 ± 1.14	0.61 ± 1.08	
	Cs-137	-0.78 ± 1.28	0.27 ± 0.56	-1.05 ± 1.22	0.07 ± 0.96	
	Be-7	112 ± 40.3	136 ± 23.3	105 ± 26.4	86.8 ± 34.7	110 ± 40.7
BASF	Cs-134	0.66 ± 0.96	0.82 ± 0.71	-0.06 ± 0.80	0.14 ± 0.58	
	Cs-137	-1.41 ± 0.83	-0.22 ± 0.55	-0.08 ± 0.65	-0.15 ± 0.60	
	Be-7	127 ± 29.5	137 ± 22.7	127 ± 23.7	114 ± 21.8	126 ± 18.9
FE	Cs-134	0.83 ± 1.11	-0.06 ± 0.76	0.09 ± 0.60	0.75 ± 1.11	
	Cs-137	-0.22 ± 1.03	0.28 ± 0.79	0.00 ± 0.51	-0.38 ± 1.18	
	Be-7	99.6 ± 37.3	144 ± 27.1	116 ± 21.9	98.3 ± 33.4	114 ± 42.5
NN-C	Cs-134	-0.23 ± 0.50	0.32 ± 0.76	0.99 ± 0.78	-0.03 ± 0.84	
	Cs-137	-0.21 ± 0.47	-0.16 ± 0.60	-0.28 ± 0.79	0.85 ± 0.83	
	Be-7	105 ± 29.2	147 ± 29.1	130 ± 23.0	92.0 ± 23.3	119 ± 49.4

**TABLE 3-6: GAMMA EMITTER AND STRONTIUM CONCENTRATIONS IN MILK**

Surry Power Station, Surry County, Virginia - 2013

pCi/Liter ± 2 Sigma

Page 1 of 3

NUCLIDE	EPPS	COLONIAL PARKWAY	WILLIAMS-C
<b>JANUARY</b>			
Cs-134	-1.88 ± 4.34	-0.35 ± 5.68	-3.32 ± 4.61
Cs-137	-0.58 ± 3.92	-0.75 ± 5.14	-0.38 ± 4.11
Ba-140	14.4 ± 22.8	-4.30 ± 27.6	0.32 ± 20.2
La-140	-0.48 ± 5.45	3.58 ± 8.40	2.22 ± 7.02
I-131	-0.08 ± 0.39	0.10 ± 0.43	0.34 ± 0.34
K-40	1270 ± 151	1260 ± 171	1160 ± 150
<b>FEBRUARY</b>			
Cs-134	-3.32 ± 4.63	-8.88 ± 4.21	-0.72 ± 3.73
Cs-137	-1.30 ± 3.94	1.42 ± 3.53	-0.33 ± 3.41
Ba-140	4.34 ± 20.1	26.0 ± 22.1	-2.24 ± 17.1
La-140	0.60 ± 6.24	0.69 ± 6.65	-4.55 ± 5.51
I-131	0.03 ± 0.35	0.10 ± 0.36	0.14 ± 0.34
K-40	1410.0 ± 157	1290 ± 164	1340 ± 139
<b>MARCH</b>			
Cs-134	-1.34 ± 2.32	-5.95 ± 2.95	-1.35 ± 4.09
Cs-137	0.53 ± 1.69	-0.14 ± 2.83	3.94 ± 4.07
Ba-140	-1.97 ± 9.0	2.00 ± 13.6	-17.0 ± 22.6
La-140	0.7 ± 2.51	-0.6 ± 4.23	-2.47 ± 5.43
I-131	0.29 ± 0.35	-0.15 ± 0.38	-1.03 ± 0.47
K-40	1270 ± 81	1360 ± 110	1310 ± 163
Sr-89		3.04 ± 2.87	
Sr-90		0.75 ± 0.58	
<b>APRIL</b>			
Cs-134	0.90 ± 3.46	1.28 ± 2.87	-1.63 ± 2.52
Cs-137	-1.06 ± 3.12	-0.11 ± 2.84	0.94 ± 2.30
Ba-140	-1.9 ± 15.2	-5.04 ± 15.2	0.79 ± 13.2
La-140	0.44 ± 5.17	-0.32 ± 4.83	0.39 ± 3.49
I-131	-0.18 ± 0.32	-0.16 ± 0.34	0.00 ± 0.30
K-40	1330 ± 120	1260 ± 110	1420 ± 105

**TABLE 3-6: GAMMA EMITTER AND STRONTIUM CONCENTRATIONS IN MILK**

Surry Power Station, Surry County, Virginia - 2013

pCi/Liter ± 2 Sigma

Page 2 of 3

NUCLIDE	EPPS	COLONIAL PARKWAY	WILLIAMS-C
<b><u>MAY</u></b>			
Cs-134	-2.63 ± 3.19	-1.27 ± 4.23	0.76 ± 3.89
Cs-137	3.30 ± 3.42	-2.29 ± 3.80	-1.49 ± 3.69
Ba-140	2.18 ± 17.4	8.07 ± 20.3	-1.80 ± 18.9
La-140	1.95 ± 6.07	-0.96 ± 5.17	-4.18 ± 4.56
I-131	-0.16 ± 0.41	-0.26 ± 0.40	-0.08 ± 0.42
K-40	1440 ± 151	1260 ± 140	1210 ± 122
Th-228			16.5 ± 11.2
<b><u>JUNE</u></b>			
Cs-134	-1.67 ± 4.38	-0.85 ± 4.79	0.57 ± 3.45
Cs-137	1.23 ± 4.16	1.29 ± 5.19	-0.52 ± 3.00
Ba-140	9.77 ± 21.4	13.50 ± 28.2	0.95 ± 14.4
La-140	2.72 ± 6.48	-7.34 ± 6.82	-1.63 ± 3.72
I-131	-0.17 ± 0.55	0.66 ± 0.52	-0.05 ± 0.39
K-40	1360 ± 148	1220 ± 166	1370 ± 108
Sr-89		1.99 ± 1.91	
Sr-90		-0.75 ± 0.53	
<b><u>JULY</u></b>			
Cs-134	0.66 ± 2.40	1.73 ± 2.10	-0.91 ± 3.50
Cs-137	-0.16 ± 2.52	0.71 ± 2.10	-1.23 ± 2.43
Ba-140	-5.1 ± 18.0	6.02 ± 13.6	0.66 ± 18.3
La-140	0.91 ± 6.33	1.17 ± 4.35	0.63 ± 4.47
I-131	0.02 ± 0.32	0.10 ± 0.32	-0.02 ± 0.39
K-40	1390 ± 102	1390 ± 89.7	1320 ± 87.3
<b><u>AUGUST</u></b>			
Cs-134	-4.09 ± 4.22	-4.77 ± 3.72	-0.64 ± 4.59
Cs-137	1.17 ± 4.20	4.00 ± 4.16	6.10 ± 4.00
Ba-140	-12.0 ± 19.1	15.6 ± 22.7	2.01 ± 21.3
La-140	3.22 ± 6.00	1.18 ± 5.56	-3.36 ± 7.38
I-131	0.41 ± 0.48	0.58 ± 0.54	0.23 ± 0.47
K-40	1360 ± 150	1460 ± 168	1320 ± 147



**TABLE 3-6: GAMMA EMITTER AND STRONTIUM CONCENTRATIONS IN MILK**

Surry Power Station, Surry County, Virginia - 2013

pCi/Liter ± 2 Sigma

Page 3 of 3

NUCLIDE	EPPS	COLONIAL PARKWAY	WILLIAMS-C
<b>SEPTEMBER</b>			
Cs-134	1.48 ± 4.12	-6.38 ± 3.80	-2.16 ± 3.88
Cs-137	-0.02 ± 4.73	0.93 ± 3.90	1.92 ± 3.86
Ba-140	12.2 ± 27.0	13.5 ± 23.6	-5.74 ± 24.2
La-140	-4.13 ± 9.37	4.72 ± 7.37	-0.71 ± 7.21
I-131	-0.07 ± 0.34	0.12 ± 0.37	0.19 ± 0.33
K-40	1240 ± 159	1340 ± 148	1360 ± 144
Sr-89		3.35 ± 2.56	
Sr-90		-0.56 ± 0.42	
<b>OCTOBER</b>			
Cs-134	0.43 ± 3.97	-1.25 ± 4.41	4.32 ± 4.03
Cs-137	3.56 ± 4.09	-1.65 ± 4.20	1.15 ± 4.62
Ba-140	4.29 ± 25.0	18.50 ± 27.2	-14.0 ± 27.9
La-140	1.41 ± 5.57	-0.65 ± 5.84	-1.77 ± 7.62
I-131	-0.87 ± 0.48	0.11 ± 0.48	0.07 ± 0.40
K-40	1390 ± 138	1430 ± 153	1320 ± 147
<b>NOVEMBER</b>			
Cs-134	-0.67 ± 3.23	0.56 ± 2.47	-3.28 ± 4.64
Cs-137	-0.44 ± 3.10	-0.48 ± 2.51	-2.19 ± 5.19
Ba-140	-9.03 ± 35.5	-2.25 ± 26.8	-2.47 ± 24.5
La-140	-7.64 ± 9.59	-5.07 ± 7.87	-5.75 ± 8.22
I-131	-0.40 ± 0.44	0.09 ± 0.42	0.11 ± 0.24
K-40	1370 ± 103	1390 ± 97.4	1290 ± 189
<b>DECEMBER</b>			
Cs-134	-1.85 ± 4.33	-3.59 ± 3.68	-0.03 ± 3.78
Cs-137	0.25 ± 4.65	-1.09 ± 4.04	1.26 ± 3.28
Ba-140	-8.83 ± 25.5	-3.30 ± 22.8	10.40 ± 22.7
La-140	5.39 ± 7.55	-0.64 ± 6.02	2.52 ± 4.21
I-131	0.31 ± 0.34	-0.30 ± 0.41	-0.59 ± 0.34
K-40	977 ± 164	1400 ± 165	1200 ± 145
Sr-89		4.08 ± 2.88	
Sr-90		0.62 ± 0.43	

**TABLE 3-7: GAMMA EMITTER CONCENTRATION IN FOOD PRODUCTS**

Surry Power Station, Surry County, Virginia - 2013

pCi/kg (wet) ± 2 Sigma

Page 1 of 1

SAMPLING LOCATIONS	COLLECTION DATE	SAMPLE TYPE	ISOTOPE				
			Cs-134	Cs-137	I-131	K-40	Be-7
BROCK FARM	11/1/2013	Corn	17.0 ± 6.44	2.71 ± 5.4	12.30 ± 26.5	2980 ± 144	
	11/1/2013	Peanuts	-0.97 ± 4.62	5.13 ± 4.39	-5.16 ± 22.6	4650 ± 170	201 ± 67.8
			Th-228 22.5 ± 9.84				
SLADE FARM	11/11/2013	Soybeans	-5.23 ± 4.76	7.52 ± 5.25	-1.5 ± 10.4	14500 ± 287	Th-228 12.4 ± 10.8

**TABLE 3-8: GAMMA EMITTER AND TRITIUM CONCENTRATIONS IN WELL WATER**

Surry Power Station, Surry County, Virginia - 2013

pCi/Liter ± 2 Sigma

Page 1 of 2

SAMPLING LOCATIONS	COLLECTION DATE	ISOTOPE				
SS		<b>Mn-54</b>	<b>Co-58</b>	<b>Fe-59</b>	<b>Co-60</b>	<b>Zn-65</b>
	3/12/2013	0.93 ± 2.72	0.96 ± 3.62	-0.54 ± 5.70	0.58 ± 3.72	-5.14 ± 7.54
	6/10/2013	-0.68 ± 3.21	-0.83 ± 2.90	0.67 ± 4.79	0.48 ± 3.01	-6.46 ± 6.85
	9/4/2013	2.96 ± 3.42	-0.20 ± 3.74	3.69 ± 8.25	2.23 ± 4.21	-4.31 ± 7.42
	12/10/2013	0.59 ± 3.30	-3.01 ± 3.56	-0.95 ± 6.25	-1.91 ± 2.80	7.50 ± 8.57
		<b>Nb-95</b>	<b>Zr-95</b>	<b>I-131</b>	<b>Cs-134</b>	<b>Cs-137</b>
	3/12/2013	1.89 ± 3.70	-2.51 ± 6.20	-0.61 ± 5.64	1.17 ± 3.43	-3.72 ± 3.72
	6/10/2013	-0.23 ± 3.25	0.57 ± 4.46	0.00 ± 0.29	1.21 ± 2.94	-0.28 ± 3.19
	9/4/2013	1.43 ± 4.23	-5.12 ± 6.09	-0.03 ± 0.36	-9.52 ± 3.79	-3.08 ± 3.42
	12/10/2013	3.05 ± 3.87	-3.79 ± 6.42	-0.35 ± 0.35	-2.56 ± 3.52	1.63 ± 3.65
		<b>Ba-140</b>	<b>La-140</b>	<b>H-3</b>		
	3/12/2013	-10.4 ± 15.10	-0.55 ± 5.45	90.70 ± 494		
	6/10/2013	4.81 ± 14.4	-3.44 ± 5.61	6.70 ± 501		
	9/4/2013	-4.49 ± 25.7	-8.00 ± 9.90	-38.3 ± 506		
	12/10/2013	5.83 ± 17.4	3.03 ± 6.51	-172 ± 504		
	HIR		<b>Mn-54</b>	<b>Co-58</b>	<b>Fe-59</b>	<b>Co-60</b>
3/12/2013		1.17 ± 3.82	-1.85 ± 3.15	-0.43 ± 8.37	3.87 ± 4.32	-5.43 ± 10.50
6/10/2013		1.53 ± 2.76	1.07 ± 2.75	4.95 ± 5.75	-1.38 ± 2.91	-9.22 ± 6.26
9/10/2013		0.06 ± 3.09	-0.66 ± 3.35	1.44 ± 6.74	-1.16 ± 3.79	-4.15 ± 7.13
12/10/2013		2.30 ± 3.78	-1.42 ± 3.72	-0.84 ± 7.41	2.28 ± 4.17	-2.19 ± 9.04
		<b>Nb-95</b>	<b>Zr-95</b>	<b>I-131</b>	<b>Cs-134</b>	<b>Cs-137</b>
3/12/2013		-0.72 ± 3.93	-6.03 ± 7.21	-0.44 ± 5.89	-4.26 ± 4.10	-0.31 ± 4.00
6/10/2013		1.66 ± 2.61	0.90 ± 4.55	0.23 ± 0.32	0.64 ± 3.25	3.57 ± 3.27
9/10/2013		-1.03 ± 3.88	-0.55 ± 5.91	-0.12 ± 0.34	1.60 ± 3.89	-2.36 ± 3.30
12/10/2013		0.78 ± 4.18	-1.12 ± 7.17	0.16 ± 0.37	-1.16 ± 3.88	1.14 ± 3.78
		<b>Ba-140</b>	<b>La-140</b>	<b>H-3</b>		
3/12/2013		7.11 ± 17.3	0.60 ± 5.94	220 ± 504		
6/10/2013		-6.71 ± 14.8	-2.42 ± 4.77	-26.7 ± 495		
9/10/2013		8.56 ± 15.7	-0.75 ± 6.37	-207 ± 498		
12/10/2013		-2.85 ± 17.6	-0.02 ± 5.86	310 ± 444		

**TABLE 3-8: GAMMA EMITTER AND TRITIUM CONCENTRATIONS IN WELL WATER**

Surry Power Station, Surry County, Virginia - 2013

pCi/Liter ± 2 Sigma

Page 2 of 2

SAMPLING LOCATIONS	COLLECTION DATE	ISOTOPE				
		Mn-54	Co-58	Fe-59	Co-60	Zn-65
CS	3/12/2013	0.457 ± 2.72	0.34 ± 2.54	1.44 ± 6.30	-1.27 ± 2.97	-5.83 ± 7.08
	6/10/2013	0.76 ± 2.61	-1.77 ± 2.67	-1.08 ± 2.85	-0.49 ± 3.19	-4.31 ± 6.44
	9/4/2013	0.71 ± 3.24	-1.34 ± 3.72	-0.32 ± 7.19	1.46 ± 3.73	-1.34 ± 6.55
	12/10/2013	-1.91 ± 3.18	-0.03 ± 3.33	3.63 ± 7.55	2.07 ± 3.65	-3.57 ± 8.22
		Nb-95	Zr-95	I-131	Cs-134	Cs-137
	3/12/2013	0.51 ± 2.68	0.63 ± 5.23	-1.52 ± 5.16	-1.18 ± 4.52	2.05 ± 3.46
	6/10/2013	-1.44 ± 2.82	-4.57 ± 4.52	0.46 ± 0.29	-0.89 ± 2.79	0.86 ± 3.18
	9/4/2013	1.24 ± 4.32	3.84 ± 5.86	-0.16 ± 0.43	-6.93 ± 4.10	1.01 ± 4.14
	12/10/2013	2.18 ± 4.14	-2.85 ± 5.87	0.07 ± 0.36	-5.68 ± 3.36	-0.76 ± 3.67
		Ba-140	La-140	H-3		
	3/12/2013	-2.25 ± 14.4	0.40 ± 3.84	694 ± 540		
	6/10/2013	-7.56 ± 13.3	2.95 ± 4.68	305 ± 533		
	9/4/2013	15.7 ± 27.1	-0.53 ± 7.33	-223 ± 489		
	12/10/2013	15.7 ± 17.1	1.05 ± 6.31	148 ± 428		

**TABLE 3-9: GAMMA EMITTER AND TRITIUM CONCENTRATIONS IN RIVER WATER**

Surry Power Station, Surry County, Virginia - 2013

pCi/Liter ± 2 Sigma

Page 1 of 2

SAMPLING LOCATIONS	COLLECTION DATE	ISOTOPE				
SD	1/15/2013	Mn-54	Co-58	Fe-59	Co-60	Zn-65
	2/12/2013	0.50 ± 1.01	0.06 ± 1.11	2.26 ± 2.48	-0.01 ± 1.34	0.18 ± 2.40
	3/12/2013	-1.06 ± 2.57	-0.54 ± 2.46	0.26 ± 5.23	-1.09 ± 2.65	-8.2 ± 5.41
	4/8/2013	0.74 ± 1.94	0.52 ± 2.03	-0.44 ± 3.79	1.01 ± 1.92	-0.68 ± 4.67
	5/21/2013	1.20 ± 2.22	0.97 ± 2.07	-2.84 ± 4.60	-0.35 ± 2.16	0.50 ± 5.51
	6/10/2013	0.42 ± 1.08	0.82 ± 1.10	0.58 ± 2.22	0.35 ± 1.10	-7.63 ± 2.45
	7/8/2013	-1.14 ± 2.54	-0.25 ± 2.68	2.32 ± 5.40	1.49 ± 2.83	-1.21 ± 5.49
	8/13/2013	0.15 ± 1.87	0.05 ± 2.00	1.09 ± 3.93	-1.36 ± 1.68	-4.02 ± 4.23
	9/17/2013	-0.34 ± 2.31	-0.86 ± 2.68	-1.33 ± 6.05	-0.91 ± 2.75	-7.71 ± 6.01
	10/7/2013	1.46 ± 2.63	-0.55 ± 2.72	0.54 ± 5.14	-1.43 ± 2.82	-6.11 ± 6.04
	11/11/2013	1.79 ± 1.77	-1.79 ± 1.86	1.19 ± 3.97	0.34 ± 1.89	-3.24 ± 3.88
	12/10/2013	3.18 ± 2.84	-0.24 ± 3.27	1.90 ± 5.56	-0.86 ± 3.51	-3.89 ± 7.73
	2.92 ± 3.51	3.36 ± 3.49	-4.72 ± 6.92	2.69 ± 3.38	-8.47 ± 10.10	
		Nb-95	Zr-95	I-131	Cs-134	Cs-137
	1/15/2013	0.65 ± 1.12	-1.06 ± 1.97	-3.01 ± 4.09	0.09 ± 1.16	0.48 ± 1.17
	2/12/2013	-0.14 ± 2.15	3.67 ± 4.42	4.53 ± 5.16	1.11 ± 2.40	-0.66 ± 2.55
	3/12/2013	2.78 ± 2.07	0.36 ± 3.56	-1.41 ± 3.47	-3.00 ± 2.43	-0.02 ± 2.17
	4/8/2013	1.73 ± 2.40	-1.08 ± 4.02	5.58 ± 4.15	-1.54 ± 3.00	0.15 ± 2.29
	5/21/2013	-0.60 ± 1.18	2.65 ± 1.96	0.09 ± 2.35	-0.82 ± 1.24	-0.63 ± 1.18
	6/10/2013	2.26 ± 3.38	-1.04 ± 5.54	-1.02 ± 5.47	0.45 ± 3.14	0.31 ± 2.66
	7/8/2013	0.78 ± 2.28	-0.24 ± 3.85	-0.24 ± 3.60	-0.55 ± 2.25	0.91 ± 1.95
	8/13/2013	1.70 ± 2.76	0.90 ± 4.88	3.55 ± 5.59	0.12 ± 3.11	1.39 ± 2.62
	9/17/2013	-0.67 ± 2.74	4.93 ± 5.20	0.01 ± 5.35	-0.05 ± 3.09	-0.35 ± 2.87
	10/7/2013	1.54 ± 1.83	2.11 ± 3.38	-0.18 ± 4.34	-3.77 ± 2.02	-0.40 ± 1.86
	11/11/2013	1.97 ± 3.16	-1.76 ± 5.45	0.73 ± 5.33	3.53 ± 3.52	1.27 ± 3.32
	12/10/2013	-1.79 ± 2.95	-3.06 ± 6.04	-0.74 ± 0.96	-2.04 ± 3.70	-0.45 ± 3.36
		Ba-140	La-140	H-3	K-40	Th-228
	1/15/2013	-4.26 ± 8.06	-0.88 ± 2.28		114 ± 27.4	
	2/12/2013	-3.39 ± 13.2	2.20 ± 4.67		87.1 ± 51.7	
	3/12/2013	-6.96 ± 10.0	-2.86 ± 3.04	151 ± 547	83.9 ± 44.8	6.58 ± 5.27
	4/8/2013	-16.4 ± 11.5	0.89 ± 2.86			
	5/21/2013	2.64 ± 5.89	-0.09 ± 1.86			
	6/10/2013	3.36 ± 13.6	3.27 ± 5.23	-46.9 ± 491		
	7/8/2013	0.45 ± 10.2	-0.41 ± 3.21		54.1 ± 31.7	
	8/13/2013	-10.5 ± 13.4	0.78 ± 4.10		60.0 ± 54.3	
	9/17/2013	2.30 ± 13.3	-1.91 ± 5.12	1610 ± 605	87.3 ± 59.3	
	10/7/2013	8.33 ± 10.9	-1.12 ± 3.14		103 ± 40.6	
	11/11/2013	-5.94 ± 14.9	1.75 ± 5.26		125 ± 75.1	
	12/10/2013	5.12 ± 18.6	0.69 ± 6.99	77.4 ± 729	88.7 ± 58.5	

**TABLE 3-9: GAMMA EMITTER AND TRITIUM CONCENTRATIONS IN RIVER WATER**

Surry Power Station, Surry County, Virginia - 2013

pCi/Liter ± 2 Sigma

Page 2 of 2

<b>SAMPLING LOCATIONS</b>	<b>COLLECTION DATE</b>	<b>ISOTOPES</b>				
		<b>Mn-54</b>	<b>Co-58</b>	<b>Fe-59</b>	<b>Co-60</b>	<b>Zn-65</b>
<b>SW-C</b>	1/15/2013	-0.01 ± 1.77	-1.07 ± 1.89	1.43 ± 3.80	1.55 ± 1.74	1.57 ± 3.81
	2/12/2013	-0.96 ± 2.52	1.65 ± 2.60	5.20 ± 5.37	0.74 ± 2.66	-7.76 ± 6.66
	3/12/2013	-0.98 ± 2.41	-0.01 ± 2.55	-3.09 ± 5.66	-0.91 ± 2.31	-7.06 ± 5.87
	4/9/2013	1.90 ± 2.67	-1.32 ± 2.70	-1.70 ± 5.56	-0.15 ± 2.61	-2.63 ± 5.67
	5/21/2013	0.65 ± 1.10	-0.27 ± 1.17	1.48 ± 2.60	0.42 ± 1.12	-3.11 ± 2.66
	6/10/2013	0.30 ± 2.82	-1.96 ± 3.02	1.74 ± 5.97	-1.52 ± 2.90	-4.62 ± 5.18
	7/8/2013	1.71 ± 3.30	2.50 ± 3.64	-1.86 ± 7.05	-0.57 ± 4.02	-0.49 ± 7.89
	8/13/2013	0.32 ± 2.94	1.77 ± 3.11	-1.81 ± 5.79	0.29 ± 2.99	-2.32 ± 6.31
	9/17/2013	-2.10 ± 2.81	-0.34 ± 2.53	2.16 ± 5.48	0.85 ± 2.56	-3.54 ± 5.27
	10/8/2013	-0.43 ± 1.74	1.46 ± 1.72	-1.81 ± 3.46	1.41 ± 1.72	-0.81 ± 3.30
	11/12/2013	-0.09 ± 2.89	1.28 ± 3.07	2.61 ± 6.47	-1.93 ± 3.86	-3.65 ± 7.40
	12/10/2013	1.96 ± 3.38	0.86 ± 3.95	-0.26 ± 7.23	0.06 ± 3.23	-4.47 ± 8.36
		<b>Nb-95</b>	<b>Zr-95</b>	<b>I-131</b>	<b>Cs-134</b>	<b>Cs-137</b>
	1/15/2013	0.77 ± 1.97	1.28 ± 3.43	-6.01 ± 6.11	-1.01 ± 1.97	-0.04 ± 1.91
	2/12/2013	-0.83 ± 2.74	-1.26 ± 4.90	1.30 ± 5.66	-6.89 ± 3.28	1.86 ± 2.79
	3/12/2013	-0.94 ± 2.34	1.07 ± 4.59	1.17 ± 4.65	-1.74 ± 2.87	-1.57 ± 2.64
	4/9/2013	0.38 ± 2.63	1.34 ± 4.62	-2.15 ± 4.32	-2.59 ± 2.96	-0.66 ± 2.70
	5/21/2013	0.91 ± 1.19	0.91 ± 2.08	-0.93 ± 2.46	0.75 ± 1.22	-0.11 ± 1.22
	6/10/2013	1.31 ± 3.09	-0.52 ± 4.76	2.27 ± 5.95	-3.25 ± 3.33	-2.93 ± 3.20
	7/8/2013	-0.82 ± 3.84	0.39 ± 6.78	1.34 ± 5.26	-3.60 ± 3.47	0.97 ± 3.70
	8/13/2013	1.49 ± 3.06	5.74 ± 4.84	-2.58 ± 5.90	0.33 ± 3.35	0.71 ± 3.00
	9/17/2013	-2.88 ± 2.83	-0.74 ± 4.83	4.87 ± 5.26	-3.20 ± 2.96	-0.86 ± 2.90
	10/8/2013	0.39 ± 1.78	-0.25 ± 3.14	-1.64 ± 3.52	0.77 ± 1.86	1.15 ± 1.78
	11/12/2013	-0.24 ± 3.03	-4.01 ± 5.33	3.45 ± 5.34	1.36 ± 2.95	0.39 ± 3.08
	12/10/2013	-1.13 ± 3.30	5.08 ± 6.14	-6.03 ± 6.70	-3.93 ± 4.23	-2.27 ± 3.63
		<b>Ba-140</b>	<b>La-140</b>	<b>H-3</b>	<b>K-40</b>	<b>Ra-226</b>
	1/15/2013	-5.01 ± 12.3	1.28 ± 4.21		61.1 ± 45.5	77.5 ± 65.1
	2/12/2013	0.86 ± 15.9	0.41 ± 4.35			
	3/12/2013	8.47 ± 13.0	1.50 ± 3.82	-327 ± 514		
	4/9/2013	-3.22 ± 12.0	1.27 ± 4.71			
	5/21/2013	-2.44 ± 6.2	-1.03 ± 1.98			
	6/10/2013	-9.11 ± 16.2	-1.30 ± 4.06	115 ± 496		
	7/8/2013	-7.67 ± 17.0	1.57 ± 5.93			
	8/13/2013	1.86 ± 16.1	-1.14 ± 3.66		70.5 ± 64.5	
	9/17/2013	-0.97 ± 14.9	-3.31 ± 4.15	541 ± 518	52.9 ± 25.2	
	10/8/2013	-3.32 ± 9.46	-0.65 ± 2.52		88.6 ± 35.9	
	11/12/2013	10.1 ± 14.4	-0.85 ± 4.72			
	12/10/2013	-0.18 ± 18.9	3.93 ± 4.91	460 ± 775	77.2 ± 62.2	

**TABLE 3-10: GAMMA EMITTER CONCENTRATIONS IN SILT**

Surry Power Station, Surry County, Virginia - 2013

pCi/kg (dry) ± 2 Sigma

Page 1 of 1

SAMPLING LOCATIONS	COLLECTION DATE	ISOTOPE				
		Cs-134	Cs-137	K-40	Th-232	Th-228
SD	3/14/2013	-8.36 ± 34.3	121 ± 48.6	15400 ± 1210	995 ± 166	1200 ± 944
	9/18/2013	-12.3 ± 57.0	163 ± 102	20200 ± 1990	1640 ± 246	1650 ± 159
		<b>Ra-226</b>		<b>Be-7</b>	<b>Ac-228</b>	
	3/14/2013	2210 ± 837		384 ± 316		
	9/18/2013	5310 ± 2350	1780 ± 980			
			<b>Cs-134</b>	<b>Cs-137</b>	<b>K-40</b>	<b>Th-232</b>
CHIC-C	3/14/2013	19.1 ± 48.5	175 ± 96.6	17200 ± 1710	1040 ± 221	1290 ± 159
	9/18/2013	45.9 ± 68.6	237 ± 98.8	18900 ± 2020	1370 ± 330	1680 ± 167
		<b>Ra-226</b>				
	3/14/2013	2520 ± 1230				
	9/18/2013	3560 ± 2600				

**TABLE 3-11: GAMMA EMITTER CONCENTRATIONS IN SHORELINE SEDIMENT**

Surry Power Station, Surry County, Virginia - 2013

pCi/kg (dry) ± 2 Sigma

Page 1 of 1

SAMPLING LOCATIONS	COLLECTION DATE	ISOTOPE				
		Cs-134	Cs-137	K-40	Th-228	Th-232
HIR	2/12/2013	4.99 ± 19.9	11.9 ± 20.1	6730 ± 774	131 ± 40.4	
	8/20/2013	1.98 ± 20.6	-15.2 ± 20.7	5440 ± 627	314 ± 45.7	235 ± 89.9
CHIC-C	2/12/2013	-1.75 ± 23.1	13.3 ± 22.6	2850 ± 478	415 ± 57.0	398 ± 105
	8/20/2013	26.9 ± 44.3	-50.8 ± 44.1	1970 ± 797	4870 ± 158	4880 ± 245
		<b>Ra-226</b>				
	2/12/2013					
	8/20/2013	4280 ± 1420				



**TABLE 3-12: GAMMA EMITTER CONCENTRATION IN FISH**

Surry Power Station, Surry County, Virginia - 2013

pCi/kg (wet) ± 2 Sigma

Page 1 of 1

SAMPLING LOCATION	COLLECTION DATE	SAMPLE TYPE	ISOTOPE				
			K-40	Mn-54	Co-58	Fe-59	
SD	4/9/2013	Catfish	2820 ± 1150	4.65 ± 54.3	-71.5 ± 61.8	25.6 ± 127	
	4/9/2013	White Perch	2260 ± 1260	-10.2 ± 44.7	2.96 ± 56.6	-12.4 ± 122	
	10/1/2013	Catfish	2340 ± 760	16.2 ± 40.8	-31.9 ± 43.3	31.2 ± 91.5	
	10/1/2013	White Perch	2060 ± 1230	-3.05 ± 45.7	3.86 ± 49.8	48.2 ± 112	
				Co-60	Zn-65	Cs-134	Cs-137
	4/9/2013	Catfish	30.4 ± 57.3	-21.9 ± 109	-34.2 ± 58.6	6.44 ± 50.5	
	4/9/2013	White Perch	18.8 ± 50.2	101 ± 75.8	-11.6 ± 53.1	35.3 ± 52.2	
	10/1/2013	Catfish	-27.1 ± 38.9	-66.3 ± 98.3	23.0 ± 45.0	12.4 ± 41.9	
10/1/2013	White Perch	-20.3 ± 41.8	-46.1 ± 93.0	-16.9 ± 54.6	-6.98 ± 36.4		

**TABLE 3-13: GAMMA EMITTER CONCENTRATIONS IN OYSTERS**

Surry Power Station, Surry County, Virginia - 2013

pCi/kg (wet) ± 2 Sigma

Page 1 of 1

SAMPLING LOCATIONS	COLLECTION DATE	ISOTOPE			
		Mn-54	Co-58	Fe-59	Co-60
POS					
	3/13/2013	-15.2 ± 20.9	5.88 ± 25.3	-20.3 ± 46.8	-12.8 ± 21.7
	9/19/2013	-16.4 ± 32.0	-12.1 ± 38.5	-35.2 ± 86.0	-33.50 ± 29.7
	3/13/2013	17.2 ± 44.8	-6.23 ± 23.4	6.65 ± 19.1	623 ± 418
	9/19/2013	-32.5 ± 64.4	-11.5 ± 34.2	7.54 ± 31.5	
MP					
	3/13/2013	10.80 ± 21.3	-20.0 ± 23.7	20.9 ± 51.4	-0.39 ± 22.4
	9/19/2013	0.33 ± 32.2	9.55 ± 45.8	-30.1 ± 94.4	10.7 ± 32.4
	3/13/2013	-28.4 ± 52.9	-46.30 ± 27.3	7.2 ± 22.3	608 ± 444
	9/19/2013	32.2 ± 64.6	4.42 ± 36.1	29.5 ± 33.2	
LC					
	3/13/2013	-10.3 ± 22.3	2.18 ± 26.4	-4.23 ± 60.0	-4.45 ± 19.0
	9/19/2013	11.1 ± 21.1	-19.6 ± 25.1	29.4 ± 68.6	-15.6 ± 20.9
	3/13/2013	-4.25 ± 52.2	-14.7 ± 25.9	4.03 ± 22.9	943 ± 464
	9/19/2013	-56.0 ± 53.1	-20.8 ± 23.7	-11.7 ± 19.8	738 ± 400

**TABLE 3-14: GAMMA EMITTER CONCENTRATIONS IN CLAMS**

Surry Power Station, Surry County, Virginia - 2013

pCi/kg (wet) ± 2 Sigma

Page 1 of 1

SAMPLING LOCATIONS	COLLECTION DATE	ISOTOPE			
JI		<b>Mn-54</b>	<b>Co-58</b>	<b>Fe-59</b>	<b>Co-60</b>
	3/14/2013	17.00 ± 22.9	2.8 ± 21.9	-7.9 ± 48.4	7.65 ± 19.8
	9/18/2013	14.8 ± 24.5	46.8 ± 35.5	-98.5 ± 72.9	11.9 ± 23.5
		<b>Zn-65</b>	<b>Cs-134</b>	<b>Cs-137</b>	<b>K-40</b>
	3/14/2013	21.8 ± 40.5	13.90 ± 23.7	-9.5 ± 22.4	
	9/18/2013	9.27 ± 48.7	-11.5 ± 30.2	21.50 ± 26.6	679 ± 567
		<b>Th-228</b>			
	3/14/2013				
	9/18/2013	152 ± 101			
	SD		<b>Mn-54</b>	<b>Co-58</b>	<b>Fe-59</b>
3/14/2013		3.46 ± 21.8	-13.8 ± 23.4	33.1 ± 48.8	10.3 ± 21.6
9/18/2013		-21.8 ± 20.2	16.2 ± 28.0	21.1 ± 76.3	9.64 ± 23.1
		<b>Zn-65</b>	<b>Cs-134</b>	<b>Cs-137</b>	<b>K-40</b>
3/14/2013		20.20 ± 49.6	-5.96 ± 27.4	-4.97 ± 23.5	
9/18/2013		-17.2 ± 55.3	10.4 ± 27.9	-8.29 ± 21.4	473 ± 467
		<b>Mn-54</b>	<b>Co-58</b>	<b>Fe-59</b>	<b>Co-60</b>
3/14/2013		7.54 ± 21.4	-4.87 ± 22.9	-23.1 ± 45.6	-3.39 ± 21.3
9/18/2013		-4.94 ± 24.0	-6.37 ± 36.3	-13.6 ± 78.7	-2.22 ± 20.2
		<b>Zn-65</b>	<b>Cs-134</b>	<b>Cs-137</b>	<b>K-40</b>
3/14/2013	22.3 ± 40.0	-3.39 ± 26.7	-22.5 ± 21.7	461 ± 369	
9/18/2013	1.46 ± 62.1	-55.3 ± 30.7	-0.93 ± 22.3		
	<b>Th-228</b>				
3/14/2013	95.2 ± 67.8				
9/18/2013					

**TABLE 3-15: GAMMA EMITTER CONCENTRATIONS IN CRABS**

Surry Power Station, Surry County, Virginia - 2013

pCi/kg (wet) ± 2 Sigma

Page 1 of 1

SAMPLING LOCATIONS	COLLECTION DATE	ISOTOPE			
SD	7/10/2013	<b>K-40</b> 2670 ± 683	<b>Mn-54</b> 11.10 ± 29.8	<b>Co-58</b> -13.40 ± 28.0	<b>Fe-59</b> -24.6 ± 60.5
		<b>Co-60</b> 7.35 ± 34.5	<b>Zn-65</b> -91.0 ± 63.7	<b>Cs-134</b> 23.40 ± 32.3	<b>Cs-137</b> 9.35 ± 31.8

## 4. DISCUSSION OF RESULTS

Data from the radiological analyses of environmental media collected during 2013 and tabulated in Section 3, are discussed below. The procedures and specifications followed in the laboratory for these analyses are as required in the Teledyne Brown Engineering quality assurance manuals and laboratory procedures. In addition to internal quality control measures performed by the laboratories, they also participate in an Interlaboratory Comparison Program. Participation in this program ensures that independent checks on the precision and accuracy of the measurements of radioactive material in environmental samples are performed. The results of the Interlaboratory Comparison Program are provided in Appendix B.

The predominant radioactivity detected throughout 2013 was from external sources, such as fallout from nuclear weapons tests (cesium-137) and naturally occurring radionuclides. Naturally occurring nuclides such as beryllium-7, potassium-40, radium-226, thorium-228 and thorium-232 were detected in numerous samples.


The following is a discussion and summary of the results of the environmental measurements taken during the 2013 reporting period.

### *4.1 Gamma Exposure Rate*

A thermoluminescent dosimeter (TLD) is an inorganic crystal used to detect ambient radiation. Two TLDs, made of CaF and LiF elements and specifically designed for environmental monitoring, are deployed at each sampling location. TLDs are placed in two concentric rings around the station. The inner ring is located in the vicinity of the site boundary, and the outer ring is located at approximately five miles from the station. TLDs are also placed in special interest areas, such as population centers and nearby residences. Additional TLDs serve as controls. Ambient radiation comes from naturally occurring radioisotopes in the air and soil, radiation from cosmic origin, fallout from nuclear weapons testing, station effluents and direct radiation from the station.

The results of the TLD analyses are presented in Table 3-2. Figure 4-1 shows a historical trend of TLD exposure rate measurements, comparing the average of indicator TLDs located near the site boundary and at 5 miles to the average of all control TLD locations. Control and indicator averages indicate a steady relationship. In 2013, Panasonic UD-814 environmental TLDs replaced Harshaw environmental TLDs that were used since 2001. Benchmarking showed that Panasonic UD-814 TLDs were the industry best environmental TLD with improved precision over the Harshaw TLDs. Along with implementing new environmental

TLDs in 2013, an improved method for calculating control dosimeter dose was implemented to estimate transit dose. A program review found that control dosimeters cannot be used directly to assess the transit dose, since control dosimeters also accrue dose from cosmic radiation while stored in the shielded storage cask/cave. Therefore, additional calculations must be made in order to determine the transit dose component. This transit dose component was determined by processing the control dosimeters, and subtracting out the monitoring period storage dose. Previously, control dosimeters were assumed to be a direct measurement of transit dose which resulted in a non-conservative (lower) result of reported field doses. The field dose with the replacement TLDs is higher than that of the previously used TLDs as the greater precision and accuracy of the replacement TLD along with improved control dosimeter dose provides a more representative response to ambient radiation





#### 4.2 Airborne Gross Beta

Air is continuously sampled by passing it through glass fiber particulate filters. The filters collect airborne particulate radionuclides. Once a week the samples are collected and analyzed for gross beta activity. Results of the weekly gross beta analyses are presented in Table 3-3. A review of the results from control and indicator locations continues to show no significant variation in measured activities (see Figure 4-2 and 4-3). This indicates that any station contribution is

not measurable.

Gross beta activity found during the pre-operational and early operating period of Surry Power Station was higher because of nuclear weapons testing. During that time, nearly 740 nuclear weapons were tested worldwide. In 1985 weapons testing ceased, and with the exception of the Chernobyl accident in 1986, airborne gross beta results have remained steady.





### 4.3 Airborne Radioiodine

Air is also continuously sampled for radioiodines by passing it through charcoal cartridges. Once a week the charcoal cartridge samples are collected and analyzed. The results of the analyses are presented in Table 3-4. All results are below the lower limit of detection. No positive iodine-131 was detected. These results are similar to pre-operational data and the results of samples taken prior to and after the 1986 accident in the Soviet Union at Chernobyl and the Fukushima Daiichi nuclear incident in 2011.

### 4.4 Air Particulate Gamma

The air particulate filters from the weekly gross beta analyses are composited by location and analyzed quarterly by gamma spectroscopy. The results are listed in Table 3-5. The results indicate the presence of naturally occurring potassium-40 and beryllium-7, which is produced by cosmic processes. No man-made radionuclides were identified. These analyses confirm the lack of station effects.



#### *4.5 Cow Milk*

Analysis of milk samples is generally the most sensitive indicator of fission product existence in the terrestrial environment. This, in combination with the fact that consumption of milk is significant, results in this pathway usually being the most critical from the plant release viewpoint. This pathway also shows measurable amounts of nuclear weapons testing fallout. Therefore, this media needs to be evaluated very carefully when trying to determine if there is any station effect.

Results of gamma spectroscopy indicate no other detectable station related radioactivity in the milk samples. In years past, cesium-137 has been detected sporadically. The occurrences were attributed to residual global fallout from past atmospheric weapons testing. Cs-137 was not detected at a level above the LLD in 2013.

At the request of the Commonwealth of Virginia, a quarterly composite sample is prepared from the monthly milk samples from the Colonial Parkway collection station. The composite samples are analyzed for strontium-89 and strontium-90. No strontium was detected in the four composites analyzed. This is the second year since at least 1990 that strontium-90 has not been detected in at least one composite sample. The average Sr-90 concentration for the ten year period of 2002 to 2011 is 1.77 pCi/L. Sr-90 is not a component of the station radiological effluents and is a product of nuclear weapons testing fallout which has been well documented.

#### *4.6 Food Products*

Three samples were collected and analyzed by gamma spectroscopy. The results of the analyses are presented in Table 3-7. As expected, naturally occurring potassium-40 was detected in all samples. The average concentration is consistent with that observed in previous years. Thorium-228 was also detected at typical historical concentrations. No station related radioactivity was detected. Berillium-7 was detected in one sample.

#### *4.7 Well Water*

Well water is not considered to be affected by station operations because there are no discharges made to this pathway. However, Surry Power Station monitors well water quarterly at three indicator locations and analyzes for gamma radiation and for tritium. The results of these analyses are presented in Table 3-8. Consistent with past monitoring, no station related radioactivity was detected. No gamma emitting isotopes were detected during the pre-operational period.

#### ***4.8 River Water***

Samples of the James River water are collected monthly and the results are presented in Table 3-9. All samples are analyzed by gamma spectroscopy. The monthly samples are also composited and analyzed for tritium on a quarterly basis. With the exception of natural products, no other gamma emitters were detected. Tritium was detected in one of eight samples at 1,610 pCi/liter. This concentration represents 5.4% of the 30,000 pCi/liter NRC reporting level concentration. The tritium was detected at the station discharge canal indicator sample location. The water in the discharge canal is further diluted by the river water beyond the discharge structure. No tritium or gamma emitting radionuclides were detected in the control river water samples. Naturally occurring potassium-40, radium-226 and thorium-228 were detected in some samples. No station related radioactivity was detected.


#### ***4.9 Silt***

Silt is sampled to evaluate any buildup of radionuclides in the environment due to the operation of the station. Sampling of this pathway provides a good indication of the dispersion effects of effluents to the river. Buildup of radionuclides in silt could indirectly lead to increasing radioactivity levels in clams, oysters, crabs and fish.

Samples of silt are collected from two locations, one upstream and one downstream of the station. The results of the gamma spectroscopy analyses are presented in Table 3-10. Naturally occurring beryllium-7, potassium-40, radium-226, thorium-228, actinium-228 and thorium-232 were detected. Historically, cobalt-60 has been detected in samples obtained from the indicator location (SD). Cobalt-60 has not been detected since 2003. Trend graphs of cobalt-60 and cesium-137 in silt appear in Figures 4-4 and 4-5.


Cesium-137 was detected, as expected, in both the control and indicator samples. The levels detected indicate a continual decreasing trend seen for over a decade. The detection of cesium-137 in both the control and indicator samples and decreasing levels indicate that the presence of cesium-137 is the result of accumulation and runoff into the river of residual weapons testing fallout. Its global presence has been well documented. During the pre-operational period, cesium-137 was detected in most silt samples with an average concentration as indicated in Figure 4-5. In 2013, cesium-137 was detected with an average indicator location concentration of 142 pCi/kg and an average control location concentration of 206 pCi/kg. These activities continue to represent fallout from nuclear weapons testing. Both indicator and control cesium-137 activities trend

closely as shown in Figure 4-5.



Chickahominy had detectable activity in 1982 and 1984 through 1994. Other years were <MDC, Minimum Detectable Concentration. Station Discharge was <MDC activity 1996 through 1998 and 2004 through 2013.

Figure 4-5: CESIUM-137 IN SILT



#### 4.10 Shoreline Sediment

Shoreline sediment, unlike river silt, may provide a direct dose to humans. Buildup of radionuclides along the shoreline may provide a source of direct exposure for those using the area for commercial and recreational uses. The results are presented in Table 3-11.

The naturally occurring radionuclides potassium-40, radium-226, thorium-228 and thorium-232 were detected at concentrations equivalent to normal background activities. The activities of these radionuclides indicate a steady trend. There were no radionuclides attributable to the operation of the station found in any shoreline sediment samples.

#### 4.11 Fish

The radioactivity measured in fish sampled from the station discharge canal and analyzed by gamma spectroscopy is presented in Table 3-12. These results are the same as those seen over the last decade. No activity was observed in this media except for naturally occurring potassium-40.

#### *4.12 Oysters*

Oysters were collected from three different locations. The results of the oyster analyses are presented in Table 3-13.

There were no gamma emitting radionuclides detected in oysters sampled except for naturally occurring potassium-40. No station related radioactivity has been detected in this media since 1991. The absence of station related radionuclides is attributable to the replacement of steam generators in 1982 and past improvements made to liquid effluent treatment systems.

#### *4.13 Clams*

Clams are analyzed from four different locations. The results of the gamma spectroscopy analyses are presented in Table 3-14. Like oysters, no station related radioactivity was detected. Naturally occurring potassium-40 and thorium-228 were detected.

#### *4.14 Crabs*

A crab sample was collected in June from the station discharge canal and analyzed by gamma spectroscopy. The results of the analysis are presented in Table 3-15. Other than naturally occurring potassium-40, no other gamma emitting radionuclides were detected in the sample. This is consistent with pre-operational data and data collected over the past decade.

## 5. PROGRAM EXCEPTIONS

There were three REMP exceptions for scheduled sampling and analysis during 2013.

1. The Lawne's Creek clam sample station did not produce a sample during the spring shellfish sampling campaign. Finding clams at this station had been increasingly difficult over the past three to five years. Oysters were discovered in the same Lawne's Creek area and a sample of those oysters was obtained. The REMP sampling program has been changed to replace the clam sample with the oysters found in the same Lawne's Creek area.
2. The 4th quarter indicator environmental TLD #25 was missing when TLDs were collected. Therefore, there was no gamma dose evaluation available at this location for the 4th quarter.
3. The 1/8/13 Colonial Parkway (CP) milk sample was not analyzed to the required 15 pCi/Liter LLD for lanthanum-140. The reported LLD was 15.1 pCi/Liter. A software variable that controls the confidence level setting for Minimum Detectable Concentration (MDC) for one particular detector at the TBE laboratory was not set with the appropriate value to meet the 95% confidence level concentration criteria. The variable was set at a default value of 3.29 vice 4.66. Activity and 2 sigma uncertainty results are correct. The TBE laboratory initiated Non-Conformance Report 13-07 to document this issue. A revised analytical report was issued by TBE to document the actual MDC and the MDC variable now appears on the TBE laboratory analytical reports for review and verification by laboratory personnel.

## 6. CONCLUSIONS

The results of the 2013 Radiological Environmental Monitoring Program for Surry Power Station have been presented in previous sections. This section presents conclusions for each pathway.

- **Direct Radiation Exposure Pathway** - Control and indicator location averages continue to indicate a steady relationship and trend over the long term.
- **Airborne Exposure Pathway** - Analysis of charcoal cartridge samples for radioiodines indicated no positive activity was detected. Quarterly gamma isotopic analyses of the composite particulate samples identified only naturally occurring beryllium-7. Air particulate gross beta concentrations at all of the indicator locations for 2013 trend well with the control location.
- **Milk** - Milk samples are an important indicator measuring the effect of radioactive iodine and radionuclides in airborne releases. Cesium-137 and iodine-131 were not detected in any of the thirty-six samples. Naturally occurring potassium-40 was detected at a similar level when compared to the averages of the previous years.

Strontium-90 was not detected in any samples this year. Although Strontium-90 is not a component of station effluents, but rather, a product of nuclear weapons testing fallout, this is only the second year that it was not detected.

- **Food Products** - As expected, naturally occurring potassium-40 was detected in all three samples. In the past, cesium-137 has occasionally been detected in these samples and is attributable to global fallout from past nuclear weapons testing. Cesium-137 was not detected in any of the three samples collected in 2013.
- **Well Water** - Well water samples were analyzed and the analyses indicated that there were no man-made radionuclides present. This trend is consistent throughout the monitoring period. No radioactivity attributable to the operation of the station was identified.
- **River Water** - All river water samples were analyzed for gamma emitting radionuclides. The naturally occurring radionuclides potassium-40, radium-226 and thorium-228 were detected. Tritium was detected in one of eight samples with a concentration of 1.610 pCi/liter. This represents 5.4% of the NRC reporting level concentration. Because river water is not used for drinking water or for crop irrigation, there is a reduced dose consequence to the public from this pathway.

- **Silt** - Cesium-137 was detected in both the control and indicator samples. The presence of cesium-137 is attributable to residual weapons testing fallout; its presence has been well documented. Cobalt-60 has not been detected since 2003.
- **Shoreline Sediment** - Naturally occurring radionuclides were detected at concentrations equivalent to normal background activities. There were no radionuclides attributable to the operation of Surry Power Station found in any sample.

### **Aquatic Biota**

- **Fish** - As expected, naturally occurring potassium-40 was detected. There were no other gamma emitting radionuclides detected in any of the fish samples.
- **Oysters and Clams** - Other than naturally occurring potassium-40 and thorium-228, there were no other gamma emitting radionuclides detected in any of the oyster or clam samples.
- **Crabs** - Naturally occurring potassium-40 was detected. No other gamma emitting radionuclides were detected.



**REFERENCES**

## *References*

1. NUREG-0472, "Radiological Effluent Technical Specifications for PWRs", Draft Rev. 3, March 1982.
2. United States Nuclear Regulatory Commission, Regulatory Guide 1.109, Rev. 1, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10CFR50, Appendix I", October 1977.
3. United States Nuclear Regulatory Commission, Regulatory Guide 4.8, "Environmental Technical Specifications for Nuclear Power Plants", December 1975.
4. United States Nuclear Regulatory Commission Branch Technical Position, "Acceptable Radiological Environmental Monitoring Program", Rev. 1, November 1979.
5. Dominion, Station Administrative Procedure, VPAP-2103S, "Offsite Dose Calculation Manual (Surry)".
6. Virginia Electric and Power Company, Surry Power Station Technical Specifications, Units 1 and 2.
7. HASL-300, Environmental Measurements Laboratory, "EML Procedures Manual," 27<sup>th</sup> Edition, Volume 1, February 1992.
8. NUREG/CR-4007, "Lower Limit of Detection: Definition and Elaboration of a Proposed Position for Radiological Effluent and Environmental Measurements," September 1984.
9. NCRP Report No. 160, "Ionizing Radiation Exposure of the Population of the United States," March 2009.

**APPENDICES**

APPENDIX A: LAND USE CENSUS

**Year 2013**

**LAND USE CENSUS\***

**Surry Power Station, Surry County, Virginia**

January 1 to December 31, 2013

Page 1 of 1

<b>Sector</b>	<b>Direction</b>	<b>Nearest Resident</b>	<b>Nearest Garden**</b>	<b>Nearest Cow</b>	<b>Nearest Goat</b>
A	N	4.1 @ 10°	(a)	(a)	(a)
B	NNE	1.9 @ 32°	(a)	(a)	(a)
C	NE	4.7 @ 35°	(a)	(a)	(a)
D	ENE	(a)	(a)	(a)	(a)
E	E	(a)	(a)	(a)	(a)
F	ESE	(a)	(a)	(a)	(a)
G	SE	2.8 @ 142°	(a)	(a)	(a)
H	SSE	2.7 @ 158°	(a)	(a)	(a)
J	S	1.7 @ 181°	2.0 @ 183°	(a)	(a)
K	SSW	1.9 @ 192°	1.9 @ 192°	4.8 @ 200°	(a)
L	SW	2.3 @ 221°	4.7 @ 228°	(a)	(a)
M	WSW	0.4 @ 244°	3.6 @ 245°	(a)	(a)
N	W	3.1 @ 260°	3.4 @ 260°	(a)	(a)
P	WNW	4.9 @ 283°	(a)	(a)	(a)
Q	NW	4.6 @ 321°	(a)	(a)	(a)
R	NNW	3.8 @ 338°	4.4 @ 334°	3.7 @ 336°	(a)

\* Locations are listed by miles and degrees heading relative to true north from center of Unit #1 Containment.

\*\* Area greater than 50 m<sup>2</sup> and contains broadleaf vegetation.

(a) None

APPENDIX B: SUMMARY OF INTERLABORATORY COMPARISONS

**Year 2013**

## **INTRODUCTION**

This appendix covers the Interlaboratory Comparison Program (ICP) of Teledyne Brown Engineering (TBE). TBE use QA/QC samples provided by Eckert & Ziegler Analytics, Inc., Environmental Resource Associates (ERA) and the Mixed Analyte Performance Evaluation Program (MAPEP) to monitor the quality of analytical processing associated with the REMP. Each provider has a documented Quality Assurance program and the capability to prepare Quality Control materials traceable to the National Institute of Standards and Technology (NIST). The providers supply the samples to TBE, and upon receipt, the laboratories perform the analyses in a normal manner. The results are then reported to the provider for evaluation. The suite of QA/QC samples is designed to provide sample media and radionuclide combinations that are offered by the providers and included in the REMP and typically includes:

- milk for gamma nuclides and low-level iodine-131 analyses,
- milk for Sr-89 and Sr-90 analyses,
- water for gamma nuclides, low-level iodine-131, and gross beta analyses,
- water for tritium, Sr-89, and Sr-90 analyses,
- cartridge for I-131 analyses,
- air filter for gamma nuclide, gross beta, and Sr-90 analyses.

The accuracy of each result reported to Eckert & Ziegler Analytics, Inc. is measured by the ratio of the TBE result to the known value. Accuracy for all other results is based on statistically derived acceptance ranges calculated by the providers. An investigation is undertaken whenever the ratio or reported result fell outside of the acceptance range.

## **RESULTS**

The TBE ICP results are included in the following tables for the first through the fourth quarters of 2013. Three analyses did not meet the acceptance criteria. TBE initiated non-conformance reports (NCRs) to document and address the analyses. The results of the NCRs are as follows.

1. NCR 13-14, MAPEP filter sample 12-RdF29 failed Cs-134. The TBE value of -0.570 Bq/sample was evaluated as a failed false positive test based on MAPAP's evaluation of the result as a significant negative value at 3 standard deviations. The reported value was a calculated forced activity performed by the gamma software because the nuclide was not detected. No follow-on actions were deemed necessary by TBE.
2. NCR 13-15, Eckert & Ziegler Analytics Milk sample E10646 failed Sr-89 and Sr-90. The TBE analyses failed low. TBE determined the cause to be analyst error. Sample reanalysis with a different analyst was performed and

the results were acceptable. The first analyst is on an extended leave of absence and could not be retrained. TBE also determined the error was specific to sample E10646 only. TBE client samples for the associated time period were evaluated and TBE determined no client samples were affected by this failure.



**ECKERT & ZIEGLER ANALYTICS ENVIRONMENTAL RADIOACTIVITY CROSS CHECK PROGRAM**  
**TELEDYNE BROWN ENGINEERING ENVIRONMENTAL SERVICES**  
(PAGE 1 OF 1)

Month/Year	Identification Number	Matrix	Nuclide	Units	Reported Value (a)	Known Value (b)	Ratio (c) TBE/Analytics	Evaluation (d)		
March 2013	E10477	Milk	Sr-89	pCi/L	120	99.7	1.20	A		
			Sr-90	pCi/L	9.21	11.0	0.84	A		
	E10478	Milk	I-131	pCi/L	87.1	100	0.87	A		
			Ce-141	pCi/L	186	187	0.99	A		
			Cr-51	pCi/L	463	472	0.98	A		
			Cs-134	pCi/L	201	214	0.94	A		
			Cs-137	pCi/L	262	266	0.98	A		
			Co-58	pCi/L	200	208	0.96	A		
			Mn-54	pCi/L	215	208	1.03	A		
			Fe-59	pCi/L	266	252	1.06	A		
			Zn-65	pCi/L	311	301	1.03	A		
			Co-60	pCi/L	384	400	0.96	A		
			E10480	Filter	Ce-141	pCi	95.3	95.6	1.00	A
					Cr-51	pCi	264	241	1.10	A
Cs-134	pCi	123			109	1.13	A			
Cs-137	pCi	142			136	1.04	A			
Co-58	pCi	112			106	1.06	A			
Mn-54	pCi	115			106	1.08	A			
Fe-59	pCi	139			129	1.08	A			
Zn-65	pCi	163			153	1.07	A			
E10479	Charcoal	I-131	pCi	90.1	92.6	0.97	A			
June 2013	E10564	Milk	Sr-89	pCi/L	110	95.0	1.16	A		
			Sr-90	pCi/L	15.8	17.0	0.93	A		
	E10545	Milk	I-131	pCi/L	92.6	95.5	0.97	A		
			Ce-141	pCi/L	83.1	90.4	0.92	A		
			Cr-51	pCi/L	253	250	1.01	A		
			Cs-134	pCi/L	118	125	0.94	A		
			Cs-137	pCi/L	143	151	0.95	A		
			Co-58	pCi/L	87.1	94.0	0.93	A		
			Mn-54	pCi/L	171	172	0.99	A		
			Fe-59	pCi/L	125	120	1.04	A		
			Zn-65	pCi/L	220	217	1.01	A		
			Co-60	pCi/L	169	175	0.97	A		

Footnotes are on page 3 of 3.

**ECKERT & ZIEGLER ANALYTICS ENVIRONMENTAL RADIOACTIVITY CROSS CHECK PROGRAM  
TELEDYNE BROWN ENGINEERING ENVIRONMENTAL SERVICES**

(PAGE 2 OF 3)

Month/Year	Identification Number	Matrix	Nuclide	Units	Reported Value (a)	Known Value (b)	Ratio (c) TBE/Analytics	Evaluation (d)
June 2013	E10547	Filter	Ce-141	pCi	56.8	56.7	1.00	A
			Cr-51	pCi	168	157	1.07	A
			Cs-134	pCi	85.2	78.4	1.09	A
			Cs-137	pCi	101	94.6	1.07	A
			Co-58	pCi	62.7	58.9	1.06	A
			Mn-54	pCi	125	108	1.16	A
			Fe-59	pCi	85.7	75.0	1.14	A
			Zn-65	pCi	169	136	1.24	W
			Co-60	pCi	116	110	1.05	A
				E10546	Charcoal	I-131	pCi	86.5
September 2013	E10646	Milk	Sr-89	pCi/L	63.9	96.0	0.67	N (1)
			Sr-90	pCi/L	8.88	13.2	0.67	N (1)
	E10647	Milk	I-131	pCi/L	93.9	98.3	0.96	A
			Ce-141	pCi/L				NA (2)
			Cr-51	pCi/L	272	277	0.98	A
			Cs-134	pCi/L	150	172	0.87	A
			Cs-137	pCi/L	125	131	0.95	A
			Co-58	pCi/L	105	108	0.97	A
			Mn-54	pCi/L	138	139	0.99	A
			Fe-59	pCi/L	125	130	0.96	A
			Zn-65	pCi/L	264	266	0.99	A
			Co-60	pCi/L	187	196	0.95	A
	E10672	Filter	Ce-141	pCi				NA (2)
			Cr-51	pCi	208	223	0.93	A
			Cs-134	pCi	143	139	1.03	A
			Cs-137	pCi	106	105	1.01	A
			Co-58	pCi	97.0	86.5	1.12	A
			Mn-54	pCi	116	112	1.04	A
			Fe-59	pCi	98.6	105	0.94	A
			Zn-65	pCi	219	214	1.02	A
	E10648	Charcoal	I-131	pCi	76.3	71.7	1.06	A
December 2013	E10774	Milk	Sr-89	pCi/L	97.3	93.8	1.04	A
			Sr-90	pCi/L	13.3	12.9	1.03	A

Footnotes are on page 3 of 3.

**ECKERT & ZIEGLER ANALYTICS ENVIRONMENTAL RADIOACTIVITY CROSS CHECK PROGRAM  
TELEDYNE BROWN ENGINEERING ENVIRONMENTAL SERVICES**

(PAGE 3 OF 3)

Month/Year	Identification Number	Matrix	Nuclide	Units	Reported Value (a)	Known Value (b)	Ratio (c) TBE/Analytics	Evaluation (d)
December 2013	E10775	Milk	I-131	pCi/L	89.7	96.1	0.93	A
			Ce-141	pCi/L	99.8	110	0.91	A
			Cr-51	pCi/L	297	297	1.00	A
			Cs-134	pCi/L	129	142	0.91	A
			Cs-137	pCi/L	126	126	1.00	A
			Co-58	pCi/L	116	112	1.04	A
			Mn-54	pCi/L	167	168	0.99	A
			Fe-59	pCi/L	117	110	1.06	A
			Zn-65	pCi/L	757	741	1.02	A
	Co-60	pCi/L	141	147	0.96	A		
	E10777	Filter	Ce-141	pCi	85.1	88.0	0.97	A
			Cr-51	pCi	278	238	1.17	A
			Cs-134	pCi	123	114	1.08	A
			Cs-137	pCi	102	101	1.01	A
			Co-58	pCi	84.4	89.9	0.94	A
			Mn-54	pCi	132	135	0.98	A
			Fe-59	pCi	101	88.3	1.14	A
			Zn-65	pCi	506	595	0.85	A
	E10776	Charcoal	I-131	pCi	84.7	80.5	1.05	A

- (1) Milk, Sr-89/90 - The failure was due to analyst error. No client samples were affected by this failure. NCR 13-15
- (2) The sample was not spiked with Ce-141
- (a) Teledyne Brown Engineering reported result.
- (b) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.
- (c) Ratio of Teledyne Brown Engineering to Analytics results.
- (d) Analytics evaluation based on TBE internal QC limits: A= Acceptable, reported result falls within ratio limits of 0.80-1.20. W=Acceptable with warning, reported result falls within 0.70-0.80 or 1.20-1.30. N = Not Acceptable, reported result falls outside the ratio limits of < 0.70 and > 1.30.

**DOE's MIXED ANALYTE PERFORMANCE EVALUATION PROGRAM (MAPEP)**  
**TELEDYNE BROWN ENGINEERING ENVIRONMENTAL SERVICES**  
(PAGE 1 OF 2)

Month/Year	Identification Number	Media	Nuclide	Units	Reported Value (a)	Known Value (b)	Acceptance Range	Evaluation (c)		
March 2013	13-MaW28	Water	Cs-134	Bq/L	21.0	24.4	17.1 - 31.7	A		
			Cs-137	Bq/L	0.0446		(1)	A		
			Co-57	Bq/L	28.3	30.9	21.6 - 40.2	A		
			Co-60	Bq/L	18.2	19.56	13.69 - 25.43	A		
			H-3	Bq/L	506	507	355 - 659	A		
			Mn-54	Bq/L	25.7	27.4	19.2 - 35.6	A		
			K-40	Bq/L	2.09		(1)	A		
			Sr-90	Bq/L	10.5	10.5	7.4 - 13.7	A		
			Zn-65	Bq/L	29.2	30.4	21.3 - 39.5	A		
	13-GrW28	Water	Gr-A	Bq/L	2.74	2.31	0.69 - 3.93	A		
			Gr-B	Bq/L	15.6	13.0	6.5 - 19.5	A		
			13-RdF28	Filter	Cs-134	Bq/sample	1.73	1.78	1.25 - 2.31	A
					Cs-137	Bq/sample	2.73	2.60	1.82 - 3.38	A
	13-RdF28	Filter	Co-57	Bq/sample	2.38	2.36	1.65 - 3.07	A		
			Co-60	Bq/sample	0.0302		(1)	A		
			Mn-54	Bq/sample	4.36	4.26	2.98 - 5.54	A		
			Sr-90	Bq/sample	1.43	1.49	1.04 - 1.94	A		
			Zn-65	Bq/sample	3.14	3.13	2.19 - 4.07	A		
			13-GrF28	Filter	Gr-A	Bq/sample	0.767	1.20	0.36 - 2.04	A
	Gr-B	Bq/sample			0.871	0.85	0.43 - 1.28	A		
	September 2013	13-MaW29	Water	Cs-134	Bq/L	29.1	30.0	21.0 - 39.0	A	
Cs-137				Bq/L	34.5	31.6	22.1 - 41.1	A		
Co-57				Bq/L	0.0358		(1)	A		
Co-60				Bq/L	24.6	23.58	16.51 - 30.65	A		
H-3				Bq/L	2.45		(1)	A		
Mn-54				Bq/L	0.0337		(1)	A		
K-40				Bq/L	0.193		(1)	A		
Sr-90				Bq/L	9.12	7.22	5.05 - 9.39	W		
Zn-65				Bq/L	38.1	34.6	24.2 - 45.0	A		
13-GrW29		Water	Gr-A	Bq/L	1.13	0.701	0.210 - 1.192	A		
			Gr-B	Bq/L	7.61	5.94	2.97 - 8.91	A		

**DOE's MIXED ANALYTE PERFORMANCE EVALUATION PROGRAM (MAPEP)**  
**TELEDYNE BROWN ENGINEERING ENVIRONMENTAL SERVICES**  
(PAGE 2 OF 2)

Month/Year	Identification Number	Media	Nuclide	Units	Reported Value (a)	Known Value (b)	Acceptance Range	Evaluation (c)
September 2013	13-RdF29	Filter	Cs-134	Bq/sample	-0.570		(1)	N (2)
			Cs-137	Bq/sample	2.85	2.7	1.9 - 3.5	A
			Co-57	Bq/sample	3.30	3.4	2.4 - 4.4	A
			Co-60	Bq/sample	2.41	2.3	1.6 - 3.0	A
			Mn-54	Bq/sample	3.65	3.5	2.5 - 4.6	A
			Sr-90	Bq/sample	1.40	1.81	1.27 - 2.35	W
			Zn-65	Bq/sample	2.90	2.7	1.9 - 3.5	A
	13-GrF29	Filter	Gr-A	Bq/sample	0.872	0.9	0.3 - 1.5	A
			Gr-B	Bq/sample	1.57	1.63	0.82 - 2.45	A

(1) False positive test.

(2) AP, Cs-134 - MAPEP evaluated the -0.570 as a failed false positive test. No client samples were affected by these failures. NCR 13-04

(a) Teledyne Brown Engineering reported result.

(b) The MAPEP known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.

(c) DOE/MAPEP evaluation: A=acceptable, W=acceptable with warning, N=not acceptable.

**ERA ENVIRONMENTAL RADIOACTIVITY CROSS CHECK PROGRAM  
TELEDYNE BROWN ENGINEERING ENVIRONMENTAL SERVICES**

(PAGE 1 OF 1)

Month/Year	Identification Number	Media	Nuclide	Units	Reported Value (a)	Known Value (b)	Acceptance Limits	Evaluation (c)
May 2013	RAD-93	Water	Sr-89	pCi/L	48.3	41.3	31.6 - 48.4	A
			Sr-90	pCi/L	19.3	23.9	17.2 - 28.0	A
			Ba-133	pCi/L	81.9	82.1	69.0 - 90.3	A
			Cs-134	pCi/L	40.9	42.8	34.2 - 47.1	A
			Cs-137	pCi/L	44.0	41.7	37.0 - 48.8	A
			Co-60	pCi/L	61.9	65.9	59.3 - 75.0	A
			Zn-65	pCi/L	202	189	170 - 222	A
			Gr-A	pCi/L	34.2	40.8	21.1 - 51.9	A
			Gr-B	pCi/L	18.0	21.6	13.0 - 29.7	A
			I-131	pCi/L	23.8	23.8	19.7 - 28.3	A
			U-Nat	pCi/L	60.4	61.2	49.8 - 67.9	A
			H-3	pCi/L	3970	4050	3450 - 4460	A
				MRAD-18	Filter	Gr-A	pCi/filter	Lost during processing
November 2013	RAD-95	Water	Sr-89	pCi/L	25.5	21.9	14.4 - 28.2	A
			Sr-90	pCi/L	14.3	18.1	12.8 - 21.5	A
			Ba-133	pCi/L	57.2	54.2	44.7 - 59.9	A
			Cs-134	pCi/L	83.3	86.7	71.1 - 95.4	A
			Cs-137	pCi/L	201	206	185 - 228	A
			Co-60	pCi/L	104	102	91.8 - 114	A
			Zn-65	pCi/L	361	333	300 - 389	A
			Gr-A	pCi/L	29.5	42.8	22.2 - 54.3	A
			Gr-B	pCi/L	30.1	32.2	20.8 - 39.9	A
			I-131	pCi/L	23.1	23.6	19.6 - 28.0	A
			U-Nat	pCi/L	5.53	6.24	47.0 - 7.44	A
			H-3	pCi/L	17650	17700	15500 - 19500	A
				MRAD-19	Filter	Gr-A	pCi/filter	33.0

(a) Teledyne Brown Engineering reported result.

(b) The ERA known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.

(c) ERA evaluation: A=acceptable. Reported result falls within the Warning Limits. NA=not acceptable. Reported result falls outside of the Control Limits. CE=check for Error. Reported result falls within the Control Limits and outside of the Warning Limit.