



Clinton Power Station
8401 Power Road
Clinton, IL 61727

U-604171
April 24, 2014

10CFR50.36a

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Clinton Power Station, Unit 1
Facility Operating License No. NPF-62
NRC Docket No. 50-461

Subject: Clinton Power Station 2013 Annual Radioactive Effluent Release Report

Exelon Generating Company, LLC (Exelon), Clinton Power Station is submitting the 2013 Annual Radioactive Effluent Release Report. This report is submitted in accordance with Technical Specification 5.6.3, "Radioactive Effluent Release Report," and covers the period from January 1, 2013 through December 31, 2013.

There are no commitments contained in this letter.

Questions on this letter may be directed to Mr. Rick Bair, Chemistry Manager, at 217-937-3200.

Respectfully,

A handwritten signature in black ink, appearing to read "B. Keith Taber".

B. Keith Taber
Site Vice President
Clinton Power Station

DRA/blf

Attachment

cc: Regional Administrator – NRC Region III
NRC Senior Resident Inspector - Clinton Power Station
Office of Nuclear Facility Safety – Illinois Emergency Management Agency

JE48
NRR



ExelonSM
Nuclear

01 January 2013 – 31 December 2013

**ANNUAL RADIOACTIVE EFFLUENT RELEASE
REPORT**

CLINTON POWER STATION – DOCKET NUMBER 50-461

Prepared by:

Clinton Power Station

TABLE OF CONTENTS

SECTION	TITLE	PAGE
1	Executive Summary	5
2	Introduction	6
3	Supplemental Information	12
4	Radioactive Effluent Data	17
5	Solid Waste Disposal Information	27
6	Dose Measurements and Assessments	30
7	ODCM Operational Remedial Requirement Reports	41
8	Meteorological Data and Dispersion Estimates	42
9	Changes to Radioactive Waste Treatment Systems	102
10	Corrections to Data Reported in Previous Reports	103

LIST OF TABLES

TABLE NUMBER	TITLE	PAGE
1	Gaseous Effluents – Summation of All Releases	17
	• 1A Air Doses Due to Gaseous Releases	18
	• 1B Doses to a Member of the Public Due to Radioiodines, Tritium and Particulates in Gaseous Releases	18
2	Gaseous Effluents – Nuclides Released	19
3	Radioactive Gaseous Waste LLD Values	20
4	Waterborne Effluents – Summation of All Releases	22
5	Waterborne Effluents – Nuclides Released	23
6	Radioactive Liquid Waste LLD Values	24
7	Solid Waste and Irradiated Fuel Shipments	28
8	Maximum Offsite Doses and Dose Commitments to Members of the Public In Each Sector	31
9	Calculated Doses to Members of the Public During Use of the Road in the Southeast Sector within the CPS Site Boundary	34
10	Calculated Doses to Members of the Public During Use of the Agricultural Acreage in the South-Southwest Sector within the CPS Site Boundary	35
11	Calculated Doses to Members of the Public During Use of Clinton Lake in the Northwest Sector within the CPS Site Boundary	36
12	Calculated Doses to Members of the Public During Use of the Department of Natural Resources Recreation Area in the East-Southeast Sector within the CPS Site Boundary	37
13	Calculated Doses for the Residents in the Southwest Sector within the CPS Site Boundary	38
14	Calculated Doses for the Residents in the West-Southwest Sector within the CPS Site Boundary	39
15	Calculated Doses for the Residents in the South-Southeast Sector within the CPS Site Boundary	40
16	Meteorological Data Availability	43
17	Classification of Atmospheric Stability	44
18	Joint Wind Frequency Distribution by Stability Class	45

LIST OF FIGURES

FIGURE NUMBER	TITLE	PAGE
1	CPS Airborne Effluent Release Points	7
2	CPS Waterborne Effluents Release Pathway	8
3	Effluent Exposure Pathways	11
4	Areas Within the CPS Site Boundary Open to Members of the Public	33

SECTION 1

EXECUTIVE SUMMARY

The Annual Radioactive Effluent Release Report is a detailed description of gaseous and liquid radioactive effluents released from Clinton Power Station [CPS] and the resulting radiation doses for the period of 01 January 2013 through 31 December 2013. This report also includes a detailed meteorological section providing weather history of the surrounding area during this period. This information is used to calculate the offsite dose to our public.

The report also includes a summary of the amounts of radioactive material contained in solid waste that is packaged and shipped to a federally approved disposal / burial facility offsite. Additionally, this report notifies the U.S. Nuclear Regulatory Commission [NRC] staff of changes to CPS's Offsite Dose Calculation Manual [ODCM] and exceptions to the CPS effluent monitoring program that must be reported in accordance with ODCM Remedial Requirements 2.7.1.b and 3.9.2.b.

The Report also includes a summary of events that are to be included per ODCM Remedial Requirements.

The NRC requires that nuclear power facilities be designed, constructed, and operated in such a manner as to maintain radioactive effluent releases to unrestricted areas As Low As Reasonably Achievable [ALARA]. To ensure compliance with this criterion, the NRC has established limitations governing the release of radioactivity in effluents.

During 2013, CPS operations were well within these federally required limits. The maximum annual radiation dose delivered to the inhabitants of the area surrounding CPS - due to radioactivity released from the station - was 2.65E-02 [or 0.027] mrem. The radiation dose to the public in the vicinity of CPS was calculated by using the concentration of radioactive nuclides from each gaseous effluent release coupled with historical weather conditions. The dose from CPS gaseous radioactive effluents was only a small fraction of the limit for the maximum exposed member of the public. There were no liquid effluent releases in 2013. As such, there was no dose received by the public from the liquid radioactive effluent pathway.

SECTION 2

INTRODUCTION

CPS is located in Harp Township, DeWitt County approximately six (6) miles east of the city of Clinton in east-central Illinois. CPS is a ~1,140 megawatt gross electrical power output boiling water reactor. Initial fuel load commenced in September of 1986 with initial criticality of the reactor occurring on 27 February 1987. Commercial operation commenced in April 1987 and the reactor reached 100% power for the first time on 15 September 1987.

CPS releases airborne effluents via two (2) gaseous effluent release points to the environment. They are the Common Station Heating, Ventilating, and Air Conditioning [HVAC] Vent and the Standby Gas Treatment System [SGTS] Vent [see Figure 1]. Each gaseous effluent release point is continuously monitored through a surveillance program of periodic sampling and analysis as specified in the ODCM.

CPS is licensed to release radioactive liquid effluents in a batch mode, however there were no radioactive liquid releases in 2013 at CPS. Each release would have been sampled and analyzed prior to release. Depending upon the amount of activity in a release, liquid effluents would vary from 10 to 300 gallons per minute [GPM]. This volume is then further combined with both Plant Service Water flow [a minimum of approximately 5,000 GPM] along with Plant Circulating Water flow [0 to 567,000 GPM] in the seal well, just prior to entering the 3.4 mile discharge flume into Lake Clinton [see Figure 2].


Processing and Monitoring

CPS strictly controls effluents to ensure radioactivity released to the environment is maintained ALARA and does not exceed federal release limit criteria. Effluent controls include the operation of radiation monitoring systems within the plant as well as an offsite environmental analysis program. In-plant radiation monitoring systems are used to provide a continuous indication of radioactivity in effluent streams. Some are also used to collect particulate and radioiodine samples. Radioactive effluent related samples are analyzed in a controlled laboratory environment to identify the specific concentration of those radionuclides being released. Sampling and analysis provides for a more sensitive and precise method of determining effluent composition to complement the information provided by real-time radiation monitoring instruments.

Beyond the plant itself, a Radiological Environmental Monitoring Program [REMP] is maintained in accordance with Federal Regulations. The purpose of the REMP program is to assess the radiological impact on the environment due to the operation of CPS. Implicit in this charter is the license requirement to trend and assess radiation exposure rates and radioactivity concentrations that may contribute to dose to the public. The program consists of two phases; pre-operational and operational. During the pre-operational phase of the program, the baseline for the local radiation environment was established. The operational phase of the program includes the objective of making confirmatory measurements to verify that the in-plant controls for the release of radioactive material are functioning as designed. Assessment of the operational impact of CPS on the environment is based on data collected since initial criticality of the reactor.

Figure 1

CPS AIRBORNE EFFLUENT RELEASE POINTS




	<u>HVAC Exhaust Vent</u>	<u>SGTS Exhaust Vent</u>
Release Point Height (feet)	200	200
Building Height (feet)	190	190
Release Point Geometry	Duct	Pipe
Release Point Area (ft ²)	120	2
Release Point Diameter (feet)	12*	1
Annual Average Flow Rate (ft ³ /sec)	3452	75
Vertical Exit Velocity (feet/sec)	29	38

* Effective $2(A/\pi)^2$ diameter

Figure 2

CPS WATERBORNE EFFLUENTS RELEASE PATHWAY



Exposure Pathways

A radiological exposure pathway is the vehicle by which the public may become exposed to radioactivity released from nuclear facilities. The major pathways of concern are those that could cause the highest calculated radiation dose. These pathways are determined from the type and amount of radioactivity released, the environmental transport mechanism, and how the plant environs are used (i.e., residence, gardens, etc.). The environmental transport mechanism includes the historical meteorological characteristics of the area that are defined by wind speed and wind direction. This information is used to evaluate how the radionuclides will be distributed within the surrounding area. The most important factor in evaluating the exposure pathway is the use of the environment by the public living around CPS. Factors such as location of homes in the area, use of cattle for milk, and the growing of gardens for vegetable consumption are important considerations when evaluating exposure pathways. Figure 3 illustrates the effluent exposure pathways that were considered.

The radioactive gaseous effluent exposure pathways include direct radiation, deposition on plants and soil, and inhalation by animals and humans. The radioactive liquid effluent exposure pathways include fish consumption and direct exposure from Clinton Lake.

Dose Assessment

Whole body radiation involves the exposure of all organs in the human body to ionizing radiation. Most naturally occurring background radiation exposures consist of whole body exposure although specific organs can receive radiation exposure from distinct radionuclides. These radionuclides enter the body through inhalation and ingestion and seek different organs depending on the nuclide. For example, radioactive iodine selectively concentrates in the thyroid, radioactive cesium collects in muscle and liver tissue, and radioactive strontium in mineralized bone.

The total dose to organs from a given radionuclide also depends on the amount of activity in the organ and the amount of time that the radionuclide remains in the body. Some radionuclides remain for very short periods of time due to their rapid radioactive decay and / or elimination rate from the body, while others may remain longer.

Radiation dose to the public in the area surrounding CPS is calculated for each release using historical weather conditions coupled with the concentrations of radioactive material present. The dose is calculated for all sixteen geographical sectors surrounding CPS and includes the location of the nearest residents, vegetable gardens producing broad leaf vegetables and dairy animals in all sectors. The calculated dose also uses the scientific concept of a "maximum exposed individual" and "standard man", and the maximum use factors for the environment, such as how much milk an average person consumes and how much air a person breathes in a year.

Section 6 contains more detailed information on dose to the public.

Gaseous Effluents

Gaseous effluent radioactivity released from CPS is classified into two (2) categories. The first category is noble gases. The second category consists of I-131, I-133, H-3, C-14 and all radionuclides in particulate form with radioactive half-lives greater than eight (8) days. Noble gases - such as xenon and krypton - are biologically and chemically non-reactive. As such, these radionuclides - specifically Kr-85m, Xe-133 and Xe-135 - are the major contributors to external doses. Halogens I-131 and I-133, H-3, C-14 and radionuclides in particulate form with radioactive half-lives greater than eight (8) days are the major contributors to internal doses.

Liquid Effluents


Liquid effluents may originate from two (2) sources at CPS. The first is effluent from the Radioactive Waste Treatment System. This water is demineralized prior to release. Samples are taken after the tank has been allowed to adequately recirculate. The second is from heat exchanger leaks found in closed cooling water systems that service radioactively contaminated systems. This would be considered an abnormal release. As a matter of station management commitment, CPS strives to be a zero (0) radioactive liquid release plant. The last liquid release occurred in September of 1992.

Solid Waste Shipments

To reduce the radiation exposure to personnel and maintain the federally required ALARA concept, the NRC and the Department of Transportation [DOT] have established limits on the types of radioactive waste and the amount of radioactivity that may be packaged and shipped offsite for burial or disposal. To ensure that CPS is complying with these regulations, the types of waste and the radioactivity present are reported to the NRC.

FIGURE 3

EFFLUENT EXPOSURE PATHWAYS



SECTION 3

SUPPLEMENTAL INFORMATION

I. REGULATORY LIMITS

The NRC requires nuclear power facilities to be designed, constructed and operated in such a way that the radioactivity in effluent releases to unrestricted areas are kept ALARA. To ensure these criteria are met, each license authorizing nuclear reactor operation includes the Offsite Dose Calculation Manual [ODCM] governing the release of radioactive effluents. The ODCM designates the limits for release of effluents, as well as the limits for doses to the general public from the release of radioactive liquids and gases. These limits are taken from Title 10 of the Code of Federal Regulations, Part 50, Appendix I (10CFR50 Appendix I), Title 10 of the Code of Federal Regulations, Part 20.1301 (10CFR20.1301) and Section 5.5.1 of our Station's Technical Specifications. Maintaining effluent releases within these operating limitations demonstrates compliance with ALARA principles. These limits are just a fraction of the dose limits established by the Environmental Protection Agency [EPA] found within Environmental Dose Standard Title 40, Code of Federal Regulations, Part 190 [40CFR190]. The EPA has established dose limits for members of the public in the vicinity of a nuclear power plant. These dose limits are:

- Less than or equal to 25 mrem per year to the total body.
- Less than or equal to 75 mrem per year to the thyroid.
- Less than or equal to 25 mrem per year to any other organ.

Specific limit information is given below.

A. Gaseous Effluents

1. The maximum permissible concentrations for gaseous effluents shall not exceed the values provided within Section 5.5.4.g of Station Technical Specifications. To ensure these concentrations are not exceeded, dose rates due to radioactive materials released in gaseous effluents from the site to areas at and beyond the site area boundary shall be limited to the following:
 - a. Noble gases
 - Less than or equal to 500 mrem/year to the total body.
 - Less than or equal to 3,000 mrem/year to the skin.
 - b. I-131, I-133, H-3, C-14, and all radionuclides in particulate form with radioactive half-lives greater than eight (8) days:
 - Less than or equal to 1,500 mrem/year to any organ.

2. In accordance with Title 10 of the Code of Federal Regulations, Part 50, Appendix I, (10CFR50 Appendix I) air dose due to noble gases released in gaseous effluents to areas at and beyond the site boundary shall be limited to the following:

a. Less than or equal to 5 mrad for gamma radiation and less than or equal to 10 mrad for beta radiation during any calendar quarter.

b. Less than or equal to 10 mrad for gamma radiation and less than or equal to 20 mrad for beta radiation during any calendar year.

3. In accordance with Title 10 of the Code of Federal Regulations, Part 50, Appendix I, (10CFR50 Appendix I), dose to a member of the public (from I-131, I-133, H-3, C-14, and all radionuclides in particulate form with radioactive half-lives greater than eight (8) days) in gaseous effluents released to areas at and beyond the site boundary shall be limited to the following values:

a. Less than or equal to 7.5 mrem to any organ, during any calendar quarter.

b. Less than or equal to 15 mrem to any organ, during any calendar year.

B. Liquid Effluents

1. The concentration of radioactive material released in liquid effluents to unrestricted areas shall be limited to the values provided within Section 5.5.4.b of Station Technical Specifications for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to 2.0E-04 $\mu\text{Ci/ml}$ total activity.

2. The dose or dose commitment to a member of the public from radioactive materials in liquid effluents released to unrestricted areas shall be limited to:

a. Less than or equal to 1.5 mrem to the total body and less than or equal to 5 mrem to any organ during any calendar quarter.

b. Less than or equal to 3 mrem to the total body and less than or equal to 10 mrem to any organ during any calendar year.

II. AVERAGE ENERGY

The CPS ODCM limits the dose equivalent rates due to the release of fission and activation gases to less than or equal to 500 mrem per year to the total body and less than or equal to 3,000 mrem per year to the skin. These limits are based on dose calculations using actual isotopic concentrations from our effluent release streams and not based upon the gross count rate from our monitoring systems. Therefore, the average beta and gamma energies [E] for gaseous effluents as described in Regulatory Guide 1.21, "Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants", are not applicable.

III. MEASUREMENT AND APPROXIMATIONS OF TOTAL RADIOACTIVITY

A. Fission and Activation Gases

Gas samples are collected weekly and are counted on a high purity germanium detector (HPGe) for principal gamma emitters. The HVAC and SGTS release points are continuously monitored and the average release flow rates for each release point are used to calculate the total activity released during a given time period.

B. Iodines

Iodine is continuously collected on a silver zeolite cartridge filter via an isokinetic sampling assembly from each release point. Filters are normally exchanged once per week and then analyzed on an HPGe system. The average flow rates for each release point are averaged over the duration of the sampling period and these results - along with specific isotopic concentrations - are then used to determine the total activity released during the time period in question.

C. Particulates

Particulates are continuously collected on a filter paper via an isokinetic sampling assembly on each release point. Filters are normally exchanged once per week and then analyzed on an HPGe system. The average flow rates for each release point are averaged over the duration of the sampling period and these results - along with specific isotopic concentrations - are then used to determine the total activity released during the time period in question.

D. Tritium

Tritium is collected by passing a known volume of the sample stream through a gas washer containing a known quantity of demineralized water. The collected samples are distilled and analyzed by liquid scintillation. The tritium released was calculated for each release point from the measured tritium concentration, the volume of the sample, the tritium collection efficiency, and the respective stack exhaust flow rates.

E. Gross Alpha

Gross alpha is analyzed routinely for the gaseous effluent pathway and is analyzed for when liquid effluents exist. Weekly gaseous particulate media is composited for offsite vendor analysis. Gross alpha activity greater than vendor LLD values are assigned to the applicable timeframe and gaseous volume released.

F. Carbon-14

Carbon-14 release values were estimated using the methodology included in the Electric Power Research Institute (EPRI) Technical Report 1021106, using the 2013 Clinton Power Station specific parameters of normalized Carbon-14 production rate of 5.049 Ci/GWt-yr, a gaseous release fraction of 0.99, a Carbon-14 carbon dioxide fraction of 0.95, a reactor power rating of 3473 MWt, and equivalent full power operation of 312.12 days.

G. Liquid Effluents

Each tank of liquid radwaste is recirculated for at least two (2) tank volumes, sampled, and analyzed for principal gamma emitters prior to release. Each sample tank is recirculated for a sufficient amount of time prior to sampling, ensuring that a representative sample is obtained. Samples are then analyzed on an HPGe system and liquid release permits are generated based upon the values obtained from the isotopic analysis and the most recent values for H-3, gross alpha, Fe-55, Sr-89 and Sr-90. An aliquot based on release volume is saved and added to composite containers. The concentrations of composited isotopes and the volumes of the releases associated with these composites establish the proportional relationships that are then utilized for calculating the total activity released for these isotopes.

H. Description of Error Estimates

Estimates of measurement and analytical error for gaseous and liquid effluents are calculated as follows:

$$E_T = \sqrt{[(E_1)^2 + (E_2)^2 + \dots + (E_n)^2]}$$

where: E_T = total percent error, and
 $E_1 \dots E_N$ = percent error due to calibration standards, laboratory analysis, instruments, sample flow, etc.

IV. ABNORMAL RELEASES

A. Liquid

1. Number of Releases 0
2. Total Activity (Ci) Released 0

B. Gaseous

1. Number of Releases 0
2. Total Activity (Ci) Released 0

V. ODCM Revisions

There were no changes to the Offsite Dose Calculation Manual in 2013.

SECTION 4

RADIOACTIVE EFFLUENT DATA

TABLE 1
GASEOUS EFFLUENTS - Summation Of All Releases
 Data Period: 01 January 2013 – 31 December 2013
 Continuous Mixed Mode

Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Est. Total Error, %
-------	--------------	--------------	--------------	--------------	---------------------------

A. Fission & Activation Gases

1. Total Release	Ci	2.01E+00	2.69E+00	2.87E+00	0.00E+00	30
2. Average release rate for period	µCi/sec	2.58E-01	3.42E-01	3.61E-01	0.00E+00	
3. Percent of ODCM Limit	%	*	*	*	*	

B. Iodines

1. Total Iodine-131	Ci	7.16E-06	0.00E+00	0.00E+00	9.18E-06	31
2. Average release rate for period	µCi/sec	9.21E-07	0.00E+00	0.00E+00	1.16E-06	
3. Percent of ODCM Limit	%	*	*	*	*	

C. Particulates

1. Particulates with half-lives >8 days	Ci	1.63E-05	1.43E-05	0.00E+00	8.11E-05	24
2. Average release rate for period	µCi/sec	2.09E-06	1.81E-06	0.00E+00	1.02E-05	
3. Percent of ODCM Limit	%	*	*	*	*	
4. Gross alpha radioactivity	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00	

D. Tritium

1. Total Release	Ci	7.13E+00	6.34E+00	8.05E+00	4.99E+00	21
2. Average release rate for period	µCi/sec	9.16E-01	8.06E-01	1.01E+00	6.28E-01	
3. Percent of ODCM Limit	%	*	*	*	*	

E. Carbon-14

1. Total Release	Ci	4.01E+00	4.05E+00	4.27E+00	2.66E+00	
2. Average release Rate for period	µCi/sec	5.27E-01	5.26E-01	5.48E-01	3.42E-01	

* Applicable limits are expressed in terms of dose. See Tables 1A and 1B of this report.

TABLE 1A

Air Doses Due to Gaseous Releases

Doses per Quarter

Type of Radiation	ODCM Limit	1 st Quarter	% of Limit	2 nd Quarter	% of Limit	3 rd Quarter	% of Limit	4 th Quarter	% of Limit
Gamma	5 mrad	9.28E-05	1.86E-03	1.25E-04	2.49E-03	1.33E-04	2.66E-03	0.00E+00	0.00E+00
Beta	10 mrad	3.27E-05	3.27E-04	4.39E-05	4.39E-04	4.69E-05	4.69E-04	0.00E+00	0.00E+00

Doses per Year

Type of Radiation	ODCM Limit	Year	% of Limit
Gamma	10 mrad	3.50E-04	3.50E-3
Beta	20 mrad	1.24E-04	6.18E-04

TABLE 1B

Doses to a Member of the Public Due to Radioiodines, Tritium, Carbon-14, and Particulates in Gaseous Releases

Doses per Quarter

Type of Organ	ODCM Limit	Quarter 1	% of Limit	Quarter 2	% of Limit	Quarter 3	% of Limit	Quarter 4	% of Limit
Bone	7.5 mrem	7.09E-03	9.45E-02	7.17E-03	9.56E-02	7.54E-03	1.01E-01	4.71E-03	6.28E-02
Liver	7.5 mrem	1.18E-04	1.57E-03	1.04E-04	1.39E-03	1.32E-04	1.77E-03	8.30E-05	1.11E-03
TBody	7.5 mrem	1.53E-03	2.04E-02	1.54E-03	2.05E-02	1.64E-03	2.19E-02	1.04E-03	1.39E-02
Thyroid	7.5 mrem	1.42E-04	1.89E-03	1.04E-04	1.39E-03	1.33E-04	1.77E-03	1.13E-04	1.51E-03
Kidney	7.5 mrem	1.18E-04	1.57E-03	1.04E-04	1.39E-03	1.33E-04	1.77E-03	8.26E-05	1.10E-03
Lung	7.5 mrem	1.17E-04	1.57E-03	1.04E-04	1.39E-03	1.33E-04	1.77E-03	8.26E-05	1.10E-03
GI LLI	7.5 mrem	1.19E-04	1.58E-03	1.06E-04	1.42E-03	1.33E-04	1.77E-03	8.76E-05	1.17E-03

Doses per Year

Type of Organ	ODCM Limit	Year	% of Limit
Bone	15 mrem	2.65E-02	1.77E-01
Liver	15 mrem	4.37E-04	2.92E-03
TBody	15 mrem	5.75E-03	3.83E-02
Thyroid	15 mrem	4.92E-04	3.28E-03
Kidney	15 mrem	4.37E-04	2.91E-03
Lung	15 mrem	4.37E-04	2.91E-03
GI LLI	15 mrem	4.45E-04	2.97E-03

All dose calculations were performed using the methodology contained in the CPS ODCM, with the exception of dose due to C-14, which was calculated using methodology included in the EPRI Technical Report 1021106. The doses were determined using the 2013 critical receptor. The critical receptor was an adult in the North sector at 1.50 km.

TABLE 2

CLINTON POWER STATION
GASEOUS EFFLUENTS - Nuclides Released
YEAR: 2013

Mixed Mode Release	X
Elevated Release	
Ground-Level Release	

Continuous Mode	X
Batch Mode	

	Units	Quarter 1 ^[2]	Quarter 2 ^[2]	Quarter 3 ^[2]	Quarter 4 ^[2]
A. Fission Gases ^[1]					
Ar-41	Ci	2.01E+00	2.69E+00	2.87E+00	<LLD
Kr-87	Ci	<LLD	<LLD	<LLD	<LLD
Kr-88	Ci	<LLD	<LLD	<LLD	<LLD
Xe-133	Ci	<LLD	<LLD	<LLD	<LLD
Xe-133m	Ci	<LLD	<LLD	<LLD	<LLD
Xe-135	Ci	<LLD	<LLD	<LLD	<LLD
Xe-138	Ci	<LLD	<LLD	<LLD	<LLD
Total for Period	Ci	2.01E+00	2.69E+00	2.87E+00	<LLD
B. Iodines ^[1]					
I-131	Ci	7.16E-06	<LLD	<LLD	9.18E-06
I-133	Ci	1.47E-05	<LLD	<LLD	<LLD
I-135	Ci	<LLD	<LLD	<LLD	<LLD
Total for Period	Ci	2.19E-5	<LLD	<LLD	9.18E-06
C. Particulates ^[1]					
Cr-51	Ci	<LLD	<LLD	<LLD	4.92E-05
Mn-54	Ci	1.62E-05	<LLD	<LLD	2.14E-05
Co-58	Ci	<LLD	<LLD	<LLD	<LLD
Fe-59	Ci	<LLD	<LLD	<LLD	<LLD
Co-60	Ci	<LLD	<LLD	<LLD	1.05E-05
Zn-65	Ci	<LLD	<LLD	<LLD	<LLD
Sr-89	Ci	<LLD	1.43E-05	<LLD	<LLD
Sr-90	Ci	<LLD	<LLD	<LLD	<LLD
Mo-99	Ci	<LLD	<LLD	<LLD	<LLD
Cs-134	Ci	<LLD	<LLD	<LLD	<LLD
Cs-137	Ci	<LLD	<LLD	<LLD	<LLD
Ce-141	Ci	<LLD	<LLD	<LLD	<LLD
Ce-144	Ci	<LLD	<LLD	<LLD	<LLD
Gross Alpha	Ci	<LLD	<LLD	<LLD	<LLD
Total for Period	Ci	1.62E-05	1.43E-05	<LLD	8.11E-05
D. Tritium ^[1]					
Total for Period	Ci	7.12E+00	6.34E+00	8.05E+00	4.99E+00
E. Carbon-14 ^[1]					
Total for Period	Ci	4.01E+00	4.05E+00	4.27E+00	2.66E+00

^[1] Ten (10) times the values found in 10CFR20 Appendix B, Table 2, Column 1 are used for all Effluent Concentration Limit [ECL] calculations. For dissolved and entrained noble gases, the concentration is limited to 2.00E-04 µCi/cc total activity.

^[2] The lower the value of the actual sample activity - with respect to background activity - the greater the counting error. Proportionally, large errors are reported for the various components of CPS gaseous effluents because of their consistent low sample activity.

ODCM required LLD values are listed in Table 3. All analyses met the required LLD's.

TABLE 3

RADIOACTIVE GASEOUS WASTE LLD VALUES

TYPE OF ACTIVITY ANALYSIS	ODCM Required Lower Limit of Detection (LLD) ^a (μCi/cc)
Principal Gamma Emitters, [Noble Gases] ^{b,c}	≤1.00E-04
H-3 ^c	≤1.00E-06
I-131 ^d	≤1.00E-12
I-133 ^d	≤1.00E-10
Principal Gamma Emitters, [Particulates] ^{b,e}	≤1.00E-11
Sr-89, Sr-90 ^f	≤1.00E-11
Gross Alpha ^f	≤1.00E-11

Table 3 Notations

^aThe Lower Limit of Detection (LLD) as defined for purposes of these specifications, as an "a priori" determination of the smallest concentration of radioactive material in a sample that will yield a net count - above system background - that will be detected with a 95% probability and with a low (5%) probability of incorrectly concluding that a blank observation represents a "real" signal.

For a particular measurement system, which may include radiochemical separation:

$$LLD = \frac{4.66 \cdot s_b}{E \cdot V \cdot 2.22 \times 10^6 \cdot Y \cdot e^{-\lambda \Delta t}}$$

Table 3 Notations (continued)

Where:

LLD is the "a priori" lower limit of detection as defined above, as μCi per unit mass or volume,

s_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate, in counts per minute (cpm),

E is the counting efficiency, in counts per disintegration,

V is the sample size in units of mass or volume,

$2.22\text{E}+06$ is the number of disintegrations per minute (dpm) per microcurie,

Y is the fractional radiochemical yield, when applicable,

λ is the radioactive decay constant for the particular radionuclide (sec^{-1}) and

Δt for plant effluents is the elapsed time between the midpoint of sample collection and the time of counting (sec).

Typical values of E, V, Y, and Δt should be used in the calculation.

The LLD is defined as an *a priori* (before the fact) limit representing the capability of a measurement system and not as an *a posteriori* (after the fact) limit for a particular measurement.

^bThe principal gamma emitters for which the LLD specification applies include the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135, and Xe-138 in noble gas releases and Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, I-131, Cs-134, Cs-137, Ce-141, and Ce-144 in iodine and particulate releases. This list does not mean that only these nuclides are to be considered. Other gamma peaks that are identifiable - together with those of the above nuclides - shall also be analyzed and reported in the Radioactive Effluent Release Report.

^cWeekly grab sample and analysis

^dContinuous charcoal sample analyzed weekly

^eContinuous particulate sample analyzed weekly

^fComposite particulate sample analyzed monthly

TABLE 4

WATERBORNE EFFLUENTS - Summation Of All Releases
 Data Period: 01 January 2013 through 31 December 2013

There were zero (0) liquid radwaste releases from CPS in 2013.

	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Est. Total Error, %
A. Fission & Activation Products						
1. Total Release	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00	N/A
2. Average diluted concentration during period	µCi/ml	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
3. Percent of ODCM Limit	%	N/A	N/A	N/A	N/A	
B. Tritium						
1. Total Release	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00	N/A
2. Average diluted concentration during period	µCi/ml	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
3. Percent of ODCM Limit	%	N/A	N/A	N/A	N/A	
C. Dissolved and Entrained Gases						
1. Total Release	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00	N/A
2. Average diluted concentration during period	µCi/ml	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
3. Percent of ODCM Limit	%	N/A	N/A	N/A	N/A	
D. Gross Alpha Radioactivity						
Gross alpha radioactivity	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00	N/A
E. Volume of Waste Released (prior to Dilution)						
	Liters	0.00E+00	0.00E+00	0.00E+00	0.00E+00	N/A
F. Volume of dilution water used during period						
	Liters	0.00E+00	0.00E+00	0.00E+00	0.00E+00	N/A

TABLE 5

WATERBORNE EFFLUENTS - Nuclides Released ^[1]
Data Period: 01 January 2013 – 31 December 2013
All Modes

There were zero (0) liquid radwaste releases from CPS in 2013.

Continuous Mode		Batch Mode	X
-----------------	--	------------	---

Nuclide	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4
---------	-------	-----------	-----------	-----------	-----------

A. Tritium

H-3	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
-----	----	----------	----------	----------	----------

B. Fission and Activation Products

Sr-89	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Sr-90	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-134	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-137	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-131	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-58	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Co-60	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Fe-59	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zn-65	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mn-54	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cr-51	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Zr/Nb-95	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mo-99	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Tc-99m	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Ba/La-140	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Ce-141	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Ce-144	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Total	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

C. Dissolved and Entrained Noble Gases

Xe-133	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Xe-135	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Total	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

[1] A value corresponding to ten times the values found in 10CFR20 Appendix B, Table 2, Column 2 are used for all Effluent Concentration Limit (ECL) calculations. For dissolved and entrained noble gases, the concentration is limited to 2.00E-04 µCi/ml total activity.

TABLE 6

RADIOACTIVE LIQUID WASTE LLD VALUES

TYPE OF ACTIVITY ANALYSIS	ODCM Required Lower Limit of Detection (LLD) ^a (μCi/ml)
Principal Gamma Emitters ^b	≤5.00E-07
I-131	≤1.00E-06
Dissolved and Entrained Gases (Gamma Emitters) ^c	≤1.00E-05
H-3	≤1.00E-05
Gross Alpha	≤1.00E-07
Sr-89, Sr-90	≤5.00E-08
Fe-55	≤1.00E-06

Table 6 Notations

^aThe Lower Limit of Detection (LLD) as defined for purposes of these specifications, as an "a priori" determination, of the smallest concentration of radioactive material in a sample that will yield a net count - above system background - that will be detected with a 95% probability and with only a 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system, which may include radiochemical separation:

$$LLD = \frac{4.66 \cdot s_b}{E \cdot V \cdot 2.22 \times 10^6 \cdot Y \cdot e^{-\lambda \Delta t}}$$

Where:

LLD is the "a priori" lower limit of detection as defined above, as μCi per unit mass or volume,

s_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate, in counts per minute (cpm),

Table 6 Notations (continued)

E is the counting efficiency, as counts per disintegration,

V is the sample size in units of mass or volume,

$2.22\text{E}+06$ is the number of disintegrations per minute (dpm) per microcurie,

Y is the fractional radiochemical yield, when applicable,

λ is the radioactive decay constant for the particular radionuclide (sec^{-1}) and

Δ_t for plant effluents is the elapsed time between the midpoint of sample collection and the time of counting (sec).

Typical values of E, V, Y, and λt should be used in the calculation.

The LLD is defined as an *a priori* (before the fact) limit representing the capability of a measurement system and not as an *a posteriori* (after the fact, MDA) limit for a particular measurement.

^bThe principal gamma emitters for which the LLD requirement applies include the following radionuclides: Mn^{54} , Fe^{59} , Co^{58} , Co^{60} , Zn^{65} , Mo^{99} , Cs^{134} , Cs^{137} , Ce^{141} , and Ce^{144} shall also be measured, but with an LLD of $5.0\text{E}-06$. This list does not mean that only these nuclides are detected and reported. Other gamma peaks that are measurable - together with those of the above nuclides - shall also be analyzed and reported in the Radioactive Effluent Release Report.

^cDissolved and entrained gases are: Xe^{133} , Xe^{135} , Xe^{138} , $\text{Kr}^{85\text{m}}$, Kr^{87} and Kr^{88} .

BATCH RELEASES

There were zero (0) liquid radwaste releases from CPS in 2013.

A. Batch Liquid Releases: 2013

1. Number of batch releases: 0
2. Total time period for batch releases: N/A
3. Maximum time period for batch release: N/A
4. Average time period for batch release: N/A
5. Minimum time period for batch release: N/A
6. Average stream flow during periods of release: N/A
7. Total waste volume: N/A
8. Total dilution volume: N/A

B. Batch Gaseous Releases: 2013

1. Number of batch releases: 0
2. Total time period for batch releases: N/A
3. Maximum time period for batch release: N/A
4. Average time period for batch release: N/A
5. Minimum time period for batch release: N/A

SECTION 5

SOLID WASTE DISPOSAL INFORMATION

During this reporting period – 01 January 2013 through 31 December 2013 - there were Seventeen (17) radioactive waste shipments and zero (0) irradiated fuel shipments from CPS. In addition, the CPS ODCM requires reporting of the following information for solid waste shipped offsite during the above reporting period:

1. Container volume: Class A Waste: **6.66E+02** m³ / Class B Waste: **0.0** m³ / Class C Waste: **0.0** m³

This total includes Dry Active Waste (DAW), resins, filters, evaporator bottoms, waste sludge.

2. Total curie quantity: Class A Waste was **2.61E+02** curies and Class B Waste was **0.0** curies (determined by dose-to-curie and sample concentration methodology estimates) and Class C Waste was **0.0** curies in 2013.
3. Principal radionuclides: See A.2 for listing of measured radionuclides.
4. Source of waste and processing employed: Dry Active Waste (DAW), resins, filters, evaporator bottoms, waste sludge
5. Type of container: Type A and Strong Tight Container.
6. Solidification agent or absorbent: None.

Table 7

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

A. Solid Waste Shipped Offsite for Burial or Disposal: [**NOT** irradiated fuel]

1. Types of Waste

Types of Waste	Total Quantity (m ³)	Total Activity (Ci)	Period	Est. Total Error, %
a. Spent resins, filter sludges, evaporator bottoms, etc.	4.75E+01	2.61E+02	Jan-Dec 2013	25
b. Dry compressible waste, contaminated equip, etc.	6.19E+02	4.56E-01	Jan-Dec 2013	25
c. Irradiated components, control rods, etc.	0.00E+00	0.00E+00	Jan-Dec 2013	25
d. Other	0.00E+00	0.00E+00	Jan-Dec 2013	25

2. Estimate of major nuclide composition (by type of waste)

Type of Waste	Major Nuclide Composition	%
a. Spent resins, filter sludges, evaporator bottoms, etc.	C-14	0.96
	Mn-54	3.78
	Fe-55	83.69
	Co-60	10.07
	Ni-63	0.58
	Zn-65	0.45
	Other	0.47
	b. Dry compressible waste, contaminated equip, etc.	Mn-54
Fe-55		25.74
Co-60		28.42
Ni-63		0.43
Zn-65		1.03
Other		0.43
c. Irradiated components, control rods, etc.	N/A	N/A
d. Other	N/A	N/A

Table 7

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS [continued]

3. Solid Waste Disposition

January - June 2013

Number of Shipments	Mode of Transportation	Destination
5	Hittman Transport	Barnwell Processing Facility
1	Hittman Transport	Duratek/Gallaher Road Facility
10	Hittman Transport	Energy Solutions – Bear Creek
1	Hittman Transport	Energy Solutions LLC – Clive Disposal Facility

B. Irradiated Fuel Shipments (Disposition)

Number of Shipments	Mode of Transportation	Destination
0	N/A	N/A

C. Changes to the Process Control Program

No changes were made to the Process Control Program during 2013.

SECTION 6

DOSE MEASUREMENTS AND ASSESSMENTS

This section of the Annual Effluent Release Report provides the dose received by receptors around CPS from gaseous and liquid effluents. The dose to the receptor that would have received the highest dose in each sector (defined as the Critical Receptor for that sector) is listed within this report. This section also provides the dose to individuals who were inside the Site Boundary. This section also summarizes CPS's compliance with the requirements found within 40CFR190.

The 2013 maximum expected annual dose from Carbon-14 released from CPS has been calculated using the methodology included in the EPRI Technical Report 1021106 using the maximum gross thermal capacity maintained for 312.1 days of equivalent full power operation.

The assumptions used in determining dose values are as follows:

- All receptors within a five (5) mile radius are included in the Annual Land Use Census. This Annual Census determines what dose pathways are present as well as the distance of each receptor from the site.
- The annual average meteorological data for 2013 was used in conjunction with the Annual Land Use Census to determine the dose to each receptor within five (5) miles.
- The doses for each receptor from each sector were determined using methodologies given in the ODCM, with the exception of dose due to C-14, which was calculated using methodology included in the EPRI Technical Report 1021106.
- The occupancy factor was taken into consideration by calculating the dose to individuals using areas inside the Site Boundary in non-residential areas. The occupancy factor is determined by dividing the number of hour[s] of occupancy per year (taken from the ODCM) and dividing that value by the total number of hour[s] per year.
- Dose to individuals using areas inside the Site Boundary (that are not residences) was calculated using the Ground Plane and Inhalation pathways.

COMPLIANCE WITH 40CFR190 REQUIREMENTS

Optically Stimulated Luminescent Dosimeter [OSLD] are stationed around CPS to measure the ambient gamma radiation field. Monitoring stations are placed near the site boundary and approximately five (5) miles from the reactor, in locations representing the sixteen (16) compass sectors. Other locations are chosen to measure the radiation field at places of special interest such as nearby residences, meeting places and population centers. Control sites are located further than ten (10) miles from the site, in areas that should not be affected by plant operations. The results from the OSLDs are reported in the Annual Radiological Environmental Monitoring Report [REMP]. The results from this effort indicated no excess dose to offsite areas.

Additionally, NUREG-0543, METHODS FOR DEMONSTRATING LWR COMPLIANCE WITH THE EPA URANIUM FUEL CYCLE STANDARD (40 CFR PART 190) states in section IV, "As long as a nuclear plant site operates at a level below the Appendix I reporting requirements, no extra analysis is required to demonstrate compliance with 40 CFR Part 190." The organ and whole body doses reported in Table 8 are determined using 10 CFR 50 Appendix I methodology. The doses reported are well below the limits of Appendix I.

DOSE TO MEMBERS OF THE PUBLIC WITHIN THE SITE BOUNDARY

CPS ODCM section 7.2 requires that the Radioactive Effluent Release Report include an assessment of the radiation doses from radioactive liquids and gaseous effluents to MEMBERS OF THE PUBLIC due to their activities inside the SITE BOUNDARY. Within the CPS site boundary there are seven areas that are open to members of the public as identified by CPS ODCM Table 3.4-4 (see Figure 4):

-
- The Department of Natural Resources Recreation Area at 1.287 kilometers (0.8 miles) in the ESE sector
 - A road at 0.495 kilometers (0.3 miles) in the SE sector
 - A residence at 2.736 kilometers (1.7 miles) in the SSE sector
 - A residence at 1.219 kilometers (0.8 miles) in the SW sector
 - Agricultural acreage at 1.372 kilometers (0.9 miles) in the SSW sector
 - A residence at 2.414 kilometers (1.5 miles) in the WSW sector
 - A portion of Clinton Lake at 0.335 kilometers (0.2 miles) in the NW sector
-

At all of the above locations, the plume, inhalation and ground-plane exposure pathways are used for dose calculations. The 2013 Annual Land Use Census identified no other exposure pathways. All dose calculations were performed using the methodology contained in the CPS ODCM, with the exception of dose due to C-14, which was calculated using methodology included in the EPRI Technical Report 1021106.

FIGURE 4

AREAS WITHIN THE CPS SITE BOUNDARY OPEN
TO MEMBERS OF THE
PUBLIC




TABLE 9**CALCULATED DOSES TO MEMBERS OF THE PUBLIC DURING USE OF THE ROAD
IN THE SOUTHEAST SECTOR WITHIN THE CPS SITE BOUNDARY**

Data Period: 01 January 2013 – 31 December 2013

DESCRIPTION	DOSE	UNITS
Total Body Dose Rate (Noble Gases)	2.19E-05	mrem/year
Skin Dose Rate (Noble Gases)	3.20E-05	mrem/year
Gamma Air Dose	2.49E-05	mrads
Beta Air Dose	8.79E-06	mrads
Total Body Dose (Particulates)	4.84E-05	mrem
Skin Dose (Particulates) ^[1]	2.57E-06	mrem

[1] DOSE includes the dose values resulting from the release of iodines, particulates (with half lives >8 days) tritium, and carbon-14 in gaseous effluents.

Highest Organ Dose by Age Group:

Adult Bone	9.85E-05	mrem
Teen Bone	1.40E-04	mrem
Child Bone	1.93E-04	mrem
Infant Bone	1.43E-04	mrem

TABLE 10

**CALCULATED DOSES TO MEMBERS OF THE PUBLIC DURING USE OF THE
AGRICULTURAL ACREAGE IN THE SOUTH-SOUTHWEST SECTOR WITHIN THE
CPS SITE BOUNDARY**

Data Period: 01 January 2013 – 31 December 2013

DESCRIPTION	DOSE	UNITS
Total Body Dose Rate (Noble Gases)	1.23E-05	mrem/year
Skin Dose Rate (Noble Gases)	1.80E-05	mrem/year
Gamma Air Dose	1.29E-05	mrads
Beta Air Dose	4.55E-06	mrads
Total Body Dose (Particulates)	2.07E-05	mrem
Skin Dose (Particulates) ^[1]	1.32E-06	mrem

[1] DOSE includes the dose values resulting from the release of iodines, particulates (with half lives >8 days) tritium, and carbon-14 in gaseous effluents.

Highest Organ Dose by Age Group:

Adult Bone	5.11E-05	mrem
Teen Bone	7.26E-05	mrem
Child Bone	N/A ^[2]	mrem
Infant Bone	N/A ^[2]	mrem

[2] Dose calculated only for the age groups likely to be in the field.

TABLE 11

CALCULATED DOSES TO MEMBERS OF THE PUBLIC DURING USE OF CLINTON LAKE IN THE NORTHWEST SECTOR WITHIN THE CPS SITE BOUNDARY

Data Period: 01 January 2013 – 31 December 2013

DESCRIPTION	DOSE	UNITS
Total Body Dose Rate (Noble Gases)	1.99E-04	mrem/year
Skin Dose Rate (Noble Gases)	2.92E-04	mrem/year
Gamma Air Dose	2.08E-04	mrads
Beta Air Dose	7.35E-05	mrads
Total Body Dose (Particulates)	3.96E-04	mrem
Skin Dose (Particulates) ^[1]	1.23E-05	mrem

[1] DOSE includes the dose values resulting from the release of iodines, particulates (with half lives >8 days) tritium, and carbon-14 in gaseous effluents.

Highest Organ Dose by Age Group:

Adult Bone	8.15E-04	mrem
Teen Bone	1.16E-03	mrem
Child Bone	1.60E-03	mrem
Infant Bone	1.18E-03	mrem

TABLE 12

**CALCULATED DOSES TO MEMBERS OF THE PUBLIC DURING USE OF THE
DEPARTMENT OF NATURAL RESOURCES RECREATION AREA IN THE EAST-
SOUTHEAST SECTOR WITHIN THE CPS SITE BOUNDARY**

Data Period: 01 January 2013 – 31 December 2013

DESCRIPTION	DOSE	UNITS
Total Body Dose Rate (Noble Gases)	7.81E-05	mrem/year
Skin Dose Rate (Noble Gases)	1.14E-04	mrem/year
Gamma Air Dose	8.15E-05	mrad
Beta Air Dose	2.88E-05	mrad
Total Body Dose (Particulates)	1.59E-04	mrem
Skin Dose (Particulates) ^[1]	9.03E-06	mrem

[1] DOSE includes the dose values resulting from the release of iodines, particulates (with half lives >8 days) tritium, and carbon-14 in gaseous effluents.

Highest Organ Dose by Age Group:

Adult Bone	3.23E-04	mrem
Teen Bone	4.58E-04	mrem
Child Bone	6.30E-04	mrem
Infant Bone	4.68E-04	mrem

TABLE 13**CALCULATED DOSES FOR THE RESIDENTS IN THE SOUTHWEST SECTOR
WITHIN THE CPS SITE BOUNDARY**

Data Period: 01 January 2013 – 31 December 2013

DESCRIPTION	DOSE	UNITS
Total Body Dose Rate (Noble Gases)	1.53E-04	mrem/year
Skin Dose Rate (Noble Gases)	2.24E-04	mrem/year
Gamma Air Dose	1.61E-04	mrads
Beta Air Dose	5.67E-05	mrads
Total Body Dose (Particulates)	3.11E-04	mrem
Skin Dose (Particulates) ^[1]	1.38E-05	mrem

[1] DOSE includes the dose values resulting from the release of iodines, particulates (with half lives >8 days) tritium, and carbon-14 in gaseous effluents.

Highest Organ Dose by Age Group:

Adult Bone	6.34E-04	mrem
Teen Bone	9.03E-04	mrem
Child Bone	1.24E-03	mrem
Infant Bone	9.19E-04	mrem

TABLE 14

**CALCULATED DOSES FOR THE RESIDENTS IN THE WEST-SOUTHWEST SECTOR
WITHIN THE CPS SITE BOUNDARY**

Data Period: 01 January 2013 – 31 December 2013

DESCRIPTION	DOSE	UNITS
Total Body Dose Rate (Noble Gases)	7.72E-05	mrem/year
Skin Dose Rate (Noble Gases)	1.13E-04	mrem/year
Gamma Air Dose	8.12E-05	mrads
Beta Air Dose	2.87E-05	mrads
Total Body Dose (Particulates)	1.55E-04	mrem
Skin Dose (Particulates) ^[1]	4.60E-06	mrem

[1] DOSE includes the dose values resulting from the release of iodines, particulates (with half lives >8 days) tritium, and carbon-14 in gaseous effluents.

Highest Organ Dose by Age Group:

Adult Bone	3.18E-04	mrem
Teen Bone	4.54E-04	mrem
Child Bone	6.25E-04	mrem
Infant Bone	4.62E-04	mrem

TABLE 15

CALCULATED DOSES FOR THE RESIDENTS IN THE SOUTH-SOUTHEAST SECTOR
WITHIN THE CPS SITE BOUNDARY

Data Period: 01 January 2013 – 31 December 2013

DESCRIPTION	DOSE	UNITS
Total Body Dose Rate (Noble Gases)	9.08E-05	mrem/year
Skin Dose Rate (Noble Gases)	1.33E-04	mrem/year
Gamma Air Dose	9.55E-05	mrads
Beta Air Dose	3.37E-05	mrads
Total Body Dose (Particulates)	1.83E-04	mrem
Skin Dose (Particulates) ^[1]	5.94E-06	mrem

[1] DOSE includes the dose values resulting from the release of iodines, particulates (with half lives >8 days) tritium, and carbon-14 in gaseous effluents.

Highest Organ Dose by Age Group:

Adult Bone	3.75E-04	mrem
Teen Bone	5.34E-04	mrem
Child Bone	7.35E-04	mrem
Infant Bone	5.43E-04	mrem

SECTION 7

ODCM OPERATIONAL REMEDIAL REQUIREMENT REPORTS

In accordance with CPS ODCM section[s] 2.7.1 and 3.9.2, INOPERABLE radioactive liquid and gaseous effluent monitoring instrumentation channels remaining in an INOPERABLE condition for greater than 30 days shall be reported in the Annual Radioactive Effluent Release Report.

During the course of 2013, there were zero (0) instances when either a radioactive liquid or gaseous effluent instrumentation channel[s] was INOPERABLE for greater than any 30 day period.

During the course of 2013, there were no occurrences where Surveillance requirements were not met.

SECTION 8

METEOROLOGICAL DATA AND DISPERSION ESTIMATES

On 13 April 1972, the meteorological monitoring program commenced at the Clinton Power Station site. The meteorological system consists of a tower 199 feet high with two (2) levels of instrumentation at the 10-meter and 60-meter elevations. A combined cup and vane sensor measures wind direction and wind speed[s] at the 10-meter and 60-meter levels. An aspirated dual temperature sensor senses the temperatures at these levels. One-half of the dual sensors at each elevation are used for ambient temperature while the other half is used to provide a differential temperature between the 10-meter and 60-meter levels.

Meteorological monitoring instruments have been placed on the Clinton Power Station microwave tower at the 10-meter level to serve as a backup to the primary meteorological tower.

Clinton Power Station meteorological data is transmitted to the Main Control Room [MCR] via a dedicated communication link. Once the signals are received at the MCR, they are then converted to a 4 to 20 milliamp signal and fed individually to a microprocessor and chart recorders. The microprocessor is part of the Clinton Power Station Radiation Monitoring System [RMS]. Meteorological data is available via the microprocessors in the Main Control Room and the Technical Support Center [TSC].

Dispersion modeling for effluents for normal operation of Clinton Power Station is a straight-line, sector-averaged Gaussian plume model designed to estimate average relative concentration at various receptor points. The model was developed in accordance with routine release analysis procedures specified in Regulatory Guide 1.111. For joint frequency input data, periods of calm are distributed in accordance with a directional distribution. For hourly input data, periods of calm are the previous hour's wind direction. Periods of calm are assigned a wind speed value of half the specified instrument threshold value. Reference Table 18 for more detailed information on meteorology and dispersion data.

TABLE 16

METEOROLOGICAL DATA AVAILABILITY

Data Period: 01 January 2013 – 31 December 2013

PARAMETER	PERCENT OF VALID PARAMETER HOURS (%)			
	Quarter 1	Quarter 2	Quarter 3	Quarter 4
1. Wind Speed				
a. 10-Meter sensor	99.9	97.9	100.0	99.8
b. 60 Meter sensor	97.1	97.9	100.0	99.8
2. Wind Direction				
a. 10-Meter sensor	99.9	97.9	100.0	99.8
b. 60 Meter sensor	99.9	97.6	100.0	99.8
3. Temperature				
a. 10-Meter sensor	99.9	97.9	100.0	99.8
b. 60 Meter sensor	99.9	97.9	100.0	99.8
c. Temperature Difference (10m-60m)	99.9	97.9	100.0	99.8
4. Percent of hours for which valid 10-meter Wind Speed, Wind Direction, and Delta Temperature were available	99.9	97.9	100.0	99.8
5. Percent of hours for which valid 60-meter Wind Speed, Wind Direction, and Delta Temperature were available	97.1	97.6	100.0	99.8

Clinton Power Station was able to achieve 99.0% Meteorological Recoverable Data during 2013 exceeding the minimum criteria of 90% as delineated within Regulatory Guide 1.23.

TABLE 17**CLASSIFICATION OF ATMOSPHERIC STABILITY**

Stability Classification	Pasquill Category	Defining Conditions
Extremely unstable	A	----- $<\Delta T \leq -1.042$
Moderately unstable	B	$-1.042 <\Delta T \leq -0.933$
Slightly unstable	C	$-0.933 <\Delta T \leq -0.823$
Neutral	D	$-0.823 <\Delta T \leq -0.274$
Slightly stable	E	$-0.274 <\Delta T \leq 0.823$
Moderately stable	F	$0.823 <\Delta T \leq 2.195$
Extremely stable	G	$2.195 <\Delta T \leq$ -----

ΔT = temperature difference in degrees Fahrenheit per 100 feet

TABLE 18

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Reporting Period: 01 January 2013 through 31 December 2013

The following table contains the joint wind frequency tables for CPS. The tables are segregated by sensor elevation and calendar quarter. All tabled values are in hours.

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013

Stability Class - Extremely Unstable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	2	0	0	0	2
NNE	0	0	0	0	0	0	0
NE	0	1	3	0	0	0	4
ENE	0	2	3	0	0	0	5
E	0	1	3	0	0	0	4
ESE	0	2	2	0	0	0	4
SE	0	2	3	0	0	0	5
SSE	0	2	3	0	0	0	5
S	0	3	4	0	0	0	7
SSW	0	1	1	0	0	0	2
SW	0	0	0	0	0	0	0
WSW	0	0	1	1	0	0	2
W	0	2	1	5	3	0	11
WNW	0	1	4	10	11	0	26
NW	0	3	5	4	4	0	16
NNW	0	0	4	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	0	20	39	20	18	0	97

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013

Stability Class - Moderately Unstable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	3	0	0	0	4
NNE	0	0	0	0	0	0	0
NE	0	1	1	0	0	0	2
ENE	0	0	5	0	0	0	5
E	0	1	1	0	0	0	2
ESE	0	1	1	0	0	0	2
SE	0	0	4	0	0	0	4
SSE	0	6	6	0	0	0	12
S	0	4	3	0	0	0	7
SSW	0	3	0	2	0	0	5
SW	0	1	5	1	0	0	7
WSW	0	0	6	6	0	0	12
W	0	2	1	2	2	0	7
WNW	0	0	7	8	5	0	20
NW	0	3	7	4	1	0	15
NNW	0	0	8	1	0	0	9
Variable	0	0	0	0	0	0	0
Total	0	23	58	24	8	0	113

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013
 Stability Class - Slightly Unstable - - 60m-10m Delta-T (F)
 Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	10	3	0	0	13
NNE	0	2	0	0	0	0	2
NE	1	0	1	0	0	0	2
ENE	0	3	2	0	0	0	5
E	0	0	0	0	0	0	0
ESE	0	3	2	0	0	0	5
SE	0	5	0	0	0	0	5
SSE	0	3	5	0	0	0	8
S	0	5	5	2	0	0	12
SSW	1	1	5	4	0	0	11
SW	0	2	2	3	1	0	8
WSW	0	0	1	4	0	0	5
W	0	3	6	9	4	0	22
WNW	0	6	4	3	2	0	15
NW	1	5	7	4	1	0	18
NNW	0	4	10	2	0	0	16
Variable	0	0	0	0	0	0	0
Total	3	42	60	34	8	0	147

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013

Stability Class - Neutral - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	16	44	28	0	0	90
NNE	2	9	17	4	4	0	36
NE	2	13	13	13	1	0	42
ENE	3	10	23	13	1	0	50
E	2	4	25	5	0	0	36
ESE	2	18	19	2	0	0	41
SE	2	29	36	0	0	0	67
SSE	0	11	43	10	3	0	67
S	3	11	25	11	4	0	54
SSW	2	5	39	17	6	0	69
SW	2	16	26	6	0	0	50
WSW	2	10	28	20	5	0	65
W	1	16	31	37	10	2	97
WNW	3	9	81	63	44	0	200
NW	1	16	71	52	6	0	146
NNW	1	18	52	30	0	0	101
Variable	0	0	0	0	0	0	0
Total	30	211	573	311	84	2	1211

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013
 Stability Class - Slightly Stable - 60m-10m Delta-T (F)
 Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	5	2	0	0	0	8
NNE	4	6	2	0	0	0	12
NE	3	11	0	0	0	0	14
ENE	1	5	0	1	0	0	7
E	4	13	4	0	0	0	21
ESE	5	24	2	0	0	0	31
SE	5	12	12	0	0	0	29
SSE	0	15	18	2	0	0	35
S	1	12	29	6	0	0	48
SSW	2	12	24	35	4	0	77
SW	4	10	15	2	0	0	31
WSW	1	16	11	3	1	0	32
W	6	23	16	4	0	0	49
WNW	3	17	18	1	0	0	39
NW	1	18	8	1	0	0	28
NNW	0	5	3	0	0	0	8
Variable	0	0	0	0	0	0	0
Total	41	204	164	55	5	0	469

Hours of calm in this stability class: 3
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013

Stability Class - Moderately Stable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	1	1	0	0	0	3
NNE	3	3	0	0	0	0	6
NE	3	4	0	0	0	0	7
ENE	2	4	0	0	0	0	6
E	2	1	0	0	0	0	3
ESE	1	3	0	0	0	0	4
SE	2	3	0	0	0	0	5
SSE	0	4	0	0	0	0	4
S	2	3	0	0	0	0	5
SSW	3	7	2	0	0	0	12
SW	4	7	0	0	0	0	11
WSW	6	11	1	0	0	0	18
W	1	3	0	0	0	0	4
WNW	3	6	0	0	0	0	9
NW	0	8	0	0	0	0	8
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	33	68	4	0	0	0	105

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013

Stability Class - Extremely Stable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	1	2	0	0	0	0	3
ENE	0	1	0	0	0	0	1
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	2	0	0	0	0	0	2
SSW	0	0	0	0	0	0	0
SW	1	0	0	0	0	0	1
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	1	0	0	0	0	0	1
NW	1	3	0	0	0	0	4
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	6	6	0	0	0	0	12

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013

Stability Class - Extremely Unstable - 60m-10m Delta-T (F)

Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	2	0	0	2
NNE	0	0	0	0	0	0	0
NE	0	0	2	0	0	0	2
ENE	0	0	5	1	0	0	6
E	0	0	1	4	0	0	5
ESE	0	1	1	2	0	0	4
SE	0	1	5	0	0	0	6
SSE	0	0	4	0	0	0	4
S	0	1	4	2	0	0	7
SSW	0	0	1	0	0	0	1
SW	0	0	1	0	0	0	1
WSW	0	0	0	2	0	0	2
W	0	3	0	4	4	2	13
WNW	0	0	2	7	5	13	27
NW	0	1	1	6	2	2	12
NNW	0	0	1	4	0	0	5
Variable	0	0	0	0	0	0	0
Total	0	7	28	34	11	17	97

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013
 Stability Class - Moderately Unstable - 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	2	1	0	0	4
NNE	0	0	0	0	0	0	0
NE	0	1	1	0	0	0	2
ENE	0	0	2	2	0	0	4
E	0	1	1	0	1	0	3
ESE	0	1	0	1	0	0	2
SE	0	2	4	0	0	0	6
SSE	0	3	0	6	0	0	9
S	0	5	3	0	0	0	8
SSW	0	3	0	0	2	0	5
SW	0	1	2	4	0	0	7
WSW	0	0	3	4	5	0	12
W	0	1	0	2	2	2	7
WNW	1	0	2	6	7	6	22
NW	0	2	5	3	1	1	12
NNW	0	0	2	8	0	0	10
Variable	0	0	0	0	0	0	0
Total	1	21	27	37	18	9	113

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013
 Stability Class - Slightly Unstable - 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	3	9	0	0	12
NNE	0	0	1	0	0	0	1
NE	0	1	0	0	0	0	1
ENE	0	3	2	2	0	0	7
E	0	0	0	0	0	0	0
ESE	0	2	2	0	2	0	6
SE	0	1	3	0	0	0	4
SSE	0	2	1	5	0	0	8
S	0	5	4	2	1	1	13
SSW	1	0	5	0	1	3	10
SW	0	0	2	2	3	1	8
WSW	0	0	0	2	3	0	5
W	0	2	5	7	4	4	22
WNW	0	4	5	3	2	3	17
NW	0	2	4	6	3	1	16
NNW	0	4	3	7	0	0	14
Variable	0	0	0	0	0	0	0
Total	1	26	40	45	19	13	144

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 3
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013
 Stability Class - Neutral
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	9	27	37	15	0	88
NNE	0	1	12	11	2	5	31
NE	2	6	6	6	7	2	29
ENE	0	4	7	8	15	8	42
E	1	0	4	16	19	3	43
ESE	0	7	5	18	3	2	35
SE	0	11	28	32	1	0	72
SSE	1	8	11	32	16	5	73
S	0	4	6	21	12	12	55
SSW	0	3	9	27	11	11	61
SW	1	11	12	25	4	1	54
WSW	0	3	11	26	18	6	64
W	1	7	23	31	22	12	96
WNW	3	2	15	58	47	52	177
NW	1	3	31	55	28	9	127
NNW	2	8	28	40	32	1	111
Variable	0	0	0	0	0	0	0
Total	12	87	235	443	252	129	1158

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 53
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013
 Stability Class - Slightly Stable - 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	5	2	0	0	8
NNE	1	1	2	2	0	0	6
NE	0	4	10	1	0	0	15
ENE	0	0	3	4	1	0	8
E	1	1	8	5	0	0	15
ESE	0	3	12	12	3	0	30
SE	0	8	15	13	0	0	36
SSE	1	1	8	14	12	2	38
S	0	2	4	14	14	6	40
SSW	0	1	10	26	22	26	85
SW	0	3	6	18	3	1	31
WSW	0	2	9	10	6	2	29
W	0	2	16	17	2	3	40
WNW	0	2	17	26	3	1	49
NW	0	5	11	9	2	0	27
NNW	0	1	10	4	0	0	15
Variable	0	0	0	0	0	0	0
Total	3	37	146	177	68	41	472

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013
 Stability Class - Moderately Stable - 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	2	0	0	2
NNE	0	1	1	0	0	0	2
NE	0	1	4	0	0	0	5
ENE	0	0	3	2	0	0	5
E	0	0	4	0	0	0	4
ESE	1	0	4	2	0	0	7
SE	0	3	5	0	0	0	8
SSE	0	0	2	1	0	0	3
S	0	0	0	0	0	0	0
SSW	0	0	1	2	0	0	3
SW	0	1	3	5	0	0	9
WSW	0	6	3	4	0	0	13
W	0	4	12	1	0	0	17
WNW	0	2	9	1	0	0	12
NW	0	0	9	0	0	0	9
NNW	0	2	4	0	0	0	6
Variable	0	0	0	0	0	0	0
Total	1	20	64	20	0	0	105

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: January - March 2013
 Stability Class - Extremely Stable - 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	1	0	0	0	1
NE	0	0	0	1	0	0	1
ENE	0	1	0	0	0	0	1
E	0	1	0	0	0	0	1
ESE	0	0	1	0	0	0	1
SE	0	1	0	0	0	0	1
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	1	0	0	0	1
WNW	0	0	0	0	0	0	0
NW	0	0	5	0	0	0	5
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	3	8	1	0	0	12

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013

Stability Class - Extremely Unstable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	6	0	0	0	7
NNE	0	1	7	4	0	0	12
NE	0	3	8	1	0	0	12
ENE	0	3	7	0	0	0	10
E	0	3	0	0	0	0	3
ESE	0	0	0	0	0	0	0
SE	0	0	9	0	0	0	9
SSE	0	1	2	0	0	0	3
S	0	5	9	3	0	0	17
SSW	0	1	8	1	0	0	10
SW	0	1	1	4	0	0	6
WSW	0	0	0	1	0	0	1
W	0	3	2	4	0	0	9
WNW	1	2	6	10	0	0	19
NW	0	6	9	3	0	0	18
NNW	0	1	2	1	0	0	4
Variable	0	0	0	0	0	0	0
Total	1	31	76	32	0	0	140

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013

Stability Class - Moderately Unstable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	4	1	3	0	0	8
NNE	0	5	2	2	0	0	9
NE	0	2	4	0	0	0	6
ENE	0	4	1	0	0	0	5
E	0	4	0	0	0	0	4
ESE	0	4	0	0	0	0	4
SE	0	4	6	0	0	0	10
SSE	1	1	3	0	0	0	5
S	0	8	6	4	1	0	19
SSW	1	0	4	13	0	0	18
SW	0	0	7	1	0	0	8
WSW	0	1	5	3	0	0	9
W	0	1	6	3	0	0	10
WNW	0	2	3	5	0	0	10
NW	0	4	2	3	0	0	9
NNW	0	0	3	0	0	0	3
Variable	0	0	0	0	0	0	0
Total	2	44	53	37	1	0	137

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013

Stability Class - Slightly Unstable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	4	0	0	0	5
NNE	0	2	6	3	0	0	11
NE	0	5	2	1	0	0	8
ENE	1	5	1	0	0	0	7
E	0	3	0	0	0	0	3
ESE	0	4	1	0	0	0	5
SE	1	5	5	0	0	0	11
SSE	3	8	7	0	0	0	18
S	2	1	9	4	0	0	16
SSW	2	2	9	6	3	0	22
SW	0	3	8	4	0	0	15
WSW	0	0	3	1	0	0	4
W	1	4	3	0	1	0	9
WNW	1	2	4	1	0	0	8
NW	0	2	9	8	1	0	20
NNW	0	5	5	0	0	0	10
Variable	0	0	0	0	0	0	0
Total	11	52	76	28	5	0	172

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013

Stability Class - Neutral - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	14	34	6	0	0	55
NNE	2	16	27	8	1	0	54
NE	1	23	22	9	0	0	55
ENE	3	13	20	2	0	0	38
E	5	15	16	0	0	0	36
ESE	1	42	9	0	0	0	52
SE	6	31	17	1	0	0	55
SSE	9	25	31	2	0	0	67
S	3	22	53	34	4	0	116
SSW	0	12	51	27	1	0	91
SW	2	11	26	9	0	0	48
WSW	3	9	34	14	5	0	65
W	1	6	29	26	10	0	72
WNW	2	13	17	13	0	0	45
NW	2	9	15	4	1	0	31
NNW	3	13	20	3	0	0	39
Variable	0	0	0	0	0	0	0
Total	44	274	421	158	22	0	919

Hours of calm in this stability class: 1

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013

Stability Class - Slightly Stable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	3	11	6	0	0	0	20
NNE	0	14	7	0	0	0	21
NE	6	33	6	0	0	0	45
ENE	8	16	5	0	0	0	29
E	9	21	4	0	0	0	34
ESE	7	21	5	0	0	0	33
SE	7	37	2	0	0	0	46
SSE	5	35	25	4	0	0	69
S	6	38	29	3	0	0	76
SSW	7	25	8	7	4	0	51
SW	3	24	21	2	0	0	50
WSW	2	13	19	4	0	0	38
W	1	13	6	2	0	0	22
WNW	1	23	14	0	0	0	38
NW	3	12	4	0	0	0	19
NNW	0	12	4	0	0	0	16
Variable	0	0	0	0	0	0	0
Total	68	348	165	22	4	0	607

Hours of calm in this stability class: 3

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013

Stability Class - Moderately Stable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	1	0	0	0	0	3
NNE	2	2	0	0	0	0	4
NE	9	5	0	0	0	0	14
ENE	4	1	0	0	0	0	5
E	3	2	0	0	0	0	5
ESE	3	1	0	0	0	0	4
SE	6	5	0	0	0	0	11
SSE	2	8	0	0	0	0	10
S	1	4	0	0	0	0	5
SSW	2	4	1	0	0	0	7
SW	3	2	0	0	0	0	5
WSW	6	3	1	0	0	0	10
W	7	7	0	0	0	0	14
WNW	3	8	0	0	0	0	11
NW	1	3	0	0	0	0	4
NNW	3	0	0	0	0	0	3
Variable	0	0	0	0	0	0	0
Total	57	56	2	0	0	0	115

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013

Stability Class - Extremely Stable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	7	0	0	0	0	0	7
NE	10	4	0	0	0	0	14
ENE	4	0	0	0	0	0	4
E	2	0	0	0	0	0	2
ESE	1	0	0	0	0	0	1
SE	1	1	0	0	0	0	2
SSE	3	0	0	0	0	0	3
S	0	0	0	0	0	0	0
SSW	1	0	0	0	0	0	1
SW	0	2	0	0	0	0	2
WSW	1	0	0	0	0	0	1
W	5	0	0	0	0	0	5
WNW	0	0	0	0	0	0	0
NW	1	0	0	0	0	0	1
NNW	2	0	0	0	0	0	2
Variable	0	0	0	0	0	0	0
Total	38	7	0	0	0	0	45

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013

Stability Class - Extremely Unstable - 60m-10m Delta-T (F)

Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	3	4	0	0	7
NNE	0	0	5	5	0	0	10
NE	0	0	12	4	0	0	16
ENE	0	0	6	1	0	0	7
E	0	0	2	0	0	0	2
ESE	0	0	0	0	0	0	0
SE	0	0	3	5	0	0	8
SSE	0	0	3	1	0	0	4
S	0	1	8	5	4	0	18
SSW	0	0	1	6	1	0	8
SW	0	1	1	4	0	0	6
WSW	0	1	0	1	0	0	2
W	0	0	1	4	1	0	6
WNW	0	3	5	7	5	0	20
NW	0	1	6	10	2	0	19
NNW	0	3	1	2	0	0	6
Variable	0	0	0	0	0	0	0
Total	0	10	57	59	13	0	139

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 1

Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013
 Stability Class - Moderately Unstable - 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	3	1	2	0	7
NNE	0	0	6	1	1	0	8
NE	0	0	3	3	0	0	6
ENE	0	4	1	0	0	0	5
E	0	1	4	0	0	0	5
ESE	0	1	2	0	0	0	3
SE	0	0	5	3	0	0	8
SSE	0	2	2	1	0	0	5
S	0	5	6	3	3	3	20
SSW	0	0	2	8	7	1	18
SW	0	1	1	6	0	1	9
WSW	0	0	3	4	1	0	8
W	0	1	1	7	1	0	10
WNW	0	0	4	3	5	0	12
NW	0	2	2	2	1	0	7
NNW	0	0	4	2	0	0	6
Variable	0	0	0	0	0	0	0
Total	0	18	49	44	21	5	137

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013

Stability Class - Slightly Unstable - 60m-10m Delta-T (F)

Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	3	3	1	0	0	7
NNE	0	2	3	3	2	0	10
NE	0	1	6	1	2	0	10
ENE	0	2	0	1	0	0	3
E	0	1	2	0	0	0	3
ESE	0	3	0	2	0	0	5
SE	0	2	5	3	0	0	10
SSE	1	1	4	5	0	0	11
S	1	2	2	7	5	1	18
SSW	2	1	2	9	4	5	23
SW	1	2	2	5	3	0	13
WSW	2	0	3	2	1	0	8
W	0	4	4	2	0	1	11
WNW	0	2	5	3	1	0	11
NW	0	1	4	11	2	3	21
NNW	0	1	4	2	0	0	7
Variable	0	0	0	0	0	0	0
Total	7	28	49	57	20	10	171

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 1

Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013
 Stability Class - Neutral - 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	8	17	26	5	0	57
NNE	0	3	22	19	5	1	50
NE	1	3	17	13	13	3	50
ENE	0	2	9	12	11	1	35
E	0	5	5	19	6	0	35
ESE	0	7	19	22	4	0	52
SE	1	14	25	14	1	0	55
SSE	2	8	19	17	9	2	57
S	2	5	15	37	40	18	117
SSW	2	4	9	45	28	8	96
SW	0	6	12	23	6	3	50
WSW	2	6	11	32	11	8	70
W	0	4	10	26	20	12	72
WNW	1	4	15	12	12	3	47
NW	2	8	10	12	3	2	37
NNW	0	2	16	18	3	0	39
Variable	0	0	0	0	0	0	0
Total	14	89	231	347	177	61	919

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 1
 Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013

Stability Class - Slightly Stable - 60m-10m Delta-T (F)

Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	4	11	9	0	0	25
NNE	0	3	9	17	1	0	30
NE	0	1	14	20	1	0	36
ENE	0	1	12	13	2	0	28
E	0	3	7	4	1	0	15
ESE	0	1	13	20	3	0	37
SE	0	6	22	10	1	0	39
SSE	0	5	33	37	11	4	90
S	0	3	20	40	9	3	75
SSW	0	3	16	14	5	8	46
SW	0	3	15	17	8	1	44
WSW	1	0	17	16	10	0	44
W	0	2	8	15	2	1	28
WNW	0	2	8	24	0	0	34
NW	0	1	12	7	0	0	20
NNW	0	1	9	7	0	0	17
Variable	0	0	0	0	0	0	0
Total	2	39	226	270	54	17	608

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 2

Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013

Stability Class - Moderately Stable - 60m-10m Delta-T (F)

Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	4	0	0	0	5
NNE	0	0	1	2	0	0	3
NE	0	4	4	4	0	0	12
ENE	0	2	3	2	0	0	7
E	0	1	0	1	0	0	2
ESE	0	2	3	2	0	0	7
SE	0	3	3	1	0	0	7
SSE	0	1	5	2	0	0	8
S	1	2	7	5	0	0	15
SSW	0	0	2	1	0	0	3
SW	0	1	1	2	0	0	4
WSW	0	0	2	2	0	0	4
W	1	1	6	3	0	0	11
WNW	0	3	15	4	0	0	22
NW	0	0	2	1	0	0	3
NNW	0	0	2	0	0	0	2
Variable	0	0	0	0	0	0	0
Total	2	21	60	32	0	0	115

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: April - June 2013

Stability Class - Extremely Stable - 60m-10m Delta-T (F)

Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	0	0	0	0	0	1
NNE	0	0	0	0	0	0	0
NE	1	1	4	0	0	0	6
ENE	0	1	1	1	0	0	3
E	0	1	2	0	0	0	3
ESE	0	4	4	0	0	0	8
SE	0	5	2	0	0	0	7
SSE	0	1	2	2	0	0	5
S	0	0	0	0	0	0	0
SSW	0	0	1	0	0	0	1
SW	1	2	0	0	0	0	3
WSW	0	0	2	1	0	0	3
W	0	0	0	0	0	0	0
WNW	0	1	1	0	0	0	2
NW	0	1	0	0	0	0	1
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	3	17	19	4	0	0	43

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 2

Hours of missing stability measurements in all stability classes: 45

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013
 Stability Class - Extremely Unstable - 60m-10m Delta-T (F)
 Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	5	13	0	0	0	18
NNE	0	9	20	2	0	0	31
NE	0	11	15	0	0	0	26
ENE	0	11	4	0	0	0	15
E	0	11	3	0	0	0	14
ESE	0	9	0	0	0	0	9
SE	0	19	1	0	0	0	20
SSE	0	26	3	0	0	0	29
S	0	22	12	1	0	0	35
SSW	0	11	17	3	0	0	31
SW	0	6	28	0	0	0	34
WSW	0	6	15	1	0	0	22
W	0	4	4	11	0	0	19
WNW	0	5	15	7	0	0	27
NW	0	12	15	0	0	0	27
NNW	0	1	11	0	0	0	12
Variable	0	0	0	0	0	0	0
Total	0	168	176	25	0	0	369

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013

Stability Class - Moderately Unstable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	6	3	1	0	0	10
NNE	0	2	3	3	0	0	8
NE	0	7	4	2	0	0	13
ENE	0	19	2	0	0	0	21
E	0	8	0	0	0	0	8
ESE	0	6	0	0	0	0	6
SE	0	9	0	0	0	0	9
SSE	1	16	3	0	0	0	20
S	0	8	4	0	0	0	12
SSW	0	7	6	1	0	0	14
SW	0	3	6	0	0	0	9
WSW	0	4	8	0	0	0	12
W	0	2	2	0	0	0	4
WNW	0	3	1	0	0	0	4
NW	0	7	2	1	0	0	10
NNW	0	4	1	1	0	0	6
Variable	0	0	0	0	0	0	0
Total	1	111	45	9	0	0	166

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013

Stability Class - Slightly Unstable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	3	1	0	0	0	4
NNE	0	4	4	3	0	0	11
NE	0	13	5	0	0	0	18
ENE	0	6	1	0	0	0	7
E	0	2	0	0	0	0	2
ESE	0	3	0	0	0	0	3
SE	1	10	0	0	0	0	11
SSE	2	9	1	0	0	0	12
S	0	4	3	0	0	0	7
SSW	0	3	5	0	0	0	8
SW	0	5	9	0	0	0	14
WSW	0	5	7	0	0	0	12
W	0	3	2	0	0	0	5
WNW	0	3	2	0	0	0	5
NW	0	10	4	0	0	0	14
NNW	0	2	1	0	0	0	3
Variable	0	0	0	0	0	0	0
Total	3	85	45	3	0	0	136

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013

Stability Class - Neutral - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	15	9	0	0	0	24
NNE	1	22	17	6	0	0	46
NE	2	25	19	1	0	0	47
ENE	3	15	1	0	0	0	19
E	1	15	0	0	0	0	16
ESE	1	12	1	0	0	0	14
SE	4	21	5	0	0	0	30
SSE	0	50	3	0	0	0	53
S	3	28	14	0	0	0	45
SSW	2	19	19	3	0	0	43
SW	2	36	27	0	1	0	66
WSW	3	14	11	2	0	0	30
W	0	11	2	0	0	0	13
WNW	1	13	6	0	0	0	20
NW	3	12	10	0	0	0	25
NNW	1	13	6	0	0	0	20
Variable	0	0	0	0	0	0	0
Total	27	321	150	12	1	0	511

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013
 Stability Class - Slightly Stable - 60m-10m Delta-T (F)
 Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	16	5	0	0	0	21
NNE	1	20	7	0	0	0	28
NE	6	27	6	0	0	0	39
ENE	3	22	2	0	0	0	27
E	4	14	0	0	0	0	18
ESE	4	38	0	0	0	0	42
SE	7	24	0	0	0	0	31
SSE	10	37	2	0	0	0	49
S	10	66	8	0	0	0	84
SSW	6	66	31	0	0	0	103
SW	5	30	21	0	0	0	56
WSW	1	10	12	0	0	0	23
W	5	9	0	0	0	0	14
WNW	7	28	1	0	0	0	36
NW	1	19	8	0	0	0	28
NNW	3	5	1	0	0	0	9
Variable	0	0	0	0	0	0	0
Total	73	431	104	0	0	0	608

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013
 Stability Class - Moderately Stable - 60m-10m Delta-T (F)
 Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	4	0	0	0	0	4
NNE	6	13	0	0	0	0	19
NE	11	40	0	0	0	0	51
ENE	4	21	0	0	0	0	25
E	8	10	0	0	0	0	18
ESE	5	6	0	0	0	0	11
SE	4	1	0	0	0	0	5
SSE	5	15	0	0	0	0	20
S	7	10	1	0	0	0	18
SSW	9	19	1	0	0	0	29
SW	14	8	0	0	0	0	22
WSW	7	8	0	0	0	0	15
W	6	4	0	0	0	0	10
WNW	8	3	0	0	0	0	11
NW	5	3	0	0	0	0	8
NNW	3	2	0	0	0	0	5
Variable	0	0	0	0	0	0	0
Total	102	167	2	0	0	0	271

Hours of calm in this stability class: 1
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013
 Stability Class - Extremely Stable - 60m-10m Delta-T (F)
 Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	6	0	0	0	0	0	6
NNE	20	5	0	0	0	0	25
NE	26	53	0	0	0	0	79
ENE	4	5	0	0	0	0	9
E	6	1	0	0	0	0	7
ESE	1	0	0	0	0	0	1
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	1	0	0	0	0	0	1
WSW	1	1	0	0	0	0	2
W	2	0	0	0	0	0	2
WNW	1	1	0	0	0	0	2
NW	2	6	0	0	0	0	8
NNW	3	1	0	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	73	73	0	0	0	0	146

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013
 Stability Class - Extremely Unstable - 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	9	5	0	0	15
NNE	0	8	8	9	2	0	27
NE	0	4	17	7	0	0	28
ENE	0	5	14	1	0	0	20
E	0	5	7	1	0	0	13
ESE	0	5	5	0	0	0	10
SE	0	8	17	0	0	0	25
SSE	0	16	8	0	0	0	24
S	0	9	16	8	2	2	37
SSW	0	6	18	6	0	0	30
SW	0	2	14	17	0	0	33
WSW	0	3	13	5	0	0	21
W	0	2	6	9	5	0	22
WNW	0	4	2	16	5	0	27
NW	0	7	8	9	0	0	24
NNW	0	0	10	3	0	0	13
Variable	0	0	0	0	0	0	0
Total	0	85	172	96	14	2	369

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013
 Stability Class - Moderately Unstable - 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	3	3	0	0	8
NNE	0	3	3	0	3	0	9
NE	0	5	2	4	2	0	13
ENE	0	9	10	1	0	0	20
E	0	7	2	0	0	0	9
ESE	0	3	3	0	0	0	6
SE	0	11	2	0	0	0	13
SSE	0	10	8	0	0	0	18
S	0	2	9	2	1	0	14
SSW	0	3	3	4	0	0	10
SW	0	0	7	3	0	0	10
WSW	0	1	8	2	0	0	11
W	0	1	0	2	0	0	3
WNW	0	5	0	1	0	0	6
NW	0	6	2	1	1	0	10
NNW	0	3	2	0	1	0	6
Variable	0	0	0	0	0	0	0
Total	0	71	64	23	8	0	166

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013
 Stability Class - Slightly Unstable - 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	2	0	0	0	4
NNE	0	2	2	2	1	2	9
NE	0	6	7	4	1	0	18
ENE	0	4	4	1	0	0	9
E	0	0	1	0	0	0	1
ESE	0	2	2	0	0	0	4
SE	1	7	6	0	0	0	14
SSE	0	6	1	0	0	0	7
S	1	4	2	3	0	0	10
SSW	0	2	1	3	0	0	6
SW	0	1	6	7	0	0	14
WSW	0	3	6	4	0	0	13
W	0	3	3	1	0	0	7
WNW	0	4	0	2	0	0	6
NW	0	5	4	2	0	0	11
NNW	0	1	1	1	0	0	3
Variable	0	0	0	0	0	0	0
Total	2	52	48	30	2	2	136

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013
 Stability Class - Neutral - 60m-10m Delta-T: (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	6	9	7	0	0	22
NNE	1	10	11	11	2	2	37
NE	1	12	16	21	1	1	52
ENE	0	4	13	2	1	0	20
E	1	3	11	1	0	0	16
ESE	1	2	11	1	0	0	15
SE	1	13	16	5	0	0	35
SSE	3	9	38	1	0	0	51
S	0	10	18	13	3	0	44
SSW	1	6	23	14	3	0	47
SW	2	9	29	20	0	1	61
WSW	0	11	10	7	1	1	30
W	0	5	10	1	0	0	16
WNW	0	6	5	5	0	0	16
NW	0	10	8	7	0	0	25
NNW	1	7	10	5	1	0	24
Variable	0	0	0	0	0	0	0
Total	12	123	238	121	12	5	511

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013

Stability Class - Slightly Stable - 60m-10m Delta-T (F)

Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	13	10	0	0	25
NNE	0	4	4	12	0	0	20
NE	1	2	11	13	3	0	30
ENE	0	1	10	11	1	0	23
E	0	5	12	10	0	0	27
ESE	0	2	14	6	1	0	23
SE	2	11	41	4	0	0	58
SSE	1	12	28	12	0	0	53
S	0	14	52	25	1	0	92
SSW	0	3	31	52	0	0	86
SW	0	3	12	44	0	0	59
WSW	0	3	12	12	4	0	31
W	0	1	3	1	0	0	5
WNW	1	5	17	7	0	0	30
NW	0	5	14	11	0	0	30
NNW	0	4	8	4	0	0	16
Variable	0	0	0	0	0	0	0
Total	5	77	282	234	10	0	608

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013
 Stability Class: Moderately Stable - 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	3	2	1	0	0	7
NNE	0	1	4	3	0	0	8
NE	0	0	5	13	0	0	18
ENE	0	3	8	18	0	0	29
E	0	1	21	9	0	0	31
ESE	1	4	15	5	0	0	25
SE	1	2	5	0	0	0	8
SSE	0	5	5	0	0	0	10
S	0	6	28	4	0	0	38
SSW	0	5	10	12	0	0	27
SW	0	5	13	5	0	0	23
WSW	1	5	4	1	0	0	11
W	0	5	4	3	0	0	12
WNW	0	6	3	0	0	0	9
NW	0	7	5	0	0	0	12
NNW	1	1	2	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	5	59	134	74	0	0	272

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: July - September 2013

Stability Class - Extremely Stable - 60m-10m Delta-T (F)

Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	6	0	0	0	8
NNE	1	1	3	1	0	0	6
NE	1	2	12	8	0	0	23
ENE	0	4	7	16	0	0	27
E	3	4	12	14	0	0	33
ESE	1	4	10	4	0	0	19
SE	4	5	4	0	0	0	13
SSE	2	2	0	0	0	0	4
S	0	0	0	0	0	0	0
SSW	1	0	0	0	0	0	1
SW	0	0	2	1	0	0	3
WSW	0	0	2	0	0	0	2
W	0	0	0	0	0	0	0
WNW	0	1	1	0	0	0	2
NW	0	0	1	0	0	0	1
NNW	0	2	2	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	13	27	62	44	0	0	146

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013

Stability Class - Extremely Unstable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	3	0	0	0	5
NNE	0	2	0	0	0	0	2
ENE	0	0	0	0	0	0	0
E	0	1	1	0	0	0	2
ESE	0	5	0	0	0	0	5
SE	0	6	2	0	0	0	8
SSE	0	5	0	0	0	0	5
S	0	5	3	0	0	0	8
SSW	0	3	10	3	0	0	16
SW	0	0	6	2	0	0	8
WSW	0	0	6	7	0	0	13
W	0	0	1	4	0	0	5
WNW	0	0	7	6	1	0	14
NW	0	1	5	0	0	0	6
NNW	0	2	8	1	0	0	11
Variable	0	0	0	0	0	0	0
Total	0	32	52	23	1	0	108

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 4

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013

Stability Class - Moderately Unstable - 60m-10m Delta-T (F)
Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	2	1	0	0	3
NNE	0	0	2	0	0	0	2
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	2	0	0	0	0	2
SE	0	5	1	0	0	0	6
SSE	0	4	2	1	0	0	7
S	0	6	2	0	0	0	8
SSW	0	3	12	4	0	0	19
SW	0	3	7	3	0	0	13
WSW	0	2	7	9	0	0	18
W	0	0	5	5	3	0	13
WNW	0	0	5	6	1	0	12
NW	0	8	4	0	0	0	12
NNW	0	0	4	4	0	0	8
Variable	0	0	0	0	0	0	0
Total	0	33	53	33	4	0	123

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013

Stability Class - Slightly Unstable - 60m-10m Delta-T (F)
Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	3	4	0	0	0	7
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	1	1	0	0	0	2
E	0	1	1	0	0	0	2
ESE	0	6	0	0	0	0	6
SE	0	8	1	0	0	0	9
SSE	0	5	2	0	0	0	7
S	0	2	3	1	0	0	6
SSW	0	1	7	4	0	0	12
SW	0	2	7	3	0	0	12
WSW	0	2	2	3	1	0	8
W	1	3	4	6	2	0	16
WNW	0	1	8	8	0	0	17
NW	1	4	9	6	0	0	20
NNW	0	0	0	6	0	0	6
Variable	0	0	0	0	0	0	0
Total	2	39	49	37	3	0	130

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013

Stability Class - Neutral - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	8	28	17	0	0	53
NNE	0	15	4	5	0	0	24
NE	0	11	7	0	0	0	18
ENE	0	11	9	0	0	0	20
E	0	15	6	0	0	0	21
ESE	0	20	2	0	0	0	22
SE	0	34	15	0	0	0	49
SSE	1	30	44	6	0	0	81
S	0	30	54	18	1	0	103
SSW	3	17	65	36	2	1	124
SW	0	16	42	13	1	0	72
WSW	0	28	30	5	0	1	64
W	3	19	50	34	2	1	109
WNW	0	20	69	43	1	0	133
NW	1	11	55	33	0	0	100
NNW	0	5	44	17	0	0	66
Variable	0	0	0	0	0	0	0
Total	8	290	524	227	7	3	1059

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013
 Stability Class - Slightly Stable - 60m-10m Delta-T (F)
 Winds Measured at: 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	6	3	0	0	0	9
NNE	0	4	0	0	0	0	4
NE	0	9	0	0	0	0	9
ENE	1	6	0	0	0	0	7
E	1	7	0	0	0	0	8
ESE	6	17	0	0	0	0	23
SE	5	39	4	0	0	0	48
SSE	5	33	13	1	0	0	52
S	4	33	28	7	0	0	72
SSW	0	20	79	38	3	0	140
SW	0	26	24	3	0	0	53
WSW	2	18	7	0	0	0	27
W	0	15	8	11	0	0	34
WNW	0	32	28	6	0	0	66
NW	0	20	13	0	0	0	33
NNW	0	4	0	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	24	289	207	66	3	0	589

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013

Stability Class - Moderately Stable - 60m-10m Delta-T (F)

Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	0	0	0	0	2
NNE	1	4	0	0	0	0	5
NE	0	11	0	0	0	0	11
ENE	0	8	0	0	0	0	8
E	1	2	0	0	0	0	3
ESE	4	0	0	0	0	0	4
SE	1	5	1	0	0	0	7
SSE	1	4	1	0	0	0	6
S	1	3	1	0	0	0	5
SSW	3	12	2	0	0	0	17
SW	0	14	0	0	0	0	14
WSW	2	6	0	0	0	0	8
W	1	9	5	0	0	0	15
WNW	0	7	0	0	0	0	7
NW	1	10	0	0	0	0	11
NNW	0	4	0	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	16	101	10	0	0	0	127

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 4

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013

Stability Class - Extremely Stable - 60m-10m Delta-T (F)
Winds Measured at 10 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	1	0	0	0	0	2
NNE	2	1	0	0	0	0	3
NE	3	11	0	0	0	0	14
ENE	4	4	0	0	0	0	8
E	8	0	0	0	0	0	8
ESE	5	0	0	0	0	0	5
SE	1	0	0	0	0	0	1
SSE	0	0	0	0	0	0	0
S	0	1	0	0	0	0	1
SSW	1	3	0	0	0	0	4
SW	4	3	0	0	0	0	7
WSW	2	1	0	0	0	0	3
W	1	1	0	0	0	0	2
WNW	2	2	0	0	0	0	4
NW	0	4	0	0	0	0	4
NNW	1	1	0	0	0	0	2
Variable	0	0	0	0	0	0	0
Total	35	33	0	0	0	0	68

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013

Stability Class - Extremely Unstable - 60m-10m Delta-T (F)
Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	5	0	0	0	6
NNE	0	0	1	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	2	1	0	0	3
ESE	0	3	2	0	0	0	5
SE	0	5	6	0	0	0	11
SSE	0	1	1	0	0	0	2
S	0	2	4	5	0	0	11
SSW	0	0	4	7	2	1	14
SW	0	0	3	4	1	0	8
WSW	0	0	2	5	4	0	11
W	0	0	0	1	4	0	5
WNW	0	0	0	12	2	1	15
NW	0	0	2	5	0	0	7
NNW	0	0	3	5	1	0	9
Variable	0	0	0	0	0	0	0
Total	0	12	35	45	14	2	108

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013

Stability Class - Moderately Unstable - 60m-10m Delta-T (F)
Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	1	2	0	0	3
NNE	0	0	2	0	0	0	2
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	2	1	0	0	0	3
SE	0	4	1	1	0	0	6
SSE	0	2	2	2	0	0	6
S	0	4	3	0	1	0	8
SSW	0	2	7	10	4	0	23
SW	0	1	4	3	1	0	9
WSW	0	1	6	4	7	0	18
W	0	0	0	7	6	3	16
WNW	0	0	2	3	3	1	9
NW	0	7	1	5	0	0	13
NNW	0	0	0	5	2	0	7
Variable	0	0	0	0	0	0	0
Total	0	23	30	42	24	4	123

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013
 Stability Class - Slightly Unstable - 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	0	4	0	0	6
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	2	0	0	0	2
E	0	0	0	1	0	0	1
ESE	0	2	5	0	0	0	7
SE	0	6	3	1	0	0	10
SSE	0	2	2	0	0	0	4
S	0	4	3	1	1	1	10
SSW	0	0	0	9	3	0	12
SW	0	0	5	3	2	0	10
WSW	0	1	2	4	2	1	10
W	0	2	2	4	6	1	15
WNW	0	0	3	8	4	1	16
NW	0	3	2	12	1	1	19
NNW	1	0	1	0	6	0	8
Variable	0	0	0	0	0	0	0
Total	1	22	30	47	25	5	130

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013
 Stability Class - Neutral 60m-10m Delta-T (F)
 Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	3	9	26	12	0	50
NNE	0	9	10	1	2	0	22
NE	0	2	8	3	0	0	13
ENE	0	2	8	14	1	0	25
E	0	5	6	7	2	0	20
ESE	0	2	15	7	0	0	24
SE	0	5	35	16	0	0	56
SSE	0	6	19	37	16	2	80
S	0	2	29	44	23	18	116
SSW	0	5	17	53	27	6	108
SW	1	7	16	36	12	1	73
WSW	0	6	27	24	4	1	62
W	0	6	35	46	27	3	117
WNW	0	3	25	56	36	3	123
NW	2	3	19	49	27	1	101
NNW	0	2	9	49	9	0	69
Variable	0	0	0	0	0	0	0
Total	3	68	287	468	198	35	1059

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013

Stability Class - Slightly Stable - 60m-10m Delta-T (F)

Winds Measured at: 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	3	7	0	0	10
NNE	0	0	2	1	0	0	3
NE	0	1	1	1	0	0	3
ENE	0	0	3	8	0	0	11
E	1	1	2	5	0	0	9
ESE	0	2	6	3	0	0	11
SE	0	5	31	16	0	0	52
SSE	0	1	25	30	6	0	62
S	0	2	10	30	22	9	73
SSW	0	2	7	49	60	8	126
SW	0	1	10	36	8	0	55
WSW	0	1	7	15	0	0	23
W	0	3	14	9	9	2	37
WNW	0	1	18	33	16	0	68
NW	0	0	17	19	0	0	36
NNW	0	0	9	1	0	0	10
Variable	0	0	0	0	0	0	0
Total	1	20	165	263	121	19	589

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 4

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013

Stability Class - Moderately Stable - 60m-10m Delta-T (F)

Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	4	0	0	4
NNE	0	0	0	0	0	0	0
NE	0	0	7	1	0	0	8
ENE	0	0	1	7	0	0	8
E	0	0	2	5	0	0	7
ESE	0	0	0	2	0	0	2
SE	0	4	2	2	0	0	8
SSE	0	0	2	6	0	0	8
S	0	0	0	3	1	0	4
SSW	0	0	1	8	0	0	9
SW	0	0	5	12	0	0	17
WSW	0	1	3	8	0	0	12
W	0	0	4	6	0	0	10
WNW	0	1	4	4	2	0	11
NW	0	1	9	4	0	0	14
NNW	0	1	2	2	0	0	5
Variable	0	0	0	0	0	0	0
Total	0	8	42	74	3	0	127

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 4

TABLE 18 (continued)

JOINT WIND FREQUENCY DISTRIBUTION BY STABILITY CLASS

Clinton Power Station

Period of Record: October - December 2013

Stability Class - Extremely Stable - 60m-10m Delta-T (F)

Winds Measured at 60 Meters

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	3	0	0	3
NNE	0	0	1	1	0	0	2
NE	0	1	0	2	0	0	3
ENE	0	0	1	8	0	0	9
E	0	0	0	7	0	0	7
ESE	0	1	2	0	0	0	3
SE	0	0	0	0	0	0	0
SSE	0	0	10	1	0	0	11
S	0	0	3	0	0	0	3
SSW	0	0	2	2	0	0	4
SW	0	1	3	5	0	0	9
WSW	0	0	2	0	0	0	2
W	0	1	0	1	0	0	2
WNW	0	2	1	0	0	0	3
NW	0	0	3	0	0	0	3
NNW	0	0	2	2	0	0	4
Variable	0	0	0	0	0	0	0
Total	0	6	30	32	0	0	68

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

SECTION 9

CHANGES TO RADIOACTIVE WASTE TREATMENT SYSTEMS

In accordance with Section 7.2 of the CPS ODCM, licensee-initiated changes to the liquid, gaseous or solid radioactive waste treatment systems shall be reported in the Annual Radioactive Effluent Release Report:

There were no instances of licensee-initiated changes to the liquid, gaseous or solid radioactive waste treatment systems during 2013.

SECTION 10.

CORRECTIONS TO DATA REPORTED IN PREVIOUS REPORTS

It was identified that the dosimeters used for measuring the ambient gamma radiation field were incorrectly identified as Thermoluminescent Dosimeters [TLD] on page 34 of the 2012 Annual Radioactive Effluent Release Report. The following page has been revised to appropriately identify the dosimeters as Optically Stimulated Luminescent Dosimeters [OSLD].

COMPLIANCE WITH 40CFR190 REQUIREMENTS

Optically Stimulated Luminescent Dosimeters [OSLD] are stationed around CPS to measure the ambient gamma radiation field. Monitoring stations are placed near the site boundary and approximately five (5) miles from the reactor, in locations representing the sixteen (16) compass sectors. Other locations are chosen to measure the radiation field at places of special interest such as nearby residences, meeting places and population centers. Control sites are located further than ten (10) miles from the site, in areas that should not be affected by plant operations. The results from the OSLDs are reported in the Annual Radiological Environmental Monitoring Report [REMP]. The results from this effort indicated no excess dose to offsite areas.

Additionally, NUREG-0543, METHODS FOR DEMONSTRATING LWR COMPLIANCE WITH THE EPA URANIUM FUEL CYCLE STANDARD (40 CFR PART 190) states in section IV, "As long as a nuclear plant site operates at a level below the Appendix I reporting requirements, no extra analysis is required to demonstrate compliance with 40 CFR Part 190." The organ and whole body doses reported in Table 8 are determined using 10 CFR 50 Appendix I methodology. The doses reported are well below the limits of Appendix I.

DOSE TO MEMBERS OF THE PUBLIC WITHIN THE SITE BOUNDARY

CPS ODCM section 7.2 requires that the Radioactive Effluent Release Report include an assessment of the radiation doses from radioactive liquids and gaseous effluents to MEMBERS OF THE PUBLIC due to their activities inside the SITE BOUNDARY. Within the CPS site boundary there are seven areas that are open to members of the public as identified by CPS ODCM Table 3.4-4 (see Figure 4):

-
- The Department of Natural Resources Recreation Area at 1.287 kilometers (0.8 miles) in the ESE sector
 - A road at 0.495 kilometers (0.3 miles) in the SE sector
 - A residence at 2.736 kilometers (1.7 miles) in the SSE sector
 - A residence at 1.219 kilometers (0.8 miles) in the SW sector
 - Agricultural acreage at 1.372 kilometers (0.9 miles) in the SSW sector
 - A residence at 2.414 kilometers (1.5 miles) in the WSW sector
 - A portion of Clinton Lake at 0.335 kilometers (0.2 miles) in the NW sector
-

At all of the above locations, the plume, inhalation and ground-plane exposure pathways are used for dose calculations. The 2012 Annual Land Use Census identified no other exposure pathways. All dose calculations were performed using the methodology contained in the CPS ODCM, with the exception of dose due to C-14, which was calculated using methodology included in the EPRI Technical Report 1021106.