

**IAY 0 5 2014** L-2014-086 10 CFR 50.36b

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, D.C. 20555-00001

Re: Turkey Point Units 3 and 4 Docket Nos. 50-250 and 50-251 2013 Annual Radiological Environmental Operating Report

Enclosed is the 2013 Annual Radiological Environmental Operating Report for Turkey Point Units 3 and 4, as required by Technical Specification 6.9.1.3.

Should there be any questions or comments regarding this information, please contact Robert J. Tomonto at (305) 246-7327.

Sincerely,

Muli

Michael Kiley Vice President Turkey Point Nuclear Plant

SM Enclosure

cc: Regional Administrator, Region II, USNRC Senior Resident Inspector, USNRC, Turkey Point Plant

# TABLE OF CONTENTS

DESCRIPTION	PAGE
Introduction	1
Radiological Environmental Monitoring Program	1
Discussion and Interpretation of Results	4
Environmental Radiological Monitoring Program Annual Summary	TABLE 1
Deviations / Missing Data	TABLE 1A
Analyses with LLDs Above Required Detection Capabilities	TABLE 1B
Land Use Census	TABLE 2
Key to Sample Locations	ATTACHMENT A
Radiological Surveillance of Florida Power and Light Company's Turkey Point Site	ATTACHMENT B
First Quarter, 2013	
Second Quarter, 2013	
Third Quarter, 2013	
Fourth Quarter, 2013	
Results from the Interlaboratory Comparison Program, 2013	ATTACHMENT C
Ground Water Protection, Industry Initiative	ATTACHMENT D

#### EXECUTIVE SUMMARY

The data obtained through the Turkey Point Radiological Environmental Monitoring Program verifies that the levels of radiation and concentrations of radioactive materials in environmental samples are not increasing. These measurements verify that the dose or dose commitment to members of the public, due to operation of Turkey Point Units 3 & 4, during the surveillance year, is well within the limits established by 10 CFR 50, Appendix I. The sampling period was from January 1, 2013 to December 31, 2013.

Additionally, supplemental samples collected by the State of Florida, DOH, do not indicate adverse trends in the radiological environment.



Turkey Point 2013 REMP Gross Beta in Air, pCi/m<sup>3</sup>



2013 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4



Turkey Point Surface Water Tritium - 2013

T-84, T-97, and T-08 are supplemental samples to track cooling canal tritium levels.

### I. INTRODUCTION

This report is submitted pursuant to Specification 6.9 of Turkey Point Units 3 & 4 Technical Specifications. The Annual Radiological Environmental Operating Report provides information, summaries and analytical results pertaining to the Radiological Environmental Monitoring Program for the calendar year indicated. This report covers surveillance activities described in the Offsite Dose Calculation Manual (ODCM) meeting the requirements of Unit 3 and Unit 4 Technical Specifications.

# II. RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

### A. <u>Purpose</u>

The purpose of the Radiological Environmental Monitoring Program is to provide representative measurements of radiation and of radioactive materials in those exposure pathways and for those radionuclides which lead to the highest potential radiation exposures of members of the public resulting from station operation. The Radiological Environmental Monitoring Program also supplements the radiological effluent monitoring program by verifying that the measurable concentrations of radioactive materials and levels of radiation are not higher than expected on the basis of the effluent measurements and the modeling of the environmental exposure pathways.

#### B. Program Description

The Radiological Environmental Monitoring Program (REMP) for the Turkey Point Plant is conducted pursuant to Control 5.1 of Turkey Point Unit 3 & 4 ODCM.

- 1. Sample Locations, Types and Frequencies:
  - a. Direct radiation gamma exposure rate is monitored continuously at 23 locations by thermoluminescent dosimeters (TLDs). TLDs are collected and analyzed quarterly.
  - b. Airborne radioiodine and particulate samplers are operated continuously at six locations. Samples are collected and analyzed weekly. Analyses include lodine-131, gross beta, and gamma isotopic measurements.
  - c. Surface water samples are collected from three locations. Samples are collected and analyzed monthly. Analyses include gamma isotopic and tritium measurements.

### ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4

- d. Shoreline sediment samples are collected from three locations coinciding with the locations for surface water samples. Samples are collected and analyzed semi-annually. Sediment samples are analyzed by gamma isotopic measurements.
- e. Fish and invertebrate samples are collected from two locations coinciding with two of the locations for surface water samples. Samples are collected and analyzed semi-annually. Fish and invertebrate samples are analyzed by gamma isotopic measurements.
- f. Broad leaf vegetation samples are collected from three locations. Samples are collected and analyzed monthly. Broad leaf vegetation samples are analyzed by gamma isotopic measurements.

Attachment A provides specific information pertaining to sample locations, types and frequencies.

- Note: Ground Water Protection, NEI Initiative: The program and results are described in Attachment D
- 2. Analytical Responsibility:

Radiological environmental monitoring for the Turkey Point Plant is conducted by the State of Florida, Department of Health (DOH). Samples are collected and analyzed by DOH personnel.

Samples are analyzed at the DOH Environmental Radiation Control Laboratory in Orlando, Florida.

Note: The State is not involved in the (Industry Initiative) ground water monitoring program.

C. <u>Analytical Results</u>

<u>Table 1, Environmental Radiological Monitoring Program Annual Summary</u> provides a summary for all specified samples collected during the referenced surveillance period. Deviations from the sample schedule, missing data and/or samples not meeting the specified "A PRIORI" LLD, if any, are noted and explained in Tables 1A and 1B respectively. Analysis data for all specified samples analyzed during the surveillance period is provided in Attachment B.

#### D. Land Use Census

A land use census out to a distance of 5 miles radius from the Turkey Point Plant is conducted annually to determine the location of the nearest milk animal, residence, and garden producing broad leaf vegetation, in each of the sixteen meteorological sectors. A summary of the land use census for the surveillance year is provided in <u>Table 2</u>, <u>Land Use Census Summary</u>.

#### E. Interlaboratory Comparison Program

The intercomparison program consists of participating in the DOE Mixed Analyte Performance Evaluation Program (MAPEP).

This program provides similar testing (matrices, nuclides, and levels) as the former EPA Interlaboratory Comparison Program and is referred to as the Mixed Analyte Performance Evaluation Program (MAPEP).

The samples are analyzed using the methods applicable to the REMP (gamma spectroscopy, Gross Beta, and Tritium for water).

#### From the MAPEP handbook:

Acceptance criteria were developed from a review of precision and accuracy data compiled by other performance evaluation programs (PEPs), the analytical methods literature, from several MAPEP pilot studies, and from what is considered reasonable, acceptable, and achievable for routine analyses among the more experienced laboratories.

The results for nuclides associated with the REMP are listed in ATTACHMENT C, RESULTS FROM THE INTERLABORATORY COMPARISON PROGRAM.

# ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4

#### III. DISCUSSION AND INTERPRETATION OF RESULTS

#### A. <u>Reporting of Results</u>

The Annual Radiological Environmental Operating Report contains the summaries, interpretations and information required by Control 1.4 of ODCM. Table 1 provides a summary of the measurements made for the nuclides required by ODCM Table 5.1-2, for all samples specified by Table 5.1-1. In addition, summaries are provided for other nuclides identified in the specified samples, including those not related to station operation. These include nuclides such as K-40, Th-232, Ra-226, and Be-7 which are common in the Florida environment.

#### B. Interpretation of Results

#### 1. Direct Radiation:

The results of direct radiation monitoring are consistent with past measurements for the specified locations.

The exposure rate data shows no indication of any trends attributed to effluents from the plant. The measured exposure rates are consistent with exposure rates that were observed during the pre-operational surveillance program. Direct radiation monitoring results are summarized in Table 1.

2. Air Particulates/Radioiodine:

For results attributed to plant effluents:

The results for radioactive air particulate and radioiodine monitoring are consistent with past measurements and indicate no trends attributed to plant effluents. All samples for radioiodine yielded no detectable I-131. Gamma isotopic measurements yielded no indication of any nuclides attributed to station operation. The results for air particulate/radioiodine samples are consistent with measurements that were made during the pre-operational surveillance program. Air particulate and radioiodine monitoring results are summarized in Table 1.

3. Waterborne, Surface Water:

The results of radioactivity measurements in surface water samples are consistent with past measurements. Tritium was reported as present in five of 24 indicator location and zero of 12 control location surface water samples collected. These results are consistent with the known subsurface interchange that occurs between the closed cooling canal and its surrounding waters, and the pressure gradients caused by the flow of aquifer subsurface waters in South Florida. The highest reported tritium is 6.7% of the required detection level specified by ODCM Table 5.1-3.

- 4. Waterborne, Sediment: Gamma isotopic measurements yielded no indication of any nuclides attributed to station operation.
- 5. Waterborne, Food Products:

The results are consistent with past measurements. Gamma isotopic measurements yielded no indication of any nuclides attributed to station operation.

6. Broad Leaf Vegetation

#### For results attributed to plant effluents:

The results of radioactivity measurements are consistent with past measurements. Cs-137 was detected in samples collected from the indicator locations. The maximum concentration reported was 11.5% of the reporting level specified by ODCM Table 5.1-2. No other fission products were detected.

7. Land Use Census

There were no additions to the land use relative to last year's report.

No locations yielding a calculated dose or dose commitment greater than the values currently being calculated were identified by the land use census.

No locations yielding a calculated dose or dose commitment (via the same exposure pathway) 20% greater than locations currently being sampled in the radiological environmental monitoring program were identified by the land use census.

8. Interlaboratory Comparison Program

The State laboratory participated in MAPEP 28 and 29. These satisfied the requirement of Control 5.3 of the ODCM for the Interlaboratory Comparison Program.

The results are listed in Attachment C.

C. <u>Conclusions</u>

The data obtained through the Turkey Point Plant Radiological Environmental Monitoring Program verifies that the levels of radiation and concentrations of radioactive materials in environmental samples, representing the highest potential exposure pathways to members of the public, are not being increased.

The measured exposure rates are consistent with exposure rates that were observed during the pre-operational surveillance program.

The results for air particulate/radioiodine samples are consistent with measurements that were made during the pre-operational surveillance program.

The highest value of tritium in surface water was 6.7% of the required LLD listed in ODCM Table 5.1-3. There were no indications of any other nuclides that could be attributed to plant effluents.

There were no indications of any nuclides in waterborne sediment or food products attributed to plant effluents.

The results of radioactivity measurements for broad leaf vegetation are consistent with past measurements.

Additionally, supplemental to the ODCM program, sampling of the direct exposure, inhalation, and ingestion pathways, performed by DOH, does not show adverse trends in levels of radiation and radioactive materials in unrestricted areas.

The measurements verify that the dose or dose commitment to members of the public, due to operation of Turkey Point Units 3 & 4, during the surveillance year, are well within "as low as reasonably achievable (ALARA)" criteria established by 10 CFR 50, Appendix I.

# TABLE 1ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM ANNUAL SUMMARY<br/>Name of Facility Turkey Point Units 3 & 4, Docket No(s). 50-250 & 50-251Location of Facility Miami-Dade, Florida , Reporting Period January 1 - December 31, 2013<br/>(County, State)

## PATHWAY: DIRECT RADIATION SAMPLES COLLECTED: TLD UNITS: micro-R/hr

			Location with High	nest Annual Mean	
		_	Name <sup>c</sup>	Mean (f) <sup>b</sup>	
Type and Total Number of Analyses Performed	Lower Limit of Detection <sup>a</sup> (LLD)	All Indicator Locations Mean (f) <sup>b</sup> Range	Distance & Range C Direction M	Control Locations Mean (f) <sup>ь</sup> Range	
Exposure Rate, 92 <sup>d</sup>		3.51 (86/88) 2.2 5.5	NW-10 10 mi., NW	4.39 (4/4) 3.5 - 5.0	3.91 (4/4) 3.2 - 4.4

# TABLE 1ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM ANNUAL SUMMARY<br/>Name of Facility Turkey Point Units 3 & 4, Docket No(s). 50-250 & 50-251Location of Facility Miami-Dade, Florida, Reporting Period January 1 - December 31, 2013<br/>(County, State)

# PATHWAY: AIRBORNE SAMPLES COLLECTED: RADIOIODINE AND PARTICULATES UNITS: pCi/m<sup>3</sup>

		Location with Hig			
		_	Name <sup>c</sup>	Mean (f) <sup>⁵</sup>	
Type and Total Number of Analyses Performed	Lower Limit of Detection <sup>a</sup> (LLD)	All Indicator Locations Mean (f) <sup>b</sup> Range	Distance & Direction	Range	Control Locations Mean (f) <sup>b</sup> Range
<sup>131</sup> I, 311	0.012	<mda< td=""><td></td><td></td><td>&lt; MDA</td></mda<>			< MDA
Gross Beta, 318	0.0064	0.013 (263/265) 0.003 - 0.030	T-57 4 mi, NW	0.0133 (53/53) 0.005 - 0.030	0.012 (52/53) 0.005 - 0.030
Composite Gamma Isotopic, 32					
<sup>7</sup> Be	0.0006	0.1064 (28/28) 0.0805 - 0.1462	T-72 < 1 mi., WSW	0.1105(4/4) 0.0894 - 0.1258	0.0994 (4/4) 0.0832 - 0.1139
<sup>40</sup> K		< MDA			0.00033 (1/4)
					0.00033 - 0.00033
<sup>134</sup> Cs	0.0008	< MDA			< MDA
<sup>137</sup> Cs	0.0008	< MDA			< MDA
<sup>210</sup> Pb		0.0121 (19/28) 0.0093 - 0.0170	T-72 < 1 mi., WSW	0.0149 (3/4) 0.0139 – 0.0154	0.0224 (4/4) 0.0091 0.0556

Be-7, K-40 & Pb-210 are naturally occurring.

# TABLE 1 ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM ANNUAL SUMMARY Name of Facility Turkey Point Units 3 & 4, Docket No(s). 50-250 & 50-251 Location of Facility Miami-Dade, Florida , Reporting Period January 1 - December 31, 2013 (County, State)

# PATHWAY: WATERBORNE

# SAMPLES COLLECTED: SURFACE WATER

UNITS: pCi/L

			Location with Hig	hest Annual Mean	
		_	Name <sup>c</sup>	Mean (f) <sup>ь</sup>	_
Type and Total Number of Analyses Performed	Lower Limit of Detection <sup>a</sup> (LLD)	All Indicator Locations Mean (f) <sup>b</sup> Range	Distance & Direction	Range	Control Locations Mean (f) <sup>b</sup> Range
Tritium, 36	172	173 ( 4/24)	T-81	173 ( 3/12)	127 (1/12)
		142 - 201	6 mi., S	142 - 201	127 -127
Gamma Isotopic, 36					
⁴ºK	58	270 (24/24) 81 - 361	T-81 6 mi., S	308 (12/12) 196 - 361	138 (8/12) 20 - 285
<sup>54</sup> Mn	3	< MDA			< MDA
<sup>59</sup> Fe	6	< MDA			< MDA
<sup>58</sup> Co	3	< MDA			< MDA
<sup>60</sup> Co	4	< MDA			< MDA
<sup>65</sup> Zn	7	< MDA			< MDA
<sup>95</sup> Zr-Nb	6	< MDA			< MDA
<sup>131</sup>	4	< MDA			< MDA
<sup>134</sup> Cs	4	< MDA			< MDA
<sup>137</sup> Cs	4	< MDA			< MDA
<sup>140</sup> Ba-La	9	< MDA			< MDA

K-40 is naturally occurring.

# TABLE 1 ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM ANNUAL SUMMARY Name of Facility Turkey Point Units 3 & 4, Docket No(s). 50-250 & 50-251 Location of Facility Miami-Dade, Florida , Reporting Period January 1 - December 31, 2013 (County, State)

#### PATHWAY: WATERBORNE SAMPLES COLLECTED: SHORELINE SEDIMENT UNITS: pCi/kg, DRY

			Location with Higher	st Annual Mean	
			Name <sup>c</sup>	Mean (f) <sup>b</sup>	_
Type and Total Number of Analyses Performed	Lower Limit of Detection <sup>a</sup> (LLD)	All Indicator Locations Mean (f) <sup>b</sup> Range	Distance & Direction	Range	Control Locations Mean (f) <sup>b</sup> Range
Gamma Isotopic, 6				·	
<sup>7</sup> Be	56	67 (3/4) 54 - 86	T-42 <1 mi., ENE	86 (1/2)	77 (1/2)
<sup>40</sup> K	100	147 (4/4) 122 - 175	T-81 6 mi., S	169 (2/2) 163 – 175	236 (2/2) 231 - 241
<sup>58</sup> Co	6	<mda< td=""><td></td><td></td><td>&lt; MDA</td></mda<>			< MDA
<sup>60</sup> Co	7	<mda< td=""><td></td><td></td><td>&lt; MDA</td></mda<>			< MDA
<sup>134</sup> Cs	7	<mda< td=""><td></td><td></td><td>&lt; MDA</td></mda<>			< MDA
<sup>137</sup> Cs	7	<mda< td=""><td></td><td></td><td>5.5 (2/2)</td></mda<>			5.5 (2/2)
					5 - 6
<sup>210</sup> Pb		628 (4/4)	T-81	644 (2/2)	606 (2/2)
		584 - 676	6 mi., S	612 - 676	523 - 688
<sup>226</sup> Ra	15	447 (4/4) 328 - 566	T-81 6 mi., S	492 (2/2) 418 - 566	327 (2/2) 243 - 411
<sup>235</sup> U		55 (3/4)	T-81	61.5 (2/2)	42.5 (2/2)
		43 - 64	6 mi., S	59 - 64	38 - 47
<sup>238</sup> U		472 (3/4) 418 - 537	T-81 6 mi., S	498.5 (2/2) 460 - 537	478.5 (2/2) 336 - 621

Be-7, K-40, Pb-210, Ra-226, U-235 & U-238 are naturally occurring.

#### <u>TABLE 1</u> ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM ANNUAL SUMMARY Name of Facility <u>Turkey Point Units 3 & 4</u>, Docket No(s). <u>50-250 & 50-251</u> Location of Facility <u>Miami-Dade, Florida</u>, Reporting Period <u>January 1 - December 31, 2013</u> (County, State)

# PATHWAY: INGESTION SAMPLES COLLECTED: CRUSTACEA UNITS: pCi/kg, WET

			Location with Hig	hest Annual Mean	
			Name <sup>c</sup>	Mean (f) <sup>b</sup>	_
Type and Total Number of Analyses Performed	Lower Limit of Detection <sup>a</sup> (LLD)	All Indicator Locations Mean (f) Range	Distance & Direction	Range	Control Locations Mean (f) <sup>b</sup> Range
Gamma Isotopic, 3					
<sup>40</sup> K	270	1509 (3/3) 1067 - 1900	T-81 6 mi., S	1509 (3/3) 1067 - 1900	
<sup>226</sup> Ra	300				
<sup>54</sup> Mn	16				
<sup>59</sup> Fe	28				
<sup>58</sup> Co	15				
<sup>60</sup> Co	16				
<sup>65</sup> Zn	32				
<sup>134</sup> Cs	16				
<sup>137</sup> Cs	16	27 (1/3)	T-81 6 mi., S	27 (1/3)	

Blue Crabs were collected in the location T-81. No crustacea was collected at the control location in 2013.

# TABLE 1ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM ANNUAL SUMMARY<br/>Name of Facility Turkey Point Units 3 & 4, Docket No(s). 50-250 & 50-251Location of Facility Miami-Dade, Florida, Reporting Period January 1 - December 31, 2013<br/>(County, State)

# PATHWAY: INGESTION SAMPLES COLLECTED: FISH UNITS: pCi/kg, WET

			Location with Hig	hest Annual Mean	
			Name <sup>c</sup>	Mean (f) <sup>ь</sup>	_
Type and Total Number of Analyses Performed	Lower Limit of Detection <sup>a</sup> (LLD)	All Indicator Locations Mean (f) Range	Distance & Direction	Range	Control Locations Mean (f) <sup>♭</sup> Range
Gamma Isotopic, 4					
<sup>7</sup> Be		<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>40</sup> K	270	2419 (2/2) 2252- 2586	T-81 6 mi., S	2419 (2/2) 2252- 2586	2367 (2/2) 2272 - 2462
<sup>54</sup> Mn	16	<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>59</sup> Fe	28	<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>58</sup> Co	15	<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>60</sup> Co	16	<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>65</sup> Zn	32	<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>134</sup> Cs	16	<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>137</sup> Cs	16	<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>226</sup> Ra	300	<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>238</sup> U		<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>

Be-7, K-40, Pb-210, Ra-226 & U-238 are naturally occurring.

# TABLE 1 ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM ANNUAL SUMMARY Name of Facility <u>Turkey Point Units 3 & 4</u>, Docket No(s). <u>50-250 & 50-251</u> Location of Facility <u>Miami-Dade, Florida</u>, Reporting Period <u>January 1 - December 31, 2013</u> (County, State)

# PATHWAY: INGESTION SAMPLES COLLECTED: BROAD LEAF VEGETATION UNITS: pCi/kg, WET

			Location with Hig	hest Annual Mean	
			Name <sup>c</sup>	Mean (f) <sup>⊳</sup>	
Type and Total Number of Analyses Performed	Lower Limit of Detection <sup>a</sup> (LLD)	All Indicator Locations Mean (f)Range	Distance & Direction	Range	Control Locations Mean (f) <sup>b</sup> Range
Gamma Isotopic, 36			· · · · · · · · · · · · · · · · · · ·		
<sup>7</sup> Be	64	1642(24/24) 952 - 2410	T-40 3 mi., W	1644 (12/12) 952 - 2386	1607 (12/12) 995 - 2692
<sup>40</sup> K	120	4595 (24/24) 1931 - 6493	T-40 3 mi., W	4649 (12/12) 1931 - 6144	4946 (12/12) 4195 - 6512
<sup>58</sup> Co	6	<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>60</sup> Co	8	<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>131</sup> I	9	<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>134</sup> Cs	8	<mda< td=""><td></td><td></td><td><mda< td=""></mda<></td></mda<>			<mda< td=""></mda<>
<sup>137</sup> Cs	8	69.2 (24/24) 18 - 231	T-41 2 mi., W/NW	96 (12/12) 18 - 231	14 (2/12) 5 - 23
<sup>210</sup> Pb		390 (7/24) 264 – 792	T-41 2 mi., W/NW	508 (3/12) 325 - 792	566 (6/12) 246 - 1270
<sup>226</sup> Ra	189	796 (1/24)	T-40 3 mi., W	796 (1/24)	<mda< td=""></mda<>

Be-7, K-40, Pb-210 & Ra-226 are naturally occurring.

# TABLE 1ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM ANNUAL SUMMARY<br/>Name of Facility Turkey Point Units 3 & 4, Docket No(s). 50-250 & 50-251Location of Facility Miami-Dade, Florida \_, Reporting Period January 1 - December 31, 2013<br/>(County, State)

### NOTES

a. The LLD is an "a priori" lower limit of detection which establishes the smallest concentration of radioactive material in a sample that will yield a net count above system background that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a real signal.

LLDs in this column are at time of measurement. The MDAs reported in Attachment B for the individual samples have been corrected to the time of sample collection.

- b. Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f).
- c. Specific identifying information for each sample location is provided in Attachment A.
- d. Results were based upon the average net response of three elements in a TLD. (Thermoluminescent Dosimeter).

MDA refers to minimum detectable activity.

(Page 1 of 4)

# **DEVIATIONS / MISSING DATA**

<b>A)</b>	Pathway:	Direct Exposure - TLDs
	Location:	W-1 On site north side of discharge canal. 0.7 miles West
	Dates:	12/11/12 to 3/26/13
	Deviation:	Failure to provide continuous monitoring.
	Description of Problem:	TLD missing; discovered at collection attempt
	Corrective action	Replaced TLD
B)	Pathway	Airborne – Particulates and iodine
	Location:	T-58, 1.3 miles Northwest
	Dates:	2/6/13
	Deviation:	Estimated run time of 119.7 out of 168.2 hours.
	Description of Problem:	Pump failure.
	Corrective Action:	Pump replaced upon discovery.
C)	Pathway	Airborne – Particulates and iodine
	Location:	T-51, 2.2 miles North Northwest
	Dates:	2/12/13
	Deviation:	Estimated run time 107.5 out of 144.3 hours.
	Description of Problem:	Power failure resulted in shorter collection time for sample.
	Corrective Action	Power was restored upon discovery.
D)	Pathway	Airborne – Particulates and iodine
	Location:	T-51, 2.2 miles North Northwest
	Dates:	2/18/13
	Deviation:	Estimated run time 117.4 out of 141.3
	Description of Problem:	Lower sample flow rate discovered.
	Corrective Action:	Sample flow adjusted to correct flow rate.

-

# (Page 2 of 4)

		DEVIATIONS / MISSING DATA
E)	Pathway	Airborne – Particulates and iodine
	Location:	T-57, 4 miles Northwest
	Dates:	2/18/13
	Deviation:	Estimated run time of 94 out of 144 hours.
	Description of Problem:	Lower sample flow rate discovered.
	Corrective Action:	Sample flow adjusted to correct flow rate.
F)	Pathway:	Direct Exposure - TLDs
	Location:	WSW-8, 7.8 miles West Southwest
	Dates:	3/26/13 to 5/4/13
	Deviation:	No data reported
	Description of Problem:	Data lost due to a computer error.
	Corrective Action:	Compared sample results from the first and fourth quarter. Doses within acceptable range.
G)	Pathway	Airborne – Particulates and iodine
	Location:	T-57, 4 miles Northwest
	Dates:	4/24/13
	Deviation:	Estimated run time of 62.3 out of 168.2 hours.
	Description of Problem:	Lower sample flow rate discovered.
	Corrective Action	Sample flow adjusted to correct flow rate.
H)	Pathway	Airborne – Particulates and iodine
	Location:	T-51, 2.2 miles North Northwest
	Dates:	5/29/13
	Deviation:	Estimated run time 155 out of 193.4 hours.
	Description of Problem:	Power failure resulted in shorter collection time for sample.
	Corrective Action	Power was restored upon discovery.

# (Page 3 of 4)

# **DEVIATIONS / MISSING DATA**

I)	Pathway	Direct Exposure - TLDs
	Location:	WNW2 Palm Drive West of FPL Satellite School, near site boundary
	Dates:	N/A
	Deviation:	WNW2 State of FL DOH had been reporting this TLD as part of the supplemental report. WNW2 TLD is part of the ODCM.
	Description of Problem:	Supplemental TLD was moved from the Supplemental samples to the ODCM required samples and quarterly reports from FL DOH did not reflect change.
	Corrective Action	FL DOH has fixed report and will report WNW2 as part of the ODCM required samples. The ODCM has bee updated to reflect WNW2 as part of the required TLDs and removed T-41. No samples were missed.
J)	Pathway	MAPEP
	Location:	N/A
	Dates:	7/10/1013
	Deviation:	REMP MAPEP series 28 results for Beta on Air Filter not acceptable from the State of FL DOH.
	Description of Problem:	FL DOH analyst used incorrect spreadsheet to calculate the Gross Beta. This resulted in a value of 1.53 Bq/sample which was outside the range of .43 to 1.28 Bq/sample. The unacceptable results were not verified by FL DOH prior to sending to MAPEP.
	Corrective Action	Correct spreadsheet used for the calculation and the final result was 1.04 Bq/sample, which is well within the limits. State of FL DOH updated procedure QP-F "Quality Verification" to ensure results are verified prior to submittal.
K)	Pathway	Airborne – Particulates and iodine
	Location:	T-64 Natoma Substation, 2475 SW 16 Ct. 22 miles from site.
	Dates:	7/17/13 - 7/30/13
	Deviation:	Air sampler T-64 experienced low sample flow three weeks in a row. First week 108.6 out of 169.9 hours of run time, second week 97.4 out of 144 hours, and the third week 73 out of 168.8 and pump was found not running.
	Description of Problem:	Sample pump failure led to lower sample run time.
	Corrective Action	Pump was replaced.

# ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4 <u>TABLE 1A</u>

# (Page 4 of 4)

# **DEVIATIONS / MISSING DATA**

L)	Pathway	MAPEP
	Location:	N/A
	Dates:	11/30/13
	Deviation:	Not acceptable results for Co-57
	Description of Problem:	False positive results due to incorrect analyte library used in the gamma spec system.
	Corrective Action	FLDOH procedures changed to use the Nuclear Power library in the gamma spec analysis. Once the Nuclear Power library was used Co-57 was no longer misidentified.
M)	Pathway	Airborne – Particulates and iodines
	Location:	T-58, Turkey Point entrance road, 1.3 miles NW
	Dates:	10/16/13 - 10/21/13
	Deviation:	No sample taken due to power outage
	Description of Problem:	Damaged power supply caused lost of sampler. Estimated run time 116.6 of 192.1 hours.
	Corrective Action	Power supply repaired on 10/21/13 at 1800 with a temporary power line since the permanent is under ground. Permanent repairs are scheduled for 2014.
N)	Pathway	Airborne – Particulates and iodine
	Location:	Entrance to Homestead Bay Front Park, 2.2 mi NNW
	Dates:	12/16/13 to 12/23/13
	Deviation:	Power failure
	Description of Problem:	Power failure with an estimated runtime of 30.6 out of 122.3 hours.
	Corrective Action	Power restored on 12/17/13 at 1700.
0)	Pathway	Crustacea
	Location:	T-67 Biscayne Bay, vicinity of Cutler Plant nor to Matheson Hammock Park.
		N, NNE 13-18 miles from the plant.
	Dates:	1/1/13 to 12/31/13
	Deviation:	No crustacea collected in the control site for 2013.
	Description of Problem:	No comparison to blue crab collected in T81 could be made.
	Corrective Action	State of FL continues to set traps with proper bate.

# (Page 1 of 1)

# ANALYSIS WITH LLDs ABOVE ODCM TABLE 5.1-3 DETECTION CAPABILITIES 1/1/2013 – 12/31/2013

None

The values specified in ODCM Table 5.1-3, Detection Capabilities

# LAND USE CENSUS (Page 1 of 5)

The range (miles) and the bearing (degrees) from the plant are summarized for each receptor type in the table below.

SECTOR	NEAREST RESIDENCE	NEAREST GARDEN (A)	NEAREST MILK ANIMAL
N	1.9 mi @ 349° 2.0 mi @ 354°	*	*
NNE	*	*	*
NE	*	*	*
ENE	*	*	*
E	*	*	*
ESE	*	*	*
SE	*	*	*
SSE	*	*	*
S	*	*	*
SSW	*	*	*
SW	*	*	*
WSW	*	*	*
W	*	*	*
WNW	3.7 mi @ 302° 4.5 mi @ 303°	4.5 mi @ 303° 4.7 mi @ 303°	*
NW	3.7 mi @ 311° 3.9 mi @ 314°	*	*
NNW	4.4 mi @ 333°	4.6 mi @ 327°	*

(A) - Only gardens with an estimated total area of 500 square feet, or more, and producing green leafy vegetables are considered.

\* - No suitable sites were located within a five-mile range.

# ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4 <u>TABLE 2</u>

# LAND USE CENSUS (Page 2 of 5)

	Range				
Sector	Bearing	Nearest Residence Location			
N (A)	<u>1.9 miles</u> 349°	This is the Homestead Bayfront Park complex. Contact is Jim White. Hours are 6 a.m. to 12 a.m. with security from 5 p.m. to 7 a.m. There is occasional overnight recreational occupancy (up to 4 nights) on boats at the marina. There are 30 workers at the park working various hours 7 days a week; number of daily workers sometimes varies. There is always someone here 24 hours with more workers in the summer than the rest of the year (February thru September have the highest peak of workers). New restaurant called LaPlaya opened at the park with 6 to 8 employees. N25° 27.683' W80° 20.200'.			
N (B)	<u>2.0 miles</u> 354°	Biscayne National Park at Convoy Point. There are 3 trailer pads with full utility hookups for volunteers who provide their own RV's or trailers staying for up to 6 months. There are 2 residences: one is for up to 4 occupants, volunteers and/or interns and the other for a law enforcement officer and family. From Monday to Friday up to 50 daytime workers may be present. During the weekend, up to 20 events may be occurring. N25° 27.817' W80° 20.067'.			
NNE	No residences w	ere located within a five-mile range.			
NE	No residences w	No residences were located within a five-mile range.			
ENE	No residences w	No residences were located within a five-mile range.			
E	No residences were located within a five-mile range.				
ESE	No residences w	ere located within a five-mile range.			
SE	No residences w	ere located within a five-mile range.			
SSE	No residences w	No residences were located within a five-mile range.			
S	No residences w	ere located within a five-mile range.			
SSW	No residences w	ere located within a five-mile range.			
SW	No residences w	No residences were located within a five-mile range.			
WSW	No residences w	No residences were located within a five-mile range.			
W	No residences w	ere located within a five-mile range.			
WNW (A)	<u>1.7 miles</u> 302°	FP&L operates a daycare center for its employees and a shooting range near the entrance to the Turkey Point Plant. These facilities are occupied during normal business hours and can have anywhere from 20-40 people present at the facility for training purposes. N25° 26.817' W80° 21.217'.			

## ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4

# TABLE 2

# LAND USE CENSUS (Page 3 of 5)

Sector	<u>Range</u> Bearing	Nearest Residence Location
WNW (B)	<u>3.7 miles</u> 302°	Usually three people (a couple and their son) live at 11790 Canal Drive on the south side of Canal Drive (SW 328 St) west of SW 117th Avenue (no gardens). This year the gate was locked. N25° 27.767' W80° 22.867'.
WNW (C)	<u>4.5 miles</u> 303°	Usually two people (an Asian man and his wife) live on a small farm where mainly guava is grown south of Mowry Dr. (SW 320th St) and about 0.6 miles west of Allapattah Road (SW 117th Ave). There are three small trailers onsite. This year a driveway chain prevented access. N25° 28.217' W80° 23.467', N25° 28.126' W80° 23.439' and N25° 28.156' W80° 23.439'.
NW (A)	<u>3.6 miles</u> 304°	The Delta Homestead Landfill (a subsidiary of Waste Management) is located north of Canal Drive (SW 328 <sup>th</sup> St) and east of SW 117 <sup>th</sup> Ave. There are 10 full time workers onsite Monday thru Friday usually from 7 a.m. to 4 p.m., although the schedules can sometimes vary. N25° 27.833' W80° 22.767'.
NW (B)	<u>3.7 miles</u> 311°	Employees at Snapper Creek Nurseries indicated they have seen a couple of people working at this location but not known if they live at an old farmhouse just south of the Mowry Canal east of SW 117th Ave. The information could not be confirmed because gates were locked which prevents access to the property. N25° 28.217' W80° 22.567'.
NW (C)	<u>3.9 miles</u> 314°	There is 24-hour security staffing at the Snapper Creek Nurseries located at 316 <sup>th</sup> Street and 117 <sup>th</sup> Avenue. There is one man who lives in a trailer on the premises and 8 workers that work Monday thru Saturday 7 am to 5 pm. N25° 28.444' W80° 22.560'.
NNW (A)	<u>4.4 miles</u> 333°	This nursery recently changed ownership. Louis Rodriguez is new owner, but nursery does not have a name. There are 2 workers Monday thru Friday during the day at 29800 SW 107th Ave, just north of the Military Canal on the west side of Allapattah Rd (SW 107th Av). N25° 29.450' W80° 21.817'.
NNW (B)	<u>4.6 miles</u> 327°	Unable to gain access because of a locked gate or locate someone to obtain more information in order to verify past data. In years past someone had lived at this location west of SW 107 <sup>th</sup> Ave and north of Military Canal. N25° 29.367' W80° 22.283'.

# TABLE 2

# LAND USE CENSUS (Page 4 of 5)

· . -

Sector	<u>Range</u> Bearing	Nearest Garden Location (with estimated total area of 500 square feet, or more, and producing green leafy vegetables).			
Ν	No suitable gardens were located within a five-mile range.				
NNE	No suitable garden	s were located within a five-mile range.			
NE	No suitable garden	s were located within a five-mile range.			
ENE	No suitable garden	s were located within a five-mile range.			
Е	No suitable garden	s were located within a five-mile range.			
ESE	No suitable garden	s were located within a five-mile range.			
SE	No suitable garden	s were located within a five-mile range.			
SSE	No suitable garden	s were located within a five-mile range.			
S	No suitable garden	No suitable gardens were located within a five-mile range.			
SSW	No suitable gardens were located within a five-mile range.				
SW	No suitable garden	s were located within a five-mile range.			
WSW	No suitable garden	s were located within a five-mile range.			
W	No suitable garden	s were located within a five-mile range.			
WNW (A)	<u>4.5 miles</u> 303°	Mint, guava (mostly), peppers and bananas have been grown at the small farm run by an Asian family south of Mowry Drive (SW 320th St) and about 0.6 miles west of Allapattah Rd (SW 117th Ave). This year a locked chain link fence prevented access, but site appears unchanged. N25° 28.217' W80° 23.467'.			
WNW (B)	<u>4.7 miles</u> 303°	Guava, small amounts of squash and eggplant are being grown at a small farm north of Mowry Dr. (SW 320th St) and about 0.8 miles west of Allapattah Rd. (SW 117th Ave) (run by an Asian man, who does not live on the farm). N25° 28.265' W80° 23.618'.			

# ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4 <u>TABLE 2</u>

# LAND USE CENSUS (Page 5 of 5)

Sector	<u>Range</u> Bearing	Nearest Garden Location (with estimated total area of 500 square feet, or more, and producing green leafy vegetables).
WNW (C)	<u>4.8 miles</u> 302°	Located at the northeast corner of the intersection of SW 127 <sup>th</sup> Ave and SW 320 <sup>th</sup> Street. This is an inaccessible grove with coconut palms, some banana trees and a few avocado trees which appears to be unattended. N25° 28.250' W80° 23.750'.
WNW (D)	<u>6.0 miles</u> 295°	Farm Share, Inc at 14125 SW 320 <sup>th</sup> St, where farmers donate locally grown produce to be given to charitable organizations. Produce donations usually start in November and run through April. There are usually 15 workers present from 8 am to 4:30pm Monday thru Friday. The produce usually donated is tomatoes, squash and green beans. N25° 28.255' W80° 25.111'.
NNW	<u>4.6 miles</u> 327°	Unable to gain access because of a locked gate or locate someone to obtain more information. In years past someone had lived at this location west of SW 107 <sup>th</sup> Ave and north of Military Canal. Bananas, plantains and coconuts have been seen growing here. N25° 29.367' W80° 22.283'.

Note: At the time of our survey, many fields in the area surveyed were bare soil or cover crops. Other than the sites already described above, the only non-ornamental crops known to have been grown in the survey area were: bananas, beans, corn, guava, malanga, papaya, eggplant, sorghum, squash, sugar cane, tambis, okra and melon.

# ATTACHMENT A

KEY TO SAMPLE LOCATIONS

# 2013 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4 <u>NEAR SITE SAMPLING LOCATIONS</u>



(Page 1 of 6)

# 2013 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4 <u>DISTANT REMP SAMPLING LOCATIONS</u>





# ATTACHMENT A

(Page 3 of 6)

PATHWAY: DIRECT RADIATION SAMPLES COLLECTED: TLD SAMPLE COLLECTION FREQUENCY: QUARTERLY

-

Location <sup>(a)</sup> Name	Description
N-2	Convey Point, Parking Area
N-7	Black Point Marina Parking Lot
N-10	Old Cutler Rd, approx, 196th Street
NNW-2	East End North Canal Road
NNW-10	Bailes Road & U.S. #1
NW-1	Turkey Point Entrance Road
NW-5	Mowry Drive & 117th Avenue
NW-10	Newton Road, North of Coconut Palm Drive
WNW-2	Satellite School
WNW-10	Homestead Middle School
W-1	On-Site, North Side of Discharge Canal
W-5	Palm Drive & Tallahassee Road
W-9	Card Sound Road, 0.6 mile from U.S. #1
WSW-8	Card Sound Road, 3.4 miles from U.S. #1
SW-1	On-Site near Land Utilization Offices
SW-8	Card Sound Road, 5 miles from U.S. #1
SSW-5	On-Site, Southwest Corner of Cooling Canals
SSW-10	Card Sound Road, west side of Toll Plaza
S-5	On-Site, South East Corner of Cooling Canals
S-10	Card Sound Road at Steamboat Creek
SSE-1	Turtle Point
SSE-10	Ocean Reef
Control	

Control NNE-22

.

Natoma Substation, 2475 SW 16 Ct.

<sup>&</sup>lt;sup>a</sup>The location name is the direction sector - approximate distance (miles)

# 2013 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4 <u>ATTACHMENT A</u>

(Page 4 of 6)

# PATHWAY: AIRBORNE SAMPLES COLLECTED: RADIOIODINE AND PARTICULATES SAMPLE COLLECTION FREQUENCY: WEEKLY

Location <u>Name</u>	Direction <u>Sector</u>	Approximate Distance <u>(miles)</u>	Description
T-51	NNW	2	Entrance Area to Biscayne National Park
T-57	NW	4	SW 107th Avenue at Mowry Canal
T-58	NW	1	Turkey Point Entrance Road
T-72	WSW	<1	Just before entrance to Land Utilization's access gate.

Control:				
T-64	NNE	22	Natoma Substation,	2475 SW 16 Ct.

### ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4

# ATTACHMENT A

#### (Page 5 of 5)

# PATHWAY: WATERBORNE SAMPLES COLLECTED: SURFACE WATER (OCEAN) SAMPLE COLLECTION FREQUENCY: MONTHLY

Location <u>Name</u>	Direction Sector	Approximate Distance <u>(miles)</u>	Description
T-42	ENE	<1	Biscayne Bay at Turkey Point
T-81	S	6	Card Sound, near Mouth of Old Discharge Canal
Control:			
T-67	N, NNE	13-18	Near Biscayne Bay, Vicinity of Cutler Plant, North to Matheson Hammock Park

# SAMPLES COLLECTED: SHORELINE SEDIMENT SAMPLE COLLECTION FREQUENCY: SEMI-ANNUALLY

Location <u>Name</u>	Direction Sector	Approximate Distance <u>(miles)</u>	<u>Description</u>
T-42	ENE	<1	Biscayne Bay at Turkey Point
T-81	S	6	Card Sound, near Mouth of Old Discharge Canal
Control:			
T-67	N, NNE	13-18	Near Biscayne Bay, Vicinity of Cutler Plant, North to Matheson Hammock Park

# ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4 <u>ATTACHMENT A</u>

# (Page 6 of 6)

# PATHWAY: INGESTION SAMPLES COLLECTED: CRUSTACEA AND FISH SAMPLE COLLECTION FREQUENCY: SEMI-ANNUALLY

Location <u>Name</u>	Direction Sector	Approximate Distance _ (miles)	Description
T-81	S	6	Card Sound Vicinity of Turkey Point Facility
<u>Control</u> :			
T-67	N, NNE	13-18	Near Biscayne Bay, Vicinity of Cutler Plant, North to Matheson Hammock Park

# SAMPLES COLLECTED: BROAD LEAF VEGETATION SAMPLE COLLECTION FREQUENCY: MONTHLY

Location <u>Name</u>	Direction <u>Sector</u>	Approximate Distance <u>(miles)</u>	<u>Description</u>
T-40	W	3	South of Palm Dr. on S.W. 117th Street Extension
T-41	WNW	2	Palm Dr., West of Old Missile Site near Plant Site Boundary
Control:			
T-67	N, NNE	13-18	Near Biscayne Bay, Vicinity of Cutler Plant, North to Matheson Hammock Park

# 2013 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4 <u>ATTACHMENT B</u>

### RADIOLOGICAL SURVEILLANCE OF

## FLORIDA POWER AND LIGHT COMPANY'S

..

### TURKEY POINT SITE

#### 2013

First Quarter, 2013

Second Quarter, 2013

Third Quarter, 2013

Fourth Quarter, 2013
## 2013 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4 <u>ATTACHMENT B</u>



1

#### RADIOLOGICAL SURVEILLANCE

OF

FLORIDA POWER AND LIGHT COMPANY

**TURKEY POINT SITE** 

FIRST QUARTER 2013

BUREAU OF RADIATION CONTROL

#### 2013 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT **TURKEY POINT PLANT – UNITS 3 & 4** TURKEY POINT SITE

#### Offsite Dose Calculation Manual Sampling

### First Quarter, 2013

Sample Type	Collection Frequency	Number of Sample Locations	Number of <u>Samples</u>
1. Direct Radiation	Quarterly	22	21
2. Airborne 2.a. Air Iodines	Weekly	6	78
2.b. Air Particulates	Weekly	6	78
<ol> <li>Waterborne</li> <li>3.a. Surface Water</li> </ol>	Monthly	3	9
3.b. Shoreline Sediment	Semiannually	3	3
4. Ingestion 4.a. Fish and Invertebrates			
4.a.1. Crustacea	Semiannually	2	0
4.a.2. Fish	Semiannually	2	2
4.b. Broadleaf Vegetation	Monthly	3	9
			Total: 200

NOTE: Measurement results having magnitudes that are significantly above the background of the measurement system are reported as net values plus or minus a one-standard-deviation error term. Measurement results that are not significantly above background are reported as less than a Lower Limit of Detection (<LLD), which is an estimated upper limit (with at least 95% confidence) for the true activity in the sample.

The marine fauna listed in this report were collected in part, under Florida FWC SAL030.

1. DIRECT RADIATION - TLD's - (µR/hour)

Deployment 11-Dec-12 Collection 26-Mar-13	Sample Site	Deployment 11-Dec-12 Collection 26-Mar-13
$4.15 \pm 0.05$	WSW-8	$3.37 \pm 0.07$
$3.28 \pm 0.26$		
$3.72 \pm 0.25$	SW-1	$3.11 \pm 0.27$
	SW-8	$2.98 \pm 0.20$
$3.26 \pm 0.22$		
$3.67 \pm 0.31$	SSW-5	$3.11 \pm 0.20$
	SSW-10	$3.25 \pm 0.31$
$4.15 \pm 0.39$		
$3.18 \pm 0.03$	S-5	$3.01 \pm 0.53$
$4.68 \pm 0.34$	S-10	$3.51 \pm 0.31$
$4.14 \pm 0.21$	SSE-1	$2.79 \pm 0.10$
	SSE-10	$3.11 \pm 0.25$
(A)		
$3.31 \pm 0.18$	NNE-22	$3.93 \pm 0.15$
$3.43\pm0.04$		
	Deployment 11-Dec-12 Collection 26-Mar-13 4.15 $\pm$ 0.05 3.28 $\pm$ 0.26 3.72 $\pm$ 0.25 3.26 $\pm$ 0.22 3.67 $\pm$ 0.31 4.15 $\pm$ 0.39 3.18 $\pm$ 0.03 4.68 $\pm$ 0.34 4.14 $\pm$ 0.21 (A) 3.31 $\pm$ 0.18 3.43 $\pm$ 0.04	Deployment11-Dec-12 SiteSample Site $4.15 \pm 0.05$ WSW-8 $3.28 \pm 0.26$ $3.72 \pm 0.25$ $3.72 \pm 0.25$ SW-1 SW-8 $3.26 \pm 0.22$ $3.67 \pm 0.31$ $3.67 \pm 0.31$ SSW-5 SSW-10 $4.15 \pm 0.39$ $5.5$ $4.68 \pm 0.34$ $4.14 \pm 0.21$ SSE-1 SSE-10(A) $3.31 \pm 0.18$ NNE-22 $3.43 \pm 0.04$ NNE-22

(A) TLD missing.

## 2.a. IODINE-131 IN WEEKLY AIR CARTRIDGES - (pCi/m<sup>3</sup>)

Collection Date						
	T41	T51	T57	T58	T64	T72
02-Jan-13	< 0.03	< 0.03	< 0.02	< 0.02	< 0.02	< 0.03
08-Jan-13	< 0.03	<0.03	< 0.03	< 0.03	< 0.03	< 0.03
16-Jan-13	< 0.02	< 0.03	<0.02	< 0.02	< 0.02	<0.03
23-Jan-13	< 0.02	<0.02	< 0.02	< 0.02	< 0.02	< 0.02
30-Jan-13	< 0.03	< 0.03	< 0.02	< 0.03	< 0.03	< 0.03
06-Feb-13	< 0.02	< 0.02	< 0.02	<0.03(A)	< 0.02	< 0.02
12-Feb-13	< 0.02	<0.02(B)	< 0.02	< 0.02	< 0.03	< 0.02
18-Feb-13	< 0.04	<0.02(C)	<0.02(D)	< 0.04	< 0.04	<0.04
25-Feb-13	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03
05-Mar-13	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03
12-Mar-13	< 0.03	< 0.03	< 0.03	< 0.04	< 0.03	< 0.04
18-Mar-13	< 0.03	<0.03	< 0.03	< 0.03	< 0.03	< 0.04
25-Mar-13	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03

(A) Pump failed and was replaced. Estimated run time 119.7 out of 168.2 hours.

(B) Power failure to air station. Estimated run time 107.5 out of 144.3 hours.

(C) Estimated run time 117.4 out of 141.3 hours; unknown reason for a lower flow rate.

(D) Estimated run time 94 out of 144 hours; unknown reason for a lower flow rate.

## 2.b.1. AIR PARTICULATES - GROSS BETA - (pCi/m<sup>3</sup>)

Collection Date	T41	T51	T57	T58	T64	T72
02-Jan-13	$0.014 \pm 0.002$	$0.012 \pm 0.002$	$0.016 \pm 0.002$	$0.015 \pm 0.002$	$0.015 \pm 0.002$	$0.019 \pm 0.002$
08-Jan-13	$0.010\pm0.002$	$0.011 \pm 0.002$	$0.006\pm0.002$	$0.008\pm0.002$	$0.005 \pm 0.002$	$0.010 \pm 0.002$
16-Jan-13	$0.008\pm0.002$	$0.006 \pm 0.002$	$0.010 \pm 0.002$	$0.007\pm0.002$	$0.009\pm0.002$	$0.008 \pm 0.002$
23-Jan-13	$0.014\pm0.002$	$0.012\pm0.002$	$0.011 \pm 0.002$	$0.016\pm0.002$	$0.008 \pm 0.002$	$0.013 \pm 0.002$
30-Jan-13	$0.025 \pm 0.003$	$0.025 \pm 0.003$	$0.025 \pm 0.003$	$0.025 \pm 0.002$	$0.030 \pm 0.003$	$0.027 \pm 0.003$
06-Feb-13	$0.014 \pm 0.002$	$0.018\pm0.002$	$0.016 \pm 0.002$	$0.013 \pm 0.003(A)$	$0.011 \pm 0.002$	$0.012 \pm 0.002$
12-Feb-13	$0.017 \pm 0.002$	$0.014 \pm 0.003(B)$	$0.017\pm0.002$	$0.015\pm0.002$	$0.014\pm0.002$	$0.011 \pm 0.002$
18-Feb-13	$0.014 \pm 0.002$	$0.012 \pm 0.003(C)$	$0.017 \pm 0.003(D)$	$0.014\pm0.002$	$0.014\pm0.002$	$0.009\pm0.002$
25-Feb-13	$0.013 \pm 0.002$	$0.009\pm0.002$	$0.011 \pm 0.002$	$0.012 \pm 0.002$	$0.014 \pm 0.002$	$0.012 \pm 0.002$
05-Mar-13	$0.020\pm0.002$	$0.022 \pm 0.002$	$0.021 \pm 0.002$	$0.017\pm0.002$	$0.017\pm0.002$	$0.017\pm0.002$
12-Mar-13	$0.014 \pm 0.002$	$0.016 \pm 0.002$	$0.010\pm0.002$	$0.011 \pm 0.002$	$0.010 \pm 0.002$	$0.012\pm0.002$
18-Mar-13	$0.020 \pm 0.003$	$0.023 \pm 0.003$	$0.019 \pm 0.003$	$0.020 \pm 0.003$	$0.015 \pm 0.002$	$0.020 \pm 0.003$
25-Mar-13	$0.016 \pm 0.002$	$0.014 \pm 0.002$	$0.015 \pm 0.002$	$0.017 \pm 0.002$	$0.019 \pm 0.002$	$0.013 \pm 0.002$
Average:	$0.015 \pm 0.001$	$0.015 \pm 0.001$	$0.015 \pm 0.001$	$0.014 \pm 0.001$	$0.014 \pm 0.001$	$0.014 \pm 0.001$

(A) Pump failed and was replaced. Estimated run time 119.7 out of 168.2 hours.

(B) Power failure to air station. Estimated run time 107.5 out of 144.3 hours.

(C) Estimated run time 117.4 out of 141.3 hours; unknown reason for a lower flow rate.

(D) Estimated run time 94 out of 144 hours; unknown reason for a lower flow rate.

#### 2.b.2. AIR PARTICULATES - GAMMA ANALYSIS OF QUARTERLY COMPOSITES - (pCi/m<sup>3</sup>)

Sample Site	<u>Be-7</u>	<u>K-40</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>
T41	$0.1180 \pm 0.0124$	< 0.0216	< 0.0009	< 0.0009	<0.0648
T51	$0.1080 \pm 0.0099$	< 0.0234	< 0.0013	<0.0009	< 0.0643
T57	$0.1124 \pm 0.0106$	< 0.0281	< 0.0014	<0.0008	< 0.0563
T58	$0.1036 \pm 0.0079$	< 0.0175	< 0.0012	< 0.0012	< 0.0083
T64	$0.1071 \pm 0.0101$	< 0.0181	<0.0017	< 0.0012	$0.0556 \pm 0.0175$
T72	$0.1120 \pm 0.0105$	< 0.0228	< 0.0014	< 0.0010	< 0.0688

#### 3.a. SURFACE WATER - (pCi/L)

Sample <u>Site</u>	Collection <u>Date</u>	<u>H-3</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	Zr-95 <u>Nb-95</u> (A)	<u>1-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	Ba-140 <u>La-140</u> (B)
T42	09-Jan-13	<137	245 ± 17	<3	<2	<6	<3	<5	<4	<4	<3	<3	<4
	18-Feb-13	<140	249 ± 29	<5	<5	<7	<8	<13	<9	<6	<5	<6	<8
	19-Mar-13	<141	$262 \pm 20$	<3	<3	<6	<3	<7	<6	<5	<3	<3	<4
T67	09-Jan-13	<137	88 ± 21	<6	<5	<11	<6	<15	<13	<	<7	<7	<9
	19-Feb-13	<168	81 ± 22	<5	<5	<10	<8	<12	<8	<6	<5	<6	<9
	18-Mar-13	<141	$20 \pm 7$	<3	<3	<6	<3	<7	<5	<5	<3	<3	<5
T81	08-Jan-13	<169	317 ± 32	<4	<4	<9	<6	<8	<7	<7	<4	<4	<5
	19-Feb-13	<140	339 ± 63	<3	<3	<6	<3	<8	<5	<4	<3	<3	<5
	18-Mar-13	<141	361 ± 65	<3	<3	<7	<3	<7	<5	<6	<3	<3	<5

(A) - These tabulated LLD values for Zr/Nb-95 are the higher of the individual parent or daughter LLD's.

(B) - These tabulated LLD values are for Ba-140, either based on direct measurement of Ba-140 or based on ingrowth of La-140, whichever method yields the greater sensitivity for a given sample.

#### 3.b. SHORELINE SEDIMENT - (pCi/kg, dry weight)

Sample Site	Collection Date												
. —		<u>Be-7</u>	<u>K-40</u>	<u>Co-58</u>	<u>Co-60</u>	<u>Cs-</u>	<u>134</u>	<u>Cs-137</u>	<u>Pb-210</u>	<u>Ra-226</u>	<u>Th-232</u>	<u>U-235</u>	<u>U-238</u>
T42	09-Jan-13	<75	127 ± 22	<8	<7	<	7	<7	$584 \pm 88$	328 ± 126	<32	44 ± 6	377 ± 24
T67	09-Jan-13	<78	241 ± 31	<8	<7	<	8	5 ± 2	523 ± 83	411 ± 99	<38	$47 \pm 3$	$336\pm28$
T81	08-Jan-13	54 ± 15	175 ± 26	<8	<8	<	8	<8	676 ± 101	418 ± 117	<35	59 ± 6	$537\pm30$
<u>4.a.1.</u>	<u>CRUSTACEA - M</u>	lixed Specie	es - (pCi/kg, wo	et weight)									
Sam <u>Si</u> r	iple Collect te Date	ion 2	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>	
Т	31 Th	is sample to	be collected.										
<u>4.a.2. I</u>	FISH - Mixed Spe	cies - (pCi/l	kg, wet weight)	1									
Sam <u>Si</u> i	iple Collect te <u>Date</u>	ion <u>:</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>	
те	57 30-Jan-	-13	2462 ± 482	<18	<19	<41	<20	<42	<23	<22	<372	<79	
Τ8	31 10-Jan-	-13	2586 ± 170	<22	<18	<38	<18	<48	<22	<22	<370	<89	

## 4.b. BROADLEAF VEGETATION - Brazilian Pepper - (pCi/kg, wet weight)

Sample Site	Collection Date	Be-7	K-40	<u> </u>	Cs-134	Cs-137	Pb-210	Ra-226	<u>Ra-228</u>
T40	10-Jan-13	1168 ± 83	4304 ± 235	<11	<6	$32 \pm 3$	<149	<166	<33
	19-Feb-13	1921 ± 139	5456 ± 275	<29	<21	51 ± 11	<3594	<415	<76
	19-Mar-13	1644 ± 102	6144 ± 233	<20	<11	$22 \pm 3$	<1048	<256	<45
T41	10-Jan-13	$1719 \pm 54$	6493 ± 130	<12	<9	23 ± 5	792 ± 292	<196	<35
	19-Feb-13	1715 ± 110	2567 ± 179	<29	<14	201 ± 14	<3087	<314	<60
	19-Mar-13	1443 ± 121	6043 ± 319	<19	<11	<6	$325\pm62$	<219	<43
Т67	09-Jan-13	$1075 \pm 81$	4341 ± 164	<20	<13	<16	<1198	<292	<50
	19-Feb-13	2015 ± 133	4764 ± 230	<30	<20	<17	<3646	<359	<80
	18-Mar-13	$2264\pm73$	5413 ± 289	<18	<8	23 ± 1	754 ± 96	<206	<34

#### 2013

## ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT

TURKEY POINT PLANT – UNITS 3 & 4

TURKEY POINT SITE

#### Supplemental Sampling

#### First Quarter, 2013

Sample Type	Collection Frequency	Number of Sample Locations	Number of <u>Samples</u>
1. Direct Radiation	Quarterly	11	11
2. Airborne			
2.a. Air Iodines	Weekly	2	26
2.b. Air Particulates	Weekly	2	26
3. Waterborne			
3.a. Surface Water	Monthly	4	12
3.b. Shoreline Sediment	Semiannually	10	10
3.c. Aquatic Vegetation	Quarterly	1	1
4. Ingestion			
4.a. Milk	Semiannually	1	0
4.b. Marine Life	Semiannually	1	1
4.c. Food Crops	At Harvest	3	2
			Total: 89

NOTE: Measurement results having magnitudes that are significantly above the background of the measurement system are reported as net values plus or minus a one-standard-deviation error term. Measurement results that are <u>not</u> significantly above background are reported as less than a Lower Limit of Detection (<LLD), which is an estimated upper limit (with at least 95% confidence) for the true activity in the sample.

1. DIRECT\_RADIATION - TLD's - (µR/hour)

Sample Site	Deployment 11-Dec-12 Collection 26-Mar-13
NNW-6	$3.45 \pm 0.29$
NW-7	$3.98 \pm 0.26$
NW-8	$3.97\pm0.45$
WNW-2	$3.63 \pm 0.64$
WNW-3	$3.84 \pm 0.10$
WNW-6	$3.64 \pm 0.17$
W-8	$3.77 \pm 0.44$
ENE-1	$3.00 \pm 0.05$
T72	$3.58 \pm 0.42$
PTN-1	$3.47 \pm 0.43$
PTN-2	$3.10 \pm 0.04$

## 2.a. IODINE-131 IN WEEKLY AIR CARTRIDGES - (pCi/m<sup>3</sup>)

Collection Date		
	T52	T56
02-Jan-13	< 0.02	< 0.02
08-Jan-13	< 0.03	< 0.03
16-Jan-13	< 0.02	< 0.02
23-Jan-13	< 0.02	< 0.02
30-Jan-13	< 0.03	< 0.03
06-Feb-13	< 0.02	< 0.02
12-Feb-13	< 0.02	< 0.02
18-Feb-13	< 0.04	< 0.04
25-Feb-13	< 0.03	< 0.03
05-Mar-13	< 0.03	< 0.03
12-Mar-13	< 0.03	< 0.03
18-Mar-13	<0.03	< 0.03
25-Mar-13	< 0.03	< 0.03

## 2.b.1. AIR PARTICULATES - GROSS BETA - (pCi/m<sup>3</sup>)

Collection Date		
Conection Date	T52	T56
02-Jan-13	$0.019 \pm 0.002$	$0.014\pm0.002$
08-Jan-13	$0.010\pm0.002$	$0.007 \pm 0.002$
16-Jan-13	$0.006\pm0.002$	$0.009 \pm 0.002$
23-Jan-13	$0.015 \pm 0.002$	$0.008\pm0.002$
30-Jan-13	$0.030 \pm 0.003$	$0.025 \pm 0.003$
06-Feb-13	$0.016\pm0.002$	$0.016\pm0.002$
12-Feb-13	$0.014\pm0.002$	$0.021\pm0.003$
18-Feb-13	$0.015 \pm 0.002$	$0.019\pm0.003$
25-Feb-13	$0.015\pm0.002$	$0.012\pm0.002$
05-Mar-13	$0.023\pm0.002$	$0.018\pm0.002$
12-Mar-13	$0.016\pm0.002$	$0.011\pm0.002$
18-Mar-13	$0.022 \pm 0.003$	$0.021\pm0.003$
25-Mar-13	$0.012\pm0.002$	$0.012\pm0.002$
Average:	$0.016 \pm 0.001$	$0.015 \pm 0.001$

### 2.b.2. AIR PARTICULATES GAMMA ANALYSIS OF QUARTERLY COMPOSITES - (pCi/m³)

Sample Site	<u>Be-7</u>	<u>K-40</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>
T52	$0.1122 \pm 0.0108$	< 0.0237	< 0.0016	< 0.0012	< 0.0645
T56	$0.0984 \pm 0.0117$	< 0.0221	< 0.0011	< 0.0010	<0.0511

#### 3.a. SURFACE WATER - (pCi/L)

Sample <u>Site</u>	Collection <u>Date</u>	<u>H-3</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	Zr-95 <u>Nb-95</u> (A)	<u>I-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	Ba-140 <u>La-140</u> (B)
Т08	08-Jan-13	5487 ± 124	$393 \pm 64$	<3	<3	<6	<3	<6	<4	<4	<2	<3	<5
	19-Feb-13	5530 ± 125	$553 \pm 61$	<5	<5	<12	<8	<12	<7	<7	<7	<6	<11
	18-Mar-13	6223 ± 132	566 ± 70	<3	<3	<7	<4	<7	<6	<6	<3	<4	<6
T75	08-Jan-13	<137	<26	<2	<2	<4	<3	<4	<4	<4	<3	<2	<4
	19-Feb-13	<140	<75	<5	<4	<8	<8	<9	<9	<7	<5	<5	<9
	18-Mar-13	<141	<61	<5	<4	<9	<7	<10	<9	<10	<4	<5	<8
T84	08-Jan-13	5317 ± 122	$467\pm54$	<3	<3	<6	<3	<6	<5	<4	<2	<3	<4
	19-Feb-13	5798 ± 127	$493\pm 60$	<5	<6	<12	<7	<13	<9	<7	<6	<5	<14
	18-Mar-13	5499 ± 125	621 ± 80	<6	<5	<12	<7	<11	<9	<10	<5	<6	<8
Т97	09-Jan-13	5610 ± 125	413 ± 66	<2	<2	<6	<3	<6	<5	<4	<2	<3	<3
	18-Feb-13	5736 ± 127	571 ± 82	<3	<3	<6	<3	<7	<5	<4	<3	<3	<5
	19-Mar-13	$4780 \pm 117$	641 ± 126	<4	<5	<]]	<7	<11	<10	<10	<5	<6	<8

(A) - These tabulated LLD values for Zr/Nb-95 are the higher of the individual parent or daughter LLD's.

(B) - These tabulated LLD values are for Ba-140, either based on direct measurement of Ba-140 or based on ingrowth of La-140, whichever method yields the greater sensitivity for a given sample.

#### 3.b. SHORELINE SEDIMENT - (pCi/kg, dry weight)

-

Sample <u>Site</u>	Collection Date	<u>Be-7</u>	<u>K-40</u>	<u>Co-58</u>	<u>Co-60</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>	<u>Ra-226</u>	<u>Th-232</u>	<u>U-235</u>	<u>U-238</u>
TOI	09-Jan-13	<113	259 ± 54	<12	<13	<10	<10	<690	1159 ± 148	<42	<97	517 ± 177
T02	09-Jan-13	427 ± 98	2678 ± 139	<20	47 ± 5	<20	29 ± 9	$1765 \pm 436$	3803 ± 301	193 ± 26	<160	2375 ± 331
Т03	09-Jan-13	<186	2278 ± 121	<21	<27	<19	29 ± 4	2749 ± 117	3594 ± 477	169 ± 17	<37	<285
T04	08-Jan-13	<115	189 ± 61	<12	<14	<10	<12	2512 ± 335	1614 ± 143	<48	<102	<420
T07	09-Jan-13	<130	585 ± 78	<12	<17	<14	36 ± 6	1941 ± 334	$1132 \pm 155$	<63	<121	<483
T08	09-Jan-13	<155	1059 ± 111	<16	30 ± 5	<16	43 ± 5	$1525 \pm 480$	1397 ± 190	<71	<128	<523
T09	09-Jan-13	<108	368 ± 55	<11	<12	<10	<12	<703	1259 ± 150	<48	<101	418 ± 155
T10	09-Jan-13	<98	695 ± 182	<12	<11	<10	<13	<205	905 ± 185	<47	<19	<140
T84*	08-Jan-13	<167	1219 ± 102	<16	64 ± 6	<16	42 ± 7	1423 ± 394	2894 ± 253	<70	<146	<579
T85*	08-Jan-13	<93	121 ± 22	<10	17 ± 2	<9	<10	823 ± 122	1326 ± 145	<40	<12	$503\pm30$

\*Note that site T84 is the same location as site T05, and site T85 is the same location as site T06.

### 3.c. AQUATIC VEGETATION - Non-Specific - (pCi/kg, wet weight)

Sample Site	Collection Date	Be-7	K-40	Mn-54	Co-58	Co-60	Ag-110m	I-131	Cs-134	Cs-137	Ra-226	Ra-228
Т84	18-Feb-13	962 ± 83	3158 ± 164	<12	<20	<20	<15	<15	<17	<15	464 ± 131	<81

#### 4.a. GOAT'S MILK - (pCi/L)

						Ba-140
Sample	Collection Date					La-140
Site		<u> </u>	<u>I-131</u>	<u>Cs-134</u>	Cs-137	<u>(A)</u>

T99 This sample to be collected.

(A) - This tabulated LLD value is for Ba-140, either based on direct measurement of Ba-140 or based on ingrowth of La-140, whichever method yields the greater sensitivity.

#### 4.b. MARINE LIFE - Horseshoe Crab - (pCi/kg, wet weight)

Sample Site	Collection Date	K-40	Mn-54	Co-58	Fe-59	<u>Co-60</u>	Zn-65	Ag-110m	Cs-134	Cs-137	Ra-226	Ra-228	_
Т84	19-Mar-13	1137 ± 181	<34	<35	<65	<58	<72	<36	<36	<36	<672	<150	
<u>4.c. FOOD C.</u>	<u>ROPS (pCi/kg,</u>	wet weight)											
Sample Site	Collection Date	Be-7	K-40	Mn-54	Co-58	Co-60	Ag-110	m I-13	l Cs	-134	Cs-137	Ra-226	Ra-228
T43(A)	10-Jan-13	<73	3133 ± 131	<7	<8	<13	<8	<13	} <	11	<10	<210	<38
T44(B)	10-Jan-13	<107	2396 ± 145	<12	<12	<23	<11	<24	+ <	17	<15	<317	<51

T45 This sample to be collected.

(A) Green string beans

(B) Corn

## ATTACHMENT B



#### RADIOLOGICAL SURVEILLANCE

OF

FLORIDA POWER AND LIGHT COMPANY

**TURKEY POINT SITE** 

SECOND QUARTER 2013

BUREAU OF RADIATION CONTROL

#### TURKEY POINT SITE

Offsite Dose Calculation Manual Sampling

#### Second Quarter, 2013

Sample Type	Collection Frequency	Locations Sampled	Number of <u>Samples</u>
1. Direct Radiation	Quarterly	22	22
2. Airborne			
2.a. Air Iodines	Weekly	6	78
2.b. Air Particulates	Weekly	6	78
3. Waterborne			
3.a. Surface Water	Monthly	3	9
3.b. Shoreline Sediment	Semiannually	3	0
<ol> <li>Ingestion</li> <li>4.a. Fish and Invertebrates</li> </ol>			
4.a.1. Crustacea	Semiannually	2	1
4.a.2. Fish	Semiannually	2	0
4.b. Broadleaf Vegetation	Monthly	3	9
			Total: 197

NOTE: Measurement results having magnitudes that are significantly above the background of the measurement system are reported as net values plus or minus a one-standard-deviation error term. Measurement results that are <u>not</u> significantly above background are reported as less than a Lower Limit of Detection (<LLD), which is an estimated upper limit (with at least 95% confidence) for the true activity in the sample.

The marine fauna listed in this report were collected in part, under Florida FWC SAL030.

Sample Site	Deployment 26-Mar-13 Collection 04-June-13	Sample Site	Deployment 26-Mar-13 Collection 04-June-13
N-2	$4.45 \pm 0.14$	WSW-8	(A)
N-7	$3.74 \pm 0.14$		
N-10	$4.19 \pm 0.52$	SW-1	$3.67 \pm 0.18$
		SW-8	$3.47 \pm 0.01$
NNW-2	$3.60 \pm 0.23$		
NNW-10	$4.18 \pm 0.18$	SSW-5	$3.49 \pm 0.11$
		SSW-10	$3.70 \pm 0.31$
NW-1	$4.52 \pm 0.31$		
NW-5	$4.77\pm0.95$	S-5	$3.61 \pm 0.25$
NW-10	$4.96 \pm 0.25$	S-10	$3.98\pm0.28$
WNW-10	$4.69 \pm 0.03$	SSE-1	$3.33 \pm 0.12$
		SSE-10	$3.59 \pm 0.26$
W-1	$4.62\pm0.44$		
W-5	$3.77 \pm 0.18$	NNE-22	$4.37 \pm 0.17$
W-9	$3.75 \pm 0.09$		

### 1. DIRECT RADIATION - TLD's - (µR/hour)

(A) Data lost due to computer error.

### 2.a. IODINE-131 IN WEEKLY AIR CARTRIDGES - (pCi/m3)

Collection Date						
	T41	T51	T57	T58	T64	T72
02-Apr-13	< 0.03	< 0.03	<0.03	< 0.03	< 0.03	< 0.03
10-Apr-13	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
17-Apr-13	< 0.03	< 0.03	< 0.02	< 0.03	<0.03	< 0.03
24-Apr-13	< 0.02	< 0.02	<0.02(A)	< 0.02	< 0.02	< 0.02
29-Apr-13	< 0.04	<0.04	< 0.04	< 0.04	< 0.04	< 0.04
07-May-13	< 0.03	< 0.02	< 0.02	< 0.03	< 0.03	< 0.03
14-May-13	< 0.03	< 0.03	< 0.03	< 0.04	<0.04	< 0.04
21-May-13	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03
29-May-13	< 0.02	<0.02(B)	< 0.02	< 0.02	< 0.02	< 0.02
05-Jun-13	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03
11-Jun-13	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03
17-Jun-13	< 0.03	<0.03	< 0.03	< 0.03	< 0.03	< 0.03
26-Jun-13	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02

(A) Low flow experienced; unknown reason. Estimated run time 62.3 out of 168.2 hours.

(B) Power failure experienced during sample run. Estimated run time 155 out of 193.4 hours.

## 2.b. AIR PARTICULATES - GROSS BETA - (pCi/m3)

Collection Date	T41	T51	<u> </u>	T58	T64	T72
02-Apr-13	$0.020\pm0.002$	$0.021 \pm 0.002$	$0.021 \pm 0.002$	$0.020 \pm 0.002$	$0.020\pm0.002$	$0.024\pm0.002$
10-Apr-13	$0.014 \pm 0.002$	$0.014 \pm 0.002$	$0.015\pm0.002$	$0.015 \pm 0.002$	$0.007 \pm 0.001$	$0.017 \pm 0.002$
17-Apr-13	$0.006\pm0.002$	$0.005 \pm 0.001$	$0.005 \pm 0.001$	$0.008\pm0.002$	$0.008\pm0.002$	$0.011 \pm 0.002$
24-Apr-13	$0.012\pm0.002$	$0.009 \pm 0.002$	$0.030 \pm 0.005(A)$	$0.012 \pm 0.002$	$0.009\pm0.002$	$0.009\pm0.002$
29-Apr-13	$0.015 \pm 0.003$	$0.014 \pm 0.003$	$0.009 \pm 0.002$	$0.015 \pm 0.003$	$0.009\pm0.003$	$0.011 \pm 0.003$
07-May-13	$0.012\pm0.002$	$0.010\pm0.002$	$0.011 \pm 0.002$	$0.009 \pm 0.002$	$0.005 \pm 0.001$	$0.011 \pm 0.002$
14-May-13	$0.018\pm0.002$	$0.017\pm0.002$	$0.021 \pm 0.002$	$0.020\pm0.002$	$0.019\pm0.002$	$0.021 \pm 0.002$
21-May-13	$0.015\pm0.002$	$0.018\pm0.002$	$0.020\pm0.002$	$0.019\pm0.002$	$0.016\pm0.002$	$0.016\pm0.002$
29-May-13	$0.013\pm0.002$	$0.013 \pm 0.002(B)$	$0.014\pm0.002$	$0.012\pm0.002$	$0.013\pm0.002$	$0.012 \pm 0.002$
05-Jun-13	$0.010\pm0.002$	$0.009\pm0.002$	$0.010\pm0.002$	$0.008\pm0.002$	$0.007\pm0.002$	$0.010\pm0.002$
11-Jun-13	$0.010\pm0.002$	$0.009\pm0.002$	$0.014\pm0.002$	$0.011 \pm 0.002$	$0.012\pm0.002$	$0.017\pm0.002$
17-Jun-13	$0.014\pm0.002$	$0.009\pm0.002$	$0.010\pm0.002$	$0.009 \pm 0.002$	$0.010\pm0.002$	$0.016\pm0.002$
26-Jun-13	$0.018\pm0.002$	$0.018\pm0.002$	$0.015 \pm 0.002$	$0.017\pm0.002$	$0.008 \pm 0.001$	$0.013 \pm 0.002$
Average:	$0.014 \pm 0.001$	$0.013 \pm 0.001$	$0.015 \pm 0.001$	$0.014 \pm 0.001$	$0.011 \pm 0.001$	$0.014 \pm 0.001$

(A) Low flow experienced; unknown reason. Estimated run time 62.3 out of 168.2 hours.

(B) Power failure experienced during sample run. Estimated run time 155 out of 193.4 hours.

#### 2.b. AIR PARTICULATES - GAMMA ANALYSIS OF QUARTERLY COMPOSITES - (pCi/m<sup>3</sup>)

Sample Site	<u>Be-7</u>	<u>K-40</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>
T <b>4</b> 1	$0.1052 \pm 0.0089$	< 0.0178	< 0.0013	< 0.0015	< 0.0103
T51	$0.1069 \pm 0.0174$	< 0.0158	< 0.0014	< 0.0015	$0.0170 \pm 0.0065$
T57	$0.1098 \pm 0.0040$	< 0.0143	<0.0009	<0.0009	$0.0115 \pm 0.0040$
T58	$0.1081 \pm 0.0138$	< 0.0140	<0.0009	<0.0009	$0.0102 \pm 0.0016$
T64	$0.0935 \pm 0.0134$	< 0.0139	<0.0009	<0.0009	$0.0095 \pm 0.0043$
T72	$0.1148 \pm 0.0162$	< 0.0175	< 0.0011	<0.0009	$0.0154 \pm 0.0050$

#### 3.a. SURFACE WATER - (pCi/L)

Sample <u>Site</u>	Collection <u>Date</u>	<u>H-3</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	Zr-95 <u>Nb-95</u> (A)	<u>I-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	Ba-140 <u>La-140</u> (B)
T42	16-Apr-13	<138	320 ± 93	<3	<3	<7	<4	<7	<5	<4	<3	<3	<5
	15-May-13	<140	320 ± 34	<5	<4	<9	<8	<11	<8	<6	<5	<6	<9
	04-Jun-13	<146	224 ± 29	<5	<5	<9	<7	<9	<9	<7	<5	<5	<7
Т67	15-Apr-13	<138	<67	<4	<5	<10	<7	<]]	<9	<7	<5	<6	<8
	13-May-13	127 ± 27	70 ± 18	<3	<4	<8	<4	<8	<6	<4	<4	<4	<8
	03-Jun-13	<138	33 ± 12	<2	<2	<4	<3	<5	<3	<3	<2	<2	<3
T81	15-Apr-13	$175 \pm 34$	196 ± 17	<3	<3	<7	<3	<6	<5	<4	<3	<3	<5
	13-May-13	<139	325 ± 45	<6	<5	<11	<6	<13	<10	<8	<7	<7	<9
	03-Jun-13	<138	348 ± 23	<1	<1	<3	<1	<3	<2	<2	<1	<1	<2

(A) - These tabulated LLD values for Zr/Nb-95 are the higher of the individual parent or daughter LLD's.

(B) - These tabulated LLD values are for Ba-140, either based on direct measurement of Ba-140 or based on ingrowth of La-140, whichever method yields the greater sensitivity for a given sample.

## 3.b. SHORELINE SEDIMENT - (pCi/kg, dry weight)

Sample <u>Site</u>	Collection Date	<u>Be-7</u>	<u>K-40</u>	<u>Co-58</u>	<u>Co-60</u>	<u>Cs-134</u>	<u>4 Cs-</u>	<u>37 Pb-</u>	-210	<u>Ra-226</u>	<u> Th-232</u>
	These sa	mples were prev	viously collec	ted.							
4.a.1. CRUS	FACEA - Blue Crat	o - (pCi/kg, wet	weight)								
Sample	Collection										
Site	Date	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>
Т67	There was r	no sample avail	able during th	ne quarter.							
T81	24-Jun-13	$1509 \pm 510$	<27	<29	<59	<27	<59	<29	<22	$1265 \pm 139$	9 <132
<u>4.a.2. FISH -</u>	Mixed Species - (p	Ci/kg, wet weig	<u>(ht)</u>								
Sample	Collection										
Site	Date	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>

T67 This sample was previously collected.

T81 This sample was previously collected.

## 4.b. BROADLEAF VEGETATION - Brazilian Pepper - (pCi/kg, wet weight)

Sample Site	Collection <u>Date</u>	<u>Be-7</u>	<u>K-40</u>	<u>1-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>	<u>Pb-212</u>	<u>Ra-226</u>	<u>Ra-228</u>
T40	16-Apr-13	1492 ± 139	$6100\pm360$	<31	<19	$24 \pm 10$	<4551	<130	<410	<99
	15-May-13	952 ± 95	5121 ± 294	<17	<23	32 ± 9	<3636	<100	<324	<80
	03-Jun-13	$1700 \pm 129$	$4566\pm268$	<20	<20	43 ± 8	<3264	<90	796 ± 168	<69
T41	16-Apr-13	$1493 \pm 94$	$3320\pm171$	<18	<12	187 ± 11	<2196	<61	<218	<50
	15-May-13	998 ± 137	$3078 \pm 171$	<16	<13	171 ± 18	<1358	<28	<322	<60
	03-Jun-13	1448 ± 104	2427 ± 181	<17	<16	119 ± 11	<2932	<83	<296	<63
Т67	15-Apr-13	1258 ± 142	$5251\pm249$	<30	<14	<17	<1470	21 ± 5	<370	<59
	13-May-13	1483 ± 107	$5865\pm318$	<20	<21	<14	<3173	<98	<313	<73
	03-Jun-13	1554 ± 53	$6512 \pm 293$	<11	<8	<8	390 ± 83	<15	<175	<33

## TURKEY POINT SITE

#### Supplemental Sampling

#### Second Quarter, 2013

Sample Type	Collection Frequency	Locations Sampled	Number of <u>Samples</u>
1. Direct Radiation	Quarterly	11	11
2. Airborne			
2.a. Air Iodines	Weekly	2	26
2.b. Air Particulates	Weekly	2	26
3. Waterborne			
3.a. Surface Water	Monthly	4	12
3.b. Shoreline Sediment	Semiannually	10	0
3.c. Aquatic Vegetation	Quarterly	1	1
4. Ingestion			
4.a. Milk	Semiannually	1	0
4.b. Marine Life	Semiannually	1	0
4.c. Food Crops	At Harvest	3	1
			Total: 77

NOTE: Measurement results having magnitudes that are significantly above the background of the measurement system are reported as net values plus or minus a one-standard-deviation error term. Measurement results that are <u>not</u> significantly above background are reported as less than a Lower Limit of Detection (<LLD), which is an estimated upper limit (with at least 95% confidence) for the true activity in the sample.

# 1. DIRECT RADIATION - TLD's - (µR/hour)

Sample Site	Deployment 26-Mar-13 Collection 04-June-13
NNW-6	$3.81 \pm 0.10$
NW-7	$4.44 \pm 0.15$
NW-8	$4.41 \pm 0.16$
WNW-2	$4.00\pm0.22$
WNW-3	$4.23\pm0.30$
WNW-6	$3.91 \pm 0.30$
W-8	$4.20\pm0.10$
ENE-1	$3.63 \pm 0.16$
T <b>72</b>	$4.11 \pm 0.10$
PTN-1	$3.91 \pm 0.18$
PTN-2	$3.36\pm0.16$

### 2.a. IODINE-131 IN WEEKLY AIR CARTRIDGES - (pCi/m<sup>3</sup>)

Collection Date		
	T52	T56
02-Apr-13	< 0.03	< 0.03
10-Apr-13	< 0.02	< 0.02
17-Apr-13	< 0.03	< 0.03
24-Apr-13	< 0.02	< 0.02
29-Apr-13	< 0.04	< 0.04
07-May-13	< 0.02	< 0.02
14-May-13	< 0.03	< 0.03
21-May-13	< 0.03	< 0.03
29-May-13	< 0.02	< 0.02
05-Jun-13	< 0.03	< 0.03
11-Jun-13	< 0.03	< 0.03
17-Jun-13	< 0.03	< 0.03
26-Jun-13	< 0.02	< 0.02

## 2.b. AIR PARTICULATES - GROSS BETA - (pCi/m<sup>3</sup>)

Collection Date		
	T52	T56
02-Apr-13	$0.018\pm0.002$	$0.008 \pm 0.001$
10-Apr-13	$0.016 \pm 0.002$	$0.015\pm0.002$
17-Apr-13	$0.009\pm0.002$	$0.008\pm0.002$
24-Apr-13	$0.009 \pm 0.002$	$0.009\pm0.002$
29-Apr-13	$0.008\pm0.002$	$0.017 \pm 0.003$
07-May-13	$0.012\pm0.002$	$0.011 \pm 0.002$
14-May-13	$0.018\pm0.002$	$0.012 \pm 0.002$
21-May-13	$0.022\pm0.002$	$0.018\pm0.002$
29-May-13	$0.013 \pm 0.002$	$0.015 \pm 0.002$
05-Jun-13	$0.010\pm0.002$	$0.008\pm0.002$
11-Jun-13	$0.013 \pm 0.002$	$0.009 \pm 0.002$
17-Jun-13	$0.009\pm0.002$	$0.014\pm0.002$
26-Jun-13	$0.019\pm0.002$	$0.015 \pm 0.002$
Average:	$0.014 \pm 0.001$	$0.012 \pm 0.001$

#### 2.b. AIR PARTICULATES - GAMMA ANALYSIS OF QUARTERLY COMPOSITES - (pCi/m<sup>3</sup>)

Sample Site	<u>Be-7</u>	<u>K-40</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>
T52	$0.1180 \pm 0.0093$	<0.0250	< 0.0011	< 0.0014	$0.0072 \pm 0.0017$
Т56	$0.1065 \pm 0.0205$	< 0.0174	< 0.0013	< 0.0010	<0.0105

#### 3.a. SURFACE WATER - (pCi/L)

Sample <u>Site</u>	Collection Date	<u>H-3</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	Zr-95 <u>Nb-95</u> (A)	<u>I-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	Ba-140 <u>La-140</u> (B)
T08	15-Apr-13	$9039 \pm 156$	$626 \pm 66$	<5	<5	<10	<6	<14	<9	<7	<6	<5	<8
	13-May-13	7098 ± 140	$531 \pm 42$	<5	<5	<10	<7	<12	<9	<8	<5	<6	<8
	03-Jun-13	4189 ± 111	$540 \pm 35$	<2	<2	<5	<3	<5	<4	<3	<3	<3	<3
Т75	15-Apr-13	<138	<72	<5	<3	<10	<5	<10	<7	<5	<5	<4	<7
	13-May-13	<140	<40	<3	<3	<6	<5	<6	<5	<4	<3	<3	<4
	03-Jun-13	<138	<59	<4	<4	<9	<3	<8	<6	<5	<5	<5	<7
T84	15-Apr-13	8744 ± 153	$565 \pm 36$	<2	<2	<4	<2	<5	<4	<3	<3	<2	<3
	13-May-13	$7432 \pm 143$	551 ± 30	<3	<3	<7	<3	<7	<5	<4	<3	<4	<5
	03-Jun-13	$4056 \pm 109$	$529 \pm 35$	<2	<2	<5	<3	<5	<4	<3	<3	<3	<4
T9 <b>7</b>	16-Apr-13	9234 ± 157	$567 \pm 44$	<5	<5	<10	<7	<11	<9	<8	<5	<6	<9
	15-May-13	$6603 \pm 136$	$582 \pm 43$	<4	<4	<8	<5	<9	<6	<4	<5	<4	<8
	04-Jun-13	4399 ± 113	522 ± 25	<2	<2	<5	<3	<5	<4	<3	<2	<2	<4

(A) - These tabulated LLD values for Zr/Nb-95 are the higher of the individual parent or daughter LLD's.

(B) - These tabulated LLD values are for Ba-140, either based on direct measurement of Ba-140 or based on ingrowth of La-140, whichever method yields the greater sensitivity for a given sample.

### 3.b. SHORELINE SEDIMENT - (pCi/kg, dry weight)

This sample was previously collected.

T84

Sample <u>Site</u>	Collection <u>Date</u>	<u>Be-7</u>	<u>K-40</u>	<u>Co-58</u>	<u>Co-60</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>	<u>Ra-226</u>	<u>Th-232</u>			
	These	samples were	previously col	lected.									
<u>3.c. AQUATI</u>	C VEGETAT	ION - Non-Spe	ecific - (pCi/kg	, wet weig	<u>ht)</u>								
Sample <u>Site</u>	Collection Date	<u>Be-7</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Co-60</u>	<u>Ag-110m</u>	<u>1-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-212</u>	<u>Ra-226</u>	<u>Ra-228</u>
T84	15-May-13	3939 ± 196	1044 ± 113	<14	34 ± 9	<18	<18	<18	<18	<14	287 ± 114	2414 ± 207	$178\pm35$
<u>4.a. GOAT'S</u>	I.a. GOAT'S MILK - (pCi/L)												
Sample <u>Site</u>	Collectio	on <u>Date</u>	<u>K-40</u>	Ī	<u>-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	Ba <u>La</u> (	-140 <u>-140</u> A)				
Т99	The	re was no samp	le available du	iring the qu	arter.								
(A) - This tab sensitiv	A) - This tabulated LLD value is for Ba-140, either based on direct measurement of Ba-140 or based on ingrowth of La-140, whichever method yields the greater sensitivity.												
<u>4.b. Marine</u>	<u>E LIFE - Horse</u>	eshoe Crab - (p	Ci/kg, wet wei	<u>ght)</u>									
Sample <u>Site</u>	Collection Date	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-5</u>	<u>9 Co-(</u>	<u>50 Zn-65</u>	<u>Ag-110</u>	<u>)m Cs-134</u>	<u>4 Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>	

59

## 4.c. FOOD CROPS - Coconut Milk - (pCi/kg, wet weight)

Sample <u>Site</u>	Collection Date	<u>Be-7</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Co-60</u>	<u>Ag-110m</u>	<u>I-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>
T43	This sample was previously collected.											
T44	This sa	ample was p	reviously collect	ed.								
T45	03-Apr-13	<238	$2892 \pm 216$	<25	<28	<36	<26	<137	<25	<26	<398	<90

### ATTACHMENT B

Third Quarter, 2013



RADIOLOGICAL SURVEILLANCE

FLORIDA POWER AND LIGHT COMPANY

**TURKEY POINT SITE** 

THIRD QUARTER 2013

BUREAU OF RADIATION CONTROL

OF

#### TURKEY POINT SITE

Offsite Dose Calculation Manual Sampling

#### Third Quarter, 2013

Sample Type	Collection Frequency	Locations Sampled	Number of <u>Samples</u>
1. Direct Radiation	Quarterly	22	22
2. Airborne			
2.a. Air Iodines	Weekly	6	78
2.b. Air Particulates	Weekly	6	78
3. Waterborne			
3.a. Surface Water	Monthly	3	9
3.b. Shoreline Sediment	Semiannually	3	3
<ol> <li>Ingestion</li> <li>4.a. Fish and Invertebrates</li> </ol>			
4.a.1. Crustacea	Semiannually	2	0
4.a.2. Fish	Semiannually	2	1
4.b. Broadleaf Vegetation	Monthly	3	9
			Total: 200

NOTE: Measurement results having magnitudes that are significantly above the background of the measurement system are reported as net values plus or minus a one-standard-deviation error term. Measurement results that are <u>not</u> significantly above background are reported as less than a Lower Limit of Detection (<LLD), which is an estimated upper limit (with at least 95% confidence) for the true activity in the sample.

The marine fauna listed in this report were collected in part, under Florida FWC SAL030.

Sample Site	Deployment 04-June-13 Collection 17-Sep-13	Sample Site	Deployment 04-June-13 Collection 17-Sep-13
N-2	$4.26 \pm 0.33$	WSW-8	$3.64 \pm 0.28$
N-7	$3.54 \pm 0.14$		
N-10	$4.14 \pm 0.23$	SW-1	$3.23\pm0.02$
		SW-8	$3.04 \pm 0.20$
NNW-2	$3.25 \pm 0.15$		
NNW-10	$3.84 \pm 0.13$	SSW-5	$3.14 \pm 0.13$
		SSW-10	$3.15 \pm 0.24$
NW-1	$4.23 \pm 0.37$		
NW-5	$3.57\pm0.23$	S-5	$3.13 \pm 0.37$
NW-10	$4.44\pm0.05$	S-10	$3.93\pm0.30$
WNW-10	$4.26\pm0.24$	SSE-1	$3.05 \pm 0.23$
		SSE-10	$3.32 \pm 0.03$
W-1	$3.95 \pm 0.36$		
W-5	$3.60 \pm 0.21$	NNE-22	$4.13 \pm 0.28$
W-9	$3.42 \pm 0.13$		

# J. DIRECT RADIATION - TLD's - (µR/hour)

2.a. JODINE-13	1 IN WEEKLY AIR	CARTRIDGES -	(pCi/m <sup>3</sup> )	

Collection Date						
	T41	T51	T57	T58	<u>T64</u>	<u>T72</u>
02-Jul-13	< 0.02	< 0.03	< 0.02	< 0.02	<0.02	< 0.03
09-Jul-13	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
17-Jul-13	< 0.02	< 0.03	<0.02	< 0.02	<0.02(A)	< 0.02
23-Jul-13	< 0.03	<0.03	< 0.03	< 0.03	<0.02(B)	< 0.03
30-Jul-13	< 0.03	< 0.03	<0.03	< 0.03	<0.02(C)	< 0.03
08-Aug-13	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
14-Aug-13	< 0.03	< 0.03	< 0.03	< 0.03	<0.03	< 0.03
21-Aug-13	< 0.02	<0.02	< 0.02	< 0.03	<0.02	< 0.02
27-Aug-13	<0.04	< 0.04	<0.04	< 0.04	<0.04	< 0.04
04-Sep-13	<0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03
11-Sep-13	< 0.03	< 0.03	< 0.03	< 0.03	<0.03	< 0.03
18-Sep-13	< 0.03	< 0.03	< 0.03	< 0.03	< 0.02	< 0.03
25-Sep-13	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02

(A) Experienced low volume; gas meter changed out. Estimated run time 108.6 out of 169.9 hours.

(B) Experienced low volume again. Estimated run time 97.4 out of 144 hours.

(C) Pump not operating upon arrival; changed out vacuum pump. Estimated run time 73 out of 168.8 hours.

,

### 2.b. AIR PARTICULATES - GROSS BETA - (pCi/m3)

Collection Date	T41	<u>T51</u>	T57	T58	T64	T72
02-Jul-13	$0.014\pm0.002$	$0.016\pm0.002$	$0.012 \pm 0.002$	$0.016 \pm 0.002$	$0.011 \pm 0.002$	$0.017\pm0.002$
09-Jul-13	$0.013\pm0.002$	$0.013\pm0.002$	$0.010\pm0.002$	$0.010\pm0.002$	$0.005\pm0.002$	$0.010\pm0.002$
17-Jul-13	$0.005\pm0.001$	$0.008\pm0.002$	$0.007 \pm 0.002$	$0.011 \pm 0.002$	$0.014 \pm 0.003(A)$	$0.006\pm0.002$
23-Jul-13	$0.012\pm0.002$	$0.018\pm0.002$	$0.021 \pm 0.003$	$0.013 \pm 0.002$	$0.016 \pm 0.003(B)$	$0.020 \pm 0.003$
30-Jul-13	$0.019\pm0.002$	$0.026 \pm 0.003$	$0.022\pm0.002$	$0.025 \pm 0.003$	$0.019 \pm 0.004(C)$	$0.027 \pm 0.003$
08-Aug-13	$0.009 \pm 0.001$	$0.009 \pm 0.001$	$0.011\pm0.002$	$0.011 \pm 0.002$	$0.009\pm0.001$	$0.010 \pm 0.002$
14-Aug-13	$0.014\pm0.002$	$0.013 \pm 0.002$	$0.011 \pm 0.002$	$0.014 \pm 0.002$	$0.011 \pm 0.002$	$0.015 \pm 0.002$
21-Aug-13	$0.012\pm0.002$	$0.010\pm0.002$	$0.011\pm0.002$	$0.012 \pm 0.002$	$0.012 \pm 0.002$	$0.012\pm0.002$
27-Aug-13	$0.013\pm0.002$	$0.013\pm0.002$	$0.011 \pm 0.002$	$0.013\pm0.002$	$0.008\pm0.002$	$0.010 \pm 0.002$
04-Sep-13	$0.010\pm0.002$	$0.008\pm0.002$	$0.010\pm0.002$	$0.011 \pm 0.002$	$0.009 \pm 0.002$	$0.008\pm0.002$
11-Sep-13	$0.009\pm0.002$	$0.007\pm0.002$	$0.008\pm0.002$	$0.007\pm0.002$	$0.007\pm0.002$	$0.006 \pm 0.002$
18-Sep-13	$0.012\pm0.002$	$0.012\pm0.002$	$0.013 \pm 0.002$	$0.015\pm0.002$	$0.011 \pm 0.002$	$0.016 \pm 0.002$
25-Sep-13	$0.010\pm0.002$	$0.013\pm0.002$	$0.011 \pm 0.002$	$0.012 \pm 0.002$	$0.008 \pm 0.002$	$0.006 \pm 0.002$
Average:	$0.012 \pm 0.001$	$0.013\pm0.001$	$0.012 \pm 0.001$	$0.013 \pm 0.001$	$0.011 \pm 0.001$	$0.013 \pm 0.001$

(A) Experienced low volume; gas meter changed out. Estimated run time 108.6 out of 169.9 hours.

(B) Experienced low volume again. Estimated run time 97.4 out of 144 hours.

(C) Pump not operating upon arrival; changed out vacuum pump. Estimated run time 73 out of 168.8 hours.

#### 2.b. AIR PARTICULATES - GAMMA ANALYSIS OF QUARTERLY COMPOSITES - (pCi/m<sup>3</sup>)

Sample Site	<u>Be-7</u>	<u>K-40</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>
T41	$0.0889 \pm 0.0082$	< 0.0224	< 0.0013	< 0.0012	$0.0097 \pm 0.0018$
T51	$0.0871 \pm 0.0043$	< 0.0113	<0.0007	< 0.0006	$0.0104 \pm 0.0010$
T57	$0.0842 \pm 0.0042$	< 0.0100	<0.0006	< 0.0006	$0.0130 \pm 0.0028$
T58	$0.0805 \pm 0.0065$	< 0.0141	< 0.0011	< 0.0011	< 0.0102
T64	$0.0832 \pm 0.0033$	$0.0033 \pm 0.0013$	< 0.0005	< 0.0004	$0.0153 \pm 0.0011$
Т72	$0.0894 \pm 0.0074$	< 0.0063	< 0.0005	< 0.0004	$0.0139 \pm 0.0028$

#### 3.a. SURFACE WATER - (pCi/L)

Sample <u>Site</u>	Collection <u>Date</u>	<u>H-3</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	Zr-95 <u>Nb-95</u> (A)	<u>I-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	Ba-140 <u>La-140</u> (B)
T42	09-Jul-13	<147	236 ± 29	<4	<5	<9	<7	<10	<8	<9	<5	<5	<8
	13-Aug-13	<135	223 ± 20	<3	<3	<6	<3	<6	<6	<3	<3	<3	<5
	18-Sep-13	<147	81 ± 14	<3	<3	<6	<3	<6	<5	<3	<3	<3	<7
Т67	10-Jul-13	<147	279 ± 31	<5	<5	<11	<7	<10	<9	<8	<5	<5	<9
	12-Aug-13	<142	<52	<3	<3	<6	2	<6	<5	<4	<3	<3	<4
	18-Sep-13	<141	<47	<3	<3	<6	<3	<6	<4	<3	<3	<3	<6
T81	09-Jul-13	201 ± 28	311 ± 59	<3	<3	<6	<3	<7	<6	<5	<3	<3	<5
	12-Aug-13	142 ± 27	277 ± 31	<4	<5	<10	<7	<11	<8	<7	<5	<5	<8
	16-Sep-13	<137	338 ± 32	<5	<4	<10	<7	<12	<9	<7	<5	<5	<7

(A) - These tabulated LLD values for Zr/Nb-95 are the higher of the individual parent or daughter LLD's.

(B) - These tabulated LLD values are for Ba-140, either based on direct measurement of Ba-140 or based on ingrowth of La-140, whichever method yields the greater sensitivity for a given sample.

### 3.b. SHORELINE SEDIMENT - (pCi/kg, dry weight)

Sample <u>Site</u>	Collection Date											
		<u>Be-7</u>	<u>K-40</u>	<u>Co-58</u>	<u>Co-60</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>	<u>Ra-226</u>	<u>Th-232</u>	<u>U-235</u>	<u>U-238</u>
T42	09-Jul-13	$86 \pm 14$	122 ± 22	<7	<7	<7	<7	$640 \pm 96$	$474 \pm 121$	<35	$43 \pm 10$	$418\pm25$
T67	10-Jul-13	77 ± 19	231 ± 37	<10	<14	<10	$6 \pm 2$	$688 \pm 161$	$915 \pm 102$	68 ± 9	$38 \pm 6$	621 ± 57
T81	09-Jul-13	$62 \pm 18$	$163 \pm 35$	<11	<13	<10	<12	$612 \pm 156$	$566 \pm 91$	<45	$64 \pm 16$	$460 \pm 47$

## 4.a.1. CRUSTACEA - Blue Crab - (pCi/kg, wet weight)

Sample <u>Site</u>	Collection <u>Date</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>
T67	This sample	e not yet collected.									
T81	This sample	e not yet collected.									

### 4.a.2. FISH - Drums - (pCi/kg, wet weight)

Sample	Collection										
<u>Site</u>	Date	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>
T67	This samp	ole not yet collecte	ed.								
T81	31-Jul-13	2252 ± 443	<31	<25	<61	<41	<50	<26	<31	<515	<127

## 4.b. BROADLEAF VEGETATION - Brazilian Pepper - (pCi/kg, wet weight)

Sample Site	Collection Date	<u>Be-7</u>	<u>K-40</u>	<u>1-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>	<u>Pb-212</u>	<u>Ra-226</u>	<u>Ra-228</u>
T40	09-Jul-13	2386 ± 79	3935 ± 152	<19	<10	$125 \pm 6$	359 ± 62	<19	<212	<34
	14-Aug-13	1931 ± 72	$5389 \pm 215$	<15	<9	$36 \pm 3$	286 ± 58	<18	<211	<40
	16-Sep-13	$1674 \pm 68$	4199 ± 171	<21	<10	$31 \pm 3$	<993	<22	<273	<43
T41	09-Jul-13	$1576 \pm 79$	3583 ± 189	<29	<14	231 ± 11	<1442	<31	<348	<58
	14-Aug-13	$2003 \pm 76$	$5934\pm237$	<17	<11	80 ± 5	$406 \pm 68$	<22	<236	<48
	16-Sep-13	$2410\pm94$	$5115\pm215$	<30	<13	$18 \pm 4$	<1266	<28	<345	<57
Т67	10-Jul-13	$1548 \pm 77$	5145 ± 239	<28	<11	<15	<1338	<29	<323	<58
	12-Aug-13	2692 ± 102	4322 ± 193	<29	<13	<16	$1270\pm226$	<29	<345	<66
	18-Sep-13	$1922\pm70$	4376 ± 180	<14	<8	<10	$246\pm56$	<17	<214	<38
#### TURKEY POINT SITE

Supplemental Sampling

#### Third Quarter, 2013

Sample Type	Collection Frequency	Locations Sampled	Number of <u>Samples</u>
1. Direct Radiation	Quarterly	11	11
2. Airborne			
2.a. Air Iodines	Weekly	2	26
2.b. Air Particulates	Weekly	2	26
3. Waterborne			
3.a. Surface Water	Monthly	4	12
3.b. Shoreline Sediment	Semiannually	2	2
3.c. Aquatic Vegetation	Quarterly	1	1
4. Ingestion			
4.a. Milk	Semiannually	1	1
4.b. Marine Life	Semiannually	1	0
4.c. Food Crops	At Harvest	3	0
			Total: 79

NOTE: Measurement results having magnitudes that are significantly above the background of the measurement system are reported as net values plus or minus a one-standard-deviation error term. Measurement results that are <u>not</u> significantly above background are reported as less than a Lower Limit of Detection (<LLD), which is an estimated upper limit (with at least 95% confidence) for the true activity in the sample.

The marine fauna listed in this report were collected in part, under Florida FWC SAL030.

## 1. DIRECT RADIATION - TLD's - (µR/hour)

Sample Site	Deployment 04-Jun-13 Collection 17-Sep-13
NNW-6	$3.57 \pm 0.39$
NW-7	$4.21 \pm 0.38$
NW-8	$4.22\pm0.17$
WNW-2	$3.84 \pm 0.09$
WNW-3	$4.01 \pm 0.31$
WNW-6	$3.86 \pm 0.12$
W-8	$3.97\pm0.27$
ENE-1	$3.19 \pm 0.24$
T72	$3.81 \pm 0.07$
PTN-1	$3.73\pm0.26$
PTN-2	$3.24 \pm 0.33$

### 2.a. IODINE-131 IN WEEKLY AIR CARTRIDGES - (pCi/m<sup>3</sup>)

Collection Date		
Conection Date	T52	T56
02-Jul-13	< 0.03	< 0.03
09-Jul-13	< 0.02	< 0.02
17-Jul-13	< 0.02	< 0.02
23-Jul-13	<0.03	<0.03
30-Jul-13	< 0.03	< 0.03
08-Aug-13	< 0.02	< 0.02
14-Aug-13	< 0.03	< 0.03
21-Aug-13	< 0.02	< 0.02
27-Aug-13	<0.04	< 0.04
04-Sep-13	< 0.03	< 0.03
11-Sep-13	< 0.03	< 0.03
18-Sep-13	< 0.03	< 0.03
25-Sep-13	< 0.02	< 0.02

# 2.b. AIR PARTICULATES - GROSS BETA - (pCi/m<sup>3</sup>)

Collection Date		
	T52	T56
02-Jul-13	$0.013 \pm 0.002$	$0.011 \pm 0.002$
09-Jul-13	$0.007\pm0.002$	$0.013 \pm 0.002$
17-Jul-13	$0.006\pm0.002$	$0.007\pm0.002$
23-Jul-13	$0.018\pm0.003$	$0.016\pm0.002$
30-Jul-13	$0.021\pm0.002$	$0.021 \pm 0.002$
08-Aug-13	$0.011 \pm 0.002$	$0.011 \pm 0.002$
14-Aug-13	$0.015\pm0.002$	$0.015 \pm 0.002$
21-Aug-13	$0.010\pm0.002$	$0.013 \pm 0.002$
27-Aug-13	$0.011 \pm 0.002$	$0.014 \pm 0.002$
04-Sep-13	$0.010\pm0.002$	$0.012 \pm 0.002$
11-Sep-13	$0.006\pm0.002$	$0.009\pm0.002$
18-Sep-13	$0.012 \pm 0.002$	$0.013 \pm 0.002$
25-Sep-13	$0.013 \pm 0.002$	$0.011 \pm 0.002$
Average:	$0.012\pm0.001$	$0.013 \pm 0.001$

#### 2.b. AIR PARTICULATES - GAMMA ANALYSIS OF QUARTERLY COMPOSITES - (pCi/m<sup>3</sup>)

Sample Site	<u>Be-7</u>	<u>K-40</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>
T52	$0.0675 \pm 0.0060$	< 0.0162	< 0.0011	<0.0007	$0.0119 \pm 0.0080$
T56	$0.0865 \pm 0.0036$	< 0.0070	< 0.0005	< 0.0004	$0.0090 \pm 0.0009$

#### 3.a. SURFACE WATER - (pCi/L)

Sample <u>Site</u>	Collection Date	<u>H-3</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	Zr-95 <u>Nb-95</u> (A)	<u>1-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	Ba-140 <u>La-140</u> (B)
T08	09-Jul-13	2881 ± 94	$508 \pm 42$	<5	<6	<12	<8	<13	<12	<11	<5	<6	<8
	12-Aug-13	1932 ± 81	581 ± 33	<3	<3	<7	<3	<7	<5	<4	<3	<3	<5
	16-Sep-13	$1672 \pm 76$	$622 \pm 43$	<5	<6	<11	<8	<12	<8	<7	<4	<5	<9
T75	09-Jul-13	<130	<37	<3	<3	<7	<3	<6	<5	<5	<3	<3	<4
	12-Aug-13	<135	<76	<5	<5	<8	<7	<10	<9	<7	<5	<5	<7
	16-Sep-13	<141	<64	<5	<5	<9	<7	<10	<8	<7	<4	<6	<7
T84	09-Jul-13	$2654 \pm 91$	$518 \pm 42$	<4	<6	<12	<7	<11	<10	<9	<6	<5	<8
	12-Aug-13	$1855 \pm 47$	$601 \pm 43$	<4	<4	<12	<8	<12	<9	<7	<5	<6	<8
	16-Sep-13	1731 ± 77	$547 \pm 40$	<4	<5	<11	<8	<13	<9	<8	<5	<6	<8
T97	09-Jul-13	2674 ± 92	497 ± 32	<5	<5	<11	<8	<11	<10	<12	<6	<6	<7
	13-Aug-13	2042 ± 82	588 ± 30	<3	<3	<6	<5	<7	<5	<5	<3	<4	<4
	18-Sep-13	1701 ± 80	579 ± 33	<3	<3	<7	<3	<7	<5	<3	<3	<3	<6

(A) - These tabulated LLD values for Zr/Nb-95 are the higher of the individual parent or daughter LLD's.

(B) - These tabulated LLD values are for Ba-140, either based on direct measurement of Ba-140 or based on ingrowth of La-140, whichever method yields the greater sensitivity for a given sample.

#### 3.b. SHORELINE SEDIMENT - (pCi/kg, dry weight)

Sample <u>Site</u>	Collection Date	<u>Be-7</u>	<u>K-40</u>	<u>Co-58</u>	<u>Co-60</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>	<u>Ra-226</u>	<u>Th-232</u>	<u>U-235</u>	<u>U-238</u>
T84	09-Jul-13	171 ± 26	479 ± 49	<13	$32 \pm 3$	<13	<14	965 ± 198	1497 ± 124	$59 \pm 9$	<18	403 ± 67
T85	09-Jul-13	$65 \pm 20$	$180 \pm 35$	<13	19 ± 3	<11	<14	755 ± 176	$1005 \pm 105$	33 ± 7	49 ± 16	380 ± 53

#### 3.c. AQUATIC VEGETATION - Non-Specific - (pCi/kg, wet weight)

Sample Site	Collection Date	<u>Be-7</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u> <u>C</u>	<u>co-60</u>	<u>Ag-110m</u>	<u>1-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>	<u>Pb-212</u>	<u>Ra-226</u>	<u>Ra-228</u>
Т84	13-Aug-13	1878 ± 58	946 ± 50	7 ± 1	21 ± 2	<9	17 ± 1	<17	<10	<10	881 ± 70	132 ± 5	5695 ± 266	452 ± 15
Others: Sb-1	25 134 ± 5 pC	i/kg												

#### 4.a. GOAT'S MILK - (pCi/L)

Sample Site	Collection Date	K-40	<u>I-131</u>	Cs-134	Cs-137	Ba-140 La-140 (A)
Т99	01-Aug-13	1633 ± 47	<1	<1	37 ± 1	<3

(A) - This tabulated LLD value is for Ba-140, either based on direct measurement of Ba-140 or based on ingrowth of La-140, whichever method yields the greater sensitivity.

#### 4.b. MARINE LIFE - Horseshoe Crab - (pCi/kg, wet weight)

Sample <u>Site</u>	Collection Date	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	<u>Ag-110m</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>
T84	This sam	ple not yet co	ollected.									

#### 4.c. FOOD CROPS - (pCi/kg, wet weight)

Sample <u>Site</u>	Collection Date	<u>Be-7</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Co-60</u>	<u>Ag-110m</u>	<u>l-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>
T43	This sa	ample was pre	eviously colled	cted.								
T44	This sa	ample was pre	eviously colled	cted.								
T45	This sa	ample was pre	eviously colled	cted.								

## ATTACHMENT B

Fourth Quarter, 2013



RADIOLOGICAL SURVEILLANCE

OF

FLORIDA POWER AND LIGHT COMPANY

**TURKEY POINT SITE** 

FOURTH QUARTER 2013

BUREAU OF RADIATION CONTROL

## TURKEY POINT SITE

Offsite Dose Calculation Manual Sampling

Fourth Quarter, 2013

Sample Type	Collection Frequency	Locations Sampled	Number of <u>Samples</u>
1. Direct Radiation	Quarterly	23	23
2. Airborne 2.a. Air Iodines	Weekly	6	84
2.b. Air Particulates	Weekly	6	84
<ol> <li>Waterborne</li> <li>3.a. Surface Water</li> </ol>	Monthly	3	9
3.b. Shoreline Sediment	Semiannually	3	0
<ol> <li>Ingestion</li> <li>4.a. Fish and Invertebrates</li> </ol>			
4.a.1. Crustacea	Semiannually	2	2
4.a.2. Fish	Semiannually	2	ł
4.b. Broadleaf Vegetation	Monthly	3	9
			Total: 212

NOTE: Measurement results having magnitudes that are significantly above the background of the measurement system are reported as net values plus or minus a one-standard-deviation error term. Measurement results that are <u>not</u> significantly above background are reported as less than a Lower Limit of Detection (<LLD), which is an estimated upper limit (with at least 95% confidence) for the true activity in the sample.

The marine fauna listed in this report were collected in part, under Florida FWC SAL030.

Sample Site	Deployment 17-Sep-13 Collection 18-Dec-13	Sample Site	Deployment 17-Sep-13 Collection 18-Dec-13
N-2	$3.10 \pm 0.08$	WSW-8	$2.77\pm0.05$
N-7	$2.82 \pm 0.26$		
N-10	$3.08 \pm 0.29$	SW-1	$2.49 \pm 0.18$
		SW-8	$2.31 \pm 0.06$
NNW-2	$2.55 \pm 0.19$		
NNW-10	$3.28 \pm 0.12$	SSW-5	$2.60 \pm 0.19$
		SSW-10	$2.60 \pm 0.20$
NW-1	$3.46 \pm 0.23$		
NW-5	$2.77 \pm 0.19$	S-5	$2.45 \pm 0.12$
NW-10	$3.48 \pm 0.19$	S-10	$2.93 \pm 0.29$
WNW-10	$3.64 \pm 0.35$	SSE-1	$2.24 \pm 0.15$
		SSE-10	$2.43 \pm 0.20$
W-1	$3.06 \pm 0.04$		
W-5	$2.84 \pm 0.19$	NNE-22	$3.22 \pm 0.39$
W-9	$2.79 \pm 0.27$		
		WNW-2	$2.92 \pm 0.21$

### 1. DIRECT RADIATION - TLD's - (µR/hour)

## 2.a. IODINE-131 IN WEEKLY AIR CARTRIDGES - (pCi/m<sup>3</sup>)

Collection Date						
	T41	T51	T57	T58	T64	T72
01-Oct-13	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03
08-Oct-13	< 0.03	<0.03	< 0.03	< 0.03	< 0.03	< 0.03
16-Oct-13	< 0.02	< 0.02	< 0.02	<0.01(A)	< 0.02	<0.02
22-Oct-13	< 0.02	< 0.02	< 0.02	<0.05(B)	< 0.02	<0.02
30-Oct-13	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
05-Nov-13	< 0.03	<0.03	< 0.03	<0.03	< 0.04	< 0.03
12-Nov-13	< 0.03	<0.03	< 0.03	< 0.03	< 0.03	< 0.03
18-Nov-13	< 0.04	< 0.03	< 0.03	< 0.03	< 0.03	< 0.04
26-Nov-13	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
02-Dec-13	< 0.04	< 0.04	< 0.04	<0.04	< 0.04	< 0.04
11-Dec-13	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
16-Dec-13	< 0.03	<0.05(C)	< 0.03	< 0.03	< 0.03	< 0.03
23-Dec-13	< 0.03	<0.04(D)	< 0.03	< 0.03	< 0.03	< 0.03
31-Dec-13	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03

(A) Power failure, estimated run time 116.6 out of 192.1 hours.

(B) Power restored on 10/21/13 at 1800 hours.

(C) Power failure, estimated run time 30.6 out of 122.3 hours.

(D) Power restored 12/17/13 at approximately 1700 hours.

## 2.b. AIR PARTICULATES - GROSS BETA - (pCi/m<sup>3</sup>)

Collection Date	T41	T51	Т57	Т58	T64	Т72
01-Oct-13	$0.010 \pm 0.002$	$0.011 \pm 0.002$	$0.013 \pm 0.002$	$0.007 \pm 0.002$	$0.010 \pm 0.002$	$0.013 \pm 0.002$
08-Oct-13	$0.009 \pm 0.002$	$0.008 \pm 0.002$	$0.009 \pm 0.002$	$0.010\pm0.002$	$0.010\pm0.002$	$0.008\pm0.002$
16-Oct-13	$0.007 \pm 0.001$	$0.005 \pm 0.001$	$0.007\pm0.001$	$0.013 \pm 0.003(A)$	$0.007 \pm 0.001$	$0.008\pm0.002$
22-Oct-13	$0.007\pm0.002$	$0.010 \pm 0.002$	$0.006 \pm 0.002$	<0.053(B)	< 0.002	$0.007\pm0.002$
30-Oct-13	$0.026\pm0.002$	$0.023\pm0.002$	$0.023\pm0.002$	$0.019\pm0.002$	$0.018\pm0.002$	$0.023\pm0.002$
05-Nov-13	$0.015 \pm 0.002$	$0.019 \pm 0.003$	$0.015 \pm 0.002$	$0.014 \pm 0.002$	$0.018 \pm 0.003$	$0.018\pm0.003$
12-Nov-13	$0.008 \pm 0.002$	$0.008 \pm 0.002$	$0.014\pm0.002$	$0.012 \pm 0.002$	$0.011 \pm 0.002$	$0.007\pm0.002$
18-Nov-13	$0.009 \pm 0.002$	$0.013 \pm 0.002$	$0.009\pm0.002$	$0.014 \pm 0.002$	$0.012 \pm 0.002$	$0.008\pm0.002$
26-Nov-13	$0.006 \pm 0.001$	$0.003 \pm 0.001$	$0.005 \pm 0.001$	$0.005 \pm 0.001$	$0.007 \pm 0.001$	$0.006\pm0.001$
02-Dec-13	$0.006 \pm 0.002$	$0.008 \pm 0.002$	$0.012\pm0.002$	$0.010 \pm 0.002$	$0.006 \pm 0.002$	$0.010\pm0.002$
11-Dec-13	$0.009 \pm 0.001$	$0.008 \pm 0.001$	$0.007 \pm 0.001$	$0.009 \pm 0.001$	$0.007 \pm 0.001$	$0.010\pm0.001$
16-Dec-13	$0.013 \pm 0.002$	$0.015 \pm 0.006(C)$	$0.014 \pm 0.002$	$0.010 \pm 0.002$	$0.006 \pm 0.002$	$0.011\pm0.002$
23-Dec-13	$0.010 \pm 0.002$	$0.009 \pm 0.002(D)$	$0.011\pm0.002$	$0.013 \pm 0.002$	$0.013 \pm 0.002$	$0.012\pm0.002$
31-Dec-13	< 0.004	$0.010\pm0.002$	$0.006\pm0.001$	$0.005 \pm 0.001$	$0.005 \pm 0.001$	$0.006 \pm 0.001$
Average:	< 0.010	$0.011 \pm 0.001$	$0.011 \pm 0.001$	< 0.014	< 0.009	$0.011 \pm 0.001$

(A) Power failure, estimated run time 116.6 out of 192.1 hours.

(B) Power restored on 10/21/13 at 1800 hours.

(C) Power failure, estimated run time 30.6 out of 122.3 hours.

(D) Power restored 12/17/13 at approximately 1700 hours.

#### 2.b. AIR PARTICULATES - GAMMA ANALYSIS OF QUARTERLY COMPOSITES - (pCi/m<sup>3</sup>)

Sample Site	<u>Be-7</u>	<u>K-40</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>
T41	$0.0868 \pm 0.0169$	< 0.0198	<0.0011	< 0.0011	$0.0093 \pm 0.0039$
T51	$0.1137 \pm 0.0188$	< 0.0129	< 0.0012	<0.0009	< 0.0106
T57	$0.0948 \pm 0.0176$	< 0.0223	< 0.0012	< 0.0013	$0.0096 \pm 0.0016$
T58	$0.1064 \pm 0.0051$	< 0.0095	< 0.0008	<0.0006	$0.0103 \pm 0.0043$
Т64	$0.0951 \pm 0.0060$	< 0.0138	< 0.0008	<0.0009	$0.0091 \pm 0.0037$
T72	$0.1002 \pm 0.0071$	<0.0116	<0.0009	<0.0009	$0.0153 \pm 0.0022$
172	$0.1002 \pm 0.0071$	<0.0116	<0.0009	<0.0009	$0.0153 \pm 0.002$

#### 3.a. SURFACE WATER - (pCi/L)

Sample <u>Site</u>	Collection Date	<u>H-3</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	Zr-95 <u>Nb-95</u> (A)	<u>I-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	Ba-140 <u>La-140</u> (B)
T42	15-Oct-13	<148	139 ± 16	<3	<3	<6	<3	<6	<5	<4	<3	<3	<5
	18-Nov-13	<146	$266 \pm 29$	<5	<5	<10	<7	<12	<9	<7	<5	<7	<11
	18-Dec-13	<140	235 ± 14	<2	<2	<3	<2	<4	<3	<3	<2	<2	<3
Т67	14-Oct-13	<148	251 ± 28	<5	<5	<9	<7	<10	<10	<7	<5	<6	<7
	19-Nov-13	<146	<70	<5	<4	<8	<6	<9	<8	<6	<5	<6	<8
	18-Dec-13	<140	285 ± 21	<3	<3	<6	<3	<6	<5	<4	<3	<3	<6
T81	14-Oct-13	<148	$265 \pm 22$	<3	<3	<7	<3	<8	<5	<4	<3	<3	<5
	18-Nov-13	<146	313 ± 31	<5	<5	<10	<7	<9	<9	<7	<4	<6	<9
	18-Dec-13	<140	$300 \pm 22$	<3	<3	<5	<3	<6	<5	<4	<3	<3	<6

(A) - These tabulated LLD values for Zr/Nb-95 are the higher of the individual parent or daughter LLD's.

(B) - These tabulated LLD values are for Ba-140, either based on direct measurement of Ba-140 or based on ingrowth of La-140, whichever method yields the greater sensitivity for a given sample.

## 3.b. SHORELINE SEDIMENT - (pCi/kg, dry weight)

Sample <u>Site</u>	Collection Date										
		<u>Be-7</u>	<u>K-40</u>	<u>Co-58</u>	<u>Co-60</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>	<u>Ra-226</u>	<u>Th-232</u>	Others:
T42	This sam	ple was prev	iously collect	ed.							
Т67	This sam	ple was prev	iously collect	ed.							
T81	This sam	ple was prev	iously collect	ed.							

### 4.a.1. CRUSTACEA - Blue Crab - (pCi/kg, wet weight)

Sample	Collection										
<u>Site</u>	Date	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>
T67	This samp	e was previously col	lected.								
T81	14-Oct-13	$1900\pm207$	<21	<21	<40	<33	<44	<22	27 ± 4	$389\pm53$	<86
T81	30-Oct-13	$1067 \pm 122$	<21	<31	<80	<22	<53	<26	<23	<507	<92

### 4.a.2. FISH - Mixed Species - (pCi/kg, wet weight)

Sample <u>Site</u>	Collection Date	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>
Т67	18-Dec-13	$2272 \pm 215$	<26	<22	<54	<40	<56	<27	<27	<450	<112
T81	This samp	le was previously col	llected.								

### 4.b. BROADLEAF VEGETATION - Brazilian Pepper - (pCi/kg, wet weight)

Sample Site	Collection <u>Date</u>	<u>Be-7</u>	<u>K-40</u>	<u>l-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>	<u>Pb-212</u>	<u>Ra-226</u>	<u>Ra-228</u>
T40	16-Oct-13	$1289\pm55$	$4538 \pm 186$	<14	<8	46 ± 3	$264\pm50$	<17	<214	<35
	19-Nov-13	$1543 \pm 56$	$4003 \pm 162$	<9	<7	28 ± 3	$300 \pm 48$	<15	<183	<31
	18-Dec-13	$2039\pm85$	5491 ± 231	<20	<11	40 ± 5	<1361	<30	<383	<63
T41	16-Oct-13	$1697\pm82$	$5774\pm246$	<26	<15	27 ± 4	<1480	<32	<381	<61
	19-Nov-13	$1381\pm64$	$4698 \pm 196$	<15	<12	51 ± 5	<1144	<25	<271	<50
	18-Dec-13	$1803 \pm 77$	5464 ± 225	<17	<13	$20 \pm 4$	<1300	<27	<336	<62
Т67	14-Oct-13	$1312\pm69$	4811 ± 216	<29	<16	<17	<1162	<27	<334	<69
	19-Nov-13	$1171 \pm 51$	$4361 \pm 181$	<10	<9	5 ± 2	$420\pm55$	<18	<198	<36
	18-Dec-13	995 ± 44	4195 ± 170	<9	<8	<8	318 ± 52	<16	<176	<33

#### TURKEY POINT SITE

#### Supplemental Sampling

#### Fourth Quarter, 2013

Sample Type	Collection Frequency	Locations Sampled	Number of <u>Samples</u>
1. Direct Radiation	Quarterly	10	9
2. Airborne 2.a. Air Iodines	Weekly	2	28
2.b. Air Particulates	Weekly	2	28
<ol> <li>Waterborne</li> <li>3.a. Surface Water</li> <li>3.b. Shoreline Sediment</li> </ol>	Monthly Semiannually	4 2	12 0
3.c. Aquatic Vegetation	Quarterly	1	1
4. Ingestion			
4.a. Milk	Semiannually	1	1
4.b. Marine Life	Semiannually	1	0
4.c. Food Crops	At Harvest	3	0
			Total: 79

NOTE: Measurement results having magnitudes that are significantly above the background of the measurement system are reported as net values plus or minus a one-standard-deviation error term. Measurement results that are not significantly above background are reported as less than a Lower Limit of Detection (<LLD), which is an estimated upper limit (with at least 95% confidence) for the true activity in the sample.

The marine fauna listed in this report were collected in part, under Florida FWC SAL030.

## 1. DIRECT RADIATION - TLD's - (µR/hour)

Sample Site	Deployment 17-Sep-13 Collection 18-Dec-13
NNW-6	$2.85 \pm 0.39$
NW-7	$3.25 \pm 0.22$
NW-8	$3.27 \pm 0.06$
WNW-3	$3.18 \pm 0.06$
WNW-6	$2.88 \pm 0.16$
W-8	$3.10 \pm 0.32$
ENE-1	$2.45 \pm 0.22$
Т72	$2.89 \pm 0.15$
PTN-1	$2.90 \pm 0.16$
PTN-2	(A)

(A) TLD lost when the surrounding area was cleared.

#### 2.a. IODINE-131 IN WEEKLY AIR CARTRIDGES - (pCi/m<sup>3</sup>)

Collection Date		
	T52	T56
01-Oct-13	< 0.03	< 0.03
08-Oct-13	< 0.03	< 0.03
16-Oct-13	< 0.02	<0.02
22-Oct-13	< 0.02	< 0.02
30-Oct-13	< 0.03	< 0.02
05-Nov-13	<0.04	<0.04
12-Nov-13	< 0.03	< 0.03
18-Nov-13	< 0.03	<0.04
26-Nov-13	< 0.02	< 0.02
02-Dec-13	< 0.04	< 0.04
11-Dec-13	< 0.02	< 0.02
16-Dec-13	< 0.03	< 0.03
23-Dec-13	< 0.03	< 0.03
31-Dec-13	< 0.03	< 0.02

## 2.b. AIR PARTICULATES - GROSS BETA - (pCi/m<sup>3</sup>)

Collection Date		
	T52	T56
01-Oct-13	$0.005\pm0.002$	$0.010\pm0.002$
08-Oct-13	$0.010\pm0.002$	$0.010\pm0.002$
16-Oct-13	$0.004\pm0.001$	$0.010\pm0.002$
22-Oct-13	$0.004\pm0.002$	$0.005\pm0.002$
30-Oct-13	$0.023 \pm 0.002$	$0.019\pm0.002$
05-Nov-13	$0.011 \pm 0.002$	$0.015 \pm 0.002$
12-Nov-13	$0.007\pm0.002$	$0.010 \pm 0.002$
18-Nov-13	$0.011 \pm 0.002$	$0.011 \pm 0.002$
26-Nov-13	$0.003 \pm 0.001$	$0.006\pm0.001$
02-Dec-13	$0.005 \pm 0.002$	$0.009 \pm 0.002$
11-Dec-13	$0.007 \pm 0.001$	$0.008 \pm 0.001$
16-Dec-13	$0.012\pm0.002$	$0.008\pm0.002$
23-Dec-13	$0.010 \pm 0.002$	$0.007 \pm 0.001$
31-Dec-13	$0.005 \pm 0.001$	$0.003 \pm 0.001$
Average:	$0.008 \pm 0.001$	$0.009 \pm 0.001$

#### 2.b. AIR PARTICULATES - GAMMA ANALYSIS OF QUARTERLY COMPOSITES - (pCi/m<sup>3</sup>)

Sample Site	<u>Be-7</u>	<u>K-40</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Pb-210</u>
T52	$0.0795 \pm 0.0073$	<0.0196	< 0.0012	< 0.0013	<0.0089
Т56	$0.0922 \pm 0.0069$	< 0.0117	<0.0009	<0.0009	<0.0101

#### 3.a. SURFACE WATER - (pCi/L)

Sample <u>Site</u>	Collection <u>Date</u>	<u>H-3</u>	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	Zr-95 <u>Nb-95</u> (A)	<u>I-131</u>	<u>Cs-134</u>	<u>Cs-137</u>	Ba-140 <u>La-140</u> (B)
T08	14-Oct-13	1093 ± 69	$587 \pm 34$	<3	<3	<7	<3	<8	<6	<4	<3	<3	<6
	18-Nov-13	732 ± 62	674 ± 45	<5	<5	<11	<8	<11	<9	<7	<5	<6	<7
	18-Dec-13	$3057\pm94$	$657 \pm 45$	<4	<5	<10	<8	<13	<9	<6	<6	<6	<9
T75	14-Oct-13	<148	<71	<4	<5	<8	<7	<9	<7	<7	<5	<5	<6
	18-Nov-13	<146	<74	<5	<5	<11	<6	<10	<9	<7	<5	<5	<7
	18-Dec-13	<140	<40	<3	<3	<6	<4	<6	<5	<4	<3	<3	<7
T84	14-Oct-13	1138 ± 69	541 ± 41	<4	<5	<10	<7	<11	<9	<8	<5	<6	<8
	18-Nov-13	$722\pm61$	687 ± 36	<3	<3	<8	<4	<8	<6	<4	<3	<3	<6
	18-Dec-13	2993 ± 93	$645 \pm 35$	<3	<3	<7	<3	<8	<5	<4	<3	<4	<5
Т97	15-Oct-13	1071 ± 68	$604 \pm 43$	<5	<5	<11	<8	<11	<9	<7	<5	<5	<11
	18-Nov-13	797 ± 63	627 ± 35	<3	<3	<7	<3	<7	<5	<4	<3	<3	<6
	18-Dec-13	2866 ± 92	$680 \pm 45$	<5	<6	<11	<8	<12	<9	<7	<5	<6	<10

(A) - These tabulated LLD values for Zr/Nb-95 are the higher of the individual parent or daughter LLD's.

(B) - These tabulated LLD values are for Ba-140, either based on direct measurement of Ba-140 or based on ingrowth of La-140, whichever method yields the greater sensitivity for a given sample.

#### Sample Site Collection Date <u>Be-7</u> <u>K-40</u> <u>Co-58</u> <u>Pb-210</u> <u>Th-232</u> Others: <u>Co-60</u> <u>Cs-134</u> <u>Cs-137</u> Ra-226 This sample was previously collected. T84 T85 This sample was previously collected. 3.c. AQUATIC VEGETATION - Non-Specific - (pCi/kg, wet weight) Sample Collection Date <u>Be-7</u> <u>Ag-110m</u> Site <u>K-40</u> <u>Mn-54</u> <u>Co-58</u> <u>Co-60</u> <u>I-131</u> <u>Cs-134</u> <u>Cs-137</u> <u>Pb-212</u> <u>Ra-226</u> <u>Ra-228</u> <8 T84 18-Nov-13 $1122 \pm 35$ $811 \pm 41$ <8 7 ± 1 <8 <12 <8 <8 $96 \pm 4$ $4103 \pm 146$ $350 \pm 12$ 4.a. GOAT'S MILK - (pCi/L) Ba-140 La-140 Sample Collection Date K-40 1-131 Cs-134 Cs-137 Site (A)

<4

<5

<15

(A) - This tabulated LLD value is for Ba-140, either based on direct measurement of Ba-140 or based on ingrowth of La-140, whichever method yields the greater sensitivity.

<4

 $866 \pm 52$ 

3.b. SHORELINE SEDIMENT - (pCi/kg, dry weight)

19-Dec-13

T99

### 4.b. MARINE LIFE - Horseshoe Crab - (pCi/kg, wet weight)

Sample <u>Site</u>	Collection Date	<u>K-40</u>	<u>Mn-54</u>	<u>Co-58</u>	<u>Fe-59</u>	<u>Co-60</u>	<u>Zn-65</u>	<u>Ag-110m</u>	<u>Cs-134</u>	<u>Cs-137</u>	<u>Ra-226</u>	<u>Ra-228</u>	
T84	There w	vas no sample	available dur	ing the quart	er.								
<u>4.c. FOOD CR</u>	<u> (pCi/kg. †</u>	wet weight)											
Sample	Collection Date	Be-7	K-40	Mn-54	Co-58	Co-60	Δα-110	)m I_13	1 Cs-	.134 (	Cs-137	Ra-226	Ra-228
Site	Date	<u>BC-7</u>	<u>K-40</u>	<u>MII-54</u>	<u>C0-58</u>	<u>C0-00</u>	<u>Ag-110</u>	<u>//// 1-15</u>	<u>1 CS-</u>	154	<u>CS-137</u>	<u>Ka-220</u>	<u> Na-220</u>
T43	This sa	mple was prev	iously collect	ed.									
T44	This sa	mple was prev	iously collect	ed.									

T45 This sample was previously collected.

### ATTACHMENT C

## **RESULTS FROM THE 2013**

## INTERLABORATORY COMPARISON PROGRAM

## CONDUCTED BY

## DEPARTMENT OF ENERGY

### 2013

## ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4

Program status	Radion	Result	Ref. Value	Flag (Evaluation)	Acceptance Range
Matrix: RdF	Air Filter	Bq/filter			
Required	MN54	4.8	4.26	А	2.98 – 5.54
Required	CO57	2.2	2.36	А	1.65 –3. 07
Required	CO60	0.02		A	False Positive Test (acceptable)
	ZN65	3.6	3.13	А	2.19 - 4.07
Required	CS134	1.70	1.78	А	1.25 – 2.31
Required	CS137	2.8	2.6	А	1.82 – 2.38
Matrix: GrF	Air Filter I	3q/filter			
Required	Gross Beta	1.04	.85	A	.43 – 1.28
Matrix: MaS	Soil Bq/	kg			
Required	K40	667	625.3	А	437.7 - 812. <del>9</del>
	MN54	-0.7		A	False Positive Test (acceptable)
	CO57	0.7		A	False Positive Test (acceptable)
	CO60	695	691	А	484 - 898
	ZN65	1077	995	А	697 - 1294
	CS134	795	887	А	621 - 1153
Required	CS137	603	587	А	411 - 763
Matrix: MaV	V Water	Bq/L			
Required	H3	489	507	A	355 – 659
	MN54	29.8	27.4	A	19.2 - 35.6
	CO57	32.1	30.9	A	21.6 – 40.2
Required	CO60	20.7	19.56	А	13.69 - 25.43
	NI63	NR	33.4	Ν	23.4 43.4 (Not Reporting Previously Reported Analyte)
	ZN65	34.7	30.4	А	21.3 - 39.5
Required	CS134	25.6	24.4	А	17.1 - 31.7
Required	CS137	-0.06		А	False Positive Test
					(acceptable)
	SR90	0.03	10.5	N	7.4 - 13.7
Matrix: RdV	Vegetatio	n, Bq/sample :			
	MN54	-0.01		А	False Positive Test (acceptable)
	CO57	7.9	8.68	A	6.08 – 11.28

## DOE-MAPEP 28 RESULTS

Required	CO60	5.8	5.85	А	4.10 - 7.67
	ZN65	6.3	6.25	А	4.38 – 8.13
	CS134	7.91	8.43	А	5.90 - 10.96
Required	CS137	0.18	0.04	N	False Positive Test

Evaluation : A = Acceptable, W = Acceptable with Warning, N = Not Acceptable \* Acceptable Uncertainty Value for False Positive.

There are two relevant data flags. A false positive flag on Potassium-40 in water was reported. The MAPEP criteria for reporting require a value to be reported, regardless of significance. The value reported (0.7 Bq/L) was below any level of significance for reporting, is a value for a naturally occurring radioactive material, and thus is not a concern for environmental monitoring. A review of the data revealed no anomaly. No further actions will be taken as a result of this flag. The second flag is of concern because it was on the gross beta determination on an air filter and was a not acceptable flag.

The value reported was 1.8x the reference value. After the flag result was indicated, an investigation revealed a cause. The laboratory supervisor departed the program with minimal notice two weeks before the reporting date of the study. The analyst that calculated the reported values did not verify that the correct data was used in the spreadsheet (The same spreadsheet is used each time and it is believed old data was used), and I, being unfamiliar with the process did not catch the error when I reported the data to MAPEP. The corrected spreadsheet resulted in a value of 1.04, well within the acceptance range. A verification process that should have caught the program was also not used due to unfamiliarity with the process. This verification process will be used for subsequent studies. The analyst has also been apprised of the issue.

## 2013

## ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT TURKEY POINT PLANT – UNITS 3 & 4

Program status	Radionu	Result	Ref. Value	Flag (Evaluation)	Acceptance Range
Matrix: RdF	Air Filter E	Ba/filter			
Required	MN54	3.7	3.5	А	2.5 -4.6
Required	CO57	3.1	3.4	А	2.4 - 4.4
Required	CO60	2.2	2.3	А	1.6 - 3.0
	ZN65	3.1	2.7	А	1.9 - 3.5
Required	CS134	-0.1	0	А	False Positive within acceptable range
Required	CS137	2.8	2.7	А	1.9 - 3.5
Matrix: GrF	Air Filter B	q/filter			
Required	Gross Beta	1.752	1.63	A	0.82 - 2.45
Matrix: MaS	Soil Bq/k	g			
Required	K40	700	633	А	443 - 823
	MN54	731	674	А	472 - 876
	CO57	606	0	N	False positive (Not required for Soil See the cause and action taken below)
	CO60	492	451	А	316 - 586
	ZN65	-0.5	0	А	False Positive
	CS134	1266	1172	А	820 - 1524
Required	CS137	1061	977	А	684 - 1270
Matrix: MaV	V Water B	q/L			
Required	Н3	6.8	0	Ν	False Positive See the cause and action taken below
	MN54	-0.1	0	Α	False Positive within acceptable range
	CO57	0.1	0	Α	False Positive within acceptable range
Required	CO60	24.6	23.58	А	16.51 - 30.65
	NI63	10.5	26.4	Ν	18.5 - 34.3
					Analysis not required
	ZN65	39.7	34.6	А	24.2 - 45.0
Required	CS134	32.3	30.0	А	21.0 - 39.0
Required	CS137	34.6	31.6	А	22.1 - 41.1
	SR90	-0.2	7.22	Ν	5.05 - 9.39

#### DOE-MAPEP 29 RESULTS

Analysis not required

Matrix: RdV	Vegetation, B	q/sample :			
	MN54	7.2	7.88	А	5.52 - 10.24
	CO57	0.1	0	А	False Positive within acceptable range
Required	CO60	0.1	0	А	False Positive within acceptable range
	ZN65	2.5	2.63	A	1.84 - 3.42
	CS134	5.0	5.20	А	3.64 - 6.76
Required	CS137	6.0	6.60	A	4.62 - 8.58

Evaluation : A = Acceptable, W = Acceptable with Warning, N = Not Acceptable \* Acceptable Uncertainty Value for False Positive.

There were two relevant data flags. A false positive flag on Tritium in water was reported. This was caused by static discharge on the vial. The analyst did not follow the procedure which indicated that the vials should be wiped to remove static. When the sample was rerun, and anti-static wipes were used on the vial, the value obtained was not sufficient to cause a false positive signal. The laboratory procedure was modified to require the use of anti-static wipes on all vials prior to placement in the liquid scintillation counter.

The second flag is a false positive on Co-57 in water. This was caused because the lab used a gamma analysis library that is specific for MAPEP analytes. The false positive was caused by the presence of Eu-152 which is not in the MAPEP gamma library. When the nuclear power library (the library used for all power plant samples) was used, Co-57 was no longer identified. The state of Florida lab process has been changed to require the use of the nuclear power library for analysis in the future.

# ATTACHMENT D

Industry Initiative

Ground Water Protection Program

Tritium in Ground Water Monitoring

2013

A. Description of Program:

Turkey Point maintains a sampling and analysis program to meet the requirements of NEI 07-07, Industry Ground Water Protection Initiative. The procedures that govern the performance are EV-AA-100-1001, Fleet Ground Water Protection Program Implementing Guideline and 0-ADM-654, Ground Water Protection Program.

The sampling frequency is quarterly; more often if conditions warrant.

Sample assay is performed by a private contractor for the first two quarters. The last two quarters were sampled by trained in house Technicians in accordance with procedure 0-NCAP-103.

## B. Discussion

The Turkey Point Nuclear site is surrounded on three sides by the closed cooling canal system. This canal system, in addition to being the source of tertiary cooling, is the body of water receiving permitted liquid radiological waste; the canal system tritium level averages was 4,011 pCi/L in 2013. This supports the expectation to see tritium in subsurface water collected either on-site or offsite close to the (within the Owner Controlled Area) cooling canal system. Twenty eight (28) wells were involved in the 2013 monitoring program; some locations have multiple (two or three) depths.

Samples are analyzed for Tritium & Gamma emitters. As conditions warrant, analysis included Fe-55, Ni-63, Sr-89/90 and alpha (all were < LLD).

88 'routine' samples were collected.

## C. Results

Tritium was detected in those locations reasonably affected by the cooling canal. The tritium results were from <MDA to 11,200 pico curies per liter. All results were less than the limits of the Offsite Dose Calculation Manual, Table 5.1-2, Reporting Levels for Radioactivity Concentrations in Environmental Samples. Cooling canal tritium values typically vary from 722 to 9234 pCi/L.

Tabular results follow:

C. Results (continued)

# Turkey Point 2013 Well Sampling Results, pCi/L

Note:

# --- denotes less than detectable, Typical MDAs K-40: 90 pCi/L Cs-137: 7 pCi/L

Blank boxes indicate not sampled this period.

Gray boxes in bold denote samples analyzed additionally for hard to detect beta emitters for isotopes Fe-55, Ni-63, Sr-89/90 and alpha (all were < LLD) based on GWI program requirements.

Well number	First Quarter 2013			Second Quarter 2013			Third Quarter 2013			Fourth Quarter 2013		
	H-3	K-40	Cs-	H-3	K-40	Cs-	H-3	K-40	Cs-	H-3	K-40	Cs-
	212	6 991	1/ 29	252		10 73	206	99.04	6 25	202		137
	200	407.7	07.04	303		10.75	200	00.04	0.35	203		
	300	107.7	21.24	/ 24			247			383		
P-94-2	975	215.4					/61	243.8				
P-94-4	242			560			549			782		6.93
STP-1					 		167					
		<u> </u>										
PTN-MW-1s							81.8					
PTN-MW-1i	592	436.6					324	344.5				
PTN-MW-1d	1850	499					1980	422.3				
PTN-MW-2s							72.2					
PTN-MW-3s							196					
PTN-MW-4s				115			116			918		
PTN-MW-4i	3490	531.6		3300	555.7		2990	526.1		140		
PTN-MW-4d	3480	502		3550	630.8		3560	617.5		78.5		
PTN-MW-5s		272.2		284	231.2		280	307.5		304		
PTN-MW-5i	468	340.2		411	465		345	431.9		234		
PTN-MW-5d	3390	612.4		2670	629.3		2150	588		418		
PTN-MW-6s		93.4		[								
PTN-MW-6d	1500	391.2		[	]		.176	438.7				
PTN-MW-7s	2580			1630			620	27.13		370		
PTN-MW-7i	1160	289.2		263	336.4		2420	220.5		1810		
PTN-MW-7d	2330	289		2190	336		75.1					
PTN-MW-8s	2810	148.8		360	137.5	10.75	1700			11,200		14.3
PTN-MW-9s	475	120		667	91.04		247			376		

C. Results (continued)

# Turkey Point 2013 Well Sampling Results, pCi/L

Note: -- denotes less than detectable, Typical MDAs K-40: 90 pCi/L Cs-137: 7 pCi/L Blank boxes indicate not sampled this period. Gray boxes in bold denote samples analyzed additionally for hard to beta emitters for isotopes Fe-55, Ni-63, Sr-89/90 and alpha (all were < LLD) based on GWI program requirements.

Well number	First Quarter 2013		Second Quarter 2013			Third Quarter 2013			Fourth Quarter 2013			
	H-3	K-40	Cs- 137	H-3	K-40	Cs- 137	H-3	K-40	Cs- 137	H-3	K-40	Cs- 137
PTN-MW-10s								78.22				
PTN-MW-10i	1790	345.9					1530	334.5				
PTN-MW-10d	3140	551.1					2620	552.8				
PTN-MW-11s				129			80.5					
PTN-MW-12s	820			635			786	103.7		658		

D. List of wells and their locations

Well Name	Location
PTN-MW-1s PTN-MW-1i PTN-MW-1d	Northeast of Switch Yard, South of entrance road to Fossil Plant
PTN-MW-2s	South Switch Yard by parking lot
PTN-MW-3s	Northeast of new Issues Warehouse
PTN-MW-4s PTN-MW-4i PTN-MW-4d	SW corner of parking lot South of Training Bldg
PTN-MW-5s PTN-MW-5i PTN-MW-5d	SW of CRF, by canal
PTN-MW-6s PTN-MW-6d	NE of site in the berm for fossil oil tanks
PTN-MW-7s PTN-MW-7i PTN-MW-7d	NE of RCA, by Neutralization Tank
PTN-MW-8s	Near U3 RWST
PTN-MW-9s	Near U4 RWST
PTN-MW-10s PTN-MW-10i PTN-MW-10d	SE of Radwaste Bldg by S/G Bldg
PTN-MW-11s	South of truck entrance to Rad Waste Bldg
PTN-MW-12s	West of Condenser Polisher road
STP-1	West of Maintenance Bldg on corner or road into parking lot
P-94-4	East of Dressout Building, under delay fence
P-94-2	By Neutralization Basin, East of the RCA
CD-1	By Neutralization Basin, East of the RCA
PTPED-1	By Neutralization Basin, East of the RCA

Note: s, i and d refer to well depth: shallow - 20 ft., intermediate - 40 ft. and deep - 60 ft Maps depicting the well locations follow.



Onsite Tritium Monitoring Wells