



NUREG-1437
Supplement 54

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 54

Regarding Byron Station, Units 1 and 2

Draft Report for Comment

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>. Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and Title 10, "Energy," in the *Code of Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents
U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250
2. The National Technical Information Service
Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: U.S. Nuclear Regulatory Commission
Office of Administration
Publications Branch
Washington, DC 20555-0001

E-mail: DISTRIBUTION.RESOURCE@NRC.GOV
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

DISCLAIMER: This report was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product, or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 54

Regarding Byron Station, Units 1 and 2

Draft Report for Comment

Manuscript Completed: December 2014
Date Published: December 2014

1 **COVER SHEET**

2 **Responsible Agency:** U.S. Nuclear Regulatory Commission, Office of Nuclear Reactor
3 Regulation. There are no cooperating agencies involved in the preparation of this document.

4 **Title:** *Generic Environmental Impact Statement for License Renewal of Nuclear Plants,*
5 *Supplement 54, Regarding Byron Station, Units 1 and 2, Draft Report for Comment*
6 (NUREG-1437). Byron Station, Units 1 and 2 (Byron), is located in Ogle County, Illinois.

7 For additional information or copies of this document contact:

8 Division of License Renewal
9 U.S. Nuclear Regulatory Commission
10 Office of Nuclear Reactor Regulation
11 Mail Stop O-11F1
12 11555 Rockville Pike
13 Rockville, Maryland 20852
14 Phone: 1-800-368-5642, extension 3306
15 Fax: (301) 415-2002
16 Email: lois.james@nrc.gov

17 **ABSTRACT**

18 This supplemental environmental impact statement (SEIS) has been prepared in response to an
19 application submitted by Exelon Generation Company, LLC (Exelon), to renew the operating
20 license for Byron Station, Units 1 and 2 (Byron), for an additional 20 years.

21 This SEIS includes the preliminary analysis that evaluates the environmental impacts of the
22 proposed action and alternatives to the proposed action. Alternatives considered include: new
23 nuclear generation, coal-integrated gasification combined cycle (IGCC), natural gas
24 combined-cycle (NGCC), combination (NGCC, wind, and solar generation), replacement power,
25 and no renewal of the license (the no-action alternative).

26 The U.S. Nuclear Regulatory Commission (NRC) staff's preliminary recommendation is that the
27 adverse environmental impacts of license renewal for Byron are not so great that preserving the
28 option of license renewal for energy-planning decisionmakers would be unreasonable. This
29 recommendation is based on the following:

- 30 • the analysis and findings in NUREG-1437, Volumes 1 and 2, *Generic*
31 *Environmental Impact Statement for License Renewal of Nuclear Plants*;
- 32 • the Environmental Report submitted by Exelon;
- 33 • consultation with Federal, state, local, and tribal government agencies;
- 34 • the NRC's environmental review; and
- 35 • consideration of public comments received during the scoping process.

TABLE OF CONTENTS

1		
2	ABSTRACT	iii
3	TABLE OF CONTENTS	v
4	FIGURES	xv
5	TABLES	xvii
6	EXECUTIVE SUMMARY	xxi
7	ABBREVIATIONS AND ACRONYMS	xxvii
8	1.0 INTRODUCTION	1-1
9	1.1 Proposed Federal Action.....	1-1
10	1.2 Purpose and Need for Proposed Federal Action	1-1
11	1.3 Major Environmental Review Milestones.....	1-1
12	1.4 Generic Environmental Impact Statement.....	1-3
13	1.5 Supplemental Environmental Impact Statement.....	1-5
14	1.6 Decisions to be Supported by the SEIS	1-6
15	1.7 Cooperating Agencies.....	1-6
16	1.8 Consultations	1-6
17	1.9 Correspondence	1-7
18	1.10 Status of Compliance.....	1-7
19	1.11 Related State and Federal Activities	1-7
20	1.12 References	1-8
21	2.0 ALTERNATIVES INCLUDING THE PROPOSED ACTION	2-1
22	2.1 Proposed Action	2-1
23	2.1.1 Plant Operations During the License Renewal Term	2-1
24	2.1.2 Refurbishment and Other Activities Associated With License Renewal ..	2-2
25	2.1.3 Termination of Nuclear Power Plant Operations and Decommissioning	
26	After the License Renewal Term	2-3
27	2.2 Alternatives	2-3
28	2.2.1 No-Action Alternative.....	2-3
29	2.2.2 Replacement Power Alternatives.....	2-4
30	2.2.2.1 New Nuclear Alternative	2-11
31	2.2.2.2 IGCC Alternative.....	2-12
32	2.2.2.3 NGCC Alternative	2-14
33	2.2.2.4 Combination Alternative (NGCC, Wind, Solar).....	2-15
34	2.2.2.5 Purchased Power Alternative	2-18
35	2.3 Alternatives Considered but Dismissed.....	2-18
36	2.3.1 Energy Conservation and Energy Efficiency.....	2-18
37	2.3.2 Solar	2-19

Table of Contents

1	2.3.3	Wind.....	2-19
2		2.3.3.1 Offshore Wind.....	2-20
3		2.3.3.2 Wind Power with Storage.....	2-20
4		2.3.3.3 Conclusion.....	2-21
5	2.3.4	Biomass.....	2-21
6	2.3.5	Hydroelectric.....	2-22
7	2.3.6	Wave and Ocean Energy.....	2-22
8	2.3.7	Fuel Cells.....	2-22
9	2.3.8	Delayed Retirement.....	2-23
10	2.3.9	Geothermal.....	2-23
11	2.3.10	Municipal Solid Waste.....	2-24
12	2.3.11	Petroleum.....	2-24
13	2.3.12	SCPC.....	2-25
14	2.4	Comparison of Alternatives.....	2-25
15	2.5	References.....	2-28
16	3.0	AFFECTED ENVIRONMENT.....	3-1
17	3.1	Description of Nuclear Power Plant Facility and Operation.....	3-1
18	3.1.1	External Appearance and Setting.....	3-1
19	3.1.2	Nuclear Reactor Systems.....	3-5
20	3.1.3	Cooling and Auxiliary Water Systems.....	3-5
21		3.1.3.1 Circulating Water System.....	3-6
22		3.1.3.2 Nonessential Service Water System.....	3-8
23		3.1.3.3 Essential Service Water System.....	3-8
24		3.1.3.4 Cooling and Auxiliary Water Treatment.....	3-9
25	3.1.4	Radioactive Waste Management Systems.....	3-9
26		3.1.4.1 Radioactive Liquid Waste Management.....	3-10
27		3.1.4.2 Radioactive Gaseous Waste Management.....	3-11
28		3.1.4.3 Radioactive Solid Waste Management.....	3-13
29		3.1.4.4 Radioactive Waste Storage.....	3-13
30		3.1.4.5 Radiological Environmental Monitoring Program.....	3-13
31	3.1.5	Nonradioactive Waste Management Systems.....	3-14
32	3.1.6	Utility and Transportation Infrastructure.....	3-15
33		3.1.6.1 Electricity.....	3-15
34		3.1.6.2 Fuel.....	3-15
35		3.1.6.3 Water.....	3-15
36		3.1.6.4 Transportation Systems.....	3-15
37		3.1.6.5 Power Transmission Systems.....	3-15
38	3.1.7	Nuclear Power Plant Operations and Maintenance.....	3-16
39	3.2	Land Use and Visual Resources.....	3-16
40	3.2.1	Land Use.....	3-16
41	3.2.2	Visual Resources.....	3-18

Table of Contents

1	3.3	Meteorology, Air Quality, and Noise	3-18
2	3.3.1	Meteorology and Climatology	3-18
3	3.3.2	Air Quality	3-20
4	3.3.3	Noise.....	3-22
5	3.4	Geologic Environment.....	3-23
6	3.4.1	Physiography and Geology	3-23
7	3.4.2	Soils	3-24
8	3.4.3	Seismic Setting	3-25
9	3.5	Water Resources	3-25
10	3.5.1	Surface Water Resources	3-25
11	3.5.1.1	Surface Water Hydrology.....	3-25
12	3.5.1.2	Surface Water Use.....	3-28
13	3.5.1.3	Surface Water Quality and Effluents	3-29
14	3.5.2	Groundwater Resources	3-32
15	3.5.2.1	Site Description and Hydrogeology	3-32
16	3.5.2.2	Groundwater Use.....	3-36
17	3.5.2.3	Groundwater Quality	3-36
18	3.6	Terrestrial Resources.....	3-37
19	3.6.1	Byron Ecoregion.....	3-37
20	3.6.2	Byron Site and Vicinity	3-38
21	3.6.2.1	Summary of Past Byron Surveys and Reports	3-38
22	3.6.2.2	Vegetation	3-39
23	3.6.2.3	Wildlife	3-42
24	3.6.3	Transmission Line Corridors.....	3-46
25	3.6.4	WHC Wildlife at Work Program	3-46
26	3.7	Aquatic Resources.....	3-47
27	3.8	Special Status Species and Habitats.....	3-59
28	3.8.1	Species and Habitats Protected Under the Endangered Species Act ...	3-59
29	3.8.1.1	Action Area	3-59
30	3.8.1.2	Species and Habitats under the FWS’s Jurisdiction	3-60
31	3.8.1.3	Species and Habitats Under NMFS’s Jurisdiction	3-64
32	3.8.2	Species and Habitats Protected Under the Magnuson–Stevens Act.....	3-65
33	3.9	Historic and Cultural Resources.....	3-65
34	3.9.1	Cultural Background.....	3-65
35	3.9.2	Historic and Cultural Resources	3-67
36	3.10	Socioeconomics.....	3-68
37	3.10.1	Power Plant Employment and Expenditures.....	3-68
38	3.10.2	Regional Economic Characteristics	3-69
39	3.10.2.1	Employment and Income	3-69
40	3.10.2.2	Unemployment.....	3-72

Table of Contents

1	3.10.3	Demographic Characteristics	3-72
2	3.10.3.1	Transient Population	3-74
3	3.10.3.2	Migrant Farm Workers	3-76
4	3.10.4	Housing and Community Services.....	3-78
5	3.10.4.1	Housing	3-78
6	3.10.4.2	Education.....	3-79
7	3.10.4.3	Public Water Supply.....	3-79
8	3.10.5	Tax Revenues	3-80
9	3.10.6	Local Transportation.....	3-84
10	3.11	Human Health.....	3-85
11	3.11.1	Radiological Exposure and Risk.....	3-85
12	3.11.2	Chemical Hazards.....	3-87
13	3.11.3	Microbiological Hazards	3-87
14	3.11.4	Electromagnetic Fields	3-89
15	3.11.5	Other Hazards.....	3-90
16	3.12	Environmental Justice.....	3-90
17	3.12.1	Minority Population.....	3-91
18	3.12.2	Low-Income Population.....	3-93
19	3.13	Waste Management and Pollution Prevention.....	3-95
20	3.13.1	Radioactive Waste	3-95
21	3.13.2	Nonradioactive Waste	3-95
22	3.14	References	3-95
23	4.0	ENVIRONMENTAL CONSEQUENCES AND MITIGATING ACTIONS.....	4-1
24	4.1	Introduction.....	4-1
25	4.2	Land Use and Visual Resources	4-1
26	4.2.1	Proposed Action.....	4-1
27	4.2.2	No-Action Alternative.....	4-2
28	4.2.2.1	Land Use	4-2
29	4.2.2.2	Visual Resources.....	4-2
30	4.2.3	New Nuclear Alternative	4-2
31	4.2.3.1	Land Use	4-2
32	4.2.3.2	Visual Resources.....	4-3
33	4.2.4	Integrated Gasification Combined Cycle (IGCC) Alternative.....	4-3
34	4.2.4.1	Land Use	4-3
35	4.2.4.2	Visual Resources.....	4-3
36	4.2.5	Natural Gas Combined-Cycle (NGCC) Alternative	4-3
37	4.2.5.1	Land Use	4-3
38	4.2.5.2	Visual Resources.....	4-4
39	4.2.6	Combination Alternative (NGCC, Wind, Solar)	4-4
40	4.2.6.1	Land Use	4-4
41	4.2.6.2	Visual Resources.....	4-4

Table of Contents

1	4.2.7	Purchased Power.....	4-5
2		4.2.7.1 Land Use	4-5
3		4.2.7.2 Visual Resources.....	4-5
4	4.3	Air Quality and Noise	4-5
5	4.3.1	Proposed Action.....	4-5
6		4.3.1.1 Air Quality.....	4-5
7		4.3.1.2 Noise	4-6
8	4.3.2	No-Action Alternative.....	4-6
9		4.3.2.1 Air Quality.....	4-6
10		4.3.2.2 Noise	4-6
11	4.3.3	New Nuclear Alternative.....	4-7
12		4.3.3.1 Air Quality.....	4-7
13		4.3.3.2 Noise	4-8
14	4.3.4	IGCC Alternative	4-9
15		4.3.4.1 Air Quality.....	4-9
16		4.3.4.2 Noise	4-12
17	4.3.5	NGCC Alternative.....	4-13
18		4.3.5.1 Air Quality.....	4-13
19		4.3.5.2 Noise	4-15
20	4.3.6	Combination Alternative (NGCC, Wind, Solar)	4-15
21		4.3.6.1 Air Quality.....	4-16
22		4.3.6.2 Noise	4-17
23	4.3.7	Purchased Power.....	4-19
24		4.3.7.1 Air Quality.....	4-19
25		4.3.7.2 Noise	4-19
26	4.3.8	Conclusions	4-19
27	4.4	Geologic Environment.....	4-20
28	4.4.1	Proposed Action.....	4-21
29	4.4.2	No-Action Alternative.....	4-21
30	4.4.3	New Nuclear Alternative.....	4-21
31	4.4.4	IGCC Alternative	4-22
32	4.4.5	NGCC Alternative.....	4-22
33	4.4.6	Combination Alternative (NGCC, Wind, Solar)	4-22
34	4.4.7	Purchased Power.....	4-22
35	4.5	Water Resources	4-22
36	4.5.1	Proposed Action.....	4-22
37		4.5.1.1 Surface Water Resources.....	4-22
38		4.5.1.2 Groundwater Resources	4-24
39	4.5.2	No-Action Alternative.....	4-26
40		4.5.2.1 Surface Water Resources.....	4-26
41		4.5.2.2 Groundwater Resources	4-26

Table of Contents

1	4.5.3	New Nuclear Alternative	4-26
2	4.5.3.1	Surface Water Resources	4-26
3	4.5.3.2	Groundwater Resources	4-27
4	4.5.4	IGCC Alternative	4-27
5	4.5.4.1	Surface Water Resources	4-27
6	4.5.4.2	Groundwater Resources	4-28
7	4.5.5	NGCC Alternative.....	4-28
8	4.5.5.1	Surface Water Resources	4-28
9	4.5.5.2	Groundwater Resources	4-29
10	4.5.6	Combination Alternative (NGCC, Wind, Solar)	4-29
11	4.5.6.1	Surface Water Resources	4-29
12	4.5.6.2	Groundwater Resources	4-30
13	4.5.7	Purchased Power.....	4-30
14	4.5.7.1	Surface Water Resources	4-30
15	4.5.7.2	Groundwater Resources	4-30
16	4.6	Terrestrial Resources.....	4-30
17	4.6.1	Proposed Action.....	4-30
18	4.6.1.1	Generic Terrestrial Resource Issues.....	4-31
19	4.6.1.2	Effects on Terrestrial Resources (Noncooling System	
20		Impacts).....	4-31
21	4.6.1.3	Water Use Conflicts with Terrestrial Resources (Plants	
22		with Cooling Ponds or Cooling Towers Using Makeup	
23		Water from a River).....	4-32
24	4.6.2	No-Action Alternative.....	4-33
25	4.6.3	New Nuclear Alternative	4-33
26	4.6.4	IGCC Alternative	4-34
27	4.6.5	NGCC Alternative.....	4-35
28	4.6.6	Combination Alternative (NGCC, Wind, Solar)	4-35
29	4.6.7	Purchased Power.....	4-36
30	4.7	Aquatic Resources.....	4-36
31	4.7.1	Proposed Action.....	4-37
32	4.7.1.1	Generic GEIS Issues	4-37
33	4.7.1.2	Water Use Conflicts With Aquatic Resources.....	4-38
34	4.7.2	No-Action Alternative.....	4-38
35	4.7.3	New Nuclear Alternative	4-38
36	4.7.4	IGCC Alternative	4-39
37	4.7.5	NGCC Alternative.....	4-40
38	4.7.6	Combination Alternative (NGCC, Wind, Solar)	4-40
39	4.7.7	Purchased Power.....	4-40

1 4.8 Special Status Species and Habitats..... 4-41

2 4.8.1 Proposed Action..... 4-41

3 4.8.1.1 Species and Habitats Protected Under the Endangered

4 Species Act..... 4-41

5 4.8.1.2 Species and Habitats Protected Under the Magnuson–

6 Stevens Act 4-43

7 4.8.2 No-Action Alternative..... 4-43

8 4.8.3 New Nuclear Alternative 4-43

9 4.8.4 IGCC Alternative 4-44

10 4.8.5 NGCC Alternative..... 4-44

11 4.8.6 Combination Alternative (NGCC, Wind, Solar) 4-45

12 4.8.7 Purchased Power..... 4-45

13 4.9 Historic and Cultural Resources..... 4-45

14 4.9.1 Proposed Action..... 4-45

15 4.9.2 No-Action Alternative..... 4-48

16 4.9.3 New Nuclear Alternative 4-48

17 4.9.4 IGCC Alternative 4-48

18 4.9.5 NGCC Alternative..... 4-49

19 4.9.6 Combination Alternative (NGCC, Wind, Solar) 4-49

20 4.9.7 Purchased Power..... 4-50

21 4.10 Socioeconomics..... 4-50

22 4.10.1 Proposed Action..... 4-50

23 4.10.2 No-Action Alternative..... 4-51

24 4.10.2.1 Socioeconomics..... 4-51

25 4.10.2.2 Transportation..... 4-52

26 4.10.3 New Nuclear Alternative 4-52

27 4.10.3.1 Socioeconomics..... 4-52

28 4.10.3.2 Transportation..... 4-53

29 4.10.4 IGCC Alternative 4-53

30 4.10.4.1 Socioeconomics..... 4-53

31 4.10.4.2 Transportation..... 4-54

32 4.10.5 NGCC Alternative..... 4-55

33 4.10.5.1 Socioeconomics..... 4-55

34 4.10.5.2 Transportation..... 4-55

35 4.10.6 Combination Alternative (NGCC, Wind, Solar) 4-56

36 4.10.6.1 Socioeconomics..... 4-56

37 4.10.6.2 Transportation..... 4-57

38 4.10.7 Purchased Power..... 4-57

39 4.10.7.1 Socioeconomics..... 4-57

40 4.10.7.2 Transportation..... 4-57

Table of Contents

1	4.11 Human Health.....	4-58
2	4.11.1 Proposed Action.....	4-58
3	4.11.1.1 Normal Operating Conditions.....	4-58
4	4.11.1.2 Environmental Impacts of Postulated Accidents.....	4-62
5	4.11.2 No-Action Alternative.....	4-68
6	4.11.3 New Nuclear Alternative.....	4-69
7	4.11.4 IGCC Alternative.....	4-69
8	4.11.5 NGCC Alternative.....	4-70
9	4.11.6 Combination Alternative (NGCC, Wind, Solar).....	4-70
10	4.11.7 Purchased Power.....	4-70
11	4.12 Environmental Justice.....	4-71
12	4.12.1 Proposed Action.....	4-71
13	4.12.2 No-Action Alternative.....	4-73
14	4.12.3 New Nuclear Alternative.....	4-73
15	4.12.4 IGCC Alternative.....	4-74
16	4.12.5 NGCC Alternative.....	4-74
17	4.12.6 Combination Alternative (NGCC, Wind, Solar).....	4-75
18	4.12.7 Purchased Power.....	4-75
19	4.13 Waste Management and Pollution Prevention.....	4-75
20	4.13.1 Proposed Action.....	4-75
21	4.13.1.1 10 CFR 51.23 (Continued Storage Rule) and	
22	10 CFR 51, Subpart A, Table B-1 (License Renewal).....	4-76
23	4.13.1.2 CLI-14-08: Holding that Revised 10 CFR 51.23 and	
24	NUREG-2157 Satisfy NRC’s NEPA Obligations for	
25	Continued Storage and Directing Staff to Account for	
26	Environmental Impacts In NUREG-2157.....	4-79
27	4.13.1.3 At-Reactor Storage.....	4-79
28	4.13.1.4 Away-From-Reactor Storage.....	4-80
29	4.13.1.5 Cumulative Impacts.....	4-82
30	4.13.1.6 Conclusion.....	4-82
31	4.13.2 No-Action Alternative.....	4-82
32	4.13.3 New Nuclear Alternative.....	4-83
33	4.13.4 IGCC Alternative.....	4-83
34	4.13.5 NGCC Alternative.....	4-83
35	4.13.6 Combination Alternative (NGCC, Wind, Solar).....	4-84
36	4.13.7 Purchased Power.....	4-84
37	4.14 Evaluation of New and Potentially Significant Information.....	4-84
38	4.15 Impacts Common to All Alternatives.....	4-85
39	4.15.1 Fuel Cycle.....	4-85
40	4.15.1.1 Uranium Fuel Cycle.....	4-85
41	4.15.1.2 Replacement Power Plant Fuel Cycles.....	4-86

Table of Contents

1	4.15.2	Terminating Power Plant Operations and Decommissioning	4-87
2	4.15.2.1	Existing Nuclear Power Plant.....	4-87
3	4.15.2.2	Replacement Power Plants.....	4-88
4	4.15.3	Greenhouse Gas Emissions and Climate Change.....	4-89
5	4.15.3.1	Greenhouse Gas Emissions From the Proposed Project	
6		and Alternatives	4-89
7	4.15.3.2	Climate Change Impacts to Resource Areas	4-92
8	4.16	Cumulative Impacts of the Proposed Action.....	4-97
9	4.16.1	Air Quality and Noise.....	4-98
10	4.16.1.1	Air Quality	4-98
11	4.16.1.2	Noise	4-99
12	4.16.1.3	Conclusion	4-100
13	4.16.2	Geology and Soils	4-100
14	4.16.3	Water Resources	4-100
15	4.16.3.1	Surface Water Resources	4-100
16	4.16.3.2	Groundwater Resources	4-102
17	4.16.3.3	Conclusion	4-102
18	4.16.4	Terrestrial Resource.....	4-102
19	4.16.4.1	Historic Conditions	4-103
20	4.16.4.2	Urbanization	4-103
21	4.16.4.3	Agricultural Runoff	4-103
22	4.16.4.4	Park and Conservation Areas	4-103
23	4.16.4.5	Unit 2 Steam Generator Replacement	4-104
24	4.16.4.6	Conclusion	4-104
25	4.16.5	Aquatic Resources	4-104
26	4.16.5.1	Past River Development, Channelization, and Damming ...	4-105
27	4.16.5.2	Energy Development	4-105
28	4.16.5.3	Runoff from Agriculture and Municipal Facilities.....	4-106
29	4.16.5.4	Parks and Recreational Areas	4-106
30	4.16.5.5	Conclusion	4-106
31	4.16.6	Historic and Cultural Resources	4-106
32	4.16.7	Socioeconomics	4-107
33	4.16.7.1	Unit 2 Steam Generator Replacement	4-107
34	4.16.7.2	Units 1 and 2 Reactor Pressure Vessel Head	
35		Replacement.....	4-108
36	4.16.7.3	Conclusion	4-108
37	4.16.8	Human Health	4-108
38	4.16.9	Environmental Justice	4-109
39	4.16.9.1	Unit 2 Steam Generator Replacement	4-110
40	4.16.9.2	Units 1 and 2 Reactor Pressure Vessel Head	
41		Replacement.....	4-110
42	4.16.9.3	Conclusion	4-110

Table of Contents

1	4.16.10 Waste Management and Pollution Prevention.....	4-110
2	4.16.11 Global Climate Change	4-111
3	4.16.12 Summary of Cumulative Impacts.....	4-113
4	4.17 Resource Commitments Associated With the Proposed Action.....	4-115
5	4.17.1 Unavoidable Adverse Environmental Impacts	4-115
6	4.17.2 Relationship Between Short-Term Use of the Environment and	
7	Long-Term Productivity	4-116
8	4.17.3 Irreversible and Irrecoverable Commitment of Resources	4-117
9	4.18 References	4-117
10	5.0 CONCLUSION.....	5-1
11	5.1 Environmental Impacts of License Renewal.....	5-1
12	5.2 Comparison of Alternatives	5-1
13	5.3 Recommendations	5-2
14	6.0 LIST OF PREPARERS	6-1
15	7.0 LIST OF AGENCIES, ORGANIZATIONS, AND PERSONS TO WHOM COPIES	
16	OF THIS SEIS ARE SENT.....	7-1
17	8.0 INDEX.....	8-1
18	APPENDIX A. COMMENTS RECEIVED ON THE BYRON STATION	
19	ENVIRONMENTAL REVIEW.....	A-1
20	APPENDIX B. APPLICABLE LAWS, REGULATIONS, AND OTHER	
21	REQUIREMENTS	B-1
22	APPENDIX C. CONSULTATION CORRESPONDENCE	C-1
23	APPENDIX D. CHRONOLOGY OF ENVIRONMENTAL REVIEW	
24	CORRESPONDENCE	D-1
25	APPENDIX E. PROJECTS CONSIDERED IN THE CUMULATIVE IMPACTS	
26	ANALYSIS.....	E-1
27	APPENDIX F. U.S. NUCLEAR REGULATORY COMMISSION STAFF EVALUATION	
28	OF SEVERE ACCIDENT MITIGATION ALTERNATIVES FOR BYRON	
29	STATION, UNITS 1 AND 2, IN SUPPORT OF LICENSE RENEWAL	
30	APPLICATION REVIEW.....	F-1

FIGURES

2	Figure 1–1.	Environmental Review Process.....	1-2
3	Figure 1–2.	Environmental Issues Evaluated for License Renewal	1-5
4	Figure 2–1.	Territories of MISO and PJM Interconnection.....	2-6
5	Figure 3–1.	Byron 50-Mile Radius Map.....	3-2
6	Figure 3–2.	Byron 6-Mile Radius Map.....	3-3
7	Figure 3–3.	Byron Site Boundary	3-4
8	Figure 3–4.	Closed-Cycle Cooling System with Natural Draft Cooling Tower.....	3-6
9	Figure 3–5.	Byron Cooling Water Intake and Discharge Pipelines	3-7
10	Figure 3–6.	Site Topography	3-24
11	Figure 3–7.	Rock River Basin in Illinois and Wisconsin.....	3-26
12	Figure 3–8.	The Rock River and USGS Stream Gaging Stations in the Vicinity of	
13		Byron	3-27
14	Figure 3–9.	NPDES Discharge Locations	3-31
15	Figure 3–10.	Generalized Hydrogeologic Column of Byron.....	3-33
16	Figure 3–11.	Generalized East – West Hydrogeologic Cross Section	3-35
17	Figure 3–12.	Rock River Aquatic Survey Sampling Locations.....	3-49
18	Figure 3–13.	Minority Block Groups Within a 50-mi Radius of Byron	3-92
19	Figure 3–14.	Low-Income Block Groups Within a 50-mi (80-km) Radius of Byron	3-94

TABLES

1			
2	Table ES-1.	Summary of NRC Conclusions Relating to Site-Specific Impacts of License Renewal.....	xxiii
3			
4	Table 2-1.	Summary of Replacement Power Alternatives and Key Characteristics Considered in Depth	2-9
5			
6	Table 2-2.	Summary of Environmental Impacts of Proposed Action and Alternatives	2-26
7			
8	Table 3-1.	Air Emission Estimates for Permitted Combustion Sources at Byron	3-21
9	Table 3-2.	Common Noise Sources and Noise Levels	3-22
10	Table 3-3.	Annual Surface Water Withdrawals and Return Discharges to the Rock River, Byron	3-28
11			
12	Table 3-4.	National Pollutant Discharge Elimination System-Permitted Outfalls, Byron	3-30
13			
14	Table 3-5.	State-Listed Plant Species in Ogle County.....	3-41
15	Table 3-6.	Most Common or Abundant Wildlife on the Byron Site.....	3-43
16	Table 3-7.	State-Listed Bird Species in Ogle County	3-44
17	Table 3-8.	State-Listed Mammal Species in Illinois.....	3-45
18	Table 3-9.	State-Listed Reptile and Amphibian Species in Ogle County	3-46
19	Table 3-10.	Sampling Locations for Preoperational and Operational Aquatic Monitoring and Surveys of the Rock River	3-48
20			
21	Table 3-11.	Fish Species Collected in the Vicinity of Byron During EAI Baseline Monitoring, 1973-1974	3-54
22			
23	Table 3-12.	Fish Species Collected Downstream of Byron During INHS Study, 1986-1987	3-56
24			
25	Table 3-13.	Fish Species Collected in the Vicinity of Byron During EA Engineering Survey, 2011.....	3-58
26			
27	Table 3-14.	Federally Listed Species in Ogle County, Illinois.....	3-61
28	Table 3-15.	Cultural Resources Within the Byron Site	3-68
29	Table 3-16.	Exelon Generation Employees Residence by County	3-69
30	Table 3-17.	Employment by Industry in the Byron ROI (5-year estimates 2008-2012).....	3-70
31			
32	Table 3-18.	Major Employers in Ogle County in 2012	3-71
33	Table 3-19.	Estimated Income Information for the Byron ROI (5-year estimates 2008-2012).....	3-72
34			
35	Table 3-20.	Population and Percent Growth in Byron ROI Counties 1970-2010, 2012 (estimated), and Projected for 2020-2060	3-73
36			
37	Table 3-21.	Illinois Department of Commerce and Economic Opportunity (DCEO) Population Projections for 2000-2030.....	3-73
38			
39	Table 3-22.	Demographic Profile of the Population in the Byron ROI in 2010	3-74
40	Table 3-23.	2007-2011 Estimated Seasonal Housing in Counties Located Within 50 mi (80 km) of Byron.....	3-75
41			
42	Table 3-24.	Migrant Farm Workers and Temporary Farm Labor in Counties Located within 50 mi (80 km) of Byron	3-77
43			

Tables

1	Table 3–25.	Housing in the Byron ROI (2008–2012, 5-year estimate).....	3-78
2	Table 3–26.	Local Public Water Supply Systems (in million gallons per day (mgd)).....	3-79
3	Table 3–27.	PIAT Payments and Recipients, 2008 and 2010	3-80
4	Table 3–28.	Property Tax Payment Comparison, All Taxing Districts Combined	3-81
5	Table 3–29.	Property Tax Payment Comparison, All Taxing Districts Combined	3-82
6	Table 3–30.	2011 Property Tax Payment Comparison, Each Taxing District	
7		Individually	3-83
8	Table 3–31.	2012 Property Tax Payment Comparison, Each Taxing District	
9		Individually	3-84
10	Table 3–32.	Major Commuting Routes in the Vicinity of Byron: 2012 AADT	3-85
11	Table 4–1.	Land Use and Visual Resources Issues.....	4-2
12	Table 4–2.	Air Quality and Noise	4-6
13	Table 4–3.	Estimated Direct Air Emissions From Operation of the Byron Proposed	
14		Action and Alternatives (Tons/Year).....	4-20
15	Table 4–4.	Geology and Soils Issues.....	4-21
16	Table 4–5.	Surface Water Resources Issues	4-23
17	Table 4–6.	Groundwater Issues.....	4-25
18	Table 4–7.	Terrestrial Resource Issues	4-31
19	Table 4–8.	Aquatic Resource Issues	4-37
20	Table 4–9.	Special Status Species and Habitat Issues	4-41
21	Table 4–10.	Effect Determinations for Federally Listed Species	4-42
22	Table 4–11.	Historic and Cultural Resources.....	4-46
23	Table 4–12.	Socioeconomic NEPA Issues Affected by License Renewal	4-51
24	Table 4–13.	Human Health Issues.....	4-58
25	Table 4–14.	Issues Related to Postulated Accidents	4-62
26	Table 4–15.	Byron Core Damage Frequency for Internal Events	4-65
27	Table 4–16.	Breakdown of Population Dose and Offsite Economic Cost by	
28		Containment Release Mode.....	4-66
29	Table 4–17.	Environmental Justice.....	4-71
30	Table 4–18.	Waste Management Issues.....	4-76
31	Table 4–19.	Issues Related to the Uranium Fuel Cycle	4-86
32	Table 4–20.	Issues Related to Decommissioning	4-88
33	Table 4–21.	Estimated GHG Emissions From Operations at Byron Station	4-90
34	Table 4–22.	Direct Uncontrolled GHG Emissions From Operation of the Proposed	
35		Action and Alternatives	4-92
36	Table 4–23.	Comparison of GHG Emission Inventories.....	4-112
37	Table 4–24.	Summary of Cumulative Impacts on Resource Areas	4-114
38	Table 6–1.	List of Preparers	6-2
39	Table 7–1.	List of Agencies, Organizations, and Persons to Whom Copies of This	
40		SEIS Are Sent.....	7-1
41	Table A–1.	Individuals Providing Comments During the Scoping Comment Period.....	A-2
42	Table A–2.	Issue Categories.....	A-3

1	Table B-1.	Federal and State Requirements	B-3
2	Table B-2.	Licenses and Permits.....	B-8
3	Table C-1.	Section 7 Consultation Correspondence	C-3
4	Table C-2.	NHPA Correspondence.....	C-4
5	Table D-1.	Environmental Review Correspondence	D-2
6	Table E-1.	Projects and Actions Considered in the Cumulative Impacts Analysis.....	E-2
7	Table F-1.	Byron CDF for Internal Events	F-3
8	Table F-2.	Breakdown of Population Dose and Offsite Economic Cost by	
9		Containment Release Mode.....	F-4
10	Table F-3.	Summary of Major PRA Models and Corresponding CDF and LERF	
11		Results.....	F-6
12	Table F-4(a).	Major Byron Unit 1 Contributors to Fire CDF	F-12
13	Table F-4(b).	Major Byron Unit 2 Contributors to Fire CDF	F-13
14	Table F-5.	SAMA Cost/Benefit Screening Analysis for Byron Station.....	F-29

EXECUTIVE SUMMARY

1

2 BACKGROUND

3 By letter dated May 29, 2013, Exelon Generation Company, LLC (Exelon), submitted an
4 application to the U.S. Nuclear Regulatory Commission (NRC) to issue renewed operating
5 licenses for Byron Station, Units 1 and 2 (Byron), for an additional 20-year period.

6 Pursuant to Title 10 of the *Code of Federal Regulations* 51.20(b)(2) (10 CFR 51.20(b)(2)), the
7 renewal of a power reactor operating license requires preparation of an environmental impact
8 statement (EIS) or a supplement to an existing EIS. In addition, 10 CFR 51.95(c) states that, in
9 connection with the renewal of an operating license, the NRC shall prepare an EIS, which is a
10 supplement to the Commission's NUREG-1437, *Generic Environmental Impact Statement*
11 *(GEIS) for License Renewal of Nuclear Plants*.

12 Upon acceptance of Exelon's application, the NRC staff began the environmental review
13 process described in 10 CFR Part 51 by publishing a Notice of Intent to prepare a supplemental
14 environmental impact statement (SEIS) and conduct scoping. In preparation of this SEIS for
15 Byron, the NRC staff performed the following:

- 16 • conducted public scoping meetings on August 20, 2013, in Byron, Illinois;
- 17 • conducted a site audit at Byron from September 16 to 19, 2013;
- 18 • reviewed Exelon's Environmental Report (ER) and compared it to the GEIS;
- 19 • consulted with Federal, state, and local agencies;
- 20 • conducted a review of the issues following the guidance set forth in
21 NUREG-1555, *Standard Review Plans for Environmental Reviews for*
22 *Nuclear Power Plants, Supplement 1, Revision 1: Operating License*
23 *Renewal*; and
- 24 • considered public comments received during the scoping process.

25 PROPOSED ACTION

26 Exelon initiated the proposed Federal action—issuance of a renewed power reactor operating
27 licenses—by submitting an application for license renewal of Byron, for which the existing
28 licenses (NPF-37 and NPF-66) expire on October 31, 2024, and November 6, 2026,
29 respectively. The NRC's Federal action is to decide whether to renew the license for an
30 additional 20 years. In accordance with 10 CFR 2.109, if a licensee of a nuclear power plant
31 files an application to renew an operating license at least 5 years before the expiration date of
32 that license, the existing license will not be deemed to have expired until the safety and
33 environmental reviews are completed and the NRC has made a final decision to either deny the
34 application or issue a renewed license for the additional 20 years.

35 PURPOSE AND NEED FOR ACTION

36 The purpose and need for the proposed action (issuance of renewed licenses) is to provide an
37 option that allows for power generation capability beyond the term of the current nuclear power
38 plant operating license to meet future system generating needs. Such needs may be
39 determined by other energy-planning decisionmakers, such as states, operators, and, where
40 authorized, Federal agencies (other than NRC). This definition of purpose and need reflects the

Executive Summary

1 NRC's recognition that, unless there are findings in the safety review required by the Atomic
2 Energy Act or findings in the National Environmental Policy Act (NEPA) environmental analysis
3 that would lead the NRC to reject a license renewal application, the NRC does not have a role in
4 the energy-planning decisions as to whether a particular nuclear power plant should continue to
5 operate.

6 ENVIRONMENTAL IMPACTS OF LICENSE RENEWAL

7 The SEIS evaluates the potential environmental impacts of the proposed action. The
8 environmental impacts from the proposed action are designated as SMALL, MODERATE, or
9 LARGE. As set forth in the GEIS, Category 1 issues are those that meet all of the following
10 criteria:

- 11 • The environmental impacts associated with the issue
12 are determined to apply either to all plants or, for some
13 issues, to plants having a specific type of cooling
14 system or other specified plant or site characteristics.
- 15 • A single significance level (i.e., SMALL, MODERATE,
16 or LARGE) has been assigned to the impacts, except
17 for collective offsite radiological impacts from the fuel
18 cycle and from high-level waste and spent fuel
19 disposal.
- 20 • Mitigation of adverse impacts associated with the issue
21 is considered in the analysis, and it has been
22 determined that additional plant-specific mitigation
23 measures are likely not to be sufficiently beneficial to
24 warrant implementation.

SMALL: Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE: Environmental effects are sufficient to alter noticeably, but not to destabilize, important attributes of the resource.

LARGE: Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

25 For Category 1 issues, no additional site-specific analysis is required in this SEIS unless new
26 and significant information is identified. Chapter 4 of this SEIS presents the process for
27 identifying new and significant information. Site-specific issues (Category 2) are those that do
28 not meet one or more of the criteria for Category 1 issues; therefore, an additional site-specific
29 review for these nongeneric issues is required, and the results are documented in the SEIS.

30 Neither Exelon nor NRC identified information that is both new and significant related to
31 Category 1 issues that would call into question the conclusions in the GEIS. This conclusion is
32 supported by the NRC's review of the applicant's ER and other documentation relevant to the
33 applicant's activities, the public scoping process and substantive comments raised, and the
34 findings from the environmental site audit conducted by the NRC staff. The NRC staff,
35 therefore, relies upon the conclusions of the GEIS for all Category 1 issues applicable to Byron.

36 Table ES-1 summarizes the Category 2 issues relevant to Byron as well as the NRC staff's
37 findings related to those issues. If the NRC staff determined that there were no Category 2
38 issues applicable for a particular resource area, the findings of the GEIS, as documented in
39 Appendix B to Subpart A of 10 CFR Part 51, are incorporated for that resource area.

1
2**Table ES–1. Summary of NRC Conclusions Relating to Site-Specific Impacts of License Renewal**

Resource Area	Relevant Category 2 Issues	Impacts
Land Use	None	SMALL
Air Quality	None	SMALL
Geology and Soils	None	SMALL
Surface Water Resources	Surface water use conflicts (plants with cooling ponds or cooling towers using makeup water from a river)	SMALL
Groundwater Resources	Groundwater use conflicts (plants with closed-cycle cooling systems that withdraw makeup water from a river)	SMALL
	Radionuclides released to groundwater	SMALL
Terrestrial Resources	Effects on terrestrial resources (noncooling system impacts)	SMALL
	Water use conflicts with terrestrial resources (plants with cooling ponds or cooling towers using makeup water from a river)	SMALL
Aquatic Resources	Water use conflicts with aquatic resources	SMALL
Special Status Species	Threatened or endangered species	No effect ^(a)
Historic and Cultural	Historic and cultural resources	No adverse effect ^(b)
Socioeconomics	None	SMALL
Human Health	Microbiological hazards to the public health (plants with cooling ponds or canals or cooling towers that discharge to a river)	SMALL
	Electric shock hazards	SMALL
Environmental Justice	Minority and low-income populations	See note below ^(c)
Waste Management	None	SMALL
Cumulative Impacts	Air Quality and Noise	SMALL
	Geology and Soils	SMALL
	Water Resources	SMALL
	Terrestrial Ecology	SMALL-MODERATE
	Aquatic Resources	MODERATE
	Historic and Cultural Resources	SMALL
	Socioeconomic	SMALL
	Human Health	SMALL
	Environmental Justice	See note below ^(c)
	Waste Management	SMALL
Global Climate Change	MODERATE	

Executive Summary

Resource Area	Relevant Category 2 Issues	Impacts
		(a) For Federally protected species, the NRC reports the effects from continued operation of Byron during the license renewal period in terms of its Endangered Species Act (ESA) findings of “no effect,” “may effect, but not likely to adversely effect,” or “may affect, and is likely to adversely affect.”
		(b) The National Historic Preservation Act of 1966, as amended (NHPA) requires Federal agencies to consider the effects of their undertakings on historic properties.
		(c) There would be no disproportionately high and adverse impacts to minority and low-income populations and subsistence consumption from continued operation of Byron during the license renewal period and from cumulative impacts.

1 SEVERE ACCIDENT MITIGATION ALTERNATIVES

2 Since the staff had not previously considered severe accident mitigation alternatives (SAMA) in
3 an environmental impact statement or in an environmental assessment for Byron,
4 10 CFR 51.53(c)(3)(ii)(L) requires a consideration of alternatives to mitigate severe accidents in
5 the course of the license renewal review. SAMAs are potential ways to reduce the risk or
6 potential impacts of uncommon, but potentially severe accidents, and they may include changes
7 to plant components, systems, procedures, and training.

8 The NRC staff reviewed Exelon’s ER evaluation of potential SAMAs. Based on the staff’s
9 review, the NRC staff concluded that none of the potentially cost beneficial SAMAs relate to
10 adequately managing the effects of aging during the period of extended operation. Therefore,
11 they need not be implemented as part of the license renewal, pursuant to 10 CFR Part 54.

12 ALTERNATIVES

13 The NRC staff considered the environmental impacts associated with alternatives to license
14 renewal. These alternatives include other methods of power generation and not renewing the
15 Byron operating license (the no-action alternative). The feasible and commercially viable
16 replacement power alternatives considered were:

- 17 • new nuclear;
- 18 • integrated gasification combined cycle (IGCC);
- 19 • natural gas combined-cycle (NGCC);
- 20 • a combination of NGCC, wind, and solar power; and
- 21 • purchased power.

22 The NRC staff initially considered a number of additional alternatives for analysis as alternatives
23 to the license renewal of Byron; these were later dismissed because of technical, resource
24 availability, or commercial limitations that currently exist and that the NRC staff believes are
25 likely to continue to exist when the existing Byron licenses expire. The no-action alternative and
26 the effects it would have were also considered by the NRC staff.

27 Where possible, the NRC staff evaluated potential environmental impacts for these alternatives
28 located both at the Byron site and at some other unspecified alternate location. Alternatives
29 considered, but dismissed, were:

- 30 • energy conservation and energy efficiency;
- 31 • solar power;

- 1 • wind power;
- 2 • biomass power;
- 3 • hydroelectric power;
- 4 • wave and ocean energy;
- 5 • fuel cells;
- 6 • delayed retirement;
- 7 • geothermal power;
- 8 • municipal solid waste;
- 9 • petroleum; and
- 10 • supercritical pulverized coal.

11 The NRC staff evaluated each alternative using the same resource areas that were used in
12 evaluating impacts from license renewal.

13 **PRELIMINARY RECOMMENDATION**

14 The NRC staff's preliminary recommendation is that the adverse environmental impacts of
15 license renewal for Byron are not so great that preserving the option of license renewal for
16 energy-planning decisionmakers would be unreasonable. This recommendation is based on the
17 following:

- 18 • the analyses and findings in the GEIS;
- 19 • the ER submitted by Exelon;
- 20 • the NRC staff's consultation with Federal, state, and local agencies;
- 21 • the NRC staff's independent environmental review; and
- 22 • the NRC staff's consideration of public comments received during the scoping
23 process.

ABBREVIATIONS AND ACRONYMS

1		
2	µL/L	microliter(s) per liter
3	µm	micrometer(s)
4	AADT	average annual daily traffic
5	ac	acre(s)
6	AC	alternating current
7	ACC	averted cleanup and decontamination costs
8	ACHP	Advisory Council on Historic Preservation
9	ADAMS	Agencywide Documents Access and Management System
10	AEA	Atomic Energy Act of 1954 (as amended)
11	AEC	U.S. Atomic Energy Commission
12	AFW	auxiliary feedwater
13	ALARA	as low as is reasonably achievable
14	AMSAC	ATWS mitigating system actuation circuitry
15	ANL	Argonne National Laboratory
16	ANS	American Nuclear Society
17	AOC	averted offsite property damage costs
18	AOE	averted occupational exposure
19	AOSC	averted onsite costs
20	AP	auxiliary power
21	APE	averted public exposure
22		averted potential exposure
23	AQCR	Air Quality Control Region
24	ARERR	Annual Radiological Effluent Release Report
25	ASA	Acoustical Society of America
26	ASLB	Atomic Safety and Licensing Board (NRC)
27	ASME	American Society of Mechanical Engineers
28	ATWS	anticipated transient(s) without scram
29	AWEA	American Wind Energy Association
30	AWT	Association of Water Technologies
31	BACT	best available control technology
32	BEA	Bureau of Economic Analysis
33	BLH	BLH Technologies, Inc.
34	BLM	Bureau of Land Management

Abbreviations and Acronyms

1	BLS	Bureau of Labor Statistics
2	BMP	best management practice
3	BOEM	Bureau of Ocean Energy Management
4	BP	before present
5	BSER	best system of emission reduction
6	BTU/ft ³	British thermal unit(s) per cubic foot
7	Byron	Byron Station, Units 1 and 2
8	CAA	Clean Air Act
9	CAES	compressed air energy storage
10	CAIR	Clean Air Interstate Rule
11	Callaway Unit 2	Callaway Nuclear Power Plant Unit 2
12	CB&I	Chicago Bridge & Iron
13	CCS	carbon capture and storage
14	CCW	component cooling water
15	CDF	core damage frequency
16	CEQ	Council on Environmental Quality
17	C _{eq} /kWh	carbon equivalent per kilowatt-hour
18	CET	containment event tree
19	CFE	early containment failure
20	CFR	<i>Code of Federal Regulations</i>
21	cfs	cubic foot (feet) per second
22	CH ₄	methane
23	CISEH	Center for Invasive Species and Ecosystem Health
24	CLB	current licensing basis/bases
25	cm	centimeter(s)
26	CO	carbon monoxide
27	CO ₂	carbon dioxide
28	CO ₂ /MWh	carbon dioxide per megawatt hour
29	COL	combined license
30	ComEd	Commonwealth Edison
31	CPE	catch per effort
32	CRA	Conestoga-Rovers & Associates
33	CRMP	Cultural Resource Management Plant
34	CRMP	Cultural Resource Management Plant
35	CSAPR	Cross-State Air Pollution Rule

Abbreviations and Acronyms

1	CVCS	chemical and volume control system
2	CWA	Clean Water Act
3	DAW	dry active waste
4	dBA	decibels adjusted
5	DBA	design-basis accident
6	DCEO	Department of Commerce and Economic Opportunity
7	div.	Division
8	DLOOP	dual unit loss(es) of offsite power
9	DMS	Diverse Mitigation System
10	DNPS	Dresden Nuclear Power Station
11	DOE	Department of Energy
12	DSEIS	draft supplemental environmental impact statement
13	DSIRE	Database of State Incentives for Renewables & Efficiency
14	DSM	demand-side management
15	EA	environmental assessment
16	EAI	Environmental Analysts, Inc.
17	EAV	equalized assessed value
18	ECCS	emergency core cooling system
19	EcoCAT	Ecological Compliance Assessment Tool
20	EFH	essential fish habitat
21	EIA	Energy Information Administration
22	EIS	environmental impact statement
23	ELF	extremely low frequency
24	ELPC	Environmental Law and Policy Center
25	Eiv.	Elevation
26	EMF	electromagnetic field
27	EO	Executive Order
28	EPA	U.S. Environmental Protection Agency
29	EPRI	Electric Power Research Institute
30	EPZ	emergency planning zone
31	ER	Environmental Report
32	ERC	Energy Recovery Council
33	ER-O	Environmental Report for Byron operation
34	ES	Environmental Services
35	ESA	Endangered Species Act of 1973, as amended

Abbreviations and Acronyms

1	ESF	engineered safety feature
2	ESFAS	engineered safety features actuation system
3	ESI	Ecological Specialists, Inc.
4	ESP	early site permit
5	ESW	emergency service water
6	ET	Earth Tech, Inc.
7	Exelon	Exelon Generation Company, LLC
8	F&O	fact and observation
9	FD	fresh dead shell(s)
10	FERC	Federal Energy Regulatory Commission
11	Fermi Unit 3	Enrico Fermi Atomic Power Plant, Unit 3
12	FES	final environmental statement
13	FES-C	Final Environmental Statement for Byron construction
14	FES-O	Final Environmental Statement for Byron operation
15	FESOP	Federally Enforceable State Operating Permit
16	FHWA	Federal Highway Administration
17	FIVE	fire-induced vulnerability evaluation
18	FR	<i>Federal Register</i>
19	FRN	<i>Federal Register</i> notice
20	ft	foot (feet)
21	ft ²	square foot (feet)
22	ft ³	cubic foot (feet)
23	FW	feedwater
24	FWCA	Fish and Wildlife Coordination Act of 1934, as amended
25	FWS	U.S. Fish and Wildlife Service
26	g	gram(s)
27	gal	gallon(s)
28	GE	General Electric
29	GEIS	generic environmental impact statement
30	GHG	greenhouse gas
31	GI	generic issue
32	GL	generic letter
33	gpd	gallon(s) per day
34	gpm	gallon(s) per minute
35	Gt	gigatonne(s)

Abbreviations and Acronyms

1	GWPS	gaseous waste processing system
2	H ₂ O	water vapor
3	ha	hectare(s)
4	HAI	healthcare-associated infections
5	HAP	hazardous air pollutant
6	HCLPF	high confidence in low probability of failure
7	HEP	human error probability
8	HFE	human failure event
9	HFO	high winds, floods, and other
10	hr	hour(s)
11	HRA	human reliability analysis
12	HRSG	heat recovery steam generator
13	HUD	U.S. Department of Housing and Urban Development
14	HX	heat exchanger
15	IAC	Illinois Administrative Code
16	IBA	Important Bird Area
17	IDNR	Illinois Department of Natural Resources
18	IDOT	Illinois Department of Transportation
19	IDPH	Illinois Department of Public Health
20	IEA	International Energy Agency
21	IEMA	Illinois Emergency Management Agency
22	IEPA	Illinois Environmental Protection Agency
23	IESPB	Illinois Endangered Species Protection Board
24	IGCC	integrated gasification combined cycle
25	IHPA	Illinois Historic Preservation Agency
26	ILCS	Illinois Compiled Statutes
27	ILGA	Illinois General Assembly
28	in.	inch(es)
29	INEEL	Idaho National Engineering and Environmental Laboratory
30	INHS	Illinois Natural History Survey
31	Invenergy	Invenergy, LLC
32	IPCC	Intergovernmental Panel on Climate Change
33	IPE	individual plant examination
34	IPEEE	individual plant examination(s) of external events
35	ISBE	Illinois State Board of Education

Abbreviations and Acronyms

1	ISD	Integrated Surface Data
2	ISFSI	independent spent fuel storage installation
3	ISGS	Illinois State Geological Survey
4	ISLOCA	interfacing-systems loss-of-coolant accident
5	ISM	Illinois State Museum
6	JHEP	joint human error probability
7	km	kilometer(s)
8	km ²	square kilometer(s)
9	kW	kilowatt(s)
10	kWe	kilowatt(s) electric
11	L	liter(s)
12	L	live individual(s)
13	L/min	liter(s) per minute
14	L/s	liter(s) per second
15	lb	pound(s)
16	L _{dn}	day-night average sound level—the 24-hour A-weighted
17		equivalent sound level, with a 10-decibel penalty applied to
18		nighttime levels
19	L _{eq}	equivalent continuous noise level
20	LER	large, early release
21	LERF	large early release frequency
22	LIDAR	Light Detection and Ranging
23	LLW	low-level radioactive waste
24	LMFW	loss of main feedwater
25	LOCA	loss-of-coolant accident
26	LOOP	loss(es) of offsite power
27	Lpd	liters per day
28	LRA	license renewal application
29	m/s	meter(s) per second
30	m ²	square meter(s)
31	m ³	cubic meter(s)
32	m ³ /s	cubic meter(s) per second
33	MAAP	Modular Accident Analysis Program
34	MACCS2	MELCOR Accident Consequence Code System 2
35	MACR	maximum averted cost-risk

Abbreviations and Acronyms

1	MAE Center	Mid-America Earthquake Center
2	MATS	Mercury and Air Toxics Standards
3	MBTA	Migratory Bird Treaty Act
4	MCR	main control room
5	MDNR	Minnesota Department of Natural Resources
6	MELCOR	Methods for Estimation of Leakages and Consequences of Releases
7		
8	mg/L	milligram(s) per liter
9	mgd	million gallons per day
10	mg/y	million gallons per year
11	mGy	milligray
12	mi	mile(s)
13	mi ²	square mile(s)
14	MISO	Midcontinent Independent System Operator, Inc.
15	MMPA	Marine Mammal Protection Act
16	MMSHT	Michigan Mine Safety & Health Training
17	MMT	million metric tons
18	MODNR	Missouri Department of Natural Resources
19	MOV	motor-operated valve
20	mph	mile(s) per hour
21	mrad	millirad
22	mrem	millirem
23	MSA	Magnuson–Stevens Fishery Conservation and Management Act,
24		as amended through 2006
25	mSv	millisievert
26	MT	metric ton(s)
27	MUR	measurement uncertainty recapture
28	MW	megawatt(s)
29	MWe	megawatt(s) electric
30	MWh	megawatt hour(s)
31	MWt	megawatt(s) thermal
32	N ₂ O	nitrous oxide
33	NAAQS	National Ambient Air Quality Standards
34	NAH	North American Hydro
35	NARUC	National Association of Regulatory Utility Commissioners

Abbreviations and Acronyms

1	NASS	National Agricultural Statistics Service
2	NCDC	National Climatic Data Center
3	NCES	National Center for Education Statistics
4	NEA	Nuclear Energy Agency
5	NEI	Nuclear Energy Institute
6	NEIS	National Energy Information Service
7	NEPA	National Environmental Policy Act
8	NESC®	National Electrical Safety Code®
9	NETL	National Energy Technology Laboratory
10	NGCC	natural gas combined-cycle
11	NHL	National historic landmark
12	NHPA	National Historic Preservation Act of 1966, as amended
13	NIEHS	National Institute of Environmental Health Sciences
14	NMFS	National Marine Fisheries Service (of NOAA)
15	NO ₂	nitrogen dioxide
16	NO _x	nitrogen oxide(s)
17	NP	National park
18	NPDES	National Pollutant Discharge Elimination System
19	NPL	National Priorities List
20	NPS	National Park Service
21	NRC	U.S. Nuclear Regulatory Commission
22	NREL	National Renewable Energy Laboratory
23	NRHP	National Register of Historic Places
24	NRR	Nuclear Reactor Regulation, Office of (NRC)
25	NSR	New Source Review
26	NUREG	NRC technical report designation
27	NWCC	National Wind Coordinating Committee
28	O ₃	ozone
29	OCPZD	Ogle County Planning & Zoning Department
30	ODCM	Offsite Dose Calculation Manual
31	OECD	Organisation for Economic Co-operation and Development
32	OECR	offsite economic cost risk
33	ORNL	Oak Ridge National Laboratory
34	OSH	Occupational Safety and Health
35	OSHA	Occupational Safety & Health Administration

Abbreviations and Acronyms

1	PAM	primary amoebic meningoencephalitis
2	Pb	lead
3	PCB	polychlorinated biphenyl
4	pCi/L	picocurie(s) per liter
5	PDR	population dose risk
6	PDS	plant damage state
7	PEIS	programmatic environmental impact statement
8	PFC	perfluorocarbon
9	PIAT	payment in addition to taxes
10	PIMW	potentially infectious medical waste
11	PIN	Property Index Number
12	PJM	PJM Interconnection, LLC
13	PL	public law
14	PLS-CADD™	Power Line Systems—Computer Aided Design and Drafting
15	PM	particulate matter
16	PM ₁₀	particulate matter with aerodynamic diameters of 10 micrometers
17		or less
18	PM _{2.5}	particulate matter with aerodynamic diameters of 2.5 micrometers
19		or less
20	PNNL	Pacific Northwest National Laboratory
21	PONAR	sampling device used to study composition of lake bottom or river
22		bottom, named after Great Lakes scientists Powers, Ogle, Noble,
23		Ayers, and Robertson
24	PORV	power-operated relief valve
25	PPA	Pollution Prevention Act of 1990
26	ppm	parts per million
27	PRA	probabilistic risk assessment
28	PSD	prevention of significant deterioration
29	PTE	potential to emit
30	PV	photovoltaic
31	PWR	pressurized-water reactor
32	RAI	request(s) for additional information
33	RCP	reactor coolant pump
34	RCRA	Resource Conservation and Recovery Act
35	RDS	Research and Development Solutions, LLC
36	rem	roentgen equivalent(s) man

Abbreviations and Acronyms

1	REMP	radiological environmental monitoring program
2	RES	Office of Nuclear Regulatory Research
3	RHR	residual heat removal
4		Regional Haze Rule
5	RM	river mile
6	ROI	region(s) of influence
7	ROW	right-of-way
8	RPC	replacement power cost
9	RPS	reactor protection system
10	RPV	reactor pressure vessel
11	RRW	risk reduction worth
12	RTO	Regional Transmission Organization
13	RWST	refueling water storage tank
14	SAFSTOR	safe storage, also called deferred dismantling; a decommissioning
15		strategy in which the nuclear facility is maintained and monitored
16		in a condition that allows the radioactivity to decay before
17		dismantling the plant and decontaminating the property
18	SAMA	severe accident mitigation alternative
19	SAR	safety analysis report
20	SAT	system auxiliary transformer
21	SBO	station blackout
22	SCR	selective catalytic reduction
23	SCPC	supercritical pulverized coal
24	SDCI	State Data Center of Iowa
25	SDWIS	Safe Drinking Water Information System
26	SEIS	supplemental environmental impact statement
27	SER	safety evaluation report
28	SF ₆	sulfur hexafluoride
29	SFU	Simon Fraser University
30	SG	steam generator
31	SGTR	steam generator tube rupture
32	SI	safety injection
33	SIP	State Implementation Plan
34	SMA	seismic margin assessment
35	SO ₂	sulfur dioxide
36	SO _x	sulfur oxide(s)

Abbreviations and Acronyms

1	spp.	species (plural)
2	SR	supporting requirement
3	SRM	staff requirements memorandum (memoranda)
4	SSC	structure, system, and component
5	SSEL	Safe Shutdown Equipment List
6	Sv	sievert(s)
7	SW	service water
8	SX	essential service water
9	t	U.S. short ton(s)
10	TAC	technical assignment control
11	TEEIC	Tribal Energy and Environmental Information Clearinghouse
12	Teledyne	Teledyne Brown Engineering Environmental Services
13	Tg	teragram(s)
14	TS	technical specification
15	U.S.	United States
16	U.S.C.	United States Code
17	UAT	unit auxiliary transformer
18	UFSAR	updated final safety analysis report
19	USACE	United States Army Corps of Engineers
20	USCB	U.S. Census Bureau
21	USDA	U.S. Department of Agriculture
22	USDHHS	U.S. Department of Health and Human Services
23	USFS	U.S. Forest Service
24	USGCRP	U.S. Global Change Research Program
25	USGS	U.S. Geological Survey
26	Vogtle Units 3 and 4	Vogtle Electric Generating Plant, Units 3 and 4
27	yd	yard(s)
28	yd ³	cubic yard(s)
29	W/m ²	watt(s) per square meter
30	WAPA	Western Area Power Administration
31	WAW	wet active waste
32	WCAP	Westinghouse Commercial Atomic Power
33	WDOA	Wisconsin Department of Administration
34	WHC	Wildlife Habitat Council
35	WSA	wet gas sulfuric acid

Abbreviations and Acronyms

1	yd	yard(s)
2	yd ³	cubic yard(s)
3	yr	year

1.0 INTRODUCTION

Under the U.S. Nuclear Regulatory Commission's (NRC's) environmental protection regulations in Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR 51)—which implement the National Environmental Policy Act (NEPA)—issuance of a new nuclear power plant operating license requires the preparation of an environmental impact statement (EIS).

The Atomic Energy Act of 1954 (AEA) specified that licenses for commercial power reactors can be granted for up to 40 years. NRC regulations (10 CFR 54.31) allow for an option to renew a license for up to an additional 20 years. The initial 40-year licensing period was based on economic and antitrust considerations rather than on technical limitations of the nuclear facility.

The decision to seek a license renewal rests entirely with nuclear power facility owners and, typically, is based on the facility's economic viability and the investment necessary to continue to meet NRC safety and environmental requirements. The NRC makes the decision to grant or deny license renewal based on whether the applicant has demonstrated that the environmental and safety requirements in the agency's regulations can be met during the period of extended operation.

1.1 Proposed Federal Action

Exelon Generation Company, LLC (Exelon), initiated the proposed Federal action by submitting an application for license renewal of Byron Station, Units 1 and 2 (Byron), for which the existing licenses (NPF-37 and NPF-66) expire on October 31, 2024, and November 6, 2026. The NRC's Federal action is to decide whether to renew the license for an additional 20 years.

1.2 Purpose and Need for Proposed Federal Action

The purpose and need for the proposed action (issuance of a renewed license) is to provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license to meet future system generating needs, as such needs may be determined by other energy-planning decisionmakers. This definition of purpose and need reflects the NRC's recognition that, unless there are findings in the safety review required by the AEA or findings in the NEPA environmental analysis that would lead the NRC to reject a license renewal application (LRA), the NRC does not have a role in the energy-planning decisions of state regulators and utility officials as to whether a particular nuclear power plant should continue to operate.

1.3 Major Environmental Review Milestones

Exelon submitted an Environmental Report (ER) (Exelon 2013a) as part of its LRA (Exelon 2013b) in May 2013. After reviewing the LRA and ER for sufficiency, the NRC staff published a *Federal Register* Notice of Acceptability and Opportunity for Hearing (78 FR 44603) on July 24, 2013. Then, on August 6, 2013, the NRC published another notice in the *Federal Register* (78 FR 47800) on the intent to conduct scoping, thereby beginning the 60-day scoping period.

Two public scoping meetings were held on August 20, 2013, in Byron, Illinois (NRC 2013a). The comments received during the scoping process are presented in "Environmental Impact Statement, Scoping Process, Summary Report," published in May 2014 (NRC 2014). The scoping process summary report presents NRC responses to comments that the staff

Introduction


1 considered to be out of scope of the environmental license renewal review. The comments
2 considered to be within the scope of the environmental license renewal review and the NRC
3 responses are presented in Appendix A of this supplemental environmental impact statement
4 (SEIS).

5 To independently verify information provided in the ER, NRC staff conducted a site audit at
6 Byron in September 2013. During the site audit, NRC staff met with plant personnel, reviewed
7 specific documentation, toured the facility, and met with interested local agencies. A summary
8 of that site audit and the attendees is contained in "Summary of Site Audit in Support to the
9 Environmental Review of the License Renewal Application for Byron Station, Units 1 and 2,
10 (TAC Nos. MF1834 and MF1835)" published October 3, 2013 (NRC 2013c).

11 Upon completion of the scoping period and site audit, NRC staff compiled its findings in a draft
12 SEIS. This document is made available for public comment for 75 days. During this time, NRC
13 staff will host public meetings and collect public comments. Based on the information gathered,
14 the NRC staff will amend the draft SEIS findings, as necessary, and publish the final SEIS.
15 Figure 1–1 shows the major milestones of the NRC's LRA environmental review.

16

Figure 1–1. Environmental Review Process



17

18 The NRC has established a license renewal process that can be completed in a reasonable
19 period of time with clear requirements to ensure safe plant operation for up to an additional
20 20 years of plant life. The NRC staff conducts the safety review simultaneously with the
21 environmental review. The staff documents the findings of the safety review in a safety
22 evaluation report (SER). The findings in the SEIS and the SER are both factors in the NRC's
23 decision to either grant or deny the issuance of a renewed license.

1 1.4 Generic Environmental Impact Statement

2 The NRC staff performed a generic assessment of the environmental impacts associated with
 3 license renewal to improve the efficiency of its license renewal review. The *Generic*
 4 *Environmental Impact Statement for License Renewal of Nuclear Power Plants*, NUREG-1437
 5 (GEIS), (NRC 1996, 1999, 2013b), documented the results of the staff's systematic approach to
 6 evaluate the environmental consequences of renewing the licenses of individual nuclear power
 7 plants and operating them for an additional 20 years. The staff analyzed in detail and resolved
 8 those environmental issues that could be resolved generically in the GEIS. The GEIS was
 9 originally issued in 1996, Addendum 1 to the GEIS was issued in 1999, and Revision 1 to the
 10 GEIS was issued in 2013. Unless otherwise noted, all references to the GEIS include the GEIS,
 11 Addendum 1, and Revision 1.

12 The GEIS establishes separate environmental impact issues for the NRC staff to independently
 13 verify. Of these issues, the NRC staff determined that some generic issues are generic to all
 14 plants (Category 1). Other issues do not lend themselves to generic consideration (Category 2
 15 or uncategorized). The staff evaluated these issues on a site-specific basis in the SEIS.
 16 Appendix B to Subpart A of 10 CFR 51 provides a summary of the staff findings in the GEIS.

17 For each potential environmental issue, in the GEIS the NRC staff:

- 18 • describes the activity that affects the environment,
- 19 • identifies the population or resource that is affected,
- 20 • assesses the nature and magnitude of the impact on the affected population
 21 or resource,
- 22 • characterizes the significance of the effect for both beneficial and adverse
 23 effects,
- 24 • determines whether the results of the analysis apply to all plants, and
- 25 • considers whether additional mitigation measures would be warranted for
 26 impacts that would have the same significance level for all plants.

27 The NRC's standard of significance for impacts was established using the Council on
 28 Environmental Quality terminology for "significant." The NRC established three levels of
 29 significance for potential impacts—SMALL, MODERATE, and LARGE, as defined below.

30 **SMALL:** Environmental effects are not
 31 detectable or are so minor that they will neither
 32 destabilize nor noticeably alter any important
 33 attribute of the resource.

34 **MODERATE:** Environmental effects are
 35 sufficient to alter noticeably, but not to
 36 destabilize, important attributes of the resource.

37 **LARGE:** Environmental effects are clearly
 38 noticeable and are sufficient to destabilize important attributes of the resource.

Significance indicates the importance of likely environmental impacts and is determined by considering two variables: **context** and **intensity**.
Context is the geographic, biophysical, and social context in which the effects will occur.
Intensity refers to the severity of the impact, in whatever context it occurs.

Introduction

1 The GEIS includes a determination of whether the analysis of the environmental issue could be
2 applied to all plants and whether additional mitigation measures would be warranted. Issues
3 are assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1
4 issues are those that meet the following criteria:


- 5 • The environmental impacts associated with the issue have been determined
6 to apply either to all plants or, for some issues, to plants having a specific
7 type of cooling system or other specified plant or site characteristics.
- 8 • A single significance level (i.e., SMALL, MODERATE, or LARGE) has been
9 assigned to the impacts (except for collective offsite radiological impacts from
10 the fuel cycle and from high-level waste and spent fuel disposal).
- 11 • Mitigation of adverse impacts associated with the issue has been considered
12 in the analysis, and it has been determined that additional plant-specific
13 mitigation measures are likely not to be sufficiently beneficial to warrant
14 implementation.

15 For generic issues (Category 1), no additional site-specific analysis is required in the SEIS
16 unless new and significant information is identified. The process for identifying new and
17 significant information for site-specific analysis is presented in Chapter 4. Site-specific issues
18 (Category 2) are those that do not meet one or more of the criteria of Category 1 issues;
19 therefore, additional site-specific review for these issues is required. A site-specific analysis is
20 required for 17 of those 78 issues evaluated in the GEIS. Figure 1–2 illustrates this process.
21 The results of that site-specific review are documented in the SEIS.

1
2
3
4

Figure 1–2. Environmental Issues Evaluated for License Renewal

*In the GEIS, the NRC evaluated 78 issues.
A site-specific analysis is required for 17 of those 78 issues.*



5 1.5 Supplemental Environmental Impact Statement

6 The SEIS presents an analysis that considers the environmental effects of the continued
7 operation of Byron, alternatives to license renewal, and mitigation measures for minimizing
8 adverse environmental impacts. Chapter 4 contains analysis and comparison of the potential
9 environmental impacts from alternatives, while Chapter 5 presents the recommendation of the
10 NRC on whether the environmental impacts of license renewal are so great that preserving the
11 option of license renewal would be unreasonable. The final recommendation will be made after
12 consideration of comments received on the draft SEIS during the public comment period.

13 In the preparation of the SEIS for Byron, the NRC staff carried out the following activities:

- 14 • reviewed the information provided in Exelon’s ER;
- 15 • consulted with Federal agencies, state and local agencies, and tribal nations;

Introduction

- 1 • conducted an independent review of the issues during site audit; and
- 2 • considered the public comments received for the review (during the scoping
- 3 process).

4 New information can be identified from many
5 sources, including the applicant, the NRC, other
6 agencies, or public comments. If a new issue is
7 revealed, it is first analyzed to determine whether
8 it is within the scope of the license renewal
9 environmental evaluation. If the new issue is not addressed in the GEIS, the NRC staff would
10 determine the significance of the issue and document the analysis in the SEIS.

New and significant information - To merit additional review, information must be both “new” and “significant,” and it must bear on the proposed action or its impacts.

11 **1.6 Decisions to be Supported by the SEIS**

12 The decision to be supported by the SEIS is whether to renew the operating licenses for Byron
13 for an additional 20 years. The NRC decision standard is specified in 10 CFR 51.103(a)(5):

14 In making a final decision on a license renewal action pursuant to Part 54 of this
15 chapter, the Commission shall determine whether or not the adverse
16 environmental impacts of license renewal are so great that preserving the option
17 of license renewal for energy planning decisionmakers would be unreasonable.

18 There are many factors that the NRC takes into consideration when deciding whether to renew
19 the operating license of a nuclear power plant. The analyses of environmental impacts
20 evaluated in this GEIS will provide the NRC’s decisionmaker (in this case, the Commission) with
21 important environmental information for use in the overall decisionmaking process. There are
22 also decisions outside the regulatory scope of license renewal that cannot be made on the basis
23 of the GEIS analysis. These decisions include the following issues: changes to plant cooling
24 systems, disposition of spent nuclear fuel, emergency preparedness, safeguards and security,
25 need for power, and seismicity and flooding (NRC 2013b).

26 **1.7 Cooperating Agencies**

27 During the scoping process, no Federal, state, or local agencies were identified as cooperating
28 agencies in the preparation of this SEIS.

29 **1.8 Consultations**

30 The Endangered Species Act of 1973, as amended; the Magnuson–Stevens Fisheries
31 Conservation and Management Act of 1996, as amended (MSA); and the National Historic
32 Preservation Act of 1966, as amended (NHPA), require that Federal agencies consult with
33 applicable state and Federal agencies and groups before taking action that may affect
34 endangered species, fisheries, or historic and archaeological resources, respectively. The NRC
35 consulted with the following agencies and groups; Appendix D provides a discussion of the
36 consultation documents:

- 37 • U.S. Fish and Wildlife Service (FWS);
- 38 • Illinois Historic Preservation Agency;
- 39 • Advisory Council on Historic Preservation;
- 40 • Ho-Chunk Nation;
- 41 • Miami Tribe of Oklahoma;

- 1 • Peoria Tribe of Indians of Oklahoma;
- 2 • Citizen Potawatomi Nation;
- 3 • Sac and Fox Tribe of the Mississippi in Iowa/Meswaki Nation;
- 4 • Sac and Fox Nation of Missouri in Kansas and Nebraska;
- 5 • Sac and Fox Nation;
- 6 • Pokagon Band of Potawatomi;
- 7 • Forest County Potawatomi;
- 8 • Hannahville Indian Community, Band of Potawatomi;
- 9 • Prairie Band Potawatomi Nation;
- 10 • Winnebago Tribe of Nebraska;
- 11 • Kickapoo Tribe in Kansas; and
- 12 • Kickapoo Tribe of Oklahoma.

13 **1.9 Correspondence**

14 During the course of the environmental review, the NRC staff contacted Federal, state, regional,
15 local, and tribal agencies listed in Section 1.8. Appendices C and D contain a chronological list
16 of all documents sent and received during the environmental review. Appendix D lists the
17 correspondence associated with Endangered Species Act of 1973, as amended; the MSA; and
18 the NHPA. Appendix C lists all other correspondence.

19 **1.10 Status of Compliance**

20 Exelon is responsible for complying with all NRC regulations and other applicable Federal,
21 state, and local requirements. Appendix F of the GEIS describes some of the major applicable
22 Federal statutes. There are numerous permits and licenses issued by Federal, state, and local
23 authorities for activities at Byron. Appendix B contains further information about Byron status of
24 compliance.

25 **1.11 Related State and Federal Activities**

26 The NRC reviewed the possibility that activities of other Federal agencies might impact the
27 renewal of the operating license for Byron. There are no Federal projects that would make it
28 necessary for another Federal agency to become a cooperating agency in the preparation of
29 this SEIS.

30 There are no known American Indian lands within 50 mi (80 km) of Byron. There are
31 two Federally owned facilities within 50 mi of Byron: (1) Fermi National Accelerator Laboratory
32 and (2) Upper Mississippi River Wildlife and Fish Refuge.

33 The NRC is required under Section 102(2)(C) of NEPA to consult with and obtain the comments
34 from any Federal agency that has jurisdiction by law or special expertise with respect to any
35 environmental impact involved in the subject matter of the EIS. For example, during the course
36 of preparing the SEIS, the NRC consulted with the FWS. A complete list of consultation
37 correspondences is listed in Appendix D.

1 **1.12 References**

- 2 10 CFR 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental protection
3 regulations for domestic licensing and related regulatory functions.”
- 4 10 CFR 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for renewal
5 of operating licenses for nuclear power plants.”
- 6 78 FR 44603. U.S. Nuclear Regulatory Commission. “Byron Nuclear Station, Units 1 and 2, and
7 Braidwood Nuclear Station, Units 1 and 2; Exelon Generation Company, LLC.” *Federal*
8 *Register* 78(142):44603-44606. July 24, 2013.
- 9 78 FR 47800. U.S. Nuclear Regulatory Commission. “License Renewal Application for Byron
10 Station, Units 1 and 2; Exelon Generation Company, LLC.” *Federal*
11 *Register* 78(151):47800-47802. August 6, 2013.
- 12 [AEA] Atomic Energy Act of 1954, as amended. 42 U.S.C. § 2011 et seq.
- 13 Endangered Species Act of 1973, as amended. 16 U.S.C. § 1531 et seq.
- 14 [Exelon] Exelon Generation Company, LLC. 2013a. “Applicant’s Environmental Report—
15 Operating License Renewal Stage, Byron Station.” May 31, 2013. 707 p. Agencywide
16 Documents Access and Management System (ADAMS) No. ML14022A048.
- 17 [Exelon] Exelon Generation Company, LLC. 2013b. “License Renewal Application, Byron and
18 Braidwood Stations, Units 1 and 2.” June 3, 2013. 3,749 p. ADAMS No. ML131620554.
- 19 [MSA] Magnuson–Stevens Fishery Conservation and Management Act, as amended.
20 16 U.S.C. § 1801 et seq.
- 21 [NEPA] National Environmental Policy Act of 1969, as amended. 42 U.S.C. § 4321 et seq.
- 22 [NHPA] National Historic Preservation Act of 1966, as amended. 16 U.S.C. § 470 et seq.
- 23 [NRC] U.S. Nuclear Regulatory Commission. 1996. *Generic Environmental Impact Statement*
24 *for License Renewal of Nuclear Plants, Final Report*. Washington, DC: NRC. NUREG–1437,
25 Volumes 1 and 2. May 31, 1996. 1,204 p. ADAMS Nos. ML040690705 and ML040690738.
- 26 [NRC] U.S. Nuclear Regulatory Commission. 1999. Section 6.3—Transportation, Table 9.1,
27 Summary of findings on NEPA issues for license renewal of nuclear power plants. In: *Generic*
28 *Environmental Impact Statement for License Renewal of Nuclear Plants*. Washington, DC:
29 NRC. NUREG–1437, Volume 1, Addendum 1. August 1999. ADAMS No. ML040690720.
- 30 [NRC] U.S. Nuclear Regulatory Commission. 2011. Commission Memorandum and Order:
31 Denying Suspension Petitions, Addressing Additional Requests for Relief, and Granting a
32 Request for a Safety Analysis (CLI-11-05). September 9, 2011. ADAMS No. ML11252A958.
- 33 [NRC] U.S. Nuclear Regulatory Commission. 2013a. Memorandum from L. James, Senior
34 Project Manager, to A. Simmons, Acting Chief. Subject: Forthcoming meeting to discuss the
35 license renewal process and environmental scoping for Exelon Generation Company, LLC
36 (Exelon), Byron Nuclear Station, Units 1 and 2. August 7, 2013. ADAMS No. ML13217A069.
- 37 [NRC] U.S. Nuclear Regulatory Commission. 2013b. *Generic Environmental Impact Statement*
38 *for License Renewal of Nuclear Plants. Revision 1*. Washington, DC: NRC. NUREG-1437
39 Volumes 1, 2, and 3. June 19, 2013. 1,535 p. ADAMS No. ML13107A023.

- 1 [NRC] U.S. Nuclear Regulatory Commission. 2013c Letter from L. James, Project Manager, to
- 2 M. Gallagher, Exelon Generating Company, LLC. Subject: "Summary of the site audit related to
- 3 the review of the license renewal application for Byron Nuclear Station, Units 1 and 2 (TAC
- 4 Nos. MF1834 and MF1835)." October 4, 2013. ADAMS No. ML13270A069.
- 5 [NRC] U.S. Nuclear Regulatory Commission. 2014. *Environmental Impact Statement Scoping*
- 6 *Process Summary Report, Byron Station, Units 1 and 2, Byron, IL*. Rockville, MD: NRC.
- 7 May 28, 2014. 83 p. ADAMS No. ML14041A334.

2.0 ALTERNATIVES INCLUDING THE PROPOSED ACTION

Although the U.S. Nuclear Regulatory Commission's (NRC's) decisionmaking authority in license renewal is limited to deciding whether or not to renew a nuclear power plant's operating license, the NRC's implementation of the National Environmental Policy Act (NEPA) requires consideration of the environmental impacts of potential alternatives to renewing a plant's operating license. While the ultimate decision about which alternative (or the proposed action) to carry out falls to operator, state, or other non-NRC Federal officials, comparing the impacts of renewing the operating license to the environmental impacts of alternatives allows the NRC to determine whether the environmental impacts of license renewal are so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable (10 CFR 51.95(c)(4)).

Energy-planning decisionmakers and owners of the nuclear power plant ultimately decide whether the plant will continue to operate, and economic and environmental considerations play important roles in this decision. In general, the NRC's responsibility is to ensure the safe operation of nuclear power facilities and not to formulate energy policy or encourage or discourage the development of alternative power generation. The NRC does not engage in energy-planning decisions and makes no judgment as to which energy alternatives evaluated would be the most likely alternative in any given case.

The remainder of this chapter provides: (1) a description of the proposed action, (2) a description of alternatives to the proposed action (including the no-action alternative), and (3) alternatives to Byron Station, Units 1 and 2 (Byron) license renewal that were considered and eliminated from detailed study. Chapter 4 of this plant-specific supplemental environmental impact statement (SEIS) compares the impacts of renewing the operating licenses of Byron and continued plant operations to the environmental impacts of alternatives.

2.1 Proposed Action

As stated in Section 1.1 of this document, the NRC's proposed Federal action is the decision of whether to renew the Byron operating licenses for an additional 20 years. For the NRC to determine the impacts from continued operation of Byron, an understanding of that operation is needed. A description of normal power plant operations during the license renewal term is provided in Section 2.1.1. Byron is a two-unit, nuclear-powered steam-electric generating facility that began commercial operation in February 1985 (Unit 1) and January 1987 (Unit 2). The nuclear reactor for each unit is a Westinghouse pressurized-water reactor (PWR), producing 2,370 megawatts electric (MWe) (Exelon 2013a).

2.1.1 Plant Operations During the License Renewal Term

Most plant operation activities during license renewal would be the same as or similar to those occurring during the current license term (NRC 2013a). Section 2.1.1 of the *Generic Environmental Impact Statement for License Renewal of Nuclear Power Plants* (GEIS), NUREG-1437, Revision 1 (NRC 2013a), describes the general types of activities that are carried out during the operation of a nuclear power plant such as Byron, as follows:

- reactor operation;
- waste management;
- security;

Alternatives Including the Proposed Action

- 1 • office and clerical work;
- 2 • surveillance, monitoring, and maintenance; and
- 3 • refueling and other outages.

4 As stated in the Exelon Generation Company, LLC's (Exelon's) Environmental Report (ER),
5 Byron will continue to operate during the license renewal term in the same manner as during the
6 current license term except for, as appropriate, additional aging management programs to
7 address structure and component aging, in accordance with Title 10 of the *Code of Federal*
8 *Regulations* (10 CFR) Part 54, "Requirements for Renewal of Operating Licenses for Nuclear
9 Power Plants."

10 **2.1.2 Refurbishment and Other Activities Associated With License Renewal**

11 Refurbishment activities include replacement and repair of major systems, structures, and
12 components. Replacement activities include replacement of steam generators for PWRs and
13 recirculation piping systems for boiling-water reactors (BWRs). The major refurbishment class
14 of activities characterized in the *Generic Environmental Impact Statement for License Renewal*
15 *of Nuclear Plants* (GEIS) (NRC 2013a) is intended to encompass actions that typically take
16 place only once in the life of a nuclear plant, if at all. Examples of these activities include, but
17 are not limited to, replacement of boiling-water reactor recirculation piping and pressurized-
18 water reactor steam generators. These actions may have an impact on the environment
19 beyond those that occur during normal operations and may require evaluation, depending on
20 the type of action and the plant-specific design.

21 In preparation for its license renewal application, Exelon performed an evaluation of these
22 structures, systems, and components (SSCs) in accordance with 10 CFR 54.21, "Contents of
23 application—technical information," to identify the need to undertake any major refurbishment
24 activities that would be necessary to support the continued operation of Byron, during the
25 proposed 20-year period of extended operation (Exelon 2013a).

26 As a result of its SSC evaluation, Exelon did not identify the need to undertake any major
27 refurbishment or replacement activities associated with license renewal to support the continued
28 operation of Byron beyond the end of the existing operating license (Exelon 2013a). Therefore,
29 refurbishment activities are not discussed under the proposed action in Chapter 4.

30 However, Exelon identified two hypothetical refurbishment activities that may occur during the
31 period of continued operation (Exelon 2013a), which will be discussed in Section 4.16,
32 Cumulative Impacts of Proposed Action:

- 33 • steam generator replacement for Unit 2, and
- 34 • reactor pressure vessel (RPV) head replacement for both or either unit.

35 Exelon's experience in replacing the steam generators for Unit 1 allowed for a determination
36 that analyses of environmental impacts associated with the hypothetical steam generator
37 replacement would bound the hypothetical RPV head replacement. Specifically, the
38 replacement of the steam generators would require more time (90 days vs. 7 days) and more
39 people (500 vs. 340) than the RPV head replacement. The remaining factors (personnel
40 access, parking and potable water supply, sufficient disturbed land to support onsite laydown
41 facilities, and new storage facility) would be similar for both activities (Exelon 2013a).

42 As a result of experience and analyses, Exelon chose to analyze the hypothetical replacement
43 of the Unit 2 steam generators (Exelon 2013a). Specific impacts of the hypothetical
44 replacement of Unit 2's steam generators are discussed in Section 4.16, Cumulative Impacts.

2.1.3 Termination of Nuclear Power Plant Operations and Decommissioning After the License Renewal Term

The impacts of decommissioning are described in the *Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Regarding the Decommissioning of Nuclear Power Reactors*, NUREG-0586 (NRC 2002). The majority of the activities associated with plant operations would cease with reactor shutdown. Some activities (e.g., security and oversight of spent nuclear fuel) would remain unchanged, while others (waste management, office and clerical work, laboratory analysis, and surveillance, monitoring, and maintenance) would continue at reduced or altered levels. Systems dedicated to reactor operations would cease operations; however, impacts from their physical presence may continue if not removed after reactor shutdown. For sites such as Byron, with more than one unit, shared systems may operate at reduced capacities. Impacts associated with dedicated systems that remain in place or shared systems that continue to operate at normal capacities would remain unchanged.

Decommissioning will occur whether Byron is shut down at the end of its current operating licenses or at the end of the period of extended operation. There are no site-specific issues related to decommissioning. The GEIS concludes that license renewal would have a negligible (SMALL) effect on the impacts of terminating operations and decommissioning on all resources.

2.2 Alternatives

As stated at the beginning of this chapter, the NRC has the obligation to consider reasonable alternatives to the proposed action of renewing the license for a nuclear reactor. A reasonable replacement power alternative must be commercially viable on a scale capable of producing baseload power and must be operational prior to the expiration of the reactor’s operating license(s), or expected to become commercially viable or expected to produce baseload power and be operational prior to the expiration of the reactor’s operating license(s). The 2013 GEIS update incorporated the latest information on replacement power alternatives; however, rapidly evolving technologies are likely to outpace the information presented in the GEIS. As such, a site-specific analysis of alternatives must be performed for each SEIS, taking into account changes in technology and science since the preparation of the GEIS.

Section 2.2.1 below describes the no-action alternative (i.e., the NRC takes no action and does not issue renewed licenses for Byron). Sections 2.2.2.1–2.2.2.5 describe the characteristics of replacement power alternatives for Byron.

2.2.1 No-Action Alternative

At some point, operating nuclear power plants will terminate operations and undergo decommissioning. The no-action alternative represents a decision by the NRC not to renew the operating license of a nuclear power plant beyond the current operating license term. Under the no-action alternative, the NRC does not renew the operating licenses, and the Byron plant shuts down at or before the end of the current licenses, in 2024 and 2026. After shutdown, plant operators will initiate decommissioning in accordance with 10 CFR 50.82.

Only those impacts that arise directly as a result of plant shutdown will be addressed in this SEIS. The environmental impacts from decommissioning and related activities are addressed in several other documents, including the *Final Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities*, NUREG-0586, Supplement 1 (NRC 2002); the license renewal GEIS, Chapter 4 (NRC 2013a); and Chapter 4 of this SEIS. These analyses either directly address or bound the environmental impacts of decommissioning whenever Exelon ceases to operate Byron.

Alternatives Including the Proposed Action

1 Even with renewed operating licenses, Byron will eventually shut down, and the
2 environmental impacts addressed later in Chapter 4 of this SEIS will occur at that time.
3 As with decommissioning impacts, shutdown impacts are expected to be similar whether they
4 occur at the end of the current license or at the end of a renewed license.

5 Termination of operations at Byron would result in the total cessation of electrical power
6 production. Unlike the alternatives described below in Section 2.2.2, no-action does not
7 expressly meet the purpose and need of the proposed action as described in Section 1.2, as it
8 does not provide a means of delivering baseload power to meet future electric system needs.
9 Assuming that a need currently exists for the power generated by Byron, the no-action
10 alternative would likely create a need for a replacement power alternative. A full range of
11 replacement power alternatives (including fossil fuels, new nuclear, and renewable energy
12 sources) are described in the following section, and their potential impacts are assessed in
13 Chapter 4. Although the NRC's authority only extends to the decision of whether to renew the
14 Byron operating licenses, the replacement power alternatives described in the following sections
15 represent possible options for energy-planning decisionmakers should the NRC choose not to
16 renew the Byron operating licenses.

17 **2.2.2 Replacement Power Alternatives**

18 In evaluating alternatives to license renewal, the NRC considered energy technologies or
19 options currently in commercial operation, as well as technologies not currently in commercial
20 operation but likely to be commercially available by the time the current Byron operating
21 licenses expire. The current operating licenses for the Byron Units 1 and 2 expire on
22 October 31, 2024, and November 6, 2026, respectively. Alternatives that cannot be
23 constructed, permitted, and connected to the grid by the time Byron licenses expire were
24 eliminated from detailed consideration.

25 Alternatives that cannot provide the equivalent of Byron's current generating capacity and, in
26 some cases, those alternatives whose costs or benefits do not justify inclusion in the range of
27 reasonable alternatives, were eliminated from detailed consideration. Each alternative
28 eliminated from detailed study is briefly discussed, and a basis for its removal is provided at the
29 end of this section. In total, 17 alternatives to the proposed action were considered (see text
30 box) and then narrowed to the 5 alternatives considered in Sections 2.2.2.1–2.2.2.5. The NRC
31 staff evaluated the environmental impacts of these five alternatives and the no-action alternative
32 and discusses them in depth in Chapter 4 of this SEIS.

33 The GEIS presents an overview of some energy technologies but does not reach any
34 conclusions about which alternatives are most appropriate. Because many energy technologies
35 are continually evolving in capability and cost, and because regulatory structures have changed
36 to either promote or impede development of particular alternatives, the analyses in this chapter
37 may include updated information from the following sources:

- 38 • Energy Information Administration (EIA),
- 39 • other offices within the U.S. Department of Energy (DOE),
- 40 • U.S. Environmental Protection Agency (EPA),
- 41 • industry sources and publications, and
- 42 • information submitted by Exelon in its ER.

1 The evaluation of each alternative in Chapter 4
 2 of this SEIS considers the environmental
 3 impacts across several impact categories:
 4 land use and visual resources, air quality and
 5 noise, geologic environment, water resources,
 6 ecological resources, historic and cultural
 7 resources, socioeconomics, human health,
 8 environmental justice, and waste
 9 management. Most site-specific issues
 10 (Category 2) have been assigned a
 11 significance level of SMALL, MODERATE, or
 12 LARGE. For ecological and historic and
 13 archaeological resources, the impact
 14 significance determination language is specific
 15 to the authorizing legislation (e.g., Endangered
 16 Species Act and National Historic Preservation
 17 Act). The order of presentation of the
 18 alternatives is not meant to imply increasing or
 19 decreasing level of impact. Nor does it imply
 20 that an energy-planning decisionmaker would
 21 be more likely to select any given alternative.

22 To ensure that the alternatives analysis is
 23 consistent with state or regional energy
 24 policies, the NRC reviewed energy-related statutes, regulations, and policies within the Byron
 25 region. As a result, the staff considers alternatives that include wind power or solar photovoltaic
 26 (PV) power, as well as a combination that includes both of them.

27 Region of Influence

28 Byron is owned and operated by Exelon and provides electricity through Commonwealth Edison
 29 (ComEd) (Exelon 2013a). ComEd operates under the PJM Interconnection, a regional
 30 transmission organization that coordinates the movement of wholesale electricity in 13 states
 31 across the Midwest and Northeast (Exelon 2013a). ComEd provides service to 3.8 million
 32 customers across northern Illinois. Its service territory borders Iroquois County to the south, the
 33 Wisconsin border to the north, the Iowa border to the west, and the Indiana border to the east
 34 (ComEd 2013). However, electricity consumption in Illinois is not limited to electricity that is
 35 generated within the State. Although northern Illinois relies on electricity from ComEd, the rest
 36 of Illinois and surrounding states, which are not part of the PJM Interconnection, are part of the
 37 Midcontinent Independent System Operator (MISO) (See Figure 2–1) (Exelon 2013a).

38 If renewed licenses were not issued, replacement power for Byron would be required in northern
 39 Illinois. Electricity could be replaced by generation sources from a variety of locations.
 40 Electricity could be transported from within the PJM Interconnection; however, the PJM
 41 Interconnection in Illinois is geographically distant from the rest of the PJM region (see
 42 Figure 2–1). It is also possible that electricity within MISO could be purchased by PJM, and
 43 efforts are currently being made to increase coordination and deliverability between the regional
 44 transmission organizations (Ott 2013b). In addition, the State of Illinois has a renewable
 45 portfolio standard that includes a geographic eligibility requirement stipulating that eligible
 46 renewable resources must be procured from facilities located in Illinois or states that adjoin
 47 Illinois (Wisconsin, Indiana, Iowa, Kentucky, Michigan, and Missouri) (ILGA 2011). Renewable
 48 resources can be obtained only from other regions of the country if they are not available in
 49 Illinois or in adjoining states (ILGA 2011).

<p style="text-align: center;">Alternatives Evaluated in Depth:</p> <ul style="list-style-type: none"> • new nuclear • coal-integrated gasification combined cycle • natural gas combined cycle • combination alternative (wind power, natural gas combined cycle, and solar power) • purchased power <p style="text-align: center;">Other Alternatives Considered:</p> <ul style="list-style-type: none"> • energy efficiency and conservation • wind power • solar power • hydroelectric power • wave and ocean energy • geothermal power • municipal solid waste • biomass • oil-fired power • fuel cells • delayed retirement

Alternatives Including the Proposed Action


1 Therefore, because replacement power would be required in northern Illinois and any renewable
2 energy resources would need to be procured from adjoining states, the NRC staff evaluated the
3 impacts of locating replacement power facilities within the States of Illinois, Indiana, Iowa,
4 Kentucky, Michigan, Missouri, and Wisconsin. These seven states constitute the region of
5 influence (ROI) for the NRC staff's analysis of alternatives. The NRC assumes that
6 replacement power would either be produced in northern Illinois within the PJM region or would
7 be purchased by PJM from MISO.

8 In 2012, electric generators in the ROI had a net summer generating capacity of approximately
9 179,000 megawatts (MW). This capacity included units fueled by coal (49 percent), natural gas
10 (27 percent), nuclear (11 percent), and wind (6.6 percent) (EIA 2014c).

11 In 2011, the electric industry in the ROI provided approximately 744 million megawatt hours
12 (MWh) of electricity. Electricity produced in the ROI was dominated by coal (67 percent) and
13 nuclear (21 percent). While natural gas makes up nearly 30 percent of the installed generating
14 capacity in the ROI, it provides only 6 percent of electricity in the region. Nonhydroelectric
15 renewable energy produced 1.3 percent of the electricity in the ROI (EIA 2014b).

16

Figure 2-1. Territories of MISO and PJM Interconnection



17

18

Source: MISO-PJM undated

19 Renewable energy legislation in the Region of Influence

20 Renewable energy legislation in Illinois allows the purchase of electricity generation in adjoining
21 states; therefore, any legislation targeting renewable energy in these states could impact a
22 state's incentive to develop renewable resources. Five States in the ROI (Illinois, Iowa,
23 Missouri, Wisconsin, and Michigan) have legally mandated renewable energy legislation. The
24 State of Indiana has a voluntary program, and State of Kentucky does not have any renewable
25 energy requirements. The paragraphs below briefly outline each state's program, including
26 renewable energy goals and benchmarks.

27 In August 2007, Illinois adopted a renewable portfolio standard that requires the State's utilities
28 to produce at least 25 percent of their power from renewable sources by 2025, 75 percent of
29 which must come from wind. Solar photovoltaics must comprise 6 percent of the annual
30 requirement for calendar year 2015 and thereafter. Other eligible sources include biomass and

1 existing hydroelectric power (DSIRE 2012a). The law also includes an energy efficiency
2 standard that requires utilities to implement cost-effective energy efficiency measures to meet
3 energy savings of 2 percent by calendar year 2015 and thereafter (ILGA 2011). For electric
4 utilities (including ComEd), eligible resources must be located in Illinois; resources can be
5 purchased from adjoining states only if there are insufficient instate resources (ILGA 2011).

6 Iowa's Alternative Energy Production Law requires the State's two investor-owned utilities to
7 generate a combined total of 105 megawatts (MW) of their generating capacity from renewable
8 energy sources. A 2007 order allows the utilities to participate in renewable energy credit
9 trading programs by distinguishing between renewable electricity production capacity used to
10 comply with Iowa law and that which can be used to satisfy other states' renewable portfolio
11 standards (DSIRE 2012b).

12 Missouri adopted a renewable portfolio standard that requires investor-owned utilities to
13 increase their use of renewable sources by 15 percent by 2021 and includes a provision
14 specifying that 2 percent of the renewable portfolio standard requirement must be met by solar
15 energy. Resources can be purchased from outside Missouri, but renewable energy generated
16 in State receives a multiplier of 1.25 compared to out-of-State generation (DSIRE 2013b).

17 Wisconsin's renewable portfolio standard requires utilities to produce 10 percent of their
18 electricity from renewable sources by 2015. Included in the renewable portfolio standard is a
19 provision that allows electricity providers to create and sell or transfer renewable resource
20 credits and renewable energy certificates. Renewable energy generated outside Wisconsin is
21 eligible, provided that the electricity is distributed to Wisconsin customers (DSIRE 2012c).

22 Michigan enacted a Renewable Energy Standard in 2008 that requires utilities to generate
23 10 percent of their retail electricity sales from renewable energy resources by 2015. The
24 standard also allows energy efficiency and advanced cleaner energy systems to meet part of
25 the requirement. Renewable energy credits can be purchased from in-State or out-of-State
26 facilities, provided that the facilities are located within the retail electric service territory of a
27 utility that is recognized by the Michigan Public Service Commission (DSIRE 2013a).

28 Indiana does not have a mandatory renewable or alternative energy portfolio standard. On
29 July 9, 2012, Indiana adopted a Clean Energy Portfolio Standard, which sets a voluntary goal of
30 10 percent clean energy by 2025, based on the amount of electricity supplied by the utility in
31 2010. Unlike many of the other ROI states, up to 30 percent of the goal may be met with clean
32 coal technology, nuclear energy, combined heat and power systems, natural gas that displaces
33 electricity from coal, clean coal technology, and net-metered distributed generation facilities.
34 Fifty percent of qualifying energy must come from within the State (DSIRE 2012d).

35 Kentucky is the only state in the ROI that does not have mandatory or voluntary renewable
36 energy requirements.

37 Given known technology and technological and demographic trends, the EIA predicts that
38 32 percent of electricity in the United States will be generated by coal in 2040 (EIA 2013a). In
39 all the Midwest case projections, coal accounts for 42 percent in 2040 (EIA 2013a). Natural gas
40 generation rose from 16 percent in 2000 to 24 percent in 2011 and is projected to increase to
41 35 percent in 2040, surpassing coal as the largest share of U.S. electric power generation
42 (EIA 2013a, 2013d). Electricity generation from renewable energy is expected to grow from
43 13 percent of total generation in 2011 to 16 percent in 2040. However, there are uncertainties
44 that could affect this forecast, particularly the implementation of policies aimed at reducing
45 greenhouse gas emissions which would have a direct effect on fossil fuel based generation
46 technologies (EIA 2013a).

Alternatives Including the Proposed Action

1 This section describes replacement power alternatives to license renewal. These include a new
2 nuclear alternative in Section 2.2.2.1; a coal-integrated gasification combined cycle (IGCC)
3 alternative in Section 2.2.2.2; a natural gas combined-cycle (NGCC) alternative in
4 Section 2.2.2.3; a combination natural gas, wind, and solar power alternative in Section 2.2.2.4;
5 and a purchased power alternative in Section 2.2.2.5. Table 2–1 summarizes key design
6 characteristics of the alternative technologies evaluated in depth. The environmental impacts of
7 these alternatives are evaluated in Chapter 4.

1
2

Table 2–1. Summary of Replacement Power Alternatives and Key Characteristics Considered in Depth

	New Nuclear Alternative	IGCC Alternative	NGCC Alternative	Combination Alternative
Summary of Alternative	Two-unit nuclear plant, each with 1,120 MWe, for a total of 2,240 MWe	Four 618-MWe units, for a total of 2,472 MWe	Five 560-MWe units, for a total of 2,800 MWe	One 360 MWe NGCC unit; a 1,813 MWe wind farm; and a 227 MWe installed solar photovoltaic facility, for a total of 2,400 MWe.
Location	An existing nuclear plant site or retired coal plant site. New transmission line(s) and other infrastructure upgrades may be required. Some facilities (e.g., support buildings, potable water supply, and sanitary discharge structures) could be shared with existing plant.	An existing plant site or retired coal plant site. New transmission line(s) and other infrastructure upgrades may be required. Some facilities (e.g., support buildings, potable water supply, and sanitary discharge structures) could be shared with existing plant.	An existing plant site or retired coal plant site. New transmission line(s) and other infrastructure upgrades may be required; would require construction of a new or upgraded pipeline. Some facilities (e.g., support buildings, potable water supply, and sanitary discharge structures) could be shared with existing plant.	Spread across multiple sites throughout the ROI
Cooling System	Closed-cycle with natural draft cooling towers. Cooling water withdrawal—54 mgd; consumptive water use—40 mgd (NRC 2008).	Closed-cycle with mechanical draft cooling towers. Cooling water withdrawal—25 mgd; consumptive water use—20 mpd (NETL 2013a).	Closed-cycle with mechanical draft cooling towers. Cooling water withdrawal—17 mgd; consumptive water use—13 mgd (NETL 2013a).	For NGCC portion, closed-cycle with mechanical draft cooling towers. Cooling water would be 15% of that required for NGCC alternative. Minimal water use for wind and solar.

Alternatives Including the Proposed Action

	New Nuclear Alternative	IGCC Alternative	NGCC Alternative	Combination Alternative
Land Requirements	355 ac (144 ha) (NRC 2008); 520 ac (210 ha) for uranium mining and processing ¹ (NRC 2013a)	2,000 ac (800 ha) for the major permanent facilities; 1,100 ac (450 ha) per year for mining (DOE 2010a)	94 ac (38 ha) for the plant, including pipelines (Exelon 2013a); 10,080 ac (4,079 ha) for gas extraction and collection (NRC 1996)	Wind farms would require 3,376 ac (1,366 ha) to 10,127 ac (4,098 ha); (WAPA and FWS 2013); solar photovoltaic facilities would require 6,749 ac (2,731 ha) (Ong et al. 2013). For NGCC portion, land use would remain the same at 94 ac (38 ha) (Exelon 2013a).
Work Force	3,500 workers during peak construction; 812 workers during operations (NRC 2008)	4,600 workers during peak construction; 420 workers during operations (DOE 2010a)	1,783 workers during peak construction; 94 workers during operations (Exelon 2013a)	Solar photovoltaic—600 workers during peak construction, 60 workers during operations; for wind—931 workers during construction, 566 workers during operations (DOE 2010b). The number of construction and operations workers would be less than the standalone alternative but would not be a linear reduction because of needing a minimum number of workers regardless of the size of the NGCC plant.

¹ Normalized to model light water reactor annual fuel requirement. 46% of this land requirement is temporarily committed land.

Key: ac = acres; cfs = cubic feet per second; ha = hectares; IGCC = coal-integrated gasification combined cycle; mgd = million gallons per day; MWe = megawatts electric; NGCC = natural gas combined-cycle; ROI = region of influence

Sources: DOE 2010a, 2010b; Exelon 2013a; NETL2013a; NRC 1996, 2008, 2013b; Ong et al. 2013; WAPA and FWS 2013

1 *2.2.2.1 New Nuclear Alternative*

2 In this section, NRC staff describes the new nuclear alternative. NRC staff evaluates the
3 environmental impacts from this alternative in Chapter 4.

4 The NRC staff considered the construction of a new nuclear plant to be a reasonable alternative
5 to license renewal. For example, nuclear generation currently provides 21 percent of electricity
6 generation in the ROI (EIA 2014b). Twelve nuclear power plants operate in the ROI;
7 six applicants have received renewed licenses and three additional applicants have applied for
8 renewed licenses from the NRC (including Byron) (NRC 2013b). In addition, there is interest in
9 new nuclear power plant development in the region; combined license (COL) applications have
10 been filed for two new nuclear power plants in the ROI. On July 24, 2008, Union Electric
11 Company submitted a COL application for Callaway Plant, Unit 2 (Callaway Unit 2), in Callaway
12 County, Missouri, on the existing Callaway site (AmerenUE 2009). However, that application
13 has since been suspended (NRC 2009b). An application was also filed in September 2008 for
14 Enrico Fermi Atomic Power Plant, Unit 3 (Fermi Unit 3), in Monroe County, Michigan, on the
15 existing Fermi site. The NRC staff published the Final Environmental Impact Statement (EIS)
16 for Fermi 3 in January 2013 (NRC 2013c). Although the State of Indiana does not currently
17 have any nuclear power plants, its voluntary clean energy initiative includes nuclear as an
18 eligible technology (DSIRE 2012b).

19 The NRC staff determined that there is sufficient time for Exelon to prepare and submit an
20 application, build, and operate two new nuclear units before the Byron licenses expire in
21 October 2024 and November 2026. For example, the NRC staff review of a COL application
22 that references a certified design is at least 30 months, not including hearing time. Noncertified
23 designs would take 48 to 60 months to review (NRC 2009a). The recently licensed Vogtle
24 Electric Generating Plant, Units 3 and 4 (Vogtle Units 3 and 4), anticipates a construction
25 schedule of 6 to 7 years (Southern 2013).

26 In evaluating the new nuclear alternative, the NRC staff assumed that two new nuclear reactors
27 would be built on an existing nuclear or coal power plant site, allowing for the maximum use of
28 existing ancillary facilities such as support buildings and transmission infrastructure. In 1987,
29 Illinois passed a moratorium preventing the construction of new nuclear power plants within the
30 state. Unless the moratorium is lifted, any new nuclear alternative would have to be located
31 elsewhere in the ROI. For the purposes of this analysis, the NRC relied on the Vogtle Units 3
32 and 4 COL EIS for technological parameters for the new nuclear alternative, because the Vogtle
33 Units 3 and 4 COL considers two new nuclear reactor units with similar output as Byron and is
34 representative of the reactors that could be constructed in the ROI before Byron's licenses
35 expire (NRC 2011). As such, the NRC staff assumed two Westinghouse AP1000 reactors with
36 a net electrical output of 2,240 MWe would replace Byron's current reactors for this alternative.
37 The NRC staff estimated that 324 acres (ac) (131 hectares (ha)) of additional land would be
38 required on a long-term basis because of permanent facilities, and an additional 31 ac (12.5 ha)
39 would be disturbed for temporary facilities, a laydown area, and storage of dredge material
40 (NRC 2008).

41 The heat rejection demands of a new nuclear alternative would be similar to those of Byron.
42 The new reactors may require a new cooling system (including natural draft cooling towers and
43 intake and discharge structures). The NRC staff assumes that water requirements for the new
44 nuclear alternative would be similar to current water use at Byron. The existing transmission
45 lines leaving the site, as well as construction and drinking water wells are expected to serve the
46 replacement reactor with few modifications required. A new onsite transmission line may be
47 required if insufficient transmission occurs on the site. Construction materials would be
48 delivered by a combination of rail spur, truck, and barge, depending on the specific site location.

Alternatives Including the Proposed Action

1 It is possible that modifications would be required to deliver such materials, depending on the
2 existing infrastructure at the site; modifications could include new rail lines or access roads.

3 The NRC staff also considered the installation of multiple small modular reactors as an
4 alternative to renewing the Byron licenses. The NRC established the Advanced Reactor
5 Program in the Office of New Reactors because of considerable interest in small modular
6 reactors along with anticipated license applications by vendors. Small modular reactors are
7 approximately 300 megawatts (MW) or less, would have lower initial capacity than large-scale
8 units, and would have siting flexibility for locations that are not large enough to accommodate
9 traditional nuclear reactors (DOE undated b). As of January 2014, no applications for small
10 modular reactors have been submitted to the NRC. The DOE has estimated that the technology
11 may achieve commercial operation by 2021 to 2025 (DOE undated b). Because small modular
12 reactors are not expected to be operational at a commercial scale until near the time Byron's
13 licenses expire, it is unlikely that eight new small modular reactors (the number of units required
14 to replace Byron's current output) could be constructed in the ROI; therefore, this analysis
15 focuses on nuclear generation by larger nuclear units.

16 *2.2.2.2 IGCC Alternative*

17 In this section, the NRC staff describes the IGCC alternative. The NRC staff evaluates the
18 environmental impacts from this alternative in Chapter 4.

19 Coal provides the greatest share of electrical power in the ROI, and in 2010, coal represented
20 49 percent of installed generation capacity and accounted for 67 percent of all electricity
21 generated in the ROI (EIA 2014b). IGCC is a technology that generates electricity from coal
22 and combines modern coal gasification technology with both gas-turbine and steam-turbine
23 power generation. The technology is cleaner than conventional pulverized coal plants because
24 major pollutants are removed from the gas stream before combustion. An IGCC power plant
25 consists of coal gasification and combined-cycle power generation. Coal gasifiers convert coal
26 into a gas (synthesis gas, also referred to as syngas) which fuels the combined-cycle power
27 generating units. The combined-cycle system for a 618-MWe IGCC power plant includes two
28 combustion turbines, two heat recovery steam generators, and a steam turbine. The combined-
29 cycle units combust gas in one or more combustion turbines, and the resulting hot exhaust gas
30 is then used to heat water into steam to drive a steam turbine. The steam turbine then uses the
31 heat from the gas turbine's exhaust through a heat recovery steam generator to produce
32 additional electricity (DOE 2010a). This two-cycle process has a high rate of efficiency, since
33 the exhaust heat that would otherwise be lost is captured and reused. In addition, the power
34 plant would reduce sulfur dioxide, nitrogen oxides, mercury, and particulate emissions by
35 removing constituents from the syngas before combustion. Nearly 100 percent of the nitrogen
36 from the syngas would be removed prior to combustion in the gas turbines and would result in
37 lower nitrogen oxide emissions compared to conventional coal-fired power plants (DOE 2010a).

38 IGCC power plants have been in operation since the mid-1990s; the Wabash Rice IGCC
39 repowering project in Indiana and the Polk Power Station in Florida are two examples of
40 operating IGCC plants. Recently, there has been an increased interest in new IGCC projects,
41 and multiple new projects have been proposed or have recently begun operations in the
42 United States. The Duke Energy Edwardsport Generation Station in Indiana is a 618-MWe
43 IGCC power plant in the ROI that began commercial operation in June 2013. Duke Energy
44 estimates that the IGCC plant will produce 10 times as much power as the retired coal plant it
45 replaced with 70 percent fewer emissions of sulfur dioxide, nitrogen oxides, and particulates.
46 The IGCC plant will reduce carbon emissions per MWh by nearly half (Duke Energy 2013). In
47 addition, the Edwardsport Generation Station has potential for carbon capture and geologic

1 sequestration. Space has been reserved at the site for carbon dioxide capture equipment
2 (NETL 2013b).

3 Many IGCC power plants have been designed with carbon capture and storage (CCS) to further
4 reduce carbon dioxide emissions. The Kemper County IGCC project in east-central Mississippi
5 proposes to use CCS to reduce carbon dioxide emissions by almost 70 percent by removing
6 carbon from the syngas post-gasification (DOE 2010a). According to a 2013 National Energy
7 Technology Laboratory (NETL) report, nine IGCC projects totaling over 4,000 MW are currently
8 active; these projects are in the planning stages, or they have begun construction.
9 Thirteen projects have been proposed and subsequently cancelled for a variety of reasons,
10 including air quality issues, state laws and regulations, redirected focus on gas-fired generation
11 and renewables, and unanticipated rising costs (NETL 2013c).

12 IGCC technology and proposed projects have experienced a number of setbacks and
13 opposition, hindering IGCC's ability to fully integrate into the energy market. The most
14 significant roadblock is IGCC's high capital cost compared to conventional coal-fired power
15 plants. Cost overruns have been experienced at both the Edwardsport IGCC project and the
16 Kemper County IGCC project. FutureGen, an IGCC plant featuring CCS, lost DOE financial
17 support because of escalating cost estimates (Reuters 2012). Other issues include:

- 18 • construction timeline overruns,
- 19 • limited track record for reliable performance, and
- 20 • opposition from an environmental perspective (Rosenberg 2004).

21 Despite some of the current setbacks and concerns associated with IGCC projects, the NRC
22 staff considers IGCC technology to be a reasonable source of baseload power to replace Byron
23 by the time its licenses expire in 2024 and 2026 because of the current regulatory framework
24 and the number of active IGCC plants within the ROI. For example, on January 8, 2014, EPA
25 issued a proposed rule for carbon pollution that would apply to new fossil fuel-fired power
26 plants. The action proposes performance standards for utility boilers and IGCC units based on
27 partial implementation of a CCS system as the best method of emission reduction. The
28 proposed emission limit for these sources is 1,100 lb carbon dioxide per megawatt hour
29 (CO₂/MWh). The proposed rule cites a number of IGCC projects and concludes that the
30 projects are "consistent with the EIA modeling which projects that few, if any, new coal-fired
31 units would be built in this decade and that those that are built would include CCS"
32 (79 FR 1430). If this rule becomes final, any new coal-fired power plants would likely require
33 CCS in order to achieve the 1,100 lb CO₂/MWh emission limit. Therefore, in this section, the
34 NRC staff considers IGCC power plants as an alternative to Byron because the Edwardsport
35 IGCC project in Indiana is currently in operation and the Kemper IGCC project in Mississippi is
36 under construction. The technology parameters for these plants are considered the current
37 state of technology and are used here to describe a hypothetical IGCC power plant located on
38 an existing power plant site within the ROI.

39 To replace the electricity that Byron generates, the NRC staff considered four IGCC units, each
40 with a net capacity of 618 MWe. Various coal sources are available to coal-fired power plants in
41 the ROI. For the purpose of this evaluation, the NRC staff assumes that the IGCC alternative
42 would burn a sub-bituminous coal, based on the type of coal used in electric plants in Illinois.
43 NRC staff presumes that coal burned in Illinois will be representative of coal that would be
44 burned in an IGCC alternative regardless of where it may be located (EIA 2012). The IGCC
45 units would reduce sulfur dioxide, nitrogen oxides, mercury, and particulate emissions by
46 removing constituents from the syngas. The removal of nearly 100 percent of the nitrogen from
47 the syngas prior to combustion in the gas turbines would result in significantly lower nitrogen

Alternatives Including the Proposed Action

1 oxide emissions compared to conventional coal-fired power plants (DOE 2010a). In
2 addition, the units would be designed with the potential to add CCS later. In a CCS, carbon
3 dioxide emissions would be compressed and piped off site where it could be sold for beneficial
4 use or geologic storage. Additional discussion of air quality impacts associated with the IGCC
5 alternative is discussed in Section 4.3.

6 The IGCC alternative would be located at an existing site (such as an existing power plant site)
7 to maximize availability of infrastructure and reduce other environmental impacts. Depending
8 on the specific site location, there might be a need to construct new intake and discharge
9 facilities and a new cooling system. The IGCC alternative would use about the same amount of
10 water as Byron and a similar amount as the Edwardsport IGCC plant. The NRC staff assumes
11 the cooling system would use a closed-cycle system with mechanical draft cooling towers. This
12 system would withdraw 25 million gallons per day (gpd) (95 million liters per day (Lpd)) of water
13 and consume 20 million gpd (76 million Lpd). Onsite visible structures could include the boilers,
14 exhaust stacks, intake and discharge structures, mechanical draft cooling towers, transmission
15 lines, and an electrical switchyard. Construction materials would be delivered by a combination
16 of rail spur, truck, and barge, depending on the specific site location. Modifications may be
17 required to deliver such materials; modifications could include new rail lines or access roads.

18 The NRC staff also considered supercritical pulverized coal (SCPC) as an alternative to
19 renewing the Byron licenses. SCPC was dismissed as the coal alternative because of new
20 regulations aimed at limiting the environmental impacts from conventional pulverized coal
21 plants. The presence of active IGCC plants in the ROI also contributed to the selection of IGCC
22 for analysis.

23 *2.2.2.3 NGCC Alternative*

24 In this section, the NRC staff describes the NGCC alternative. The NRC staff evaluates the
25 environmental impacts from this alternative in Chapter 4.

26 Natural gas represents nearly 30 percent of installed generation capacity in the ROI, but
27 provides only 6 percent of all electrical power in the ROI (EIA 2014b and 2014c). Nationwide,
28 the percentage of power generated by natural gas is expected to rise by 2040, although the
29 actual rise in natural gas generation will depend on future natural gas prices (EIA 2013a). The
30 NRC staff considers the construction of an NGCC power plant to be a reasonable alternative to
31 license renewal because it is a feasible, commercially available option for providing electrical
32 generating capacity beyond the expiration of Byron's current licenses.

33 Baseload NGCC power plants have proven their reliability and can have capacity factors as high
34 as 85 percent. In an NGCC system, electricity is generated using a gas turbine that burns
35 natural gas. A steam turbine uses the heat from gas turbine exhaust through a heat recovery
36 steam generator to produce additional electricity. This two-cycle process has a high rate of
37 efficiency since the exhaust heat that would otherwise be lost is captured and reused. Like
38 other fossil fuel sources, NGCC power plants are a source of greenhouse gases, including
39 carbon dioxide. An NGCC power plant, however, produces significantly fewer greenhouse
40 gases per unit of electrical output than conventional coal-powered plants.

41 To replace the electricity that Byron generates, the NRC staff considered five NGCC units, each
42 with a net capacity of 560 MWe (NETL 2007). The NRC staff assumes that each plant
43 configuration consists of two combustion turbine generators, two heat recovery steam
44 generators, and one steam turbine generator with mechanical draft cooling towers for heat
45 rejection. The power plant is assumed to incorporate a selective catalytic reduction (SCR)
46 system to minimize the plant's nitrogen oxide emissions (NETL 2007).

1 This 2,800-MWe NGCC plant would consume 124 billion cubic feet (ft³) (3,500 million cubic
 2 meters (m³)) of natural gas annually, assuming an average heat content of 1,021 British thermal
 3 units per cubic foot (BTU/ft³) (EIA 2013c). Natural gas would be extracted from the ground
 4 through wells, then treated to remove impurities and blended to meet pipeline gas standards
 5 before being piped through the State pipeline system to the plant site. This NGCC alternative
 6 would produce relatively little waste, primarily in the form of spent catalysts used for control of
 7 nitrogen oxide emissions.

8 The NGCC alternative would be located at an existing power plant site to maximize availability
 9 of infrastructure and reduce other environmental impacts. Depending on the specific site
 10 location, there might be a need to construct new intake and discharge facilities and a new
 11 cooling system. Because NGCC power plants generate much of their power from a gas-turbine
 12 combined-cycle plant, and the overall thermal efficiency of this type of plant is high, an NGCC
 13 alternative would require less cooling water than Byron would. This system would withdraw
 14 17 million gallons per day (gpd) (64 million litres per day (Lpd)) of water and consume
 15 13 million gpd (49 Lpd). The NRC staff assumes the cooling system would use a closed-cycle
 16 system with mechanical draft cooling towers. Onsite visible structures could include the cooling
 17 towers, exhaust stacks, intake and discharge structures, transmission lines, natural gas
 18 pipelines, and an electrical switchyard. Construction materials would be delivered by a
 19 combination of rail spur, truck, and barge, depending on the specific site location. Modifications
 20 may be required to deliver such materials; modifications could include new rail lines or access
 21 roads.

22 *2.2.2.4 Combination Alternative (NGCC, Wind, Solar)*

23 In this section, NRC staff describes the environmental impacts of a combination alternative to
 24 the continued operation of Byron, consisting of an NGCC facility constructed at an existing
 25 power plant site, operating in conjunction with land-based wind farms as well as solar energy
 26 facilities, all of which would be located within the ROI. The NRC staff evaluates the
 27 environmental impacts from this alternative in Chapter 4.

28 To serve as an effective baseload power alternative to the Byron reactors, this combination
 29 alternative must be capable of providing an equivalent amount of baseload power. For the
 30 purpose of this evaluation, the NRC staff presumes that NGCC, wind farms, and solar
 31 photovoltaic facilities would comprise the combination alternative.

32 NGCC Portion of the Combination Alternative

33 To produce its required share of power, the NGCC portion, operating at an expected capacity
 34 factor of 85 percent (NETL 2007), would need to have a nameplate rating of approximately
 35 425 MWe.

36 In 2013, the EIA reported that natural gas-fired power plants are generally used infrequently for
 37 shorter periods to meet peak demand. Capacity factors for natural gas plants averaged less
 38 than 5 percent during off-peak demand hours for most regions of the country. Natural gas is
 39 used for these “peaker plants” because natural gas combustion turbines can respond quickly, so
 40 they tend to be used to meet short-term increases in electricity demand (EIA 2013d). A report
 41 prepared by CITI Research stated that gas-fired power plants can help overcome the
 42 intermittent nature of renewable energy (Channell et al. 2012). The peaking aspect of natural
 43 gas-fired power plants makes natural gas an ideal addition to an otherwise renewable energy
 44 combination alternative.

45 NRC staff assumed that one new NGCC unit of the type described in Section 2.2.2.3 would be
 46 constructed and installed at an existing power plant site with a total net capacity of 360 MWe.
 47 The appearance of an NGCC unit would be similar to that of the full NGCC alternative

Alternatives Including the Proposed Action

1 considered in Section 2.2.2.3, although only one unit would be constructed. The NRC staff
2 assumes that the NGCC portion of this alternative, which is assumed to be located at an
3 existing power plant site, would utilize existing electrical switchyards, substations, and
4 transmission lines. Depending on the existing site conditions, it is possible that intake and
5 discharge structures of the existing cooling system could continue in service, but would be
6 connected to a new closed-cycle cooling system. For the purposes of this analysis, the NRC
7 staff assumes that the NGCC portion of the combination would utilize mechanical draft cooling
8 towers.

9 Wind Portion of the Combination Alternative

10 The NRC staff assumes that the wind-generated power from this combination alternative would
11 come from land-based wind farms which would be located in the ROI within the states of Illinois,
12 Indiana, Iowa, Kentucky, Michigan, Missouri, or Wisconsin. The wind portion, assuming a
13 capacity factor of 30 percent, would require a nameplate capacity of 6,042 MWe (WAPA and
14 FWS 2013).

15 The American Wind Energy Association (AWEA) reports a total of more than 60,000 MW of
16 installed wind energy capacity nationwide as of March 31, 2013 (AWEA 2013). As of
17 March 2013, Texas is by far the leader in installed land-based capacity with 12,214 MW.
18 Two states in the ROI have the third- and fourth-largest installed capacity: Iowa with 5,133 MW,
19 followed by Illinois with 3,568 MW (AWEA 2013). The installed wind capacity in the ROI has
20 been increasing annually by 1,000 MWe to 2,500 MWe in each of the past 6 years, for a total of
21 over 11,000 MWe of additional wind capacity from 2007 to 2012 (DOE 2013a). Therefore, NRC
22 staff considers 6,042 MW of wind energy to be a reasonable amount by the time the Byron
23 licenses expire in 2024 and 2026. As is the case with other renewable energy sources, the
24 feasibility of wind resources serving as alternative baseload power is dependent on the location
25 (relative to expected load centers), value, accessibility, and constancy of the resource. Wind
26 energy must be converted to electricity at or near the point where it is extracted, and there are
27 limited energy storage opportunities available to overcome the intermittency and variability of
28 wind resources. At the current stage of wind energy technology development, wind resources in
29 wind power class 3 and higher are suitable for most utility scale applications (NREL 2014).
30 Wind power class 3 is defined as having a wind speed of 15.7 miles per hour (mph) (7.0 meters
31 per second (m/s)) and a wind density of 500 watts per square meter (W/m^2) at 164 ft (50 m)
32 (NREL 2014). Individual wind turbine capacity increased from 0.71 MW in 1999 to 1.79 MW in
33 2010. The size of turbine most frequently installed in the United States in recent years is the
34 1.5-MW turbine (WAPA and FWS 2013). For the purposes of this analysis, the NRC staff
35 assumes wind turbines with a capacity of 1.79 MW. The capacity factors of land-based wind
36 farms are lower than offshore wind farms (WAPA and FWS 2013). For the wind portion of the
37 combination alternative, the NRC staff assumed a capacity factor of 30 percent, resulting in an
38 estimated total net capacity of 1,813 MWe. Wind turbines must be well-separated from each
39 other to avoid interferences to wind flowing through the wind farm, resulting in wind farms
40 requiring substantial amounts of land. Wind turbines may require as much as 1 to 3 ac (0.4 to
41 1.2 ha) of land for each turbine (WAPA and FWS 2013). Based on the size of the turbines and
42 amount of land required between each turbine, approximately 3,376 turbines and 3,376 to
43 10,127 ac (1,366 to 4,098 ha) would be required for the wind portion of the combination
44 alternative.

45 Wind energy's intermittency affects its viability and value as a baseload power source.
46 However, the variability of wind-generated electricity can be lessened if the proposed wind
47 farms were located at a large distance from one another and allowed to operate as
48 interconnected wind farms, an aggregate controlled from a central point. Distance separation
49 ensures that the two wind farms will not simultaneously experience the same climate, and

1 power will likely be produced at some of the wind farms at any given time (Archer and
2 Jacobson 2007).

3 Solar Photovoltaic Portion of the Combination Alternative

4 The solar portion of the combination alternative would be generated through one or more solar
5 photovoltaic energy facilities located in the ROI. Assuming a capacity factor of 19 percent, the
6 solar energy facilities would need a collective nameplate rating of 1,193 MWe. Solar
7 photovoltaic technologies could be installed on building roofs at existing residential, commercial,
8 or industrial sites or at larger standalone solar facilities.

9 Nationwide, growth in large solar photovoltaic facilities (greater than 5 MW) has resulted in an
10 increase from 70 MW in 2009 to over 700 MW installed capacity in 2011. As of January 2012, it
11 is estimated that more than 11,000 MW of large solar photovoltaic projects have signed power
12 purchase agreements (Mendelsohn et al. 2012). Over 9,000 MW of those solar projects are
13 50 MW or greater, although most are located in the southwestern United States (Mendelsohn
14 et al. 2012). As described in Section 2.2.2, two States in the ROI (Missouri and Illinois) have
15 renewable energy legislation that includes requirements for solar photovoltaic technology.
16 Missouri's renewable portfolio standard includes a provision specifying that 2 percent of the
17 renewable portfolio standard requirement must be met by solar energy by 2021. Illinois'
18 renewable portfolio standard specifies that solar photovoltaic must comprise 6 percent of the
19 annual requirement for the year 2015-2016 and thereafter. As of 2010, only 9 MW of solar
20 energy capacity had been installed in the ROI.

21 Solar photovoltaic resources in the ROI range from 4.0 to 5.0 kilowatt hours per square meter
22 per day (kWh/m²/day). The most viable solar resources are located in Missouri, Iowa, and
23 southern Illinois and Indiana (NREL 2013c). Economically viable solar resources are
24 considered to be 6.75 kWh/m²/day and greater (BLM and DOE 2010). As is the case with wind
25 energy sources, the feasibility of solar energy resources serving as alternative baseload power
26 is dependent on the location, value, accessibility, and constancy of the resource. Solar
27 photovoltaic uses solar panels to convert solar radiation into usable electricity. Solar cells are
28 formed into solar panels by solar manufacturers that can then be linked into photovoltaic arrays
29 to generate electricity. The electricity generated can be stored, used directly, fed into a large
30 electricity grid, or combined with other electricity generators as a hybrid plant. Solar
31 photovoltaics can generate electricity whenever there is sunlight, regardless of whether or not
32 the sun is directly shining on solar panels. Therefore, solar photovoltaic technologies do not
33 need to directly face and track the sun, which has allowed solar photovoltaic systems to have
34 broader geographical use than concentrated solar power (Ardani and Margolis 2011). Because
35 the ROI contains average solar photovoltaic resources and solar photovoltaics is a commercially
36 available option for providing electrical generating capacity, the NRC staff considers the
37 construction of solar photovoltaic facilities to be a reasonable alternative to license renewal
38 when combined with wind and NGCC.

39 For the purposes of this analysis, the NRC staff assumes solar photovoltaic facilities with a
40 capacity factor of 19 percent (Ardani and Margolis 2011). Solar photovoltaic facilities may
41 require 6.2 ac (2.5 ha)/MW of land (NRC 2013a). Although not all of this land would be cleared
42 of vegetation and permanently impacted, it represents the land enclosed in the total site
43 boundary of the solar facility (Ong et al. 2013). For the solar portion of this combination
44 alternative, approximately 7,397 ac (2,993 ha) would be required to support an installed net
45 capacity of 227 MWe. In this analysis, the NRC staff does not speculate on the number and
46 size of individual solar facilities, nor their locations within the ROI. However, as stated above,
47 some of the output could be realized by solar photovoltaic installations on building roofs at
48 existing residential, commercial, or industrial sites or at larger standalone solar facilities. To the

Alternatives Including the Proposed Action

1 extent that rooftop or building-integrated solar photovoltaic installations remain popular, land
2 impacts would be relatively minor. Solar photovoltaic systems do not require water for cooling
3 purposes, but a small amount of water is needed to clean the panels and for potable water for
4 the workforce. Impacts identified in the BLM and DOE's Solar Energy Programmatic
5 Environmental Impact Statement (PEIS) (BLM and DOE 2010, 2012), among other technical
6 reports, provide information used in the analyses presented in the impact sections in Chapter 4.

7 *2.2.2.5 Purchased Power Alternative*

8 In this section, the NRC staff describes purchased power as an alternative to the continued
9 operation of Byron.

10 The impacts from purchased power would depend substantially on the generation technologies
11 used to supply the purchased power. Impacts from operation of other electricity generators
12 would likely occur in the ROI. As discussed in Section 2.2.1, replacement power for Byron
13 would be required in northern Illinois and could come from anywhere within Illinois or adjoining
14 states in either the PJM or MISO Regional Transmission Organizations (RTOs). Given the large
15 geographic area, multiple RTOs within the ROI, and wide-ranging generating facilities, the NRC
16 staff considers purchased power to be a feasible source of baseload power to replace Byron by
17 the time the licenses expire in 2024 and 2026.

18 Purchased power would likely come from the most common types of electricity generation within
19 the ROI: coal, natural gas, nuclear, and wind. All of these power sources are discussed as
20 alternatives to license renewal of Byron and are identified in Sections 2.2.2.2 to 2.2.2.4.
21 Construction and operational impacts from these sources of electricity generation are
22 considered in Chapter 4. Unlike the alternatives considered in Chapter 4, however, facilities
23 from which power would be purchased would not likely be constructed solely to replace Byron.
24 Purchased power may, however, require new transmission lines (which may require new
25 construction) and may also rely on older and less-efficient power plants operating at higher
26 capacities than they currently operate or new facilities that would be constructed. During
27 operations, impacts from nuclear, coal-fired, and natural gas-fired plants, wind, and solar energy
28 projects would be similar to that described under the new nuclear, coal, natural gas, and
29 combination alternatives described in Chapter 4 for all resource areas. Impacts to air quality
30 from the operations of existing coal and natural gas-fired plants would likely be greater than the
31 operations of new plants because older plants are more likely to be less efficient and without
32 modern emissions controls. Impacts to other resource areas from the operation of existing
33 power plant facilities would likely be less than those for new plants because existing facilities
34 would not require new construction.

35 **2.3 Alternatives Considered but Dismissed**

36 Alternatives to Byron license renewal that were considered and eliminated from detailed study
37 are presented in this section. These alternatives were eliminated because of technical resource
38 availability or current commercial limitations. Many of these limitations would continue to exist
39 when the current Byron licenses expire.

40 **2.3.1 Energy Conservation and Energy Efficiency**

41 Energy conservation can include reducing energy demand through behavioral changes or
42 altering the shape of the electricity load and usually does not require the addition of new
43 generating capacity. Conservation and energy efficiency programs are more broadly referred to
44 as demand-side management (DSM).

1 Conservation and energy efficiency programs can be initiated by a utility, by transmission
 2 operators, by the state, or by other load-serving entities. The State of Illinois' renewable
 3 portfolio standard includes an energy efficiency portfolio standard that requires utilities to reduce
 4 electric usage by 2 percent of demand by 2015 (DSIRE 2012a), which is equivalent to
 5 4 million MWh, only 20 percent of the amount that would be required to offset Byron's current
 6 electrical generation.

7 In general, residential electricity consumers have been responsible for the majority of peak load
 8 reductions, and participation in most programs is voluntary. Therefore, the existence of a
 9 program does not guarantee that reductions in electricity demand would occur. The GEIS
 10 concludes that while the energy conservation or energy efficiency potential in the United States
 11 is substantial, there are likely no cases where an energy efficiency or conservation program has
 12 been implemented expressly to replace or offset a large baseload generation station
 13 (NRC 2013a). While significant energy savings are possible in the ROI through DSM and
 14 energy efficiency programs, conservation and energy efficiency programs are not likely to
 15 replace Byron as a standalone alternative, and therefore the NRC staff does not consider
 16 conservation and energy efficiency to be a reasonable alternative to license renewal.

17 **2.3.2 Solar**

18 Solar power, including solar photovoltaic and concentrated solar power technologies, produce
 19 power generated from sunlight. Photovoltaics convert sunlight directly into electricity using solar
 20 cells, made from silicon or cadmium telluride. Concentrating solar power uses heat from the
 21 sun to boil water and produce steam to drive a turbine connected to a generator to produce
 22 electricity (NREL 2013d). To be considered a viable alternative, a solar alternative must replace
 23 the amount of electricity Byron provides. Assuming a capacity factor of 19 percent (Ardani and
 24 Margolis 2011), approximately 12,400 MWe of electricity would need to be generated by solar
 25 energy facilities in the seven-state ROI.

26 In 2011, 14 MWh of electricity was generated from solar energy in the ROI (EIA 2014c). DOE's
 27 National Renewable Energy Laboratory (NREL) reports that the states in the ROI receive solar
 28 insolation of 4.0 to 5.0 kWh/m²/day, which is considered low to average (NREL 2013c). For
 29 utility-scale development, insolation levels below 6.5 kWh/m²/day are not considered
 30 economically viable given current technologies (BLM and DOE 2010). There is more potential
 31 for solar development using local photovoltaic applications, such as rooftop solar panels, than
 32 through utility-scale solar facilities. In addition, a solar facility can only generate electricity when
 33 the sun is shining. Energy storage can be used to overcome intermittency for concentrating
 34 solar power facilities; however, current and foreseeable storage technologies that have been
 35 paired with solar power facilities have a much smaller capacity than would be necessary to
 36 replace Byron. Taking all of the factors above into account, it is unlikely that solar photovoltaic
 37 or concentrated solar power technologies could serve as baseload power in the ROI to replace
 38 Byron's current electricity output. Given the modest levels of solar energy available throughout
 39 the ROI, the lack of substantial installed solar capacity in the ROI and the weather-dependent
 40 intermittency of solar power, the NRC staff concludes that a solar power energy facility in the
 41 ROI would not be a reasonable alternative to license renewal. The NRC staff evaluated an
 42 alternative of solar power in combination with wind and an NGCC plant in Section 2.2.2.4.

43 **2.3.3 Wind**

44 Two states in the ROI have the third- and fourth-largest installed capacity in the Nation: Iowa
 45 with 5,133 MW, followed by Illinois with 3,568 MW (AWEA 2013). The installed wind capacity in
 46 the ROI has been increasing annually by 1,000 MWe to 2,500 MWe in each of the past 6 years,

Alternatives Including the Proposed Action

1 for a total of over 11,000 MWe of additional wind capacity from 2007 to 2012 (DOE 2013a). All
2 of the wind energy facilities and the electricity generation from wind currently being produced in
3 the ROI are land-based. To be considered a viable alternative, a wind alternative must replace
4 the amount of electricity Byron provides. Assuming a capacity factor of 30 percent for
5 land-based wind and 40 percent for offshore wind, a range of 5,665 to 7,553 MWe of electricity
6 would need to be generated by some combination of land-based and offshore wind energy
7 facilities in the seven-state ROI.

8 As is the case with other renewable energy sources, the feasibility of wind resources serving as
9 alternative baseload power is dependent on the location (relative to expected load centers),
10 value, accessibility, and constancy of the resource. Wind energy must be converted to
11 electricity at or near the point where it is extracted, and there are limited energy storage
12 opportunities available to overcome the intermittency and variability of wind resource availability.
13 Although wind power is intermittent and individual facilities are unable to provide baseload
14 power, it has been proposed that multiple interconnected wind installations separated by long
15 distances could function as a virtual power plant and provide baseload power since individual
16 facilities would be exposed to different weather and wind conditions. To date, however, no
17 states or utilities operate arrays of wind installations as virtual power plants.

18 Given the amount of wind capacity necessary to replace Byron and the intermittency of wind
19 power, the NRC staff finds a completely wind-based alternative to be unreasonable. However,
20 the NRC staff also concludes that, when used in combination with other technologies with
21 inherently higher capacity factors, wind energy can provide a viable alternative. The NRC staff
22 evaluated such a possible combination as described in Section 2.2.2.4.

23 *2.3.3.1 Offshore Wind*

24 The United States does not have any offshore wind farms in operation; however, approximately
25 20 projects representing more than 2,000 MW of capacity are in the planning and permitting
26 process as of 2010 (Musial and Ram 2010). Offshore wind projects have been developed in
27 Europe, most of which are located close to shore and in shallow water less than 98.4 ft (30 m) in
28 depth. Total worldwide installed capacity has been estimated at 2,377 MW (Musial and
29 Ram 2010).

30 While wind data suggest there is potential for offshore wind farms in the Great Lakes, project
31 costs likely will limit the future potential of large-scale projects (Tidball et al. 2010). NREL
32 (Tidball et al. 2010) estimated that offshore project costs would run approximately 200 to
33 300 percent higher than land-based systems. In addition, based on current prices for wind
34 turbines, the 20-year levelized cost of electricity produced from an offshore wind farm would be
35 above the current production costs from existing power generation facilities. In addition to cost,
36 other barriers include the immature status of the technology, limited resource area, and high
37 risks and uncertainty (Tidball et al. 2010). As no offshore wind capacity yet exists in either the
38 Great Lakes or on the Atlantic Coast and as none appears likely to exist on a large commercial
39 scale in the Great Lakes by 2024 (given the current state of development), the NRC staff finds
40 that offshore wind will not be a reasonable alternative to Byron.

41 *2.3.3.2 Wind Power with Storage*

42 Energy storage is one possible way to overcome intermittency. Besides pumped hydroelectric
43 facilities, compressed air energy storage (CAES) is the technology most suited for storage of
44 large amounts of energy. In CAES systems, electricity generated during low-demand periods
45 can be stored by using a compressor to pressurize and store air, and during high-demand
46 periods, the compressed air can be used to drive a turbine to generate electricity. A 2011 DOE
47 report analyzed various power generation sources, including wind, coupled with CAES systems

1 (Ilic et al. 2011). The report considered siting criteria, using (1) proximity to natural gas lines,
 2 high voltage transmission, and a market for wholesale electric power and (2) availability of
 3 geology and wind resources. The results show that within the ROI there is potential for one
 4 CAES site in northwestern Iowa. Without detailed wind-speed data, specific site information,
 5 and detailed information on the energy-storage capacity of the potential CAES site, it is difficult
 6 to estimate how much wind capacity would be necessary and whether or not it could provide for
 7 an all-wind alternative. Furthermore, the NRC staff is not aware of a CAES project coupled with
 8 wind generation that is providing baseload power. Therefore, the NRC staff concludes that the
 9 use of CAES in combination with wind turbines to replace the Byron power plant is unlikely.

10 **2.3.3.3 Conclusion**

11 Despite the relatively high reliability demonstrated by modern turbines, the recent technological
 12 advancements in turbine design and wind farm operation, and wind energy’s dramatic market
 13 penetrations of recent years, empirical data on wind farm capacity factors and wind energy’s
 14 limited ability to store power for delayed production of electricity cause the NRC staff to
 15 conclude that wind energy—on shore, off shore, or a combination thereof—could not serve as a
 16 discrete alternative to the baseload power supplied by the Byron reactors. However, the NRC
 17 staff also concludes that, when used in combination with other technologies with inherently
 18 higher capacity factors, wind energy can provide a viable alternative. The NRC staff evaluated
 19 such a possible combination as described in Section 2.2.2.4.

20 **2.3.4 Biomass**

21 Biomass resources used for biomass-fired generation include agricultural residues, animal
 22 manure, wood wastes from forestry and industry, residues from food and paper industries,
 23 municipal green wastes, dedicated energy crop, and methane from landfills (IEA 2007). Using
 24 biomass-fired generation for baseload power depends on the geographic distribution, available
 25 quantities, constancy of supply, and energy content of biomass resources. For this analysis, the
 26 NRC staff assumed that biomass would be combusted for power generation in the electricity
 27 sector. Biomass is also used for space heating in residential and commercial buildings and can
 28 be converted to a liquid form for use in transportation fuels (Haq undated).

29 In the GEIS, the NRC staff indicated a wood waste facility could provide baseload power and
 30 operate with capacity factors between 70 and 80 percent (NRC 2013a). Although the ROI
 31 currently produces electricity from biomass fuels, the plants operating within the ROI generated
 32 less than 1 percent of the total power generation in 2011 (EIA 2014c). Based on the relatively
 33 low electricity generation currently produced at biomass plants, it is unlikely that these plants, or
 34 the construction of several new biomass plants, could increase capacity by adding 2,336 MWe
 35 of electricity from biomass-fired generation by the time Byron’s licenses expire in 2024 and
 36 2026.

37 For utility-scale biomass electricity generation, the NRC staff assumes that the technologies
 38 used for biomass conversion would be similar to fossil fuel plants including the direct
 39 combustion of biomass in a boiler to produce steam (NRC 2013a). Biomass generation is
 40 generally more cost-effective when cofired with coal plants (IEA 2007). Biomass-fired
 41 generation plants generally are small and can reach capacities of 50 MWe, meaning that more
 42 than 40 new facilities would be required before the Byron licenses expire. After reevaluating
 43 current technologies, the NRC staff finds biomass-fired alternatives as still unable to reliably
 44 replace the Byron capacity. For this reason, the NRC staff does not consider biomass to be a
 45 reasonable alternative to Byron license renewal.

Alternatives Including the Proposed Action

1 **2.3.5 Hydroelectric**

2 Hydroelectric power uses the force of water to turn turbines which spin a generator to produce
3 electricity. In a run-of-the-river system, the force of a river current provides the force to create
4 the needed pressure for the turbine. In a storage system, water is accumulated in reservoirs
5 created by dams and is released as needed to generate electricity.

6 DOE's Idaho National Environmental Engineering Laboratory (INEEL) (now Idaho National
7 Laboratory) completed a comprehensive survey of hydropower resources in 1997. The ROI has
8 hydroelectric generating potential of 1,954 MW, adjusting for environmental, legal, and
9 institutional constraints (Conner et al. 1998). These constraints could include (1) scenic,
10 cultural, historical, and geological values; (2) Federal and state land use; and (3) legal
11 protection issues, such as Wild and Scenic legislation and Threatened or Endangered Fish and
12 Wildlife legislative protection. A separate assessment by DOE of nonpowered dams (dams that
13 do not produce electricity) concluded that there is potential for 4,185 MW of electricity in the ROI
14 (ORNL 2012). These nonpowered dams serve various purposes such as providing water
15 supply to inland navigation.

16 EIA reported that the states composing the ROI generated 2,262 MW electricity from
17 hydroelectric power in 2012 (EIA 2014b). In order to replace Byron's current output,
18 hydroelectric generation across the ROI would need to double by 2024. Although there is
19 potential for anywhere between 1,954 MW and 4,185 MW of hydroelectric power, it is unlikely
20 that the maximum levels of development would occur across the entire ROI by the time Byron's
21 licenses expire in 2024 and 2026 given that generating capacity of hydroelectric power is
22 projected to continue decreasing through 2040 (EIA 2013b). Given the decrease in projected
23 power generation from hydroelectric facilities, the NRC staff does not consider hydroelectric
24 power to be a reasonable alternative to license renewal.

25 **2.3.6 Wave and Ocean Energy**

26 Waves, currents, and tides are often predictable and reliable, making them attractive candidates
27 for potential renewable energy generation. Four major technologies may be suitable to harness
28 wave energy: terminator devices that range from 500 kW to 2 MW, attenuators, point
29 absorbers, and overtopping devices (BOEM undated). Point absorbers and attenuators use
30 floating buoys to convert wave motion into mechanical energy, driving a generator to produce
31 electricity. Overtopping devices trap a portion of a wave at a higher elevation than the sea
32 surface; waves then enter a tube, compressing air that is used to drive a generator that
33 produces electricity (NRC 2013a). Some designs are undergoing demonstration testing at
34 commercial scales, but none are currently used to provide baseload power (BOEM undated).

35 The Great Lakes do not experience large tides, and there is limited energy output for wave
36 technologies in the Great Lakes. The Electric Power Resource Institute (EPRI) published a
37 document that assessed ocean wave energy resources in the United States. The Great Lakes
38 were not included in the analysis, suggesting that the resource potential is not great enough to
39 use on a commercial scale (EPRI 2011). Consequently, the limited resource availability and
40 infancy of the technologies in the Great Lakes support the NRC staff's conclusion that wave and
41 ocean energy technologies are not feasible substitutes for Byron.

42 **2.3.7 Fuel Cells**

43 Fuel cells oxidize fuels without combustion and its environmental side effects. Fuel cells use a
44 fuel (e.g., hydrogen) and oxygen to create electricity through an electrochemical process. The
45 only byproducts (depending on fuel characteristics) are heat, water, and carbon dioxide

1 (depending on hydrogen fuel type) (DOE undated a). Hydrogen fuel can come from a variety of
2 hydrocarbon resources. Natural gas is a typical hydrogen source.

3 Fuel cells are not economically or technologically competitive with other alternatives for
4 electricity generation. EIA projects that fuel cells may cost \$6,835 per installed kW (total
5 overnight capital costs, 2010 dollars), which is high compared to other alternative technologies
6 analyzed in this section (EIA 2010). More importantly, fuel cell units are likely to be small in size
7 (approximately 10 MWe). It would be extremely costly to replace the power Byron provides; it
8 would require approximately 230 units and modifications to the existing transmission system.
9 Given the immature status of fuel cell technology and high cost, the NRC staff does not consider
10 fuel cells to be a reasonable alternative to Byron license renewal.

11 **2.3.8 Delayed Retirement**

12 A delayed retirement alternative would consider deferring the retirement of generating facilities
13 in Illinois and its six adjoining states that include MISO and PJM RTOs.

14 To maintain reliable operations, electric systems must be able to meet peak load requirements.
15 To ensure sufficient capacity, this must also include a planning reserve margin (FERC 2013).
16 The projected MISO reserve margin for 2021 is 18.6 percent, which exceeds the reserve margin
17 requirement of 17.4 percent. However, pending EPA regulations may lead to increased coal
18 plant retirements at a faster pace than projected. In that case, 3,000 MW to 12,600 MW of plant
19 retirements could decrease the projected reserves anywhere from 16.22 to 6.9 percent, well
20 below the reserve margin requirement (MISO 2011).

21 PJM is facing similar constraints due, in large part, to retirements of coal plants given air quality
22 regulations (Ott 2013a). This indicates an emerging reliability problem potentially affecting
23 major population centers within the PJM region in the near future (Ott 2013a). Because the
24 current generation mix has not resulted in the long-term commitment of generation needed for
25 reliability, generation retirements that have occurred with short notice have created
26 unanticipated reliability problems for PJM (Ott 2013a).

27 The 2014 Annual Energy Outlook predicts that there will be more coal plant retirements before
28 2016 than previously predicted. These accelerated retirements are driven by low natural gas
29 prices, slow growth in electricity demand, and the requirements of the Mercury and Air Toxics
30 Standards (MATS) that will require significant reductions in plant emissions (EIA 2014a).
31 Exelon also expects increased generation retirements for a variety of reasons, including
32 increased operating costs for older facilities, increased environmental regulations and
33 competition, and decreased load (Exelon undated). As generators are required to adhere to
34 future regulations, some power plants may opt for early retirement of older units rather than
35 incur the cost for compliance. Exelon has further stated that some of their nuclear fleet may be
36 retired early because of low wholesale energy prices and current energy policy
37 (Bloomberg 2014). Because of the uncertain regulatory environment and concerns expressed
38 by MISO and PJM concerning the retirement pace of coal power plants, the NRC staff does not
39 consider delayed retirement to be a reasonable alternative to Byron license renewal.

40 **2.3.9 Geothermal**

41 Geothermal technologies extract the heat contained in geologic formations to produce steam to
42 drive a conventional steam turbine generator. Facilities producing electricity from geothermal
43 energy have demonstrated capacity factors of 95 percent or greater, making geothermal energy
44 a potential source of baseload electric power. However, the feasibility of geothermal power
45 generation to provide baseload power depends on the regional quality and accessibility of

Alternatives Including the Proposed Action

1 geothermal resources. Utility-scale geothermal energy generation requires geothermal
2 reservoirs with a temperature above 200 °F (93 °C). Utility-scale power plants range from small
3 300 kilowatts electric (kWe) to 50 MWe and greater (TEEIC undated). Geothermal resources
4 are concentrated in the western United States. Specifically, these resources are found in
5 Alaska, Arizona, California, Colorado, Hawaii, Idaho, Montana, Nevada, New Mexico, Oregon,
6 Utah, Washington, and Wyoming (USGS 2008). In general, most assessments of geothermal
7 resources have been concentrated on these western states. The DOE has also quantified
8 geothermal resources in Minnesota and Vermont but not in any of the states that compose the
9 ROI (DOE 2013c). Geothermal resources are used in the ROI for heating and cooling
10 purposes, but no electricity is currently being produced from geothermal resources in the ROI
11 (EIA 2014c). Given the low resource potential in the ROI, the NRC staff does not consider
12 geothermal to be a reasonable alternative to license renewal.

13 **2.3.10 Municipal Solid Waste**

14 Energy recovery from municipal solid waste converts nonrecyclable waste materials into usable
15 heat, electricity, or fuel through combustion (EPA 2013b). The three types of combustion
16 technologies include mass burning, modular systems, and refuse-derived fuel systems
17 (EPA 2013a). Mass burning is the method used most frequently in the United States. The heat
18 released from combustion is used to convert water to steam, which is used to drive a turbine
19 generator to produce electricity. Ash is collected and taken to a landfill and particulates are
20 captured through a filtering system (EPA 2013a). As of 2010, approximately 86 waste-to-
21 energy plants are in operation in 25 states, processing more than 28 million tons of waste per
22 year (EPA 2013b). These waste-to-energy plants have an aggregate capacity of 2,720 MWe,
23 and although some plants have expanded to handle additional waste and produce more energy,
24 no new plants have been built in the United States since 1995 (EPA 2013b). The average
25 waste-to-energy plant produces about 50 MWe, with some reaching 77 MWe, and can operate
26 at capacity factors greater than 90 percent (Michaels 2010). Indiana has one waste recovery
27 facility that produces steam; Iowa has one waste-to-energy facility that produces 10 MW of
28 electricity; Michigan has three facilities that produce 89.7 MW of electricity; and Wisconsin has
29 two facilities that generate 32.3 MW of electricity (Michaels 2010). In total, as of 2010, the ROI
30 had a municipal solid waste generating capacity of 132 MW. More than 46 average-sized plants
31 would be necessary to provide the same level of output as Byron, almost doubling the national
32 waste-to-energy generation.

33 The decision to burn municipal waste to generate energy is usually driven by the need for an
34 alternative to landfills rather than energy considerations. Given the improbability that additional
35 stable supplies of municipal solid waste would be available to support approximately 46 new
36 facilities and that so few existing plants operate in the ROI, the NRC staff does not consider
37 municipal solid waste combustion to be a reasonable alternative to Byron license renewal.

38 **2.3.11 Petroleum**

39 In the ROI, oil-fired generation in 2012 had a generating capacity of 4,986 MW (EIA 2014b).

40 The variable costs of oil-fired generation tend to be greater than those of the nuclear or
41 coal-fired operations, and oil-fired generation tends to have greater environmental impacts than
42 natural gas-fired generation. The high cost of oil has resulted in a steady decline in its use for
43 electricity generation (EIA 2013a). Given the high cost of oil and the small generating capacity
44 from oil-fired power plants in the ROI, the NRC staff does not consider oil-fired generation a
45 reasonable alternative to Byron license renewal.

1 **2.3.12 SCPC**

2 In general, SCPC power plants are feasible, commercially available options for providing
 3 electrical generating capacity. Baseload coal units have proven their reliability and can sustain
 4 capacity factors as high as 79 percent. Pulverized coal power generation uses crushed coal
 5 that is fed into a boiler where it is burned to create heat. The heat produces steam that is used
 6 to spin one or more turbines to generate electricity. Among the technologies available,
 7 pulverized coal boilers producing supercritical steam (SCPC boilers) are increasingly common
 8 for new coal-fired plants given their high operating temperatures and pressures that increase
 9 thermal efficiencies and overall reliability. SCPC facilities consume less fuel per unit output,
 10 reducing environmental impacts (NETL undated).

11 As described in Section 2.2.3, EPA has issued a proposed rule for carbon pollution that would
 12 apply to new fossil fuel-fired power plants, including SCPC facilities. The action proposes
 13 performance standards and has identified a CCS system as the best method of emission
 14 reduction. The proposed emission limit for these sources is 1,100 lb CO₂/MWh. EIA modeling
 15 projects that if the proposed rule were implemented, few, if any, new coal-fired units would be
 16 built and that those that are built would include CCS (79 FR 1430). If this rule becomes final,
 17 any new coal-fired power plants would likely require CCS in order to achieve the 1,100 lb
 18 CO₂/MWh emission limit.

19 In addition, given known technology and technological and demographic trends, EIA predicts
 20 that by 2040 natural gas will surpass coal as the largest share of U.S. electric power generation
 21 (EIA 2013a). This does not consider the proposed EPA rule described above, but indicates a
 22 general trend away from coal-fired facilities in favor of natural gas-fired power plants due to
 23 falling natural gas prices. MISO projects that the pending EPA regulations could lead to
 24 increased coal plant retirements, and estimates retirements between 3,000 MW to 12,600 MW,
 25 which could have a large impact on MISO's reserve margin in the future (MISO 2011).

26 Although SCPC plants are currently the most widely used source of electricity generation within
 27 the ROI, given the potential for stringent air quality regulations and trends towards natural
 28 gas-fired power plants, the NRC staff does not consider SCPC to be a reasonable alternative to
 29 Byron license renewal. Instead, the NRC staff describes an IGCC plant under the coal
 30 alternative in Section 2.2.2.2.

31 **2.4 Comparison of Alternatives**

32 In this chapter, the NRC staff considered the following alternatives to Byron license renewal:
 33 new nuclear generation; IGCC generation; NGCC generation; a combination alternative of
 34 natural gas, wind, and solar; and purchased power. The no-action-by-NRC alternative and its
 35 effects also were considered. The impacts for all alternatives to Byron license renewal are
 36 discussed in Chapter 4 and summarized in Table 2–2 below.

37 The environmental impacts of the proposed action (issuing renewed Byron operating licenses)
 38 would be SMALL for all impact categories. The environmental impacts from all other
 39 alternatives would be larger than the proposed license renewal, as indicated in Table 2–2.

Table 2-2. Summary of Environmental Impacts of Proposed Action and Alternatives

Impact Area (Resource)	Byron License Renewal (Proposed Action)	No-Action	New Nuclear Alternative	IGCC Alternative	NGCC Alternative	Combination Alternative (NGCC, Wind, Solar)	Purchased Power
Land Use and Visual Resources							
Land Use	SMALL	SMALL	SMALL	SMALL TO MODERATE	SMALL	SMALL TO MODERATE	SMALL
Visual Resources	SMALL	SMALL	SMALL TO MODERATE	SMALL TO MODERATE	SMALL TO MODERATE	SMALL TO MODERATE	SMALL
Air Quality and Noise							
Air Quality	SMALL	SMALL	SMALL	MODERATE	MODERATE	SMALL TO MODERATE	SMALL TO MODERATE
Noise	SMALL	SMALL	SMALL	SMALL TO MODERATE	SMALL	SMALL TO MODERATE	SMALL TO MODERATE
Geologic Environment	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Water Resources							
Surface Water Resources	SMALL	SMALL	SMALL TO MODERATE	SMALL TO MODERATE	SMALL	SMALL	SMALL TO MODERATE
Groundwater Resources	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Terrestrial Resources	SMALL	SMALL	SMALL TO MODERATE	MODERATE	SMALL TO MODERATE	SMALL TO MODERATE	SMALL
Aquatic Resources	SMALL	SMALL	SMALL	SMALL TO MODERATE	SMALL TO MODERATE	SMALL	SMALL
Special Status Species and Habitats	NO EFFECT	SEE NOTE ¹	SEE NOTE ¹	SEE NOTE ¹	SEE NOTE ¹	SEE NOTE ¹	SEE NOTE ¹
Historic and Cultural Resources	SEE NOTE ²	NO EFFECT	SMALL	SMALL	SMALL TO MODERATE	SMALL TO MODERATE	SMALL TO MODERATE

Impact Area (Resource)	Byron License Renewal (Proposed Action)	No-Action	New Nuclear Alternative	IGCC Alternative	NGCC Alternative	Combination Alternative (NGCC, Wind, Solar)	Purchased Power
Socioeconomics							
Socioeconomics	SMALL	SMALL TO LARGE	SMALL TO MODERATE	SMALL TO MODERATE	SMALL TO MODERATE	SMALL	SMALL TO LARGE
Transportation	SMALL	SMALL	SMALL TO MODERATE	SMALL TO MODERATE	MODERATE TO LARGE	SMALL TO MODERATE	SMALL TO LARGE
Human Health	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Environmental Justice	SEE NOTE ³	SEE NOTE ⁴	SEE NOTE ⁵	SEE NOTE ⁶	SEE NOTE ⁷	SEE NOTE ⁸	SEE NOTE ⁹
Waste Management and Pollution Prevention							
Waste Management and Pollution Prevention	SMALL	SMALL	SMALL	SMALL TO MODERATE	SMALL	SMALL	SMALL TO MODERATE

Notes:

- The magnitude of impacts could vary widely based on site selection and the presence or absence of special status species and habitats when the alternative is implemented; thus, the NRC staff cannot forecast a level of impact for this alternative.
- Based on (1) there being currently no NRHP-eligible historic properties in the APE, (2) tribal input, (3) Exelon's draft CRMP, (4) the fact that no license renewal-related physical changes or ground-disturbing activities would occur, (5) IHFA input, and (6) cultural resource assessment, license renewal would not affect any known historic properties (36 CFR Section 800.4(d)(1)).
- Continued operation of Byron would not have disproportionately high and adverse human health and environmental effects on these populations.
- The No-Action Alternative could disproportionately affect minority and low-income populations that may have become dependent on the public services in Ogle County.
- The new nuclear alternative would not have disproportionately high and adverse human health and environmental effects on minority and low-income populations.
- The IGCC Alternative would not have disproportionately high and adverse human health and environmental effects on minority and low-income populations.
- The NGCC Alternative would not have disproportionately high and adverse human health and environmental effects on minority and low-income populations.
- The Combination Alternative would not have disproportionately high and adverse human health and environmental effects on minority and low-income populations.
- The Purchased Power Alternative could be disproportionately affect low-income populations by increased utility bills because of the cost of purchased power. However, programs, such as the low income home energy assistance program in Illinois, are available to assist low-income families in paying for increased electrical costs.

Alternatives Including the Proposed Action

1 In conclusion, the environmentally preferred alternative is the granting of a renewed license for
2 Byron. All other alternatives capable of meeting the needs currently served by Byron entail
3 potentially greater impacts than the proposed action of renewing the license for Byron. To make
4 up the lost generation if a renewed license is not issued (the no-action alternative), one or a
5 combination of alternatives would be implemented, all of which have greater impacts than the
6 proposed action. Hence, the NRC staff concludes that the no-action alternative will have
7 environmental impacts greater than or equal to the proposed license renewal action.

8 **2.5 References**

- 9 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic licensing of
10 production and utilization facilities.”
- 11 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
12 protection regulations for domestic licensing and related regulatory functions.”
- 13 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for
14 renewal of operating licenses for nuclear power plants.”
- 15 79 FR 1430. U.S. Environmental Protection Agency. “Standards of performance for greenhouse
16 gas emissions from new stationary sources: electric utility generating units.” *Federal*
17 *Register* 79(5):1430–1519. January 8, 2014.
- 18 AmerenUE. 2009. *Callaway Plant Unit 2 Combined License Application Part 3: Environmental*
19 *Report*. Revision 1. February 2009. 1,444 p. ADAMS No. ML090710402.
- 20 Archer CL, Jacobson MZ. 2007. Supplying baseload power and reducing transmission
21 requirements by interconnecting wind farms. *Journal of Applied Meteorology and*
22 *Climatology* 46(11):1701–1717. Available at
23 <http://www.stanford.edu/group/efmh/winds/aj07_jamc.pdf> (accessed 24 April 2014).
- 24 Ardani K, Margolis R. 2011. *2010 Solar Technologies Market Report*. Golden, CO: National
25 Renewable Energy Laboratory. November 2011. 136 p. Available at
26 <<http://www.nrel.gov/docs/fy12osti/51847.pdf>> (accessed 1 December 2013).
- 27 [AWEA] American Wind Energy Association. 2013. *AWEA U.S. Wind Industry First Quarter*
28 *2013 Market Report Executive Summary*. April 30, 2013. 7 p. Available at
29 <http://awea.files.cms-plus.com/FileDownloads/pdfs/AWEA%20US%20Wind%20Industry%201Q%202013%20Market%20Report_Executive%20Summary.pdf> (accessed 26 November 2013).
- 30
31
- 32 [BLM and DOE] U.S. Department of the Interior Bureau of Land Management and
33 U.S. Department of Energy. 2010. *Draft Programmatic Environmental Impact Statement for*
34 *Solar Energy Development in Six Southwestern States*. DES 10-59; DOE/EIS-0403, Volumes 1
35 to 8. December 2010. 11,145 p. Available at
36 <<http://www.solareis.anl.gov/documents/dpeis/index.cfm#vol1>> (accessed 26 November 2013).
- 37 [BLM and DOE] U.S. Department of the Interior Bureau of Land Management and
38 U.S. Department of Energy. 2012. *Final Programmatic Environmental Impact Statement (PEIS)*
39 *for Solar Energy Development in Six Southwestern States*. FES 12-24; DOE/EIS-0403,
40 Volumes 1 to 7. July 2012. 3,596 p. Available at
41 <<http://www.solareis.anl.gov/documents/fpeis/index.cfm>> (accessed 26 November 2013).
- 42 [Bloomberg] Bloomberg Businessweek. 2014. “AP Digital: Nuclear power company to consider
43 plant closures.” February 14, 2014. Available at <<http://www.businessweek.com/ap/2014-02-14/nuclear-power-company-to-consider-plant-closures>> (accessed 18 February 2014).
- 44

- 1 [BOEM] Bureau of Ocean Energy Management. undated. "Ocean Wave Energy." Available at
 2 <[http://www.boem.gov/Renewable-Energy-Program/Renewable-Energy-Guide/
 3 Ocean-Wave-Energy.aspx](http://www.boem.gov/Renewable-Energy-Program/Renewable-Energy-Guide/Ocean-Wave-Energy.aspx)> (accessed 20 January 2014).
- 4 Channell J, Lam T, Pourreza S. 2012. *Shale & renewables: a symbiotic relationship*. CITI
 5 Research. September 12, 2012. 88 p. Available at <[http://www.ourenergypolicy.org/
 6 wp-content/uploads/2013/04/citigroup-renewables-and-natgas-report.pdf](http://www.ourenergypolicy.org/wp-content/uploads/2013/04/citigroup-renewables-and-natgas-report.pdf)> September 12, 2012.
 7 (accessed 26 November 2013).
- 8 [ComEd] Commonwealth Edison Company. 2013. "ComEd—An Exelon Company: Company
 9 Profile." Available at
 10 <<https://www.comed.com/about-us/company-information/Pages/profile.aspx>> (accessed
 11 20 January 2014).
- 12 Conner AM, Francfort JE, Rinehart BN. 1998. *U.S. Hydropower Resource Assessment, Final
 13 Report*. Idaho Falls, ID: Idaho National Engineering and Environmental Laboratory.
 14 DOE/ID-10430.2. December 1998. 49 p. Available at
 15 <<http://hydropower.inl.gov/resourceassessment/pdfs/doeid-10430.pdf>>.
- 16 [DOE] U.S. Department of Energy. 2010a. *Kemper County Integrated Gasification
 17 Combined-Cycle (IGCC) Project, Final Environmental Impact Statement (EIS)*. Washington, DC:
 18 DOE. DOE/EIS-0409, Volume 1. May 2010. 671 p. Available at
 19 <[http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/
 20 EIS-0409-FEIS-01-2010.pdf](http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/EIS-0409-FEIS-01-2010.pdf)> (accessed 26 November 2013).
- 21 [DOE] U.S. Department of Energy. 2010b. Final Environmental Assessment for Department of
 22 Energy Loan Guarantee for the Agua Caliente Solar Project in Yuma County, Arizona.
 23 DOE/EA-1797. November 2010. Available at
 24 <http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/EA-1797-FEA-2010.pdf>
 25 (accessed 9 July 2014).
- 26 [DOE] U.S. Department of Energy. 2013a. "WINDEXchange: U.S. Installed Wind Capacity."
 27 Available at <http://www.windpoweringamerica.gov/wind_installed_capacity.asp> (accessed
 28 15 January 2014).
- 29 [DOE] U.S. Department of Energy. 2013c. "State Geothermal Resource Assessment and Data
 30 Collection Efforts." February 22, 2013. Available at
 31 <http://www1.eere.energy.gov/geothermal/resource_assessments.html> (accessed
 32 20 January 2014).
- 33 [DOE] U.S. Department of Energy. undated a. "Fuel Cell—Basics." Available at
 34 <<http://energy.gov/eere/fuelcells/fuel-cells-basics>> (accessed 21 January 2014).
- 35 [DOE] U.S. Department of Energy. undated b. "Small Modular Nuclear Reactors." Available at
 36 <<http://energy.gov/ne/nuclear-reactor-technologies/small-modular-nuclear-reactors>> (accessed
 37 20 January 2014).
- 38 [DSIRE] Database of State Incentives for Renewables & Efficiency. 2012a. "Illinois Renewable
 39 Portfolio Standard." September 7, 2012. Available at
 40 <http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=IL04R> (accessed
 41 26 November 2013).
- 42 [DSIRE] Database of State Incentives for Renewable Energy. 2012b. "Database of State
 43 Incentives for Renewables and Efficiency. Iowa Incentives/Policies for Renewables and
 44 Efficiency: Alternative Energy Law." Available at
 45 <http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=IA01R&re=1&ee=0>
 46 (accessed 26 November 2013).

Alternatives Including the Proposed Action

- 1 [DSIRE] Database of State Incentives for Renewables & Efficiency. 2012c. "Wisconsin
2 Renewable Portfolio Standard." December 14, 2012. Available at
3 <http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=WI05R> (accessed
4 26 November 2013).
- 5 [DSIRE] Database of State Incentives for Renewable Energy. 2012d. "Database of State
6 Incentives for Renewables and Efficiency. Indiana Incentives/Policies for Renewables and
7 Efficiency: Clean Energy Portfolio Goal." Available at
8 <http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=IN12R&re=0&ee=0>
9 (accessed November 26, 2013).
- 10 [DSIRE] Database of State Incentives for Renewables & Efficiency. 2013a. "Michigan
11 Renewable Energy Standard." February 5, 2013. Available at
12 <http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=MI16R> (accessed
13 26 November 2013).
- 14 [DSIRE] Database of State Incentives for Renewables & Efficiency. 2013b. "Missouri
15 Renewable Electricity Standard." July 29, 2013. Available at
16 <http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=MO08R> (accessed
17 26 November 2013).
- 18 Duke Energy. 2013. "Project Overview." Available at
19 <<http://www.duke-energy.com/about-us/edwardsport-overview.asp>> (accessed
20 26 November 2013).
- 21 [EIA] Energy Information Administration. 2010. "Updated Capital Cost Estimates for Electricity
22 Generation Plants." November 2010. Available at
23 <http://www.eia.gov/oiaf/beck_plantcosts/index.html> (accessed 20 January 2014).
- 24 [EIA] Energy Information Administration. 2012b. "Voluntary Reporting of Greenhouse Gases
25 Program—Emission Factors and Global Warming." Available at
26 <http://www.eia.gov/oiaf/1605/emission_factors.html> (accessed 26 November 2013).
- 27 [EIA] Energy Information Administration. 2013a. *Annual Energy Outlook 2013 with Projections
28 to 2040*. DOE/EIA 0383 (2013). Washington, DC: EIA. April 26, 2013. 244 p. Available at
29 <[http://www.eia.gov/forecasts/aeo/pdf/0383\(2013\).pdf](http://www.eia.gov/forecasts/aeo/pdf/0383(2013).pdf)> (accessed 26 November 2013).
- 30 [EIA] Energy Information Administration. 2013b. "Annual Energy Outlook 2014 Early Release."
31 December 16, 2013. Available at <<http://www.eia.gov/forecasts/aeo/er/index.cfm>> (accessed
32 13 January 2014).
- 33 [EIA] Energy Information Administration. 2013c. "U.S. Energy Information Adm—FAQ—How
34 much coal, natural gas, or petroleum is used to generate a kilowatthour of electricity?" Available
35 at <<http://www.eia.gov/tools/faqs/faq.cfm?id=667&t=2>> (accessed 26 November 2013).
- 36 [EIA] Energy Information Administration. 2013d. "U.S. Energy Informat—Today in Energy—
37 Natural gas-fired combustion turbines are generally used to meet peak electricity load."
38 October 1, 2013. Available at <<http://www.eia.gov/todayinenergy/detail.cfm?id=13191>>
39 (accessed 26 November 2013).
- 40 [EIA] Energy Information Administration. 2014a. "U.S. Energy Informat—Today in Energy—
41 AEO2014 projects more coal-fired power plant retirements by 2016 than have been scheduled."
42 February 14, 2014. Available at
43 <<http://www.eia.gov/todayinenergy/detail.cfm?id=15031&src=email>> (accessed
44 18 February 2014).

- 1 [EIA] Energy Information Administration. 2014b. *State Electricity Profiles 2011*. Washington, DC:
 2 EIA. Available at <<http://www.eia.gov/electricity/state/archive/sep2011.pdf>> (accessed
 3 17 September 2014).
- 4 [EIA] Energy Information Administration. 2014c. *State Electricity Profiles 2012*. Washington, DC:
 5 EIA. Available at <[http://www.eia.gov/electricity/state/\[state name\]/index.cfm](http://www.eia.gov/electricity/state/[state name]/index.cfm)> (accessed
 6 17 September 2014).
- 7 [EPA] U.S. Environmental Protection Agency. 2013a. "Municipal Solid Waste: Basic Information
 8 about Energy Recovery from Waste." Available at
 9 <<http://www.epa.gov/osw/nonhaz/municipal/wte/basic.htm>> (accessed 5 December 2013).
- 10 [EPA] U.S. Environmental Protection Agency. 2013b. "Municipal Solid Waste: Energy Recovery
 11 from Waste." Available at <<http://www.epa.gov/osw/nonhaz/municipal/wte/>> (accessed
 12 5 December 2013).
- 13 [EPRI] Electric Power Research Institute. 2011. *Mapping and Assessment of the United States
 14 Ocean Wave Energy Resource*. Palo Alto, CA: EPRI. 1024637. December 2011. 176 p.
 15 Available at <<http://www1.eere.energy.gov/water//pdfs/mappingandassessment.pdf>> (accessed
 16 20 January 2014).
- 17 [Exelon] Exelon Generation Company, LLC. undated. *PJM TOA-AC July Meeting, At-Risk
 18 Generation Retirement*. 6 p. Available at <[http://www.pjm.com/~media/
 19 committees-groups/committees/toa-ac/20100715/
 20 20100715-item-04-generation-retirements.ashx](http://www.pjm.com/~media/committees-groups/committees/toa-ac/20100715/20100715-item-04-generation-retirements.ashx)> (accessed 6 December 2013).
- 21 [Exelon] Exelon Generation Company, LLC. 2013a. *Byron and Braidwood Stations, Units 1 and
 22 2, License Renewal Application*. Kennett Square, PA: Exelon. May 29, 2013. 3,503 p. ADAMS
 23 No. ML131550528.
- 24 [Exelon] Exelon Generation Company, LLC. 2013b. *License Renewal Application, Byron and
 25 Braidwood Stations, Units 1 and 2*. Kennett Square, PA: Exelon. June 3, 2013. 3,749 p. ADAMS
 26 No. ML131620554.
- 27 [FERC] Federal Energy Regulatory Commission. 2013. *Centralized Capacity Market Design
 28 Elements*. Commission Staff Report AD13-7-000. August 23, 2013. 34 p. Available at
 29 <<http://www.ferc.gov/CalendarFiles/20130826142258-Staff%20Paper.pdf>> (accessed
 30 20 January 2014).
- 31 Haq Z. undated. *Biomass for Electricity Generation*. Energy Information Administration. 18 p.
 32 Available at <<http://www.eia.gov/oiaf/analysispaper/biomass/pdf/biomass.pdf>> (accessed
 33 3 December 2013).
- 34 [IEA] International Energy Agency. 2007. *Biomass for power generation and CHP*. IEA Energy
 35 Technology Essentials ETE03. Available at <<http://www.iea.org/techno/essentials3.pdf>>
 36 (accessed 3 December 2013).
- 37 [ILGA] Illinois General Assembly. 2011. Illinois Senate Bill 1652, Section 5, Illinois Power
 38 Agency Act. Available at <<http://www.ilga.gov/legislation/97/SB/09700SB1652enr.htm>>
 39 (accessed 26 November 2013).
- 40 Ilic J, Prica M, Rabiei S, Goellner J, Wilson D, Shih C (Booz Allen Hamilton, Inc.). 2011.
 41 *Technical and Economic Analysis of Various Power Generation Resources Coupled with CAES
 42 Systems*. National Energy Technology Laboratory. May 17, 2011. DOE/NETL-2011/1472. 96 p.
 43 Available at
 44 <[http://www.netl.doe.gov/File%20Library/Research/Energy%20Analysis/Publications/
 45 HybridGeneration05242011.pdf](http://www.netl.doe.gov/File%20Library/Research/Energy%20Analysis/Publications/HybridGeneration05242011.pdf)> (accessed 26 November 2013).

Alternatives Including the Proposed Action

- 1 Mendelsohn M, Lowder T, Canavan B. 2012. *Utility-Scale Concentrating Solar Power and*
2 *Photovoltaics Projects: A Technology and Market Overview*. Golden, CO: National Renewable
3 Energy Laboratory. NREL/TP-6A20-51137. April 2012. 65 p. Available at
4 <<http://www.nrel.gov/docs/fy12osti/51137.pdf>> (accessed 20 January 2014).
- 5 Michaels T. 2010. *The 2010 ERC Directory of Waste-to-Energy Plants*. Washington, DC:
6 Energy Recovery Council. November 12, 2010. 32 p. Available at
7 <http://www.energyrecoverycouncil.org/userfiles/file/ERC_2010_Directory.pdf> (accessed
8 5 December 2013).
- 9 [MISO] Midcontinent Independent System Operator, Inc. 2011. *2011 Long Term Resource*
10 *Assessment*. 34 p. Available at
11 <[https://www.misoenergy.org/Library/Repository/Study/Seasonal%20Assessments/](https://www.misoenergy.org/Library/Repository/Study/Seasonal%20Assessments/2011%20Long-Term%20Resource%20Assessment.pdf)
12 [2011%20Long-Term%20Resource%20Assessment.pdf](https://www.misoenergy.org/Library/Repository/Study/Seasonal%20Assessments/2011%20Long-Term%20Resource%20Assessment.pdf)> (accessed 26 November 2013).
- 13 [MISO-PJM] MISO and PJM Interconnection. undated. "Joint and Common Market." Available at
14 <<http://www.miso-pjm.com/>> (accessed 19 May 2013).
- 15 Musial W (NREL (National Renewable Energy Laboratory)), Ram B (Energetics). 2010.
16 *Large-Scale Offshore Wind Power in the United States: Assessment of Opportunities and*
17 *Barriers*. Golden, CO: NREL. NREL/TP-500-40745. September 2010. 240 p. Available at
18 <<http://www.nrel.gov/docs/fy10osti/40745.pdf>> (accessed 26 November 2013).
- 19 [NETL] National Energy Technology Laboratory. 2007. *Natural Gas Combined-Cycle Plant*. 4 p.
20 Available at
21 <http://www.netl.doe.gov/KMD/cds/disk50/NGCC%20Plant%20Case_FClass_051607.pdf>
22 (accessed 20 January 2014).
- 23 [NETL] National Energy Technology Laboratory. 2013a. *Cost and Performance Baseline for*
24 *Fossil Energy Plants, Volume 1: Bituminous Coal and Natural Gas to Electricity*. Revision 2a.
25 DOE/NETL-2010/1397, September 2013. 626 p. Available at
26 <[http://www.netl.doe.gov/File%20Library/research/energy%20analysis/publications/](http://www.netl.doe.gov/File%20Library/research/energy%20analysis/publications/BitBase_FinRep_Rev2.pdf)
27 [BitBase_FinRep_Rev2.pdf](http://www.netl.doe.gov/File%20Library/research/energy%20analysis/publications/BitBase_FinRep_Rev2.pdf)> (accessed 26 November 2013).
- 28 [NETL] National Energy Technology Laboratory. 2013b. "Project Examples." Available at
29 <[http://www.netl.doe.gov/research/coal/energy-systems/gasification/gasifipedia/](http://www.netl.doe.gov/research/coal/energy-systems/gasification/gasifipedia/project-examples)
30 [project-examples](http://www.netl.doe.gov/research/coal/energy-systems/gasification/gasifipedia/project-examples)> (accessed 23 April 2014).
- 31 [NETL] National Energy Technology Laboratory. 2013c. "Gasification Database: Proposed
32 U.S. Projects having Commercial Potential." October 2013. Available at
33 <[http://www.netl.doe.gov/File%20Library/research/coal/energy%20systems/gasification/](http://www.netl.doe.gov/File%20Library/research/coal/energy%20systems/gasification/worldwide%20database/US-Gasification-Database.xlsx)
34 [worldwide%20database/US-Gasification-Database.xlsx](http://www.netl.doe.gov/File%20Library/research/coal/energy%20systems/gasification/worldwide%20database/US-Gasification-Database.xlsx)> (accessed 2 June 2014).
- 35 [NETL] National Energy Technology Laboratory. undated. *Supercritical Pulverized Bituminous*
36 *Coal Plant*. 4 p. Available at
37 <http://www.netl.doe.gov/KMD/cds/disk50/PC%20Plant%20Case_Supercritical_051507.pdf>
38 (accessed 26 November 2013).
- 39 [NRC] U.S. Nuclear Regulatory Commission. 1996. *Generic Environmental Impact Statement*
40 *for License Renewal of Nuclear Plants, Final Report*. Washington, DC: NRC. NUREG-1437,
41 Volumes 1 and 2. May 31, 1996. 1,204 p. ADAMS Nos. ML040690705 and ML040690738.
- 42 [NRC] U.S. Nuclear Regulatory Commission. 2002. *Generic Environmental Impact Statement*
43 *on Decommissioning of Nuclear Facilities, Supplement 1: Regarding the Decommissioning of*
44 *Nuclear Power Reactors*. NUREG-0586, Volumes 1 and 2. Washington, DC: NRC.
45 November 30, 2002. 516 p. ADAMS Nos. ML023470327, ML023500228, and ML023500295.

- 1 [NRC] U.S. Nuclear Regulatory Commission. 2008. *Final Environmental Impact Statement for*
2 *an Early Site Permit (ESP) at the Vogtle Electric Generating Plant Site*. Washington, DC: NRC.
3 NUREG–1872, Volumes 1 and 2. August 2008. 1,242 p. Available at
4 <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1872/index.html> (accessed
5 August 2008).
- 6 [NRC] U.S. Nuclear Regulatory Commission. 2009a. *Frequently Asked Questions About*
7 *License Applications for New Nuclear Power Reactors*. NUREG/BR-0468. December 2009.
8 110 p. Available at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/brochures/br0468/>
9 (accessed 2 June 2014).
- 10 [NRC] U.S. Nuclear Regulatory Commission. 2009b. Letter from D. Matthews, Director, to
11 A. Heflin, Senior Vice President and Chief Nuclear Officer, AmerenUE/Callaway plant. Subject:
12 Staff review of the combined license application for Callaway Plant Unit 2 nuclear power plant.
13 June 29, 2009. ADAMS No. ML091750665.
- 14 [NRC] U.S. Nuclear Regulatory Commission. 2011. *Final Supplemental Environmental Impact*
15 *Statement for Combined Licenses (COLs) for Vogtle Electric Generating Plant, Units 3 and 4,*
16 *Final Report*. Washington, DC: NRC. NUREG–1947. March 2011. 568 p. ADAMS
17 No. ML11076A010.
- 18 [NRC] U.S. Nuclear Regulatory Commission. 2013a. *Generic Environmental Impact Statement*
19 *for License Renewal of Nuclear Plants*. Revision 1. Washington, DC: NRC. NUREG–1437,
20 Volumes 1, 2, and 3. June 30, 2013. 1,535 p. ADAMS Nos. ML13106A241, ML13106A242, and
21 ML13106A244.
- 22 [NRC] U.S. Nuclear Regulatory Commission. 2013b. “Status of License Renewal Applications
23 and Industry Activities.” Available at
24 <http://www.nrc.gov/reactors/operating/licensing/renewal/applications.html> (accessed
25 17 January 2014).
- 26 [NRC] U.S. Nuclear Regulatory Commission. 2013c. *Environmental Impact Statement for the*
27 *Combined License (COL) for Enrico Fermi Unit 3, Final Report*. Washington, DC: NRC.
28 NUREG–2105, Volume 1. January 2013. 753 p. ADAMS No. ML12307A172. [NREL] National
29 Renewable Energy Laboratory. 2013c. “Dynamic Maps, GIS Data, and Analysis Tools—Solar
30 Maps.” September 3, 2013. Available at <http://www.nrel.gov/gis/solar.html> (accessed
31 3 December 2013).
- 32 [NREL] National Renewable Energy Laboratory. 2013d. “Learning—Solar Energy Basics.”
33 October 16, 2013. Available at http://www.nrel.gov/learning/re_solar.html (accessed
34 3 December 2013).
- 35 [NREL] National Renewable Energy Laboratory. 2014. “Dynamic Maps, GIS Data, and Analysis
36 Details: Wind Data Details.” Available at http://www.nrel.gov/gis/wind_detail.html (accessed
37 18 February 2014).
- 38 Ong S, Campbell C, Denholm P, Margolis R, Heath G. 2013. *Land–Use Requirements for Solar*
39 *Power Plants in the United States*. Golden, CO: National Renewable Energy Laboratory.
40 NREL/TP-6A20-56290. June 2013. 47 p. Available at
41 <http://www.nrel.gov/docs/fy13osti/56290.pdf> (accessed 26 November 2013).
- 42 [ORNL] Oak Ridge National Laboratory. 2012. *An Assessment of Energy Potential at*
43 *Non-Powered Dams in the United States*. Oak Ridge, TN: ORNL. April 2012. 44 p. Available at
44 http://www1.eere.energy.gov/water/pdfs/npd_report.pdf (accessed 20 January 2014).

Alternatives Including the Proposed Action

- 1 Ott A. 2013a. *Centralized Capacity Markets in Regional Transmission Organizations and*
2 *Independent System Operators*. Norristown, PA: PJM Interconnection, LLC. October 3, 2013.
3 33 p. Available at <[http://www.pjm.com/~media/about-pjm/who-we-are/public-disclosures/](http://www.pjm.com/~media/about-pjm/who-we-are/public-disclosures/20131004-board-response-to-chairman-powelson-regarding-generation-retirements.ashx)
4 [20131004-board-response-to-chairman-powelson-regarding-generation-retirements.ashx](http://www.pjm.com/~media/about-pjm/who-we-are/public-disclosures/20131004-board-response-to-chairman-powelson-regarding-generation-retirements.ashx)>
5 (accessed 6 December 2013).
- 6 Ott A. 2013b. *PJM/MISO Seams Coordination and Capacity Deliverability*. PJM Interconnection,
7 LLC. June 20, 2013. 9 p. Available at
8 <<http://www.ferc.gov/industries/electric/indus-act/rto/pjm.pdf>> (accessed 20 January 2014).
- 9 [Reuters] Thomson Reuters. 2012. "Southern, Duke push US coal gasification; others quit."
10 June 12, 2012. Available at <[http://www.reuters.com/article/2012/06/12/](http://www.reuters.com/article/2012/06/12/utilities-coal-gasification-idUSL1E8H78P420120612)
11 [utilities-coal-gasification-idUSL1E8H78P420120612](http://www.reuters.com/article/2012/06/12/utilities-coal-gasification-idUSL1E8H78P420120612)> (accessed 26 November 2013).
- 12 Rosenberg WG. 2004. *Financing IGCC for Near-Term Deployment*. Kennedy School of
13 Government, Harvard University. July 2004. 20 p. Available at
14 <http://www.climatevision.gov/pdfs/coal_roundtable/rosenberg.pdf> (accessed
15 26 November 2013).
- 16 [Southern] Southern Company. 2013. VEGP 3&4, UFSAR. Revision 2. July 3, 2013. 448 p.
17 ADAMS No. ML13205A268.
- 18 [TEEIC] Tribal Energy and Environmental Information Clearinghouse. undated. "Utility-Scale
19 and Direct Use Geothermal Energy Generation." Available at
20 <<http://teeic.indianaffairs.gov/er/geothermal/restech/scale/index.htm>> (accessed 24 April 2014).
- 21 Tidball R, Bluestein J, Rodriguez N, Knoke S (ICF International). 2010. *Cost and Performance*
22 *Assumptions for Modeling Electricity Generation Technologies*. Golden, CO: National
23 Renewable Energy Laboratory. NREL/SR-6A20-48595. November 2010. 211 p. Available at
24 <<http://www.nrel.gov/docs/fy11osti/48595.pdf>> (accessed 26 November 2013).
- 25 [USGS] U.S. Geological Survey. 2008. *Assessment of Moderate- and High-Temperature*
26 *Geothermal Resources of the United States*. Menlo Park, CA: USGS. Fact Sheet 2008-3082.
27 4 p. Available at <<http://pubs.usgs.gov/fs/2008/3082/pdf/fs2008-3082.pdf>> (accessed
28 2 December 2013).
- 29 [WAPA and FWS] Western Area Power Administration and U.S. Fish and Wildlife Service. 2013.
30 *Upper Great Plains Wind Energy Programmatic Environmental Impact Statement, Draft*.
31 DOE/EIS-0408. March 2013. 938 p. Available at
32 <http://plainswindeis.anl.gov/documents/dpeis/Draft_UGP_Wind_Energy_PEIS.pdf> (accessed
33 26 November 2013).

3.0 AFFECTED ENVIRONMENT

In this supplemental environmental impact statement (SEIS), the “affected environment” is the environment that currently exists at and around Byron Station, Units 1 and 2 (Byron). Because existing conditions are at least partially the result of past construction and operation at the plant, the impacts of these past and ongoing actions and how they have shaped the environment are presented here. The facility and its operation are presented in Section 3.1. The affected environment is presented in Sections 3.2 to 3.13.

3.1 Description of Nuclear Power Plant Facility and Operation

Byron is a two unit nuclear power plant located in Ogle, Illinois. It began commercial operation in February 1985 (Unit 1) and January 1987 (Unit 2). Generally, the U.S. Nuclear Regulatory Commission (NRC) staff drew information about Byron’s facilities and operation from Exelon Generation Company, LLC’s (Exelon’s) Environmental Report (ER) (Exelon 2013a).

3.1.1 External Appearance and Setting

The Byron site is in northern Illinois near the center of Ogle County, approximately 90 mi (145 km) west-northwest of Chicago, 17 mi (27 km) southwest of Rockford, and 3.7 mi (6 km) south-southwest of the City of Byron (Figure 3–1) (Exelon 2013a).


The site is located on approximately 1,782 acres (ac) (721 hectares (ha)), and consists of the main site area and a right-of-way (ROW) to the Rock River for the circulating water makeup intake and blowdown discharge pipelines (Figures 3–2 and 3–3). The main site area occupies approximately 1,398 ac (566 ha), while the water pipelines’ ROW occupies the remaining 384 ac (155 ha) (Exelon 2013a). The water intake and discharge pipelines’ ROW runs from the northwest site boundary approximately 2 mi (3.2 km) west to the Rock River (Exelon 2013a).

The Byron site’s main structures include two reactor containment structures and related facilities, two circulating water natural draft cooling towers, two essential service water mechanical draft cooling towers, a switchyard, and administration buildings, warehouses, and other features (Exelon 2013a).

There are three ROWs that connect Byron to the regional electrical grid. These ROWs, which total approximately 1,210 ac (490 ha), are owned and maintained by Commonwealth Edison Company (ComEd) (Exelon 2013a).

1

Figure 3-1. Byron 50-Mile Radius Map




2

3

Source: Exelon 2013a

1

Figure 3–2. Byron 6-Mile Radius Map




2

3

Source: Exelon 2013a

1

Figure 3-3. Byron Site Boundary



2

3

Source: Exelon 2013a

1 The Byron Salvage Yard Superfund Site (Byron Salvage Site; not contaminated by activities at
2 Byron) is by the north portion of the west side of the Byron site (Figure 3–3) and consists of two
3 separate parcels: the Byron Salvage Yard and Dirk’s Farm. The Byron Salvage Site is
4 administered by U.S. Environmental Protection Agency (EPA) Region 5 and was proposed for
5 listing on the Superfund National Priorities List (NPL) in 1982. The Dirk’s Farm property is a
6 former farm that is owned by Exelon and lies west of the Byron Salvage Yard. The Byron
7 Salvage Yard property is a former automotive salvage yard and dump that is owned by ComEd.
8 After the broader Byron Salvage Site was nominated for listing on the Superfund NPL, EPA
9 performed a Remedial Investigation/Feasibility Study and initiated action under Superfund. In
10 2000, a Consent Decree was entered for remedial work on the Dirk’s Farm property. The final
11 remedial action for soils on the Dirk’s Farm property was completed by Exelon in 2003, ending
12 its responsibilities under the Consent Decree. A long-term groundwater monitoring plan for the
13 Byron Salvage Yard Superfund Site was approved by EPA in 2003 (Exelon 2013a).

14 **3.1.2 Nuclear Reactor Systems**

15 The nuclear reactor for each of the two Byron units is a Westinghouse pressurized-water reactor
16 (PWR) with four steam generators. Byron Units 1 and 2 entered commercial service on
17 September 16, 1985, and August 21, 1987, respectively. On June 23, 2011, Exelon submitted a
18 license amendment request to the NRC to increase the maximum power levels based on
19 measurement uncertainty recapture (MUR) (Exelon 2011d). On February 7, 2014, the NRC
20 staff issued license amendments approving the MUR and raised the rated thermal power to
21 3,645 megawatts thermal (NRC 2014a). At 100 percent reactor power, the combined net
22 electrical output from both Byron units is approximately 2,370 megawatts electric
23 (Exelon 2013a).

24 The Unit 1 steam generators are Babcock & Wilcox recirculating vertical U-tube units. The
25 Unit 2 steam generators are Westinghouse recirculating vertical U-tube units. The original
26 Byron Unit 1 steam generators were replaced in 1998; the Byron Unit 2 steam generators are
27 original to the plant. The reactor coolant pumps are Westinghouse vertical, single-stage,
28 centrifugal pumps equipped with controlled-leakage shaft seals (Exelon 2013a).

29 The reactor containment structure for each unit is a steel-lined, post-tensioned concrete vertical
30 cylinder with a reinforced concrete base and a shallow dome (Exelon 2013a).

31 Both Byron units are licensed for low-enriched uranium dioxide fuel with enrichment to a
32 nominal 5.0 percent by weight of uranium-235 and an allowable fuel burnup not to exceed
33 60,000 megawatt-days per metric ton (Mt) uranium. The uranium dioxide fuel is in the form of
34 high-density ceramic pellets enclosed in Zircaloy-based tubing (Exelon 2013a).


35 **3.1.3 Cooling and Auxiliary Water Systems**

36 Byron uses a closed-cycle cooling tower-based heat dissipation system. In closed-cycle
37 systems, water travels through the system to cool plant condensers and other system
38 components and is then routed to cooling towers, which dissipate excess heat through
39 evaporation. Water that is not lost to evaporation is either recirculated through the system as
40 cooling water or discharged as blowdown (i.e., water that is periodically rinsed from the cooling
41 system to remove impurities and sediment that may degrade plant performance) to a receiving
42 water body. Water lost to evaporation or discharged as blowdown must be replaced; this
43 replacement water is referred to as makeup water. Figure 3–4 provides a basic schematic
44 diagram of a closed-cycle cooling system with a natural draft cooling tower. Byron has both
45 natural draft cooling towers and mechanical draft cooling towers that service its three cooling
46 and auxiliary water systems. All of Byron’s systems withdraw makeup water from and discharge

Affected Environment

1 blowdown to the Rock River, which lies 2 mi (3.2 km) west of the Byron site's northwestern
2 boundary. Unless otherwise cited, the description of Byron's cooling and auxiliary water
3 systems is derived from Exelon's Environmental Report (ER) (Exelon 2013a) and Exelon's
4 responses to the staff's requests for additional information (RAI) dated December 19, 2013
5 (Exelon 2013b).

6 **Figure 3–4. Closed-Cycle Cooling System with Natural Draft Cooling Tower**



7

8

Source: NRC 2013a, modified from Figure 3.1-4


9

3.1.3.1 Circulating Water System

10 The circulating water system provides cooling water to the main condensers to cool the Byron
11 reactor cores. At 100 percent power, each reactor unit requires 693,000 gallons per minute
12 (gpm) (1,540 cubic feet per second (cfs) (43.5 cubic meters per second (m^3/s))—
13 1,386,000 gpm (3,080 cfs (87 m^3/s)) in total—of circulating water to remove excess heat from
14 the condensers. Following use for cooling, heated water is pumped to two natural draft cooling
15 towers for heat dissipation where about 19,800 gpm (52.9 cfs (1.5 m^3/s) of water is lost to
16 evaporation. The remaining water is routed to an open flume located between the two cooling
17 towers. Water in the flume either enters the circulating water pump house, from which it is
18 returned to the circulating water system, or it is discharged as blowdown. Byron discharges
19 approximately 13,000 to 17,000 gpm (29 to 37.9 cfs (0.82 to 1.1 m^3/s) to the river as
20 blowdown. Blowdown water travels from the flume through a 30-in. (76.2-cm) pipeline that runs
21 west along Exelon's 2-mi (3.2-km)-long ROW to the Rock River (see Figure 3–5). The outfall
22 structure lies about 61 m (200 ft) downstream of the intake point at the river screen house
23 (described below). From the outfall structure, water discharges to the river through an 84-m
24 (275-ft)-long rip-rapped channel.

1

Figure 3-5. Byron Cooling Water Intake and Discharge Pipelines



2

3

Source: Exelon 2013a, modified from Figure 2.1-3

Affected Environment

1 To account for evaporative and blowdown losses, Byron's circulating water intake system
2 withdraws an average of 36,750 gpm (81.8 cfs (2.3 m³/s)) of makeup water. Typically, the
3 Rock River near Byron flows at a rate of 6,033 cfs (170 m³/s) (see Section 3.5.1.1). During low
4 river flow (i.e., less than 679 cfs (19.2 m³/s), Byron has an agreement with the Illinois
5 Department of Natural Resources (IDNR) to limit Rock River water consumption to no more
6 than 9 percent of total river flow during times when the river flow is at or below the specified low
7 river flow. Commonwealth Edison Company made this agreement with the Illinois Department
8 of Transportation (IDOT), Division of Water Resources (now IDNR) in 1977 during the process
9 for obtaining a permit to construct the Byron intake and discharge structures (IDOT 1977). The
10 permit also imposes a maximum withdrawal rate of 46,700 gpm (125 cfs (3.5 m³/s)) regardless
11 of the volume of flow in the river. Exelon has since incorporated the implementation of these
12 permit conditions into several site procedures.

13 Makeup water is withdrawn from the Rock River through an intake structure on the east bank of
14 the river (referred to as the "river screen house"), which is located at river mile (RM) 115 (river
15 kilometer (RKM) 185) (see Figure 3–5). The river screen house has three dedicated makeup
16 pumps, each with a capacity of 24,000 gpm (54 cfs or 1.5 m³/s). Two of the pumps support
17 normal operations and one serves as a backup. Prior to entering the intake structure, water
18 flows at a speed of 0.43 to 0.55 feet per second (fps) (0.13 to 0.17 meters per second (m/s))
19 through trash racks located outside of the river screen house. The trash racks remove large
20 debris and ice (in winter months) and are spaced 3 in. (8 cm) apart and extend from the intake
21 channel floor to a height of 28 ft (8.5 m). Water then enters the screen house and is routed
22 through traveling screens with 3/8-in. (0.95-cm) wire mesh openings. The design through-
23 screen flow rate is 1.65 fps (0.5 m/s), but actual maximum through-screen velocity was
24 measured as 0.91 fps (0.28 m/s) during preoperational impingement studies (IEPA 1989). The
25 traveling screens operate automatically based on pressure differential, or if there is no pressure
26 differential for a given period of time, every 12 hours for a period of 55 minutes. Debris and
27 aquatic organisms collected on the screens are collected in trash baskets and disposed of off
28 site. Following the traveling screens, circulating water makeup pumps direct water into a 48-in.
29 (1.2-m) pipeline that runs approximately 2 mi (3.2 km) east from the river screen house to the
30 boundary of the Byron site. The pipeline discharges into the flume between the cooling towers,
31 at which point makeup water can enter the circulating water system through the circulating
32 water pump house.

33 *3.1.3.2 Nonessential Service Water System*

34 The nonessential service water system provides water to non-safety-related systems. This
35 system draws water from the circulating water pump house and returns water to the natural draft
36 cooling towers. Makeup water from this system is supplied through the circulating water
37 system's infrastructure, which is described above.

38 *3.1.3.3 Essential Service Water System*

39 The essential service water system removes heat from the reactor safeguard and auxiliary
40 systems. During normal operations, this system draws water from the circulating water pump
41 house, which pumps water to the auxiliary building, at which point water enters the essential
42 service water system. The essential service water system also includes two 12-in. (0.3-m)
43 intake pipelines that are dedicated to providing a source of backup makeup water during
44 conditions in which makeup is not available from the circulating water system. The makeup
45 pipelines run parallel to the circulating water system makeup pipelines from the river screen
46 house to the site boundary and then to the mechanical draft cooling towers. These
47 two mechanical draft cooling towers serve as the ultimate heat sink for the plant's two reactor

1 units. Blowdown from these cooling towers is routed to the flume between the circulating water
2 system's natural draft cooling towers.

3 *3.1.3.4 Cooling and Auxiliary Water Treatment*

4 Exelon treats each water system to prevent corrosion, scaling (i.e., the buildup of inorganic
5 nutrients, such as calcium, magnesium, and silica), and biofouling. Exelon adds zinc to prevent
6 corrosion; sulfuric acid, polyphosphate, potassium phosphate, acrylic polymer, and triazole to
7 prevent scaling; sodium hypochlorite and sodium bromide to makeup water to prevent
8 biofouling; and polyacrylate to disperse silt. Circulating water system makeup water is also
9 treated with a low concentration of copper ions to prevent zebra mussel growth. Byron's
10 National Pollutant Discharge Elimination System (NPDES) permit, which is discussed in more
11 detail in Section 3.5.1.3, limits the chemical concentrations in blowdown discharged to the Rock
12 River.

13 **3.1.4 Radioactive Waste Management Systems**

14 As part of normal operations and as a result of equipment repairs and replacements due to
15 normal maintenance activities, nuclear power plants routinely generate both radioactive and
16 nonradioactive wastes. Nonradioactive wastes include hazardous and nonhazardous wastes.
17 There is also a class of waste, called mixed waste that is both radioactive and hazardous. The
18 systems used to manage (i.e., treat, store, and dispose of) these wastes are described in this
19 section. Waste minimization and pollution prevention measures commonly employed at nuclear
20 power plants are also discussed in this section.

21 All nuclear plants were licensed with the expectation that they would release radioactive
22 material to both the air and water during normal operation. However, NRC regulations require
23 that gaseous and liquid radioactive releases from nuclear power plants must meet radiation
24 dose-based limits specified in Title 10 of *Code of Federal Regulations* (10 CFR) Part 20, and the
25 as low as is reasonably achievable (ALARA) criteria in Appendix I to 10 CFR Part 50.
26 Regulatory limits are placed on the radiation dose that members of the public can receive from
27 radioactive effluents released by a nuclear power plant. All nuclear power plants use
28 radioactive waste management systems to control and monitor radioactive wastes.

29 Byron uses liquid, gaseous, and solid waste processing systems to collect and process, as
30 needed, radioactive materials produced as a by-product of plant operations. The liquid and
31 gaseous radioactive effluents are processed to reduce the levels of radioactive material prior to
32 discharge into the environment. This is to ensure that the dose to members of the public from
33 radioactive effluents is reduced to levels that are ALARA in accordance with NRC's regulations.
34 The radioactive material removed from the effluents is converted into a solid form for eventual
35 disposal at a licensed radioactive disposal facility.

36 Byron has a radiological environmental monitoring program (REMP) to assess the radiological
37 impact, if any, to the public and the environment from radioactive effluents released during
38 operations at Byron. The REMP measures the aquatic, terrestrial, and atmospheric
39 environment for radioactivity, as well as the ambient radiation. In addition, the REMP measures
40 background radiation (i.e., cosmic sources, global fallout, and naturally occurring radioactive
41 material, including radon) (Teledyne 2013).

42 Byron has an Offsite Dose Calculation Manual (ODCM) that contains the methods and
43 parameters used to calculate offsite doses resulting from liquid and gaseous radioactive
44 effluents. These methods are used to ensure that radioactive material discharges from the plant
45 meet NRC and EPA regulatory dose standards. The ODCM also contains the requirements for
46 the REMP (Teledyne 2013).

Affected Environment

1 3.1.4.1 Radioactive Liquid Waste Management

2 Radioactive liquids are processed as necessary by the liquid radwaste system (LRWS) for
3 release to the environment into the Rock River via the circulating water blowdown line. The
4 LRWS is designed so that liquid radwaste discharged from the site will have radioactive nuclide
5 concentrations well within the limits specified in 10 CFR 20 and 10 CFR 50, Appendix I. The
6 layout of the LRWS consists of two main subsystems designed for collecting and processing the
7 liquid waste: the steam generator blowdown subsystem and the non-blowdown subsystem.
8 Each of the liquid radwaste processing streams terminates in a monitor tank, allowing each
9 batch of liquid waste to be sampled and analyzed to ensure they are ALARA before being
10 released. Based on the analysis of each sample, these wastes are either released under
11 controlled conditions via the cooling water system or recycled through the same or a different
12 subsystem for further processing. The data from the analysis is used to ensure that the release
13 conforms to the controls specified in the ODCM. The ODCM's controls are based on the
14 concentration of radioactive material in the liquid effluent and the projected dose from the
15 release.

16 Radioactive liquid waste is processed through a demineralizer system which removes soluble
17 and suspended radioactive material using an ion exchange process and filtration prior to being
18 released into the environment. Once the resin and filter media are expended, they are
19 processed as waste for disposal.

20 The LRWS is shared by the two units; however, Unit 1 and Unit 2 have separate equipment and
21 floor drain collection sump systems. The non-blowdown radwaste subsystem treats waste
22 streams from the auxiliary building equipment drains, auxiliary building floor drains, chemical
23 waste drains, regeneration waste drains, laundry drains, turbine building equipment and floor
24 drains, and condensate polisher sump.

25 Radioactive liquid effluent paths are processed, monitored, and recycled or discharged via
26 release tanks. Radioactivity analysis of the waste is performed prior to transferring the contents
27 to the release tank. If the activity is below NRC regulatory release limits specified in the ODCM,
28 the tank contents may be discharged to the Rock River via the circulating water blowdown line
29 without further treatment. The blowdown line enters the Rock River approximately 61 m (200 ft)
30 downstream of the water intake structure to prevent mixing of the wastewater with the makeup
31 water lines. Prior to where the release tank discharge line mixes with the blowdown line, a
32 backup radiation detector monitors the discharged liquid. If abnormal radiation levels are
33 detected, a valve closes automatically to prevent the release and an alarm annunciates in the
34 Control Room.

35 A spent resin storage tank stores the used demineralizer resins. The resin is held in this tank
36 for a period of time to allow for the decay of short-lived isotopes. The resin is periodically
37 removed for disposal as radioactive solid waste.

38 The use of these radioactive waste systems and the procedural requirements in the ODCM
39 ensure that the dose from radioactive liquid effluents complies with NRC and EPA regulatory
40 dose standards.

41 Dose estimates for members of the public are calculated based on radioactive liquid effluent
42 release data and aquatic transport models. Exelon's annual radiological effluent release report
43 contains a detailed presentation of the radioactive liquid effluents released from Byron and the
44 resultant calculated doses. The NRC staff reviewed 5 years of radioactive effluent release data:
45 2008 through 2012 (Exelon 2009b, 2010c, 2011b, 2012c, 2013g). A 5-year period provides a
46 data set that covers a broad range of activities that occur at a nuclear power plant such as
47 refueling outages, routine operation, and maintenance activities that can affect the generation of

1 radioactive effluents. The NRC staff compared the data against NRC dose limits and looked for
 2 indication of adverse trends (i.e., increasing dose levels) over the period of 2008 through 2012.
 3 The following summarizes the calculated doses from radioactive liquid effluents released during
 4 2012:

5 Unit 1

- 6 • The total-body dose to an offsite member of the public from Byron Unit 1
 7 radioactive liquid effluents was 8.03×10^{-2} millirem (mrem)
 8 (8.03×10^{-4} millisievert (mSv)), which is well below the 3 mrem (0.03 mSv)
 9 dose criterion in Appendix I to 10 CFR Part 50.
- 10 • The organ dose (adult/GI-tract) to an offsite member of the public from Byron
 11 Unit 1 radioactive liquid effluents was 1.38×10^{-1} mrem (1.38×10^{-3} mSv),
 12 which is well below the 10 mrem (0.1 mSv) dose criterion in Appendix I to
 13 10 CFR Part 50.

14 Unit 2

- 15 • The total-body dose to an offsite member of the public from Byron Unit 2
 16 radioactive liquid effluents was 8.03×10^{-2} mrem (8.03×10^{-4} mSv), which is
 17 well below the 3 mrem (0.03 mSv) dose criterion in Appendix I to 10 CFR
 18 Part 50.
- 19 • The organ dose (adult/GI-tract) to an offsite member of the public from Byron
 20 Unit 2 radioactive liquid effluents was 1.38×10^{-1} mrem (1.38×10^{-3} mSv),
 21 which is well below the 10 mrem (0.1 mSv) dose criterion in Appendix I to
 22 10 CFR Part 50.

23 The NRC staff's review of Byron's radioactive liquid effluent control program showed that
 24 radiation doses to members of the public were controlled within NRC's and EPA's radiation
 25 protection standards contained in Appendix I to 10 CFR Part 50, 10 CFR Part 20, and 40 CFR
 26 Part 190. No adverse trends were observed in the dose levels.

27 Routine plant refueling and maintenance activities currently performed will continue during the
 28 license renewal term. Based on the past performance of the radioactive waste system to
 29 maintain doses from radioactive liquid effluents to be ALARA, similar performance is expected
 30 during the license renewal term.

31 *3.1.4.2 Radioactive Gaseous Waste Management*

32 The gaseous waste processing system (GWPS) is designed to remove fission product gases
 33 from the reactor coolant and minimize the amount of radioactive material released into the
 34 environment. The GWPS is a shared system serving both units. It consists of two waste-gas
 35 compression packages, six gas decay tanks, and the associated piping, valves, and
 36 instrumentation. Gaseous wastes are generated from the following activities: gases removed
 37 from the reactor coolant and purging of the volume control tank prior to a cold shutdown of the
 38 reactor, displacing of cover gases caused by the accumulation of liquids in storage tanks,
 39 purging of some equipment, sampling and gas analyzer operation, and operating the boron
 40 recycle system. The reduction of the levels of radioactive material is accomplished by internal
 41 recirculation of the gases within piping systems and temporary storage in gas decay tanks. The
 42 recirculation of the gases and the temporary storage in the decay tanks allows time for
 43 radioactive decay to reduce the levels of radioactivity.

44 Gaseous radioactive wastes are released into the atmosphere, in a controlled and monitored
 45 manner, through two mixed-mode release point ventilation stacks. The radioactive gaseous
 46 waste sampling and analysis program specifications provided in the ODCM address the

Affected Environment

1 gaseous release type, sampling frequency, minimum analysis frequency, type of activity
2 analysis, and lower limit of detection (i.e., sensitivity) for the radiation monitor.

3 The use of these radioactive waste systems and the procedural requirements in the ODCM
4 ensure that the dose from radioactive gaseous effluents complies with NRC and EPA regulatory
5 dose standards.

6 Dose estimates for members of the public are calculated based on radioactive gaseous effluent
7 release data and atmospheric transport models. Exelon's annual radioactive material release
8 report contains a detailed presentation of the radioactive gaseous effluents released from Byron
9 and the resultant calculated doses. The NRC staff reviewed 5 years of radioactive effluent
10 release data: 2008 through 2012. A 5-year period provides a data set that covers a broad
11 range of activities that occur at a nuclear power plant such as refueling outages, nonrefueling
12 outage years, routine operation, and maintenance activities that can affect the generation of
13 radioactive effluents. The NRC staff compared the data against NRC dose limits and looked for
14 indication of adverse trends (i.e., increasing dose levels) over the period of 2008 through 2012.
15 The following summarizes the calculated doses from radioactive gaseous effluents released
16 during 2012:

17 Unit 1

- 18 • The air dose at the site boundary from gamma radiation in gaseous effluents
19 from Byron Unit 1 was 4.36×10^{-4} millirad (mrad) (4.36×10^{-6} milligray (mGy)),
20 which is well below the 10 mrad (0.1 mGy) dose criterion in Appendix I to
21 10 CFR Part 50.
- 22 • The air dose at the site boundary from beta radiation in gaseous effluents
23 from Byron Unit 1 was 3.07×10^{-3} mrad (3.07×10^{-5} mGy), which is well below
24 the 20 mrad (0.2 mGy) dose criterion in Appendix I to 10 CFR Part 50.
- 25 • The dose to an organ (child bone) from radioactive iodine, radioactive
26 particulates, and carbon-14 from Byron Unit 1 was 4.06×10^{-1} mrem
27 (4.06×10^{-3} mSv), which is well below the 15 mrem (0.15 mSv) dose criterion
28 in Appendix I to 10 CFR Part 50.

29 Unit 2

- 30 • The air dose at the site boundary from gamma radiation in gaseous effluents
31 from Byron Unit 2 was 5.87×10^{-6} mrad (5.87×10^{-8} mGy), which is well below
32 the 10 mrad (0.1 mGy) dose criterion in Appendix I to 10 CFR Part 50.
- 33 • The air dose at the site boundary from beta radiation in gaseous effluents
34 from Byron Unit 2 was 1.19×10^{-5} mrad (1.19×10^{-7} mGy), which is well below
35 the 20 mrad (0.2 mGy) dose criterion in Appendix I to 10 CFR Part 50.
- 36 • The dose to an organ (child bone) from radioactive iodine, radioactive
37 particulates, and carbon-14 from Byron Unit 2 was 4.57×10^{-1} mrem
38 (4.57×10^{-3} mSv), which is well below the 15 mrem (0.15 mSv) dose criterion
39 in Appendix I to 10 CFR Part 50.

40 The NRC staff's review of Byron's radioactive gaseous effluent control program showed that
41 radiation doses to members of the public were controlled within NRC's and EPA's radiation
42 protection standards contained in Appendix I to 10 CFR Part 50, 10 CFR Part 20, and 40 CFR
43 Part 190. No adverse trends were observed in the dose levels.

44 Routine plant refueling and maintenance activities currently performed will continue during the
45 license renewal term. Based on the past performance of the radioactive waste system to

1 maintain doses from radioactive gaseous effluents to be ALARA, similar performance is
2 expected during the license renewal term.

3 *3.1.4.3 Radioactive Solid Waste Management*

4 Solid low-level radioactive waste (LLW) is generated by the removal of radioactive material from
5 liquid waste streams, filtration of gaseous effluents, and removal of contaminated material from
6 various reactor areas. The waste is divided into two categories: dry active waste (DAW) and
7 wet active waste (WAW). The solid waste system collects, processes, packages, and provides
8 temporary storage for WAW prior to offsite shipment and burial, in accordance with NRC
9 regulations in 10 CFR Parts 61 and 71. Transportation of the radioactive solid waste is
10 governed by the U.S. Department of Transportation (DOT) regulations in 49 CFR 171 to 178.
11 The solid waste system also receives, decontaminates, compacts, and provides temporary
12 storage for DAW prior to offsite shipment and burial.

13 Types of waste handled by this system include expended deep bed demineralizer resins,
14 disposable cartridge filter elements, DAW (such as air filters, miscellaneous paper, rags from
15 contaminated areas and contaminated clothing, tools, and equipment parts), and solid
16 laboratory wastes. Drums are used for packaging both WAW and DAW. Byron has a
17 drumming area where two remotely operated cranes are used to transport and position the
18 drums while in storage, as well as transport them to trucks for offsite disposal.

19 Routine plant operation, refueling outages, and maintenance activities that generate radioactive
20 solid waste will continue during the license renewal term. Radioactive solid waste is expected
21 to be generated and shipped off site for disposal during the license renewal term.

22 *3.1.4.4 Radioactive Waste Storage*

23 Low-level radioactive waste is stored temporarily on site in restricted areas until it can be
24 shipped off site for disposal at a licensed LLW disposal facility.

25 Byron stores its spent nuclear fuel in a spent fuel pool and also maintains an independent spent
26 fuel storage installation (ISFSI) on site. The ISFSI is used to safely store spent fuel in licensed
27 and approved dry cask storage containers on site. The installation and monitoring of this facility
28 is governed by NRC requirements in 10 CFR Part 72, "Licensing requirements for the
29 independent storage of spent nuclear fuel, high-level radioactive waste, and reactor-related
30 Greater than class C waste." The Byron ISFSI would remain in place until the U.S. Department
31 of Energy (DOE) takes possession of the spent fuel and removes it from the site for permanent
32 disposal or processing. Expansion of the onsite spent fuel storage capacity may be required
33 during the license renewal term. The impacts associated with this expansion would be
34 assessed under the 10 CFR Part 72 license process separate from that of the Byron operating
35 units. The Byron ISFSI is located within the existing protected area boundary. Spent fuel
36 transfers to the ISFSI began in September 2010 when fuel from the spent fuel pool was placed
37 in six casks and transferred to the ISFSI outdoor storage pad area and eight casks were added
38 in 2012 (Teledyne 2013).

39 *3.1.4.5 Radiological Environmental Monitoring Program*

40 Exelon conducts a REMP to assess the radiological impact, if any, to the public and the
41 environment from the operations at Byron.

42 The REMP measures the aquatic, terrestrial, and atmospheric environment for radioactivity, as
43 well as the ambient radiation by sampling air, water, milk, foods, soil, fish, and shoreline
44 sediment. In addition, the REMP measures background radiation (i.e., cosmic sources, global
45 fallout, and naturally occurring radioactive material, including radon). The radiation detection

Affected Environment

1 devices and analysis methods used to determine the radioactivity in environmental samples are
2 very sensitive to small amounts of radioactivity.

3 In addition to the REMP, Byron has an onsite ground water protection program designed to
4 monitor the onsite plant environment for detection of leaks from plant systems and pipes
5 containing radioactive liquid (Exelon 2013a). Information on the ground water protection
6 program is contained in Section 3.5.2 of this document.

7 The NRC staff reviewed 5 years of annual radiological environmental monitoring data: 2008
8 through 2012 (Teledyne 2009, 2010, 2011, 2012, 2013). A 5-year period provides a data set
9 that covers a broad range of activities that occur at a nuclear power plant such as refueling
10 outages, routine operation, and maintenance activities that can affect the generation and
11 release of radioactive effluents into the environment. The NRC staff looked for indication of
12 adverse trends (i.e., buildup of radioactivity levels) over the period of 2008 through 2012.

13 The NRC staff's review of Exelon's data showed no indication of an adverse trend in
14 radioactivity levels in the environment. The data showed that there was no measurable impact
15 to the environment from operations at Byron.

16 **3.1.5 Nonradioactive Waste Management Systems**

17 Like any other industrial facility, nuclear power plants generate wastes that are not
18 contaminated with either radionuclides or hazardous chemicals. These wastes include trash,
19 paper, wood, and sewage.

20 Byron has a nonradioactive waste management program to handle its nonradioactive hazardous
21 and nonhazardous wastes. The waste is collected in central collection areas within the plant
22 site and managed in accordance with Exelon's procedures. The materials are received in
23 various forms and packaged to meet regulatory requirements prior to final disposition at an
24 offsite facility licensed to receive and manage the waste. Listed below is a summary of the
25 types of waste materials generated and managed at Byron.

- 26 • Byron is registered as a small-quantity hazardous waste generator, however,
27 hazardous wastes are managed according to large-quantity generator
28 standards. The amount of hazardous wastes generated are only a small
29 percentage of the total wastes generated; consisting of paints and
30 paint-related materials, spent and off-specification and shelf-life expired
31 chemicals, laboratory chemical wastes, and occasional project-specific
32 wastes. Byron has contracts in place to transfer hazardous waste to licensed
33 offsite treatment and disposal facilities.
- 34 • Byron's nonhazardous wastes include potentially infectious medical waste
35 (PIMW), used oil, grease, antifreeze, adhesives, and other petroleum-based
36 liquids. PIMW is generated at a health facility on site and can include used
37 and unused hypodermic needles and syringes, as well as items contaminated
38 with human blood. PIMW is considered a unique special waste category in
39 Illinois and transportation and disposal of this waste is regulated under
40 35 Illinois Administrative Code (IAC) 1420.104 (a).
- 41 • Universal wastes, such as batteries and mercury-containing lamps.
- 42 • General plant trash is collected in dumpsters and transported to a
43 state-licensed regional landfill permitted to accept solid wastes. General
44 trash typically consists of garbage, paper, plastic, packing materials, leather,
45 rubber, glass, soft drink and food cans, dead animals and fish, floor
46 sweepings, ashes, wood, textiles, and scrap metal.

1 Exelon operates a sewage treatment package plant onsite. Effluent discharge is regulated
2 under NPDES permit IL0048313. If the treatment plant is out of service, Exelon is authorized to
3 transfer raw sewage up to 18,000 gallons per day (68,000 L/d) to the City of Oregon wastewater
4 collection system for treatment. This effluent discharge is regulated under the town's NPDES
5 permit IL0020184 (Exelon 2003).

6 **3.1.6 Utility and Transportation Infrastructure**

7 Existing utility and transportation infrastructure characteristics for Byron are briefly described in
8 the following subsections.

9 *3.1.6.1 Electricity*

10 Byron receives offsite electrical power, as needed, from four different independent sources, via
11 two separate power circuits from the 345-kV switchyard (Exelon 2013a). Each of these power
12 circuits has its own separate ROW with independent transmission line structures. Byron also
13 has two emergency diesel generators per unit designed to supply electrical power to key plant
14 components when normal offsite power sources are not available (Exelon 2013d).

15 *3.1.6.2 Fuel*

16 Fuel is supplied to each diesel via the Fuel Oil System, which contains various tanks and fuel
17 transfer pumps that provide fuel to each engine for a minimum of 7 days of operation without
18 offsite support (Exelon 2013d). Byron's Fuel Oil System consists of four 25,000-gallon (gal)
19 diesel oil storage tanks dedicated to Unit 1 and two 50,000-gal storage tanks dedicated to Unit 2
20 (Exelon 2013d).

21 *3.1.6.3 Water*

22 Systems designed to provide cooling water at Byron are described in Section 3.1.3. In addition
23 to water needed for cooling, Byron requires water for sanitary purposes and for everyday use by
24 personnel (e.g., drinking, showering, cleaning, laundry, toilets, and eyewashes). Byron draws
25 potable water from the Cambrian-Ordovician Ironton-Galesville and Mt. Simon aquifers using
26 two onsite groundwater wells, which also supply water to the demineralizer system
27 (Exelon 2013a). As discussed in Section 3.1.5, Exelon operates an on-site sewage treatment
28 package plant. Exelon is also authorized to transfer raw sewage to the City of Oregon
29 wastewater collection system for treatment in the city's sanitary wastewater treatment plant.

30 *3.1.6.4 Transportation Systems*

31 Byron has extensive paved surfaces, including parking lots and roads connecting power plant
32 infrastructure. Direct access to the site is via German Church Road (County Highway 2), which
33 runs northeast-southwest (Exelon 2013a). Section 3.10.6 describes roadway access and other
34 local transportation systems in more detail. The Canadian Pacific Railway provides a railroad
35 spur to the Byron site (Exelon 2013a).

36 *3.1.6.5 Power Transmission Systems*

37 Transmission lines that are within the scope of the NRC's license renewal review are limited to
38 those transmission lines that connect the nuclear plant to the substation where electricity is fed
39 into the regional distribution system and transmission lines that supply power to the nuclear
40 plant from the grid (NRC 2013a). Byron's main power transformers are connected via
41 intermediate, onsite transmission lines to the onsite 345-kV switchyard (Exelon 2013a).

42 Commonwealth Edison Company is the owner and operator of the power transmission line
43 systems for Byron, which connect the site to the Mid-America Interpool Network regional
44 transmission grid (Exelon 2013a). No separate transmission lines supply offsite power to Byron

Affected Environment

1 from the grid (Exelon 2013a). Both switchyards and all the high-voltage lines would remain in
2 service regardless of the proposed license renewal (ComEd 2013).

3 **3.1.7 Nuclear Power Plant Operations and Maintenance**

4 Maintenance activities conducted at Byron include inspection, testing, and surveillance to
5 maintain the current licensing basis (CLB) of the facility and to ensure compliance with
6 environmental and safety requirements. Various programs and activities currently exist at Byron
7 to maintain, inspect, test, and monitor the performance of facility equipment. These
8 maintenance activities include inspection requirements for reactor vessel materials, boiler and
9 pressure vessel inservice inspection and testing, and maintenance of water chemistry.

10 Additional programs include those carried out to meet technical specification surveillance
11 requirements, those implemented in response to the NRC generic communications, and various
12 periodic maintenance, testing, and inspection procedures (Exelon 2013a). Byron must
13 periodically discontinue the production of electricity for outages supporting refueling, periodic
14 inservice inspection, and testing and maintenance activities. The Byron units are on staggered
15 18-month refueling cycles (Exelon 2013a).

16 **3.2 Land Use and Visual Resources**

17 **3.2.1 Land Use**

18 The Byron site is located in Ogle County in northern Illinois, approximately 3.7 mi (6.0 km)
19 southwest of the City of Byron. Ogle County is the 17th largest county in Illinois and covers
20 763 square miles (mi²) (1,976 square kilometers (km²)). Ogle County is located within the Rock
21 River Hill Country subsection in the Till Plains section of the Central Lowland physiographic
22 province (IDNR 2001).

23 The most common land use within Ogle County is agriculture (89 percent), which includes
24 farmsteads, farm buildings, pasture, grazing lands, timberlands, grasslands, and other rural
25 open space uses. The major crops grown in Ogle County are corn and soybeans. Wheat, oats,
26 and hay are also grown (Exelon 2013a). Livestock raised in Ogle County include cattle and
27 hogs. Remaining land uses include municipalities (4.5 percent), rural settlements (1.5 percent),
28 residential (1.0 percent), and state parks/forested land (1.0 percent) (Exelon 2013a; Ogle
29 County 2012). Population growth in Ogle County has been minimal over the past decade
30 (Exelon 2013a). The municipalities (the largest of which are Rochelle, Oregon, and Byron)
31 account for only 4.5 percent of land use in Ogle County, although 57 percent of the county
32 population resides within these areas (Exelon 2013a).

33 The Ogle County Illinois Comprehensive Plan 2012 Update (Ogle County 2012) is the County's
34 land-use plan, and its goal is to:

35 [establish] an identifiable destination that allows both the governing body and
36 private interests to plan and budget with an idea as to the direction the County
37 may move in the future, [and to] ensure that future growth is not only anticipated,
38 but planned for.

39 In addition to this plan, Ogle County continues to implement its zoning and subdivision
40 ordinances, greenways and trails plan, special flood hazards ordinance, comprehensive
41 stormwater management ordinance, and municipality comprehensive land use plans
42 (Exelon 2013a).

43 The Ogle County Greenways and Trails Plan (Sheaffer 2003) outlines the County's land use
44 goals for green infrastructure. Green infrastructure and greenways are defined in this plan as

1 recreational paths and trails, ecologically significant natural corridors, scenic and historic routes,
2 networks of natural land forms (such as valleys and ridges), and urban waterfronts. The goals
3 of the plan include development and conservation of greenways that contain multiple resources
4 (particularly riparian areas), the protection of floodplains, the stabilization of native vegetation
5 through the introduction of fragile soils, and the preservation of biodiversity and historic and
6 cultural resources.

7 In Ogle County, one of the most important natural areas is the Lowden-Miller State Forest near
8 the City of Oregon (IDNR undated). The forest is adjacent to Castle Rock State Park, which is
9 named for a unique sandstone bluff on the Rock River. Combined, these two areas cover
10 approximately 4,225 ac (1,710 ha). These areas contain important natural habitat and are
11 home to more breeding pairs of forest bird species than any other part of Illinois (IDNR 2001).
12 These parks and their terrestrial habitats are discussed further in Section 3.6.

13 Because Exelon's ER (Exelon 2013a) looked at land use within a 5-mi (8-km) radius of the
14 Byron site, NRC staff used this radius during its review. Land use within this radius is primarily
15 agricultural. Some residential land use is centered on the cities of Byron and Oregon, both of
16 which are within 5 mi (8 km) of the Byron site, and the remaining areas are primarily rural.
17 Within 5 mi (8 km) of Byron are eight privately owned recreational areas, one county park, and
18 one state park. The Lowden Memorial State Park is 3.5 mi (5.6 km) to the southwest of the
19 Byron site and occupies 207 ac (84 ha). Weld Memorial Park, owned by Ogle County, is 3 mi
20 (4.8 km) northeast and occupies 35 ac (14 ha). These parks offer such recreational activities to
21 the public as camping, picnicking, hiking, fishing, and boating on the Rock River.

22 The Byron Salvage Yard Superfund Site lies beyond the northwest boundary of the main Byron
23 site. The superfund site consists of two separate land parcels: the Byron Salvage Yard and
24 Dirk's Farm (Exelon 2013a). Dirk's Farm was purchased by Exelon as part of Byron's
25 circulating water pipeline ROW. The Byron Salvage Yard is not owned by Exelon. The
26 automotive salvage yard portion of the Byron Salvage Yard was used as a dump for a variety of
27 waste and debris. A contamination investigation and subsequent remediation began after
28 several cattle deaths from cyanide-contaminated water occurred on Dirk's Farm in 1975
29 (EPA 2003). All soil and groundwater remedial actions are now completed on both sites and
30 groundwater monitoring plans remain in place (EPA 2003).

31 The Byron site occupies 1,782 ac (721 ha), which consists of the main site area, which occupies
32 1,398 ac (566 ha), and the water intake and discharge pipeline corridor, which occupies 384 ac
33 (155 ha) (Exelon 2013a). Figure 3–3 depicts the main site area, which is surrounded primarily
34 by agricultural fields. The power block and support facilities (buildings, switchyard, parking lots,
35 and roads) occupy approximately 154 ac (62 ha), or 9 percent of the main site area. The plant
36 exclusion area is located entirely within the main site area boundary and all activities occurring
37 within the exclusion area are controlled by Exelon. Exelon operates an ISFSI within the site
38 boundary. The Byron site is bounded by County Highway 2 (German Church Road), Deer Path
39 Road, and Razorville Road. County Highway 2 provides access to the Byron site from
40 highways State Route 72 and State Route 64.

41 The pipeline corridor extends west of the main site area approximately 2 mi (3.2 km) to the Rock
42 River. The Rock River creates the furthest western boundary of the Byron site. The pipeline
43 corridor is surrounded on- and off-site by primarily wooded lands (Exelon 2013a). Byron's
44 circulating water makeup intake structure is located at Rock River RM 115 (RKm 185),
45 approximately 5 mi (8 km) downstream of the Byron, Illinois, U.S. Geological Survey (USGS)
46 gaging station at Rock RM 120.3 (RKm 193.6). The Oregon Dam 4 mi (6.4 km) downstream
47 creates the pool from which Byron draws its circulating water makeup and discharges its
48 blowdown to and controls the water level at the intake.

Affected Environment

1 Approximately 538 ac (218 ha) of the Byron site was disturbed during the construction of the
2 Byron facilities (30 percent) (Exelon 2013b). Forty-seven percent of the Byron site (840 ac)
3 (340 ha) has been leased for agricultural use. This land is considered disturbed because most
4 of it is tilled. The remaining 23 percent (404 ac (163 ha)) of Byron is undisturbed land.
5 Regarding control of leased land within the Byron site, Exelon Generation generally retains an
6 unrestricted right to enter, use, and dispose of the leased land for its business purposes and in
7 the event of emergencies. Also, subleases are not permitted and leases typically restrict use of
8 the leased land solely to a designated purpose, such as for farming and agricultural purposes,
9 for cultivating crops, or for pastureland. Some leases may prohibit certain specific activities on
10 the leased land, such as removing top soil, changing the original ground grade level, altering the
11 natural water drainage pattern, and installing irrigation systems.

12 **3.2.2 Visual Resources**

13 The Byron site is situated at one of the highest points within a 5-mi (8-km) radius, at 869 ft
14 (265 m) mean sea level. The topography surrounding the Byron facility gently slopes downward
15 in nearly all directions, including west to the bank of the Rock River. Predominant features at
16 the Byron site include the two reactor containment buildings, a turbine building, an auxiliary
17 building, a fuel handling building, service buildings, training buildings, a steam generator storage
18 building, a circulating water pumphouse, a circulating water blowdown discharge structure,
19 two natural draft cooling towers, two mechanical draft cooling towers, electrical switchyard, and
20 an ISFSI (Exelon 2013a).

21 The tallest structures on site are the two natural draft cooling towers at approximately 495 ft
22 (151 m) above the ground (NRC 2006). A visible plume of condensation rising from the cooling
23 towers can be seen when the cooling towers are operating. The height and visibility of the
24 plume depends on weather conditions, such as temperature, humidity, and wind speed. Most
25 cooling tower plumes at Byron occur between the cooling tower top (495 ft (151 m)) and a
26 height of 1,640 ft (500 m). Visible plumes may occasionally rise as high as 9,840 ft (3,000 m),
27 although fewer than 10 percent of plumes are expected to ever exceed 3,280 ft (1,000 m).
28 Visual impacts from natural draft cooling tower plumes at Byron are minimal in the summer and
29 in cloudy weather. Impacts will be greatest on clear and calm winter days when plumes may
30 reach higher elevations.

31 **3.3 Meteorology, Air Quality, and Noise**

32 **3.3.1 Meteorology and Climatology**

33 The Byron site is located near the center of Ogle County in northern Illinois, about 86 ft (139 km)
34 west-northwest of Chicago. The site is located within Rock River Hill Country of the Till Plains
35 Section of the Central Lowland Province in an agricultural area of gently rolling topography
36 (ISGS 2013). The regional climate is continental with cold winters, warm summers, and
37 frequent short fluctuations in temperature, humidity, cloudiness, and wind direction
38 (NCDC 2013a). Weather systems create the wide variety of weather conditions that occur
39 almost daily as a result of varying air masses and passing storm systems. Frequently, the polar
40 jet stream is located near or over Illinois, especially in nonsummer months, which is associated
41 with the creation and movement of low-pressure storm systems characterized by clouds, winds,
42 and precipitation (NCDC 2013a). To some extent, the site is influenced by Lake Michigan,
43 which is located as close as 76 mi (122 km) east of the site (NCDC 2013b).

44 The NRC staff obtained climatological data collected at the Rockford Airport National Weather
45 Service (NWS) station, which is located about 13 mi (21 km) northeast of the site. Additionally,
46 Byron maintains a meteorological facility that consists of a 250-ft (91-m) tower that is

1 instrumented at two levels for wind and ambient temperature measurements (Exelon 2013b).
2 Data from these stations was used to characterize the region's climate and are presented
3 below.

4 For the 5-year period of 2008 to 2012, the average wind speed at the Rockford Airport NWS
5 station was about 8.9 mph (4.0 m/s), with the highest at 10.3 mph (4.6 m/s) in spring and the
6 lowest at 7.2 mph (3.2 m/s) in summer. Albeit not prominent, the prevailing wind direction was
7 from the south (about 9.4 percent of the time). In general, southerly wind components are more
8 frequent, followed by winds from northwesterly quadrant, from west through north. By season,
9 wind blew from the south throughout the year, except from the west-northwest in winter. Wind
10 speeds categorized as calm (less than 1.1 mph (0.5 m/s)) occurred about 14 percent of the
11 time. The predominant wind direction at Byron for the 2008 to 2012 period was from the south
12 with average annual wind speeds of 3.6 to 7.5 mph (1.6 to 3.4 m/s) (Exelon 2013b).

13 For the 62-year period, the annual average temperature at the Rockford Airport NWS station
14 was 9.1 °C (48.3 °F) (NCDC 2013b). January was the coldest month with a mean monthly
15 average of -6.8 °C (19.8 °F), while July was the warmest with a mean monthly average of
16 23.0 °C (73.4 °F). During the same period, the highest temperature of 40.6 °C (105 °F) was
17 reached in July 2012, and the lowest of -32.8 °C (-27 °F) in January 1982. In warmer months,
18 daytime maximum temperatures exceed 32.2 °C (90 °F) about 15 days per year, with a peak of
19 5.7 days in July. A daily minimum temperature at or below freezing is common during colder
20 months (about 133 days per year), and subzero temperatures are recorded on about 11.5 days
21 per year. The number of days with these temperatures peaked in January, about 29 days and
22 5.5 days, respectively. Temperature trends from recent observations (2008 to 2012) at the
23 Byron site (Exelon 2013b) are consistent with temperature observations at the Rockford Airport
24 NWS station.

25 For the 30-year period, annual precipitation at the Rockford Airport NWS station averaged about
26 36.2 in. (92.1 cm) (NCDC 2013b). On average, about 119 days per year have measurable
27 precipitation (0.01 in. (0.025 cm) or higher). Summer is the wettest season, while winter is the
28 driest season. Snow occurs as early as October and as late as April. On average, snowfalls
29 are the highest in December, but peaks can occur in any of the three winter months. For the
30 same period, the annual average snowfall was about 36.7 in. (93.2 cm), with the highest
31 monthly snowfall of 30.2 in. (76.7 cm) in February 1994. Precipitation trends from recent
32 observations (2008 to 2012) made at the Byron site (Exelon 2013b) are consistent with
33 precipitation observations at the Rockford Airport NWS station.

34 Ogle County, where Byron is located, experiences severe weather events, such as floods,
35 thunderstorm winds, and tornadoes. Other significant weather can be associated with these
36 events; for example, lightning, hail, and high winds frequently occur with thunderstorms, and
37 tornadoes can occur with thunderstorms. Since 1996, 10 floods, 49 hail events, and
38 5 tornadoes have been reported in Ogle County (NCDC 2013d). The tornadoes occurring in
39 Ogle County were relatively weak, mostly either F0 or EF1 on the Fujita scale.¹

¹ The original Fujita six-point scale (F0 to F5) was used to rate the intensity of a tornado based on the damage it inflicts to structures and vegetation from the lowest intensity, F0, to the highest, F5. In February 2007, the enhanced Fujita scale replaced the original Fujita scale. The enhanced Fujita scale still uses six categories of tornado intensity (EF0 to EF5), but the new scale more accurately matches wind speeds to the severity of damage caused by the tornado.

1 **3.3.2 Air Quality**

2 Under the Clean Air Act (CAA), the EPA has set primary and secondary National Ambient Air
3 Quality Standards (NAAQS, 40 CFR 50) for six common criteria pollutants to protect sensitive
4 populations and the environment. The NAAQS criteria pollutants include carbon monoxide
5 (CO), lead (Pb), nitrogen dioxide (NO₂), ozone (O₃), sulfur dioxide (SO₂), and particulate matter
6 (PM). Particulate matter is further categorized by size—PM₁₀ (aerodynamic diameter of
7 10 micrometers or less) and PM_{2.5} (aerodynamic diameter of 2.5 micrometers or less).

8 The EPA designates areas of “attainment” and “nonattainment” with respect to the NAAQS.
9 Areas that have insufficient data to determine designation status are denoted as
10 “unclassifiable.” Areas that were once in nonattainment, but are now in attainment, are called
11 “maintenance” areas; these areas are under a 10-year monitoring plan to maintain the
12 attainment designation status. States have primary responsibility for ensuring attainment and
13 maintenance of the NAAQS. Under section 110 of the CAA (42 U.S.C. 7410) and related
14 provisions, states are to submit, for EPA approval, State Implementation Plans (SIPs) that
15 provide for the timely attainment and maintenance of the NAAQS.

16 Air quality designations are generally made at the county level. For the purpose of planning and
17 maintaining ambient air quality with respect to the NAAQS, EPA has developed Air Quality
18 Control Regions (AQCRs). Air Quality Control Regions are intrastate or interstate areas that
19 share a common airshed (40 CFR 81). The Byron site is located in Ogle County, Illinois; this
20 county, along with the other four neighboring counties in Illinois and one county in Wisconsin,
21 compose the Rockford (Illinois)-Janesville-Beloit (Wisconsin) Interstate AQCR (40 CFR 81.71).
22 With regard to the NAAQS criteria pollutants, Ogle County is designated as an
23 attainment/unclassifiable area for all criteria pollutants (40 CFR 81.314). Nearby designated
24 nonattainment areas are McHenry County and Kane County for 8-hour ozone and PM_{2.5}, which
25 are about 30 mi (49 km) east-northeast of and 35 mi (56 km) east of the site, respectively.
26 McHenry County and Kane County are also designated maintenance areas for the PM_{2.5}
27 standard (78 FR 60704).

28 Byron has a number of stationary emission sources permitted through its Federally Enforceable
29 State Operating Permit (FESOP Permit No. 141820AAA); these include standby emergency
30 diesel generators, auxiliary boilers, auxiliary feedwater pumps, essential service water makeup
31 water pumps, a fire pump, and two natural draft and two mechanical draft cooling towers
32 (IEPA 2002). A source is eligible for a FESOP (also known as “synthetic minor” air permit) if the
33 potential to emit (PTE) from the source triggers CAA Permit Program requirements, but
34 maximum actual emissions are below, or can be restricted to remain below, major source
35 thresholds. As reported and submitted to the Illinois Environmental Protection Agency (IEPA),
36 actual total emissions from all sources at Byron from 2008 to 2012 are presented in Table 3–1
37 (Exelon 2009a, 2010a, 2011a, 2012a, 2013c). Annual emissions vary from year to year, but the
38 highest emissions were reported in 2012. Byron has been in compliance with the requirements
39 set forth in the air permit and there are no reported violations since October 1, 2011
40 (EPA 2014a).

1 **Table 3–1. Air Emission Estimates for Permitted Combustion Sources at Byron** ^(a)

	NO _x (t) ^(b)	CO (t) ^(b)	SO _x (t) ^(b)	PM _{2.5} (t) ^(b)	PM ₁₀ (t) ^(b)	VOC (t) ^(b)	CO ₂ e (t) ^(b)
2008	18.83	4.98	0.05	20.32	20.32	0.63	965
2009	24.51	6.50	0.04	20.83	20.83	0.72	1,257
2010	21.35	5.66	0.02	20.42	20.42	0.71	1,099
2011	21.30	5.65	0.02	21.13	21.13	0.67	1,101
2012	28.29	7.51	0.02	23.12	23.13	0.90	1,501

^(a) NO_x = nitrogen oxides; CO = carbon monoxide; SO_x = sulfur oxides; PM_{2.5} = particulate matter with an aerodynamic diameter of 2.5 micrometers or less; PM₁₀ = particulate matter with an aerodynamic diameter of 10 micrometers or less; VOC = volatile organic compound; CO₂e = carbon dioxide equivalent.

^(b) To convert t (short tons) to MT (metric tons), multiply by 0.9072.

Sources: Exelon 2009a, 2010a, 2011a, 2012a, 2013c

2 On October 30, 2009, EPA published a rule for the mandatory reporting of greenhouse gases
 3 (GHGs) from sources that in general emit 25,000 MT or more of carbon dioxide equivalent
 4 (CO₂e)² per year in the United States (74 FR 56260). Most small facilities across all sectors of
 5 the economy fall below the 25,000-MT threshold and are not required to report GHG emissions
 6 to EPA. On June 3, 2010, EPA promulgated the Prevention of Significant Deterioration (PSD)
 7 and Title V GHG Tailoring Rule (75 FR 31514). Beginning January 2, 2011³, operating permits
 8 issued to major sources of GHG under the prevention of significant deterioration (PSD) or
 9 Title V Federal permit programs must contain provisions requiring the use of best available
 10 control technology (BACT) to limit the emissions of GHGs if those sources would be subject to
 11 PSD or Title V permitting requirements because of their non-GHG pollutant emission potentials
 12 and their estimated GHG emissions are at least 75,000 tons/yr of CO₂ equivalents (CO₂e). As
 13 discussed above, Byron is a synthetic minor source and as shown in Table 3–1, GHG emissions
 14 from combustion sources at Byron are below the GHG Mandatory Reporting and Tailoring Rules
 15 thresholds; therefore, the NRC staff anticipates that Byron would be exempted from GHG
 16 emission limits. Additional GHG emission discussions are presented in Section 4.14 of this
 17 SEIS.

18 EPA promulgated the Regional Haze Rule to improve and protect visibility in national parks and
 19 wilderness areas from haze, which is caused by numerous, diverse sources located across a
 20 broad region (40 CFR 51.308–309). Specifically, 40 CFR 81 Subpart D lists mandatory Class I
 21 Federal Areas where visibility is an important value. The Regional Haze Rule requires states to
 22 develop SIPs to reduce visibility impairment at Class I Federal Areas. The nearest⁴ Class I

² Carbon dioxide equivalents (CO₂e) is a metric used to compare the emissions of GHG based on their global warming potential (GWP). GWP is a measure used to compare how much heat a GHG traps in the atmosphere. GWP is the total energy that a gas absorbs over a period of time, compared to carbon dioxide. Carbon dioxide equivalent is obtained by multiplying the amount of the GHG by the associated GWP. For example, the GWP of methane (CH₄) is estimated to be 21; therefore, 1 t of methane emission is equivalent to 21 t of carbon dioxide emissions.

³ On June 23, 2014, the U.S. Supreme Court issued a decision that the EPA may not treat GHGs as an air pollutant for purposes of determining whether a source is a major source required to obtain a PSD or Title V permit, but could continue to require PSD and Title V permits, otherwise required based on emissions of conventional pollutants. In July 2014, the EPA issued a memorandum in response to the Supreme Court’s decision and acknowledged that, while the decision is pending judicial action, the EPA will no longer require PSD or Title V permits for GHG-emitting sources that are not sources subject to PSD or Title V permits based on emissions of conventional pollutants (nitrogen oxides, carbon monoxide, etc.) (EPA 2014c).

⁴ Rainbow Lake in Wisconsin is a Mandatory Federal Class I area where visibility is not an important air quality-related value. In 1980 Rainbow Lake was excluded for purposes of visibility protection as a Class I area. Rainbow Lake is approximately 505 km (314 mi) north-northwest of Byron.

Affected Environment

1 Federal area for visibility protection is the Seney Wilderness Area in Michigan (40 CFR 81.414),
2 about 323 mi (520 km) north-northeast of the Byron site. The next nearest Class I area is the
3 Mingo Wilderness Area in Missouri (40 CFR 81.416), which is located about 350 mi 563 km
4 south of the site. Considering the distances to the nearest Class I areas and the minor nature of
5 air emissions from the site, there is little likelihood that activities at the Byron site could
6 adversely affect air quality and air quality-related values (e.g., visibility or acid deposition) in any
7 of the Class I areas.

8 3.3.3 Noise

9 Any pressure variation that the human ear can detect is considered as sound, and noise is
10 defined as unwanted sound. Sound is described in terms of amplitude (perceived as loudness)
11 and frequency (perceived as pitch). Sound pressure levels are typically measured by using the
12 logarithmic decibel scale. A-weighting (denoted by dBA) (ASA 1983, 1985) is widely used to
13 account for human sensitivity to frequencies of sound (i.e., less sensitive to lower and higher
14 frequencies and most sensitive to sounds between 1 and 5 kilohertz), which correlates well with
15 a human's subjective reaction to sound. Several sound descriptors have been developed to
16 account for variations of sound with time. The equivalent continuous sound level (L_{eq}) is a
17 sound level that, if it were continuous during a specific time period, would contain the same total
18 energy as a time-varying sound. Unless designated otherwise, all sound levels are
19 instantaneous or L_{eq} values measured over short time periods. In addition, human responses to
20 noise differ depending on the time of the day (e.g., higher sensitivity to noise during nighttime
21 hours because of lower background noise levels). The day-night average sound level (L_{dn}) is a
22 single dBA value calculated from hourly L_{eq} over a 24-hour period, with the addition of 10 dBA to
23 sound levels from 10 p.m. to 7 a.m. to account for the greater sensitivity of most people to
24 nighttime noise. Generally, a 3-dBA change over existing noise levels is considered to be a
25 "just noticeable" difference, and a 10-dBA increase is subjectively perceived as a doubling in
26 loudness and almost always causes an adverse community response (NWCC 2002). Table 3–2
27 presents common sound sources and their respective noise levels.

28

Table 3–2. Common Noise Sources and Noise Levels

Source	Noise Level (dBA)
Jet plane (at 100 ft distance)	130
Diesel truck (at 30 ft distance)	100
Food blender (at 3 ft distance)	90
Car (50 mph at 50 ft distance)	65
Conversation	55
Threshold of hearing	0

Sources: MMSHT 2008; SFU 1999

29 Nuclear power generation is an industrial process that can generate noise. Example noise
30 sources at the Byron site include cooling towers, ventilation supply and exhaust fans,
31 transformers, intake water pumps, transmission lines (corona discharge), relief valves, onsite
32 vehicle traffic (commuter or delivery trucks), and shooting range activities (Exelon 2013c).
33 Cooling towers and transformers are the primary contributing noise source as they are located
34 outdoors and attributed to continuous plant operation.

1 In addition to natural background noise (e.g., birds chipping, wind), noise sources around Byron
2 include agricultural activities, local traffic on rural roads, recreational activities (e.g., motorsports
3 park), nearby community activities and events, and infrequent aircraft overflights. Nearby
4 noise sensitive receptors include several residences (mostly farmhouses) scattered around the
5 site but are more than 0.6 mi (9 km) from primary noise sources at Byron and a church
6 (Ebenezer Reformed Church), which is located about 1.0 mi (1.6 km) south of primary noise
7 sources at Byron (Exelon 2013b). Noise modeling studies were made at four receptor locations
8 within and around the site property line (Exelon 2013b). Predicted noise levels ranged between
9 50 and 57 dBA L_{dn} , considering both the background and station contributions.

10 The activities at Byron would have to follow applicable Federal, State, or local guidelines and
11 regulations on noise. Illinois has a noise regulation with allowable octave-band sound levels
12 according to emitting and receiving land-use classification and time of day (IAC, Title 35:
13 Environmental Protection, Subtitle H: Noise). The predicted noise levels from station
14 operations are estimated to be below Illinois noise regulations (Exelon 2013b). Ogle County
15 has noise ordinances with nuisance clauses against noise but has established no quantitative
16 noise limits (Ogle County 2013). EPA uses a threshold level of 55 dBA L_{dn} to protect against
17 excess noise during outdoor activities (EPA 1974). However, according to EPA this threshold
18 does “not constitute a standard, specification, or regulation,” but was intended to provide a basis
19 for State and local governments establishing noise standards (EPA 1974). The Department of
20 Housing and Urban Development (HUD) has established noise assessment guidelines and finds
21 that a noise level of 65 dBA L_{dn} or less is acceptable (HUD 2013).

22 **3.4 Geologic Environment**

23 This section describes the geologic environment of the Byron site and vicinity, including
24 landforms, geology, soils, and seismic conditions.


25 **3.4.1 Physiography and Geology**

26 The Byron site is located in the Rock River Hill Country Subsection of the Till Plains Section of
27 the Central Lowlands Physiographic Province (Leighton et al. 1948). This subsection is
28 characterized by gently rolling, dissected uplands covered by thin layers of glacial drift deposits
29 (geologic material deposited by glaciers or glacier associated streams and lakes). The
30 southwest-trending Rock River Valley runs through the eastern portion of the subsection.

31 The bedrock surface controls the topography (Figure 3–6), which consists of well-developed
32 drainages surrounded by subdued rolling hills and some sharp ridges containing local
33 exposures of bedrock (USACE 2006). Relatively thin glacial drift deposits of sand, silt, and
34 glacial till (poorly sorted nonstratified sand, silt, and gravel) overlie the bedrock surface. The
35 power station was constructed in an area where the bedrock is close to the land surface, and
36 the foundation of the generating facility was built into the bedrock. Depth to bedrock increases
37 near the Rock River, which is underlain by alluvium (stream deposits). The underlying bedrock
38 consists of 2,000 to 3,000 ft (610 to 910 m) of dolomite, sandstone, and shale rock. In turn,
39 these rocks are underlain by granites and granodiorites to a great depth (CRA 2006).

1

Figure 3-6. Site Topography



2

3

Source: CRA 2006

4

3.4.2 Soils

5

At Byron, most of the soils have formed in glacial drift. The soils developed in geologic material that was directly deposited by the glacier (moraine deposits), or deposited by melting glacial ice water (outwash deposits), or by wind (loess and dune deposits), or deposited by the Rock River and local streams. Almost all of these soils contain a large amount of fine-grained silt-sized

8

1 material. Within the site boundary and along the pipeline that runs between the site and the
2 river, most of the soils formed in moraine or outwash deposits. These soils are well-drained and
3 are classified as silty loam or loam (USDA 2013).

4 **3.4.3 Seismic Setting**

5 The only reported injury from an earthquake that occurred in Illinois happened on April 12, 1883,
6 when an old frame house was shaken down, resulting in slight injury to the inhabitants.
7 A number of earthquakes (USGS 2013a, 2013b, 2013c) have originated within Illinois and
8 include:

- 9 • May 26, 1909, a large earthquake knocked over many chimneys in Aurora
10 and swayed buildings in Chicago.
- 11 • July 18, 1909, an earthquake knocked down chimneys in Petersburg.
- 12 • August 14, 1965, a sharp local earthquake knocked down chimneys at Elco,
13 Unity, Olive Branch, and Olmstead.
- 14 • November 9, 1968, a magnitude 5.3 earthquake was felt over a large area.

15 Dozens of earthquakes originating outside Illinois have been felt inside the State without
16 causing damage. These earthquakes originated in Missouri, Arkansas, Kansas, Nebraska,
17 Tennessee, Indiana, Ohio, Michigan, Kentucky, and Canada. However, southern Illinois could
18 experience major damage should a large-magnitude earthquake occur in the New Madrid
19 Seismic Zone (located in southern Illinois and neighboring states) (MODNR 2013; USGS 2009).
20 The site is located in northeast Illinois, which has a very small probability of experiencing
21 damaging earthquakes (FEMA 2013; MAE Center 2009). The NRC requires every nuclear plant
22 to be designed for site-specific ground motions that are appropriate for its location.

23 **3.5 Water Resources**

24 **3.5.1 Surface Water Resources**


25 This section describes surface water resources within and near Byron.

26 *3.5.1.1 Surface Water Hydrology*

27 The Rock River is the major surface water body in the region. It is located about 2 mi (3.2 km)
28 to the west of Byron. The Rock River originates in southeastern Wisconsin and flows in a
29 southwesterly direction into Illinois, ultimately discharging into the Mississippi River just
30 downstream of Rock Island, Illinois (Figure 3–7). In total, the Rock River is approximately
31 318 mi (512 km) long, with about 163 mi (262 km) of that length in Illinois (IEPA 2006;
32 Sinclair 1996). There are eight major dams on the river's main stem: Milan, Sterling, Rock
33 Falls, Dixon, Oregon, Rockford, Rockton Spillway Lower, and Rockton Spillway Upper. These
34 dams originally were built in the mid-1800s to early 1900s and are typically 10 to 15 ft (3 to 5 m)
35 high (Knapp and Russell 2004). The dam at the City of Oregon, about 5 mi (8 km) downstream
36 of Byron intake structure, forms the pool from which the station withdraws its makeup water and
37 to which it discharges (Exelon 2013f; IEPA 2006).

1

Figure 3–7. Rock River Basin in Illinois and Wisconsin



2

3


Source: modified from Knapp and Russell 2004

4
5
6
7
8
9
10
11

The river screen house (intake structure) at the Byron site is located on the Rock River's east bank at RM 115 (RKm 185) upstream from the river's confluence with the Mississippi River (Exelon 2013b). The USGS maintains a stream gaging station on the Rock River at the City of Byron, Illinois (station 05440700). This gage is located approximately 5 mi (8 km) upstream of the river screen house. Another stream gaging station is located at Como, Illinois (station 05443500). This gage is located approximately 46 mi (74 km) downstream of the river screen house (see Figure 3–8) (USGS 2013d). Discharge data from the City of Byron gage dates back only to May 2000 (12 years of record). Therefore, it may not be most representative

1 of long-term river flow variability. The USGS gaging station at Como, Illinois, has a much longer
 2 reported record of river discharge (77 years). The mean annual river discharge measured at the
 3 USGS gage at Como, Illinois, for water years 1935 through 2012, is 6,033 cfs (170 m³/s). The
 4 lowest average annual mean flow recorded over the period of record is 2,187 cfs (61.9 m³/s).
 5 The mean 90 percent exceedance flow is 1,760 cfs (49.7 m³/s) for the period of record. The
 6 90 percent exceedance flow is an indicator value of hydrologic drought in a watershed
 7 (USGS 2013d, 20113e).

8 **Figure 3–8. The Rock River and USGS Stream Gaging Stations in the Vicinity of Byron**



9

Source: NRC Generated

10

11 At the plant site, the only notable surface water body is an engineered retention pond called the
 12 Construction Runoff Pond. This pond is part of the plant's storm drainage system and receives
 13 surface water runoff from the immediate vicinity of the plant. Prior to surface water reaching the
 14 pond, it passes through an oil-water separator. Discharges from this pond and all site storm
 15 water discharge is governed by the site's Storm Water Pollution Prevention Plan
 16 (Exelon 2013a). Storm water collected in the Construction Runoff Pond either flows to the
 17 Unit 2 natural draft cooling tower basin where it becomes part of the circulating water system or
 18 it flows through NPDES Outfall 003 via drainage ditches located along German Church Road to
 19 the north of the main plant complex. From there the water ultimately flows to Woodland Creek
 20 and from Woodland Creek to the Rock River (Exelon 2013a, 2013b). Byron's Storm Water
 21 Pollution Prevention Plan is implemented and maintained to comply with Special Condition 16 of
 22 the site's Illinois-issued NPDES permit. The site's NPDES permit is further discussed in
 23 Section 3.5.1.3.

Affected Environment

1 3.5.1.2 Surface Water Use

2 As summarized in Section 3.1.3, Byron withdraws surface water from the Rock River to provide
3 cooling water to the plant's steam turbine condensers and, secondarily, to the plant's
4 nonessential service water (i.e., non-safety-related) system. Cooling tower blowdown and other
5 permitted effluent streams are discharged back to the Rock River via the plant's primary NPDES
6 outfall (Outfall 001) at a point located about 200 ft (61 m) downstream of the plant's intake at the
7 river screen house.

8 Exelon reports that Byron's average makeup withdrawal rate has averaged about 36,750 gpm
9 (81.9 cfs or 2.31 m³/s), or about 52.9 million gallons per day (mgd) (200,000 m³/day)
10 (Exelon 2013a). NRC staff reviewed submittals by Exelon to the Illinois State Water Survey that
11 recorded the volume of water intake and discharge from 2008 to 2012 (Table 3–3). Over that
12 time period, Byron's surface water withdrawals averaged 83.2 cfs (2.35 m³/s or 53.8 mgd) and
13 the plant discharge rate to the Rock River averaged 30.3 cfs (0.86 m³/s or 19.6 mgd). The
14 remaining 52.9 cfs (1.5 m³/s or 34.2 mgd) was consumed by the plant and lost to the
15 atmosphere by evaporation and drift. In contrast, the maximum (nominal) surface water
16 withdrawal rate for Byron Units 1 and 2 is 45,200 gpm (101 cfs or 2.85 m³/s). This is equivalent
17 to 65 mgd (246,000 m³/day) (Exelon 2013a).

18 **Table 3–3. Annual Surface Water Withdrawals and Return Discharges to the Rock River,**
19 **Byron**

Year	Withdrawals (mgy)	mgd	Discharges (mgy)	mgd
2008	19,142.4	52.4	7,083.0	19.4
2009	20,239.5	55.5	7,272.9	19.9
2010	20,265.0	55.5	7,462.9	20.4
2011	18,966.8	52.0	7,003.1	19.2
2012	19,530.0	53.5	6,855.1	18.8
Average	19,628.7	53.8	7,135.4	19.6

Note: Reported values are rounded. To convert million gallons per year (mgy) to million cubic meters (m³), divide by 264.2.

Sources: Exelon 2008, 2009c, 2010d, 2011c, 2012e

20 Exelon limits the consumption of water from the Rock River by the Byron cooling systems
21 (Exelon 2013b) to no more than 9 percent of total river flow when river flow is at or below
22 679 cfs (19.2 m³/s) (Exelon 2013b). This limit was established by an April 1977 construction
23 permit (No. 15001) from the IDOT, Division of Water Resources. The construction permit also
24 contains a requirement that limits Byron's maximum makeup withdrawal rate from the river to
25 125 cfs (3.5 m³/s) (Exelon 2013a, 2013b). This operational limit is prescribed by Byron's
26 UFSAR (Exelon 2012d). A Byron plant operating procedure stipulates actions that plant
27 personnel must take during low river flow. In summary, plant personnel monitor river flow using
28 NWS and USGS data. When the river flow at the river screen house falls to 2,400 cfs
29 (67.8 m³/s) or less, daily monitoring of river flow is performed. If the calculated river flow falls to
30 679 cfs (19.2 m³/s), personnel then begin to calculate and monitor consumptive water use. If
31 consumptive use exceeds 9 percent of river flow, the procedure dictates that circulating water
32 makeup and blowdown flows are to be reduced until the consumption of river water falls below

1 9 percent of the flow in the river. If further action is needed, the procedure requires the power
2 output of the reactor units to be reduced to further lower consumptive water use (Exelon 2013b).

3 *3.5.1.3 Surface Water Quality and Effluents*

4 The Illinois Pollution Control Board, a sister Agency to the Illinois EPA, promulgates water
5 quality standards in Illinois. Two Sections of Title 35 of the IAC (35 IAC 302; 35 IAC 303)
6 contain standards applicable to lakes and streams. Procedures for the use of water quality
7 standards in setting NPDES permit limits are found in Section 309 (35 IAC 309). Designated
8 uses prescribed by 35 IAC 303 are those uses specified in water quality standards for each
9 lake, river, stream, and groundwater resource. In designating uses for a water body, the Illinois
10 Pollution Control Board takes into consideration a water body's value for public water supply; for
11 propagation of fish, shellfish, and wildlife; and for recreational, agricultural, industrial, and
12 navigational purposes (IEPA 2006).

13 The Rock River is designated as "general use water" by the Illinois Pollution Control Board.
14 Water bodies designated as "general use water" must meet water quality standards protective of
15 aquatic life, wildlife, agricultural use, secondary contact use, as well as most industrial uses and
16 aesthetic quality (35 IAC 303). These standards pertain to pH, phosphorus, dissolved oxygen,
17 radioactivity (gross beta, strontium-90, and radium-226 and -228), and various chemical
18 constituents (metals and organic compounds), fecal coliform, and other toxic substances (as
19 appropriate). Section 303(d) of the Federal Clean Water Act (CWA) requires the State of Illinois
20 and other states to identify all "impaired" waters for which effluent limitations and pollution
21 control activities are not sufficient to attain water quality standards (33 U.S.C. 1251
22 Section 303d). The 303(d) list identifies stream segments that require the development of total
23 maximum daily loads to assure future compliance with water quality standards. The IEPA has
24 identified a 25.1-mi (~42-km) long segment of the Rock River that includes the Byron site as
25 impaired, because it does not meet water quality standards for three contaminants due to
26 contamination from polychlorinated biphenyls (PCBs), mercury, and ethanol attributable to
27 various upstream sources (IEPA 2012).

28 The water quality of surface water discharges is regulated by the IEPA via the NPDES program.
29 NPDES permits are issued by the IEPA on a 5-year cycle. Byron is currently operating under
30 NPDES Permit No. IL0048313, issued on January 24, 2011; the permit expires on
31 December 31, 2015 (Exelon 2013b; IEPA 2011). It specifies discharge standards and
32 monitoring requirements for chemical releases, water temperatures, and for storm water
33 discharges through the plant's outfalls to the Rock River and its tributaries. The outfalls are
34 described in Table 3-4 and mapped in Figure 3-9.

35 The NPDES permit requires Exelon to monitor the flow rate, pH, suspended solids, and
36 temperature of its cooling system blowdown discharge to the Rock River through its primary
37 outfall (Outfall 001); other parameters include metals (zinc, iron, lead, copper, nickel, and
38 chromium), hydrazine (an anticorrosive agent), oil and grease, 126 priority pollutants, and total
39 residual chlorine/total residual oxidant (biocides agents). Sampling results are reported in
40 monthly discharge monitoring reports submitted to the State. NRC staff reviewed discharge
41 monitoring reports from 2008 through 2012 (Exelon 2013b) and found no "notice of violations" of
42 NPDES permit requirements, unusual conditions of operations, or that effluent limitations were
43 exceeded. As previously noted in Section 3.5.1.1, Exelon has prepared a storm water
44 protection plan for Byron to manage its storm water discharges in compliance with Special
45 Condition 16 of Byron's NPDES permit.

Affected Environment

1 **Table 3–4. National Pollutant Discharge Elimination System-Permitted Outfalls, Byron^(a)**

Outfalls	Average Flow Rate (mgd)	Description
001	20.3	Cooling tower blowdown; nonessential and essential service water blowdown and strainer backwash; discharges to the Rock River via rip-rapped channel
A01	0.019	Demineralizer regenerant waste; discharges via Outfall 001
B01	0.008	Sewage treatment plant effluent; discharges via Outfall 001
C01	0.028	Wastewater treatment plant effluent; discharges via Outfall 001
D01	0.022	Radwaste treatment plant effluent; discharges via Outfall 001
E01	0.119	Storm water runoff basin; discharges via Outfall 001
F01	Intermittent	Intake screen backwash; discharges to the Rock River via Outfall 001
002	Intermittent	Stormwater runoff basin overflow to Woodland Creek
003	Intermittent	East station area runoff to Woodland Creek
004	Intermittent	West station area runoff to unnamed tributary to Rock River

Note: To convert million gallons per day (mgd) to million cubic meters (m³), divide by 264.2.

^(a) Special Conditions 3 and 12 of the NPDES permit restrict temperature changes in the river and require Exelon to monitor the temperature of its discharge and provide the results in its monthly discharge monitoring report to the IEPA. When the river flow is less than 2,400 cfs (67.8 m³/s) and/or the temperature differential between the main river temperature and the water quality standard is less than 3 °F (1.7 °C), compliance is to be demonstrated by calculations based on hourly measurements (averaged over a 24-hour period) of river flow, main river temperature, blowdown flow, and blowdown temperature values.

Outfalls A01, B01, C01, D01, E01, and F01 are internal monitoring stations for Outfall 001.


Source: IEPA 2011

2 An applicant (in this case Exelon) for a Federal license to conduct activities that may cause a
 3 discharge of regulated pollutants into navigable waters is required by Section 401 of the CWA to
 4 provide the licensing agency (in this case NRC) with water quality certification from the state (in
 5 this case the State of Illinois). This certification implies that discharges from the project or
 6 facility to be licensed will comply with CWA requirements and will not cause or contribute to a
 7 violation of state water quality standards. If the applicant has not received Section 401
 8 certification, the NRC cannot issue a renewed license unless that state has waived the
 9 requirement. The NRC recognizes that some NPDES-delegated states explicitly integrate their
 10 401 certification process with NPDES permit issuance. However, Byron’s NPDES permit does
 11 not explicitly convey water quality certification under CWA Section 401.

12 The Rock Island District of the U.S. Army Corps of Engineers (USACE) sent a letter to Exelon in
 13 October 2012 stating that no permit was required from USACE and that it had no objection to
 14 renewing the Section 401 certification for Byron (Exelon 2013b). Previously, by letter dated
 15 July 2, 2012, Exelon submitted an application to the IEPA Bureau of Water Pollution Control
 16 requesting certification that renewal of the plant’s NRC operating licenses would not violate
 17 state water quality standards (Exelon 2013b).

1

Figure 3-9. NPDES Discharge Locations



2

3

Source: modified from Exelon 2013b

Affected Environment

1 In July 2013, the IEPA Division of Water Pollution Control responded to the Exelon request and
2 sent a letter to the NRC regarding Byron's 401 certification providing the 401 certification
3 subject to inclusion of two conditions into the NRC license for Byron (IEPA 2013).
4 In November 2014, NRC staff responded to IEPA, noting that since the two conditions are
5 license requirements either because they are imposed as a matter of law or they state existing
6 statutory provisions, no further NRC action is needed with respect to these two conditions.
7 Specifically, (1) Exelon must obtain CWA Section 402 (NPDES) permits from the State in
8 accordance with 33 U.S.C. § 1342, and (2) a 401 certification does not authorize activities that
9 require authorizations under Section 404 of the CWA, 33 U.S.C. § 1344 (i.e., the permits for
10 discharges of dredged or fill material, which are issued by the USACE) (NRC 2014b).

11 To maintain the surface water intake system at the river screen house (see Section 3.1.3),
12 Exelon conducts dredging to remove accumulated river sediment. The river bottom in the
13 vicinity of the intake was engineered during plant construction to prevent the buildup of
14 sediment and to maintain a connection to the cooler water in the main river channel.
15 Specifically, a system of upstream wing dams and precast concrete turning vanes was
16 constructed which directs cooling water toward the intakes while reducing scour and erosion of
17 the opposite river bank (Exelon 2012d). While there is no prescribed frequency for dredging,
18 divers are used to periodically examine intake area to assess the need to remove sediment.
19 Dredging was performed at the river screen house in 2001 and again in 2007. Historically, both
20 mechanical and hydraulic dredging has been conducted, with diver-assisted hydraulic dredging
21 conducted most recently. Dredged river sediment is placed in a retention pond located in an
22 upland area near the river screen house. Maintenance dredging at Byron is conducted via
23 USACE Nationwide Permits in accordance with Section 10 of the Rivers and Harbors
24 Appropriation Act of 1899 and Section 404 of the Clean Water Act (33 U.S.C. 403 Section 10
25 and 33 U.S.C. 1251 Section 404). Permit coverage for maintenance dredging activities at Byron
26 was reaffirmed in a letter from the USACE to Exelon in September 2012 (Exelon 2013b).

27 **3.5.2 Groundwater Resources**

28 This section describes the current groundwater resources within and near the Byron.


29 *3.5.2.1 Site Description and Hydrogeology*

30 There are four significant hydrogeologic units in the area of Byron. These are (in order of
31 increasing depth) (1) the glacial drift, (2) the Galena-Platteville Dolomite aquifer, (3) the
32 sandstone units of the Cambrian-Ordovician Aquifer System (including the St. Peter Sandstone
33 and Ironton-Galesville Sandstone aquifers), and (4) the Mt. Simon Sandstone aquifer
34 (Figure 3–10). Glacial drift occurs as a thin mantle across the site, with the depth to the
35 underlying bedrock varying from zero to 12 ft (3.7 m). Groundwater in the glacial drift is
36 recharged by local precipitation. Because it is thin and has low permeability, the glacial drift has
37 not been developed as a source of groundwater on a large scale (CRA 2006; Exelon 2013b).

38 The Galena-Platteville Dolomite aquifer underlies the glacial drift. It ranges in thickness from
39 100 to 225 ft (31 to 69 m). As with the glacial drift, recharge is by local precipitation.
40 Groundwater in the glacial drift and in the Galena-Platteville Dolomite aquifer forms the local
41 water table (CRA 2006; Kay et al. 1997). Groundwater movement in a water-table aquifer
42 generally follows the local topography. Because Byron is situated on a topographic high,
43 groundwater in the glacial drift and Galena-Platteville Dolomite aquifer flows from the site and
44 discharges into the alluvium along the Rock River (Avery 1994). Groundwater in the
45 Galena-Platteville Dolomite aquifer flows through the porous rock matrix and through fractures,
46 joints, and solution openings. The aquifer provides modest yields for domestic use (Avery 1994;
47 Exelon 2013b; IDNR 2002a; Kay et al. 1997).

1

Figure 3-10. Generalized Hydrogeologic Column of Byron



2

3

Source: NRC Staff Generated

Affected Environment

1 The Galena-Platteville Dolomite aquifer is underlain by the Glenwood Formation, which is 37 ft
2 (11.3 m) thick and is made up of sandstone, dolomite, and shale beds. The Harmony Hill Shale
3 forms the top of this formation (Kay et al. 1997). This shale does not readily transmit
4 groundwater (due to low permeability) and is about 5 ft (1.5 m) thick. Along with other shales,
5 within the Glenwood Formation, it forms a semiconfining layer above the underlying St. Peter
6 Sandstone aquifer (Kay et al. 1997) (Figure 3–11).


7 The St. Peter Sandstone aquifer underlies the Glenwood Formation. It is about 420 ft (128 m)
8 thick and is a regional aquifer (Kay et al. 1997). It is fully saturated and, because of the shale
9 beds within the overlying Glenwood Formation, it is semiconfined. However, near the Rock
10 River, the St. Peter Sandstone aquifer is unconfined (under water table conditions), as the
11 overlying geologic units have been eroded away at that location (Kay et al. 1997). The
12 groundwater recharge areas of the St. Peter Sandstone lie outside the Byron site area in
13 northern Illinois and southern Wisconsin. However, locally it does receive some additional
14 groundwater recharge by vertical leakage through the Glenwood Formation (CRA 2006). From
15 the site, groundwater in the St. Peter Sandstone aquifer flows westward and discharges to the
16 alluvium along the Rock River (Avery 1994; Kay et al. 1997). As a regional aquifer, the
17 St. Peter Sandstone aquifer supplies small municipalities and domestic and industrial activities
18 that have water needs of less than 200 gpm (757 liters per minute (L/min)) (Avery 1994;
19 Kay et al. 1997).

20 The St. Peter Sandstone aquifer is underlain by the Prairie du Chien Group, Eminence
21 Formation, Potosi Dolomite, and Franconia Formation. These units are comprised mainly of
22 dolomite and shale with some sandstone. These units are an estimated 150 ft (46 m) thick
23 (Visocky et al. 1985) and act as a “confining unit” between the St. Peter Sandstone aquifer and
24 the underlying Ironton-Galesville Sandstone aquifer (Burch 2008).

25 The Ironton-Galesville Sandstone aquifer can be a productive source of groundwater and has
26 an estimated thickness of about 150 ft (46 m). Together the St. Peter Sandstone aquifer and
27 the Ironton-Galesville Sandstone aquifer make up the regional aquifer known as the
28 Cambrian-Ordovician Aquifer System. This system is a significant source of water across
29 northern Illinois (Burch 2008). The Eau Claire Formation underlies the Ironton-Galesville
30 Sandstone aquifer. It has an estimated thickness of 200 ft (61 m). Because of its shale content,
31 it is not considered to be an aquifer and acts as an aquitard (confining unit) (Sasman and
32 Baker 1966; Visocky et al. 1985).

33 The Eau Claire Formation is underlain by the Mt. Simon Sandstone aquifer, which is a fine- to
34 course-grained sandstone with gravel. The Mt. Simon Sandstone aquifer has an estimated
35 thickness of about 1,500 to 2,000 ft (457 to 610 m) thick. It is capable of yielding moderate
36 amounts of water (Sasman and Baker 1966; Visocky et al. 1985). Deeper sections of the
37 Mt. Simon Sandstone aquifer (1,300 ft below sea level) are commonly too salty for municipal
38 use (Sasman and Baker 1966).

Figure 3-11. Generalized East-West Hydrogeologic Cross Section



Source: modified from CRA 2006

Affected Environment

1 3.5.2.2 Groundwater Use

2 Most of the water for municipal, domestic, and industrial use in the region is obtained from the
3 St. Peter Sandstone aquifer. The nearest public water supply is the Northern Illinois University
4 Lorado Taft field campus well field, located about 3.5 mi (5.6 km) to the southwest of the Byron.
5 Here groundwater is withdrawn from two wells completed in the St. Peter Sandstone aquifer.
6 The City of Byron, located about 4 mi (6.4 km) northwest of the station, uses groundwater from
7 wells completed in the Ironton-Galesville Sandstone and Mt. Simon Sandstone aquifers
8 (Exelon 2013b).

9 Two wells, W-1 and W-2, provide Byron with all its potable and demineralizer water supplies.
10 The onsite wells extend to a depth of 1,500 ft (457 m) and produce water from the Ironton-
11 Galesville Sandstone and the Mt. Simon Sandstone aquifers. Each well has a maximum
12 capacity of 800 gpm (3,028 L/min) and when both wells are in operation, they can supply Byron
13 with water at 1,600 gpm (6,056 L/min). This high pumping capacity is available as an
14 emergency backup water supply, in the event that essential cooling tower makeup water is not
15 available from the Rock River. Exelon files annual reports documenting its groundwater
16 withdrawals with the Illinois State Water Survey (Exelon 2013b). Groundwater consumption
17 varies depending on the activities conducted at the plant. The peak demand for groundwater is
18 usually associated with refueling and maintenance activities. This activity could require up to
19 470 gpm (1,779 L/min) (Exelon 2013b). However, this rate of groundwater consumption is of
20 short duration. As a result, yearly groundwater use between 2008 and 2012 ranged from
21 18 gpm to 43 gpm (68 to 163 L/min) and averaged 30 gpm (114 L/min) (Exelon 2009c, 2010d,
22 2011c, 2012e; Teledyne 2008).

23 3.5.2.3 Groundwater Quality

24 All of the groundwater aquifers previously discussed can supply good quality water. However,
25 northwest of the site, groundwater quality in the Galena-Platteville Dolomite aquifer has been
26 contaminated and degraded by the Byron Salvage Yard Superfund Site. The Byron Salvage
27 Yard Superfund Site occupies an area of about 180 ac (73 ha) near the northwest corner of the
28 Byron site (IDPH 2005). The groundwater quality at the Byron Salvage Yard Superfund Site
29 was not contaminated by any activities associated with Byron. During the 1960s and 1970s, the
30 owner of the Byron Salvage Yard accepted electroplating wastes and other waste materials
31 such as oil sludge, paint sludge, cutting wheels, solvents, and scrap metal. These materials
32 were buried at the Byron Salvage Yard Superfund Site and in some areas dumped on the
33 ground.

34 In 1976, the IEPA confirmed the presence of volatile organic compounds (VOCs) and heavy
35 metals in the soil, surface water, and groundwater at the Byron Salvage Yard Superfund Site.
36 Contaminants in groundwater include vinyl chloride, trichloroethylene, and cyanide
37 (EPA 2013a). From the Byron Salvage Yard Superfund Site, two plumes of contamination are
38 moving laterally within the Galena-Platteville aquifer. One plume moved northwest and
39 one plume moved southwest (Kay et al. 1997). Both plumes are moving toward the Rock River.
40 Cleanup and groundwater remediation activities at the Byron Salvage Yard Superfund Site have
41 been ongoing since 1975. Groundwater monitoring will continue at the Byron Salvage Yard
42 Superfund Site until contaminant levels fall below safe drinking water standards (EPA 2013a).

43 Beginning in 2006, Exelon conducted a groundwater investigation of the discharge (blowdown)
44 pipeline that runs from the plant to the Rock River. As part of this investigation, multiple
45 samples were obtained from the pipeline, from vacuum breaker vaults installed along the
46 pipeline, from nearby residential wells, and from monitoring wells. Other than tritium, no
47 radionuclides were or have since been discovered above their lower limit of laboratory
48 detection. As reported in 2007, tritium was detected above the lower limit of detection in

1 four monitoring wells (AR-2, AR-3, AR-4, and AR-11). These wells are located close to
 2 three vacuum breaker vaults: VB-2, VB-3, and VB-4. The tritium concentrations in these wells
 3 ranged from 327 picocuries per liter (pCi/L) to 3,050 pCi/L. These concentrations were well
 4 below the EPA drinking water standard for tritium of 20,000 pCi/L. No tritium was detected in
 5 residential wells or found to be moving off site at detectible concentrations (CRA 2006).

6 Exelon continued to investigate tritium releases from the discharge (blowdown) pipeline in
 7 cooperation with the IEPA, the Illinois Attorney General's Office, and the NRC. In March 2010,
 8 Exelon agreed to a consent order with the State of Illinois that was approved by the Circuit
 9 Court for the Fifteenth Judicial Circuit (Ogle County). The consent order required Exelon to
 10 prevent further releases of regulated wastewater to soil, surface water, or groundwater at Byron
 11 and to operate continuous monitoring systems in the vacuum breaker vaults along the pipeline.
 12 Exelon has complied with the consent order. The consent order was terminated in March 2011
 13 (Exelon 2013b), but Exelon continues to monitor the groundwater and vacuum breaker vaults.

14 By 2012, tritium was detected in only two wells adjacent to the pipeline (AR-4 and AR-11).
 15 Tritium levels in well AR-4 had declined from 3,050 pCi/L in 2007 to 830 pCi/L in 2012, and
 16 tritium levels in well AR-11 had declined from 1,820 pCi/L in 2007 to 994 pCi/L in 2012
 17 (Exelon 2013b; Teledyne 2008). Tritium concentrations in these two wells continue to be well
 18 below the EPA drinking water standard of 20,000 pCi/L.

19 Exelon routinely monitors the groundwater for radiological constituents and reports the results to
 20 the NRC. In addition, in 2007, the nuclear power industry began implementing its "Industry
 21 Ground Water Protection Initiative" (NEI 2007). The NRC staff has been monitoring
 22 implementation of this initiative at licensed nuclear reactor sites since 2008. Results from the
 23 "Industry Ground Water Protection Initiative" are reported annually to the NRC.

24 **3.6 Terrestrial Resources**

25 **3.6.1 Byron Ecoregion**

26 Beginning in the 1980s, the USGS, EPA, the Commission for Environmental Cooperation
 27 (CEC), and various other Federal agencies and interagency groups began delineating
 28 North American ecoregions in order to provide a common geographical framework to assess
 29 and manage the environment. Ecoregions are divided into Levels I through IV. Level I is the
 30 broadest category, while Level IV is the most specific. Ecoregions are delineated by many
 31 factors to include location, climate, vegetation, hydrology, terrain, wildlife, and land use. The
 32 Byron site lies within the following Level I through IV ecoregions (EPA 2013b):

- 33 • Level I: Eastern Temperate Forests,
- 34 • Level II: Central USA Plains,
- 35 • Level III: Central Corn Belt Plains, and
- 36 • Level IV: Illinois/Indiana Prairies.

37 The Eastern Temperate Forests ecoregion covers the majority of the Eastern States and is
 38 characterized as having a moderate to mildly humid climate with dense and diverse forest cover
 39 consisting mostly of tall broadleaf, deciduous trees and needle-leaf conifers (CEC 2008). Within
 40 the Eastern Temperate Forests, the Central USA Plains is mostly glaciated to rolling plains, with
 41 some sand dunes and lake plains (Wiken et al. 2011). Large prairie communities and
 42 oak–hickory forests were native to this ecoregion, but have been largely replaced by agriculture.
 43 Within these plains, Byron lies in the Central Corn Belt Plains, which occupies 38,000 mi²
 44 (98,000 km²) of land, primarily in northern Illinois and the northwestern corner of Indiana.

Affected Environment

1 Gently rolling smooth plains, irregular plains, and shallow stream valleys characterize much of
2 the area (USFS 1996). The native landscape of the ecoregion was composed of bluestem
3 prairie communities and oak–hickory forests, but has mostly been replaced by corn and
4 soybean agriculture. Common wildlife found in the region include white-tailed deer (*Odocoileus*
5 *virginianus*), coyote (*Canis latrans*), bobcat (*Lynx rufus*), meadow vole (*Microtus*
6 *pennsylvanicus*), Canada goose (*Branta canadensis*), mallard duck (*Anas platyrhynchos*),
7 black-capped chickadee (*Parus atricapillus*), upland sandpiper (*Bartramia longicauda*), Illinois
8 mud turtle (*Kinosternon flavescens*), and Illinois chorus frog (*Pseudacris illinoensis*) (Wiken
9 et al. 2011). Agricultural lands are the predominant land cover in the ecoregion at 75.3 percent,
10 followed by developed land (11.6 percent), and forests (9.3 percent). Although developed land
11 is less prominent than agricultural land, from 1973 to 2000, the percent of developed land has
12 increased 2.4 percent, while the percent of agricultural land and forested land has decreased
13 (Karstensen et al. 2013d).

14 Byron site lies within the Upper Rock River watershed, which occupies 830 mi² (2,100 km²) of
15 the Rock River Hill Country Natural Division (IDNR 2002b). This area is characterized by rolling
16 glaciated topography and a landscape historically dominated by prairie communities
17 (59 percent), oak forests, dry upland forests, and floodplain forests. The Upper Rock River area
18 land cover is now dominated by cropland (52.1 percent), grasslands (25.1 percent), forests
19 (10.4 percent), open water (1.1 percent), and wetlands (1.5 percent) (IDNR 2002b).

20 **3.6.2 Byron Site and Vicinity**

21 The Byron site occupies 1,782 ac (721 ha) immediately east of the Rock River. The main Byron
22 site area, which is where the majority of the plant facilities are located, is approximately
23 1,398 ac (566 ha) and is surrounded primarily by agricultural fields. Within the main site area,
24 the power block and support facilities (buildings, switchyard, parking lots, and roads) occupy
25 approximately 154 ac (62 ha). Approximately 840 ac (340 ha) are disturbed lands that are
26 leased for agricultural uses, including croplands, pastures, and fallow fields. Forests, meadows,
27 and grasslands occupy the undisturbed portions of the site, which encompass 404 ac (163 ha).
28 The water intake and discharge pipeline and transmission corridor occupy the remaining 384 ac
29 (155 ha) of the site. This corridor extends west from the main site area approximately 2 mi
30 (3.2 km) to the Rock River and is surrounded by primarily wooded lands. (Exelon 2013b)

31 *3.6.2.1 Summary of Past Byron Surveys and Reports*

32 Commonwealth Edison Company conducted site surveys of the Byron site in the fall of 1972,
33 and the winter, spring, and summer of 1973 as part of the construction permit application for
34 Byron Units 1 and 2. Vegetation and wildlife in the transmission and pipeline corridor were
35 surveyed in November 1973. These initial site surveys were used to determine baseline
36 conditions of the terrestrial environment before construction.

37 In 2006, while developing a biodiversity assessment and wildlife habitat management plan for
38 the Byron site, Exelon staff conducted tours of the site with trained biologists (Starke and
39 Cox 2011). Exelon staff recorded any vegetation, bird species, or other wildlife observed during
40 these tours.

41 These surveys are the primary sources for describing the terrestrial resources at Byron. To
42 supplement such surveys, the NRC staff conducted an environmental site visit and a desktop
43 review of other natural resource databases and surveys within the vicinity of Byron.

1 3.6.2.2 Vegetation

2 Common Vegetation

3 Byron lies within the Upper Rock River Basin, which covers nearly 6,000 ac (2,428 ha) in
 4 northern Illinois and supports approximately 800 native plant species. Prior to the construction
 5 of the Byron facilities, 50 percent of the site was agricultural cropland. The northern half of the
 6 site was wooded with some cropland, and the southern half was mainly cropland.
 7 Approximately 35 percent of the site was grassland and fallow fields, consisting mainly of
 8 ragweed (*Ambrosia artemisiifolia*), alfalfa (*Medicago sativa*), and red clover (*Trifolium pretense*)
 9 in the fallow fields, and Kentucky bluegrass (*Poa pratensis*), timothy (*Phleum pretense*), and
 10 Canada bluegrass (*Poa compressa*) in the grasslands (Exelon 2013a). The remaining
 11 15 percent was forested and consisted primarily of oak (*Quercus* spp.) and hickory (*Carya* spp.)
 12 varieties. The transmission and pipeline corridor area was approximately 44 percent (212 ac
 13 (86 ha)) cultivated land (mostly cornfields), and approximately 39 percent (189 ac (76 ha)) was
 14 forested. The wooded and meadow areas of the Byron site have remained undisturbed since
 15 the property was purchased in the 1970s.

16 Construction of Byron disturbed approximately 538 ac (218 ha), or 30 percent of the existing
 17 Byron site. The majority of land on the Byron site is currently agricultural land, with about
 18 300 ac (121 ha) of wooded lands and 150 ac (61 ha) of meadow or grasslands. Currently, 47
 19 percent of the Byron site (840 ac (340 ha)) is leased for agricultural use. This land is
 20 considered disturbed because most of it is tilled. The remaining 23 percent (404 ac (163 ha)) of
 21 Byron is undisturbed land (Exelon 2013b).

22 Based on baseline surveys performed by ComEd (1981), Exelon concluded that the dominant
 23 tree species on the site are oak (*Quercus* spp.) and hickory (*Carya* spp.) varieties. Common
 24 oak varieties recorded during the 2006 tours of the Byron site include black oak (*Q. velutina*),
 25 jack oak (*Q. ellipsoidal*), pin oak (*Q. palustris*), red oak (*Q. rubra*), and white oak (*Q. alba*).
 26 Hickory varieties recorded include mockernut hickory (*C. tomentosa*), shagbark hickory
 27 (*C. ovate*), and shellbark hickory (*C. laciniosa*). Other common tree assemblages found in both
 28 1973 and 2006 include American elm (*Ulmus americana*), black walnut (*Juglans nigra*),
 29 hackberry (*Celtis occidentalis*), and cottonwood (*Populus deltoides*). Understory plants include
 30 round-leaf dogwood (*Cornus rugosa*), northern prickly ash (*Zanthoxylum americanum*), and wild
 31 grape (*Vitis* spp.) (ComEd 1981; Starke and Cox 2011).

32 Several invasive species common to Illinois are found on the Byron site. Observed invasive
 33 species include bull thistle (*Cirsium vulgare*), chicory (*Cichorium intybus*), giant foxtail (*Setaria*
 34 *faberii*), wild carrot (*Daucus carota*), wild parsnip (*Pastinaca sativa*), and Osage-orange
 35 (*Maclura pomifera*) (CISEH 2009; Starke and Cox 2011).

36 Wetlands

37 Based on an examination of U.S. Fish and Wildlife Service (FWS) National Wetland Inventory
 38 maps, a small presence of wetlands exists on the Byron site. The only occurrence of wetlands
 39 on site is less than 5 ac (2 ha), or less than 0.3 percent of the Byron total site area. These
 40 freshwater forested/shrub wetlands occur on the north edge of the site's western border,
 41 adjacent to the Rock River. FWS (2013d) classifies these wetlands as palustrine, which means
 42 that the nontidal wetlands occur in a floodplain and are dominated by trees, shrubs, emergent
 43 vegetation, mosses, or lichens. Other characteristics are that the total area of the wetlands
 44 does not exceed 8 ha (20 ac), the wetlands do not have an active wave-formed or bedrock
 45 shoreline, the wetlands have a depth less than 2 m (6.6 ft) at low water, and have a salinity of
 46 less than 0.5 parts per thousand. This wetland is also characterized as being seasonally

Affected Environment

1 flooded and created or modified by a manmade barrier or dam, which obstructs the inflow or
2 outflow of water.

3 Additional wetlands occur within the vicinity (5 mi (8 km)) of Byron, including more freshwater
4 forested and shrub wetlands as well as freshwater emergent wetlands (FWS 2013d). These
5 wetlands primarily occur along the Rock River.

6 Vegetation Management

7 Vegetation management at Byron is the responsibility of the Facilities Maintenance Department.
8 Different vegetation management guidelines are followed based on the particular area of the
9 Byron site. For example, the high-security areas both inside and outside the Protected Area
10 around the facility are mowed to a height of 6 in. Outlying areas that are of less significance to
11 plant security are treated to some degree with vegetation maintenance to allow for worker
12 access, but are mowed only about twice a year. The undeveloped areas of the site are typically
13 given vegetation maintenance only in response to special requests (Exelon 2013b).

14 State-Listed Vegetation

15 This section discusses plant species protected only by the State, and Section 3.8 discusses
16 those species protected under the Endangered Species Act (ESA) alone or in combination with
17 the State. As discussed in Section 3.1.6, Byron and the inscope transmission lines are located
18 entirely within Ogle County. Table 3–5 identifies the 55 plant species that are considered
19 threatened or endangered by the State of Illinois within Ogle County and Winnebago County.
20 On the Byron site, no State-threatened or endangered species have been observed during the
21 1973 baseline surveys or while developing the site’s wildlife habitat management plan
22 (ComEd 1981; Starke and Cox 2011).

1

Table 3–5. State-Listed Plant Species in Ogle County

Scientific Name	Common Name	State of Illinois Status^(a)
<i>Amelanchier sanguinea</i>	shadbush	SE
<i>Arctostaphylos uva-ursi</i>	bearberry	SE
<i>Asclepias lanuginosa</i>	wooly milkweed	SE
<i>Aster furcatus</i>	forked aster	ST
<i>Besseyia bullii</i>	kitten tails	ST
<i>Betula alleghaniensis</i>	yellow birch	SE
<i>Carex cryptolepis</i>	sedge	SE
<i>Carex echinata</i>	little prickly sedge	SE
<i>Carex woodii</i>	pretty sedge	ST
<i>Castilleja sessiliflora</i>	downy yellow painted cup	SE
<i>Ceanothus herbaceus</i>	redroot	SE
<i>Cornus canadensis</i>	bunchberry	SE
<i>Corydalis sempervirens</i>	pink corydalis	SE
<i>Cyclonaias tuberculata</i>	purple wartyback	ST
<i>Cypripedium acaule</i>	moccasin flower	SE
<i>Dichanthelium boreale</i>	northern panic grass	SE
<i>Equisetum pretense</i>	meadow horsetail	ST
<i>Equisetum sylvaticum</i>	horsetail	SE
<i>Filipendula rubra</i>	queen-of-the-prairie	SE
<i>Gymnocarpium dryopteris</i>	oak fern	SE
<i>Helianthus giganteus</i>	tall sunflower	SE
<i>Lathyrus ochroleucus</i>	pale vetchling	ST
<i>Lespedeza leptostachya</i>	prairie bush clover	SE
<i>Luzula acuminata</i>	hairy woodrush	SE
<i>Lycopodium clavatum</i>	running pine	SE
<i>Lycopodium dendroideum</i>	ground pine	SE
<i>Nothocalais cuspidata</i>	prairie dandelion	SE
<i>Phegopteris connectilis</i>	long beech fern	SE
<i>Sorbus Americana</i>	American mountain ash	SE
<i>Sullivantia sullivantii</i>	Sullivantia	ST
<i>Tomanthera auriculata</i>	ear-leafed foxglove	ST

Affected Environment

Scientific Name	Common Name	State of Illinois Status ^(a)
<i>Trientalis borealis</i>	star-flower	SE
<i>Woodsia ilvensis</i>	rusty woodsia	SE

^(a) SE = State-endangered; ST = State-threatened

Source: IDNR 2013

1 3.6.2.3 Wildlife

2 Common Wildlife

3 Byron is in the Upper Rock River Basin, which has a high terrestrial species diversity due to its
4 extensive range of habitats and available vegetation (IDNR 2001). The Byron site provides
5 several types of terrestrial habitats for birds, mammals, and other wildlife. Plant communities
6 and wooded areas along the Rock River shoreline provide an important source of food and
7 refuge for birds. The combination of food, protection, and other resources available make the
8 Upper Rock River Basin and the Byron site an important habitat for many birds and wildlife. In
9 addition, the area is part of the Mississippi flyway and an important stopover location for many
10 migratory birds (Exelon 2013a; IDNR 2002b).

11 The baseline surveys at the Byron site identified 103 migratory and resident bird species on the
12 site (ComEd 1981). The more recent 2006 wildlife observations indicate a total of 107 bird
13 species (Starke and Cox 2011). Fourteen mammal species were originally identified in the 1973
14 surveys, with an additional seven species added from more current observations. Only
15 three reptile and amphibian species were observed in 1973, and, since the baseline surveys,
16 seven more species have been added to that list. Table 3–6 describes the most common or
17 abundant birds, mammals, reptiles, and amphibians on the Byron site.

18 As described in Section 3.2, several important natural areas occur within the vicinity of Byron.
19 As described above, this area is part of the Mississippi flyway, used by migrating birds as
20 important stopover points during long seasonal migrations (FWS 2013f). Species of diving and
21 dabbling ducks, Canada geese, and particularly snow geese (*Chen caerulescens*) use corridors
22 that cross north central Illinois in their migration. High-quality bird habitats within the region
23 surrounding Byron include the Lowden–Miller State Forest and the adjacent Castle Rock State
24 Park. The Audubon Society designates both of these areas as Important Bird Areas (IBAs).
25 Combined, these two areas cover approximately 4,225 ac (1,710 ha) and provide one of the
26 finest bird habitats in Illinois. This large, forested tract of land offers resident and migratory
27 birds protection and is home to more breeding pairs of forest bird species than any other part of
28 Illinois (IDNR 2001). Castle Rock State Park contains some of the most diverse terrestrial
29 habitats in the Upper Rock River area, including ravine forest, upland forest, prairie, river
30 creeks, and sandstone outcrops (IDNR 2002b). The most unique features of the park are mesic
31 upland forest and sandstone cliffs, which provide habitat for relict boreal plants (IDNR 2002b).

1

Table 3–6. Most Common or Abundant Wildlife on the Byron Site

Birds	
<i>Migratory Birds</i>	
fox sparrow (<i>Passerella iliaca</i>)	slate-colored junco (<i>Junco hyemalis</i>)
golden-crowned kinglet (<i>Regulus calendula</i>)	white-throated sparrow (<i>Zonotrichia albicollis</i>)
<i>Resident Birds</i>	
American crow (<i>Corvus brachyrhynchos</i>)	cedar waxwing (<i>Bombycilla cedrorum</i>)
American goldfinch (<i>Spinus tristis</i>)	robin (<i>Turdus migratorius</i>)
<i>Game Birds</i>	
American woodcock (<i>Philohela minor</i>)	mourning dove (<i>Zenaidura macroura</i>)
bobwhite quail (<i>Colinus virginianus</i>)	ring-necked pheasant (<i>Phasianus colchicus</i>)
gray partridge (<i>Perdix perdix</i>)	
Mammals	
common opossum (<i>Didelphis marsupialis</i>)	raccoon (<i>Procyon lotor</i>)
deer mouse (<i>Peromyscus maniculatus</i>)	wood mouse (<i>Peromyscus leucopus</i>)
meadow vole (<i>Microtus pennsylvanicus</i>)	
Reptiles and Amphibians	
alligator snapping turtle (<i>Macrochelys temminckii</i>)	garter snake (<i>Thamnophis sirtalis</i>)
American toad (<i>Bufo americanus</i>)	red milk snake (<i>Lampropeltis triangulum sypila</i>)
Bullfrog (<i>Rana catesbeiana</i>)	smooth softshell turtle (<i>Apalone mutica</i>)
Bullsnake (<i>Pituophis melanoleucus</i>)	spring peeper (<i>Hyla crucifer</i>)
eastern hognose snake (<i>Heterodon platyrhinos</i>)	western chorus frog (<i>Pseudacris triseriata</i>)
Sources: Exelon 2013a; Starke and Cox 2011	

Affected Environment

1 State-Listed and Other Important Wildlife

2 This section discusses bird, mammal, and reptile species protected only by the State, the Bald
3 and Golden Eagle Protection Act (BGEPA), and the Migratory Bird Treaty Act (MBTA).

4 Section 3.8 discusses those species protected under the ESA alone or in combination with the
5 State.

6 *Birds*

7 Table 3–7 identifies the four birds that are considered threatened or endangered by the State of
8 Illinois within Ogle County.

9 **Table 3–7. State-Listed Bird Species in Ogle County**

Scientific Name	Common Name	State of Illinois Status
Birds		
<i>Ammodramus henslowii</i>	Henslow's sparrow	Threatened
<i>Bartramia longicauda</i>	upland sandpiper	Endangered
<i>Haliaeetus leucocephalus</i>	bald eagle	Threatened
<i>Lanius ludovicianus</i>	loggerhead shrike	Threatened

Source: IDNR 2013

10 With the exception of the bald eagle, none of the State-listed bird species presented in
11 Table 3–7 have been observed on the Byron site during the 1973 baseline surveys or while
12 developing the site's wildlife habitat management plan (ComEd 1981; Exelon 2013a; Starke and
13 Cox 2011).

14 Byron is located approximately 6 mi (10 km) northeast of the Castle Rock State Park and
15 Lowden–Miller State Forest IBA (Exelon 2013b). The Lowden–Miller State Forest and Castle
16 Rock State Park host a variety of rare breeding warblers and other song birds and host nesting
17 populations of several bird species rarely found in Illinois, including the black-throated green
18 warbler (*Setophaga virens*), the cerulean warbler (*S. cerulea*), the hooded warbler (*S. citrina*),
19 the worm-eating warbler (*Helmitheros vermivorum*), the chestnut-sided warbler
20 (*S. pensylvanica*), and the golden-winged warbler (*Vermivora chrysoptera*). The Audubon
21 Society designated this area IBA because it meets the habitat criteria for both the State-listed
22 threatened cerulean warbler and the blue-winged warbler (*V. cyanoptera*) (Audubon 2013).

23 *Species Protected under the Bald and Golden Eagle Protection Act*

24 The Bald and Golden Eagle Protection Act of 1940, as amended (16 U.S.C. §668–668c)
25 (BGEPA), prohibits anyone from taking bald or golden eagles (*Aquila chrysaetos*), including
26 their nests or eggs, without a permit issued by the FWS. The Act and regulations define the
27 word “take” to include the following: to pursue, shoot, shoot at, poison, wound, kill, capture,
28 trap, collect, destroy, molest, or disturb (50 CFR 22.3). The word “disturb” means, among other
29 things, to take action that causes (1) injury to an eagle, or (2) a decrease in its productivity or
30 nest abandonment, by substantially interfering with breeding, feeding, or sheltering behavior
31 (50 CFR 22.3).

32 Bald eagles have been observed along the banks of the Rock River near the Byron site, as well
33 as other locations along the Rock River and its tributaries (eBird 2013; Exelon 2013a).

1 *Species Protected Under the Migratory Bird Treaty Act*

2 The MBTA of 1918, as amended (16 U.S.C. §§ 703–712), is administered by the FWS. The Act
 3 prohibits anyone from taking native migratory birds, their eggs, feathers, or nests. MBTA
 4 regulations define “take” to mean to pursue, hunt, shoot, wound, kill, trap, capture, or collect, or
 5 any attempt to carry out those actions (50 CFR 10.12). However, take does not include habitat
 6 destruction or alteration. All Illinois State listed species shown in Table 3–7 are protected under
 7 the MBTA.

8 *Mammals*

9 Table 3–8 identifies the nine mammals that are considered threatened or endangered by the
 10 State of Illinois.

11 **Table 3–8. State-Listed Mammal Species in Illinois**

Scientific Name	Common Name	State of Illinois Status
Mammals		
<i>Canis lupus</i>	gray/timber wolf	Threatened
<i>Corynorhinus rafinesquii</i>	Rafinesque’s big-eared bat	Endangered
<i>Myotis austroriparius</i>	southeastern myotis	Endangered
<i>Myotis grisescens</i>	gray bat	Endangered
<i>Myotis sodalist</i>	Indiana bat	Endangered
<i>Neotoma floridana</i>	eastern woodrat	Endangered
<i>Ochrotomys nuttali</i>	golden mouse	Threatened
<i>Oryzomys palustris</i>	rice rat	Threatened
<i>Spermophilus franklinii</i>	Franklin’s ground squirrel	Threatened

Source: IESPB 2011

12 None of the State-listed mammals reported in Table 3–8 above have been reported on or near
 13 the Byron site (Exelon 2013a; Starke and Cox 2011).

14 *Reptiles and Amphibians*

15 Table 3–9 identifies the two reptiles and one amphibian that are considered threatened or
 16 endangered by the State of Illinois.

1 **Table 3–9. State-Listed Reptile and Amphibian Species in Ogle County**

Scientific Name	Common Name State-Listed Reptile and Amphibian Species in Ogle County	State of Illinois Status
Reptiles		
<i>Equisetum pretense</i>	Blanding’s turtle	Threatened
<i>Hemidactylium scutatum</i>	four-toed salamander	Threatened
<i>Heterodon nasicus</i>	western hognose snake	Threatened

Source: IDNR 2013

2 None of the State-listed species reported in Table 3–9 above have been reported on or near the
 3 Byron site during the 1973 baseline surveys or while developing the site’s wildlife habitat
 4 management plan (Exelon 2013a; Starke and Cox 2011).

5 **3.6.3 Transmission Line Corridors**

6 Section 3.1.6.5 describes the inscope transmission lines, which are limited to those
 7 transmission lines that connect the nuclear plant to the switchyard where electricity is fed in to
 8 the regional distribution system (NRC 2013a). For Byron, the onsite 345-kV station switchyard
 9 serves this purpose (Exelon 2013b). The switchyards are adjacent to Units 1 and 2 and within
 10 the boundary of the Byron site (see Figure 3–3). Therefore, the above discussion of the
 11 affected terrestrial environment for the Byron site is representative of the affected environment
 12 for the inscope transmission lines.

13 **3.6.4 WHC Wildlife at Work Program**

14 The Wildlife Habitat Council (WHC) Wildlife at Work Program provides a structure for
 15 corporations to implement voluntary conservation efforts that exceed regulatory requirements
 16 (WHC 2014). These habitat projects can vary in size and scope and emphasize community
 17 involvement and collaboration.

18 Exelon (a WHC member since 2005) established a Wildlife at Work Program at Byron with the
 19 mission of increasing biodiversity at the Byron site. The program focuses on the management
 20 and monitoring of individual onsite habitat projects. The program at Byron is managed by the
 21 Byron Environmental Stewardship Team, which has up to 25 members (Starke and Cox 2011).

22 There are several ongoing projects that are part of Byron’s Wildlife at Work Program. First is
 23 the enhancement of habitats for cavity-nesting birds, which provides houses for local birds in
 24 need of nesting areas. According to Exelon’s monitoring of this project, the bird houses located
 25 in meadows and wooded areas on the Byron property have been successful in encouraging
 26 bluebirds (*Sialia sialis*) and wood ducks (*Aix sponsa*) to utilize the habitats present at Byron
 27 (Exelon 2011b). An increase in the number of bluebirds has been observed in the project area,
 28 along with an increase in the number of houses with chicks that have fledged. The number of
 29 wood duck houses with ducklings has also increased (Starke and Cox 2011).

30 The second project is the enhancement of habitats for bats, which provides houses for local bat
 31 species. This project began in 2007 after Byron personnel noticed bats roosting under an
 32 awning on one of the main facility buildings. The bat houses were constructed to encourage the
 33 bats to roost nearer to the Rock River where there is a more abundant food supply of insects for

1 the bats. Although deposits found on the foliage below the bat houses suggest the presence of
2 bats, relatively few observations of bats using the houses have been made. Also, no
3 observations or surveys have been conducted using trained biologists to determine the species
4 of bat present on the site (Exelon 2013b; Starke and Cox 2011).

5 The third ongoing project on site is a butterfly garden, which provides food and cover for a
6 variety of different species. The garden was established outside the training building and has
7 proven very successful in attracting different pollinators, birds, and butterflies. According to
8 Exelon, employees and visitors to the Byron site have had a very positive reaction to this project
9 in particular (Starke and Cox 2011).

10 As part of the Wildlife at Work program, Exelon plans to continue to maintain and monitor
11 existing bird and bat houses, as well as the butterfly garden. Future potential projects being
12 discussed include the installation of heron platforms along the Rock River, the creation of
13 retention ponds on the property where birds and animals would have increased access to water,
14 and the possible addition of prairie plant habitat on the Byron property (Starke and Cox 2011).

15 **3.7 Aquatic Resources**

16 Rock River

17 The Byron site is located 2 mi (3.2 km) east of the Rock River from which the facility withdrawals
18 and discharges cooling system make-up and blowdown water. From its source in the Horicon
19 Marsh in Dodge County, Wisconsin, the Rock River meanders south to the Wisconsin–Illinois
20 state line and then southwest through Illinois to its confluence with the Mississippi River at Rock
21 Island, Illinois. The river flows a total length of 318 mi (512 km). The river’s watershed covers
22 an area of approximately 28,270 km² (10,915 mi², 6,985,600 ac, or 2,826,972 ha), of which
23 14,633 km² (5,650 mi², 3,616,000 ac, or 1,463,343 ha) are in Illinois. The primary land use
24 within the Rock River basin is agricultural. The largest tributaries are the Pecatonica, the
25 Kishwaukee, and the Green Rivers (Sinclair 1996).

26 The IDNR has designated the lower Rock River basin, which includes Ogle County and
27 eight other Illinois counties, as a Resource Rich Area (Suloway et al. 1996). However, the lower
28 basin is highly disturbed: in 2006, the IEPA reported that only about 412 ac (167 ha) of
29 undegraded, high-quality natural habitat remained in this basin (IEPA 2006). Industrial point
30 source discharge, agricultural runoff, and urbanization are the major sources of Rock River
31 water quality degradation. Channelization beginning in the early 1900s, the installation of
32 seven in-channel dams, and the drainage of wetlands have also reduced the quantity and
33 quality of aquatic habitat in the basin (Sinclair 1996). The closest dam to Byron lies in Oregon,
34 Illinois, approximately 8.0 km (5.0 mi) downstream of the Byron discharge (Exelon 2013a).

35 Aquatic Surveys and Monitoring

36 Prior to Byron construction and operation, ComEd commissioned Environmental Analysts,
37 Inc. (EAI) to perform baseline monitoring of phytoplankton, zooplankton, benthic
38 macroinvertebrate, and fish communities in the Rock River between 1972 and 1985 for the
39 following sample periods: 1972 to 1974, 1975 to 1979, and 1983 to 1985. ComEd presented
40 the baseline monitoring results from the 1972-to-1973 sampling year in its ER for Byron
41 construction and the results from the 1973-to-1974 sampling year in its ER for Byron operation
42 (ER-O) (ComEd 1981). The NRC also provided brief summaries of the results of these studies
43 in its Final Environmental Statements for Byron construction (FES-C) (AEC 1974) and operation
44 (FES-O) (NRC 1982).

Affected Environment

1 Following the commencement of Byron operation (Unit 1 in September 1985; Unit 2 in
 2 August 1987), aquatic surveys of fish and benthos continued from 1986 through 2002 and
 3 in 2011. Exelon commissioned EA Engineering, Science, and Technology (EA Engineering,
 4 successor to EAI) to perform the 2011 survey (EA Engineering 2012) in support of the
 5 preparation of Exelon’s license renewal application. All of the preoperational and operational
 6 studies collected samples at the same locations: five transects in the Rock River (from a point
 7 2.4 mi (3.9 km) upstream of Byron, Illinois, to just upstream of the dam at Oregon, Illinois) and
 8 at the mouths of six tributary streams that flow into the Rock River near the Byron site (Stillman
 9 Creek, Mill Creek, Woodland Creek, Leaf River, Spring Creek, and Silver Creek). Table 3–10
 10 lists and describes these locations, and Figure 3–12 illustrates the sampling locations.

11 In 1986 and 1987, biologists from the Illinois Natural History Survey (INHS) surveyed fish in the
 12 Rock River near Castle Rock State Park as well as in three nearby tributary streams to support
 13 an IDOT road improvement project (Wetzel et al. 1998). Although this study was unrelated to
 14 Byron, the study site was located approximately 10 mi (16 km) downstream of the Byron
 15 discharge.

16 **Table 3–10. Sampling Locations for Preoperational and Operational Aquatic Monitoring**
 17 **and Surveys of the Rock River**


Location	Description
Rock River Transects	
R-1	2.4 mi (3.9 km) upstream of Byron, IL; represents conditions well above (upriver of) the Byron intake
R-2	300 yd (270 m) upstream of the blowdown discharge point; represents conditions in the vicinity of the Byron intake
R-3	at the Byron blowdown discharge point
R-4	0.7 mi (1.1 km) downstream of the blowdown discharge point; represents conditions inclusive of Byron’s thermal plume
R-5	3.4 mi (5.5 km) downstream of Byron and 1,000 yd (910 m) above the dam at Oregon, IL; represents conditions well below (downriver of) Byron
Tributaries	
S-1	Stillman Creek
S-2	Mill Creek
S-3	Woodland Creek (this creek was sampled at three pool locations: W-1, W-2, and W-3)
S-4	Leaf River
S-5	Spring Creek
S-6	Silver Creek

Source: ComEd 1981

18 In 1993, ComEd commissioned Ecological Specialists, Inc. (ESI), to conduct a mussel study
 19 within the Rock River near the Byron intake and discharge points. Exelon commissioned ESI to
 20 repeat this survey in 2011 (ESI 2011) in support of the preparation of Exelon’s license renewal
 21 application.

1

Figure 3-12. Rock River Aquatic Survey Sampling Locations



2

3

Source: ComEd 1981, Figure 2.2-1

Affected Environment

1 The following sections characterize the aquatic communities in the vicinity of Byron by
2 summarizing the results of the available studies.

3 Phytoplankton

4 EAI conducted the first phytoplankton survey near the Byron site on 15 sample days between
5 May 1972 and June 1973 at five river transection locations (R-1 through R-5) and at
6 three tributary mouths (S-3, S-4, and S-5) by immersing several 1-L (liter) polypropylene bottles
7 beneath the surface of the water. The FES-C (AEC 1974) provides a brief summary of the first
8 sample year. The FES-C states that between 7 and 37 phytoplankton species were identified
9 on each sample day, and the biovolume of each sample ranged from less than 1 microliter per
10 liter ($\mu\text{L/L}$) in winter to over 40 $\mu\text{L/L}$ in late summer. A group of about eight centric diatom
11 species dominated the samples by biomass and were those typical of the upper Mississippi
12 River Basin (which includes the Rock River Basin), including: *Melosira ambigua*,
13 *Stephanodocus hantzchii*, *S. niagarae*, *S. astraea minutula*, and *Cyclotella meneghiniana*.
14 Green, blue--green, and euglenoid algae were of localized abundance on certain sample days
15 and were very rare during the colder months. Filamentous blue-green algae were most
16 abundant in September and August. The FES-C concluded that the Rock River in the vicinity of
17 the Byron site is a moderately eutrophic stream with planktonic flora normal for the region.

18 In the second sample year (September 1973 through October 1974), EAI surveyed
19 phytoplankton at four of the five river transection locations (R-2 through R-5) and at the mouths
20 of two tributaries (S-4 and S-5) on 6 sample days. ComEd (1981) reported the results of this
21 sample year in its ER-O. The survey yielded a total of 119 taxa, which included 59 diatoms
22 (comprising 93.7 percent of all collected phytoplankton), 43 green algae (3.3 percent),
23 9 blue-green algae (2.4 percent), 4 euglenids (0.1 percent), 2 dinoflagellates (less
24 than 0.1 percent), 1 golden algae (0.5 percent), and 1 cryptomonad (less than 0.1 percent). The
25 same diatom species dominated the samples by biomass as those in the first sample year with
26 the additional mention of *M. granulata*, *M. granulata* var. *angustissima*, *S. minutus*, *S. subtilus*,
27 and *Nitzschia palea* as frequently collected species.

28 Zooplankton

29 EAI conducted a zooplankton survey on 19 sample days between April 1972 and June 1973 at
30 five river transection locations (R-1 through R--5) and at three tributary mouths (S-3, S-4, and
31 S-5) by pouring 60 L (20 gal) of surface water through a #20 mesh plankton net. The FES-C
32 (AEC 1974) provides a brief summary of the first sample year. The FES-C states that EAI
33 collected 38 rotifer species and 31 protozoan species. Of these, 7 rotifers and 5 protozoa
34 occurred on more than two-thirds of sample days. Rotifers in the genera *Keratella*, *Polyarthra*,
35 and *Brachionus* and protozoa in the genera *Centropyxis*, *Diffugia*, and *Vorticella* were most
36 common. One species of copepod (*Cyclops bicuspidatus*) was also frequently collected.
37 Zooplankton were most abundant in spring and fall samples and least abundant in summer and
38 winter samples.

39 In the second sample year (September 1973 through October 1974), EAI surveyed the same
40 sampling locations as in the previous sample year, but on fewer occasions (6 sample days).
41 ComEd (1981) reported the results of the second sample year in its ER-O. The survey collected
42 18 rotifer species, 14 protozoan species, 7 cladoceran species, 3 copepod species, 2 tardigrade
43 species, as well as unspecified nematodes, oligochaetes, and chironomids. As in the first
44 sample year, rotifers were the numerically dominant taxa at both Rock River and tributary
45 sampling locations. The most commonly occurring forms included the juvenile copepod stages
46 (nauplii and copepodites), the cladocerans *Bosmina* and *Chydorus*, and the rotifer genera
47 *Brachionus*, *Keratella*, and *Synchaeta*. Zooplankton samples exhibited summer and winter lows
48 and spring and fall peaks ranging from 2 organisms per L (R-2, January 1974) to 350 organisms

1 per L (R-2, April 1974), which corresponded to abundance measurements during the first
2 sample year.

3 Periphyton Artificial Substrate Samplers

4 Information on the first year of periphyton sampling was not included in the FES-C (AEC 1974);
5 therefore, only the sampling results from the second sample year are discussed below.

6 ComEd's ER-O (1981) notes that periphyton data collected during the second sample year did
7 not deviate markedly from the information collected during the corresponding seasons of the
8 first sample year.

9 EAI sampled periphyton with artificial substrate samplers at the five river stations (R-1 through
10 R-5), four tributary stream stations (S-3, S-4, and S-5 from September through December 1973,
11 and S-3, S-5, and S-6 from January through September 1974), and two Woodland Creek pool
12 stations (W-1 and W-2) from September 1973 through September 1974. A total of 266 algae
13 taxa were identified from all samples, which included 181 diatoms, 64 green algae, 1 golden
14 algae, 12 blue-green algae, 7 euglenids, and 1 dinoflagellate. Diatoms dominated the samples,
15 and the most commonly collected forms included *Melosira ambigua*, *M. granulata*
16 var. *angustissima*, *Nitzschia linearis*, *Navicula viridula* var. *avenacea*, *Gomphonema olivaceum*,
17 and *G. parvulum*, all of which are commonly found in eutrophic waters.

18 Zoobenthos

19 The FES-C (AEC 1974) indicates that EAI sampled zoobenthos on 7 days between May 1972
20 and June 1973. Samples were dominated by four groups of invertebrates: oligochaete worms
21 (family Tubificidae, 9 taxa, 147.3 organisms per square meter (m^2)), mayfly larvae (order
22 Ephemeroptera, 5 taxa, 9.6/ m^2), caddisfly larvae (order Trichoptera, 2 taxa, 15.7/ m^2), and midge
23 fly larvae (family Chironomidae, 21 taxa; 20.1/ m^2). Caddis fly and mayfly larvae numbers were
24 lower in fall, which correlates with the time during which mature larvae would emerge from the
25 stream.

26 ComEd's ER-O (1981) provides more detailed information on zoobenthos collected during the
27 second sample year (1973 to 1974). EAI collected PONAR dredge samples on 6 sample days
28 between September 1973 and October 1974 at river sampling locations R-1 through R-5 and
29 tributary locations S-3, S-5, W-1, and W-3. These locations included a variety of substrate
30 types. Samples containing coarse gravel supported the greatest number of invertebrate taxa
31 (93), followed by samples containing sand (77 taxa), fine gravel (43 taxa), silt (40 taxa), muck
32 (40 taxa), fine rubble (17 taxa), detritus (11 taxa), and mollusk shells (3 taxa). The same
33 four groups of invertebrates dominated the second year samples as those that dominated the
34 first year. However, midge fly larvae were the most prevalent taxa in the second year. Samples
35 also included two species of family Naididae (aquatic worms), two species of leeches (class
36 Hirudinea), five genera of dragonflies (order Odonata), nine genera of beetles (order
37 Coleoptera), true flies (order Diptera), flatworms (class Turbellaria), roundworms (phylum
38 Nematoda), and water mites (subclass Acari).

39 Ichthyoplankton

40 The FES-C (AEC 1974) and FES-O (NRC 1982) indicate that ichthyoplankton (fish eggs and
41 larvae) densities were very low at Rock River sampling locations during preoperational surveys
42 (one egg or larvae per 100 cubic meters (m^3) (3,500 cubic feet (ft^3))) in 1972 to 1973 and
43 six larvae per 100 m^3 (3,500 ft^3) in 1973 to 1974. Ichthyoplankton densities were higher at
44 tributary sampling locations, which the FES-O attributed to washout from spawning sites. In
45 1973, three sampled streams averaged a density of 288 eggs or larvae per 100 m^3 (3,500 ft^3).
46 Larvae of minnows (family Cyprinidae), suckers (family Catostomidae), bullhead catfishes
47 (family Ictaluridae), and sunfishes (family Centrarchidae) were the most commonly collected.

Affected Environment

1 Mussels

2 In 2009, Bales et al. (2012) surveyed mussels at 36 sites in the Rock River and its tributaries by
3 hand grabbing and visual detection when water conditions permitted. The survey found
4 27 extant species across the river basin. The pimpleback (*Quadrula pustulosa*) occurred at all
5 mainstem sample sites, and the plain pocketbook (*Lampsilis cardium*), fragile papershell
6 (*Leptodea fragilis*), State-threatened black sandshell (*Ligumia recta*), Wabash pigtoe (*Fusconaia*
7 *flava*), and pink papershell (*Potamilus ohioensis*) were also commonly occurring species at the
8 majority (50 to 86 percent) of sites. One of the sample sites was 1 mi (1.6 km) downstream of
9 Byron (Site No. 4). This site yielded eight species with live individuals (L) or fresh dead shells
10 (FD): paper pondshell (*Utterbackia imbecillis*, 1 L), Wabash pigtoe (3 L), pimpleback (23 L),
11 plain pocketbook (15 L), fragile papershell (unspecified number of FD), black sandshell (1 L),
12 pink papershell (1 L), and lilliput (*Toxolasma parvum*, 1 L).

13 The first mussel survey in the direct vicinity of the Byron site was conducted in 1993 by ESI to
14 determine if mussels would be affected by the construction of sediment control structures.
15 During that study, ESI collected 21 species of mussels, 7 of which were only collected as
16 weathered shells.

17 In 2011, ESI (2011) repeated the 1993 survey along 25 100-m (330-ft) transects that ran
18 perpendicular to the bank starting 800 m (0.5 mi) upstream of the Byron discharge and
19 continuing at 100-m (330-ft) intervals to a point 1,600 m (1 mi) downstream of the discharge.
20 For each sample, a diver searched each transect line for a minimum of 3 minutes and collected
21 all mussels encountered within 1 m (3.2 ft) of the line. Several quantitative and qualitative
22 samples were also collected within areas of mussel concentrations to estimate density and
23 species richness.

24 A total of 21 species were collected during the study, only 8 of which were collected as live
25 individuals. Pimpleback (93.1 percent of individuals collected) overwhelmingly dominated the
26 live samples, followed by plain pocketbook (4.1 percent) and Wabash pigtoe (1.0 percent). The
27 remaining live species were fatmucket clam (*Lampsilis siliquoidea*, 0.5 percent), fragile
28 papershell (0.5 percent), round pigtoe (*Pleurobema sintoxia*, 0.3 percent), white heelsplitter
29 (*Lasmigona complanata complanata*, 0.3 percent), and pink papershell (0.2 percent). No
30 Illinois-protected species were collected alive, although ESI collected weathered shells of
31 four species: purple wartyback (*Cyclonaias tuberculata*, State-threatened), spike (*Elliptio*
32 *dilatata*, State-threatened), sheepsnose (*Plethobasus cyphus*, State-endangered), and black
33 sandshell (State-threatened). The butterfly mussel (*Ellipsaria lineolata*, State-threatened) was
34 collected as a subfossil shell.

35 Mussel density was relatively high (12.0 individuals per 1 m² (11 square feet)). Mussels were
36 most abundant within the transition zone between cobble/gravel/sand substrate and sand
37 substrate. The average number of mussels was also significantly higher along the east bank
38 (1.5 individuals per 10 by 1 m (32 by 3.2 ft) section) than along the west bank
39 (0.6 individuals/section). Mussels were also more abundant upstream (1.8 individuals/section)
40 of Byron than downstream (0.5 individuals/section). ESI determined that this was not
41 temperature related, because the thermal plume was limited to an area near the west bank and
42 mussel densities abundance in semiquantitative samples did not differ significantly between
43 upstream and downstream locations along that bank. Samples were composed of both young
44 and old individuals, and half of the individuals collected were over 5 years old. Only 3.2 percent
45 of mussels collected were fresh dead shells, which indicates that the community has a low
46 mortality rate.

47 As a result of the 2011 study, ESI concluded that while species richness declined between the
48 1993 and 2011 study, a level-of-effort comparison between the two studies indicated that

1 species abundance increased. Both studies yielded the most individuals in a thin strip of
2 transitional substrate along the east bank, and more individuals occurred upstream than
3 downstream.

4 Fish

5 Beginning in 1972, EAI surveyed the Rock River fish community near Byron at the five river
6 sampling locations (R-1 through R-5) and at the mouths of the tributary streams listed in
7 Table 3–10. The results of the first sample year (1972 to 1973) were not reported in the FES-C
8 (AEC 1974), but some of the results of the first year are summarized in ComEd's ER-O (1981).
9 Its ER-O also describes the results of the second sample year (1973 to 1974).

10 EAI conducted fish samples with seines and by electrofishing. Seine samples were collected
11 with 10-ft and 50-ft beach seines with 1/4-in. mesh. Electrofishing was conducted with a
12 230-volt, 2,000-watt, 3-phase AC generator for 15 minutes on each side of the river at each of
13 the river stations. Beginning in 1974, hoop nets were also used to sample fish. EAI collected
14 42 species representing 8 families in the first sample year (1972 to 1973) and 31 species in
15 8 families in the second sample year (1973 to 1974). The 1972-to-1973 surveys included a
16 greater variety of minnows (*Pimephales* spp.), catfishes, and sunfishes (*Lepomis* spp.), while
17 the 1973-to-1974 surveys collected greater numbers of carpsuckers (*Carpionodes* spp.,
18 40.2 percent of individuals collected) and channel catfish (*Ictalurus punctatus*, 19.1 percent).
19 ComEd (1981) attributed this shift in collected species on changes in gear type (hoop nets
20 beginning in 1974) and effort (decrease in seining effort in several shallow areas in the second
21 sample year). Channel catfish dominated the game species collected in 1973 to 1974;
22 14 species of game fish were collected, which accounted for over 30 percent of total fish
23 collected, and 62 percent of these were channel catfish. The baselines studies found no
24 significant difference in the abundance or diversity of fish caught at the different sampling
25 locations. Table 3–11 lists the species collected during the 1973-to-1974 sample year and
26 relative abundance of each.

27 Preoperational monitoring continued until Byron began operating in 1985. The FES-O
28 (NRC 1982) provides limited information about the results of monitoring between 1975 and
29 1982, when the FES-O was published. Between 1975 and 1979, an additional eight species of
30 fish were collected that had not appeared in the first or second sample years. Channel catfish
31 continued to be the most abundant game fish collected in 1975 to 1976 and 1976 to 1977;
32 bluegill (*Lepomis macrochirus*) was the most abundant game species collected from 1977 to
33 1978; and black crappie (*Pomoxis nigromaculatus*) was most abundant in 1978-to-1979 and
34 1979-to-1980 collections.

35 In 1986 and 1987, biologists from INHS conducted fish surveys in Rock River adjacent to Castle
36 Rock State Park, which lies approximately 10 mi (16 km) downstream of the Byron discharge,
37 as well as in three tributary streams, to support an IDOT road improvement project (Wetzel
38 et al. 1988). Within the Rock River, INHS biologists collected minnow seine and bag seine
39 samples on September 4, 1986, in two narrow reaches of the river in waters of 0 to 5 ft (0 to
40 1.5 m). The minnow seines were 4 by 10 ft (1.2 by 3.0 m) in size with 1/4-in. mesh. Biologists
41 took at least 10 hauls per site and continued sampling at each site until no additional species
42 were collected. Bag seines were 4 by 30 ft (1.2 by 9.1 m) in size with 1/4-in. mesh. Biologists
43 also continued bag seine sampling until no additional species were collected.

1
2**Table 3–11. Fish Species Collected in the Vicinity of Byron During EAI Baseline Monitoring, 1973–1974**

Species	Common Name	No. Individuals Collected ^(a)			Relative Abundance (% Collected)
		Rock River	Tributaries	Total	
Catostomidae	Suckers	313	232	545	49.5
<i>Carpiodes carpio</i>	river carpsucker	157	118	275	25.0
<i>Carpiodes cyprinus</i>	quillback carpsucker	76	92	168	15.2
<i>Moxostoma macrolepidotum</i>	northern redhorse	53	9	62	5.6
<i>Catostomas commersoni</i>	white sucker	22	11	33	3.0
<i>Ictiobus cyprinellus</i>	bigmouth buffalo	3	0	3	0.3
<i>Moxostoma</i> spp.	redhorse spp.	2	0	2	0.2
<i>Hypentelium nigricans</i>	hog sucker	0	1	1	0.1
<i>Ictiobus bubalus</i>	smallmouth buffalo	0	1	1	0.1
Cyprinidae	Minnows	161	52	213	19.3
<i>Cyprinus carpio</i>	carp	104	39	143	13.0
<i>Notropis atherinoides</i>	emerald shiner	40	6	46	4.2
<i>Pimephales vigilax</i>	bullhead minnow	8	3	11	1.0
<i>Pimephales notatus</i>	bluntnose minnow	5	1	6	0.5
<i>Semotilus atromaculatus</i>	creek chub	2	0	2	0.2
<i>Notropis stramineus</i>	sand shiner	0	2	2	0.2
<i>Carassius auratus</i>	goldfish	1	0	1	0.1
<i>Hybopsis storeriana</i>	silver chub	1	0	1	0.1
<i>Notropis spilopterus</i>	spottail shiner	0	1	1	0.1
Ictaluridae	Bullhead Catfishes	207	4	211	19.2
<i>Ictalurus punctatus</i>	channel catfish	206	4	210	19.1
<i>Ictalurus melas</i>	black bullhead	1	0	1	0.1
Centrarchidae	Sunfishes	84	29	113	10.3
<i>Pomoxis nigromaculatus</i>	black crappie	38	9	47	4.3
<i>Pomoxis annularis</i>	white crappie	28	7	35	3.2
<i>Lepomis macrochirus</i>	bluegill	8	8	16	1.5
<i>Micropterus salmoides</i>	largemouth bass	5	3	8	0.7
<i>Micropterus dolomieu</i>	smallmouth bass	2	1	3	0.3
<i>Lepomis humilis</i>	orangespotted sunfish	2	1	3	0.3

Species	Common Name	No. Individuals Collected ^(a)			Relative Abundance (% Collected)
		Rock River	Tributaries	Total	
<i>Lepomis cyanellus</i>	green sunfish	1	0	1	0.1
Moronidae	Temperate Basses	8	0	8	0.7
<i>Morone chrysops</i>	white bass	6	0	6	0.5
<i>Morone mississippiensis</i>	yellow bass	2	0	2	0.2
Percidae	Perches	3	3	6	0.6
<i>Etheostoma nigrum</i>	johnny darter	2	2	4	0.4
<i>Stizostedion vitreum</i>	walleye	1	1	2	0.2
Esocidae	Pikes	1	4	5	0.5
<i>Esox Lucius</i>	northern pike	1	4	5	0.5
Sciaenidae	Drums	1	0	1	0.1
<i>Aplodinotus grunniens</i>	freshwater drum	1	0	1	0.1
TOTAL		778	324	1,102	100.0

^(a) Samples collected from Rock River sample locations R-1, R-2, R-3, R-4, and R-5; Woodland Creek (S-3); Leaf River (S-4); Spring Creek (S-5); and Silver Creek (S-6). Species arranged by number collected.

Source: ComEd 1981

1 In total, INHS collected 37 species of fish representing 8 families and 24 genera, of which
2 25 species representing 7 families and 16 genera were collected from two sampling transects in
3 the Rock River. Cyprinids were most commonly collected. Spotfin shiner (*Cyprinella*
4 *spilopterus*), which accounted for 63.1 percent of fish collected in the river, was the most
5 prevalent cyprinid, followed by bullhead minnow (*Pimephales vigilax*, 7.1 percent), bluntnose
6 minnow (*Pimephales notatus*, 6.9 percent), and striped shiner (*Luxilus chrysocephalus*,
7 5.8 percent). Game fishes were less commonly collected than would be expected: black
8 crappie, largemouth bass (*Micropterus salmoides*), and bluegill accounted for 3.9, 1.2, and
9 1.1 percent of Rock River collections, respectively. The low collection frequency of these
10 species was likely due to sampling gear. Seines are only effective in shallow areas with
11 relatively flat bottoms. Electrofishing or a mix of sampling gear designed for a wider variety of
12 microhabitats may have returned a more diverse and representative collection of fish. Thus,
13 while the INHS study indicates certain species' presence, it does not necessarily accurately
14 account for those species' abundance. One State-listed threatened species was collected
15 during this survey: a single gravel chub (*Erimystax x-punctatus*). Table 3–12 lists all species
16 collected in the Rock River during the INHS study.

1 **Table 3–12. Fish Species Collected Downstream of Byron During INHS Study, 1986–1987**

Species	Common Name	Individuals Collected at Rock River Sampling Locations ^(a)	
		Number	Percent (%)
<i>Cyprinella spiloptera</i>	spotfin shiner	358	63.1
<i>Pimephales vigilax</i>	bullhead minnow	40	7.1
<i>Pimephales notatus</i>	bluntnose minnow	39	6.9
<i>Luxilus chrysocephalus</i>	striped shiner	33	5.8
<i>Pomoxis nigromaculatus</i>	black crappie	22	3.9
<i>Notropis stramineus</i>	sand shiner	17	3.0
<i>Notropis hudsonius</i>	spottail shiner	11	1.9
<i>Micropterus salmoides</i>	largemouth bass	7	1.2
<i>Lepomis macrochirus</i>	bluegill	6	1.1
<i>Etheostoma zonale</i>	banded darter	6	1.1
<i>Notropis flavus</i>	stonecat	4	0.7
<i>Lepomis humilis</i>	orangespotted sunfish	4	0.7
<i>Stizostedion vitreum</i>	walleye	4	0.7
<i>Esox Lucius</i>	northern pike	3	0.5
<i>Percina phoxocephala</i>	slenderhead darter	2	0.4
<i>Etheostoma nigrum</i>	johnny darter	2	0.4
<i>Nocomis biguttatus</i>	hornyhead chub	1	0.2
<i>Erimystax x-punctata</i>	gravel chub	1	0.2
<i>Pimephales promelas</i>	fathead minnow	1	0.2
<i>Carpionodes cyprinus</i>	quillback	1	0.2
<i>Moxostoma erythrurum</i>	golden redhorse	1	0.2
<i>Moxostoma macrolepidotum</i>	northern redhorse	1	0.2
<i>Pylodictis olivaris</i>	flathead catfish	1	0.2
<i>Labidesthes sicculus</i>	brook silverside	1	0.2
<i>Lepomis cyanellus</i>	green sunfish	1	0.2
TOTAL		567	100

^(a) Species arranged by number collected.

Source: Wetzell et al. 1988

2 In August 2011, EA Engineering (2012) conducted electrofishing and seine samples at River
3 locations R-2, R-3, R-4, and R-5 and at the mouth of Spring Creek (S-5). Each transect was
4 sampled on the east bank (L) and west bank (R) and results were reported in terms of both
5 sampling transect and bank (i.e., R-1L, R-1R, R-2L, R-2R, etc.). Fish were collected by both

1 electrofishing and seining on August 29 and 30. Electrofishing was conducted using a
2 boat-mounted boom-type electrofishing system for 30-minute durations in a downstream
3 direction. Seining was conducted with seines 25 by 6 ft (7.6 by 1.8 m) in size with 3/16-in. ace
4 mesh along 15-m (49.2-ft) transects of shoreline in a downstream direction. Seining and
5 electrofishing were conducted on different days to avoid bias.

6 EA Engineering collected a total of 2,577 fish (1,794 individuals with seines and 783 individuals
7 with electrofishing gear) of 28 species representing 10 families during the study. While seining
8 collected the most individuals, electrofishing collected a more diverse sample that appears to
9 better represent the fish community near Byron. As in the previous studies near Byron,
10 cyprinids accounted for the overwhelming majority of individuals collected, with spotfin shiner
11 and bullhead minnow being particularly abundant (accounting for 40.2 and 25.0 percent of the
12 total individuals collected, respectively) and sand shiner (*Notropis stramineus*) and bluntnose
13 minnow being relatively common at 8.3 and 4.2 percent, respectively. Collected sport fish
14 included smallmouth bass (*Micropterus dolomieu*, 4.0 percent), channel catfish (1.4 percent),
15 and largemouth bass (0.8 percent). Gizzard shad (*Dorosoma cepedianum*, 4.9 percent) and
16 freshwater drum (*Aplodinotus grunniens*, 3.8 percent) were also relatively common. The
17 remaining 18 species each accounted for less than 2 percent of collected individuals (see
18 Table 3–13). No State-listed endangered or threatened fish were collected during this study.

19 During electrofishing samples, sampling location R-3R (along the west bank of the Rock River
20 upstream of Byron's discharge) yielded the highest number of fish (234 individuals), while the
21 lowest numbers were collected at the mouth of Spring Creek (S-5, 64 individuals) and along the
22 east river bank upstream of the discharge point (R-2L, 67 individuals). Similar numbers were
23 collected at the remaining sample locations (87 to 89 fish). Species composition ranged from
24 12 taxa (R-2R) to 17 taxa (R-3R, R-4L). Seven species—gizzard shad, spotfin shiner, bullhead
25 minnow, channel catfish, green sunfish (*Lepomis cyanellus*), smallmouth bass, and freshwater
26 drum—were collected at each of the seven sampling locations. The mean catch per effort
27 (CPE) for fish collected at all sampling locations was 224.0 fish/hour (fish/hr). Mean CPE for
28 sampling locations upstream of the Byron discharge (R-2L, R-2R) was 154 fish/hr, while mean
29 CPE at downstream locations (R-3L, R-3R, R-4L, R-4R, S-5) was 251.6 fish/hr. The CPE was
30 higher along the east river bank ("L" sample locations), on which Byron is located, which was
31 mainly due to higher catches of spotfin shiner and bullhead minnow at these locations.

32 During the seine samples, the most fish (965 individuals) were collected along the east river
33 bank near the discharge (R-3L), and the fewest number of fish (24) were collected along the
34 west river bank near the discharge (R-3R). Species composition ranged from 6 taxa along the
35 east bank upstream of the discharge (R-2L) and along the east bank downstream of the
36 discharge (R-4L) to 10 taxa along the west bank upstream of the discharge (R-2R) and along
37 the east bank near the discharge (R-3L). Four species—spotfin shiner, bluntnose minnow,
38 bullhead minnow, and smallmouth bass—were collected at each of the seven sampling
39 locations, and one species—sand shiner—was collected at six locations.

1
2**Table 3–13. Fish Species Collected in the Vicinity of Byron During EA Engineering Survey, 2011**

Species	Common Name	Individuals Collected ^(a)			Percent (%)
		Electrofishing	Seine	Combined	
<i>Cyprinella spiloptera</i>	spotfin shiner	148	889	1,037	40.2
<i>Pimephales vigilax</i>	bullhead minnow	103	540	643	25.0
<i>Notropis stramineus</i>	sand shiner	24	189	213	8.3
<i>Dorosoma cepedianum</i>	gizzard shad	108	17	125	4.9
<i>Pimephales notatus</i>	bluntnose minnow	28	81	109	4.2
<i>Micropterus dolomieu</i>	smallmouth bass	82	20	102	4.0
<i>Aplodinotus grunniens</i>	freshwater drum	99	0	99	3.8
<i>Lepomis huxnilis</i>	bluegill	33	14	47	1.8
<i>Notropis atherinoides</i>	emerald shiner	20	17	37	1.4
<i>Ictalurus punctatus</i>	channel catfish	28	9	37	1.4
<i>Lepomis cyanellus</i>	green sunfish	28	0	28	1.1
<i>Micropterus salmoides</i>	largemouth bass	18	3	21	0.8
<i>Carpodes cyprinus</i>	quillback	12	0	12	0.5
<i>Moxostoma anisuruin</i>	silver redhorse	12	0	12	0.5
<i>Cyprinus carpio</i>	common carp	10	1	11	0.4
<i>Carpodes</i> spp. and/or <i>Ictiobus</i> spp.	Ictiobinae spp.	0	7	7	0.3
<i>Moxostoma macrolepidotum</i>	shorthead redhorse	6	0	6	0.2
<i>Carpodes carpio</i>	river carpsucker	5	0	5	0.2
<i>Moxostoma erythrurum</i>	golden redhorse	4	0	4	0.2
<i>Etheostoma nigrum</i>	johnny darter	1	2	3	0.1
<i>Morone chrysops</i>	white bass	3	0	3	0.1
<i>Notropis</i> spp.	<i>Notropis</i> spp.	1	1	2	0.1
<i>Pylodictis olivaris</i>	flathead catfish	2	0	2	0.1
<i>Labidesthes sicculus</i>	brook silverside	2	0	2	0.1
<i>Lepomis</i> spp.	<i>Lepomis</i> spp.	0	2	2	0.1
<i>Lepomis humilis</i>	orangespotted sunfish	0	2	2	0.1
<i>Luxilus cornutus</i>	common shiner	1	0	1	<0.1
<i>Sander vitreus</i>	walleye	1	0	1	<0.1
<i>Esox Lucius</i>	northern pike	1	0	1	<0.1
<i>Ictiobus cyprinellus</i>	bigmouth buffalo	1	0	1	<0.1

Species	Common Name	Individuals Collected ^(a)			Percent (%)
		Electrofishing	Seine	Combined	
<i>Moxostoma duquesnei</i>	black redhorse	1	0	1	<0.1
<i>Lepomis hybrid</i>	<i>Lepomis hybrid</i>	1	0	1	<0.1
TOTAL		783	1,794	2,577	100

^(a) Species arranged by number collected.

Source: EA Engineering 2012

1 **3.8 Special Status Species and Habitats**

2 This section addresses species and habitats that are Federally protected under the Endangered
 3 Species Act of 1973 (16 U.S.C. § 1531 et seq., herein referred to as ESA) and the
 4 Magnuson–Stevens Fishery Conservation and Management Reauthorization Act, as amended
 5 (16 U.S.C. §§ 1801–1884, herein referred to as MSA). The ESA, along with the MSA, put
 6 requirements on Federal agencies such as the NRC. The terrestrial and aquatic resource
 7 sections (Sections 3.6 and 3.7, respectively) discuss other species and habitats protected by
 8 other Federal acts and the State of Illinois that do not put requirements on the NRC.

9 **3.8.1 Species and Habitats Protected Under the Endangered Species Act**

10 The FWS and the National Marine Fisheries Service (NMFS) jointly administer the ESA. The
 11 FWS manages the protection of, and recovery effort for, listed terrestrial and freshwater
 12 species, and NMFS manages the protection of and recovery effort for listed marine and
 13 anadromous species. This section describes the action area and considers those species that
 14 could occur in the action area under both FWS’s and NMFS’s jurisdictions.

15 **3.8.1.1 Action Area**

16 The implementing regulations for section 7(a)(2) of the ESA define “action area” as all areas
 17 affected directly or indirectly by the Federal action and not merely the immediate area involved
 18 in the action (50 CFR 402.02). The action area effectively bounds the analysis of
 19 ESA-protected species and habitats because only species that occur within the action area may
 20 be affected by the Federal action.

21 For the purposes of the ESA analysis in this SEIS, the NRC staff considers the action area to be
 22 the Byron site (described in Sections 3.1 and 3.6) and the Rock River (described in Section 3.7)
 23 from 300 yd (270 m) upstream of the cooling tower blowdown discharge point and extending
 24 0.7 mi (1.1 km) downstream of the discharge point. This area of the river corresponds to the
 25 area that EAI and EA Engineering, Science, and Technology determined to be inclusive of
 26 effects from Byron operations during preoperational and operational aquatic monitoring (as
 27 discussed in Section 3.7). The NRC staff expects all direct and indirect effects of the proposed
 28 action to be contained within these areas.

29 The NRC staff recognizes that while the action area is stationary, Federally listed species can
 30 move in and out of the action area. For instance, a migratory fish species could occur in the
 31 action area seasonally as it travels up and down the river past Byron. Similarly, a flowering
 32 plant known to occur near, but outside, of the action area could appear within the action area
 33 over time if its seeds are carried into the action area by wind, water, or animals. Thus, in its

Affected Environment

1 analysis, the NRC staff considers not only those species known to occur directly within the
2 action area, but those species that may passively or actively move into the action area. The
3 staff then considers whether the life history of each species makes the species likely to move
4 into the action area where it could be affected by the proposed Byron license renewal.

5 Within the action area, Federally listed terrestrial species could experience impacts such as
6 habitat disturbance associated with refurbishment or other ground-disturbing activities, cooling
7 tower drift, collisions with cooling towers and transmission lines, exposure to radionuclides, and
8 other direct and indirect impacts associated with station, cooling system, and inscope
9 transmission line operation and maintenance (NRC 2013a). The proposed action has the
10 potential to affect Federally listed aquatic species in several ways: impingement or entrainment
11 of individuals into the cooling system; alteration of the riverine environment through water level
12 reductions, changes in dissolved oxygen, gas supersaturation, eutrophication, and thermal
13 discharges from cooling system operation; habitat loss or alteration from dredging; and
14 exposure to radionuclides (NRC 2013a).

15 *3.8.1.2 Species and Habitats under the FWS's Jurisdiction*

16 Table 3–14 identifies the species under FWS's jurisdiction that occur within Ogle County. Ogle
17 County includes approximately 488,000 ac (198,000 ha) of varying land uses and habitat types.
18 Thus, a Federally listed species that occurs within Ogle County does not necessarily occur
19 within the action area. The NRC staff uses this geographical range as a starting point for its
20 analysis because Federally listed species distribution and critical habitat information is readily
21 available at the county level. Additionally, the action area is a small area of land near the center
22 of and wholly contained within the geographical boundaries of the county. Following the table,
23 descriptions of each species include a determination of whether each species occurs in the
24 action area based on the species' habitat requirements, life history, and available occurrence
25 information.

26 The NRC compiled the list of species in Table 3–14 from the FWS's Endangered Species
27 Program online database (FWS 2013b); correspondence between the NRC and the FWS
28 (FWS 2013a; NRC 2013b, 2013c); the Illinois Natural Heritage Database (IDNR 2013);
29 information from Exelon's ER (Exelon 2013a); and available scientific studies, surveys, and
30 literature. The NRC staff did not identify any candidate species or proposed or designated
31 critical habitats within the action area.

1

Table 3–14. Federally Listed Species in Ogle County, Illinois

Species	Common Name	Federal Status ^(a)	Habitat
Mammals			
<i>Myotis septentrionalis</i>	northern long-eared bat	P	Intact forest with relatively full canopy and oaks, maples, beech, or pine present
<i>Myotis sodalis</i>	Indiana bat	E	Hardwood forests and hardwood–pine forests; old-growth forest; agricultural lands and old fields
Plants			
<i>Lespedeza leptostachya</i>	prairie bush clover	T	Dry tallgrass prairie with gravelly soils
<i>Platanthera leucophaea</i>	Eastern prairie fringed orchid	T	Mesic prairie, wetlands, sedge meadows, marsh edges, and bogs with full sun and little to no woody encroachments
<i>Dalea foliosa</i>	leafy prairie clover	E	Mesic and wet-mesic dolomite prairie, limestone cedar glades, and limestone barrens

^(a) E = endangered; T = threatened; P = proposed for Federal listing

Sources: Exelon 2013a; FWS 2013a, 2013b

2 **Northern Long-Eared Bat (*Myotis septentrionalis*)**

3 The FWS published a proposed rule to list the northern long-eared bat as endangered
 4 throughout its range on December 2, 2013 (78 FR 72058). The FWS did not propose to
 5 designate critical habitat for the species because it found that such habitat is “not determinable
 6 at this time” (78 FR 61046). White-nose syndrome, wind energy development, and loss of
 7 habitat specifically linked to surface coal mining in prime summer habitat are factors that have
 8 contributed to this species’ decline.

9 The northern long-eared bat is a medium-sized bat that is distinguished from other *Myotis*
 10 species by its long ears, which average 0.7 in. (17 mm) in length. This bat inhabits 39 states in
 11 the eastern and north central United States and all Canadian provinces west to the southern
 12 Yukon Territory and eastern British Columbia. Populations tend to be patchily distributed across
 13 its range and are typically composed of small numbers. More than 780 winter hibernacula have
 14 been recorded in the United States (36 in Illinois), most of which contain only a few (one to
 15 three) individuals. The FWS recognize four United States populations. Northern long-eared
 16 bats inhabiting Illinois are considered part of the Midwest population (78 FR 61046).

17 In the Midwest, the northern long-eared bat is fairly common during summer mist-net surveys
 18 and is found infrequently in winter hibernacula surveys (78 FR 61046). The species is regularly
 19 caught in consistent numbers in mist-net surveys in the Shawnee National Forest
 20 (78 FR 61046), which lies about 320 mi (515 km) south of the Byron site. In summer, bats roost
 21 alone or in small colonies under the bark of live or dead trees; in caves or mines; or in
 22 manmade structures, such as barns, sheds, and other buildings. The species opportunistically

Affected Environment

1 roosts in a variety of trees, including several species of oak, maple, beech, and pine
2 (78 FR 61046). Carter and Feldhamer (2005) found that roosting females in southern Illinois
3 prefer intact forest with greater canopy cover. Northern long-eared bats forage both in flight and
4 on the ground and eat a variety of moths, flies, leafhoppers, caddisflies, and beetles. The
5 species breeds from late July to early October, after which time it will migrate to winter
6 hibernacula. Northern long-eared bats are short-distance migrators and will travel 35 to 55 mi
7 (56 to 89 km) from summer roosts to winter hibernacula (78 FR 61046). Hibernating females
8 store sperm until spring, and give birth to one pup approximately 60 days after fertilization
9 (78 FR 61046). Females raise young in maternity colonies of up to 30 individuals
10 (78 FR 61046).

11 The majority of the action area is developed or composed of unsuitable habitat types for
12 hibernation, roosting, and foraging. The action area includes some small areas of mixed
13 woodlands, which would likely not be adequately sized to support the northern long-eared bat's
14 preference for intact forests with relatively full canopy cover. The NRC staff did not identify any
15 records or other studies that suggest the occurrence of northern long-eared bats in the action
16 area, and in its ER, Exelon (Exelon 2013a) does not indicate awareness of any records or
17 observations of the northern long-eared bat's occurring on plant property.

18 Given the available information, the NRC staff concludes that the northern long-eared bat is
19 unlikely to occur within the action area.

20 Indiana Bat (*Myotis sodalis*)

21 The FWS listed the Indiana bat as endangered in 1967 (32 FR 4001). The FWS designated
22 critical habitat for the Indiana bat in 1976 (41 FR 41914) to include 11 caves and 2 mines in
23 six states, including a cave in LaSalle County, Illinois. However, no critical habitat for this
24 species occurs in Ogle County.

25 The Indiana bat is an insectivorous, migratory bat that inhabits the central portion of the Eastern
26 United States and hibernates colonially in caves and mines. The decline of Indiana bats is
27 attributed to urban expansion, habitat loss and degradation, human-caused disturbance of
28 caves or mines, insecticide poisoning, and white-nose syndrome (FWS 2011; Pruitt and
29 TeWinkel 2007).

30 During summer months, reproductive female bats tend to roost in colonies under slabs of
31 peeling tree bark or cracks within trees in forest fragments, often near agricultural areas (Pruitt
32 and TeWinkel 2007). Colonies may also inhabit closed-canopy, bottomland deciduous forest;
33 riparian habitats; wooded wetlands and floodplains; and upland communities (Pruitt and
34 TeWinkel 2007). Maternity colonies typically consist of 60 to 80 adult females (Whitaker and
35 Brack 2002). Colonies occupy multiple trees for roosting and rearing young (Watrous
36 et al. 2006) and, once established, usually return to the same areas each year (Pruitt and
37 TeWinkel 2007). Nonreproductive females and males do not roost in colonies during the
38 summer; they may remain near the hibernacula or migrate to summer habitat (Pruitt and
39 TeWinkel 2007). High-quality summer habitat includes mature forest stands containing open
40 subcanopies, multiple moderate- to high-quality snags, and trees with exfoliating bark (Farmer
41 et al. 2002). In summer, bats forage for insects along forest edges, riparian areas, and in
42 semiopen forested habitats. In the winter, Indiana bats rely on caves for hibernation. The
43 species prefers hibernacula in areas with karst (limestone, dolomite, and gypsum), although it
44 may also use other cave-like locations, such as mines.

45 The Indiana Bat Recovery Plan (Pruitt and TeWinkel 2007) indicates that Indiana bats are
46 distributed across 36 of the 102 counties in Illinois. Twenty-two winter hibernacula (16 extant,
47 4 of uncertain status, and 2 historic) are located throughout these counties. Additionally,

1 29 extant maternity colonies occur in Illinois, and adult males, nonreproductive females, or both
2 have been captured during summer surveys within 26 of the 36 counties. None of these
3 records identify Ogle County or any of the counties directly neighboring Ogle County as
4 containing hibernacula or maternity colonies. For 2007, the FWS (2009) estimated that Illinois's
5 total population of Indiana bats was 54,095 individuals. According to more recent estimates
6 based on FWS winter surveys conducted in January and February of 2013, the Illinois
7 population of Indiana bats has increased by almost 2,000 over the past 6 years to
8 55,956 individuals (King 2013).

9 The majority of the action area is developed or composed of unsuitable habitat types for
10 hibernation, roosting, and foraging. The action area includes approximately 750 ac (300 ha) of
11 land leased for agricultural use as well as some areas of mixed woodlands, meadows, and
12 grasslands that could provide some marginal foraging habitat. The IDNR (2013) Natural
13 Heritage Database indicates that the Indiana bat was last observed in Ogle County in
14 April 2011. However, in March 2012, Exelon generated an IDNR Ecological Compliance
15 Assessment Tool (EcoCAT) report that included Illinois Natural Heritage Database information
16 on species that could potentially be affected by the proposed license renewal. This report did
17 not indicate the presence of the Indiana bat on or in the vicinity of the Byron site
18 (Exelon 2013a). The NRC staff did not identify any other records or other studies that suggest
19 the occurrence of Indiana bats in the action area. Additionally, Exelon (2013a) indicates in its
20 ER that it is not aware of observations or records of Indiana bat occurrences on plant property.

21 Given the available information, the NRC staff concludes that the Indiana bat is unlikely to occur
22 within the action area.

23 Prairie Bush Clover (*Lespedeza leptostachya*)

24 The FWS listed the prairie bush clover as threatened in 1987 (52 FR 781). No critical habitat
25 has been designated for this species.

26 The prairie bush clover is an herbaceous perennial in the pea family (Fabaceae) that grows up
27 to 1 m (3.2 ft) tall (Smith et al. 1988). The plant has clover-like leaves, pale pink to
28 cream-colored flowers that bloom in mid-July, and silvery-green seed pods (FWS 2013f).
29 Historically, the species spanned 27 counties in Minnesota, Wisconsin, Iowa, and Illinois in the
30 tallgrass prairie region of the Upper Mississippi River Valley. Today, it is present in 24 counties
31 and is most prevalent in northern Iowa and southern Minnesota (Smith et al. 1988). The
32 species inhabits north-facing mesic to dry-mesic prairie slopes in soils with a mixture of loam,
33 colluvium, sand, and gravel and occurs in populations ranging from tens to thousands of
34 individuals (MDNR 2013). The IDNR (2013) Natural Heritage Database indicates that the
35 prairie bush clover was last observed in Ogle County in the summer of 2009.

36 The March 2012 EcoCAT report indicated that the prairie bush clover may occur in the vicinity of
37 the Byron site (Exelon 2013a). Although the action area includes approximately 150 ac of
38 grasslands (Starke and Cox 2011), these grasslands do not include tallgrass prairie habitat (see
39 Section 3.6 for a description of terrestrial resources). Additionally, Exelon (2012b) states in a
40 biological evaluation submitted to the IDNR that the Byron site does not provide optimal habitat
41 for the prairie bush clover and that it is not aware of observations or records of the species
42 occurring on plant property.

43 Given the available information, the NRC staff concludes that the prairie bush clover is unlikely
44 to occur within the action area.

Affected Environment

1 Eastern Prairie Fringed Orchid (*Platanthera leucophaea*)

2 The FWS listed the eastern prairie fringed orchid as threatened in 1989 (54 FR 39857). No
3 critical habitat has been designated for this species.

4 The eastern prairie fringed orchid is a perennial herb that grows 8 to 40 in. (20 to 102 cm) tall
5 and produces long clusters of up to 40 white flowers in early July (NatureServe 2013). It
6 inhabits mesic prairie, wetlands, sedge meadows, marsh edges, and bogs with full sun and little
7 to no woody encroachments (FWS 2013e). These orchids require hawkmoths for successful
8 pollination, and seedling establishment requires a mycorrhizal relationship with soil fungus
9 (Bowles 1999). Eastern prairie fringed orchids occur in the Eastern United States, Great Lakes
10 states, and in Nova Scotia and Ontario, Canada. Illinois contained the largest historic
11 populations of the species with populations at one time occurring in 33 counties (Bowles 1999).
12 Today, about 20 populations are thought to exist in six counties near the Chicago region
13 (Bowles 1999).

14 The IDNR (2013) Natural Heritage Database does not indicate that the eastern prairie fringed
15 orchid has been observed in Ogle County, nor did the EcoCAT report indicate that the species
16 occurs on or in the vicinity of the Byron site (Exelon 2013a). Additionally, Exelon (2012b) states
17 in a biological evaluation submitted to the IDNR that the Byron site does not provide optimal
18 habitat for the eastern prairie fringed orchid and that it is not aware of observations or records of
19 the species occurring on plant property.

20 Given the available information, the NRC staff concludes that the eastern prairie fringed orchid
21 is unlikely to occur within the action area.

22 Leafy Prairie Clover (*Dalea foliosa*)

23 The FWS listed the leafy prairie clover as endangered in 1991 (56 FR 19953). No critical
24 habitat has been designated for this species.

25 The leafy prairie clover is a perennial wildflower in the legume family (Fabaceae) that grows
26 1 to 2 ft (0.3 to 0.6 m) tall (DeMauro and Bowles 1996). The plant has alternate compound
27 leaves, and small purple-to-pink flowers form in dense spikes at the top of stems in mid-to-late
28 summer. Leafy prairie clovers grow in partial to full sun and thin rocky soils that are moist to
29 slightly dry. The species occurs in northern Illinois, Tennessee, and Alabama. In Illinois, it is
30 found in mesic dolomite prairie remnants along the Des Plaines River, while in Tennessee and
31 Alabama, it is found in cedar glades (DeMauro and Bowles 1996; FWS 2013c).

32 Given that the action area does not include any portion of the Des Plaines River, the leafy
33 prairie clover is unlikely to be present. Additionally, the IDNR (2013) Natural Heritage Database
34 does not indicate that the leafy prairie clover has been observed in Ogle County, and the
35 EcoCAT report did not indicate that the species occurs on or in the vicinity of the Byron site
36 (Exelon 2013a).

37 Given the available information, the NRC staff concludes that the leafy prairie clover is unlikely
38 to occur within the action area.

39 *3.8.1.3 Species and Habitats Under NMFS's Jurisdiction*

40 As discussed in Section 3.7, the Rock River does not contain marine or anadromous fish
41 species. Therefore, no Federally listed species or habitats under NMFS's jurisdiction occur
42 within the action area.

1 **3.8.2 Species and Habitats Protected Under the Magnuson–Stevens Act**

2 NMFS has not designated essential fish habitat in the Rock River. Therefore, this section does
3 not contain a discussion of any species or habitats protected under the MSA.

4 **3.9 Historic and Cultural Resources**

5 This section discusses the cultural background and the known historic and cultural resources
6 found on and in the vicinity of Byron. The discussion is based on a review of historic and
7 cultural resource surveys and other background information on the region surrounding Byron.
8 In addition, a records search was performed via the Illinois Historic Preservation Agency (IHPA)
9 (Pauketat 1993) to obtain the most updated information about historic and cultural resources in
10 the region.

11 The Area of Potential Effect (APE) is the area at the Byron power plant site, the transmission
12 lines up to the first substation, and immediate environs that may be affected by the license
13 renewal decision and land-disturbing activities associated with continued reactor operations.
14 For this analysis, the first substation (345-kV Byron switchyard) is located on the Byron site
15 (Exelon 2013b). The APE may extend beyond the immediate environs in instances where
16 land-disturbing maintenance and operations activities during the license renewal term or
17 refurbishment activities could potentially have an effect. See Figure 3–3.

18 **3.9.1 Cultural Background**

19 Human occupation in the vicinity of Byron site is generally characterized according to the
20 following chronological sequence (Pauketat 1993):

- 21 • Paleo-Indian Period (12,000 – 10,000 before present (BP)),
- 22 • Archaic Period (10,000 – 3,000 BP),
- 23 • Woodland Period (3,000 – 1,100 BP),
- 24 • Mississippian Period (1,100 – 400 BP (ca. A.D. 900 – 1600)), and
- 25 • Protohistoric/Historic Period (400 – Present (ca. A.D. 1600 – Present)).

26 Paleo-Indian Period (12,000 – 10,000 BP)

27 The earliest evidence of people living in Illinois dates to the Paleo-Indian Period. Paleo-Indian
28 sites are generally found upland or on river terraces and are characterized by specific types of
29 projectile points (i.e., fluted Clovis and Folsom points) and stone tools such as graters,
30 scrapers, or large blades. These artifacts often occur in association with mastodon remains,
31 suggesting a reliance on megafauna (e.g., mammoth, ground sloth, and saber-tooth tiger) for
32 subsistence, along with plants, small game, birds, and amphibians. Social organization
33 consisted of small, highly nomadic bands of hunter-gatherers, leaving Paleo-Indian sites with
34 little detailed archaeological information (Neusius and Gross 2007; Pauketat 1993).

35 Archaic Period (10,000 – 3,000 BP)

36 The Archaic Period was a time of major climatic shifts as colder environments transitioned to
37 warmer environments similar to modern conditions. In response to this shift, new technologies
38 and subsistence strategies were developed during this time. The Archaic Period is often divided
39 into early, middle, and late subperiods. The Early Archaic Period is characterized by a shift
40 from nomadic to sedentary settlement patterns, with central base camps located on river
41 terraces and smaller hunting camps located in upland areas. This subperiod also shows an
42 increased reliance on wild plant foods, small game, and aquatic resources. The Middle Archaic

Affected Environment

1 Period is characterized by an increased number of settlement sites on high stream terraces,
2 which may reflect population increases. While subsistence and settlement patterns remained
3 fairly similar to the Early Archaic Period, artifact assemblages suggest increased exploitation of
4 aquatic resources as well as new artifacts such as pecked and ground stone tools used for
5 intensive processing of nuts, banner stones that signaled the innovation of a new projectile
6 technology called the atlatl or spear-thrower, and grooved axes. The Late Archaic Period is
7 characterized by an increase in the number and size of settlement sites, which indicates an
8 increase in population and a more sedentary lifestyle. New features of Late Archaic artifact
9 assemblages, such as crude ceramic vessels, represent a shift toward increased reliance on
10 horticulture as a subsistence strategy, although hunting and gathering would have continued
11 (Fagan 2005; Neusius and Gross 2007; Pauketat 1993).

12 Woodland Period (3,000 – 1,100 BP)

13 The Woodland Period is also often divided into early, middle and late periods. However, the
14 distinction between the early and middle period is not fixed. The Woodland Period is marked by
15 an increase in more permanent settlements, changes in burial practices, increased cultivation of
16 plants such as sunflowers and cucurbits (i.e., squashes, gourds, melons, etc.), and a rise in the
17 manufacture and use of pottery (Fagan 2005). During the Middle Woodland Period, the large
18 and complex Hopewell Culture emerged in the northeastern and midwestern United States,
19 including Illinois. This culture is characterized by settlement in villages, increased reliance on
20 intensive horticulture, burial mounds, and long-distance trade networks. These long-distance
21 networks allowed the trade of exotic materials, such as marine shells from the Gulf Coast,
22 obsidian from the Rocky Mountains, copper from Lake Superior, and mica from the Appalachian
23 Mountains far outside their immediate locations. Evidence of the Illinois Hopewell culture is
24 found primarily in the bluffs and floodplains of the Illinois River Valley. The burial mounds of this
25 period often included central features, lined with logs, and filled with grave goods. Different
26 burial treatments within the mounds point to social stratification within society, but through sex
27 and age rather than hereditary lineage (Neusius and Gross 2007). The Late Woodland Period
28 is characterized by an increase in settlement sites, which suggests a rise in population and/or a
29 change in settlement patterns from large, centralized village sites to smaller, dispersed
30 habitation sites. Late Woodland Period artifact assemblages are characterized by an increase
31 in thin-walled plain ceramic types and stemmed and side-notched projectile points. The sudden
32 appearance of very small, thin triangular projectile points between 1,300 and 1,400 BP indicates
33 the invention of bow-and-arrow technology and suggests a corresponding change in hunting
34 techniques (Fagan 2005).

35 Mississippian Period (1,100 – 400 BP (ca. A.D. 900 – 1600))

36 The Mississippian Period is characterized by major changes in settlement, subsistence patterns,
37 and social structure. Large highly centralized chiefdoms with permanent settlement sites
38 supported by numerous satellite villages emerged during this period. The platform mound, a
39 new ceremonial earthen mound appeared in association with these permanent settlements.
40 Platform mounds, burial mounds, and defensive structures, such as moats and palisades, were
41 often constructed in clusters in settlements of this period and were common in the larger river
42 valleys of the Midwest. Mississippian Period subsistence relied heavily on maize agriculture, as
43 well as hunting and gathering. Long-distance trading increased and craft specialists produced
44 highly specialized lithic and ceramic artifacts, beadwork and shell pendants (Fagan 2005).

45 In southern Wisconsin and northern Illinois, the emerging Mississippian culture was blended
46 with the receding Woodland culture to produce the Oneota tradition. The Oneota were
47 organized in permanent villages, produced unique ceramic artifacts, and relied on a mixed
48 subsistence strategy of hunting and gathering, though cultivation of maize was practiced. Burial

1 traditions varied from the mounds of the Woodland Period to nonmounded cemeteries near their
2 villages (Exelon 2013a; Neusius and Gross 2007).

3 Protohistoric/Historic Period (A.D. 1600 – Present)

4 The end of the Mississippian Period is characterized by severe social, political, and
5 demographic changes that resulted from indirect and direct contact with Europeans. In
6 particular, it is believed that the introduction of European infectious diseases such as smallpox,
7 yellow fever, typhoid, and influenza severely decimated Native American populations, which had
8 no immunity to these diseases. The spread of these diseases, which were fatal to large
9 numbers of Native Americans, resulted in the widespread abandonment of villages and a
10 concurrent collapse of Native American socioeconomic networks, such that by the time of
11 widespread European contact and settlement, the Mississippian chiefdoms were gone
12 (Fagan 2005). During this time period, Illinois was primarily populated with a confederation of
13 tribes known as the Illinois, or Illiniwek, and the Miami tribe. During the 1700s and early 1800s,
14 new tribes migrated to Illinois, including the Iroquois, Fox (Mesquakie), loway, Kickapoo,
15 Mascouten, Piankashaw, Potawatomi, Sauk, Shawnee, Wea, and Winnebago. Competition for
16 resources led to sporadic war among the Illinois and surrounding tribes for approximately the
17 next 120 years (ISM 2002). French explorers and fur traders travelled down the Mississippi
18 River into Illinois in the 17th century. Early European settlements were established along the
19 river systems by settlers seeking to profit from the fur trade. Illinois became part of the
20 United States Northwest Territory at the close of the American Revolution and became a state
21 in 1818 with Ogle County being formed in 1836. The area surrounding the Byron site has
22 principally been used as agricultural land from this period onward (Ogle County 2014).

23 **3.9.2 Historic and Cultural Resources**

24 Historic and cultural resources include prehistoric era and historic era archaeological sites,
25 historic districts, and buildings, as well as any site, structure, or object that may be considered
26 eligible for listing on the National Register of Historic Places (NRHP). Historic and cultural
27 resources also include traditional cultural properties that are important to a living community of
28 people for maintaining their culture. “Historic property” is the legal term for a historic and/or
29 cultural resource that is eligible for listing on the NRHP.

30 A review of databases maintained by the National Park Service (NPS) indicates that there are
31 24 properties listed in the NRHP within Ogle County, including one that has been designated a
32 National Historic Landmark (NHL) (NPS 2014a, 2014b). These historic properties reflect the
33 historic cultural contexts for the Byron property and include historic buildings, structures, and
34 districts dating from the mid-18th through mid-20th centuries. However, none of the 24 historic
35 properties are located within the boundaries of the Byron property. The closest NRHP-eligible
36 site is in Byron, Illinois, approximately 4 mi (6 km) to the northeast.

37 In 1973 and 1974, Phase I and Phase II archaeological surveys were undertaken by the
38 University of Wisconsin – Milwaukee for all lands purchased by ComEd for the proposed
39 construction of Byron. These surveys identified eight archaeological sites and recommended
40 fencing sites along the Rock River for protection if any construction would occur in their
41 immediate area. Surveyors also recommended leaving a 15-meter (m) (50-ft) buffer between
42 the other identified sites and any new construction (Birmingham and Fowler 1974). The Illinois
43 State Historic Preservation Officer (SHPO) concurred that operation of Byron would not result in
44 any significant impact on historic and cultural sites in the area (Exelon 2013b).

45 A search of the Illinois State Archaeological Site Files, a database maintained by the Illinois
46 SHPO, by NRC staff identified four cultural resources within the current confines of the Byron

Affected Environment

1 site, with one site immediately adjacent to the property boundary. All sites are ineligible for the
2 NRHP. These sites are identified in Table 3–15.

3 **Table 3–15. Cultural Resources Within the Byron Site**

Site	On the Byron Site	Description	NRHP
11OG153	No	Archaic dwelling and/or hearth	Ineligible
11OG155	Yes	Prehistoric; scattered surface finds of projectile points, scrapers, and flakes	Ineligible
11OG156	Yes	Prehistoric; scattered surface finds of projectile points, scrapers, and flakes	Ineligible
11OG157	Yes	Prehistoric; scattered surface finds of projectile points, scrapers, and flakes	Ineligible
11OG158	Yes	Prehistoric; scattered surface finds of projectile points, scrapers, and flakes	Ineligible

Source: Illinois Inventory of Archaeological Sites, ISM 2014

4 **3.10 Socioeconomics**

5 This section describes current socioeconomic factors that have the potential to be directly or
6 indirectly affected by changes in operations at Byron. Byron, and the communities that support
7 it, can be described as a dynamic socioeconomic system. The communities supply the people,
8 goods, and services required to operate the nuclear power plant. Power plant operations, in
9 turn, supply wages and benefits for people and dollar expenditures for goods and services. The
10 measure of a community’s ability to support Byron operations depends on its ability to respond
11 to changing environmental, social, economic, and demographic conditions.

12 **3.10.1 Power Plant Employment and Expenditures**

13 The socioeconomic region of influence (ROI) is defined by the areas where Byron employees
14 and their families reside, spend their income, and use their benefits, thus affecting the economic
15 conditions of the region. Exelon Generation employs a permanent workforce of approximately
16 870 employees and 20 long-term contract employees (Exelon 2013a). Approximately
17 82 percent of Byron employees reside in a three-county area in northern Illinois in Lee, Ogle,
18 and Winnebago Counties. Most of the remaining 18 percent of the workforce are spread among
19 18 other counties in Illinois and 5 counties outside of Illinois, with numbers ranging from 1 to
20 53 employees per county (Exelon 2013a). Given the residential locations of Byron employees,
21 the most significant effects of plant operations are likely to occur in Ogle, Lee, and Winnebago
22 counties. Table 3–16 summarizes the Byron workforce geographic distribution. The focus of
23 the socioeconomic impact analysis in this SEIS is, therefore, on the impacts of continued Byron
24 operations on these three counties, also termed the ROI.

1

Table 3–16. Exelon Generation Employees Residence by County

County	Number of Employees	Percentage of Total
DeKalb	25	3
Lee	115	13
Ogle	352	41
Whiteside	52	6
Winnebago	243	28
Other counties	80	9
Total	867	100

Source: Exelon 2013b

2 Exelon purchases goods and services to facilitate Byron operations. While specialized
3 equipment and services are procured from a wider region, some proportion of the goods and
4 services used in plant operations are acquired from within the ROI. These transactions fuel a
5 portion of the local economy, as jobs are provided and additional local purchases are made by
6 plant suppliers.

7 The Byron units are on staggered 18-month refueling intervals. During refueling outages, site
8 employment typically increases by an average of 1,400 temporary workers for approximately
9 20 days (Exelon 2013a). Outage workers are drawn from all regions of the country; however,
10 the majority would be expected to come from Illinois, Wisconsin, and other Midwestern States.

11 **3.10.2 Regional Economic Characteristics**

12 This section presents information on employment and income in the Byron socioeconomic ROI.
13 The three-county ROI is predominantly rural and agricultural. Agricultural and forested land
14 comprises the majority of the land use in Ogle, Lee, and Winnebago Counties. Urban
15 developed land makes up only about 8, 7, and 25 percent of total land area of each county,
16 respectively (NASS 2012b).

17 *3.10.2.1 Employment and Income*

18 From 2000 to 2012, the labor force in the Byron ROI decreased approximately 4 percent to just
19 over 183,000. The number of employed persons declined by about 10.6 percent over the same
20 period, to approximately 163,000. Consequently, the number of unemployed people in the ROI
21 has increased nearly 135 percent in the same period, to over 11,700, or about 6.7 percent of the
22 current workforce—up from 4.5 percent in 2000 (BLS 2014).

23 According to the U.S. Census Bureau's (USCB's) 2008–2012 American Community Survey
24 5-Year Estimates, the educational, health, and social services industry represented the largest
25 employment sector in the socioeconomic ROI (22.5 percent) followed by manufacturing
26 (21 percent) and retail (11.4 percent). A list of employment by industry in each county of the
27 ROI is provided in Table 3–17.

Affected Environment

1 **Table 3–17. Employment by Industry in the Byron ROI (5-year estimates 2008–2012)**

Industry	Lee	Ogle	Winnebago	Total	Percent
Total employed civilian workers	16,202	25,827	131,758	173,787	–
Agriculture, forestry, fishing, hunting, and mining	463	606	648	1,717	1.0
Construction	851	1,834	6,525	9,210	5.3
Manufacturing	3,127	4,360	28,961	36,448	21.0
Wholesale trade	564	875	3,104	4,543	2.6
Retail trade	1,731	3,087	14,929	19,747	11.4
Transportation, warehousing, and utilities	1,074	2,420	7,585	11,079	6.4
Information	220	503	2,243	2,966	1.7
Finance, insurance, real estate, rental, and leasing	644	1,237	6,466	8,347	4.8
Professional, scientific, management, administrative, and waste management services	988	1,924	10,314	13,226	7.6
Educational, health, and social services	3,975	5,014	30,097	39,086	22.5
Arts, entertainment, recreation, accommodation, and food services	1,143	1,709	10,169	13,021	7.5
Other services (except public administration)	632	1,342	6,938	8,912	5.1
Public administration	790	916	3,779	5,485	3.2

Source: USCB 2014a

- 2 Major employers in Ogle County, the county in which Byron is located, are listed in Table 3–18.
3 Exelon Generation is shown as the largest employer in the county.
- 4 Estimated income information for the Byron ROI is presented in Table 3–19. According to the
5 USCB’s 2008–2012 American Community Survey 5-Year Estimates, people living in the
6 three-county ROI had median household and per capita incomes below the State average.
7 Winnebago County has the highest percentages of persons (17 percent) living below the official
8 poverty level when compared to the other two counties and the State of Illinois as a whole. Lee
9 and Ogle Counties had 10 percent, respectively, and the State of Illinois as a whole had
10 13.7 percent. The percentage of families living below the poverty level in Lee and Ogle
11 Counties (7.4 percent, respectively) was lower than the percentage of families in Winnebago
12 County and the State of Illinois as a whole (12.8 percent and 10 percent, respectively)
13 (USCB 2014a).

1

Table 3–18. Major Employers in Ogle County in 2012

Employer (City or Village)	Industry/Product/Service	Number of Employees
Exelon Generation (Byron)	Electric utility, nuclear power generation	870
Rochelle Foods/Hormel (Rochelle)	Pork products	760
E.D. Etnyre & Co. (Oregon)	Road construction equipment manufacturing	350
Pine Crest Manor (Mt. Morris)	Nursing care facility	312
Rochelle Schools (Rochelle)	Education	305
Rochelle Hospital (Rochelle)	Health care	265
Veolia (Davis Junction)	Solid waste disposal/landfill operation	251
Byron Schools (Byron)	Education	250
Sara Lee (Rochelle)	Cold storage, sales & marketing	235
Americold (Rochelle)	Frozen foods storage & distribution	232
Quality Metal Finishing, Inc. (Byron)	Metal plating/finishing	210
Woods Equipment Co. (Oregon)	Manufacturing of attachments and replacement parts for agricultural, landscape and light construction markets	200
PNC, Inc. (Polo)	Manufacturer of custom electromagnet solenoid coils and wiring harnesses for the automotive and hydraulic industry	200
Silgan Containers (Rochelle)	Provider of metal food packaging products	200
Village of Progress (Oregon)	Social service organization	169
Austin-Westran (Byron)	Metal cabinets/metal fabrication	155
County of Ogle (Oregon)	County government	150
Bay Valley Foods (Rochelle)	Labeling, warehousing, distribution of shelf-stable foods	150
Del Monte, Inc. (Rochelle)	Warehousing and distribution of canned food products	150
Ryder Logistics (Rochelle)	Warehousing and distribution of refrigerated/frozen food products	135
City of Rochelle (Rochelle)	Municipal government	125
The Neighbors (Byron)	Nursing care facility	115
Rochelle Nursing Home (Rochelle)	Nursing care facility	115

Source: Ogle County 2012

1 **Table 3–19. Estimated Income Information for the Byron ROI (5-year estimates 2008–2012)**

	Lee	Ogle	Winnebago	Illinois
Median household income (dollars) ^(a)	50,342	55,590	47,573	56,853
Per capita income (dollars) ^(a)	25,484	26,331	24,404	29,519
Individuals living below the poverty level (percent)	10.0	10.0	17.0	13.7
Families living below the poverty level (percent)	7.4	7.4	12.8	10.0

^(a) In 2012 inflation adjusted dollars

Source: USCB 2014a

2 **3.10.2.2 Unemployment**

3 According to the USCB’s 2008–2012 American Community Survey 5-Year Estimates, the
 4 unemployment rates were: Lee County, 9.2 percent; Ogle County, 9.8 percent; and Winnebago
 5 County, 12 percent. Comparatively, the State of Illinois’s unemployment rate during this same
 6 time period was 9.9 percent (USCB 2014a).

7 **3.10.3 Demographic Characteristics**

8 According to the 2010 Census, an estimated 248,387 people lived within 20 mi (32 km) of
 9 Byron, which equates to a population density of 198 persons per mi² (Exelon 2013a). This
 10 translates to a Category 4, “least sparse” population density using the generic environmental
 11 impact statement (GEIS) measure of sparseness (greater than or equal to 120 persons per mi²
 12 within 20 mi). An estimated 1,247,087 people live within 50 mi (80 km) of Byron with a
 13 population density of 159 persons per mi² (Exelon 2013a). This translates to a Category 3
 14 density, using the GEIS measure of proximity (one or more cities with 100,000 or more persons
 15 and less than 190 persons per mi² within 50 mi (80 km)). The nearest city with a population
 16 greater than 100,000 is Rockford, Illinois (17 mi (27 km) northeast), with a 2010 population of
 17 152,871 (USCB 2014b). Therefore, Byron is located in a high population area based on the
 18 GEIS sparseness and proximity matrix.

19 Table 3–20 shows population projections and percent growth from 1970 to 2060 in the
 20 three-county Byron ROI. The population in the ROI has increased over the previous 2 decades
 21 (2000 and 2010). Based on State forecasts, the population is expected to continue to increase
 22 at a moderate to high rate due in part to the close proximity of the ROI to Chicago. Population
 23 projections for years 2020 and 2030 shown in the table were developed by the Illinois
 24 Department of Commerce and Economic Opportunity (DCEO) and are based on projected 2000
 25 population census estimates (see Table 3–21). As a result, the projected 2020 and 2030
 26 population estimates may be overstated, as actual population data from the 2000 and 2010
 27 decennial census were lower than the 2000 and 2010 population estimates projected by the
 28 DCEO.

1
2

Table 3–20. Population and Percent Growth in Byron ROI Counties 1970–2010, 2012 (estimated), and Projected for 2020–2060

Year	Lee County		Ogle County		Winnebago County	
	Population	Percent growth	Population	Percent growth	Population	Percent growth
1970	37,947	–	42,876	–	246,623	–
1980	36,328	–4.3	46,338	8.1	250,884	1.7
1990	34,392	–5.3	45,957	–0.8	252,913	0.8
2000	36,062	4.9	51,032	11.0	278,418	10.1
2010	36,031	–0.1	53,497	4.8	295,266	6.1
2012*	35,037	–2.8	52,848	–1.2	292,069	–1.1
2020	37,939	3.8	59,230	8.3	337,049	9.7
2030	38,923	2.6	63,765	7.7	359,900	6.8
2040	38,971	0.1	66,245	3.9	377,172	4.8
2050	39,645	1.7	69,943	5.6	400,439	6.2
2060	40,319	1.7	73,640	5.3	423,705	5.8

Sources: Decennial population data for 1970–2010, and estimated 2012 (USCB 2014b); projections for 2020–2030 by Illinois Department of Commerce and Economic Opportunity (DCEO 2012); 2040–2060 calculated

* Bold indicates most recent population estimate from the U.S. Census.

3
4

Table 3–21. Illinois Department of Commerce and Economic Opportunity (DCEO) Population Projections for 2000–2030

Year	Lee County		Ogle County		Winnebago County	
	Population	Percent growth	Population	Percent growth	Population	Percent growth
2000	36,118	–	51,119	–	278,902	–
2010	36,554	1.2	54,704	7.0	307,349	10.2
2020	37,939	3.8	59,230	8.3	337,049	9.7
2030	38,923	2.6	63,765	7.7	359,900	6.8

Source: DCEO 2012

5 The 2010 Census demographic profile of the three-county region of influence population is
6 presented in Table 3–22. According to the 2010 Census, minorities (race and ethnicity
7 combined) comprised 23.7 percent of the total three-county population. The largest minority
8 populations in the three-county ROI are Hispanic or Latino (10.1 percent) and Black or
9 African-American (9.8 percent).

1 **Table 3–22. Demographic Profile of the Population in the Byron ROI in 2010**

	Lee	Ogle	Winnebago	ROI
Total Population	36,031	53,497	295,266	384,794
Race (percent of total population, Not-Hispanic or Latino)				
White	88.3	88.6	72.5	76.3
Black or African-American	4.7	0.9	12.0	9.8
American Indian & Alaska Native	0.1	0.2	0.2	0.2
Asian	0.7	0.5	2.3	1.9
Native Hawaiian & Other Pacific Islander	0.0	0.0	0.0	0.0
Some other race	0.1	0.0	0.1	0.1
Two or more races	1.0	0.9	2.0	1.8
Ethnicity				
Hispanic or Latino	1,802	4,741	32,177	38,720
Percent of total population	5.0	8.9	10.9	10.1
Minority population (including Hispanic or Latino ethnicity)				
Total minority population	4,207	6,072	81,070	91,349
Percent minority	11.7	11.4	27.5	23.7

Source: USCB 2014c

2 **3.10.3.1 Transient Population**

3 Within 50 mi (80 km) of Byron, colleges and recreational opportunities attract daily and seasonal
 4 visitors who create a demand for temporary housing and services. In 2013, approximately
 5 27,700 students attended colleges and universities within 50 mi (80 km) of Byron (NCES 2013).

6 Based on the 2008–2012 American Community Survey (ACS) estimates, approximately
 7 18,800 seasonal housing units are located within 50 mi (80 km) of Byron. Of those, 1,168 were
 8 located in the Byron ROI. Table 3–23 presents information about seasonal housing for the
 9 counties located all or partly within 50 mi (80 km) of Byron.

1 **Table 3–23. 2007–2011 Estimated Seasonal Housing in Counties Located Within 50 mi**
 2 **(80 km) of Byron**

County ^(a)	Total Seasonal Housing Units	Vacant Housing Units: for Seasonal, Recreational, or Occasional Use	Percent
Illinois			
Boone	19,909	38	0.2
Bureau	15,712	219	1.4
Carroll	8,432	819	9.7
DeKalb	40,932	305	0.7
Henry	22,135	118	0.5
Jo Daviess	13,560	2,797	20.6
Kane	181,587	399	0.2
Kendall	40,002	82	0.2
La Salle	49,924	731	1.5
Lee	15,049	373	2.5
McHenry	116,015	1,136	1.0
Ogle	22,539	321	1.4
Stephenson	22,076	427	1.9
Whiteside	25,742	233	0.9
Winnebago	125,928	474	0.4
County Subtotal	719,542	8,472	1.2
Iowa			
Clinton	21,753	172	0.8
Jackson	9,400	465	4.9
County Subtotal	31,153	637	2.0
Wisconsin			
Green	15,857	316	2.0
Lafayette	7,218	140	1.9
Rock	68,369	1,105	1.6
Walworth	51,441	8,146	15.8
County Subtotal	142,885	9,707	6.8
Total	893,580	18,816	2.1

^(a) Counties within a 50 mi (80 km) radius of Byron

Source: USCB 2014d

Affected Environment

1 3.10.3.2 Migrant Farm Workers

2 Migrant farm workers are individuals whose employment requires travel to harvest agricultural
3 crops. These workers may or may not have a permanent residence. Some migrant workers
4 follow the harvesting of crops, particularly fruit, throughout rural areas of the United States.
5 Others may be permanent residents near Byron and travel from farm to farm harvesting crops.

6 Migrant workers may be members of minority or low-income populations. Because they travel
7 and can spend a significant amount of time in an area without being actual residents, migrant
8 workers may be unavailable for counting by census takers. If uncounted, these workers would
9 be “underrepresented” in USCB minority and low-income population counts.

10 Information about migrant farm and temporary labor was collected in the 2007 Census of
11 Agriculture. Table 3–24 supplies information about migrant farm workers and temporary farm
12 labor (less than 150 days) within 50 mi (80 km) of Byron. According to the 2007 Census of
13 Agriculture, approximately 14,100 farm workers were hired to work for less than 150 days and
14 were employed on 4,689 farms within 50 mi (80 km) of Byron. The county with the highest
15 number of temporary farm workers (1,127) on 219 farms was McHenry County, Illinois
16 (NASS 2012a).

17 In the 2002 Census of Agriculture, farm operators were asked for the first time whether or not
18 they hired migrant workers—defined as a farm worker whose employment required travel—to
19 do work that prevented the migrant workers from returning to their permanent place of residence
20 the same day. A total of 182 farms, in the 50-mi radius of Byron, reported hiring migrant
21 workers in the 2007 Census of Agriculture. DeKalb County, Illinois, reported the most farms
22 with migrant farm labor (16 farms) (NASS 2012a).

1
2**Table 3–24. Migrant Farm Workers and Temporary Farm Labor in Counties Located within 50 mi (80 km) of Byron**

County ^(a)	Number of Farms with Hired Farm Labor ^(b)	Number of Farms Hiring Workers for Less Than 150 Days ^(b)	Number of Farm Workers Working for Less Than 150 Days ^(b)	Number of Farms Reporting Migrant Farm Labor ^(b)
Illinois				
Boone	121	97	274	12
Bureau	321	278	786	4
Carroll	202	165	382	9
DeKalb	269	223	1,014	16
Henry	423	344	808	15
Jo Daviess	214	163	449	4
Kane	231	172	798	13
Kendall	111	94	371	11
La Salle	402	338	760	9
Lee^(c)	242	203	462	10
McHenry	284	219	1,127	15
Ogle^(c)	293	258	629	7
Stephenson	286	209	560	11
Whiteside	316	273	739	9
Winnebago^(c)	146	125	364	1
County Subtotal	3,861	3,161	9,523	146
Iowa				
Clinton	411	341	1,021	1
Jackson	234	190	489	2
County Subtotal	645	531	1,510	3
Wisconsin				
Green	403	284	662	6
Lafayette	377	267	718	13
Rock	348	266	933	8
Walworth	252	180	747	6
County Subtotal	1,380	997	3,060	33
Total	5,886	4,689	14,093	182

Affected Environment

County ^(a)	Number of Farms with Hired Farm Labor ^(b)	Number of Farms Hiring Workers for Less Than 150 Days ^(b)	Number of Farm Workers Working for Less Than 150 Days ^(b)	Number of Farms Reporting Migrant Farm Labor ^(b)
-----------------------	--	--	--	---

^(a) Counties within 50 mi (80 km) of Byron with at least one block group located within the 50-mi radius

^(b) Table 7. Hired farm Labor—Workers and Payroll: 2007

^(c) Counties in the socioeconomic ROI

Source: 2007 Census of Agriculture — County Data (NASS 2012a)

1 3.10.4 Housing and Community Services

2 This section presents information regarding housing and local public services, including
3 education and water supply.

4 3.10.4.1 Housing

5 Table 3–25 lists the total number of occupied and vacant housing units, vacancy rates, and
6 median value in the ROI. Based on the USCB's 2008–2012 ACS 5-Year Estimates, there were
7 nearly 164,000 housing units in the socioeconomic region, of which nearly 148,000 were
8 occupied. The median values of owner-occupied housing units in the ROI range from \$113,000
9 in Lee County to about \$151,000 in Ogle County. The vacancy rate also varied considerably
10 between the three counties, from 8 percent in Ogle County to 10.2 percent in Winnebago
11 County (USCB 2014e).

12 **Table 3–25. Housing in the Byron ROI (2008–2012, 5-year estimate)**

	Lee County	Ogle County	Winnebago County	ROI
Total housing units	15,049	22,539	125,928	163,516
Occupied housing units	13,686	20,728	113,119	147,533
Total vacant housing units	1,363	1,811	12,809	15,983
Percent total vacant	9.1	8.0	10.2	9.8
Owner occupied units	10,195	15,496	76,421	102,112
Median value (dollars)	113,000	151,400	127,500	129,679
Owner vacancy rate (percent)	1.3	1.8	1.2	1.3
Renter occupied units	3,491	5,232	36,698	45,421
Median rent (dollars/month)	622	669	721	707
Rental vacancy rate (percent)	5.4	7.1	5.2	5.4

Source: USCB 2014e

1 **3.10.4.2 Education**

2 There are six public school districts in Lee County with 15 schools and an average daily total
 3 enrollment of approximately 4,600 students during the 2010–2011 school year. Winnebago
 4 County has 11 public school districts with 95 schools and had approximately 38,600 students.
 5 In Ogle County, the county in which Byron is located, there are 10 public school districts with
 6 27 schools and over 9,600 students (ISBE 2014).

7 **3.10.4.3 Public Water Supply**

8 Table 2.9-1 of Exelon’s ER (Exelon 2013a) lists the largest public water suppliers in Ogle, Lee,
 9 and Winnebago Counties and provides water use and supply information for those suppliers.
 10 The discussion of public water supply systems is limited to major municipal water systems in the
 11 local area. Most of the water for domestic, municipal, and industrial use in the region comes
 12 from groundwater. Information about municipal water suppliers close to Byron, their maximum
 13 design yields, reported annual average usage, and population served are presented in
 14 Table 3–26. All major public water suppliers in Ogle, Lee, and Winnebago Counties obtain their
 15 supplies from groundwater. Currently, there is excess capacity in every major public water
 16 system in the three counties. Byron gets potable water from two onsite groundwater wells not
 17 connected to a public water system.

18 **Table 3–26. Local Public Water Supply Systems (in million gallons per day (mgd))**

Public Water System	County	Usage (mgd)	Pump Capacity (mgd)	Population Served ^(a)
Dixon	Lee	2.2	12.0	16,100
Woodhaven	Lee	0.4	2.1	4,100
Byron	Ogle	0.6	2.3	4,101
Oregon	Ogle	0.4	3.1	4,101
Rochelle	Ogle	2.7	7.2	9,850
Cherry Valley	Winnebago	0.6	6.2	5,000
Illinois American – South Beloit	Winnebago	0.7	NA	6,750
Loves Park	Winnebago	3.0	6.9	22,476
North Park Public Water District	Winnebago	3.5	18.1	35,737
Rockford	Winnebago	25.6	125.0	155,000
Rockton	Winnebago	0.8	6.2	7,440

NA = Not available

^(a) Safe Drinking Water Search for the State of Illinois (EPA 2014b)

Sources: EPA 2014b; Exelon 2013a

1 **3.10.5 Tax Revenues**

2 Property taxes paid by Exelon Generation for Byron are generally determined using the
 3 equalized assessed value (EAV) set by the county assessor, and the tax levy and rates set by
 4 each taxing district. Periodically, Exelon Generation enters into negotiations (which may result
 5 in a “settlement agreement”) with Ogle County and the other taxing districts to set the EAV for
 6 Byron. Negotiations can consider, but are not limited to, property valuation approaches, tax
 7 “triggers” (or limits), and payments in addition to taxes (PIAT). Exelon’s last settlement
 8 agreement for Byron was signed on November 8, 2008, and covered tax years 2005 through
 9 2011, which included negotiated triggers or tax limits. If tax levies exceeded these negotiated
 10 triggers, Exelon Generation could reduce Byron’s property tax obligation by the amounts in
 11 excess of the triggers. Exelon Generation also agreed to make additional payments (PIAT) to
 12 specific tax recipients. These payments are not considered tax payments in the traditional
 13 sense. They have fewer limitations for use and provide additional benefits for recipients. In
 14 accordance with the 2008 settlement agreement, Exelon Generation made two PIAT payments
 15 of \$2,302,000 each; one in 2008 and the other in 2010 (Exelon 2013b). Table 3–27 lists the
 16 PIAT payments and their recipients.

17 Exelon Generation and the taxing bodies have not entered into another settlement agreement,
 18 although negotiations have begun. Negotiations are in the early stages, and PIAT payments
 19 may be included as part of any future settlement agreement. Exelon Generation expects the
 20 recipients would remain the same as those listed in Table 3–27 because those are the taxing
 21 institutions that levy tax on the two power block Property Index Numbers (PINs). The settlement
 22 agreements have historically only settled the EAV for the two power block PINs (Exelon 2013b).

23 **Table 3–27. PIAT Payments and Recipients, 2008 and 2010**

Tax Recipients	Dollars	Percent of Total
Ogle County	270,863	11.8
Byron Fire Protection District	166,564	7.2
Byron Library District	56,659	2.5
Byron Museum District	6,256	0.3
Byron Forest Preserve District	127,339	5.5
Oregon Park District	147,137	6.4
Rockvale Township	12,888	0.6
Rockvale Township Road District	30,192	1.3
Rock Valley College	90,874	3.9
Byron Community Unit School District No. 226	1,346,079	58.5
Kishwaukee College	4,926	0.2
Oregon Community Unit School District No. 220	42,223	1.8
Total	2,302,000	100.0

Source: Exelon 2013a

1 The Ogle County Assessor set the EAV for the 2012 tax year at \$499 million, which is more
 2 than 4 percent higher than the EAV set under the existing settlement agreement. Exelon
 3 Generation believes the higher EAV overvalues Byron because an independent appraiser set
 4 the 2012 value of the station at \$1.85 billion, which equates to an EAV of approximately
 5 \$296.9 million. On this basis, Exelon Generation appealed the 2012 assessment to the Ogle
 6 County Board of Review. Upon an unfavorable ruling by the Board of Review, Exelon
 7 Generation then appealed the assessment to the Illinois Property Tax Appeal Board. The
 8 company will continue to negotiate with the taxing bodies to reach a settlement agreement, and
 9 in its absence, will appeal any assessment that does not reflect a valuation of the plant that they
 10 believe is fair (Exelon 2013b).

11 Pending the outcome of such actions, Exelon Generation has paid the tax assessed for 2012
 12 (an increase of more than \$2 million over the prior year, see Table 3–28). This increase was
 13 based on the EAV set by the assessor for the two combined power block PINs. Exelon
 14 Generation actually pays property taxes on 48 land parcels or PINs at Byron. The total taxes
 15 paid by Exelon Generation include taxes for all of the PINs (Exelon 2013b).

16 As previously discussed, the Ogle County Treasurer collects the property tax payment and
 17 disperses it to various institutions within the county to partially fund their operating budgets.
 18 These include, but are not limited to, the Byron Forest Preserve, the Oregon Park District, the
 19 Rock Valley Community College 511, the Byron Unit 226 School District, the Byron Fire District,
 20 the Byron Library District, Ogle County, and Rockvale Township (Exelon 2013a). From 2008
 21 through 2012, Ogle County’s total adjusted property tax levies ranged from approximately
 22 \$111.3 to \$116.6 million annually (see Table 3–28). From 2008 through 2012, Byron’s total
 23 property tax payments (after tax triggers and not including PIAT payments) represented 26.0 to
 24 28.3 percent of Ogle County’s total adjusted property tax levy (see Table 3–28).

25 **Table 3–28. Property Tax Payment Comparison, All Taxing Districts Combined**

Year	Total Combined Taxing District Levy—Ogle County (after adjustments) (millions of dollars)	Byron Property Tax Payment (after tax triggers have been applied and not including PIAT payments) (millions of dollars)	Byron Payment as Percent of Total District Levy (percent)
2008	111.3	29.1	26.1
2009	113.8	29.6	26.0
2010	114.5	30.2	26.4
2011	113.9	30.8	27.0
2012	^(a) 116.6	^(a) 33.0	^(a) 28.3

^(a) Preliminary data

Sources: Exelon 2013a, 2013b

26 The recipient of the largest percentage of Byron’s property tax payment is the Byron Unit 226
 27 School District (Exelon 2013a). Table 3–29 compares Byron’s property tax payments (after tax
 28 triggers and not including PIAT payments) to the Byron Unit 226 School District’s adjusted total
 29 property tax levies. From 2008 through 2012, Byron’s property tax payments to the school
 30 district represented 72.9 to 75.6 percent of the school district’s total adjusted property tax levies
 31 (see Table 3–29).

1 **Table 3–29. Property Tax Payment Comparison, All Taxing Districts Combined**

Year	Total Byron Unit 226 School District Levy (after adjustments) (millions of dollars)	Byron Unit 226 School District Portion of Byron Property Tax Payment (after tax triggers have been applied and not including PIAT payments) (millions of dollars)	Byron Payment as Percent of Total District Levy (percent)
2008	22.4	16.3	72.9
2009	22.7	16.7	73.3
2010	23.1	17.0	73.5
2011	23.2	17.2	74.3
2012	^(a) 24.5	^(a) 18.5	^(a) 75.6

^(a) Preliminary data

Sources: Exelon 2013a, 2013b

2 Exelon Generation pays property taxes directly to Ogle County in accordance with tax bills
 3 received from Ogle County each year. Each bill shows all of the taxing bodies that are imposing
 4 a tax on each tax parcel. As the Byron property is large, some of its tax parcels fall within
 5 multiple taxing districts. Exelon Generation, however, has no control over how the tax money is
 6 allocated to the respective taxing districts. Each district has the ability to levy against all
 7 taxpayers within its respective district according to its own charter and according to State law.
 8 The Ogle County Treasurer then allocates the tax money according to predetermined levies
 9 once all taxes have been collected (Exelon 2013b).

10 The following tables show the total levy for each taxing body and the amount paid by Exelon
 11 Generation to each taxing body. The tables also show the percentage of total revenue
 12 represented by Exelon Generation’s tax payment for the tax years 2011 and 2012 (see
 13 Tables 3–30 and 3–31, respectively). The 2012 data are preliminary when submitted by the
 14 applicant, and the total levies for any one of the taxing bodies within Ogle County may change
 15 when the tax year closes (Exelon 2013b).

16 Although variations in tax levies are not completely under its control, Exelon Generation expects
 17 that Byron’s annual property tax payments will remain relatively constant through the license
 18 renewal period. In 1998, Byron replaced the Unit 1 steam generators. Because the
 19 replacement was considered one-for-one, the Station’s assessed value was unaffected. Exelon
 20 expects that any future one-for-one replacement projects will also not affect the station’s
 21 assessed value (Exelon 2013a).

1 **Table 3–30. 2011 Property Tax Payment Comparison, Each Taxing District Individually**

Taxing Body	Total Taxing District Levy (dollars)	Taxing District Portion of Byron Property Tax Payment (dollars)	Byron Payment as Percent of Taxing District Levy (percent)
Rockvale Township Road District	439,398.38	412,078.70	94
Rockvale Township	162,893.90	147,867.78	91
Oregon Park District	2,426,968.19	1,945,577.49	80
Byron Library District	985,733.24	790,179.58	80
Byron Fire District	2,847,882.53	2,137,067.08	75
Byron Forest Preserve	2,235,104.08	1,664,691.42	75
Byron School Unit 226	23,175,260.74	17,219,124.59	74
Byron Museum District	107,847.70	80,314.40	74
Rock Valley Community College 511	3,996,316.29	2,131,800.53	53
Ogle County	10,895,856.26	3,500,490.42	32
Oregon School Unit 220	9,954,055.80	608,129.98	6
Kishwaukee College 523	2,178,105.74	70,351.06	3
Marion Township Road	280,324.97	7,001.20	2
Marion Township	202,895.79	4,815.41	2
Stillman Valley Fire District	564,747.94	6,558.42	1
Byron Park District	535,352.10	5,599.27	1
Meridian Unit 223	7,668,245.10	28,676.18	<1
Julia Hull District Library	216,840.52	746.90	<1
Oregon Fire District	393,225.48	511.33	<1
City of Byron	680,358.62	789.59	<1
Byron Township Road	531,168.42	359.68	<1
Byron Township	197,888.03	121.79	<1

Source: Exelon 2013a

1 **Table 3–31. 2012 Property Tax Payment Comparison, Each Taxing District Individually**

Taxing Body	Total Taxing District Levy (dollars)	Taxing District Portion of Byron Property Tax Payment (dollars)	Byron Payment as Percent of Taxing District Levy (percent)
Rockvale Township Road District	473,936.19	433,301.95	91
Rockvale Township	170,402.82	155,781.07	91
Oregon Park District	2,592,707.40	2,053,432.47	79
Byron Library District	1,100,021.40	832,826.26	76
Byron Fire District	2,849,570.86	2,173,799.08	76
Byron Forest Preserve	2,723,877.90	2,063,496.61	76
Byron School Unit 226	24,531,412.11	18,540,024.03	76
Byron Museum District	107,904.13	81,743.99	76
Rock Valley Community College 511	3,983,228.58	2,186,116.75	55
Ogle County	11,050,901.32	3,696,958.55	33
Oregon School Unit 220	9,727,868.75	636,845.75	7
Kishwaukee College 523	2,408,561.88	81,556.77	3
Marion Township Road	275,794.50	6,764.70	2
Marion Township	203,166.03	4,835.00	2
Stillman Valley Fire District	546,071.62	6,333.17	1
Byron Park District	537,766.04	5,622.09	1
Meridian Unit 223	7,638,510.57	28,042.48	<1
Julia Hull District Library	227,365.20	721.32	<1
Oregon Fire District	407,275.39	556.99	<1
City of Byron	664,602.29	814.93	<1
Byron Township Road	548,577.95	366.86	<1
Byron Township	205,197.50	141.50	<1

Source: Exelon 2013a

2 **3.10.6 Local Transportation**

3 Major freeways serving Ogle County include interstates I-39 and I-88. Other major roadways
4 serving the county are north/south state routes 2, 26, and 251, U.S. Highway 52, and east/west
5 state routes 38, 64, and 72. Road access to Byron is via German Church Road (also known as
6 County Highway 2), which runs northeast-southwest. Byron has two access roads, a northern
7 entrance and a southern entrance, both of which intersect German Church Road approximately
8 3 to 4 mi (5 to 6 km) southwest of the City of Byron. The northern access road provides primary
9 access to the site for employees. In the City of Byron, German Church Road intersects County
10 Highway 33 and State route Illinois (IL) 72, at a single intersection. State route IL 72 travels

1 east and north at that intersection. County Highway 33 travels west. German Church Road
 2 intersects State route IL 64 at a location 5 to 6 mi (8 to 9.5 km) south of the Byron entrance.
 3 Employees traveling from the north use a combination of State routes IL 2, IL 72, County
 4 Highway 33, and North German Church Road to reach the station. Employees traveling from
 5 the south use a combination of State routes IL 2, IL 64, and South German Church Road to
 6 reach the station.

7 Exelon Generation employees report that there has been no traffic congestion in the area during
 8 normal operations (Exelon 2013a). During major refueling or maintenance outages, both
 9 entrances are opened to alleviate potential traffic congestion. During the first weeks of an
 10 outage, some traffic backups occur at the northern entrance because the back shifts have not
 11 yet started and most outage workers are on the first shift. Once the back shifts start, traffic
 12 congestion usually abates. Byron maintenance crews add signage to warn drivers of temporary
 13 traffic congestion in the area. Byron employees do not recall any congestion issues during the
 14 1998 steam generator replacement project (Exelon 2013a).

15 Table 3-32 lists commuting routes to the Byron site and average annual daily traffic (AADT)
 16 volume values. The AADT values represent traffic volumes for a 24-hour period factored by
 17 both the day of the week and the month of the year.

18 **Table 3–32. Major Commuting Routes in the Vicinity of Byron: 2012 AADT**

Roadway and Location	Average Annual Daily Traffic (AADT) ^(a)
The section of North German Church Road between the station entrance and IL 72	1,300 – 2,250
On County Highway 33, near its intersection with North German Church Road	2,800
On IL 72, just east of its intersection with North German Church Road	12,300
The section of South German Church Road between the station entrance and IL 64	750 – 1,350
On IL 64, just east of the intersection with South German Church Road	^(b) 4,200
On IL 64, just west of the intersection with South German Church Road	^(b) 4,900

^(a) Unless otherwise indicated, all AADTs represent traffic volume during the average 24-hour day during 2012.

^(b) AADTs in 2011

Source: IDOT 2014

19 **3.11 Human Health**

20 **3.11.1 Radiological Exposure and Risk**

21 As required by NRC regulation, 10 CFR 20.1101, Exelon has a radiation protection program
 22 designed to protect onsite personnel, including employees, contractor employees, visitors, and
 23 offsite members of the public from radiation and radioactive material generated at Byron.

Affected Environment

1 The radiation protection program is extensive and includes, but is not limited to the following:

- 2 • Organization and Administration (i.e., a Radiation Protection Manager who is
3 responsible for the program and having trained and qualified workers),
- 4 • Implementing procedures,
- 5 • ALARA Program to minimize dose to workers and members of the public,
- 6 • Dosimetry Program (i.e., measure radiation dose of plant workers),
- 7 • Radiological Controls (i.e., protective clothing, shielding, filters, respiratory
8 equipment, and individual work permits with specific radiological
9 requirements),
- 10 • Radiation Area Entry and Exit Controls (i.e., locked or barricaded doors,
11 interlocks, local and remote alarms, personnel contamination monitoring
12 stations),
- 13 • Posting of Radiation Hazards (i.e., signs and notices alerting plant personnel
14 of potential hazards),
- 15 • Record Keeping and Reporting (i.e., documentation of worker dose and
16 radiation survey data),
- 17 • Radiation Safety Training (i.e., classroom training and use of mockups to
18 simulate complex work assignments),
- 19 • Radioactive Effluent Monitoring Management (i.e., control and monitor
20 radioactive liquid and gaseous effluents released into the environment),
- 21 • Radioactive Environmental Monitoring (i.e., sampling and analysis of
22 environmental media, such as air, water, vegetation, food crops, direct
23 radiation, and milk to measure the levels of radioactive material in the
24 environmental that may impact human health), and
- 25 • Radiological Waste Management (i.e., control, monitor, process, and dispose
26 of radioactive solid waste).

27 Regarding the radiation exposure to Byron personnel, the NRC staff reviewed the data
28 contained in NUREG–0713, *Occupational Radiation Exposure at Commercial Nuclear Power
29 Reactors and Other Facilities 2011: Forty-Fourth Annual Report (NUREG–0713, Volume 33)*
30 (Lewis et al. 2013). This report, which was the most recent available at the time of this review,
31 summarizes the occupational exposure data through 2011 that are maintained in the NRC’s
32 Radiation Exposure Information and Reporting System database. Nuclear power plants are
33 required by 10 CFR 20.2206 to report their occupational exposure data to the NRC annually.

34 NUREG–0713 calculates a 3-year average collective dose per reactor for all nuclear power
35 reactors licensed by the NRC. The 3-year average collective dose is one of the metrics that the
36 NRC uses in the Reactor Oversight Program to evaluate the applicant’s ALARA program.
37 Collective dose is the sum of the individual doses received by workers at a facility licensed to
38 use radioactive material over a 1-year time period. There are no NRC or EPA standards for
39 collective dose. Based on the data for operating PWRs like those at Byron, the average annual
40 collective dose per reactor was 59.71 person-rem. In comparison, Byron had a reported annual
41 collective dose per reactor of 63.99 person-rem.

42 In addition, as reported in NUREG–0713, for 2011, no worker at Byron received an annual dose
43 greater than 2.0 rem (0.02 sievert (Sv)), which is well below the NRC occupational dose limit of
44 5.0 rem (0.05 Sv) in 10 CFR 20.1201.

1 3.11.2 Chemical Hazards

2 The use, storage, and discharge of chemicals, biocides, and sanitary wastes, as well as minor
 3 chemical spills are regulated by State and Federal environmental agencies. Chemical hazards
 4 to plant workers resulting from continued operations and refurbishment associated with license
 5 renewal are expected to be minimized by the applicant's implementing good industrial hygiene
 6 practices as required by permits and Federal and State regulations. Plant discharges of these
 7 chemical and sanitary wastes are monitored and controlled as part of the plant's NPDES permit
 8 process to minimize impacts to the public and the environment. In addition, proposed changes
 9 in the use of cooling water treatment chemicals would require review by the plant's NPDES
 10 permit-issuing authority and possible modification of the existing NPDES permit, including
 11 examination of the human health effects of the change.

12 The use, storage, and discharge of chemicals and sanitary wastes at Byron are controlled in
 13 accordance with Exelon's fleet chemical control procedures and site-specific chemical spill
 14 prevention plans. Exelon's Spill Prevention, Control and Countermeasure plan serves as the
 15 site's hazardous waste contingency plan. Chemical wastes are controlled and managed in
 16 accordance with Exelon's waste management procedure. These plant procedures and plans
 17 are designed to prevent and minimize the potential for a chemical or hazardous waste release
 18 that could impact workers, members of the public, and the environment (Exelon 2003).

19 3.11.3 Microbiological Hazards

20 Radioactive Waste Nuclear plants that have cooling towers and that discharge thermal effluents
 21 to cooling ponds, lakes, canals, or rivers, such as Byron, have the potential to promote the
 22 increased growth of thermophilic microorganisms, which could result in adverse health effects
 23 for plant workers and the public. Microorganisms of particular concern include several types of
 24 bacteria (*Legionella* spp., *Salmonella* spp., *Shigella* spp., and *Pseudomonas aeruginosa*) and
 25 the free-living amoeba *Naegleria fowleri*.

26 Nuclear plant workers can be exposed to *Legionella* spp. when performing maintenance
 27 activities on plant cooling systems if workers inhale cooling tower vapors, because vapors are
 28 often within the optimum temperature range for *Legionella* growth. Plant personnel most likely
 29 to come in contact with *Legionella* aerosols would be workers who clean biofilms off of
 30 condenser tubes, cooling towers, and related system components or equipment. Exposure of
 31 the public to *Legionella* from nuclear plant operations is generally not a concern, because
 32 *Legionella* exposure would be confined to a small area of the site within the protected area.

33 The public can be exposed to the thermophilic microorganisms *Salmonella*, *Shigella*,
 34 *P. aeruginosa*, and *N. fowleri* during swimming, boating, or other recreational uses of fresh
 35 water. If a nuclear plant's thermal effluent enhances the growth of thermophilic microorganisms,
 36 recreational users could experience an elevated risk of exposure when using waters near the
 37 plant's discharge.

38 *Thermophilic Microorganisms of Concern*

39 *Legionella* is a genus of common warm water bacteria that occurs in lakes, ponds, and other
 40 surface waters, as well as some groundwater sources and soils. The bacteria are pathogenic to
 41 humans when aerosolized and inhaled into the lungs. Approximately 2 to 5 percent of those
 42 exposed in this way to *Legionella* develop an acute bacterial infection of the lower respiratory
 43 tract known as Legionnaires' disease (Pearson 2003). Optimal growth occurs in stagnant
 44 surface waters with biofilms or slimes that range in temperature from 35 to 45 °C (95 to 113 °F),
 45 though the bacteria can persist in waters from 20 to 50 °C (68 to 122 °F) (Pearson 2003).
 46 Elderly and immunocompromised individuals are most susceptible to Legionnaires' disease

Affected Environment

1 (Pearson 2003). According to data from the Centers for Disease Control and Prevention
2 (CDC 2011a) from 2000 through 2009, New England and Middle Atlantic states generally have
3 the highest number of reported legionellosis cases each year.

4 Approximately 2,000 serotypes of *Salmonella* spp. cause the bacterial infection salmonellosis in
5 humans. Of these, the serotypes Typhimurium and Enteritidis are the most common in the
6 United States (CDC 2010a). Salmonellosis is most common in summer months, and it is
7 transmitted through contact with food, water, or animals contaminated with human or animal
8 feces (CDC 2010a). The bacteria have an optimal growth temperature of 98.6 °F (37 °C) but
9 can grow at temperatures ranging from 43 to 115 °F (6 to 46 °C) (Albrecht 2013a). Studies
10 examining the persistence of *Salmonella* spp. outside of a host have found that *Salmonella* can
11 survive for several months in water and in aquatic sediments (Moore et al. 2003).

12 *Shigella* is a genus of bacteria species that causes shigellosis (i.e., bacterial dysentery), which
13 is spread through consuming fecal-contaminated food or water or by swimming in contaminated
14 water. Its optimum growth temperature is 37 °C (98.6 °F), though it can grow in water
15 temperatures ranging from 10 to 40 °C (50 to 104 °F) (Albrecht 2013b). Shigellosis is most
16 common in summer months and among toddlers age 2 to 4 in childcare settings (CDC 2013e).

17 *Pseudomonas aeruginosa* is a free-living bacterium found in soil, water, and plant surfaces. It is
18 most commonly linked to infections transmitted in healthcare settings. However, as a
19 waterborne pathogen, it can cause ear infections (i.e., “swimmer’s ear”), eye infections, and skin
20 rashes after exposure to contaminated hot tubs, swimming pools, or other recreational waters
21 (CDC 2013a). Its optimum growth temperature is 37 °C (98.6 °F), though it can grow at
22 temperatures as high as 42 °C (107.6 °F) (Todar 2004). *P. aeruginosa* almost exclusively infects
23 immunocompromised individuals or already injured or inflamed sites on the skin (Todar 2004).

24 *Naegleria fowleri* is a free-living amoeba that occurs in warm lakes, rivers, or hot springs. It is
25 the causative agent of human primary amoebic meningoencephalitis (PAM). Infection occurs
26 when contaminated freshwater enters the nose, and the amoeba migrates to brain tissue; the
27 ensuing illness is usually fatal (CDC 2013b). *N. fowleri* grows best at higher temperatures up to
28 46 °C (115 °F) (CDC 2013b), though it has also been isolated from thermally altered waters
29 surrounding power plant discharges at temperatures ranging from 35 to 41 °C (95 to 105.8 °F)
30 (Stevens et al. 1977).

31 *Prevalence of Waterborne Diseases Associated with Recreational Waters*

32 From 2002 through 2011, the CDC (2003, 2004a, 2005, 2006a, 2007, 2008a, 2009, 2010b,
33 2011b, 2012) reported an average of 2,774 cases of Legionnaires’ disease per year, of which
34 between 28 and 151 per year were reported from Illinois. Although *Legionella* is often present
35 in the cooling tower vapors of power plants, cases of Legionnaires’ disease from this type of
36 exposure are rare due to workers’ use of appropriate respiratory protection.

37 The Illinois Department of Public Health (IDPH) indicates that approximately 1,500 to
38 2,000 cases of salmonellosis are reported in the State each year (IDPH 2009). However, the
39 overwhelming majority of salmonellosis cases are foodborne (CDC 2010a). The CDC reports
40 biannually on waterborne disease outbreaks associated with recreational waters. A review of
41 the past 10 available data years (1999 through 2008) of these reports indicates that no
42 outbreaks or cases of waterborne *Salmonella* infection from recreational waters occurred in the
43 United States during this timeframe (CDC 2002, 2004b, 2006b, 2008b, 2011c). From 2006 to
44 2013, all CDC-reported salmonellosis outbreaks have been caused by contaminated produce,
45 meats, or prepared foods or through contact with contaminated animals (CDC 2013d).

46 Approximately 1,300 confirmed cases of shigellosis are reported in Illinois each year
47 (IDPH 2013). CDC reports (2002, 2004b, 2006b, 2008b, 2011c) indicate that less than a

1 dozen shigellosis outbreaks have been attributed to lakes, reservoirs, and other recreational
2 waters in the past 10 available data years (1999 through 2008). None of these cases were in
3 Illinois.

4 Infections attributed to *Pseudomonas aeruginosa* are most commonly contracted in pools, spas,
5 and hot tubs. No cases of infection linked to contaminated recreational waters in the
6 United States have been reported within the past 10 available data years (1999 through 2008)
7 (CDC 2002, 2004b, 2006b, 2008b, 2011c).

8 The *N. fowleri*-caused disease, PAM, is rare in the United States. Since 1962, between zero
9 and eight cases of PAM have been reported to the CDC annually, and no cases have been
10 reported in Illinois (CDC 2013c)

11 **3.11.4 Electromagnetic Fields**

12 Based on the GEIS, the Commission found that electric shock resulting from direct access to
13 energized conductors or from induced charges in metallic structures has not been found to be a
14 problem at most operating plants and generally is not expected to be a problem during the
15 license renewal term. However, a site-specific review is required to determine the significance
16 of the electric shock potential along the portions of the transmission lines that are within the
17 scope of this SEIS.

18 In the GEIS, the NRC found that without a review of the conformance of each nuclear plant
19 transmission line with National Electrical Safety Code® (NESC®) criteria, it was not possible to
20 determine the significance of the electric shock potential (IEEE 2002). Evaluation of individual
21 plant transmission lines is necessary because the issue of electric shock safety was not
22 addressed in the licensing process for some plants. For other plants, land use in the vicinity of
23 transmission lines may have changed, or power distribution companies may have chosen to
24 upgrade line voltage. To comply with 10 CFR 51.53(c)(3)(ii)(H), the applicant must provide an
25 assessment of the impact of the proposed action on the potential shock hazard from the
26 transmission lines if the transmission lines that were constructed for the specific purpose of
27 connecting the plant to the transmission system do not meet the recommendations of the NESC
28 for preventing electric shock from induced currents. The NRC uses the NESC criteria and the
29 applicant's adherence to those criteria during the current operating license as its baseline to
30 assess the potential human health impact of the induced current from an applicant's
31 transmission lines. As discussed in the GEIS, the issue of electric shock is of small significance
32 for transmission lines that are operated in adherence with the NESC criteria.

33 Byron's associated transmission lines were designed and constructed in accordance with the
34 Illinois Commerce Commission General Order 160 and the sixth edition of the NESC. ComEd is
35 the owner and operator of the transmission lines and has surveillance and maintenance
36 procedures to assure that current ground clearances will not change. ComEd performs routine
37 inspections and aerial patrols to check for encroachments, broken conductors, or any other
38 evidence of clearance issues.

39 Exelon used the Power Line Systems Software program (PLS-CADD™) to analyze the
40 three-dimensional models created from the LIDAR (Light Detection and Ranging) data and
41 calculate the potential for induced shock effects. All electromagnetic field calculations in
42 PLS-CADD are based on the Electric Power Research Institute methodology. Of the
43 three 345-kV transmission lines studied, Exelon reported that none exceed the 5-milliampere
44 NESC standard (Exelon 2013a).

Affected Environment

1 3.11.5 Other Hazards

2 Two additional human health issues are addressed in this section: physical occupational
3 hazards and electric shock hazards.

4 Nuclear power plants are industrial facilities that have many of the typical occupational hazards
5 found at any other electric power generation utility. Workers at or around nuclear power plants
6 would be involved in some electrical work, electric power line maintenance, repair work, and
7 maintenance activities and exposed to some potentially hazardous physical conditions
8 (e.g., falls, excessive heat, cold, noise, electric shock, and pressure). The issue of physical
9 occupational hazards is generic to all nuclear power plants.

10 The Occupational Safety & Health Administration (OSHA) is responsible for developing and
11 enforcing workplace safety regulations. OSHA was created by the Occupational Safety and
12 Health Act of 1970 (OSH Act) (29 U.S.C. 651 et seq.), which was enacted to safeguard the
13 health of workers. With specific regard to nuclear power plants, plant conditions that result in an
14 occupational risk, but do not affect the safety of licensed radioactive materials, are under the
15 statutory authority of OSHA rather than the NRC as set forth in a Memorandum of
16 Understanding (53 FR 42950, October 31, 1988) between the NRC and OSHA. Occupational
17 hazards can be minimized when workers adhere to safety standards and use appropriate
18 protective equipment; however, fatalities and injuries from accidents can still occur.

19 Byron maintains an occupational safety program in accordance with OSHA regulations for its
20 workers (Exelon 2013a).

21 3.12 Environmental Justice

22 Environmental Justice Under Executive Order (EO) 12898 (59 FR 7629), Federal agencies are
23 responsible for identifying and addressing, as appropriate, disproportionately high and adverse
24 human health and environmental impacts on minority and low-income populations. In 2004, the
25 Commission issued a *Policy Statement on the Treatment of Environmental Justice Matters in*
26 *NRC Regulatory and Licensing Actions* (69 FR 52040), which states, "The Commission is
27 committed to the general goals set forth in EO 12898, and strives to meet those goals as part of
28 its National Environmental Policy Act (NEPA) review process."

29 The Council on Environmental Quality (CEQ) provides the following information in
30 *Environmental Justice: Guidance Under the National Environmental Policy Act* (CEQ 1997):

31 **Disproportionately High and Adverse Human Health Effects.**

32 Adverse health effects are measured in risks and rates that could result in latent
33 cancer fatalities, as well as other fatal or nonfatal adverse impacts on human
34 health. Adverse health effects may include bodily impairment, infirmity, illness, or
35 death. Disproportionately high and adverse human health effects occur when the
36 risk or rate of exposure to an environmental hazard for a minority or low-income
37 population is significant (as employed by NEPA) and appreciably exceeds the
38 risk or exposure rate for the general population or for another appropriate
39 comparison group.

40 **Disproportionately High and Adverse Environmental Effects.**

41 A disproportionately high environmental impact that is significant (as employed
42 by NEPA) refers to an impact or risk of an impact on the natural or physical
43 environment in a low-income or minority community that appreciably exceeds the
44 environmental impact on the larger community. Such effects may include
45 ecological, cultural, human health, economic, or social impacts. An adverse
46 environmental impact is an impact that is determined to be both harmful and

1 significant (as employed by NEPA). In assessing cultural and aesthetic
 2 environmental impacts, impacts that uniquely affect geographically dislocated or
 3 dispersed minority or low-income populations or American Indian tribes are
 4 considered.

5 The environmental justice analysis assesses the potential for disproportionately high and
 6 adverse human health or environmental effects on minority and low-income populations that
 7 could result from the operation of Byron during the renewal term. In assessing the impacts, the
 8 following definitions of minority individuals and populations and low-income population were
 9 used (CEQ 1997):

10 **Minority individuals**

11 Individuals who identify themselves as members of the following population
 12 groups: Hispanic or Latino, American Indian or Alaska Native, Asian, Black or
 13 African American, Native Hawaiian or Other Pacific Islander, or two or more
 14 races, meaning individuals who identified themselves on a Census form as being
 15 a member of two or more races, for example, White and Asian.

16 **Minority populations**

17 Minority populations are identified when (1) the minority population of an affected
 18 area exceeds 50 percent or (2) the minority population percentage of the affected
 19 area is meaningfully greater than the minority population percentage in the
 20 general population or other appropriate unit of geographic analysis.

21 **Low-income population**

22 Low-income populations in an affected area are identified with the annual
 23 statistical poverty thresholds from the Census Bureau's Current Population
 24 Reports, Series P60, on Income and Poverty.

25 **3.12.1 Minority Population**

26 According to 2010 Census data, approximately 20 percent of the population residing within a
 27 50-mi (80-km) radius of Byron identified themselves as minority individuals. The largest minority
 28 group was Hispanic or Latino (of any race) (11 percent), followed by Black or African-American
 29 (5 percent) (USCB 2014a).


30 According to 2010 Census data, minority populations in the socioeconomic ROI (Lee, Ogle, and
 31 Winnebago counties) composed 23.7 percent of the total two-county population (see
 32 Table 3–19). Figure 3–13 shows predominantly minority population block groups, using 2010
 33 Census data for race and ethnicity, within a 50-mi (80-km) radius of Byron.

34 Census block groups were considered minority population block groups if the percentage of the
 35 minority population within any block group exceeded 20 percent (the percent of the minority
 36 population within the 50-mi (80-km) radius of Byron). A minority population exists if the
 37 percentage of the minority population within the block group is meaningfully greater than the
 38 minority population percentage in the 50-mi (80-km) radius. Approximately 356 of the
 39 979 census block groups located within the 50-mi (80-km) radius of Byron have meaningfully
 40 greater minority populations (USCB 2014f).

41 As shown in Figure 3–13, the nearest minority population block groups (race and ethnicity) are
 42 mostly clustered near Rockford, Rochelle, and Freeport, Illinois. None of the block groups near
 43 Byron have meaningfully greater minority populations.

1

Figure 3–13. Minority Block Groups Within a 50-mi Radius of Byron



2

3

Cities	Aggregate Minority Population	 N W E S
Byron Nuclear Generating Station	County Boundaries	
50 Mile Buffer	State Boundaries	0 3 6 12 18 24 Miles

Source: USCB 2014f

1 **3.12.2 Low-Income Population**


2 According to the USCB's 2008–2012 American Community Survey 5 Year Estimates, an
3 average of 7.7 percent of families and 11.8 percent of individuals residing within a 50-mi
4 (80-km) radius of Byron were identified as living below the Federal poverty threshold
5 (USCB 2014a). The 2012 Federal poverty threshold was \$23,942 for a family of four.

6 According to the USCB's 2008–2012 American Community Survey 5 Year Estimates,
7 10 percent of families and 13.7 percent of individuals in Illinois were living below the Federal
8 poverty threshold in 2012, and the median household income for Illinois was \$56,853
9 (USCB 2014a). People living in the socioeconomic ROI (Lee, Ogle, and Winnebago Counties)
10 had median household incomes below the State average. Winnebago County had the lowest
11 median household income average (\$47,573) of the three counties and the highest percentages
12 of persons (17 percent of individuals and 12.8 percent of families) living below the poverty level.
13 Lee and Ogle Counties had median household income averages of \$50,342 and \$55,590,
14 respectively, and each had 10 percent of individuals and 7.4 percent of families, respectively,
15 living below the poverty level (USCB 2014a).

16 Figure 3–14 shows the location of predominantly low-income population block groups within a
17 50-mi (80-km) radius of Byron. Census block groups were considered low-income population
18 block groups if the percentage of individuals living below the Federal poverty threshold within
19 any block group exceeded 11.8 percent (the percent of the individuals living below the Federal
20 poverty threshold within the 50-mi (80-km) radius of Byron). Approximately 337 of the
21 979 census block groups located within the 50-mi (80-km) radius of Byron have meaningfully
22 greater low-income populations (USCB 2014f).

23 As shown in Figure 3–14, the nearest low-income population block groups are mostly clustered
24 near Rockford, Rochelle, and Freeport, Illinois. None of the block groups encompassing Byron
25 have meaningfully greater low-income populations.

1 **Figure 3-14. Low-Income Block Groups Within a 50-mi (80-km) Radius of Byron**



2

3

- Cities
- ★ Byron Nuclear Generating Station
- ◻ 50 Mile Buffer
- Low Income Population
- ◻ County Boundaries
- ◻ State Boundaries

N
W —+— E
S

0 3 6 12 18 24 Miles

Source: USCB 2014f

1 **3.13 Waste Management and Pollution Prevention**

2 **3.13.1 Radioactive Waste**

3 As discussed in Section 3.1.4 of this SEIS, Byron uses liquid, gaseous, and solid waste
4 processing systems to collect and treat, as needed, radioactive materials produced as a
5 byproduct of plant operations. Radioactive materials in liquid and gaseous effluents are
6 reduced prior to being released into the environment so that the resultant dose to members of
7 the public from these effluents is well within NRC and EPA dose standards. Radionuclides that
8 can be efficiently removed from the liquid and gaseous effluents prior to release are converted
9 to a solid waste form for disposal in a licensed disposal facility.

10 **3.13.2 Nonradioactive Waste**

11 Waste minimization and pollution prevention are important elements of operations at all nuclear
12 power plants. The applicants are required to consider pollution prevention measures as
13 dictated by the Pollution Prevention Act of 1990 (PPA) (Public Law (PL) 101-508) and Resource
14 Conservation and Recovery Act (RCRA) (PL 94-580).

15 As described in Section 3.1.5, Byron has a nonradioactive waste management program to
16 handle this nonradioactive waste. In addition to managing its nonradioactive waste, Exelon has
17 programs in place to minimize the generation of this waste. Byron implements a hazardous
18 waste minimization plan to reduce, to the extent feasible, waste generated, treated,
19 accumulated, or disposed (Exelon 2003). This plan documents waste streams that have been
20 eliminated and lists current waste streams generated at the facility (Exelon 2003). The plan is
21 updated annually and used in conjunction with plant waste management procedures on solid,
22 special, hazardous, mixed waste, and chemicals to control and minimize waste generation to
23 the maximum extent practicable.

24 **3.14 References**

25 10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, "Standards for
26 protection against radiation."

27 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic licensing of
28 production and utilization facilities."

29 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental
30 protection regulations for domestic licensing and related regulatory functions."

31 10 CFR Part 61. *Code of Federal Regulations*, Title 10, *Energy*, Part 61, "Licensing
32 requirements for land disposal of radioactive waste."

33 10 CFR Part 71. *Code of Federal Regulations*, Title 10, *Energy*, Part 71, "Packaging and
34 transportation of radioactive material."

35 10 CFR Part 72. *Code of Federal Regulations*, Title 10, *Energy*, Part 72, "Licensing
36 requirements for the independent storage of spent nuclear fuel, high-level radioactive waste,
37 and reactor-related Greater than Class C waste."

38 40 CFR Part 50. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 50,
39 "National primary and secondary ambient air quality standards."

40 40 CFR Part 51. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 51,
41 "Requirements for preparation, adoption, and submittal of implementation plans."

Affected Environment

- 1 40 CFR Part 81. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 81,
2 “Designation of areas for air quality planning purposes.”
- 3 40 CFR Part 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190,
4 “Environmental radiation protection standards for nuclear power operations.”
- 5 49 CFR Parts 171–178. *Code of Federal Regulations*, Title 49, *Transportation*, Subchapter C—
6 Hazardous Materials Regulations and “Specifications for packagings.”
- 7 50 CFR Part 10. *Code of Federal Regulations*, Title 50, *Wildlife and Fisheries*, Part 10, “General
8 provisions,” Section 10.12, “Definitions.”
- 9 50 CFR Part 22. *Code of Federal Regulations*, Title 50, *Wildlife and Fisheries*, Part 22, “Eagle
10 permits,” Section 22.3, “Definitions.”
- 11 50 CFR Part 402. *Code of Federal Regulations*, Title 50, *Wildlife and Fisheries*, Part 402,
12 “Interagency cooperation—Endangered Species Act of 1973, as amended.”
- 13 32 FR 4001. U.S. Fish and Wildlife Service. “Endangered species.” *Federal*
14 *Register* 32(48):4001. March 11, 1967.
- 15 41 FR 41914. U.S. Fish and Wildlife Service. “Endangered and threatened wildlife and plants;
16 determination of critical habitat for American crocodile, California condor, Indiana bat, and
17 Florida manatee.” *Federal Register* 41(187):41914–41916. September 24, 1976.
- 18 52 FR 781. U.S. Fish and Wildlife Service. “Endangered and threatened wildlife and plants;
19 determination of threatened status for *Lespedeza leptostachya* (prairie bush-clover).” *Federal*
20 *Register* 52(6):781–785. January 9, 1987. Available at
21 http://ecos.fws.gov/docs/federal_register/fr1213.pdf (accessed 29 October 2013).
- 22 54 FR 39857. U.S. Fish and Wildlife Service. “Endangered and threatened wildlife and plants;
23 determination of threatened status for eastern and western prairie fringed orchids.” *Federal*
24 *Register* 54(187):39857–39863. September 28, 1989. Available at
25 http://ecos.fws.gov/docs/federal_register/fr1602.pdf (accessed 30 October 2013).
- 26 56 FR 19953. U.S. Fish and Wildlife Service. “Endangered and threatened wildlife and plants;
27 *Dalea foliosa* (leafy prairie-clover) determined to be endangered.” *Federal Register*
28 56(84):19953–19959. May 1, 1991. Available at
29 http://ecos.fws.gov/docs/federal_register/fr1847.pdf (accessed 7 January 2014).
- 30 59 FR 7629. Executive Order No. 12898. “Federal actions to address environmental justice in
31 minority populations and low-income populations.” *Federal Register* 59(32):7629–7634.
32 February 16, 1994.
- 33 69 FR 41576. U.S. Environmental Protection Agency. “National Pollutant Discharge Elimination
34 System—final regulations to establish requirements for cooling water intake structures at
35 Phase II existing facilities.” *Federal Register* 69(131):41576–41693. July 9, 2004.
- 36 69 FR 52040. U.S. Nuclear Regulatory Commission. “Policy statement on the treatment of
37 environmental justice matters in NRC regulatory and licensing actions.” *Federal Register*
38 69(163):52040–52048. August 24, 2004.
- 39 74 FR 56260. U.S. Environmental Protection Agency. “Mandatory reporting of greenhouse
40 gases.” *Federal Register* 74(209):56260–56519. October 30, 2009.
- 41 75 FR 31514. U.S. Environmental Protection Agency. “Prevention of Significant Deterioration
42 and Title V Greenhouse Gas Tailoring Rule.” *Federal Register* 75(106)31514–31608.
43 June 3, 2010.

- 1 78 FR 60704. U.S. Environmental Protection Agency. "Approval and promulgation of air quality
2 implementation plan; Illinois; redesignation of the Chicago area to attainment of the 1997 annual
3 fine particulate matter standard." *Federal Register* 78(191):60704–60707. October 2, 2013.
- 4 78 FR 61046. U.S. Fish and Wildlife Service. "Endangered and threatened wildlife and plants;
5 12-month finding on a petition to list the eastern small-footed bat and the northern long-eared
6 bat as endangered or threatened species; listing the northern long-eared bat as an endangered
7 species." *Federal Register* 78(191):61046–61080. October 2, 2013. Available at
8 <<http://www.gpo.gov/fdsys/pkg/FR-2013-10-02/pdf/2013-23753.pdf>> (accessed
9 30 January 2014).
- 10 78 FR 72058. U.S. Fish and Wildlife Service. "Endangered and threatened wildlife and plants;
11 listing the northern long-eared bat as an endangered species." *Federal*
12 *Register* 78(231):72058–72059. December 2, 2013. Available at
13 <<http://www.gpo.gov/fdsys/pkg/FR-2013-12-02/pdf/2013-28705.pdf>> (accessed
14 30 January 2014).
- 15 35 IAC 302. Illinois Administrative Code, Title 35, *Environmental Protection*, Subtitle C, "Water
16 pollution," Chapter I, "Pollution Control Board," Part 302, "Water quality standards." Available at
17 <<http://www.ipcb.state.il.us/SLR/IPCBandIEPAEnvironmentalRegulations-Title35.aspx>>
18 (accessed 13 February 2014).
- 19 35 IAC 303. Illinois Administrative Code, Title 35, *Environmental Protection*, Subtitle C, "Water
20 pollution," Chapter I, "Pollution Control Board," Part 303, "Water use designations and site
21 specific water quality standards." Available at
22 <<http://www.ipcb.state.il.us/SLR/IPCBandIEPAEnvironmentalRegulations-Title35.aspx>>
23 (accessed 13 February 2014).
- 24 35 IAC 309. Illinois Administrative Code, Title 35, *Environmental Protection*, Subtitle C, "Water
25 pollution," Chapter I, "Pollution Control Board," Part 309, "Permits," Subpart A, "NPDES
26 permits." Available at
27 <<http://www.ipcb.state.il.us/SLR/IPCBandIEPAEnvironmentalRegulations-Title35.aspx>>
28 (accessed 13 February 2014).
- 29 35 IAC 900. Illinois Administrative Code, Title 35, *Environmental Protection*, Subtitle H, "Noise,"
30 Chapter I, "Pollution Control Board." Available at
31 <<http://www.ipcb.state.il.us/SLR/IPCBandIEPAEnvironmentalRegulations-Title35.aspx>>
32 (accessed 28 August 2014).
- 33 35 IAC 1420. Illinois Administrative Code, Title 35, *Environmental Protection*, Subtitle M,
34 "Biological materials," Chapter I, "Pollution Control Board," Subchapter b, "Potentially infectious
35 medical wastes," Part 1420, "General provisions." Available at
36 <<http://www.ipcb.state.il.us/SLR/IPCBandIEPAEnvironmentalRegulations-Title35.aspx>>
37 (accessed 20 May 2014).
- 38 [AEC] U.S. Atomic Energy Commission. 1974. *Final Environmental Statement Related to the*
39 *Proposed Byron Station, Units 1 and 2*. Washington, DC: AEC. July 31, 1974. 295 p. ADAMS
40 No. ML13273A372.
- 41 Albrecht JA. 2013a. "University of Nebraska-Lincoln Food: Bacteria Causing Foodborne Illness:
42 Salmonella." Available at <<http://food.unl.edu/web/safety/salmonella>> (accessed
43 23 October 2013).
- 44 Albrecht JA. 2013b. "University of Nebraska-Lincoln Food: Bacteria Causing Foodborne Illness:
45 Shigella." Available at <<http://food.unl.edu/web/safety/shigella>> (accessed 23 October 2013).

Affected Environment

- 1 [ASA] Acoustical Society of America. 1983. American National Standard Specification for Sound
2 Level Meters, ANSI S1.4-1983. New York, NY.
- 3 [ASA] Acoustical Society of America. 1985. American National Standard Specification for Sound
4 Level Meters, ANSI S1.4A-1985 Amendment to ANSI S1.4-1983. New York, NY.
- 5 [Audubon] National Audubon Society. 2013. "Important Bird Areas: Site Profile: Castle Rock
6 State Park and Lowden-Miller State Forest Site." Available at
7 <<http://netapp.audubon.org/iba/site/1698>> (accessed 7 February 2014).
- 8 Avery C. 1994. *Interaction of Ground Water With the Rock River Near Byron, Illinois*. Urbana, IL:
9 U.S. Geological Survey. Water-Resources Investigation Report 94-4034. 26 p. Available at
10 <http://il.water.usgs.gov/pubs/wrir94_4034.pdf> (accessed 30 December 2013).
- 11 Bales SA, Price AL, Shasteen DK. 2012. *Freshwater Mussels of the Rock River*. Champaign, IL:
12 Illinois Natural History Survey. Technical Report 2012 (17). May 29, 2012. 22 p. Available at
13 <[http://www.dnr.illinois.gov/conservation/iwap/documents/mussel%20basin%20surveys/
14 rock_mussels.pdf](http://www.dnr.illinois.gov/conservation/iwap/documents/mussel%20basin%20surveys/rock_mussels.pdf)> (accessed 27 January 2014).
- 15 [BGEPA] Bald and Golden Eagle Protection Act of 1940, as amended. 16 U.S.C. § 668–668c.
- 16 Birmingham R, Fowler M. 1974. *Archaeological Statement Byron Nuclear Power Station Project*.
17 University of Wisconsin—Milwaukee.
- 18 [BLS] U.S. Bureau of Labor Statistics. 2014. "Local Area Unemployment Statistics." Available at
19 <<http://www.bls.gov/data/>> (accessed January 2014).
- 20 Bowles ML (The Morton Arboretum). 1999. *Eastern Prairie Fringed Orchid (Platanthera
21 leucophaea) Recovery Plan*. Fort Snelling, MN: FWS. September 29, 1999. 63 p. Available at
22 <http://ecos.fws.gov/docs/recovery_plan/990929.pdf> (accessed 30 October 2013).
- 23 Burch SL. 2008. *A Comparison of Potentiometric Surfaces for the Cambrian-Ordovician
24 Aquifers of Northeastern Illinois, 2000 and 2007*. Champaign, IL: Illinois State Water Survey.
25 Data/Case Study 2008-04. December 2008. Available at
26 <<http://www.isws.illinois.edu/pubdoc/DCS/ISWSDCS2008-04.pdf>> (accessed
27 7 November 2013).
- 28 Carter TC, Feldhamer GA. 2005. Roost tree use by maternity colonies of Indiana bats and
29 northern long-eared bats in southern Illinois. *Forest Ecology and
30 Management* 219(2005):259–268. Available at
31 <[http://tccarter.iweb.bsu.edu/Carter%20and%20Feldhamer%202005%20MYSO%20Roosting%
32 20-%20FEM.pdf](http://tccarter.iweb.bsu.edu/Carter%20and%20Feldhamer%202005%20MYSO%20Roosting%20-%20FEM.pdf)> (accessed 28 August 2014).
- 33 [CDC] Centers for Disease Control and Prevention. 2002. "Surveillance for Waterborne-Disease
34 Outbreaks—United States, 1999–2000." *Morbidity and Mortality Weekly Report* 51(8):1–28.
35 November 22, 2002. Available at <<http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5108a1.htm>>
36 (accessed 23 October 2013).
- 37 [CDC] Centers for Disease Control and Prevention. 2003. *Summary of Notifiable Diseases—
38 United States, 2001*. *Morbidity and Mortality Weekly Report* 50(53). Atlanta, GA: CDC.
39 May 2, 2003. 136 p. Available at <<http://www.cdc.gov/mmwr/PDF/wk/mm5053.pdf>> (accessed
40 22 October 2013).
- 41 [CDC] Centers for Disease Control and Prevention. 2004a. *Summary of Notifiable Diseases—
42 United States, 2002*. *Morbidity and Mortality Weekly Report* 51(53). Atlanta, GA: CDC.
43 April 30, 2004. 88 p. Available at <<http://www.cdc.gov/mmwr/PDF/wk/mm5153.pdf>> (accessed
44 22 October 2013).

- 1 [CDC] Centers for Disease Control and Prevention. 2004b. "Surveillance for
2 Waterborne-Disease Outbreaks and Other Health Events Associated with Recreational Water—
3 United States, 2001–2002." *Morbidity and Mortality Weekly Report* 53(8):1–22.
4 October 22, 2004. Available at <<http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5308a1.htm>>
5 (accessed 23 October 2013).
- 6 [CDC] Centers for Disease Control and Prevention. 2005. *Summary of Notifiable Diseases—*
7 *United States, 2003*. *Morbidity and Mortality Weekly Report* 52(54). Atlanta, GA: CDC.
8 April 22, 2005. 88 p. Available at <<http://www.cdc.gov/mmwr/PDF/wk/mm5254.pdf>> (accessed
9 22 October 2013).
- 10 [CDC] Centers for Disease Control and Prevention. 2006a. *Summary of Notifiable Diseases—*
11 *United States, 2004*. *Morbidity and Mortality Weekly Report* 53(53). June 16, 2006. Available at
12 <<http://www.cdc.gov/mmwr/PDF/wk/mm5353.pdf>> (accessed 22 October 2013).
- 13 [CDC] Centers for Disease Control and Prevention. 2006b. "Surveillance for
14 Waterborne-Disease Outbreaks and Other Health Events Associated with Recreational Water—
15 United States, 2003–2004." *Morbidity and Mortality Weekly Report* 55(12):1–24.
16 December 22, 2006. Available at <<http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5512a1.htm>>
17 (accessed 23 October 2013).
- 18 [CDC] Centers for Disease Control and Prevention. 2007. *Summary of Notifiable Diseases—*
19 *United States, 2005*. *Morbidity and Mortality Weekly Report* 54(53). Atlanta, GA: CDC.
20 March 30, 2007. 96 p. Available at <<http://www.cdc.gov/mmwr/PDF/wk/mm5453.pdf>> (accessed
21 22 October 2013).
- 22 [CDC] Centers for Disease Control and Prevention. 2008a. *Summary of Notifiable Diseases—*
23 *United States, 2006*. *Morbidity and Mortality Weekly Report* 55(53). Atlanta, GA: CDC.
24 March 21, 2008. 100 p. Available at <<http://www.cdc.gov/mmwr/PDF/wk/mm5553.pdf>>
25 (accessed 22 October 2013).
- 26 [CDC] Centers for Disease Control and Prevention. 2008b. "Surveillance for
27 Waterborne-Disease and Outbreaks Associated with Recreational Water Use and Other Aquatic
28 Facility-Associated—United States, 2005–2006." *Morbidity and Mortality Weekly*
29 *Report* 57(9):1–29. September 9, 2008. Available at
30 <<http://www.cdc.gov/mmwr/preview/mmwrhtml/ss5709a1.htm>> (accessed 23 October 2013).
- 31 [CDC] Centers for Disease Control and Prevention. 2009. *Summary of Notifiable Diseases—*
32 *United States, 2007*. *Morbidity and Mortality Weekly Report* 56(53). Atlanta, GA: CDC.
33 July 9, 2009. 100 p. Available at <<http://www.cdc.gov/mmwr/PDF/wk/mm5653.pdf>> (accessed
34 22 October 2013).
- 35 [CDC] Centers for Disease Control and Prevention. 2010a. "General Information on
36 Salmonella." April 5, 2012. Available at <<http://www.cdc.gov/salmonella/general/>> (accessed
37 23 October 2013).
- 38 [CDC] Centers for Disease Control and Prevention. 2010b. *Summary of Notifiable Diseases—*
39 *United States, 2008*. *Morbidity and Mortality Weekly Report* 57(54). Atlanta, GA: CDC.
40 June 25, 2010. 100 p. Available at <<http://www.cdc.gov/mmwr/PDF/wk/mm5754.pdf>> (accessed
41 22 October 2013).
- 42 [CDC] Centers for Disease Control and Prevention. 2011a. "Legionellosis—United States,
43 2000–2009." *Morbidity and Mortality Weekly Report* 60(32):1083–1086. August 19, 2011.
44 Available at <<http://www.cdc.gov/mmwr/preview/mmwrhtml/mm6032a3.htm>> (accessed
45 23 October 2013).

Affected Environment

- 1 [CDC] Centers for Disease Control and Prevention. 2011b. *Summary of Notifiable Diseases—*
2 *United States, 2009*. Morbidity and Mortality Weekly Report 58(53). Atlanta, GA: CDC.
3 May 13, 2011. 104 p. Available at <<http://www.cdc.gov/mmwr/PDF/wk/mm5853.pdf>> (accessed
4 22 October 2013).
- 5 [CDC] Centers for Disease Control and Prevention. 2011c. “Surveillance for Waterborne
6 Disease Outbreaks and Other Health Events Associated with Recreational Water—
7 United States, 2007–2008.” Morbidity and Mortality Weekly Report 60(12):1–32.
8 September 23, 2011. Available at
9 <http://www.cdc.gov/mmwr/preview/mmwrhtml/ss6012a1.htm?s_cid=ss6012a1_w> (accessed
10 23 October 2013).
- 11 [CDC] Centers for Disease Control and Prevention. 2012. *Summary of Notifiable Diseases—*
12 *United States, 2010*. Morbidity and Mortality Weekly Report 59(53). Atlanta, GA: CDC.
13 June 1, 2012. 116 p. Available at <<http://www.cdc.gov/mmwr/PDF/wk/mm5953.pdf>> (accessed
14 22 October 2013).
- 15 [CDC] Centers for Disease Control and Prevention. 2013a. “*Pseudomonas aeruginosa* in
16 Healthcare Settings—HAI.” Available at <<http://www.cdc.gov/hai/organisms/pseudomonas.html>>
17 (accessed 23 October 2013).
- 18 [CDC] Centers for Disease Control and Prevention. 2013b. “*Naegleria fowleri* - Primary Amebic
19 Meningoencephalitis (PAM).” Available at <<http://www.cdc.gov/parasites/naegleria/index.html>>
20 (accessed 23 October 2013).
- 21 [CDC] Centers for Disease Control and Prevention. 2013c. “*Naegleria fowleri*—Sources of
22 Infection—Number of Case-reports of Primary Amebic Meningoencephalitis by State of
23 Exposure: United States, 1962–2012.” June 6, 2013. Available at
24 <<http://www.cdc.gov/parasites/naegleria/state-map.html>> (accessed 21 October 2013).
- 25 [CDC] Centers for Disease Control and Prevention. 2013d. “Reports of Selected *Salmonella*
26 Outbreak Investigations.” Available at <<http://www.cdc.gov/salmonella/outbreaks.html>>
27 (accessed 23 October 2013).
- 28 [CDC] Centers for Disease Control and Prevention. 2013e. “Shigellosis: General Information—
29 NCZVED.” May 14, 2013. Available at
30 <<http://www.cdc.gov/nczved/divisions/dfbmd/diseases/shigellosis/>> (accessed
31 23 October 2013).
- 32 [CEC] Commission for Environmental Cooperation. 2008. “Eastern Temperate Forests
33 ecoregion (CEC).” October 16, 2008. Available at <<http://www.eoearth.org/view/article/151915>>
34 (accessed 7 February 2014).
- 35 [CEQ] Council on Environmental Quality. 1997. *Environmental Justice: Guidance Under the*
36 *National Environmental Policy Act*. Washington, DC: CEQ. December 10, 1997. 40 p. Available
37 at <<http://ceq.hss.doe.gov/nepa/regs/ej/justice.pdf>>.
- 38 [CISEH] Center for Invasive Species and Ecosystem Health. 2009. “Illinois Invasive Plant List.”
39 April 13, 2009. Available at <<http://www.invasive.org/species/list.cfm?id=152>> (accessed
40 7 February 2014).

- 1 [ComEd] Commonwealth Edison Company. 1981. Byron Station Environmental Report
2 Operating License Stage. Volume 2, Amendment No. 4. January 1983. Available in: Letter from
3 M.P. Gallagher, Vice President – License Renewal Projects, Exelon, to NRC. Subject:
4 Response to NRC Request for Additional Information - Additional Request, dated
5 January 29, 2014, related to the Byron and Braidwood Stations, Units 1 and 2 License Renewal
6 Application, Byron Station Applicant’s Environmental Report. February 11, 2014.
7 ADAMS No. ML14045A101.
- 8 [ComEd] Commonwealth Edison Company. 2013. Letter from T.W. Kay, Manager –
9 Interconnection & System Studies, to Exelon. Subject: Byron Station license renewal
10 Environmental Report – NRC request regarding transmission lines. RAI Response TE-5.
11 August 29, 2013. Available in: Letter from M.P. Gallagher, Vice President – License Renewal
12 Projects, Exelon, to NRC. Subject: Response to NRC request for additional information dated
13 November 21, 2013, related to the Byron and Braidwood Stations, Units 1 and 2, license
14 renewal application, Byron Station applicant’s Environmental Report. December 19, 2013.
15 ADAMS No. ML14007A078 (package).
- 16 [CRA] Conestoga-Rovers & Associates. 2006. *Hydrogeologic Investigation Report, Fleetwide*
17 *Assessment, Byron Generating Station, Byron, Illinois*. Revision 1. Waterloo, Canada: CRA.
18 045136 (13). September 2006. 634 p. ADAMS No. ML062750384.
- 19 [CWA] Clean Water Act of 1977, as amended. 33 U.S.C. § 1251 et seq.
- 20 [DCEO] Illinois Department of Commerce and Economic Opportunity. 2012. “County Population
21 Projections.” Projected Illinois County Population numbers categorized by race, age group and
22 gender through 2030. January 27, 2012. Available at <<http://www2.illinoisbiz.biz/popProj/>>
23 (accessed February 2014).
- 24 DeMauro MM (Forest Preserve District of Will County), Bowles ML (The Morton Arboretum).
25 1996. *Leafy Prairie-Clover Recovery Plan*. Atlanta, GA: FWS. September 30, 1996. 83 p.
26 Available at <http://ecos.fws.gov/docs/recovery_plans/1996/960930c.pdf> (accessed
27 7 January 2014).
- 28 [eBird] eBird. 2013. “Explore Data: Bird Observations: Bald Eagle.” Available at
29 <[http://ebird.org/ebird/
30 GuideMe?src=changeDate&speciesCodes=baleag&getLocations=counties&counties
31 =US-IL-141&parentState=US-IL&reportType=species&monthRadio=on&bMonth=01&eMonth
32 =12&bYear=1980&eYear=2014&continue.x=13&continue.y=9](http://ebird.org/ebird/GuideMe?src=changeDate&speciesCodes=baleag&getLocations=counties&counties=US-IL-141&parentState=US-IL&reportType=species&monthRadio=on&bMonth=01&eMonth=12&bYear=1980&eYear=2014&continue.x=13&continue.y=9)> (accessed 7 February 2014).
- 33 [EA Engineering] EA Engineering, Science, and Technology. 2012. *Byron Station 2011 Fish and*
34 *Benthos Monitoring and Historical Fish and Benthos Comparisons*. Deerfield, IL:
35 EA Engineering. July 2012. 57 p. Available in: “Byron, Units 1 and 2, Response to NRC Request
36 for Additional Information, dated November 21, 2013, Related to the Byron and Braidwood
37 Stations, Units 1 and 2 License Renewal Application, Byron Station Applicant’s Environmental
38 Report.” December 19, 2013. ADAMS Nos. ML14007A078 (package) and ML14007A083
39 (Part 2 of 15).
- 40 [EPA] U.S. Environmental Protection Agency. 1974. *Information on Levels of Environmental*
41 *Noise Requisite to Protect Public Health and Welfare with an Adequate Margin of Safety*.
42 Washington, DC: EPA. 550/9-74-004. March 1974. Available at
43 <<http://www.nonoise.org/library/levels74/levels74.htm>> (accessed 5 December 2013).

Affected Environment

- 1 [EPA] U.S. Environmental Protection Agency. 2003. *Five-Year Review Report: Byron Salvage*
2 *Yard Superfund Site, Ogle County, Illinois*. Chicago, IL: EPA. 11 p. Available at
3 <http://www.epa.gov/region5/cleanup/byron/pdfs/byron_5yr_2004.pdf> (accessed
4 7 February 2014).
- 5 [EPA] U.S. Environmental Protection Agency. 2013a. "Region 5 Superfund, Byron Salvage
6 Yard, EPA ID# ILD010236230, NPL Fact Sheet." November 2011. Available at
7 <<http://www.epa.gov/R5Super/npl/illinois/ILD010236230.html>> (accessed 15 December 2013).
- 8 [EPA] U.S. Environmental Protection Agency. 2013b. "Western Ecology Division: Level III and
9 Level IV Ecoregions of the United States." November 2013. Available at
10 <http://www.epa.gov/wed/pages/ecoregions/level_iii_iv.htm> (accessed 7 February 2014).
- 11 [EPA] U.S. Environmental Protection Agency. 2014a. "Enforcement and Compliance History
12 Online." Available at <<http://echo.epa.gov/?redirect=echo>> (accessed 4 February 2014).
- 13 [EPA] U.S. Environmental Protection Agency. 2014b. "Envirofacts—Safe Drinking Water
14 Information System (SDWIS)." County Search—Lee, Ogle, and Winnebago Counties, IL.
15 Available at <<http://www.epa.gov/enviro/facts/sdwis/search.html>> (accessed February 2014).
- 16 [EPA] U.S. Environmental Protection Agency. 2014c. Memorandum: Next Steps and Preliminary
17 Views on the Application of Clean Air Act Permitting Programs to Greenhouse Gases Following
18 the Supreme Court's Decisions in Utility Air Regulatory Group v. Environmental Protection
19 Agency. Available at
20 <<http://www.epa.gov/airprog/oar/oaqps/nsr/documents/20140724memo.pdf>> (accessed
21 5 September 2014).
- 22 [ESA] Endangered Species Act of 1973, as amended. 16 U.S.C. § 1531 et seq.
- 23 [ESI] Ecological Specialists, Inc. 2011. *Unionid Communities Near Byron Station, Rock River*.
24 O'Fallon, MO: ESI. Project No. 11-003a. November 2011. 44 p. Available in: "Byron, Units 1 and
25 2, Response to NRC Request for Additional Information, dated November 21, 2013, Related to
26 the Byron and Braidwood Stations, Units 1 and 2 License Renewal Application, Byron Station
27 Applicant's Environmental Report." ADAMS Nos. ML14007A078 (package) and ML14007A083
28 (Part 2 of 15).
- 29 [Exelon] Exelon Generation Company, LLC. 2003. *Storm Water Pollution Prevention Plan –*
30 *Byron Nuclear Power Station*. June 2003. Available in: Letter from M.P. Gallagher,
31 Vice President – License Renewal Projects, to NRC. Subject: Response to NRC request for
32 additional information dated November 21, 2013, related to the Byron and Braidwood Stations,
33 Units 1 and 2, license renewal application, Byron Station applicant's Environmental Report.
34 December 19, 2013. ADAMS No. ML14007A078 (package).
- 35 [Exelon] Exelon Generation Company, LLC. 2008. *Illinois Water Inventory Program (Byron*
36 *Station Report Submitted to the Illinois State Water Survey for Calendar Year 2008)*. Available
37 in: "Byron, Units 1 and 2, response to NRC request for additional information, dated
38 November 21, 2013, related to the Byron and Braidwood Stations, Units 1 and 2, license
39 renewal application, Byron Station applicant's Environmental Report." December 19, 2013.
40 ADAMS No. ML14007A088 (Part 13 of 15).
- 41 [Exelon] Exelon Generation Company, LLC. 2009a. *2008 Annual Emission Report*.
42 April 24, 2009. Available in: "Byron, Units 1 and 2, Response to NRC request for additional
43 information, dated November 21, 2013, related to the Byron and Braidwood Stations, Units 1
44 and 2, license renewal application, Byron Station applicant's Environmental Report."
45 December 19, 2013. ADAMS No. ML14007A088 (Part 13 of 15).

- 1 [Exelon] Exelon Generation Company, LLC. 2009b. *Byron Nuclear Power Station Annual*
2 *Radiological Effluent Release Report (ARERR), 2008*. Byron, IL: Exelon Nuclear. May 2009.
3 94 p. ADAMS No. ML091200667.
- 4 [Exelon] Exelon Generation Company, LLC. 2009c. *Illinois Water Inventory Program (Byron*
5 *Station Report Submitted to the Illinois State Water Survey for Calendar Year 2009)*. Available
6 in: "Byron, Units 1 and 2, response to NRC request for additional information, dated
7 November 21, 2013, related to the Byron and Braidwood Stations, Units 1 and 2, license
8 renewal application, Byron Station applicant's Environmental Report." December 19, 2013.
9 ADAMS No. ML14007A088 (Part 13 of 15).
- 10 [Exelon] Exelon Generation Company, LLC. 2010a. *2009 Annual Emission Report*.
11 April 24, 2010. Available in: "Byron, Units 1 and 2, response to NRC request for additional
12 information, dated November 21, 2013, related to the Byron and Braidwood Stations, Units 1
13 and 2, license renewal application, Byron Station applicant's Environmental Report."
14 December 19, 2013. ADAMS No. ML14007A088 (Part 13 of 15).
- 15 [Exelon] Exelon Generation Company, LLC. 2010c. *Byron Nuclear Power Station Annual*
16 *Radiological Effluent Release Report (ARERR), 2009*. Byron, IL. 50 p. ADAMS
17 No. ML101230140.
- 18 [Exelon] Exelon Generation Company, LLC. 2010d. *Illinois Water Inventory Program (Byron*
19 *Station Report Submitted to the Illinois State Water Survey for Calendar Year 2010)*. Available
20 in: "Byron, Units 1 and 2, response to NRC request for additional information, dated
21 November 21, 2013, related to the Byron and Braidwood Stations, Units 1 and 2, license
22 renewal application, Byron Station applicant's Environmental Report." December 19, 2013.
23 ADAMS No. ML14007A088 (Part 13 of 15).
- 24 [Exelon Nuclear] Exelon Generation Company, LLC. 2011a. *2010 Annual Emission Report*.
25 April 14, 2011. Available in: "Byron, Units 1 and 2, response to NRC request for additional
26 information, dated November 21, 2013, related to the Byron and Braidwood Stations, Units 1
27 and 2, license renewal application, Byron Station applicant's Environmental Report."
28 December 19, 2013. ADAMS No. ML14007A088 (Part 13 of 15).
- 29 [Exelon] Exelon Generation Company, LLC. 2011b. *Byron Nuclear Power Station Annual*
30 *Radiological Effluent Release Report (ARERR), 2010*. Byron, IL: Exelon Nuclear. April 29, 2011.
31 78 p. ADAMS No. ML111730662.
- 32 [Exelon] Exelon Generation Company, LLC. 2011c. *Illinois Water Inventory Program (Byron*
33 *Station Report Submitted to the Illinois State Water Survey for Calendar Year 2011)*. Available
34 in: "Byron, Units 1 and 2, response to NRC request for additional information, dated
35 November 21, 2013, related to the Byron and Braidwood Stations, Units 1 and 2, license
36 renewal application, Byron Station applicant's Environmental Report." December 19, 2013.
37 ADAMS No. ML14007A088 (Part 13 of 15).
- 38 [Exelon] Exelon Generation Company, LLC. 2011d, *Request for License Amendment Regarding*
39 *Measurement Uncertainty Recapture (MUR) Power Uprate*. June 23, 2011. ADAMS
40 No. ML111790026 (package).
- 41 [Exelon] Exelon Generation Company, LLC. 2012a. *2011 Annual Emission Report*.
42 April 26, 2012. Available in: "Byron, Units 1 and 2, response to NRC request for additional
43 information, dated November 21, 2013, related to the Byron and Braidwood Stations, Units 1
44 and 2, license renewal application, Byron Station applicant's Environmental Report."
45 December 19, 2013. ADAMS No. ML14007A088 (Part 13 of 15).

Affected Environment

- 1 [Exelon] Exelon Generation Company, LLC. 2012b. Biological Evaluation – Byron Station.
2 p. C-47 to C-49. Available in: “Byron, Units 1 and 2—Environmental Report.” May 29, 2013.
3 ADAMS Nos. ML131550528 (package), ML13155A423 (part 2).
- 4 [Exelon] Exelon Generation Company, LLC. 2012c. *Byron Nuclear Power Station Annual*
5 *Radiological Effluent Release Report (ARERR), 2011*. Byron, IL. December 31, 2011. 81 p.
6 ADAMS No. ML122290703.
- 7 [Exelon] Exelon Generation Company, LLC. 2012d. *Byron/Braidwood Nuclear Stations,*
8 *Updated Final Safety Analysis Report (UFSAR)*. Revision 14. December 14, 2012. ADAMS
9 No. ML130040043.
- 10 [Exelon] Exelon Generation Company, LLC. 2012e. *Illinois Water Inventory Program (Byron*
11 *Station Report Submitted to the Illinois State Water Survey for Calendar Year 2012)*. Available
12 in: “Byron, Units 1 and 2, response to NRC request for additional information, dated
13 November 21, 2013, related to the Byron and Braidwood Stations, Units 1 and 2, license
14 renewal application, Byron Station applicant’s Environmental Report.” December 19, 2013.
15 ADAMS No. ML14007A088 (Part 13 of 15).
- 16 [Exelon] Exelon Generation Company, LLC. 2013a. *Applicant’s Environmental Report –*
17 *Operation License Renewal Stage Byron Station – Unit 1, License No. NPF-37, Unit 2, License*
18 *No. NPF-66*. May 2013. ADAMS No. ML131550528 (package).
- 19 [Exelon] Exelon Generation Company, LLC. 2013b. Letter from M.P. Gallagher, Vice President
20 – License Renewal Projects, Exelon, to NRC. Subject: Byron, Units 1 and 2, response to NRC
21 request for additional information, dated November 21, 2013, related to the Byron and
22 Braidwood, Units 1 and 2, license renewal application, Byron Station applicant’s Environmental
23 Report. December 19, 2013. ADAMS No. ML14007A078 (package).
- 24 [Exelon] Exelon Generation Company, LLC. 2013c. *2012 Annual Emission Report*.
25 February 13, 2013. Available in: “Byron, Units 1 and 2, response to NRC request for additional
26 information, dated November 21, 2013, related to the Byron and Braidwood Stations, Units 1
27 and 2, license renewal application, Byron Station applicant’s Environmental Report.”
28 December 19, 2013. ADAMS No. ML14007A088 (Part 13 of 15).
- 29 [Exelon] Exelon Generation Company, LLC. 2013d. *Byron and Braidwood Stations, Units 1*
30 *and 2, License Renewal Application*. Kennett Square, PA: Exelon. June 3, 2013. 3,749 p.
31 ADAMS No. ML131620554 (package).
- 32 [Exelon] Exelon Generation Company, LLC. 2013f. *Storm Water Pollution Prevention Plan*.
33 Byron, IL: Byron Nuclear Power Station. January 2013. Exelon Nuclear] Exelon Nuclear.
34 Available in “Byron, Units 1 and 2, Response to NRC Request for Additional Information, dated
35 November 21, 2013, Related to the Byron and Braidwood Stations, Units 1 and 2 License
36 Renewal Application, Byron Station Applicant’s Environmental Report. Part 14 of 15.” ADAMS
37 No. ML14007A089.
- 38 [Exelon] Exelon Generation Company, LLC. 2013g. *Byron Nuclear Station Annual Radiological*
39 *Effluent Release Report (ARERR), 2012*. Byron, IL. 88 p. ADAMS No. ML13161A201.Fagan
40 BM. 2005. *Ancient North America*. London: Thames & Hudson Ltd.
- 41 Farmer A, Cade S, Stauffer DF. Evaluation of Habitat Suitability Index Model. In: Kurta A,
42 Kennedy J, editors. 2002. *The Indiana Bat: Biology and Management of an Endangered*
43 *Species*. Austin, TX: Bat Conservation International. p. 172–181.
- 44 [FEMA] Federal Emergency Management Agency. 2013. “Earthquake Hazard Maps.” Available
45 at <www.fema.gov/earthquake/earthquake-hazard-maps#0> (accessed 14 April 2013).

- 1 [FWS] U.S. Fish and Wildlife Service. 2011. *A National Plan for Assisting States, Federal*
2 *Agencies, and Tribes in Managing White-Nose Syndrome in Bats*. Hadley, MA: FWS. May 2011.
3 21 p. Available at <[http://static.whitenosesyndrome.org/sites/default/files/](http://static.whitenosesyndrome.org/sites/default/files/white-nose_syndrome_national_plan_may_2011.pdf)
4 [white-nose_syndrome_national_plan_may_2011.pdf](http://static.whitenosesyndrome.org/sites/default/files/white-nose_syndrome_national_plan_may_2011.pdf)> (accessed 22 August 2013).
- 5 [FWS] U.S. Fish and Wildlife Service. 2013a. E-mail from J. Duyvejonck to B. Grange,
6 U.S. Nuclear Regulatory Commission. Subject: Byron Illinois License Renewal.
7 August 30, 2013. ADAMS No. ML13246A385.
- 8 [FWS] U.S. Fish and Wildlife Service. 2013c. "Leafy Prairie Clover (*Dalea foliosa*) Fact Sheet."
9 January 3, 2013. Available at <<http://www.fws.gov/midwest/endangered/plants/leafypra.html>>
10 (accessed 7 January 2014).
- 11 [FWS] U.S. Fish and Wildlife Service. 2013d. "National Wetlands Inventory." Available at
12 <<http://www.fws.gov/wetlands/>> (accessed 7 February 2014).
- 13 [FWS] U.S. Fish and Wildlife Service. 2013e. "Species Profile for Eastern Prairie Fringed orchid
14 (*Platanthera leucophaea*)."
15 October 30, 2013. Available at
16 <[http://ecos.fws.gov/speciesProfile/profile/](http://ecos.fws.gov/speciesProfile/profile/speciesProfile.action?sPCODE=Q2GG&ftb_embed=true)
[speciesProfile.action?sPCODE=Q2GG&ftb_embed=true](http://ecos.fws.gov/speciesProfile/profile/speciesProfile.action?sPCODE=Q2GG&ftb_embed=true)> (accessed 30 October 2013).
- 17 [FWS] U.S. Fish and Wildlife Service. 2013f. "Species Profile for Prairie bush-clover (*Lespedeza*
18 *leptostachya*)."
19 October 30, 2013. Available at
20 <<https://ecos.fws.gov/speciesProfile/profile/speciesProfile.action?sPCODE=Q2CB>> (accessed
30 October 2013).
- 21 [HUD] U.S. Department of Housing and Urban Development. 2013. "Noise Abatement and
22 Control." Available at <[https://www.hudexchange.info/environmental-review/noise-abatement-](https://www.hudexchange.info/environmental-review/noise-abatement-and-control)
23 [and-control](https://www.hudexchange.info/environmental-review/noise-abatement-and-control)> (accessed 30 August 2014).
- 24 [IDNR] Illinois Department of Natural Resources. 2001. *Critical Trends in Illinois Ecosystems*.
25 Springfield, IL: IDNR. Chapter 4, Rock River watershed. p. 38–50. Available at
26 <<http://dnr.state.il.us/orep/ctap2/chp%204.pdf>> (accessed 7 February 2014).
- 27 [IDNR] Illinois Department of Natural Resources. 2002a. *Upper Rock River Area Assessment,*
28 *Volume 1: Geology*. Champaign, IL: IDNR. May 2002. 103 p. Available at
29 <<https://www.ideals.illinois.edu/bitstream/handle/2142/14426/upperrock1.pdf?sequence=2>>
30 (accessed 28 August 2014).
- 31 [IDNR] Illinois Department of Natural Resources. 2002b. *Upper Rock River Area Assessment,*
32 *Volume 3: Living Resources*. Champaign, IL: IDNR. January 2002. 271 p. Available at
33 <<https://www.ideals.illinois.edu/bitstream/handle/2142/14426/upperrock3.pdf?sequence=4>>
34 (accessed 28 August 2014).
- 35 [IDNR] Illinois Department of Natural Resources. 2013. *Illinois Threatened and Endangered*
36 *Species By County*. June 2013. 129 p. Available at
37 <http://www.dnr.illinois.gov/ESPB/Documents/ET_by_County.pdf> (accessed 30 October 2013
38 and 7 February 2014).
- 39 [IDNR] Illinois Department of Natural Resources. undated. "Lowden-Miller State Forest."
40 Available at <<http://www.dnr.state.il.us/lands/Landmgt/PARKS/R1/Lowdenmi.htm>> (accessed
41 7 February 2014).

Affected Environment

- 1 [IDOT] Illinois Department of Transportation. 1977. Permit No. 15001 to construct river screen
2 house and blowdown outlet in the Rock River at Byron Power Station, County of Ogle, State of
3 Illinois. April 7, 1977. Available in: "Byron, Units 1 and 2, Response to NRC Request for
4 additional information, dated November 21, 2013, related to the Byron and Braidwood Stations,
5 Units 1 and 2 license renewal application, Byron Station applicant's Environmental Report."
6 December 19, 2013. ADAMS No. ML14007A089 (Part 14 of 15).
- 7 [IDOT] Illinois Department of Transportation. 2014. *2011 Average Daily Total Traffic, State*
8 *Primary System, Illinois*. 1 p. Available at <http://www.dot.il.gov/trafficmaps/adt_statewide.pdf>
9 (accessed February 2014).
- 10 [IDPH] Illinois Department of Public Health. 2005. *Health Consultation: Byron Salvage Yard*
11 *(a/k/a Byron Johnson), Byron, Ogle County, Illinois (EPA Facility ID: ILD010236230)*. Atlanta,
12 GA: U.S. Department of Health and Human Services. February 23, 2005. 10 p. Available at
13 <<http://www.atsdr.cdc.gov/HAC/pha/ByronSalvage022305-IL/ByronSalvage022305-IL.pdf>>
14 (accessed 15 December 2013).
- 15 [IDPH] Illinois Department of Public Health. 2009. "Salmonella." January 2009. Available at
16 <<http://www.idph.state.il.us/public/hb/hbsam.htm>> (accessed 23 October 2013).
- 17 [IDPH] Illinois Department of Public Health. 2013. "Shigellosis Healthbeat." Available at
18 <<http://www.idph.state.il.us/public/hb/hbshigellosis.htm>> (accessed 23 October 2013).
- 19 [IEEE] Institute of Electrical and Electronics Engineers, Inc. 2002. National Electrical Safety
20 Code.
- 21 [IEPA] Illinois Environmental Protection Agency. 1989. Letter from T. McSwiggin, Manager,
22 Permit Section, Division of Water Pollution Control, to Commonwealth Edison Company, Byron
23 Nuclear Power Station. Subject: Determination under Section 316(b) of the Clean Water Act.
24 May 15, 1989. Available in: "Byron, Units 1 and 2, response to NRC request for additional
25 information, dated November 21, 2013, related to the Byron and Braidwood Stations, Units 1
26 and 2 license renewal application, Byron Station applicant's Environmental Report."
27 December 19, 2013. ADAMS No. ML14007A083 (Part 2 of 15).
- 28 [IEPA] Illinois Environmental Protection Agency. 2002. Federally Enforceable State Operating
29 Permit, I.D. No. 141820AAA. December 13, 2002. Available in: "Byron, Units 1 and 2, Response
30 to NRC Request for Additional Information, dated November 21, 2013, Related to the Byron and
31 Braidwood Stations, Units 1 and 2 License Renewal Application, Byron Station Applicant's
32 Environmental Report." December 19, 2013. ADAMS No. ML14007A088 (Part 13 of 15).
- 33 [IEPA] Illinois Environmental Protection Agency. 2006. *Rock River Basin Assessment: An*
34 *Overview of the Rock River Watershed in Illinois*. March 2006. 400 p. Available at
35 <<http://www.epa.state.il.us/water/watershed/facility-planning/rock-basin.pdf>> (accessed
36 12 July 2013 and 2 February 2014).
- 37 [IEPA] Illinois Environmental Protection Agency. 2011. *NPDES Permit No. IL0048313, National*
38 *Pollutant Discharge Elimination System, Reissued (NPDES) Permit*. Facility: Exelon Generation
39 Company, LLC, Byron Nuclear Power Station. Effective date: January 24, 2011; Modification
40 date: July 15, 2011. Springfield, IL: IEPA. In: Applicant's Environmental Report operating license
41 renewal stage, Byron Station, Units 1 and 2, Appendix B. 22 p. ADAMS No. ML13162A366.
- 42 [IEPA] Illinois Environmental Protection Agency. 2012. *Illinois Integrated Water Quality Report*
43 *and Section 303(d) List, 2012 – Volume I: Surface Water, Appendix A-2: Illinois' 2012 303(d)*
44 *List, Alphabetically by Water Name*. Illinois Environmental Protection Agency, Bureau of Water.
45 October 17, 2012. (Final submitted to USEPA Region 5.) 60 p. Available at
46 <<http://www.epa.state.il.us/water/tmdl/303d-list.html>> (accessed 4 February 2014).

- 1 [IEPA] Illinois Environmental Protection Agency. 2013. Letter from A. Keller, Manager, Permit
2 Section, Division of Water Pollution Control, to U.S. Nuclear Regulatory Commission, Division of
3 License Renewal—Office of Nuclear Reactor Regulation. Subject: Exelon Generation Company
4 (Ogle County), Renewal of Nuclear Regulatory Commission Operating Licenses for Exelon
5 Byron Generating Station Units 1 and 2 (NPF-37 and NPF-66). July 5, 2013. ADAMS
6 No. ML14113A544.
- 7 [IESPB] Illinois Endangered Species Protection Board. 2011. *Checklist of Endangered and*
8 *Threatened Animals and Plants of Illinois*. Effective February 22, 2011. 10 p. Available at
9 <<http://www.dnr.illinois.gov/ESPB/Documents/ETChecklist2011.pdf>> (accessed 11 July 2014).
- 10 [ISBE] Illinois State Board of Education. 2012. *2011 Annual Statistical Report of the Illinois State*
11 *Board of Education*. December 2012. 365 p. Available at
12 <http://www.isbe.state.il.us/research/pdfs/annual_stat_rpt10-11.pdf> (accessed
13 28 August 2014).
- 14 [ISGS] Illinois State Geological Survey. 2013. “Physiographic Divisions of Illinois.” Available at
15 <<http://crystal.isgs.uiuc.edu/maps-data-pub/publications/physio.shtml>> (accessed
16 5 December 2013).
- 17 [ISM] Illinois State Museum. 2002. “Native Americans: American Indian Tribes of Illinois.”
18 October 2, 2002. Available at
19 <http://www.museum.state.il.us/muslink/nat_amer/post/index.html> (accessed
20 5 February 2014).
- 21 [ISM] Illinois State Museum. 2014. “Illinois Inventory of Archaeological Sites.” Sites 11OG153,
22 11OG155, 11OG156, 11OG157, 11OG158. Available at (permission needed)
23 <<http://geoserver.dnr.illinois.gov/Arch/default.aspx>> (accessed 18 September 2013).
- 24 Karstensen KA, Shaver DK, Alexander RL, Over TM, Soong D. 2013. *Land Change in the*
25 *Central Corn Belt Plains Ecoregion and Hydrologic Consequences in Developed Areas –*
26 *1939–2000*. Reston, VA: U.S. Geological Survey. Open-File Report 2013-1157. 32 p. Available
27 at <<http://pubs.usgs.gov/of/2013/1157/pdf/ofr2013-1157.pdf>> (accessed 7 February 2014).
- 28 Kay RT, Rauman JR, Prinos ST (U.S. Geological Survey (USGS)), Yeskis DJ, Bolen WJ
29 (U.S. Environmental Protection Agency). 1997. *Geology, Hydrology, and Ground-Water Quality*
30 *at the Byron Superfund Site Near Byron, Illinois*. DeKalb, IL: U.S. Geological Survey.
31 Water-Resources Investigations Report 95-4240. 91 p. Available at
32 <http://il.water.usgs.gov/pubs/wrir95_4240.pdf> (accessed 16 December 2013).
- 33 King A. 2013. “2013 Rangewide Population Estimate for the Indiana Bat (*Myotis sodalis*) by
34 USFWS Region.” Bloomington, IN: U.S. Fish and Wildlife Service. August 26, 2013. 6 p.
35 Available at
36 <[http://www.fws.gov/midwest/Endangered/mammals/inba/pdf/2013inbaPopEstimate26Aug2013.](http://www.fws.gov/midwest/Endangered/mammals/inba/pdf/2013inbaPopEstimate26Aug2013.pdf)
37 [pdf](http://www.fws.gov/midwest/Endangered/mammals/inba/pdf/2013inbaPopEstimate26Aug2013.pdf)> (accessed 28 August 2013).
- 38 Knapp HV, Russell AM. 2004. *Rock River Basin Streamflow Assessment Model, Illinois State*
39 *Water Survey*. Champaign, IL: Illinois Department of Natural Resources. Contract
40 Report 2004-02. February 2004. 182 p. Available at
41 <<http://www.isws.illinois.edu/pubdoc/CR/ISWSCR2004-02.pdf>> (accessed 4 February 2014).
- 42 Leighton MM, Ekblaw GE, Horberg L. 1948. *Physiographic Divisions of Illinois*. Urbana, IL:
43 Illinois State Geological Survey. Report of Investigations No. 129. 26 p. Available at
44 <<https://archive.org/details/physiographicdiv129leiq>> (accessed 2 January 2014).

Affected Environment

- 1 Lewis DE (U.S. Nuclear Regulatory Commission (NRC)), Hagemeyer DA, McCormick YU (Oak
2 Ridge Associated Universities). 2013. *Occupational Radiation Exposure at Commercial Nuclear
3 Power Reactors and Other Facilities 2011: Forty-Fourth Annual Report*. Washington, DC: NRC.
4 NUREG-0713, Volume 33. April 2013. 191 p. ADAMS No. ML13095A191.
- 5 [MAE Center] Mid-America Earthquake Center. 2009. *Impact of New Madrid Seismic Zone
6 Earthquakes on the Central USA*. Urbana, IL: MAE Center. Report No. 09-03, Volume I.
7 October 2009. 153 p. Available at <[https://www.ideals.illinois.edu/bitstream/handle/2142/14810/
8 ImpactofNewMadridSeismicZoneEarthquakeso%20theCentral%20USAVol1.pdf?sequence=3](https://www.ideals.illinois.edu/bitstream/handle/2142/14810/ImpactofNewMadridSeismicZoneEarthquakeso%20theCentral%20USAVol1.pdf?sequence=3)>
9 (accessed 7 October 2013).
- 10 [MBTA] Migratory Bird Treaty Act of 1918, as amended, 16 U.S.C. §§ 703–712.
- 11 [MDNR] Minnesota Department of Natural Resources. 2013. “Species profile: *Lespedeza
12 leptostachya*.” Available at <[http://www.dnr.state.mn.us/rsg/
13 profile.html?action=elementDetail&selectedElement=PDFAB27090](http://www.dnr.state.mn.us/rsg/profile.html?action=elementDetail&selectedElement=PDFAB27090)> (accessed
14 30 October 2013).
- 15 [MODNR] Missouri Department of Natural Resources. 2013. *The New Madrid Seismic Zone,
16 Division of Geology and Land Survey Fact Sheet Number 26*. January 2013. Available at
17 <<http://www.dnr.mo.gov/pubs/pub2465.pdf>> (accessed 7 October 2013).
- 18 Moore BC, Martinez E, Gay JM, Rice DH. 2003. Survival of *Salmonella enterica* in freshwater
19 and sediments and transmission by the aquatic midge *Chironomus tentans* (Chironomidae:
20 Diptera). *Applied and Environmental Microbiology* 69(8):4556–4560. Available at
21 <<http://www.ncbi.nlm.nih.gov/pmc/articles/PMC169145/>> (accessed 23 October 2013).
- 22 [MMSHT] Michigan Mine Safety & Health Training. 2008. “Noise Basics.” January 31, 2008.
23 Available at <http://www.mine-safety.mtu.edu/noise/03noise_basics.htm> (accessed
24 5 December 2013).
- 25 [MSA] Magnuson–Stevens Fishery Conservation and Management Reauthorization Act of 2006,
26 as amended. 16 U.S.C. §§ 1801–1884.
- 27 [NASS] U.S. Department of Agriculture, National Agricultural Statistics Service. 2012a. “2007
28 Census of Agriculture,” Volume 1, Chapter 2, Table 7. 2007 Census of Agriculture, Volume 1,
29 Chapter 2, County Level Data for Illinois. Table 7: “Hired Farm Labor—Workers and Payroll:
30 2007.” March 29, 2012. Available at
31 <http://www.agcensus.usda.gov/Publications/2007/Full_Report/Census_by_State/> (accessed
32 January 2014).
- 33 [NASS] U.S. Department of Agriculture, National Agricultural Statistics Service. 2012b.
34 “CropScape – Cropland Data Layer Program.” 2012 CDL Statistics for Ogle, Illinois. Available at
35 <<http://nassgeodata.gmu.edu/CropScape/>> (accessed January 2014).
- 36 NatureServe. 2013. “Comprehensive Report Species—Eastern Prairie White-fringed Orchid
37 (*Platanthera leucophaea*).” Available at <[http://www.natureserve.org/explorer/servlet/
38 NatureServe?searchName=Platanthera+leucophaea](http://www.natureserve.org/explorer/servlet/NatureServe?searchName=Platanthera+leucophaea)> (accessed 30 October 2013).
- 39 [NCDC] National Climatic Data Center. 2013a. *Climate of Illinois*. Asheville, NC: NCDC. 5 p.
40 Available at <http://hurricane.ncdc.noaa.gov/climatenormals/clim60/states/Clim_IL_01.pdf>
41 (accessed 28 August 2014).
- 42 [NCDC] National Climatic Data Center. 2013b. *2012 Local Climatological Data Annual Summary
43 With Comparative Data, Rockford, Illinois (KRFD)*. Asheville, NC: NCDC. 8 p. Available at
44 <<http://www7.ncdc.noaa.gov/IPS/lcd/lcd.html>> (accessed 10 July 2013).

- 1 [NCDC] National Climatic Data Center. 2013d. "Storm Events Database." Available at
2 <<http://www.ncdc.noaa.gov/stormevents/>> (accessed 26 November 2013).
- 3 [NCES] National Center for Education Statistics. 2013. "College Navigator." College and
4 university student population within 50 miles of ZIP code 61010. Released August 2013.
5 Available at <<http://nces.ed.gov/collegenavigator/default.aspx>> (accessed February 2014).
- 6 [NEI] Nuclear Energy Institute. 2007. *Industry Ground Water Protection Initiative – Final*
7 *Guidance Document*. Washington, DC: NEI. NEI 07-07. August 2007. 27 p. ADAMS
8 No. ML072600295.
- 9 Neusius SW, Gross GT. 2007. *Seeking Our Past: An Introduction to North American*
10 *Archaeology*. New York, NY: Oxford University Press, Inc. 720 p.
- 11 [NPS] National Park Service. 2014a. "National Register of Historic Places, NPS Focus: Ogle
12 County, Illinois." February 5, 2014. Available at
13 <<http://nrhp.focus.nps.gov/natreghome.do?searchtype=natreghome>> (accessed
14 5 February 2014).
- 15 [NPS] National Park Service. 2014b. "Illinois NHLs: National Historic Landmarks Program."
16 May 24, 2013. Available at <<http://www.nps.gov/nhl/find/statelists/il.htm>> (accessed
17 14 July 2014).
- 18 [NRC] U.S. Nuclear Regulatory Commission. 1982. *Final Environmental Statement Related to*
19 *the Operation of Byron Station, Units 1 and 2*. Washington, DC: NRC. NUREG–0848.
20 April 30, 1982. 296 p. ADAMS No. ML13269A184.
- 21 [NRC] U.S. Nuclear Regulatory Commission. 2006. *Environmental Impact Statement for an*
22 *Early Site Permit (ESP) at the Exelon ESP Site*. Washington, DC: NRC. NUREG–1815,
23 Volume 1. July 2006. 504 p. ADAMS No. ML061930264.
- 24 [NRC] U.S. Nuclear Regulatory Commission. 2013a. *Generic Environmental Impact Statement*
25 *for License Renewal of Nuclear Plants*. Revision 1. Washington, DC: NRC. NUREG-1437,
26 Volumes 1, 2, and 3. June 19, 2013. 1,535 p. ADAMS No. ML13107A023.
- 27 [NRC] U.S. Nuclear Regulatory Commission. 2013b. Letter from M. Wong, Chief, to T. Melius,
28 Midwest Regional Director, U.S. Fish and Wildlife Service. Subject: Request for concurrence
29 with list of Federally listed species and habitats for the proposed Byron Station, Units 1 and 2,
30 license renewal. August 8, 2013. ADAMS No. ML13176A377.
- 31 [NRC] U.S. Nuclear Regulatory Commission. 2013c. E-mail from B. Grange, Biologist, to
32 J. Duyvejonck, U.S. Fish and Wildlife Service. Subject: Byron Illinois License Renewal.
33 September 3, 2013. ADAMS No. ML13246A386.
- 34 [NRC] U.S. Nuclear Regulatory Commission. 2014a. *Braidwood Station, Units 1 and 2, and*
35 *Byron Station, Units 1 and 2, Issuance of Amendments Regarding Measurement Uncertainty*
36 *Recapture Power Uprate*. February 7, 2014. ADAMS No. ML13281A000.
- 37 [NRC] U.S. Nuclear Regulatory Commission. 2014b. Letter from C. Miller, Director, to A. Keller,
38 Manager, Permit Section, Illinois Environmental Protection Agency: Illinois Environmental
39 Protection Agency Letters on Clean Water Act Section 401 Certification and the U.S. Nuclear
40 Regulatory Commission Review of the Byron and Braidwood Stations License Renewal
41 Application. November 5, 2014. ADAMS No. ML14220A382.
- 42 [NWCC] National Wind Coordinating Committee. 2002. *Permitting of Wind Energy Facilities: A*
43 *Handbook*. Washington, DC: NWCC. August 2002. 58 p. Available at
44 <<http://nationalwind.org/wp-content/uploads/assets/publications/permitting2002.pdf>> (accessed
45 9 July 2014).

Affected Environment

- 1 Ogle County. 2012. *Ogle County, Illinois, Amendatory Comprehensive Plan "2012 Update."*
2 Adopted October 16, 2012. 203 p. Available at
3 <<http://oglecounty.org/departments/planning-zoning/comprehensive-plan>> (accessed
4 7 February 2014).
- 5 Ogle County. 2013. "Laws & Regulations." Available at
6 <<http://oglecounty.org/departments/solid-waste-management/laws-regs>> (accessed
7 8 December 2013).
- 8 Ogle County. 2014. "History." Available at <<http://oglecounty.org/county-2/history/>> (accessed
9 5 February 2014).
- 10 [OSH Act] Occupational Safety and Health Act of 1970, as amended. 29 U.S.C. § 651 et seq.
- 11 Pauketat TR. 1993. *A Tour Guide to the Prehistory and Native Cultures of Southwestern Illinois*
12 *and the Greater St. Louis Area*. Illinois Archaeology Educational Series Number 2.
13 Springfield, IL: Illinois Historic Preservation Agency. January 1993. 60 p. Available at
14 <<https://archive.org/download/tourguidetoprehi00pauk/tourguidetoprehi00pauk.pdf>>.
- 15 Pearson WE. 2003. *Legionella 2003: An Update and Statement by the Association of Water*
16 *Technologies (AWT)*. Rockville, MD: AWT. June 2003. 33 p. Available at
17 <<http://awt.org/IndustryResources/Legionella03.pdf>> (accessed 21 October 2013).
- 18 [PPA] Pollution Prevention Act of 1990. 42 U.S.C. § 13101.
- 19 Pruitt L, TeWinkel L, editors. 2007. *Indiana Bat (Myotis sodalis) Draft Recovery Plan*. First
20 Revision. Fort Snelling, MN: U.S. Fish and Wildlife Service. April 2007. 258 p. Available at
21 <http://ecos.fws.gov/docs/recovery_plan/070416.pdf> (accessed 26 September 2013).
- 22 [RCRA] Resource Conservation and Recovery Act of 1976, as amended. 42 U.S.C. § 6901
23 et seq.
- 24 Rivers and Harbors Appropriation Act of 1899. 33 U.S.C. § 403 Section 10.
- 25 Sasman RT, Baker WH. 1966. *Ground-Water Pumpage in Northwestern Illinois through 1963*.
26 Urbana, IL: Illinois State Water Survey. Report of Investigation 52. 1966. 39 p. Available at
27 <<http://www.isws.illinois.edu/pubdoc/RI/ISWSRI-52.pdf>> (accessed 30 January 2014).
- 28 [SFU] Simon Fraser University. 1999. "Decibel." Available at
29 <<http://www.sfu.ca/sonic-studio/handbook/Decibel.html>> (accessed 5 September 2013).
- 30 [Sheaffer] Sheaffer Landscape Architects. 2003. *The Greenways & Trails Plan for Ogle County,*
31 *Illinois*. Dixon, IL: Sheaffer. June 2003. 50 p. Available at
32 <http://www.oglecounty.org/wp-content/uploads/2013/04/GT-Plan_consolidated.pdf> (accessed
33 28 August 2014).
- 34 Sinclair RA. 1996. *Rock River Basin: Historical Background, IEPA Targeted Watersheds, and*
35 *Resource-Rich Areas*. Champaign, IL: Illinois State Water Survey. Miscellaneous
36 Publication 174. April 1996. 27 p. Available at
37 <<http://www.isws.illinois.edu/pubdoc/MP/ISWSMP-174.pdf>> (accessed 12 July 2013).
- 38 Stevens AR, Tyndall RL, Coutant CC, Willaert E. 1977. Isolation of the etiological agent of
39 primary amoebic meningoencephalitis from artificially heated waters. *Applied and Environmental*
40 *Microbiology* 34(6):701–705. Available at <<http://aem.asm.org/content/34/6/701.full.pdf+html>>
41 (accessed 23 October 2013).
- 42 Todar K. 2004. *Todar's Online Textbook of Bacteriology*. University of Wisconsin, Department of
43 Bacteriology. Available at <<http://textbookofbacteriology.net/index.html>> (accessed
44 23 October 2013).

- 1 Smith W, Sather N (Minnesota Department of Natural Resources), Harrison B (U.S. Fish and
2 Wildlife Service (FWS), Martin M (Wisconsin Department of Natural Resources), Roosa D (Iowa
3 Department of Natural Resources), Schwegman J (Illinois Department of Conservation). 1988.
4 *Lespedeza leptostachya Recovery Plan*. Twin Cities, MN: FWS. October 1988. 47 p. Available
5 at <http://ecos.fws.gov/docs/recovery_plan/881006.pdf> (accessed 29 October 2013).
- 6 Starke D, Cox Z. 2011. *Byron Generating Station Wildlife Management Plan*. 20 p. Available in:
7 "Byron, Units 1 and 2, response to NRC request for additional information, dated
8 November 21, 2013, related to the Byron and Braidwood Stations, Units 1 and 2 license renewal
9 application, Byron Station applicant's Environmental Report." ADAMS No. ML14007A083
10 (Part 2 of 15).
- 11 Suloway L, Joselyn M, Brown PW. 1996. *Inventory of Resource Rich Areas in Illinois: An*
12 *Evaluation of Ecological Resources*. Champaign, IL: Illinois Natural History Survey.
13 IDNR/EEA-96/08 3M/1996. Available at <<http://www.inhs.illinois.edu/research/rra>> (accessed
14 12 July 2013).
- 15 [Teledyne] Teledyne Brown Engineering Environmental Services. 2008. *Byron Nuclear*
16 *Generating Station, Units 1 and 2, Annual Radiological Environmental Operating Report,*
17 *1 January Through 31 December 2007*. Byron, IL: Exelon Nuclear. May 15, 2008. 214 p.
18 ADAMS No. ML081370069.
- 19 [Teledyne] Teledyne Brown Engineering Environmental Services. 2009. *Byron Nuclear*
20 *Generating Station, Units 1 and 2, Annual Radiological Environmental Operating Report,*
21 *1 January Through 31 December 2008*. Byron, IL: Exelon Nuclear. 206 p. ADAMS
22 No. ML091270070.
- 23 [Teledyne] Teledyne Brown Engineering Environmental Services. 2010. *Byron Nuclear*
24 *Generating Station, Units 1 and 2, 2009 Annual Radiological Environmental Operating Report,*
25 *1 January Through 31 December 2009*. Byron, IL: Exelon Nuclear. May 2010. 207 p. ADAMS
26 No. ML101390394.
- 27 [Teledyne] Teledyne Brown Engineering Environmental Services. 2011. *Byron Nuclear*
28 *Generating Station, Units 1 and 2, Annual Radiological Environmental Operating Report,*
29 *1 January Through 31 December 2010*. Byron, IL: Exelon Nuclear. May 2011. 209 p. ADAMS
30 No. ML11137A061.
- 31 [Teledyne] Teledyne Brown Engineering Environmental Services. 2012. *Byron Nuclear*
32 *Generating Station, Units 1 and 2, Annual Radiological Environmental Operating Report,*
33 *1 January Through 31 December 2011*. Byron, IL: Exelon Nuclear. May 2012. 201 p. ADAMS
34 No. ML12136A477.
- 35 [Teledyne] Teledyne Brown Engineering Environmental Services. 2013. *Byron Nuclear*
36 *Generating Station, Units 1 and 2, Annual Radiological Environmental Operating Report,*
37 *1 January Through 31 December 2012*. Byron, IL: Exelon Generation. May 2013. 207 p.
38 ADAMS No. ML13168A066.
- 39 [USACE] United States Army Corps of Engineers. 2006. *Illinois River Basin Restoration*
40 *Comprehensive Plan With Integrated Environmental Assessment, Appendix D: Geomorphology,*
41 *Sediment Delivery, Sediment Removal and Beneficial Use*. 27 p. Available at
42 <[http://www.mvr.usace.army.mil/Portals/48/docs/Environmental/ILRBR/CompPlan/](http://www.mvr.usace.army.mil/Portals/48/docs/Environmental/ILRBR/CompPlan/IRBR_AppendixD.pdf)
43 [IRBR_AppendixD.pdf](http://www.mvr.usace.army.mil/Portals/48/docs/Environmental/ILRBR/CompPlan/IRBR_AppendixD.pdf)> (accessed 3 September 2013).

Affected Environment

- 1 [USCB] U.S. Census Bureau. 2014a. “American FactFinder, 2008–2012, 5-Year Estimate,
2 American Community Survey, Table DP03 – Selected Economic Characteristics.” and
3 “American FactFinder, 2010 Census, Table QT-P4 – Race, Combinations of Two Races, and
4 Not Hispanic or Latino.” Available at
5 <<http://factfinder2.census.gov/faces/nav/jsf/pages/index.xhtml>> (accessed January 2014).
- 6 [USCB] U.S. Census Bureau. 2014b. “American FactFinder, Annual Estimates of the Resident
7 Population: April 1, 2010 to July 1, 2012, 2012 Population Estimates” for Lee, Ogle, and
8 Winnebago Counties and Rockford, Illinois. Available at
9 <<http://factfinder2.census.gov/faces/nav/jsf/pages/index.xhtml>> (accessed January 2014).
- 10 [USCB] U.S. Census Bureau. 2014c. “American FactFinder, 2010 Census, Table QT-P4 –
11 Race, Combinations of Two Races, and Not Hispanic or Latino” for Lee, Ogle, and Winnebago
12 Counties, Illinois. Available at <<http://factfinder2.census.gov/faces/nav/jsf/pages/index.xhtml>>
13 (accessed January 2014).
- 14 [USCB] U.S. Census Bureau. 2014d. “American FactFinder, 2008–2012, 5-Year Estimate,
15 American Community Survey, Table B25004 – Vacancy Status” for counties within 50-mile
16 radius of Byron. Available at <<http://factfinder2.census.gov/faces/nav/jsf/pages/index.xhtml>>
17 (accessed February 2014).
- 18 [USCB] U.S. Census Bureau. 2014e. “American FactFinder, 2008–2012, American Community
19 Survey 5-Year Estimates, Selected Housing Characteristics” for Lee, Ogle, and Winnebago
20 Counties, Illinois. Available at <<http://factfinder2.census.gov/faces/nav/jsf/pages/index.xhtml>>
21 (accessed February 2014).
- 22 [USCB] U.S. Census Bureau. 2014f. “American FactFinder, 2008–2013, 2008–2013. Tables
23 B03002 – Hispanic or Latino Origin by Race and B17021 – Poverty Status of Individuals in the
24 Past 12 Months” for 2013 for census blocks within 50-mile radius of Byron. Available at
25 <http://www2.census.gov/acs2012_5yr/> (accessed May 2014).
- 26 [USDA] U.S. Department of Agriculture. 2013. “Web Soil Survey.” Custom Soil Resource Report
27 for Ogle County, Illinois. Available at
28 <<http://websoilsurvey.nrcs.usda.gov/app/WebSoilSurvey.aspx>> (accessed 19 June 2013).
- 29 [USFS] U.S. Forest Service. 1996. *Ecological Subregions of the United States*. Chapter 28,
30 Prairie parkland (temperate). Available at
31 <<http://www.fs.fed.us/land/pubs/ecoregions/ch28.html#251G>> (accessed 7 February 2014).
- 32 [USGS] U.S. Geological Survey. 2009. *Earthquake Hazard in the New Madrid Seismic Zone
33 Remains a Concern*. Denver, CO: USGS. Fact Sheet 2009-3071. August 2009. 2 p. Available at
34 <<http://pubs.usgs.gov/fs/2009/3071/pdf/FS09-3071.pdf>> (accessed 5 September 2013).
- 35 [USGS] U.S. Geological Survey. 2013a. “Earthquake History of Illinois.” Available at
36 <<http://earthquake.usgs.gov/earthquakes/states/illinois/history.php>> (accessed
37 4 September 2013).
- 38 [USGS] U.S. Geological Survey. 2013b. “Historic Earthquakes: Largest Earthquake in Illinois.”
39 November 1, 2012. Available at
40 <http://earthquake.usgs.gov/earthquakes/states/events/1968_11_09.php> (accessed
41 4 September 2013).
- 42 [USGS] U.S. Geological Survey. 2013c. “Historic Earthquakes: Isoleismal Map of 1968
43 earthquake.” Available at
44 <http://earthquake.usgs.gov/earthquakes/states/events/1968_11_09_iso.php> (accessed
45 4 September 2013).

- 1 [USGS] U.S. Geological Survey. 2013d. *Water-Resources Data for the United States, Water*
2 *Year 2012*. Water-Data Report WDR-US-2012, site 05440700. 7 p. Available at
3 <<http://wdr.water.usgs.gov/wy2012/pdfs/05440700.2012.pdf>> (accessed 2 February 2014).
- 4 [USGS] U.S. Geological Survey. 2013e. *Water-Resources Data for the United States, Water*
5 *Year 2012*. Water-Data Report WDR-US-2012, site 05443500. 5 p. Available at
6 <<http://wdr.water.usgs.gov/wy2012/pdfs/05443500.2012.pdf>> (accessed 2 February 2014).
- 7 Visocky AP, Sherrill MG, Cartwright K. 1985. *Geology, Hydrology, and Water Quality of the*
8 *Cambrian and Ordovician Systems in Northern Illinois*. Champaign, IL: Illinois State Geological
9 Survey and Illinois State Water Survey. Cooperative Groundwater Report 10. 144 p. Available at
10 <<http://isws.illinois.edu/pubdoc/COOP/ISWSCOOP-10.pdf>> (accessed 16 December 2013).
- 11 Watrous KS, Donovan TM, Mickey RM, Darling SR, Hicks AC, Von Oettingen SL. 2006.
12 Predicting minimum habitat characteristics for the Indiana bat in the Champlain Valley. *The*
13 *Journal of Wildlife Management* 70(5):1228-1237. Available at
14 <[http://www.uvm.edu/rsenr/vtcfwru/Donovan/](http://www.uvm.edu/rsenr/vtcfwru/Donovan/Watrous%20et%20al.%202006%20Publication.pdf)
15 [Watrous%20et%20al.%202006%20Publication.pdf](http://www.uvm.edu/rsenr/vtcfwru/Donovan/Watrous%20et%20al.%202006%20Publication.pdf)>.
- 16 Wetzel MJ, Ceas PA, Carney DA, Page LM. 1988. Survey of Rock River Fishes in the Vicinity of
17 Castle Rock State Park, Ogle County, Illinois: Illinois Route 2-FAP 742 and Ridge Road–Pines
18 Road Alternate. Champaign, IL: Illinois Natural History Survey. Section of Faunistic Surveys and
19 Insect Identification Technical Report 1988 (4). April 15, 1988. 26 p. Available at
20 <<https://ideals.illinois.edu/handle/2142/10535>> (accessed 18 October 2013).
- 21 [WHC] Wildlife Habitat Council. 2014. “Wildlife at Work—Wildlife Habitat Council promotes and
22 certifies habitat conservation and management on working lands.” Available at
23 <<http://www.wildlifehc.org/programs/wildlife-at-work/>> (accessed 7 February 2014).
- 24 Whitaker JO Jr, Brack V Jr. Distribution and summer ecology in Indiana. p 48–54. In: Kurta A,
25 Kennedy J, editors. 2002. *The Indiana Bat: Biology and Management of an Endangered*
26 *Species*. Austin, TX: Bat Conservation International. 253 p. Available at
27 <<http://www.environmentalsi.com/DOCS/PDFs/045.pdf>>.
- 28 Wiken E, Jiménez Nava F, Griffith G. 2011. *North American Terrestrial Ecoregions—Level III*.
29 Montréal, Canada: Commission for Environmental Cooperation. May 2011. 149 p. Available at
30 <[ftp://ftp.epa.gov/wed/ecoregions/pubs/](ftp://ftp.epa.gov/wed/ecoregions/pubs/NA_TerrestrialEcoregionsLevel3_Final-2june11_CEC.pdf)
31 [NA_TerrestrialEcoregionsLevel3_Final-2june11_CEC.pdf](ftp://ftp.epa.gov/wed/ecoregions/pubs/NA_TerrestrialEcoregionsLevel3_Final-2june11_CEC.pdf)> (accessed 7 February 2011).

1 **4.0 ENVIRONMENTAL CONSEQUENCES AND MITIGATING ACTIONS**

2 **4.1 Introduction**

3 In this chapter, the U.S. Nuclear Regulatory Commission (NRC) evaluates the environmental
4 consequences of the proposed action (i.e., license renewal of Byron Station, Units 1 and 2
5 (Byron)), including the (1) impacts associated with continued operations similar to those that
6 have occurred during the current license terms; (2) impacts of various alternatives to the
7 proposed action; (3) impacts from the termination of nuclear power plant operations and
8 decommissioning after the license renewal term (with emphasis on the incremental effect
9 caused by an additional 20 years of operation); (4) impacts associated with the uranium fuel
10 cycle; (5) impacts of postulated accidents (design-basis accidents (DBAs) and severe
11 accidents); (6) cumulative impacts of the proposed action; and (7) resource commitments
12 associated with the proposed action, including unavoidable adverse impacts, the relationship
13 between short-term use and long-term productivity, and irreversible and irretrievable
14 commitment of resources. The NRC also considers new and potentially significant information
15 on environmental issues related to the impacts of operation during the renewal term.

16 NUREG-1437, *Generic Environmental Impact Statement (GEIS) for License Renewal of Nuclear*
17 *Plants* (NRC 1996, 1999, 2013a) identifies 78 issues to be evaluated in the license renewal
18 environmental review process. This supplemental environmental impact statement (SEIS)
19 supplements the information provided in the GEIS. Generic issues (Category 1) rely on the
20 analysis presented in the GEIS, unless otherwise noted. Applicable site-specific issues
21 (Category 2) have been analyzed for Byron and assigned a significance level of SMALL,
22 MODERATE, or LARGE. Section 1.4 of this SEIS provides an explanation of the criteria for
23 Category 1 and Category 2 issues, as well as the definitions of SMALL, MODERATE, and
24 LARGE. Resource-specific impact significance level definitions are provided where applicable.

25 **4.2 Land Use and Visual Resources**

26 This section describes the potential impacts of the proposed action (license renewal) and
27 alternatives to the proposed action on land use and visual resources.

28 **4.2.1 Proposed Action**

29 Section 3.2 of this SEIS describes land use and visual resources in the vicinity of the Byron site.
30 The four generic (Category 1) issues that apply to land use and visual resources during the
31 proposed license renewal period appear in Table 4–1. The GEIS (NRC 2013a) discusses these
32 issues in Section 4.2.1. The GEIS does not identify any site-specific (Category 2) land use or
33 visual resource issues.

34 The NRC staff did not identify any new and significant information related to the generic
35 (Category 1) issues listed above during the review of the applicant's Environmental Report (ER)
36 (Exelon 2013a), the site audit, or the scoping process. Therefore, the NRC expects no impacts
37 associated with these issues beyond those discussed in the GEIS. The GEIS concludes that
38 the impact level for each of these issues is SMALL.

1

Table 4–1. Land Use and Visual Resources Issues

Issue	GEIS Section	Category
Land Use		
Onsite land use	4.2.1.1	1
Offsite land use	4.2.1.1	1
Offsite land use in transmission line right-of-ways (ROWs) ^(a)	4.2.1.2	1
Visual Resources		
Aesthetic impacts	4.2.1.2	1

^(a)This issue applies only to the inscope portion of electric power transmission lines, which are defined as transmission lines that connect the nuclear power plant to the substation where electricity is fed into the regional power distribution system and transmission lines that supply power to the nuclear plant from the grid.

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51; NRC 2013a

2 **4.2.2 No-Action Alternative**

3 **4.2.2.1 Land Use**

4 If Byron were to shut down, the impacts to land use would remain similar to those during
 5 operations until the plant is fully decommissioned. Temporary buildings and staging or laydown
 6 areas may be required during large component and structure dismantling. Byron is likely to
 7 have sufficient space within previously disturbed areas for these needs, and therefore, no
 8 additional land would need to be disturbed that would result in changes to current land uses. In
 9 NUREG–0586, *Generic Environmental Impact Statement on Decommissioning of Nuclear*
 10 *Facilities, Supplement 1*, NRC (2002) concludes generically that land use impact during
 11 decommissioning activities would be SMALL. The GEIS (NRC 2013a) notes that land use
 12 impacts could occur in other areas beyond the immediate nuclear plant site as a result of the
 13 no-action alternative if new power plants are needed to replace lost capacity. The NRC staff did
 14 not identify any impacts that may result at Byron beyond those discussed in NUREG–0586.
 15 Thus, the NRC staff concludes that the impacts of the no-action alternative on land use during
 16 the proposed license renewal term would be SMALL.

17 **4.2.2.2 Visual Resources**

18 If Byron were to shut down, visual resources impacts would remain similar to those experienced
 19 during operations until the site is fully decommissioned. The cooling towers, which create the
 20 largest visual impact, may eventually be dismantled, which would reduce the already SMALL
 21 impacts to visual resources that would occur during the proposed license renewal term. Thus,
 22 the NRC staff concludes that the impacts of the no-action alternative on visual resources would
 23 be SMALL.

24 **4.2.3 New Nuclear Alternative**

25 **4.2.3.1 Land Use**

26 The new nuclear alternative assumes that the new facility would be built at an existing nuclear
 27 or retired coal plant site within the region of influence (ROI) but outside of Illinois. Construction
 28 of the new nuclear plant would require an estimated 324 acres (ac) (131 hectares (ha)) for
 29 permanent buildings and facilities and an additional 31 ac (12.5 ha) for temporary facilities and

1 laydown areas. The NRC staff assumes that this alternative would use existing onsite
2 structures and previously disturbed areas to the extent practicable to minimize development of
3 undisturbed land. Thus, this alternative would not significantly affect existing land uses. Given
4 the land requirements, it is expected that some undisturbed lands would be affected, which
5 would result in the conversion of natural areas to industrial areas. No additional land use
6 changes would result from operation of the nuclear facility. The NRC staff concludes that the
7 impacts to land use from construction and operation of a new nuclear alternative would be
8 SMALL.

9 4.2.3.2 *Visual Resources*

10 Because the facility would be located on an existing site, visual resources impacts of most new
11 buildings and infrastructure would be minimal. The construction of natural draft cooling towers
12 would be the largest visual impact because both the towers themselves and the plume could be
13 visible from a distance. The magnitude of this impact would vary based on the topography of
14 the chosen site and surrounding area. The NRC staff concludes that the impacts to visual
15 resources from construction and operation of a new nuclear alternative would be SMALL to
16 MODERATE.

17 4.2.4 **Integrated Gasification Combined Cycle (IGCC) Alternative**

18 4.2.4.1 *Land Use*

19 The IGCC alternative assumes that the new facility would be built at an existing
20 energy-producing site or a retired coal plant site in Illinois or another state within the ROI. The
21 facility would require 2,000 ac (809 ha) of land to construct the facility. The NRC staff assumes
22 that this alternative would use existing onsite structures and previously disturbed areas to the
23 extent practicable to minimize new development in undisturbed areas. However, because the
24 footprint of the facility would be large, it is likely that construction would require clearing of lands
25 that are currently in a different land use, such as agricultural, forested, or other natural areas.
26 The impacts of this would vary widely based on the specific site selection and land uses that
27 would be lost due to construction. No additional land use changes would result from operation
28 of the IGCC facility. The NRC staff concludes that the impacts to land use from construction
29 and operations of an IGCC alternative would be SMALL to MODERATE, primarily due to the
30 potential for conversion of land to industrial use during construction.

31 4.2.4.2 *Visual Resources*

32 Because the facility would be located on an existing site, visual resources impacts would be
33 minimal. The mechanical draft cooling towers would likely not be significantly taller than other
34 buildings on the site. However, the plume created from operation of the towers could create
35 noticeable visual impacts depending on the topography of the chosen site and surrounding
36 area. The NRC staff concludes that the impacts to visual resources from construction and
37 operation of an IGCC alternative would be SMALL to MODERATE.

38 4.2.5 **Natural Gas Combined-Cycle (NGCC) Alternative**

39 4.2.5.1 *Land Use*

40 The NGCC alternative assumes that the facility would be built at an existing energy-producing
41 site or a retired coal plant site in Illinois or another state within the ROI. The facility would
42 require 94 ac (38 ha) of land for the plant and associated pipelines. Because the footprint of the
43 facility would be relatively small, the entire construction footprint could likely be sited in
44 already-developed areas of the site, which would minimize land use changes. No additional

Environmental Consequences and Mitigating Actions

1 land use changes would result from operation of the NGCC facility. The NRC staff concludes
2 that the impacts to land use from construction and operation of an NGCC alternative would be
3 SMALL.

4 4.2.5.2 *Visual Resources*

5 Because the facility would be located on an existing site, visual resources impacts would be
6 minimal. The mechanical draft cooling towers would likely not be significantly taller than other
7 buildings on the site. However, the plume created from operation of the towers could create
8 noticeable visual impacts depending on the topography of the chosen site and surrounding
9 area. The NRC staff concludes that the impacts to land use and visual resources from
10 construction and operation of an NGCC alternative would be SMALL to MODERATE.

11 4.2.6 **Combination Alternative (NGCC, Wind, Solar)**

12 4.2.6.1 *Land Use*

13 The NGCC component of this alternative would require the same amount of land as the NGCC
14 alternative (94 ac (38 ha)), but the NGCC component would likely make better use of existing
15 infrastructure because it would be sited at an existing power plant in Illinois or another state
16 within the ROI and could use buildings and structures that are already in place and operational
17 for the existing facility. Land use impacts would be similar to or less than those described in
18 Section 4.2.5 for the NGCC alternative and would, therefore, be SMALL.

19 The wind component of the combination alternative would require 3,376 ac (1,366 ha) to
20 10,127 ac (4,098 ha) at sites across the ROI. However, the majority of this land would only be
21 temporarily disturbed during construction. Permanently disturbed land would hold the wind
22 turbines, access roads, and transmission lines. Land used for equipment laydown and turbine
23 component assembly and erection could be returned to its original state. Given the large
24 footprint of the wind component, land use could be affected. However, some land uses, such as
25 agriculture, could continue once the wind turbines are operational. Land use impacts for the
26 wind component would range from SMALL to MODERATE depending on the amount and types
27 of land that would be affected by wind turbine construction.

28 The solar component would require 6,749 ac (2,731 ha) of land across the ROI. The majority of
29 solar installations could be installed on building roofs at existing residential, commercial, or
30 industrial sites or at larger standalone solar facilities, and thus, it is possible that little land would
31 be required for construction. However, the exact magnitude of impacts on land use would
32 depend on the amount of land that is required to be converted for construction of solar
33 installations. Unlike wind power, solar-powered installations often cannot be colocated with
34 existing land uses (such as in a crop-producing agricultural field). The impacts of the solar
35 component of this alternative on land use would range from SMALL to MODERATE depending
36 on the amount and types of land that would be affected by construction of the solar installations.

37 The NRC staff concludes that the impacts of the combination alternative on land use would be
38 SMALL to MODERATE. This range is primarily the result of the variability in land required for
39 the wind and solar components of the alternative.

40 4.2.6.2 *Visual Resources*

41 Visual resources impacts for the NGCC component of this alternative would be similar to or less
42 than those described in Section 4.2.5 for the NGCC alternative and would, therefore, be
43 SMALL. Visual resources would be significantly affected by construction of the wind
44 component. Although specific effects would vary based on the topography and remoteness of
45 the wind turbine locations, the visual impact of wind energy is often one of the most significant

1 impacts and could range from MODERATE to LARGE. The visual impacts of the solar
2 component would also vary based on the topography of the area but are expected to be minimal
3 because individual solar installations are not tall or expansive, and many of the installations
4 could be constructed on building roofs at existing residential, commercial, or industrial sites.
5 Larger standalone solar facilities could have a greater visual impact depending on the location,
6 but the staff finds that the impacts of the solar component would likely be SMALL overall.
7 Overall, the NRC concludes that the impacts of the combination alternative on visual resources
8 would be SMALL to LARGE.

9 **4.2.7 Purchased Power**

10 *4.2.7.1 Land Use*

11 The purchased power alternative would have wide-ranging impacts that are hard to specifically
12 assess because this alternative could include a mixture of coal, natural gas, nuclear, and wind
13 across many different sites in the ROI. This alternative would likely have little to no construction
14 impacts because it would include power from already-existing power generating facilities. The
15 construction of additional transmission lines could affect land uses if the lines require the
16 clearing of new transmission line corridors. The types of operational impacts would be similar to
17 the effects discussed in the preceding alternative sections. This alternative would be more likely
18 to intensify already-existing effects at power generating facilities than create wholly new effects
19 on land use. Existing facilities would likely have best management practices (BMPs) and other
20 procedures in place to ensure that effects to the environment during operations are minimized.
21 The NRC staff concludes that the impacts on land use from the purchased power alternative
22 would be SMALL.

23 *4.2.7.2 Visual Resources*

24 The purchased power alternative would not result in the construction of any buildings or facilities
25 or any other changes to existing visual resources. Thus, the NRC staff concludes that the
26 purchased power alternative would have no impact on visual resources, and as such, it would
27 be SMALL.

28 **4.3 Air Quality and Noise**

29 This section describes the potential impacts of the proposed action (license renewal) and
30 alternatives to the proposed action on air quality and noise conditions.

31 **4.3.1 Proposed Action**

32 *4.3.1.1 Air Quality*

33 Section 3.3 describes the meteorological, air quality, and noise conditions in the vicinity of Byron
34 Station. Part 51 of Title 10 of the *Code of Federal Regulations* (CFR), Subpart A, Appendix B,
35 Table B-1 lists a summary of findings on National Environmental Policy Act (NEPA) issues for
36 license renewal of nuclear power plants. Two Category 1 air quality issues are applicable to
37 Byron Station, “air quality impacts (all plants)” and “air quality effects of transmission lines” (see
38 Table 4–2). There are no Category 2 issues for air quality. The Category 1 issue “air quality
39 effects of transmission lines” considers the production of ozone and oxides of nitrogen; the
40 GEIS found that minute and insignificant amounts of ozone and nitrogen oxides are generated
41 during transmission. The Category 1 issue “air quality impacts (all plants)” considers the air
42 quality impacts from continued operation and refurbishment associated with license renewal.
43 The GEIS concludes that the impact of refurbishment activities on air quality during the license

Environmental Consequences and Mitigating Actions

1 renewal term would be SMALL for most plants, but could be cause for concern at plants located
2 in or near air quality nonattainment or maintenance areas (NRC 2013a).

3 **Table 4–2. Air Quality and Noise**

Issue	GEIS Section	Category
Air quality impacts (all plants)	4.3.1.1	1
Air quality effects of transmission lines	4.3.1.1	1
Noise impacts	4.3.1.2	1

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

4 The NRC staff did not identify any new and significant information during the review of Exelon
5 Generation Company, LLC's (Exelon's) ER (Exelon 2013a), the site audit, or during the scoping
6 process. As a result, no information or impacts related to these issues were identified that
7 would change the conclusions presented in the GEIS. Therefore, there are no impacts related
8 to these issues beyond those discussed in the GEIS. The GEIS concludes that the impact level
9 for each of these issues is SMALL.

10 4.3.1.2 Noise

11 One Category 1 noise issue is applicable to Byron Station, "noise impacts" (see Table 4–2).
12 The 1996 GEIS (NRC 1996) concluded that noise was not a problem at operating plants and
13 was not expected to be a problem at any nuclear plant during the license renewal term. The
14 2013 GEIS (NRC 2013a) did not identify new information that would alter this conclusion;
15 therefore, impacts are expected to be SMALL. The NRC staff did not identify any new and
16 significant information during the review of Exelon's ER (Exelon 2013a), the site audit, or during
17 the scoping process. As a result, no information or impacts related to these issues were
18 identified that would change the conclusions presented in the GEIS. Therefore, there are no
19 impacts related to these issues beyond those discussed in the GEIS. The GEIS concludes that
20 the impact level this issue is SMALL.

21 4.3.2 No-Action Alternative

22 4.3.2.1 Air Quality

23 When the plant stops operating, there would be a reduction in emissions from activities related
24 to plant operation such as cooling towers, use of stationary combustion sources (such as diesel
25 generators, auxiliary boilers, or fire pump), and vehicle traffic (such as workers and delivery).
26 Therefore, if emissions decrease, the impact on air quality from shutdown of the Byron Station
27 would be SMALL.

28 4.3.2.2 Noise

29 As discussed in Section 3.3.3 of this SEIS, the NRC staff found that the predicted total
30 (background and station contributions combined) noise levels at nearby receptors from plant
31 operation were a little higher than U.S. Environmental Protection Agency (EPA) guideline of 55
32 A-weighted decibels (dBA) day–night average sound level (L_{dn}) but well below the acceptable
33 Department of Housing and Urban Development (HUD) L_{dn} guideline of 65 dBA. When the
34 plant stops operating, there will be no noise from activities related to plant operation such as the
35 use of cooling towers, switchyard/transformers, stationary combustion sources (such as diesel
36 generators, auxiliary boilers, fire pump), and vehicle traffic (such as workers and delivery). In

1 other words, noise levels around the site would return to the background levels that existed
 2 before the Byron Station was built. Therefore, if noise sources are reduced, the impact on
 3 ambient noise levels would also be reduced and would be SMALL.

4 **4.3.3 New Nuclear Alternative**

5 *4.3.3.1 Air Quality*

6 This alternative includes the construction and operation of two Westinghouse AP1000 reactors,
 7 each with an approximate generating capacity of 1,200 megawatts electric (MWe). Due to the
 8 moratorium preventing the construction of new nuclear power plants within Illinois, the new
 9 nuclear alternative would have to be located elsewhere in the ROI (Indiana, Iowa, Michigan,
 10 Missouri, Kentucky, and Wisconsin).

11 Construction of the new nuclear plant would result in temporary impacts on local air quality.
 12 During the construction phase, the primary sources of air emissions would consist of engine
 13 exhaust and fugitive dust emissions. Engine exhaust emissions would be from heavy
 14 construction equipment and commuter, delivery, and support vehicular traffic traveling within, to,
 15 and from the facility. Fugitive dust emissions would be from soil disturbances by heavy
 16 construction equipment (e.g., earthmoving, excavating, bulldozing), vehicle traffic on unpaved
 17 surfaces, concrete batch plant operations (if any), and wind erosion to a lesser extent. Air
 18 emissions include criteria pollutants (particulate matter (PM), NO_x, CO, and SO₂), volatile
 19 organic compounds (VOCs), hazardous air pollutants (HAPs), and greenhouse gases (GHGs).
 20 Small quantities of VOCs and HAPs emissions would be released from equipment refueling;
 21 organic solvents used in cleaning, onsite storage, and use of petroleum-based fuels; onsite
 22 maintenance of the heavy construction equipment; and certain painting and other
 23 construction-finishing activities.

24 A new nuclear plant site in the Midwest would likely be located on a relatively flat site and no
 25 heavy earthmoving activities, such as major cut-and-fill operations, would be needed. Air
 26 emissions would be intermittent and vary based on the level and duration of a specific activity
 27 throughout the construction phase. Construction lead times for nuclear plants are anticipated to
 28 be 7 years (NRC 2013a). Based on the State and Federal permits and regulated practices for
 29 managing air emissions from construction equipment and temporary stationary sources,
 30 controlling fugitive dust, and vehicle inspection and traffic management plans, the NRC staff
 31 expects that potential impacts on air quality from building a nuclear power plant would be
 32 minimal. Since air emissions from construction activities would be limited, local, and temporary,
 33 the NRC staff concludes that the overall air quality impacts associated with construction of a
 34 new nuclear alternative would be SMALL.

35 Operation of a new nuclear generating plant would result in similar air emissions to those of the
 36 existing Byron site. Nuclear power plants do not burn fossil fuels to generate electricity.
 37 Sources of air emissions include stationary combustion sources (e.g., emergency diesel
 38 generators, diesel-driven fire pumps, and auxiliary boilers), cooling towers (natural or
 39 mechanical draft cooling towers), and mobile sources (worker vehicles, onsite heavy equipment
 40 and support vehicles, and delivery of materials and disposal of wastes). Air pollutants emitted
 41 from stationary combustion sources (e.g., criteria pollutants, VOCs, HAPs, and GHGs) and from
 42 cooling towers (PM as drift) associated with operations of a nuclear power plant would be
 43 permitted in accordance with State and Federal regulatory requirements. As noted in
 44 Section 3.3, Byron maintains a Federally Enforceable State Operating Permit (also known as a
 45 “synthetic minor” air permit). A synthetic minor source has the potential to emit air pollutants in
 46 quantities at or above the major source threshold levels but has accepted Federally enforceable
 47 limitations to keep the emissions below such levels. Because air emissions would be similar for

Environmental Consequences and Mitigating Actions

1 a new nuclear plant, the NRC staff expects similar air permitting conditions and regulatory
2 requirements. Subpart P of 40 CFR Part 51.307 contains the visibility protection regulatory
3 requirements, including the review of the new sources that may affect visibility in any Federal
4 Class I area. If a new nuclear plant were located near a mandatory Class I area, additional air
5 pollution control requirements may be required.

6 In general, most stationary combustion sources at a nuclear power plant would operate only for
7 limited periods, often for periodic maintenance testing. Thus, emissions from stationary
8 combustion sources would fall far below the threshold for major sources (100 U.S. short tons (t)
9 per year) and the threshold for mandatory GHG reporting (25,000 metric tons (MT) per year)
10 (see Table 3–1 of this SEIS for air emissions at Byron during operation). In contrast, cooling
11 towers would operate continuously for the entire year. However, a nuclear power plant located
12 in the ROI would use cooling water taken from a nearby river or lake, which would have
13 relatively low concentrations of total dissolved solids. In addition, modern cooling towers would
14 be equipped with drift eliminators to minimize the loss of cooling water from the tower via drift.
15 Thus, PM emissions from cooling towers would be anticipated to be minimal. The NRC staff
16 expects similar air emissions for combustion sources from a new nuclear plant as is currently
17 being emitted from Byron:

- 18 • sulfur oxides (SO_x) – 0.02 t (0.02 MT) per year,
- 19 • nitrogen oxides (NO_x) – 28 t (25 MT) per year,
- 20 • carbon monoxide (CO) – 7.5 t (6.8 MT) per year,
- 21 • particulate matter (PM_{2.5}) – 23 t (21 MT) per year,
- 22 • particulate matter (PM₁₀) – 23 t (21 MT) per year, and
- 23 • carbon dioxide equivalent (CO₂e) – 1,501 t (1,363 MT) per year.

24 The NRC staff evaluated potential impacts on air quality associated with criteria pollutants and
25 GHG emissions from operating a new nuclear alternative. The NRC staff determined that the
26 impacts would be minimal. Therefore, the NRC staff concludes that the impacts of operation of
27 a new nuclear alternative on air quality from emissions of criteria pollutants and GHGs would be
28 SMALL.

29 The NRC staff concludes that the air quality impacts associated with construction and operation
30 of a new nuclear alternative would be SMALL.

31 4.3.3.2 Noise

32 Construction of a new nuclear power plant is similar to that of other large industrial projects and
33 involves many noise-generating activities. In general, noise emissions vary with each phase of
34 construction, depending on the level of activity, the mix of construction equipment for each
35 phase, and site-specific conditions. Noise propagation to receptors is affected by several
36 factors, including source-receptor configuration, land cover, meteorological conditions
37 (temperature, relative humidity, and vertical profiles of wind and temperature), and screening
38 (such as topography, and natural or manmade barriers). Typical construction equipment, such
39 as dump trucks, loaders, bulldozers, graders, scrapers, air compressors, generators, and mobile
40 cranes would be used, and pile-driving and blasting activities would take place, during the
41 construction of a new nuclear power plant. Other noise sources include commuter, delivery,
42 and support vehicular traffic traveling within, to, and from the facility.

43 During the construction phase, a variety of construction equipment would be used and at
44 varying duration. Noise emissions from construction equipment are predicted to be in the 85 to
45 100 dBA range (Knauer and Pedersen 2011); however, noise levels attenuate rapidly with

1 distance such that at half a mile distance from construction equipment, 85 to 90 dBA noise
 2 levels can drop to 51 to 61 dBA (NRC 2002). Additionally, noise abatement and controls can be
 3 incorporated to reduce noise impacts. Accounting for attenuation from the construction site and
 4 noise controls, predicted noise levels can exceed EPA's guideline of 55 dbA but be less than
 5 HUD's acceptable noise level guideline of 65 dBA. Based on the temporary nature of
 6 construction activities, consideration of noise attenuation from the construction site to
 7 residences, the location and characteristics (i.e., ground cover), and good noise control
 8 practices, the NRC staff concludes that the potential noise impacts of construction activities
 9 from a new nuclear alternative would be SMALL.

10 During the operation phase, noise sources from the new nuclear power plant would come from
 11 cooling towers, transformers, turbines, pumps, compressors, other auxiliary equipment such as
 12 standby generators or auxiliary boilers, and vehicular traffic (commuting, delivery, and support),
 13 similar to those for Byron discussed in Section 3.3.3 of this SEIS. Noise level estimates at
 14 four receptors around Byron and the nearest residence located more than 0.9 km (0.6 mi) from
 15 primary noise sources (see Section 3.3.3 of this SEIS), ranged between 50 and 57 dBA L_{dn} ,
 16 considering both the background and station contributions.

17 Although the plant layout and the distance from primary noise sources to the nearby receptors
 18 at Byron might be different from those at a new nuclear alternative, the NRC staff does not
 19 expect noise impacts for a new nuclear plant to be any greater than that analyzed for the
 20 existing Byron site. Therefore, the noise impacts of a new nuclear plant located within the ROI
 21 region would be SMALL.

22 The NRC staff concludes that the noise impacts associated with operation and construction of a
 23 new nuclear alternative would be SMALL.

24 **4.3.4 IGCC Alternative**

25 *4.3.4.1 Air Quality*

26 This alternative includes the construction and operation of four IGCC units with a total output of
 27 2,472 MWe and a capacity factor of 85 percent. The new power plant is assumed to be located
 28 at existing power plant site(s). These sites could be located in Illinois (including the Byron site)
 29 or other adjoining states in the ROI (Indiana, Iowa, Michigan, Missouri, Kentucky, and
 30 Wisconsin). New infrastructure and infrastructure upgrades would depend on specific site
 31 locations.

32 Construction of an IGCC plant would be similar to that of other large industrial projects and
 33 involves many activities similar to those for a new nuclear alternative presented in Section 4.3.3.
 34 Construction of an IGCC plant would result in the release of various criteria pollutants (PM, NO_x,
 35 CO, and SO₂), VOCs, HAPs, and GHGs from operation of internal combustion engines in
 36 construction vehicles, equipment, delivery vehicles, and vehicles used by the commuting
 37 construction workforce. In addition, soil disturbance activities such as earthmoving and material
 38 handling would generate fugitive dust. The onsite storage and dispensing of vehicle and
 39 equipment fuels result in VOC releases. Air emissions would be intermittent and vary based on
 40 the level and duration of a specific activity throughout the construction phase. Construction lead
 41 times for IGCC plants are estimated to be 3 years (NETL 2013b). Impacts would be localized,
 42 intermittent, and short-lived, and adherence to well-developed and well-understood construction
 43 BMPs would mitigate such impacts. The NRC staff concludes that construction-related impacts
 44 on air quality from an IGCC alternative would be of relatively short duration and would be
 45 SMALL.

Environmental Consequences and Mitigating Actions

1 The sources of air emissions during operation include heat recovery steam generator (HRSG)
2 stacks, the wet gas sulfuric acid (WSA) system exhaust, acid gas removal process
3 startup/shutdown vents, startup stacks, flares, material handling equipment, and mechanical
4 draft cooling towers (DOE 2010a). The HRSG stacks would release the most emissions.
5 Auxiliary boilers and firewater pumps would also generate emissions on an infrequent basis.

6 Compared to conventional coal-fired power plants, the proposed IGCC power plant would
7 reduce sulfur dioxide, nitrogen oxides, mercury, and PM emissions by removing constituents
8 from the syngas (DOE 2010a). The IGCC alternative would also result in lower nitrogen oxide
9 emissions since nearly 100 percent of the fuel-bound nitrogen from the syngas would be
10 removed from the syngas before combustion in the gas turbine. Sulfur removal technology
11 would remove more than 99 percent of the sulfur in the syngas. The use of sulfide-activated
12 carbon could remove more than 92 percent of mercury from the syngas. More than
13 99.9 percent of particulate emissions would be removed from the syngas using
14 high-temperature, high-pressure filtration.

15 Various Federal and state regulations aimed at controlling air pollution would affect an IGCC
16 alternative located in the seven-state ROI. A new IGCC plant would qualify as a new major
17 source because of its potential to emit (PTE) greater than 100 t per year of criteria pollutants,
18 and would be subject to New Source Review (NSR) permitting program requirements under the
19 Clean Air Act (CAA) (EPA 2013d). An NSR permit or construction permit would specify
20 emission limits for each pollutant, along with monitoring and reporting requirements,
21 specifications for fuel and control equipment, and monitoring and performance testing for the
22 IGCC units, auxiliary boiler, and WSA process. The new IGCC plant would be required to
23 secure a Title V operating permit from the state agency.

24 An NSR review would limit emissions for criteria pollutants and would reflect existing ambient air
25 quality at the selected location. Because the IGCC alternative could be located anywhere within
26 the seven-state ROI, it is unknown at this time whether or not the specific site(s) would be
27 located within a designated attainment area. For instance, if the IGCC alternative were to be
28 located at the Byron site, Ogle County is designated as an attainment/unclassifiable area for all
29 criteria pollutants (40 CFR 81.314). Analysis regarding National Ambient Air Quality Standards
30 (NAAQS) compliance would be conducted at the specific site location. The IGCC alternative
31 also would need to comply with the standard of performance for new stationary sources set forth
32 in 40 CFR Part 60, Subpart Da, "Standards of performance for electric utility steam generating
33 units."

34 If the IGCC alternative were located close to a mandatory Class I area, additional air pollution
35 control requirements would be necessary (Subpart P of 40 CFR Part 51) as mandated by the
36 Regional Haze Rule. Within the ROI, there are five Class I Federal areas, including: Mammoth
37 Cave National Park (NP) in Kentucky (40 CFR 81.411), Isle Royale NP and Seney Wilderness
38 Area (WA) in Michigan (40 CFR 81.414), and Hercules-Glades WA and Mingo WA in Missouri
39 (40 CFR 81.416). The rule could apply to the IGCC alternative, but would depend on specific
40 site locations(s). If the IGCC alternative were to be located at the Byron site, the nearest⁵
41 Class I Federal area for visibility protection is the Seney WA in Michigan (40 CFR 81.414),
42 about 520 km (323 mi) north-northeast of the Byron site.

⁵ Rainbow Lake in Wisconsin is a Mandatory Federal Class I area where visibility is not an important air quality related value. In 1980 Rainbow Lake was excluded for purposes of visibility protection as a Class I area. Rainbow Lake is approximately 505 km (314 mi) north-northwest of the Byron site.

1 Air emissions for the IGCC alternative were estimated based on data presented in Table 4.3-1
 2 in the GEIS (NRC 2013a). The resulting IGCC emissions are estimated to be as follows:

- 3 • sulfur dioxide (SO₂)—820 t (740 MT) per year,
- 4 • nitrogen oxides (NO_x)—3,000 t (2,720 MT) per year,
- 5 • particulate matter (PM₁₀)—480 t (435 MT) per year,
- 6 • carbon monoxide (CO)—2,045 t (1,850 MT) per year, and
- 7 • carbon dioxide equivalent (CO₂e)—14.3 million t (13.0 million MT) per year.

8 The IGCC alternative would produce 820 t (740 MT) per year of sulfur dioxide and 3,000 t
 9 (2,072 MT) per year of nitrogen oxides. The IGCC plant would have to comply with Title IV of
 10 the CAA (42 USC § 7651) reduction requirements for sulfur oxides and nitrogen oxides, which
 11 are the main precursors of acid rain and the major causes of reduced visibility. Title IV
 12 establishes maximum sulfur oxide and nitrogen oxide emission rates from the existing plants
 13 and a system of sulfur oxide emission allowances that can be used, sold, or saved for future use
 14 by the new plants. The new plant would be subjected to the continuous monitoring
 15 requirements of sulfur dioxide and nitrogen oxides as specified in 40 CFR Part 75. The Clean
 16 Air Interstate Rule⁶ (CAIR) requires 27 states (including Indiana, Iowa, Michigan, Missouri,
 17 Kentucky, and Wisconsin) to improve air quality requiring power plants to reduce sulfur dioxide
 18 and nitrogen oxide emissions (EPA 2014a). A new IGCC plant would be subject to these
 19 additional rules and regulations.

20 The IGCC alternative would emit approximately 14.3 million t (approximately 13 million MT) per
 21 year of CO₂e emissions. The plant would be subjected to the continuous monitoring
 22 requirements for carbon dioxide, as specified in 40 CFR Part 75. On July 12, 2012, EPA issued
 23 a final rule tailoring the criteria that determine which stationary sources and modifications to
 24 existing projects become subject to permitting requirements for GHG emissions under the
 25 prevention of significant deterioration (PSD) and Title V Federal permit programs of the CAA
 26 (77 FR 41051). Beginning January 2, 2011⁷, operating permits issued to major sources of GHG
 27 under the PSD or Title V permit programs must contain provisions requiring the use of best
 28 available control technology (BACT) to limit the emissions of GHGs if those sources would be
 29 subject to PSD or Title V permitting requirements because of their non-GHG pollutant emission
 30 potentials and their estimated GHG emissions are at least 75,000 tons/yr of CO₂e. If the IGCC
 31 alternative meets PSD or Title V permitting requirements for non-GHG pollutant emissions and
 32 the GHG emission thresholds established in the rule, then GHG emissions from this alternative
 33 would be regulated under the PSD and Title V permit programs.

⁶ The Clean Air Interstate Rule (CAIR) was first issued by EPA in 2005; however, the Federal rule was vacated by the D.C. Circuit Court on February 8, 2008. In December 2008, the U.S. Court of Appeals for the D.C. Circuit reinstated the rule, allowing it to remain in effect but also requiring EPA to revise the rule and its implementation plan. On July 6, 2010, EPA proposed replacing CAIR with the Cross-State Air Pollution Rule (CSAPR) for control of sulfur dioxide and nitrogen oxide emissions that cross state lines, the regulations of which would be implemented in 2011 and finalized in 2012. However, CSAPR was vacated by the D.C. Circuit Court on August 21, 2012. On April 29, 2014, the U.S. Supreme Court reversed the D.C. Circuit opinion vacating CSAPR. EPA is reviewing the opinion and CAIR remains in effect.

⁷ On June 23, 2014, the U.S. Supreme Court issued a decision that the EPA may not treat GHGs as an air pollutant for purposes of determining whether a source is a major source required to obtain a PSD or Title V permit, but could continue to require PSD and Title V permits otherwise required based on emissions of conventional pollutants. In July 2014, the EPA issued a memorandum in response to the Supreme Court's decision and acknowledged that while the decision is pending judicial action, the EPA will no longer require PSD or Title V permits for GHG-emitting sources that are not sources subject to PSD or Title V permits based on emissions of conventional pollutants (nitrogen oxides, carbon monoxide, etc.) (EPA 2014b).

Environmental Consequences and Mitigating Actions

1 In response to the Consolidated Appropriations Act of 2008 (Public Law 110-161), EPA issued
2 final mandatory GHG reporting regulations for major sources effective in December 2009
3 (EPA 2012b). Major sources are defined as those emitting more than 25,000 t per year of all
4 GHGs. An IGCC alternative would be subject to these reporting regulations with or without
5 carbon capture. On January 8, 2014, EPA issued a new proposal for GHG emissions from new
6 fossil fuel-fired electric utility steam generating units (79 FR 1430). It also proposes standards
7 of performance for IGCC units that burn coal. The performance standards are based on partial
8 implementation of carbon capture and sequestration (CCS) as the best system of emission
9 reduction (BSER). Although the proposed rule has not been finalized, the IGCC alternative
10 analysis includes an option for future implementation of CCS.

11 An IGCC alternative also would be subject to the Mercury and Air Toxics Standards (MATS)
12 final rule, finalized by EPA on December 16, 2011 (EPA 2012a). Standards for emissions of
13 heavy metals (mercury, arsenic, chromium, and nickel) and acid gases (hydrochloric acid and
14 hydrofluoric acid) are set by MATS. Mercury is the most prominent HAP emitted and is subject
15 to regulation by the MATS rule. New IGCC units are required to meet a mercury emission limit
16 of 0.003 lb per gigawatt-hour (40 CFR Part 63 Subpart UUUUU). NRC staff estimates that an
17 IGCC alternative replacing the electrical output of Byron would generate 0.03 t (0.02 MT) of
18 mercury per year.

19 The impact from sulfur dioxide and nitrogen oxide emissions would be significant and subject to
20 a Title V permit. GHG emissions also would be noticeable and significant; GHG emissions
21 would be much larger than the threshold in EPA's GHG Tailoring Rule and GHG emissions may
22 be regulated under the PSD and Title V permit programs. that would trigger a regulated NSR.
23 In the near future, carbon dioxide emissions could be reduced considerably if CCS technology
24 were installed. The NRC staff concludes that the air quality impacts associated with operation
25 of an IGCC alternative would be MODERATE.

26 The NRC staff concludes that the overall air quality impacts associated with construction and
27 operation of an IGCC alternative would be MODERATE.

28 4.3.4.2 Noise

29 Construction of an IGCC plant is similar to that of other large industrial projects, and
30 construction-related noise sources would be virtually the same as those for construction of the
31 nuclear alternative. However, the construction period for the IGCC alternative would be shorter
32 and the level of activities scattered over a wide area would be less extensive compared with
33 construction of a nuclear alternative. Consequently, with construction-related noise for the
34 nuclear alternative as a bounding condition, the NRC staff concludes that construction-related
35 noise associated with the IGCC alternative would be SMALL.

36 Operation of an IGCC plant would introduce mechanical sources of noise that would be audible
37 off site. Continuous sources include the mechanical equipment associated with normal plant
38 operations and mechanical draft cooling towers. Intermittent sources include the equipment
39 related to coal handling, solid waste disposal, transportation related to coal and lime/limestone
40 delivery, use of outside loudspeakers, and the commuting of plant employees. Noise
41 associated with rail delivery of coal and lime/limestone would extend beyond the plant site
42 boundary and would be most significant for residents living in the vicinity of the facility and along
43 the rail route. Noise impacts associated with rail delivery are predicted to be in the 80 to 96 dBA
44 range (NRC 2002). Transportation-related noise sources have the potential to impact as these
45 noise sources reach beyond the plant site boundary. The NRC staff concludes that the potential
46 impacts of noise on residents in the vicinity of the facility of an IGCC alternative and the rail line
47 are considered to range from SMALL to MODERATE, depending on the distance from primary
48 noise sources to nearby sensitive receptors.

1 The NRC staff concludes that the overall potential impacts of noise associated with construction
 2 and operation of the IGCC alternative and the rail line are considered to range from SMALL to
 3 MODERATE.

4 **4.3.5 NGCC Alternative**

5 *4.3.5.1 Air Quality*

6 This alternative includes the construction and operation of five NGCC 560-MWe units (total
 7 2,800 MWe) and a capacity factor of 85 percent. These sites could be located at an existing
 8 power plant site in the ROI (including the Byron site). Some infrastructure upgrades may be
 9 required and would require construction of a new or upgraded pipeline. Using existing power
 10 plant sites maximizes availability of infrastructure and reduces disruption to land and
 11 populations.

12 Construction of an NGCC power plant would be similar to that of other large industrial projects.
 13 Construction of an NGCC power plant would result in the release of various criteria pollutants
 14 (PM, NO_x, CO, and SO₂), VOCs, HAPs, and GHGs from the operation of internal combustion
 15 engines in construction vehicles, equipment, delivery vehicles, and vehicles used by the
 16 commuting construction workforce. In addition, onsite soil disturbance activities such as
 17 earthmoving and material handling would generate fugitive dust. Releases of VOCs will also
 18 result from the onsite storage and dispensing of vehicle and equipment fuels. Air emissions
 19 would be intermittent and vary based on the level and duration of a specific activity throughout
 20 the construction phase. Gas-fired power plants are constructed relatively quickly; construction
 21 lead times for NGCC plants are around 2 to 3 years (EIA 2011; OECD/NEA 2005). Impacts
 22 would be localized, intermittent, and short-lived, and adherence to well-developed and
 23 well-understood construction BMPs would mitigate such impacts. Therefore the NRC staff
 24 concludes that construction-related impacts on air quality from an NGCC alternative would be of
 25 relatively short duration and would be SMALL.

26 Operation of the NGCC plant would result in significant emissions of certain criteria pollutants,
 27 including carbon monoxide, nitrogen oxides, and PM. The sources of air emissions during
 28 operation include gas turbines through HRSG stacks and mechanical draft cooling towers.
 29 Auxiliary boilers and emergency generators would also generate emissions on an infrequent
 30 basis.

31 The NGCC alternative could be located anywhere within the seven-state ROI; it is therefore
 32 unknown at this time whether or not the specific site(s) would be located within a designated
 33 attainment area. For instance, if the NGCC alternative were to be located at the Byron site,
 34 Ogle County is designated as an attainment/unclassifiable area for all criteria pollutants
 35 (40 CFR 81.314). Analysis regarding NAAQS compliance would be conducted at the specific
 36 site location. Various Federal and state regulations aimed at controlling air pollution would
 37 affect an NGCC alternative located in the seven-state ROI. An NGCC plant would be subject to
 38 NSR permitting program requirements to ensure air emissions are minimized and the local air
 39 quality is not substantially degraded (EPA 2013d). The new NGCC plant would be required to
 40 secure a Title V operating permit from the state agency. The NGCC plant would need to comply
 41 with the standards of performance for stationary combustion turbines set forth in 40 CFR
 42 Part 60 Subpart KKKK. If the NGCC alternative were located close to a mandatory Class I area,
 43 additional air pollution control requirements would be required (Subpart P of 40 CFR Part 51) as
 44 mandated by the Regional Haze Rule. A detailed discussion of these Federal and state
 45 regulations is provided in Section 4.3.4.1 (see Air Quality Operation discussion for the IGCC
 46 alternative).

Environmental Consequences and Mitigating Actions

1 Air emissions for the NGCC alternative were estimated based on data presented in Table 4.3-2
2 in the GEIS (NRC 2013a) and EPA emission factors (EPA 2000; NRC 2013a). The estimate is
3 based on using advanced F class gas turbines at one or multiple sites within the ROI. The
4 resulting NGCC emissions are estimated to be as follows:

- 5 • sulfur dioxide (SO₂)—380 t (350 MT) per year,
- 6 • nitrogen oxides (NO_x)—600 t (540 MT) per year,
- 7 • particulate matter (PM₁₀)—210 t (190 MT) per year,
- 8 • carbon monoxide (CO)—1,690 t (1,530 MT) per year, and
- 9 • carbon dioxide equivalent (CO₂e)—7.9 million t (7.2 million MT) per year.

10 The NGCC alternative would produce 380 t (350 MT) per year of sulfur dioxide and 600 t
11 (540 MT) per year of nitrogen oxides based on the use of dry low-nitrogen-oxide combustion
12 technology coupled with use of selective catalytic reduction (SCR) to significantly reduce
13 nitrogen oxide emissions (NETL 2013b). The new plant would be subjected to the continuous
14 monitoring requirements of sulfur dioxide and nitrogen oxides as specified in 40 CFR Part 75.
15 The CAIR requires 27 states (including Indiana, Iowa, Michigan, Missouri, Kentucky, and
16 Wisconsin) to improve air quality, requiring power plants to reduce sulfur dioxide and nitrogen
17 oxide emissions (EPA 2014a). A new NGCC plant would be subject to these additional rules
18 and regulations.

19 The NGCC alternative would emit approximately 7.9 million t (approximately 7.2 million MT) per
20 year of CO₂e. The plant would be subjected to the continuous monitoring requirements for
21 carbon dioxide, as specified in 40 CFR Part 75. On July 12, 2012, EPA issued a final rule
22 tailoring the criteria that determine which stationary sources and modifications to existing
23 projects become subject to permitting requirements for GHG emissions under the PSD and
24 Title V Programs of the CAA (77 FR 41051). Beginning January 2, 2011⁸, operating permits
25 issued to major sources of GHG under PSD or Title V Federal permit programs must contain
26 provisions requiring the use of best available control technology (BACT) to limit the emissions of
27 GHGs if those sources would be subject to PSD or Title V permitting requirements because of
28 their non-GHG pollutant emission potentials and their estimated GHG emissions are at least
29 75,000 tons/yr of CO₂ equivalents (CO₂e). If the NGCC alternative meets PSD or Title V
30 permitting requirements for non-GHG pollutant emissions and the GHG emission thresholds
31 established in the rule, then GHG emissions from this alternative would be regulated under the
32 PSD and Title V permit programs.

33 In response to the Consolidated Appropriations Act of 2008 (Public Law 110-161), EPA issued
34 final mandatory GHG reporting regulations for major sources effective in December 2009
35 (EPA 2012b). Major sources are defined as those emitting more than 25,000 t per year of all
36 GHGs. An NGCC alternative would be subject to these reporting regulations with or without
37 carbon capture.

⁸ On June 23, 2014, the U.S. Supreme Court issued a decision that the EPA may not treat GHGs as an air pollutant for purposes of determining whether a source is a major source required to obtain a PSD or Title V permit, but could continue to require PSD and Title V permits otherwise required based on emissions of conventional pollutants. In July 2014, the EPA issued a memorandum in response to the Supreme Court's decision and acknowledged that while the decision is pending judicial action, the EPA will no longer require PSD or Title V permits for GHG-emitting sources that are not sources subject to PSD or Title V permits based on emissions of conventional pollutants (nitrogen oxides, carbon monoxide, etc.) (EPA 2014b).

1 On January 8, 2014, EPA issued a new proposal for GHG emissions from new fossil fuel-fired
2 electric utility steam generating units (79 FR 1430). It also proposes standards of performance
3 for natural gas-fired stationary combustion turbines based on modern, efficient NGCC
4 technology as the BSER.

5 In December 2000, EPA issued regulatory findings on emissions of HAPs from electric utility
6 steam-generating units (65 FR 79825). These findings indicated that natural gas-fired plants
7 emit HAPs such as arsenic, formaldehyde, and nickel and stated that:

8 ...the impacts due to HAP emissions from natural gas-fired electric utility steam
9 generating units were negligible based on the results of the study. The
10 Administrator finds that regulation of HAP emissions from natural gas-fired
11 electric utility steam generating units is not appropriate or necessary.
12 [65 FR 79825]

13 Mercury is not emitted from NGCC power plants due to the lack of mercury in natural gas used
14 as fuel.

15 Considerable air emissions are emitted from operations of the NGCC alternative. The impacts
16 from nitrogen oxide emissions would be significant and subject to a Title V permit. GHG
17 emissions also would be noticeable and significant; carbon dioxide emissions would be much
18 larger than the threshold in EPA's GHG Tailoring Rule. The NRC staff concludes that the
19 overall air quality impacts associated with operation of an NGCC alternative would be
20 MODERATE.

21 The NRC staff concludes that the overall air quality impacts associated with construction and
22 operation of an NGCC alternative would be MODERATE.

23 4.3.5.2 Noise

24 The construction-related noise sources for an NGCC alternative would be virtually the same as
25 those for construction of the IGCC alternative. Construction vehicles and equipment associated
26 with the construction of the NGCC plant would generate noise; these impacts would be
27 intermittent and last only through the duration of plant construction. Noise emissions from
28 common construction equipment would be in the 85 to 100 dBA range (Knauer and
29 Pedersen 2011). However, noise abatement and controls can be incorporated to reduce noise
30 impacts. The review team concludes that construction-related noise impacts associated with
31 the NGCC alternative would be SMALL.

32 Noise impacts from operations would include cooling towers (water pumps, cascading water, or
33 fans), transformers, turbines, pumps, compressors, exhaust stacks, the combustion inlet filter
34 house, condenser fans, high-pressure steam piping, and vehicles (Saussus 2012). Pipelines
35 delivering natural gas fuel could be audible off site near gas compressor stations, but such
36 noise impacts would be similar to impacts already occurring in the vicinity of the existing pipeline
37 to which the new NGCC site would connect. Most noise-producing equipment is located inside
38 the power block buildings and no outside fuel-handling activities will occur. Minor offsite noise
39 sources could include pipeline compressor stations. The NRC staff concludes that
40 operation-related noise impacts from the NGCC alternative would be SMALL.

41 The NRC staff concludes that construction operation-related noise impacts from the NGCC
42 alternative would be SMALL.

43 4.3.6 Combination Alternative (NGCC, Wind, Solar)

44 The combination alternative relies on NGCC, wind, and solar generating capacity. The total
45 installed solar photovoltaic (PV) capacity is 1,193 megawatts (MW), the total installed wind

Environmental Consequences and Mitigating Actions

1 capacity is 6,042 MW of onshore wind, and the total installed capacity for NGCC is 267 MW in
2 this alternative. All portions of the combination alternative would be located in Illinois or other
3 adjoining states in the ROI (Indiana, Iowa, Michigan, Missouri, Kentucky, and Wisconsin).

4 The NGCC alternative would require one 267-MW unit. For the NGCC portion of the
5 combination alternative, it is assumed that sites would be located at an existing power plant site
6 which maximizes availability of existing infrastructure and reduces disruption to land and
7 populations. Most of the wind farms would likely be located on open agricultural cropland,
8 which would remain largely unaffected by the wind turbines. The solar portion requires
9 1,193 MW, and it is assumed that some of the capacity would be from small units and may be
10 installed on building roofs or on existing residential, commercial, or industrial sites.

11 4.3.6.1 Air Quality

12 Air emissions associated with the construction of the NGCC portion of the combination
13 alternative are similar to the NGCC alternative but reduced considerably because its electricity
14 output is approximately 10 percent that of the NGCC alternative. As discussed in
15 Section 4.3.5.1, construction activities for an NGCC alternative would cause some temporary
16 impacts to air quality from dust generation during operation of the earthmoving and material
17 handling equipment and exhaust emissions from worker vehicles and construction equipment.
18 These emissions include criteria pollutants, VOCs, GHGs, and small amounts of HAPs.
19 However, these impacts would be localized, intermittent, and short-lived, and adherence to
20 well-developed and well-understood construction BMPs would mitigate such impacts. The NRC
21 staff concludes that construction-related impacts on air quality from an NGCC portion of the
22 combination alternative would be of relatively short duration and would be SMALL.

23 For the wind portion of the combination alternative, only a small percentage of site land
24 (5 percent or less) would be disturbed by construction activities because wind turbines need to
25 be separated from one another in order to maximize energy production and avoid wake
26 turbulences created by upwind turbines. Construction of the wind portion of the combination
27 alternative would involve a number of activities, including road and staging/laydown area
28 construction, land clearing, topsoil stripping, earthmoving operations, grading, ground
29 excavation, drilling, foundation treatment, wind turbines erection, ancillary building/structure
30 construction, and electrical and mechanical installation. For most wind energy facilities, the site
31 preparation phase would last for only a few months, followed by a year-long construction phase
32 (depending on size of the wind energy facility) (Tegen 2006). Air emissions associated with
33 construction activities result from fugitive dust from soil disturbances and engine exhaust from
34 heavy equipment and vehicular traffic. These emissions include criteria pollutants, VOCs,
35 GHGs, and HAPs. Dust suppression methods and other mitigation measures could reduce
36 impacts from fugitive dust. The wind portion of the combination alternative would have no
37 power block, for which intensive construction activities would occur. Accordingly, the number of
38 heavy equipment and workforce, level of activities, and construction duration would be
39 substantially lower than other alternatives. Therefore, the NRC staff concludes that the overall
40 air quality impacts associated with construction of the wind portion of the combination
41 alternative would be SMALL.

42 Construction of the solar portion of the combination alternative would cause temporary impacts
43 to air quality from fugitive dust from soil disturbances and engine exhaust from heavy equipment
44 and from vehicular traffic. Air emissions associated with construction activities include criteria
45 pollutants, VOCs, GHGs, and HAPs to a lesser amount. Dust suppression methods and other
46 mitigation measures could reduce impacts from fugitive dust. The solar PV portion of the
47 combination alternative would have no power block, for which intensive construction activities
48 would occur. Accordingly, the number of heavy equipment and workforce, level of activities,

1 and construction duration would be substantially lower than those for other alternatives.
 2 Therefore, the NRC staff concludes that the overall air quality impacts associated with
 3 construction of the solar PV portion of the combination alternative would be SMALL.

4 Air emissions associated with the operation of the NGCC portion of the combination alternative
 5 are similar to the NGCC alternative in Section 4.3.5.1 but reduced proportionally because its
 6 electricity output is approximately 13 percent that of the NGCC alternative.

7 Air emissions for the NGCC alternative were estimated based on data presented in Table 4.3-2
 8 in the GEIS (NRC 2013a) and Energy Information Administration (EIA) emission factors
 9 (EIA 1999; NRC 2013a). The estimate is based on using advanced F class gas turbines at one
 10 or multiple sites within the ROI. The resulting NGCC emissions are estimated to be as follows:

- 11 • sulfur dioxide (SO₂)—50 t (45 MT) per year,
- 12 • nitrogen oxides (NO_x)—80 t (70 MT) per year,
- 13 • particulate matter (PM₁₀)—30 t (25 MT) per year,
- 14 • carbon monoxide (CO)—220 t (200 MT) per year, and
- 15 • carbon dioxide equivalent (CO₂e)—1.0 million t (0.9 million MT) per year.

16 Annual emissions of sulfur dioxide and nitrogen oxides would be lower than the major source
 17 threshold, while those of carbon monoxide would exceed the major source threshold. The
 18 overall air quality impacts associated with operation of the NGCC portion of the combination
 19 alternative would be SMALL to MODERATE.

20 Emissions from the operation of wind energy facilities would include minor dust and engine
 21 exhaust emissions from vehicles and heavy equipment associated with site inspections,
 22 maintenance activities, and wind erosion from cleared land and access roads. The types of
 23 emission sources and pollutants during operation would be similar to those during construction,
 24 but much fewer emissions would be released during operation. The NRC staff concludes that
 25 the overall air quality impacts associated with the operation of the wind portion of the
 26 combination alternative would be SMALL.

27 In general, air emissions associated with the operation of solar energy facilities are negligible
 28 because no fossil fuels are burned to generate electricity. Emissions from solar fields would
 29 include fugitive dust and engine exhaust emissions from vehicles and heavy equipment
 30 associated with site inspections, maintenance activities (panel washing or replacement), and
 31 wind erosion from cleared lands and access roads. The types of emission sources and
 32 pollutants during operation would be similar to those during construction, but much fewer
 33 emissions would be released during operation. These emissions should not cause
 34 exceedances of air quality standards or have any impacts on climate change. The NRC staff
 35 concludes that the overall air quality impacts associated with the operation of the solar PV
 36 portion of the combination alternative would be SMALL.

37 The overall air quality impacts associated with construction and operation of the combination
 38 alternative would be SMALL to MODERATE.

39 4.3.6.2 Noise

40 The construction-related noise sources for the NGCC portion of the combination alternative
 41 would be virtually the same as those for construction of the NGCC alternative. The construction
 42 period for the NGCC portion would be shorter and the level of construction activities would be
 43 less extensive than the NGCC alternative. Consequently, the NRC staff concludes that

Environmental Consequences and Mitigating Actions

1 construction-related noise associated with the NGCC portion of the combination alternative
2 would be SMALL.

3 Construction of the wind portion of the combination alternative would involve a number of
4 activities, as described above. The wind portion of the combination alternative would have no
5 power block, for which intensive construction activities would occur. Accordingly, the number of
6 heavy equipment and workforce, level of activities, and construction duration would be
7 substantially lower than other alternatives. Considering these factors, the NRC staff concludes
8 that construction-related noise associated with the wind portion of the combination alternative
9 would be SMALL.

10 Construction of the solar PV portion of the combination alternative would involve a number of
11 activities. The solar PV portion of the combination alternative would have no power block, for
12 which intensive construction activities would occur. Accordingly, the number of heavy
13 equipment and workforce, level of activities, and construction duration would be substantially
14 lower than other alternatives. Considering these factors, the NRC staff concludes that
15 construction-related noise associated with the solar PV portion of combination alternative would
16 be SMALL.

17 Besides noise from the power block area, cooling towers, and vehicular traffic, operation-related
18 noise for the NGCC portion would include limited outdoor waste handling activities. Pipelines
19 delivering natural gas fuel could be audible off site near gas compressor stations, but such
20 sound impacts would be similar to impacts already occurring in the vicinity of the existing
21 pipeline to which the new NGCC site would connect. Most noise-producing equipment is
22 located inside the power block buildings, and no outside fuel-handling activities would occur.
23 Minor offsite noise sources could be pipeline compressor stations. The NRC staff concludes
24 that operation-related noise from the NGCC portion of the combination alternative would be
25 SMALL.

26 Noise impacts from wind generation operations would include aerodynamic noise from the
27 turbine rotors and mechanical noise from the turbine drivetrain components. Noise levels are
28 dependent on the wind and atmospheric conditions, which vary with time, and on site-specific
29 conditions, including: the number and size of wind turbines, their layout, distance to nearby
30 sensitive receptors, land cover, and topography. Wind turbine noise levels can reach 105 dBA;
31 however, studies show that at approximately 1,000 ft (300 m) from a wind turbine, noise levels
32 can reach 43 dBA (GE 2010; Hessler 2011). Therefore, masking effects of background noise
33 should be taken into consideration. Unless noise from wind turbines is masked by high
34 background levels (e.g., near major highways or industrial complexes), it can be noticeable and
35 annoying at farther distances. One study indicated that, for the same A-weighted sound level,
36 proportions of respondents annoyed by wind turbine noise are higher than for other community
37 noise, such as aircraft, road, or railway traffic, and that the proportion annoyed increases more
38 rapidly (Pedersen and Persson Waye 2004). Therefore, the NRC staff concludes that
39 operation-related noise from the wind portion of the combination alternative would be SMALL to
40 MODERATE, depending on the layout and location of the wind facility and the distance to
41 nearby sensitive receptors.

42 The solar PV portion of the combination alternative would have no power block and cooling
43 towers, and thus there would be a minimal number of noise sources with low-level noises.
44 Noise sources include small-scale cooling systems to dissipate heat from solar module
45 assemblies, solar tracking devices, inverters, transformers, and vehicle traffic for maintenance
46 and inspection. Because of minimal noise-generating activities, noise from a solar PV facility
47 would be anticipated to be inaudible or barely perceptible at the facility boundaries. Considering
48 the minimum number of sources with low-noise levels and the area size of the solar PV facility,

1 the NRC staff concludes that operation-related noise from the solar PV portion of the
2 combination alternative would be SMALL.

3 The noise impacts associated with construction and operation of the combination alternative
4 would be SMALL to MODERATE.

5 **4.3.7 Purchased Power**

6 *4.3.7.1 Air Quality*

7 As discussed in Section 2.2.2.5, purchased power would come from common types of existing
8 technology (coal, natural gas, and nuclear) within the ROI, and it is not likely that new facilities
9 would be constructed to replace Byron. Construction of new transmission lines would result in
10 additional amounts of air emissions. Air emissions associated with the construction of
11 transmission lines would be from operation of the earthmoving and material handling equipment
12 and exhaust emissions from worker vehicles and construction equipment. These emissions
13 include criteria pollutants, VOCs, GHGs, and HAPs. However, these impacts would be
14 temporary and not likely to be high. For purchased power from existing plants, the impacts on
15 air quality are expected to be SMALL as there would be minimal change in existing plant
16 operations.

17 If new facilities were to be constructed for purchased power, the impact on air quality would
18 depend on the plant technology constructed, since air emissions can vary substantially, as can
19 be observed from the alternative air quality discussions provided above. For instance, natural
20 gas- and coal-fired plants emit higher amounts of nitrogen oxides, sulfur oxides, PM, and carbon
21 dioxide than nuclear plants. Purchased power from new nuclear plants would not have
22 noticeable impacts on air quality. New natural gas- and coal-fired plants would have noticeable
23 impacts on air quality as a result of the higher amounts of air emissions.

24 Therefore, impacts on air quality from purchased power of new plants would be SMALL to
25 MODERATE.

26 *4.3.7.2 Noise*

27 Purchased power from existing electricity generating facilities would not have noticeable
28 impacts on noise as there would be minimal change in existing plant operations. Purchased
29 power from new generating facilities could have impacts on noise. Construction and operation
30 of new facilities could result in additional noise sources including mechanical equipment
31 associated with normal plant operations and vehicular traffic. Additionally, construction of new
32 transmission lines could increase noise levels. Increase in noise levels from construction of
33 new transmission lines and new facilities would be dependent on the distance of residents to the
34 noise sources. Noise levels from operation will also be dependent on the type of technology, for
35 instance, operation of nuclear or wind power. Therefore, impacts from purchased power on
36 noise would be SMALL to MODERATE.

37 **4.3.8 Conclusions**

38 Air Quality

39 Estimated air emissions from operations of the proposed action and five alternatives are
40 presented in Table 4–3. Air emissions from the proposed action and the new nuclear alternative
41 would be lowest, while the IGCC alternative would release the highest emissions, followed by
42 the NGCC alternative. Air emissions from the combination alternative would fall between the
43 nuclear alternative and the NGCC alternative. It is apparent that the IGCC and NGCC
44 alternatives will produce significantly greater air pollutant emissions than those associated with

Environmental Consequences and Mitigating Actions

1 the proposed action (license renewal of Byron), new nuclear alternative, or the combination
 2 alternative. Air emissions from purchased power will vary and depend on the type of technology
 3 and whether the purchased power is from existing or new constructed technology. If purchased
 4 power is solely from coal-fired plants, air emissions would be higher as opposed to purchased
 5 power from nuclear plants, which would result in lower emissions. It is assumed that purchased
 6 power would come from a combination of technologies. In 2012, coal, natural gas, and nuclear
 7 power accounted for 37-, 30-, and 19-percent share, respectively, of total U.S. electricity
 8 generation (EIA 2014). Using these percent shares for the purchased power alternative, the
 9 NRC staff estimates that air emissions will be greater than the NGCC alternative, but less than
 10 the IGCC alternative. However, actual emissions may be greater or less than what is estimated
 11 in Table 4–3 and will depend on the technology from which the purchased power comes.

12 **Table 4–3. Estimated Direct Air Emissions From Operation of the Byron**
 13 **Proposed Action and Alternatives (Tons/Year)**

	Proposed Action ^(a)	New Nuclear ^(b)	IGCC	NGCC	Combination ^(c)	Purchased Power ^(d)
NO_x	28	28	3,000	600	80	1,295
SO_x	0.02	0.02	820	380	50	417
PM₁₀	23	23	480	210	30	188
CO	7.5	7.5	2,045	1,690	220	1,265
CO_{2e}	1.5×10 ³	1.5×10 ³	14.3×10 ⁶	7.9×10 ⁶	1.0×10 ⁶	7.7×10 ⁶

^(a) Highest annual emissions from the Byron Station during the 2008 to 2012 period.

^(b) Assumed air emissions from the Byron Station.

^(c) Assumed air emissions only from the NGCC portion of the combination alternative.

^(d) Assumed air emissions were estimated by assuming that purchased power coal accounted for a 37% share, natural gas a 30% share, nuclear a 19% share, and renewable a 14% share of electricity generation.

Legend: CO = carbon monoxide; CO_{2e} = carbon dioxide equivalent; PM₁₀ = particulate matter, ≤10 μm; NO_x = nitrogen oxides; SO_x = sulfur oxides

14 Noise

15 As discussed in the sections above, noise levels and impacts from operation of the NGCC and
 16 new nuclear combination alternatives would not be greater than those associated with operation
 17 of the Byron site and expected to be SMALL. Noise levels and impacts from operation of the
 18 IGCC, combination, and purchased power are expected to be SMALL to MODERATE. Noise
 19 levels for these three alternatives are dependent on the distance of receptors to the noise
 20 sources unique to the technology. For instance, the IGCC alternative will introduce noise
 21 associated with rail delivery predicted to be in the 80 to 96 dBA range. The wind power portion
 22 of the combination alternative will introduce wind turbine noise levels that can reach 105 dBA.

23 **4.4 Geologic Environment**

24 This section describes the potential impacts of the proposed action (license renewal) and
 25 alternatives to the proposed action on geologic and soil resources.

26 During construction, for all the alternatives to the proposed action discussed in this section,
 27 sources of aggregate such as crushed stone and sand and gravel would be required to
 28 construct buildings, foundations, roads, and parking lots. These resources would likely be

1 obtained from commercial suppliers using local or regional sources. In addition, land would be
 2 cleared of vegetation. Land clearing during construction and the installation of power plant
 3 structures and impervious surfaces would expose soils to erosion and alter surface drainage.
 4 To reduce soil erosion, BMPs would be implemented in accordance with applicable permitting
 5 requirements. These practices would include use of sediment fencing, staked hay bales, check
 6 dams, sediment ponds, riprap aprons at construction and laydown yard entrances, mulching
 7 and geotextile matting of disturbed areas, and rapid reseeding of temporarily disturbed areas.
 8 Removed soils and any excavated materials would be stored on site for redistribution, such as
 9 for backfill at the end of construction. Therefore, for all the alternatives to the proposed action,
 10 construction impacts on geologic and soil resources would be SMALL.

11 Table 4–4 identifies issues related to geology and soils that are applicable to the Byron Station
 12 during the renewal term. Section 3.4 describes the local and regional geologic environment of
 13 the Byron site.

14 **Table 4–4. Geology and Soils Issues**

Issue	GEIS Section	Category
Geology and soils	4.4.1	1

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

15 **4.4.1 Proposed Action**

16 As further discussed below, the impact by the proposed action on geology and soil resources
 17 are SMALL.

18 The NRC staff did not identify any new and significant information associated with the
 19 Category 1 geology and soils issues identified in Table 4–4 during the review of the applicant’s
 20 ER (Exelon 2013a), the site audit, the scoping process, or the evaluation of other available
 21 information. As a result, no information or impacts related to these issues were identified that
 22 would change the conclusions presented in the GEIS (NRC 1996, 2013a). For these geology
 23 and soils issues, the GEIS concludes that the impacts are SMALL. Therefore, it is expected
 24 that there would be no incremental impacts related to these Category 1 issues during the
 25 renewal term beyond those discussed in the GEIS, and therefore the impacts associated with
 26 these issues by the proposed action would be SMALL.

27 **4.4.2 No-Action Alternative**

28 There would not be any impacts to the geology and soils at the Byron site with shutdown of the
 29 facility. Therefore, impacts would be SMALL.

30 **4.4.3 New Nuclear Alternative**

31 This alternative would be located at an existing plant site or retired coal plant site. As such, it
 32 would be located in an area where the soils had already been disturbed by previous activities at
 33 the site. For this alternative, the impacts on the geology and soil resources would occur during
 34 construction. As discussed in Section 4.4 of the GEIS (NRC 2013a), construction impacts for all
 35 alternatives to the proposed actions would be SMALL, and therefore the impact of this
 36 alternative on geology and soil resources would be SMALL.

Environmental Consequences and Mitigating Actions

1 **4.4.4 IGCC Alternative**

2 This alternative would be located at an existing plant site. As such, it would be located in an
3 area where the soils had already been disturbed by previous activities at the site. For this
4 alternative, the impacts on the geology and soil resources would occur during construction. As
5 discussed in Section 4.4 of the GEIS (NRC 2013a), construction impacts for all alternatives to
6 the proposed actions would be SMALL, and therefore the impact of this alternative on geology
7 and soil resources would be SMALL.

8 **4.4.5 NGCC Alternative**

9 This alternative would be located at an existing plant site or retired coal plant site. As such, it
10 would be located in an area where the soils had already been disturbed by previous activities at
11 the site. For this alternative, the impacts on the geology and soil resources would occur during
12 construction. As discussed in Section 4.4 of the GEIS (NRC 2013a), construction impacts for all
13 alternatives to the proposed actions would be SMALL, and therefore the impact of this
14 alternative on geology and soil resources would be SMALL.

15 **4.4.6 Combination Alternative (NGCC, Wind, Solar)**

16 This alternative requires a large amount of land (up to 19,790 ac (8,009 ha)). However, much of
17 the land would be undisturbed. For this alternative, the impacts on the geology and soil
18 resources would occur during construction. As discussed in Section 4.4 of the GEIS
19 (NRC 2013a), construction impacts for all alternatives to the proposed actions would be SMALL,
20 and therefore the impact of this alternative on geology and soil resources would be SMALL.

21 **4.4.7 Purchased Power**

22 The impacts of this alternative on the geology and soil resources are likely to be bounded by the
23 impact descriptions of the other alternatives, and therefore the impact of this alternative on
24 geology and soil resources would be SMALL.

25 **4.5 Water Resources**

26 This section describes the potential impacts of the proposed action (license renewal) and
27 alternatives to the proposed action on surface water and groundwater resources.

28 **4.5.1 Proposed Action**

29 *4.5.1.1 Surface Water Resources*

30 The Category 1 (generic) and Category 2 surface water use and quality issues applicable to
31 Byron are discussed in the following sections and listed in Table 4–5. Surface water
32 resource-related aspects and conditions relevant to the Byron site are described in
33 Section 3.5.1.

1

Table 4–5. Surface Water Resources Issues

Issue	GEIS Section	Category
Surface water use and quality (non-cooling system impacts)	4.5.1.1	1
Altered current patterns at intake and discharge structures	4.5.1.1	1
Scouring caused by discharged cooling water	4.5.1.1	1
Discharge of metals in cooling system effluents	4.5.1.1	1
Discharge of biocides, sanitary wastes, and minor chemical spills	4.5.1.1	1
Surface water use conflicts (plants with cooling ponds or cooling towers using makeup water from a river)	4.5.1.1	2
Effects of dredging on surface water quality	4.5.1.1	1
Temperature effects on sediment transport capacity	4.5.1.1	1

Sources: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51; NRC 2013a

2 Generic Surface Water Resources

3 The NRC staff did not identify any new and significant information associated with the
4 Category 1 surface water issues identified in Table 4–5 during the review of the applicant’s ER
5 (Exelon 2013a), the site audit, the scoping process, or the evaluation of other available
6 information. As a result, no information or impacts related to these issues were identified that
7 would change the conclusions presented in the GEIS (NRC 2013a). For these issues the GEIS
8 concludes that the impacts are SMALL. Therefore, it is expected that there would be no
9 incremental impacts related to these Category 1 issues during the renewal term beyond those
10 discussed in the GEIS, and therefore the impacts associated with these issues by the proposed
11 action would be SMALL.

12 The Category 2 (Table 4–5) issue related to surface water during the renewal term is discussed
13 in the following text.

14 Surface Water Use Conflicts

15 This section presents the NRC staff’s review of the plant-specific (Category 2) surface water use
16 conflict issue listed in Table 4–5.

17 *Plants with Cooling Ponds or Cooling Towers Using Makeup Water From a River*

18 For nuclear power plants using cooling towers or cooling ponds supplied with makeup water
19 from a river, the potential impact on the flow of the river and its availability to meet the demands
20 of other users is a Category 2 issue. This designation requires a plant-specific assessment.

21 In evaluating the potential impacts resulting from surface water use conflicts associated with
22 license renewal, the NRC staff uses as its baseline the surface water resource conditions as
23 described in Sections 3.1.3 and 3.5.1. These baseline conditions encompass the defined
24 hydrologic (flow) regime of the surface water(s) potentially affected by continued operations as
25 well as the magnitude of surface water withdrawals for cooling and other purposes (as
26 compared to relevant appropriation and permitting standards). The baseline also considers
27 other downstream uses and users of surface water.

28 The mean annual discharge of the Rock River (see Section 3.5.1.1) measured at the
29 U.S. Geological Survey (USGS) gage at Como, Illinois, is 6,033 cubic feet per second (cfs)

Environmental Consequences and Mitigating Actions

1 (170 cubic meters per second (m^3/s)). As described in Section 3.5.1.2, Byron's average surface
2 water withdrawal rate from the Rock River is 83.2 cfs ($2.35 m^3/s$ or 53.8 mgd), with consumptive
3 use averaging 52.9 cfs ($1.5 m^3/s$ or 34.2 mgd). This results in a rate of consumption of
4 0.9 percent of the Rock River's average flow. Further, the lowest annual mean flow recorded
5 for the Rock River at Como, Illinois, is 2,187 cfs ($61.9 m^3/s$), and the mean
6 90 percent-exceedance flow is 1,760 cfs ($49.7 m^3/s$) for the period of record. Compared to
7 these measures of reduced river flow, Byron's consumptive water use represents a 2.4- and a
8 3.0-percent reduction, respectively, in the flow of the Rock River downstream of Byron Station.

9 In addition, the provisions of Exelon's agreement with the State pursuant to Byron's construction
10 permit for its cooling water intake limit the plant's consumptive use of surface water to no more
11 than 9 percent of total river flow when river flow is at or below 679 cfs ($19.1 m^3/s$). This
12 condition would represent a consumptive use totaling about 61 cfs ($1.7 m^3/s$) for Byron
13 operations (see Section 3.5.1.2). Under low river flow conditions, a plant operating procedure
14 stipulates actions that Exelon personnel must take to maintain compliance including reducing
15 circulating water makeup and blowdown flows and, if necessary, reducing reactor power output
16 to reduce consumptive water use.

17 The construction permit also limits Byron's maximum makeup withdrawal rate from the river to
18 125 cfs ($3.5 m^3/s$). However, the maximum (nominal) surface water withdrawal rate for Byron is
19 about 101 cfs ($2.85 m^3/s$), and, as a result, the maximum permitted withdrawal rate would not
20 likely be exceeded during the period of continued operations.

21 Future Rock River flow is not expected to significantly change over the license renewal period
22 (Dziegielewski et al. 2005; Exelon 2013a). Future water demand (both groundwater and
23 surface water) in the Illinois counties within the Rock River basin is projected to increase by
24 about 10 percent from 2000 to 2025. Most of this projected demand is for thermoelectric
25 generation near the southern end of the river in the County of Rock Island (Dziegielewski
26 et al. 2005; IEPA 2006).

27 In conclusion, operation of Byron during the license renewal term is not expected to result in a
28 water use conflict on the Rock River. Byron's surface water withdrawals and low rate of
29 consumptive use of Rock River flow is very unlikely to impact the downstream availability and
30 instream uses of surface water. Byron's surface water withdrawals are also subject to low-flow
31 limitations imposed by the State of Illinois. Therefore, the NRC staff concludes that the potential
32 impacts on surface water resources and downstream water availability from Byron's
33 consumptive water use during the license renewal term would be SMALL.

34 4.5.1.2 Groundwater Resources

35 Table 4–6 identifies issues related to groundwater that are applicable to Byron Station during
36 the renewal term. Section 3.5.2 describes groundwater resources at the Byron Station.

37 The NRC staff did not identify any new and significant information associated with the
38 Category 1 groundwater issues identified in Table 4–6 during the review of the applicant's ER,
39 the site audit, the scoping process, or the evaluation of other available information. As a result,
40 no information or impacts related to these issues were identified that would change the
41 conclusions presented in the GEIS (NRC 2013a). For these issues, the GEIS concludes that
42 the impacts are SMALL. Therefore, it is expected that there would be no incremental impacts
43 related to these Category 1 issues during the renewal term beyond those discussed in the
44 GEIS, and therefore the impacts associated with these issues by the proposed action would be
45 SMALL.

1

Table 4–6. Groundwater Issues

Issue	GEIS Section	Category
Groundwater contamination and use (noncooling system impacts)	4.5.1.2	1
Groundwater use conflicts (plants that withdraw less than 100 gpm)	4.5.1.2	1
Groundwater use conflicts (plants with closed-cycle cooling systems that withdraw makeup water from a river)	4.5.1.2	2
Radionuclides released to groundwater	4.5.1.2	2

Source: Table B-1 in Appendix B, Subpart A to 10 CFR Part 51

2 The Category 2 issues related to groundwater during the renewal term are discussed in the
 3 following text (see also Table 4–6).

4 Groundwater Use Conflicts (Plants Using Cooling Towers or Cooling Ponds and Withdrawing
 5 Makeup Water From a Small River)

6 The issue of groundwater use conflicts applies to the Byron Station because it uses cooling
 7 towers and withdraws water from a small river. Cooling towers lose water to the atmosphere by
 8 evaporation and drift. As a result, less water is returned to Rock River than is withdrawn. This
 9 issue evaluates the impact of consuming river water and its impact on groundwater supplies.

10 The Rock River Alluvium is hydrologically connected to both the Galena-Platteville Dolomite
 11 Aquifer and the St. Peter Sandstone Aquifer. Groundwater from these aquifers discharges into
 12 the river alluvium. As described in Section 4.5.1.1, the low impact of plant water consumption
 13 on Rock River flows over the period of licensing, and therefore on river water levels, means that
 14 local aquifers in the site area are very unlikely to suffer dewatering from the consumptive use of
 15 river water by the Byron plant. Therefore, the NRC staff concludes that impacts to groundwater
 16 use would be SMALL.

17 Radionuclides Released to Groundwater

18 As described in Section 3.5.2.3, Exelon discovered in 2006 that water had leaked from some of
 19 the vacuum breaker vaults located along the blowdown pipeline running from the plant to the
 20 Rock River. The leaked water contaminated a small area of the Galena-Platteville Dolomite
 21 aquifer near a few vacuum breaker vaults with low levels of tritium. Other than tritium, no
 22 radionuclides above their lower limit of laboratory detection were or have since been discovered
 23 from these leaks. Tritium concentrations in the area of contamination were and are well below
 24 the EPA drinking water standard of 20,000 picocuries per liter. Exelon has improved monitoring
 25 along the pipeline and taken additional measures to prevent future groundwater contamination
 26 from the discharge pipeline.

27 Probably as a result of dilution from local recharge to the aquifer and from dispersion, from 2007
 28 to 2013, tritium concentrations in the areas of groundwater contamination have steadily
 29 decreased. There are no wells between the area of contamination and the river (in the direction
 30 of groundwater flow); therefore, it is not anticipated that tritium-contaminated groundwater would
 31 be intercepted by a private well user. Any tritium in the groundwater that reached the Rock
 32 River would be greatly reduced in concentration by the relatively large volumes of water flowing
 33 in the river.

Environmental Consequences and Mitigating Actions

1 Remediation of the contaminated groundwater at Byron Station is not planned by Exelon,
2 because of its low tritium concentrations, limited extent of the contamination, and because the
3 problems causing the leaks from the vacuum breakers along the pipeline have been corrected.
4 The NRC staff will continue to monitor any unanticipated radionuclide releases and take
5 appropriate regulatory action, as warranted. Final cleanup of the site, including contaminated
6 geologic materials, would be addressed by Exelon with NRC oversight during decommissioning
7 of the facility.

8 Based on its review, the NRC staff concludes that inadvertent releases of tritium have not
9 substantially impaired site groundwater quality and future groundwater quality impacts are not
10 anticipated. The NRC staff therefore concludes that groundwater quality impacts from
11 “radionuclides released to groundwater” are SMALL.

12 **4.5.2 No-Action Alternative**

13 *4.5.2.1 Surface Water Resources*

14 The rate of consumptive use of surface water would greatly decrease and eventually cease after
15 Byron is shut down. Wastewater discharges would be reduced considerably. Shutdown would
16 reduce the impacts on surface water use and quality. Therefore, the impact of this alternative
17 on surface water resources would be SMALL.

18 *4.5.2.2 Groundwater Resources*

19 With the cessation of operations at the Byron site, the consumption of groundwater would be
20 much less and there should be little or no impacts on groundwater quality. Therefore, the
21 impact of this alternative on groundwater resources would be SMALL.

22 **4.5.3 New Nuclear Alternative**

23 *4.5.3.1 Surface Water Resources*

24 Impacts from construction activities on surface water resources associated with the new nuclear
25 alternative would be considerable in scale by virtue of the land area required for new nuclear
26 units (i.e., 355 ac (143 ha)). Deep excavation work for the nuclear island as well as extensive
27 site clearing and a large laydown area for facility construction would have the potential for direct
28 and indirect impacts on water resources.

29 Construction activities would alter any onsite surface water drainage features. Some temporary
30 impacts to surface water quality may result from increased sediment loading and from any
31 pollutants in stormwater runoff from disturbed areas, from excavation, and any dredge-and-fill
32 activities. Stormwater runoff from construction areas and spills and leaks from construction
33 equipment could potentially affect downstream surface water quality. Nevertheless, application
34 of BMPs in accordance with a State-issued National Pollutant Discharge Elimination System
35 (NPDES) general permit, including appropriate waste management, water discharge,
36 stormwater pollution prevention, and spill prevention practices, would prevent or minimize any
37 surface water quality or groundwater quality impacts during construction.

38 In addition, the NRC staff assumes that any existing intake and discharge infrastructure at an
39 alternative site location would be refurbished and used to maximize use of existing facilities.
40 This would reduce construction-related impacts on surface water quality. Dredge-and-fill
41 operations would be conducted under a permit from the U.S. Army Corps of Engineers
42 (USACE) and State-equivalent permits requiring the implementation of applicable BMPs to
43 minimize associated impacts.

1 The staff assumes that there would be no direct use of surface water during construction
2 because it is expected that groundwater would be used or water could be supplied by a local
3 water utility or trucked to the point of use. During construction, the dewatering of excavations
4 would not be expected to affect offsite surface water bodies.

5 The operation of the two new nuclear units would require an estimated 83.5 cfs (2.4 m³/s or
6 54 million gallons per day (mgd)) of surface water for cooling makeup and related processes.
7 Consumptive water use would be approximately 62 cfs (1.75 m³/s or 40 mgd), equivalent to
8 approximately 1.0 percent of the Rock River's average flow. The projected consumptive use
9 under this alternative represents about 17 percent more surface water than current Byron
10 operations, which consume approximately 52.9 cfs (1.5 m³/s or 34.2 mgd) (see Sections 3.5.1.2
11 and 4.5.1.1). However, the NRC staff expects that that State would impose limits on surface
12 water withdrawals and consumption during low river flows, similar to those currently in place for
13 Byron, which would reduce the cited makeup water and consumptive use demands for this
14 alternative on an annualized basis.

15 The NRC staff further expects that water treatment additives for new nuclear plant operations
16 and effluent discharges would be relatively similar in quality and volume to Byron. Additionally,
17 effluent discharges and storm water discharges would be subject to a State-issued NPDES
18 permit, and surface water withdrawals would be subject to applicable state water appropriation
19 and registration requirements. To prevent and respond to accidental nonnuclear releases to
20 surface water, facility operations would be conducted in accordance with a spill prevention,
21 control, and countermeasures plan; storm water pollution prevention plan; or equivalent plans
22 and associated BMPs and procedures.

23 Based on the above, the overall impacts on surface water use and quality from construction and
24 operations under the new nuclear alternative would be SMALL to MODERATE.

25 4.5.3.2 *Groundwater Resources*

26 For this alternative, as discussed in Section 4.5 of the GEIS, construction impacts for all
27 alternatives to the proposed action on groundwater resources would be SMALL. Also as
28 discussed in Section 4.5 of the GEIS, operational impacts for all alternatives to the proposed
29 action on groundwater quality would be SMALL. During operations the consumptive use of
30 groundwater would be similar to the proposed action. Therefore, the impacts of this alternative
31 on groundwater resources would be SMALL.

32 **4.5.4 IGCC Alternative**

33 4.5.4.1 *Surface Water Resources*

34 Impacts from construction activities associated with the IGCC alternative on surface water
35 resources would be expected to be similar to but somewhat greater than those under the new
36 nuclear alternative (see Section 4.5.3.1). The potential for greater impacts is attributable to the
37 additional land required for construction of the power blocks for four IGCC units and for
38 excavation and construction of other onsite facilities for coal handling and storage, and for coal
39 ash and scrubber waste management. The same assumptions for construction and operations
40 also apply to this alternative, except as noted.

41 Some temporary impacts to surface water quality may result from increased sediment loading
42 and from pollutants in stormwater runoff from disturbed areas and from excavation and
43 dredge-and-fill activities. There also would be the potential for hydrologic and water-quality
44 impacts to occur from the extension or refurbishment of rail spurs to transport coal and other
45 materials to, and coal ash from, potential site locations. Use of the Byron site would have the
46 advantage of use of the existing cooling water intake, effluent discharge, and rail infrastructure.

Environmental Consequences and Mitigating Actions

1 Regardless, as described in Section 4.5.3.1 for the new nuclear alternative, water-quality
2 impacts would be minimized by the application of BMPs and compliance with State-issued
3 NPDES permits for construction. Any dredge-and-fill operations would be conducted under a
4 permit from the USACE and State-equivalent permits requiring the implementation of BMPs to
5 minimize impacts.

6 Operation of an IGCC plant would require less makeup water and would have lower
7 consumptive use than either the new nuclear alternative or current Byron operations. The
8 projected cooling water makeup requirement for an IGCC plant under this alternative is 51 cfs
9 (1.44 m³/s or 33 mgd), with consumptive use of about 40 cfs (1.14 m³/s or 26 mgd). This
10 alternative would consume about 24 percent less surface water than current Byron operations,
11 which consumes approximately 52.9 cfs (1.5 m³/s or 34.2 mgd).

12 As summarized in Section 4.5.3.1 for the new nuclear alternative, surface water withdrawals
13 and effluent discharges would be subject to applicable regulatory requirements under this
14 alternative. However, management of runoff and leachate from coal and ash storage facilities
15 would require additional regulatory oversight and would present an additional risk to surface
16 water resources in proximity to site locations.

17 For this alternative, based on the projected magnitude of ground disturbance and hydrologic
18 alteration and potential water quality impacts from coal and ash handling and management,
19 impacts on surface water resources would range from SMALL to MODERATE.

20 4.5.4.2 Groundwater Resources

21 For this alternative, as discussed in Section 4.5 of the GEIS, construction impacts for all
22 alternatives to the proposed action on groundwater resources would be SMALL. Also as
23 discussed in Section 4.5 of the GEIS, operational impacts for all alternatives to the proposed
24 action on groundwater quality would be SMALL. During operations the consumptive use of
25 groundwater would be similar to the proposed action. Therefore, the impacts of this alternative
26 on groundwater resources would be SMALL.

27 4.5.5 NGCC Alternative

28 4.5.5.1 Surface Water Resources

29 Direct impacts from construction activities associated with the NGCC alternative on surface
30 water resources would be expected to be much smaller than those under either the new nuclear
31 or IGCC alternative. A new NGCC plant and associated pipelines would occupy a much smaller
32 footprint (i.e., about 94 ac (38 ha)) than the current Byron plant or the proposed new nuclear or
33 IGCC facilities. This would result in less extensive excavation and earthwork. Otherwise, the
34 same assumptions for construction and operations also apply to this alternative, except as
35 noted. In particular, use of the Byron site would offer the advantage of use of the existing
36 cooling water intake and discharge infrastructure.

37 Some temporary impacts to surface water quality may result from increased sediment loading
38 and from any pollutants in stormwater runoff from disturbed areas, from excavation, and
39 dredge-and-fill activities. Depending on the path of any required new gas pipelines and
40 transmission lines to service the NGCC plant, some stream crossings could be necessary.
41 However, because of the short-term nature of any required dredging and filling and
42 stream-crossing activities, the hydrologic alterations and sedimentation would be localized and
43 water-quality impacts would be temporary and would cease after construction has been
44 completed and the site stabilized. The use of modern pipeline construction techniques, such as
45 horizontal directional drilling, would further minimize the potential for water-quality impacts in the
46 affected streams. In addition, as described in Section 4.5.3.1 for the new nuclear alternative,

1 water-quality impacts would be minimized by the application of BMPs and compliance with
2 State-issued NPDES permits for construction. Any dredge-and-fill operations would be
3 conducted under a permit from the USACE and State-equivalent permits requiring the
4 implementation of BMPs to minimize impacts.

5 For onsite facility operations, a five-unit NGCC plant would have a smaller cooling water
6 demand and lower consumptive water use as compared to current Byron operations and the
7 new nuclear and IGCC alternatives. It is projected that an NGCC plant would require
8 approximately 26.3 cfs (0.74 m³/s or 17 mgd) of surface water for cooling and related
9 processes, with consumptive use totaling about 20.1 cfs (0.57 m³/s or 13 mgd). Thus, this
10 alternative would consume about 62 percent less surface water than current Byron operations,
11 which consumes approximately 52.9 cfs (1.5 m³/s or 34.2 mgd).

12 Based on this analysis, the overall impacts on surface water resources from construction and
13 operations under the NGCC alternative would be SMALL.

14 4.5.5.2 *Groundwater Resources*

15 For this alternative, as discussed in Section 4.5 of the GEIS, construction impacts for all
16 alternatives to the proposed action on groundwater resources would be SMALL. Also as
17 discussed in Section 4.5 of the GEIS, operational impacts for all alternatives to the proposed
18 action on groundwater quality would be SMALL. During operations the consumptive use of
19 groundwater would be similar to the proposed action. Therefore, the impacts of this alternative
20 on groundwater resources would be SMALL.

21 4.5.6 **Combination Alternative (NGCC, Wind, Solar)**

22 4.5.6.1 *Surface Water Resources*

23 For the NGCC component of this alternative, the impacts on surface water resources from
24 facility construction and operations at either the Byron site or alternative sites would be a
25 fraction of those described in Section 4.5.5.1 because the NGCC plant would be scaled back to
26 a single 360-MW unit. As a result, operational cooling water demands would be reduced by
27 about 85 percent.

28 Impacts on surface water resources from constructing up to 2,532 land-based wind turbines
29 would primarily be limited to the relatively small amounts of water needed at each installation
30 site for dust suppression and soil compaction during site clearing and for concrete production.
31 Construction of utility-scale solar PV farms would require relatively large volumes of water per
32 site due to the much larger land area required per MW of replacement power produced. For
33 both components under this alternative, the NRC assumes that required water would be
34 procured from offsite sources and trucked to the point of use on an as-needed basis. Water
35 could also be supplied via a local water utility. The likely use of ready-mix concrete would also
36 reduce the need for onsite use of nearby water sources for construction.

37 Installation of land-based wind turbines and utility-scale solar PV farms would also require
38 construction of access roads and possibly transmission lines (especially for sites not already
39 proximal to transmission line corridors). Access road construction would also require some
40 water for dust suppression and roadbed compaction and would have the potential to result in
41 soil erosion and stormwater runoff from cleared areas. For construction, water would likely be
42 trucked to the point of use from offsite locations along with road construction materials. In all
43 cases, it is expected that construction activities would be conducted in accordance with
44 State-issued NPDES or equivalent permits for stormwater discharges associated with
45 construction activity, which would require the implementation of appropriate BMPs to prevent or
46 mitigate water-quality impacts. In contrast to land-based wind turbine sites and utility-scale

Environmental Consequences and Mitigating Actions

1 solar PV farms, installation of small solar PV units on rooftops and at already-developed sites
2 within the electric service ROI (see Section 2.2.2) would have little or no impact on surface
3 water resources.

4 To support the operation of wind turbine and PV installations, no direct use of surface water
5 would be expected. Water would likely be obtained from groundwater or purchased from a
6 water utility. Regardless, only very small amounts of water would be needed to periodically
7 clean turbine blades and motors and could be trucked to the point of use as part of routine
8 servicing. Water also would be required to clean panels at solar PV farms or situated in rooftop
9 arrays. Adherence to appropriate waste management and minimization plans, spill prevention
10 practices, and pollution prevention plans during servicing of wind turbine and solar PV
11 installations and operation of vehicles connected with site operations would minimize the risks
12 to soils and surface water resources from spills of petroleum, oil, and lubricant products and
13 stormwater runoff.

14 In consideration of these facts, the impacts on surface water resources from construction and
15 operations under the combination alternative would be SMALL.

16 4.5.6.2 *Groundwater Resources*

17 For this alternative, as discussed in Section 4.5 of the GEIS, construction impacts for all
18 alternatives to the proposed action on groundwater resources would be SMALL. Also as
19 discussed in Section 4.5 of the GEIS, operational impacts for all alternatives to the proposed
20 action on groundwater quality would be SMALL. During operations the consumptive use of
21 groundwater would be much smaller than the proposed action. Therefore, the impacts of this
22 alternative on groundwater resources would be SMALL.

23 4.5.7 **Purchased Power**

24 4.5.7.1 *Surface Water Resources*

25 The impacts of this alternative on surface water resources are likely to be bounded by the
26 impact descriptions for the other alternatives, except that no new construction would be likely.
27 Specifically, new and continued operation of nuclear, coal-fired, and natural gas-fired plants and
28 renewable energy projects would not be expected to result in incremental impacts on surface
29 water use and quality that are greater than those described in Sections 4.5.3, 4.5.4, 4.5.5, and
30 4.5.6 provided that all energy-generating facilities operate within their associated water use and
31 NPDES permits. Therefore, the impact of this alternative on surface water resources would be
32 expected to range from SMALL to MODERATE.

33 4.5.7.2 *Groundwater Resources*

34 The impacts of this alternative on groundwater resources are likely to be bounded by the impact
35 descriptions for the other alternatives. Therefore, the impact of this alternative on groundwater
36 resources would be SMALL.

37 4.6 **Terrestrial Resources**

38 This section describes the potential impacts of the proposed action (license renewal) and
39 alternatives to the proposed action on terrestrial resources.

40 4.6.1 **Proposed Action**

41 Section 3.6 of this SEIS describes terrestrial resources on and in the vicinity of the Byron site.
42 The generic (Category 1) and site-specific (Category 2) issues that apply to terrestrial resources

1 during the proposed license renewal period appear in Table 4–7. The GEIS (NRC 2013a)
 2 discusses these issues in Section 4.6.1.1.

3 **Table 4–7. Terrestrial Resource Issues**

Issue	GEIS Section	Category
Effects on terrestrial resources (noncooling system impacts)	4.6.1.1	2
Exposure of terrestrial organisms to radionuclides	4.6.1.1	1
Cooling tower impacts on vegetation (plants with cooling towers)	4.6.1.1	1
Bird collisions with plant structures and transmission lines ^(a)	4.6.1.1	1
Water use conflicts with terrestrial resources (plants with cooling ponds or cooling towers using makeup water from a river)	4.6.1.1	2
Transmission line ROW management impacts on terrestrial resources ^(a)	4.6.1.1	1
Electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees, wildlife, livestock) ^(a)	4.6.1.1	1

^(a) This issue applies only to the inscope portion of electric power transmission lines, which are defined as transmission lines that connect the nuclear power plant to the substation where electricity is fed into the regional power distribution system and transmission lines that supply power to the nuclear plant from the grid.

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

4 **4.6.1.1 Generic Terrestrial Resource Issues**

5 For the generic (Category 1) terrestrial resources issues listed in Table 4–7, the NRC staff did
 6 not identify any new and significant information related to the generic (Category 1) issues listed
 7 above during the review of the applicant’s ER (Exelon 2013a), the site audit, or the scoping
 8 process. Therefore, the NRC staff expects no impacts associated with these issues beyond
 9 those discussed in the GEIS. The GEIS concludes that the impact level for each of these
 10 issues is SMALL.

11 **4.6.1.2 Effects on Terrestrial Resources (Noncooling System Impacts)**

12 In the GEIS (NRC 2013a), the NRC staff determined that noncooling system effects on
 13 terrestrial resources is a Category 2 issue (see Table 4–7) that requires site-specific evaluation
 14 during each license renewal review. According to the GEIS, noncooling system impacts can
 15 include those impacts that result from landscape maintenance activities, stormwater
 16 management, elevated noise levels, and other ongoing operations and maintenance activities
 17 that would occur during the renewal period and that could affect terrestrial resources on and
 18 near the Byron site.

19 Section 3.6 indicates that approximately 1,244 ac (503 ha) of the Byron site (70 percent)
 20 remains as natural areas that are either leased for agricultural use or as unmanaged forest,
 21 meadow, or grassland habitat (Exelon 2014). The majority of site landscape maintenance is
 22 performed within the protected area and not within natural areas on the site. Typically, only
 23 trees and shrubs that pose a safety or security threat are removed from natural areas. Leased
 24 lands are maintained by the leasee in accordance with the standing lease.

25 Stormwater on the Byron site drains into the Construction Runoff Pond. From the pond, water
 26 either flows into the Unit 2 natural draft cooling tower basin where it becomes part of the
 27 circulating water system, or it flows through NPDES Outfall 003 via drainage ditches located

Environmental Consequences and Mitigating Actions

1 along German Church Road to the north of the main plant complex (Exelon 2013a). Special
2 Condition 16 of the NPDES permit requires Exelon to develop and implement a Stormwater
3 Pollution Prevention Plan (Exelon 2013a). This plan identifies sources of pollution that could
4 affect the quality of stormwater and describes practices that Exelon uses to reduce such
5 pollutants. Areas with spill potential, such as areas around tanks that contain oil, are further
6 monitored under the Byron Station Spill Prevention Control and Countermeasure Plan.
7 Collectively, these measures ensure that the effects to terrestrial resources from pollutants
8 carried by stormwater would be small during the proposed license renewal term.

9 The GEIS (NRC 2013a) indicates that elevated noise levels could be a noncooling system
10 impact to terrestrial resources. However, the GEIS also concludes that generic noise impacts
11 would be small because noise levels would remain well below regulatory guidelines for offsite
12 receptors during continued operations and refurbishment associated with license renewal. The
13 NRC staff did not identify any information during its review that would indicate that noise
14 impacts to terrestrial resources at Byron would be unique or require separate analysis.

15 Other operations and maintenance activities that could occur in the future include the
16 replacement of the Unit 2 steam generators (SGs). While Exelon has previously replaced the
17 Unit 1 SGs, Exelon has not replaced the Unit 2 SGs. Exelon has no plans to replace the Unit 2
18 SGs at this time, but may choose to replace them prior to the end of the 40-year initial license
19 term. Because SG replacement is not necessary for safe operation during license renewal, the
20 NRC does not consider it part of the proposed action. As such, the impacts of Unit 2 SG
21 replacement on terrestrial resources are discussed in Section 4.16.4 rather than in this section.
22 Exelon (2013a) is planning no other land-disturbing activities or construction unrelated to
23 possible Unit 2 SG replacement. No disturbances to natural habitats would occur during license
24 renewal, and Exelon does not expect any changes in operations or changes to existing land
25 uses during the proposed license renewal period. As such, no measurable impacts to the
26 terrestrial environment are expected during the license renewal period.

27 When new activities that could impact the environment occur at Byron, Exelon follows several
28 procedures to ensure that potential environmental effects are considered and appropriately
29 addressed. Exelon maintains a procedure (No. EN-AA-103) that requires Exelon staff to screen
30 proposed activities, such as maintenance activities, operational changes, procedure changes,
31 and other facility activities, to determine if the activity warrants further evaluation for
32 environmental impact or risk (Exelon 2013b). If the activity warrants further evaluation, Exelon
33 Procedure No. EN-AA-103-F-02 provides guidance to Exelon staff on performing such an
34 evaluation and determining the environmental and regulatory impacts of the activity
35 (Exelon 2013b). This procedure also requires that implementation of the activity be halted until
36 any environmental impacts are addressed.

37 Based on the NRC staff's independent review, the staff concludes that the landscape
38 maintenance activities, stormwater management, elevated noise levels, and other ongoing
39 operations and maintenance activities that Exelon might undertake during the renewal term
40 would primarily be confined to disturbed areas of the Byron site. These activities would not
41 have noticeable effects on terrestrial resources, nor would they destabilize any important
42 attribute of the terrestrial resources on or in the vicinity of the Byron site. Therefore, the NRC
43 staff expects noncooling system impacts on terrestrial resources during the license renewal
44 term to be SMALL.

45 4.6.1.3 *Water Use Conflicts with Terrestrial Resources (Plants with Cooling Ponds or Cooling 46 Towers Using Makeup Water from a River)*

47 In the GEIS (NRC 2013a), the NRC staff determined that effects of water use conflicts on
48 terrestrial resources is a Category 2 issue (see Table 4–7) that requires site-specific evaluation

1 during each license renewal review. Water use conflicts occur when the amount of water
 2 needed to support terrestrial resources is diminished as a result of demand for agricultural,
 3 municipal, or industrial use or decreased water availability due to droughts, or a combination of
 4 these factors.

5 Section 4.5.1.1 addresses surface water use conflicts and concludes that the potential impacts
 6 on surface water resources and downstream water availability from Byron's consumptive water
 7 use during the license renewal term would be SMALL because the State of Illinois imposes
 8 withdrawal restrictions to ensure adequate instream and downstream flows. Section 4.7.1.2
 9 addresses water use conflicts with aquatic resources and determines that Byron has consumed
 10 a very small amount (between 0.7 and 1.7 percent) of the Rock River's flow each year for the
 11 past 12 years, under the conservative assumption that Byron was operating at 100 percent
 12 power at all times. This section concludes that the impacts of water use conflicts would be
 13 SMALL for terrestrial resources. The NRC staff finds no other impacts that would be
 14 experienced by riparian or other terrestrial habitats that are not discussed in Sections 4.5.1.1 or
 15 4.7.1.2. Accordingly, the NRC staff concludes that the impact of water use conflicts on
 16 terrestrial resources from the proposed license renewal would be SMALL.

17 **4.6.2 No-Action Alternative**

18 If Byron were to shut down, the impacts to terrestrial ecology would remain similar to those
 19 during operations until the plant is fully decommissioned. Temporary buildings and staging or
 20 laydown areas may be required during large component and structure dismantling. Byron is
 21 likely to have sufficient space within previously disturbed areas for these needs, and therefore,
 22 no additional land disturbances would occur on previously undisturbed land. Adjacent lands
 23 may experience temporary increases in erosional runoff, dust, or noise, but these impacts could
 24 be minimized with the implementation of standard BMPs (NRC 2002). In NUREG-0586,
 25 *Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities,*
 26 *Supplement 1*, NRC (2002) concludes generically that impacts to terrestrial ecology during
 27 decommissioning activities would be SMALL. Reclamation of the site following
 28 decommissioning could create terrestrial habitat in areas currently used as industrial areas. The
 29 GEIS (NRC 2013a) notes that terrestrial resource impacts could occur in other areas beyond
 30 the immediate nuclear plant site as a result of the no-action alternative if new power plants are
 31 needed to replace lost capacity. The NRC staff concludes that the no-action alternative is
 32 unlikely to noticeably alter or have more than minor effects on terrestrial resources. Thus, the
 33 NRC staff concludes that the impacts of the no-action alternative on terrestrial resources during
 34 the proposed license renewal term would be SMALL.

35 **4.6.3 New Nuclear Alternative**

36 The new nuclear alternative assumes that the new facility would be built at an existing nuclear
 37 or retired coal plant site within the ROI but outside of Illinois. Construction of the new nuclear
 38 plant would require an estimated 324 ac (131 ha) for permanent buildings and facilities and an
 39 additional 31 ac (12.5 ha) for temporary facilities and laydown areas. The NRC staff assumes
 40 that this alternative would use existing onsite structures and previously disturbed areas to the
 41 extent practicable to minimize new development in undisturbed areas. However, given the land
 42 requirements, it is expected that some undisturbed areas would be affected, which would
 43 directly impact terrestrial resources. During construction, terrestrial species could experience
 44 habitat loss or fragmentation, loss of food resources, and altered behavior due to noise and
 45 other construction-related disturbances. Erosion and sedimentation from clearing, leveling, and
 46 excavating land could affect adjacent riparian and wetland habitats, if present. Implementation
 47 of appropriate BMPs would minimize these effects. This alternative could also require

Environmental Consequences and Mitigating Actions

1 construction of new transmission lines or upgrades to existing lines. Because the new nuclear
2 facility would be located on an existing energy-producing site, transmission lines could likely be
3 colocated within existing transmission line corridors to minimize land disturbance. Although
4 construction activities could noticeably alter terrestrial resources through habitat loss or
5 fragmentation, construction is unlikely to destabilize any important attributes of the terrestrial
6 environment. The exact magnitude of impacts would vary based on the chosen location of the
7 facility and the amount and types of undisturbed habitat that would be affected by construction
8 of the alternative, and thus, impacts of construction could range from SMALL to MODERATE.

9 During operation, impacts would be similar in type and magnitude to those assessed in
10 Section 4.6.1 for continued operation of Byron under the proposed renewal term and would,
11 therefore, be SMALL.

12 The NRC concludes that the impacts of construction and operation of the new nuclear
13 alternative on terrestrial resources would be SMALL to MODERATE.

14 **4.6.4 IGCC Alternative**

15 The IGCC alternative assumes that the new facility would be built at an existing
16 energy-producing site or a retired coal plant site in Illinois or another state within the ROI. The
17 facility would require 2,000 ac (809 ha) of land to construct the facility. The NRC staff assumes
18 that this alternative would use existing onsite structures and previously disturbed areas to the
19 extent practicable to minimize new development in undisturbed areas. However, because the
20 footprint of the facility would be large, it is likely that construction would require clearing of
21 previously undisturbed terrestrial habitats. This would result in habitat loss and fragmentation
22 and loss of food resources. Terrestrial species may also alter their behaviors due to noise and
23 other construction-related disturbances. Erosion and sedimentation from clearing, leveling, and
24 excavating land could affect adjacent riparian and wetland habitats, if present. Implementation
25 of appropriate BMPs would minimize these effects. This alternative could also require
26 construction of new transmission lines or upgrades to existing lines. Because the IGCC facility
27 would be located on an existing energy-producing site, any new transmission lines could likely
28 be colocated within existing transmission line corridors to minimize land disturbance.
29 Depending on the site and terrestrial habitats present, construction activities could noticeably
30 alter or destabilize attributes of the terrestrial environment due to the large land requirements of
31 the facility. The exact magnitude of impacts would vary based on the chosen location of the
32 facility and the amount and types of undisturbed habitat that would be affected by construction
33 of the alternative. The NRC staff expects that impacts of construction on terrestrial resources
34 would be MODERATE.

35 The GEIS (NRC 2013a) concludes that impacts to terrestrial resources from operation of fossil
36 energy alternatives would essentially be similar to those from continued operations of a nuclear
37 facility. Unique impacts would include periodic maintenance dredging if coal is delivered by
38 barge, which could create noise, dust, and sedimentation. Dredging and delivery of coal to the
39 site could introduce minerals and trace elements to water resources on which terrestrial biota
40 rely. Such minerals could also bioaccumulate in nearby riparian or wetland habitats. Air
41 emissions during operation would include sulfur oxides and nitrogen oxides, which can combine
42 with water vapor and create sulfuric and nitric acids. These acids would then be released back
43 into the environment through precipitation, which could affect the acidity levels of water
44 resources and have detrimental effects to plant foliage. Acid precipitation has the potential to
45 destabilize the terrestrial environment by creating conditions that are too acidic for certain plants
46 or animals. The IGCC facility would also emit various GHGs during operation, which is an effect
47 that can have far-reaching consequences because GHGs contribute to climate change. The
48 effects of climate change on terrestrial resources are discussed in Section 4.13.3.2. The

1 various air emissions during operation of the IGCC facility could create noticeable impacts that
2 could destabilize certain attributes of the terrestrial environment, and therefore, the operational
3 impacts would be MODERATE.

4 The NRC concludes that the impacts of construction and operation of the IGCC alternative on
5 terrestrial resources would be MODERATE.

6 **4.6.5 NGCC Alternative**

7 The NGCC alternative assumes that the facility would be built at an existing energy-producing
8 site or a retired coal plant site in Illinois or another state within the ROI. The facility would
9 require 94 ac (38 ha) of land for the plant and associated pipelines. Because the footprint of the
10 facility would be relatively small, the entire construction footprint could likely be sited in already
11 developed areas of the site, which would minimize impacts to terrestrial habitats and species.
12 However, the level of direct impact would vary based on the specific location of new buildings
13 and infrastructure on the site. During construction, terrestrial species could experience habitat
14 loss or fragmentation, loss of food resources, and altered behavior due to noise and other
15 construction-related disturbances. Erosion and sedimentation from clearing, leveling, and
16 excavating land could affect adjacent riparian and wetland habitats, if present. Implementation
17 of appropriate BMPs would minimize these effects. This alternative could also require
18 construction of new transmission lines or upgrades to existing lines. Because the NGCC facility
19 would be located on an existing site, any new transmission lines could likely be colocated within
20 existing transmission line corridors to minimize land disturbance. Similarly, any new pipelines
21 could be colocated within existing pipeline corridors. Although construction activities could
22 noticeably alter terrestrial resources, primarily through habitat loss or fragmentation,
23 construction is unlikely to destabilize any important attributes of the terrestrial environment. The
24 exact magnitude of impacts would vary based on the chosen location of the facility and the
25 amount and types of undisturbed habitat that would be disturbed for construction of the
26 alternative, and thus, impacts of construction could range from SMALL to MODERATE.

27 The GEIS (NRC 2013a) concludes that impacts to terrestrial resources from operation of fossil
28 energy alternatives would essentially be similar to those from continued operations of a nuclear
29 facility. Unique impacts would include air emissions of GHGs such as nitrogen oxides, carbon
30 dioxide, and methane, all of which can have far-reaching consequences because they
31 contribute to climate change. The effects of climate change on terrestrial resources are
32 discussed in Section 4.13.3.2. Although the impacts of operating the NGCC alternative may be
33 noticeable, they are unlikely to destabilize any important attribute of the terrestrial environment
34 and would, therefore, be SMALL.

35 The NRC concludes that the impacts of construction and operation of the NGCC alternative on
36 terrestrial resources would be SMALL to MODERATE.

37 **4.6.6 Combination Alternative (NGCC, Wind, Solar)**

38 The NGCC component of this alternative would require the same amount of land as the NGCC
39 alternative (94 ac (38 ha)), but the NGCC component would likely make better use of existing
40 infrastructure because it would be sited at an existing power plant in Illinois or another state
41 within the ROI and could use buildings and structures that are already in place and operational
42 for the existing facility. The types of impacts on the terrestrial environment would be similar to
43 those discussed in Section 4.6.5, but the NRC staff expects the magnitude of impacts to be less
44 because of the use of existing infrastructure. Thus, the impacts of construction and operation of
45 the NGCC component of the combination alternative would be SMALL.

Environmental Consequences and Mitigating Actions

1 The wind component of the combination alternative would require 3,376 ac (1,366 ha) to
2 10,127 ac (4,098 ha) at sites across the ROI. However, the majority of this land would only be
3 temporarily disturbed during construction. Permanently disturbed land would hold the wind
4 turbines, access roads, and transmission lines. Land used for equipment laydown and turbine
5 component assembly and erection could be returned to its original state. Use of BMPs would
6 ensure that disturbed lands were appropriately restored to reduce the long-term impacts to the
7 terrestrial environment. Operation of wind turbines could uniquely affect terrestrial species
8 through mechanical noise, collision with turbines and meteorological towers, and interference
9 with migratory behavior. Bat and bird mortality from turbine collisions is an ongoing concern for
10 operating wind farms; however, recent developments in turbine design have reduced the
11 potential for bird and bat strikes. The NRC staff expects that this component has the potential
12 to noticeably alter terrestrial resources, primarily through the loss of habitat and bird and bat
13 mortalities associated with wind turbine operation. However, it is unlikely that the wind
14 component would destabilize any important attribute of the terrestrial environment, and thus,
15 impacts would be MODERATE.

16 The solar component would require 6,749 ac (2,731 ha) of land across the ROI. The majority of
17 solar installations could be installed on building roofs at existing residential, commercial, or
18 industrial sites or at larger standalone solar facilities, and thus, it is possible that little terrestrial
19 habitat would be disturbed during construction. However, the exact magnitude of impacts on
20 terrestrial resources would depend on the amount of terrestrial habitat that is lost or fragmented
21 during construction of solar installations. Operation would have no measurable effects on the
22 terrestrial environment. Overall impacts from construction and operation of this component of
23 the alternative would range from SMALL to MODERATE depending on the locations of solar
24 installations and the amount of terrestrial habitat affected.

25 The NRC staff concludes that the impacts of the combination alternative on terrestrial resources
26 would be SMALL to MODERATE.

27 **4.6.7 Purchased Power**

28 The purchased power alternative would have wide-ranging impacts that are hard to specifically
29 assess because this alternative could include a mixture of coal, natural gas, nuclear, and wind
30 across many different sites in the ROI. This alternative would likely have little to no construction
31 impacts because it would include power from already-existing power generating facilities. The
32 construction of additional transmission lines would require implementation of BMPs to minimize
33 erosion and sedimentation that could affect riparian areas and wetlands. The types of
34 operational impacts would be similar to the effects discussed in the preceding alternative
35 sections. This alternative would be more likely to intensify already-existing effects at power
36 generating facilities than create wholly new effects on terrestrial species and habitats. Existing
37 facilities would likely have BMPs and other procedures in place to ensure that effects to the
38 environment during operations are minimized. The NRC staff concludes that the impacts on
39 terrestrial resources from the purchased power alternative would be SMALL.

40 **4.7 Aquatic Resources**

41 This section describes the potential impacts of the proposed action (license renewal) and
42 alternatives to the proposed action on aquatic resources.

1 **4.7.1 Proposed Action**

2 Section 3.1.3 of this SEIS describes the Byron cooling and auxiliary water systems, and
 3 Section 3.7 describes the aquatic resources. The generic (Category 1) and site-specific
 4 (Category 2) issues that apply to aquatic resources at Byron during the proposed license
 5 renewal period appear in Table 4–8. The GEIS (NRC 2013a) discusses these issues in
 6 Section 4.6.1.2.

7 **Table 4–8. Aquatic Resource Issues**

Issue	GEIS Section	Category
All plants		
Entrainment of phytoplankton and zooplankton	4.6.1.2	1
Infrequently reported thermal impacts	4.6.1.2	1
Effects of cooling water discharge on dissolved oxygen, gas supersaturation, and eutrophication	4.6.1.2	1
Effects of nonradiological contaminants on aquatic organisms	4.6.1.2	1
Exposure of aquatic organisms to radionuclides	4.6.1.2	1
Effects of dredging on aquatic organisms	4.6.1.2	1
Effects on aquatic resources (noncooling system impacts)	4.6.1.2	1
Impacts of transmission line ROW management on aquatic resources ^(a)	4.6.1.2	1
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	4.6.1.2	1
Plants with cooling towers		
Impingement and entrainment of aquatic organisms	4.6.1.2	1
Thermal impacts on aquatic organisms	4.6.1.2	1
Plants with cooling ponds or cooling towers using makeup water from a river		
Water use conflicts with aquatic resources	4.6.1.2	2

^(a) This issue applies only to the inscope portion of electric power transmission lines, which are defined as transmission lines that connect the nuclear power plant to the substation where electricity is fed into the regional power distribution system and transmission lines that supply power to the nuclear plant from the grid.

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

8 **4.7.1.1 Generic GEIS Issues**

9 The GEIS (NRC 2013a) concludes that the 11 Category 1 issues listed in Table 4–8 would have
 10 a SMALL impact on aquatic resources during the license renewal term for all plants. For these
 11 issues, no additional plant-specific analysis is required unless new and significant information is
 12 identified.

13 During its review, the NRC staff considered Exelon’s ER, aquatic surveys and studies
 14 performed at Byron and in the Rock River, and available scientific literature; conducted a site
 15 audit; and considered Federal and State agency and public comments received during the
 16 scoping process. The NRC staff did not identify any new and significant information related to

Environmental Consequences and Mitigating Actions

1 any of the Category 1 issues. Therefore, no site-specific analysis is required for these issues,
2 and there would be no impacts associated with these issues beyond those discussed in the
3 GEIS.

4 4.7.1.2 *Water Use Conflicts With Aquatic Resources*

5 In the GEIS (NRC 2013a), the NRC staff determined that effects of water use conflicts on
6 aquatic resources is a Category 2 issue (see Table 4–8) that requires site-specific evaluation
7 during each license renewal review. Water use conflicts occur when the amount of water
8 needed to support aquatic resources is diminished as a result of demand for agricultural,
9 municipal, or industrial use or decreased water availability due to droughts, or a combination of
10 these factors.

11 According to USGS (2014) data from the nearest surface water gaging station (USGS Station
12 No. 05440700), the average annual flow of the Rock River at Byron, Illinois, in the past 12 data
13 years (2001 through 2012) has ranged from 4,834 cfs (139,900 liters per second (L/s) or
14 2.17 million gallons per minute (gpm)) in 2012 to 12,090 cfs (342,400 L/s or 5.43 million gpm) in
15 2008. At 100 percent power, Byron's circulating water system withdraws an average of
16 2,320 L/s (36,750 gpm) of makeup water. Thus, Byron uses between 0.7 and 1.7 percent of the
17 Rock River's flow each year for the past 12 years, under the conservative assumption that
18 Byron was operating at 100 percent power at all times. In times when the river flow is low,
19 Byron has an agreement with the Illinois Department of Natural Resources (IDNR) to limit Rock
20 River water consumption to no more than 9 percent of total river flow when flow is less than
21 19,200 L/s (679 cfs) (Exelon 2013a). The amount of Rock River water Byron consumes is
22 minor in comparison to the flow of water past the plant, and regulatory mechanisms are in place
23 to ensure that Byron does not consume an amount that would be harmful to aquatic biota during
24 low river flow conditions. The fish species described in Section 3.7 that occur in the Rock River
25 in the vicinity of the Byron site do not appear to be affected by the consumption of water from
26 the river. The NRC staff concludes that the impact of water use conflicts on aquatic resources
27 from the proposed license renewal would be SMALL.

28 **4.7.2 No-Action Alternative**

29 If Byron were to cease operating, impacts to aquatic ecology would decrease or stop following
30 reactor shutdown. Some withdrawal of water from the Rock River would continue during the
31 shutdown period as the fuel is cooled, although the amount of water withdrawn would decrease
32 over time. The reduced demand for cooling water would further decrease the effects of
33 impingement, entrainment, and thermal effluents, which were determined to be SMALL for
34 Byron during the proposed license renewal term (see Section 4.7.1.1). These effects would
35 likely stop following the removal of fuel assemblies from the reactor cores.

36 NUREG–0586, *Generic Environmental Impact Statement on Decommissioning of Nuclear*
37 *Facilities, Supplement 1*, concludes generically that impacts to aquatic ecology during
38 decommissioning activities would be SMALL for facilities at which the decommissioning
39 activities would be limited to existing operational areas (NRC 2002). In the case of Byron, the
40 NRC staff did not identify any effects that would have more than minor impacts on aquatic
41 resources. Thus, the NRC staff concludes that the impacts of the no-action alternative on
42 aquatic resources during the proposed license renewal term would be SMALL.

43 **4.7.3 New Nuclear Alternative**

44 Construction of a new nuclear alternative would occur at an existing power plant site (other than
45 the Byron site) or at a retired coal plant site outside of Illinois. Construction activities could

1 degrade water quality of nearby streams, ponds, or rivers through erosion and sedimentation;
2 result in loss of habitat through pond or wetland filling; or result in direct mortality of aquatic
3 organisms from dredging or other inwater work. Due to the short-term nature of construction
4 activities, these effects would likely be relatively localized and temporary. Siting the plant on an
5 existing site could make use of existing transmission lines, roads, parking areas, and other
6 infrastructure, which would limit the amount of habitat disturbance that would be required. Less
7 habitat disturbance would create less erosion and sedimentation. The construction of intake
8 and discharge structures could result in direct mortality of individuals as well as water quality
9 degradation. Appropriate permits would ensure that water quality impacts would be addressed
10 through mitigation or BMPs, as stipulated in the permits. The U.S. Environmental Protection
11 Agency, USACE, or the State would oversee applicable permitting, including a Clean Water Act
12 Section 404 permit, Section 401 certification, and Section 402(p) NPDES general stormwater
13 permit. The NRC (2013g) has completed the review of one combined license (COL) application
14 to build and operate a new nuclear plant in the ROI (Enrico Fermi 3 in Michigan) and found that
15 construction would have SMALL impacts on aquatic resources. Without more specific details on
16 the location of the new nuclear alternative, the NRC staff finds it reasonable to adopt previous
17 conclusions regarding Enrico Fermi 3 for the construction portion of this alternative.

18 Operational impacts would include those listed in Table 4–8, and the GEIS (NRC 2013a)
19 conclusions of SMALL for Category 1 issues in the table would apply during the operational
20 phase of the new nuclear alternative. Water use conflicts with aquatic resources would depend
21 on the site location, water body, and specific aquatic community present and cannot be
22 determined without more-specific details on the location of this alternative.

23 The NRC staff concludes that the impacts to aquatic resources from construction and operation
24 of a new nuclear alternative would be SMALL.

25 **4.7.4 IGCC Alternative**

26 Construction of an IGCC alternative would occur at the Byron site or another existing power
27 plant site in the ROI. The GEIS (NRC 2013a) indicates that the impacts of new power plant
28 construction on ecological resources would be qualitatively similar. Thus, those impacts
29 discussed under the new nuclear alternative would apply during the construction phase.
30 Because the IGCC alternative would require significantly more land than the new nuclear
31 alternative (2,000 ac (809 ha) versus 355 ac (144 ha)), the magnitude of impacts would likely be
32 greater and could create noticeable effects on aquatic resources. Thus, construction impacts
33 would be MODERATE.

34 Operation of the IGCC alternative would require less cooling water than Byron. Accordingly,
35 impingement, entrainment, and thermal effects on aquatic resources would likely be smaller
36 than for continued operation of Byron, though the exact magnitude would depend upon the
37 water body and specific aquatic communities present. Chemical discharges from the cooling
38 system would be similar to those at Byron. Operation would require coal deliveries, cleaning,
39 and storage, which would require periodic dredging (if coal is delivered by barge); create dust,
40 sedimentation, and turbidity; and introduce trace elements and minerals into the water. Air
41 emissions from the IGCC units would include small amounts of sulfur dioxide, particulates, and
42 mercury that would settle on water bodies or be introduced into the water from soil erosion. If
43 the IGCC plant were located on the same water body (the Rock River) in the vicinity of the
44 Byron site, overall operational impacts would be similar to the continued operation of Byron with
45 the exception of air emissions. However, without knowing the location of the IGCC plant, the
46 associated water body, aquatic species, and their interactions within the ecosystem, the NRC
47 staff cannot assume that overall impacts of operation of an IGCC plant would not create

Environmental Consequences and Mitigating Actions

1 noticeable effects on the aquatic environment. Thus, impacts could range from SMALL to
2 MODERATE.

3 The NRC staff concludes that the impacts to aquatic resources from construction of an IGCC
4 plant would be MODERATE and the impacts of operation would be within the range of SMALL
5 to MODERATE.

6 **4.7.5 NGCC Alternative**

7 Construction of an NGCC alternative would occur at the Byron site or another existing power
8 plant site in the ROI. The GEIS (NRC 2013a) indicates that the impacts of new power plant
9 construction on ecological resources would be qualitatively similar. Thus, those impacts
10 discussed under the new nuclear alternative would apply during the construction phase.
11 Construction of new pipelines, if necessary, could impact previously undisturbed habitats. This
12 impact would vary depending on the location of the plant and would be more likely to impact
13 terrestrial resources than aquatic resources. Because the NGCC alternative would be built on
14 an existing power plant site, new pipelines could be colocated in existing corridors to reduce
15 impacts. Overall, construction impacts would be SMALL.

16 Operation of the NGCC alternative cooling system would be qualitatively similar to the IGCC
17 alternative but would result in smaller impacts because the NGCC alternative would consume
18 less cooling water. Air emissions from the NGCC units would include nitrogen oxide, carbon
19 dioxide, and particulates that would settle on water bodies or be introduced into the water from
20 soil erosion. If the NGCC plant were located on the same water body (the Rock River) in the
21 vicinity of the Byron site, overall operational impacts would be less than for the continued
22 operation of Byron. However, without knowing the location of the NGCC plant, the associated
23 water body, aquatic species, and their interactions within the ecosystem, the NRC staff cannot
24 assume that overall impacts of operation of an NGCC plant would not create noticeable effects
25 on the aquatic environment. Thus, impacts could range from SMALL to MODERATE.

26 The NRC staff concludes that the impacts to aquatic resources from construction of an NGCC
27 plant would be SMALL and the impacts of operation would be within the range of SMALL to
28 MODERATE.

29 **4.7.6 Combination Alternative (NGCC, Wind, Solar)**

30 The NGCC portion of this alternative could be located at the Byron site or another existing
31 power plant site in the ROI. Construction and operation impacts would be qualitatively similar to
32 those discussed for the NGCC alternative, but would be much lower in magnitude due to the
33 smaller footprint of the plant, reduced cooling water consumption, and lowered air emissions.
34 The wind and solar portions of the alternative, which account for 90 percent of the alternative's
35 power generation, would not require cooling or consumptive water use during operation, and
36 thus, would not affect aquatic resources. The NRC staff concludes that the impacts on aquatic
37 resources from the combination alternative would be SMALL.

38 **4.7.7 Purchased Power**

39 The purchased power alternative would have wide-ranging impacts that are hard to specifically
40 assess because this alternative could include a mixture of coal, natural gas, nuclear, and wind
41 across many different sites in the ROI. This alternative would likely have little to no construction
42 impacts because it would include power from already-existing power generating facilities. The
43 construction of additional transmission lines would require implementation of BMPs to minimize
44 erosion and sedimentation in nearby streams, ponds, or rivers. The types of operational

1 impacts would be similar to the effects discussed in the preceding alternative sections. This
 2 alternative would be more likely to intensify already-existing effects at power generating facilities
 3 than create wholly new effects on aquatic species and habitats. Existing facilities would likely
 4 have BMPs and other procedures in place to ensure that effects to the environment during
 5 operations are minimized. The NRC staff concludes that the impacts on aquatic resources from
 6 the purchased power alternative would be SMALL.

7 **4.8 Special Status Species and Habitats**

8 This section describes the potential impacts of the proposed action (license renewal) and
 9 alternatives to the proposed action on special status species and habitats.

10 **4.8.1 Proposed Action**

11 Section 3.8 of this SEIS describes the special status species and habitats that have the
 12 potential to be affected by the proposed action. The discussion of species and habitats
 13 protected under the Endangered Species Act of 1973 (16 U.S.C. § 1531 et seq., herein referred
 14 to as ESA), includes a description of the action area as defined by the ESA section 7
 15 regulations at 50 CFR 402.02. The action area encompasses all areas that would be directly or
 16 indirectly affected by the proposed Byron license renewal.

17 Table 4–9 lists the one Category 2 issue related to special status species and habitats identified
 18 in the GEIS (NRC 2013a). Appendix D.1 contains information on the NRC staff’s section 7
 19 consultation with the U.S. Fish and Wildlife Service (FWS) for the proposed action. The NRC
 20 did not consult with the National Marine Fisheries Service (NMFS) as part of the Byron license
 21 renewal review because (as described in Sections 3.8 and 4.8.1.1) no species or habitats under
 22 NMFS’s jurisdiction occur within the action area.

23 **Table 4–9. Special Status Species and Habitat Issues**

Issue	GEIS Section	Category
Threatened, endangered, and protected species, critical habitat and essential fish habitat	4.6.1.3	2

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

24 **4.8.1.1 Species and Habitats Protected Under the Endangered Species Act**

25 **Species and Habitats Under the FWS’s Jurisdiction**

26 Section 3.8 considers whether the four Federally listed species and one proposed species
 27 identified in Table 4–10 occur in the action area based on each species’ habitat requirements,
 28 life history, and other available information. In that section, the NRC staff concludes that none
 29 of these species are likely to occur in the action area. The NRC staff also concludes that no
 30 candidate species, or proposed or designated critical habitat occur in the action area. Thus, the
 31 NRC staff concludes that the proposed action would have no effect on Federally listed species
 32 or habitats under FWS’s jurisdiction.

33 If in the future, a Federally listed species is observed on the Byron site, the NRC has measures
 34 in place to ensure that NRC staff would be appropriately notified so that the NRC staff could
 35 determine the appropriate course of action, such as possibly reinitiating section 7 consultation
 36 under the ESA with the FWS at that time. Byron’s operating licenses, Appendix B,

Environmental Consequences and Mitigating Actions

1 “Environmental Protection Plan,” Section 4.1, “Unusual or Important Environmental Events”
 2 (NRC 1985, 1987) require Exelon to report to the NRC within 24 hours any occurrence of a
 3 species protected by the ESA on the Byron site. Additionally, the NRC’s regulations containing
 4 notification requirements require that operating nuclear power reactors report to the NRC within
 5 4 hours “any event or situation, related to...protection of the environment, for which a news
 6 release is planned or notification to other government agencies has been or will be made” (Title
 7 10 of the *Code of Federal Regulations* (10 CFR) 50.72(b)(2)(xi)). Such notifications include
 8 reports regarding Federally listed species, as described in Section 3.2.12 of NUREG–1022,
 9 *Event Report Guidelines: 10 CFR 50.72 and 50.73* (NRC 2013b).

10 **Table 4–10. Effect Determinations for Federally Listed Species**

Species	Common Name	Federal Status ^(a)	Effect Determination
Mammals			
<i>Myotis septentrionalis</i>	northern long-eared bat	P	no effect
<i>Myotis sodalis</i>	Indiana bat	E	no effect
Plants			
<i>Lespedeza leptostachya</i>	prairie bush clover	T	no effect
<i>Platanthera leucophaea</i>	eastern prairie fringed orchid	T	no effect
<i>Dalea foliosa</i>	leafy prairie clover	E	no effect

^(a) E = endangered; T = threatened; P = proposed for Federal listing

Sources: Exelon 2013a; FWS 2013a, 2013b

11 Species and Habitats Under NMFS’s Jurisdiction

12 As discussed in Section 3.8, no species or habitats under NMFS’s jurisdiction occur within the
 13 action area. Thus, the NRC staff concludes that the proposed action would have no effect on
 14 Federally listed species or habitats under NMFS’s jurisdiction.

15 Cumulative Effects

16 The ESA regulations at 50 CFR 402.12(f)(4) direct Federal agencies to consider cumulative
 17 effects as part of the proposed action effects analysis. Under the ESA, cumulative effects are
 18 defined as “those effects of future State or private activities, not involving Federal activities, that
 19 are reasonably certain to occur within the action area of the Federal action subject to
 20 consultation” (50 CFR 402.02). Unlike the NEPA definition of cumulative impacts (see
 21 Section 4.16), cumulative effects under the ESA do not include past actions or other Federal
 22 actions requiring separate ESA section 7 consultation. When formulating biological opinions
 23 under formal section 7 consultation, the FWS and NMFS (1998) consider cumulative effects
 24 when determining the likelihood of jeopardy or adverse modification. Therefore, consideration
 25 of cumulative effects under the ESA is necessary only if listed species will be adversely affected
 26 by the proposed action (FWS 2014).

27 In the case of Byron, because the NRC staff concluded earlier in this section that the proposed
 28 license renewal would have no effect on listed, proposed, or candidate species or on designated
 29 or proposed critical habitat, consideration of cumulative effects is not necessary.

1 4.8.1.2 Species and Habitats Protected Under the Magnuson–Stevens Act

2 As discussed in Section 3.8, NMFS has not designated essential fish habitat (EFH) pursuant to
3 the Magnuson–Stevens Fishery Conservation and Management Act, as amended
4 (16 U.S.C. §§ 1801–1884; herein referred to as MSA) in the Rock River. Thus, the NRC staff
5 concludes that the proposed action would have no effect on EFH.

6 4.8.2 No-Action Alternative

7 Under the no-action alternative, Byron would shut down. Federally listed species and
8 designated critical habitat can be affected not only by operation of nuclear power plants but also
9 by activities during shutdown. The ESA action area for the no-action alternative would most
10 likely be the same or similar to the action area described in Section 3.8. The plant would
11 require substantially less cooling water, so potential impacts to aquatic species and habitats
12 would be reduced, although the plant would still require some cooling water for some time.
13 Changes in land use and other shutdown activities might affect terrestrial species differently
14 than under continued operation.

15 Because no Federally listed species or habitats occur in the action area, the no-action
16 alternative would likely have no effect on any such species or habitats. However, NRC would
17 assess the need for ESA consultation upon plant shutdown. The ESA forbids “take” of a listed
18 species, where “take” means “harass, harm, pursue, hunt, shoot, wound, kill, trap, capture, or
19 collect, or attempt to engage in any such conduct.” In the case of a take, ESA section 7
20 requires that NRC initiate consultation with the FWS or NMFS. The implementing regulations at
21 50 CFR 402.16 also direct Federal agencies to reinstate consultation in circumstances
22 where (a) the incidental take limit in a biological opinion is exceeded, (b) new information
23 reveals effects to Federally listed species or designated critical habitats that were not previously
24 considered, (c) the action is modified in a manner that causes effects not previously considered,
25 or (d) new species are listed or new critical habitat is designated that may be affected by the
26 action. An ESA section 7 consultation could identify impacts on Federally listed species or
27 critical habitat, require monitoring and mitigation to minimize such impacts, and provide a level
28 of exempted takes. Regulations and guidance regarding the ESA section 7 consultation
29 process are provided in 50 CFR Part 402 and in the *Endangered Species Consultation*
30 *Handbook* (FWS and NMFS 1998).

31 The effects on ESA-listed aquatic species would likely be smaller than the effects under
32 continued operation but would depend on the listed species and habitats present when the
33 alternative is implemented. The types and magnitudes of adverse impacts to terrestrial
34 ESA-listed species would depend on the shutdown activities and the listed species and habitats
35 present when the alternative is implemented, and thus, the NRC cannot forecast a particular
36 level of impact for this alternative.

37 4.8.3 New Nuclear Alternative

38 This alternative entails shutdown and decommissioning of Byron and construction of a new
39 nuclear alternative at an existing power plant site (other than the Byron site) or at a retired coal
40 plant site outside of Illinois. Section 4.8.2 discusses ESA considerations for the shutdown of
41 Byron.

42 Because the new nuclear alternative would be built outside of Illinois, the special status species
43 and habitats affected by the action would be different from those considered under the proposed
44 action. Because NRC would remain the licensing agency under this alternative, the ESA would
45 require NRC to initiate consultation with the FWS and NMFS, as applicable, prior to construction

Environmental Consequences and Mitigating Actions

1 to ensure that the construction and operation of the new nuclear plant would not adversely
2 affect any Federally listed species or adversely modify or destroy designated critical habitat.

3 In the unlikely event that the new nuclear plant is sited in an area that could affect water bodies
4 with designated EFH, which applies to only certain commercially harvested marine and
5 anadromous fish species, consultation with NMFS under the MSA would be required to assess
6 potential impacts to that habitat.

7 Because the types and magnitudes of adverse impacts to ESA-listed species and EFH would
8 depend on the proposed site, plant design, operation, and species and habitats listed when the
9 alternative is implemented, the NRC cannot forecast a particular level of impact for this
10 alternative.

11 **4.8.4 IGCC Alternative**

12 This alternative entails shutdown and decommissioning of Byron and construction of a new
13 IGCC facility at the Byron site or another existing power plant site in the ROI. Section 4.8.2
14 discusses ESA considerations for the shutdown of Byron.

15 Unlike the new nuclear alternative, the NRC does not license IGCC facilities, and the NRC
16 would not be responsible for initiating section 7 consultation if listed species or habitats might be
17 adversely affected under this alternative. The facilities themselves would be responsible for
18 protecting listed species because the ESA forbids take of a listed species.

19 If the IGCC alternative were to be built on the Byron site, the ESA action area might be different,
20 and the activities and structures associated with the site would be different from those described
21 for the proposed license renewal. If the IGCC alternative were to be built on a site other than
22 the Byron site, the listed species and habitats affected by the action would be different from
23 those identified for Byron. Because the types and magnitudes of adverse impacts to ESA-listed
24 species would depend on the proposed site, plant design, operation, and species and habitats
25 listed when the alternative is implemented, the NRC cannot forecast a particular level of impact
26 for this alternative.

27 **4.8.5 NGCC Alternative**

28 This alternative entails shutdown and decommissioning of Byron and construction of a new
29 NGCC facility at the Byron site or another existing power plant site in the ROI. Section 4.8.2
30 discusses ESA considerations for the shutdown of Byron.

31 Unlike the new nuclear alternative, the NRC does not license NGCC facilities, and the NRC
32 would not be responsible for initiating section 7 consultation if listed species or habitats might be
33 adversely affected under this alternative. The facilities themselves would be responsible for
34 protecting listed species because the ESA forbids take of a listed species.

35 If the NGCC alternative were to be built on the Byron site, the ESA action area might be
36 different, and the activities and structures associated with the site would be different from those
37 described for the proposed license renewal. If the NGCC alternative were to be built on a site
38 other than the Byron site, the listed species and habitats affected by the action would be
39 different from those identified for Byron. Because the types and magnitudes of adverse impacts
40 to ESA-listed species would depend on the proposed site, plant design, operation, and species
41 and habitats listed when the alternative is implemented, the NRC cannot forecast a particular
42 level of impact for this alternative.

1 **4.8.6 Combination Alternative (NGCC, Wind, Solar)**

2 This alternative entails shutdown and decommissioning of Byron and construction and operation
3 of a new NGCC plant at the Byron site or another existing power plant site in the ROI as well as
4 wind turbines and solar PV systems throughout the ROI. Section 4.8.2 discusses ESA
5 considerations for the shutdown of Byron.

6 Unlike the new nuclear alternative, the NRC does not license NGCC, wind, and solar facilities,
7 and the NRC would not be responsible for initiating section 7 consultation if listed species or
8 habitats might be adversely affected under this alternative. The facilities themselves would be
9 responsible for protecting listed species because the ESA forbids take of a listed species.

10 If part of the combination alternative were to be built on the Byron site, the ESA action area
11 might be different, and the activities and structures associated with the site would be different
12 from those described under continued operation. If parts of the combination alternative were to
13 be built on a site or sites other than the Byron site, the listed species and habitats affected by
14 the action would be different from those identified for Byron. Because the types and
15 magnitudes of adverse impacts to ESA-listed species would depend on the proposed site,
16 alternative design, operation, and species and habitats listed when the alternative is
17 implemented, the NRC cannot forecast a particular level of impact for this alternative.

18 **4.8.7 Purchased Power**

19 Because the purchased power alternative would include a mixture of coal, natural gas, nuclear,
20 and wind across many different sites in the ROI, the special status species and habitats affected
21 by the action would be different from those considered under the proposed action. This
22 alternative would be more likely to intensify already-existing effects at existing power generating
23 facilities than create wholly new effects on protected species and habitats. Because the types
24 and magnitudes of adverse impacts to ESA-listed species would depend on the proposed sites,
25 plant designs, operation, and species and habitats listed at the various sites when the
26 alternative is implemented, the NRC cannot forecast a particular level of impact for this
27 alternative. As with the other alternatives discussed previously, the facilities themselves, and
28 not the NRC, would be responsible for initiating section 7 consultation if listed species or
29 habitats might be adversely affected under this alternative. The NRC cannot forecast a
30 particular level of impact for this alternative.

31 **4.9 Historic and Cultural Resources**

32 This section describes the potential impacts of the proposed action (license renewal) and
33 alternatives to the proposed action on historic and cultural resources.

34 **4.9.1 Proposed Action**

35 The historic and cultural resource issue applicable to Byron during the license renewal term is
36 listed in Table 4–11. Section 3.9 of this SEIS describes the historic and cultural resources that
37 have the potential to be affected by the proposed action.

1

Table 4–11. Historic and Cultural Resources

Issue	GEIS Section	Category
Historic and Cultural Resources	4.7.1	2

Source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51

2 The National Historic Preservation Act of 1966, as amended (NHPA), requires Federal agencies
 3 to consider the effects of their undertakings on historic properties, and renewing the operating
 4 license of a nuclear power plant is an undertaking that could potentially affect historic properties.
 5 Historic properties are defined as resources eligible for listing in the National Register of Historic
 6 Places (NRHP). The criteria for eligibility are listed in 36 CFR Part 60.4 and include
 7 (1) association with significant events in history; (2) association with the lives of persons
 8 significant in the past; (3) embodiment of distinctive characteristics of type, period, or
 9 construction; and (4) sites or places that have yielded, or are likely to yield, important
 10 information.

11 The historic preservation review process (Section 106 of the NHPA) is outlined in regulations
 12 issued by the Advisory Council on Historic Preservation (ACHP) in 36 CFR Part 800.

13 In accordance with the provisions of the NHPA, the NRC is required to make a reasonable effort
 14 to identify historic properties included in or eligible for inclusion in the NRHP in the area of
 15 potential effect (APE). The APE for a license renewal action is the area at the power plant site,
 16 the transmission lines up to the first substation and immediate environs that may be affected by
 17 the license renewal decision, and land-disturbing activities associated with continued reactor
 18 operations. For Byron, the first substation is located on site at the 345-kV Byron Station
 19 switchyard (Exelon 2013b).

20 If historic properties are present within the APE, the NRC is required to contact the State
 21 Historic Preservation Office, assess the potential impact, and resolve any possible adverse
 22 effects of the undertaking (license renewal) on historic properties. In addition, the NRC is
 23 required to notify the State Historic Preservation Office if historic properties would not be
 24 affected by license renewal or if no historic properties are present. The State Historic
 25 Preservation Office is part of the Illinois Historic Preservation Agency (IHPA).

26 Consultation

27 In accordance with 36 CFR 800.8(c), on August 9, 2013, the NRC initiated consultations on the
 28 proposed action by writing to the ACHP and IHPA (NRC 2013d, 2013e). Also on
 29 August 9, 2013, the NRC initiated consultation with the following 14 Federally recognized tribes
 30 (NRC 2013f) (see Appendix D for a copy of these letters):

- 31 • Ho-Chunk Nation;
- 32 • Miami Tribe of Oklahoma;
- 33 • Peoria Tribe of Indians of Oklahoma;
- 34 • Citizen Potawatomi Nation;
- 35 • Sac and Fox Tribe of the Mississippi in Iowa/Meskwiki Nation;
- 36 • Sac and Fox Nation of Missouri in Kansas and Nebraska;
- 37 • Sac and Fox Nation;

- 1 • Pokagon Band of Potawatomi;
- 2 • Forest County Potawatomi;
- 3 • Hannahville Indian Community, Band of Potawatomi;
- 4 • Prairie Band Potawatomi Nation;
- 5 • Winnebago Tribe of Nebraska;
- 6 • Kickapoo Tribe in Kansas; and
- 7 • Kickapoo Tribe of Oklahoma.

8 By letter, the NRC provided information about the proposed action, defined the APE, and
9 indicated that the NHPA review would be integrated with the NEPA process, according to
10 36 CFR 800.8. NRC invited participation in the identification and possible decisions concerning
11 historic properties and also invited participation in the scoping process. The NRC received no
12 scoping comments from any of the tribes contacted. In September 2013, the NRC received a
13 determination from the IHPA stating no objection to the undertaking and that no historic
14 properties would be affected (IHPA 2013) (see Appendix D).

15 Exelon currently has no planned physical changes or license renewal-related ground-disturbing
16 activities at the Byron site (Exelon 2013b). As described in Section 3.9, there are no historic
17 properties or known NRHP-eligible historic or cultural resources located within the Byron APE.
18 However, non-NRHP eligible cultural resources are present within the APE and approximately
19 400 ac of the Byron site is undisturbed land (Exelon 2013b). Furthermore, the Illinois Inventory
20 of Archaeological Sites has identified the area along the banks of the Rock River in the Byron
21 site as having archaeological resource potential (ISM 2014). As a result, Exelon established a
22 draft Cultural Resource Management Plan (CRMP) to ensure historic and cultural resources are
23 considered prior to any ground-disturbing activities at Byron. The CRMP identifies locations of
24 known historic and cultural resource sites and previously disturbed areas within Byron property.
25 The CRMP also instructs Exelon staff on how to evaluate land-disturbing activity for possible
26 impacts to historic and cultural resources (Exelon 2013b). If historic or cultural resources are
27 inadvertently discovered during operational activities, the CRMP directs Exelon staff to stop
28 work, protect exposed resources, and contact Exelon environmental personnel to take
29 appropriate action (Exelon 2013b). Supplemental cultural resource surveys may be performed
30 on the affected areas based on consultation with the State Historic Preservation Office.
31 Day-to-day maintenance of the Byron site follows guidelines based on the type of land use, and
32 less developed areas are not regularly landscaped unless specially requested. Land known to
33 contain historic and cultural resources on the Byron site is not maintained any differently than
34 other landscapes within the property (Exelon 2013b).

35 Based on (1) there being currently no NRHP-eligible historic properties in the APE, (2) tribal
36 input, (3) Exelon's draft CRMP, (4) the fact that no license renewal-related physical changes or
37 ground-disturbing activities would occur, (5) IHPA input, and (6) cultural resource assessment,
38 license renewal would not affect any known historic properties (36 CFR Section 800.4(d)(1)).
39 Exelon could reduce the risk of potential impacts to historic and cultural resources located on or
40 near the Byron site by finalizing their draft CRMP, with input from the State Historic Preservation
41 Office, and by providing training on cultural resources for Exelon staff engaged in planning and
42 executing ground-disturbing activities.

Environmental Consequences and Mitigating Actions

1 **4.9.2 No-Action Alternative**

2 Not renewing the operating licenses and terminating reactor operations would have no effect on
3 historic properties and cultural resources on or in the immediate vicinity of Byron. A separate
4 environmental review would be conducted to determine the impacts of decommissioning
5 activities on historic properties and cultural resources.

6 **4.9.3 New Nuclear Alternative**

7 Any land areas potentially affected by the construction and operation of a new nuclear
8 alternative power plant would need to be surveyed to identify and record historic and
9 archaeological cultural resources. An inventory of a previously disturbed former plant industrial
10 site may still be necessary if the site has not been previously surveyed or to verify the level of
11 previous disturbance and to evaluate the potential for intact subsurface cultural resources to be
12 present. All potentially affected land areas would need to be surveyed, including land required
13 for new roads, transmission corridors, other right-of-ways (ROWs). Any cultural resources
14 found during these surveys would need to be evaluated for eligibility for listing on the NRHP.
15 Mitigation of adverse effects would need to be considered if eligible resources were
16 encountered. Areas with the greatest sensitivity and most significant cultural resources should
17 be avoided. Visual impacts on significant cultural resources, such as the viewsheds of historic
18 properties near the proposed power plant site, should also be assessed and evaluated.

19 The potential for impacts to historic and cultural resources from the construction and operation
20 of a new nuclear power plant would vary greatly depending on the location of the site. Cooling
21 towers could impact historic property viewsheds. However, given that the preference is to
22 construct a new nuclear power plant at a previously disturbed former power plant site,
23 avoidance of undisturbed land could further reduce potential impacts to historic and cultural
24 resources. Therefore, the impacts on historic and cultural resources from the construction and
25 operation of a new nuclear power plant would be SMALL.

26 **4.9.4 IGCC Alternative**

27 Any areas potentially affected by the construction and operation of an IGCC power plant would
28 need to be surveyed to identify and record historic and cultural resources. If the IGCC power
29 plant is constructed at the existing Byron site, previously disturbed areas known to not contain
30 historic and cultural resources could be used. If the power plant is sited on the approximately
31 400 ac (162 ha) of undisturbed land on the Byron site, a survey and inventory of potential
32 historic and cultural resources would need to be performed. If the IGCC power plant is sited at
33 an existing power plant site other than Byron, a cultural resource survey may still be necessary
34 if the site has not been previously surveyed or to verify the level of disturbance and evaluate the
35 potential for intact subsurface resources. Any resources found in these surveys would need to
36 be evaluated for eligibility on the NRHP, and mitigation of adverse effects would need to be
37 addressed if eligible resources were encountered. Areas with the greatest sensitivity should be
38 avoided. Visual impacts on significant cultural resources, such as the viewsheds of historic
39 properties near the proposed power plant site, should also be assessed and evaluated.

40 The potential for impacts on historic and cultural resources from the construction and operation
41 of an IGCC power plant would vary greatly depending on the location of the proposed site.
42 Given that the preference is to use a previously disturbed former power plant site and no major
43 infrastructure upgrades are necessary, avoidance of significant historic and cultural resources
44 should be possible and effectively managed under current laws and regulations. Therefore, the
45 impacts on historic and cultural resources from the IGCC alternative would be SMALL.

1 **4.9.5 NGCC Alternative**

2 Any areas potentially affected by the construction and operation of an NGCC power plant would
3 need to be surveyed to identify and record historic and cultural resources. If the NGCC power
4 plant is constructed at the existing Byron site, previously disturbed areas known to not contain
5 historic and cultural resources could be used. If the power plant is sited on the approximately
6 400 ac (162 ha) of undisturbed land on the Byron site, a survey and inventory of potential
7 historic and cultural resources would need to be performed. If the NGCC power plant is sited at
8 an existing power plant site other than Byron, a cultural resource survey may still be necessary
9 if the site has not been previously surveyed or to verify the level of disturbance and evaluate the
10 potential for intact subsurface resources. Additionally, plant operators would need to survey all
11 areas associated with the alternative (e.g., a new pipeline, roads, transmission corridors, other
12 ROWs). Any resources found in these surveys would need to be evaluated for eligibility on the
13 NRHP, and mitigation of adverse effects would need to be addressed if eligible resources were
14 encountered. Areas with the greatest sensitivity should be avoided. Visual impacts on
15 significant cultural resources, such as the viewsheds of historic properties near the proposed
16 power plant site, should also be assessed and evaluated.

17 The potential for impacts on historic and cultural resources from the construction and operation
18 of an NGCC power plant would vary greatly depending on the location of the proposed site.
19 Given that the preference is to use a previously disturbed former power plant site, avoidance of
20 significant historic and cultural resources should be possible and effectively managed under
21 current laws and regulations. However, historic and archaeological resources could potentially
22 be affected, depending on the resource richness of the land required for a new gas pipeline.
23 Therefore, the impacts on historic and cultural resources from the NGCC alternative would be
24 SMALL to MODERATE.

25 **4.9.6 Combination Alternative (NGCC, Wind, Solar)**

26 Areas potentially affected by the construction and operation of an NGCC power plant and wind
27 and solar PV power generating facilities would need to be surveyed to identify and record
28 historic and archaeological resources. Any historic and cultural resources found in these
29 surveys would need to be evaluated for eligibility on the NRHP, and mitigation of adverse
30 effects would need to be addressed if eligible resources were encountered.

31 Impacts to historic and cultural resources from the NGCC portion of this alternative would be
32 similar to the NGCC alternative in Section 4.9.5. The potential for impacts on historic and
33 cultural resources from the wind portion of this alternative would vary greatly, depending on the
34 location of the proposed sites. Areas with the greatest cultural sensitivity could be avoided or
35 effectively managed under current laws and regulations. Construction of wind farms and their
36 support infrastructure could impact historic and cultural resources because of earthmoving
37 activities (e.g., grading and digging) and the aesthetic changes to the viewshed of historic
38 properties located nearby. The impacts of the construction of a new solar PV alternative on
39 historic and cultural resources would vary depending on the form of the solar capacity installed.
40 Rooftop installations minimize land disturbance and the modifications necessary to the
41 transmission system, thereby minimizing impacts to historic and cultural resources. Land-based
42 installations would be larger than rooftop installations and will require some degree of land
43 disturbance for installation purposes, potentially causing greater impacts to historic and cultural
44 resources. Aesthetic changes caused by the installation of both forms could have a noticeable
45 effect on the viewshed of nearby historic properties. Using previously disturbed sites for
46 land-based installations and collocating any new transmission lines with existing ROWs could
47 minimize impacts to historic and cultural resources. Areas with the greatest amount of

Environmental Consequences and Mitigating Actions

1 significant resources could be avoided or effectively managed under current laws and
2 regulations. Therefore, depending on the resource richness of the sites chosen for the NGCC,
3 wind, and solar PV alternative, the impacts on historic and cultural resources could range from
4 SMALL to LARGE.

5 **4.9.7 Purchased Power**

6 No direct impacts on historic and cultural resources are expected from purchased power. If new
7 transmission lines were needed to convey power to the PJM Interconnection area, surveys
8 similar to those discussed in Section 4.9.3 would need to be performed. However, transmission
9 lines would likely be collocated with existing ROWs minimizing any impacts to historic and
10 cultural resources.

11 Indirectly, construction of new nuclear, coal-fired, and natural gas-fired plants, or wind energy
12 projects, and any new transmission lines to support increased demand in the purchased power
13 alternative could affect historic and cultural resources. Any areas potentially affected by
14 construction would need to be surveyed to identify and record historic and cultural resources.
15 Resources found in these surveys would need to be evaluated for eligibility on the NRHP, and
16 mitigation of adverse effects would need to be addressed if eligible resources were
17 encountered. Plant operators would need to survey all areas associated with operation of the
18 alternative (e.g., roads, transmission corridors, other ROWs). The potential for impacts on
19 historic and cultural resources would vary greatly depending on the location of the proposed
20 sites; however, using previously disturbed sites could greatly minimize impacts to historic and
21 cultural resources. Areas with the greatest sensitivity could be avoided or effectively managed
22 under current laws and regulations. Therefore, depending on the resource richness of the sites
23 chosen, the impacts on historic and cultural resources could range from SMALL to LARGE.

24 **4.10 Socioeconomics**

25 In license renewal environmental reviews, the NRC considers the environmental consequences
26 of the proposed action (i.e., continued reactor operations), the no-action alternative (i.e., not
27 renewing the operating license), and the environmental consequences of various alternatives for
28 replacing the nuclear power plant's generating capacity. In plant-specific environmental
29 reviews, the NRC staff compares the environmental impacts of license renewal with those of the
30 no-action alternative and replacement power alternatives to determine whether the adverse
31 environmental impacts of license renewal are great enough to deny the option of license
32 renewal for energy-planning decisionmakers.

33 **4.10.1 Proposed Action**

34 The Category 1 (generic) socioeconomic NEPA issues in 10 CFR Part 51, Appendix B to
35 Subpart A, Table B-1, applicable to the license renewal of Byron are shown in Table 4-12.
36 No Category 2 socioeconomic NEPA issues were identified during the review conducted for the
37 2013 GEIS revision (NRC 2013a). Socioeconomic effects of ongoing reactor operations at
38 Byron have become well-established as regional socioeconomic conditions have adjusted to the
39 presence of the nuclear power plant. These conditions are described in Section 3.10. Any
40 changes in employment and tax payments caused by license renewal and any associated
41 refurbishment activities could have a direct and indirect impact on community services and
42 housing demand, as well as traffic volumes in the communities around a nuclear power plant.

1 **Table 4–12. Socioeconomic NEPA Issues Affected by License Renewal**

Issue	GEIS Section	Category
Employment and income, recreation, and tourism	4.8.1.1	1
Tax revenues	4.8.1.2	1
Community services and education	4.8.1.3	1
Population and housing	4.8.1.4	1
Transportation	4.8.1.5	1

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

2 The supplemental site-specific socioeconomic impact analysis for the license renewal of Byron
3 included a review of Exelon’s ER (Exelon 2013a), scoping comments, other information records,
4 and a data-gathering site visit to Byron. NRC staff did not identify any new and significant
5 information during the review that would result in impacts that would exceed the predicted
6 socioeconomic impacts evaluated in the GEIS, and no additional socioeconomic NEPA issues
7 were identified beyond those listed in Table B-1.

8 In addition, Exelon indicated in its ER (Exelon 2013a) that it has no plans to add non-outage
9 workers during the license renewal term and that increased maintenance and inspection
10 activities could be managed using the current workforce. Consequently, people living in the
11 vicinity of Byron are not likely to experience any changes in socioeconomic conditions during
12 the license renewal term beyond what is currently being experienced. Therefore, the impact of
13 continued reactor operations during the license renewal term would not exceed the
14 socioeconomic impacts predicted in the GEIS. For these issues, the GEIS predicted that the
15 impacts would be SMALL for all nuclear plants.

16 **4.10.2 No-Action Alternative**

17 *4.10.2.1 Socioeconomics*

18 Not renewing the operating licenses and terminating reactor operations would have a noticeable
19 impact on socioeconomic conditions in the communities located near Byron. The loss of jobs
20 and income would have an immediate socioeconomic impact. Some, but not all, of the
21 approximately 890 employees (870 Exelon and 20 long-term contract employees) would begin
22 to leave after reactor operations are terminated; and overall tax revenue generated by plant
23 operations would be reduced (Exelon 2013a). Exelon pays annual property taxes to a number
24 of taxing entities within, and including, Ogle County. The Ogle County Treasurer collects
25 Byron’s property tax payment and disperses it to the various taxing entities to partially fund their
26 respective operating budgets. The taxing entities to which Exelon pays taxes include, but are
27 not limited to, the Byron Forest Preserve, the Oregon Park District, the Rock Valley Community
28 College 511, the Byron Unit 226 School District, the Byron Fire District, the Byron Library
29 District, Ogle County, and Rockvale Township (Exelon 2013a). The loss of tax revenue could
30 reduce or eliminate some public and educational services. Indirect employment and income
31 generated by plant operations would also be reduced.

32 Former Byron workers and their families could leave in search of employment elsewhere. The
33 increase in available housing along with decreased demand could cause housing prices to fall.
34 Since the majority of employees reside in Ogle, Lee, and Winnebago Counties, socioeconomic
35 impacts from the termination of reactor operations would be concentrated in these counties, with
36 a corresponding reduction in purchasing activity and tax revenue in the regional economy.

Environmental Consequences and Mitigating Actions

1 Income and revenue losses from the termination of reactor operations at Byron would directly
2 affect Ogle County and nearby communities most reliant on income from power plant
3 operations. The impact of the job loss, however, may not be as noticeable in local communities
4 given the amount of time required for decommissioning. The socioeconomic impacts from the
5 termination of nuclear plant operations (which may not entirely cease until after
6 decommissioning) would, depending on the jurisdiction, range from SMALL to LARGE.

7 *4.10.2.2 Transportation*

8 Traffic congestion caused by commuting workers and truck deliveries on roads in the vicinity of
9 Byron would be reduced after power plant shutdown. Most of the reduction in traffic volume
10 would be associated with the loss of jobs. The number of truck deliveries to Byron would be
11 reduced until decommissioning. Traffic-related transportation impacts would be SMALL as a
12 result of the shutdown of the nuclear power plant.

13 **4.10.3 New Nuclear Alternative**

14 *4.10.3.1 Socioeconomics*

15 Socioeconomic impacts are defined in terms of changes to the demographic and economic
16 characteristics and social conditions of a region. For example, the number of jobs created by
17 the construction and operation of a power plant could affect regional employment, income, and
18 expenditures.

19 Two types of jobs would be created by this alternative: (1) construction jobs, which are
20 transient, short in duration, and less likely to have a long-term socioeconomic impact, and
21 (2) power plant operations jobs, which have the greater potential for permanent, long-term
22 socioeconomic impacts. Workforce requirements for the construction and operation of a new
23 nuclear power plant were evaluated to measure their possible effects on current socioeconomic
24 conditions.

25 Exelon estimated the construction workforce would peak at 3,500 workers (NRC 2008). The
26 relative economic effect of this many workers on the local economy and tax base would vary
27 with the greatest impacts occurring in the communities where the majority of construction
28 workers would reside and spend their income. As a result, local communities could experience
29 a short-term economic “boom” from increased tax revenue and income generated by
30 construction expenditures and the increased demand for temporary (rental) housing and public
31 as well as commercial services.

32 After construction, local communities could experience a return to preconstruction economic
33 conditions. Based on this information and given the number of workers, socioeconomic impacts
34 during construction in communities near an existing nuclear power plant or retired coal site
35 could range from MODERATE to LARGE.

36 An estimated 812 workers would be required during nuclear power plant operations
37 (NRC 2008). Some Byron operations workers could transfer to the new nuclear power plant.
38 Local communities near the new nuclear power plant would experience the economic benefits
39 from increased tax revenue and income generated by operational expenditures and demand for
40 housing and public as well as commercial services. The amount of property tax payments
41 under the new nuclear alternative may also increase if additional land is required to support this
42 alternative.

43 This alternative would also result in a loss of approximately 890 relatively high-paying jobs at
44 Byron and a corresponding reduction in purchasing activity and revenue contributions to the
45 regional economy. Should Byron cease operations, there would be an immediate

1 socioeconomic impact to local communities and businesses from the loss of jobs (some, but not
2 all, of the 890 employees would begin to leave), and tax payments may be reduced. In addition,
3 the housing market could experience increased vacancies and decreased prices if operations
4 workers and their families move out of the region. The impact of the job loss, however, may not
5 be noticeable in local communities given the amount of time required for decommissioning of
6 the existing Byron facilities. Based on this information and given the number of operations
7 workers, socioeconomic impacts during nuclear power plant operations on local communities
8 could range from SMALL to MODERATE.

9 *4.10.3.2 Transportation*

10 Transportation impacts associated with construction and operation of a new nuclear power plant
11 would consist of commuting workers and truck deliveries of construction materials to the power
12 plant site. During periods of peak construction activity, up to 3,500 workers could be commuting
13 daily to the construction site (NRC 2008). Workers commuting to the construction site would
14 arrive via site access roads and the volume of traffic on nearby roads could increase
15 substantially during shift changes. In addition to commuting workers, trucks would be
16 transporting construction materials and equipment to the work site, thereby increasing the
17 amount of traffic on local roads. The increase in vehicular traffic would peak during shift
18 changes, resulting in temporary levels of service impacts and delays at intersections. Materials
19 could also be delivered by rail or barge, depending on the location. Traffic-related
20 transportation impacts during construction would likely range from MODERATE to LARGE.

21 Traffic-related transportation impacts on local roads would be greatly reduced after the
22 completion of the power plant. Transportation impacts would include daily commuting by the
23 operating workforce, equipment and materials deliveries, and the removal of commercial waste
24 material to offsite disposal or recycling facilities by truck. Traffic on roadways would peak during
25 shift changes, resulting in temporary levels of service impacts and delays at intersections.
26 Overall, at the new nuclear power plant site, transportation impacts would be SMALL to
27 MODERATE during operations.

28 **4.10.4 IGCC Alternative**

29 *4.10.4.1 Socioeconomics*

30 As explained in Section 4.10.3, two types of jobs would be created by this alternative:
31 (1) construction jobs, which are transient, short in duration, and less likely to have a long-term
32 socioeconomic impact, and (2) power plant operations jobs, which have the greater potential for
33 permanent, long-term socioeconomic impacts. Workforce requirements for the construction and
34 operation of the IGCC alternative were evaluated to measure their possible effects on current
35 socioeconomic conditions.

36 The construction workforce could peak at 4,600 workers (DOE 2010a), if the four new units are
37 constructed at four different locations. Fewer construction workers would be required if all units
38 are constructed at Byron or a single existing power plant site. The relative economic effect of
39 this many workers on the local economy and tax base would vary with the greatest impacts
40 occurring in the communities where the majority of construction workers would reside and
41 spend their income. As a result, local communities could experience a short-term economic
42 “boom” from increased tax revenue and income generated by construction expenditures and the
43 increased demand for temporary (rental) housing and public as well as commercial services.

44 After construction, local communities could experience a return to preconstruction economic
45 conditions. Based on this information and given the number of workers, socioeconomic impacts

Environmental Consequences and Mitigating Actions

1 during construction in communities near an existing power plant site could range from
2 MODERATE to LARGE.

3 An estimated 420 workers would be required during power plant operations (DOE 2010a), if the
4 four new units are operated at four different locations. Fewer workers would be required if all
5 four units are operated at Byron or a single existing power plant site. Local communities would
6 experience the economic benefits from increased tax revenue and income generated by
7 operational expenditures and demand for housing and public as well as commercial services.
8 The amount of property tax payments under the IGCC alternative may also increase if additional
9 land is required to support this alternative.

10 This alternative could also result in a loss of approximately 890 relatively high-paying jobs at
11 Byron and a corresponding reduction in purchasing activity and revenue contributions to the
12 regional economy. Should Byron cease operations, there would be an immediate
13 socioeconomic impact to local communities and businesses from the loss of jobs (some, but not
14 all, of the 890 employees would begin to leave), and tax payments may be reduced. In addition,
15 the housing market could experience increased vacancies and decreased prices if operations
16 workers and their families move out of the region. The impact of the job loss, however, may not
17 be noticeable in local communities given the amount of time required for decommissioning of
18 the existing Byron facilities. Based on this information and given the number of operations
19 workers, socioeconomic impacts during IGCC power plant operations on local communities
20 could range from SMALL to MODERATE.

21 *4.10.4.2 Transportation*

22 Transportation impacts associated with construction and operation of the four-unit IGCC power
23 plants would consist of commuting workers and truck deliveries of construction materials to
24 Byron or the existing power plant site. During periods of peak construction activity, up to
25 4,600 workers could be commuting daily to one or more construction sites. As previously
26 discussed, fewer workers would be commuting if all four units are constructed at Byron or a
27 single existing power plant site. Workers commuting to the construction site would arrive via
28 site access roads and the volume of traffic on nearby roads could increase substantially during
29 shift changes. In addition to commuting workers, trucks would be transporting construction
30 materials and equipment to the work site, thereby increasing the amount of traffic on local
31 roads. The increase in vehicular traffic would peak during shift changes, resulting in temporary
32 levels of service impacts and delays at intersections. Materials could also be delivered by rail or
33 barge, depending on location. Traffic-related transportation impacts during construction would
34 likely range from MODERATE to LARGE.

35 Traffic-related transportation impacts on local roads would be greatly reduced after the
36 completion of the power plant. The estimated maximum number of operations workers
37 commuting daily to one or more power plant sites could be 420 (DOE 2010a). Fewer workers
38 would be commuting if all four units are operated at the same site. Frequent coal and limestone
39 deliveries and ash removal by rail would add to the overall transportation impact. The increase
40 in traffic on roadways would peak during shift changes, resulting in temporary levels of service
41 impacts and delays at intersections. Onsite coal storage would make it possible to receive
42 several trains per day at a site with rail access. If the IGCC power plant is located on navigable
43 waters, coal and other materials could be delivered by barge. Coal and limestone delivery and
44 ash removal via rail would cause levels of service impacts due to delays at railroad crossings.
45 Overall, transportation impacts would be SMALL to MODERATE during IGCC power plant
46 operations.

1 **4.10.5 NGCC Alternative**

2 *4.10.5.1 Socioeconomics*

3 As explained in Section 4.10.3, two types of jobs would be created by this alternative:
4 (1) construction jobs, which are transient, short in duration, and less likely to have a long-term
5 socioeconomic impact, and (2) power plant operations jobs, which have the greater potential for
6 permanent, long-term socioeconomic impacts. Workforce requirements for the construction and
7 operation of the NGCC alternative were evaluated to measure their possible effects on current
8 socioeconomic conditions.

9 The construction workforce would peak at 1,783 workers (Exelon 2013a). The relative
10 economic effect of this many workers on the local economy and tax base would vary, with the
11 greatest impacts occurring in the communities where the majority of construction workers would
12 reside and spend their income. As a result, local communities near Byron or another existing
13 power plant site could experience a short-term economic “boom” from increased tax revenue
14 and income generated by construction expenditures and the increased demand for temporary
15 (rental) housing and public as well as commercial services.

16 After construction, local communities could experience a return to preconstruction economic
17 conditions. Based on this information and given the number of workers, socioeconomic impacts
18 during construction in communities near Byron or another existing power plant site could range
19 from MODERATE to LARGE.

20 An estimated 94 workers would be required during power plant operations (Exelon 2013a).
21 Local communities would experience the economic benefits from increased tax revenue and
22 income generated by operational expenditures and demand for housing and public as well as
23 commercial services. The amount of property tax payments under the NGCC alternative may
24 also increase if additional land is required to support this alternative.

25 This alternative would also result in a loss of approximately 890 relatively high-paying jobs at
26 Byron and a corresponding reduction in purchasing activity and revenue contributions to the
27 regional economy. Should Byron cease operations, there would be an immediate
28 socioeconomic impact to local communities and businesses from the loss of jobs (some, but not
29 all, of the 890 employees would begin to leave), and tax payments may be reduced. In addition,
30 the housing market could experience increased vacancies and decreased prices if operations
31 workers and their families move out of the region. The impact of the job loss, however, may not
32 be noticeable in local communities given the amount of time required for decommissioning of
33 the existing Byron Station facilities. Based on this information and given the number of
34 operations workers, socioeconomic impacts during NGCC power plant operations on local
35 communities could range from SMALL to MODERATE.

36 *4.10.5.2 Transportation*

37 Transportation impacts associated with construction and operation of a five-unit NGCC power
38 plant would consist of commuting workers and truck deliveries of construction materials to the
39 power plant site.

40 During periods of peak construction activity, up to 1,783 workers could be commuting daily to
41 the construction site. Workers commuting to the construction site would arrive via site access
42 roads and the volume of traffic on nearby roads could increase substantially during shift
43 changes. In addition to commuting workers, trucks would be transporting construction materials
44 and equipment to the work site, thus increasing the amount of traffic on local roads. The
45 increase in vehicular traffic would peak during shift changes, resulting in temporary levels of
46 service impacts and delays at intersections. Pipeline construction and modification of existing

Environmental Consequences and Mitigating Actions

1 natural gas pipeline systems could also have a temporary impact. Materials also could be
2 delivered by barge or rail, depending on location. Traffic-related transportation impacts during
3 construction would likely range from MODERATE to LARGE.

4 Traffic-related transportation impacts would be greatly reduced after completing the installation
5 of the NGCC alternative. Transportation impacts would include daily commuting by the
6 operating workforce, equipment and materials deliveries, and the removal of commercial waste
7 material to offsite disposal or recycling facilities by truck. The operations workforce of
8 94 workers would likely not be noticeable relative to total traffic volumes on local roadways.
9 Since fuel is transported by pipeline, the transportation infrastructure would experience little to
10 no increased traffic from plant operations. Overall, given the relatively small operations
11 workforce estimate of 94 workers, transportation impacts would be SMALL during power plant
12 operations.

13 **4.10.6 Combination Alternative (NGCC, Wind, Solar)**

14 *4.10.6.1 Socioeconomics*

15 As explained in Section 4.10.3, two types of jobs would be created by this alternative:
16 (1) construction jobs, which are transient, short in duration, and less likely to have a long-term
17 socioeconomic impact, and (2) operations jobs, which have the greater potential for permanent,
18 long-term socioeconomic impacts. Workforce requirements for the construction and operation
19 of the NGCC, wind, and solar generation components of this combination alternative were
20 evaluated to estimate their possible effects on current socioeconomic conditions.

21 Fewer workers would be required to construct the single NGCC unit at an existing power plant
22 site than the full-power NGCC alternative. Installation of an estimated 3,376 wind turbines
23 would likely be done in stages and could employ up to 931 construction workers (DOE 2010b).
24 Additional workers would be required to install solar PV systems on existing buildings or
25 structures at already-developed residential, commercial, or industrial sites. Similar to the wind
26 farms, installation would likely be done in stages and could employ up to 600 construction
27 workers (DOE 2010b).

28 Conversely, a small number of operations workers would be needed to operate the single
29 NGCC unit, and additional small numbers of workers would be required to maintain the wind
30 farms and PV systems. Local communities could experience the economic benefits from
31 increased tax revenue and income generated by operational expenditures and demand for
32 housing and public as well as commercial services. The amount of property tax payments
33 under the wind and solar PV components may also increase if additional land is required to
34 support this combination alternative.

35 This combination alternative would also result in a loss of approximately 890 relatively
36 high-paying jobs at Byron and a corresponding reduction in purchasing activity, tax payments,
37 and revenue contributions would occur in the surrounding regional economy. Should Byron
38 cease operations, there would be an immediate socioeconomic impact to local communities and
39 businesses from the loss of jobs (some, but not all, of the 890 employees would begin to leave),
40 and tax payments may be reduced. In addition, the housing market could experience increased
41 vacancies and decreased prices if operations workers and their families move out of the region.
42 The impact of the job loss, however, may not be noticeable in local communities given the
43 amount of time required for decommissioning of the existing Byron Station facilities. Based on
44 this information and given the relatively small numbers of construction and operations workers,
45 socioeconomic impacts during construction and operations on local communities would be
46 SMALL.

1 *4.10.6.2 Transportation*

2 Transportation impacts during the construction and operation of the NGCC unit as well as the
3 wind and solar components of this combination alternative would be less than the impacts for
4 any of the previous alternatives discussed. This is because the construction workforce for each
5 component and the volume of materials and equipment needing to be transported to the
6 respective construction site would be smaller than for any one of the individual replacement
7 power alternatives. In other words, the transportation impacts would not be concentrated as in
8 the other alternatives, but spread out over a wider area.

9 Workers commuting to the construction site would arrive via site access roads and the volume
10 of traffic on nearby roads could increase during shift changes. In addition to commuting
11 workers, trucks would be transporting construction materials and equipment to the work site,
12 thereby increasing the amount of traffic on local roads. The increase in vehicular traffic would
13 peak during shift changes, resulting in temporary levels of service impacts and delays at
14 intersections. Transporting heavy and oversized components on local roads could have a
15 noticeable impact over a large area. Some components and materials could also be delivered
16 by rail or barge, depending on location. Traffic-related transportation impacts during
17 construction could range from SMALL to MODERATE at the NGCC power plant, wind farms
18 and solar installations, depending on current road capacities and average daily traffic volumes.

19 During operations, transportation impacts would be less noticeable during shift changes and
20 maintenance activities. Given the small numbers of operations workers, the levels of service
21 traffic impacts on local roads from NGCC, wind farm, and solar PV operations would be SMALL.

22 **4.10.7 Purchased Power**

23 *4.10.7.1 Socioeconomics*

24 Purchased power from existing power generating facilities would not have any socioeconomic
25 impact, because there would be no change in power plant operations or workforce. If the
26 amount of purchased power exceeds the available supply, new electrical power generating
27 facilities would be needed. Construction and operation of a new electrical power generating
28 facility to supply purchased power could cause noticeable socioeconomic impacts in the
29 communities located near the new facility. The intensity of the impact would depend on the
30 number of workers required to build and operate the new electrical power generating facility and
31 the amount of increased demand for housing and public services.

32 Whether or not there would be a socioeconomic impact would depend on whether a new
33 electrical power generating facility was needed to supply purchased power. If a new power
34 generating facility is needed, socioeconomic impacts would range anywhere from SMALL to
35 LARGE.

36 *4.10.7.2 Transportation*

37 Similarly, purchased power from existing power generating facilities would also not have any
38 transportation impact, because there would be no change in power plant operations or
39 workforce. Construction and operation of a new electrical power generating facility could cause
40 noticeable transportation impacts depending on the number of workers and truck deliveries
41 required to build and operate the new electrical power generating facility. Traffic volumes could
42 increase noticeably on local roads during shift changes.

43 Whether or not there would be a transportation impact would depend on whether a new
44 electrical power generating facility was needed to supply purchased power. If a new power

Environmental Consequences and Mitigating Actions

1 generating facility is needed, transportation impacts would range anywhere from SMALL to
2 LARGE.

3 **4.11 Human Health**

4 This section describes the potential impacts of the proposed action (license renewal) and
5 alternatives to the proposed action on human health resources.

6 **4.11.1 Proposed Action**

7 The human health issues applicable to Byron are discussed below and are listed in Table 4–13
8 for Category 1, Category 2, and uncategorized issues. Table B-1 of Appendix B to Subpart A of
9 10 CFR Part 51 contains more information on these issues.

10 **Table 4–13. Human Health Issues**

Issue	GEIS Section	Category
Radiation exposures to the public	4.9.1.1.1	1
Radiation exposures to plant workers	4.9.1.1.1	1
Human health impact from chemicals	4.9.1.1.2	1
Microbiological hazards to the public (plants with cooling ponds or canals or cooling towers that discharge to a river)	4.9.1.1.3	2
Microbiological hazards to plant workers	4.9.1.1.3	1
Chronic effects of electromagnetic fields (EMFs) ^(a)	4.9.1.1.4	N/A ^(b)
Physical occupational hazards	4.9.1.1.5	1
Electric shock hazards ^(a)	4.9.1.1.5	2

^(a) This issue applies only to the inscope portion of electric power transmission lines, which are defined as transmission lines that connect the nuclear power plant to the substation where electricity is fed into the regional power distribution system and transmission lines that supply power to the nuclear plant from the grid.

^(b) N/A (not applicable) The categorization and impact finding definition does not apply to this issue

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51 (NRC 2013a)

11 *4.11.1.1 Normal Operating Conditions*

12 Generic Human Health Issues (Category 1)

13 The NRC staff did not identify any new and significant information during its review of Exelon's
14 ER (Exelon 2013a), the site audit, or the scoping process for the Category 1 issues listed in
15 Table 4–13. Therefore, there are no impacts related to these issues beyond those discussed in
16 the GEIS. For these Category 1 issues, the GEIS concluded that the impacts are SMALL.

17 *Chronic Effects of Electromagnetic Fields (EMFs)*

18 In the GEIS (NRC 2013a), the chronic effects of 60-Hz electromagnetic fields (EMFs) from
19 power lines were not designated as Category 1 or 2 and will not be until a scientific consensus
20 is reached on the health implications of these fields.

1 The potential for chronic effects from these fields continues to be studied and is not known at
2 this time. The National Institute of Environmental Health Sciences (NIEHS) directs related
3 research through the U.S. Department of Energy (DOE).

4 The report by NIEHS (NIEHS 1999) contains the following conclusion:

5 The NIEHS concludes that ELF-EMF (extremely low frequency-electromagnetic
6 field) exposure cannot be recognized as entirely safe because of weak scientific
7 evidence that exposure may pose a leukemia hazard. In our opinion, this finding
8 is insufficient to warrant aggressive regulatory concern. However, because
9 virtually everyone in the United States uses electricity and therefore is routinely
10 exposed to ELF-EMF, passive regulatory action is warranted such as continued
11 emphasis on educating both the public and the regulated community on means
12 aimed at reducing exposures. The NIEHS does not believe that other cancers or
13 non-cancer health outcomes provide sufficient evidence of a risk to currently
14 warrant concern.

15 This statement is not sufficient to cause the NRC staff to change its position with respect to the
16 chronic effects of EMFs. The NRC staff considers the GEIS finding of "UNCERTAIN" still
17 appropriate and will continue to follow developments on this issue.

18 Site-Specific Human Health Issues (Category 2)

19 *Microbiological Hazards to the Public*

20 In the GEIS (NRC 2013a), the NRC staff determined that effects of thermophilic microorganisms
21 on the public for plants using cooling ponds, lakes, or canals or cooling towers that discharge to
22 a river is a Category 2 issue (see Table 4–12) that requires site-specific evaluation during each
23 license renewal review.

24 In order to determine whether the continued operations of Byron could promote increased
25 growth of thermophilic microorganisms, and thus have an adverse effect on the public, the NRC
26 staff considered several factors: the thermophilic microorganisms of concern, Byron's thermal
27 effluent characteristics, Exelon's chlorination procedures, recreational Rock River use in the
28 vicinity of Byron, and input from the Illinois Department of Public Health (IDPH).

29 *Thermophilic Microorganisms of Concern*

30 Section 3.11.3 describes the thermophilic microorganisms that the GEIS identified to be of
31 potential concern at nuclear power plants and summarizes data from the Centers for Disease
32 Control and Prevention (CDC) on the prevalence of waterborne diseases associated with these
33 microorganisms that have been linked to recreational water use in the past 10 available data
34 years (1999 through 2008). CDC data indicate that no outbreaks or cases of waterborne
35 *Salmonella* or *Pseudomonas aeruginosa* infection from recreational waters have occurred in the
36 United States during this timeframe. *Shigella* and *Naegleria fowleri* infections linked to
37 exposure in recreational waters were rarely reported, and none of the reported cases occurred
38 in Illinois. Public exposure to aerosolized *Legionella* from nuclear plant operations is generally
39 not a concern because such exposure would be confined to a small area of the site to which the
40 public would not have access. Based on the information presented in Section 3.11.3, the
41 thermophilic organisms most likely to be of potential concern at Byron are *Shigella* and
42 *N. fowleri*.

43 *Byron Thermal Effluent Characteristics*

44 Byron discharges cooling tower blowdown to the Rock River at an average rate of 900 L/s
45 (14,000 gpm) (Exelon 2013a). Sections 3.1.3 and 3.5.1 describe the cooling system and
46 surface water characteristics, respectively.

Environmental Consequences and Mitigating Actions

1 The Illinois Administrative Code (IAC) Title 35, *Environmental Protection*, Section 302, “Water
2 Quality Standards,” stipulates that for thermal effluents, the maximum temperature rise shall not
3 exceed 2.8 °C (5 °F) above natural receiving water body temperatures and that the water
4 temperature at representative locations in the main river shall at no time exceed 33.7 °C (93 °F)
5 from April through November and 17.7 °C (63 °F) in other months (35 IAC 302.211). Special
6 Condition 12 of Byron’s NPDES permit (IEPA 2011) requires Exelon to perform daily
7 calculations to demonstrate compliance with the thermal water quality standard during times
8 when Rock River flow is less than 67,944 L/s (1,076,900 gpm) or the temperature difference
9 between the main river temperature and the water quality standard is less than 3 °F (1.6 °C).

10 In recent years, the highest daily blowdown temperature that Exelon reported was 39.4 °C
11 (103 °F) in July 2012 (Exelon 2013b). This temperature was recorded during drought conditions
12 in Illinois. Previously, the highest temperature had been 36 °C (97 °F) in August 2009
13 (Exelon 2013a). The July 2012 maximum temperature is below the optimum growth
14 temperature for the microorganisms of concern. At this temperature, *Shigella* could persist but
15 would be unlikely to experience enhanced growth or survival from the thermal addition of
16 cooling tower blowdown to the river. *N. fowleri* prefers much higher temperatures for optimum
17 growth (46 °C (115 °F)). *N. fowleri* has been isolated from thermally altered waters surrounding
18 power plant discharges at temperatures ranging from 35 to 41 °C (95 to 105.8 °F); however,
19 because the IAC normally limits discharge temperatures to 33.7 °C (93 °F), the species is
20 unlikely to be present in the water.

21 Additionally, the IAC prohibits the area and volume of thermal mixing from being more than
22 25 percent of the cross-sectional area or volume of stream flow (35 IAC 302.102). The Illinois
23 Environmental Protection Agency (IEPA) has determined that Byron meets this criterion, as
24 stated in Special Condition 3 of Byron’s NPDES permit (IEPA 2011). Thus, the IAC’s thermal
25 mixing limitations effectively minimize the area and volume over which microorganisms could
26 experience enhanced growth or survival.

27 *Byron Chlorination Procedures*

28 Chlorine is an effective disinfectant for water containing the microorganisms of concern. EPA
29 (1999a) reports that chlorination at concentrations of 1 to 2 milligrams per liter (mg/L) (1 to
30 2 parts per million (ppm)) in water at a pH of 6.0 to 8.0 can effectively eliminate health hazards
31 caused by bacteria, including *Shigella*. The CDC (2013) reports that chlorine at a concentration
32 of 1 ppm (1 mg/L) added to 77 °F (25 °C) clear water at a pH of 7.5 will reduce the number of
33 viable *Naegleria fowleri* trophozoites by 99.99 percent in 12 minutes.

34 Exelon chlorinates Rock River water, which is then used in Byron’s three cooling and auxiliary
35 water systems. Sodium hypochlorite and sodium bromide at target concentrations of 0.2 and
36 0.5 ppm are injected into each unit’s circulating water system for 2 hours per day per unit during
37 operation. The nonessential service water system is chlorinated by continuously injecting
38 sodium hypochlorite at a concentration of 0.05 to 0.2 ppm. The essential service water (SX)
39 system is also continuously chlorinated with sodium hypochlorite at a concentration of 0.05 to
40 0.2 ppm. Sodium bisulfate is added to water to eliminate any residual biocide concentration
41 prior to returning water to the Rock River (Exelon 2013b). Although Exelon chlorinates station
42 water at lower concentrations than those indicated by EPA and the CDC as most effectively
43 eliminating the microorganisms of concern, chlorination of the system is likely to prevent some
44 increased growth and survival of microorganisms that might otherwise result from operation of
45 Byron.

1 *Recreational Rock River Use in the Vicinity of Byron*

2 As discussed above, Byron’s thermal mixing zone is relatively small. Thus, the highest risk of
3 exposure to elevated levels of thermophilic microorganisms, if present, would likely be within the
4 restricted area. Additionally, the majority of land adjacent to the Rock River in the vicinity of
5 Byron is private and zoned for agricultural uses (OCPZD 2013). Thus, because public access
6 to waters that are thermally affected by Byron operations is limited, exposure of the public to
7 elevated levels of thermophilic microorganisms is unlikely. Additionally, the IAC prohibits mixing
8 “in water adjacent to bathing beaches, bank fishing areas, boat ramps or dockages or any other
9 public access area.” Thus, any changes in surrounding land use during the proposed license
10 renewal term would continue to limit public exposure to thermally altered waters.

11 *Illinois Department of Public Health Review*

12 The Environmental Standard Review Plan for license renewal (NRC 2013c) directs NRC staff to
13 consult with the state public health department—in this case, the IDPH—regarding concerns
14 about the potential for waterborne disease outbreaks associated with license renewal.
15 Appendix E of the ER (Exelon 2013a) includes copies of correspondence between Exelon and
16 IDPH regarding this issue. In a January 2013 letter to IDPH, Exelon (2013d) provided a brief
17 assessment that concluded that the license renewal “would not contribute to any increase in
18 adverse effects on public health from exposure to *N. fowleri* or any other thermophilic pathogen
19 in the Rock River.” The IDPH (2013) responded in a March 2013 letter and indicated that its
20 staff does not have the expertise necessary to adequately evaluate Exelon’s assessment.
21 Accordingly, the NRC did not separately contact the IDPH during its license renewal review.

22 *Conclusion*

23 The thermophilic microorganisms *Shigella* and *Naegleria fowleri* have been linked to waterborne
24 outbreaks in recreational waters within the United States. However, based on these
25 microorganisms’ temperature tolerances, *N. fowleri* is unlikely to be present in the vicinity of
26 Byron, and thermal discharges during the proposed license renewal term would only be
27 expected to minimally enhance the survival of *Shigella* spp. Exelon’s chlorination procedures
28 and the small thermal mixing zone make the exposure of recreational Rock River users to
29 elevated levels of thermophilic microorganisms unlikely. The NRC staff concludes that the
30 impacts of thermophilic microorganisms on the public are SMALL for Byron license renewal.

31 Electric shock hazards

32 Based on the GEIS, the Commission found that electric shock resulting from direct access to
33 energized conductors or from induced charges in metallic structures has not been found to be a
34 problem at most operating plants and generally is not expected to be a problem during the
35 license renewal term. However, a site-specific review is required to determine the significance
36 of the electric shock potential along the portions of the transmission lines that are within the
37 scope of this SEIS.

38 As discussed in Section 3.11.4, Exelon performed an evaluation of Byron’s transmission lines to
39 determine whether the lines conform to the National Electrical Safety Code® (NESC®) criteria
40 for induced electric shock. The Exelon evaluation concluded that none of its transmission lines
41 exceeded the NESC criteria.

42 Because Byron’s transmission lines conform to the NESC criteria during its current license term
43 and is expected to continue to conform to this standard during the license renewal term, the
44 NRC staff concludes that the potential impacts from acute electric shock during the license
45 renewal term would be SMALL.

Environmental Consequences and Mitigating Actions

1 4.11.1.2 Environmental Impacts of Postulated Accidents

2 This section describes the environmental impacts from postulated accidents that Byron might
3 experience during the period of extended operation. The term “accident” refers to any
4 unintentional event outside the normal plant operational envelope that results in a release or the
5 potential for release of radioactive materials into the environment. The two classes of
6 postulated accidents listed in Table 4–14 are contained in Table B-1 of Appendix B to Subpart A
7 of 10 CFR Part 51 and are evaluated in detail in the GEIS. These two classes of accidents are
8 DBAs and severe accidents.

9 **Table 4–14. Issues Related to Postulated Accidents**

Issue	GEIS Section	Category
DBAs	4.9.1.2	1
Severe accidents	4.9.1.2	2

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

10 Design-Basis Accidents

11 In order to receive U.S. Nuclear Regulatory Commission (NRC) approval to operate a nuclear
12 power facility, an applicant for an initial operating license must submit a Safety Analysis Report
13 (SAR) as part of its application. The SAR presents the design criteria and design information for
14 the proposed reactor and comprehensive data on the proposed site. The SAR also discusses
15 various hypothetical accident situations and the safety features that are provided to prevent and
16 mitigate accidents. The NRC staff reviews the application to determine whether the plant
17 design meets the Commission’s regulations and requirements and includes, in part, the nuclear
18 plant design and its anticipated response to an accident.

19 Design-basis accidents are those accidents that both the applicant and the NRC staff evaluate
20 to ensure that the plant can withstand normal and abnormal transients and a broad spectrum of
21 postulated accidents, without undue hazard to the health and safety of the public. Many of
22 these postulated accidents are not expected to occur during the life of the plant, but are
23 evaluated to establish the design basis for the preventive and mitigative safety systems of the
24 nuclear power plant. Parts 50 and 100 of 10 CFR describe the acceptance criteria for DBAs.

25 The environmental impacts of DBAs are evaluated during the initial licensing process, and the
26 ability of the plant to withstand these accidents is demonstrated to be acceptable before
27 issuance of the operating license. The results of these evaluations are found in licensee
28 documentation such as the applicant’s final safety analysis report, the safety evaluation report,
29 the final environmental statement (FES), and Section 5.1 of this SEIS. A licensee is required to
30 maintain the acceptable design and performance criteria throughout the life of the plant,
31 including any extended-life operation. The consequences for these events are evaluated for the
32 hypothetical maximum exposed individual; as such, changes in the plant environment will not
33 affect these evaluations. Because of the requirements that continuous acceptability of the
34 consequences and aging management programs be in effect for the period of extended
35 operation, the environmental impacts as calculated for DBAs should not differ significantly from
36 initial licensing assessments over the life of the plant, including the period of extended
37 operation. Accordingly, the design of the plant relative to DBAs during the period of extended
38 operation is considered to remain acceptable, and the environmental impacts of those accidents
39 were not examined further in the GEIS.

1 The Commission has determined that the environmental impacts of DBAs are of SMALL
2 significance for all plants because the plants were designed to successfully withstand these
3 accidents. Therefore, for the purposes of license renewal, DBAs are designated as a
4 Category 1 issue. The early resolution of the DBAs makes them a part of the current licensing
5 basis of the plant; the current licensing basis of the plant is to be maintained by the licensee
6 under its current license and, therefore, under the provisions of 10 CFR 54.30, is not subject to
7 review under license renewal.

8 No new and significant information related to DBAs was identified during the review of the Byron
9 ER (Exelon 2013a), site audit, the scoping process, or evaluation of other available information.
10 Therefore, there are no impacts related to these issues beyond those discussed in the GEIS.

11 Severe Accidents

12 Severe nuclear accidents are those that are more severe than DBAs because they could result
13 in substantial damage to the reactor core, whether or not there are serious offsite
14 consequences. In the GEIS, the NRC staff assessed the effects of severe accidents during the
15 period of extended operation, using the results of existing analyses and site-specific information
16 to conservatively predict the environmental impacts of severe accidents for each plant during
17 the period of extended operation.

18 Severe accidents initiated by external phenomena such as tornadoes, floods, earthquakes,
19 fires, and sabotage have not traditionally been discussed in quantitative terms in FESs and
20 were not specifically considered for the Byron site in the GEIS (NRC 1996). However, the GEIS
21 did evaluate existing impact assessments performed by NRC and by the industry at 44 nuclear
22 plants in the United States and concluded that the risk from beyond-design-basis earthquakes
23 at existing nuclear power plants is SMALL. The GEIS for license renewal performed a
24 discretionary analysis of terrorist acts in connection with license renewal, and concluded that the
25 core damage and radiological release from such acts would be no worse than the damage and
26 release expected from internally initiated events. In the GEIS, the Commission concludes that
27 the risk from sabotage and beyond-design-basis earthquakes at existing nuclear power plants is
28 small and additionally, that the risks from other external events are adequately addressed by a
29 generic consideration of internally initiated severe accidents (NRC 1996, 2013a).

30 Based on information in the GEIS, the staff found the following to be true:

31 The probability weighted consequences of atmospheric releases, fallout onto
32 open bodies of water, releases to ground water, and societal and economic
33 impacts from severe accidents are small for all plants. However, alternatives to
34 mitigate severe accidents must be considered for all plants that have not
35 considered such alternatives.

36 The NRC staff identified no new and significant information related to postulated accidents
37 during the review of Exelon's ER for Byron (Exelon 2013a), the site audit, the scoping process,
38 or evaluation of other available information. Therefore, there are no impacts related to these
39 issues beyond those discussed in the GEIS. However, in accordance with
40 10 CFR 51.53(c)(3)(ii)(L), the staff has reviewed severe accident mitigation alternatives
41 (SAMAs) for Byron. The results of the review are discussed in Section 5.3.

42 Severe Accident Mitigation Alternatives

43 Section 51.53(c)(3)(ii)(L) requires that license renewal applicants consider alternatives to
44 mitigate severe accidents if the staff has not previously evaluated SAMAs for the applicant's
45 plant in an environmental impact statement (EIS) or related supplement or in an environmental
46 assessment (EA). The purpose of this consideration is to ensure that plant changes
47 (i.e., hardware, procedures, and training) with the potential for improving severe accident safety

Environmental Consequences and Mitigating Actions

1 performance are identified and evaluated. SAMAs have not been previously considered for
2 Byron; therefore, the remainder of this section addresses those alternatives.

3 *Overview of SAMA Process*

4 This section presents a summary of the SAMA evaluation for Byron conducted by Exelon and
5 the NRC staff's review of that evaluation. The NRC staff performed its review with contract
6 assistance from Pacific Northwest National Laboratory. The NRC staff's review is available in
7 full in Appendix F; the full Exelon SAMA evaluation is available in Exelon's ER.

8 The SAMA evaluation for Byron was conducted with a four-step approach. In the first step,
9 Exelon quantified the level of risk associated with potential reactor accidents using the
10 plant-specific probabilistic risk assessment (PRA) and other risk models.

11 In the second step, Exelon examined the major risk contributors and identified possible ways
12 (SAMAs) of reducing that risk. Common ways of reducing risk are changes to components,
13 systems, procedures, and training. Exelon identified 30 potential SAMAs for Byron. Exelon
14 performed an initial screening to determine if any SAMAs could be eliminated because they are
15 not applicable to Byron due to design differences, they have already been implemented at
16 Byron or their intent is achieved by other means, or they have estimated implementation costs
17 that would exceed the dollar value associated with completely eliminating all severe accident
18 risk at Byron related to power generation operations. Three SAMAs were eliminated based on
19 this screening, leaving 27 for further evaluation. One additional candidate SAMA was also
20 further evaluated after accounting for analysis uncertainties.

21 In the third step, Exelon estimated the benefits and the costs associated with each of the
22 SAMAs. Estimates were made of how much each SAMA could reduce risk. Those estimates
23 were developed in terms of dollars in accordance with NRC guidance for performing regulatory
24 analyses (NRC 1997). The cost of implementing the proposed SAMAs was also estimated.

25 In the fourth step, the costs and benefits of each of the remaining SAMAs were compared to
26 determine whether the SAMA was cost beneficial, meaning the benefits of the SAMA were
27 greater than the cost (a positive cost benefit). Exelon concluded in its ER that several of the
28 SAMAs evaluated are potentially cost beneficial (Exelon 2013a). In response to NRC staff
29 inquiries regarding estimated benefits for certain SAMAs and lower cost alternatives,
30 two additional potentially cost-beneficial SAMAs were identified (Exelon 2014).

31 Finally, the potentially cost-beneficial SAMAs are evaluated to determine if they are in the scope
32 of license renewal, (i.e., they are subject to aging management). This evaluation considers
33 whether the structures, systems, and components (SSCs) associated with these SAMAs:
34 (1) perform their intended function without moving parts or without a change in configuration or
35 properties and (2) are subject to replacement based on qualified life or specified time period.
36 The potentially cost-beneficial SAMAs identified for Byron do not relate to adequately managing
37 the effects of aging during the period of extended operation; therefore, they need not be
38 implemented as part of license renewal in accordance with 10 CFR Part 54, "Requirements for
39 renewal of operating licenses for nuclear power plants." Byron's SAMA analyses and the NRC's
40 review are discussed in more detail below.

41 *Estimate of Risk*

42 Exelon submitted an assessment of SAMAs for Byron as part of its ER (Exelon 2013). This
43 assessment was based on the most recent Byron PRA available at that time, a plant-specific
44 offsite consequence analysis performed using the MELCOR Accident Consequence Code
45 System 2 computer program, and insights from the Byron Individual Plant Examination (IPE)

1 (ComEd 1994, 1997) and Individual Plant Examination of External Events (IPEEE)
 2 (ComEd 1996).

3 The scope of the Level 1 PRA model includes both internal events and a limited fire PRA. The
 4 fire PRA is not fully integrated with the most recent internal events model and is an interim
 5 implementation of NUREG-6850 (EPRI and NRC 2005). Hence, Exelon performed a separate
 6 assessment of the risk (and risk reduction) for internal and fire events.

7 The baseline core damage frequency (CDF) for the purpose of the SAMA evaluation is
 8 approximately 4.0×10^{-5} per year for Unit 1 and 3.8×10^{-5} per year for Unit 2 for internal events
 9 (including internal flooding events). The total fire CDF for Unit 1 is approximately 5.4×10^{-5} per
 10 year. The Unit 2 fire CDF was not reported or used since the Unit 2 fire model had not been
 11 developed to the same degree as the Unit 1 model. Exelon accounted for the potential risk
 12 reduction benefits associated with internal events by quantifying the benefits using the internal
 13 events model. For internal event-related SAMAs, Exelon accounted for the potential risk
 14 reduction benefits associated with external events (e.g., seismic and fire events) by multiplying
 15 the estimated benefits for internal events by a factor of 2.6. For fire-related SAMAs, Exelon
 16 separately estimated the risk reduction benefits using the fire risk model. The breakdown of
 17 CDF by initiating event for Byron is provided in Table 4-15 for internal events.

18 **Table 4-15. Byron Core Damage Frequency for Internal Events**

Initiating Event	Unit 1 CDF (per year)	Unit 1 Percent CDF Contribution	Unit 2 CDF (per year)	Unit 2 Percent CDF Contribution
Loss of Essential Service Water (SX)	1.8×10^{-5}	46	1.7×10^{-5}	45
Loss of Component Cooling Water (CCW)	8.3×10^{-6}	21	8.1×10^{-6}	21
Internal Flooding	5.6×10^{-6}	14	5.8×10^{-6}	15
Loss of Auxiliary Power (AP)	2.4×10^{-6}	6	1.8×10^{-6}	5
Small Loss-of-Coolant Accident (LOCA)	1.6×10^{-6}	4	1.5×10^{-6}	4
Other Initiating Events	1.6×10^{-6}	4	1.6×10^{-6}	4
Steam Generator Tube Rupture (SGTR)	1.2×10^{-6}	3	1.5×10^{-6}	4
General Transient and Loss of Main Feedwater (LMFW)	7.9×10^{-7}	2	6.8×10^{-7}	2
Total (Internal Events)^(a)	4.0×10^{-5}	100	3.8×10^{-5}	100

^(a) Column totals may be different due to round off.

19 As shown in these tables, internal event CDF is dominated by loss of SX, loss of component
 20 cooling water (CCW), and internal flooding for both units.

21 Exelon estimated the dose to the population within 50 mi (80 km) of the Byron site to be
 22 approximately 0.355 person-sievert (Sv) (35.5 person-rem) per year (Exelon 2013a) for internal
 23 events. The breakdown of the total population dose by containment release mode is
 24 summarized in Table 4-16. Containment overpressure accidents, interfacing-systems
 25 loss-of-coolant accident (ISLOCA), and steam generator tube rupture (SGTR) are the dominant
 26 contributors to population dose risk from internal events.

Environmental Consequences and Mitigating Actions

1 **Table 4–16. Breakdown of Population Dose and Offsite Economic Cost by Containment**
 2 **Release Mode** ^(a)

Containment Release Mode	Population Dose (person-rem ^(b) per year)	Percent Contribution	Offsite Economic Cost (\$/yr)	Percent Contribution
Containment overpressure (late)	28.3	80	222,700	88
ISLOCA	4.42	12	11,800	5
Steam generator tube rupture	2.16	6	17,600	7
Containment isolation failure	0.34	<1	1,660	<1
Containment intact	0.13	<1	120	<1
Early containment failure	0.09	<1	580	<1
Basemat melt-through (late)	0.02	<1	40	<1
Total ^(c)	35.5	100	255,000	100

^(a) Values in table derived from Table F.3-9 of the ER.

^(b) 1 person-rem = 0.01 person-Sv.

^(c) Column totals may be different due to round off.

3 The NRC staff has reviewed Exelon’s data and evaluation methods and concludes that the
 4 quality of the risk analyses is adequate to support an assessment of the risk reduction potential
 5 for candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on the CDFs
 6 and offsite doses reported by Exelon.

7 *Potential Plant Improvements*

8 Once the dominant contributors to plant risk were identified, Exelon searched for ways to reduce
 9 that risk. In identifying and evaluating potential SAMAs, Exelon considered insights from the
 10 plant-specific PRA and SAMA analyses performed for other operating plants that have
 11 submitted license renewal applications. This search included reviewing insights from the
 12 plant-specific risk studies, considering insights from the Byron PRA Group, and reviewing plant
 13 improvements considered in the IPE, IPEEE, and previous SAMA analyses. Exelon identified
 14 30 potential risk-reducing improvements (SAMAs) to plant components, systems, procedures
 15 and training.

16 Exelon removed three of the SAMAs from further consideration because they are not applicable
 17 to Byron due to design differences, they have already been implemented at Byron or their intent
 18 is achieved by other means, or they have estimated implementation costs that would exceed the
 19 dollar value associated with completely eliminating all severe accident risk at Byron related to
 20 power generation operations. One additional candidate SAMA was further evaluated after
 21 accounting for analysis uncertainties. A detailed cost-benefit analysis was performed for each
 22 of the remaining 28 SAMAs.

23 The NRC staff concludes that Exelon used a systematic and comprehensive process for
 24 identifying potential plant improvements for Byron, and that the set of potential plant
 25 improvements identified by Exelon is reasonably comprehensive and, therefore, acceptable.

1 *Cost-Benefit Comparison*

2 The cost benefit analysis performed by Exelon was based primarily on NUREG/BR-0184
 3 (NRC 1997) and was executed consistent with this guidance. NUREG/BR-0058 has recently
 4 been revised to reflect the agency’s revised policy on discount rates. Revision 4 of
 5 NUREG/BR-0058 states that two sets of estimates should be developed—one at 3 percent and
 6 one at 7 percent (NRC 2004). Exelon provided both sets of estimates (Exelon 2013, 2014) and
 7 based its decisions on potentially cost-beneficial SAMAs on these values.

8 Exelon identified 10 potentially cost-beneficial SAMAs in the baseline analysis contained in its
 9 ER. The potentially cost-beneficial SAMAs are:

- 10 • SAMA 3 – Auto Start of Standby SX Pump;
- 11 • SAMA 5 – Modify the Startup Feedwater Pump to Start Using the AMSAC SG
 12 Low-Low-Low Level Signal to Mitigate AFW Failure;
- 13 • SAMA 9 – Install Flow Restrictors in Fire Protection Pipes;
- 14 • SAMA 10 – Alter Ductwork Between the Aux BLDG Room and the SX Pump
 15 Room;
- 16 • SAMA 13 – Alternate AFW Cooling with Seal Protection;
- 17 • SAMA 15 – Resolve Regulatory Issues and Complete Implementation of the
 18 Inter Unit AFW Cross-tie;
- 19 • SAMA 25 – Install a Filtered Containment Vent;
- 20 • SAMA 26 – DMS Using a Dedicated Generator, Self Cooled Charging Pump,
 21 and a Portable AFW Pump;
- 22 • SAMA 27 – Protect RHR,SI and CVCS Cubicle Cooling Fan Cables in Fire
 23 Zone 11.3-0; and
- 24 • SAMA 31 – Protect Cables for 2AF013A, B, and D in the AUX Building
 25 General Area, Elevation 426’.

26 Exelon performed additional analyses to evaluate the impact of parameter choices and
 27 uncertainties on the results of the SAMA assessment (Exelon 2013, 2014). If the benefits are
 28 increased by a factor of 2.53 to account for uncertainties, 10 additional SAMA candidates were
 29 determined to be potentially cost beneficial:

- 30 • SAMA 1 – Install Diesel Driven SX Pump in a New Dedicated Building;
- 31 • SAMA 2 – Replace the Positive Displacement Pump with a Self-Cooled, Auto
 32 Start Pump;
- 33 • SAMA 4 – Install “No Leak” Seals;
- 34 • SAMA 7 – Establish Flow to the RH HX on RH Pump Start;
- 35 • SAMA 8 – Install Kill Switches for the Fire Protection Pumps in the MCR;
- 36 • SAMA 11 – Implement DMS;
- 37 • SAMA 16 – Install High Flow Sensors on the Non-Essential Service Water
 38 System;
- 39 • SAMA 19 – Replace MOVs in the RHR Discharge Line with Valves that can
 40 Isolate an ISLOCA Event;

Environmental Consequences and Mitigating Actions

- 1 • SAMA 28 – Install Fire Barriers Around MCC 134X; and
- 2 • SAMA 30 – Protect AFW Cables in the AUX Building General Area,
- 3 Elevation 383'.

4 Exelon stated in its ER that 18 of the SAMAs (SAMAs 2, 3, 5, 7, 8, 9, 10, 11, 13, 15, 16, 19, 25,
5 26, 27, 28, 30, and 31) determined to be cost beneficial in its ER baseline and uncertainty
6 evaluations have been submitted to the Byron Plant Health Committee for further
7 implementation consideration (Exelon 2013a). Exelon stated that installation of SAMA 4 at
8 Byron is planned, that contract awards have already been made to install the new reactor
9 coolant pump seals, and that engineering and analysis work necessary to install the new seals
10 has already begun (Exelon 2014). Exelon also stated in its ER that SAMA 11 may be fully or
11 partially implemented at Byron for other purposes, which, if fully implemented along with
12 SAMA 15 (which is currently being implemented), would result in SAMA 1 no longer being cost
13 beneficial. Since full implementation of SAMA 11 in conjunction with SAMA 15 would result in
14 SAMA 1 not being cost beneficial, the NRC staff concludes that the applicant should consider
15 SAMA 1 for further evaluation, depending on the degree of implementation of SAMA 11.

16 The NRC staff concludes that, with the exception of the potentially cost-beneficial SAMAs
17 discussed above, the costs of the SAMAs evaluated would be higher than the associated
18 benefits when they are considered independently.

19 *Conclusions*

20 The NRC staff reviewed Exelon's analysis and concludes that the methods used and the
21 implementation of those methods were sound. The treatment of SAMA benefits and costs
22 support the general conclusion that the SAMA evaluations performed by Exelon are reasonable
23 and sufficient for the license renewal submittal.

24 Based on its review of the SAMA analysis, the NRC staff finds Exelon's identification of areas in
25 which risk can be further reduced in a cost-beneficial manner through the implementation of all
26 or a subset of potentially cost-beneficial SAMAs to be acceptable. Given the potential for
27 cost-beneficial risk reduction, the staff considers that further evaluation of these SAMAs by
28 Exelon is warranted. Additionally, the NRC staff evaluated the identified potentially
29 cost-beneficial SAMAs to determine if they are in the scope of license renewal, (i.e., they are
30 subject to aging management). This evaluation considers whether the SSCs associated with
31 these SAMAs: (1) perform their intended function without moving parts or without a change in
32 configuration or properties and (2) are not subject to replacement based on qualified life or
33 specified time period. The NRC staff determined that these SAMAs do not relate to adequately
34 managing the effects of aging during the period of extended operation. Therefore, they need
35 not be implemented as part of the license renewal pursuant to 10 CFR Part 54.

36 **4.11.2 No-Action Alternative**

37 Human health risks would be smaller following plant shutdown. The two reactor units, which are
38 currently operating within regulatory limits, would emit less radioactive gaseous, liquid, and solid
39 material to the environment. In addition, following shutdown, the variety of potential accidents at
40 the plant (radiological or industrial) would be reduced to a limited set associated with shutdown
41 events and fuel handling and storage. In Section 4.11.1, the NRC staff concluded that the
42 impacts of continued plant operation on human health would be SMALL, except for "Chronic
43 effects of electromagnetic fields (EMFs)," for which the impacts are UNCERTAIN. In
44 Section 4.11.1.2, the NRC staff concluded that the impacts of accidents during operation are
45 SMALL. Therefore, as radioactive emissions to the environment decrease, and as the likelihood

1 and types of accidents decrease following shutdown, the NRC staff concludes that the risk to
2 human health following plant shutdown would be SMALL.

3 **4.11.3 New Nuclear Alternative**

4 Impacts on human health from construction of two new nuclear units would be similar to impacts
5 associated with the construction of any major industrial facility. Compliance with worker
6 protection rules would control those impacts on workers at acceptable levels. Impacts from
7 construction on the general public would be minimal since limiting active construction area
8 access to authorized individuals is expected. Impacts on human health from the construction of
9 two new nuclear units would be SMALL.

10 The human health effects from the operation of two new nuclear power plants would be similar
11 to those of the existing Byron. As presented in Section 4.11.1.1, impacts on human health from
12 the operation of Byron would be SMALL, except for “Chronic effects of electromagnetic fields
13 (EMFs),” for which the impacts are UNCERTAIN. Therefore, the impacts on human health from
14 the operation of two new nuclear plants would be SMALL.

15 **4.11.4 IGCC Alternative**

16 Impacts on workers are expected to be similar to those experienced during construction of any
17 major industrial facility. Impacts from construction of combustion-based renewable energy
18 facilities are expected to be the same as those for construction of fossil fuel facilities.
19 Construction would increase traffic on local roads, which could affect the health of the general
20 public. Human health impacts would be the same for all facilities whether located on greenfield
21 sites or at an existing nuclear plant. Personal protective equipment, training, and engineered
22 barriers would protect the workforce (NRC 2013a). Therefore, the impacts on human health
23 from the construction of an IGCC facility would be SMALL.

24 The IGCC alternative introduces worker risks from coal and limestone mining, worker and public
25 risk from coal and lime/limestone transportation, worker and public risk from disposal of
26 coal-combustion waste, and public risk from inhalation of stack emissions. In addition, human
27 health risks are associated with the management and disposal of coal combustion waste. Coal
28 combustion generates waste in the form of ash, and equipment for controlling air pollution
29 generates additional ash and scrubber sludge. Human health risks may extend beyond the
30 facility workforce to the public depending on their proximity to the coal combustion waste
31 disposal facility. The character and the constituents of coal combustion waste depend on both
32 the chemical composition of the source coal and the technology used to combust it. Generally,
33 the primary sources of adverse consequences from coal combustion waste are from exposure
34 to sulfur oxide and nitrogen oxide in air emissions and radioactive elements such as uranium
35 and thorium as well as the heavy metals and hydrocarbon compounds contained in fly ash and
36 bottom ash, and scrubber sludge (NRC 2013a).

37 Regulatory agencies, including EPA and state agencies, base air emission standards and
38 requirements on human health impacts. These agencies also impose site-specific emission
39 limits as needed to protect human health. Given the regulatory oversight exercised by EPA and
40 state agencies, the NRC staff concludes that the human health impacts from radiological doses
41 and inhaled toxins and particulates generated from the IGCC alternative would be SMALL
42 (NRC 2013a).

Environmental Consequences and Mitigating Actions

1 **4.11.5 NGCC Alternative**

2 Impacts on human health from construction of the NGCC alternative would be similar to effects
3 associated with the construction of any major industrial facility. Compliance with worker
4 protection rules would control those impacts on workers at acceptable levels. Impacts from
5 construction on the general public would be minimal since crews would limit active construction
6 area access to authorized individuals. Based on the above, the NRC staff concludes that the
7 impacts on human health from the construction of the NGCC alternative would be SMALL.

8 Impacts from the operation of an NGCC facility introduces public risk from inhalation of gaseous
9 emissions. The risk may be attributable to nitrogen oxide emissions that contribute to ozone
10 formation, which in turn contribute to health risk. Regulatory agencies, including EPA and state
11 agencies, base air emission standards and requirements on human health impacts. These
12 agencies also impose site-specific emission limits as needed to protect human health. Given
13 the regulatory oversight exercised by EPA and state agencies, the NRC staff concludes that the
14 human health impacts from the NGCC alternative would be SMALL.

15 **4.11.6 Combination Alternative (NGCC, Wind, Solar)**

16 Impacts on human health from construction of a combination of NGCC, wind, and solar PV
17 alternatives would be similar to those associated with the construction of any major industrial
18 facility. Compliance with worker protection rules would control those impacts on workers at
19 acceptable levels. Impacts from construction on the general public would be minimal since
20 crews would limit active construction area access to authorized individuals. Based on the
21 above, the NRC staff concludes that the impacts on human health from the construction of the
22 NGCC, wind, and solar alternative would be SMALL.

23 Operational hazards at an NGCC facility are similar to those at an IGCC facility and are
24 discussed in Section 4.11.4.

25 Operational hazards at a wind facility for the workforce include working at heights, near rotating
26 mechanical or electrically energized equipment, and working in extreme weather. Potential
27 impacts to workers and the public include ice thrown from rotor blades and broken blades
28 thrown due to mechanical failure. Potential impacts also include EMF exposure, aviation safety
29 hazard, and exposure to noise and vibration from the rotating blades.

30 Operational hazards at a solar PV facility may involve exposure to airborne toxic metals
31 (e.g., cadmium) and silicon if the PV cell loses its integrity from a fire. Workers could also inhale
32 silicon dust if the PV cell was smashed by an object or from a fall to the ground.

33 However, given the expected compliance with worker protection rules and remediation efforts to
34 contain the toxic material, the potential impacts to workers at the facility and offsite exposure to
35 the public, the impacts would be SMALL.

36 **4.11.7 Purchased Power**

37 Purchased power is expected to come from the types of electricity generation available within
38 the ROI: coal, natural gas, nuclear, and wind. The human health impacts from the operation of
39 these types of power plants are discussed in Sections 4.11.3, 4.11.4, 4.11.5, and 4.11.6. Based
40 on the information in those sections, the NRC staff concludes that the human health impacts of
41 the purchased power alternative using coal, natural gas, nuclear, and wind would be SMALL.

1 **4.12 Environmental Justice**

2 This section describes the potential human health and environmental effects of the proposed
 3 action (license renewal) and alternatives to the proposed action on minority and low-income
 4 populations and special pathway receptors.

5 **4.12.1 Proposed Action**

6 The environmental justice issue applicable to Byron during the license renewal term is listed in
 7 Table 4–17. Section 3.12 of this SEIS describes the environmental justice matters with respect
 8 to Byron.

9 **Table 4–17. Environmental Justice**

Issue	GEIS Section	Category
Minority and low-income populations	4.10.1	2

Source: Table B–1 in Appendix B, Subpart A, to 10 CFR Part 51

10 The NRC addresses environmental justice matters for license renewal by (1) identifying the
 11 location of minority and low-income populations that may be affected by the continued operation
 12 of the nuclear power plant during the license renewal term, (2) determining whether there would
 13 be any potential human health or environmental effects to these populations and special
 14 pathway receptors, and (3) determining if any of the effects may be disproportionately high and
 15 adverse. Adverse health effects are measured in terms of the risk and rate of fatal or nonfatal
 16 adverse impacts on human health. Disproportionately high and adverse human health effects
 17 occur when the risk or rate of exposure to an environmental hazard for a minority or low-income
 18 population is significant and exceeds the risk or exposure rate for the general population or for
 19 another appropriate comparison group. Disproportionately high environmental effects refer to
 20 impacts or risks of impacts on the natural or physical environment in a minority or low-income
 21 community that are significant and appreciably exceed the environmental impact on the larger
 22 community. Such effects may include biological, cultural, economic, or social impacts.

23 As discussed above, the environmental justice impact analysis evaluates the potential for
 24 disproportionately high and adverse human health and environmental effects on minority and
 25 low-income populations. Some of these potential effects have been identified in resource areas
 26 discussed in this SEIS. For example, increased demand for rental housing during replacement
 27 power plant construction could disproportionately affect low-income populations. Minority and
 28 low-income populations are subsets of the general public residing in the vicinity of all the
 29 alternatives listed below, and all are exposed to the same hazards generated by each
 30 alternative.

31 Figures 3–15 and 3–16 show the location of predominantly minority and low-income population
 32 block groups residing within a 50-mi (80-km) radius of Byron. This area of impact is consistent
 33 with the impact analysis for public and occupational health and safety, which also focuses on
 34 populations within a 50-mi (80-km) radius of the plant. Chapter 4 presents the assessment of
 35 environmental and human health impacts for each resource area. The analyses of impacts for
 36 all environmental resource areas indicated that the impact from license renewal would be
 37 SMALL.

38 Potential impacts on minority and low-income populations (including migrant workers or Native
 39 Americans) would mostly consist of socioeconomic and radiological effects; however, radiation

Environmental Consequences and Mitigating Actions

1 doses from continued operations during the license renewal term are expected to continue at
2 current levels, and they would remain within regulatory limits. Section 4.11.1.2 of this SEIS
3 discusses the environmental impacts from postulated accidents that might occur during the
4 license renewal term, which include both design-basis and severe accidents. In both cases, the
5 Commission has generically determined that impacts associated with DBAs are small because
6 nuclear plants are designed and operated to successfully withstand such accidents, and the
7 probability weighted consequences of severe accidents are small.

8 Therefore, based on this information and the analysis of human health and environmental
9 impacts presented in Chapter 4 of this SEIS, there would be no disproportionately high and
10 adverse human health and environmental effects on minority and low-income populations from
11 the continued operation of Byron during the license renewal term.

12 As part of addressing environmental justice concerns associated with license renewal, the
13 NRC staff also assessed the potential radiological risk to special population groups (such as
14 migrant workers or Native Americans) from exposure to radioactive material received through
15 their unique consumption practices and interaction with the environment, including subsistence
16 consumption of fish, native vegetation, surface waters, sediments, and local produce;
17 absorption of contaminants in sediments through the skin; and inhalation of airborne radioactive
18 material released from the plant during routine operation. This analysis is presented below.

19 *Subsistence Consumption of Fish and Wildlife*

20 The special pathway receptors analysis is an important part of the environmental justice
21 analysis because consumption patterns may reflect the traditional or cultural practices of
22 minority and low-income populations in the area, such as migrant workers or Native Americans.

23 Section 4-4 of Executive Order (EO) 12898 (1994) (59 FR 7629) directs Federal agencies,
24 whenever practical and appropriate, to collect and analyze information about the consumption
25 patterns of populations that rely principally on fish or wildlife for subsistence and to
26 communicate the risks of these consumption patterns to the public. In this SEIS, the NRC staff
27 considered whether there were any means for minority or low-income populations to be
28 disproportionately affected by examining impacts on American Indian, Hispanics, migrant
29 workers, and other traditional lifestyle special pathway receptors. The assessment of special
30 pathways considered the levels of radiological and nonradiological contaminants in native
31 vegetation, crops, soils and sediments, groundwater, surface water, fish, and game animals on
32 or near Byron.

33 The following is a summary discussion of Exelon's radiological environmental monitoring
34 programs (REMPs) that assess the potential impacts from the subsistence consumption of fish
35 and wildlife near the Byron site.

36 Exelon has an ongoing comprehensive REMP to assess the impact of Byron operations on the
37 environment. To assess the impact of nuclear power plant operations, samples are collected
38 annually from the environment and analyzed for radioactivity. A plant effect would be indicated
39 if the radioactive material detected in a sample were significantly larger than background levels.
40 Two types of samples are collected. The first type, a control sample, is collected from areas
41 that are beyond the measurable influence of the nuclear power plant or any other nuclear
42 facility. These samples are used as reference data to determine normal background levels of
43 radiation in the environment. These samples are then compared with the second type of
44 samples, indicator samples, collected near the nuclear power plant. Indicator samples are
45 collected from areas where any contribution from the nuclear power plant will be at its highest
46 concentration. These samples are then used to evaluate the contribution of nuclear power plant
47 operations to radiation or radioactivity levels in the environment. An effect would be indicated if

1 the radioactivity levels detected in an indicator sample were significantly larger than the control
2 sample or background levels.

3 Samples of environmental media are collected from the aquatic and terrestrial pathways in the
4 vicinity of Byron. The aquatic pathways include groundwater, surface water, fish, and shoreline
5 sediment. The terrestrial pathways include airborne particulates, milk, and food products
6 (i.e., cabbage, beets and beet greens, kohlrabi, potatoes, rhubarb leaves, onions, and turnips).
7 During 2012, 1,480 analyses performed on 913 samples of environmental media at Byron
8 showed no significant or measurable radiological impact above background levels from site
9 operations (Teledyne 2013).

10 *Conclusion*

11 Based on the radiological environmental monitoring data from Byron, the NRC staff finds that no
12 disproportionately high and adverse human health impacts would be expected in special
13 pathway receptor populations in the region as a result of subsistence consumption of water,
14 local food, fish, and wildlife. Continued operation of Byron would not have disproportionately
15 high and adverse human health and environmental effects on these populations.

16 **4.12.2 No-Action Alternative**

17 Impacts on minority and low-income populations would depend on the number of jobs and the
18 amount of tax revenues lost by communities in the immediate vicinity of the power plant after
19 Byron ceases operations. Not renewing the operating licenses and terminating reactor
20 operations would have a noticeable impact on socioeconomic conditions in the communities
21 located near Byron. The loss of jobs and income would have an immediate socioeconomic
22 impact. Some, but not all, of the approximately 890 employees would begin to leave after
23 reactor operations are terminated; and overall tax revenue generated by plant operations would
24 be reduced. The reduction in tax revenue would decrease the availability of public services in
25 Ogle County. This could disproportionately affect minority and low-income populations that may
26 have become dependent on these services. Effects could be high or adverse depending on the
27 needs of the individual impacted. See also Appendix J of NUREG-0586, Supplement 1
28 (NRC 2002), for additional discussion of these impacts.

29 **4.12.3 New Nuclear Alternative**

30 Potential impacts to minority and low-income populations from the construction and operation of
31 a new nuclear power plant would mostly consist of environmental and socioeconomic effects
32 (e.g., noise, dust, traffic, employment, and housing impacts). Noise and dust impacts from
33 construction would be short-term and primarily limited to onsite activities. Minority and
34 low-income populations residing along site access roads would be affected by increased
35 commuter vehicle traffic during shift changes and truck traffic. However, these effects would be
36 temporary during certain hours of the day and would not likely be high and adverse. Increased
37 demand for rental housing during construction could affect low-income populations. However,
38 given the proximity of some existing nuclear power plant sites to metropolitan areas, many
39 construction workers could commute to the site, thereby reducing the potential demand for
40 rental housing.

41 Potential impacts to minority and low-income populations from new nuclear power plant
42 operations would mostly consist of radiological effects; however, radiation doses are expected
43 to be well below regulatory limits. All people living near the nuclear power plant would be
44 exposed to the same potential effects from power plant operations, and any impacts would

Environmental Consequences and Mitigating Actions

1 depend on the magnitude of the change in ambient air quality conditions. Permitted air
2 emissions are expected to remain within regulatory standards.

3 Based on this information and the analysis of human health and environmental impacts
4 presented in this SEIS, the construction and operation of a new nuclear power plant would not
5 have disproportionately high and adverse human health and environmental effects on minority
6 and low-income populations.

7 **4.12.4 IGCC Alternative**

8 Potential impacts to minority and low-income populations from the construction and operation of
9 a new IGCC plant at the Byron site or an existing power plant site would consist of
10 environmental and socioeconomic effects (e.g., noise, dust, traffic, employment, and housing
11 impacts). Noise and dust impacts from construction would be short-term and primarily limited to
12 onsite activities. Minority and low-income populations residing along site access roads would
13 be affected by increased commuter vehicle traffic during shift changes and truck traffic.
14 However, these effects would be temporary during certain hours of the day and would not likely
15 be high and adverse. Increased demand for rental housing during construction could affect
16 low-income populations. However, given the proximity of some existing power plant sites and
17 the Byron site to metropolitan areas, many construction workers could commute to the site,
18 thereby reducing the potential demand for rental housing.

19 Emissions from the operation of an IGCC plant could affect minority and low-income populations
20 as well as the general population living in the vicinity of the new power plant. However, all
21 would be exposed to the same potential effects from IGCC power plant operations and any
22 impacts would depend on the magnitude of the change in ambient air quality conditions.
23 Permitted air emissions are expected to remain within regulatory standards.

24 Based on this information and the analysis of human health and environmental impacts
25 presented in this SEIS, the construction and operation of a new IGCC plant would not have
26 disproportionately high and adverse human health and environmental effects on minority and
27 low-income populations.

28 **4.12.5 NGCC Alternative**

29 Potential impacts to minority and low-income populations from the construction and operation of
30 a new NGCC plant at the Byron site or an existing power plant site would mostly consist of
31 environmental and socioeconomic effects (e.g., noise, dust, traffic, employment, and housing
32 impacts). Noise and dust impacts from construction would be short-term and primarily limited to
33 onsite activities. Minority and low-income populations residing along site access roads would
34 be affected by increased commuter vehicle traffic during shift changes and truck traffic.
35 However, these impacts would only be during certain hours of the day and would not likely be
36 high and adverse. Increased demand for rental housing during construction could affect
37 low-income populations. However, given the proximity of some existing power plant sites and
38 the Byron site to metropolitan areas, many construction workers could commute to the site,
39 thereby reducing the potential demand for rental housing.

40 Emissions from the operation of an NGCC plant could affect minority and low-income
41 populations as well as the general population living in the vicinity of the new power plant.
42 However, all would be exposed to the same potential effects from NGCC power plant
43 operations, and any impacts would depend on the magnitude of the change in ambient air
44 quality conditions. Permitted air emissions are expected to remain within regulatory standards.

1 Based on this information and the analysis of human health and environmental impacts
2 presented in this SEIS, the construction and operation of a new NGCC plant would not have
3 disproportionately high and adverse human health and environmental effects on minority and
4 low-income populations.

5 **4.12.6 Combination Alternative (NGCC, Wind, Solar)**

6 Potential impacts to minority and low-income populations from the construction and operation of
7 a new NGCC plant, wind turbines, and solar PV installations would mostly consist of
8 environmental and socioeconomic effects (e.g., noise, dust, traffic, employment, and housing
9 impacts). Noise and dust impacts from construction would be short-term and primarily limited to
10 onsite activities. Minority and low-income populations residing along site access roads would
11 be affected by increased commuter vehicle traffic during shift changes and truck traffic.
12 However, these impacts would only be during certain hours of the day and would not likely be
13 high and adverse. Increased demand for rental housing during construction could affect
14 low-income populations. However, given the small number of construction workers and the
15 possibility that many workers could commute to these construction sites, the potential need for
16 rental housing would not be significant.

17 Minority and low-income populations living in close proximity to wind farm and solar PV power
18 generating installations could be disproportionately affected by maintenance and operations
19 activities. However, everyone would be exposed to the same operational impacts, and any
20 impact would depend on the magnitude of change from current conditions. Operational impacts
21 from the wind turbines and solar PV installations would mostly be limited to noise and aesthetic
22 effects. The general public living near the wind farms and solar PV installations would also be
23 exposed to the same effects.

24 Based on this information and the analysis of human health and environmental impacts
25 presented in this SEIS, the construction and operation of a new NGCC plant, wind farms, and
26 solar PV installations would not have disproportionately high and adverse human health and
27 environmental effects on minority and low-income populations.

28 **4.12.7 Purchased Power**

29 Low-income populations could be disproportionately affected by increased utility bills because of
30 the cost of purchased power. However, programs, such as the low income home energy
31 assistance program in Illinois, are available to assist low-income families in paying for increased
32 electrical costs.

33 **4.13 Waste Management and Pollution Prevention**

34 This section describes the potential impacts of the proposed action (license renewal) and
35 alternatives to the proposed action on waste management and pollution prevention.

36 **4.13.1 Proposed Action**

37 The waste management issues applicable to Byron are discussed below and listed in
38 Table 4–18. Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 contains more
39 information on these issues.

1

Table 4–18. Waste Management Issues

Issue	GEIS Section	Category
Low-level waste storage and disposal	4.11.1.1	1
Onsite storage of spent nuclear fuel	4.11.1.2 ^(a)	1
Offsite radiological impacts of spent nuclear fuel and high-level waste disposal	4.11.1.3 ^(b)	1
Mixed-waste storage and disposal	4.11.1.4	1
Nonradioactive waste storage	4.11.1.4	1

^(a) The environmental impact of this issue for the timeframe beyond the licensed life for reactor operations is contained in NUREG-2157 (NRC 2014a).

^(b) The environmental impact of this issue is contained in NUREG-2157 (NRC 2014a).

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

2 The NRC staff’s evaluation of the environmental impacts associated with spent nuclear fuel is
 3 addressed in two issues in Table 4–18, “Onsite storage of spent nuclear fuel” and “Offsite
 4 radiological impacts of spent nuclear fuel and high-level waste disposal.” However, as
 5 explained later in this section, these two issues now incorporate the generic environmental
 6 impact determinations codified in the revised 10 CFR 51.23 pursuant to the Continued Storage
 7 Rule (79 FR 56238)⁹.

8 The NRC staff did not identify any new and significant information related to waste management
 9 issues listed in Table 4–18 during its review of the applicant’s ER (Exelon 2013a), the site visit,
 10 or the scoping process. Therefore, there are no impacts related to these issues beyond those
 11 discussed in the GEIS (NRC 2013a) and the “Generic Environmental Impact Statement for
 12 Continued Storage of Spent Nuclear Fuel, Volumes 1 and 2” (NUREG-2157) (NRC 2014a).
 13 During the license renewal term, for these Category 1 issues discussed in the GEIS, the NRC
 14 staff concludes that the impacts are SMALL.

15 *4.13.1.1 10 CFR 51.23 (Continued Storage Rule) and 10 CFR 51, Subpart A, Table B-1*
 16 *(License Renewal)*

17 The NRC’s findings regarding the environmental impacts associated with the renewal of a
 18 power reactor operating license are contained in Table B-1, “Summary of Findings on NEPA
 19 Issues for License Renewal of Nuclear Power Plants.” The table is located in Appendix B to
 20 Subpart A of 10 CFR Part 51, “Environmental Effect of Renewing the Operating License of a
 21 Nuclear Power Plant”¹⁰ (Table B-1). In 1996, as part of the 10 CFR Part 51 license renewal
 22 rulemaking, the NRC determined that offsite radiological impacts of spent nuclear fuel and
 23 high-level waste disposal would be a Category 1 (generic) issue with no impact level assigned
 24 (61 FR 28467, 28495; June 5, 1996). The NRC analyzed the EPA generic repository standards
 25 and dose limits in existence at the time and concluded that offsite radiological impacts
 26 warranted a Category 1 determination (61 FR 28467, 28478; June 5, 1996). In its 2009

⁹ 79 FR 56238. U.S. Nuclear Regulatory Commission. “Continued Storage of Spent Nuclear Fuel.” Federal Register 79 (182):56238–56263. September 19, 2014.

¹⁰The Commission issued Table B-1 in June 1996 (61 FR 28467; June 5, 1996). The Commission issued an additional rule in December 1996 that made minor clarifying changes to, and added language inadvertently omitted from, Table B-1 (61 FR 66537; December 18, 1996). The NRC revised Table B-1 and other regulations in 10 CFR Part 51, relating to the NRC’s environmental review of a nuclear power plant’s license renewal application in a 2013 rulemaking (78 FR 37282; June 20, 2013).

1 proposed rule, the NRC stated its intention to reaffirm that determination (74 FR 38117, 38127;
2 July 31, 2009).

3 For the offsite radiological impacts resulting from spent fuel and high-level waste disposal and
4 the onsite storage of spent fuel, which will occur after the reactors have been permanently
5 shutdown, the NRC's Waste Confidence Decision and Temporary Storage Rule (WCD and rule)
6 (10 CFR 51.23) historically represented the Commission's generic determination that spent fuel
7 can continue to be stored safely and without significant environmental impacts for a period of
8 time after the end of the licensed life for operation. This generic determination meant that the
9 NRC did not need to consider the storage of spent fuel after the end of a reactor's licensed life
10 for operation in NEPA documents that support its reactor and spent fuel storage application
11 reviews.

12 The NRC first adopted the Waste Confidence Decision and Rule in 1984. The NRC amended
13 the decision and rule in 1990, reviewed them in 1999, and amended them again in 2010, as
14 published in the *Federal Register* (FR) (49 FR 34685, 34694; 55 FR 38472, 38474;
15 64 FR 68005; and 75 FR 81032 and 81037). The Waste Confidence Decision and Rule are
16 codified in 10 CFR 51.23.

17 On December 23, 2010, the Commission published in the FR a revision of the Waste
18 Confidence Decision and Rule to reflect information gained from experience in the storage of
19 spent fuel and the increased uncertainty in the siting and construction of a permanent geologic
20 repository for the disposal of spent fuel and high-level waste (75 FR 81032 and 81037). In
21 response to the 2010 Waste Confidence Decision and Rule, the States of New York,
22 New Jersey, Connecticut, and Vermont—along with several other parties—challenged the
23 Commission's NEPA analysis in the decision, which provided the regulatory basis for the rule.
24 On June 8, 2012, the United States Court of Appeals, District of Columbia Circuit in
25 *New York v. NRC*, 681 F.3d 471 (D.C. Cir. 2012), vacated the NRC's Waste Confidence
26 Decision and Rule after finding that it did not comply with NEPA.

27 In response to the court's ruling, the Commission, in CLI-12-16 (NRC 2012a), determined that it
28 would not issue licenses that rely upon the Waste Confidence Decision and Rule until the issues
29 identified in the court's decision are appropriately addressed by the Commission. In CLI-12-16,
30 the Commission also noted that the decision not to issue licenses only applied to final license
31 issuance; all licensing reviews and proceedings should continue to move forward.

32 In addition, the Commission directed in SRM-COMSECY-12-0016 (NRC 2012b) that the NRC
33 staff proceed with a rulemaking that includes the development of a generic EIS to support a
34 revised Waste Confidence Decision and Rule and to publish both the EIS and the revised
35 decision and rule in the FR within 24 months (by September 2014). The Commission indicated
36 that both the EIS and the revised Waste Confidence Decision and Rule should build on the
37 information already documented in various NRC studies and reports, including existing EAs that
38 the NRC developed as part of the 2010 Waste Confidence Decision and Rule. The Commission
39 directed that any additional analyses should focus on the issues identified in the court's
40 decision. The Commission also directed that the NRC staff provide ample opportunity for public
41 comment on both the draft EIS and the proposed Waste Confidence Decision and Rule.

42 As discussed above, in *New York v. NRC*, 681 F.3d 471 (D.C. Cir. 2012), the court vacated the
43 Commission's Waste Confidence Decision and Rule (10 CFR 51.23). In response to the court's
44 *vacatur*, the Commission developed a revised rule and associated *Generic Environmental*
45 *Impact Statement for Continued Storage of Spent-Nuclear Fuel* (NUREG-2157). Before the
46 issuance of the revised 10 CFR 51.23 and NUREG-2157, the NRC issued the 2013 final license
47 renewal rule, which amended Table B-1—along with other 10 CFR Part 51 regulations—and
48 stated that upon finalization of the revised Waste Confidence rule and accompanying technical

Environmental Consequences and Mitigating Actions

1 analyses,¹¹ the NRC would make any necessary conforming amendments to Table B-1
2 (78 FR 37282, 37293; June 20, 2013).

3 On August 26, 2014, the Commission approved the Continued Storage Rule and associated
4 *Generic Environmental Impact Statement for Continued Storage of Spent Nuclear Fuel*
5 (NUREG-2157, NRC 2014a). Subsequently, on September 19, 2014, the NRC published the
6 final rule (79 FR 56238) in the *Federal Register*, along with NUREG-2157 (79 FR 53238,
7 56263). The Continued Storage Rule adopts the generic impact determinations made in
8 NUREG-2157 and codifies the NRC's generic determinations regarding the environmental
9 impacts of continued storage of spent nuclear fuel beyond a reactor's operating license (i.e.,
10 those impacts that could occur as a result of the storage of spent nuclear fuel at at-reactor or
11 away-from-reactor sites after a reactor's licensed life for operation and until a permanent
12 repository becomes available). As directed by 10 CFR 51.23(b), the impacts assessed in
13 NUREG-2157 regarding continued storage are deemed incorporated by rule into this license
14 renewal SEIS.

15 In the Continued Storage Rule, the NRC made conforming changes to the two environmental
16 issues in Table B-1 that were impacted by the vacated Waste Confidence rule: "Onsite spent
17 fuel" and "Offsite radiological impacts (spent fuel and high-level waste disposal)."¹² Although
18 NUREG-2157 (the technical basis for the Continued Storage Rule) does not include high-level
19 waste disposal in the analysis of impacts, it does address the technical feasibility of a repository
20 in Appendix B of NUREG-2157 and concludes that a geologic repository for spent fuel is
21 technically feasible and the same analysis applies to the feasibility of geologic disposal for
22 high-level waste.

23 The Commission revised the Table B-1 finding for "Onsite storage of spent nuclear fuel" to add
24 the phrase "during the license renewal term" to make clear that the SMALL impact is for the
25 license renewal term only. Some minor clarifying changes were also made to the paragraph.
26 The first paragraph of the column entry now reads, "During the license renewal term, SMALL.
27 The expected increase in the volume of spent nuclear fuel from an additional 20 years of
28 operation can be safely accommodated onsite during the license renewal term with small
29 environmental impacts through dry or pool storage at all plants."

30 In addition, a new paragraph is added to address the impacts of onsite storage of spent fuel
31 during the continued storage period. The second paragraph of the column entry reads, "For the
32 period after the licensed life for reactor operations, the impacts of onsite storage of spent
33 nuclear fuel during the continued storage period are discussed in NUREG-2157 and as stated in
34 § 51.23(b), shall be deemed incorporated into this issue." The changes reflect that this issue
35 covers the environmental impacts associated with the storage of spent nuclear fuel during the
36 license renewal term as well as the period after the licensed life for reactor operations.

37 The Table B-1 entry for "Offsite radiological impacts of spent nuclear fuel and high-level waste
38 disposal" also was revised to reclassify the impact determination as a Category 1 issue with no
39 impact level assigned. The finding column entry for this issue includes reference to EPA's
40 radiation protection standards for the high-level waste and spent nuclear fuel disposal
41 component of the fuel cycle. Although the status of a repository, including a repository at Yucca
42 Mountain, is uncertain and outside the scope of the generic environmental analysis conducted

¹¹At the time of the 2013 final license renewal rule, the Continued Storage Rule was referred to by its long-standing historical moniker, Waste Confidence.

¹²These two issues were renamed, "Onsite storage of spent nuclear fuel" and "Offsite radiological impacts of spent nuclear fuel and high-level waste disposal," respectively, by the 2013 license renewal rule. See "Revisions to Environmental Review for Renewal of Nuclear Power Plant Operating Licenses," 78 FR 37282–37324 (June 20, 2013).

1 to support the Continued Storage Rule, the NRC believes that the current radiation standards
2 for Yucca Mountain are protective of public health and safety and the environment.

3 The changes to these two issues finalize the Table B-1 entries that the NRC had intended to
4 issue in its 2013 license renewal rulemaking, but was unable to because the 2010 Waste
5 Confidence rule had been vacated.

6 NUREG-2157 concludes that deep geologic disposal remains technically feasible, while the
7 bases for the specific conclusions in Table B-1 are found elsewhere (e.g., the 1996 rule that
8 issued Table B-1 and the 1996 license renewal GEIS, which provided the technical basis for
9 that rulemaking, as reaffirmed by the 2013 rulemaking and final license renewal GEIS). Based
10 on the Continued Storage Rule, these two issues were revised accordingly in Table B-1.

11 *4.13.1.2 CLI-14-08: Holding that Revised 10 CFR 51.23 and NUREG-2157 Satisfy NRC's*
12 *NEPA Obligations for Continued Storage and Directing Staff to Account for*
13 *Environmental Impacts In NUREG-2157*

14 In CLI-14-08 (NRC 2014b), the Commission held that the revised 10 CFR 51.23 and associated
15 NUREG-2157 cure the deficiencies identified by the court in *New York* and stated that the rule
16 satisfies the NRC's NEPA obligations with respect to continued storage for initial, renewed, and
17 amended licenses for reactors.

18 As the Commission noted in CLI-14-08, the NRC staff must account for these environmental
19 impacts before finalizing its licensing decision in this proceeding. To account for these impact
20 determinations, the generic environmental impact determinations made pursuant to the
21 Continued Storage Rule and the associated NUREG-2157 are deemed incorporated into this
22 SEIS.

23 The NRC staff relies on the Continued Storage Rule and its supporting generic environmental
24 impact statement (i.e., NUREG-2157) to provide the NEPA analyses of the environmental
25 impacts of spent fuel storage at the reactor site or at an away-from-reactor storage facility
26 beyond the licensed life for reactor operations. By virtue of the revised 10 CFR 51.23, the
27 impact determinations in NUREG-2157 regarding continued storage complete the analysis of
28 the environmental impacts associated with spent fuel storage beyond the licensed life for
29 reactor operations and are deemed incorporated into this SEIS, as further described below.

30 *4.13.1.3 At-Reactor Storage*

31 The analysis in NUREG-2157 concludes that the potential impacts of at-reactor storage during
32 the short-term timeframe (the first 60 years after the end of licensed life for operations of the
33 reactor) would be SMALL (see Section 4.20 of NUREG-2157). Furthermore, the analysis in
34 NUREG-2157 states that disposal of the spent fuel by the end of the short-term timeframe is the
35 most likely outcome (see Section 1.2 of NUREG-2157).

36 However, the analysis in NUREG-2157 also evaluated the potential impacts of continued
37 storage if the fuel is not disposed of by the end of the short-term timeframe. The analysis in
38 NUREG-2157 determined that the impacts to historic and cultural resources from at-reactor
39 storage during the long-term timeframe (the 100-year period after the short-term timeframe) and
40 the indefinite timeframe (the period after the long-term timeframe) are dependent on factors that
41 are unpredictable this far in advance and therefore concluded those impacts would be SMALL
42 to LARGE (see Section 4.12 of NUREG-2157). Among other things, as discussed in
43 NUREG-2157, the NRC cannot accurately determine at this time what resources may be
44 present or discovered at a continued storage site a century or more in the future and whether
45 those resources will be historically or culturally significant to future generations. Additionally,
46 impacts greater than SMALL could occur if the activities to replace an independent spent fuel

Environmental Consequences and Mitigating Actions

1 storage installation (ISFSI) and the dry transfer system (DTS) adversely affect cultural or historic
2 resources and the effects cannot be mitigated. As discussed in NUREG-2157, given the
3 minimal size of an ISFSI and DTS, and the large land areas at nuclear power plant sites,
4 licensees should be able to locate these facilities away from historic and cultural resources.
5 Potential adverse effects on historic properties or impacts on historic and cultural resources
6 could also be minimized through development of agreements, license conditions, and
7 implementation of the licensee's historic and cultural resource management plans and
8 procedures to protect known historic and cultural resources and address inadvertent discoveries
9 during construction and replacement of these facilities. However, it may not be possible to
10 avoid adverse effects on historic properties under the National Historic Preservation Act of 1966
11 (NHPA), as amended, or impacts on historic and cultural resources under NEPA and, therefore,
12 the analysis in NUREG-2157 concluded that impacts would be SMALL to LARGE (see
13 Section 4.12.2 of NUREG-2157).

14 The analysis in NUREG-2157 also concludes that the impacts of nonradioactive waste in the
15 indefinite timeframe would be SMALL to MODERATE, with the higher impacts potentially
16 occurring if the waste from repeated replacement of the ISFSI and DTS exceeds local landfill
17 capacity (see Section 4.15 of NUREG-2157). Although the NRC concluded that nonradioactive
18 waste disposal would not be destabilizing (or LARGE), the range reflects uncertainty regarding
19 whether the volume of nonradioactive waste from continued storage would contribute to
20 noticeable waste management impacts over the indefinite timeframe when considered in the
21 context of the overall local volume of nonradioactive waste.

22 As previously discussed, the NRC found in NUREG-2157 that disposal of the spent fuel is most
23 likely to occur by the end of the short-term timeframe. Therefore, disposal during the long-term
24 timeframe is less likely, and the scenario depicted in the indefinite timeframe—continuing to
25 store spent nuclear fuel indefinitely—is unlikely. As a result, the most likely impacts of the
26 continued storage of spent fuel are those considered in the short-term timeframe. In the unlikely
27 event that fuel remains on site into the long-term and indefinite timeframes, the associated
28 impact ranges in NUREG-2157 reflect the accordingly greater uncertainties regarding the
29 potential impacts over these very long periods of time. Taking into account the impacts that the
30 NRC considers most likely, which are SMALL; the greater uncertainty reflected in the ranges in
31 the long-term and indefinite timeframes compared to the greater certainty in the SMALL
32 findings; and the relative likelihood of the timeframes, the impact determinations for at-reactor
33 storage presented in NUREG-2157 are deemed incorporated into this SEIS pursuant to
34 10 CFR 51.23.

35 *4.13.1.4 Away-From-Reactor Storage*

36 In NUREG-2157, the NRC concluded that a range of potential impacts could occur for some
37 resource areas if the spent fuel from multiple reactors is shipped to a large (roughly 40,000
38 metric tons Uranium) away-from-reactor ISFSI (see Section 5.20 of NUREG-2157). The ranges
39 for some resources are driven by the uncertainty regarding the location of such a facility and the
40 local resources that would be affected.

41 For away-from-reactor storage, the unavoidable adverse environmental impacts for most
42 resource areas is SMALL across all timeframes, except for air quality, terrestrial resources,
43 aesthetics, waste management, and transportation where the impacts are SMALL to
44 MODERATE. Socioeconomic impacts range from SMALL (adverse) to LARGE (beneficial) and
45 historic and cultural resource impacts could be SMALL to LARGE across all timeframes. The
46 potential MODERATE impacts on air quality, terrestrial wildlife, and transportation are based on
47 potential construction-related fugitive dust emissions, terrestrial wildlife direct and indirect
48 mortalities, terrestrial habitat loss, and temporary construction traffic impacts. The potential

1 MODERATE impacts on aesthetics and waste management are based on noticeable changes
2 to the viewshed from constructing a new away-from-reactor ISFSI, and the volume of
3 nonhazardous solid waste generated by assumed facility ISFSI and DTS replacement activities
4 for the indefinite timeframe, respectively. The potential LARGE beneficial impacts on
5 socioeconomics are due to local economic tax revenue increases from an away-from-reactor
6 ISFSI.

7 The potential impacts to historic and cultural resources during the short-term storage timeframe
8 would range from SMALL to LARGE. The magnitude of adverse effects on historic properties
9 and impacts on historic and cultural resources largely depends on where facilities are sited,
10 what resources are present, the extent of proposed land disturbance, whether the area has
11 been previously surveyed to identify historic and cultural resources, and if the licensee has
12 management plans and procedures that are protective of historic and cultural resources. Even
13 a small amount of ground disturbance (e.g., clearing and grading) could affect a small but
14 significant resource. In most instances, placement of storage facilities on the site can be
15 adjusted to minimize or avoid impacts on any historic and cultural resources in the area.
16 However, the NRC recognizes that this may not always be possible. The NRC's site-specific
17 environmental review and compliance with the NHPA process could identify historic properties,
18 identify adverse effects, and potentially resolve adverse effects on historic properties and
19 impacts on other historic and cultural resources. Under the NHPA, mitigation does not eliminate
20 a finding of adverse effect on historic properties. The potential impacts to historic and cultural
21 resources during the long-term and indefinite storage timeframes would also range from SMALL
22 to LARGE. This range takes into consideration routine maintenance and monitoring (i.e., no
23 ground-disturbing activities), the absence or avoidance of historic and cultural resources, and
24 potential ground-disturbing activities that could affect historic and cultural resources. The
25 analysis also considers uncertainties inherent in analyzing this resource area over long
26 timeframes. These uncertainties include any future discovery of previously unknown historic
27 and cultural resources; resources that gain significance within the vicinity and the viewshed
28 (e.g., nomination of a historic district) due to improvements in knowledge, technology, and
29 excavation techniques and changes associated with predicting resources that future
30 generations will consider significant. If construction of a DTS and replacement of the ISFSI and
31 DTS occurs in an area with no historic or cultural resource present or construction occurs in a
32 previously disturbed area that allows avoidance of historic and cultural resources, then impacts
33 would be SMALL. By contrast, a MODERATE or LARGE impact could result if historic and
34 cultural resources are present at a site and, because they cannot be avoided, are impacted by
35 ground-disturbing activities during the long-term and indefinite timeframes.

36 Impacts on Federally listed species, designated critical habitat, and essential fish habitat would
37 be based on site-specific conditions and determined as part of consultations required by the
38 Endangered Species Act and the Magnuson-Stevens Fishery Conservation and Management
39 Act.

40 Continued storage of spent nuclear fuel at an away-from-reactor ISFSI is not expected to cause
41 disproportionately high and adverse human health and environmental effects on minority and
42 low-income populations. As indicated in the Commission's policy statement on environmental
43 justice, should the NRC receive an application for a proposed away-from-reactor ISFSI, a site-
44 specific NEPA analysis would be conducted, and this analysis would include consideration of
45 environmental justice impacts. Pursuant to 10 CFR 51.23, the impact determinations for away-
46 from-reactor storage presented in NUREG-2157 are deemed incorporated into this SEIS.

Environmental Consequences and Mitigating Actions

1 4.13.1.5 Cumulative Impacts

2 NUREG-2157 examines the incremental impact of continued storage on each resource area
3 analyzed in NUREG-2157 in combination with other past, present, and reasonably foreseeable
4 future actions. NUREG-2157 indicates ranges of potential cumulative impacts for multiple
5 resource areas (see Section 6.5 of NUREG-2157). However, these ranges are primarily driven
6 by impacts from activities other than the continued storage of spent fuel at the reactor site; the
7 impacts from these other activities would occur regardless of whether spent nuclear fuel is
8 stored during the continued storage period. In the short-term timeframe, which is the most likely
9 timeframe for the disposal of the fuel, the potential impacts of continued storage for at-reactor
10 storage are SMALL and would, therefore, not be a significant contributor to the cumulative
11 impacts. In the longer timeframes for at-reactor storage, or in the less likely case of away-from-
12 reactor storage, some of the impacts from the storage of spent nuclear fuel could be greater
13 than SMALL. As noted in NUREG-2157, other Federal and non-Federal activities occurring
14 during the longer timeframes include uncertainties as well. It is primarily these uncertainties
15 (i.e., those associated with activities other than continued storage) that contribute to the ranges
16 of potential cumulative impacts discussed throughout Chapter 6 of NUREG-2157 and
17 summarized in Table 6-4 of NUREG-2157. Because, as stated above, the impacts from these
18 other activities would occur regardless of whether continued storage occurs, the overall
19 cumulative impact conclusions in NUREG-2157 would still be the stated ranges regardless of
20 whether there are impacts of continued storage from any individual licensing action.

21 Taking into account the impacts that the NRC considers most likely, which are SMALL; the
22 uncertainty reflected by the ranges in some impacts; and the relative likelihood of the
23 timeframes, the impact determinations for cumulative impacts presented in NUREG-2157 are
24 deemed incorporated into this SEIS pursuant to 10 CFR 51.23.

25 4.13.1.6 Conclusion

26 Based on the information discussed above, the impacts of continued storage of spent nuclear
27 fuel are those presented in NUREG-2157 and are deemed incorporated into this SEIS pursuant
28 to 10 CFR 51.23. In addition, the revised 10 CFR 51.23 and NUREG-2157 have gone through
29 the rulemaking process that involved significant input from the public. Therefore, the NRC staff
30 concludes that the information in NUREG-2157 provides the appropriate NEPA analyses of the
31 potential environmental impacts associated with the continued storage of spent fuel beyond the
32 licensed life for reactor operations at Byron Station.

33 The NRC staff concludes that the revised 10 CFR 51.23, which adopts the generic impact
34 determination regarding continued storage from NUREG-2157, satisfies the NRC's NEPA
35 obligations with respect to continued storage of spent nuclear fuel, as it relates to the issues,
36 "Onsite storage of spent nuclear fuel" and "Offsite radiological impacts of spent nuclear fuel and
37 high-level waste disposal" for the environmental review associated the license renewal for
38 Byron.

39 4.13.2 No-Action Alternative

40 If the no-action alternative were implemented, Byron would cease operation at the end of the
41 initial operating licenses, or sooner, and enter decommissioning. The plants, which are
42 currently operating within regulatory limits, would generate less spent nuclear fuel and emit less
43 gaseous and liquid radioactive effluents into the environment. In addition, following shutdown,
44 the variety of potential accidents at the plants (radiological and industrial) would be reduced to a
45 limited set associated with shutdown events and fuel handling and storage. In Section 4.11 of
46 this SEIS, the NRC staff concluded that the impacts of continued operations on human health
47 would be SMALL. In Section 4.11 of this SEIS, the NRC staff concluded that the impacts of

1 accidents would be SMALL. In Section 4.15.2 of this SEIS the NRC staff concludes that the
2 impacts from decommissioning would be SMALL. Therefore, as radioactive emissions to the
3 environment decrease, and the likelihood and variety of accidents decrease following shutdown
4 and decommissioning, the NRC staff concludes that the risk to human health following plant
5 shutdown would be SMALL.

6 **4.13.3 New Nuclear Alternative**

7 Construction-related debris would be generated during construction activities, and would be
8 recycled or disposed of in approved landfills.

9 During normal plant operations, routine plant maintenance, and cleaning activities would
10 generate radioactive low-level waste, spent nuclear fuel, and high-level waste as well as
11 nonradioactive waste. Sections 3.1.4 and 3.1.5 discuss radioactive and nonradioactive waste
12 management at Byron. Quantities of radioactive and nonradioactive waste generated by Byron
13 would be comparable to that generated by the two new nuclear plants.

14 According to the GEIS (NRC 1996, 2013a), the generation and management of solid radioactive
15 and nonradioactive waste during the license renewal term are not expected to result in
16 significant environmental impacts.

17 Based on this information, the waste impacts would be SMALL for the new nuclear alternative.

18 **4.13.4 IGCC Alternative**

19 Construction-related debris would be generated during plant construction activities, and would
20 be recycled or disposed of in approved landfills. The amount of the construction waste would
21 be small compared to the amount of waste generated during the operational stage and much of
22 it could be recycled (i.e., marketed for beneficial use).

23 Coal combustion generates waste in the form of fly ash and bottom ash. In addition, equipment
24 for controlling air pollution generates additional ash, spent SCR catalyst, and scrubber sludge.
25 The management and disposal of the large amounts of coal combustion waste is a significant
26 part of the operation of a coal-fired power generating facility.

27 Although an IGCC facility is likely to use offsite disposal of coal combustion waste, some
28 short-term storage of coal combustion waste (either in open piles or in surface impoundments)
29 is likely to take place on site, thus establishing the potential for leaching of toxic chemicals into
30 the local environment.

31 The impacts of managing the substantial amounts of solid waste, especially fly ash and
32 scrubber sludge generated during operation of this alternative would be MODERATE
33 (NRC 1996).

34 Therefore, the staff concludes that the overall waste management impacts from construction
35 and operation of this alternative would be SMALL to MODERATE.

36 **4.13.5 NGCC Alternative**

37 Construction-related debris would be generated during plant construction activities, and would
38 be recycled or disposed of in approved landfills.

39 Waste generation from NGCC technology would be minimal. The only significant waste
40 generated at an NGCC power plant would be spent SCR catalyst, which is used to control
41 nitrogen oxide emissions.

Environmental Consequences and Mitigating Actions

1 The spent catalyst would be regenerated or disposed of off site. Other than spent SCR catalyst,
2 waste generation at an operating natural gas-fired plant would be limited largely to typical
3 operations and maintenance nonhazardous waste. Overall, the NRC staff concludes that waste
4 impacts from the NGCC alternative would be SMALL.

5 **4.13.6 Combination Alternative (NGCC, Wind, Solar)**

6 Construction-related debris would be generated during construction activities, and would be
7 recycled or disposed of in approved landfills.

8 Waste generation from NGCC technology would be minimal. The only significant waste
9 generated at an NGCC power plant would be spent SCR catalyst, which is used to control
10 nitrogen oxide emissions.

11 Waste generation from a combination of wind and solar PV alternatives would be minimal,
12 consisting of debris from routine maintenance and the disposal of worn or broken parts. Based
13 on this information, the NRC staff concludes that waste impacts from the construction and
14 operation of a combination wind and solar PV alternative would be SMALL.

15 **4.13.7 Purchased Power**

16 The types of waste generated by the alternative electricity generation sources (i.e., coal, natural
17 gas, nuclear, and wind) used in the purchased power alternative are discussed in
18 Sections 4.13.3, 4.13.4, 4.13.5, and 4.13.6. Depending on types of power-generation plants
19 used to provide the electricity for the purchased power alternative, the NRC staff concludes that
20 the waste management impacts would range from SMALL to MODERATE.

21 **4.14 Evaluation of New and Potentially Significant Information**

22 New and significant information is information that must be new, based on a review of the GEIS
23 (NRC 2013a) and codified in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, and must
24 bear on the proposed action or its impacts, presenting a seriously different picture of the
25 impacts from those envisioned in the GEIS (i.e., impacts of greater severity than impacts
26 considered in the GEIS, considering their intensity and context).

27 In accordance with 10 CFR 51.53(c), the ER that the applicant submits must provide an analysis
28 of the Category 2 issues in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B. Additionally, it
29 must discuss actions to mitigate any adverse impacts associated with the proposed action and
30 environmental impacts of alternatives to the proposed action. In accordance with
31 10 CFR 51.53(c)(3), the ER does not need to contain an analysis of any Category 1 issue
32 unless there is new and significant information on a specific issue.

33 The NRC process for identifying new and significant information is described in NUREG-1555,
34 Supplement 1, *Standard Review Plans for Environmental Reviews for Nuclear Power Plants*,
35 *Supplement 1: Operating License Renewal* (NRC 1999, 2013ai). The search for new
36 information includes:

- 37 • review of an applicant's ER and the process for discovering and evaluating
38 the significance of new information;
- 39 • review of public comments;
- 40 • review of environmental quality standards and regulations;

- 1 • coordination with Federal, state, local, and tribal environmental protection and
2 resource agencies; and
- 3 • review of the technical literature.

4 New information that the staff discovers is evaluated for significance using the criteria set forth
5 in the GEIS. For Category 1 issues in which new and significant information is identified,
6 reconsideration of the conclusions for those issues is limited in scope to assessment of the
7 relevant new and significant information; the scope of the assessment does not include those
8 facets of an issue that are not affected by the new information.

9 The NRC staff reviewed the discussion of environmental impacts associated with operation
10 during the renewal term in the GEIS and has conducted its own independent review, including a
11 public involvement process (e.g., public meetings) to identify new and significant issues for the
12 Byron license renewal application environmental review. The NRC staff has not identified new
13 and significant information on environmental issues related to operation of Byron during the
14 renewal term. The NRC staff also determined that information provided during the public
15 comment period did not identify any new issue that requires site-specific assessment.

16 **4.15 Impacts Common to All Alternatives**

17 This section describes the impacts that are considered common to all alternatives discussed in
18 this SEIS, including the proposed action and replacement power alternatives. The continued
19 operation of a nuclear power plant and replacement fossil fuel power plants both involve mining,
20 processing, and the consumption of fuel, which results in comparative impacts (NRC 2013a).
21 The termination of operations and the decommissioning of both a nuclear power plant and
22 replacement fossil fueled power plants are also discussed in the following sections, as well as
23 GHG emissions.

24 **4.15.1 Fuel Cycle**

25 This section describes the environmental impacts associated with the fuel cycles of the
26 proposed action and replacement power alternatives. Most replacement power alternatives
27 employ a set of steps in the utilization of their fuel sources, which can include extraction,
28 transformation, transportation, and combustion. Emissions generally occur at each stage of the
29 fuel cycle (NRC 2013a).

30 *4.15.1.1 Uranium Fuel Cycle*

31 The uranium fuel cycle issues applicable to Byron are discussed below and listed in Table 4–19
32 for Category 1 issues. Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 contains more
33 information on these issues.

1

Table 4–19. Issues Related to the Uranium Fuel Cycle

Issue	GEIS Section	Category
Offsite radiological impacts—individual impacts from other than the disposal of spent fuel and high-level waste	4.12.1.1	1
Office radiological impacts—collective impacts from other than the disposal of spent fuel and high-level waste	4.12.1.1	1
Nonradiological impacts of the uranium fuel cycle	4.12.1.1	1
Transportation	4.12.1.1	1

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

2 The uranium fuel cycle includes uranium mining and milling, the production of uranium
 3 hexafluoride, isotopic enrichment, fuel fabrication, reprocessing of irradiated fuel, transportation
 4 of radioactive materials, and management of low-level wastes and high-level wastes related to
 5 uranium fuel cycle activities. The generic potential impacts of the radiological and
 6 nonradiological environmental impacts of the uranium fuel cycle and transportation of nuclear
 7 fuel and wastes are described in detail in NUREG–1437, *Generic Environmental Impact*
 8 *Statement (GEIS) for License Renewal of Nuclear Plants* (NRC 1996, 1999, 2013a).

9 The NRC staff did not identify any new and significant information related to the uranium fuel
 10 cycle issues listed in Table 4–19 during its review of the applicant’s ER (Exelon 2013a), the site
 11 visit, and the scoping process. Therefore, there are no impacts related to these issues beyond
 12 those discussed in the GEIS. For these Category 1 issues, the GEIS concludes that the
 13 impacts are SMALL, except for the issue, “Offsite radiological impacts—collective impacts,” to
 14 which the NRC has not assigned an impact level. This issue assesses the 100-year radiation
 15 dose to the U.S. population (i.e., collective effects or collective dose) from radioactive effluent
 16 released as part of the uranium fuel cycle for a nuclear power plant during the license renewal
 17 term compared to the radiation dose from natural background exposure. It is a comparative
 18 assessment for which there is no regulatory standard to base an impact level.

19 **4.15.1.2 Replacement Power Plant Fuel Cycles**

20 **Fossil Fuel Energy Alternatives**

21 Fuel cycle impacts for a fossil-fuel-fired plant result from the initial extraction of fuel, cleaning
 22 and processing of fuel, transport of fuel to the facility, and management and ultimate disposal of
 23 solid wastes from fuel combustion. These impacts are discussed in more detail in
 24 Section 4.12.1.2 of the GEIS (NRC 2013a) and can generally include:

- 25 • significant changes to land use and visual resources;
- 26 • impacts to air quality, including release of criteria pollutants, fugitive dust,
 27 VOCs, and coalbed methane in the atmosphere;
- 28 • noise impacts;
- 29 • geology and soil impacts due to land disturbances and mining;
- 30 • water resource impacts, including degradation of surface water and
 31 groundwater quality;
- 32 • ecological impacts, including loss of habitat and wildlife disturbances;
- 33 • historic and cultural resources impacts within the mine footprint;

- 1 • socioeconomic impacts from employment of both the mining workforce and
- 2 service and support industries;
- 3 • environmental justice impacts;
- 4 • health impacts to workers from exposure to airborne dust and methane
- 5 gases; and
- 6 • generation of coal and industrial wastes.

7 New Nuclear Energy Alternatives

8 Fuel cycle impacts for a nuclear plant result from the initial extraction of fuel, transport of fuel to
9 the nuclear plant, and management and ultimate disposal of spent fuel. The environmental
10 impacts of the uranium fuel cycle are discussed above, in Section 4.15.1.1.

11 Renewable Energy Alternatives

12 The term “fuel cycle” has varying degrees of relevance for renewable energy facilities. The term
13 has meaning for renewable energy technologies that rely on combustion of fuels such as
14 biomass grown or harvested for the express purpose of power production. The term is
15 somewhat more difficult to define for renewable technologies such as wind, solar, geothermal,
16 and ocean wave and current. Those natural energy resources exist regardless of any effort to
17 harvest them for electricity production. The common technological strategy for harvesting
18 energy from such natural resources is to convert the kinetic or thermal energy inherent in that
19 resource to mechanical energy or torque. The torque is then applied directly (e.g., as in the
20 case of a wind turbine) or indirectly (e.g., for those facilities that use conventional steam cycles
21 to drive turbines that drive generators) to produce electricity. However, because those
22 renewable technologies capture very small fractions of the total kinetic or thermal energy
23 contained in those resources, impacts from the presence or absence of the renewable energy
24 technology are often indistinguishable (NRC 2013a).

25 **4.15.2 Terminating Power Plant Operations and Decommissioning**

26 This section describes the environmental impacts associated with the termination of operations
27 and the decommissioning of a nuclear power plant and replacement power alternatives. All
28 operating power plants will terminate operations and be decommissioned at some point after the
29 end of their operating life or after a decision is made to cease operations. For the proposed
30 action, license renewal would delay this eventuality for an additional 20 years beyond the
31 current license period, which ends in 2024 and 2026 for Byron Units 1 and 2, respectively.

32 *4.15.2.1 Existing Nuclear Power Plant*

33 Environmental impacts from the activities associated with the decommissioning of any reactor
34 before or at the end of an initial or renewed license are evaluated in Supplement 1 of
35 NUREG–0586, *Final Generic Environmental Impact Statement on Decommissioning of Nuclear*
36 *Facilities Regarding the Decommissioning of Nuclear Power Reactors* (NRC 2002).
37 Additionally, the incremental environmental impacts associated with decommissioning activities
38 resulting from continued plant operation during the renewal term are discussed in the GEIS.

39 Table 4–20 lists the Category 1 issues in Table B-1 of Title 10 of the CFR Part 51, Subpart A,
40 Appendix B that are applicable to Byron decommissioning following the license renewal term.

1

Table 4–20. Issues Related to Decommissioning

Issue	GEIS Section	Category
Radiation doses	4.12.2.1	1
Waste management	4.12.2.1	1
Air quality	4.12.2.1	1
Water quality	4.12.2.1	1
Ecological resources	4.12.2.1	1
Socioeconomic impacts	4.12.2.1	1

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51

2 Decommissioning would occur whether Byron were shut down at the end of its current operating
 3 license or at the end of the period of the license renewal term. Exelon stated in its ER
 4 (Exelon 2013a) that it is not aware of any new and significant information on the environmental
 5 impacts of Byron during the license renewal term. The NRC staff has not found any new and
 6 significant information during its independent review of Exelon’s ER, the site visit, or the scoping
 7 process. Therefore, the NRC staff concludes that there are no impacts related to these issues,
 8 beyond those discussed in the GEIS. For all of these issues, the NRC staff concluded in the
 9 GEIS that the impacts are SMALL.

10 *4.15.2.2 Replacement Power Plants*

11 Fossil Fuel Energy Alternatives

12 The environmental impacts from the termination of power plant operations and
 13 decommissioning of a fossil-fuel-fired plant are dependent on the facility’s decommissioning
 14 plan. General elements and requirements for a fossil fuel plant decommissioning plan are
 15 discussed in Section 14 of the GEIS and can include the removal of structures to at least 3 ft
 16 (1 m) below grade, removal of all coal, combustion waste, and accumulated sludge, removal of
 17 intake and discharge structures, and the cleanup and remediation of incidental spills and leaks
 18 at the facility. The decommissioning plan outlines the actions necessary to restore the site to a
 19 condition equivalent in character and value to the site on which the facility was first constructed
 20 (NRC 2013a).

21 The environmental consequences of decommissioning are discussed in Section 4.12.2.2 of the
 22 GEIS and can generally include:

- 23 • short-term impacts on air quality and noise from the deconstruction of facility
 24 structures,
- 25 • short-term impacts on land use and visual resources,
- 26 • long-term reestablishment of vegetation and wildlife communities,
- 27 • socioeconomic impacts due to decommissioning workforce and the long-term
 28 loss of jobs, and
- 29 • elimination of health and safety impacts on operating personnel and general
 30 public.

1 New Nuclear Alternatives

2 Termination of operations and decommissioning impacts for a nuclear plant include all activities
3 related to the safe removal of the facility from service and the reduction of residual radioactivity
4 to a level that permits release of the property under restricted conditions or unrestricted use and
5 termination of a license (NRC 2013a). The environmental impacts of the uranium fuel cycle are
6 discussed above, in Section 4.15.1.1.

7 Renewable Alternatives

8 Termination of power plant operation and decommissioning for renewable energy facilities
9 would be similar to the impacts discussed for fossil-fuel-fired plants above. Decommissioning
10 would involve the removal of facility components and operational wastes and residues in order
11 to restore the site to a condition equivalent in character and value to the site on which the facility
12 was first constructed (NRC 2013a).

13 **4.15.3 Greenhouse Gas Emissions and Climate Change**

14 The following sections discuss GHG emissions released from operation of Byron Station and
15 the environmental impacts that could occur from changes in climate conditions. The cumulative
16 impacts of GHG emissions on climate are discussed in Section 4.16.11, Global Climate
17 Change.

18 *4.15.3.1 Greenhouse Gas Emissions From the Proposed Project and Alternatives*

19 Gases found in the Earth's atmosphere that trap heat and play a role in Earth's climate are
20 collectively termed GHGs. GHGs include carbon dioxide (CO₂), methane (CH₄), nitrous oxide
21 (N₂O), water vapor (H₂O), and fluorinated gases such as hydrofluorocarbons (HFCs),
22 perfluorocarbons (PFCs), and sulfur hexafluoride (SF₆). Earth's climate responds to changes in
23 concentration of GHG in the atmosphere as GHGs affect the amount of energy absorbed and
24 heat trapped by the atmosphere. Increasing GHG concentration in the atmosphere generally
25 increases Earth's surface temperature. Atmospheric concentrations of carbon dioxide,
26 methane, and nitrous oxide have significantly increased since 1750 (Solomon et al. 2007).
27 Carbon dioxide, methane, nitrous oxide, HFCs, PFCs, and sulfur hexafluoride (termed long-lived
28 GHGs) are well-mixed throughout Earth's atmosphere and their impact on climate is long-lasting
29 as a result of their long atmospheric lifetime (EPA 2009b). Carbon dioxide is of primary concern
30 for global climate change due to its long atmospheric lifetime, and it is the primary gas emitted
31 as a result of human activities. Climate change research indicates that the cause of the Earth's
32 warming over the last 50 years is due to the buildup of GHGs in atmosphere resulting from
33 human activities (Melillo et al. 2014).

34 Proposed Action

35 Plant operations at Byron Station release GHG emissions (primarily carbon dioxide) from
36 stationary combustion sources, such as standby emergency diesel generators, auxiliary boilers,
37 auxiliary feedwater (AFW) pumps, SX makeup water pumps, and a fire pump. Other sources
38 include mobile combustion sources (e.g., compressors, generators) and vehicle traffic (such as
39 workers and delivery). Fluorinated gases are used as the refrigerant in air conditioning and
40 refrigeration systems and in electrical transmission and distribution systems. These fluorinated
41 gases are typically emitted in small quantities but their impacts could be substantial because of
42 high global warming potential.

43 The GHG emissions generated directly and indirectly by an entity can be classified into
44 three "Scopes," based on the source of the emissions (EPA 2013a). Scope 1 GHG emissions
45 are direct emissions that are owned or controlled by the entity, which include emissions from

Environmental Consequences and Mitigating Actions

1 fossil fuels burned on site, emissions from entity-owned or entity-leased vehicles, and other
2 direct sources. Scope 2 GHG emissions are indirect emissions resulting from the generation of
3 electricity, heating/cooling, or steam generated off site but purchased by the reporting entity.
4 Scope 3 GHG emissions are indirect emissions from sources not owned or directly controlled by
5 the reporting entity but related to the entity's activities such as vendor supply chains, delivery
6 services, outsourced activities, and employee travel and commuting. GHG emissions from
7 nuclear power plants including Byron Station belong to all three Scopes. Annual total GHG
8 emissions at Byron Station are presented in Table 4–21 for the 2008 to 2012 period. Direct
9 emissions include permitted combustion sources only, which are reported to the IEPA per the
10 requirements of 35 IAC Part 254 (Exelon 2009, 2010, 2011, 2012, 2013c). Total (direct plus
11 indirect) GHG emissions include permitted combustion sources (diesel generators and auxiliary
12 boilers), fugitive gas emissions, direct fluorinated gases, indirect purchased electricity, and
13 ozone depleting substances from refrigerants. However, total emissions do not include GHG
14 emissions from mobile sources because Exelon does not compile site-specific data for such
15 sources (Exelon 2013b). The NRC staff estimates annual GHG emission resulting from
16 employee vehicles to be approximately 8,400 MT CO₂e.

17 **Table 4–21. Estimated GHG Emissions From Operations at Byron Station**

Year	CO ₂ e (MT/year)
2008	12,102
2009	10,872
2010	12,059
2011	12,017
2012	13,962

Source: Exelon 2013b

18 No-Action Alternative

19 As discussed in previous no-action alternative sections, the no-action alternative represents a
20 decision by the NRC not to renew the operating license of a nuclear power plant beyond the
21 current operating license term. At some point, all nuclear plants will terminate operations and
22 undergo decommissioning. Under the no-action alternative, plant operations for Byron would
23 terminate at or before the end of the current license term (NRC 2013a). When the plant stops
24 operating, there will be a reduction in GHG emissions from activities related to plant operation,
25 such as use of diesel generators and employee vehicles. GHG emissions are anticipated to be
26 less than what is presented in Table 4–21.

27 New Nuclear Alternative

28 As discussed in Section 2.2.2.2, the NRC staff evaluated the new nuclear power plant
29 alternative that would consist of two units with an approximate generating capacity of
30 1,120 MWe each. The GEIS presents life-cycle GHG emissions associated with nuclear power
31 generation. As presented in Tables 4.12-4 through 4.12-6 of the GEIS, life-cycle¹³ GHG
32 emissions from nuclear power generation can range from 1 to 288 g carbon equivalent per
33 kilowatt-hour (C_{eq}/kWh). Operation of nuclear power plants does not burn fossil fuels to

¹³Life-cycle carbon emissions analyses consider construction, operation, decommissioning, and associated processing of fuel (gas, coal, etc.).

1 generate electricity and so does not directly emit GHG emissions. Sources of GHG emissions
 2 include stationary combustion sources (e.g., emergency diesel generators, diesel-driven fire
 3 pumps, auxiliary boilers) and mobile sources (worker vehicles, onsite heavy equipment and
 4 support vehicles, and delivery of materials and disposal of wastes). As discussed in
 5 Section 4.3.3.1, it is anticipated that air emissions from a new nuclear power plant would be
 6 similar to those from Byron.

7 IGCC Generation Alternative

8 As discussed in Section 2.2.2.2, the NRC staff evaluated the IGCC plant alternative that would
 9 consist of four units with a total output of 2,472 MW.

10 The IGCC alternative would release GHGs. The NRC staff estimates that operation of
 11 four IGCC units will directly emit about 14.3 million t (approximately 12.9 million MT) per year of
 12 CO₂e.

13 Emissions were estimated for the IGCC alternative without CCS. Among the alternatives, GHG
 14 emissions are the highest from IGCC plants. As described in Chapter 2, the IGCC alternative
 15 assumes that the plants may install CCS technology at some point in the future, which would
 16 reduce carbon dioxide emissions considerably. The DOE's National Energy Technology
 17 Laboratory (NETL) performed a study to establish the cost and performance for a range of
 18 carbon dioxide capture levels (up to 97 percent) for new IGCC power plants (NETL 2013a). The
 19 study identified technical configurations that were tailored to achieve a specific level of carbon
 20 capture.

21 NGCC Generation Alternative

22 As discussed in Section 2.2.2.3, the NRC staff evaluated an NGCC alternative that consists of
 23 five NGCC 560-MWe units (total 2,800 MWe). The GEIS presents life-cycle GHG emissions
 24 associated with natural gas power generation. As presented in Table 4.12-5 of the GEIS,
 25 life-cycle GHG emissions from natural gas can range from 120 to 930 g C_{eq}/kWh. The NRC
 26 staff estimates that operation of the NGCC alternative directly will emit about 7.9 million t
 27 (approximately 7.2 million MT) per year of CO₂e emissions.

28 Combination Alternative (NGCC, Wind, and Solar)

29 For this combination alternative, it is assumed that the majority of the GHG emissions result
 30 from the NGCC portion only because renewable portions (wind and solar PV) do not burn fossil
 31 fuels to generate electricity. As discussed in Section 4.3.6.1, GHG emissions associated with
 32 the operation of the NGCC portion are reduced proportionally because its electricity output is
 33 approximately 13 percent that of the NGCC alternative. The NRC staff estimates that operation
 34 of the combination alternative will directly emit 1.0 million t (0.9 million MT) per year of CO₂e.

35 Purchased Power Alternative

36 Purchased power would come from common types of existing technology (coal, natural gas,
 37 nuclear, and renewable sources) within the ROI and it is not likely that new facilities would be
 38 constructed to replace Byron. GHG emissions from purchased power will vary and depend on
 39 the type and combination of technology purchased power comes from. In 2012, coal, natural
 40 gas, and nuclear power accounted for 37-, 30-, and 19-percent share, respectively, of total
 41 U.S. electricity generation (EIA 2014). Using these percent shares for the purchased power
 42 alternative, the NRC staff estimates 7.7 million t (6.9 million MT) per year of CO₂e will be
 43 emitted. However, GHG emissions may be greater or less than this estimate and will depend
 44 on the technology from which the purchased power comes.

Environmental Consequences and Mitigating Actions

1 Summary of GHG Emissions From the Proposed Action and Alternatives

2 Table 4–22 presents the direct uncontrolled GHG emissions from operation of the proposed
3 action and alternatives. GHG emissions from the proposed action (continued operation at
4 Byron) and the new nuclear alternative would be lowest. GHG emissions for IGCC, NGCC,
5 combination, and purchased power alternatives are higher than those for the proposed action
6 and a new nuclear alternative by several orders of magnitude. GHG emissions for purchased
7 power are expected to be greater than the NGCC alternative, but less than the IGCC
8 alternative.

9 **Table 4–22. Direct Uncontrolled GHG Emissions From Operation of the Proposed Action**
10 **and Alternatives**

Technology	CO ₂ e (MT/year)
Byron Station continued operation	1.363×10 ³
New Nuclear	1.363×10 ³
IGCC	13.0×10 ⁶
NGCC	7.2×10 ⁶
Combination ^(a)	1.0×10 ⁶
Purchased Power ^(b)	6.9×10 ⁶

^(a) Only NGCC portion of GHG emissions

^(b) Assumed air emissions were estimated by assuming that purchased-power coal accounted for 37 percent share, natural gas a 30 percent share, nuclear a 19 percent share, and renewable a 14 percent share of electricity generation.

11 *4.15.3.2 Climate Change Impacts to Resource Areas*

12 Climate change is the decades or longer change in climate measurements (temperature,
13 precipitation, etc.) that has been observed on a global, national, and regional level (EPA 2012a;
14 Melillo et al. 2014; Solomon et al. 2007). Climate change can vary regionally, spatially, and
15 seasonally depending on local, regional, and global factors. Just as the regional climate differs
16 throughout the world, the impacts of climate change can vary between locations.

17 On a global level, from 1901 to 2011, average surface temperatures have risen at a rate of
18 0.08 °C (0.14 °F) per decade, and total annual precipitation has increased at an average rate of
19 2.3 percent per decade (EPA 2012a). The observed global change in average surface
20 temperature and precipitation has been accompanied by an increase in sea surface
21 temperatures, a decrease in global glacier ice, increase in sea level, and changes in extreme
22 weather events. Such extreme events include an increase in frequency of heat waves, heavy
23 precipitation, and minimum and maximum temperatures (EPA 2012a; Karl et al. 2009;
24 Melillo et al. 2014; Solomon et al. 2007).

25 In the United States, the U.S. Global Change Research Program (USGCRP) reports that from
26 1895 to 2012, average surface temperature has increased by 1.3 °F to 1.9 °F (0.72 to 1.06 °C)
27 and since 1900, average annual precipitation has increased by 5 percent (Melillo et al. 2014).
28 On a seasonal basis, warming has been the greatest in winter and spring. From 1895 to 2001,
29 an increase in the length of the freeze-free season, the period between the last occurrence of
30 0 °C (32 °F) in the spring and first occurrence of 0 °C (32 °F) in the fall has been observed for the
31 contiguous United States; between 1991 and 2011 the average freeze-free season was 10 days

1 longer than between 1901 and 1960 (Melillo et al. 2014). Since the 1970s, the United States
2 has warmed at a faster rate as the average surface temperature rose at an average rate of 0.17
3 to 0.25 °C (0.31 to 0.45 °F) per decade. In addition, the year 2012 was the warmest on record
4 (Melillo et al. 2014). Observed climate-related changes in the United States include increases
5 in the frequency and intensity of heavy precipitation, earlier onset of spring snowmelt and runoff,
6 rise of sea level in coastal areas of the United States, increase in occurrence of heat waves,
7 and a decrease in occurrence of cold waves (EPA 2012a; Karl et al. 2009; Kunkel et al. 2013b;
8 Melillo et al. 2014).

9 Temperature data indicate that the Midwest region, where Byron is located, experienced a
10 0.06 °C (0.11 °F) per decade increase in annual mean temperature during the 1900 to 2010
11 period (Kunkel et al. 2013a). Temperature data for the recent past indicate an increased rate of
12 warming for the Midwest: 0.12 °C (0.22 °F) per decade for the 1950 to 2010 time period and a
13 0.26 °C (0.47 °F) temperature increase for the 1979 to 2010 time period. Average annual
14 precipitation data for the Midwest exhibit an increasing trend of 0.31 in. per decade for the
15 long-term period (1895 to 2011) (Kunkel et al. 2013a). Precipitation data over the 1958 to 2007
16 period exhibit clear trends toward more very-heavy precipitation events (defined as the heaviest
17 1 percent of all daily events) for the Nation as a whole, and particularly in the Northeast and
18 Midwest. Temperature and precipitation trends were analyzed for the period of 1961 to 2012 at
19 the Rockford Airport (NCDC 1984, 2013). Although there are large year-to-year variations, a
20 clear upward trend in temperature and a downward trend in precipitation are observed. At
21 Byron, for the 1973 to 2013 period, an upward trend in ambient annual average temperature
22 has also been observed (Exelon 2013b).

23 Future GHG emission concentration and climate models are commonly used to project possible
24 climate change. Climate models indicate that over the next few decades, temperature
25 increases will continue due to current GHG emissions concentrations in the atmosphere (Melillo
26 et al. 2014). Over the longer term, the magnitude of temperature increases and climate change
27 effects will depend on both past and future GHG emission scenarios (Karl et al. 2009;
28 Melillo et al. 2014; Solomon et al. 2007). Climate models project a continued increase in global
29 surface temperatures, more frequent and long-lasting heat waves, continued increase in sea
30 level, continued decline in arctic sea ice, an increase in heavy precipitation events, and an
31 increased frequency of severe droughts.

32 For the license renewal period of Byron, climate model simulations (between 2021 and 2050
33 relative to the reference period (1971 to 1999)) indicate an increase in annual mean
34 temperature in the Midwest region from 2.5 to 3.5 °F (1.5 to 2.1 °C) (Kunkel et al. 2013a). The
35 predicted increase in temperature during this time period occurs for all seasons with the largest
36 increase occurring in the summertime (June, July, and August). Models project an increase in
37 summertime mean temperatures of 3 °F (1.6 °C); however, climate models displayed a wide
38 range in summertime temperatures, ranging from an increase of 1.5 to 5.5 °F (0.76 to 2.98 °C)
39 (Kunkel et al. 2013a). Climate model simulations (for the time period 2021 to 2050) suggest
40 spatial differences in annual mean precipitation changes for the Midwest with northern areas
41 experiencing an increase in precipitation and the southern areas experiencing a decrease in
42 precipitation. For Illinois, the models indicate a 0 to 3 percent increase in annual mean
43 precipitation with fall, winter, and spring seasons experiencing precipitation change increases
44 and the summer season experiencing a decrease in precipitation. However, these changes in
45 precipitation were not significant and the models indicate changes that are less than normal
46 year-to-year variations (Kunkel et al. 2013a). While future regional changes in precipitation are
47 difficult to predict, the USGCRP reports that storm tracks are expected to shift northward,
48 increases in heavy precipitation events will continue, the number of dry days between rainfalls
49 will increase, and an increase in drought are expected (Melillo et al. 2014).

Environmental Consequences and Mitigating Actions

1 Changes in climate have broader implications for public health, water resources, land use and
2 development, and ecosystems. For instance, changes in precipitation patterns and increase in
3 air temperature can affect water availability and quality, distribution of plant and animal species,
4 and land-use patterns and land cover, which can in turn affect terrestrial and aquatic habitats.
5 The following sections discuss how future climate change may impact air quality, water
6 resources, land use, terrestrial resources, aquatic resources, and human health in the region of
7 interest for Byron Station. Although there is uncertainty in the exact future climate change
8 scenario, the discussions provided below demonstrate the potential implications of climate
9 change on resources.

10 Air Quality

11 Air pollutant concentrations result from complex interactions between physical and dynamic
12 properties of the atmosphere, land, and ocean. The formation, transport, dispersion, and
13 deposition of air pollutants depend in part on weather conditions (Parry et al. 2007). Air
14 pollutant concentrations are sensitive to winds, temperature, humidity, and precipitation
15 (EPA 2009b). Hence, climate change can impact air quality as a result of the changes in
16 meteorological conditions.

17 Ozone has been found to be particularly sensitive to climate change (EPA 2009a; Melillo
18 et al. 2014; Parry et al. 2007). Ozone is formed as a result of the chemical reaction of nitrogen
19 oxides and VOCs in the presence of heat and sunlight. Sunshine, high temperatures, and air
20 stagnation are favorable meteorological conditions to higher levels of ozone (EPA 2009a; Parry
21 et al. 2007). The emission of ozone precursors also depends on temperature, wind, and solar
22 radiation (Parry et al. 2007); both nitrogen oxide and biogenic VOC emissions are expected to
23 be higher in a warmer climate (EPA 2009a). Warmer climate and weaker air circulation are
24 conducive to higher ozone levels. Regional air quality modeling indicates that the northern
25 regions of the United States can experience an increase in ozone concentration by the year
26 2050 (Tagaris et al. 2009). However, air quality projections (particularly ozone and particulate
27 matter with aerodynamic diameters of 2.5 μm or less ($\text{PM}_{2.5}$)) are uncertain and indicate that
28 concentrations are driven primarily by emissions rather than by physical climate change
29 (Stocker et al. 2013). The combination of higher temperatures, stagnant air masses, sunlight,
30 and emissions of precursors may make it difficult to meet ozone NAAQS (Karl et al. 2009).

31 Land Use

32 Anthropogenic land use is both a contributor to climate change as well as a receptor of climate
33 change impacts (Dale 1997). As described previously in this section, the Midwest will likely
34 experience rising temperatures and heavier precipitation events during the proposed license
35 renewal period. Agriculture (the major land use in the vicinity of Byron) and growing urban
36 areas will further exacerbate these changes by continuing to inhibit natural ecosystem functions
37 that could moderate climate change effects. For instance, air temperatures and near-surface
38 moisture levels change in areas where natural vegetation is converted to agricultural use, and in
39 the Midwest, higher temperatures have been observed as a result of converting land to
40 agricultural use (Melillo et al. 2014). The USGCRP (Melillo et al. 2014) indicates that land use
41 changes, such as the continued expansion of urban areas, paired with climate change effects,
42 such as heavier precipitation events, can exacerbate climate change effects, including reduced
43 water filtration into the soil and increased surface runoff. While anthropogenic land uses will
44 contribute to climate change in these and other ways, land uses will also be affected by climate
45 change in several ways. For instance, plant winter hardiness zones are likely to shift one-half to
46 one full zone by the end of the proposed license renewal period (Melillo et al. 2014). This will
47 affect the ability to grow certain crops as the Midwest will likely contain plants now associated
48 with the Southeast by the end of the century (Melillo et al. 2014). Water availability will likely

1 affect urban areas, which are growing rapidly in the Midwest. This growth will likely lead to
2 water use conflicts as climate change reduces water availability and the growing population
3 requires more water.

4 Water Resources

5 Predicted changes in the timing, intensity, and distribution of precipitation would be likely to
6 result in changes in surface water runoff affecting water availability across the Midwest. As
7 discussed above, the Midwest may experience increased precipitation during the fall, winter,
8 and spring. As cited by the USGCRP, the loss of moisture from soils because of higher
9 temperatures, as is projected for the Midwest, along with evapotranspiration from vegetation, is
10 likely to increase the frequency, duration, and intensity of droughts across the region into the
11 future (Karl et al. 2009; Melillo et al. 2014); such conditions can reduce the amount of water
12 available for surface runoff and streamflow. Runoff and streamflow at a regional scale for the
13 Midwest region indicate no clear trend during the last half century. However, annual runoff and
14 river flow are projected to increase in the upper Midwest, and soil moisture has increased in
15 most seasons in the upper Midwest between 1998 and 2010 (Melillo et al. 2014). Climate
16 change impacts on groundwater availability depends on basin geology, frequency and intensity
17 of high-rainfall periods, recharge, soil moisture, and groundwater–surface water interactions
18 (Melillo et al. 2014). Precipitation and evapotranspiration are key drivers in aquifer recharge.
19 Although exact responses in groundwater storage and flow to climate change are not
20 well-understood, recent studies have started to consider the effects that climate change has on
21 groundwater resources (Melillo et al. 2014).

22 Terrestrial Resources

23 As described above, the Midwest will likely experience rising temperatures and heavier
24 precipitation events during the proposed license renewal period. As the climate changes,
25 terrestrial resources will either need to be able to tolerate the new physical conditions or shift
26 their population range to new areas with a more suitable climate. Scientists currently estimate
27 that species are shifting their ranges at a rate of between 6.1 to 11 m (20 to 36 ft) in elevation
28 per decade and 6.1 to 16.9 km (3.8 to 10.5 mi) in latitude per decade (Chen et al. 2011;
29 Thuiller 2007). While some species may readily adapt to a changing climate, others may be
30 more prone to experience adverse effects. For example, species whose ranges are already
31 limited by habitat loss or fragmentation or who require very specific environmental conditions
32 may not be able to successfully shift their ranges over time. Migratory birds that travel long
33 distances may also be disproportionately affected because they may not be able to pick up on
34 environmental cues that a warmer, earlier spring is occurring in the United States while
35 overwintering in tropical areas. Fraser et al. (2013) found that songbirds overwintering in the
36 Amazon did not leave their winter sites earlier, even when spring sites in the Eastern
37 United States experienced a warmer spring. As a result, the songbirds missed periods of peak
38 food availability. Habitat ranges for forest systems in the Midwest, such as paper birch, balsam
39 fir, and black spruce, are projected to decline across the Midwest as they shift northward, and
40 species that are common farther south, such as oaks and pines, will expand their range north
41 into the Midwest region (Melillo et al. 2014). Special status species and habitats, such as those
42 that are Federally protected by the ESA, would likely be more sensitive to climate changes
43 because these species' populations are already experiencing threats that are endangering their
44 continued existence throughout all or a significant portion of their ranges. Climate changes
45 could also favor nonnative, invasive species and promote population increases of insect pests
46 and plant pathogens, which may be more tolerant to a wider range of climate conditions.

Environmental Consequences and Mitigating Actions

1 Aquatic Resources

2 The potential effects of climate change, whether from natural cycles or manmade activities
3 could result in changes that would affect aquatic resources in the Rock River. Raised air
4 temperatures could result in higher water temperatures in the Rock River and its tributaries.
5 Higher water temperatures would increase the potential for thermal effects on aquatic biota and
6 could exacerbate existing environmental stressors, such as excess nutrients, sedimentation,
7 and lowered dissolved oxygen associated with eutrophication (Melillo et al. 2013). The Midwest
8 will likely experience increased frequency of extreme rainfall events, which will cause erosion
9 and could lead to a decline in water quality (Melillo et al. 2014). Species that require cleaner
10 waters, such as freshwater mussels, could experience further population declines. The
11 USGCRP (Melillo et al. 2014) predicts habitat loss and local extinctions of fish and other aquatic
12 species throughout the United States from the combined effects of water withdrawal and climate
13 change. Shifts in species' assemblages and distributions are also likely as climate change
14 continues (Melillo et al. 2014), and these shifts could alter the balance of the aquatic community
15 in the Rock River. As discussed above under "Terrestrial Resources," special status species,
16 such as those that are Federally protected under the ESA, would be more sensitive to climate
17 changes. Invasions of nonnative species that thrive under a wide range of environmental
18 conditions could further disrupt the current composition of aquatic communities (NRC 2013a).

19 Historic and Cultural Resources

20 Increases in river and lake water levels because of changes in meteorological conditions due to
21 climate change could result in the loss of historic and cultural resources from flooding, erosion,
22 or inundation. Due to water-level changes, some resources could be lost before they could be
23 documented or otherwise studied. However, the limited extent of climate change that may
24 occur during the 20-year license renewal term would not likely result in any significant loss of
25 historic and cultural resources at Byron.

26 Socioeconomics

27 Rapid changes in climate conditions could have an impact on the availability of jobs in certain
28 industries. For example, tourism and recreation are major job creators in some regions,
29 bringing billions of dollars to regional economies. Across the Nation, fishing, hunting, and other
30 outdoor activities make important economic contributions to rural economies and are also a part
31 of the cultural tradition. A changing climate would mean reduced opportunities for some
32 activities in some locations and expanded opportunities for others. Hunting and fishing
33 opportunities could also change as animals' habitats shift and as relationships among species
34 are disrupted by their different responses to climate change (Melillo et al. 2014).
35 Water-dependent recreation could also be affected (Karl et al. 2009;). The USGCRP reports
36 that increasing heat and humidity associated with climate change in parts of the Midwest region
37 by the year 2050 could create unfavorable conditions for summertime outdoor recreation and
38 tourism activity (Melillo et al. 2014). However, the limited extent of climate change that may
39 occur during the 20-year license renewal term would not be likely to cause any significant
40 changes in socioeconomic conditions in the vicinity of Byron.

41 Human Health

42 Increasing temperatures due to changes in climate conditions could have an impact on human
43 health. However, changes in climate conditions that may occur during the license renewal term
44 will not result in any change to the impacts discussed in Section 4.11 from Byron's radioactive
45 and nonradioactive effluents.

1 Environmental Justice

2 Rapid changes in climate conditions could disproportionately affect minority and low-income
3 populations. The USGCRP (Karl et al. 2009) indicates that “infants and children, pregnant
4 women, the elderly, people with chronic medical conditions, outdoor workers, and people living
5 in poverty are especially at risk from a variety of climate-related health effects.” Examples of
6 these effects include increased heat stress, air pollution, extreme weather events, and diseases
7 carried by food, water, and insects. The greatest health burdens related to climate change are
8 likely to fall on the poor, especially those lacking adequate shelter and access to other
9 resources such as air conditioning. Elderly people on fixed incomes, who are more likely to be
10 poor, are more likely to have debilitating chronic diseases or limited mobility. In addition, the
11 elderly have a reduced ability to regulate their own body temperature or sense when they are
12 too hot. According to the USGCRP (Karl et al. 2009), they “are at greater risk of heart failure,
13 which is further exacerbated when cardiac demand increases in order to cool the body during a
14 heat wave.” The USGCRP study also found that people taking medications, such as diuretics
15 for high blood pressure, have a higher risk of dehydration (Karl et al. 2009). The USGCRP
16 (Melillo et al. 2014) study reconfirmed the previous report findings regarding the risks of climate
17 change on low-income populations, and also warns that climate change could affect the
18 availability and access to local plant and animal species, thus impacting the people that have
19 historically depended on them for food or medicine (Melillo et al. 2014). However, due to the
20 amount of expected change in the environment during the 20-year license renewal term,
21 minority and low-income populations at Byron are not likely to experience disproportionately
22 high and adverse impacts from climate change.

23 **4.16 Cumulative Impacts of the Proposed Action**

24 The NRC staff considered potential cumulative impacts in the environmental analysis of
25 continued operation Byron during the 20-year license renewal period. Cumulative impacts may
26 result when the environmental effects associated with the proposed action are overlaid or added
27 to temporary or permanent effects associated with other past, present, and reasonably
28 foreseeable actions. Cumulative impacts can result from individually minor, but collectively
29 significant, actions taking place over a period of time. It is possible that an impact that may be
30 SMALL by itself could result in a MODERATE or LARGE cumulative impact when considered in
31 combination with the impacts of other actions on the affected resource. Likewise, if a resource
32 is regionally declining or imperiled, even a SMALL individual impact could be important if it
33 contributes to or accelerates the overall resource decline.

34 For the purposes of this cumulative analysis, past actions are those before the receipt of the
35 license renewal application. Present actions are those related to the resources at the time of
36 current operation of the power plant, and future actions are those that are reasonably
37 foreseeable through the end of plant operation, including the period of extended operation.
38 Therefore, the analysis considers potential impacts through the end of the current license terms
39 as well as the 20-year renewal license term. The geographic area over which past, present,
40 and reasonably foreseeable actions would occur depends on the type of action considered and
41 is described below for each resource area.

42 To evaluate cumulative impacts, the incremental impacts of the proposed action, as described
43 in Sections 4.2 to 4.15, are combined with other past, present, and reasonably foreseeable
44 future actions regardless of what agency (Federal or non-Federal) or person undertakes such
45 actions. The NRC staff used the information provided in Exelon’s ER; responses to requests for
46 additional information; information from other Federal, State, and local agencies; scoping
47 comments; and information gathered during the visits to the Byron site to identify other past,

Environmental Consequences and Mitigating Actions

1 present, and reasonably foreseeable actions. To be considered in the cumulative analysis, the
2 NRC staff determined if the project would occur within the noted geographic areas of interest
3 and within the period of extended operation, was reasonably foreseeable, and if there would be
4 a potential overlapping effect with the proposed project. For past actions, consideration within
5 the cumulative impacts assessment is resource- and project-specific. In general, the effects of
6 past actions are included in the description of the affected environment in Chapter 3, which
7 serves as the baseline for the cumulative impacts analysis. However, past actions that continue
8 to have an overlapping effect on a resource potentially affected by the proposed action are
9 considered in the cumulative analysis.

10 Other actions and projects identified during this review and considered in the NRC staff's
11 analysis of the potential cumulative effects are described in Appendix E. Not all actions or
12 projects listed in Appendix E are considered in each resource area due to the uniqueness of the
13 resource and its geographic area of consideration.

14 **4.16.1 Air Quality and Noise**

15 This section addresses the direct and indirect effects of license renewal on air quality and noise
16 when added to the aggregate effects of other past, present, and reasonably foreseeable future
17 actions. As described in Section 4.3.1, the incremental impacts on air quality and noise levels
18 from the proposed license renewal would be SMALL.

19 *4.16.1.1 Air Quality*

20 The geographic area considered in the cumulative air quality analysis is the county of the
21 proposed action as air quality designations for criteria air pollutants are generally made at the
22 county level. Counties are further grouped together based on a common airshed—known as an
23 Air Quality Control Region (AQCR)—to provide for the attainment and maintenance of the
24 NAAQS. The Byron site is located in Ogle County, Illinois, which is part of Rockford (Illinois)–
25 Janesville–Beloit (Wisconsin) Interstate AQCR (40 CFR 81.71).

26 As noted in Section 3.3.2, EPA regulates six criteria pollutants under the NAAQS, including
27 carbon monoxide, lead, nitrogen dioxide, ozone, sulfur dioxide, and PM. With regard to the
28 NAAQS criteria pollutants, Ogle County is designated as an attainment/unclassifiable area for
29 all criteria pollutants (40 CFR 81.314).

30 Criteria pollutant air emissions from the Byron site are presented in Section 3.3.2; these
31 emissions are from permitted sources including standby emergency diesel generators, auxiliary
32 boilers, AFW pumps, SX makeup water pumps, a fire pump, and two natural draft and
33 two mechanical draft cooling towers (Exelon 2013b). Since there will be no
34 refurbishment-related activities, the NRC staff expects similar emissions during the license
35 renewal period. Therefore, cumulative changes to air quality in Hamilton County and AQCR
36 would be the result of changes to present-day emissions as well as future projects and actions
37 within the county.

38 Appendix E provides a list of present and reasonably foreseeable projects that could contribute
39 to cumulative impacts to air quality. For example, there are limited industrial facilities, including
40 two landfills, one small hydroelectric power plant, and several water supply and treatment
41 facilities, within the 80-km (50-mi) radius of Byron Station, and IEPA regulates air emissions
42 through air permits. Continued air emissions from existing projects and actions listed in
43 Appendix F as well as proposed new source activities would contribute to air emissions in Ogle
44 County.

45 At Byron Station, about 60 staff could be added to implement aging management programs and
46 temporary workforces on staggered 18-month refueling cycles (Exelon 2013a). Additionally,

1 Units 1 and 2 reactor pressure vessel head replacement (assumed to occur during a 7-day
2 period with 340 additional workers) and Unit 2 SG replacement (estimated to require an
3 additional 500 workers for 90 days) may occur at Byron. The main contributors to air quality
4 impacts associated with these activities would be fugitive dust generation from construction
5 activities, work to open containment to replace the SGs and related equipment, and exhaust
6 emissions from motorized equipment and vehicles of temporary workers. The additional vehicle
7 air emissions resulting from the additional workforce for SG replacement activities (used as the
8 bounding conditions for this analysis) would be temporary and are estimated to result in an
9 additional 3.3 t (3.0 MT) of VOCs, 9.8 t (8.9 MT) of nitrogen oxides, 0.04 t (0.04 MT) of sulfur
10 dioxide, and 0.40 t (0.36 MT) of PM_{2.5} (direct emissions) being emitted, which do not exceed the
11 de minimis levels of 100 t per year set forth in 40 CFR 93.153(b). Therefore, the additional
12 emissions resulting from these activities at Byron are expected to be minor.

13 Development and construction activities associated with regional growth of housing, business,
14 and industry, as well as associated vehicular traffic, will also result in additional air emissions.
15 Project timing and location, which are difficult to predict, affect cumulative impacts to air quality.
16 However, permitting and licensing requirements, efficiencies in equipment, cleaner fuels, and
17 various mitigation measures can be used to minimize cumulative air quality impacts.
18 Accordingly, cumulative impacts on air quality are expected to be minor and remain minor
19 during the license renewal term.

20 Climate change can impact air quality as a result of changes in meteorological conditions. Air
21 pollutant concentrations are sensitive to winds, temperature, humidity, and precipitation
22 (EPA 2009b). As discussed in Section 4.15.3.2, ozone levels have been found to be particularly
23 sensitive to climate change influences (EPA 2009a; Solomon et al. 2007). Sunshine, high
24 temperatures and air stagnation are favorable meteorological conditions leading to higher levels
25 of ozone (EPA 2009a; Solomon et al. 2007). The combination of higher temperatures, stagnant
26 air masses, sunlight, and emissions of precursors may make it difficult to meet ozone NAAQS
27 (Karl et al. 2009). States, however, must continue to comply with the CAA and ensure air
28 quality standards are met.

29 *4.16.1.2 Noise*

30 Section 3.3.3 presents a summary of noise sources at Byron and site vicinity. Noise emission
31 sources from Byron include cooling towers, ventilation supply and exhaust fans, transformers,
32 intake water pumps, transmission lines, infrequent relief valves, onsite vehicle traffic (commuter
33 or delivery trucks), and shooting range activities (Exelon 2013b).

34 Noise is usually considered as a local problem. Noise levels in the vicinity of a nuclear power
35 plant could increase from planned activities associated with urban, industrial, and commercial
36 development. The magnitude of cumulative impacts depends on the nuclear plant's proximity to
37 other noise sources. A 3-dBA change in sound level is considered barely discernible, as
38 discussed in Section 3.3.3. A 3-dBA increase would occur with the placement of another
39 identical source over an existing source, (e.g., double the traffic volume). Ongoing or
40 foreseeable future projects in and around the Byron Station as identified in Appendix F would
41 increase noise levels only in the vicinity of their noise sources, and combined noise levels are
42 not expected to be high enough to cause noise issues. For instance, activities at the Byron site
43 related to SG replacement or reactor pressure vessel head replacement, if they occur, would
44 increase noise levels as a result of construction activities related to the storage facility,
45 motorized equipment, and increased vehicles. Construction equipment, for instance, can result
46 in noise levels in the range of 85 to 90 dBA; however, noise levels attenuate rapidly with
47 distance such that at half a mile distance from construction equipment, noise levels can drop to
48 51 to 61 dBA (NRC 2002). Additional noise from construction activities would be temporary and

Environmental Consequences and Mitigating Actions

1 intermittent and the majority of work activities would occur inside of buildings. The additional
2 noise sources are not expected to be audible beyond the site boundary. Therefore,
3 contributions to noise levels from future actions are limited by projects in the vicinity of Byron.
4 Accordingly, cumulative impacts on noise levels are expected to be minor and remain minor
5 during the license renewal term.

6 *4.16.1.3 Conclusion*

7 Past, present, and reasonably foreseeable future activities exist in the geographic areas of
8 interest (local for noise, local and regional for criteria pollutants) that could affect air quality and
9 noise resources. However, the incremental contribution of impacts on air quality and noise
10 resources from plant operations at Byron Station would be minimal. The NRC staff concludes
11 that cumulative impacts from other past, present, and reasonably foreseeable future actions on
12 air quality and noise resources in the geographic areas of interest would be SMALL.

13 **4.16.2 Geology and Soils**

14 This section addresses the direct and indirect effects of license renewal on geology and soils
15 when added to the aggregate effects of other past, present, and reasonably foreseeable future
16 actions. As noted in Section 2.1.2, Exelon has no plans to conduct refurbishment or
17 replacement actions, and activities associated with continued operations are not expected to
18 affect the geologic environment. Ongoing operation and maintenance activities at the Byron site
19 are expected to be confined to previously disturbed areas, and geologic conditions are not
20 expected to change during the license renewal term. Any use of geologic materials, such as
21 aggregates to support operation and maintenance activities, would be procured from local and
22 regional sources. These materials are abundant in the region, and supplies would be sufficient
23 for any current or future projects in the area requiring these materials. Thus, the NRC staff
24 concludes that the cumulative impact of the proposed license renewal of Byron, when combined
25 with other past, present, and reasonably foreseeable future projects or actions, would be
26 SMALL on geology and soils.

27 **4.16.3 Water Resources**

28 This section addresses the direct and indirect effects of license renewal on surface water and
29 groundwater when added to the aggregate effects of other past, present, and reasonably
30 foreseeable future actions. As described in Sections 4.5.1.1 and 4.5.1.2, the incremental
31 impacts on water resources from continued operations of Byron during the license renewal term
32 would be SMALL. NRC staff also conducted an assessment of other projects and actions for
33 consideration in determining their cumulative impacts on water resources (see Appendix F).
34 The geographic area considered for the surface water resources component of the cumulative
35 impacts analysis spans the Rock River basin. For groundwater, the geographic area of interest
36 is comprised of the local groundwater basin relative to the Byron site, the Ironton-Galesville and
37 Mt. Simon Sandstone aquifers. As such, this review focused on those projects and activities
38 that would (1) withdraw water from or discharge wastewater to the Rock River basin or (2) use
39 groundwater from the Ironton-Galesville and Mt. Simon Sandstone aquifers.

40 *4.16.3.1 Surface Water Resources*

41 The Rock River basin drains an area of approximately 10,915 square miles (mi²) (17,566 square
42 kilometers (km²)). Approximately half of the basin is in northern Illinois while the remaining half
43 is in south-central Wisconsin (Section 3.5.1.1, Figure 3–8). From Wisconsin, the river drains
44 southwestward through Illinois and into the Mississippi River. The landscape and soils have a
45 substantial influence on the hydrology of the Rock River basin and the landscape of the Rock

1 River basin is quite varied. The landscape includes dissected, hilly terrain, rolling hills, and a
2 flat outwash plain. There is also considerable spatial variability in the permeability and drainage
3 characteristics of the soils in the basin. However, land use, another important influence of the
4 hydrology of a drainage basin, is comparatively homogeneous, with more than 85 percent of the
5 basin in row crops or rural grassland (Knapp and Russell 2004).

6 The total population residing in the Rock River basin in both Wisconsin and Illinois is about
7 1.7 million people. The two major population centers in the basin are the cities of Rockford,
8 Illinois, and Madison, Wisconsin. Between 1990 and 2000, the population in the Illinois portion
9 of the basin rose by approximately 10 percent as a result of growth near the Chicago
10 metropolitan area. However, the population in the western part of the basin (which includes the
11 Byron site) experienced little or no increases in population. The eastern part of the basin will
12 likely continue to see significant population growth in future decades as the margins of the
13 Chicago metropolitan area continue to expand (Knapp and Russell 2004).

14 Prior to European settlement, the land cover in the Rock River basin was a mixture of open
15 woodland interspersed with short- and tall-grass prairie. The Rock River basin also had
16 abundant wetlands, lakes, and large marshes. Today, the only remaining large marsh in the
17 watershed is the Horicon Marsh, near the headwaters of the Rock River in northern Dodge
18 County, Wisconsin. It has been designated a “wetland of international importance”. Agriculture
19 (including cultivation, the removal and drainage of wetland areas, stream channelization, and
20 deforestation) has had a large impact on the basin. Most of these major modifications to the
21 landscape occurred in the late 1800s, prior to the onset of stream gaging activities; thus, the
22 large-scale effects of these modifications on stream flow hydrology were not quantitatively
23 measured (IEPA 2006; Knapp and Russell 2004).

24 There are seven low-head channel dams on the Rock River in Illinois. These dams originally
25 were built in the mid-1800s to early 1900s and are typically 10 to 15 ft (3 to 5 m) high. For the
26 most part, these small reservoirs do not have a noticeable impact on stream flows in the Rock
27 River. From the 1960s through 1999, average stream flow rates for the Rock River in Illinois
28 have increased. These increases appear to be most directly related to increases in the average
29 precipitation over the Rock River basin (IDNR 1998a, 2001).

30 In Illinois, the Rock River is not used as a source of public water or for navigation
31 (Exelon 2013a). Other than for thermoelectric power generation, most water in the basin used
32 for public, commercial, and industrial purposes is obtained from groundwater (Dziegielewski
33 et al. 2005; IEPA 2006). Much of the water obtained from groundwater is eventually discharged
34 into streams as treated wastewater, which adds additional water to the Rock River.

35 Surface water from the Rock River in Illinois has been able to support ongoing demands and will
36 likely be sufficient through the license renewal term based on current projections. Future water
37 demand (both groundwater and surface water) in the Illinois counties within the Rock River
38 basin is projected to increase by about 10 percent from 2000 to 2025. Most of this projected
39 demand is for thermoelectric generation near the southern end of the river in the County of Rock
40 Island. The Byron plant is located in Ogle County. In Ogle County, water demand from either
41 surface water or groundwater is projected to increase by only a small amount for all types of
42 water uses (including thermoelectric generation, public supply, commercial, and industrial).
43 From 2005 to 2025, water demand in Ogle County is projected to increase by about 2 percent.
44 This is a 2.1 mgd (7,900 cubic meters per day) increase above 2000 water use (Dziegielewski
45 et al. 2005).

46 As described in Section 4.15.3.2, future climatic changes are anticipated to result in increased
47 precipitation overall across the region including an increase in heavy-precipitation events, which
48 in turn would tend to result in increased runoff and flow over the headwaters of the Rock River.

Environmental Consequences and Mitigating Actions

1 If future water demand increases through the period of extended operation (up to 2046) are
2 similar to the projected demand increases between 2005 and 2025, then surface water supplies
3 appear to be abundant enough to meet the reasonably foreseeable demand. Consumptive
4 water use from continued Byron operations will continue to be a very small percentage of the
5 overall flow of the Rock River.

6 Within Illinois, the surface water quality of the Rock River watershed is judged to be generally
7 good. The primary causes of water quality problems are siltation, suspended solids,
8 hydrologic/habitat modifications, and nutrients largely attributed to agriculture, with some
9 contribution from urban runoff (IEPA 1996). It is reasonable to anticipate that water
10 quality-based limits imposed by NPDES permits on wastewater discharges from Byron and on
11 other industrial facilities will continue to maintain or improve ambient surface water quality in
12 the Rock River.

13 *4.16.3.2 Groundwater Resources*

14 Groundwater resources at the site are described in Section 3.5.2. Byron has not impacted and
15 is not reasonably expected to impact the quality of groundwater in any aquifers that are a
16 current or potential future source of water for offsite users. Byron consumes groundwater from
17 the Ironton-Galesville and Mt. Simon Sandstone aquifers. Because of its depth, the Mt. Simon
18 Sandstone Aquifer is not used as a source of water by local wells. The nearest consumer of
19 Ironton-Galesville and Mt. Simon Sandstone Aquifer groundwater is the City of Byron, which is
20 6.4 km (4 mi) northwest of the site (Exelon 2013a). Groundwater modeling of the impact of
21 pumping the site groundwater wells at high volumes for an extended period of time did not show
22 any discernible impact on the City of Byron wells (Exelon 2013a).

23 As discussed in Section 4.15.3, the water demand in Ogle County for all types of water use
24 (including thermoelectric generation, public supply, commercial, and industrial) is projected to
25 increase by only a small amount. Future climatic changes are not anticipated to result in
26 decreased groundwater recharge and the availability of groundwater resources. If future water
27 demand increases through the period of licensing (up to 2046) are similar to the projected
28 demand increases between 2005 and 2025, then groundwater supplies appear to be abundant
29 enough to meet reasonably foreseeable demand.

30 *4.16.3.3 Conclusion*

31 The Byron facility has not impacted and is not expected to impact the quality of groundwater in
32 any aquifers that are a current or potential future source of water for offsite users, and
33 groundwater supply is abundant enough to meet reasonably foreseeable demand.
34 Consumptive surface water use from continued Byron operations will continue to be a very
35 small percentage of the overall flow of the Rock River, and ongoing and future surface water
36 demands by users are expected to be supported. Surface water discharges to the Rock River
37 by Byron and other industrial users will be monitored and kept at acceptable limits via NPDES
38 permits. Considering ongoing activities and reasonably foreseeable actions, the NRC staff
39 concludes that cumulative impact of the proposed license renewal when combined with other
40 past, present, and reasonably foreseeable future activities would be SMALL on surface water
41 and groundwater use and quality.

42 **4.16.4 Terrestrial Resource**

43 This section addresses past, present, and future actions that could result in cumulative impacts
44 on the terrestrial species and habitats described in Section 3.6. For purposes of this analysis,
45 the geographic area considered in the evaluation includes the Byron site. The baseline for this
46 assessment is the condition of the resource without action (i.e., the no-action alternative).

1 Section 4.6 of this SEIS concludes that the impact from the proposed license renewal would not
2 noticeably alter the terrestrial environment and would be SMALL.

3 *4.16.4.1 Historic Conditions*

4 Section 3.6 discusses the ecoregions in which the Byron site lies, including the central
5 U.S. Plains and the central Corn Belt Plains. Gently rolling smooth plains, irregular plains, and
6 shallow stream valleys characterize much of the area. The native landscape of the ecoregion
7 was composed of bluestem prairie communities and oak–hickory forests, but has mostly been
8 replaced by corn and soybean agriculture. Agricultural lands are the predominant land cover in
9 the ecoregion at 75.3 percent, followed by developed land (11.6 percent), and forests
10 (9.3 percent). Although developed land is less prominent than agricultural land, from 1973 to
11 2000, the percent of developed land has increased 2.4 percent, while the percent of agricultural
12 land and forested land has decreased (Karstensen et al. 2013).

13 Approximately 538 ac (218 ha) total of the Byron site was disturbed during the construction of
14 Byron Station (30 percent). Of the Byron site (840 ac (340 ha)), 47 percent has been leased for
15 agricultural use. This land is considered disturbed because most of it is tilled. The remaining
16 23 percent (404 ac (163 ha)) of Byron is undisturbed land. The terrestrial habitats on the
17 undeveloped portions of the site have not changed significantly since Byron’s construction
18 (Exelon 2013b).

19 *4.16.4.2 Urbanization*

20 As the region surrounding the Byron site becomes more developed, habitat fragmentation will
21 increase. Species that require larger ranges, especially predators, will likely suffer reductions in
22 their populations. Herbivores will experience less predation pressure and their populations will
23 likely increase. Edge species will benefit from fragmentation, while species that require interior
24 forest or swamp habitat will likely suffer.

25 *4.16.4.3 Agricultural Runoff*

26 Within Ogle County, 89 percent of land is used for agriculture. The major crops grown in Ogle
27 County are corn and soybeans. Wheat, oats, and hay are also grown (Exelon 2013a).
28 Livestock raised in Ogle County include cattle and hogs (Exelon 2004). The 2000 National
29 Water Quality Inventory reported that agricultural nonpoint source pollution accounted for the
30 second largest source of impairments to wetlands (EPA 2002). Fertilizers and pesticides can
31 affect wetlands and bottomlands in a number of ways. Because wetlands and bottomlands are
32 often at lower elevation than surrounding land, these habitats receive much of the runoff first,
33 and that runoff persists because it is unable to drain to lower ground. This can result in
34 bioaccumulation of pollutants and changes to species composition and abundance. Species
35 that rely on wetlands, such as birds and amphibians, are more sensitive to these environmental
36 stressors than other wildlife.

37 *4.16.4.4 Park and Conservation Areas*

38 In Ogle County, the Lowden-Miller State Forest and the adjacent Castle Rock State Park are
39 both designated Important Bird Areas and contain high-quality terrestrial habitats. Together,
40 this 4,225-ac (1,710-ha) area provides some of the most diverse terrestrial habitats in the Upper
41 Rock River Basin. This State-protected forest will continue to provide valuable habitat to native
42 wildlife and migratory birds during the proposed license renewal period. As habitat
43 fragmentation resulting from various types of nearby development increases, these areas will
44 become ecologically more important because they provide large and diverse areas of natural
45 habitat.

Environmental Consequences and Mitigating Actions

1 4.16.4.5 Unit 2 Steam Generator Replacement

2 As discussed in Section 2.1.2, Exelon determined that no major refurbishment or replacement
3 activities were needed to support the operation of Byron beyond the end of the existing
4 operating license (Exelon 2013a). However, in its ER, Exelon (2013a) indicated that it may
5 perform a replacement of Unit 2's SGs during the period of extended operation. Since the
6 Unit 2 SG replacement is not necessary to enter the period of extended operation, the NRC staff
7 is considering this action as a cumulative impact rather than part of the proposed action.
8 Because Exelon has previously replaced the Unit 1 SGs, Exelon would be able to make use of
9 previously built infrastructure if the Unit 2 SGs were to be replaced. An additional SG storage
10 facility or expansion of the existing Unit 1 storage facility could be required, but no undisturbed
11 land would be affected (Exelon 2013a). New SGs would be transported to the site via existing
12 rail and would not require any road or rail upgrades (Exelon 2013a). Wildlife could experience
13 temporary increases in noise and traffic to and from the site during the SG replacement period
14 that could lead to behavioral changes, habitat abandonment, or increased susceptibility to injury
15 or mortality from vehicle strikes. However, because nuclear plants often pair such activities with
16 refueling periods, the incremental increase in noise and traffic attributable to the SG
17 replacement would not create measurable impacts on terrestrial wildlife. Terrestrial habitats and
18 vegetation would be unaffected.

19 4.16.4.6 Conclusion

20 Section 4.6 of this SEIS concludes that the impact from the proposed license renewal would not
21 noticeably alter the terrestrial environment and would be SMALL. However, as environmental
22 stressors such as agricultural runoff and residential development continue over the proposed
23 license renewal term, certain attributes of the terrestrial environment (such as species diversity
24 and distribution) are likely to noticeably change. The NRC staff does not expect these impacts
25 to destabilize any important attributes of the terrestrial environment, but instead cause gradual
26 change, which would allow the terrestrial environment to adapt appropriately. The NRC staff
27 concludes that the cumulative impacts of the proposed license renewal of Byron and other past,
28 present, and reasonably foreseeable future projects or actions would result in MODERATE
29 impacts to terrestrial resources.

30 4.16.5 Aquatic Resources

31 This section addresses the direct and indirect effects of license renewal on aquatic resources
32 when added to the aggregate effects of other past, present, and reasonably foreseeable future
33 actions. Section 4.7 of this document finds that the direct and indirect impacts on aquatic
34 resources from the proposed license renewal when considered in the absence of the aggregate
35 effects would be SMALL. The cumulative impact is the total effect on the aquatic resources of
36 all actions taken, no matter who has taken the actions (the second principle of cumulative
37 effects analysis in CEQ 1997).

38 Two related concepts bound the analysis of cumulative impacts: the timeframe and geographic
39 extent. The timeframe for cumulative analyses for ecological resources extends far enough into
40 the past to understand the processes that affect the present resource conditions and to examine
41 whether and why aquatic resources are stable or unstable, which the NRC definitions of impact
42 levels require. The timeframe for cumulative impact analysis is more extensive than that for the
43 direct and indirect impact analysis.

44 The geographic extent considered in this cumulative aquatic resource analysis depends on the
45 particular cumulative impacts being discussed. Direct and indirect impacts from the Byron site
46 are limited to the Rock River. During preoperational and operational monitoring, studies
47 determined that the effects of Byron operations on aquatic resources are effectively confined to

1 an area of the Rock River that extends from 300 yards (270 m) upstream of the cooling tower
2 blowdown discharge point and continues 0.7 mi (1.1 km) downstream of the discharge point (as
3 discussed in Section 3.7). Fish and other aquatic organisms that occur in this area could travel
4 upstream or downstream. These species' movement would be largely prohibited by dams on
5 the river—the Rockford Dam upstream and the Oregon Dam approximately 5 mi (8 km)
6 downstream of the Byron site—and thus, direct and indirect effects to aquatic resources that
7 could result from continued operation of Byron and other actions could not be meaningfully
8 discerned or described beyond these points. However, projects or actions located beyond this
9 geographic area could directly or indirectly affect the aquatic resources in this area. This
10 section focuses on the cumulative effects of such actions.

11 The level of cumulative impacts is measured against a baseline. Consistent with the Council on
12 Environmental Quality's (CEQ's) (1997) NEPA guidance, the term "baseline" pertains to the
13 condition of the resource without the action, (i.e., under the no-action alternative). Under the
14 no-action alternative, the plant would shut down and the resource would conceptually return to
15 its condition without the plant (which is not necessarily the same as the condition before the
16 plant was constructed). The baseline, or benchmark, for assessing cumulative impacts on
17 aquatic resources takes into account the preoperational environment as recommended by
18 EPA (1999b) for its review of NEPA documents.

19 *4.16.5.1 Past River Development, Channelization, and Damming*

20 The Rock River basin covers 6,481 mi² (10,430 km²) within Illinois, and Ogle County is wholly
21 contained within the basin. The basin has experienced considerable land use modification
22 since European settlement, which has affected Rock River aquatic resources. Beginning in the
23 early 1900s, several swamps in the Rock River basin were drained, and the river was dredged
24 and channelized for navigation. Seven low-head dams, one of which still operates, were
25 constructed by the 1930s (Sinclair 1996). These changes have divided certain aquatic biota
26 into localized populations and altered stream flow, quality, and aquatic communities
27 significantly.

28 *4.16.5.2 Energy Development*

29 Five nuclear power plant sites with nine operating reactors lie within 50 mi (80 km) of the Byron
30 site (see Appendix E). Because the effects of these facilities would primarily be limited to the
31 water body from which they draw cooling water and none of these facilities draw from the Rock
32 River, the operation of these facilities would not result in cumulative effects to the aquatic
33 resources affected by Byron operation.

34 The North American Hydro Rockton Plant lies approximately 130 mi (209 km) north of Byron on
35 the Rock River. This facility began operating in 1929, and the Federal Energy Regulatory
36 Commission (FERC) has licensed it to operate through August 2023 (NAH 2014). If this
37 facility's license is renewed, the renewed term would overlap with Byron's proposed license
38 renewal period, which begins in 2024 (Unit 1) and 2026 (Unit 2). Hydroelectric dams are
39 barriers to fish migration, and the transport of fish, eggs, and larvae through the dams result in
40 some mortality (Cada 1991; Watters 2000). Dams alter flow regimes and water quality, which
41 modifies the quality and types of downstream aquatic microhabitats. This facility has likely
42 contributed to significant changes in aquatic communities in the Rock River and will continue to
43 do so during the proposed Byron license renewal period if it is relicensed to operate
44 beyond 2023.

45 The Nelson Energy Center is a combined-cycle facility that is currently under construction in
46 Rock Falls, Illinois, approximately 26 mi (42 km) southwest of Byron. The facility would begin
47 operating in 2015, prior to the proposed Byron license renewal period, and would use natural

Environmental Consequences and Mitigating Actions

1 gas fuel to operate. The IEPA issued the facility a draft NPDES Permit in August 2013 that
2 would authorize Invenergy Nelson, LLC, to discharge into the Rock River (IEPA 2013). The
3 Nelson Energy Center will be located well downriver of Byron and will be hydrologically
4 separated by the Oregon Dam and the Dixon Dam. Accordingly, the effects of Rock River water
5 use by each facility would not overlap or would be too small to be meaningfully described or
6 detected. Air emissions from the Nelson Energy Center will include GHGs such as nitrogen
7 oxides, carbon dioxide, and methane. Air emissions can have far-reaching consequences
8 because they cumulatively contribute to climate change. The effects of climate change on
9 aquatic resources are discussed in Section 4.15.3.2.

10 *4.16.5.3 Runoff from Agriculture and Municipal Facilities*

11 Illinois river and stream ecosystems historically have had naturally wooded floodplains, which
12 moderated water temperatures and stabilized stream banks to reduce erosion. Less than
13 10 percent of land bordering the Rock River remains forested, and much of the floodplains have
14 been converted to cropland. This has likely contributed to erosion and sedimentation and will
15 continue to do so during the proposed Byron license renewal period. In 1996, the IEPA rated
16 67 percent of the Rock River mainstem as “Full Support,” which means that these portions of
17 the river meet the needs of all designated uses protected by applicable water quality standards
18 (IDNR 1998b). The IEPA rated the remaining 33 percent of the mainstem as “Partial
19 Support/Minor Impairment,” which means that the water quality has been impaired, but only to a
20 minor degree. Suspended solids, phosphorus, and other organic nutrients from agricultural
21 runoff and municipal discharges were major contributors to this rating.

22 *4.16.5.4 Parks and Recreational Areas*

23 Several parks and natural areas lie within the vicinity of Byron (see Appendix E) including Castle
24 Rock State Park, which lies approximately 10 mi (16 km) downstream of the Byron. The
25 continued preservation of these areas will protect aquatic habitats and as land development
26 continues, these areas will become ecologically more important because they will provide large
27 areas of unfragmented natural habitat.

28 *4.16.5.5 Conclusion*

29 NRC staff concludes that the cumulative impacts on aquatic resources in the Rock River are
30 MODERATE based on past, present, and reasonably foreseeable future actions. This level of
31 impact is primarily the result of past river channelization and damming and ongoing runoff and
32 sedimentation from agriculture. The environmental effects of these actions are clearly
33 noticeable, but available information on the status of the Rock River aquatic communities does
34 not indicate that these effects have destabilized any important attribute of the community in the
35 vicinity of Byron. The incremental, site-specific impact from the continued operation of Byron
36 during the license renewal period would be minor and not noticeable in comparison to
37 cumulative impact on the aquatic ecology.

38 **4.16.6 Historic and Cultural Resources**

39 This section addresses the direct and indirect effects of license renewal on historic and cultural
40 resources when added to the aggregate effects of other past, present, and reasonably
41 foreseeable future actions. The geographic area considered in this analysis is the APE
42 associated with the proposed undertaking, as described in Section 3.9.

43 The archaeological record for the region indicates prehistoric and historic occupation of the
44 Byron site and its immediate vicinity. The construction of Byron resulted in destruction of
45 cultural resources within the Byron site and surrounding area. Other historic land development
46 in the vicinity of Byron also resulted in impacts on, and the loss of, cultural resources on the

1 Byron site and its immediate vicinity. However, there remains the possibility for additional
2 historic or cultural resources to be located within the Byron site. The present and reasonably
3 foreseeable projects which could affect these resources reviewed in conjunction with license
4 renewal are noted in Appendix F of this document. Direct impacts would occur if historic and
5 cultural resources in the APE were physically removed or disturbed. Indirect visual or noise
6 impact could occur from new construction or maintenance. The following projects are located
7 within the geographic area considered for cumulative impacts:

- 8 • Unit 2 SG replacement,
- 9 • Units 1 and 2 reactor pressure vessel head replacement, and
- 10 • future urbanization in the immediate vicinity of Byron.

11 As described in Section 4.9, no cultural resources would be adversely affected by Byron Units 1
12 and 2 license renewal activities as no associated changes or ground-disturbing activities will
13 occur (Exelon 2013a). Unit 2 SG replacement, Units 1 and 2 reactor pressure vessel head
14 replacement, and future urbanization all have the potential to result in impacts on cultural
15 resources through inadvertent discovery during ground-disturbing activities. However, as
16 discussed in Section 4.9, Exelon has established draft procedures to ensure cultural resources
17 are considered in project planning during normal operation of Byron. Therefore, the NRC staff
18 concludes that the cumulative impact of the proposed license renewal on historic and cultural
19 resources, when combined with other past, present, and reasonably foreseeable future
20 activities, would be SMALL.

21 **4.16.7 Socioeconomics**

22 This section addresses socioeconomic factors that have the potential to be directly or indirectly
23 affected by changes in operations at Byron in addition to the aggregate effects of other past,
24 present, and reasonably foreseeable future actions. The primary geographic area of interest
25 considered in this cumulative analysis is Ogle, Lee, and Winnebago counties, where
26 approximately 81 percent of Byron employees reside (see Table 3–16). This is where the
27 economy, tax base, and infrastructure would most likely be affected because Byron workers and
28 their families reside, spend their incomes, and use their benefits within these counties.

29 As discussed in Section 4.10 of this SEIS, continued operation of Byron during the license
30 renewal term would have no impact on socioeconomic conditions in the region beyond those
31 already being experienced. Since Exelon has no plans to hire additional workers during the
32 license renewal term, overall expenditures and employment levels at Byron would remain
33 relatively constant and unchanged with no additional demand for permanent housing and public
34 services. In addition, as employment levels and tax payments would not change, there would
35 be no population or tax revenue-related land-use impacts. Based on this and other information
36 presented in preceding sections in Chapter 4 of this SEIS, there would be no additional
37 contributory effect on socioeconomic conditions in the future from the continued operation of
38 Byron during the license renewal term beyond what is currently being experienced. Therefore,
39 the only contributory effects would come from reasonably foreseeable future planned activities
40 at Byron, unrelated to the proposed action (license renewal), and other reasonably foreseeable
41 planned offsite activities. For example, residential development is forecast for the Byron area,
42 but not to the point that overall socioeconomic conditions would noticeably change.

43 *4.16.7.1 Unit 2 Steam Generator Replacement*

44 Exelon indicated that the Unit 2 SG replacement would occur during the license renewal term.
45 Exelon estimates that SG replacement would occur during a 90-day period paralleling a

Environmental Consequences and Mitigating Actions

1 refueling outage or other scheduled maintenance outage. Steam generator replacement would
2 require 500 personnel, in addition to the 1,400 personnel required for refueling (Exelon 2013a).
3 These additional workers would create a short-term increase in the demand for temporary
4 (rental) housing, an increased use of public water and sewer services, and transportation
5 impacts on access roads in the immediate vicinity of Byron. Given the short amount of time
6 needed to replace the SG, the additional number of refueling outage and SG replacement
7 workers and truck deliveries needed to support this one-time replacement, SG replacement
8 could have a temporary cumulative effect on socioeconomic conditions in the vicinity of the
9 nuclear plant. However, since the number of nonoutage workers at Byron would not change
10 after SG replacement, there would be no long-term cumulative socioeconomic impacts in the
11 region.

12 *4.16.7.2 Units 1 and 2 Reactor Pressure Vessel Head Replacement*

13 Exelon indicated that the reactor vessel heads would be replaced before the license renewal
14 term. Exelon estimates that each vessel head replacement would require a one-time increase
15 of 340 outage workers for 1 week. If the vessel heads were replaced simultaneously, the
16 number of outage workers would remain at 340, but an additional week of work would be
17 necessary (Exelon 2013a). These additional workers would create a short-term increase in the
18 demand for temporary (rental) housing, an increased use of public water and sewer services,
19 and transportation impacts on access roads in the immediate vicinity of Byron. Given the short
20 amount of time needed to replace the vessel head and the additional number of workers and
21 truck deliveries needed to support this one-time replacement of the vessel head, vessel head
22 replacement could have a temporary cumulative effect on socioeconomic conditions in the
23 vicinity of the nuclear plant. However, since the number of nonoutage workers at Byron would
24 not change after reactor vessel head replacement, there would be no long-term cumulative
25 socioeconomic impacts in the region.

26 *4.16.7.3 Conclusion*

27 When combined with other past, present, and reasonably foreseeable future activities, there will
28 be no additional contributory effect on socioeconomic conditions from the continued operation of
29 Byron during the license renewal period beyond what is currently being experienced. Increases
30 in the Byron workforce during SG and vessel head replacement would be temporary and have
31 no long-term socioeconomic impact to the region. Therefore, the NRC staff concludes that the
32 cumulative socioeconomic impact would be SMALL in the immediate vicinity of Byron.

33 **4.16.8 Human Health**

34 The NRC and EPA established radiological dose limits for protection of the public and workers
35 from both acute and long-term exposure to radiation and radioactive materials. These dose
36 limits are codified in 10 CFR Part 20 and 40 CFR Part 190. As discussed in Section 4.11.1, the
37 NRC staff concluded impacts to human health from continued plant operations are SMALL. For
38 the purposes of this analysis, the geographical area considered is the area included within an
39 80-km (50-mi) radius of the Byron plant site. There are no other nuclear power plants within the
40 applicable geographical area; however, Byron's 80-km (50-mi) radius does overlap with the
41 80-km (50-mi) radii of several nuclear power plants in the area: Quad Cities Nuclear Power
42 Station, Clinton Power Station, Braidwood Station, LaSalle County Station, and Dresden
43 Nuclear Power Station. In addition to storing its spent nuclear fuel in a storage pool, Byron also
44 stores some of its spent nuclear fuel in an onsite independent spent fuel storage installation
45 (ISFSI) (Exelon 2013a).

46 EPA regulations in 40 CFR Part 190 limit the dose to members of the public from all sources in
47 the nuclear fuel cycle, including nuclear power plants, fuel fabrication facilities, waste disposal

1 facilities, and transportation of fuel and waste. As discussed in Section 3.1.4.5, Byron has
2 conducted a REMP since 1985. This program measures radiation and radioactive materials in
3 the environment from Byron, its ISFSI, and all other sources. The NRC staff reviewed the
4 radiological environmental monitoring results for the 5-year period from 2008 to 2012 as part of
5 the cumulative impacts assessment. The NRC staff's review of Exelon's data showed no
6 indication of an adverse trend in radioactivity levels in the environment from Byron or its ISFSI.
7 The data showed that there was no measurable impact to the environment from the operations
8 at Byron.

9 In addition, as discussed in Section 2.1.2 of this SEIS, Exelon stated in its ER that the reactor
10 vessel heads for Units 1 and 2 would be replaced before the license renewal term. In addition,
11 Exelon may replace the Byron Unit 2 SGs during the license renewal term. The staff expects
12 the dose to a member of the public and to plant workers from these projects would continue to
13 be a small fraction of the dose limits and standards specified in 10 CFR Part 20, 10 CFR
14 Part 50, Appendix I, and 40 CFR Part 190. The NRC and the State of Illinois will regulate any
15 future development or actions in the vicinity of the Byron site that could contribute to cumulative
16 radiological impacts.

17 The NRC staff concludes that the cumulative radiological impacts of the proposed license
18 renewal, when combined with other past, present, and reasonably foreseeable future activities,
19 would be SMALL. This is based on the NRC staff's review of REMP data, radioactive effluent
20 release data, Byron's expected continued compliance with Federal radiation protection
21 standards during continued operation and SG replacement, and regulation of any future
22 development or actions in the vicinity of the Byron site by the NRC and the State of Illinois.

23 **4.16.9 Environmental Justice**

24 The environmental justice cumulative impact analysis assesses the potential for
25 disproportionately high and adverse human health and environmental effects on minority and
26 low-income populations that could result from past, present, and reasonably foreseeable future
27 actions, including Byron operations during the renewal term. Adverse health effects are
28 measured in terms of the risk and rate of fatal or nonfatal adverse impacts on human health.
29 Disproportionately high and adverse human health effects occur when the risk or rate of
30 exposure to an environmental hazard for a minority or low-income population is significant and
31 exceeds the risk or exposure rate for the general population or for another appropriate
32 comparison group. Disproportionately high environmental effects refer to impacts or risks of
33 impacts on the natural or physical environment in a minority or low-income community that are
34 significant and appreciably exceed the environmental impact on the larger community. Such
35 effects may include biological, cultural, economic, or social impacts. Some of these potential
36 effects have been identified in resource areas presented in preceding sections of this SEIS.
37 Minority and low-income populations are part of the general public residing in the area and all
38 would be exposed to the same hazards generated from Byron operations. As previously
39 discussed in this chapter, the impact from license renewal for all resource areas (e.g., land, air,
40 water, ecology, and human health) would be SMALL.

41 As discussed in Section 4.12 of this SEIS, there would be no disproportionately high and
42 adverse impacts on minority and low-income populations from the continued operation of Byron
43 during the license renewal term. Because Exelon has no plans to hire additional workers during
44 the license renewal term, employment levels at Byron would remain relatively constant, and
45 there would be no additional demand for housing or increased traffic. Based on this information
46 and the analysis of human health and environmental impacts presented in the preceding
47 sections, it is not likely there would be any disproportionately high and adverse contributory
48 effect on minority and low-income populations from the continued operation of Byron during the

Environmental Consequences and Mitigating Actions

1 license renewal term. Therefore, the only contributory effects would come from the other
2 reasonably foreseeable future planned activities at Byron, unrelated to the proposed action
3 (license renewal), and other reasonably foreseeable planned offsite activities.

4 *4.16.9.1 Unit 2 Steam Generator Replacement*

5 Potential impacts to minority and low-income populations would mostly consist of environmental
6 and socioeconomic effects (e.g., traffic, employment, and housing impacts). Noise and dust
7 impacts from power plant modifications would be temporary and limited to onsite activities.
8 Minority and low-income populations residing along site access roads could experience
9 increased commuter vehicle traffic during shift changes. Increased demand for inexpensive
10 rental housing during SG-related power plant modifications could disproportionately affect
11 low-income populations; however, due to the short duration of the work and the availability of
12 housing, impacts to minority and low-income populations would be of short duration and limited.
13 Radiation doses from plant operations after power plant modifications are not expected to
14 change and will remain within regulatory limits.

15 Based on this information and the analysis of human health and environmental impacts
16 presented in this section of the SEIS, Unit 2 SG replacement would not have disproportionately
17 high and adverse human health and environmental effects on minority and low-income
18 populations residing in the vicinity of Byron.

19 *4.16.9.2 Units 1 and 2 Reactor Pressure Vessel Head Replacement*

20 Similar to SG replacement, potential impacts to minority and low-income populations from
21 reactor pressure vessel head replacement would mostly consist of environmental and
22 socioeconomic effects (e.g., traffic, employment, and housing impacts). Noise and dust impacts
23 from power plant modifications would be temporary and limited to onsite activities. Minority and
24 low-income populations residing along site access roads could experience increased commuter
25 vehicle traffic during shift changes. Increased demand for inexpensive rental housing during
26 SG-related power plant modifications could disproportionately affect low-income populations;
27 however, due to the short duration of the work and the availability of housing, impacts to
28 minority and low-income populations would be of short duration and limited. Radiation doses
29 from plant operations after power plant modifications are not expected to change and will
30 remain within regulatory limits.

31 Based on this information and the analysis of human health and environmental impacts
32 presented in this section of the SEIS, Units 1 and 2 reactor pressure vessel head replacement
33 would not have disproportionately high and adverse human health and environmental effects on
34 minority and low-income populations residing in the vicinity of Byron.

35 *4.16.9.3 Conclusion*

36 The NRC staff concludes that the contributory effects of this action, when combined with other
37 past, present, and reasonably foreseeable future activities considered, would not cause any
38 disproportionately high and adverse human health and environmental effects on minority and
39 low-income populations residing in the vicinity of Byron.

40 **4.16.10 Waste Management and Pollution Prevention**

41 This section describes waste management impacts during the license renewal term when added
42 to the aggregate effects of other past, present, and reasonably foreseeable future actions. For
43 the purpose of this cumulative impacts analysis, the area within a 50-mi (80-km) radius of Byron
44 was considered. The NRC staff concluded, in Section 4.11, that the potential human health
45 impacts from Byron's waste during the license renewal term would be SMALL.

1 As discussed in Sections 3.1.4 and 3.1.5, Exelon maintains waste management programs for
2 radioactive and nonradioactive waste generated at Byron and is required to comply with Federal
3 and State permits and other regulatory requirements for the management of waste material.
4 Current waste management activities at Byron would likely remain unchanged during the license
5 renewal term, and continued compliance with Federal and State requirements for radioactive
6 and nonradioactive waste is expected.

7 Byron is adjacent to the Byron Salvage Yard Superfund Site. This salvage yard was used as a
8 dumping ground for a variety of nonradioactive waste and debris. As discussed in
9 Section 3.2.1, all soil and groundwater remedial actions are now completed and groundwater
10 monitoring plans remain in place (EPA 2008).

11 Based on the above, the NRC staff concludes that the potential cumulative impacts from
12 radioactive and nonradioactive waste during the license renewal term would be SMALL.
13 Continued compliance with Federal and State requirements for radioactive and nonradioactive
14 waste management by Exelon is expected, and the Byron Salvage Yard Superfund Site
15 remediation actions are complete and noncontributory.

16 **4.16.11 Global Climate Change**

17 This section addresses the impact of GHG emissions resulting from continued operation of
18 Byron Station on global climate change when added to the aggregate effects of other past,
19 present, and reasonably foreseeable future actions. The impacts of climate change on air,
20 water, and ecological resources are discussed in Section 4.15.3. Climate is influenced by both
21 natural and human-induced factors; the observed global warming (increase in Earth's surface
22 temperature) in the 21st century has been attributed to the increase in GHG emissions resulting
23 from human activities (Karl et al. 2009). Climate model projections indicate that future climate
24 change is dependent on current and future GHG emissions (Karl et al. 2009; Pachauri and
25 Reisinger 2007). As described in Section 4.15.3.1, operations at Byron Station emit GHG
26 emissions directly and indirectly. Therefore, it is recognized that GHG emissions from
27 continued Byron Station operation may contribute to climate change.

28 The cumulative impact of a GHG emission source on climate is global. GHG emissions are
29 transported by wind and become well-mixed in the atmosphere as a result of their long
30 atmospheric lifetime. Therefore, the extent and nature of climate change is not specific to
31 where GHGs are emitted. In April 2013, EPA published the official U.S. inventory of GHG
32 emissions, which identifies and quantifies the primary anthropogenic sources and sinks of
33 GHGs. The EPA GHG inventory is an essential tool for addressing climate change and
34 participating with the United Nations Framework Convention on Climate Change to compare the
35 relative global contribution of different emission sources and GHGs to climate change. In 2011,
36 the United States emitted 6,702 teragrams (Tg) of carbon dioxide equivalents (CO₂e)
37 (6,702 million metric tons (MMT)), and since 1990 emissions increased at an average annual
38 rate of 0.4 percent (EPA 2013c). In 2010 and 2011, the total amount of CO₂e emissions related
39 to electricity generation was 2,303 Tg (2,303 MMT) and 2,201 Tg (2,201 MMT), respectively
40 (EPA 2013c). The EIA reported that, in 2010, electricity production alone in Illinois was
41 responsible for 94 MMT CO₂e (EIA 2013). Facilities that emit 25,000 MT (28,000 t) CO₂e or
42 more per year are required to annually report their GHG emissions to EPA. These facilities are
43 known as direct emitters and the data is publicly available in EPA's facility-level information on
44 GHGs tool (FLIGHT). In 2012, FLIGHT identified four facilities in Ogle County, Illinois, where
45 the Byron Station is located, that emitted a total of 0.33 MT (0.36 t) CO₂e (EPA 2013c). In 2012,
46 FLIGHT identified 291 facilities in Illinois that emitted a total of 130.3 MMT (130.3 Tg) CO₂e
47 (EPA 2013c).

Environmental Consequences and Mitigating Actions

1 Appendix E provides a list of present and reasonable foreseeable projects that could contribute
 2 to GHG emissions. Permitting and licensing requirements and other mitigative measures can
 3 minimize the impacts of GHG emissions. For instance, in 2012 EPA issued a final GHG
 4 Tailoring Rule to address GHG emissions from stationary sources under the CAA permitting
 5 requirements; the GHG Tailoring Rule establishes when an emission source will be subject to
 6 permitting requirements and control technology to reduce GHG emissions. On June 25, 2013,
 7 President Obama set forward a plan to reduce carbon pollution. The Climate Action Plan will
 8 reduce carbon pollution, prepare the United States for the impacts of climate change, and lead
 9 international efforts to combat global climate change. Future actions and steps taken to reduce
 10 GHG emissions will lessen the impacts on climate change.

11 EPA's U.S. inventory of GHG emissions illustrates the diversity of GHG sources emitters, such
 12 as electricity generation, industrial processes, and agriculture. Direct GHG emissions resulting
 13 from operations at Byron Station range from 941 to 1,503 MT (1,040 to 1,657 t) CO₂e
 14 (Table 4–23) and total emissions range from 10,872 to 13,962 MT (11,984 to 15,390 t) CO₂e. In
 15 comparing Byron Station's GHG emission contribution to different emissions sources, whether it
 16 be total U.S. GHG emissions, emissions from electricity production in Illinois, or emissions on a
 17 county level, GHG emissions from Byron Station are minor relative to these inventories; this is
 18 evident as presented in Table 4–23. The emissions impact of a single source on climate
 19 change requires that a climate model account for that specific source emission to project the
 20 magnitude and extent of climate change. Climate models indicate that short-term climate
 21 change (through the year 2030) is dependent on past GHG emissions. Therefore, climate
 22 change is projected to occur with or without present and future GHG emissions from Byron
 23 Station. The NRC staff concludes that the impact from the contribution of GHG emissions from
 24 continued operation of Byron Station on climate change would be SMALL. As discussed in
 25 Section 4.15.3.2, climate change and climate-related changes have been observed on a global
 26 level and climate models indicate that future climate change will depend on current and future
 27 GHG emissions. Climate models project that Earth's average surface temperature will continue
 28 to increase and climate-related changes will persist. Therefore, the cumulative impact of GHG
 29 emissions on climate change is noticeable but not destabilizing. The NRC staff concludes that
 30 the cumulative impacts from the proposed license renewal and other past, present, and
 31 reasonably foreseeable projects would be MODERATE.

32 **Table 4–23. Comparison of GHG Emission Inventories**

Source	CO ₂ e MMT/year
Global Fossil Fuel Combustion Emissions (2011) ⁽¹⁾	31,800
U.S. Emissions (2011) ⁽²⁾	6,702
Illinois (2012) ⁽³⁾	130.3
Ogle County, Illinois (2012) ⁽³⁾	0.33
Byron Station Emissions (2008–2012) ⁽⁴⁾	0.010–0.013

⁽¹⁾ Source: IEA 2012

⁽²⁾ Source: EPA 2013b

⁽³⁾ GHG emissions account only for direct emitters, those facilities that emit 25,000 MT or more a year (EPA 2013c).

⁽⁴⁾ Emissions include direct and indirect emissions from operation of Byron (Exelon 2013b).

Sources: EPA 2013b, 2013c; Exelon 2013b; IEA 2012

1 **4.16.12 Summary of Cumulative Impacts**

2 The NRC staff considered the potential impacts resulting from the operation of Byron during the
3 period of extended operation and other past, present, and reasonably foreseeable future actions
4 near Byron. The preliminary determination is that the potential cumulative impacts would range
5 from SMALL to MODERATE, depending on the resource. Table 4-24 summarizes the
6 cumulative impacts on resources areas.

1

Table 4–24. Summary of Cumulative Impacts on Resource Areas

Resource Area	Cumulative Impact
Air Quality and Noise	<p>Past, present, and reasonably foreseeable future activities exist in the geographic areas of interest (local for noise; local and regional for criteria pollutants) that could affect air quality and noise resources. However, the incremental contribution of impacts on air quality and noise resources from plant operations at Byron Station would be minimal. The NRC staff concludes that cumulative impacts from other past, present, and reasonably foreseeable future actions on air quality and noise resources in the geographic areas of interest would be SMALL.</p>
Geology and Soils	<p>Any use of geologic materials, such as aggregates to support operation and maintenance activities, would be procured from local and regional sources. These materials are abundant in the region, and geologic conditions are not expected to change during the license renewal term. Thus, activities associated with continued operations are not expected to affect the geologic environment. Considering ongoing activities and reasonably foreseeable actions, the NRC staff concludes that the cumulative impacts on geology and soils during the Byron license renewal term would be SMALL.</p>
Water Resources	<p>Considering ongoing activities and reasonably foreseeable actions, the NRC staff concludes that cumulative impact of the proposed license renewal, combined with other past, present, and reasonably foreseeable future activities, would be SMALL on surface water and groundwater use and quality. The Byron facility has not impacted and is not reasonably expected to impact the quality of groundwater in any aquifers that are a current or potential future source of water for offsite users, and groundwater supply is abundant enough to meet reasonably foreseeable demand. Consumptive surface water use from continued Byron operations will continue to be a very small percentage of the overall flow of the Rock River, and ongoing and future surface water demands by users are expected to be supported. Surface water discharges to the Rock River by Byron and other industrial users will be monitored and kept at acceptable limits via NPDES permits.</p>
Terrestrial Ecology	<p>Section 4.6 of this SEIS concludes that the impact from the proposed license renewal would not noticeably alter the terrestrial environment and would be SMALL. However, as environmental stressors such as agricultural runoff and residential development continue over the proposed license renewal term, certain attributes of the terrestrial environment (such as species diversity and distribution) are likely to noticeably change. The NRC staff does not expect these impacts to destabilize any important attributes of the terrestrial environment, but instead cause gradual change, which would allow the terrestrial environment to adapt appropriately. The NRC staff concludes that the cumulative impacts of the proposed license renewal of Byron, and other past, present, and reasonably foreseeable future projects or actions, would result in MODERATE impacts to terrestrial resources.</p>
Aquatic Ecology	<p>NRC staff concludes that the cumulative impacts on aquatic resources in the Rock River are MODERATE based on past, present, and reasonably foreseeable future actions. This level of impact is primarily the result of past river channelization and damming and ongoing runoff and sedimentation from agriculture. The environmental effects of these actions are clearly noticeable, but available information on the status of the Rock River aquatic communities does not indicate that these effects have destabilized any important attribute of the community in the vicinity of Byron. The incremental, site-specific impact from the continued operation of Byron during the license renewal period would be minor and not noticeable in comparison to cumulative impact on the aquatic ecology.</p>

Resource Area	Cumulative Impact
Historical and Cultural Resources	As described in Section 4.9, no cultural resources would be adversely affected by Byron license renewal activities as no associated changes or ground-disturbing activities will occur. Exelon has established draft procedures to ensure cultural resources are considered in project planning during normal operation of Byron. Therefore, the NRC staff concludes that the cumulative impact of the proposed license renewal when combined with other past, present, and reasonable foreseeable future activities on historic and cultural resources would be SMALL.
Socioeconomics	When combined with other past, present, and reasonably foreseeable future activities, there will be no additional contributory effect on socioeconomic conditions from the continued operation of Byron during the license renewal period beyond what is currently being experienced. Increases in the Byron workforce during SG and vessel head replacement would be temporary and have no long-term socioeconomic impact to the region. Therefore, the NRC staff concludes that the cumulative socioeconomic impact would be SMALL in the immediate vicinity of Byron.
Human Health	The NRC staff concludes that the cumulative radiological impacts of the proposed license renewal, when combined with other past, present, and reasonably foreseeable future activities, would be SMALL.
Environmental Justice	The NRC staff concludes that the contributory effects of this action, when combined with other past, present, and reasonably foreseeable future activities considered, would not cause any disproportionately high and adverse human health and environmental effects on minority and low-income populations residing in the vicinity of Byron.
Waste Management	NRC staff concludes that the potential cumulative impacts from radioactive and nonradioactive waste during the license renewal term would be SMALL. Continued compliance with Federal and State requirements for radioactive and nonradioactive waste management by Exelon is expected, and the Byron Salvage Yard Superfund Site remediation actions are complete and noncontributory.
Global Climate Change	As discussed in Section 4.15.3.2, climate change and climate-related changes have been observed on a global level, and climate models indicate that future climate change will depend on present and future GHG emissions. Climate models project that Earth's average surface temperature will continue to increase and climate-related changes will persist. Therefore, the cumulative impact of GHG emissions on climate change is noticeable but not destabilizing. The NRC staff concludes that the cumulative impacts from the proposed license renewal and other past, present, and reasonably foreseeable projects would be MODERATE.

1 **4.17 Resource Commitments Associated With the Proposed Action**

2 **4.17.1 Unavoidable Adverse Environmental Impacts**

3 Unavoidable adverse environmental impacts are impacts that would occur after implementation
4 of all workable mitigation measures. Carrying out any of the energy alternatives considered in
5 this SEIS, including the proposed action, would result in some unavoidable adverse
6 environmental impacts.

7 Minor unavoidable adverse impacts on air quality would occur due to emission and release of
8 various chemical and radiological constituents from power plant operations. Nonradiological
9 emissions resulting from power plant operations are expected to comply with EPA emissions
10 standards, although the alternative of operating a fossil-fueled power plant in some areas may

Environmental Consequences and Mitigating Actions

1 worsen existing attainment issues. Chemical and radiological emissions would not exceed the
2 National Emission Standards for Hazardous Air Pollutants.

3 During nuclear power plant operations, workers and members of the public would face
4 unavoidable exposure to radiation and hazardous and toxic chemicals. Workers would be
5 exposed to radiation and chemicals associated with routine plant operations and the handling of
6 nuclear fuel and waste material. Workers would have higher levels of exposure than members
7 of the public, but doses would be administratively controlled and would not exceed standards or
8 administrative control limits. In comparison, the alternatives involving the construction and
9 operation of a nonnuclear power generating facility would also result in unavoidable exposure to
10 hazardous and toxic chemicals to workers and the public.

11 The generation of spent nuclear fuel and waste material, including low-level radioactive waste,
12 hazardous waste, and nonhazardous waste, would also be unavoidable. In comparison,
13 hazardous and nonhazardous wastes would also be generated at nonnuclear power generating
14 facilities. Wastes generated during plant operations would be collected, stored, and shipped for
15 suitable treatment, recycling, or disposal in accordance with applicable Federal and State
16 regulations. Because of the costs of handling these materials, power plant operators would be
17 expected to carry out all activities and optimize all operations in a way that generates the
18 smallest amount of waste possible.

19 **4.17.2 Relationship Between Short-Term Use of the Environment and Long-Term** 20 **Productivity**

21 The operation of power generating facilities would result in short-term uses of the environment,
22 as described in this chapter. "Short term" is the period of time that continued power generating
23 activities take place.

24 Power plant operations require short-term use of the environment and commitment of
25 resources, as well as commitment of certain resources (e.g., land and energy) indefinitely or
26 permanently. Certain short-term resource commitments are substantially greater under most
27 energy alternatives, including license renewal, than under the no-action alternative because of
28 the continued generation of electrical power and the continued use of generating sites and
29 associated infrastructure. During operations, all energy alternatives require similar relationships
30 between local short-term uses of the environment and the maintenance and enhancement of
31 long-term productivity.

32 Air emissions from power plant operations introduce small amounts of radiological and
33 nonradiological constituents to the region around the plant site. Over time, these emissions
34 would result in increased concentrations and exposure, but they are not expected to impact air
35 quality or radiation exposure to the extent that public health and long-term productivity of the
36 environment would be impaired.

37 Continued employment, expenditures, and tax revenues generated during power plant
38 operations directly benefit local, regional, and State economies over the short term. Local
39 governments investing project-generated tax revenues into infrastructure and other required
40 services could enhance economic productivity over the long term.

41 The management and disposal of spent nuclear fuel, low-level radioactive waste, hazardous
42 waste, and nonhazardous waste require an increase in energy and consume space at
43 treatment, storage, or disposal facilities. Regardless of the location, the use of land to meet
44 waste disposal needs would reduce the long-term productivity of the land.

1 Power plant facilities are committed to electricity production over the short term. After
2 decommissioning these facilities and restoring the area, the land could be available for other
3 future productive uses.

4 **4.17.3 Irreversible and Irretrievable Commitment of Resources**

5 This section describes the irreversible and irretrievable commitment of resources that have
6 been noted in this SEIS. Resources are irreversible when primary or secondary impacts limit
7 the future options for a resource. An irretrievable commitment refers to the use or consumption
8 of resources that are neither renewable nor recoverable for future use. Irreversible and
9 irretrievable commitment of resources for electrical power generation include the commitment of
10 land, water, energy, raw materials, and other natural and manmade resources required for
11 power plant operations. In general, the commitment of capital, energy, labor, and material
12 resources are also irreversible.

13 The implementation of any of the energy alternatives considered in this SEIS would entail the
14 irreversible and irretrievable commitment of energy, water, chemicals, and in some cases, fossil
15 fuels. These resources would be committed during the license renewal term and over the entire
16 life cycle of the power plant, and they would be unrecoverable.

17 Energy expended would be in the form of fuel for equipment, vehicles, and power plant
18 operations and electricity for equipment and facility operations. Electricity and fuel would be
19 purchased from offsite commercial sources. Water would be obtained from existing water
20 supply systems. These resources are readily available, and the amounts required are not
21 expected to deplete available supplies or exceed available system capacities.

22 **4.18 References**

23 10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, "Standards for
24 protection against radiation."

25 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic licensing of
26 production and utilization facilities."

27 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental
28 protection regulations for domestic licensing and related regulatory functions."

29 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for
30 renewal of operating licenses for nuclear power plants."

31 10 CFR Part 100. *Code of Federal Regulations*, Title 10, *Energy*, Part 100, "Reactor site
32 criteria."

33 36 CFR Part 60. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,
34 Part 60, "National register of historic places."

35 36 CFR Part 800. *Code of Federal Regulations*. Title 36, *Parks, Forests, and Public Property*,
36 Part 800, "Protection of historic properties."

37 40 CFR Part 51. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 51,
38 "Requirements for preparation, adoption, and submittal of implementation plans."

39 40 CFR Part 60. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 60,
40 "Standards of performance for new stationary sources."

41 40 CFR Part 63. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 63,
42 "National emission standards for hazardous air pollutants for source categories."

Environmental Consequences and Mitigating Actions

- 1 40 CFR Part 75. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 75,
2 “Continuous emission monitoring.”
- 3 40 CFR Part 81. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 81,
4 “Designation of areas for air quality planning purposes.”
- 5 40 CFR Part 93. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 93,
6 “Determining conformity of Federal actions to state or Federal implementation plans.”
- 7 40 CFR Part 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190,
8 “Environmental radiation protection standards for nuclear power operations.”
- 9 50 CFR Part 402. *Code of Federal Regulations*, Title 50, *Wildlife and Fisheries*, Part 402,
10 “Interagency cooperation—Endangered Species Act of 1973, as amended.”
- 11 49 FR 34658. U.S. Nuclear Regulatory Commission. “Waste confidence decision and
12 requirements for licensee actions regarding the disposition of spent fuel upon expiration of
13 reactor operating licenses; Final Rules.” *Federal Register* 49 (171):34658:34696.
14 August 31, 1984.
- 15 55 FR 38472. U.S. Nuclear Regulatory Commission. “Consideration of environmental impacts of
16 temporary storage of spent fuel after cessation of Reactor operation; and waste confidence
17 decision review; Final Rules.” *Federal Register* 55 (181):38472:38514. September 18, 1990.
- 18 59 FR 7629. Executive Order No. 12898. “Federal actions to address environmental justice in
19 minority populations and low-income populations.” *Federal Register* 59(32):7629–7634.
20 February 16, 1994.
- 21 61 FR 28467. U.S. Nuclear Regulatory Commission. “Environmental review for renewal of
22 nuclear power plant operating licenses.” Final Rule. *Federal Register* 61 (109):28467–28497.
23 June 5, 1996.
- 24 61 FR 66537. U.S. Nuclear Regulatory Commission. “Environmental review for renewal of
25 nuclear power plant operating licenses.” *Federal Register* 61 (244):66537–66544.
26 December 18, 1996.
- 27 64 FR 68005. U.S. Nuclear Regulatory Commission. “Waste confidence decision review:
28 status.” *Federal Register* 64(233): 68005–68007. December 6, 1999.
- 29 65 FR 79825. U.S. Environmental Protection Agency. “Regulatory finding on the emissions of
30 hazardous air pollutants from electric utility steam generating units.” *Federal*
31 *Register* 65(245):79825–79831. December 20, 2000.
- 32 74 FR 38117. U.S. Nuclear Regulatory Commission. “Revisions to environmental review for
33 renewal of nuclear power plant operating licenses.” Proposed Rule. *Federal Register*
34 74 (146):38117–38140. July 31, 2009.
- 35 75 FR 81032. U.S. Nuclear Regulatory Commission. “Consideration of environmental impacts of
36 temporary storage of spent fuel after cessation of reactor operation.” *Federal*
37 *Register* 75(246):81032–81037. December 23, 2010.
- 38 75 FR 81037. U.S. Nuclear Regulatory Commission. “Waste confidence decision update.”
39 *Federal Register* 75(246):81037–81076. December 23, 2010.
- 40 79 FR 56238. U.S. Nuclear Regulatory Commission. “Continued storage of spent nuclear fuel.”
41 *Federal Register* 79 (182):56238–56263. September 19, 2014.

- 1 79 FR 56263. U.S. Nuclear Regulatory Commission. “Generic environmental impact statement
2 for continued storage of spent nuclear fuel.” *Federal Register* 79 (182):56263–56264.
3 September 19, 2014.
- 4 78 FR 37282. U.S. Nuclear Regulatory Commission. “Revisions to environmental review for
5 renewal of nuclear power plant operating licenses.” *Federal Register* 78(119): 37282-37324.
6 June 20, 2013.
- 7 79 FR 1430. U.S. Environmental Protection Agency. “Standards of performance for greenhouse
8 gas emissions from new stationary sources: electric utility generating units.” *Federal*
9 *Register* 79(5):1430–1519. January 8, 2014.
- 10 35 IAC 254. *Illinois Administrative Code*, Title 35, *Environmental Protection*, Part 254, “Annual
11 Emissions Report.”
- 12 35 IAC 302. *Illinois Administrative Code*, Title 35, *Environmental Protection*, Part 302, “Water
13 Quality Standards.”
- 14 [CAA] Clean Air Act: Acid Deposition Control. 42 U.S.C. § 7651 et seq.
- 15 Cada GF. 1991. *Effects of Hydroelectric Turbine Passage on Fish Early Life Stages*. Oak Ridge,
16 TN: Oak Ridge National Laboratory. CONF-910778-2. June 7, 1991. 11 p. Agencywide
17 Documents Access and Management System (ADAMS) No. ML12146A356.
- 18 [CDC] Center for Disease Control and Prevention. 2013. “Pathogen & Environment—*Naegleria*
19 *fowleri*.” November 14, 2013. Available at
20 <<http://www.cdc.gov/parasites/naegleria/pathogen.html>> (accessed 3 January 2014).
- 21 [CEQ] Council on Environmental Quality. 1997. *Considering Cumulative Effects Under the*
22 *National Environmental Policy Act*. Washington, DC: CEQ. January 1997. 122 p. Available at
23 <[http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/](http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/G-CEQ-ConsidCumulEffects.pdf)
24 [G-CEQ-ConsidCumulEffects.pdf](http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/G-CEQ-ConsidCumulEffects.pdf)> (accessed 27 January 2014).
- 25 Chen IC, Hill JK, Ohlemüller R, Roy DB, Thomas CD. 2011. Rapid range shifts of species
26 associated with high levels of climate warming. *Science* 333(6045):1024–1026. Available at
27 DOI: 10.1126/science.1206432.
- 28 [ComEd] Commonwealth Edison Company. 1994. *Byron Nuclear Generating Station Units 1*
29 *and 2 Individual Plant Examination Submittal Report*. April 1994.
- 30 [ComEd] Commonwealth Edison Company. 1996. *Individual Plant Examination of External*
31 *Events for Severe Accident Vulnerabilities Submittal Report, Byron Nuclear Generating Station*
32 *Units 1 and 2*. December 1996.
- 33 [ComEd] Commonwealth Edison Company. 1997. *Byron Nuclear Generating Station, Units 1*
34 *and 2 Response to NRC Request for Additional Information and Modified Individual Plant*
35 *Examination*. March 1997.
- 36 Consolidated Appropriations Act, 2008. Pub L. No. 110-161, 121 Stat. 1844.
37 December 26, 2007.
- 38 Dale VH. 1997. The relationship between land-use change and climate change.
39 *Ecological Applications* 7(3):753–769.
- 40 [D.C. Circuit 2012] *New York v. NRC (State of New York et al. v. U.S. Nuclear Regulatory*
41 *Commission)*. 681 F.3d 471 (D.C. Cir. 2012). ADAMS No. ML12191A407.

Environmental Consequences and Mitigating Actions

- 1 [DOE] U.S. Department of Energy. 2010a. *Kemper County Integrated Gasification*
2 *Combined-Cycle (IGCC) Project, Final Environmental Impact Statement (EIS)*. Pittsburgh, PA:
3 DOE. DOE/EIS-0409, Volume 1. May 2010. 671 p. Available at
4 [http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/](http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/EIS-0409-FEIS-01-2010.pdf)
5 [EIS-0409-FEIS-01-2010.pdf](http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/EIS-0409-FEIS-01-2010.pdf)> (accessed 7 February 2014).
- 6 [DOE] U.S. Department of Energy. 2010b. *Final Environmental Assessment for Department of*
7 *Energy Loan Guarantee for the Agua Caliente Solar Project in Yuma County, Arizona*.
8 Washington, DC: DOE. DOE/EA-1797. November 2010. 153 p. Available at
9 http://energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/EA-1797-FEA-2010.pdf>
10 (accessed 5 September 2014).
- 11 Dziegielewski B, Yang X, Bik T, Margono H, Richey M. 2005. *County-Level Forecasts of Water*
12 *Use in Illinois: 2005–2025: Project Completion Report*. Carbondale, IL: Southern Illinois
13 University Carbondale. March 30, 2005. 211 p. Available at
14 <http://www.idaillinois.org/cdm/ref/collection/edi/id/46504>> (accessed 5 September 2014).
- 15 [EIA] Energy Information Administration. 1999. *Natural Gas 1998: Issues and Trends*.
16 Washington, DC: EIA. DOE/EIA-0560(98). April 1999. 260 p. Available at
17 [http://www.eia.gov/pub/oil_gas/natural_gas/analysis_publications/](http://www.eia.gov/pub/oil_gas/natural_gas/analysis_publications/natural_gas_1998_issues_trends/pdf/it98.pdf)
18 [natural_gas_1998_issues_trends/pdf/it98.pdf](http://www.eia.gov/pub/oil_gas/natural_gas/analysis_publications/natural_gas_1998_issues_trends/pdf/it98.pdf)> (accessed 4 September 2014).
- 19 [EIA] Energy Information Administration. 2011. *International Energy Outlook 2011*. Washington,
20 DC: EIA. DOE/EIA-0484(2011). September 2011. 301 p. Available at
21 [http://www.eia.gov/forecasts/archive/ieo11/pdf/0484\(2011\).pdf](http://www.eia.gov/forecasts/archive/ieo11/pdf/0484(2011).pdf)> (accessed
22 20 September 2013).
- 23 [EIA] Energy Information Administration. 2013. *State-Level Energy-Related Carbon Dioxide*
24 *Emissions, 2000–2010*. May 2013. Available at
25 <http://www.eia.gov/pressroom/releases/press389.cfm>> (accessed 4 September 2014).
- 26 [EIA] Energy Information Administration. 2014. “FAQ—What is U.S. electricity generation by
27 energy source?” Available at <http://www.eia.gov/tools/faqs/faq.cfm?id=427&t=3>> (accessed
28 18 February 2014).
- 29 [EPA] U.S. Environmental Protection Agency. 1999a. *Alternative Disinfectants and Oxidants*
30 *Guidance Manual*. Washington, DC: EPA. 815-R-99-014. April 1999. 346 p. Available at
31 http://www.epa.gov/ogwdw/mdbp/alternative_disinfectants_guidance.pdf> (accessed
32 3 January 2014).
- 33 [EPA] U.S. Environmental Protection Agency. 1999b. *Consideration of Cumulative Impacts in*
34 *EPA Review of NEPA Documents*. Washington, DC: EPA. 315-R-99-002. 22 p. Available at
35 <http://www.epa.gov/Compliance/resources/policies/nepa/cumulative.pdf>> (accessed
36 5 February 2014).
- 37 [EPA] U.S. Environmental Protection Agency. 2000. *Compilation of Air Pollutant Emission*
38 *Factors, Volume 1: Stationary Point and Area Sources*. 5th ed. Chapter 3, Stationary internal
39 combustion sources, Section 3.1, Stationary gas turbines. p 3.1-1–3.1-20. Available at
40 <http://www.epa.gov/ttn/chief/ap42/ch03/final/c03s01.pdf>> (accessed 6 December 2013).
- 41 [EPA] U.S. Environmental Protection Agency. 2002. *National Water Quality Inventory: 2000*
42 *Report*. Washington, DC: EPA. EPA-841-R-02-001. August 2002. Available at
43 http://water.epa.gov/lawsregs/guidance/cwa/305b/2000report_index.cfm> (accessed
44 7 February 2014).

- 1 [EPA] U.S. Environmental Protection Agency. *Five-Year Review Report: Byron Salvage Yard*
2 *Superfund Site*. Available at
3 <http://www.epa.gov/region5/cleanup/byron/pdfs/byron_5yr_2004.pdf> (accessed
4 7 February 2014).
- 5 [EPA] U.S. Environmental Protection Agency. 2009a. *Assessment of the Impacts of Global*
6 *Change on Regional U.S. Air Quality: A Synthesis of Climate Change Impacts on Ground-Level*
7 *Ozone: An Interim Report of the U.S. EPAGlobal Change Research Program*. Washington, DC:
8 EPA. EPA/600/R-07/094F. April 2009. 131 p. Available at
9 <http://ofmpub.epa.gov/eims/eimscomm.getfile?p_download_id=491176> (accessed
10 6 December 2013).
- 11 [EPA] U.S. Environmental Protection Agency. 2009b. *Endangerment and Cause or Contribute*
12 *Finding for Greenhouse Gases under Section 202(a) of the Clean Air Act*. Available at
13 <<http://www.epa.gov/climatechange/endangerment/>> (accessed 6 December 2013).
- 14 [EPA] U.S. Environmental Protection Agency. 2012a. *Climate Change Indicators in the*
15 *United States, 2012*. Washington, DC: EPA. 430-R-12-004. December 2012. 84 p. Available at
16 <<http://www.epa.gov/climatechange/pdfs/climateindicators-full-2012.pdf>> (accessed
17 6 December 2013).
- 18 [EPA] U.S. Environmental Protection Agency. 2012b. "Greenhouse Gas Reporting Program
19 Home." October 30, 2012. Available at
20 <<http://www.epa.gov/climatechange/emissions/ghgrulemaking.html>> (accessed
21 6 November 2012).
- 22 [EPA] U.S. Environmental Protection Agency. 2013a. *EPA's Greenhouse Gas Emission*
23 *Reductions*. Available at <<http://www.epa.gov/greeningepa/ghg/index.htm>> (accessed
24 9 December 2013).
- 25 [EPA] U.S. Environmental Protection Agency. 2013b. *Inventory of U.S. Greenhouse Gas*
26 *Emissions and Sinks: 1990–2011*. Washington, DC: EPA. EPA 430-R-13-001. April 12, 2013.
27 505 p. Available at
28 <<http://www.epa.gov/climatechange/ghgemissions/usinventoryreport/archive.html>> (accessed
29 4 September 2014).
- 30 [EPA] U.S. Environmental Protection Agency. 2013c. "Greenhouse Gas Reporting Program
31 Home." Available at <<http://epa.gov/ghgreporting/index.html>> (accessed 6 December 2013).
- 32 [EPA] U.S. Environmental Protection Agency. 2013d. "New Source Review Basic Information on
33 PSD." Available at <<http://www.epa.gov/NSR/psd.html>> (accessed 4 September 2014).
- 34 [EPA] U.S. Environmental Protection Agency. 2014a. "Air & Radiation Home: Clean Air Markets:
35 Business: Programs and Regulations: Clean Air Interstate Rule (CAIR)." Available at
36 <<http://www.epa.gov/cair/>> (accessed 30 January 2014).
- 37 [EPA] U.S. Environmental Protection Agency. 2014b. Memorandum: Next Steps and
38 Preliminary Views on the Application of Clean Air Act Permitting Programs to Greenhouse
39 Gases Following the Supreme Court's Decisions in *Utility Air Regulatory Group v.*
40 *Environmental Protection Agency*. Available at
41 <<http://www.epa.gov/airprog/oar/oaqps/nsr/documents/20140724memo.pdf>> (accessed
42 5 September 2014).
- 43 [EPRI and NRC] Electric Power Research Institute and U.S. Nuclear Regulatory Commission.
44 2005. *EPRI/NRC-RES Fire PRA Methodology for Nuclear Power Facilities*. EPRI: Palo Alto, CA.
45 NUREG/CR-6850/EPRI TR-1011989, Volumes 1 and 2. September 23, 2005. 722 p. ADAMS
46 Nos. ML052580075 and ML052580118.

Environmental Consequences and Mitigating Actions

- 1 [ESA] Endangered Species Act of 1973, as amended. 16 U.S.C. § 1531 et seq.
- 2 [Exelon] Exelon Generation Company, LLC. 2004. Letter from K. Ainger, Manager—Licensing,
3 to Document Control Desk, U.S. Nuclear Regulatory Commission. Subject: Updated Final
4 Safety Analysis Report (UFSAR). December 16, 2004. ADAMS No. ML051660168.
- 5 [Exelon] Exelon Generation Company, LLC. 2009. *2008 Annual Emission Report*. Byron, IL:
6 Exelon. April 24, 2009. ADAMS No. ML14007A088.
- 7 [Exelon] Exelon Generation Company, LLC. 2010. *2009 Annual Emission Report*. Byron, IL:
8 Exelon. April 24, 2010. ADAMS No. ML14007A088.
- 9 [Exelon] Exelon Generation Company, LLC. 2011. *2010 Annual Emission Report*. Byron, IL:
10 Exelon. April 14, 2011. ADAMS No. ML14007A088.
- 11 [Exelon] Exelon Generation Company, LLC. 2012. *2011 Annual Emission Report*. Byron, IL:
12 Exelon. April 26, 2012. ADAMS No. ML14007A088.
- 13 [Exelon] Exelon Generation Company, LLC. 2013a. *Applicant's Environmental Report—*
14 *Operating License Renewal Stage, Byron Station*. Volume 3. May 29, 2013. 709 p. ADAMS
15 Nos. ML13155A422 and ML13155A423.
- 16 [Exelon] Exelon Generation Company, LLC. 2013b. Letter from M. Gallagher, Vice President –
17 License Renewal Projects, to Document Control Desk, U.S. Nuclear Regulatory Commission.
18 Subject: Response to NRC request for additional information, dated November 21, 2013, related
19 to the Byron and Braidwood Stations, Units 1 and 2, license renewal application, Byron Station
20 Applicant's Environmental Report. December 19, 2013. 2,454 p. ADAMS No. ML14007A078
21 (package).
- 22 [Exelon] Exelon Generation Company, LLC. 2013c. *2012 Annual Emission Report*. Byron, IL:
23 Exelon. February 21, 2013. ADAMS No. ML14007A088.
- 24 [Exelon] Exelon Generation Company, LLC. 2013d. Letter from M. Gallagher, Vice President—
25 License Renewal, to D. Culp, Deputy Director, Illinois Department of Public Health. Subject:
26 Exelon Generation, LLC – Byron Station Units 1 and 2 license renewal project, request for
27 information on thermophilic pathogens – Ogle County. January 23, 2013. ADAMS
28 No. ML13155A423.
- 29 [Exelon] Exelon Generation Company, LLC. 2014. Letter from M. Gallagher, Vice President—
30 License Renewal Projects, to Document Control Desk, U.S. Nuclear Regulatory Commission.
31 Subject: Response to NRC requests for additional information for the severe accident mitigation
32 alternatives review, dated January 6, 2014, related to the Braidwood Station, Units 1 and 2 and
33 Byron Station, Units 1 and 2 License Renewal Application. February 4, 2014. ADAMS
34 No. ML14035A512.
- 35 Fraser KC, Silverio C, Kramer P, Mickle N, Aeppli R, Stutchbury BJM. 2013. A
36 trans-hemispheric migratory songbird does not advance spring schedules or increase migration
37 rate in response to record-setting temperatures at breeding sites. PLoS ONE 8(5):e64587.
38 Available at <<http://www.ncbi.nlm.nih.gov/pmc/articles/PMC3669305/>> (accessed
39 5 September 2014).
- 40 [FWS] U.S. Fish and Wildlife Service. 2013a. E-mail from J. Duyvejonck to B. Grange,
41 U.S. Nuclear Regulatory Commission. Subject: Byron Illinois License Renewal.
42 August 30, 2013. ADAMS No. ML13246A385.[FWS] U.S. Fish and Wildlife Service. 2013b.
43 "Find Endangered Species." Search by County for Ogle County, Illinois. Available at
44 <[http://www.fws.gov/endangered/
45 ?s8fid=112761032793&s8fid=112762573903&countyName=ogle](http://www.fws.gov/endangered/?s8fid=112761032793&s8fid=112762573903&countyName=ogle)> (accessed 18 October 2013).

- 1 [FWS] U.S. Fish and Wildlife Service. 2014. *Guidance for Preparing a Biological Assessment*.
 2 6 p. Available at <<http://www.fws.gov/midwest/endangered/section7/pdf/BAGuidance.pdf>>
 3 (accessed 29 May 2014).
- 4 [FWS and NMFS] U.S. Fish and Wildlife Service and National Marine Fisheries Service. 1998.
 5 *Endangered Species Consultation Handbook: Procedures for Conducting Consultation and*
 6 *Conference Activities Under Section 7 of the Endangered Species Act*. March 1998. 315 p.
 7 Available at <http://www.fws.gov/endangered/esa-library/pdf/esa_section7_handbook.pdf>
 8 (accessed 27 May 2014).
- 9 [GE] General Electric. 2010. "How Loud is a Wind Turbine?" Available at
 10 <<http://www.gereports.com/how-loud-is-a-wind-turbine/>> (accessed 30 September 2013).
- 11 Hessler DM (Hessler Associates, Inc.). 2011. *Assessing Sound Emissions from Proposed Wind*
 12 *Farms & Measuring the Performance of Completed Projects*. Washington, DC: The National
 13 Association of Regulatory Utility Commissioners (NARUC). October 13, 2011. 69 p. Available at
 14 <[http://www.naruc.org/Grants/Documents/Final%20full%20MN%20SERCAT%20rep%20with%20](http://www.naruc.org/Grants/Documents/Final%20full%20MN%20SERCAT%20rep%20with%20NARUC%20cover%20Hessler.pdf)
 15 [NARUC%20cover%20Hessler.pdf](http://www.naruc.org/Grants/Documents/Final%20full%20MN%20SERCAT%20rep%20with%20NARUC%20cover%20Hessler.pdf)> (accessed 30 September 2013).
- 16 [IDNR] Illinois Department of Natural Resources. 1998a. Lower Rock River Area Assessment.
 17 Volume 2, Water resources. Champaign, IL: IDNR. 83 p. Available at
 18 <<http://hdl.handle.net/2142/13895>> (accessed 10 February 2014).
- 19 [IDNR] Illinois Department of Natural Resources. 1998b. *Lower Rock River Area Assessment*.
 20 Volume 3: Living resources. Champaign, IL: IDNR. 230 p. Available at
 21 <<http://hdl.handle.net/2142/13895>> (accessed 29 January 2014).
- 22 [IDNR] Illinois Department of Natural Resources. 2001. *Upper Rock River Area assessment*.
 23 Volume 2, Water resources. Springfield, IL: IDNR. Available at
 24 <<https://www.ideals.illinois.edu/bitstream/handle/2142/14426/upperrock2.pdf?sequence=3>>
 25 (accessed 5 September 2014).
- 26 [IDPH] Illinois Department of Public Health. 2013. Letter from K. McCann, Chief, Division of
 27 Environmental Health, to M. Gallagher, Vice President, License Renewal Exelon Nuclear.
 28 Subject: Response to request for information on thermophilic pathogens. March 3, 2013.
 29 ADAMS No. ML13155A423.
- 30 [IEA] International Energy Agency. 2012. "Global carbon-dioxide emissions increase by 1.0 Gt
 31 in 2011 to record high." May 24, 2012. Available at
 32 <<http://www.iea.org/newsroomandevents/news/2012/may/name.27216,en.html>> (accessed
 33 6 December 2013).
- 34 [IEPA] Illinois Environmental Protection Agency. 1996. "Rock River Watershed Fact Sheet."
 35 Available at
 36 <<http://www.epa.state.il.us/water/water-quality/report-1996/fact-sheets/fact-sheet-06.html>>
 37 (accessed 10 February 2014).
- 38 [IEPA] Illinois Environmental Protection Agency. 2006. Rock River Basin Assessment: An
 39 Overview of the Rock River Watershed in Illinois. March 2006. 400 p. Available at
 40 <<http://www.epa.state.il.us/water/watershed/facility-planning/rock-basin.pdf>> (accessed
 41 10 February 2014).
- 42 [IEPA] Illinois Environmental Protection Agency. 2011. NPDES Permit No. IL0048313 for Exelon
 43 Generation Company, LLC–Byron Station. In: *Byron Station Environmental Report, Appendix B*.
 44 July 15, 2011. ADAMS No. ML13155A423.

Environmental Consequences and Mitigating Actions

- 1 [IEPA] Illinois Environmental Protection Agency. 2013. *Draft Reissued NPDES Permit*
2 *No. IL0074209 for Nelson Energy Center*. Springfield, IL: IEPA. August 14, 2013. 14 p.
3 Available at <<http://www.epa.state.il.us/public-notices/2013/nelson-energy/index.pdf>> (accessed
4 29 January 2014).
- 5 [IHPA] Illinois Historic Preservation Agency. 2013. Letter from A. Haaker, Deputy State Historic
6 Preservation Officer, to C. Bladey, Chief, U.S. Nuclear Regulatory Commission. Subject: Will
7 County Braidwood License Renewal, Exelon Generation Company, LLC. September 4, 2013.
8 ADAMS No. ML13269A369.
- 9 [ISM] Illinois State Museum. 2014. "Illinois Inventory of Archaeological Sites." Ogle County.
10 Available at (permission needed) <<http://geoserver.dnr.illinois.gov/Arch/default.aspx>> (accessed
11 4 February 2014).
- 12 Karl TR, Peterson TC (NOAA National Climatic Data Center), Melillo JM (Marine Biological
13 Laboratory), editors. 2009. *Global Climate Change Impacts in the United States*. Cambridge:
14 Cambridge University Press. 196 p. Available at
15 <<http://downloads.globalchange.gov/usimpacts/pdfs/climate-impacts-report.pdf>> (accessed
16 10 April 2014).
- 17 Karstensen KA, Shaver DK, Alexander RL, Over TM, Soong D. 2013. *Land Change in the*
18 *Central Corn Belt Plains Ecoregion and Hydrologic Consequences in Developed Areas—*
19 *1939–2000*. Reston, VA: U.S. Geological Survey. Open-File Report 2013–1157. 32 p. Available
20 at <<http://pubs.usgs.gov/of/2013/1157/pdf/ofr2013-1157.pdf>> (accessed 7 February 2014).
- 21 Knapp HV, Russell AM. 2004. *Rock River Basin Streamflow Assessment Model, Illinois State*
22 *Water Survey*. Champaign, IL: Illinois Department of Natural Resources. Contract
23 Report 2004-02. February 2004. 182 p. Available at
24 <<http://www.isws.illinois.edu/pubdoc/CR/ISWSCR2004-02.pdf>> (accessed 4 February 2014).
- 25 Knauer H (Environmental Acoustics, Inc.), Pedersen S (Catseye Services). 2011. *Construction*
26 *Noise Handbook*. Washington, DC: Federal Highway Administration. Chapter 9.0 Construction
27 equipment noise levels and ranges. Available at
28 <http://www.fhwa.dot.gov/environment/noise/construction_noise/handbook/handbook09.cfm>
29 (accessed 10 April 2014)
- 30 Kunkel KE, Stevens LE, Stevens SE, Sun L (North Carolina State University and National
31 Climatic Data Center), Janssen E, Wuebbles D, Hilberg SD, Timlin MS, Stoecker L,
32 Westcott NE (University of Illinois at Urbana–Champaign), et al. 2013a. *Regional Climate*
33 *Trends and Scenarios for the U.S. National Climate Assessment, Part 3. Climate of the Midwest*
34 *U.S.* Washington, DC: National Oceanic and Atmospheric Administration (NOAA). NOAA
35 Technical Report NESDIS 142-3. January 2013. 103 p. Available at
36 <http://www.nesdis.noaa.gov/technical_reports/
37 [NOAA_NESDIS_Tech_Report_142-3-Climature_of_the_Midwest_U.S.pdf](http://www.nesdis.noaa.gov/technical_reports/NOAA_NESDIS_Tech_Report_142-3-Climature_of_the_Midwest_U.S.pdf)>.
- 38 Kunkel KE, Stevens LE, Stevens SE, Sun L (North Carolina State University and National
39 Climatic Data Center), Janssen E, Wuebbles D (University of Illinois at Urbana–Champaign),
40 Dobson JG (University of North Carolina at Asheville). 2013b. *Regional Climate Trends and*
41 *Scenarios for the U.S. National Climate Assessment, Part 9. Climate of the Contiguous*
42 *United States*. Washington, DC: National Oceanic and Atmospheric Administration (NOAA).
43 NOAA Technical Report NESDIS 142-9. January 2013. Available at
44 <http://www.nesdis.noaa.gov/technical_reports/
45 [NOAA_NESDIS_Tech_Report_142-9-Climature_of_the_Contiguous_United_States.pdf](http://www.nesdis.noaa.gov/technical_reports/NOAA_NESDIS_Tech_Report_142-9-Climature_of_the_Contiguous_United_States.pdf)>.

- 1 Melillo JM (Marine Biological Laboratory), Richmond TC (Van Ness Feldman GordonDerr,
2 L.L.P.), Yohe GW (Wesleyan University), editors. 2013. *Climate Change Impacts in the*
3 *United States, Draft for Public Comment*. U.S. Global Change Research Program.
4 January 2013. Available at <<http://ncadac.globalchange.gov/>> (accessed 29 January 2014).
- 5 Melillo JM (Marine Biological Laboratory), Richmond TC (Van Ness Feldman, LLP), Yohe GW
6 (Wesleyan University), editors. 2014. *Climate Change Impacts in the United States: The Third*
7 *National Climate Assessment*. Washington, DC: U.S. Global Change Research Program.
8 May 2014. 841 p. ADAMS No. ML14129A233.
- 9 [MSA] Magnuson–Stevens Fishery Conservation and Management Reauthorization Act of 2006,
10 as amended. 16 U.S.C. §§ 1801–1884.
- 11 [NAH] North American Hydro. 2014. *Rockton FERC Project # 2373*. 1 p. Available at
12 <[http://www.nahydro.com/sites/default/files/nahydro/documents/plants/](http://www.nahydro.com/sites/default/files/nahydro/documents/plants/RKTN%20Data%20Sheet.pdf)
13 [RKTN%20Data%20Sheet.pdf](http://www.nahydro.com/sites/default/files/nahydro/documents/plants/RKTN%20Data%20Sheet.pdf)> (accessed 29 January 2014).
- 14 [NCDC] National Climatic Data Center. 1984. *1983 Local Climatological Data Annual Summary*
15 *With Comparative Data, Rockford, Illinois*. National Oceanic and Atmospheric Administration,
16 Satellite and Information Service. Available at <<http://www7.ncdc.noaa.gov/IPS/lcd/lcd.html>>
17 (accessed 10 July 2013).
- 18 [NCDC] National Climatic Data Center. 2013. *2012 Local Climatological Data Annual Summary*
19 *With Comparative Data, Rockford, Illinois*. National Oceanic and Atmospheric Administration,
20 Satellite and Information Service. Available at <<http://www7.ncdc.noaa.gov/IPS/lcd/lcd.html>>
21 (accessed 10 July 2013).
- 22 [NEPA] National Environmental Policy Act of 1969, as amended. 42 U.S.C. §4321 et seq.
- 23 [NETL] National Energy Technology Laboratory. 2007. *Shell IGCC Plant*. Available at
24 <http://www.netl.doe.gov/KMD/cds/Disk50/IGCC%20Plant%20Case_Shell_051507.pdf>
25 (accessed 7 February 2014).
- 26 [RDS] Research and Development Solutions, LLC. 2013a. *Cost and Performance of PC and*
27 *IGCC Plants for a Range of Carbon Dioxide Capture*, Revision 1. DOE/NETL-2011/1498.
28 September. Available at
29 <[http://www.netl.doe.gov/File%20Library/Research/Energy%20Analysis/Coal/Gerdes-](http://www.netl.doe.gov/File%20Library/Research/Energy%20Analysis/Coal/Gerdes-08022011.pdf)
30 [08022011.pdf](http://www.netl.doe.gov/File%20Library/Research/Energy%20Analysis/Coal/Gerdes-08022011.pdf)> (accessed 31 January 2014).
- 31 [NETL] National Energy Technology Laboratory. 2013b. *Cost and Performance Baseline for*
32 *Fossil Energy Plants, Volume 1: Bituminous Coal and Natural Gas to Electricity*, Revision 2a.
33 DOE/NETL-2010/1397. September. Available at <[http://www.netl.doe.gov/energy-](http://www.netl.doe.gov/energy-analyses/pubs/BitBase_FinRep_Rev2.pdf)
34 [analyses/pubs/BitBase_FinRep_Rev2.pdf](http://www.netl.doe.gov/energy-analyses/pubs/BitBase_FinRep_Rev2.pdf)> (accessed 6 December 2013).
- 35 [NHPA] National Historic Preservation Act of 1966, as amended. 16 U.S.C. §470 et seq.
- 36 [NIEHS] National Institute of Environmental Health Sciences. 1999. *NIEHS Report on Health*
37 *Effects From Exposure to Power-Line Frequency Electric and Magnetic Fields*.
38 Research Triangle Park, NC: NIEHS. Publication No. 99-4493. May 4, 1999. 80 p. Available at
39 <http://www.niehs.nih.gov/health/assets/docs_f_o/niehs-report.pdf> (accessed
40 5 September 2014).
- 41 [NRC] U.S. Nuclear Regulatory Commission. 1985. *Byron Station, Unit No. 1, Facility Operating*
42 *License NPF-37*. February 14, 1985. Revised June 20, 2013. 377 p. ADAMS
43 No. ML052910365.
- 44 [NRC] U.S. Nuclear Regulatory Commission. 1987. *Byron Station, Unit No. 2, Facility Operating*
45 *License NPF-66*. January 30, 1987. Revised June 20, 2013. 11 p. ADAMS No. ML052910368.

Environmental Consequences and Mitigating Actions

- 1 [NRC] U.S. Nuclear Regulatory Commission. 1996. *Generic Environmental Impact Statement*
2 *for License Renewal of Nuclear Plants, Final Report*. Washington, DC: NRC. NUREG–1437,
3 Volumes 1 and 2. May 31, 1996. 1,204 p. ADAMS Nos. ML040690705 and ML040690738.
- 4 [NRC] U.S. Nuclear Regulatory Commission. 1997. *Regulatory Analysis Technical Evaluation*
5 *Handbook*. Washington, DC: NRC. NUREG/BR–0184, January 1997. 308 p. ADAMS
6 No. ML050190193.
- 7 [NRC] U.S. Nuclear Regulatory Commission. 1999. Section 6.3–Transportation, Table 9.1,
8 Summary of findings on NEPA issues for license renewal of nuclear power plants. In: *Generic*
9 *Environmental Impact Statement for License Renewal of Nuclear Plants*. Washington, DC:
10 NRC. NUREG–1437, Volume 1, Addendum 1. August 1999. ADAMS No. ML040690720.
- 11 [NRC] U.S. Nuclear Regulatory Commission. 2002. *Generic Environmental Impact Statement*
12 *on Decommissioning of Nuclear Facilities, Supplement 1: Regarding the Decommissioning of*
13 *Nuclear Power Reactors*. NUREG–0586, Volumes 1 and 2. Washington, DC: NRC.
14 November 30, 2002. 516 p. ADAMS Nos. ML023470327, ML023500228, and ML023500295.
- 15 [NRC] U.S. Nuclear Regulatory Commission. 2004. *Regulatory Analysis Guidelines of the U.S.*
16 *Nuclear Regulatory Commission*. Revision 4. Washington, DC: NRC. NUREG/BR–0058.
17 September 2004. 52 p. ADAMS No. ML042820192.
- 18 [NRC] U.S. Nuclear Regulatory Commission. 2008. *Final Environmental Impact Statement for*
19 *an Early Site Permit (ESP) at the Vogtle Electric Generating Plant Site*. Final Report.
20 Washington, DC: NRC. NUREG–1872, Volumes 1 and 2. August 8, 2008. 1,259 p. ADAMS
21 No. ML082260190.
- 22 [NRC] U.S. Nuclear Regulatory Commission. 2012a. “Commission, Memorandum and Order.”
23 Rockville, MD: NRC. CLI-12-16. August 7, 2012. 10 p. ADAMS No. ML12220A094.
- 24 [NRC] U.S. Nuclear Regulatory Commission. 2012b. Memorandum from A. Vietti-Cook,
25 Secretary, to R. W. Borchardt, Executive Director for Operations. Subject: Staff requirements—
26 COMSECY-12-0016—Approach for addressing policy issues resulting from court decision to
27 vacate Waste Confidence Decision and rule. September 6, 2012. ADAMS No. ML12250A032.
- 28 [NRC] U.S. Nuclear Regulatory Commission. 2013a. *Generic Environmental Impact Statement*
29 *for License Renewal of Nuclear Plants*. Revision 1. Washington, DC: NRC. NUREG–1437,
30 Volumes 1, 2, and 3. June 30, 2013. 1,535 p. ADAMS No. ML13107A023.
- 31 [NRC] U.S. Nuclear Regulatory Commission. 2013b. *Event Report Guidelines: 10 CFR 50.72*
32 *and 50.73*. Revision 3. Washington, DC: NRC. NUREG–1022. January 31, 2013. 107 p.
33 ADAMS No. ML13032A220.
- 34 [NRC] U.S. Nuclear Regulatory Commission. 2013c. *Standard Review Plans for Environmental*
35 *Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*. Revision 1.
36 Washington, DC: NRC. NUREG–1555, June 30, 2013. 325 p. ADAMS No. ML13106A246.
- 37 [NRC] U.S. Nuclear Regulatory Commission. 2013d. Letter from M. Wong, Chief, to A. Haaker,
38 Deputy State Historic Preservation Officer, Illinois Historic Preservation Agency. Subject: Byron
39 Station, Units 1 and 2, License Renewal Application Review. August 9, 2013. ADAMS
40 No. ML13190A331.
- 41 [NRC] U.S. Nuclear Regulatory Commission. 2013e. Letter from M. Wong, Chief, to R. Nelson,
42 Advisory Council on Historic Preservation. Subject: “Byron Nuclear Station, Units 1 and 2,
43 License Renewal Application Review.” August 9, 2013. ADAMS No. ML13184A052.

- 1 [NRC] U.S. Nuclear Regulatory Commission. 2013f. Letters from M. Wong, Chief, to 14 tribes,
 2 Subject: “Request for Scoping Comments Concerning the Byron Nuclear Generating Station,
 3 Units 1 and 2, License Renewal Application Review.” August 9, 2013. ADAMS
 4 No. ML13184A127.
- 5 [NRC] U.S. Nuclear Regulatory Commission. 2013g. *Environmental Impact Statement for the*
 6 *Combined License (COL) for Enrico Fermi Unit 3, Final Report*. Washington, DC: NRC.
 7 NUREG–2105, Volume 1. January 2013. 753 p. ADAMS No. ML12307A172.
- 8 [NRC] U.S. Nuclear Regulatory Commission. 2014a. *Generic Environmental Impact Statement*
 9 *for Continued Storage of Spent Nuclear Fuel*. Washington, DC: NRC, Office of Nuclear Material
 10 Safety and Safeguards. NUREG–2157, Volumes 1 and 2. September 2014. ADAMS
 11 Nos. ML14196A105 and ML14196A107.
- 12 [NRC] U.S. Nuclear Regulatory Commission. 2014b. “Commission, Memorandum and Order
 13 CLI-14-08.” August 26, 2014. ADAMS No. ML14238A242.
- 14 [OCPZD] Ogle County Planning & Zoning Department. 2013. “Ogle County District Map:
 15 Rockvale Township.” OCPZD: Oregon, IL. May 2013. 1 p. Available at
 16 <<http://oglecounty.org/wp-content/uploads/2013/05/Rockvale-Township.pdf>> (accessed
 17 25 October 2013).
- 18 [OECD/NEA] Organisation for Economic Co-Operation and Development Nuclear Energy
 19 Agency. 2005. *Projected Costs of Generating Electricity 2005*. OECD Publishing. 230 p.
 20 Available at: <<http://www.oecd-ilibrary.org/content/book/9789264008274-en>> (accessed
 21 5 September 2014).
- 22 Pachauri RK, Reisinger A (Intergovernmental Panel on Climate Change (IPCC)), editors. 2007.
 23 *Climate Change 2007: Synthesis Report. Contribution of Working Groups I, II and III to the*
 24 *Fourth Assessment Report of the Intergovernmental Panel on Climate Change*. Geneva,
 25 Switzerland: IPCC. 104 p. Available at <[http://www.ipcc.ch/publications_and_data/](http://www.ipcc.ch/publications_and_data/publications_ipcc_fourth_assessment_report_synthesis_report.htm)
 26 [publications_ipcc_fourth_assessment_report_synthesis_report.htm](http://www.ipcc.ch/publications_and_data/publications_ipcc_fourth_assessment_report_synthesis_report.htm)>.
- 27 Parry ML, Canziani OF, Palutikof JP, van der Linden PJ, Hanson CE (Intergovernmental Panel
 28 on Climate Change), editors. 2007. *Climate Change 2007: Impacts, Adaptation and*
 29 *Vulnerability. Contribution of Working Group II to the Fourth Assessment Report of the*
 30 *Intergovernmental Panel on Climate Change*. Cambridge, UK: Cambridge University Press.
 31 987 p. Available at
 32 <http://www.ipcc.ch/pdf/assessment-report/ar4/wg2/ar4_wg2_full_report.pdf>.
- 33 Pedersen E and Persson Wayne K. 2004. “Perception and annoyance due to wind turbine
 34 noise—a dose–response relationship.” *J. Acoust. Soc. Am.* 116(6):3460–3470. Available at
 35 <<http://www.shipdhamturbines.org.uk/files/RDG08.pdf>> (accessed 10 April 2014).
- 36 Saussus P. 2012. Major noise sources and mitigation cost estimates for gas-fired power
 37 facilities. *POWER*. Available at <[http://www.powermag.com/](http://www.powermag.com/major-noise-sources-and-mitigation-cost-estimates-for-gas-fired-power-facilities/?pagenum=1)
 38 [major-noise-sources-and-mitigation-cost-estimates-for-gas-fired-power-facilities/?pagenum=1](http://www.powermag.com/major-noise-sources-and-mitigation-cost-estimates-for-gas-fired-power-facilities/?pagenum=1)>
 39 (accessed 30 September 2013).
- 40 Sinclair RA. 1996. *Rock River Basin: Historical Background, IEPA Targeted Watersheds, and*
 41 *Resource-Rich Areas*. Champaign, IL: Illinois Department of Natural Resources. Miscellaneous
 42 Publication 174. April 1996. 27 p. Available at
 43 <<http://www.isws.illinois.edu/pubdoc/MP/ISWSMP-174.pdf>> (accessed 29 January 2014).

Environmental Consequences and Mitigating Actions

- 1 Solomon S, Qin D, Manning M, Marquis M, Averyt KB, Tignor MMB, Miller HL
2 (Intergovernmental Panel on Climate Change), Chen Z (China Meteorological Administration),
3 editors. 2007. *Climate Change 2007: The Physical Science Basis. Contribution of Working*
4 *Group I to the Fourth Assessment Report of the Intergovernmental Panel on Climate Change.*
5 Cambridge, United Kingdom: Cambridge University Press. 1,007 p. Available at
6 <http://www.ipcc.ch/pdf/assessment-report/ar4/wg1/ar4_wg1_full_report.pdf>.
- 7 Stocker TF (University of Bern), Qin D (China Meteorological Administration), Plattner GK,
8 Tignor MMB, Allen SK, Boschung J, Nauels A, Xia Y, Bex V, Midgley PM (Intergovernmental
9 Panel on Climate Change), editors. 2013. *Climate Change 2013: The Physical Science Basis.*
10 *Contribution of Working Group I to the Fifth Assessment Report of the Intergovernmental Panel*
11 *on Climate Change.* Cambridge, United Kingdom: Cambridge University Press. 1,552 p.
12 Available at <http://www.climatechange2013.org/images/report/WG1AR5_ALL_FINAL.pdf>.
- 13 Tagaris E, Liao KJ, DeLucia AJ, Deck L, Amar P, Russell AG. 2009. Potential impact of climate
14 change on air pollution-related human health effects. *Environmental Science &*
15 *Technology* 43(13):4979–4988. Available at <<http://pubs.acs.org/doi/pdf/10.1021/es803650w>>
16 (accessed 2 June 2014).
- 17 Tegen S. 2006. *Comparing Statewide Economic Impacts of New Generation from Wind, Coal,*
18 *and Natural Gas in Arizona, Colorado, and Michigan.* NREL/TP-500-37720. National
19 Renewable Energy Laboratory. May 2006. 38 p. Available at
20 <http://www.windpoweringamerica.gov/pdfs/38154_econdev_compare_statewide.pdf>
21 (accessed 30 September 2013).
- 22 [Teledyne] Teledyne Brown Engineering Environmental Services. 2013. *Byron Nuclear*
23 *Generating Station, Units 1 and 2, Annual Radiological Environmental Operating Report,*
24 *1 January Through 31 December 2012.* Byron, IL: Exelon Generation. May 2013. 207 p.
25 ADAMS No. ML13168A066.
- 26 Thuiller W. 2007. Biodiversity: climate change and the ecologist. *Nature* 448:550–552. Available
27 at <<http://www.nature.com/climate/2007/0712/full/448550a.html>>.
- 28 [USGS] U.S. Geological Survey. 2014. “USGS Surface-Water Data for USA: Annual Statistics
29 for the Nation: USGS 05440700 Rock River at Byron, IL.” Available at
30 <[http://waterdata.usgs.gov/nwis/annual/
31 ?referred_module=sw&site_no=05440700&por_05440700_4
32 =878897,00060,4,2000,2012&year_type=W&format=html_table&date_format
33 =YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list](http://waterdata.usgs.gov/nwis/annual/?referred_module=sw&site_no=05440700&por_05440700_4=878897,00060,4,2000,2012&year_type=W&format=html_table&date_format=YYYY-MM-DD&rdb_compression=file&submitted_form=parameter_selection_list)>
34 (accessed 27 January 2014).
- 35 Watters GT. 2000. Freshwater mussels and water quality: a review of the effects of hydrologic
36 and instream habitat alterations. In: Tankersley RA, Warmolts DI, Watters GT, Armitage BJ,
37 Johnson PD, Butler RS, editors. *Freshwater Mollusk Symposia Proceedings.* Columbus, OH:
38 Ohio Biological Survey. 295 p. Available at
39 <<http://www.studymode.com/essays/Freshwater-Mussel-And-Water-Quality-a-834627.html>>.

5.0 CONCLUSION

This draft supplemental environmental impact statement (SEIS) contains the environmental review of the application for renewed operating licenses for Byron Station, Units 1 and 2 (Byron), submitted by Exelon Generation Company, LLC (Exelon), as required by the *Code of Federal Regulations* (CFR), Part 51 of Title 10 (10 CFR Part 51), the U.S. Nuclear Regulatory Commission's (NRC's) regulations that implement the National Environmental Policy Act (NEPA). This chapter presents conclusions and recommendations from the site-specific environmental review of Byron. Section 5.1 summarizes the environmental impacts of license renewal; Section 5.2 presents a comparison of the environmental impacts of license renewal and energy alternatives; and Section 5.3 presents the NRC staff conclusions and recommendation.

5.1 Environmental Impacts of License Renewal

The NRC staff's review of site-specific environmental issues in this SEIS leads to the conclusion that issuing renewed licenses at Byron would have SMALL impacts for the Category 2 issues applicable to license renewal at Byron. The NRC staff considered mitigation measures for each Category 2 issue, as applicable. The NRC staff concluded that no additional mitigation measure is warranted.

5.2 Comparison of Alternatives

In Chapter 4, the staff considered the following alternatives to Byron license renewal:

- no-action alternative
- new nuclear alternative
- integrated gasification combined cycle (IGCC) alternative
- natural gas combined cycle (NGCC) alternative
- combination alternative (NGCC, wind, solar)
- purchased power

Based on the summary of environmental impacts provided in Table 2-2, the NRC staff concluded that the environmental impacts of renewal of the operating licenses for Byron would be smaller than those of feasible and commercially viable alternatives. The no-action alternative, the act of shutting down Byron on or before its licenses expires, would have SMALL environmental impacts in most areas with the exception of socioeconomic impacts, which would have SMALL to LARGE environmental impacts. Continued operations would have SMALL environmental impacts in all areas. The staff concluded that continued operation of the existing Byron units is the environmentally preferred alternative.

Conclusion

1 **5.3 Recommendations**

2 The NRC staff's preliminary recommendation is that the adverse environmental impacts of
3 license renewal for Byron are not so great that preserving the option of license renewal for
4 energy-planning decisionmakers would be unreasonable. This recommendation is based on the
5 following:

- 6 • the analysis and findings in NUREG-1437, Volumes 1 and 2, *Generic*
7 *Environmental Impact Statement for License Renewal of Nuclear Plants*;
- 8 • the environmental report submitted by Exelon;
- 9 • consultation with Federal, state, and local agencies;
- 10 • the NRC staff's environmental review; and
- 11 • consideration of public comments received during the scoping process.

1

6.0 LIST OF PREPARERS

2 Members of the U.S. Nuclear Regulatory Commission's (NRC's) Office of Nuclear Reactor
3 Regulation (NRR) prepared this supplemental environmental impact statement with assistance
4 from other NRC organizations and support from Argonne National Laboratory (ANL), Pacific
5 Northwest National Laboratory (PNNL), and BLH Technologies, Inc. (BLH). ANL and PNNL
6 provided support as identified in Table 6-1. BLH provided support for technical editing reviews.
7 Table 6-1 identifies each contributor's name, affiliation, and function or expertise.

List of Preparers

1
2

Table 6–1. List of Preparers
(in alphabetical order)

Name	Affiliation	Function or Expertise
NRC		
Russell Chazell	NRR	Alternatives
Kevin Folk	NRR	Water Resources: Surface Water
William Ford	NRR	Geology; Water Resources: Groundwater
Briana Grange	NRR	Aquatic Resources; Special Status Species and Habitats; Microbiological Hazards; Land Use and Visual Resources; Terrestrial Resources
Robert Hoffman	NRR	Meteorology, Air Quality, and Noise
Lois James	NRR	Environmental Project Manager
Steven Klementowicz	NRR	Human Health; Waste Management and Pollution Prevention
Emily Larson	NRR	Historic and Cultural Resources; Environmental Justice
Dennis Logan	NRR	Land Use and Visual Resources; Terrestrial Resources; Aquatic Resources
Nancy Martinez	NRR	Air Quality Climatic Change Meteorology, Air Quality, and Noise; Greenhouse Gas Emissions and Climate Change
John Parillo	NRR	SAMA
Jeffrey Rikhoff	NRR	Socioeconomics; Historic and Cultural Resources
Allison Travers	NRR	Land Use and Visual Resources; Terrestrial Resources
Brian Wittick	NRR	Branch Chief
David Wrona	NRR	Branch Chief
Contractor^(a)		
Young Soo Chang	ANL	Air Quality and Climate
Terri Patton	ANL	Water Resources: Surface Water; Groundwater
Konnie Wesott	ANL	Alternatives
Ellen White	ANL	Alternatives
SAMA Contractor^(b)		
Bob Schmidt	PNNL	SAMA
Bruce Schmitt	PNNL	SAMA
Steve Short	PNNL	SAMA

^(a) ANL is managed by UChicago Argonne, LLC, for the U.S. Department of Energy.

^(b) PNNL is operated by Battelle for the U.S. Department of Energy.

1 **7.0 LIST OF AGENCIES, ORGANIZATIONS, AND PERSONS**
 2 **TO WHOM COPIES OF THIS SEIS ARE SENT**

3 **Table 7–1. List of Agencies, Organizations, and Persons to Whom Copies**
 4 **of This SEIS Are Sent**

Name and Title	Company and Address
Brent Baker, President	Byron Chamber of Commerce 232 W. 2nd Street PO Box 405 Byron, IL 61010
John “Rocky” Barrett, Chairman	Citizen Potawatomi Nation 1601 S. Gordon Cooper Dr. Shawnee, OK 74801
Jenny Beckman, Campaign Manager/Ogle County Director, United Way of Rock River Valley	United Way of Rock River Valley 612 N. Main Street Suite 300 Rockford, IL 61103-6998 815-968-5400
Galen Bennett, Chief	Byron Fire Protection District E-mail
John Blackhawk, Chairman	Winnebago Tribe of Nebraska 100 Bluff Street PO Box 687 Winnebago, NE 68071
Ronald Bolin, Exelon Employee	Resident
Johnathan L. Buffalo, Historic Preservation Director	Sac and Fox Tribe of the Mississippi in Iowa/Meskwaki 349 Meskwaki Road Tama, IA 52339
Scott H. Christiansen, Chairman	Winnebago County Board of Commissioners E-mail
Allen Christianson, Exelon Employee	Exelon Generation Company, LLC 8457 Wendy Court Byron, IL 61010
Ron Colson, Member	Blackhawk Hills Regional Council E-mail
Tom Demmer, Illinois State Representative	District Office 1221 Currency Court Suite B Rochelle, IL 61068
Michael Dougherty, Chairperson	Sac and Fox Nation of Missouri in Kansas and Nebraska 305 N. Main Street Reserve, KS 66434
Bruce Drawbridge, Vice President	CBI Chicago Bridge and Iron 444 N. Wells St, Suite 602 Chicago, IL 60654-8198

List of Agencies, Organizations, and Persons to Whom Copies of This SEIS Are Sent

Name and Title	Company and Address
Mr. Jon Duyvejonck, Fish and Wildlife Biologist	Rock Island Field Office U.S. Fish and Wildlife Service 1511 47th Avenue Moline, IL 61265
EIS Filing Section	U.S. Environmental Protection Agency (EPA) 1200 Pennsylvania Avenue, NW Washington, DC 20004
Environmental Law and Policy Center (ELPC)	Environmental Law and Policy Center 35 E. Wacker Drive, Suite 1600 Chicago, IL 60601
Sarah Faller, Exelon Employee	Exelon Generation Company, LLC E-mail
Harold "Gus" Frank, Chairman	Forest County Potawatomi 5416 Everybody's Rd. Crandon, WI 54520
John P. Froman, Chief	Peoria Tribe of Indians of Oklahoma 118 S. Eight Tribes Trail P.O. Box 1527 Miami, OK 74355
Jarid Funderburg, Representative of Congressman Kinzinger	Congressman Kinzinger's Office 401 Whitney Blvd. Belvidere, IL 61008
Michael P. Gallagher, Vice President, License Renewal Projects	Exelon Generation Company, LLC 200 Exelon Way Kennett Square, PA 19348
Ron Gibson, Member	Byron Township E-mail
Kim P. Gouker, Member	Ogle County Board P.O. Box 926 Byron, IL 61010
Jon Greendeer, President	Ho-Chunk Nation W9814 Airport Road P.O. Box 667 Black River Falls, WI 54615-0667
Anne E. Haaker, Deputy State Historic Preservation Officer	Preservation Services Division Illinois Historic Preservation Agency 1 Old State Capitol Plaza Springfield, IL 62701-1507
Dr. James Hammack, Superintendent	Byron, Illinois School District E-mail
Michael Harn, Sheriff	Sheriff Ogle County E-mail
Candace Humphrey, Emergency Management Director	Ogle County, Illinois E-mail

List of Agencies, Organizations, and Persons to Whom Copies of This SEIS Are Sent

Name and Title	Company and Address
Russ Kearney, Site Vice President	Exelon Generation Company, LLC 4448 N. German Church Byron, IL 61010-9750
Joe Klinger, Assistant Director	Illinois Emergency Management Agency E-mail
David Kraft, Representative	National Energy Information Service (NEIS) 4311 West Diversey Ave. #16 Chicago, IL 60647
Douglas G. Lankford, Chief	Miami Tribe of Oklahoma P.O. Box 1326 Miami, OK 74355
Dennis Lolli, Emergency Management Director	Winnebago County, Illinois E-mail
Sandra Kaye Massey, Member	Sac and Fox Nation Administration Building 920883 S. Hwy 99 Bldg A Stroud, OK 74079
Jim McGhee, Senior Resident Inspector	4448 N. German Church Byron, IL 61010-9750
Charles Medrano, Exelon Employee	Exelon Generation Company, LLC E-mail
Tom Melius, Midwest Regional Director	Midwest Regional Director U.S. Fish and Wildlife Service 5600 American Blvd. West, Suite 990 Bloomington, MN 55437-1458
Kenneth Meshigaud, Tribal Chairperson	Hannahville Indian Community, Band of Potawatomi N14911 Hannahville B-1 Rd. Wilson, MI 49896
Chris Millard	Resident
Kelli Mosteller, THPO	1601 S. Gordon Cooper Dr. Shawnee, OK 74801
Todd R. Murray, Chief	Byron Police Department, Byron, Illinois E-mail
Reid Nelson, Director	Office of Federal Agency Programs Advisory Council on Historic Preservation Old Post Office Building 1100 Pennsylvania Avenue, NW Suite 803 Washington, DC 20004
Richard C. Nelson, Field Office Supervisor	Rock Island Field Office U.S. Fish and Wildlife Service 1511 47th Avenue Moline, Illinois 61265
Doreen O'Brien, Public Health Administrator	Ogle County Health Department E-mail

List of Agencies, Organizations, and Persons to Whom Copies of This SEIS Are Sent

Name and Title	Company and Address
Doug O'Brien, Member	Illinois Clean Energy Coalition E-mail
Penny O'Rourke	Byron Public Library District 100 S. Washington St. Byron, IL 61010
Steve Ortiz, Chair	Prairie Band of Potawatomi Nation 16281 Q Road Mayetta, KS 66509
Cindy Pederson, Regional Administrator	U.S. Nuclear Regulatory Commission Region III 2443 Warrenville Road Lisle, IL 60532
Elizabeth Poole, Environmental Scientist	NEPA Implementation Section U.S. Environmental Protection Agency 77 W Jackson Blvd. E-19J Chicago, IL 60604
John Quackenbush, THPO	HCN Cultural Resources W9036 Hwy 54 East Black River Falls, WI 54615
Nancy L. Ranek, Environmental Lead for Byron License Renewal	Exelon Generation Company, LLC 200 Exelon Way, KSA-2-E Kennett Square, PA 19348
Alvin Sanache, Chairman	Sac and Fox Tribe of the Mississippi in Iowa/Meskwaki 349 Meskwaki Road Tama, IA 52339
Tony Sullins, Threatened and Endangered Species Chief	U.S. Fish and Wildlife Service Midwest Region (Region 3) 5600 American Blvd. West, Suite 990 Bloomington, Minnesota 55437-1458
Ed Stirling, Resident	E-mail
George Strack, THPO	P.O. Box 1326 Miami, OK 74355
Brittany Theis, Attorney	WHITT LAW LLC 70 South Constitution Drive Aurora, IL 60506-7335
Ruth Thomas, Resident	Resident
Patti Thompson, Public Information Officer	Illinois Emergency Management Agency E-mail
George Thurman, Principal Chief	Sac and Fox Nation Administration Building 920883 S. Hwy 99 Bldg A Stroud, OK 74079
Todd Tucker, Executive Director	Byron Forest Preserve E-mail

List of Agencies, Organizations, and Persons to Whom Copies of This SEIS Are Sent

Name and Title	Company and Address
Matt Wesaw, Chairman	Pokagon Band of Potawatomi 58620 Sink Road Box 180 Dowagiac, MI 49047
Dan Westin, Rochelle Utilities Employee	Rochelle Utilities 333 Lincoln Highway Rochelle, IL 61068
Kenneth Westlake, EPA Employee	EPA Region 5 - Main Office 77 W. Jackson Boulevard Chicago, IL 60604 312-353-2000
Tom Wolf, Member	Illinois Chamber of Commerce 300 S. Wacker #1600 Chicago, IL 60606
Mike Zimmerman, Jr., THPO	Department of Natural Resources P.O. Box 180 58620 Sink Rd. Dowagiac, MI 49047

8.0 INDEX

- 23 **A**
- 4 **accidents**xxiv, 4-62, 4-63, 4-65, A-6, F-1,
5 F-3, F-4, F-6, F-7, F-9, F-10, F-15, F-16, F-17,
6 F-21, F-34, F-37, F-39, F-40, F-41, F-44, F-47
- 7 **Advisory Council on Historic Preservation**
8 **(AHP)**xxix, 1-6, 4-46, 4-126, 7-3, B-7,
9 C-3, C-4
- 10 **aesthetic**3-29, 3-91, 4-49, 4-75
- 11 **alternatives** v, xxvi, 1-5, 2-1, 2-3, 2-4, 2-5,
12 2-6, 2-8, 2-18, 2-21, 2-23, 2-25, 2-28, 4-1, 4-5,
13 4-16, 4-17, 4-18, 4-19, 4-20, 4-21, 4-22, 4-27,
14 4-28, 4-29, 4-30, 4-34, 4-35, 4-36, 4-41, 4-45,
15 4-50, 4-57, 4-58, 4-63, 4-64, 4-70, 4-71, 4-75,
16 4-84, 4-85, 4-87, 4-91, 4-92, 4-115, 4-116,
17 4-117, 5-1, A-1, A-7, B-3, C-2, F-26, F-27
- 18 **archaeological resources** 1-6, 2-5, 3-65,
19 3-67, 4-47, 4-48, 4-49, 4-106
- 20 **B**
- 21 **biocide** 4-60
- 22 **biological assessment** C-1, C-2
- 23 **biota**4-34, 4-38, 4-96, 4-105
- 24 **burnup** 3-5
- 25 **C**
- 26 **chronic effects** 4-58, 4-59
- 27 **Clean Air Act (CAA)** xxx, 3-20, 3-102, 4-10,
28 4-11, 4-14, 4-99, 4-112, 4-119, 4-121, B-4, B-9
- 29 **closed-cycle cooling** xxv, 2-9, 2-14, 2-15, 2-16,
30 3-5, 4-25
- 31 **Coastal Zone Management Act (CZMA)** B-5
- 32 **consumptive use**3-28, 4-24, 4-25, 4-26,
33 4-27, 4-28, 4-29, 4-30
- 34 **cooling system** xxiv, xxv, xxxi, 1-4, 1-6, 2-11,
35 2-14, 2-15, 2-16, 3-5, 3-28, 3-29, 3-47, 3-60,
36 3-87, 4-18, 4-23, 4-25, 4-39, 4-40, 4-59, F-9,
37 F-23, F-32
- 38 **core damage frequency (CDF)** xx, xxi, xxx,
39 4-65, F-1, F-2, F-3, F-5, F-6, F-7, F-8, F-9, F-10,
40 F-11, F-12, F-13, F-14, F-21, F-22, F-24, F-25,
41 F-26, F-27, F-28, F-29, F-34, F-35, F-37, F-38,
42 F-40, F-41
- 43 **Council on Environmental Quality**
44 **(CEQ)** xxx, 1-3, 3-90, 3-91, 3-100, 4-104,
45 4-105, 4-119
- 46 **critical habitat**3-60, 3-61, 3-62, 3-63, 3-64,
47 3-96, 4-41, 4-42, 4-43, 4-44, 4-81, B-7, C-1, C-2
- 48 **cultural resources**xxv, 2-5, 2-27, 3-17, 3-65,
49 3-67, 4-45, 4-47, 4-48, 4-49, 4-50, 4-79, 4-80,
50 4-81, 4-86, 4-96, 4-106, 4-107, 4-115, B-1, B-7
- 51 **D**
- 52 **design-basis accident**xxxi, 4-1
- 53 **discharges** xxv, 2-9, 2-11, 2-14, 2-15, 2-16,
54 3-1, 3-5, 3-8, 3-9, 3-10, 3-15, 3-17, 3-18, 3-22,
55 3-27, 3-28, 3-29, 3-30, 3-36, 3-37, 3-38, 3-47,
56 3-48, 3-52, 3-53, 3-57, 3-59, 3-87, 4-23, 4-25,
57 4-26, 4-27, 4-28, 4-37, 4-39, 4-58, 4-59, 4-60,
58 4-88, 4-100, 4-105, 4-106, A-4, A-8, B-4, B-5,
59 E-3, F-32, F-36
- 60 **dose**xxxvii, 3-9, 3-10, 3-11, 3-12, 3-86, 3-95,
61 4-65, 4-76, 4-86, 4-108, 4-109, 4-127, B-3, B-6,
62 F-4, F-16, F-17, F-18, F-19, F-20, F-22, F-27,
63 F-28, F-32, F-34, F-37, F-38, F-41
- 64 **dredging** 2-11, 3-32, 3-51, 3-60, 4-23, 4-26,
65 4-27, 4-28, 4-34, 4-37, 4-39
- 66 **E**
- 67 **education** 3-78, 4-51
- 68 **electromagnetic fields** xxxi, 3-89, 4-58, 4-59,
69 4-68, 4-69
- 70 **endangered and threatened species**xxv,
71 1-6, 3-40, 3-55, 3-97, B-1, B-7, C-1
- 72 **Endangered Species Act (ESA)**xxvi, xxxi,
73 1-6, 1-7, 1-8, 2-5, 3-40, 3-44, 3-59, 3-96, 3-102,
74 4-41, 4-42, 4-43, 4-44, 4-45, 4-81, 4-95, 4-96,
75 4-118, 4-122, 4-123, B-7, B-9, C-1, C-2, C-6,
76 D-1
- 77 **entrainment** 3-60, 4-37, 4-38, 4-39
- 78 **environmental justice (EJ)** 2-5, 3-91, 3-96,
79 4-71, 4-72, 4-81, 4-87, 4-109, 4-118
- 80 **essential fish habitat (EFH)** xxxi, 3-65, 4-41,
81 4-43, 4-44, 4-81, B-7, C-3
- 82 **eutrophication** 3-60, 4-37, 4-96
- 83 **evaporative loss**3-8
- 84 **F**
- 85 **Fish and Wildlife Coordination Act**
86 **(FWCA)** xxxii, B-9

Index

- 1 **G**
- 2 **Generic Environmental Impact Statement**
- 3 **(GEIS)**v, xxiii, xxiv, xxvii, xxxii, 1-3, 1-4, 1-5,
- 4 1-6, 1-7, 1-8, 2-1, 2-2, 2-3, 2-4, 2-19, 2-21, 2-32,
- 5 2-33, 3-72, 3-89, 3-109, 4-1, 4-2, 4-5, 4-6, 4-11,
- 6 4-14, 4-17, 4-21, 4-22, 4-23, 4-24, 4-25, 4-27,
- 7 4-28, 4-29, 4-30, 4-31, 4-32, 4-33, 4-34, 4-35,
- 8 4-37, 4-38, 4-39, 4-40, 4-41, 4-46, 4-50, 4-51,
- 9 4-58, 4-59, 4-61, 4-62, 4-63, 4-71, 4-76, 4-77,
- 10 4-78, 4-79, 4-83, 4-84, 4-85, 4-86, 4-87, 4-88,
- 11 4-90, 4-91, 4-126, 4-127, 5-2, A-1, A-6, A-10,
- 12 D-3, F-47
- 13 **greenhouse gases**..... xxxii, 2-7, 2-14, 2-28,
- 14 3-21, 3-96, 4-7, 4-119
- 15 **groundwater** xxv, 3-5, 3-15, 3-17, 3-29, 3-32,
- 16 3-34, 3-36, 3-37, 3-79, 3-87, 4-22, 4-24, 4-25,
- 17 4-26, 4-27, 4-28, 4-29, 4-30, 4-72, 4-73, 4-86,
- 18 4-95, 4-100, 4-101, 4-102, 4-111, 4-114, B-1,
- 19 E-3
- 20 **H**
- 21 **hazardous waste**3-14, 3-87, 3-95, 4-116,
- 22 B-6, B-9
- 23 **high-level waste** xxiv, 1-4, 4-76, 4-77, 4-78,
- 24 4-82, 4-83, 4-86
- 25 **I**
- 26 **Illinois Department of Commerce and**
- 27 **Economic Opportunity (DCEO)**..... xix, xxxi,
- 28 3-72, 3-73, 3-101, F-45
- 29 **Illinois Department of Natural Resources**
- 30 **(IDNR)** ... xxxiii, 3-8, 3-16, 3-17, 3-32, 3-38, 3-42,
- 31 3-44, 3-46, 3-47, 3-60, 3-63, 3-64, 3-105, 3-107,
- 32 3-111, 4-38, 4-101, 4-106, 4-123, 4-124, 4-127,
- 33 E-4, E-5, E-6
- 34 **Illinois Department of Public Health**
- 35 **(IDPH)**xxxiii, 3-36, 3-88, 3-106, 4-59, 4-61,
- 36 4-122, 4-123
- 37 **Illinois Department of Transportation**
- 38 **(IDOT)**xxxiii, 3-8, 3-28, 3-48, 3-53, 3-85,
- 39 3-105, 3-106, E-4
- 40 **Illinois Endangered Species Protection**
- 41 **Board (IESPB)**..... xxxiii, 3-45, 3-107
- 42 **Illinois Environmental Protection Agency**
- 43 **(IEPA)**.... xxxiii, 3-8, 3-20, 3-25, 3-29, 3-30, 3-32,
- 44 3-36, 3-37, 3-47, 3-106, 3-109, 3-110, 4-24,
- 45 4-60, 4-90, 4-98, 4-101, 4-102, 4-106, 4-123,
- 46 4-124, 4-127, A-3, A-4, A-8, A-9, B-1, B-8, B-9,
- 47 D-2, E-3, E-5, E-6
- 48 **Illinois Historic Preservation Agency**
- 49 **(IHPA)**xxxiii, 1-6, 2-27, 3-65, 3-110, 4-46,
- 50 4-47, 4-124, 4-126, 7-2, C-4, C-5, D-2
- 51 **Illinois State Geological Survey (ISGS)** ..xxxiv,
- 52 3-18, 3-107, 3-113
- 53 **impingement**..... 3-8, 3-60, 4-38, 4-39
- 54 **independent spent fuel storage installation**
- 55 **(ISFSI)**.....xxxiv, 3-13, 3-17, 3-18, 4-80, 4-81,
- 56 4-108, 4-109
- 57 **Indian tribes**.....3-67, 3-91, 3-107, 4-71, 4-72
- 58 **invasive species**..... 3-39, 4-95
- 59 **L**
- 60 **long-term dose**F-16
- 61 **low-level waste**..... 4-83, 4-86
- 62 **M**
- 63 **Magnuson-Stevens Fishery Conservation**
- 64 **and Management Act (MSA)** xxxv, 1-6, 1-7,
- 65 1-8, 3-59, 3-65, 3-108, 4-43, 4-44, 4-81, 4-125,
- 66 B-7, B-10, C-3, C-6
- 67 **Marine Mammal Protection Act**
- 68 **(MMPA)**..... xxxv, B-9
- 69 **mitigation**..... xxiv, xxxviii, 1-3, 1-4, 1-5, 4-16,
- 70 4-39, 4-43, 4-48, 4-49, 4-50, 4-81, 4-99, 4-115,
- 71 4-127, 5-1, A-6, A-7, F-30, F-34, F-41
- 72 **mixed waste**..... 3-9, 3-95
- 73 **N**
- 74 **National Environmental Policy Act**
- 75 **(NEPA)**....xx, xxiv, xxxvi, 1-1, 1-7, 1-8, 2-1, 3-90,
- 76 3-100, 4-5, 4-42, 4-47, 4-50, 4-51, 4-76, 4-77,
- 77 4-79, 4-80, 4-81, 4-82, 4-105, 4-119, 4-120,
- 78 4-125, 4-126, 5-1, 7-4, A-8, B-3, C-1, C-3, C-6
- 79 **National Historic Preservation Act**..... xx, xxvi,
- 80 xxxvi, 1-6, 1-7, 1-8, 2-5, 4-46, 4-47, 4-80, 4-81,
- 81 4-125, B-7, B-10, C-3, C-4, C-6
- 82 **National Marine Fisheries Service**
- 83 **(NMFS)**xxxvi, 3-59, 3-64, 3-65, 4-41, 4-42,
- 84 4-43, 4-44, 4-123, B-7, C-1, C-2, C-3, C-6
- 85 **National Pollutant Discharge Elimination**
- 86 **System (NPDES)**xvii, xix, xxxvi, 3-9, 3-15,
- 87 3-27, 3-28, 3-29, 3-30, 3-31, 3-32, 3-87, 3-96,
- 88 3-97, 3-106, 4-26, 4-27, 4-28, 4-29, 4-30, 4-31,
- 89 4-39, 4-60, 4-102, 4-106, 4-114, 4-123, 4-124,
- 90 A-8, A-9, B-1, B-5, B-8, B-9, E-3
- 91 **Native American tribes**..... 3-67, 3-107, 4-71,
- 92 4-72

- 1 **no-action alternative** v, xxvi, 2-1, 2-3, 2-4,
2 2-25, 2-28, 4-2, 4-33, 4-38, 4-43, 4-50, 4-82,
3 4-90, 4-102, 4-105, 4-116, 5-1
- 4 **nonattainment** 3-20, 4-6
- 5 **P**
- 6 **postulated accidents** 4-1, 4-62, 4-63, 4-72
- 7 **power uprate** F-18, F-44
- 8 **R**
- 9 **radioactive nuclides** 3-10
- 10 **radon** 3-9, 3-13
- 11 **reactor** xxiii, xxxvii, xxxviii, 2-1, 2-2, 2-3, 2-10,
12 2-11, 2-29, 3-1, 3-5, 3-6, 3-8, 3-11, 3-13, 3-16,
13 3-18, 3-29, 3-37, 3-65, 3-86, 3-95, 4-24, 4-38,
14 4-46, 4-48, 4-50, 4-51, 4-62, 4-63, 4-64, 4-68,
15 4-73, 4-76, 4-77, 4-78, 4-79, 4-80, 4-81, 4-82,
16 4-87, 4-99, 4-107, 4-108, 4-109, 4-110, 4-118,
17 A-5, A-6, A-7, E-2, E-5, E-6, E-7, F-7, F-9, F-15,
18 F-16, F-18, F-23, F-26, F-32, F-34, F-36, F-38
- 19 **refurbishment** 2-2, 3-60, 3-65, 3-87, 4-5,
20 4-27, 4-32, 4-50, 4-98, 4-100, 4-104, F-38
- 21 **replacement power** v, xxvi, xxxviii, 2-3, 2-4,
22 2-5, 2-6, 2-8, 2-18, 4-29, 4-50, 4-57, 4-71, 4-85,
23 4-87, F-35, F-38
- 24 **S**
- 25 **scoping** v, xxiii, xxiv, xxvii, 1-1, 1-2, 1-6, 1-8,
26 4-1, 4-6, 4-21, 4-23, 4-24, 4-31, 4-37, 4-47,
27 4-51, 4-58, 4-63, 4-76, 4-86, 4-88, 4-97, 5-2,
28 A-1, A-3, A-8, C-4, C-5
- 29 **seismic** xxxviii, 3-23, 4-65, F-1, F-4, F-10,
30 F-14, F-26, F-40, F-44, F-47
- 31 **severe accident mitigation alternative**
32 **(SAMA)** xxi, xxvi, xxxviii, 4-63, 4-64, 4-65,
33 4-66, 4-67, 4-68, 4-122, 6-2, D-3, D-4, F-1, F-2,
34 F-3, F-5, F-8, F-9, F-10, F-11, F-13, F-14, F-17,
35 F-18, F-19, F-20, F-21, F-22, F-23, F-24, F-25,
36 F-26, F-27, F-28, F-29, F-34, F-35, F-36, F-37,
37 F-39, F-40, F-41, F-42, F-43, F-45, F-47
- 38 **severe accidents** ... xxvi, xxxviii, 4-1, 4-62, 4-63,
39 4-64, 4-66, 4-72, 4-122, F-1, F-10, F-21, F-34,
40 F-37, F-38, F-39, F-45, F-47
- 41 **solid waste** xxvii, 2-5, 2-24, 3-9, 3-10, 3-13,
42 3-14, 3-86, 3-95, 4-12, 4-81, 4-83, 4-86, B-1
- 43 **spent fuel** xxiv, xxxiv, 1-4, 3-13, 4-77, 4-78,
44 4-79, 4-80, 4-82, 4-86, 4-87, 4-118, E-2, F-36
- 45 **State Historic Preservation Office**
46 **(SHPO)** 3-67, 4-46, 4-47, 4-124, 4-126, 7-2
- 47 **stormwater**... 3-16, 4-26, 4-27, 4-28, 4-29, 4-30,
48 4-31, 4-32, 4-39, A-8, B-5
- 49 **surface runoff** 3-27, 3-30, 3-47, 4-26, 4-27,
50 4-28, 4-29, 4-30, 4-33, 4-93, 4-94, 4-95, 4-101,
51 4-102, 4-103, 4-104, 4-106, 4-114, B-5
- 52 **surface water** 3-25, 3-27, 3-28, 3-29, 3-32,
53 3-36, 3-37, 3-50, 3-87, 4-22, 4-23, 4-24, 4-26,
54 4-27, 4-28, 4-29, 4-30, 4-33, 4-38, 4-59, 4-72,
55 4-73, 4-86, 4-95, 4-100, 4-101, 4-102, 4-114,
56 B-1, B-5
- 57 **T**
- 58 **taxes** xxxvii, 3-80, 3-81, 3-82, 4-51
- 59 **transmission line corridors** 4-5, 4-29, 4-34,
60 4-35
- 61 **transmission lines** xxxviii, 2-11, 2-14, 2-15,
62 2-16, 2-18, 3-1, 3-15, 3-22, 3-38, 3-40, 3-46,
63 3-60, 3-65, 3-89, 3-101, 4-2, 4-4, 4-5, 4-6, 4-19,
64 4-28, 4-29, 4-31, 4-34, 4-35, 4-36, 4-37, 4-39,
65 4-40, 4-46, 4-48, 4-49, 4-50, 4-58, 4-61, 4-99
- 66 **tritium** 3-36, 3-37, 4-25, 4-26
- 67 **U**
- 68 **U.S. Department of Energy (DOE)** xxxi, 2-4,
69 2-10, 2-12, 2-13, 2-14, 2-16, 2-17, 2-18, 2-19,
70 2-20, 2-22, 2-23, 2-24, 2-28, 2-29, 2-30, 2-31,
71 2-32, 2-34, 3-13, 4-10, 4-53, 4-54, 4-56, 4-59,
72 4-91, 4-120, 4-125, 6-2
- 73 **U.S. Environmental Protection Agency**
74 **(EPA)** xxxi, xxxiii, 1-1, 2-1, 2-4, 2-13, 2-23,
75 2-24, 2-25, 2-28, 2-31, 3-5, 3-8, 3-9, 3-10, 3-11,
76 3-12, 3-17, 3-20, 3-21, 3-23, 3-29, 3-36, 3-37,
77 3-79, 3-86, 3-90, 3-95, 3-96, 3-97, 3-101, 3-102,
78 3-106, 3-107, 3-109, 4-6, 4-9, 4-10, 4-11, 4-12,
79 4-13, 4-14, 4-15, 4-25, 4-39, 4-60, 4-69, 4-70,
80 4-76, 4-78, 4-89, 4-92, 4-93, 4-94, 4-98, 4-99,
81 4-103, 4-105, 4-108, 4-111, 4-112, 4-115, 4-118,
82 4-119, 4-120, 4-121, 4-123, 4-124, 5-1, 7-2, 7-4,
83 7-5, A-8, A-9, B-1, B-3, B-4, B-5, B-6, B-9, E-3,
84 E-5, E-6, F-19, F-45
- 85 **U.S. Fish and Wildlife Service (FWS)** xxxii,
86 1-6, 1-7, 2-10, 2-16, 2-34, 3-39, 3-40, 3-42,
87 3-44, 3-45, 3-59, 3-60, 3-61, 3-62, 3-63, 3-64,
88 3-96, 3-97, 3-98, 3-101, 3-104, 3-105, 3-107,
89 3-109, 3-110, 3-111, 4-41, 4-42, 4-43, 4-122,
90 4-123, 7-2, 7-3, 7-4, B-7, C-1, C-2, C-3, C-6
- 91 **uranium** ... 2-10, 3-5, 4-1, 4-69, 4-85, 4-86, 4-87,
92 4-89

Index

1	W		
2	wastewater	3-10, 3-15, 3-37, 4-100, 4-101,	
3		4-102, A-8, E-3, E-5	
4	Y		
5	Yucca Mountain		4-78

1
2
3

**APPENDIX A
COMMENTS RECEIVED ON THE BYRON STATION
ENVIRONMENTAL REVIEW**

1 **A. COMMENTS RECEIVED ON THE BYRON STATION** 2 **ENVIRONMENTAL REVIEW**

3 **A.1 Comments Received During the Scoping Period**

4 The scoping process for the environmental review of the license renewal application for Byron
5 Station Units 1 and 2 (Byron) began on August 6, 2013, with the publication of the U.S. Nuclear
6 Regulatory Commission's (NRC's) notice of intent to conduct scoping in the *Federal Register*
7 (78 FR 47800). The scoping process included two public meetings held in Byron, Illinois, on
8 August 20, 2013. Approximately 70 people attended the meetings. After the NRC's prepared
9 statements pertaining to the license renewal process, the meetings were open for public
10 comments. Attendees provided oral statements that were recorded and transcribed by a
11 certified court reporter. A summary and transcripts of the scoping meetings are available using
12 the NRC's Agencywide Documents Access and Management System (ADAMS). ADAMS
13 Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams.html>.
14 The scoping meetings summary can be found under ADAMS Nos. ML13269A006 (package)
15 and ML13240A234 (summary). Transcripts for the afternoon and evening meetings included in
16 the meeting summary package (ML13269A006) can be found under ADAMS
17 Nos. ML13266A183 and ML13266A182, respectively. In addition to comments received during
18 the public meetings, comments were also received electronically and through the mail.

19 Each commenter was given a unique identifier, so every comment can be traced back to its
20 author. Table A-1 identifies the individuals who provided comments and an accession number
21 to identify the source document of the comments in ADAMS.

22 Specific comments were categorized and consolidated by topic. Comments with similar specific
23 objectives were combined to capture the common essential issues raised by commenters.
24 Comments have been grouped into the following general categories:

- 25 • Specific comments that address environmental issues within the purview of
26 the NRC environmental regulations related to license renewal. These
27 comments address Category 1 (generic) or Category 2 (site-specific) issues
28 identified in NUREG-1437, *Generic Environmental Impact Statement for*
29 *License Renewal of Nuclear Plants* (GEIS) or issues not addressed in the
30 GEIS. The comments also address alternatives to license renewal and
31 related Federal actions.
- 32 • General comments in support of or opposed to nuclear power or license
33 renewal or comments regarding the renewal process, the NRC's regulations,
34 and the regulatory process.
- 35 • Comments that address issues that do not fall within or are specifically
36 excluded from the purview of NRC environmental regulations related to
37 license renewal. These comments typically address issues such as the need
38 for power, emergency preparedness, security, current operational safety
39 issues, and safety issues related to operation during the renewal period.

Appendix A

1 **Table A–1. Individuals Providing Comments During the Scoping Comment Period**
 2 *Each commenter is identified along with their affiliation and how their comment was submitted.*

Commenter	Affiliation (if stated)	ID	Comment Source	ADAMS Number
Chris Millard	City of Byron, Mayor	001	Afternoon Scoping Meeting	ML13269A006
Jared Funderburg	Representative for Congressman Kinzinger, Illinois, 16th District	002	Afternoon Scoping Meeting	ML13269A006
		013	Evening Scoping Meeting	
Russ Kearney	Byron Site VP	003	Afternoon Scoping Meeting	ML13269A006
		015	Evening Scoping Meeting	
Mike Gallagher	Exelon Vice President of License Renewal	004	Afternoon Scoping Meeting	ML13269A006
		016	Evening Scoping Meeting	
Ron Gibson	Byron Township	005	Afternoon Scoping Meeting	ML13269A006
Tom Wolf	Illinois Chamber of Commerce	006	Afternoon Scoping Meeting	ML13269A006
Sarah Fuller	Byron employee	007	Afternoon Scoping Meeting	ML13269A006
Michael Harn	Sheriff of Ogle County	008	Afternoon Scoping Meeting	ML13269A006
		009	Afternoon Scoping Meeting	
Doug O'Brien	Illinois Clean Energy Coalition	017	Evening Scoping Meeting	ML13269A006
		010	Afternoon Scoping Meeting	
Todd Tucker	Executive Director of the Byron Forest Preserve	010	Afternoon Scoping Meeting	ML13269A006
Allen Christianson	Exelon	011	Afternoon Scoping Meeting	ML13269A006
Jenny Beckman	Director of United Way of Ogle County	012	Afternoon Scoping Meeting	ML13269A006
Tom Demmer	State Representative	014	Evening Scoping Meeting	ML13269A006
Ron Colson	Blackhawk Hills Regional Council	018	Evening Scoping Meeting	ML13269A006
Charles Medrano	Byron employee	019	Evening Scoping Meeting	ML13269A006

Commenter	Affiliation (if stated)	ID	Comment Source	ADAMS Number
Dan Westin	Rochelle Utilities	020	Evening Scoping Meeting	ML13269A006
Ronald Bolin	Exelon	021	Evening Scoping Meeting	ML13269A006
Kim Gouker	Ogle County Board	022	Evening Scoping Meeting	ML13269A006
		026	Letter	ML13263A221
Brent Baker	Byron Chamber and Employee of the Byron Bank	023	Evening Scoping Meeting	ML13269A006
Bruce Drawbridge	Vice President with CB&I, Chicago Bridge and Iron	024	Evening Scoping Meeting	ML13269A006
David Kraft	Nuclear Energy Information Service	025	Evening Scoping Meeting	ML13269A006
		027	Letter	ML13277A306
Alan Keller	Illinois Environmental Protection Agency	028	Letter	ML14113A544

1 Comments that are general or outside the scope of the environmental review for Byron license
2 renewal are not included here but can be found in the Scoping Summary Report (ADAMS
3 No. ML14041A334). To maintain consistency with the Scoping Summary Report, the unique
4 identifier used in that report for each comment is retained in this Appendix A with one exception.
5 One comment was originally placed under Meteorology, Air Quality, and Noise. During the
6 development of the draft SEIS, the comment was addressed better under Climate Change.
7 Comments addressed in this Appendix A are provided at the end of the Scoping Summary
8 Report.

9 Comments received during the scoping comment period applicable to this environmental review
10 were placed into categories, which are based on topics contained in the Byron draft
11 supplemental environmental impact statement (DSEIS). These categories and their
12 abbreviation codes are listed in Table A–2.

13 Table A-2 also includes a comment from the Illinois Environmental Protection Agency
14 concerning the renewal of the Byron Station that was received outside of the scoping period.

15 **Table A–2. Issue Categories**

16 *Comments were divided into the categories below, each with a unique abbreviation code.*

Code	Technical Issue
CC	Climate Change (formerly, Meteorology, Air Quality, and Noise)
AL	Alternatives to License Renewal of Byron
SO	Socioeconomic Impact of Byron
SW	Water Resource – Surface Water

Appendix A

1 The following pages contain the comments, identified by the commenter's ID, comment number,
2 and comment issue category, and the NRC staff response. Comments are presented in the
3 same order as listed in Table A-2.

4 **A.1.1. Climate Change (CC) (formerly Meteorology, Air Quality, and Noise (ME))**

5 **Comment:**

6 027-2 CC - The ER submitted by Exelon is incomplete in not providing evidence that it has
7 examined the projected effects of predicted Illinois climate disruption on future operations. NRC
8 regulations are inadequate for not requiring this examination.

9 Current climate models suggest that Illinois will gradually assume a climate resembling that of
10 East Texas or Mississippi by mid-Century (within the period of operational life extension of
11 Byron), depending on whether one is running a low- or high- emissions model. Summer
12 temperatures are expected to increase on average from 3.30 to 8.60 F. While total precipitation
13 is expected to remain about the same, seasonal variation will increase, and frequency of heavy
14 precipitation events-measured in terms of number of days per year with more than 2 inches of
15 rain, and annual maximum 24-hr, 5-day and 7-day rainfall totals-is likely to continue to increase,
16 particularly closer to the Great Lakes, a factor which will have implications in the Comments
17 below.

18 The implications of these projections do not seem to be incorporated into the ER analysis
19 provided by Exelon, which invariably result in the conclusion of "small" impact. The ER clearly
20 states that the Rock River is a "small river" by definition. Make-up water for the mechanical draft
21 cooling tower system relies on the Rock River. Decreased volume and flow rates expected
22 under projected climate disruption models for Illinois could have an adverse effect on the
23 MDCT's ability to function. Since this system is dedicated to cooling the safety-related portions
24 of the plant, this could have serious consequences; but this is not evidenced in the conclusions
25 Exelon arrives at.

26 Exelon's historic penchant to request license variances on water use and thermal discharge (not
27 a factor at Byron) from IEPA suggests the possibility for greater effect than is characterized in
28 the Exelon ER document. The alternative would be curtailment of operation, which also does
29 not appear factored into the Exelon ER in any manner.

30 Recommendation: NRC should require a more thorough projection of water use at Byron, based
31 on the best possible climate modeling for Illinois between now and mid-century. Because this
32 variation in climate disruption and its effects are local/regional, it falls outside the scope of a
33 generic analysis or regulation.

34 **Response:** *This comment expresses concern over climate change projections and impacts as*
35 *a result of climate change on operations of Byron. The commenter specifically identifies*
36 *averaged climate change projections provided in the 2009 U.S. Global Climate Change*
37 *Research Program report and Hayhoe et al. 2010 for Illinois for the 2040 through 2059*
38 *timeframe and 2080 to 2099 timeframe. The NRC has evaluated the potential impacts of*
39 *climate change upon the affected resources during the Byron license renewal term (2024*
40 *through 2044 for Unit 1 and 2026 through 2046 for Unit 2) in Section 4.15.3, "Greenhouse Gas*
41 *Emissions and Climate Change," of this draft SEIS.*

42 *In informing potential climate change impacts, the NRC staff utilized, among various resources,*
43 *consensus information from both the 2009 and most recent 2014 U.S. Global Change Research*
44 *Program report and the National Oceanic and Atmospheric Administration's 2013 climate*
45 *change report. Section 4.15.3 of the SEIS discusses climate projections for the 2021 through*
46 *2050 timeframe, which is appropriate given Byron's license renewal term. Section 4.15.3*

1 describes the temperature and precipitation trends in the Midwest region, where Byron is
 2 located. Specifically, for the license renewal period of Byron and for the State of Illinois, climate
 3 model simulations (from 2021 and 2050 relative to the reference period (1971 to 1999)) indicate
 4 an increase in annual mean temperature in the Midwest region from 2.5 to 3.5 °F (1.5 to 2.1 °C),
 5 an increase in summertime mean temperatures of 3 °F (1.6 °C), and a 0 to 3 percent increase in
 6 annual mean precipitation with fall, winter, and spring seasons experiencing precipitation
 7 change increases and the summer season experiencing a decrease in precipitation. However,
 8 these changes in precipitation were not significant, and the models indicate changes that are
 9 less than normal year-to-year variations and projected summertime temperature increases
 10 displayed a wide range in temperature ranging in an increase of 1.5 to 5.5 °F (0.76 to 2.98°C)
 11 (Kunkel et al. 2013).

12 Potential climate change impacts to water resources are discussed in Section 4.15.3.2, the
 13 impacts to the Rock River from continued operation in Section 4.5.1, and climate change
 14 impacts specific to the Rock River in Section 4.16.3.1. However, the impacts of climate change
 15 on operations and safety at Byron, as the commenter raises, are addressed as part of the
 16 NRC's ongoing reactor oversight process. The NRC evaluates new information that could affect
 17 the safety of operating nuclear power plants, such as changes in the operating environment, on
 18 an ongoing basis to determine if any changes are needed at existing plants. This ongoing
 19 reactor oversight process is separate and distinct from the license renewal process, which is
 20 focused on managing the effects of aging on systems, structures, and components during the
 21 period of extended operation.

22 Concerns about the adequacy of NRC regulations may be raised in a petition that asks the NRC
 23 to develop, change, or rescind a rule by filing a petition for rulemaking in accordance with the
 24 regulations in Title 10 of the Code of Federal Regulations (10 CFR) 2.802, "Petition for
 25 rulemaking." Before filing a petition for rulemaking, a potential rulemaking petitioner may
 26 consult with the NRC concerning questions about NRC regulations and rulemaking petition
 27 procedures by calling the Rules and Directives Branch at 301-415-7163 or toll-free at
 28 800-368-5642 or by writing to the following address:

29 Chief
 30 Rules and Directives Branch
 31 Division of Administrative Services
 32 Office of Administration
 33 U.S. Nuclear Regulatory Commission
 34 Washington, DC 20555-0001

35 **A.1.2. Socioeconomic Impact of Byron (SO)**

36 **Comment:**

37 027-3 SO Analysis of socio-economic impacts are incomplete. No analysis of impacts of early
 38 or unexpected closure are considered or provided.

39 The Exelon ER documents a significant tax impact for the presence of the Byron Nuclear
 40 Station, yet only addresses the positive impacts. No mention or analysis of negative impacts
 41 resulting from abrupt, planned, or unexpected early closure of Byron is presented. This is a
 42 significant omission.

43 According to the Exelon ER Byron represents nearly 26% of the Ogle County total tax base,
 44 roughly \$30 million annually for the years 2008 through 2010. It also accounts for upwards of
 45 73% of Byron Unit 226 School District's adjusted property tax levy. These are not insignificant

Appendix A

1 amounts. Their abrupt disappearance would wreak economic havoc on the affected
2 governmental and essential service entities' ability to operate.

- 3 • The ER either fails to recognize or mention at all some of the possible events
4 that could result in such a situation:
- 5 • Unexpected major accident, resulting in immediate and presumably
6 premature closure
- 7 • NRC ordered shut down
- 8 • Exelon's unilateral decision to close the plant on economic or other grounds,
9 as it did at Zion, resulting in an immediate loss of about 55% of Zion's tax
10 base
- 11 • Devaluation through sale, as occurred at the Clinton station, resulting in
12 enormous loss of tax base
- 13 • Eventual old-age, license expiration closure (the outcome most hoped for)

14 Exelon even provides a possible indication of the kinds of circumstances that would lead it to
15 close Byron on economic grounds. Section 3.2 on Refurbishment indicates that Exelon is well
16 aware that Byron Unit 2 may need a steam generator replacement during the extended
17 operational lifetime. It is also tracking the potential for reactor vessel head replacements at its
18 operating PWRs at both Byron and Braidwood. Should either or both of these conditions
19 emerge at a time of deflated energy prices, or at a time Exelon acknowledges might occur as
20 early as 2024 when renewables are much more cost competitive and approaching base load
21 capabilities (Sec. 7.2, page 7-9), or as the result of multi-season drought curtailing water
22 availability - Exelon being a business will certainly make the calculations it made when it closed
23 Zion, and decide if Byron should continue to operate.

24 In this omission the ER makes the same mistake the U.S. Government made when it invaded
25 Iraq - it had no exit strategy. To simply assume that the only socio-economic effects of Byron's
26 presence will be positive ones is simply irrational.

27 Recommendation: Planning for some kind of eventual closure must be made long before it
28 happens to minimize economic and service disruptions to the entities whose tax base will be
29 affected. Debate about the license extension serves as a good reminder of this fact, and an
30 opportunity to take action. We recommend that dependent governmental and taxing entities
31 begin formal negotiations with Exelon to establish an escrowed "closure mitigation fund," based
32 on some mutually agreeable assessment and payment structure, so that dependent entities will
33 have some kind of temporary funds available to soften the economic blow of closure, and not
34 radically disrupt essential services.

35 **Response:** *With the exception of an unexpected major accident and NRC-ordered shutdown*
36 *for safety reasons, the possible events leading to the closure of Byron identified in this comment*
37 *involve energy planning decisions that would be made by Exelon and state officials. The NRC*
38 *has no role in these energy planning decisions. Also, the closure of Byron could occur at any*
39 *time, including upon the expiration of either the current or renewed operating license.*

40 *Information about Exelon's tax payments is described in Section 3.10.5, "Tax Revenue" in the*
41 *draft SEIS, and the socioeconomic impacts of station closure and the termination of reactor*
42 *operations caused by the expiration of the Byron operating license is described as part of the*
43 *"no action" alternative in the socioeconomic impacts of license renewal section in Chapter 4 in*
44 *the draft SEIS, specifically Section 4.10.2. The impacts of closing and decommissioning a*
45 *nuclear power plant are also described in the "Generic Environmental Impact Statement on*
46 *Decommissioning of Nuclear Facilities: Regarding the Decommissioning of Nuclear Power*

1 *Reactors” (NUREG–0586) (NRC 2002). The environmental consequences of decommissioning*
 2 *Byron itself would be during decommissioning.*

3 *In regards to what is to be discussed in the ER, 10 CFR 51.45(c) states,*

4 *Environmental reports prepared at the license renewal stage under § 51.53(c)*
 5 *need not discuss the economic or technical benefits and costs of either the*
 6 *proposed action or alternatives except if these benefits and costs are either*
 7 *essential for a determination regarding the inclusion of an alternative in the range*
 8 *of alternatives considered or relevant to mitigation. In addition, environmental*
 9 *reports prepared under § 51.53(c) need not discuss issues not related to the*
 10 *environmental effects of the proposed action [license renewal] and its*
 11 *alternatives.*

12 *In Section 4.10.2, “No-Action Alternative,” under socioeconomic impacts, the NRC*
 13 *determined that not renewing the operating licenses and terminating reactor operations*
 14 *could have a noticeable impact on socioeconomic conditions in the communities located*
 15 *near Byron. Specifically, there would be the loss of jobs and income for individuals*
 16 *working at or providing services to Byron, as well as reduced tax revenue in affected tax*
 17 *jurisdictions from the termination of power plant operations. These socioeconomic*
 18 *impacts could range from SMALL to LARGE, depending on the jurisdiction.*

19 **A.1.3. Alternatives to License Renewal of Byron (AL)**

20 **Comment:**

21 027-5 AL Recommendation: Order Exelon to re-examine its Section 7 comparisons,
 22 incorporating: 2.) better data on the capabilities of wind and solar, based on expected
 23 improvements in technology, or better and more optimal use decisions...

24 **Response:** *Chapter 2 of the draft SEIS describes the alternatives that are discussed further in*
 25 *Chapter 4 and describes the alternatives that were considered but dismissed.*

26 *Specifically, in evaluating alternatives to license renewal, the NRC staff first selects energy*
 27 *technologies or options currently in commercial operation, as well as some technologies not*
 28 *currently in commercial operation but likely to be commercially available by the time the current*
 29 *Byron operating licenses expire in 2024 and 2026.*

30 *Second, the NRC staff screens the alternatives to remove those that cannot meet future system*
 31 *needs. Then, the remaining options are screened to remove those alternatives whose costs or*
 32 *benefits do not justify inclusion in the range of reasonable alternatives. Any alternatives*
 33 *remaining, then, constitute alternatives to the proposed action that the NRC staff evaluates in*
 34 *depth throughout Chapter 4.*

35 *In Section 2.3.2, solar power was considered as a potential alternative, but dismissed because*
 36 *the NRC staff considers it unlikely that current solar power technologies could serve as*
 37 *baseload power sufficient to replace Byron’s output. In Section 2.3.4, wind power was*
 38 *considered as a potential alternative, but dismissed as unreasonable given the amount of wind*
 39 *capacity necessary to replace Byron and the intermittency of wind power. Solar and wind power*
 40 *were considered in combination with a natural gas combined-cycle facility. This combination*
 41 *alternative is described in Section 2.2.2.4 and the impact of this combination alternative is*
 42 *described under each resource area in Chapter 4.*

1 **A.1.4. Water Resources - Surface Water (comment not identified in scoping summary**
2 **report)**

3 **Comment:**

4 028-1 SW This Agency received a request on July 5, 2012 from Exelon Generating Company
5 requesting necessary comments concerning the renewal of the Nuclear Regulatory Commission
6 operating licenses for the Byron Generating Stations Units 1 and 2 in Ogle County. We offer the
7 following comments.

8 This Agency hereby issues certification under Section 401 of the Clean Water Act (PL 95-217),
9 subject to the applicant's compliance with the following conditions:

10 (1) The applicant shall be responsible for obtaining NPDES permits required for wastewater or
11 stormwater discharges to waters of the State from the proposed activity.

12 (2) This certification does not cover future activities that require a federal authorization under
13 Section 404 of the Clean Water Act.

14 This certification becomes effective when the Nuclear Regulatory Commission includes the
15 above conditions # 1 through # 2 as conditions of the requested license issued under the Atomic
16 Energy Act of 1954.

17 This certification does not grant immunity from any enforcement action found necessary by this
18 Agency to meet its responsibilities in prevention, abatement, and control of water pollution.

19 **Response:** *This comment provided input (or data) for the staff's environmental analysis of*
20 *water resource impacts of Byron on local and regional communities. This comment addresses*
21 *Clean Water Act (CWA) Section 401 certification of the Byron discharge. The staff discusses*
22 *water resource impacts, specifically the Section 401 certification in Section 3.5.1 of Chapter 3 of*
23 *the SEIS.*

24 *On May 12, 2014, Exelon updated its application (Exelon 2014) to inform the staff that by letter*
25 *to the NRC dated July 5, 2013 (IEPA 2014), the IEPA issued the CWA Section 401 certification*
26 *for Byron operation during the license renewal.*

27 *The NRC understands the importance of the CWA and a delegated State's role in implementing*
28 *the statute. As early as 1984, the Commission recognized that in revising its regulations, NRC*
29 *licenses are subject to conditions deemed imposed by the CWA as a matter of law and that the*
30 *NRC need not duplicate EPA's or a delegated State agency's water quality reviews.¹⁴ To*
31 *explicitly recognize that conditions are deemed imposed by the CWA and to remove the need to*
32 *undertake amendments to incorporate conditions imposed by statute that could be subject to*
33 *frequent changes by certifying States, the Commission added 10 CFR 50.54(aa)¹⁵ to specifically*
34 *provide that each 10 CFR Part 50 "license shall be subject to all conditions deemed imposed as*
35 *a matter of law by section 401(a)(2) and 401(d) of the CWA (33 U.S.C.A. 1341(a)(2) and (d)), as*
36 *amended)." To keep informed of the environmental effects of NRC licensing actions, the*
37 *Commission relies on reporting requirements of National Pollutant Discharge Elimination*
38 *System (NPDES) permits to alert the NRC of environmental effects of NRC licensing action. As*
39 *the Commission stated, "The NRC's role in the water quality area is limited to regulating*
40 *radiological discharges into aquatic bodies and NEPA matters such as weighing aquatic impacts*

¹⁴49 FR. 9352, 9359-60. "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions and Related Conforming Amendments." March 12, 1984.

¹⁵49 FR. 9352, 9360.

1 *in NEPA analyses which NRC is required to make before reaching a major Federal licensing*
 2 *decision.*¹⁶

3 *Because the two 401 certification conditions are license requirements either because they are*
 4 *imposed as a matter of law or they state existing statutory provisions, no further NRC action is*
 5 *needed with respect to these two conditions. Specifically, (1) Exelon must obtain a CWA*
 6 *Section 402 (NPDES) permit from the State in accordance with 33 U.S.C. § 1342, and*
 7 *(2) a 401 certification does not authorize activities that require an authorization under*
 8 *Section 404 of the CWA, 33 U.S.C. § 1344 (i.e., the permits for discharges of dredged or fill*
 9 *material, which are issued by the U.S. Army Corps of Engineers). Appendix B, paragraph 3.2 of*
 10 *the current Byron licenses further requires that Exelon provide the NRC copies of any NPDES*
 11 *permit or State certification (or changes to those documents) within 30 days of approval. If the*
 12 *licenses are renewed, this requirement will be carried over to the renewed licenses for Byron*
 13 *Units 1 and 2.*

14 **A.2 References**

15 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
 16 protection regulations for domestic licensing and related regulatory functions.”

17 78 FR 47800. U.S. Nuclear Regulatory Commission. “License Renewal Application for Byron
 18 Station, Units 1 and 2; Exelon Generation Company, LLC.” *Federal Register*
 19 78(151):47800-47802. August 6, 2013.

20 [Exelon] Exelon Generation Company, LLC. 2013. Byron Station, Units 1 and 2, License
 21 Renewal Application, Appendix E, Applicant’s Environmental Report, Operating License
 22 Renewal Stage. May 29, 2013. Agencywide Documents Access and Management System
 23 (ADAMS) Nos. ML13155A422 and ML13155A423.

24 [Exelon] Exelon Generating Company, LLC. 2014, Update to Chapter 9 of Byron and
 25 Braidwood Stations, Units 1 and 2 License Renewal Application, Byron Station Applicant’s
 26 Environmental Report. May 12, 2014. ADAMS No. ML14132A141.

27 [IEPA] Illinois Environmental Protection Agency. 2014. Illinois Environmental Protection Agency,
 28 Certification under Section 401 of the Clean Water Act (CWA). July 5, 2014. ADAMS
 29 No. ML14113A544.

30 Kunkel KE, Stevens LE, Stevens SE, Sun L (North Carolina State University and National
 31 Climatic Data Center), Janssen E, Wuebbles D, Hilberg SD, Timlin MS, Stoecker L,
 32 Westcott NE (University of Illinois at Urbana–Champaign), et al. 2013. *Regional Climate Trends*
 33 *and Scenarios for the U.S. National Climate Assessment, Part 3. Climate of the Midwest U.S.*
 34 Washington, DC: National Oceanic and Atmospheric Administration (NOAA). NOAA Technical
 35 Report NESDIS 142-3. January 2013. 103 p. Available at
 36 <[http://www.nesdis.noaa.gov/technical_reports/](http://www.nesdis.noaa.gov/technical_reports/NOAA_NESDIS_Tech_Report_142-3-Climate_of_the_Midwest_U.S.pdf)
 37 [NOAA NESDIS Tech Report 142-3-Climate of the Midwest U.S.pdf](http://www.nesdis.noaa.gov/technical_reports/NOAA_NESDIS_Tech_Report_142-3-Climate_of_the_Midwest_U.S.pdf)>.

38 Melillo JM (Marine Biological Laboratory), Richmond TC (Van Ness Feldman, LLP), Yohe GW
 39 (Wesleyan University), editors. 2014. *Climate Change Impacts in the United States: The Third*
 40 *National Climate Assessment*. Washington, DC: U.S. Global Change Research Program.
 41 May 2014. 841 p. ADAMS No. ML14129A233.

¹⁶49 FR. 9352, 9380.

Appendix A

- 1 [NRC] U.S. Nuclear Regulatory Commission. 2002. Generic Environmental Impact Statement
2 for Decommissioning of Nuclear Facilities, Supplement 1: Regarding the Decommissioning of
3 Nuclear Power Reactors. NUREG-0586, Supplement 1, Vols. 1 and 2. Office of Nuclear
4 Reactor Regulation, Washington, D.C. November 2002. ADAMS Nos. ML023470327,
5 ML023500228, ML023470304, ML023500295.
- 6 [NRC] U.S. Nuclear Regulatory Commission. 2013. Generic Environmental Impact Statement
7 for License Renewal of Nuclear Plants. Washington, DC: NRC. NUREG-1437, Revision 1.
8 June 30, 2013. ADAMS No. ML13107A023.
- 9 [NRC] U.S. Nuclear Regulatory Commission. 2014. Summary Of Public Scoping Meetings
10 Conducted Related To The Review Of The Byron Nuclear Station, License Renewal Application
11 (TAC NOS. MF1790 AND MF1791). February 7, 2014. ADAMS No. ML13269A006

1 **APPENDIX B**
2 **APPLICABLE LAWS, REGULATIONS, AND OTHER REQUIREMENTS**

1 **B. APPLICABLE LAWS, REGULATIONS, AND OTHER**
2 **REQUIREMENTS**

3 There are a number of Federal laws and regulations that affect environmental protection, health,
4 safety, compliance, and consultation at every nuclear power plant licensed by the U.S. Nuclear
5 Regulatory Commission (NRC). Certain Federal environmental requirements have been
6 delegated to state authorities for enforcement and implementation. Furthermore, states have
7 also enacted laws to protect public health and safety and the environment. It is the NRC's policy
8 to ensure nuclear power plants are operated in a manner that provides adequate protection of
9 public health and safety and protection of the environment through compliance with applicable
10 Federal and state laws, regulations, and other requirements.

11 The requirements that may be applicable to the operation of NRC-licensed nuclear power plants
12 encompass a broad range of Federal laws and regulations, addressing environmental, historic
13 and cultural, health and safety, transportation, and other concerns. Generally, these laws and
14 regulations are relevant to how the work involved in performing a proposed action would be
15 conducted to protect workers, the public, and environmental resources. Some of these laws
16 and regulations require permits or consultation with other Federal agencies or state, tribal, or
17 local governments.

18 The Atomic Energy Act of 1954 (as amended) (AEA) (42 United States Code (U.S.C.) § 2011 et
19 seq.) authorizes the U.S. Nuclear Regulatory Commission (NRC) to enter into agreement with
20 any state to assume regulatory authority for certain activities (see 42 U.S.C. § 2021). For
21 example, through the Agreement State Program, Illinois assumed regulatory responsibility over
22 certain byproduct, source, and quantities of special nuclear materials not sufficient to form a
23 critical mass. The Illinois Emergency Management Agency (IEMA), Division of Nuclear Safety
24 administers several programs to protect citizens and the environment, including: a
25 comprehensive monitoring system for the 11 operating nuclear power reactors in Illinois,
26 inspection and regulation of radioactive materials licensees and x-ray machines, and oversight
27 of cleanup efforts at sites contaminated with radioactive materials (IEMA undated).

28 In addition to carrying out some Federal programs, state legislatures develop their own laws.
29 State statutes supplement, as well as implement, Federal laws for protection of air, water
30 quality, and groundwater. State legislation may address solid waste management programs,
31 locally rare or endangered species, and historic and cultural resources.

32 The Clean Water Act (33 U.S.C. § 1251 et seq., herein referred to as CWA) allows for primary
33 enforcement and administration through state agencies, given that the state program is at least
34 as stringent as the Federal program. The state program must conform to the CWA and to the
35 delegation of authority for the Federal National Pollutant Discharge Elimination System
36 (NPDES) program from the U.S. Environmental Protection Agency (EPA) to the state. The
37 primary mechanism to control water pollution is the requirement for direct dischargers to obtain
38 an NPDES permit, or, as is the case for Illinois, the authority has been delegated from the EPA,
39 a State Pollutant Discharge Elimination System permit, under the CWA.

40 One important difference between Federal regulations and certain state regulations is the
41 definition of waters regulated by the state. Certain state regulations may include underground
42 waters, whereas the CWA only regulates surface waters. The Illinois Environmental Protection
43 Agency (IEPA) Bureau of Water, Water Pollution Control conducts the numerous programs,
44 including permit programs and surface water quality monitoring and assessment programs, to
45 protect and enhance the quality of the state's surface waters (IEPA undated).

Appendix B

1 **B.1. Federal and State Requirements**

2 Byron Station, Units 1 and 2 are subject to Federal and State requirements. Table B-1 lists the
3 principal Federal and State regulations and laws that are used or mentioned in this
4 supplemental environmental impact statement (SEIS) for the Byron Nuclear Station.

1

Table B–1. Federal and State Requirements

Law/regulation	Requirements
Current operating license and license renewal	
Atomic Energy Act (AEA), 42 U.S.C. §2011 et seq.	The 1954 Atomic Energy Act (AEA), as amended, and the Energy Reorganization Act of 1974 (42 U.S.C. 5801 et seq.) give the NRC the licensing and regulatory authority for nuclear energy uses within the commercial sector. These regulations give the NRC responsibility for licensing and regulating commercial uses of atomic energy and allow the NRC to establish dose and concentration limits for protection of workers and the public for activities under NRC jurisdiction. The NRC implements its responsibilities under the AEA through regulations set forth in Title 10 of the <i>Code of Federal Regulations</i> (10 CFR).
National Environmental Policy Act of 1969, as amended (NEPA). 42 U.S.C. 4321, et seq.	The National Environmental Policy Act (NEPA) requires Federal agencies to integrate environmental values into their decisionmaking process by considering the environmental impacts of proposed Federal actions and reasonable alternatives to those actions. NEPA establishes policy, sets goals (in Section 101), and provides means (in Section 102) for carrying out the policy. Section 102(2) contains action-forcing provisions to ensure that Federal agencies follow the letter and spirit of the Act. For major Federal actions significantly affecting the quality of the human environment, Section 102(2)(C) of NEPA requires Federal agencies to prepare a detailed statement that includes the environmental impacts of the proposed action and other specified information.
Title 10 of the <i>Code of Federal Regulations</i> (10 CFR), <i>Energy</i> , Part 51	Regulations in 10 CFR Part 51, “Environmental protection regulations for domestic licensing and related regulatory functions,” contain environmental protection regulations applicable to the NRC’s domestic licensing and related regulatory functions.
10 CFR Part 54	Regulations in 10 CFR Part 54, “Requirements for renewal of operating licenses for nuclear power plants,” govern the issuance of renewed operating licenses and renewed combined licenses for nuclear power plants licensed pursuant to Sections 103 or 104b of the AEA and Title II of the Energy Reorganization Act of 1974 (88 Stat. 1242). The regulations focus on managing adverse effects of aging. The rule is intended to ensure that important systems, structures, and components will maintain their intended functions during the period of extended operation.
10 CFR Part 50	Regulations in 10 CFR Part 50, “Domestic licensing of production and utilization facilities,” are NRC regulations issued under the AEA, as amended (68 Stat. 919), and Title II of the Energy Reorganization Act of 1974 (88 Stat. 1242) to provide for the licensing of production and utilization facilities. This part also gives notice to all persons who knowingly supply—to any licensee, applicant, contractor, or subcontractor—components, equipment, materials, or other goods or services, that relate to a licensee’s or applicant’s activities subject to this part that they may be individually subject to NRC enforcement action for violation of 10 CFR 50.5.

Appendix B

Law/regulation	Requirements
Air quality protection	
Clean Air Act (CAA), 42 U.S.C. §7401 et seq.	<p>The Clean Air Act (CAA) is intended to “protect and enhance the quality of the nation’s air resources so as to promote the public health and welfare and the productive capacity of its population.” The CAA establishes regulations to ensure maintenance of air quality standards and authorizes individual states to manage permits. Section 118 of the CAA requires each Federal agency, with jurisdiction over properties or facilities engaged in any activity that might result in the discharge of air pollutants, to comply with all Federal, state, inter-state, and local requirements with regard to the control and abatement of air pollution. Section 109 of the CAA directs the U.S. Environmental Protection Agency (EPA) to set National Ambient Air Quality Standards (NAAQS) for criteria pollutants. The EPA has identified and set NAAQS for the following criteria pollutants: particulate matter, sulfur dioxide, carbon monoxide, ozone, nitrogen dioxide, and lead. Section 111 of the CAA requires establishment of national performance standards for new or modified stationary sources of atmospheric pollutants. Section 160 of the CAA requires that specific emission increases must be evaluated before permit approval to prevent significant deterioration of air quality. Section 112 requires specific standards for release of hazardous air pollutants (including radionuclides). These standards are implemented through plans developed by each state and approved by the EPA. The CAA requires sources to meet standards and obtain permits to satisfy those standards. Nuclear power plants may be required to comply with the CAA Title V, Sections 501–507, for sources subject to new source performance standards or sources subject to National Emission Standards for Hazardous Air Pollutants. Emissions of air pollutants are regulated by the EPA in 40 CFR Parts 50 to 99.</p>
Illinois Administrative Code (IAC), Title 35, “Environmental Protection,” Subtitle B, “Air Pollution,” Chapter I, “Pollution Control Board,” Subchapter a, “Permits and General Provisions,” Part 201, “Permits and General Provisions”	<p>This part of the IAC sets standards for air emissions from auxiliary boilers, emergency generators, radwaste volume reduction system, cooling towers, and ancillary operations.</p>

Law/regulation	Requirements
Water resources protection	
<p>Clean Water Act (CWA), 33 U.S.C. § 1251 et seq., and the NPDES (40 CFR 122)</p>	<p>The CWA was enacted to “restore and maintain the chemical, physical, and biological integrity of the Nation’s water.” The Act requires all branches of the Federal Government, with jurisdiction over properties or facilities engaged in any activity that might result in a discharge or runoff of pollutants to surface waters, to comply with Federal, state, inter-state, and local requirements. As authorized by the CWA, the National Pollutant Discharge Elimination System (NPDES) permit program controls water pollution by regulating point sources that discharge pollutants into waters of the United States. The NPDES program requires all facilities that discharge pollutants from any point source into waters of the United States to obtain an NPDES permit. A nuclear power plant may also participate in the NPDES General Permit for Industrial Stormwater due to stormwater runoff from industrial or commercial facilities to waters of the United States. EPA is authorized under the CWA to directly implement the NPDES program; however, EPA has authorized many states to implement all or parts of the national program. Section 401 of the CWA requires states to certify that the permitted discharge would comply with all limitations necessary to meet established state water quality standards, treatment standards, or schedule of compliance.</p> <p>The U.S. Army Corps of Engineers is the lead agency for enforcement of CWA wetland requirements (33 CFR Part 320). Under Section 401 of the CWA, the EPA or a delegated state agency has the authority to review and approve, condition, or deny all permits or licenses that might result in a discharge to waters of the State, including wetlands.</p>
<p>Coastal Zone Management Act of 1972, as amended (16 U.S.C. 1451 et seq.)</p>	<p>Congress enacted the <i>Coastal Zone Management Act (CZMA)</i> in 1972 to address the increasing pressures of over-development upon the nation’s coastal resources. The National Oceanic and Atmospheric Administration administers the Act. The CZMA encourages states to preserve, protect, develop, and, where possible, restore or enhance valuable natural coastal resources such as wetlands, floodplains, estuaries, beaches, dunes, barrier islands, and coral reefs, as well as the fish and wildlife using those habitats. Participation by states is voluntary. To encourage states to participate, the CZMA makes Federal financial assistance available to any coastal state or territory, including those on the Great Lakes, that are willing to develop and implement a comprehensive coastal management program.</p>
<p>IAC, Title 35, “Environmental Protection,” Subtitle C, “Water Pollution,” Chapter I, “Pollution Control Board,” Part 309, “Permits”</p>	<p>This part of the Illinois Administrative Code implements the NPDES program under CWA.</p>
<p>Wild and Scenic Rivers Act, 16 U.S.C. § 1271 et seq.</p>	<p>The Wild and Scenic River Act created the National Wild and Scenic Rivers System, which was established to protect the environmental values of free flowing streams from degradation by impacting activities, including water resources projects.</p>
<p>415 Illinois Compiled Statutes (ILCS) 5, “Environmental Protection Act,” Title III, “Water Pollution”</p>	<p>This part of the Illinois Compiled Statutes sets forth state standards for water pollution.</p>

Appendix B

Law/regulation	Requirements
Waste management and pollution prevention	
Resource Conservation and Recovery Act (RCRA), 42 U.S.C. § 6901 et seq.	The Resource Conservation and Recovery Act (RCRA) requires the EPA to define and identify hazardous waste; establish standards for its transportation, treatment, storage, and disposal; and require permits for persons engaged in hazardous waste activities. Section 3006 (42 U.S.C. 6926) allows states to establish and administer these permit programs with EPA approval. EPA regulations implementing the RCRA are found in 40 CFR Parts 260 through 283. Regulations imposed on a generator or on a treatment, storage, and/or disposal facility vary according to the type and quantity of material or waste generated, treated, stored, and/or disposed. The method of treatment, storage, and/or disposal also impacts the extent and complexity of the requirements.
Pollution Prevention Act, 42 U.S.C. § 13101 et seq.	The Pollution Prevention Act establishes a national policy for waste management and pollution control that focuses first on source reduction, then on environmental issues, safe recycling, treatment, and disposal.
10 CFR Part 20,	Regulations in 10 CFR Part 20, “Standards for protection against radiation,” establish standards for protection against ionizing radiation resulting from activities conducted under licenses issued by the Nuclear Regulatory Commission. These regulations are issued under the AEA and the Energy Reorganization Act of 1974, as amended. The purpose of these regulations is to control the receipt, possession, use, transfer, and disposal of licensed material by any licensee in such a manner that the total dose to an individual (including doses resulting from licensed and unlicensed radioactive material and from radiation sources other than background radiation) does not exceed the standards for protection against radiation prescribed in the regulations in this part.
IAC Title 35, “Environmental Protection,” Subtitle G, “Waste Disposal,” Chapter I, “Pollution Control Board,” Subchapter c, “Hazardous Waste Operating Requirements,” Part 722, “Standards Applicable to Generators of Hazardous Waste”	This part of the IAC establishes standards for generators of hazardous waste.
IAC Title 35, “Environmental Protection,” Subtitle C, “Water Pollution,” Chapter II, “Environmental Protection Agency,” Part 391, “Design Criteria for Sludge Application on Land”	This part of the IAC presents criteria for transporting, storing, and applying sludge on land in an environmentally acceptable manner. In addition, it identifies methods of sludge transportation, handling, storage, application and monitoring to control potential environmental problems.

Law/regulation	Requirements
IAC Title 32, “Energy,” Chapter II, “Illinois Emergency Management Agency,” Subchapter d, “Low Level Radioactive Waste/Transportation,” Part 609, “Access to Facilities for Treatment, Storage, or Disposal of Low-Level Radioactive Waste”	This part of the IAC establishes one of the systems for the regulation of the use of facilities in the State of Illinois to: (1) collect, store, treat or dispose of low-level radioactive waste; (2) maintain a data base as to the location of all such waste in the State of Illinois; and (3) implement some of the requirements, prohibitions and mandates of the Compact, the Radioactive Waste Compact Enforcement Act [45 ILCS 141], the Radioactive Waste Tracking and Permitting Act [420 ILCS 37] and the Illinois Low-Level Radioactive Waste Management Act [420 ILCS 20]. This Part establishes a system for monitoring and tracking shipments of low-level radioactive waste into, out of or within the State of Illinois for the purpose of tracking the points of origin of the shipments, as transported to the places of destination of the shipments. This Part establishes an enforcement and verification system directed to the movements of low-level radioactive waste into, out of or within the State of Illinois. This Part applies to any generator, broker, owner or operator of any treatment or disposal facility, or to any person who sends low-level radioactive waste into, within or out of the State of Illinois.
Protected species	
Endangered Species Act (ESA), 16 U.S.C. § 1531 et seq.	The Endangered Species Act (ESA) was enacted to prevent the further decline of endangered and threatened species and to restore those species and their critical habitats. Section 7 of the Act requires Federal agencies to consult with the U.S. Fish and Wildlife Service or the National Marine Fisheries Service (NMFS) on Federal actions that may affect listed species or designated critical habitats.
Magnuson–Stevens Fishery Conservation and Management Act (MSA), (16 U.S.C. §§ 1801-1884) as amended	The Magnuson-Stevens Fishery Conservation and Management Act (MSA) governs marine fisheries management in U.S. Federal waters. The Act created eight regional fishery management councils and includes measures to rebuild overfished fisheries, protect essential fish habitat, and reduce bycatch. Under Section 305 of the Act, Federal agencies are required to consult with NMFS for any Federal actions that may adversely affect essential fish habitat.
Historic preservation and cultural resources	
National Historic Preservation Act (NHPA), 16 U.S.C. § 470 et seq.	The National Historic Preservation Act (NHPA) was enacted to create a national historic preservation program, including the <i>National Register of Historic Places</i> and the Advisory Council on Historic Preservation. Section 106 of the Act requires Federal agencies to take into account the effects of their undertakings on historic properties. The Advisory Council on Historic Preservation regulations implementing Section 106 of the Act are found in 36 CFR Part 800. The regulations call for public involvement in the Section 106 consultation process, including Indian Tribes and other interested members of the public, as applicable.

1 B.2. Operating Permits and Other Requirements

2 Table B–2 lists the permits and licenses issued by Federal, state, and local authorities for
3 activities at Byron.

Table B–2. Licenses and Permits

Permit	Number	Dates	Responsible Agency
Operating license	NPF-37	Issued: 02/14/1985 Expires: 10/31/2024	NRC
Operating license	NPF-66	Issued: 01/30/1987 Expires: 11/06/2026	NRC
National Pollutant Discharge Elimination System (NPDES) Permit	IL0048313	Issued: 01/24/2011 Expires: 12/31/2015	IEPA Division of Water Pollution Control
Water Pollution Control Permit	2011-EP-1250	Issued: 02/16/2011 Expires: 01/31/2016	IEPA Division of Water Pollution Control
Hazardous Materials Certificate of Registration	051713550083VX	Issued: 05/17/2013 Expires: 06/30/2016	U.S. Department of Transportation, Pipeline and Hazardous Materials Safety Administration
Federally Enforceable State Operating Permit (FESOP)	Application #78090018 9/11/2007; supplemented 12/10/2007 ID# 141820AA	Issued: 12/01/2001 Expires: 12/13/2007 ^(a)	IEPA Division of Air Pollution Control
Notification of Hazardous Waste Activity	ILD000806521	Not Applicable	IEPA Bureau of Land
Land application of sludge	2009-SC-2169-1	Issued: 04/20/2010 Expires: 05/31/2014 ^(b)	IEPA Bureau of Land
Waste tracking permit	IL-0105	Not Applicable	IEMA, Division of Nuclear Safety
License to deliver radioactive material	T-IL007-L12	Renewed annually	Tennessee Department of Environment and Conservation
Permit to deliver radioactive material	0110000032	Renewed annually	Utah Department of Environmental Quality

^(a) 415 Illinois Compiled Statutes 5/–, Title X, Permits, Sec. 39(x) establishes the timing for submitting a permit renewal. Specifically, as long as the renewal is submitted before the permit is expired, the current terms and conditions of the permit are extended until the final administrative action has been taken on the application for the renewal of the permit. Because Exelon Generation met this requirement, the permit is administratively extended (415 ILCS 5/39(x)).

^(b) The applicant is evaluating future land applications of the river sediment. A permit renewal application will be filed after the evaluation is completed.

Source: Exelon 2014

1 B.3. References

- 2 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic licensing of
3 production and utilization facilities.”
- 4 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
5 protection regulations for domestic licensing and related regulatory functions.”
- 6 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, “Requirements for
7 renewal of operating licenses for nuclear power plants.”
- 8 40 CFR Part 122. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 122,
9 “EPA administered permit programs: the National Pollutant Discharge Elimination System.”
- 10 49 CFR Part 107. *Code of Federal Regulations*, Title 49, *Transportation*, Part 107, “Hazardous
11 materials program procedures.”
- 12 49 U.S.C. 5108. *United States Code*. Title 49, Chapter 51, Part 5108, “Registration.”
- 13 [IAC] Illinois Administrative Code Title 32, Chapter II, Subchapter d, Part 609, “Access to
14 facilities for treatment, storage, or disposal of low-level radioactive waste.”
- 15 [IAC] Illinois Administrative Code Title 35, Subtitle B, Chapter I, Subchapter a, Part 201,
16 “Permits and general provisions.”
- 17 [IAC] Illinois Administrative Code Title 35, Subtitle C, Chapter I, Part 309, “Permits.”
- 18 [IAC] Illinois Administrative Code Title 35, Subtitle C, Chapter II, Part 391, “Design criteria for
19 sludge application on land.”
- 20 [IAC] Illinois Administrative Code Title 35, Subtitle G, Chapter I, Subchapter c, Part 722,
21 “Standards applicable to generators of hazardous waste.”
- 22 [IEMA] Illinois Emergency Protection Agency, Division of Nuclear Safety. Undated. Available
23 at: <<http://www.state.il.us/iema/dns.asp>> (accessed 14 May 2014).
- 24 [IEPA] Illinois Environmental Protection Agency, Bureau of Water. Undated. “Water Pollution
25 Control.” Available at: <<http://www.epa.state.il.us/water/index-wpc.html>> (accessed
26 14 May 2014).
- 27 415 ILCS 5/Tit. II. Illinois Compiled Statutes. Chapter 415, 5, “Environmental Protection Act,”
28 Title II, “Air pollution.”
- 29 415 ILCS 5/Tit. III. Illinois Compiled Statutes. Chapter 415, 5, “Environmental Protection Act,”
30 Title III, “Water pollution.”
- 31 [AEA] Atomic Energy Act of 1954, as amended. 42 U.S.C. §2011 et seq.
- 32 [CAA] Clean Air Act of 1963, as amended. 42 U.S.C. §7401 et seq.
- 33 [CWA] Clean Water Act of 1977, as amended. 33 U.S.C. § 1251 et seq.
- 34 [ESA] Endangered Species Act of 1973, as amended. 16 U.S.C. § 1531 et seq.
- 35 [Exelon] Exelon Generation Company. LLC. 2014. “Update to Chapter 9 of Byron and
36 Braidwood Stations, Units 1 and 2 License Renewal Application, Byron Station Applicant’s
37 Environmental Report.” May 12, 2014. Agencywide Documents Access and Management
38 System No. ML14132A141.
- 39 [FWCA] Fish and Wildlife Coordination Act of 1934, as amended. 16 U.S.C. § 661 et seq.
- 40 [MMPA] Marine Mammal Protection Act of 1972, as amended. 16 U.S.C. § 1361 et seq.

Appendix B

- 1 [MSA] Magnuson–Stevens Fishery Conservation and Management Act, as amended.
- 2 16 U.S.C. § 1801 et seq.
- 3 [NHPA] National Historic Preservation Act of 1966, as amended. 16 U.S.C. § 470 et seq.
- 4 Pollution Prevention Act of 1990. 42 U.S.C. § 13101 et seq.
- 5 [RCRA] Resource Conservation and Recovery Act of 1976, as amended. 42 U.S.C. § 6901
- 6 et seq.
- 7 Wild and Scenic Rivers Act, as amended. 16 U.S.C. § 1271 et seq.

1
2

APPENDIX C
CONSULTATION CORRESPONDENCE

1 **C. CONSULTATION CORRESPONDENCE**

2 **C.1. Section 7 Consultation**

3 **C.1.1. Federal Agency Obligations Under ESA Section 7**

4 As a Federal agency, the U.S. Nuclear Regulatory Commission (NRC) must comply with the
5 Endangered Species Act of 1973, as amended (16 *United States Code* (U.S.C.) § 1531 et seq.;
6 herein referred to as ESA), as part of any action authorized, funded, or carried out by the
7 agency, such as the proposed agency action that this supplemental environmental impact
8 statement (SEIS) evaluates: whether to issue renewed licenses for the continued operation of
9 Byron Station, Units 1 and 2 (Byron), for an additional 20 years beyond the current license
10 terms. Under section 7 of the ESA, the NRC must consult with the U.S. Fish and Wildlife
11 Service (FWS) and the National Marine Fisheries Service (NMFS) (referred to jointly as “the
12 Services” and individually as “Service”), as appropriate, to ensure that the proposed agency
13 action is not likely to jeopardize the continued existence of any endangered or threatened
14 species or result in the destruction or adverse modification of designated critical habitat.

15 The ESA and the regulations that implement ESA section 7 (Title 50 of the *Code of Federal*
16 *Regulations* (50 CFR) Part 402, “Interagency cooperation—Endangered Species Act of 1973,
17 as amended”) describe the consultation process that Federal agencies must follow in support of
18 agency actions. As part of this process, the Federal agency shall either request that the
19 Services provide a list of any listed or proposed species or designated or proposed critical
20 habitats that may be present in the action area or request that the Services concur with a list of
21 species and critical habitats that the Federal agency has created (50 CFR 402.12(c)). If it is
22 determined that any such species or critical habitats may be present, the Federal agency is to
23 prepare a biological assessment to evaluate the potential effects of the action and determine
24 whether the species or critical habitat are likely to be adversely affected by the action
25 (50 CFR 402.12(a); 16 U.S.C. § 1536(c)). Furthermore, biological assessments are required for
26 any agency action that is a “major construction activity” (50 CFR 402.12(b)), which the ESA
27 regulations define to include major Federal actions significantly affecting the quality of the
28 human environment under the National Environmental Policy Act of 1969, as amended
29 (42 U.S.C. § 4321 et seq.; herein referred to as NEPA) (50 CFR 402.02).

30 Federal agencies may fulfill their obligations to consult with the Services under ESA section 7
31 and to prepare a biological assessment in conjunction with the interagency cooperation
32 procedures required by other statutes, including NEPA (50 CFR 402.06(a)). In such cases, the
33 Federal agency should include the results of the ESA section 7 consultation in the NEPA
34 document (50 CFR 402.06(b)). Accordingly, Section D.1.2 describes the biological assessment
35 prepared for the proposed agency action evaluated in this SEIS, and Section D.1.3 describes
36 the chronology and results of the ESA section 7 consultation.

37 **C.1.2. Biological Assessment**

38 The NRC considers this SEIS to fulfill its obligation to prepare a biological assessment under
39 ESA section 7. Accordingly, the NRC did not prepare a separate biological assessment for the
40 proposed Byron license renewal.

41 Although the contents of a biological assessment are at the discretion of the Federal agency
42 (50 CFR 402.12(f)), the ESA regulations suggest information that agencies may consider for
43 inclusion. The NRC has considered this information in the following sections.

Appendix C

1 Section 3.8 describes the action area and the Federally listed and proposed species and
2 designated and proposed critical habitat that have the potential to be present in the action area.
3 This section includes information pursuant to 50 CFR 402.12(f)(1), (2), and (3).

4 Section 4.8 provides an assessment of the potential effects of the proposed Byron license
5 renewal on the species and critical habitat present and the NRC's effect determinations, which
6 are consistent with those identified in Section 3.5 of the *Endangered Species Consultation*
7 *Handbook* (FWS and NMFS 1998). The NRC also addresses cumulative effects and
8 alternatives to the proposed action. This section includes information pursuant to
9 50 CFR 402.12(f)(4) and (5).

10 **C.1.3. Chronology of ESA Section 7 Consultation**

11 Upon receipt of Exelon's license renewal application, the NRC staff considered whether any
12 Federally listed or proposed species or designated or proposed critical habitats may be present
13 in the action area (as defined at 50 CFR 402.02) for the proposed Byron license renewal. No
14 species under the NMFS's jurisdiction occur within the action area. Therefore, the NRC staff did
15 not consult with the NMFS. With respect to species under the FWS's jurisdiction, the NRC staff
16 compiled a list of ESA-protected species and critical habitats within the vicinity of the facility and
17 requested the FWS's concurrence with this list in accordance with the ESA section 7 regulations
18 at 50 CFR 402.12(c) in a letter dated August 8, 2013. The FWS concurred with the NRC staff's
19 list in an e-mail dated August 30, 2013, and indicated that an additional species—the leafy
20 prairie clover (*Dalea foliosa*)—may potentially be present in the area. The NRC used this
21 correspondence as a starting point for its analysis of effects to Federally listed species, which
22 appears in Sections 3.8 and 4.7 of this SEIS. In Section 3.8, the NRC staff concludes that no
23 ESA-protected species or critical habitats occur in the action area, and Section 4.7 concludes
24 that the proposed action would have no effect on any ESA-protected species or critical habitats.
25 The FWS (2013) does not typically provide its concurrence with “no effect” determinations by
26 Federal agencies. Thus, the ESA does not require further informal consultation or the initiation
27 of formal consultation with the FWS for the proposed Byron license renewal. Nonetheless,
28 because this SEIS constitutes the NRC's biological assessment, the NRC staff will submit a
29 copy of this SEIS, upon its issuance, to the FWS for review in accordance with
30 50 CFR 402.12(j).

31 Table C-1 lists the letters, e-mails, and other correspondence related to the NRC's ESA
32 obligations with respect to its review of the Byron license renewal application. This table will be
33 updated in the final SEIS, as applicable, to include correspondence transpiring between the
34 issuance of the draft and final SEIS.

1

Table C–1. Section 7 Consultation Correspondence

Date	Sender and Recipient	Description	ADAMS Accession No. ^(a)
August 8, 2013	M. Wong (NRC) to T. Melius (FWS)	Request for concurrence with list of Federally listed species and habitats for the proposed Byron license renewal	ML13176A377
August 30, 2013	J. Duyvejonck (FWS) to B. Grange (NRC)	Response to request for concurrence with list of Federally listed species and habitats	ML13246A385
September 3, 2013	B. Grange (NRC) to J. Duyvejonck (FWS)	RE: Response to request for concurrence with list of Federally listed species and habitats	ML13246A386

^(a) These documents can be accessed through the NRC's Agencywide Documents Access and Management System (ADAMS) at the following URL: <http://adams.nrc.gov/wba/>.

2 C.2. Essential Fish Habitat Consultation

3 The NRC must comply with the Magnuson–Stevens Fishery Conservation and Management
4 Act, as amended (16 U.S.C. § 1801 et seq., herein referred to as MSA), for any actions
5 authorized, funded, or undertaken, or proposed to be authorized, funded, or undertaken that
6 may adversely affect any essential fish habitat (EFH) identified under the MSA.

7 In Sections 3.8 and 4.8 of this SEIS, the NRC staff concludes that the NMFS has not designated
8 EFH under the MSA in the Rock River and that the proposed Byron license renewal would have
9 no effect on EFH. Thus, the MSA does not require the NRC to consult with the NMFS for the
10 proposed Byron license renewal.

11 C.3. Section 106 Consultation

12 The National Historic Preservation Act (NHPA) requires Federal agencies to consider the effects
13 of their undertakings on historic properties and consult with applicable state and Federal
14 agencies, tribal groups, and individuals and organizations with a demonstrated interest in the
15 undertaking before taking action. Historic properties are defined as resources that are eligible
16 for listing on the National Register of Historic Places. The historic preservation review process
17 (16 U.S.C. § 470f) is outlined in regulations issued by the Advisory Council on Historic
18 Preservation (ACHP) in 36 CFR Part 800. In accordance with 36 CFR 800.8(c), the NRC has
19 elected to use the NEPA process to comply with its obligations under Section 106 of the NHPA.

20 Table C–2 lists the chronology of consultation and consultation documents related to the NRC
21 Section 106 review of the Byron license renewal. The NRC staff is required to consult with the
22 noted agencies and organizations in accordance with the statutes listed above.

Table C-2. NHPA Correspondence

Date	Sender and Recipient	Description	ADAMS Accession No. ^(a)
August 9, 2013	M. Wong (NRC) to A. Haaker, Illinois Historic Preservation Agency	Request for scoping comments/notification of Section 106 review	ML13190A331
August 9, 2013	M. Wong (NRC) to R. Nelson (ACHP)	Request for scoping comments/notification of Section 106 review	ML13184A052
August 9, 2013	M. Wong (NRC) to J. Greendeer, Ho-Chunk Nation	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
August 9, 2013	M. Wong (NRC) to D. Lankford, Miami Tribe of Oklahoma	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
August 9, 2013	M. Wong (NRC) to J. Froman, Peoria Tribe of Indians of Oklahoma	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
August 9, 2013	M. Wong (NRC) to J. Barrett, Chairman, Citizen Potawatomi Nation	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
August 9, 2013	M. Wong (NRC) to A. Sanache, Chairman, Sac and Fox Tribe of the Mississippi in Iowa/Meskwaki	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
August 9, 2013	M. Wong (NRC) to M. Dougherty, Chairman, Sac and Fox Nation of Missouri in Kansas and Nebraska	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
August 9, 2013	M. Wong (NRC) to G. Thurman, Principal, Sac and Fox Nation	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
August 9, 2013	M. Wong (NRC) to M. Wesaw, Chairman, Pokagon Band of Potawatomi	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127

Date	Sender and Recipient	Description	ADAMS Accession No. ^(a)
August 9, 2013	M. Wong (NRC) to H. Frank, Chairman, Forest County Potawatomi	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
August 9, 2013	M. Wong (NRC) to K. Meshigaud, Tribal Chairman, Hannahville Indian Community, Band of Potawatomi	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
August 9, 2013	M. Wong (NRC) to S. Ortiz, Chairman, Prairie Band of Potawatomi Nation	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
August 9, 2013	M. Wong (NRC) to J. Blackhawk, Chairman, Winnebago Tribe of Nebraska	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
August 9, 2013	M. Wong (NRC) to S. Cadue, Chairman, Kickapoo Tribe in Kansas	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
August 9, 2013	M. Wong (NRC) to G. Salazar, Chairman, Kickapoo Tribe of Oklahoma	Request for scoping comments concerning the Byron Nuclear Generating Station, Units 1 and 2, LRA Review (notification of Section 106 review)	ML13184A127
September 4, 2013	A. Haaker, Illinois Historic Preservation Agency to C. Bladey (NRC)	Illinois Historic Preservation Agency Documentation of No Historic Sites Affected by Byron License Renewal Application	ML13269A020

^(a)These documents can be accessed through the NRC's Agencywide Documents Access and Management System (ADAMS) at <http://adams.nrc.gov/wba/>.

1 C.4. References

- 2 36 CFR Part 800. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,
- 3 Part 800, "Protection of historic properties."
- 4 50 CFR Part 402. *Code of Federal Regulations*, Title 50, *Wildlife and Fisheries*, Part 402,
- 5 "Interagency cooperation—Endangered Species Act of 1973, as amended."
- 6 [ESA] Endangered Species Act of 1973, as amended. 16 U.S.C. § 1531 et seq.

Appendix C

- 1 [FWS] U.S. Fish and Wildlife Service. 2013. "Endangered Species Program: What We Do:
2 Consultations: Frequently Asked Questions." July 15, 2013. Available at
3 <<http://www.fws.gov/endangered/what-we-do/faq.html#8>> (accessed 5 June 2014).
- 4 [FWS and NMFS] U.S. Fish and Wildlife Service and National Marine Fisheries Service. 1998.
5 *Endangered Species Consultation Handbook: Procedures for Conducting Consultation and*
6 *Conference Activities Under Section 7 of the Endangered Species Act.* March 1998. 315 p.
7 Available at <http://www.fws.gov/endangered/esa-library/pdf/esa_section7_handbook.pdf>
8 (accessed 8 July 2013).
- 9 [MSA] Magnuson–Stevens Fishery Conservation and Management Act, as amended.
10 16 U.S.C. § 1801 et seq.
- 11 [NEPA] National Environmental Policy Act of 1969, as amended. 42 U.S.C. § 4321 et seq.
- 12 [NHPA] National Historic Preservation Act of 1966, as amended. 16 U.S.C. § 470 et seq.

1

APPENDIX D

2

CHRONOLOGY OF ENVIRONMENTAL REVIEW CORRESPONDENCE

1 **D. CHRONOLOGY OF ENVIRONMENTAL REVIEW**
2 **CORRESPONDENCE**

3 This appendix, along with Appendix D, contains a chronological listing of correspondence
4 between the U.S. Nuclear Regulatory Commission (NRC) and external parties as part of its
5 environmental review for Byron Station, Units 1 and 2 (Byron). Appendix D contains the
6 chronological listing of consultation correspondence associated with the Endangered Species
7 Act of 1973 (16 U.S.C. § 1531) and the Magnuson–Stevens Fishery Conservation and
8 Management Act, as amended, (16 U.S.C. § 1801–1884). Appendix C contains all other
9 correspondence.

10 All documents, with the exception of those containing proprietary information, are available
11 electronically in the NRC’s Library, which is found on the Internet at the following Web address:
12 <http://www.nrc.gov/reading-rm.html>. From this site, the public can gain access to the NRC’s
13 Agencywide Documents Access and Management System (ADAMS), which provides text and
14 image files of the NRC’s public documents. The ADAMS number for each document is included
15 in the following list. If you need assistance in accessing or searching in ADAMS, contact the
16 Public Document Room Staff at 1-800-397-4209.

17 **D.1. Environmental Review Correspondence**

18 Table D–1 lists the environmental review correspondence in date order beginning with the
19 request by Exelon Generation Company, LLC (Exelon or the applicant), to renew the operating
20 license for Byron.

Table D–1. Environmental Review Correspondence

Date	Correspondence Description	ADAMS No.
29-May-13	License Renewal Application, Byron and Braidwood Stations, Units 1 and 2	ML131620554
31-May-13	Byron License Renewal Application Environmental Report	ML14022A048
06-Jun-13	Receipt and Availability of the License Renewal Application for the Byron Nuclear Station, Units 1 and 2, and the Braidwood Nuclear Station Units 1 and 2	ML13144A099
10-Jun-13	NRC Announces Public Availability of License Renewal Application for Braidwood and Byron Nuclear Power Plants in Illinois	ML13161A381
05-Jul-13	Illinois Environmental Protection Agency, Certification Under Section 401 of the Clean Water Act (CWA)	ML14113A544
16-Jul-13	Determination Of Acceptability And Sufficiency For Docketing, Proposed Review Schedule, And Opportunity For A Hearing Regarding The Application From Exelon Generation Company, LLC, For Renewal Of The Operating Licenses For Byron Nuclear Station, Units 1 and 2, and Braidwood Nuclear Station, Units 1 and 2	ML13134A136
18-Jul-13	<i>Federal Register</i> notice (FRN) - License renewal application; notice of docketing and opportunity to request a hearing and to petition for leave to intervene	ML13134A156
24-Jul-13	Press Release-13-062: NRC Announces Hearing Opportunity on License Renewal Application for Byron and Braidwood Nuclear Plants in Illinois	ML13207A291
31-Jul-13	Byron, Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process, Public Meetings, and Opportunity to Comment	ML13175A072
07-Aug-13	08/20/2013 Forthcoming Meeting to Discuss the License Renewal Process and Environmental Scoping for Exelon Generation Company, LLC (Exelon), Byron Nuclear Station, Units 1 and 2	ML13205A045
08-Aug-13	Notice Of Intent To Prepare An Environmental Impact Statement And Conduct Scoping Process For License Renewal For Byron Station, Units 1 And 2 (TAC Nos. MF1834 And MF1835)	ML13184A110
12-Aug-13	NRC Public Meetings to Discuss Environmental Reviews of Byron, Braidwood Nuclear Plant License Renewals	ML13224A318
27-Aug-13	Comment (2) of Kim P. Gouker on Behalf of Ogle County, Illinois, Supporting License Renewal Application of the Byron Power Generating Station	ML13247A010
04-Sep-13	Illinois Historic Preservation Agency Documentation of No Historic Sites Affected by Byron License Renewal Application	ML13269A020
10-Sep-13	Environmental Site Audit Regarding Byron Station, Units 1 And 2 (TAC Nos. MF1834 and MF1835)	ML13231A060

Date	Correspondence Description	ADAMS No.
16-Sep-13	Comment (1) of Kim P. Gouker on Behalf of Ogle County, Illinois, Supporting the License Renewal Application of the Byron Power Generating Station	ML13263A221
23-Sep-13	Hearing Request and Petition to Intervene by the Environmental Law and Policy Center	ML13270A137
27-Sep-13	Comment (2) of David Kraft on Behalf of NEIS re Supplement to NRC's Generic Environmental Impact Statement for License Renewal for the Byron Nuclear Power Station	ML13277A306
04-Oct-13	Summary of the Site Audit Related to the Review of the License Renewal Application for Byron Nuclear Station, Units 1 and 2 (TAC Nos. MF1834 and MF1835)	ML13270A069
04-Oct-13	Summary of Public Scoping Meetings Conducted Related to the Review of the Byron Nuclear Station, License Renewal Application (TAC Nos. MF1790 and MF1791)	ML13240A234
04-Oct-13	Memorandum from Andrew L. Bates, Acting Secretary of the Commission, to E. Roy Hawken, Chief Administrative Judge of the Atomic Safety and Licensing Board, Referring the hearing request and petition to intervene from the Environmental Law and Policy Center	ML13277A454
08-Oct-13	Establishment of Atomic Safety and Licensing Board	ML13281A798
28-Oct-13	NRC Staff Answer to Environmental Law and Policy Center Hearing Request and Petition to Intervene	ML13301A922
28-Oct-13	Exelon's Answer Opposing the Hearing Request and Petition to Intervene Filed by the Environmental Law and Policy Center	ML13301A773
29-Oct-13	License Renewal Environmental Site Audit re Byron and Braidwood Stations - Severe Accident Mitigation Alternative (TAC Nos. MF1834/1835, MF1790/1791, MF1832/1833, and MF1792/1793)	ML13270A116
04-Nov-13	Reply in Support of the Environmental Law and Policy Center's Hearing Request and Petition to Intervene	ML13308D017
19-Nov-13	Memorandum and Order (Denying Hearing Request and Petition to Intervene)	ML13323A823
21-Nov-13	Requests For Additional Information For The Environmental Review Of The Byron Nuclear Station, Units 1 And 2, License Renewal Application	ML13294A341
13-Dec-13	Audit Trip Report SAMA	ML13312A317
19-Dec-13	Byron, Units 1 and 2, Response to NRC Request for Additional Information, dated November 21, 2013, Related to the Byron and Braidwood, Units 1 and 2, License Renewal Application, Byron Station Applicant's Environmental Report	ML14007A078
02-Jan-14	ELPC Reply in Support of Its Appeal of the ASLB Denial of ELPC's Petition for Intervention and Hearing Request	ML14002A455

Appendix D

Date	Correspondence Description	ADAMS No.
06-Jan-14	Requests for Additional Information for the Review of the Byron and Braidwood Nuclear Stations License Renewal Application - Severe Accident Mitigation Alternatives Review (TAC Nos. MF1790, MF1791, MF1792, and MF1793)	ML13318A208
13-Jan-14	Byron Environmental RAIs - 1 supplemental request	ML14013A339
23-Jan-14	Byron-Braidwood SAMA RAI Conference Call Summary	ML14007A240
23-Jan-14	ELPC's Motion for Leave to File Its Reply	ML14023A884
29-Jan-14	Requests For Additional Information For The Environmental Review Of The Byron Nuclear Station, Units 1 And 2, License Renewal Application - Additional Request	ML14014A036
03-Feb-14	Exelon's Answer Opposing ELPC's Untimely Motion for Leave to File a Reply	ML14034A313
03-Feb-14	NRC Staff Answer Opposing Environmental Law and Policy Center Motion for Leave to File Reply	ML14034A406
04-Feb-14	Braidwood, Units 1 & 2, and Byron, Units 1 & 2, Response to NRC Requests for Additional Information for the Severe Accident Mitigation Alternatives Review, dated January 6, 2014, License Renewal Application	ML14035A512
11-Feb-14	Byron Station, Units 1 & 2, Response to NRC Request for Additional Information on License Renewal Application and Environmental Report	ML14045A101
05-May-14	Schedule Revision for Environmental Review of Byron and Braidwood Nuclear Stations License Renewal Application - Environmental Review Schedule (TAC Nos. MF1790, MF1791, MF1792, And MF1793).	ML14104B131
07-May-14	Commission Decision (CLI-14-06) Denying the Request for a Protective Stay of the Byron/Braidwood License Renewal Proceeding.	ML14127A220
12-May-14	Update to Chapter 9 of Byron and Braidwood Stations, Units 1 and 2 License Renewal Application, Byron Station Applicant's Environmental Report.	ML14132A141
28-May-14	Issuance Of Environmental Scoping Summary Report Associated With The Staff's Review Of The Byron Nuclear Station, Units 1 And 2, License Renewal Application.	ML14041A334
17-Oct-14	Schedule Revision for the Environmental Review of the Byron Station And Braidwood Station License Renewal Application— Environmental Review Schedule (TAC Nos. MF1790, MF1791, MF1792, And MF1793).	ML14275A003

1

APPENDIX E

2

PROJECTS CONSIDERED IN THE CUMULATIVE IMPACTS ANALYSIS

1 **E. PROJECTS CONSIDERED IN THE CUMULATIVE IMPACTS**
2 **ANALYSIS**

3 Table E-1 identifies actions and projects considered in the U.S. Nuclear Regulatory
4 Commission (NRC) staff's analysis of cumulative impacts related to the environmental analysis
5 of the continued operation of Byron Station, Units 1 and 2 (Byron). Potential cumulative impacts
6 associated with these actions and projects are addressed in Section 4.16 of this SEIS.
7 However, not all actions or projects listed in this appendix are considered in each resource area
8 because of the uniqueness of the resource and its geographic area of consideration.

1 **Table E-1. Projects and Actions Considered in the Cumulative Impacts Analysis**

Project Name	Summary of Project	Location (relative to Byron)	Status
Nuclear projects			
Quad Cities Nuclear Power Station, Units 1 and 2	Nuclear power plant, two 867-MWe General Electric Type 3 reactors	Rock Island County, IL, 50 mi (~80 km) radius overlaps with Byron	Operational (NRC 2014a, 2014b)
Clinton Power Station, Unit 1	Nuclear power plant, one 1,043-MWe General Electric Type 6 reactor	DeWitt County, IL, 50 mi (~80 km) radius overlaps with Byron	Operational (NRC 2014c)
Braidwood Station, Units 1 and 2	Nuclear power plant, two 1,121-MWe Westinghouse four-loop reactors	Will County, IL, 50 mi (~80 km) radius overlaps with Byron	Operational (NRC 2014d, 2014e)
LaSalle County Station, Units 1 and 2	Nuclear power plant, two 1,200-MWe General Electric Type 5 reactors	LaSalle County, IL, 50 mi (~80 km) radius overlaps with Byron	Operational (NRC 2014f, 2014g)
Dresden Nuclear Power Station, Units 2 and 3	Nuclear power plant, two 867-MWe General Electric Type 3 reactors	Grundy County, IL, 50 mi (~80 km) radius overlaps with Byron	Operational (NRC 2014h, 2014i)
Dresden Nuclear Power Station, Unit 1	Nuclear power plant	Grundy County, IL, 50 mi (~80 km) radius overlaps with Byron	Shut down in October 1978 and is currently in SAFSTOR. No dismantlement activities are underway. All spent fuel from DNPS Unit 1 transferred to the onsite Independent Spent Fuel Storage Installation (NRC 2014j).
Hydroelectric project			
North American Hydro Rockton Plant	Hydroelectric power plant located on the Rock River; two units totaling 1,100 kW installed generating capacity	Rockton, IL, approximately 28 mi (~45 km) north	Operational (NAH 2014)
Gas fired project			
Nelson Energy Center	Combined-cycle plant with 584 MWe generating capacity	Rock Falls, IL, approximately 29 mi (~47 km) south	Under construction; projected to open 2015 (Invenergy 2014)

Project Name	Summary of Project	Location (relative to Byron)	Status
Landfills			
Rochelle Municipal Landfill No. 2	Permitted landfill area of 80.6 ac (32.6 ha) and a permitted disposal area of 61.3 ac (24.8 ha); design capacity of 14,516,000 yd ³ (11,098,000 m ³)	Creston, IL, approximately 19 mi (~31 km) southeast	Operational, NPDES Permit No. IL0075451 (IEPA 2013)
Veolia ES Orchard Hills Landfill	Permitted landfill area of 446.32 ac (180.62 ha) and a permitted disposal area of 251.1 ac (101.6 ha); design capacity of 45,369,400 yd ³ (34,687,300 m ³)	Davis Junction, IL, approximately 9 mi (~15 km) east	Operational, NPDES Permit No. IL0075591 (IEPA 2013)
Water supply and treatment facilities			
City of Byron, water supply	Withdraws groundwater from Galesville and St. Simon aquifers	Byron, IL, approximately 3 mi (~5 km) northeast	Operational (EPA 2014c)
City of Byron, wastewater plant	Sewage treatment facility on the Rock River	Byron, IL, approximately 3 mi (~5 km) northeast	Operational, NPDES Permit No. IL0027804 (EPA 2014a)
City of Oregon, water supply	Withdraws groundwater	Oregon, IL, approximately 5 mi (~8 km) northeast	Operational (EPA 2014b)
Rock River Water Reclamation District	Water treatment plant with discharge to Rock River	Rockford, IL, approximately 16 mi (~26 km) northeast	Operational, NPDES Permit No. IL0027201 (EPA 2014a)
City of Oregon, municipal wastewater treatment facilities	Sewage treatment facility on the Rock River	Oregon, IL, approximately 5 mi (~8 km) northeast	Operational, NPDES Permit No. IL0020184 (EPA 2014a)
Various minor NPDES wastewater discharges	Various businesses with smaller wastewater dischargers to water bodies	Within 50 mi (~80 km)	Operational (EPA 2014a)

Appendix E

Project Name	Summary of Project	Location (relative to Byron)	Status
Transportation			
Jane Addams Memorial Tollway (I-90)	Major projects include completion of a new interchange at Illinois Route 47. Rebuilding and widening of the eastbound lanes between Rockford and Elgin, including work on mainline bridges and nine local crossroad bridges and ramp reconstruction at the Business U.S. Route 20/State Street Interchange in Rockford	Within 35 mi (~56 km)	In progress by Illinois Department of Transportation; expected to finish in 2016 (Illinois Tollway 2014)
Parks and recreation sites			
Franklin Creek State Natural Area	356 ha (~880 ac) near Franklin Grove, IL, with natural springs, hardwood forests, bedrock outcroppings, and a large variety of flora and fauna for various recreational activities	Approximately 15 mi (~24 km) south	Operational; managed by Illinois Department of Natural Resources (IDNR 2014a)
Castle Rock State Park	809 ha (~2,000 ac) on the west bank of the Rock River in Ogle County; hiking, fishing, camping, and small-game hunting occur within the park	Approximately 9 mi (~14 km) southwest	Operational; managed by Illinois Department of Natural Resources (IDNR 2014b)
Lowden State Park	95 ha (~235 ac) along the Rock River in Ogle County; hiking, fishing, and camping occur within the park	Approximately 4 mi (~6 km) southwest	Operational; managed by Illinois Department of Natural Resources (IDNR 2014c)
White Pines Forest State Park	155 ha (~383 ac) in the Rock River Valley; hiking, fishing, and camping occur within the park	Approximately 11 mi (~18 km) west	Operational; managed by Illinois Department of Natural Resources (IDNR 2014d)
Recreational Areas	Various parks, boat launches, campgrounds, and swimming areas on the Rock River	Within 50 mi (~80 km)	Operational

Project Name	Summary of Project	Location (relative to Byron)	Status
Byron projects			
Unit 2 steam generator replacement	Assumed to occur during normal refueling outage; 500 additional workers specific to replacement; all work to occur on previously disturbed land on site	Byron site	Assumed to occur prior to the end of the 40-year initial license term (Exelon 2013)
Units 1 and 2 reactor pressure vessel head replacement	Would occur during a 7-day period; 340 additional workers specific to replacement; all work and storage of reactor pressure vessel heads to occur on previously disturbed land	Byron site	Assumed to occur during license term (Exelon 2013)
Other projects			
Future Urbanization	Construction of housing units and associated commercial buildings; roads, bridges, and rail; water or wastewater treatment or both; and distribution facilities and associated pipelines as described in local land-use planning documents	Throughout region	Construction would occur in the future as described in State and local land-use planning documents

Sources: EPA 2014a, 2014b, 2014c; Exelon 2013; IDNR 2014a, 2014b, 2014c, 2014d; IEPA 2013; Illinois Tollway 2014; Invenergy 2014; NAH 2014; NRC 2014a, 2014b, 2014c, 2014d, 2014e, 2014f, 2014g, 2014h, 2014i, 2014j

1 E.1 References

- 2 [EPA] U.S. Environmental Protection Agency. 2014a. "Envirofacts search results: Facilities with
3 permits and discharges to waters of the United States." March 18, 2014. Available at
4 <<http://www.epa.gov/enviro/index.html>> (accessed June 2014).
- 5 [EPA] U.S. Environmental Protection Agency. 2014b. "Envirofacts: SDWIS Search: Safe
6 Drinking Water Search for the State of Illinois – Oregon." June 12, 2014. Available at
7 <http://oaspub.epa.gov/enviro/sdw_form_v2.create_page?state_abbr=IL> (accessed
8 June 2014).
- 9 [EPA] U.S. Environmental Protection Agency. 2014c. "Envirofacts: SDWIS Search: Safe
10 Drinking Water Search for the State of Illinois – Byron." June 12, 2014. Available at
11 <http://oaspub.epa.gov/enviro/sdw_form_v2.create_page?state_abbr=IL> (accessed
12 June 2014).

Appendix E

- 1 [Exelon] Exelon Generation Company, LLC. 2013. *Appendix E – Applicant’s Environmental*
2 *Report – Operating License Renewal Stage, Byron Station, Units 1 and 2, Facility Operating*
3 *License Nos. NPF-37 and NPF-66*. Byron, IL: Exelon. May 2013. 707 p. ADAMS
4 No. ML14022A048.
- 5 [IDNR] Illinois Department of Natural Resources. 2014a. “Franklin Creek State Natural Area.”
6 Available at <<http://dnr.state.il.us/lands/landmgt/parks/r1/franklin.htm>> (accessed June 2014).
- 7 [IDNR] Illinois Department of Natural Resources. 2014b. “Castle Rock State Park.” Available at
8 <<https://dnr.state.il.us/lands/landmgt/parks/r1/castle.htm>> (accessed June 2014).
- 9 [IDNR] Illinois Department of Natural Resources. 2014c. “Lowden State Park.” Available at
10 <<https://dnr.state.il.us/lands/landmgt/parks/r1/lowdensp.htm>> (accessed June 2014).
- 11 [IDNR] Illinois Department of Natural Resources. 2014d. “White Pines Forest State Park.”
12 Available at <<https://dnr.state.il.us/lands/landmgt/parks/r1/whitepns.htm>> (accessed June 2014).
- 13 [IEPA] Illinois Environmental Protection Agency. 2013. *Nonhazardous Solid Waste Management*
14 *and Landfill Capacity in Illinois: 2012*. Springfield, IL: IEPA. October 2013. 67 p. Available at
15 <<http://www.epa.state.il.us/land/landfill-capacity/2012/report.pdf>> (accessed June 2014).
- 16 Illinois Tollway. 2014. “Jane Addams Memorial Tollway (I-90).” Available at
17 <[http://www.illinoistollway.com/construction-and-planning/projects-by-roadway/](http://www.illinoistollway.com/construction-and-planning/projects-by-roadway/jane-addams-memorial-tollway-i-90)
18 [jane-addams-memorial-tollway-i-90](http://www.illinoistollway.com/construction-and-planning/projects-by-roadway/jane-addams-memorial-tollway-i-90)> (accessed June 2014).
- 19 [Invenergy] Invenergy, LLC. 2014. “Projects by Country: United States: Nelson.” Available at
20 <<http://www.invenergyllc.com/ProjectsbyCountry/UnitedStates/Nelson.aspx>> (accessed
21 June 2014).
- 22 [NAH] North American Hydro. 2014. *Rockton FERC Project # 2373*. 1 p. Available at
23 <[http://www.nahydro.com/sites/default/files/nahydro/documents/plants/](http://www.nahydro.com/sites/default/files/nahydro/documents/plants/RKTN%20Data%20Sheet.pdf)
24 [RKTN%20Data%20Sheet.pdf](http://www.nahydro.com/sites/default/files/nahydro/documents/plants/RKTN%20Data%20Sheet.pdf)> (accessed June 2014).
- 25 [NRC] U.S. Nuclear Regulatory Commission. 2014a. “Quad Cities Nuclear Power Station,
26 Unit 1.” April 23, 2014. Available at <<http://www.nrc.gov/info-finder/reactor/quad1.html>>
27 (accessed June 2014).
- 28 [NRC] U.S. Nuclear Regulatory Commission. 2014b. “Quad Cities Nuclear Power Station,
29 Unit 2.” April 23, 2014. Available at <<http://www.nrc.gov/info-finder/reactor/quad2.html>>
30 (accessed June 2014).
- 31 [NRC] U.S. Nuclear Regulatory Commission. 2014c. “Clinton Power Station, Unit 1.”
32 May 8, 2014. Available at <<http://www.nrc.gov/info-finder/reactor/clin.html>> (accessed
33 June 2014).
- 34 [NRC] U.S. Nuclear Regulatory Commission. 2014d. “Braidwood Station, Unit 1.” May 8, 2014.
35 Available at <<http://www.nrc.gov/info-finder/reactor/brai1.html>> (accessed June 2014).
- 36 [NRC] U.S. Nuclear Regulatory Commission. 2014e. “Braidwood Station, Unit 2.” May 8, 2014.
37 Available at <<http://www.nrc.gov/info-finder/reactor/brai2.html>> (accessed June 2014).
- 38 [NRC] U.S. Nuclear Regulatory Commission. 2014f. “LaSalle County Station, Unit 1.”
39 May 8, 2014. Available at <<http://www.nrc.gov/info-finder/reactor/lasa1.html>> (accessed
40 June 2014).
- 41 [NRC] U.S. Nuclear Regulatory Commission. 2014g. “LaSalle County Station, Unit 2.”
42 May 8, 2014. Available at <<http://www.nrc.gov/info-finder/reactor/lasa2.html>> (accessed
43 June 2014).

- 1 [NRC] U.S. Nuclear Regulatory Commission. 2014h. "Dresden Nuclear Power Station, Unit 2."
2 April 23, 2014. Available at <<http://www.nrc.gov/info-finder/reactor/dres2.html>> (accessed
3 June 2014).
- 4 [NRC] U.S. Nuclear Regulatory Commission. 2014i. "Dresden Nuclear Power Station, Unit 3."
5 April 23, 2014. Available at <<http://www.nrc.gov/info-finder/reactor/dres3.html>> (accessed
6 June 2014).
- 7 [NRC] U.S. Nuclear Regulatory Commission. 2014j. "Dresden – Unit 1." February 20, 2014.
8 Available at <[http://www.nrc.gov/info-finder/decommissioning/power-reactor/
9 dresden-nuclear-power-station-unit-1.html](http://www.nrc.gov/info-finder/decommissioning/power-reactor/dresden-nuclear-power-station-unit-1.html)> (accessed June 2014).

1
2
3
4
5

APPENDIX F
U.S. NUCLEAR REGULATORY COMMISSION STAFF EVALUATION OF
SEVERE ACCIDENT MITIGATION ALTERNATIVES FOR BYRON
STATION, UNITS 1 AND 2, IN SUPPORT OF LICENSE RENEWAL
APPLICATION REVIEW

F. U.S. NUCLEAR REGULATORY COMMISSION STAFF EVALUATION OF SEVERE ACCIDENT MITIGATION ALTERNATIVES FOR BYRON STATION, UNITS 1 AND 2, IN SUPPORT OF LICENSE RENEWAL APPLICATION REVIEW

F.1 Introduction

Exelon Generation Company, LLC (Exelon) submitted an assessment of severe accident mitigation alternatives (SAMAs) for the Byron Station, Units 1 and 2 (Byron), as part of the Environmental Report (ER) (Exelon 2013b). This assessment is based on the most recent Byron probabilistic risk assessment (PRA) available at that time, a plant-specific offsite consequence analysis performed using the MELCOR Accident Consequence Code System 2 (MACCS2) computer code, and insights from the Byron individual plant examination (IPE) (ComEd 1994) and individual plant examination of external events (IPEEE) (ComEd 1996). In identifying and evaluating potential SAMAs, Exelon considered SAMAs that addressed the major contributors to core damage frequency (CDF) and release frequency at Byron, as well as potential SAMA candidates at other operating plants that have submitted license renewal applications. Exelon initially identified 30 potential SAMAs. This list was reduced to 27 unique SAMA candidates by eliminating SAMAs that were not applicable to Byron because of design differences, that have already been implemented at Byron or the intent achieved by other means, or that have excessive implementation costs. One additional candidate SAMA was also further evaluated after accounting for analysis uncertainties. Exelon assessed the costs and benefits associated with each of the 28 potential SAMAs and concluded in the ER that 18 of the candidate SAMAs evaluated are potentially cost-beneficial. Exelon submitted all 18 potentially cost-beneficial SAMAs to the Byron Plant Health Committee for further implementation consideration.

Based on a review of the SAMA assessment and plant audit trip conducted November 4, 5, and 6, 2013, the U.S. Nuclear Regulatory Commission (NRC) staff issued requests for additional information (RAIs) to Exelon by letter dated January 6, 2014 (NRC 2014). Key questions concerned the disposition of internal and external review comments on the PRA model, the modeling of systems shared between units, additional details on the Level 2 and 3 PRA models, the scope and status of the Byron fire PRA model, the estimated seismic CDF, the identification of candidate SAMAs, the basis for the SAMA cost estimates, and the results of the uncertainty analysis. Exelon submitted additional information by letter dated February 4, 2014 (Exelon 2014). In the responses, Exelon provided a discussion of the conduct of the PRA model self-assessment and the resolution of review findings, a discussion of the modeling of shared systems and the incorporation of opposite unit equipment unavailabilities, clarification of Level 2 and 3 PRA modeling details and assumptions, further details on the Byron fire PRA, analyses of additional SAMAs, updated SAMA cost information, and revised SAMA benefit analyses to fully account for seismic events and uncertainty. Exelon's responses addressed the NRC staff's comments and resulted in the identification of additional potentially cost-beneficial SAMAs.

As a result of NRC staff RAIs, Exelon identified two additional cost-beneficial SAMAs. Exelon plans to implement one of these SAMAs and initiated engineering and procurement activities to do so. However, Exelon determined that the other SAMA would not be cost-beneficial if another SAMA that addresses insights from the Fukushima Dai-ichi accident were implemented since it would mitigate many of the largest contributors to Byron risk.

Appendix F

1 An assessment of SAMAs for Byron is presented below.

2 **F.2 Estimate of Risk for Byron**

3 Exelon's estimates of offsite risk at Byron are summarized in Section F.2.1. The summary is
4 followed by the NRC staff's review of Exelon's risk estimates in Section F.2.2.

5 **F.2.1 Exelon's Risk Estimates**

6 Exelon combined two distinct analyses to form the basis for the risk estimates used in the
7 SAMA analysis: (1) the Byron Level 1 and 2 PRA models, both new models developed since
8 the IPE models, and (2) a supplemental analysis of offsite consequences and economic impacts
9 (a Level 3 PRA model) developed specifically for the SAMA analysis. The SAMA analysis is
10 based on the most recent Byron Level 1 and Level 2 PRA model available at the time of the ER,
11 the Byron PRA (Revision BB011b1). The scope of this Byron PRA includes internal floods but
12 does not include external events.

13 The Byron CDF is approximately 4.0×10^{-5} per year for Unit 1 and 3.8×10^{-5} per year for Unit 2
14 (Exelon 2013b). Exelon did not explicitly include the contribution from external events within the
15 Byron SAMA risk estimates; however, it did account for the potential risk reduction benefits
16 associated with external events by multiplying the estimated benefits for internal events by 2.5.
17 This is discussed further in Sections F.2.2 and F.6.2.

18 The breakdown of CDF by initiating event is provided in Table F-1. As shown in this table,
19 events initiated by loss of essential service water (SX), loss of component cooling water (CCW),
20 and internal flooding are the dominant contributors to the CDF for both units. Exelon identified
21 that station blackout (SBO) contributes 9.9×10^{-7} per year, or 2.5 percent, for Unit 1, and
22 9.6×10^{-7} per year, or 2.6 percent, for Unit 2, to the total internal events CDF while anticipated
23 transients without scram (ATWS) contribute 1.4×10^{-7} per year, or approximately 0.4 percent, of
24 the total CDF for each unit (Exelon 2014).

1

Table F–1. Byron CDF for Internal Events

Initiating Event	Unit 1 CDF (per year)	Unit 1 Percent CDF Contribution	Unit 2 CDF (per year)	Unit 2 Percent CDF Contribution
Loss of Essential Service Water (SX)	1.8×10^{-5}	46	1.7×10^{-5}	45
Loss of Component Cooling Water (CCW)	8.3×10^{-6}	21	8.1×10^{-6}	21
Internal Flooding	5.6×10^{-6}	14	5.8×10^{-6}	15
Loss of Auxiliary Power (AP)	2.4×10^{-6}	6	1.8×10^{-6}	5
Small Loss-of-Coolant Accident (LOCA)	1.6×10^{-6}	4	1.5×10^{-6}	4
Other Initiating Events	1.6×10^{-6}	4	1.6×10^{-6}	4
Steam Generator Tube Rupture (SGTR)	1.2×10^{-6}	3	1.5×10^{-6}	4
General Transient and Loss of Main Feedwater (LMFW)	7.9×10^{-7}	2	6.8×10^{-7}	2
Total (Internal Events)^(a)	4.0×10^{-5}	100	3.8×10^{-5}	100

^(a) Column totals may be different because of rounding.

Source: Exelon 2013b

- 2 The Level 2 Byron PRA model that forms the basis for the SAMA evaluation is a new model and
3 stated to represent the current state-of-the-art (Exelon 2013b).
- 4 The Level 2 model utilizes a single containment event tree (CET) to assess the accident
5 progression following a core damage event and contains both phenomenological and systemic
6 events. The Level 1 core damage sequences are binned into plant damage states (PDSs),
7 which provide the interface between the Level 1 and Level 2 CET analysis. Each PDS bin is
8 then entered into the CET. The CET is linked directly to the Level 1 event trees and CET nodes
9 are evaluated using supporting fault trees and logic rules.
- 10 The result of the Level 2 PRA is a set of 13 release or source term categories, with their
11 respective frequency and release characteristics. The results of this analysis for Byron are
12 provided in Table F.2-8 of the ER (Exelon 2013b). The categories were defined based on the
13 similarity of scenario release characteristics and ultimate containment failure mode. This
14 resulted in six release categories with large early releases (LERs), four with late releases, two
15 with small early releases, and one for an intact containment. The frequency of each release
16 category was obtained by summing the frequency of the individual accident progression CET
17 endpoints binned into the release category. Source terms were developed for each of the
18 thirteen release categories using the results of Modular Accident Analysis Program (MAAP)
19 Version 4.0.6 computer code calculations (Exelon 2013b).
- 20 The offsite consequences and economic impact analyses use the MACCS2 code (Chanin and
21 Young 1998) to determine the offsite risk impacts on the surrounding environment and public.
22 Inputs for these analyses include plant-specific and site-specific input values for core
23 radionuclide inventory, source term and release characteristics, site meteorological data,
24 projected population distribution (within a 50-mi (80-km) radius) for the year 2046, emergency
25 response evacuation modeling, and economic data. The core radionuclide inventory

Appendix F

1 corresponds to the end-of-cycle values for Byron operating at 3,645 megawatts thermal (Mwt).
 2 The magnitude of the onsite impacts (in terms of cleanup and decontamination costs and
 3 occupational dose) is based on information provided in NUREG/BR-0184 (NRC 1997c).
 4 In the ER, Exelon estimated the dose to the population within 50 mi (80 km)) of the Byron site to
 5 be approximately 0.354 person-sievert (Sv) (35.4 person-rem) per year (Exelon 2013b). In
 6 addition, Exelon estimated the annual offsite economic cost impact to be \$255,000 per year.
 7 The breakdown of the total population dose and offsite economic cost by containment release
 8 mode is summarized in Table F–2. Late failures due to containment overpressure events (such
 9 as loss of containment heat removal due to loss of power or cooling water) and large early
 10 release frequency (LERF) accidents caused by unisolated interfacing-systems loss-of-coolant
 11 accident (ISLOCA) dominate the population dose risk at Byron. Late containment overpressure
 12 failures dominate the offsite economic cost impact.

13 **Table F–2. Breakdown of Population Dose and Offsite Economic Cost by Containment**
 14 **Release Mode** ^(a)

Containment Release Mode	Population Dose (Person-Rem ^(b) Per Year)	Percent Contribution	Offsite Economic Cost (\$/year)	Percent Contribution
Containment overpressure (late)	28.3	80	222,700	88
ISLOCA	4.42	12	11,800	5
SGTR	2.16	6	17,600	7
Containment isolation failure	0.34	<1	1660	<1
Containment intact	0.13	<1	120	<1
CFE	0.09	<1	580	<1
Basemat melt-through (late)	0.02	<1	40	<1
Total ^(c)	35.5	100	255,000	100

^(a) Values in table derived from Table F.3-9 of the ER.

^(b) One person-rem = 0.01 person-Sv.

^(c) Column totals may be different because of rounding.

Key: CFE = early containment failure; ER = Environmental Report;

ISLOCA = interfacing-systems loss-of-coolant accident; SGTR = steam generator tube rupture; Sv = sievert

15 **F.2.2 Review of Exelon’s Risk Estimates**

16 Exelon’s determination of offsite risk at the Byron site is based on the following major elements
 17 of analysis:

- 18 (1) the Level 1 risk model that supersedes the 1994/1997 IPE submittals (ComEd 1994,
 19 1997), a new interim internal fire analysis and the seismic and other external event
 20 analyses of the 1996 IPEEE submittal (ComEd 1996);
- 21 (2) the new Level 2 risk model; and

1 (3) the MACCS2 analyses performed by Exelon to translate fission product source terms
2 and release frequencies from the Level 2 PRA model into offsite consequence
3 measures.

4 Each of these analyses was reviewed by the NRC staff to determine the acceptability of the
5 Byron's risk estimates for the SAMA analysis, as summarized below.

6 *F.2.2.1 Internal Events CDF (PRA Level 1) Model*

7 The NRC staff's review of the Byron IPE is described in an NRC letter dated December 3, 1997
8 (NRC 1997b). Based on a review of the original and modified IPE submittal, the NRC staff
9 concluded that the Byron IPE has met the intent of generic letter (GL) 88-20 (NRC 1988). The
10 NRC staff review concluded that, while Exelon did not provide a definition of vulnerability,
11 Exelon identified one "potential vulnerability" and one enhancement were. These are discussed
12 in Section F.3.2.

13 There have been numerous revisions to the Byron PRA since the original 1994 IPE submittal.
14 A listing of the complete revision history of the Byron PRA since the original IPE submittal was
15 provided in the ER (Exelon 2013b) and is summarized in Table F-3 below. A comparison of the
16 internal events CDF between the 1997 modified IPE and the current PRA model indicates there
17 has been essentially no change in the total CDF (from 4.0×10^{-5} per year for both units to
18 4.0×10^{-5} per year for Unit 1 and 3.8×10^{-5} per year for Unit 2).

19 The CDF value from the 1997 modified IPE (4.0×10^{-5} per year) is in the middle range of the
20 CDF values reported in the IPEs for Westinghouse four-loop plants. Figure 11.6 of
21 NUREG-1560 shows that the IPE-based total internal events CDF for Westinghouse four-loop
22 plants ranges from 2×10^{-6} per year to 2×10^{-4} per year, with an average CDF for the group of
23 6×10^{-5} per year (NRC 1997a). It is recognized that other plants have updated the values for
24 CDF subsequent to the IPE submittals to reflect modeling and hardware changes. The current
25 internal events CDF results for Byron (4.0×10^{-5} per year for Unit 1 and 3.8×10^{-5} per year for
26 Unit 2) are comparable to results for other plants of similar vintage and characteristics.

27 The NRC staff considered the peer review performed for the Byron PRA, and the potential
28 impact of the review findings on the SAMA evaluation. In the ER (Exelon 2013b), Exelon briefly
29 described the results of the 1999 Westinghouse Owners Group peer review of Revision 0 of the
30 Byron PRA. Exelon stated that the 27 significance-level A (expected impact to be significantly
31 nonconservative) and -level B (expected impact to be nonconservative but small) facts and
32 observations (F&Os) generated during the peer review have been closed out. The NRC staff
33 requested that Exelon describe what is meant by "closed out," how this is verified, and whether
34 these F&Os were considered in the 2012 self-assessment and the corrections incorporated in
35 the PRA used for the SAMA analysis. In response, Exelon provided a description of the
36 process used to track and close out F&Os as well as other potential model changes. In the
37 ongoing model update process, the model and document changes associated with each F&O,
38 as well as the decision to not change the model or documentation, are reviewed and approved
39 with each official model approval in accordance with Exelon procedures. The approved
40 dispositions of all peer review F&Os were incorporated in the SAMA PRA. Exelon stated that
41 "changes due to the peer review F&Os were fully considered as part of the 2012 self-
42 assessment" (Exelon 2014).

43 The NRC staff has determined that Exelon's disposition of the peer review findings is consistent
44 with the guidance in Nuclear Energy Institute (NEI) 05-01 (NEI 2005) and that the final
45 resolution of the findings provides reasonable assurance of minimal impact to the results of the
46 SAMA analysis.

1 **Table F–3. Summary of Major PRA Models and Corresponding CDF and LERF Results^(a)**

PRA Model	Summary of Significant Changes From Prior Model	CDF (per year)		LERF (per year)	
		Unit 1	Unit 2	Unit 1	Unit 2
Original IPE (4/1994)	IPE Submittal	3.1×10 ⁻⁵ (same model)		2.7×10 ⁻⁶ (same model)	
Modified IPE ^(b) (3/1997)	Numerous modifications based on NRC concerns on Byron IPE similar to those on other Commonwealth Edison IPEs	4.0×10 ⁻⁵ (same model)		Not Available	
Revision 0 (10/1999)	Changed PRA model from support state model to linked fault tree model involving extensive changes to all event trees and fault trees Updated all data	5.0×10 ⁻⁵	4.9×10 ⁻⁵	4.5×10 ⁻⁶	4.4×10 ⁻⁶
Revision 1 (10/2000)	The SX pump success criterion was changed from two pumps to one pump.	4.6×10 ⁻⁵	4.5×10 ⁻⁵	5.4×10 ⁻⁶	5.3×10 ⁻⁶
Revision 3a (8/2001)	Revised LOOP/DLOOP Event Tree Revised internal flooding analysis Incorporation of plant modifications to CVCS pump lube oil cooler Incorporation of plant mod that removed AFW pump 1B dependency on instrument air	5.5×10 ⁻⁵	5.5×10 ⁻⁵	6.2×10 ⁻⁶	6.1×10 ⁻⁶
Revision 4 (2/2002)	Significant model enhancements to the following systems: RPS, ESFAS, CCW, PORVs, AFW, and instrument power Updated containment failure likelihood	5.3×10 ⁻⁵	5.2×10 ⁻⁵	5.4×10 ⁻⁶	6.2×10 ⁻⁶
Revision 5 (12/2002)	Changed small LOCA and transient accident modeling Addressed miscellaneous model issues Incorporated updated failure and unavailability data, HEPs and support system initiating event frequencies	4.9×10 ⁻⁵	4.7×10 ⁻⁵	4.4×10 ⁻⁶	4.8×10 ⁻⁶
Revision 5B (6/2003)	Reevaluated the plant-specific data Performed full convergence analysis and a human failure dependency analysis Incorporated new SX success criteria Revised the model so that automatic quantification can be performed using ORAM-Sentinel and PSALINK program	6.2×10 ⁻⁵	6.1×10 ⁻⁵	4.7×10 ⁻⁶	5.5×10 ⁻⁶
Revision 5F (12/2006)	Model revised to incorporate conditional DLOOP for most initiators Updated some LERF binning Changed modeling of ESFAS testing Added RWST switchover channel testing and common cause	5.8×10 ⁻⁵	5.7×10 ⁻⁵	4.7×10 ⁻⁶	5.6×10 ⁻⁶

PRA Model	Summary of Significant Changes From Prior Model	CDF (per year)		LERF (per year)	
		Unit 1	Unit 2	Unit 1	Unit 2
Revision 6C (5/2008)	Extensive model update including changes to AFW success criteria, revisions to human error probability to reflect procedure changes and operator interviews, revised internal flooding analysis, updated data analysis, and changes to ESW and CCW modeling.	3.6×10^{-5}	3.6×10^{-5}	2.5×10^{-6}	3.1×10^{-6}
Revision 6E3 (5/2010)	Revised RCP seal LOCA model Incorporated revised feed and bleed success criteria Incorporated AFW unit crosstie modification Revised human reliability assessment	1.7×10^{-5}	1.7×10^{-5}	1.1×10^{-6}	1.4×10^{-6}
Revision BB011a (6/2012)	Updated internal flooding analysis Incorporated new data analysis Incorporated new human reliability dependency and preinitiator analysis Removed credit for AFW unit crosstie modification	4.2×10^{-5}	4.0×10^{-5}	2.6×10^{-6}	3.2×10^{-6}
Revision BB011b (11/2012)	Improved modeling of ESW and CCW systems Incorporated new operator actions for use of ESW and CCW systems	4.0×10^{-5}	3.8×10^{-5}	2.6×10^{-6}	3.2×10^{-6}
Revision BB011b1 (12/2012)	LERF model replaced with Level 2 model based on methodology of WCAP-16341-P	4.0×10^{-5}	3.8×10^{-5}	1.1×10^{-6}	1.0×10^{-6}

(a) Except for Modified IPE information, information in table is based on ER Table F.2-1 with some intermediate models not included.

(b) Information from ComEd 1997.

KEY: AFW = auxiliary feedwater; CCW = component cooling water; CDF = core damage frequency; CVCS = chemical and volume control system; DLOOP = dual unit loss of offsite power; ER = Environmental Report; ESFAS = engineered safety features actuation system; ESW = emergency service water; HEP = human error probability; IPE = individual plant examination; LERF = large early release frequency; LOCA = loss-of-coolant accident; LOOP = loss of offsite power; NRC = U.S. Nuclear Regulatory Commission; PORV = power-operated relief valve; PRA = probabilistic risk assessment; RCP = reactor coolant pump; RPS = reactor protection system; RWST = refueling water storage tank; SX = essential service water; WCAP = Westinghouse Commercial Atomic Power

1 The NRC staff noted in an RAI that ER Table F.2-1, describing changes made to each PRA
2 revision, states PRA Revision 5A “[r]evised the model and data to address the PRA quality
3 issues raised by CR#00142080 (1/30/03) against Rev. 5 model.” The NRC staff requested
4 Exelon to identify the underlying quality process issues and the corrective actions taken. In
5 response to the RAI Exelon stated:

6 The underlying process issue that allowed these technical quality issues to occur
7 was a premature approval of the model prior to full review as required by the
8 work process procedure. Exelon T&RM [Training and Reference Material]
9 ER-AA-600-1015, ‘FPIE [full power, internal event] PRA Model Update,’ provides

Appendix F

1 specific process and review criteria for a new model to be officially approved.
2 [Exelon 2014]

3 Exelon further stated:

4 This process was not followed adequately for Revision 5, resulting in the CR
5 [condition report]. To help ensure that the review items are performed prior to
6 model approval, the Quantification Notebook for each official model of record
7 (including the current model of record) now includes confirmation that the reviews
8 required by ER-AA-600-1015 were performed to check for these and other
9 quality issues. The Quantification Notebook documenting the listed reviews is
10 internally independently reviewed. Signatures of the author, reviewers, and
11 approver confirm this review has been performed, and approval of the
12 Quantification Notebook signifies official approval of the updated model.
13 [Exelon 2014]

14 Exelon indicated that there had been several self-assessments of the Byron PRA, with the latest
15 in 2012 of Revision BB011a, against the Capability Category II requirements of the 2009
16 revision of the American Society of Mechanical Engineers (ASME) PRA standard (ASME and
17 ANS 2009). In response to an NRC staff RAI concerning this self-assessment, Exelon indicated
18 that the self-assessment considered the guidance in Regulatory Guide 1.200, Rev. 2
19 (NRC 2009), and was performed consistent with the NEI 00-02 (NEI 2006) self-assessment
20 process (Exelon 2014).

21 This self-assessment identified two supporting requirements (SRs) that were classified as not
22 being met and 22 that were considered to meet only the Capability Category I requirements.
23 The ER provided a tabulation of the issues related to the SRs that did not meet Capability
24 Category II and the potential impact on the SAMA analysis. All but four of the SRs not meeting
25 Capability Category II were associated with requirements for the LER analysis. This was a
26 result of the self-assessment being performed on the BB011a LERF-only model. These LER
27 issues were addressed in a subsequent assessment as discussed in Section F.2.2.3 below. For
28 the four non-LER issues identified in the self-assessment, Exelon concluded that not meeting
29 the Capability Category II is either conservative or is a small contributor to plant risk and,
30 therefore, requirements would have no meaningful impact on the SAMA analysis. Based on this
31 assessment by Exelon, the NRC staff concludes that meeting the Capability Category I
32 requirements is reasonable for the SAMA evaluation.

33 The NRC staff noted in an RAI that the list of CDF contribution by initiating event (see Table F-1
34 above) included a contribution due to a loss of AP but did not explicitly include a contribution
35 due to a loss of offsite power (LOOP) (NRC 2014). Exelon indicated that the loss of auxiliary
36 power (AP) is a loss of an internal AP bus and is modeled the same as the loss of any other
37 support system. The LOOP contribution is included in the "Other" category and is 1.3 percent
38 and 0.9 percent of the total internal events CDF for Units 1 and 2, respectively. These values
39 are for the LOOP initiating event only and do not include the contributions from LOOP that are
40 the consequences of other initiating events. Both single-unit LOOP and dual unit loss of offsite
41 power (DLOOP) events are included in the Byron PRA (Exelon 2014).

42 The freeze date for the inclusion of plant-specific data for the model was December 2010. In
43 response to an NRC staff RAI concerning actual or planned changes to Byron hardware or
44 operation since the freeze date, Exelon listed a number of modifications being considered, all of
45 which were considered as SAMAs in the license renewal analysis. In addition Exelon stated
46 that "no potential changes in fuel cycle or fuel management are known that would affect the
47 SAMA analysis" (Exelon 2014).

1 As indicated at the November 2013 audit and stated in an RAI response (Exelon 2014), Exelon
2 is planning to install no-leakage reactor coolant pump (RCP) seals at Byron. This planned
3 change is not included in the baseline SAMA analysis but is evaluated as a candidate SAMA.

4 In response to an NRC staff RAI to identify the systems that are shared or can be crosstied
5 between units and describe the modeling, including the treatment of unavailability during
6 outages of the other unit, Exelon indicated that the service water (SW), CCW, auxiliary
7 feedwater (AFW), auxiliary electric power, DC power and instrument air/service air systems are
8 shared or could be crosstied between Byron units and stated that:

9 The Byron PRA is a fully integrated two-unit model, so all components from each
10 unit and those shared between units are explicitly modeled. Unit-specific
11 components which can be used by the opposite unit are linked into the opposite
12 unit's fault tree logic structure.

13 Further, it is indicated that unavailability is modeled with both normal maintenance terms as well
14 as outage maintenance terms for all shared components except those needed during normal full
15 power and outage operations. The normal unavailability is based on unavailable hours during
16 normal power operation while the outage unavailability is based on unavailable hours during an
17 outage and total time (Exelon 2014).

18 During the concurrent reviews of the Byron ER SAMA analysis and that from the very similar
19 Braidwood Station (Exelon 2013a), the NRC staff noted some differences in PRA results
20 between the two sites. In an RAI, the NRC staff asked Exelon to explain the reasons for these
21 differences, and whether the reasons suggest design or operating changes that might be cost-
22 beneficial for one site or the other (NRC 2014). For sequences resulting from RCP seal LOCAs
23 following loss of CCW with failure to establish emergency core cooling system (ECCS)
24 recirculation cooling but with successful cooldown and depressurization, for which the Byron
25 CDF is considerably larger than that for Braidwood, Exelon indicated that the difference is due
26 to a different normal valve alignment at Byron which requires additional operator actions (Exelon
27 2014). For sequences resulting from random nonisolable small LOCAs with failure to establish
28 ECCS recirculation cooling but with successful cooldown and depressurization, for which the
29 Braidwood CDF is considerably larger than that for Byron, Exelon indicated that the difference is
30 primarily because at Braidwood the SX007 SW valves must be throttled open to establish an
31 appropriate flow rate through the component cooling heat exchangers (HXs). This requirement
32 results from SW's being taken from Lake Michigan whose water temperature varies throughout
33 the year. At Byron, the SX007 valves do not need manipulation during an accident
34 (Exelon 2014). The potential for SAMAs suggested by these differences is discussed in
35 Section F.3.2.

36 The NRC staff concludes that the internal events Level 1 PRA model is of sufficient quality to
37 support the SAMA evaluation based on the following:

- 38 • An early revision of the Byron internal events PRA model was peer-reviewed.
- 39 • A more recent revision was subjected to a self-assessment using the 2009 revision of
40 the ASME PRA standard and the guidance in Regulatory Guide 1.200, Revision 2. The
41 self-assessment was performed consistent with the NEI 00-02 self-assessment process,
42 and the review findings were adequately resolved.
- 43 • Exelon has satisfactorily addressed NRC staff questions regarding the PRA.

44 *F.2.2.2 External Events*

45 As indicated above, the Byron PRA used for the SAMA analysis does not include external
46 events. In the absence of such an analysis, Exelon used the Byron IPEEE and other analyses

Appendix F

1 to identify the highest risk accident sequences, to identify the potential means of reducing the
2 risk posed by those sequences, and to estimate the benefit of potential SAMAs. This is
3 discussed below and in Section F.3.2.

4 The Byron IPEEE was submitted in December 1996 (ComEd 1996), in response to
5 Supplement 4 of GL 88-20 (NRC 1991). The submittal included a seismic margin assessment
6 (SMA), a fire assessment using the Electric Power Research Institute (EPRI) fire-induced
7 vulnerability evaluation (FIVE) guidance (EPRI 1992), and a screening analysis for other (high
8 winds, floods and other (HFO)) external events. ComEd did not identify any vulnerabilities in
9 the seismic, fire, or HFO areas. However, during ComEd's IPEEE development several seismic
10 issues were identified as "outliers." Outliers are plant equipment or component conditions that
11 did not meet one or more of the seismic screening criteria and, therefore, required further
12 evaluation during the IPEEE. These outliers were considered in the SAMA evaluation, as
13 discussed further below. In its IPEEE safety evaluation report (SER) (NRC 2001), the NRC staff
14 concluded that the applicant's IPEEE process is capable of identifying the most likely severe
15 accidents and severe accident vulnerabilities for external events and, therefore, that the Byron
16 IPEEE has met the intent of Supplement 4 to GL 88-20.

17 The Byron IPEEE seismic analysis was a focused-scope SMA following NRC guidance (Chen
18 et al. 1991; NRC 1991). The SMA approach is deterministic in nature and does not result in
19 probabilistic risk information. The SMA was performed using a Safe Shutdown Equipment List
20 (SSEL) with plant walkdowns in accordance with the guidelines and procedures documented in
21 EPRI Report NP-6041-SL (EPRI 1991). Two success paths, each capable of mitigating the
22 effects of a seismically induced small break LOCA, were identified based on a review of the
23 guidance and plant documentation. The components on the SSEL were then evaluated for
24 seismic capacity.

25 The components and associated structures in which they are housed were evaluated based on
26 the screening criteria of NP-6041-SL. The review of major structures was based primarily on a
27 review of the design bases augmented by a walkdown to identify any anomalous conditions.
28 Masonry block walls were evaluated and qualified to the seismic design basis loads in
29 compliance with the plant's seismic evaluation criteria. Mechanical and electrical equipment
30 that did not meet the screening criteria were considered SMA outliers. If the equipment had
31 anchorage that was not judged robust by the walkdown team, the high confidence in low
32 probability of failure (HCLPF) anchorage evaluation was calculated to obtain an anchorage
33 seismic capacity.

34 A total of 116 outliers were identified (NRC 2001). The majority of the outliers involve seismic
35 interaction concerns that were resolved through some corrective actions. Others were resolved
36 either by Conservative Deterministic Failure Margin capacity analysis to show the capacity well
37 beyond review-level earthquake demand or by maintenance or modifications. These outliers
38 were considered further in the Phase I SAMA identification discussed in Section F.3 below.

39 For the purposes of the SAMA evaluation, Exelon assumed a seismic CDF of 1×10^{-6} per year in
40 the development of the external events multiplier (Exelon 2013b). Since the SMA approach
41 used in the IPEEE does not involve the determination of seismic CDF and Exelon did not
42 provide a basis for the value used, the NRC staff asked Exelon to consider the impact on the
43 SAMA analysis if a seismic CDF from the generic issue (GI) 199 risk assessment (NRC 2010b)
44 for the Byron site were used. Exelon indicated that, if the weakest link seismic CDF value
45 (5.8×10^{-6} per year) from GI 199 were used, the external events multiplier would increase from
46 2.5 to 2.6 and reevaluated the SAMAs using this multiplier (Exelon 2014). This is discussed in
47 more detail below.

1 The Byron IPEEE included an internal fire analysis employing EPRI's FIVE methodology
2 (EPRI 1992). The NRC's IPEEE SER for Byron reports a total fire CDF of 5.0×10^{-6} per year for
3 Unit 1 and 6.1×10^{-6} per year for Unit 2 (NRC 2001). However, the IPEEE fire analysis has been
4 superseded by the 2009 Byron fire PRA, which Exelon states to be an interim implementation of
5 NUREG/CR-6850 (NRC 2005a), given that not all tasks identified in NUREG/CR-6850
6 (NRC 2005a) are completely addressed or implemented in the model. The total fire CDF for
7 Unit 1 was reported in the ER to be 5.39×10^{-5} per year, which is an order of magnitude greater
8 than that reported in the IPEEE SER. The Unit 2 CDF was not reported since the Unit 2 fire
9 model had not been developed to the same degree as the Unit 1 model (this is discussed
10 further below). While the Byron fire PRA is a risk assessment as compared to the IPEEE fire
11 analysis, which is a screening analysis, it was not used in the SAMA analysis to estimate the
12 risk reduction of individual SAMAs. Rather, the Byron fire PRA was used in the SAMA analysis
13 for determining the fire contribution to the external events multiplier, as well as for identifying
14 potential SAMAs to mitigate the internal fire risk.

15 Exelon indicated that this was because the fire model is not fully integrated with the most recent
16 Level 2 and 3 analyses and is also based on Revision 6C of the internal events PRA rather than
17 the current Revision BB11b1 model used for the internal events SAMA analysis.

18 In response to an NRC staff RAI that asked for more information on the quality and
19 development status of the 2009 Byron fire PRA, Exelon indicated that the fire PRA development
20 tasks do not have any specific quality assurance activities (Exelon 2014). However, internal
21 processes are used to ensure that the tasks are being performed and reviewed by
22 knowledgeable personnel. This is accomplished by the use of certification guides in addition to
23 each document's having three levels of signatures: preparer, reviewer, and approver. In
24 addition, Exelon briefly discussed several conservatisms and nonconservatisms in the current
25 model. The major conservatism identified is in the fire modeling task, which uses generic
26 treatments of the zone of influence and gives no credit for fire severity. The nonconservatisms
27 identified include not accounting for the effects of hot gas layers and the limited modeling of
28 multiple spurious operations. The human reliability analysis (HRA) is identified as having
29 potentially both conservative and nonconservative impacts on the results. A flowchart method is
30 used for determining the human error probabilities (HEPs). The HEPs are generic in nature and
31 modified based on certain parameters that may not be accurate given the actual fire. In
32 addition, the HEPs may be higher due to the unavailability of cues to give the operators a
33 chance to respond to the event or, in some cases, timing constraints (Exelon 2014).

34 The NRC staff notes that, while the 2009 Byron fire PRA is still under development and has not
35 been peer reviewed, the SAMA evaluation should be performed using the best available
36 information on risk insights. The NRC staff concludes that the use of the fire PRA model
37 provides an acceptable basis for identifying and evaluating SAMA candidates based on the
38 following criteria:

- 39 • The 2009 Byron fire PRA model is a more current analysis of the fire risk at Byron than
40 the IPEEE fire analysis and, therefore, is the best currently available fire risk information.
- 41 • The reported fire risk is substantially higher for the fire PRA model than that from the
42 IPEEE.
- 43 • The fire PRA model is being developed in accordance with NUREG/CR-6850,.

44 The major fire core damage contributors for each unit (defined as having a CDF greater than
45 1×10^{-6} per year) are listed in Table F-4. This information was used by Exelon to identify
46 potential SAMAs for the fire events and to evaluate the benefit of any SAMA uniquely directed at
47 reducing the fire risk. This is discussed in Sections F.3 and F.4 below.

Table F-4(a). Major Byron Unit 1 Contributors to Fire CDF

Fire Zone	Fire Zone Description	CDF (per year)
11.3-0	Auxiliary building general area, Elv. 364	1.4×10^{-5}
11.6-0	Auxiliary building general area, Elv. 426	6.0×10^{-6}
5.2-1	Div. 11 ESF switchgear room	4.2×10^{-6}
11.3-1	Unit 1 containment pipe penetration area	4.0×10^{-6}
11.4-0	Auxiliary building general area, Elv. 383	3.8×10^{-6}
11.4C-0	Radwaste and remote shutdown panel control room	3.6×10^{-6}
11.6C-0	Auxiliary building laundry room	1.8×10^{-6}
17.2-2	SX cooling tower, div. 11/21	1.6×10^{-6}
18.14A-1	SX tower electrical equipment room, div. 12	1.5×10^{-6}
5.1-1	Div. 12 ESF switchgear room	1.3×10^{-6}
3.4A-1	Unit 1 cable riser area, Elv. 451	1.2×10^{-6}
18.3-1	Unit 1 main steam and AFW pipe tunnel	1.1×10^{-6}

Key: AFW = auxiliary feedwater; CDF = core damage frequency; div. = Division; Elv. = Elevation;
 ESF = engineered safety feature; SX = essential service water

1

Table F–4(b). Major Byron Unit 2 Contributors to Fire CDF

Fire Zone	Fire Zone Description	CDF (per year)
11.6-2	Div. 22 containment electrical penetrations area	2.1×10^{-5}
11.4-0	Auxiliary building general area, Elv. 383	1.4×10^{-5}
11.6-0	Auxiliary building general area, Elv. 426	1.1×10^{-5}
5.2-2	Div. 21 ESF switchgear room	6.5×10^{-6}
11.4c-0	Radwaste and remote shutdown panel control room	3.6×10^{-6}
1-2	Unit 2 Containment	2.0×10^{-6}
11.3f-2	SI pump 2B room	1.8×10^{-6}
11.3g-2	Centrifugal charging pump 2B room	1.8×10^{-6}
18.14A-1	Fuel handling building	1.8×10^{-6}
17.2-2	SX Cooling Tower, Div. 11/21	1.7×10^{-6}
11.3a-2	SI pump 2A room	1.7×10^{-6}
5.1-2	Div. 22 ESF switchgear room	1.6×10^{-6}
5.5-2	Unit 2 auxiliary electric equipment room	1.5×10^{-6}
3.2-0	Auxiliary building, Elv. 439	1.2×10^{-6}

Key: CDF = core damage frequency; div. = Division; Elv. = Elevation; ESF = engineered safety feature; SI = safety injection; SX = essential service water

2 As stated above, the total fire CDF for Unit 1 was reported in the ER to be 5.39×10^{-5} per year.
3 The Unit 2 CDF was not reported or used since the Unit 2 fire model had not been developed to
4 the same degree as the Unit 1 model. In response to an NRC staff RAI on the development
5 status of the Unit 2 fire PRA model, Exelon explained that at the time the SAMA analysis was
6 performed, the Byron fire model was in the process of being refined to remove model
7 conservatisms, including such changes as taking credit for hot short probabilities to more
8 accurately represent the potential for spurious operation, and refining the cable impacts based
9 on additional circuit analysis. These refinements have been completed for the Byron Unit 1 fire
10 PRA, but not for the Byron Unit 2 fire PRA. Based on this, and the similarities of the two units,
11 the Unit 1 fire CDF was considered the most representative fire CDF for Byron (Exelon 2014).

12 The NRC staff notes that a SAMA evaluation should be performed using the best available risk
13 information. Based on this, and the similarities between the two units, the NRC staff has
14 determined that the fire CDF of 5.39×10^{-5} per year is appropriate for use in the SAMA analysis
15 for both Units 1 and 2.

16 The Byron IPEEE analysis of high winds and tornadoes, external floods, and transportation and
17 other nearby facility accidents (HFO events) followed the screening and evaluation approaches
18 specified in Supplement 4 to GL 88-20 (NRC 1991). For these events, the IPEEE concluded
19 that the Byron design conforms to the 1981 Standard Review Plan criteria (NRC 1981), and,
20 therefore, the contribution to CDF from these events meets the IPEEE screening criterion of
21 1×10^{-6} per year in NUREG–1407 (Chen et al. 1991). No vulnerabilities or enhancements were
22 identified.

Appendix F

1 Based on the aforementioned results, Exelon indicated in the ER that the total external events
2 CDF is approximately 5.8×10^{-5} per year (based on a seismic CDF of 1.0×10^{-6} per year, a fire
3 CDF of 5.4×10^{-5} per year, a high wind CDF of 1.0×10^{-6} per year, an external flooding CDF of
4 1.0×10^{-6} per year, and transportation and other nearby accidents CDF of 1.0×10^{-6} per year),
5 which is approximately 1.5 times the internal events CDF of 4.0×10^{-5} per year. The total CDF
6 (internal and external events) is then approximately 9.8×10^{-5} per year or 2.5 times the Unit 1
7 internal events CDF. This multiplier was used in the SAMA analysis in the ER to account for the
8 impact of external events on the benefits determined from the internal events PRA.

9 As discussed above, the GI 199 risk assessment gives a seismic CDF for Byron of 5.8×10^{-6} per
10 year. Use of this value yields a total external events CDF of 6.3×10^{-5} per year and a total
11 internal plus external events CDF of approximately 1.0×10^{-4} per year, which is approximately
12 2.6 times the Unit 1 internal events CDF. In response to an NRC staff RAI, Exelon stated that it
13 used this higher multiplier in an updated cost-benefit analysis (Exelon 2014).

14 The NRC staff finds that the applicant's conclusion concerning the contribution from seismic,
15 fire, and HFO events to the multiplier used to represent the impact of external events is
16 acceptable and finds that the applicant's use of a multiplier of 2.6 reasonably accounts for
17 external events in the SAMA evaluation. This is discussed further in Section F.6.2.

18 *F.2.2.3 Level 2 Fission Product Release Analysis*

19 The NRC staff reviewed the general process used by Exelon to translate the results of the
20 Level 1 PRA into containment releases, as well as the results of the Level 2 analysis, as
21 described in the ER and in response to NRC staff RAI (Exelon 2014). The current Level 2
22 model is essentially a completely new model replacing the prior LERF model and developed
23 specifically for the SAMA analysis. Exelon states that the current Byron Level 2 model is a
24 state-of-the-art Level 2 analysis structure designed to address the Category II requirements of
25 Regulatory Guide 1.200 (NRC 2009) and the ASME PRA Standard (ASME 2009).

26 The Level 2 model is stated to be generally consistent with the "Simplified Level 2 Modeling
27 Guidelines," WCAP-16341-P (Westinghouse 2005). This WCAP provides a common,
28 standardized method for pressurized-water reactors (PWRs) with large, dry containments to
29 produce an analysis that generally meets Capability Category II of the ASME PRA standard.
30 The guidance particularly addresses the latest understanding for induced SGTRs, direct
31 containment heating, and other important Level 2 phenomena. While the WCAP is focused on
32 modeling the LERF for the ASME standard, it includes guidance for including intact, small, and
33 late releases to provide a more complete, though still standardized, Level 2 analysis.

34 In response to an NRC staff RAI that asked the applicant to identify areas where the Byron
35 model differs from that in WCAP-16341-P, Exelon indicated that the differences include (Exelon
36 2014):

- 37 • No credit for recovery of alternating current power or diesel generator repair
38 after core damage is given.
- 39 • Modeling of potential hot leg rupture following an induced tube rupture, such
40 that the release to the environment is substantially reduced, based on recent
41 research results from the State-of-the-Art Reactor Consequence Analysis
42 project (Bixler et al. 2013).
- 43 • A combined CET is used rather than separate SBO and non-SBO CETs.
44 This is a modeling choice and has no effect on the overall model since
45 recovery of offsite power is not credited.

- Operator action is credited to maintain a sufficient water pool over the steam generator (SG) tubes to scrub releases in SGTR events. While not specifically included in the WCAP methodology, WCAP-16341-P does identify that this type of scrubbing is possible.

As described in Section F.2.3.1 of the ER, PDSs provide the interface between the Level 1 and Level 2 analyses. Each Level 1 accident sequence that leads to core damage consists of a unique combination of an initiating event followed by the success or failure of various plant systems (including operator actions). The Level 1 sequences that result in core damage are grouped into PDS bins. Each bin collects all of those sequences for which the progression of core damage, the release of fission products from the fuel, the status of the containment and its safeguards systems, and the potential for mitigating the potential radiological source terms are similar.

The PDS bins for Byron are characterized by the status of containment bypass due to SGTR or ISLOCA, reactor coolant system pressure, and the availability of feedwater (FW) and AFW.

For Byron, a single detailed CET, which contains both phenomenological and systemic events, assesses the accident progression following a core damage event and analyzes each PDS bin as a group. The Byron CET (shown in ER Figure F.2-4) is stated to be based on the CETs provided in WCAP-16341-P. While the function of the CET is essentially the same as the WCAP CETs, some changes were made to accommodate the capabilities and features of the Byron PRA model. The event tree begins with one or more core damage sequences and then asks a number of questions to determine the type of release, if any, that occurs. Each question is modeled as a top event in the event tree, and the outcome is based on previous work for Byron (including logic taken from the existing model), recent accident progression research, and the guidance provided in the WCAP.

The NRC staff noted in an RAI that ER Section F.2.3.2 indicated that containment failure due to direct containment heating is "0.000" and asked the applicant to clarify how this and other early containment failure (CFE) probabilities are included in the Level 2 models (NRC 2014). In response to the RAI, Exelon indicated that the 0.000 containment failure probability is not a typo, but is the value reported from WCAP-16341-P, which in turn quotes the value from NUREG/CR-6338, *Resolution of Direct Containment Heating Issue for all Westinghouse Plants with Large Dry Containments or Subatmospheric Containments* (Pilch et al. 1996). The WCAP notes that the NUREG provides only three significant digits. The 0.000 value applies to all sequences and all combinations of hydrogen burns, steam explosion, and direct containment heating. Therefore, the probability of CFE at Byron or Braidwood is negligible for any sequence. However, in order to maintain flexibility in the model for sensitivity analyses, the CFE probability is maintained in the model and assigned a probability of 0.001 for any cause or combination of causes (Exelon 2014).

Each CET end state represents a radionuclide release to the environment and is assigned to a release category. Four general release categories were defined: (1) intact, (2) late release, (3) small early release, and (4) LER. Because there are a large number of Level 2 sequences that contribute to each general release category with varying release characteristics, the general release categories are subdivided into 13 detailed release categories.

The LER categories are for the containment bypass or failure conditions that lead to the release: unisolated ISLOCAs, containment isolation failures, CFEs, noninduced SGTRs with and without FW, and pressure- or thermal-induced SGTRs. The late release categories are for containment overpressure failure and basemat melt-through each with or without FW. The small early release categories are for SGTRs with FW available resulting in water level above the SG tubes, and thermally induced SGTRs shortly followed by hot-leg failure.

Appendix F

1 Exelon developed the accident progression and associated release characteristics for each
2 release category, by using the results of MAAP Version 4.0.6 computer code calculations. A
3 representative sequence was selected for each detailed release considering both the likelihood
4 of the scenario and its potential consequences. Since source terms are not always available for
5 each sequence making up a release category, the selection of the representative sequences
6 were based on judgment as to the potential consequences. Exelon stated that the sequence
7 that is judged to be associated with a higher potential source term is used as the representative
8 sequence unless there is another sequence that accounts for a majority of the release category
9 frequency and the sequence with the “higher” source term accounts for less than about
10 10 percent of the release category frequency. In those cases, the “majority” sequence would be
11 chosen as representative (Exelon 2013b). Table F.2-6 of the ER describes the representative
12 sequence used for each release category. Table F.3-8 of the ER describes and justifies the
13 MAAP case for each representative sequence and provides the resulting key event timings. In
14 response to an NRC staff RAI, Exelon stated that the input for the MAAP cases specified the
15 fission product mass as recommended by the MAAP Users Group Bulletin, “MAAP-FLASH #68”
16 (Exelon 2014).

17 The above listed tables indicate that for several release categories the run duration of the MAAP
18 analysis was quite long (200, 800, and 1,600 hours). It was stated that this duration was
19 necessary to achieve a plateau of the release fractions, with primary attention paid to cesium
20 iodide and cesium hydroxide release fractions. In response to NRC staff RAI that asked Exelon
21 to explain the reason for the longer duration and to identify conservatism in the analysis,
22 Exelon indicated that the run times for various MAAP calculations were established based on
23 the timing for the onset of core damage, the timing for either containment failure or containment
24 bypass, and consideration of revaporization of fission products that initially deposited within the
25 reactor coolant system (RCS), particularly on the SG tubes which, after the SG dries out and the
26 tube temperature increases, the deposited fission products become available for release late in
27 the event. The run times were selected to make sure to capture this revaporization
28 phenomenon (Exelon 2014).

29 In response to the RAI, Exelon provided plots of the cesium iodide release as a function of time
30 for a number of release categories, which showed that in many cases a stable total release from
31 the containment is achieved well before the end of the run. For the dominant release category
32 (LATE-CHR-NOAFW), which contributes 50 percent of the population dose risk and 73 percent
33 of the offsite economic cost risk (OECR) the cesium iodide reaches a stable value at 600 hours.
34 For cesium hydroxide (which is stated by Exelon to be the primary driver for long-term dose and
35 costs), the release is slower, and the release fraction is still increasing at a slow rate even at
36 1,600 hours.

37 The NRC staff notes that the above cited times of 600 hours (25 days) and 1,600 hours
38 (67 days) are longer than the time (generally assumed to be less than 100 hours) by which it
39 might reasonably be expected that additional onsite and offsite resources would be available to
40 mitigate the releases. This has a significant impact on the release fractions. For example, from
41 Exelon’s RAI response (Exelon 2014), for the dominant release category, at 72 hours, or 3
42 days, after declaration of a general emergency, the cesium iodide release fraction is 37 percent
43 of the value used in the consequence analysis, while the cesium hydroxide release fraction is 7
44 percent of the value used in the consequence analysis. Alternatively, if the releases were
45 terminated at 144 hours, or 6 days, after declaration of a general emergency, the cesium iodide
46 release would be 63 percent and the cesium hydroxide release would be 16 percent of the
47 values used in the consequence analysis for the dominant release category. Use of these lower
48 release fractions would result in a significant reduction in both population dose risk and OECR.

1 In response to an NRC staff's RAI that asked Exelon to identify the major factors that contribute
2 to the OECR and to discuss their realism and conservatism, Exelon, in addition to discussing
3 the conservatism involved in using the release fractions for very long run times, identified
4 conservative modeling involving the chemical form of cesium. NUREG/CR-7110 (Bixler et al.
5 2013) indicates that only a small fraction of the cesium is in the form of cesium iodide and that
6 the dominant chemical form will be cesium molybdate with the remaining cesium in the form of
7 cesium hydroxide. The Byron SAMA analyses assume that the dominant cesium chemical form
8 is cesium hydroxide. Cesium molybdate has a very low vapor pressure and would therefore be
9 expected to remain deposited on structures (e.g., the tubes in an SG) for a longer time relative
10 to cesium hydroxide. Exelon concluded that the result of this assumption is a conservative
11 SAMA assessment because the release fraction for cesium molybdate would be lower than that
12 for cesium hydroxide (Exelon 2014).

13 The NRC staff noted in an RAI that the analysis of sequences involving containment isolation
14 failure did not allow for CFE due to such phenomenology as hydrogen explosion or direct
15 containment heating (NRC 2014). In response to the RAI, Exelon indicated that while hydrogen
16 explosion and direct containment heating are potential failure modes for the containment
17 isolation failure sequences (release category LERF-CI), the probability of CFE due to these
18 mechanisms is 1×10^{-3} . While the CFE cesium iodide release fraction may be about 20 times
19 larger than the cesium iodide release fraction for containment isolation, the frequency is
20 1,000 times less. Further, the potential contribution from the fraction of isolation failures that
21 result in CFE represent only about 1 percent of the other CFE frequency (release category
22 LERF-CFE). Rebinning the CFE contributions from the LERF-CI release category into the
23 LERF-CFE release category results in no measurable change to the reported population dose
24 risk and OECR values and, therefore, would have no impact on the SAMA analysis (Exelon
25 2014).

26 The results of the Level 2 analysis are provided in ER Tables F.2-8 (release category
27 frequencies) and F.2-7 (timing and magnitude of release). The NRC staff noted in an RAI that,
28 while the release category frequencies for the two units are generally very close (within about
29 10 to 15 percent of each other), for one risk important release category (late containment failure
30 without FW (LATE-CHR-NOAFW)) the Unit 1 frequency is 20 percent more than that for Unit 2
31 (NRC 2014). In response to the RAI Exelon explained that the difference in Unit 1 and Unit 2
32 results for LATE-CHR-NOAFW is related to the assumed default configurations for the two
33 units. For Unit 1, the assumed SX pump configuration models pump 1A in standby and
34 pump 1B running. For Unit 2, the opposite configuration is modeled, with pump 2A running and
35 pump 2B in standby. Because other pumps have the same default configurations in both units,
36 unique train-based power failures can occur at Unit 1 that do not occur at Unit 2. This can result
37 in slightly different sequences because of power dependency failures such as seen here. Unit 1
38 has the higher frequency and was used for the purposes of the SAMA analysis (Exelon 2014).

39 In response to an NRC staff RAI that asked Exelon to describe the steps taken to ensure the
40 technical adequacy of the revised Byron Level 2 PRA model, Exelon indicated, for the initial
41 completion of the updated Level 2 model included in Revision BB011b1 of the PRA, an internal
42 review was conducted examining accident sequence modeling, fault tree modeling, and cutset
43 reviews. The documentation of the BB011b1 model also included a self-assessment and
44 roadmap against Capability Category II of the ASME PRA Standard. This self-assessment and
45 roadmap concluded that all applicable LERF SRs were met at Capability Category II. The
46 signature of the preparer and the reviewer confirm the internal review and agreement with the
47 conclusion of the self-assessment and roadmap. The new Level 2 model replaced the
48 simplified, and generally conservative, previous LERF model. Reductions in LERF come from

Appendix F

1 several improvements, including credit for an operator action to keep an SG full to scrub a
2 release from an SGTR and reduced CFE probabilities (Exelon 2014).

3 The NRC staff reviewed the Level 2 methodology and determined that Exelon satisfactorily
4 addressed NRC staff RAIs. While the updated Level 2 model has not been peer reviewed,
5 Exelon assessed the Level 2 model against the LERF SRs of the ASME PRA standard and
6 determined that all applicable SRs meet the Capability Category II requirements. Therefore, the
7 NRC staff concludes that the Level 2 PRA is of sufficient quality to support the SAMA
8 evaluation.

9 *F.2.2.4 Level 3 Offsite Consequence Analysis*

10 The NRC staff reviewed the process used by Exelon to extend the containment performance
11 (Level 2) portion of the PRA to an assessment of offsite consequences (Level 3 PRA). This
12 included consideration of the source terms used to characterize fission product releases for the
13 applicable containment release categories and the major input assumptions used in the offsite
14 consequence analyses. The MACCS2 code (Version 1.13.1) was utilized to estimate offsite
15 consequences (Chanin and Young 1998). Plant-specific input to the code includes the source
16 terms for each source term category and the reactor core radionuclide inventory (both
17 discussed above), site-specific meteorological data, projected population distribution within an
18 50-mi (80-km) radius for the year 2046, emergency evacuation modeling, and economic data.
19 As indicated in the ER, the reactor core radionuclide inventory used in the consequence
20 analysis was based on end-of-cycle power of 3,645 MWt. The current rated power for Byron is
21 3,586.6 MWt, and the core radionuclide inventory was based on this power (Exelon 2008).
22 Exelon has submitted a license amendment application to the NRC requesting a measurement
23 uncertainty recapture (MUR) power uprate from 3,586.6 MWt to 3,645 MWt (Exelon 2011). The
24 proposed uprate power of 3,645 MWt was included in the MACCS2 analysis by scaling the base
25 core inventory by the power uprate ratio (1.0163). This information is provided in Section 3.5 of
26 Attachment F to the ER (Exelon 2013b). Exelon performed a sensitivity study assuming the
27 current rated power (3,586.6 MWt). The decrease in power of -1.63 percent resulted in a
28 decrease in both population dose risk and cost risk of 1 percent each.

29 Exelon modeled all releases as being from midheight of the reactor containment building and
30 at 10 MW thermal content, except for intact containment (which maintained zero energy).
31 Exelon performed sensitivity studies using zero plume energy (Exelon 2013b). With zero plume
32 heat the dose risk increased approximately 0.2 percent and the cost risk increased
33 approximately 3 percent. Exelon performed sensitivity studies for plume release height and
34 deposition velocity (Exelon 2013b). Release height set to ground level resulted in a decrease in
35 dose risk of 1 percent and a decrease in cost risk of 3 percent. Release height set to the top of
36 containment resulted in an increase in dose risk of 1 percent and an increase in cost risk of
37 3 percent. The deposition velocity was reduced from 0.01 to 0.005 meter per second (m/s)
38 (0.03 to 0.016 foot per second) (a factor of 2), which resulted in a decrease in population dose
39 risk of 8 percent and decrease in cost risk of 19 percent. In response to an NRC staff RAI,
40 Exelon provided additional values and assumptions associated with the MACCS2 model input,
41 including rainfall, mixing height, building wake effects, plume energy, land fraction, region index,
42 watershed index, growing season, fraction of farmland, and shielding and protection factors
43 (Exelon 2014). Based on the information provided, the staff concludes that the release
44 parameters utilized follow NRC guidance in NEI 05-01 or accepted practices from the
45 NUREG-1150 studies and are therefore appropriate for the purposes of the SAMA evaluation.

46 Exelon used site-specific meteorological data for the 2008 calendar year as input to the
47 MACCS2 code. The development of the meteorological data is discussed in Section 3.7 of
48 Attachment F to the ER. The data were collected from onsite meteorological monitoring

1 systems. In response to an NRC staff RAI (Exelon 2014), Exelon clarified that only mixing layer
2 height was based on other meteorological data. The mixing layer height was based on an EPA
3 study (Holzworth 1972) and identified in Section F.3.7 of the ER. Missing data were filled in by
4 substituting data from a different elevation, interpolation, power law, or substituting data from
5 the previous or subsequent day. Sensitivity analyses were performed using MACCS2 and the
6 meteorological data for the years 2009 and 2010 (Exelon 2013b). The year 2009 data resulted
7 in a decrease in dose risk of 4 percent and a decrease in cost risk of 2 percent. The year 2010
8 data resulted in a decrease in dose risk of 1 percent and a decrease in cost risk of 2 percent.

9 Because the overall results of previous SAMA analyses reviewed by the NRC staff have shown
10 little sensitivity to year-to-year differences in meteorological data, the NRC staff concludes that
11 the use of the 2008 meteorological data in the SAMA analysis is reasonable.

12 The population distribution the applicant used as input to the MACCS2 analysis was estimated
13 for the year 2046 using year 2000 census data as accessed by SECPOP2000 (Bixler
14 et al. 2003) as a starting point. The transient population was included in the 10-mi (20-km)
15 emergency planning zone (EPZ), and in the population projection from year 2000 to year 2046.
16 In addition, special facilities population was also included in the initial year 2000 population
17 estimate. In response to an NRC staff RAI, Exelon provided the year 2000 transient, special
18 facility, and residential population distributions (Exelon 2014). These are presented in
19 Tables 4b-2 and 4c-2 of the RAI response. A 30-year population growth rate was estimated
20 using the year 2000 SECPOP2000 data and population growth estimates from the Illinois
21 (IDOC 2012), Wisconsin (WDOA 2012), and Iowa (SDCI 2012) county population projections to
22 year 2030. The year 2030 population estimate was then scaled to year 2046 using this growth
23 rate to obtain the distribution in 2046. NRC staff noticed that Section 2.6.1 of the ER contained
24 year 2010 census population, but that the SAMA analysis used year 2000 census data for
25 estimating population growth. In response to an NRC staff RAI, Exelon compared a projected
26 year 2010 population to the recently available year 2010 census population. The projected
27 population within the 50-mi (80-km) radius was slightly less than, but within, 2 percent of the
28 census population (Exelon 2014). The baseline population was determined for each of 160
29 sectors, consisting of 16 directions for each of 10 concentric distance rings to a radius of 50 mi
30 (80 km) surrounding the site. Individual county growth rates were applied at each grid element.
31 Some grid elements include land from multiple counties. A weighted growth rate was used for
32 those grid elements based on the fraction of land in that grid element associated with each
33 county. Counties that were projected to have negative growth rates were conservatively
34 assumed to have zero growth rates. In response to an NRC staff RAI, Exelon stated that
35 three recently publicized SECPOP2000 code errors were accounted for in the Byron analysis
36 (Exelon 2014). Exelon performed a sensitivity study for the year 2046 population by increasing
37 the population by 30 percent (uniformly). The resulting dose risk increased by 28 percent and
38 cost risk increased by 26 percent. Because population census data and population growth data
39 specific to the location of the Byron plant was used, the NRC staff considers the methods and
40 assumptions for estimating population reasonable and acceptable for purposes of the SAMA
41 evaluation.

42 The emergency evacuation model was modeled as a single evacuation zone and stated to
43 extend out 10 mi (16 km) from the plant (the EPZ) (ET 2003). Exelon assumed that 95 percent
44 of the population would evacuate. This assumption is conservative relative to the
45 NUREG-1150 study (NRC 1990), which assumed evacuation of 99.5 percent of the population
46 within the EPZ. The evacuated population was assumed to move at an average radial speed of
47 approximately 4.4 m/s (9.8 miles per hour (mph)) with a delayed start time of 115 minutes after
48 declaration of a general emergency (Exelon 2013b). The evacuation speed is a time-weighted
49 average value accounting for season, day of week, time of day, and weather conditions

Appendix F

1 (ET 2003). A general emergency declaration was assumed to occur when plant conditions
2 degraded to a point that was judged to be a credible risk to the public. In response to an NRC
3 staff RAI, Exelon clarified that the evacuation study (ET 2003) does not associate specific
4 events with the evacuation time study (Exelon 2014). Exelon performed sensitivity studies for
5 the evacuation speed and delay time to evacuation. The evacuation speed was reduced by
6 50 percent to 2.2 m/s (4.9 mph). The resulting dose risk increased by 2 percent and the change
7 in cost risk was negligible. The evacuation delay time was increased by a factor of 2 to
8 230 minutes. The resulting dose risk decreased by 0.1 percent and the change in cost risk was
9 negligible. The NRC staff concludes that the evacuation assumptions and analysis are
10 reasonable and acceptable for the purposes of the SAMA evaluation.

11 Site-specific agriculture and economic parameters were developed manually using data in the
12 2007 National Census of Agriculture (USDA 2009) and 2007 data from the Bureau of Economic
13 Analysis (BEA 2012) for each of the 21 counties surrounding Byron, to a distance of 50 mi
14 (80 km). Economic values were updated to July 2012 using the consumer price index from the
15 Bureau of Labor Statistics (BLS 2012). The values used for each of the 160 sectors were the
16 data from each of the surrounding counties multiplied by the fraction of that county's area that
17 lies within that sector. Food ingestion was modeled using the new MACCS2 ingestion pathway
18 model COMIDA2 (Chanin and Young 1998). For Byron, approximately 5.6 percent of the total
19 population dose risk is due to food ingestion (approximately 2 person-rem/year) (Exelon 2013b).
20 In response to an NRC staff RAI, Exelon stated that input parameters used were based on food
21 production parameters derived from annual food consumption of an average individual, and that
22 food ingestion dose limits were based on 1998 Food and Drug Administration Guidance
23 (Exelon 2014). Generic economic data that is applied to the region as a whole were revised
24 from the MACCS2 sample problem input in order to account for cost escalation since 1986, the
25 year that input was first specified. A factor of 2.09, representing cost escalation from 1986 to
26 July 2012, was applied to parameters describing cost of evacuating and relocating people, land
27 decontamination, and property condemnation.

28 Exelon performed a sensitivity study for the economic rate of return, resettlement planning, and
29 generic economic inputs. The rate of return was modified to 3 percent as identified in the NRC's
30 comments (NRC 2005b) on Nuclear Energy Institute (NEI) 05-01, "Severe Accident Mitigation
31 Alternative (SAMA) Analysis Guidance Document" (Revision A) (NEI 2005), and 12 percent, the
32 value used in NUREG-1150 MACCS2 analyses, from the base case of 7 percent, consistent
33 with NRC guidance (NRC 2004). The decrease in rate of return (by approximately 57 percent)
34 resulted in an increase in population dose of 1 percent and a decrease in cost risk of 9 percent.
35 The increase in rate of return (by approximately 71 percent) resulted in a decrease in population
36 dose of 2 percent and an increase in cost risk of 10 percent. Resettlement planning was
37 modified assuming no "Intermediate Phase" and a 1-year "Intermediate Phase" (in lieu of 6
38 months). The no intermediate phase resulted in an increase in dose risk of 17 percent and a
39 decrease in cost risk of 32 percent. A 1-year intermediate phase resulted in a decrease in dose
40 risk of 14 percent and an increase in cost risk of 35 percent. Key generic economic input
41 parameters to MACCS2 were modified as shown in Table F.7-1 of the ER. In general, the input
42 variables were increased by a factor of 2. The increase in these economic parameters resulted
43 in a decrease in dose risk of approximately 6 percent, and an increase in cost risk of
44 approximately 48 percent.

45 The NRC staff reviewed the applicant's methods and assumptions for estimating offsite
46 consequences, including the results of several sensitivity analyses on parameter assumptions,
47 and determined that Exelon satisfactorily addressed NRC staff RAIs, that the methods and
48 parameters follow accepted practices, and that offsite consequences are not very sensitive to
49 individual parameter assumptions. Therefore, the NRC staff concludes that the methodology

1 used by Exelon to estimate the offsite consequences for Byron provides an acceptable basis
2 from which to proceed with an assessment of risk reduction potential for candidate SAMAs.

3 Accordingly, based on the NRC staff's conclusions regarding the internal events CDF model,
4 treatment of external events, Level 2 fission product release analysis, and Level 3 offsite
5 consequence analysis, the NRC staff based its assessment of offsite risk on the CDF, offsite
6 population doses, and offsite economic costs reported by Exelon.

7 **F.3 Potential Plant Improvements**

8 The process for identifying potential plant improvements, an evaluation of that process, and the
9 improvements evaluated in detail by Exelon are discussed in this section.

10 **F.3.1 Process for Identifying Potential Plant Improvements**

11 Exelon's process for identifying potential plant improvements (SAMAs) consisted of the
12 following elements:

- 13 • review of the most significant basic events from the current plant-specific
14 PRA including the 2009 Byron fire analysis,
- 15 • review of selected cost-beneficial SAMAs from selected plants,
- 16 • review of potential plant improvements identified in the Byron IPE and IPEE,
17 and
- 18 • insights from the PRA group.

19 Based on this process Exelon identified an initial set of 30 candidate SAMAs, referred to as
20 Phase I SAMAs. In Phase I of the evaluation, Exelon performed a qualitative screening of the
21 initial list of SAMAs and eliminated SAMAs from further consideration using the following
22 criteria:

- 23 • The SAMA is not applicable to Byron plant design.
- 24 • The SAMA has already been implemented or its intent met at Byron.
- 25 • The SAMA has estimated implementation costs that would exceed the dollar
26 value associated with completely eliminating all severe accident risk at Byron.

27 Based on this screening, three SAMAs were eliminated leaving 27 for further evaluation. The
28 results of the Phase I screening analysis are provided in Table F.5-3 of the ER (Exelon 2013b).
29 The remaining SAMAs, referred to as Phase II SAMAs, are listed in Table F.6-1 of the ER
30 (Exelon 2013b). In Phase II, a detailed evaluation was performed for each of the 27 remaining
31 SAMA candidates, as discussed in Sections F.4 and F.6 below. To account for the potential
32 impact of external events, the estimated benefits based on internal events were multiplied by a
33 factor of 2.5 as discussed in Section F.2.2.2. Also as discussed in Section F.2.2.2, this
34 multiplier was increased to 2.6 in response to an NRC staff RAI (Exelon 2014).

35 **F.3.2 Review of Exelon's Process**

36 Exelon's efforts to identify potential SAMAs focused primarily on areas associated with internal
37 initiating events. The initial list of SAMAs generally addressed the accident sequences
38 considered to be important to CDF from functional, initiating event, and risk reduction worth
39 (RRW) perspectives at Byron.

Appendix F

1 Exelon provided in the ER a tabular listing of the Level 1 PRA basic events sorted according to
2 their RRW (Exelon 2013b). The SAMAs impacting these basic events would have the greatest
3 potential for reducing risk. In the ER, Exelon indicates that the review of these events down to
4 an RRW of 1.017 would correspond to a potential benefit of \$100,000 if a SAMA to mitigate this
5 event were 100 percent effective. This value is Exelon's estimate of the cost of a procedure
6 change along with any necessary engineering analysis and training. As Exelon noted, this
7 value of the RRW does not include the potential impact of external events, because the Byron
8 fire results were reviewed separately for potential SAMAs since the fire model is in an interim
9 state. Nevertheless, Exelon used an RRW cutoff of 1.005 in its review of basic events, which
10 corresponds to about a half-percent change in CDF given 100-percent reliability of the SAMA.
11 The NRC staff estimates that this equates to a benefit of approximately \$80,000 (after the
12 benefits have been multiplied by a factor of 2.6 to account for external events).

13 Exelon also provided in the ER tabular listings of the Level 2 PRA basic events for the combined
14 LERF categories and the combined Late Release categories, which in total contribute
15 approximately 95 percent population dose risk and OECR. Exelon also used an RRW cutoff of
16 1.005 when reviewing these basic events for SAMA candidates. The Level 2 sequences for the
17 intact release category were not included in the review so as to prevent high frequency–low
18 consequence events from biasing the importance listing.

19 Exelon's review of the Level 1 and Level 2 importance lists resulted in the identification of
20 26 SAMA candidates.

21 In its review of these importance lists and the SAMAs identified by Exelon, the NRC staff noted
22 the following (NRC 2014):

- 23 • In ER Table F.5-1, for basic event 0VA1SUPP----PNMM "UNIT 1 VA
24 SUPPLY PLENUM MAINTENANCE," the only SAMA identified is SAMA 4,
25 Installation of the "no-leak" RCP seals. The NRC staff suggested a
26 potentially lower cost SAMA to "provide portable ventilation during
27 maintenance activities."
- 28 • In ER Table F.5-1 basic events "1AP-142-1---TRMM" and "1AP-142-2---
29 TRMM" appear to result in the unavailability of the same equipment, namely
30 the startup FW pump and the same condensate pumps. The NRC staff
31 determined that this implies that both system auxiliary transformers (SATs)
32 are needed and suggested an alternative SAMA to temporarily align an
33 alternate power source to the FW system while this maintenance is under
34 way.

35 In response to the RAIs on these issues, Exelon indicated that for basic event 0VA1SUPP----
36 PNMM current plant procedures already direct the alignment of portable fans for CVCS pump
37 room cooling in loss of SX scenarios, which represent 96 percent of the contributors including
38 the 0VA1SUPP----PNMM event. The step to align the portable fans is included in the human
39 failure event (HFE) for establishing alternate lube oil cooling to the CV pumps, which is
40 successful in these scenarios. However, Exelon also stated that the portable fans are not
41 currently credited in the PRA model because there is no basis for assuming they would provide
42 adequate CV pump room cooling (Exelon 2014). Since Exelon already includes providing for
43 portable ventilation in plant procedures and is committed to installing the "no-leak" seals, the
44 NRC staff concludes that this possible alternative SAMA, to provide portable ventilation during
45 maintenance activities, has been adequately explored and is unlikely to be cost-beneficial.

46 Regarding basic events 1AP-142-1---TRMM and 1AP-142-2---TRMM, Exelon indicated that
47 these events involve the availability of the 142-1 and 142-2 SATs. On a plant trip, the balance

1 of plant loads normally supplied by the unit auxiliary transformers (UATs) are transferred to the
2 associated SATs. If, however, a SAT is out of service for maintenance the transfer is disabled
3 because of the potential for overloading the single available SAT. Because of the load
4 limitations on a single SAT, there are no viable temporary power alignments that could be
5 implemented during SAT maintenance using existing hardware. The loads supplied by the UAT
6 could not be prealigned to the available SAT (load limit issue) and the UATs would be
7 deenergized after a plant trip. The opposite unit's SAT can be tied to the non-Class 1E bus
8 through the Class 1E busses, but nonaccident operation in this configuration is not desirable
9 because of the potential for a single fault to fail a division of power on both units (Exelon 2014).
10 Based on this additional information, the NRC staff concludes that Exelon adequately
11 considered and properly rejected the suggested alternative SAMA.

12 The Exelon review of the late release categories importance list identified SAMA 24, to provide
13 a reactor vessel cooling system to prevent vessel melt-through, as a means of mitigating
14 basemat melt-through. The NRC staff noted that based on the Byron IPE (ComEd 1994), plant
15 procedures were implemented to direct reactor cavity flooding in core damage scenarios to
16 provide a means of exterior vessel cooling. Based on the IPE implementation of cavity flooding,
17 the NRC staff requested clarification as to why the additional cooling system in SAMA 24 was
18 required to perform this function. Exelon noted that for cases in which core damage occurred,
19 there was a concern that it might not be possible to perform cavity flooding in the time available
20 to prevent vessel failure. Preventing reactor vessel melt-through not only prevents basemat
21 melt-through but also prevents CFEs such as those due to direct containment heating. A
22 fast-acting system might therefore have added benefit. These additional failures were assumed
23 to be mitigated by SAMA 24 in the ER cost-benefit analysis. The NRC staff considers this
24 description of SAMA 24 and the explanation of its potential benefit to be reasonable.

25 Exelon reviewed the cost-beneficial Phase II SAMAs from prior SAMA analyses for six
26 Westinghouse PWR sites to aid in the identification of additional SAMA candidates. Many of the
27 industry Phase II SAMAs were already represented by other SAMAs in the Byron list, were
28 known not to impact important plant systems or be relevant to the Byron design, or were judged
29 not to have the potential to be close contenders for Byron. As a result, Exelon did not add most
30 of the SAMAs in these prior analyses to the Byron SAMA list. However, Exelon's review
31 resulted in the identification of one additional SAMA candidate, SAMA 26.

32 The NRC staff noted in an RAI that the NRC staff's evaluation of the Indian Point, Units 2 and 3,
33 SAMA analysis (NRC 2010a) identified 13 potentially cost-beneficial SAMAs for Indian Point
34 Unit 2, whereas the Byron review considered only 7 of the 13 SAMAs (NRC 2014). In response
35 to the RAI, Exelon assessed the additional six Indian Point Unit 2 SAMAs and concluded that
36 each either is not applicable to the Byron design, is implemented at Byron, or is already
37 addressed by a Byron candidate SAMA (Exelon 2014).

38 In its review of industry cost-beneficial SAMAs, Exelon noted that two Vogtle SAMAs (SAMAs 6
39 and 16) (NRC 2008) that were originally cost-beneficial were, upon further evaluation of the cost
40 and benefit, judged to not be cost-beneficial at Vogtle. In response to an NRC staff RAI to
41 consider if these SAMAs would be applicable or potentially cost-beneficial at Byron, Exelon
42 determined that the failure being mitigated by Vogtle SAMA 6 (involving adding a bypass line
43 around the cooling tower return valve) is not a significant risk contributor for Byron and the
44 SAMA would not be cost-beneficial. For Vogtle SAMA 16 (involving nonexplicit improvements in
45 ISLOCA procedures), Exelon determined that the intent of this SAMA is already met by existing
46 Byron ISLOCA procedures that are constantly trained on and improved by the plant staff
47 (Exelon 2014). Based on this additional information, the NRC staff concludes that Vogtle
48 SAMAs 6 and 16 have been adequately explored and are unlikely to be cost-beneficial at Byron.

Appendix F

1 Exelon considered the potential plant improvements described in the IPE in the identification of
2 plant-specific candidate SAMAs for internal events. As described in the ER, while the Byron
3 IPE did not identify any vulnerabilities nor provide a definitive list of enhancements, the report
4 did describe a multisite review of IPE and Accident Management insights. The ER indicated
5 that the IPE discussed two enhancements, both of which have been implemented at Byron
6 (Exelon 2013b).

7 The NRC staff noted in an RAI that, according to the NRC staff SER for the IPE (NRC 1997b),
8 the transmittal of the modified Byron IPE indicated that a potential vulnerability involving a
9 dual-unit loss of emergency service water (ESW) due to internal flooding had been identified
10 and that a modification was being considered (NRC 2014). In response to the RAI, Exelon
11 indicated that this modification has not been implemented but is included as SAMA 10 (to alter
12 the ductwork between the auxiliary building sump drain room and the SX pump room) in the
13 SAMA analysis (Exelon 2014).

14 In response to an NRC staff RAI, Exelon indicated that, as part of routine work, PRA groups
15 identify major contributors to plant risk, and, in some cases, the groups have identified specific
16 changes that could reduce risk. As part of the SAMA identification process, the site PRA group
17 was questioned by the applicant's SAMA evaluation team to determine if they have identified
18 any such changes. For Byron, the PRA group did not identify any plant enhancements that
19 were not already identified by the SAMA identification process (Exelon 2014).

20 In response to an NRC staff RAI that asked Exelon to describe the steps taken to identify
21 SAMAs involving improvements in procedures, training, or available cues for the important
22 human errors, Exelon indicated that the HRA quantifications are reviewed to identify the major
23 contributors to the HEP and to determine if there are any practical means of reducing those
24 contributors. Byron SAMAs 7 and 8 are examples of the results of this process (Exelon 2014).

25 As discussed above in Section F.2.2.1, the NRC staff noted some differences in PRA results for
26 the Byron site compared to the similar Braidwood site. Exelon indicated that for certain
27 sequences resulting from RCP seal LOCAs, for which the Byron CDF is considerably larger
28 than that for Braidwood, the difference is due to a different normal alignment of the SX crosstie
29 valves at Byron which requires additional operator actions. Exelon indicated that the planned
30 installation of "no-leak RCP seals" would make RCP seal failures noncontributors, and thus a
31 SAMA to change the Byron valve alignment would not be needed. Exelon further indicated that,
32 without the installation of the no-leak RCP seals, changing the Byron normal operation to be
33 consistent with Braidwood would be cost-beneficial. Exelon indicated that it has previously
34 considered changing the Byron valve alignment, but no changes were made because of
35 considerations unrelated to PRA insights (Exelon 2014). Based on Exelon's planned
36 implementation of SAMA 4, install "no-leak" RCP seals, the NRC staff concludes that a SAMA to
37 change the normal position of the SX crosstie valves has been adequately explored and is
38 unlikely to be cost-beneficial.

39 Based on this information, the NRC staff concludes that the set of SAMAs evaluated in the ER,
40 together with those identified in response to NRC staff RAIs, addresses the major contributors
41 to internal event CDF.

42 As discussed above, risk insights from the 2009 Bryon fire PRA were used to identify SAMA
43 candidates. Since the fire model was not fully integrated with the most recent Levels 2 and 3
44 analyses and the model was based on Revision 6C of the internal events PRA rather than the
45 current Revision BB11b1 model, it could not be used directly in the identification of SAMAs.
46 However, the fire contributors that are potentially significant to risk were reviewed to identify
47 potential SAMAs. Exelon considered and evaluated the fire zones with a CDF contribution

1 greater than the IPEEE screening threshold of 1.0×10^{-6} per year for potential SAMAs. These
2 fire zones are listed in Table F-4.

3 The major fire scenario results for each zone were reviewed and grouped together to help
4 identify target equipment that is common to multiple scenarios in a given fire zone. In response
5 to an NRC staff RAI, Exelon defined major fire scenarios as those contributing 10 percent or
6 more to the fire zone frequency (Exelon 2014). The major scenarios of each of the important
7 fire zones are described and potential SAMAs identified in Section F.5.1.6.1 of the ER. Exelon's
8 review of the major fire scenarios indicated that several of the SAMAs identified to mitigate
9 internal event risks would also mitigate fire-initiated accidents. In addition, Exelon's review of
10 the major fire risk contributors resulted in the identification of three additional SAMA candidates
11 to mitigate fire-initiated accidents.

12 The NRC staff estimates that the CDF screening value of 1.0×10^{-6} per year equates to a benefit
13 of approximately \$110,000 at a 7 percent discount rate. Because \$110,000 is essentially
14 equivalent to Exelon's estimate of \$100,000 as the cost of a procedure change, the NRC staff
15 considers the CDF screening threshold of 1.0×10^{-6} per year for potential fire-mitigating SAMAs
16 reasonable.

17 The NRC staff notes that for four fire zones in Unit 1 and for six fire zones in Unit 2 Exelon
18 states, "Because the fire is a 'bounding' scenario, fire scenarios are not developed for all of the
19 specific ignition sources in the fire zone, which limits the potential for fire specific SAMA
20 identification." In an RAI, the NRC staff noted that Fire Zone U2: 11.6-2, the largest contributor
21 to Unit 2 fire CDF, is analyzed using a bounding scenario and asked Exelon to discuss whether
22 or not insights from the analysis of the same or similar fire zone in Unit 1 can be used to identify
23 potential fire-specific SAMAs. Exelon responded that the Unit 1 counterpart of Fire Zone 11.6-2
24 (Division 22 containment electrical penetrations area) is Fire Zone 11.6-1 (Division 12
25 containment electrical penetrations area), which was also analyzed as a bounding fire and
26 therefore does not provide any additional insights related to fire sources or propagation (Exelon
27 2014).

28 Regarding Fire Zone U1: 11.6c-0 (the auxiliary building laundry room), the NRC asked Exelon
29 to consider a SAMA to move the laundry to another facility if the fire source in the fire zone is
30 due to laundry room operation (NRC 2014). In response to the RAI, Exelon indicated that the
31 laundry equipment has been removed from that room and this room no longer serves that
32 function (Exelon 2014).

33 In response to an NRC staff RAI that asked Exelon to describe the extent to which new or
34 improved Byron fire procedures mitigate the important fires have been considered in the SAMA
35 analysis, Exelon responded that review of the fire procedures to identify improvements in the
36 fire response is an iterative task that is performed as part of the fire PRA development process
37 and is not within the scope of the SAMA analysis (Exelon 2014). Unlike SAMAs to modify
38 Abnormal Operating Procedures and Emergency Operating Procedures, the identification of fire
39 response enhancement requires coordination with the fire modeling team and procedure writers
40 to ensure the actions are consistent with existing procedures and that the proposed changes
41 are appropriate for the failure modes caused by the fire events (Exelon 2014). The NRC staff
42 concludes that further consideration of new or improved fire procedures is not necessary for the
43 Byron SAMA evaluation, while acknowledging the following:

- 44 • The NRC staff cannot conclude that identifying improvements to the fire
45 procedures is beyond the scope of a SAMA analysis since the applicant's
46 CDF screening threshold of 1.0×10^{-6} per year essentially equates to Exelon's
47 estimate of the cost of a procedure change.

Appendix F

- 1 • Exelon evaluated all fire zones having a CDF contribution greater than the
2 screening threshold for potential SAMAs,

3 As discussed in Section F.2.2.2, although the IPEEE did not identify any fundamental
4 vulnerabilities or weaknesses related to external events, several “outliers” were identified from
5 the IPEEE seismic assessment (ComEd 1996). These “outliers” were addressed in the ER and
6 described as “generally items with potential seismically induced interaction issues for which it
7 was difficult to calculate a High Confidence of Low Probability of Failure value” (Exelon 2013b).
8 Exelon described each of the items and their disposition, concluding that no additional SAMAs
9 were needed to address these items. In response to an NRC staff request for clarification of the
10 disposition of these outliers, Exelon provided additional information on each outlier and
11 concluded that each has been dispositioned without the need for additional SAMAs
12 (Exelon 2014).

13 As stated earlier, the Exelon IPEEE analysis of other external hazards (high winds, tornadoes,
14 external floods, and other external events) did not identify opportunities for improvements for
15 these events.

16 The NRC staff notes that the Byron external flooding design and capability, seismic design and
17 capability, and the IPEEE seismic “outliers” were assessed in the engineering walkdowns and
18 evaluations required for the response to the Fukushima Near-Term Task Force’s
19 Recommendation 2.3 (Exelon 2012; NRC 2012; Sargent 2012).

20 An NRC staff RAI questioned Exelon about potentially lower cost alternatives to some of the
21 SAMAs evaluated (NRC 2014), including:

- 22 • A SAMA to modify procedures to avoid clearing of RCS cold leg water seals
23 in the event of core damage. In response to the RAI, Exelon explained that
24 this improvement has already been implemented at Byron because the Byron
25 procedures direct an “RCP bump” to inject reactor coolant line water into the
26 reactor vessel only if the SG level is greater than 10 percent which avoids the
27 clearing of the RCS cold leg seal (Exelon 2014).
- 28 • An SG PORV gagging device for use after an SGTR and stuck-open SG
29 PORV as an alternate to SAMA 14. In response to the RAI, Exelon explained
30 that the Byron design includes isolation valves with manual handwheels
31 upstream of the SG PORVs, hence the ability to stop flow through a
32 stuck-open PORV exists without the need for the gagging device
33 (Exelon 2014).
- 34 • Install “reduced leakage” RCP seals similar to those evaluated for Vogtle
35 SAMA 7 (NRC 2008) as an alternative to the “no-leakage” seals evaluated as
36 Byron SAMA 4. In response to the RAI, Exelon explained that this is not a
37 viable alternative for Byron because (1) Exelon already decided to implement
38 SAMA 4 at Byron, (2) Exelon already made awards for the replacement of the
39 RCP seals, and (3) the cost of engineering and analysis already exceeded
40 the cost given for the Vogtle “reduced leakage” RCP seals (Exelon 2014).
- 41 • Installation of additional flood alarms to assist in mitigating important internal
42 flood scenarios. In response to the RAI, Exelon reviewed the internal
43 flooding events and determined that internal flooding alarms already existed
44 or were evaluated in an existing SAMA (SAMA 16), or determined that the
45 flooding sequences are not risk significant (Exelon 2014).

1 The NRC staff concludes that Exelon used a systematic and comprehensive process for
2 identifying potential plant improvements for Byron, and that the set of potential plant
3 improvements identified by Exelon is reasonably comprehensive and, therefore, acceptable.
4 This search for SAMA candidates by Exelon included reviewing insights from the plant-specific
5 risk studies, and reviewing plant improvements considered in previous SAMA analyses. While
6 explicit treatment of external events other than fire events in the SAMA identification process
7 was limited, the NRC staff determined that the prior implementation of plant modifications
8 identified in the IPEEE and the absence of external event vulnerabilities reasonably justify
9 examining primarily the internal and fire events risk results for this purpose.

10 The NRC staff also notes that the set of SAMAs submitted by Exelon is not all-inclusive, since
11 additional, possibly even less expensive, design alternatives could be postulated. However,
12 because Exelon's SAMA identification process included reviewing all basic events and fire
13 zones having CDF values greater than or equal to the cost of a procedure change, the NRC
14 staff concludes that the benefits of any additional modifications are unlikely to exceed the
15 benefits of the modifications evaluated and that the alternative improvements would not likely
16 cost less than the least expensive alternatives evaluated, when the subsidiary costs associated
17 with maintenance, procedures, and training are considered.

18 Exelon's SAMA ID process included reviewing insights from the plant-specific risk studies, and
19 reviewing plant improvements considered in previous SAMA analyses. While explicit treatment
20 of external events in the SAMA identification process was limited, the NRC staff determined that
21 the prior implementation of plant modifications and the absence of external event vulnerabilities
22 reasonably justify examining primarily the internal events risk results for this purpose.

23 **F.4 Risk Reduction Potential of Plant Improvements**

24 Exelon evaluated the risk-reduction potential of the 27 SAMAs retained for the Phase II
25 evaluation in the ER (Exelon 2013b). The SAMA evaluations were generally performed by
26 Exelon in a realistic or conservative fashion that overestimates the benefit of the SAMA. In
27 most cases, the failure likelihood of the added equipment is taken to be optimistically low,
28 thereby overestimating the benefit of the SAMA. In other cases, it was assumed that the SAMA
29 eliminated all of the risk associated with the proposed enhancement. The NRC staff notes that
30 this bounding approach overestimates the benefit and is conservative.

31 Exelon used model requantification to determine the potential benefits for most of the SAMAs.
32 The CDF, population dose reductions, and offsite economic cost reductions were estimated
33 using the Byron PRA model. The changes made to the model to quantify the impact of each
34 SAMA are described in Section F.6 of the ER for each SAMA. Table F-5 summarizes the
35 assumptions used to estimate the risk reduction for each of the evaluated SAMAs, the
36 estimated risk reduction in terms of percent reduction in CDF, population dose, and offsite
37 economic cost, and the estimated total benefit (present value) of the averted risk. The
38 determination of the benefits for the various SAMAs is further discussed in Section F.6 of this
39 appendix.

40 The NRC staff reviewed the assumptions used in evaluating the benefit or risk reduction
41 estimate of each of the SAMAs as described in the ER Section F.6. In response to an NRC
42 staff RAI, Exelon clarified that for SAMA 14, automating the refueling water storage tank
43 (RWST) makeup, it is conservatively assumed for both SGTR and non-SGTR sequences that
44 transitioning to recirculation mode and terminating break flow (i.e., controlled cooldown) is
45 required. The human errors associated with both of these scenarios are reduced by a factor of
46 10 as a result of the additional time available due to this SAMA (Exelon 2014). In response to
47 another NRC staff RAI, Exelon clarified that for SAMA 15, interunit AFW crosstie, no credit is

Appendix F

1 taken for this during dual-unit events since each unit may require use of its own AFW pump
2 (Exelon 2014). The NRC staff considers the assumptions, as clarified, to be reasonable and
3 acceptable for purposes of the SAMA evaluation because they yield conservative results.

4 For those SAMAs that specifically mitigate fire risk (i.e., SAMAs 27, 28, 30, and 31), a bounding
5 estimate of the SAMA benefits was made. Exelon conservatively assumed that all of the fire
6 risk, or fire CDF, associated with the fire zones affected by the SAMA is eliminated. (Because
7 population dose risk and OEER were not directly calculated, this is noted as “Not Estimated” in
8 Table F-5). Exelon assumed these SAMAs have no additional benefits in internal events. The
9 NRC staff notes that this approach is not necessarily conservative for SAMAs in which the
10 benefit is dominated by the reduction in population dose risk or offsite economic cost risk and
11 not CDF. However, the NRC staff concludes that, since all of the fire mitigating SAMAs were
12 determined by Exelon to be potentially cost-beneficial, further evaluation of these SAMAs is not
13 necessary.

14 The NRC staff has reviewed Exelon’s bases for calculating the risk reduction for the various
15 plant improvements and concludes, with the above clarifications, that the rationale and
16 assumptions for estimating risk reduction are reasonable and generally conservative (i.e., the
17 estimated risk reduction is higher than what would actually be realized). Accordingly, the NRC
18 staff based its estimates of averted risk for the various SAMAs on Exelon’s risk reduction
19 estimates.

Table F-5. SAMA Cost/Benefit Screening Analysis for Byron Station ^(a)

SAMA	Modeling Assumptions	% Risk Reduction			Total Benefit (\$) ^(b)		Cost (\$) ^(b)
		CDF	Population Dose	OECR	Baseline (Internal + External)	Baseline With Uncertainty	
1 – Install diesel driven SX pump in a new dedicated building ^(c)	Reduce the probability of diesel-driven SX pump failure to 1×10^{-2} .	63	80	89	12.8M	32M	>15M
2 – Replace the positive displacement pump with a self-cooled, auto-start pump	Reduce the probability of RCP seal failure on loss of SX. Seal injection pump failure is 1×10^{-3} ; transfer switch is 100% reliable.	66	30	14	4.0M	10.2M	>2.8M
3 – Auto-start of standby SX pump	Reduce the probability of loss of cooling to critical loads on failure of standby SX to start. Auto start failure is 1×10^{-4} .	19	14	9	1.8M	4.5M	>565K
4 – Install “no leak” RCP seals	Reduce the probability of RCP seal for loss of seal cooling. Seal failure probability is reduced by a factor of 1,000.	67	31	15	4.3M	10.6M	>6.5M
5 – Modify the startup feedwater pump to start using the AMSAC SG low-low-low level signal to mitigate AFW failure	Modify FW pump start logic to require failure of both the automated start function and manual operator action. Auto start failure is 1×10^{-4} .	9	21	31	3.9M	9.7M	>328K
7 – Establish flow to the residual heat removal (RHR) HX on RHR pump start	Modify procedures to preclude the need for continuous action statement to protect RHR pumps. Reduce HEP from 7.3×10^{-4} to 1.4×10^{-4} .	2	<1	<1	77K	190K	100K

SAMA	Modeling Assumptions	% Risk Reduction				Total Benefit (\$) ^(b)		
		CDF	Population Dose	OECR	Baseline (Internal + External)	Baseline With Uncertainty	Cost (\$) ^(b)	
8 – Install kill switches for the fire protection pumps in the MCR	Reduce the HEP for termination of fire pump flow. Action time is assumed to be 1 minute per pump.	4	3	2	331K	825K	>217K	
9 – Install flow restrictors in fire protection pipes	Aux building fire break flow is reduced to 1,000 gpm, and is adequate to meet fire suppression requirements. The increase in available time to terminate flow reduces the flood mitigation factor to 1.2×10^{-4} .	8	6	3	709K	1.8M	>174K	
10 – Alter ductwork between the Aux BLDG room and the SX pump room	Completely eliminates the “T1” flooding scenario. Flood mitigation factors for normal SW and SX floods are simplified to HEP for termination of flooding before reaching elevation 364’.	12	12	11	1.7M	4.3M	>660K	
11 – Implement diverse mitigation system (DMS)	A portable 480V generator is aligned to support diesel-driven AFW makeup or a portable SG makeup pump. Failure probability for this function is 1×10^{-2} . Cognitive failure to diagnose the need for secondary cooling, and any dependent combinations, are assumed to fail DMS.	88	80	87	13.4M	33M	>7.3M	

SAMA	Modeling Assumptions	% Risk Reduction			Total Benefit (\$) ^(b)		Cost (\$) ^(b)
		CDF	Population Dose	OECR	Baseline (Internal + External)	Baseline With Uncertainty	
	Eliminates SX dependence for motor-driven AFW pump operation. Reduce the probability of RCP seal failure on loss of SX. Seal injection pump failure is 1×10^{-3} ; transfer switch is 100% reliable.	86	80	88	13.4M	33M	>3.0M
13 – Alternate AFW cooling with seal protection							
	Reduce HEPs for transition to recirculation mode and terminate break flow by a factor of 10. Reduce impacted joint HEPs (JHEPs) to 0 or by a factor of 10.	1	<1	<1	71K	176K	3.8M
14 – Automate RWST makeup							
15 – Resolve regulatory issues and complete implementation of the interunit AFW crosstie	The AFW crosstie action execution failure probability is 2 reduced to 2.4×10^{-2} .	2	2	3	417K	1M	0
16 – Install high flow sensors on the non-SX system	Completely eliminates all risk associated with SW flood event scenarios.	2	5	6	823K	2M	>496K
17 – Use AMSAC for alternate low SG level AFW initiation	Eliminates the independent manual AFW initiation HFE in conjunction with all associated JHEPs. The AMSAC logic is 100% reliable.	<1	<1	<1	26K	65K	>490K
18 – Automate refill of the diesel-driven AFW pump fuel oil day tank	Eliminates the independent HFE and all dependent combinations to refill the AFW pump fuel oil day tank. The AMSAC logic is 100% reliable.	<1	<1	<1	78K	194K	>804K

SAMA	Modeling Assumptions	% Risk Reduction			Total Benefit (\$) ^(D)		Cost (\$) ^(B)
		CDF	Population Dose	OECR	Baseline (Internal + External)	Baseline With Uncertainty	
19 – Replace MOVs in the RHR discharge line with valves that can isolate an ISLOCA event	Completely eliminates all risk from the ISLOCA events occurring in the RHR discharge lines.	<1	10	4	637K	1.6M	900K
20 – Disallow online RHR maintenance	Eliminates all risk associated with RHR maintenance events.	<1	<1	<1	16K	40k	20M
21 – Install an emergency isolation valve in each of the RHR suction lines	Completely eliminates all risk from the ISLOCA events occurring in the RHR discharge lines.	0	2	1	163K	407K	1.6M
22 – Install the same high flow isolation logic used on Valve_CC685 on Valve_9438	Completely eliminates all risk from the ISLOCA events occurring in the RCP thermal barrier cooling HXs.	0	1	<1	46K	114K	250K
23 – Install a passive hydrogen ignition system	Completely eliminates all containment failures due to hydrogen detonation.	0	<1	<1	40K	99K	760K
24 – Provide a reactor vessel exterior cooling system	Completely eliminates relocation of the core to the containment floor and eliminates all CFEs. Allow scrubbing to maximize averted cost.	0	<1	<1	33K	81K	>1.2M
25 – Install a filtered containment vent	The filtered vent reduces the consequential dose and offsite economic cost associated with containment overpressure failures by a factor of 10.	0	72	79	9.8M	24.5M	5.7M

SAMA	Modeling Assumptions	% Risk Reduction			Total Benefit (\$) ^(b)		Cost (\$) ^(b)
		CDF	Population Dose	OECR	Baseline (Internal + External)	Baseline With Uncertainty	
26 – DMS using a dedicated generator, self-cooled charging pump, and a portable AFW pump	Indefinite AFW makeup capability and an alternate high-pressure injection function capable of providing alternate seal injection to prevent RCP seal LOCAs. The frequency of seal LOCA sequences is reduced by a factor of 100.	88	80	87	13.4M	33M	2.4M
27 – Protect RHR, SI and CVCS cubicle cooling fan cables in Fire Zone 11.3-0	Completely eliminates all of the risk associated with Fire Zone 11.3-0.	^(d) 26	Not Estimated		2.1M	5.2M	975K
28 – Install fire barriers around Motor Control Center (MCC) 134X	Completely eliminates all of the risk associated with Fire Zone 11.6-0.	^(d) 11	Not Estimated		904K	2.3M	975K
29 – Automate swap to recirculation mode	Completely eliminates the contribution from the failure to swap to recirculation mode.	1	<1	<1	45K	110K	>1.2M
30 – Protect AFW cables in the AUX building general area, elevation 383'	Completely eliminates all of the risk associated with Fire Zone 11.4-0.	^(d) 7	Not Estimated		571K	1.4M	975K
31 – Protect cables for 2AF013A, B, and D in the AUX building general area, elevation 426'	Completely eliminates all of the risk associated with Fire Zone 11.6-0 (unit 2).	^(d) 20	Not Estimated		1.6M	4M	975K

SAMA	Modeling Assumptions	% Risk Reduction			Total Benefit (\$) ^(b)		
		CDF	Population Dose	OECR	Baseline (Internal + External)	Baseline With Uncertainty	Cost (\$) ^(b)
	<p>^(a) SAMAs in bold are potentially cost-beneficial.</p> <p>^(b) The estimated benefits and implementation costs were revised in response to NRC staff RAI 3.d, 6.a, and 6.f (Exelon 2014).</p> <p>^(c) The modeling assumptions for SAMA 1 are provided in Exelon 2013a. The estimated risk reduction for SAMA 1 CDF, population dose, and OECR were provided in response to NRC staff RAI 3.d (Exelon 2014).</p> <p>^(d) The risk reduction for fire-mitigating SAMAs was estimated by the NRC staff, utilizing information provided in the ER, as the ratio of the reduction in fire CDF divided by the total fire CDF of 5.4×10^{-5} per year.</p> <p>Key: AFW = auxiliary feedwater; AMSAC = ATWS mitigating system actuation circuitry; CDF = core damage frequency; CFE = early containment failure; CVCS = chemical and volume control system; DMS = diverse mitigation system; FW = feedwater; gpm = gallons per minute; HEP = human error probability; HFE = human failure event; HX = heat exchanger; ISLOCA = interfacing-systems loss-of-coolant accident; JHEP = joint human error probability; LOCA = loss-of-coolant accident; MCR = main control room; MOV = motor-operated valve; NRC = U.S. Nuclear Regulatory Commission; OECR = offsite economic cost risk; RAI = requests for additional information; RCP = reactor coolant pump; RHR = residual heat removal; RWST = refueling water storage tank; SAMA = severe accident mitigation alternative; SG = steam generator; SW = service water; SX = essential service water</p>						

Sources: Exelon 2013a, 2014

1 **F.5 Cost Impacts of Candidate Plant Improvements**

2 In the ER, Exelon estimated the costs of implementing the candidate SAMAs through the
3 development of Byron-specific cost estimates, the use of industry estimates, and, in some
4 cases, combinations of these two sources. It was also noted that Byron-specific implementation
5 costs do include contingency costs for unforeseen difficulties but do not account for any
6 replacement power costs (RPCs) that may be incurred due to consequential shutdown time
7 unless specifically noted. In response to an NRC staff RAI, Exelon stated that a consulting firm
8 was used to develop “order of magnitude” estimates for the cost of SAMA implementation
9 (Exelon 2014). Details such as cost of equipment, demolition, scaffolding, overtime,
10 consumables, freight, engineering, etc. were used to develop the costs. Exelon provided the
11 components of the cost estimates associated with developing supporting procedures, providing
12 lifelong training, and applicable simulator updates.

13 Exelon also identified in the RAI response that the cost estimates for several SAMAs (SAMAs 2,
14 3, 4, 5, 8, 9, 10, 11, 13, 16, 17, and 18) were for both Units 1 and 2 rather than for a single unit
15 (Exelon 2014). Revised implementation cost estimates for each of these SAMAs were provided
16 on a per unit basis. The corrected implementation costs were utilized in an updated cost-benefit
17 analysis and are reflected in Table F–5. Detailed cost estimates were not developed for SAMAs
18 that were judged to have implementation costs that far exceeded the estimated benefit.

19 In response to an NRC staff RAI concerning savings due to sharing of costs between units and
20 between the Byron and Braidwood sites, Exelon clarified that since implementation costs were
21 developed on a “per site” basis, cost sharing between units was accounted for in the updated
22 analysis by dividing the “per-site” costs in half to obtain the “per-unit” costs (Exelon 2014). Cost
23 sharing, however, was not considered between sites. Exelon explained that if cost sharing
24 between sites were possible, engineering costs at the first sister plant are estimated to be
25 generally 75 percent to 80 percent of the original costs if the modifications are identical.
26 However, Exelon indicated that sharing of costs between sites is not appropriate because:

- 27 • A SAMA implemented at one site will not necessarily be implemented at the
28 other site.
- 29 • While cost sharing between sites could reduce some implementation costs,
30 any reductions in cost would be offset if other costs were also accounted for,
31 such as inflation and RPCs.
- 32 • The SAMA designs are conceptual and the cost estimates provided are
33 “order of magnitude” estimates. Changes in the per-site engineering costs of
34 12 to 13 percent are expected to be within the margin of error.
- 35 • Actual installation costs are generally larger than estimated installation costs.
- 36 • The impact of accounting for intersite cost-sharing is bounded by the results
37 of the CDF uncertainty analysis, which is discussed in Section F.6.2.

38 The NRC staff concludes that the amount of cost savings due to sharing of cost between sites is
39 highly uncertain. The NRC staff also believes that the estimated implementation costs could be
40 reduced by up to 25 percent if sharing of costs is accounted for between the Byron and
41 Braidwood sites. However, accounting for a 25 percent reduction in the implementation costs
42 shown in Table F–5 would not result in any additional potentially cost-beneficial SAMAs. Based
43 on this result, the NRC staff considers the RAI issue concerning savings due to sharing of costs
44 between units and between the Byron and Braidwood sites resolved.

Appendix F

1 Exelon estimated that the minimum cost of making a change to a procedure and for conducting
2 the necessary training on a procedure change to be \$100,000. In response to an NRC staff
3 RAI, Exelon stated that although potentially lower cost estimates could be developed for
4 procedure changes, all SAMAs associated with procedure changes were found to be
5 cost-beneficial (Exelon 2014). Since all SAMAs associated with procedure change were found
6 to be potentially cost-beneficial, reducing the cost of a procedure change to less than \$100,000
7 would have no impact on the SAMA analysis results, and, based on this, the NRC staff finds this
8 RAI response acceptable.

9 For SAMAs 12 and 20, an NRC staff RAI requested that Exelon explain why the implementation
10 cost estimates for these SAMAs assumed an extended outage time rather than assuming
11 maintenance was performed in parallel with other outage activities (NRC 2014). Exelon
12 responded that for SAMA 12, the SAT is the primary source of power to systems supporting
13 spent fuel pool cooling when the fuel is in the spent fuel pool (Exelon 2014). At Byron, SAT
14 work has not been performed during refueling outages as the refueling unit's SAT is protected
15 during the entire outage. Shutdown risk procedures do not allow for SAT work anytime fuel is in
16 the reactor vessel. The SAT protection could be removed during defueled conditions when the
17 core fuel is in the spent fuel pool. However, the standard template for the defueled window is
18 only 32 hours. The proposed SAT maintenance typically requires approximately 14 days to
19 complete, requiring the outage to be extended. In addition, non-ESF buses are powered by the
20 SAT that is needed during the outage. Reconfiguration of the SAT would hamper the ability to
21 perform other normal outage work. Exelon responded that for SAMA 20, the primary driver is
22 that any work on an RHR train be performed during the defueled window (Exelon 2014). When
23 fuel is in the reactor vessel, it is desirable to have both RHR trains in service. In addition, while
24 pump suction and HX work could be done online, the inability to vent the RH pump discharge
25 requires that this work be performed during an outage. The proposed RHR maintenance
26 typically requires approximately 4 to 5 days to complete, requiring the outage to be extended.
27 Based on this additional information, the NRC staff considers the estimated costs for SAMAs 12
28 and 20 to be reasonable and acceptable for purposes of the SAMA evaluation.

29 For certain improvements, the NRC staff compared the cost estimates to estimates developed
30 elsewhere for similar improvements, including estimates developed as part of other licensees'
31 analyses of SAMAs for operating reactors.

32 For SAMA 1, Install a dedicated diesel-driven SX pump, the NRC staff noted that the cost
33 estimate from the Limerick SAMA analysis used as the basis for the cost estimate included
34 large HXs and safety-related equipment (PECO 1989). An NRC staff RAI questioned whether
35 non-safety grade equipment could be considered, and that large HXs significantly increase cost
36 but are not needed in SAMA 1 (NRC 2014). In response to the RAI, Exelon reevaluated the
37 cost estimate for SAMA 1 and provided the updated cost, which is included in Table F-5.

38 Given that Exelon followed the guidance in NEI 05-01 (NEI 2005) and satisfactorily addressed
39 NRC questions regarding cost estimates, the NRC staff concludes that the cost estimates
40 provided by Exelon are sufficient and appropriate for use in the SAMA evaluation.

41 **F.6 Cost-Benefit Comparison**

42 Exelon's cost-benefit analysis and the NRC staff's review are described in the following
43 sections.

1 F.6.1 Exelon's Evaluation

2 The methodology used by Exelon was based primarily on NRC's guidance for performing
3 cost-benefit analysis, i.e., NUREG/BR-0184, *Regulatory Analysis Technical Evaluation*
4 *Handbook* (NRC 1997c). The guidance involves determining the net value for each SAMA
5 according to the following formula:

6
$$\text{Net Value} = (\text{APE} + \text{AOC} + \text{AOE} + \text{AOSC}) - \text{COE}, \text{ where}$$

7 APE = present value of averted public exposure (\$)

8 AOC = present value of averted offsite property damage costs (\$)

9 AOE = present value of averted occupational exposure costs (\$)

10 AOSC = present value of averted onsite costs (\$)

11 COE = cost of enhancement (\$)

12 If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the
13 benefit associated with the SAMA and it is not considered cost-beneficial. Exelon's derivation of
14 each of the associated costs is summarized below.

15 NUREG/BR-0058 has recently been revised to reflect the agency's policy on discount rates.
16 Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed, one at
17 3 percent and one at 7 percent (NRC 2004). Exelon provided a base set of results using the
18 3 percent discount rate and a sensitivity study using the 7 percent discount rate (Exelon 2013b).

19 Averted Public Exposure Costs

20 The averted public exposure (APE) costs were calculated using the following formula:

21
$$\text{APE} = \text{Annual reduction in public exposure } (\Delta \text{ person-rem/year})$$

22
$$\times \text{monetary equivalent of unit dose } (\$2,000 \text{ per person-rem})$$

23
$$\times \text{present value conversion factor } (15.04 \text{ based on a 20-year period with a}$$

24
$$3\text{-percent discount rate})$$

25 As stated in NUREG/BR-0184 (NRC 1997c), it is important to note that the monetary value of
26 the public health risk after discounting does not represent the expected reduction in public
27 health risk due to a single accident. Rather, it is the present value of a stream of potential
28 losses extending over the remaining lifetime (in this case, the renewal period) of the facility.
29 Thus, it reflects the expected annual loss due to a single accident, the possibility that such an
30 accident could occur at any time over the renewal period, and the effect of discounting these
31 potential future losses to present value. For the purposes of initial screening, which assumes
32 elimination of all severe accidents, Exelon calculated an APE of approximately \$1,070,000 for
33 the 20-year license renewal period (Exelon 2013b).

34 Averted Offsite Property Damage Costs

35 The averted offsite property damage costs (AOC) were calculated using the following formula:

36
$$\text{AOC} = \text{Annual CDF reduction}$$

37
$$\times \text{offsite economic costs associated with a severe accident (on a per-event}$$

38
$$\text{basis})$$

39
$$\times \text{present value conversion factor}$$

40 This term represents the sum of the frequency-weighted offsite economic costs for each release
41 category, as obtained for the Level 3 risk analysis. For the purposes of initial screening, which
42 assumes elimination of all severe accidents caused by internal events, Exelon calculated an

Appendix F

1 OECR of about \$254,600 based on the Level 3 risk analysis (Exelon 2013b). This results in a
2 discounted value, or AOC, of approximately \$3,830,000 for the 20-year license renewal period.

3 Averted Occupational Exposure Costs

4 The averted occupational exposure (AOE) costs were calculated using the following formula:

$$\begin{aligned} 5 \quad \text{AOE} &= \text{Annual CDF reduction} \\ 6 \quad &\times \text{occupational exposure per core damage event} \\ 7 \quad &\times \text{monetary equivalent of unit dose} \\ 8 \quad &\times \text{present value conversion factor} \end{aligned}$$

9 Exelon derived the values for AOE from information provided in Section 5.7.3 of the regulatory
10 analysis handbook (NRC 1997c). Best estimate values provided for immediate occupational
11 dose (3,300 person-rem) and long-term occupational dose (20,000 person-rem over a 10-year
12 cleanup period) were used. The present value of these doses was calculated using the
13 equations provided in the handbook in conjunction with a monetary equivalent of unit dose of
14 \$2,000 per person-rem, a real discount rate of 3 percent, and a time period of 20 years to
15 represent the license renewal period. For the purposes of initial screening, which assumes
16 elimination of all severe accidents caused by internal events, Exelon calculated an AOE of
17 approximately \$24,600 for the 20-year license renewal period (Exelon 2013b).

18 Averted Onsite Costs

19 Averted onsite costs (AOSC) include averted cleanup and decontamination costs (ACC) and
20 averted power replacement costs. Repair and refurbishment costs are considered for
21 recoverable accidents only and not for severe accidents. Exelon derived the values for AOSC
22 based on information provided in Section 5.7.6 of NUREG/BR-0184, the regulatory analysis
23 handbook (NRC 1997c).

24 Exelon divided this cost element into two parts—the onsite cleanup and decontamination cost,
25 also commonly referred to as ACC, and the RPC.

26 ACCs were calculated using the following formula:

$$\begin{aligned} 27 \quad \text{ACC} &= \text{Annual CDF reduction} \\ 28 \quad &\times \text{present value of cleanup costs per core damage event} \\ 29 \quad &\times \text{present value conversion factor} \end{aligned}$$

30 The total cost of cleanup and decontamination subsequent to a severe accident is estimated in
31 NUREG/BR-0184 to be $\$1.5 \times 10^9$ (undiscounted). This value was converted to present costs
32 over a 10-year cleanup period and integrated over the term of the proposed license extension.
33 For the purposes of initial screening, which assumes elimination of all severe accidents caused
34 by internal events, Exelon calculated an ACC of approximately \$774,000 for the 20-year license
35 renewal period.

36 Long-term RPCs were calculated using the following formula:

$$\begin{aligned} 37 \quad \text{RPC} &= \text{Annual CDF reduction} \\ 38 \quad &\times \text{present value of replacement power for a single event} \\ 39 \quad &\times \text{factor to account for remaining service years for which replacement power is} \\ 40 \quad &\text{required} \\ 41 \quad &\times \text{reactor power scaling factor} \end{aligned}$$

1 Exelon based its calculations on a Byron net output of 1,185 megawatts electric (MWe) and
 2 scaled up from the 910-MWe reference plant in NUREG/BR-0184 (NRC 1997c). Therefore,
 3 Exelon applied a power scaling factor of 1185/910 to determine the RPCs. For the purposes of
 4 initial screening, which assumes elimination of all severe accidents caused by internal events,
 5 Exelon calculated an RPC of approximately \$286,000 and an AOSC of approximately
 6 \$1,060,000 for the 20-year license renewal period.

7 Using the above equations, Exelon estimated the total present dollar value equivalent
 8 associated with completely eliminating severe accidents from internal events at Byron to be
 9 about \$5,979,393, also referred to as the maximum averted cost-risk (MACR). The internal
 10 events MACR is rounded to the next highest thousand (\$5,980,000) for SAMA calculations.
 11 Use of a multiplier of 2.5 to account for external events increases the value to \$14.95M and
 12 represents the dollar value associated with completely eliminating all internal and external event
 13 severe accident risk for Byron, also referred to as the modified MACR.

14 Exelon's Results

15 If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA
 16 was considered not to be cost-beneficial. In the baseline analysis contained in the ER (using a
 17 3 percent discount rate), Exelon identified 10 potentially cost-beneficial SAMAs (SAMAs 3, 5, 9,
 18 10, 13, 15, 25, 26, 27, and 31). Based on consideration of uncertainty analysis, Exelon
 19 identified an additional eight potentially cost-beneficial SAMAs (SAMAs 2, 7, 8, 11, 16, 19, 28,
 20 and 30). In response to NRC staff RAI, Exelon provided the results of revised baseline and
 21 uncertainty analyses to account for updated SAMA implementation cost estimates, a revised
 22 multiplier of 2.6 to account for external events, and revisions to the uncertainty analysis
 23 (Exelon 2014). As a result, Exelon did not identify any additional cost-beneficial SAMAs in the
 24 baseline analysis, but did identify two additional potentially cost-beneficial SAMAs when
 25 uncertainties were considered (SAMAs 1 and 4).

26 The potentially cost-beneficial SAMAs for Byron are as follows:

- 27 • SAMA 1 – Install Diesel-Driven SX Pump in a new dedicated building
- 28 • SAMA 2 – Replace the Positive Displacement Pump with a Self-Cooled,
29 Auto-Start Pump
- 30 • SAMA 3 – Auto Start of Standby SX Pump
- 31 • SAMA 4 – Install “No Leak” Seals
- 32 • SAMA 5 – Modify the Startup Feedwater Pump to Start Using the AMSAC SG
33 Low-Low-Low Level Signal to Mitigate AFW Failure
- 34 • SAMA 7 – Establish Flow to the RHR HX on RHR Pump Start
- 35 • SAMA 8 – Install Kill Switches for the Fire Protection Pumps in the MCR
- 36 • SAMA 9 – Install Flow Restrictors in Fire Protection Pipes
- 37 • SAMA 10 – Alter Ductwork Between the Aux BLDG Room and the SX Pump
38 Room
- 39 • SAMA 11 – Implement DMS
- 40 • SAMA 13 – Alternate AFW Cooling with Seal Protection
- 41 • SAMA 15 – Resolve Regulatory Issues and Complete Implementation of the
42 Interunit AFW Crosstie

Appendix F

- 1 • SAMA 16 – Install High-Flow Sensors on the non-Essential Service Water
2 System
 - 3 • SAMA 19 – Replace MOVs in the RHR Discharge Line with Valves that can
4 Isolate an ISLOCA Event
 - 5 • SAMA 25 – Install a Filtered Containment Vent
 - 6 • SAMA 26 – DMS Using a Dedicated Generator, Self-Cooled charging Pump,
7 and a Portable AFW Pump
 - 8 • SAMA 27 – Protect RHR, SI and CVCS Cubicle Cooling Fan Cables in Fire
9 Zone 11.3-0
 - 10 • SAMA 28 – Install Fire Barriers Around MCC 134X
 - 11 • SAMA 30 – Protect AFW Cables in the AUX Building General Area,
12 Elevation 383'
 - 13 • SAMA 31 – Protect Cables for 2AF013A, B, and D in the AUX Building
14 General Area, Elevation 426'
- 15 The potentially cost-beneficial SAMAs and Exelon's plans for further evaluation of these SAMAs
16 are discussed in more detail in Section F.6.2.

17 **F.6.2 Review of Exelon's Cost-Benefit Evaluation**

18 The cost-benefit analysis performed by Exelon was based primarily on NUREG/BR-0184
19 (NRC 1997c) and discount rate guidelines in NUREG/BR-0058 (NRC 2004) and was executed
20 consistent with this guidance.

21 SAMAs identified primarily on the basis of the internal events analysis could provide benefits in
22 certain external events, in addition to their benefits in internal events. Exelon accounted for the
23 potential risk reduction benefits associated with external events by applying a multiplier to the
24 estimated benefits for internal events. In the analysis reported in the ER, Exelon multiplied the
25 estimated benefits for internal events by a factor of 2.5 incorporating an external events
26 multiplier of 1.5 to account for external events (Exelon 2013b). As discussed above, 10 SAMAs
27 were determined to be potentially cost-beneficial in Exelon's baseline analysis (SAMAs 3, 5, 9,
28 10, 13, 15, 25, 26, 27, and 31). As discussed in Section F.2.2.2, in response to an NRC staff
29 RAI, Exelon provided a revised baseline evaluation by applying a multiplier of 2.6 [(fire CDF of
30 5.39×10^{-5} per year + seismic CDF of 1.0×10^{-6} per year + external flooding CDF of 1.0×10^{-6} per
31 year + high winds CDF of 1.0×10^{-6} per year + transportation and nearby facility accident CDF of
32 1.0×10^{-6} per year) / (internal events CDF of 3.97×10^{-5} per year) + 1] to account for external
33 events (Exelon 2014). The results of this revised evaluation are provided in Table F-5. No
34 additional potentially cost-beneficial SAMAs were identified as a result of this revised evaluation
35 (using a multiplier of 2.6 and a 3-percent discount rate), which incorporated the revised SAMA
36 implementation costs discussed in Section F.5.

37 Exelon considered the impact that possible increases in benefits from analysis uncertainties
38 would have on the results of the SAMA assessment. In the ER, Exelon presents the results of
39 an uncertainty analysis of the internal events CDF which indicates that the 95th-percentile value
40 is a factor of 2.49 times the point estimate CDF for Byron. Exelon considered whether any
41 additional Phase I SAMAs might be retained for further analysis if the benefits from internal and
42 external events were increased by a factor of 2.49. One additional SAMA (SAMA 20) was
43 identified. Exelon also considered the impact on the Phase II screening if the estimated benefits
44 from internal and external events were increased by a factor of 2.49. The additional Phase I

1 SAMA, SAMA 20, was included in this sensitivity analysis. As discussed above, eight SAMAs
2 (SAMAs 2, 7, 8, 11, 16, 19, 28, and 30) were determined to be potentially cost-beneficial in
3 Exelon's analysis.

4 In an RAI, the NRC staff noted that the mean CDF (for PRA model BB011a) was lower than the
5 point estimate and that, usually, the mean CDF is greater than the point estimate because of the
6 correlation of uncertainties (NRC 2014). In response to the RAI, Exelon responded that many of
7 the largest contributors to the Byron PRA results are human probabilities, joint human error
8 probabilities (JHEPs), or flood mitigation events that include operator errors, which are not
9 correlated events. In addition, several contributors with large failure probabilities were assigned
10 lognormal distributions with relatively high error factors. These factors can act to reduce the
11 mean relative to the point estimate. Exelon redid the uncertainty analysis using revised error
12 factors for selected events and determined that the revised 95th-percentile value is a factor of
13 2.53 times the point estimate CDF for Byron. Exelon considered whether any additional Phase I
14 SAMAs might be retained for further analysis if the benefits from internal and external events
15 were increased by a factor of 2.53 (in addition to the multiplier of 2.6 for external events and
16 revised SAMA implementation costs discussed in Section F.5). One additional SAMA (SAMA 1)
17 was identified. Exelon also considered the impact on the Phase II screening if the estimated
18 benefits from internal and external events were increased by a factor of 2.53 (in addition to the
19 multiplier of 2.6 for external events and revised SAMA implementation costs discussed in
20 Section F.5). Two additional SAMAs (SAMAs 1 and 4) became cost-beneficial as a result of this
21 revised evaluation (using a 3-percent discount rate) (Exelon 2014). The results of this revised
22 evaluation are provided in Table F-5.

23 Exelon provided the results of additional sensitivity analyses in the ER, including the use of a
24 7-percent discount rate and variations in MACCS2 input parameters (as discussed in
25 Section F.2.2.4). Exelon determined that these analyses did not identify any additional
26 potentially cost-beneficial SAMAs (Exelon 2013b). In an RAI, the NRC staff requested that
27 Exelon to explain why the MACCS2 sensitivity case for economic rate of return resulted in a
28 change in dose consequence (NRC 2014). In response to the RAI, Exelon provided clarification
29 that the rate of return on property impacts the estimated property that is condemned (or
30 reclaimed). Changes in property reclamation will result in changes in dose consequences to
31 those who occupy the property after it has been reclaimed (Exelon 2014). The NRC staff
32 considers this explanation reasonable.

33 Exelon stated in the ER (Exelon 2013a) that SAMA 15, Resolve Regulatory Issues and
34 Complete Implementation of the Interunit AFW Crosstie, to improve AFW reliability, was in the
35 final stages of implementation at Byron at the time of the ER submittal and was therefore
36 included as a SAMA rather than being included in the base PRA model. A sensitivity analysis
37 was provided in the ER in which SAMA 15 was incorporated into the base PRA model and the
38 Phase I and II SAMAs reevaluated. This reevaluation did not alter the conclusions of either the
39 Phase I screening analysis or the Phase II cost-benefit analysis.

40 Exelon also stated in the ER that many of the SAMAs address similar areas of plant risk and
41 that implementation of one SAMA may result in other SAMAs no longer being cost-beneficial.
42 Exelon further noted that SAMA 11, Implement DMS, would mitigate many of the largest
43 contributors to Byron risk, and that it may be fully or partially implemented at Byron for reasons
44 other than the results of the SAMA analysis (specifically, it includes capabilities to address
45 insights from the Fukushima Dai-ichi accident). Exelon reevaluated the cost-beneficial SAMAs
46 assuming both SAMA 15 and SAMA 11 are implemented in an attempt to optimize a reduced
47 set of SAMAs that would address the largest risk contributors. As a result, 10 SAMAs were
48 determined to no longer be cost-beneficial (SAMAs 2, 3, 8, 9, 10, 13, 16, 25, 26, and 27)
49 (Exelon 2013b). In the response to the NRC staff RAI discussed above regarding the revised

Appendix F

1 uncertainty evaluation (applying the factor of 2.53 for uncertainty and the multiplier of 2.6 for
2 external events), Exelon also determined that SAMA 1 would no longer be cost-beneficial if both
3 SAMAs 11 and 15 were implemented (Exelon 2014). SAMA 4 is also effectively implemented in
4 this analysis since installing “no leak” RCP seals is one element of SAMA 11.

5 Exelon stated in the ER that the 18 SAMAs (SAMAs 2, 3, 5, 7, 8, 9, 10, 11, 13, 15, 16, 19, 25,
6 26, 27, 28, 30, and 31) determined to be cost-beneficial in the ER baseline and uncertainty
7 evaluations have been submitted to the Byron Plant Health Committee for further
8 implementation consideration (Exelon 2013b). Exelon made no similar commitment for
9 SAMAs 1 and 4, which were determined to be potentially cost-beneficial in response to NRC
10 staff RAIs. In responses to NRC staff RAIs, Exelon stated that installation of SAMA 4 at Byron
11 is planned, that contract awards have been made to install the new RCP seals, and that
12 engineering and analysis work necessary to install the new seals has begun (Exelon 2014). As
13 discussed previously, Exelon stated in the ER that SAMA 11 may be fully or partially
14 implemented at Byron for other purposes, which, if fully implemented along with SAMA 15
15 (which is currently being implemented), would result in SAMA 1’s no longer being cost-
16 beneficial.

17 Given that Exelon’s cost benefit evaluations have been reviewed by the NRC staff and that
18 Exelon has satisfactorily addressed NRC staff questions regarding the evaluations, the NRC
19 staff concludes that the cost-benefit evaluations are of sufficient quality to support the SAMA
20 evaluation. Therefore, the NRC staff concludes that, with the exception of the potentially
21 cost-beneficial SAMAs discussed above, the costs of the other SAMAs evaluated would be
22 higher than their associated benefits.

23 **F.7 Conclusions**

24 Exelon initially compiled a list of 30 SAMAs based on a review of the most significant basic
25 events from the plant-specific PRA and insights from the Byron PRA group, insights from the
26 plant-specific IPE and IPEEE, and Phase II SAMAs from license renewal applications for other
27 plants. An initial qualitative screening removed SAMA candidates that: (1) are not applicable to
28 Byron design due to design differences, (2) have already been implemented at Byron or the
29 intent achieved by other means, or (3) have excessive implementation costs. Based on this
30 initial screening, 3 SAMAs were eliminated leaving 27 candidate SAMAs for evaluation.
31 One additional candidate SAMA was also further evaluated after accounting for analysis
32 uncertainties.

33 For the remaining 28 SAMA candidates, benefit and cost estimates were developed as shown in
34 Table F–5. The cost-benefit analyses in the ER showed that 10 of the SAMA candidates were
35 potentially cost-beneficial in the baseline analysis (SAMAs 3, 5, 9, 10, 13, 15, 25, 26, 27, and
36 31). Exelon performed additional analyses to evaluate the impact of parameter choices and
37 uncertainties on the results of the SAMA assessment. As a result, eight additional SAMAs were
38 identified as potentially cost-beneficial (SAMAs 2, 7, 8, 11, 16, 19, 28, and 30). Exelon has
39 indicated that all 18 potentially cost-beneficial SAMAs will be submitted to the Byron Plant
40 Health Committee for further implementation consideration.

41 In response to NRC staff RAI, Exelon reevaluated the 28 SAMA candidates and 1 additional
42 SAMA candidate and, as a result, identified 2 additional potentially cost-beneficial SAMAs
43 (SAMAs 1 and 4). Exelon has plans to implement SAMA 4 and has initiated engineering and
44 procurement activities to do so. Since full implementation of SAMA 11 in conjunction with
45 SAMA 15 (which is currently being implemented) would result in SAMA 1 not being
46 cost-beneficial, the NRC staff concludes that the applicant should consider SAMA 1 for further
47 evaluation, depending on the degree of implementation of SAMA 11.

1 The NRC staff reviewed the Exelon analysis and concludes that the methods used and the
2 implementation of those methods are sound. The treatment of SAMA benefits and costs
3 support the general conclusion that the SAMA evaluations performed by Exelon are reasonable
4 and sufficient for the license renewal submittal. Although the treatment of SAMAs for external
5 events was somewhat limited, the NRC staff determined that the likelihood of there being
6 additional cost-beneficial enhancements in this area was minimized by utilizing an interim Byron
7 fire PRA to identify SAMA candidates, resolution of suggested plant improvements that were
8 identified as a result of the IPEEE process, and inclusion of a multiplier to account for the
9 external events.

10 Based on the NRC staff's review of Exelon's SAMA evaluations, including Exelon's response to
11 NRC staff questions regarding the evaluations, the NRC staff concludes that Exelon has
12 adequately identified areas in which risk can be further reduced in a cost-beneficial manner
13 through the implementation of the identified potentially cost-beneficial SAMAs. Given the
14 potential for cost-beneficial risk reduction, the NRC staff concludes that further Exelon
15 evaluation of the candidate SAMAs identified as being potentially cost-beneficial in the Exelon
16 ER is appropriate.

17 Additionally, the NRC staff evaluated the identified potentially cost-beneficial SAMAs to
18 determine if they are in the scope of license renewal, i.e., they are subject to aging
19 management. This evaluation considers whether the structures, systems, and components
20 (SSCs) associated with these SAMAs: (1) perform their intended function without moving parts
21 or without a change in configuration or properties and (2) that these SSCs are not subject to
22 replacement based on qualified life or specified time period. The NRC staff determined that
23 these SAMAs do not relate to adequately managing the effects of aging during the period of
24 extended operation. Therefore, they need not be implemented as part of license renewal in
25 accordance with Title 10 of the *Code of Federal Regulations*, Part 54, "Requirements for
26 renewal of operating licenses for nuclear power plants."

27 **F.8 References**

28 10 CFR 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for renewal
29 of operating licenses for nuclear power plants."

30 [ASME and ANS] American Society of Mechanical Engineers and American Nuclear Society.
31 2009. *Addenda to ASME/ANS RA-S-2008, Standard for Level 1/Large Early Release*
32 *Frequency Probabilistic Risk Assessment for Nuclear Power Plant Applications*. New York, NY:
33 ASME. ASME/ANS RA-Sa-2009. February 2, 2009. 352 p. Available at
34 <<http://www.ewp.rpi.edu/hartford/~povron/EP/Other/ASME-ANS%20RA-Sa-2009.pdf>>
35 (accessed 5 June 2014).

36 [BEA] Bureau of Economic Analysis. 2012. "Regional Economic Accounts." Available at
37 <<http://www.bea.gov/regional/reis/>> (accessed August 2013).

38 Bixler NE, Gauntt RO, Jones JA (Sandia National Laboratories), Leonard MT (dycoda, LLC).
39 2013. *State-of-the-Art Reactor Consequence Analyses Project*. Revision 1. Washington, DC:
40 Sandia. NUREG/CR-7110, Volumes 1 and 2. May and August 2013. 894 p. ADAMS
41 Nos. ML13150A053 and ML13240A242.

42 Bixler NE, Shannon SA, Morrow CW, Meloche BE (Sandia National Laboratories (SNL)),
43 Ridgely JN (U.S. Nuclear Regulatory Commission). 2003. *SECPOP2000: Sector Population,*
44 *Land Fraction, and Economic Estimation Program*. Revision 1. Albuquerque, NM: SNL.
45 NUREG/CR-6525. August 2003. 410 p. ADAMS No. ML032310279.

Appendix F

- 1 [BLS] Bureau of Labor Statistics. 2012. "Databases, Tables & Calculators by Subject." Available
2 at www.bls.gov/data/ (accessed August 2013).
- 3 Chanin D (Technadyne Engineering), Young ML (Sandia National Laboratories). 1998. *Code*
4 *Manual for MACCS2: User's Guide*. Washington, DC: U.S. Nuclear Regulatory Commission.
5 NUREG/CR-6613, Volume 1. May 1998. 325 p. ADAMS No. ML11355A187.
- 6 Chen JT, Chokshi NC, Kenneally RM, Kelly GB, Beckner WD, McCracken C, Murphy AJ,
7 Reiter L, Jeng DC. 1991. *Procedural and Submittal Guidance for the Individual Plant*
8 *Examination of External Events (IPEEE) for Severe Accident Vulnerabilities*. Washington, DC:
9 U.S. Nuclear Regulatory Commission. NUREG-1407. June 1991. 98 p. ADAMS
10 No. ML063550238.
- 11 [ComEd] Commonwealth Edison Company. 1994. *Byron Nuclear Generating Station Units 1*
12 *and 2 Individual Plant Examination Submittal Report*. April 1994.
- 13 [ComEd] Commonwealth Edison Company. 1996. *Individual Plant Examination of External*
14 *Events for Severe Accident Vulnerabilities Submittal Report, Byron Nuclear Generating Station*
15 *Units 1 and 2*. December 1996.
- 16 [ComEd] Commonwealth Edison Company. 1997. *Byron Nuclear Generating Station, Units 1*
17 *and 2 Response to NRC Request for Additional Information and Modified Individual Plant*
18 *Examination*. March 1997.
- 19 [EPRI] Electric Power Research Institute. 1991. *A Methodology for Assessment of Nuclear*
20 *Power Plant Seismic Margin*. Palo Alto, CA: EPRI. NP-6041-SL, Revision 1. August 1991.
21 Available at
22 <http://www.epri.com/abstracts/Pages/ProductAbstract.aspx?ProductId=NP-6041-SLR1>
23 (accessed 5 June 2014).
- 24 [EPRI] Electric Power Research Institute. 1992. "Fire-Induced Vulnerability Evaluation (FIVE)."
25 July 27, 2006. Available at
26 [http://teams.epri.com/PRA/Big%20List%20of%20PRA%20Documents/](http://teams.epri.com/PRA/Big%20List%20of%20PRA%20Documents/EPRI%20TR-100370%20(abstract).htm)
27 [EPRI%20TR-100370%20\(abstract\).htm](http://teams.epri.com/PRA/Big%20List%20of%20PRA%20Documents/EPRI%20TR-100370%20(abstract).htm) (accessed 5 June 2014).
- 28 [ET] Earth Tech, Inc. 2003. *Evacuation Time Estimates for the Byron Station Plume Exposure*
29 *Pathway Emergency Planning Zone*. December 2003.
- 30 [Exelon] Exelon Generation Company, LLC. 2008. *Re-Analysis of Fuel Handling Accident (FHA)*
31 *Using Alternate Source Terms*. BYR04-047 & BRW-04-0041-M, Revision 2. November 2008.
- 32 [Exelon] Exelon Generation Company, LLC. 2011. Letter from C. Lambert, Vice President,
33 Power Uprate, to Document Control Desk, U.S. Nuclear Regulatory Commission. Subject:
34 Request for license amendment regarding measurement uncertainty recapture (MUR) power
35 uprate. June 23, 2011. ADAMS No. ML111790030.
- 36 [Exelon] Exelon Generation Company, LLC. 2012. Letter from G. Kaegi, Director, Midwest
37 Licensing and Regulatory Affairs, to Document Control Desk, U.S. Nuclear Regulatory
38 Commission. Subject: Exelon Generation Company, LLC's 180-day response to NRC request
39 for information pursuant to 10 CFR 50.54(f) regarding the seismic aspects of
40 Recommendation 2.3 of the Near-Term Task Force review of insights from the Fukushima
41 Dai-ichi accident. November 27, 2012. ADAMS No. ML12341A160.
- 42 [Exelon] Exelon Generating Company, LLC. 2013a. *Braidwood Station, Units 1 and 2,*
43 *Environmental Report*. Kennett Square, PA: Exelon. Volume 4. May 29, 2013. 842 p. ADAMS
44 Nos. ML13155A424 and ML13155A426.

- 1 [Exelon] Exelon Generating Company, LLC. 2013b. *Byron Station, Units 1 and 2, Environmental*
2 *Report*. Kennett Square, PA: Exelon. Volume 3. May 29, 2013. 709 p. ADAMS Nos.
3 ML13155A422 and ML13155A423.
- 4 [Exelon] Exelon Generation Company, LLC. 2014. Letter from M. Gallagher, Vice President,
5 License Renewal Projects, to Document Control Desk, U.S. Nuclear Regulatory Commission.
6 Subject: Response to NRC requests for additional information for the severe accident mitigation
7 alternatives review, dated January 6, 2014, related to the Braidwood Station, Units 1 and 2 and
8 Byron Station, Units 1 and 2 license renewal application. February 4, 2014. ADAMS
9 No. ML14035A512.
- 10 Holzworth GC. 1972. *Mixing Heights, Wind Speeds, and Potential for Urban Air Pollution*
11 *Throughout the Contiguous United States*. Research Triangle Park, NC: Environmental
12 Protection Agency. Office of Air Programs Publication No. AP-101. January 1972. 132 p.
13 Available at <<http://nepis.epa.gov/Exe/ZyNET.exe/20013CDS.TXT?ZyActionD=ZyDocument&Client=EPA&Index=Prior+to+1976&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C70thru75%5CTxt%5C00000005%5C20013CDS.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75q8/r75q8/x150y150g16/i425&Display=p%7Cf&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL>> (accessed
21 5 June 2014).
- 22
- 23 [IDOC] Illinois Department of Commerce and Economic Opportunity. 2012. “2000-2030
24 Population Projections.” Available at
25 <http://www.ildceo.net/dceo/Bureaus/Facts_Figures/Population_Projections/> (accessed
26 February 2014).
- 27 [NEI] Nuclear Energy Institute. 2005. *Severe Accident Mitigation Alternative (SAMA) Analysis*
28 *Guidance Document*. Revision A. Washington, DC: NEI. NEI 05-01. November 2005. 79 p.
29 ADAMS No. ML060530203.
- 30 [NEI] Nuclear Energy Institute. 2006. *Probabilistic Risk Assessment (PRA) Peer Review*
31 *Process Guidance*. Revision 1. Washington, DC: NEI. NEI 00-02. May 2006. ADAMS
32 No. ML061510619.[PECO] Philadelphia Electric Company. 1989. *Limerick Generating Station,*
33 *Units 1 and 2 Response to Request for Additional Information Regarding Consideration of*
34 *Severe Accident Mitigation Design Alternatives*. June 23, 1989.
- 35 Pilch MM, Allen MD, Klamerus EW. 1996. *Resolution of the Direct Containment Heating Issue*
36 *for All Westinghouse Plants With Large Dry Containments or Subatmospheric Containments*.
37 Albuquerque, NM: Sandia National Laboratories. NUREG/CR-6338. February 1996. 252 p.
38 ADAMS No. ML081920672.
- 39 [Sargent] Sargent & Lundy, LLC. 2012. *Flooding Walkdown Report in Response to the 50.54(f)*
40 *Information Request Regarding Near-Term Task Force Recommendation 2.3: Flooding for the*
41 *Byron Station, Units 1 and 2*. Chicago, IL: Sargent & Lundy, LLC. November 27, 2012. 25 p.
42 ADAMS No. ML12332A380.
- 43 [PECO] Philadelphia Electric Company. 1989. *Limerick Generating Station, Units 1 and 2*
44 *Response to Request for Additional Information Regarding Consideration of Severe Accident*
45 *Mitigation Design Alternatives*. June 23, 1989.

Appendix F

- 1 [SDCI] State Data Center of Iowa. 2012. "Census Demographics— Population, Housing,
2 Economy, Government Statistics—Projections." Available at
3 <<http://data.iowadatacenter.org/browse/projections.html>> (accessed February 2014).
- 4 [USDA] U.S. Department of Agriculture. 2009. *2007 Census of Agriculture, Illinois State and
5 County Data, Iowa State and County Data, and Wisconsin State and County Data*. AC-07-A-13
6 and AC-07-A-49, Volume 1, Parts 13, 15, and 49. Updated December 2009, issued
7 February 2009. 779 p, 775 p, and 695 p. Available at
8 <[http://www.agcensus.usda.gov/Publications/2007/Full_Report/
9 Volume_1,_Chapter_1_State_Level/Illinois/ilv1.pdf](http://www.agcensus.usda.gov/Publications/2007/Full_Report/Volume_1,_Chapter_1_State_Level/Illinois/ilv1.pdf)>,
10 <[http://www.agcensus.usda.gov/Publications/2007/Full_Report/
11 Volume_1,_Chapter_1_State_Level/Iowa/iav1.pdf](http://www.agcensus.usda.gov/Publications/2007/Full_Report/Volume_1,_Chapter_1_State_Level/Iowa/iav1.pdf)>, and
12 <[http://www.agcensus.usda.gov/Publications/2007/Full_Report/
13 Volume_1,_Chapter_1_State_Level/Wisconsin/wiv1.pdf](http://www.agcensus.usda.gov/Publications/2007/Full_Report/Volume_1,_Chapter_1_State_Level/Wisconsin/wiv1.pdf)> (accessed 6 June 2014).
- 14 [NRC] U.S. Nuclear Regulatory Commission. 1981. *Standard Review Plan for the Review of
15 Safety Analysis Report for Nuclear Power Plants*. Revision 1. Washington, DC: NRC.
16 NUREG–0800. July 1981. Available at
17 <<http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>> (accessed 6 June 2014).
- 18 [NRC] U.S. Nuclear Regulatory Commission. 1988. "Individual Plant Examination for Severe
19 Accident Vulnerabilities—10 CFR 50.54(f)." Washington, DC: NRC. Generic Letter No. 88-20.
20 November 23, 1988. Available at
21 <<http://www.nrc.gov/reading-rm/doc-collections/gen-comm/gen-letters/1988/gl88020.html>>
22 (accessed 6 June 2014).
- 23 [NRC] U.S. Nuclear Regulatory Commission. 1990. *Severe Accident Risks: An Assessment for
24 Five U.S. Nuclear Power Plants*. Washington, DC: NRC. NUREG–1150. December 1990.
25 Available at <<http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1150/>> (accessed
26 6 June 2014).
- 27 [NRC] U.S. Nuclear Regulatory Commission. 1991. "Individual Plant Examination of External
28 Events for Severe Accident Vulnerabilities." Washington, DC: NRC. Generic Letter No. 88-20,
29 Supplement 4. June 28, 1991.
- 30 [NRC] U.S. Nuclear Regulatory Commission. 1997a. *Individual Plant Examination Program:
31 Perspectives on Reactor Safety and Plant Performance*. Washington, DC: NRC. NUREG–1560,
32 Volume 3. December 1997. 60 p. ADAMS No. ML063470259.
- 33 [NRC] U.S. Nuclear Regulatory Commission. 1997b. Letter from G. Dick to I. Johnson,
34 Commonwealth Edison Company. Subject: Individual Plant Examination, Byron Station, Units 1
35 and 2 (TAC Nos. M74389 and M74390). December 3, 1997.
- 36 [NRC] U.S. Nuclear Regulatory Commission. 1997c. *Regulatory Analysis Technical Evaluation
37 Handbook*. Washington, DC: NRC. NUREG/BR–0184. January 1997. 308 p. ADAMS
38 No. ML050190193.
- 39 [NRC] U.S. Nuclear Regulatory Commission. 2001. Letter from G. Dick to O. Kingsley, Exelon
40 Nuclear. Subject: Review of Individual Plant Examination of External Events Byron Station,
41 Units 1 and 2 (TAC Nos. M83600 and M83601). May 30, 2001.
- 42 [NRC] U.S. Nuclear Regulatory Commission. 2004. *Regulatory Analysis Guidelines of the U.S.
43 Nuclear Regulatory Commission*. NUREG/BR-0058, Washington, D.C., Revision 4,
44 September 30, 2004. ADAMS No. ML042820192.

- 1 [NRC] U.S. Nuclear Regulatory Commission. 2005a. *EPRI/NRC-REC Fire PRA Methodology for*
2 *Nuclear Power Facilities*. NUREG/CR-6850/EPRI 1011989, Volumes 1 and 2. September 2005.
3 ADAMS Nos. ML052580075 and ML052580118.
- 4 [NRC] U.S. Nuclear Regulatory Commission. 2005b. "U.S. Nuclear Regulatory Commission
5 comments on Nuclear Energy Institute (NEI) 05-01, 'Severe Accident Mitigation Alternative
6 (SAMA) Analysis Guidance Document' (Revision A)." July 12, 2005. ADAMS
7 No. ML051940057.
- 8 [NRC] U.S. Nuclear Regulatory Commission. 2008. *Generic Environmental Impact Statement*
9 *for License Renewal of Nuclear Plants, Supplement 34, Regarding Vogtle Electric Generating*
10 *Plant, Units 1 and 2*. Washington, DC: NRC. NUREG-1437. December 2008. 546 p. ADAMS
11 No. ML083380325.
- 12 [NRC] U.S. Nuclear Regulatory Commission. 2009. *An Approach for Determining the Technical*
13 *Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities*. Revision 2.
14 Regulatory Guide 1.200. March 1, 2009. 191 p. ADAMS No. ML090410014.
- 15 [NRC] U.S. Nuclear Regulatory Commission. 2010a. *Generic Environmental Impact Statement*
16 *for License Renewal of Nuclear Plants, Supplement 38, Regarding Indian Point Nuclear*
17 *Generating Unit Nos. 2 and 3*. Washington, DC: NRC. NUREG-1437, Volume 3.
18 December 3, 2010. 665 p. ADAMS No. ML103350442.
- 19 [NRC] U.S. Nuclear Regulatory Commission. 2010b. Letter from T. McGinty, Director, to all
20 holders of an operating license. Subject: NRC Information Notice 2010-18: Generic Issue 199,
21 "Implications of updated probabilistic seismic hazard estimates in central and Eastern
22 United States on existing plants." September 2, 2010. ADAMS No. ML101970221.
- 23 [NRC] U.S. Nuclear Regulatory Commission. 2012. Letter from E. Leeds, Director, to All Power
24 Reactor Licensees. Subject: Request for information pursuant to Title 10 of the *Code of Federal*
25 *Regulations* 50.54(f) regarding Recommendations 2.1, 2.3, and 9.3, of the Near-Term Task
26 Force review of insights from the Fukushima Dai-ichi accident. March 12, 2012. ADAMS
27 No. ML12053A340.
- 28 [NRC] U.S. Nuclear Regulatory Commission. 2014. Letter from L. James, Environmental Project
29 Manager, to M. Gallagher, Vice President, License Renewal Projects, Exelon Generation
30 Company, LLC. Subject: Requests for additional information for the review of the Byron and
31 Braidwood Nuclear Stations license renewal application—severe accident mitigation alternatives
32 review (TAC Nos. MF1790, MF1791, MF1792, and MF1793). January 6, 2014. ADAMS
33 No. ML13318A208.
- 34 [WDOA] Wisconsin Department of Administration. 2012. "State and County Age-Sex Population
35 Projections." Available at
36 <http://www.doa.state.wi.us/subcategory.asp?linksubcatid=105&locid=9> (accessed
37 February 2014).
- 38 Westinghouse. 2005. *Simplified Level 2 Modeling Guidelines—WOG Project: PARMSC-0088*.
39 Revision 0. WCAP-16341-P. November 2005.

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

1. REPORT NUMBER
(Assigned by NRC, Add Vol., Supp., Rev.,
and Addendum Numbers, if any.)

NUREG-1437, Supplement 54,
Draft

2. TITLE AND SUBTITLE

Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS),
Supplement 54, Regarding Byron Station, Units 1 and 2, Draft Report for Comment

3. DATE REPORT PUBLISHED

MONTH	YEAR
December	2014

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

See Chapter 6 of the Report.

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Division of License Renewal, Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above", if contractor, provide NRC Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address.)

Same as 8 above.

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

This supplemental environmental impact statement (SEIS) has been prepared in response to an application submitted by Exelon Generation Company, LLC (Exelon), to renew the operating license for Byron Station, Units 1 and 2 (Byron), for an additional 20 years.

This SEIS includes the preliminary analysis that evaluates the environmental impacts of the proposed action and alternatives to the proposed action. Alternatives considered include: new nuclear generation, coal-integrated gasification combined cycle, natural gas combined cycle (NGCC), combination NGCC, wind, and solar generation, replacement power, and the no action alternative.

The U.S. Nuclear Regulatory Commission (NRC) staff's preliminary recommendation is that the adverse environmental impacts of license renewal for Byron are not so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable. This recommendation is based on the following:

- the analysis and findings in NUREG-1437, Volumes 1 and 2, GEIS for License Renewal of Nuclear Plants;
- the Environmental Report submitted by Exelon;
- consultation with Federal, state, local, and tribal government agencies;
- the NRC's environmental review; and
- consideration of public comments received during the scoping process.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

Byron Station, Byron, Exelon Generation Company, LLC, Exelon, Generic Environmental Impact Statement, GEIS, Draft Supplemental Environmental Impact Statement, DSEIS, License Renewal, National Environmental Policy Act, NEPA

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, DC 20555-0001

OFFICIAL BUSINESS



**NUREG-1437
Supplement 54
Draft**

**Generic Environmental Impact Statement for License Renewal of Nuclear Plants
Regarding Byron Station, Units 1 and 2**

December 2014