

NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report





Figure 4-10
Cumulative Density Function

Fernandina, FL - Linear Trend


(Station 8720030)



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-11
 Sea Level Rise



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report





Figure 4-12
 IHO Tidal Stations Used for Tidal Calibration

References: Deltares, 2012; ESRI, 2014d

FPL-072-PR-002

REV. 0

Miami Harbor Tidal Station Calibration





NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-13

Tidal Times Series Comparison of Simulated versus Resynthesized Water Levels at Miami Harbor Entrance



★ PSL

◇ Hurricane Track

Note: Each point represents a six-hour time interval

NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report



ENERCON

Figure 4-14
Hurricane Jeanne and Hurricane Floyd Storm Tracks

References: ESRI, 2014d; NOAA, 1999; NOAA, 2004b

FPL-072-PR-002

REV. 0







- ★ PSL
- ◇ Hurricane Track

Note: Each point represents a six-hour time interval

NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-15
 Hurricane Frances and Hurricane Irene Storm Tracks



NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report






Figure 4-16
Scatter Plot of Simulated Versus Observed Maximum WSEL for Hurricane Irene, Hurricane Jeanne, Hurricane Floyd and Hurricane Frances

References: NOAA, 2000; NOAA, 2004d; NOAA, 2011b; NOAA, 2013m; NOAA, 2013n; NOAA, 2013o; NOAA, 2013p; NOAA, 2013r; NOAA, 2013x; NOAA, 2013y; NOAA, 2013z; NOAA, 2013aa; NOAA, 2013ab; NOAA, 2013ac; NOAA, 2013ad

Station 41009 Significant Wave Height




Station 41009 Period



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report




Figure 4-17
 Time Series of Simulated versus Observed
 Significant Wave Height and Wave Period for
 Hurricane Floyd at Buoy 41009



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-18
 Locator Map with Coastal Distance Intervals
 Marked in Nautical Miles and Kilometers



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report






Figure 4-19
 Adopted Central Pressure of the Probable
 Maximum Hurricane



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report




Figure 4-20
 Adopted Upper and Lower Limits of Radius of
 Maximum Winds for the PMH



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-21
 Adopted PMH Upper and Lower Limits of Forward
 Speed




Note: The track direction is in accordance with the nautical convention

NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-22
 Maximum Allowable Range of the PMH Track
 Direction




- H5** Category 5 Hurricane
- H3** Category 3 Hurricane
- H1** Category 1 Hurricane
- TD/SD** Tropical Depression
- H4** Category 4 Hurricane
- H2** Category 2 Hurricane
- TS/SS** Tropical Storm

**NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report**



Figure 4-23
Recorded Major (H3 and Above) Hurricanes within
120 Nautical Miles of PSL since 1842

Low Frequency Event Thresholds




Note: The PMH RMW range from NWS (1979) is shown for reference, along with historical hurricane data.

NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report



References: NWS, 1979; NWS, 1987; IPET, 2009; NOAA, 2012; Willoughby et al., 1989; Rappaport, 2005; Mayfield, 1995; Guiney and Lawrence, 2000; Pasch, 2006b; Beven and Cobb, 2004; Stewart, 2005; Knabb, 2006a; Knabb, 2006b; Pash, 2006a; Franklin, 2008

Figure 4-24
 Low Probability Central Pressure-RMW
 Thresholds for Hurricanes Near St. Lucie Nuclear
 Power Plant (PSL)



Legend

Pressure Drop (in Hg)	0.370802 - 0.491591	1.257098 - 1.813777
0.196058 - 0.234107	0.491592 - 0.650342	1.813778 - 2.541125
0.234108 - 0.290471	0.650343 - 0.889221	2.541126 - 3.819856
0.290472 - 0.370801	0.889222 - 1.257097	

300 N mi

NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report





Figure 4-25
 NWS23 PMH Pressure Drop Field (in Hg) Output
 Illustration



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report





Figure 4-26
 NWS23 PMH Wind Field (knots) Output Illustration

Coastal Inundation Components
(adapted from USACE, 2012)



① 10% Exceedance High Tide + Sea Level Rise = 2.66 ft-MSL + 0.20 ft = 2.86 ft-MSL

② Calculated by Numerical Modeling (DELFT3D)
③ Calculated by Numerical Modeling (DELFT3D) } = 12.36 ft

④ Calculated by Numerical Modeling (DELFT3D) = 0.66 ft

⑤ Hand-Calculated by Empirical Relationships = 0 ft at Power Block (Overtopping = 7.6×10^{-6} ft³/s/foot)

Note: Drawing not to scale

Probable Maximum Storm Surge at PSL Powerblock With Wave Runup = $\left\{ \begin{array}{l} +15.86 \text{ ft} - \text{MSL} \\ +18.3 \text{ ft} - \text{PSL Datum} \\ +14.9 \text{ ft} - \text{NAVD88} \end{array} \right\}$

NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report



Figure 4-27
Storm Surge Components




NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report




Figure 4-28
 PMSS Inundation (Excluding Runup) at
 EL 14.9 ft-NAVD88

Forward Speed 20 knots - Flood Duration



Forward Speed 6 knots - Flood Duration




Note: The points used to obtain the The Big Mud Creek and the Atlantic Ocean results are shown in Figure 4-31

NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report




Figure 4-29
Duration of Flooding for Forward Speeds

Dunes Not Breached



Dunes Breached




NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report



Figure 4-30
Significant Wave Height (m) at Time of Maximum
Surge – Breached & Non Breached Sand Dunes

Delft3D - Flow Model Bed Elevation (m-MSL)



Point of Interest	Location
1	Big Mud Creek
2	Atlantic Ocean
3	Discharge Canal
4	Obs. Point 4
5	Intake Canal
6	Obs. Point 6

NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report







Figure 4-31
 PMSS Observation Points



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-32
 PMSS Wave Results at Time of Maximum Surge



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report




Figure 4-33
 Indian River Lagoon Domain for Seiche Analysis



**NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report**





Figure 4-34
Meteorological Stations with Wind Data

References: ESRI, 2014a; FAWN, 2014; NOAA, 2014a;
NOAA, 2014b

FPL-072-PR-002

REV. 0

Wind Speed Data Span



Note: All of the stations have at least hourly information, the FAWN stations and buoy data have sub-hourly data

NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report







Figure 4-35
Record Length at Selected Meteorological
Stations with Wind Data




Station: Daytona Beach





Station: St Lucie







Station: 20 NM East of Cape Canaveral



Station: West Palm Beach



s of m/s



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report





Figure 4-37
 FFT Analysis of Wind Speed for Selected Stations




Note: All of the stations have at least hourly information, the FAWN stations and buoy data have sub-hourly data


NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-38
 Main Periods of the First Frequency Peaks for
 Selected Stations



- Tsunami Sources
- ★ PSL




NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report




Figure 4-39
Tsunami Source Locations Evaluated


Elapsed time = 0 minutes



Elapsed time = 29 minutes




Elapsed time = 99 minutes



NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report





Figure 4-40
1755 Lisbon Earthquake Tsunami Elapsed Times;
Mw = 8.53 - Tsunami Origination Zone



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report




Figure 4-41
 1755 Lisbon Earthquake Boundary Condition;
 Mw = 8.53



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-42
 1755 Lisbon Earthquake Tsunami Elapsed Times;
 Mw = 8.53 – Propagation to PSL



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report






Figure 4-43
 1755 Lisbon Earthquake Tsunami Wave
 Amplitude at PSL; Mw = 8.53


Elapsed time = 0 minutes



Elapsed time = 19 minutes



Elapsed time = 59 minutes




NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report



Figure 4-44

1755 Lisbon Earthquake Tsunami Elapsed Times;
Mw = 8.61 – Origination Zone



Lisbon Earthquake Boundary Condition



NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report



Figure 4-45
1755 Lisbon Earthquake Boundary Condition;
Mw = 8.61




NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-46
 1755 Lisbon Earthquake Tsunami Elapsed Times;
 Mw = 8.61 – Propagation to PSL

Lisbon Earthquake Wave Amplitude at PSL




NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report




Figure 4-47
1755 Lisbon Earthquake Tsunami Wave
Amplitude at PSL; Mw = 8.61


Elapsed time = 0 minutes



Elapsed time = 35 minutes




Elapsed time = 3 hours 15 minutes



NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report



Figure 4-48
Puerto Rico Trench Earthquake Tsunami




NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report




Figure 4-49
 Puerto Rico Trench Earthquake Tsunami Wave
 Amplitude at PSL


Elapsed time = 0 minutes



Elapsed time = 25 minutes




Elapsed time = 3 hours 15 minutes



NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report





Figure 4-50
Hispaniola Trench Earthquake Tsunami



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-51
 Hispaniola Trench Tsunami Wave Amplitude at PSL




NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report




Figure 4-52
 Water Surface Elevation at PSL From Hispaniola
 Trench


Elapsed time = 0 minutes



Elapsed time = 1 hour 35 minutes




Elapsed time = 2 hours 55 minutes



NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report



Figure 4-53
Cape Fear Landslide Source




NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report




Figure 4-54
 Cape Fear Landslide Boundary Condition Time Series

Elapsed time = 1 hour 35 minutes




Elapsed time = 2 hours 25 minutes



NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report



Figure 4-55
Cape Fear Landslide




NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report




Figure 4-56
 Cape Fear Landslide; PSL Water Surface
 Elevation Time Series


Elapsed time = 0 minutes



Elapsed time = 1 hour 10 minutes




Elapsed time = 3 hours 15 minutes



NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report



Figure 4-57
Currituck Slide Source




NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report




Figure 4-58
 Currituck Slide Boundary Time Series

Elapsed time = 45 minutes




Elapsed time = 2 hours 25 minutes



NextEra Energy (NEE)
St. Lucie Nuclear Power Plant Units 1 & 2
Flooding Hazards Reevaluation Report




Figure 4-59
Curritw Landslide



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-60
 Currituck Slide; PSL Water Surface Elevation



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report





Figure 4-61
 PMT Inundation at EL 14.27 ft-NAVD88


Flood loads on a vertical wall



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-62
 LIP Loading Diagram



NextEra Energy (NEE)
 St. Lucie Nuclear Power Plant Units 1 & 2
 Flooding Hazards Reevaluation Report



Figure 4-63
 Bounding LIP Loads at POIs

