



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

February 17, 2016

Mr. Bryan C. Hanson  
President and Chief Nuclear Officer  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION – STAFF REVIEW  
OF INTERIM EVALUATION ASSOCIATED WITH REEVALUATED SEISMIC  
HAZARD IMPLEMENTATING NEAR-TERM TASK FORCE  
RECOMMENDATION 2.1 (CAC NO. MF5257)

Dear Mr. Hanson:

By letter dated March 12, 2012 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML12053A340), the U.S. Nuclear Regulatory Commission (NRC) issued a request for information pursuant to Title 10 of the *Code of Federal Regulations* Part 50, Section 50.54(f) (hereafter referred to as the 50.54(f) letter). The request was issued as part of implementing lessons-learned from the accident at the Fukushima Dai-ichi nuclear power plant. Enclosure 1 to the 50.54(f) letter requested that licensees reevaluate seismic hazards at their sites using present-day methodologies and guidance. Enclosure 1, Item 6, of the 50.54(f) letter requested that licensees identify “interim evaluation and actions taken or planned to address the higher seismic hazard relative to the design basis as appropriate, prior to completion of the [seismic] risk evaluation.” In addition to the interim evaluation provided in the March 2014 Seismic Screening and Hazard report, the licensees for the Central and Eastern United States committed to providing the Expedited Seismic Evaluation Process (ESEP) report, an interim evaluation, by December 31, 2014.

By letters dated December 19, 2014<sup>1</sup>, Exelon Generation Company, LLC (Exelon, the licensee), provided its ESEP report in a response to Enclosure 1, Item (6) of the 50.54(f) letter, for Oyster Creek Nuclear Generating Station (Oyster Creek). The NRC staff assessed the licensee’s implementation of the ESEP guidance through the completion of a reviewer checklist<sup>2</sup>. In support of NRC staff questions, Exelon provided a response dated July 24, 2015<sup>3</sup>, clarifying submittal information. Based on the NRC staff review of the ESEP report and responses to the staff’s questions, the NRC staff concludes that the licensee’s implementation of the interim evaluation meets the intent of the guidance.

---

<sup>1</sup> The December 19, 2014, letter can be found under ADAMS Accession No. ML14353A332.


<sup>2</sup> The Oyster Creek ESEP NRC review checklist can be found under ADAMS Accession No. ML15238A595.

<sup>3</sup> The Exelon response to NRC staff questions can be found ADAMS Accession No. ML15212A242.

The NRC staff concludes that, through the implementation of the ESEP guidance, the licensee identified and evaluated the seismic capacity of certain key installed mitigating strategies equipment that is used for core cooling and containment functions to cope with scenarios that involve a loss of all alternating current power and loss of access to the ultimate heat sink to withstand a seismic event up to 1.60 times the licensing basis seismic spectrum for Oyster Creek. The NRC staff concludes that the licensee responded appropriately to Enclosure 1, Item (6) of the 50.54(f) letter. Application of this review is limited to the interim evaluation as part of the Recommendation 2.1 Seismic review.

If you have any questions, please contact me at (301) 415-1115 or via e-mail at [Nicholas.DiFrancesco@nrc.gov](mailto:Nicholas.DiFrancesco@nrc.gov).

Sincerely,

A handwritten signature in black ink, appearing to read "Nicholas DiFrancesco". The signature is fluid and cursive, with a large, prominent loop for the letter "D".

Nicholas DiFrancesco, Senior Project Manager  
Hazards Management Branch  
Japan Lessons-Learned Division  
Office of Nuclear Reactor Regulation

Docket No. 50-219

cc: Distribution via Listserv

The NRC staff concludes that, through the implementation of the ESEP guidance, the licensee identified and evaluated the seismic capacity of certain key installed mitigating strategies equipment that is used for core cooling and containment functions to cope with scenarios that involve a loss of all alternating current power and loss of access to the ultimate heat sink to withstand a seismic event up to 1.60 times the licensing basis seismic spectrum for Oyster Creek. The NRC staff concludes that the licensee responded appropriately to Enclosure 1, Item (6) of the 50.54(f) letter. Application of this review is limited to the interim evaluation as part of the Recommendation 2.1 Seismic review.

If you have any questions, please contact me at (301) 415-1115 or via e-mail at Nicholas.DiFrancesco@nrc.gov.

Sincerely,

*/RA/*

Nicholas DiFrancesco, Senior Project Manager  
Hazards Management Branch  
Japan Lessons-Learned Division  
Office of Nuclear Reactor Regulation

Docket No. 50-219

cc: Distribution via Listserv

**DISTRIBUTION:**

PUBLIC  
JLD R/F  
RidsOeMailCenter  
RidsNrrDorllp1-2  
RidsRgn1MailCenter  
DJackson, NRO  
NDiFrancesco, NRR

RidsNrrPMOysterCreek  
RidsNrrLASLent  
RidsNrrOd  
MShams, NRR

ADAMS Accession Number: ML15240A049

\* via concurrence e-mail

OFFICE	NRR/JLD/JHMB/PM	NRR/JLD/LA	NRO/DSEA/RGS2*
NAME	SWyman	SLent	DJackson*
DATE	8/28/2015	8/31/2015	8/25/2015
OFFICE	NRR/JLD/JHMB/BC	NRR/JLD/JHMB/PM	
NAME	MShams	NDiFrancesco	
DATE	9/3/2015	2/17/2016	

OFFICIAL RECORD COPY