

**NEI, 2012.** Nuclear Energy Institute (NEI), "Submittal of NEI 12-07, Revision 0, Guidelines for Performing Verification Walkdowns of Plant Flood Protection Features," May 2, 2012.

**NEI, 2013.** Nuclear Energy Institute (NEI), "FAQ-031, Hazard Reevaluation Report (HRR) - Interim Action Responses," Revision 1, October 29, 2013.

**NEI, 2014.** Nuclear Energy Institute (NEI), "FAQ-033, Hazard Reevaluation Report (HRR) - Options for Interim Actions for Challenging HRRs," Revision 1b, August 21, 2014.

**NOAA, 1998.** National Oceanic and Atmospheric Administration, National Weather Service (NOAA). "Hydrometeorological Report No. 58, Probable Maximum Precipitation for California – Calculation Procedures," Silver Spring, Maryland, 1998.

**NOAA, 1999.** National Oceanic and Atmospheric Administration, National Weather Service (NOAA). "Hydrometeorological Report No. 58, Probable Maximum Precipitation for California," Silver Spring, Maryland, 1999.

**NOAA, 2012.** National Oceanic and Atmospheric Administration, National Weather Service (NOAA). "NOAA Atlas 14, Precipitation-Frequency Atlas of the United States, Volume 6, Version 2," 2012, Website [http://hdsc.nws.noaa.gov/hdsc/pfds/pfds\\_map\\_cont.html?bkmrk=ca](http://hdsc.nws.noaa.gov/hdsc/pfds/pfds_map_cont.html?bkmrk=ca) data accessed February 28, 2013.

**NOAA, 2013a.** NOAA, National Oceanic and Atmospheric Administration, National Weather Service (NOAA). "Station Snow Climatology, Stations in California," Snow Climatology Data, National Climatology Data Center (NCDC), Website <http://www.ncdc.noaa.gov/ussc/index.jsp> accessed February 25, 2013.

**NOAA, 2013b.** National Oceanic and Atmospheric Administration, National Weather Service (NOAA). "Global Historical Climatology Network – Daily Data," Snow Climatology Data, National Climatology Data Center (NCDC), Website <http://www.ncdc.noaa.gov/most-popular-data#ghcn> accessed February 27, 2013.

**NOAA, 2014.** National Oceanic and Atmospheric Administration, National Weather Service (NOAA). "Global Historical Tsunami Database ". Website [http://www.ngdc.noaa.gov/hazard/tsu\\_db.shtml](http://www.ngdc.noaa.gov/hazard/tsu_db.shtml) accessed July 9, 2014.

**NRC, 1975.** U.S. Nuclear Regulatory Commission (NRC), "Supplement No. 1 to the Safety Evaluation Report by the Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission in the Matter of Pacific Gas and Electric Company Diablo Canyon Nuclear Power Station, Units 1 and 2 Docket Nos. 50-275 and 50-323," Washington, D.C., January 31, 1975.

**NRC, 1976a.** U.S. Nuclear Regulatory Commission (NRC), "Regulatory Guide 1.102 - Flood Protection for Nuclear Power Plants", Revision 1, September 1976.

**NRC, 1976b.** U.S. Nuclear Regulatory Commission (NRC), "Supplement No. 5 to the Safety Evaluation Report by the Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission in the Matter of Pacific Gas and Electric Company Diablo Canyon Nuclear Power

Station, Units 1 and 2 Docket Nos. 50-275 and 50-323," Washington, D.C., September 10, 1976.

**NRC, 1977.** United States Nuclear Regulatory Commission (NRC), "Design Basis Floods for Nuclear Power Plants," Regulatory Guide 1.59, Revision 2, Washington, D.C., August 1977.

**NRC, 1978a.** United States Nuclear Regulatory Commission (NRC), "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants," Regulatory Guide 1.70, Revision 3, Washington, D.C., 1978.

**NRC, 1978b.** United States Nuclear Regulatory Commission (NRC), " Supplement No. 8 to the Safety Evaluation Report for Pacific Gas and Electric Company Diablo Canyon Nuclear Power Plants, Units 1 and 2 (Docket Nos. 50-275 and 50-323)," Washington, D.C., November 15, 1978.

**NRC, 1984.** United States Nuclear Regulatory Commission (NRC), " Supplement 17 to the Safety Evaluation Report for Pacific Gas and Electric Company's Application for licenses to operate Diablo Canyon Nuclear Power Plants, Units 1 and 2 (Docket Nos. 50-275 and 50-323)," Washington, D.C., February 1984.

**NRC, 1999.** United States Nuclear Regulatory Commission (NRC), "Issuance of Amendments for Diablo Canyon Nuclear Power Plant, Unit No. 1 (TAC No. M97914) and Unit No. 2 (TAC No. M97915)," Washington, D.C., March 26, 1999.

**NRC, 2007.** United States Nuclear Regulatory Commission (NRC), "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR Edition," NUREG-0800, Washington, D.C., March, 2007.

**NRC, 2009.** United States Nuclear Regulatory Commission (NRC), "Tsunami Hazard Assessment at Nuclear Power Plant Sites in the United States of America - Final Report," NUREG/CR-6966, PNNL-17397, Richland, WA, March 2009.

**NRC, 2011.** United States Nuclear Regulatory Commission (NRC), "Design-Basis Flood Estimation for Site Characterization at Nuclear Power Plants in the United States of America," NUREG/CR-7046, Washington, D.C., November, 2011.

**NRC, 2012a.** United States Nuclear Regulatory Commission, Letter to Licensees, "Request for Information Pursuant to Title 10 of the Code of Federal Regulations 50.54(f) Regarding Recommendations 2.1, 2.3, and 9.3 of the Near Term Task Force Review of Insights from the Fukushima Dai-ichi Accident." March 12, 2012.

**NRC, 2012b.** United States Nuclear Regulatory Commission (NRC), "Endorsement of Nuclear Energy Institute (NEI) 12-07, 'Guidelines for Performing Verification Walkdowns of Plant Flood Protection Features,'" May 31, 2012.

**NRC, 2012c.** United States Nuclear Regulatory Commission (NRC), "Guidance for Performing the Integrated Assessment for External Flooding," Interim Staff Guidance, Revision 0. JLD-ISG-2012-05, November 30, 2012.

**NRC, 2013.** United States Nuclear Regulatory Commission (NRC), "Guidance for Performing a Tsunami, Surge and Seiche Flooding Safety Analysis Revision 0," Japan Lessons-Learned Project Directorate Interim Staff Guidance, JLD-ISG-2012-06, January 4, 2013.

**NRC, 2014.** United States Nuclear Regulatory Commission (NRC), "Diablo Canyon Power Plant – Staff Assessment of the Flooding Walkdown Report Supporting Implementation of Near-Term Task Force Recommendation 2.3 Related to the Fukushima Dai-Ichi Nuclear Power Plant Accident (TAC Nos. MF0221 and MF0222)," ADAMS Accession No. ML14136A194, June 23, 2014.

**NRC, 1994.** National Research Council (NRC), "Estimating Bounds on Extreme Precipitation Events," National Academy Press, Washington, 1994.

**Okada, 1985.** Okada, Y. "Surface deformation due to shear and tensile faults in a half-space." *Bull. Seismological Soc. Amer.*, 75(4), 1135-1154. 1985.

**Petersen et al, 2008.** Petersen, M. D., Frankel, A. D., Harmsen, S. C., Mueller, C. S., Haller, K. M., Wheeler, R. L., Wesson, R. L., Zeng, Y., Boyd, O. S., Perkins, D. M., Luco, N., Field, E. H., Wills, C. J., and Rukstales, K. S. "Documentation for the 2008 Update of the United States National Seismic Hazard Maps." U.S. Geological Survey Open-File Report 2008–1128, 61. 2008.

**PGE, 2012a.** PG&E Letter DCL-12-059, "Pacific Gas and Electric Company's Response to NRC Request for Information Pursuant to 10 CFR 50.54(f) Regarding the Flooding Aspects of Recommendations 2.1 and 2.3 of the Near-Term Task Force Review of Insights from the Fukushima Dai-ichi Accident," June 7, 2012.

**PGE, 2012b.** PG&E Letter DCL-12-114, "Final Response to Request for Information Pursuant to 10 CFR 50.54(f) Regarding Recommendation 2.3 Flooding," November 27, 2012.

**PGE, 2014.** Pacific Gas and Electric Company (PG&E). "Central Coastal California Seismic Imaging Project Report." Available at Agencywide Documents Access and Management System (ADAMS) Accession Nos. ML14260A024 through ML14260A069. September 2014.

**PGE, 2015.** Pacific Gas and Electric Company (PG&E), "Diablo Canyon Power Plant Units 1 and 2 Final Safety Analysis Report Update." Revision 22, Docket No. 50-275, 50-323, May 2015.

**Prochaska et al, 2008.** Adam B Prochaska, Paul M. Santi, Jerry D. Higgins, Susan H. Cannon. "A study of methods to estimate debris flow velocity, Landslides," DOI 10.1007/s10346-008-0137-0 © Springer-Verlag 2008.

**Resio, 1982.** Resio, D.T., "Report On Wave Climatology For Diablo Canyon, California" 1982.

**Ross et al, 2013.** Ross, S.L., Jones, L.M., Miller, Kevin, P., K.A., Wein, A., Wilson, Ri.I., Bahng, B., Barberopoulou, A., Borrero, J.C., Brosnan, D.M., Bwarie, J.T., Geist, E.L., Johnson, L.A., Kirby, S.H., Knight, W.R., Long, K., Lynett, P., Mortensen, C.E., Nicolsky, D.J., Perry, S.C., Plumlee, G.S., Real, C.R., Ryan, K., Suleimani, E., Thio, H., Titov, V.V., Whitmore, P.M. and Wood, N.J., SAFRR (Science Application for Risk Reduction) Tsunami Scenario—Executive Summary and Introduction: U.S. Geological Survey Open-File Report 2013–1170–A, in Ross, S.L., and Jones, L.M., eds., The SAFRR (Science Application for Risk Reduction) Tsunami Scenario: U.S. Geological Survey Open-File Report 2013–1170, 17 p., 2013.  
<http://pubs.usgs.gov/of/2013/1170/a/>

**Shi et al, 2012.** Shi, F., Kirby, J. T., Harris, J. C., Geiman, J. D., and Grilli, S. T., “A high-order adaptive time-stepping TVD solver for boussinesq modeling of breaking waves and coastal inundation.” *Ocean Modeling*, 43-44, 36-51. 2012.

**Strange and Graham, 1982.** Strange, R.R. and N. Graham, “A Hindcast of Severe Storm Waves at Diablo Canyon, California.” 1982.

**Suito, 2009.** Suito H., and Freymueller, J. T. . “A viscoelastic and afterslip postseismic deformation model for the 1964 Alaska earthquake.” *J. Geophys. Res.*, 114(B11404). 2009.

**Tappin et al, 2014.** Tappin D. R., Grilli, S. T., Harris, J. C., Geller, R. G., Masterlark T., Kirby, J. T., Shi, F., Ma, G., Thingbaijam K. K. S, and Mai, P. M. “Did a submarine landslide contribute to the 2011 Tohoku tsunami?” *Marine Geology*. 2014.

**USACE, 1984.** U.S. Army Corps of Engineers (USACE). “Drainage and Erosion Control Mobilization Construction.” 1984.

**USACE, 1998.** U.S. Army Corps of Engineers (USACE). “Engineering Manual EM-1110-2-1406 Runoff from Snowmelt.” 1998.

**USACE, 2008.** U.S. Army Corps of Engineers (USACE). “Coastal Engineering Manual.” EM-1110-2-1100 (Part II). August 1, 2008 (Change 2). 2008.

**USACE, 2010a.** U.S Army Corps of Engineers (USACE). “Hydrologic Modeling System, HEC-HMS Computer Software,” Version 3.5. Hydrologic Engineering Center, Davis, CA. 2010.

**USACE, 2010b.** U.S Army Corps of Engineers (USACE). “River Analysis System, HEC-RAS Computer Software,” Version 4.1.0. Hydrologic Engineering Center, Davis, CA. 2010.

**USBR, 1992.** U.S. Bureau of Reclamation (USBR). “Flood Hydrology Manual,” Water Resource Technical Publication. Denver, CO. 1992.

**USGS, 2013a.** U.S. Geological Survey (USGS). “USGS Surface-Water Data for California,” Website, <http://waterdata.usgs.gov/ca/nwis/sw> accessed January/February 2013.

**USGS, 2013b.** U.S. Geological Survey (USGS)/California Geological Survey (CGS). “The Search for Geologic Evidence of Distant-Source Tsunamis Using New Field Data in California.” Open-File Report 2013–1170–C. California Geological Survey Special Report 229. 2013.  
<http://pubs.usgs.gov/of/2013/1170/c/pdf/ofr2013-1170c.pdf>

**Uslu, 2008.** Uslu, B. "Deterministic and Probabilistic tsunami studies in California from near and farfield sources," PhD Dissertation, USC. ProQuest. 2008.

**Whitmore, 2013.** Whitmore P., Bohyun-Bahng B., and Knight, W. "Effects of subfault discretization and horizontal displacement on tsunami generation." S. L. Ross and L. M., Jones eds. Tsunami Scenario: U.S. Geological Survey Open-File Report 2013. Chp D. 2013.  
<http://pubs.usgs.gov/of/2013/1170/b/>.

**WMO, 1986.** World Meteorological Organization. "1986: Manual for Estimation of Probable Maximum Precipitation, Operational Hydrology Report No. 1," WMO No. 332, Geneva, Switzerland.

**WMO, 2006.** World Meteorological Organization. "2009: Manual for Estimation of Probable Maximum Precipitation, Operational Hydrology Report No. 1," WMO No. 1045, Geneva, Switzerland.

**Wills, 2007.** Wills, C. J., II, R. W., and Bryant, W. A. "California fault parameters for the national seismic hazard maps and working group on California earthquake probabilities. US Geological Survey Open File Report. 2007.

**Table 3-1 Diablo Creek Location Used in Storm Calculations**

Elevation Used	100 feet	
Location Used	Latitude	Longitude
	35.211	120.855

**Table 3-2 Storms Used in the Diablo Creek Site-Specific PMP Calculation**

Station Name	State	Lat	Lon	Year	Mon	Day	Maximum 1-hour Rainfall	DCCP Total Adjustment Factor	DCCP 1-hour LIP
OAKLAND SOUTH	CA	37.7830	-122.1500	1999	11	19	3.26	1.38	4.50
BEL AIR HOTEL	CA	34.0860	-118.4550	1983	3	1	3.00	1.40	4.20
OCEANSIDE	CA	33.2560	-117.3200	1993	1	16	2.95	1.39	4.10
LAGUNA BEACH	CA	33.5510	-117.8000	1997	12	6	2.50	1.47	3.68
WHEELER GORGE	CA	34.3670	-119.3830	1992	2	12	2.32	1.43	3.32
SAN MARCOS TROUT	CA	34.4830	-119.8000	1995	1	9	2.15	1.48	3.18
DOULTON TUNNEL	CA	34.4630	-119.7080	1973	2	11	2.25	1.35	3.04
STANDWOOD FIRE STATION	CA	34.4500	-119.6830	1983	9	29	2.40	1.19	2.86
BOULDER CREEK	CA	37.0916	-122.1668	1955	12	24	2.20	1.29	2.84
NOJOQUI	CA	34.5340	-120.1780	2002	12	20	2.09	1.24	2.59
GONZALES	CA	36.5150	-121.5100	1994	11	10	2.09	1.16	2.42
SIGNAL HILL	CA	33.8000	-118.1667	1995	1	4	2.00	1.19	2.38
CANYON CREEK	CA	34.0832	-118.8418	1943	1	22	1.96	1.21	2.37
ARROYO SECO	CA	36.3590	-121.2900	1993	11	11	2.01	1.06	2.13

Rainfall and LIP values are in inches.

**Table 3-3 Site-Specific LIP for Various Durations at the DCCP Power Block**

Duration (hours)	DCCP LIP (inches)
0	0
0.25	2.5
0.5	3.6
0.75	4.1
1-hour	4.5
2-hour	5.1
3-hour	5.4
4-hour	5.6
5-hour	5.8
6-hour	5.9

**Table 3-4 Temporal Distributions of 15-Minute Incremental Point PMP at DCPP Site**

Duration (hours)	Front End Peaking		One-Third Peaking		Center Peaking		Two-Third Peaking		End Peaking	
	ILIP* (in)	PLIP**	ILIP (in)	PLIP	ILIP (in)	PLIP	ILIP (in)	PLIP	ILIP (in)	PLIP
0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.250	2.475	0.423	0.043	0.007	0.026	0.005	0.006	0.001	0.006	0.001
0.500	3.555	0.608	0.093	0.016	0.054	0.009	0.032	0.006	0.032	0.006
0.750	4.095	0.700	0.173	0.030	0.084	0.014	0.059	0.010	0.059	0.010
1.000	4.500	0.769	0.269	0.046	0.118	0.020	0.086	0.015	0.086	0.015
1.250	4.683	0.801	0.422	0.072	0.161	0.028	0.115	0.020	0.115	0.020
1.500	4.841	0.828	0.605	0.103	0.211	0.036	0.146	0.025	0.146	0.025
1.750	4.994	0.854	1.145	0.196	0.291	0.050	0.177	0.030	0.177	0.030
2.000	5.130	0.877	3.620	0.619	0.387	0.066	0.211	0.036	0.211	0.036
2.250	5.226	0.893	4.700	0.803	0.540	0.092	0.254	0.043	0.246	0.042
2.500	5.318	0.909	5.105	0.873	0.723	0.124	0.304	0.052	0.289	0.049
2.750	5.397	0.923	5.263	0.900	1.263	0.216	0.384	0.066	0.335	0.057
3.000	5.465	0.934	5.399	0.923	3.738	0.639	0.480	0.082	0.385	0.066
3.250	5.515	0.943	5.491	0.939	4.818	0.824	0.633	0.108	0.453	0.077
3.500	5.561	0.951	5.558	0.950	5.223	0.893	0.816	0.139	0.532	0.091
3.750	5.604	0.958	5.604	0.958	5.381	0.920	1.356	0.232	0.624	0.107
4.000	5.639	0.964	5.639	0.964	5.517	0.943	3.831	0.655	0.720	0.123
4.250	5.673	0.970	5.673	0.970	5.608	0.959	4.911	0.839	0.856	0.146
4.500	5.704	0.975	5.704	0.975	5.676	0.970	5.316	0.909	1.009	0.172
4.750	5.735	0.980	5.735	0.980	5.721	0.978	5.474	0.936	1.167	0.199
5.000	5.764	0.985	5.764	0.985	5.757	0.984	5.610	0.959	1.350	0.231
5.250	5.791	0.990	5.791	0.990	5.789	0.989	5.701	0.975	1.755	0.300
5.500	5.818	0.994	5.818	0.994	5.817	0.994	5.769	0.986	2.295	0.392
5.750	5.844	0.999	5.844	0.999	5.844	0.999	5.814	0.994	3.375	0.577
6.000	5.900	1.000	5.900	1.000	5.900	1.000	5.900	1.000	5.900	1.000

\* ILIP = cumulative LIP; \*\* PLIP = Portion of cumulative LIP

**Table 3-5 Maximum LIP Flooding Parameters near the Doors and Areas to the West of the Turbine and Buttruss Buildings**

Correlated Buttruss Building Area <sup>2</sup>	No	Door/Unit No <sup>2</sup>	Door Threshold Elevation	Grid No	Grid Elevation (ft PG&E Datum)	Max WSE	Max WD above grid surface (ft)	Max WD above Door Threshold <sup>1</sup> (ft)	Flood Duration (hours)
			(ft PG&E Datum)			(ft PG&E Datum)			
0	1	2	3	4	5	6	7	(8) = (6) - (3)	9
<b>Turbine Building Unit 1: North</b>									
A1	1	A1.1	86.8	1034	86.58	86.79	0.21	-0.01	0
	2	A1.2	86.8	1033	86.56	86.77	0.21	-0.03	0
A2	3	A2.1	86.5	1181	86.48	86.73	0.25	0.23	7.60
	4	BU101	86.5	877	86.48	86.58	0.10	0.08	6.90
A3	5	BU102	86.5	1174	86.47	86.67	0.20	0.17	3.30
	6	BU103	86.5	2106	86.45	86.64	0.19	0.14	0.55
	7	A3.1	86.5	1326	86.45	86.71	0.26	0.21	2.75
	8	A3.2	86.5	1633	86.47	86.71	0.24	0.21	3.05
	9	A3.3	86.5	2268	86.45	86.62	0.17	0.12	0.45
	10	BU104/5	86.5	2600	86.47	86.66	0.19	0.16	3.20
N/A	11	101-1	86.8	1975	86.78	87.02	0.24	0.22	7.05
	12	102-1	86.8	1655	86.73	87.00	0.27	0.20	0.60
	13	119-1	86.8	3507	86.78	87.24	0.46	0.44	6.65
	14	122-1	86.8	4238	86.77	87.43	0.66	0.63	5.10
C	15	C1.1	86.8	2944	86.77	86.93	0.16	0.13	4.50
	16	129	86.8	3118	86.78	86.92	0.14	0.12	6.80
	17	130	86.8	3117	86.77	86.86	0.09	0.06	2.95
<b>Turbine Building Unit 2: South</b>									
C	18	C1.2	86.8	3469	86.77	87.04	0.27	0.24	5.30
B3	19	BU101-2	86.7	3112	86.47	86.68	0.21	-0.02	0
	20	BU102-2	86.65	3108	86.58	86.65	0.07	0.00	0
	21	BU103-2	86.5	3101	86.36	86.42	0.06	-0.08	0
	22	BU104-2	86.5	3454	86.36	86.46	0.10	-0.04	0
B2	23	BU108-2	86.5	4570	86.47	86.64	0.17	0.14	3.80
	24	BU105-2	86.5	4760	86.48	86.62	0.14	0.12	6.40
	25	BU106-2	86.7	5350	86.64	86.86	0.22	0.16	2.85
	26	B2.1	86.8	5550	86.77	86.91	0.14	0.11	3.20
B1	27	B1.1	86.8	5749	86.76	86.87	0.11	0.07	0.35
	28	B1.2	86.8	5950	86.79	86.93	0.14	0.13	7.35
N/A	29	101-2	86.8	7412	86.77	87.12	0.35	0.32	4.35
	30	102-2	86.8	7198	86.78	87.12	0.34	0.32	6.75
	31	119-2	86.8	8287	86.78	87.23	0.45	0.43	7.05
	32	122-2	86.8	7431	86.78	87.31	0.53	0.51	6.55

Correlated Buttress Building Area <sup>2</sup>	No	Door/Unit No <sup>2</sup>	Door Threshold Elevation	Grid No	Grid Elevation (ft PG&E Datum)	Max WSE	Max WD above grid surface	Max WD above Door Threshold <sup>1</sup>	Flood Duration (hours)
			(ft PG&E Datum)		(ft PG&E Datum)	(ft)	(ft)		
0	1	2	3	4	5	6	7	(8) = (6) - (3)	9
<b>Unit 1 - Auxiliary Building Area (Ventilation Building)</b>									
N/A	33	192-1	86.8	5003	86.78	87.48	0.70	0.68	6.95
	34	191-1	86.8	7054	86.79	87.36	0.57	0.56	6.75
	35	194-1	86.8	6425	86.77	87.35	0.58	0.55	5.20
<b>Unit 2 - Auxiliary Building Area (Ventilation Building)</b>									
N/A	36	192-2	86.8	7223	86.79	87.39	0.60	0.59	6.85
	37	191-2 191A-2	86.8	11520	86.78	87.28	0.50	0.48	6.45
	38	194-2	86.8	10338	86.73	87.26	0.53	0.46	1.30
<b>Fuel Handling Building (East of Unit 1)</b>									
N/A	39	363-1	116.8	8566	116.78	116.90	0.12	0.10	6.50
	40	361-1	116.8	9681	116.78	117.19	0.41	0.39	6.00
	41	360-1	116.8	9680	116.79	117.19	0.40	0.39	7.20
	42	355-1	116.8	10367	116.76	117.25	0.49	0.45	3.80
	43	354-1	116.8	10599	116.79	117.25	0.46	0.45	7.05
<b>Fuel Handling Building (East of Unit 2)</b>									
N/A	44	360-2	116.8	11300	116.75	117.26	0.51	0.46	5.65
	45	361-2	116.8	11536	116.76	117.26	0.50	0.46	5.30
	46	363-2	116.8	12486	116.78	116.82	[0.04] 0.05**	[0.02] 0.05**	6.40

1. Negative value reflects no LIP exceedance near the doors or areas
  2. Door/Unit Nos. are shown in Figures 3-2a and 3-2b.
- \*\* Minimum ponding depth taken as 0.05 feet.

**Table 3-6 Hydrodynamic and Total Associated Effects Resulting from LIP Flood Event**

No.	Door/Unit No <sup>2</sup>	Grid Cell No	Flow Depth (ft)	Velocity Magnitude (ft/s)	Total Head <sup>3</sup> (ft)	Force <sup>1</sup> (lb/ft)
<b>Turbine Building Unit 1: North</b>						
1	A1.1	1034	0.00	0.00	1.00	0
2	A1.2	1033	0.00	0.00	1.00	0
3	A2.1	1181	0.22	0.55	1.23	9
4	BU101	877	0.08	0.23	1.08	3
5	BU102	1174	0.17	0.35	1.17	6
6	BU103	2106	0.14	0.21	1.14	5
7	A3.1	1326	0.21	0.19	1.21	8
8	A3.2	1633	0.20	0.09	1.20	8
9	A3.3	2268	0.12	0.10	1.12	4
10	BU104/5	2600	0.16	0.26	1.16	6
11	101-1	1975	0.20	0.41	1.21	8
12	102-1	1655	0.19	0.23	1.19	7
13	119-1	3507	0.42	0.25	1.43	19
14	122-1	4238	0.60	0.00	1.60	30
15	C1.1	2944	0.13	0.26	1.13	5
16	129	3118	0.12	0.35	1.12	4
17	130	3117	0.06	0.21	1.06	2
<b>Turbine Building Unit 2: South</b>						
18	C1.2	3469	0.24	0.64	1.25	9
19	BU101-2	3112	0.00	0.00	1.00	0
20	BU102-2	3108	0.00	0.00	1.00	0
21	BU103-2	3101	0.00	0.00	1.00	0
22	BU104-2	3454	0.00	0.00	1.00	0
23	BU108-2	4570	0.13	0.15	1.13	5
24	BU105-2	4760	0.12	0.33	1.12	4
25	BU106-2	5350	0.16	0.52	1.16	6
26	B2.1	5550	0.10	0.31	1.11	4
27	B1.1	5749	0.07	0.11	1.07	2
28	B1.2	5950	0.13	0.19	1.13	5
29	101-2	7412	0.31	0.24	1.31	13
30	102-2	7198	0.31	0.23	1.31	13
31	119-2	8287	0.42	0.28	1.42	19
32	122-2	7431	0.51	0.33	1.51	24

No.	Door/Unit No <sup>2</sup>	Grid Cell No	Flow Depth (ft)	Velocity Magnitude (ft/s)	Total Head <sup>3</sup> (ft)	Force <sup>1</sup> (lb/ft)
<b>Unit 1 - Auxiliary Building Area (Ventilation Building)</b>						
33	192-1	5003	0.67	0.13	1.67	35
34	191-1	7054	0.55	0.06	1.55	27
35	194-1	6425	0.53	0.12	1.53	25
<b>Unit 2 - Auxiliary Building Area (Ventilation Building)</b>						
36	192-2	7223	0.59	0.22	1.59	29
37	191-2 191A-2	11520	0.47	0.20	1.47	21
38	194-2	10338	0.45	0.07	1.45	20
<b>Fuel Handling Building (East of Unit 1)</b>						
39	363-1	8566	0.10	0.24	1.10	3
40	361-1	9681	0.39	0.00	1.39	17
41	360-1	9680	0.39	0.15	1.39	17
42	355-1	10367	0.45	0.09	1.45	20
43	354-1	10599	0.45	0.10	1.45	20
<b>Fuel Handling Building (East of Unit 2)</b>						
44	360-2	11300	0.45	0.06	1.45	20
45	361-2	11536	0.45	0.28	1.46	21
46	363-2	12486	0.02	0.00	1.02	1

1. Total force (force per linear foot length) is rounded to the nearest whole number.
2. Door/Unit Nos. are shown in Figures 3-2a and 3-2b.
3. Per American Society of Civil Engineers 7-10, the static water level should be increased by 1 ft. However, if no flow depth or velocity is present, total force = 0 lb/ft.

**Table 3-7 GEV Fitted Precipitation Estimates and 90% CI at DCPP Site**

	<b>1,000,000 Years Return Period</b>
<b>Lower 90% CI Lower Limit</b>	2.84 inches
<b>Upper 90% CI Lower Limit</b>	3.60 inches
<b>Mean Precipitation</b>	3.17 inches

Table 3-8 General Storm PMP (Page 1 of 7)

Time (hours)	15-Minute Incremental General Storm PMP Depths (inches)				
	for Five Temporal Distributions				
	Front Peaking	One-Third Peaking	Center Peaking	Two-Thirds Peaking	End Peaking
0	0.0000	0.0000	0.0000	0.0000	0.0000
0.25	0.6551	0.0711	0.0199	0.0192	0.0192
0.5	0.6174	0.0719	0.0212	0.0199	0.0199
0.75	0.5812	0.0727	0.0225	0.0205	0.0205
1	0.5464	0.0735	0.0238	0.0212	0.0212
1.25	0.3187	0.0742	0.0251	0.0219	0.0219
1.5	0.3157	0.0749	0.0264	0.0225	0.0225
1.75	0.3127	0.0757	0.0277	0.0232	0.0232
2	0.3097	0.0764	0.0290	0.0238	0.0238
2.25	0.3068	0.0771	0.0302	0.0245	0.0245
2.5	0.3038	0.0778	0.0315	0.0251	0.0251
2.75	0.3007	0.0785	0.0327	0.0258	0.0258
3	0.2977	0.0792	0.0339	0.0264	0.0264
3.25	0.2947	0.0798	0.0351	0.0271	0.0271
3.5	0.2917	0.0805	0.0363	0.0277	0.0277
3.75	0.2886	0.0811	0.0375	0.0283	0.0283
4	0.2856	0.0818	0.0387	0.0290	0.0290
4.25	0.2825	0.0824	0.0399	0.0296	0.0296
4.5	0.2794	0.0830	0.0410	0.0302	0.0302
4.75	0.2764	0.0836	0.0422	0.0309	0.0309
5	0.2733	0.0842	0.0433	0.0315	0.0315
5.25	0.2702	0.0847	0.0444	0.0321	0.0321
5.5	0.2671	0.0853	0.0455	0.0327	0.0327
5.75	0.2640	0.0858	0.0466	0.0333	0.0333
6	0.2608	0.0864	0.0477	0.0339	0.0339
6.25	0.2577	0.0869	0.0488	0.0345	0.0345
6.5	0.2546	0.0874	0.0498	0.0351	0.0351
6.75	0.2514	0.0879	0.0509	0.0357	0.0357
7	0.2482	0.0884	0.0519	0.0363	0.0363
7.25	0.2451	0.0889	0.0530	0.0369	0.0369
7.5	0.2419	0.0894	0.0540	0.0375	0.0375
7.75	0.2387	0.0898	0.0550	0.0381	0.0381
8	0.2355	0.0903	0.0560	0.0387	0.0387
8.25	0.2323	0.0907	0.0570	0.0393	0.0393
8.5	0.2291	0.0911	0.0579	0.0399	0.0399
8.75	0.2259	0.0915	0.0589	0.0404	0.0404
9	0.2227	0.0919	0.0598	0.0410	0.0410
9.25	0.2194	0.0923	0.0608	0.0416	0.0416
9.5	0.2162	0.0927	0.0617	0.0422	0.0422
9.75	0.2129	0.0931	0.0626	0.0427	0.0427
10	0.2097	0.0934	0.0635	0.0433	0.0433
10.25	0.2064	0.0938	0.0644	0.0439	0.0439
10.5	0.2031	0.0941	0.0653	0.0444	0.0444

Table 3-8 General Storm PMP (Page 2 of 7)

Time (hours)	15-Minute Incremental General Storm PMP Depths (inches)				
	for Five Temporal Distributions				
	Front Peaking	One-Third Peaking	Center Peaking	Two-Thirds Peaking	End Peaking
10.75	0.1998	0.0944	0.0661	0.0450	0.0450
11	0.1965	0.0947	0.0670	0.0455	0.0455
11.25	0.1932	0.0950	0.0679	0.0461	0.0461
11.5	0.1899	0.0953	0.0687	0.0466	0.0466
11.75	0.1866	0.0956	0.0695	0.0472	0.0472
12	0.1832	0.0959	0.0703	0.0477	0.0477
12.25	0.0988	0.0961	0.0711	0.0482	0.0482
12.5	0.0988	0.0964	0.0719	0.0488	0.0488
12.75	0.0988	0.0966	0.0727	0.0493	0.0493
13	0.0988	0.0968	0.0735	0.0498	0.0498
13.25	0.0988	0.0970	0.0742	0.0504	0.0504
13.5	0.0988	0.0972	0.0749	0.0509	0.0509
13.75	0.0988	0.0974	0.0757	0.0514	0.0514
14	0.0988	0.0976	0.0764	0.0519	0.0519
14.25	0.0988	0.0977	0.0771	0.0524	0.0524
14.5	0.0988	0.0979	0.0778	0.0530	0.0530
14.75	0.0987	0.0980	0.0785	0.0535	0.0535
15	0.0987	0.0982	0.0792	0.0540	0.0540
15.25	0.0987	0.0983	0.0798	0.0545	0.0545
15.5	0.0987	0.0984	0.0805	0.0550	0.0550
15.75	0.0986	0.0985	0.0811	0.0555	0.0555
16	0.0986	0.0986	0.0818	0.0560	0.0560
16.25	0.0986	0.0986	0.0824	0.0565	0.0565
16.5	0.0985	0.0987	0.0830	0.0570	0.0570
16.75	0.0985	0.0987	0.0836	0.0574	0.0574
17	0.0984	0.0988	0.0842	0.0579	0.0579
17.25	0.0984	0.0988	0.0847	0.0584	0.0584
17.5	0.0983	0.0988	0.0853	0.0589	0.0589
17.75	0.0983	0.0988	0.0858	0.0594	0.0594
18	0.0982	0.0988	0.0864	0.0598	0.0598
18.25	0.0982	0.1866	0.0869	0.0603	0.0603
18.5	0.0981	0.1932	0.0874	0.0608	0.0608
18.75	0.0980	0.1998	0.0879	0.0612	0.0612
19	0.0980	0.2064	0.0884	0.0617	0.0617
19.25	0.0979	0.2129	0.0889	0.0622	0.0622
19.5	0.0978	0.2194	0.0894	0.0626	0.0626
19.75	0.0977	0.2259	0.0898	0.0631	0.0631
20	0.0977	0.2323	0.0903	0.0635	0.0635
20.25	0.0976	0.2387	0.0907	0.0640	0.0640
20.5	0.0975	0.2451	0.0911	0.0644	0.0644
20.75	0.0974	0.2514	0.0915	0.0648	0.0648
21	0.0973	0.2577	0.0919	0.0653	0.0653
21.25	0.0972	0.2640	0.0923	0.0657	0.0657

Table 3-8 General Storm PMP (Page 3 of 7)

Time (hours)	15-Minute Incremental General Storm PMP Depths (inches)				
	for Five Temporal Distributions				
	Front Peaking	One-Third Peaking	Center Peaking	Two-Thirds Peaking	End Peaking
21.5	0.0971	0.2702	0.0927	0.0661	0.0661
21.75	0.0970	0.2764	0.0931	0.0666	0.0666
22	0.0969	0.2825	0.0934	0.0670	0.0670
22.25	0.0968	0.2886	0.0938	0.0674	0.0674
22.5	0.0967	0.2947	0.0941	0.0679	0.0679
22.75	0.0966	0.3007	0.0944	0.0683	0.0683
23	0.0965	0.3068	0.0947	0.0687	0.0687
23.25	0.0964	0.3127	0.0950	0.0691	0.0691
23.5	0.0962	0.3187	0.0953	0.0695	0.0695
23.75	0.0961	0.5812	0.0956	0.0699	0.0699
24	0.0960	0.6551	0.0959	0.0703	0.0703
24.25	0.0959	0.6174	0.0961	0.0711	0.0707
24.5	0.0957	0.5464	0.0964	0.0719	0.0711
24.75	0.0956	0.3157	0.0966	0.0727	0.0715
25	0.0955	0.3097	0.0968	0.0735	0.0719
25.25	0.0953	0.3038	0.0970	0.0742	0.0723
25.5	0.0952	0.2977	0.0972	0.0749	0.0727
25.75	0.0950	0.2917	0.0974	0.0757	0.0731
26	0.0949	0.2856	0.0976	0.0764	0.0735
26.25	0.0947	0.2794	0.0977	0.0771	0.0738
26.5	0.0946	0.2733	0.0979	0.0778	0.0742
26.75	0.0944	0.2671	0.0980	0.0785	0.0746
27	0.0943	0.2608	0.0982	0.0792	0.0749
27.25	0.0941	0.2546	0.0983	0.0798	0.0753
27.5	0.0939	0.2482	0.0984	0.0805	0.0757
27.75	0.0938	0.2419	0.0985	0.0811	0.0760
28	0.0936	0.2355	0.0986	0.0818	0.0764
28.25	0.0934	0.2291	0.0986	0.0824	0.0768
28.5	0.0933	0.2227	0.0987	0.0830	0.0771
28.75	0.0931	0.2162	0.0987	0.0836	0.0775
29	0.0929	0.2097	0.0988	0.0842	0.0778
29.25	0.0927	0.2031	0.0988	0.0847	0.0782
29.5	0.0925	0.1965	0.0988	0.0853	0.0785
29.75	0.0923	0.1899	0.0988	0.0858	0.0788
30	0.0921	0.1832	0.0988	0.0864	0.0792
30.25	0.0919	0.0988	0.1866	0.0869	0.0795
30.5	0.0917	0.0988	0.1932	0.0874	0.0798
30.75	0.0915	0.0988	0.1998	0.0879	0.0802
31	0.0913	0.0988	0.2064	0.0884	0.0805
31.25	0.0911	0.0988	0.2129	0.0889	0.0808
31.5	0.0909	0.0987	0.2194	0.0894	0.0811
31.75	0.0907	0.0987	0.2259	0.0898	0.0814
32	0.0905	0.0986	0.2323	0.0903	0.0818

Table 3-8 General Storm PMP (Page 4 of 7)

Time (hours)	15-Minute Incremental General Storm PMP Depths (inches)				
	for Five Temporal Distributions				
	Front Peaking	One-Third Peaking	Center Peaking	Two-Thirds Peaking	End Peaking
32.25	0.0903	0.0985	0.2387	0.0907	0.0821
32.5	0.0900	0.0984	0.2451	0.0911	0.0824
32.75	0.0898	0.0983	0.2514	0.0915	0.0827
33	0.0896	0.0982	0.2577	0.0919	0.0830
33.25	0.0894	0.0981	0.2640	0.0923	0.0833
33.5	0.0891	0.0980	0.2702	0.0927	0.0836
33.75	0.0889	0.0978	0.2764	0.0931	0.0839
34	0.0887	0.0977	0.2825	0.0934	0.0842
34.25	0.0884	0.0975	0.2886	0.0938	0.0844
34.5	0.0882	0.0973	0.2947	0.0941	0.0847
34.75	0.0879	0.0971	0.3007	0.0944	0.0850
35	0.0877	0.0969	0.3068	0.0947	0.0853
35.25	0.0874	0.0967	0.3127	0.0950	0.0856
35.5	0.0872	0.0965	0.3187	0.0953	0.0858
35.75	0.0869	0.0962	0.5812	0.0956	0.0861
36	0.0866	0.0960	0.6551	0.0959	0.0864
36.25	0.0864	0.0957	0.6174	0.0961	0.0866
36.5	0.0861	0.0955	0.5464	0.0964	0.0869
36.75	0.0858	0.0952	0.3157	0.0966	0.0872
37	0.0856	0.0949	0.3097	0.0968	0.0874
37.25	0.0853	0.0946	0.3038	0.0970	0.0877
37.5	0.0850	0.0943	0.2977	0.0972	0.0879
37.75	0.0847	0.0939	0.2917	0.0974	0.0882
38	0.0844	0.0936	0.2856	0.0976	0.0884
38.25	0.0842	0.0933	0.2794	0.0977	0.0887
38.5	0.0839	0.0929	0.2733	0.0979	0.0889
38.75	0.0836	0.0925	0.2671	0.0980	0.0891
39	0.0833	0.0921	0.2608	0.0982	0.0894
39.25	0.0830	0.0917	0.2546	0.0983	0.0896
39.5	0.0827	0.0913	0.2482	0.0984	0.0898
39.75	0.0824	0.0909	0.2419	0.0985	0.0900
40	0.0821	0.0905	0.2355	0.0986	0.0903
40.25	0.0818	0.0900	0.2291	0.0986	0.0905
40.5	0.0814	0.0896	0.2227	0.0987	0.0907
40.75	0.0811	0.0891	0.2162	0.0987	0.0909
41	0.0808	0.0887	0.2097	0.0988	0.0911
41.25	0.0805	0.0882	0.2031	0.0988	0.0913
41.5	0.0802	0.0877	0.1965	0.0988	0.0915
41.75	0.0798	0.0872	0.1899	0.0988	0.0917
42	0.0795	0.0866	0.1832	0.0988	0.0919
42.25	0.0792	0.0861	0.0988	0.1866	0.0921
42.5	0.0788	0.0856	0.0988	0.1932	0.0923
42.75	0.0785	0.0850	0.0988	0.1998	0.0925

Table 3-8 General Storm PMP (Page 5 of 7)

Time (hours)	15-Minute Incremental General Storm PMP Depths (inches)				
	for Five Temporal Distributions				
	Front Peaking	One-Third Peaking	Center Peaking	Two-Thirds Peaking	End Peaking
43	0.0782	0.0844	0.0988	0.2064	0.0927
43.25	0.0778	0.0839	0.0988	0.2129	0.0929
43.5	0.0775	0.0833	0.0987	0.2194	0.0931
43.75	0.0771	0.0827	0.0987	0.2259	0.0933
44	0.0768	0.0821	0.0986	0.2323	0.0934
44.25	0.0764	0.0814	0.0985	0.2387	0.0936
44.5	0.0760	0.0808	0.0984	0.2451	0.0938
44.75	0.0757	0.0802	0.0983	0.2514	0.0939
45	0.0753	0.0795	0.0982	0.2577	0.0941
45.25	0.0749	0.0788	0.0981	0.2640	0.0943
45.5	0.0746	0.0782	0.0980	0.2702	0.0944
45.75	0.0742	0.0775	0.0978	0.2764	0.0946
46	0.0738	0.0768	0.0977	0.2825	0.0947
46.25	0.0735	0.0760	0.0975	0.2886	0.0949
46.5	0.0731	0.0753	0.0973	0.2947	0.0950
46.75	0.0727	0.0746	0.0971	0.3007	0.0952
47	0.0723	0.0738	0.0969	0.3068	0.0953
47.25	0.0719	0.0731	0.0967	0.3127	0.0955
47.5	0.0715	0.0723	0.0965	0.3187	0.0956
47.75	0.0711	0.0715	0.0962	0.5812	0.0957
48	0.0707	0.0707	0.0960	0.6551	0.0959
48.25	0.0703	0.0703	0.0957	0.6174	0.0960
48.5	0.0699	0.0699	0.0955	0.5464	0.0961
48.75	0.0695	0.0695	0.0952	0.3157	0.0962
49	0.0691	0.0691	0.0949	0.3097	0.0964
49.25	0.0687	0.0687	0.0946	0.3038	0.0965
49.5	0.0683	0.0683	0.0943	0.2977	0.0966
49.75	0.0679	0.0679	0.0939	0.2917	0.0967
50	0.0674	0.0674	0.0936	0.2856	0.0968
50.25	0.0670	0.0670	0.0933	0.2794	0.0969
50.5	0.0666	0.0666	0.0929	0.2733	0.0970
50.75	0.0661	0.0661	0.0925	0.2671	0.0971
51	0.0657	0.0657	0.0921	0.2608	0.0972
51.25	0.0653	0.0653	0.0917	0.2546	0.0973
51.5	0.0648	0.0648	0.0913	0.2482	0.0974
51.75	0.0644	0.0644	0.0909	0.2419	0.0975
52	0.0640	0.0640	0.0905	0.2355	0.0976
52.25	0.0635	0.0635	0.0900	0.2291	0.0977
52.5	0.0631	0.0631	0.0896	0.2227	0.0977
52.75	0.0626	0.0626	0.0891	0.2162	0.0978
53	0.0622	0.0622	0.0887	0.2097	0.0979
53.25	0.0617	0.0617	0.0882	0.2031	0.0980
53.5	0.0612	0.0612	0.0877	0.1965	0.0980

Table 3-8 General Storm PMP (Page 6 of 7)

Time (hours)	15-Minute Incremental General Storm PMP Depths (inches)				
	for Five Temporal Distributions				
	Front Peaking	One-Third Peaking	Center Peaking	Two-Thirds Peaking	End Peaking
53.75	0.0608	0.0608	0.0872	0.1899	0.0981
54	0.0603	0.0603	0.0866	0.1832	0.0982
54.25	0.0598	0.0598	0.0861	0.0988	0.0982
54.5	0.0594	0.0594	0.0856	0.0988	0.0983
54.75	0.0589	0.0589	0.0850	0.0988	0.0983
55	0.0584	0.0584	0.0844	0.0988	0.0984
55.25	0.0579	0.0579	0.0839	0.0988	0.0984
55.5	0.0574	0.0574	0.0833	0.0987	0.0985
55.75	0.0570	0.0570	0.0827	0.0987	0.0985
56	0.0565	0.0565	0.0821	0.0986	0.0986
56.25	0.0560	0.0560	0.0814	0.0985	0.0986
56.5	0.0555	0.0555	0.0808	0.0984	0.0986
56.75	0.0550	0.0550	0.0802	0.0983	0.0987
57	0.0545	0.0545	0.0795	0.0982	0.0987
57.25	0.0540	0.0540	0.0788	0.0981	0.0987
57.5	0.0535	0.0535	0.0782	0.0980	0.0987
57.75	0.0530	0.0530	0.0775	0.0978	0.0988
58	0.0524	0.0524	0.0768	0.0977	0.0988
58.25	0.0519	0.0519	0.0760	0.0975	0.0988
58.5	0.0514	0.0514	0.0753	0.0973	0.0988
58.75	0.0509	0.0509	0.0746	0.0971	0.0988
59	0.0504	0.0504	0.0738	0.0969	0.0988
59.25	0.0498	0.0498	0.0731	0.0967	0.0988
59.5	0.0493	0.0493	0.0723	0.0965	0.0988
59.75	0.0488	0.0488	0.0715	0.0962	0.0988
60	0.0482	0.0482	0.0707	0.0960	0.0988
60.25	0.0477	0.0477	0.0699	0.0957	0.1832
60.5	0.0472	0.0472	0.0691	0.0955	0.1866
60.75	0.0466	0.0466	0.0683	0.0952	0.1899
61	0.0461	0.0461	0.0674	0.0949	0.1932
61.25	0.0455	0.0455	0.0666	0.0946	0.1965
61.5	0.0450	0.0450	0.0657	0.0943	0.1998
61.75	0.0444	0.0444	0.0648	0.0939	0.2031
62	0.0439	0.0439	0.0640	0.0936	0.2064
62.25	0.0433	0.0433	0.0631	0.0933	0.2097
62.5	0.0427	0.0427	0.0622	0.0929	0.2129
62.75	0.0422	0.0422	0.0612	0.0925	0.2162
63	0.0416	0.0416	0.0603	0.0921	0.2194
63.25	0.0410	0.0410	0.0594	0.0917	0.2227
63.5	0.0404	0.0404	0.0584	0.0913	0.2259
63.75	0.0399	0.0399	0.0574	0.0909	0.2291
64	0.0393	0.0393	0.0565	0.0905	0.2323
64.25	0.0387	0.0387	0.0555	0.0900	0.2355

**Table 3-8 General Storm PMP (Page 7 of 7)**

Time (hours)	15-Minute Incremental General Storm PMP Depths (inches)				
	for Five Temporal Distributions				
	Front Peaking	One-Third Peaking	Center Peaking	Two-Thirds Peaking	End Peaking
64.5	0.0381	0.0381	0.0545	0.0896	0.2387
64.75	0.0375	0.0375	0.0535	0.0891	0.2419
65	0.0369	0.0369	0.0524	0.0887	0.2451
65.25	0.0363	0.0363	0.0514	0.0882	0.2482
65.5	0.0357	0.0357	0.0504	0.0877	0.2514
65.75	0.0351	0.0351	0.0493	0.0872	0.2546
66	0.0345	0.0345	0.0482	0.0866	0.2577
66.25	0.0339	0.0339	0.0472	0.0861	0.2608
66.5	0.0333	0.0333	0.0461	0.0856	0.2640
66.75	0.0327	0.0327	0.0450	0.0850	0.2671
67	0.0321	0.0321	0.0439	0.0844	0.2702
67.25	0.0315	0.0315	0.0427	0.0839	0.2733
67.5	0.0309	0.0309	0.0416	0.0833	0.2764
67.75	0.0302	0.0302	0.0404	0.0827	0.2794
68	0.0296	0.0296	0.0393	0.0821	0.2825
68.25	0.0290	0.0290	0.0381	0.0814	0.2856
68.5	0.0283	0.0283	0.0369	0.0808	0.2886
68.75	0.0277	0.0277	0.0357	0.0802	0.2917
69	0.0271	0.0271	0.0345	0.0795	0.2947
69.25	0.0264	0.0264	0.0333	0.0788	0.2977
69.5	0.0258	0.0258	0.0321	0.0782	0.3007
69.75	0.0251	0.0251	0.0309	0.0775	0.3038
70	0.0245	0.0245	0.0296	0.0768	0.3068
70.25	0.0238	0.0238	0.0283	0.0760	0.3097
70.5	0.0232	0.0232	0.0271	0.0753	0.3127
70.75	0.0225	0.0225	0.0258	0.0746	0.3157
71	0.0219	0.0219	0.0245	0.0738	0.3187
71.25	0.0212	0.0212	0.0232	0.0731	0.5464
71.5	0.0205	0.0205	0.0219	0.0723	0.5812
71.75	0.0199	0.0199	0.0205	0.0715	0.6174
72	0.0192	0.0192	0.0192	0.0707	0.6551
Total	30.90	30.90	30.90	30.90	30.90

**Table 3-9 Wind Speeds and Direction (by date) of Analyzed NDBC Buoys along the California Central Coast**

Year	Month	Date	Wind Direction Avg			St Dev Wind Direction			Max Daily Wind Speed			Avg Daily Wind Speed			St Dev Wind Speed		
			46011	46023	46028	46011	46023	46028	46011	46023	46028	46011	46023	46028	46011	46023	46028
2008	2	24	175.0	179.8		24.4	30.4		17.5	20.1		9.8	10.0		4.2	5.0	
2008	2	25	316.8	326.3		32.1	33.3		9.5	9.9		6.0	7.1		2.0	2.1	
2007	12	4	329.7	340.0		11.3	8.3		10.8	11.8		7.2	8.1		1.8	2.1	
2001	1	11	218.7	214.0	206.4	33.6	32.3	27.7	14.5	16.3	13.3	8.7	10.0	9.1	2.4	2.4	2.3
2001	1	12	189.1	189.3	229.3	40.9	44.4	90.4	12.9	12.8	9.8	7.2	7.4	5.8	3.2	3.9	2.7
2007	12	5	336.3	340.6		10.9	9.1		11.5	12.5		8.3	10.0		1.5	1.2	
2004	2	26	216.4	238.8	234.3	56.6	52.5	35.8	7.2	7.7	8.6	4.5	5.2	5.9	1.7	1.4	1.4
2007	1	5	319.8	283.5	347.0	68.7	128.0	5.5	16.4	18.6	17.3	12.9	14.5	15.5	2.4	2.9	1.0
2008	1	5	191.5	210.8		34.6	34.7		14.2	14.2		5.4	5.6		3.8	4.1	
2000	12	22	330.4	312.5	306.9	10.1	8.0	17.0	10.2	11.4	9.1	7.6	8.7	5.2	1.7	1.8	2.4
1999	4	4	308.2	299.5	312.0	11.3	7.5	5.7	18.4	20.9	18.1	12.7	15.2	14.3	3.1	3.0	2.3
1999	1	27	169.7	258.0	322.3	154.9	132.2	6.6	10.7	13.2	13.0	6.3	8.4	9.9	1.6	2.0	1.6
2001	12	21	267.8		268.1	37.4		37.3	11.8	13.0	13.8	8.1	9.2	10.1	1.9	2.1	2.0
1998	12	9	174.5	282.0	278.2	164.9	124.7	90.8	10.9	13.1	13.0	7.1	8.9	9.5	1.8	1.8	4.0
1998	12	1	192.3	163.4	220.8	137.1	135.7	98.7	10.7	12.7	10.6	5.2	5.5	6.9	2.6	3.4	2.3
1999	1	26	259.0	256.2	265.0	20.2	14.3	14.0	11.2	14.0	10.7	6.6	8.1	7.0	2.2	2.6	2.0
2000	12	23	316.5	312.2	318.5	67.4	9.1	6.5	10.5	12.6	11.8	6.7	10.2	9.1	2.6	1.7	0.9
2001	5	2	321.8	324.4	315.8	4.1	5.2	4.4	12.3	14.0	17.2	9.8	12.0	14.9	1.4	1.2	1.2
2009	11	8	332.3	272.5		15.6	141.1		10.5	13.4	13.3	8.2	9.8	8.7	1.3	1.5	2.6
1998	11	26	260.6	299.0	249.5	125.9	59.9	90.4	9.5	9.7	6.0	4.5	5.8	3.1	2.0	1.6	1.8
2009	11	7	319.2	333.5		5.2	4.3		11.8	14.2	14.5	9.5	11.2	11.5	1.3	1.6	2.1
2008	5	22	315.7	327.5	326.6	5.6	4.8	3.2	15.1	18.2	17.2	13.4	15.8	15.8	1.5	1.6	1.1
2008	1	6	229.0	224.3		62.8	74.3		10.6	11.4		5.5	6.0		2.5	2.8	
1999	2	17	221.4	290.7	241.5	118.3	20.0	65.9	8.2	9.0	6.1	3.3	4.3	3.9	2.1	2.2	1.1

Wind Speeds – m/s  
Wind Direction - degrees

**Table 3-10 Maximum Daily Wave Heights and Direction (by date) of Analyzed NDBC Buoys along the California Central Coast**

Year	Month	Date	Maxi Daily Wave Height					Max Daily Peak Wave Period					Avg Daily Wave Direction				Std Dev, Wave Direction			
			46011	46023	46028	46215	46218	46011	46023	46028	46215	46218	46011	46028	46215	46218	46011	46028	46215	46218
2008	2	24	6.99	7.42	5.78	5.58	9.97	21.05	20.00	19.05	20.00	20.00	228.0	210.8	225.2	214.4	43.0	46.2	30.5	57.9
2008	2	25	6.95	7.26	5.68	5.04	7.5	17.39	20.00	16.00	18.18	18.18	272.5	281.6	254.9	271.1	5.1	10.1	7.1	4.6
2007	12	4	5.05	5.73	5.92	4.2	7.37	19.05	20.00	19.05	20.00	20.00	272.6	275.1	254.3	267.3	8.6	9.5	5.2	5.0
2001	1	11	6.98	7.66	8.51	6.5	7.23	16.67	16.67	16.67	16.67	16.67			269.9	293.6			7.0	5.1
2001	1	12	7.04	6.67	6.95	5.6	7.21	16.67	16.67	16.67	16.67	16.67			267.4	294.7			8.6	4.3
2007	12	5	5.62	7.23	5.59	4.72	7.14	19.05	20.00	19.05	20.00	18.18	273.3	280.2	251.0	266.1	7.5	6.5	7.5	4.1
2004	2	26	7.16	6.75	7.65	5.94	7.13	16.67	20.00	20.00	18.18	18.18		259.3	264.2	287.0		39.3	13.7	6.0
2007	1	5	6.22	6.66	6.92	3.96	7.12	17.39	16.67	17.39	18.18	16.67	299.3	311.0	264.8	305.5	9.4	13.5	11.7	8.8
2008	1	5	8.62	7.61	8.96	6.42	7.08	19.05	20.00	19.05	20.00	20.00	276.5	268.5	254.8	278.0	34.4	33.1	18.8	23.1
2000	12	22	6.21	5.28	7.91	6.05	6.4	20.00	20.00	20.00	20.00	20.00			261.8	283.9			6.7	7.8
1999	4	4	6.64	6.58	7.72	3.66	6.57	12.50	14.29	14.29	15.38	15.38			274.8	311.0			5.5	3.4
1999	1	27	6.65	6.26	7.7	5.33	6.06	16.67	16.67	16.67	16.67	16.67			269.8	302.1			3.4	4.7
2001	12	21	6.37	7.1	7.68	5.45	6.12	16.67	16.67	16.67	16.67	16.67			264.5	287.2			5.5	4.8
1998	12	9	6.52	6.84	7.5	4.15	4.83	20.00	20.00	20.00	20.00	18.18			270.6	301.0			6.9	5.8
1998	12	1	6.27	6.71	7.44	5.33	5.78	20.00	20.00	20.00	20.00	18.18			264.3	289.4			6.5	6.2
1999	1	26	4.22	3.73	7.31	4.37	4.07	16.67	16.67	16.67	16.67	16.67			273.5	302.8			4.0	6.1
2000	12	23	7.21	6.78	7.27	6.12	6.39	20.00	16.67	16.67	18.18	18.18			266.1	288.3			5.2	3.4
2001	5	2	6.33	5.86	7.22	4.33	6.05	16.67	16.67	14.29	16.67	15.38			272.4	305.5			3.9	4.5
2009	11	8	5.35	6.68	7.19	3.42	6.37	19.05	20.00	17.39	18.18	18.18	317.5	317.5	265.3	307.5	7.2	6.3	4.9	3.4
1998	11	26	4.92	5.67	7.09	4.36	4.87	20.00	20.00	20.00	18.18	18.18			269.5	293.2			5.2	4.4
2009	11	7	5.51	6.06	7.03	3.93	6.93	19.05	20.00	19.05	20.00	20.00	314.2	317.8	269.6	305.4	8.6	3.0	4.6	6.3
2008	5	22	5.98	6.02	7	3.7	6.82	12.12	12.50	12.90	13.33	13.33	318.3	316.0	277.3	315.1	4.6	3.6	3.9	4.1
2008	1	6	7.19	7.14	6.14	4.4	5.77	17.39	16.67	17.39	18.18	18.18	298.6	293.9	261.4	296.6	5.1	6.1	4.7	3.9
1999	2	17	7.13	5.4	5.35	4.15	5.55	20.00	20.00	20.00	20.00	20.00			269.1	291.8			6.2	3.8

Wave Heights – meters  
Wave Direction - degrees

**Table 3-11 Estimated 200 Year Return Period Calibrated to DELFT3D Significant Wave Height**

NDBC Buoy	200 Yr RP (Hsig) [m]	Delft3D (Hsig) [m]	Percent Difference
46028	11.407	11.5510	-1.26%
46215	7.9061	7.9058	0.00%
46011	11.049	11.0456	-1.37%
46023	11.306	11.2005	-0.43%
46218	11.042	11.3541	-0.03%

**Table 3-12 Boundary and Physical Inputs Used in the DELFT3D Simulation**

- Significant wave height, 11.2 m
- Peak wave period, 20 s
- Wave Direction, 270° (westerly)
- Directional spreading, 4°
- Wind Velocity, 10 m/s
- Wind Direction, 270° (westerly)
- Water Density, 1,025 kg/m<sup>3</sup>
- Collins Bottom Friction Coefficient, 0.1118 (calibrated)

**Table 3-13 Maximum Amplitude of Far-Field Coseismic Tsunamis Recorded at Avilla Beach (AB) and Port San Luis (PSL) Tide Gauges**

No.	Date	Far-Field Coseismic Tsunamis (since 1946)					Max. Ampl. (m)	
		Region/source	Lat. (deg.)	Lon. (deg.)	Dist. (km)	Mw	PSL	AB
1	4/1/1946	Alaska/Unimak	53.492	-162.832	3839	8.6	1.2	
2	12/20/1946	Japan/E. Honshu	33	135.6	9039	8.1		0.1
3	11/4/1952	Kamchatka/Kuril	52.755	160.057	6289	9		1.4
4	3/9/1957	Alaska	51.292	-175.629	4668	8.6		0.53
5	11/6/1958	Kamchatka/Kuril	44.53	148.54	7411	8.3		0.14
6	5/22/1960	S. America/Chile	-39.5	-74.5	9565	9.6		0.99
7	10/13/1963	Kamchatka/Kuril	44.77	149.798	7310	8.5		0.3
8	3/28/1964	Alaska	61.017	-147.648	3448	9.2		1.6
9	10/17/1966	S. America/Peru	-10.748	-78.638	6759	8.1		0.1
10	5/16/1968	Japan/E. Honshu	40.8	143.2	7994	8.2		0.1
11	11/29/1975	Hawaii	19.451	-155.033	3785	7.7	0.39	
12	6/22/1977	S. Pac./Tonga Tr.	-22.878	-175.9	8685	7.2	0.12	
13	10/4/1994	Kamchatka/Kuril	43.773	147.321	7535	8.3	0.15	
14	7/30/1995	S. America/Chile	-23.34	-70.294	8402	8	0.12	
15	12/3/1995	Kamchatka/Kuril	44.663	149.3	7349	7.9	0.07	
16	6/10/1996	Alaska/Andreanov	51.564	-177.632	4805	7.9	0.09	
17	11/26/1999	S. Pacific/Vanuatu	-16.423	168.214	9423	7.5	0.05	
18	6/23/2001	S. America/Peru	-16.265	-73.641	7577	8.4	0.14	
19	9/25/2003	Japan/Hokaido	41.815	143.91	7884	8.3	0.03	
20	12/26/2004	Indonesia/Sumatra	3.316	95.854	14286	9.1	0.27	
21	11/15/2006	Kamchatka/Kuril	46.592	153.266	6979	8.3	0.56	
22	1/13/2007	Kamchatka/Kuril	46.243	154.524	6906	8.1	0.11	
23	4/1/2007	S. Pac./Solomon Isl.	-8.466	157.043	9851	8.1	0.09	
24	8/15/2007	S. America/Peru	-13.386	-76.603	7127	8	0.08	
25	1/3/2009	S. Pac./PNG	-0.414	132.885	11518	7.6	0.08	
26	9/29/2009	S. Pac./Samoa Is.	-15.489	-172.095	7812	8	0.28	
27	10/7/2009	S. Pac./Vanuatu Is.	-13.006	166.51	9329	7.6	0.08	
28	2/27/2010	S. America/Chile	-36.122	-72.898	9350	8.8	0.80	
29	3/11/2011	Japan/Honshu	38.297	142.372	8200	9	2.02	
30	10/28/2012	Canada/Queen Ch.	52.788	-132.101	2153	7.7	0.27	
31	2/6/2013	S. Pac./Solomon Isl.	-10.799	165.114	9295	7.9	0.14	
32	4/1/2014	S. America/Chile	-19.642	-70.817	8056	8.2	0.22	

**Table 3-14 Maximum Amplitude of Near-Field Coseismic Tsunamis**

No.	Date	Far-Field Coseismic Tsunamis (since 1946)					Max. Ampl. (m)	
		Region/source	Lat. (deg.)	Lon. (deg.)	Dist. (km)	Mw	PSL	AB
	11/22/1878	San Luis Obispo				N/A*		
33	11/4/1927	California/Lompoc	34.813	-120.774	40	7.3**	1.2***	
34	4/25/1992	California/Humboldt	40.368	-124.316	657	7.2	0.07	

\* 11/22/1878 event was likely caused by a local submarine mass failure

\*\* Original magnitude was Mw 7.0; increased magnitude was recommended by Ellsworth (2003)

\*\*\* Reported in literature. Tide gauge not yet installed.

**Table 3-15 Maximum Expected Magnitudes (Mw) Used in RPMT Simulations**

Sources		Max $M_w$	References
Far-Field	Alaska (ASZ)	9.2	Johnson et al. (1996)
		9.2	Ichinose et al. (2007)
		9.2	Suito and Freimueller (2009)
	Semidi (SSZ)	9.1	Ross et al. (2013), Whitmore et al. (2013)
	Kamchatka (KSZ)	9.2	Gonzalez et al. (2009)* (Zone KSZ1)
			Gonzalez et al. (2009)* (Zone KSZ2)
Japan (JSZ)	9.1	Grilli et al. (2013a,b; Tappin et al., 2014)	
Near-Field	Hosgri fault (HFS)	7.66	Petersen et al. (2008), Wills et al. (2007)*
	San Lucia fault (SLFS)	7.49	Petersen et al. (2008), Wills et al. (2007)*

\* Parameters revised in present study

**Table 3-16 SMF Parameters Used in RPMT Simulations**

SMF proxy simulations In NHWAVE	Goleta SMF proxy	Big Sur North SMF proxy
Grid used for generation	Goleta 125	Big Sur 500
Center of mass location ( $x_o, y_o$ )	35.153 N -120.985 W	35.097 N -121.904 W
Width $w$ (km)	10.5	10
Length $b$ (km)	7.45	15
Thickness $T$ (m)	75	235
Depth $d$ (m) at center of mass	300 (100-400)	2600
Mean slope $\beta$ of failure surface (deg)	2	4
Azimuth $\theta$ of SMF movement (deg. true N)	245	255
Initial acceleration $a_o$ (m/s <sup>2</sup> )	0.14	0.26
Maximum velocity $u_{max}$ (m/s)	25.0	51.9
Motion duration $t_f$ (s)	559.0	635.4
Motion runout $s_f$ (km)	8.88	21.04

**Table 3-17 Summary of RPMT Runup and Drawdown Results**

	Far-Field (Distant) Seismic Tsunami		Near-Field (Local) Seismic Tsunami		Goleta Proxy SMF Tsunami		Goleta Proxy SMF Tsunami with Reduced Breakwater Evaluation (no CLB)
	CLB	Reevaluation (SSZ)	CLB	Reevaluation (HFS)	CLB	Reevaluation	
Max. Water Elevation in the Area of the Intake Structure (HHWL)	30.3 ft.	17.4 ft. <sup>(5)</sup>	34.9 ft.	1.3 ft. <sup>(5)</sup>	N/A	27.9 ft. <sup>(4)</sup>	32.8 ft.
Max. Runup Elevation Behind Intake Structure <sup>(3)</sup> (HHWL)	N/A	N/A	N/A	N/A	N/A	32.8 ft.	62.3 ft.
Combined <sup>(2)</sup> Drawdown Elevation	-8.7 ft.	-9.2 ft.	-3.8 ft.	N/A	-8.7 ft. <sup>(6)</sup>	-15.7 ft.	-15.7 ft.
Splash	N/A	N/A <sup>(1)</sup>	60.32 ft.	N/A <sup>(1)</sup>	N/A	N/A <sup>(1)</sup>	N/A <sup>(1)</sup>

All elevations are in NAVD88.

1. RPMT did not result in any splash due to the longer period waves that are seen in the model.
2. The CLB included effects from tsunami, storm waves, storm surge, and tide. Combinations stipulated in NUREG/CR-7046 do not combine the effects from tsunami, storm waves, storm surge, & tide. The RPMT combination includes tsunami, tide, and long-term sea level rise. See Section 3.9.
3. In cases where the water level is high enough to continue over the intake structure, the maximum elevation that is reached up the steep hill behind the intake structure is provided.
4. The HAWL value is reported because it is more limiting than the HHWL.
5. Water levels shown are in the front of the intake structure since levels were not high enough to flow over the top deck of the structure (i.e., less than elevation 20.4 ft. NAVD88 [17.5 ft. MSL]).
6. Even though there is no CLB for the Goleta Proxy SMF, it is compared to -8.7 ft. since this is the most-limiting CLB drawdown value.

**Table 3-18 Maximum Water Current Velocities and Impulse Forces for RPMTs**

<b>Safety-Related SSC</b>	<b>Water Velocity</b>	<b>Water Impulse Force</b>
ASW Ventilation Huts / ASW Ventilation Snorkels	26.2 ft/s	0.86 kip/ft
Intake Structure Curtain Wall	18.0 ft/s	11.3 kip/ft
ASW Forebay Ceiling	18.0 ft/s	20.4 kip/ft
Intake Structure Top Deck	39.4 ft/s	11.6 kip/ft

\* The velocity and impulse force for the ASW ventilation snorkels are zero because they are not inundated by the RPMTs.

**Table 3-19 Potential Tsunami Debris**

#	Commodity	Weight Class	Material Type
1	Bar Racks	3	Steel
2	Aux Salt Water Pump Screen Gate	5	Steel
3	Screen Wash Pumps	5	Steel
4	Traveling Screen Housing or Internal Parts (Outer covers are fiberglass)	2, 3, 4	Steel
5	Control/office building	1, 2, 3, 4, 5	Masonry Concrete
6	Intake Access Control & Security building cement blocks, roofing material, interior commodities	1, 2, 3, 4, 5	Masonry Concrete, Wood, Steel
7	Maintenance Machine Shop Building cement blocks, roofing material, interior commodities	1, 2, 3, 4, 5	Masonry Concrete, Wood, Steel
8	Maintenance and Storage Sea Trains	1, 2, 3, 4, 5, 6	Steel
9	Chlorination Tanks	4, 5, 6	Plastic
10	Security Fences and Gratings	2, 3, 4	Steel
11	Security Guard Towers	5, 6	Wood, Steel
12	PVC Piping for Biolab (located on hillside)	2	Plastic
13	Lighting/camera posts (permanently mounted)	3	Steel
14	Lighting stanchions (with concrete base)	4	Reinforced Concrete, Steel
15	Portable powered lighting carts	4	Steel
16	Gantry Crane	6	Steel
17	Movable Crane	6	Steel
18	Chemical Storage Tank	4, 5, 6	Plastic
19	Chemical Transferring Station	5	Steel, Plastic
20	Moored Intake Cove Boats	5	Steel, Wood
21	Kelp Cutter Boat and Trailer	6	Steel
22	Intake Cove Docks	2, 3, 4, 5	Wood
23	Maintenance and operations vehicles (pickup trucks)	5	Steel
24	Smaller 'golf cart' vehicles for personnel transport	4	Steel
25	Employee and visitor personal vehicles	5	Steel
26	Spare Tribars for breakwater construction	6	Reinforced Concrete
27	Lumber/cribbing	1	Wood
28	Meteorologist/Shower/Offices – Building 123	1, 2, 3, 4, 5, 6	Wood
29	Lumber fence located near Building 123	2	Wood
30	Lumber used as retaining walls.	1	Wood
31	Concrete block used as retaining walls directly to east of intake protected area	1	Masonry Concrete

#	Commodity	Weight Class	Material Type
32	'Porta Potties'	2	Plastic
33	Metal storage bins/dumpsters	2, 3	Steel
34	Plastic storage bins	2	Plastic
35	Compressed air/welding/CO <sup>2</sup> cylinders	1	Steel
36	Portable commodities associated with plant operation and maintenance including commodities temporarily stored/staged for maintenance activities	1, 2, 3, 4, 5, 6	Steel, Wood
37	Machine shop tools (metal-working floor mounted tools)	4, 5	Steel
38	Manmade and Natural items found in the landscape of areas expected to be inundated	1, 2, 3, 4	Soil, Sand, Rock
39	Navigation buoys	2	Plastic
40	Concrete wheel chocks (for vehicle parking)	2	Reinforced Concrete
41	Eyewash Station	2	Plastic
42	Ladders	1	Steel
43	Sandbags	1	Soil, Sand, Rock
44	BBQs	1	Steel
45	Yellow Flotation Devices	1	Plastic
46	Small temporary building	3	Steel

Weight Classes are as follows:

- 1 < 100 lbs.
- 2 > 100 lbs. and < 500 lbs.
- 3 > 500 lbs. and < 1,000 lbs.
- 4 > 1,000 lbs. and < 2,000 lbs.
- 5 > 2,000 lbs. and < 10,000 lbs.
- 6 > 10,000 lbs.

**Table 3-20 Tsunami Debris Projectile Impact, Debris Damming, and Combined Forces**


<b>Civil Commodity</b>	<b>Limiting RPMT Projectile Force</b>	<b>Limiting CLB Tornado-Generated Missile Force</b>	<b>Bounded/ Not Bounded</b>
Intake Structure Curtain Wall	4,188 kips	44,206 kips	Bounded
Intake Structure Top Deck	231.9 kips	44,206 kips	Bounded
ASW Forebay Ceiling <sup>1</sup>	N/A	N/A	N/A
ASW Ventilation Huts	224.3 kips	44,206 kips	Bounded
ASW Ventilation Snorkels <sup>2</sup>	N/A	N/A	N/A

1. The ASW forebay ceiling is an interior structural commodity. The ASW pump forebay draws seawater that enters under the curtain wall. As the height of the incoming wave exceeds the height of the bottom of the curtain wall (elevation -4.9 ft. NAVD88), floating projectiles would be excluded from entry to the ASW forebay. Projectiles in the flowstream for the tsunami at an elevation under the bottom of the curtain wall could enter the ASW forebay, but will not strike the forebay ceiling, located at elevation -0.7 ft. NAVD88, 4.2 feet above the bottom of the curtain wall, as they are not expected to have a velocity component after the forebay area is re-flooded after drawdown. Therefore, projectile impact to the forebay ceiling is not considered a credible event.
2. The ASW ventilation snorkels are not inundated by the RPMT. The maximum inundation height at the ASW ventilation huts is 5.8 feet. The height of the ASW ventilation huts is 14.5 feet from the intake structure top deck. Therefore, a floating projectile (such as the kelp harvesting vessel) that has a profile above the maximum inundation height is insufficient height to impact the ASW ventilation snorkels.




BASE MAP FROM THE PORT SAN LUIS, CA (2012) USGS QUADRANGLE MAP, PROVIDED BY WWW.USGSSTORE.GOV. CONTOUR ELEVATIONS REFERENCE NAVD 88, CONTOURS ARE SHOWN IN FEET AT 40 FOOT INTERVALS.

**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant  
**Figure 2-1**  
DCPP Site Location




**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant


**Figure 2-2**  
Diablo Creek Watershed



**Flooding Hazard  
 Reevaluation Report  
 Diablo Canyon Power Plant**  
**Figure 3-1**  
 Locations of Storms Used  
 in LIP Determination




**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant  
**Figure 3-2a**  
Locations of Doors, Safety and  
Non Safety-Related Structures,  
and Areas to the West of the  
Turbine and Buttress Buildings  
Evaluated for LIP




**Flooding Hazard  
 Reevaluation Report  
 Diablo Canyon Power Plant**

**Figure 3-2b**  
 Location and Identification of  
 Commodities on the West of the  
 Turbine Building




**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant  
**Figure 3-3**  
Maximum Water Depth  
from LIP (ft.)




**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant

**Figure 3-4**  
Diablo Creek General Storm  
All-Season Cumulative PMP  
Values





<p><b>Flooding Hazard Reevaluation Report</b> Diablo Canyon Power Plant</p>
<p><b>Figure 3-5</b> DCPP Site Locations of PMF Inundation</p>




**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant

**Figure 3-6**  
Critical Fetch Line from  
Wind Wave Analysis




**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant

**Figure 3-7**  
Tropical Storm Ignacio and  
Resulting Significant Wave  
Heights at the DCPD Waverider  
Buoy (August 20, 1997)




**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant

**Figure 3-8**  
Locations of Analyzed  
NDBC Buoys Along the  
California Central Coast




**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant

**Figure 3-9**  
Return Periods for Significant  
Wave Heights at Analyzed NDBC  
Buoys Along the California Central  
Coast



**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant


**Figure 3-10**  
Maximum Crest Wave Level (m)  
at Various Observation Points at  
the DCPD Breakwaters (with  
SAWL)



Acronyms: Alaska Subduction Zone (ASZ), Semidi Subduction Zone (SSZ), Kamchatka Subduction Zone (KSZ), Japan Subduction Zone (JSZ).


Color scale denotes bathymetry (<0) and topography (> 0) in meter.

<p><b>Flooding Hazard Reevaluation Report</b> Diablo Canyon Power Plant</p>
<p><b>Figure 3-11</b> Location of Various Tsunami Source Areas for DCPP</p>




**Flooding Hazard  
 Reevaluation Report**  
 Diablo Canyon Power Plant

**Figure 3-12**  
 Physiographic Features in  
 the DCPP Area




- |             |                                    |
|-------------|------------------------------------|
| Explanation |                                    |
| ●           | Diablo Canyon Power Plant (DCPP)   |
| —           | Fault                              |
| —           | Rupture scenario                   |
| CF          | Casmalia fault zone                |
| HF          | Hosgri fault zone                  |
| PS          | Purísima structure                 |
| SLBF        | Santa Lucia Banks fault zone       |
| SLBF-S      | Santa Lucia Banks fault zone-south |
| SCF         | Southwest Channel fault            |
| WBF         | West Basin fault                   |




**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant

**Figure 3-13**  
Fault Zones Used in the  
RPMT Modeling



From Greene et al. (2006)

**Flooding Hazard  
 Reevaluation Report**  
 Diablo Canyon Power Plant  
**Figure 3-14**  
 Location of Goleta and  
 Gaviota Slides



Explanation

-  Major fan valley
- MFV Monterey fan valley
- AFV Ascension fan valley
- MEFV Monterey East fan valley
-  Headwall scarp of Sur Slide
- DCPP** Diablo Canyon Power Plant


Notes:

- 1) Modified from Gutmacher and Normark (1993).
- 2) Offshore base map from NCDC/NCAA Coastal Relief DEM (NDGC, 2005).
- 3) Onshore base map from U.S.G.S. 90-meter DEM.



**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant

**Figure 3-15**  
Location of Sur Slide



SMSB - Santa Maria Slope Break zone  
 SSB - Sur Shelf Break zone  
 ACZ - Arguello-Conception zone  
 SLBS - Santa Lucia Bank scarp zone  
 LSC - Lower Slope Canyon zone  
 SSL - Southern Santa Lucia Basin zone  
 ENSZ - Escarpment-northern Sur zone  
 ENZ - Escarpment-northern zone  
 ECZ - Escarpment-central zone  
 ESZ - Escarpment-southern zone


Explanation

**DCPP** Diablo Canyon Power Plant

 Landslide source zones




**Flooding Hazard  
 Reevaluation Report**  
 Diablo Canyon Power Plant  
**Figure 3-16**  
 Landslide Source Zones  
 Used in Previous Tsunami  
 Analyses




The black ellipse is the  $w = 10.5$  km by  $b = 7.45$  km footprint of a  $1.75$  km<sup>3</sup> slide on the slope, with center of mass located at 35.153N-120.985W. The black straight line is a transect in the direction of the steepest slope from DCP in azimuth  $\theta = 245$  deg. from North. Bathymetry is color scale in meters.

<b>Flooding Hazard Reevaluation Report</b> Diablo Canyon Power Plant
<b>Figure 3-17</b> Goleta SMF Proxy Location and Bathymetry




Black ellipses are the  $w = 10$  km by  $b = 15$  km footprint of 4.5 (or 10.5) km<sup>3</sup> slides on the slope, with center of mass located at 35.097N-121.904W and 34.993N-121.872W, respectively. The black straight lines are transects in the direction of the steepest slope in azimuths  $\theta = 255$  and 290 deg. from North, respectively. Bathymetry is color scale in meters.

<b>Flooding Hazard Reevaluation Report</b> Diablo Canyon Power Plant
<b>Figure 3-18</b> Big Sur SMF Proxy Location and Bathymetry



**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant

**Figure 3-19**  
Elevation Profile of SSCs  
of Intake Structure  
(NAVD88)



**Flooding Hazard  
Reevaluation Report**  
Diablo Canyon Power Plant  
**Figure 3-20**  
RPMT Hydrodynamic &  
Hydrostatic Forces on the  
Intake Structure

**Table of Changes to Diablo Canyon Power Plant Units 1 and 2  
 Flood Hazard Reevaluation Report Sections, Tables, and Figures**

<b>Section, Table, Figure</b>	<b>Flooding Hazards Reanalysis Report, Revision 0</b>	<b>Flooding Hazards Reanalysis Report, Revision 1</b>	<b>Reason for Change</b>
Section 1.5	This section provides clarifications on terminology used in the report.	<p>A paragraph was added to describe use of the terms current design basis (CDB) and current licensing basis (CLB) throughout the report.</p> <p>A paragraph was added to describe use of the terms Pacific Gas and Electric (PG&amp;E) Design Class I and safety-related throughout the report.</p>	Provides clarification on use of terminology.
Sections 2.3.2, 2.3.2.1	Define acronyms for Updated Final Safety Analysis Report (UFSAR) and current licensing basis.	Deleted acronym definitions.	Editorial changes made because acronyms were defined in newly added paragraph in Section 1.5.
Sections 2.2, 2.3.2.1, 2.3.2.2, 2.3.2.3, 2.3.2.4, 2.3.2.5, 2.3.2.6.1, 2.3.2.6.2, 2.3.2.7, 2.3.2.8, 2.3.2.12, 2.3.2.13, 2.3.2.14, 2.3.3, 3.3	These sections referenced UFSAR Revision 21.	These sections were updated to reference UFSAR Revision 22.	Reflects the most current UFSAR.

Section, Table, Figure	Flooding Hazards Reanalysis Report, Revision 0	Flooding Hazards Reanalysis Report, Revision 1	Reason for Change
Sections 2.3.2.1, 2.3.2.2, 2.3.2.11, 2.3.2.13, 2.3.3	These sections made reference to safety-related buildings or components	Replaced the term safety-related with PG&E Design Class I.	Revised to be consistent with the terminology used in UFSAR Revision 22.
Section 3.1.2	This section provided the cumulative depth of the 1-hour and 6-hour LIP of 4.5 and 5.9 inches, respectively.	<p>A sentence was added to address additional methods used in performing the revised LIP modeling: FLO-2D models (locations and elevations) of the buildings and features were verified by site walkdowns.</p> <p>The cumulative depth was revised to clarify that the cumulative rainfall amount of the 1-hour and 6-hour LIP was 4.5 and 5.9 inches, respectively.</p>	<p>Reflects more conservative assumptions used in the revised LIP modeling.</p> <p>Editorial change made to clarify that the values provided represent rainfall amount.</p>
Section 3.1.3	<p>This section presented the LIP reevaluation results. Six topics and their associated results were presented:</p> <p>(1) Frequency analysis results showed the 90 percent confidence interval for 106 years return period varied between 3.62 and 2.86 inches.</p> <p>(2) Water depth above the door thresholds and areas to the west of the turbine and buttress buildings varied between 0.09 ft. and 1.4 ft., with five of the doors/areas showing no inundation.</p>	<p>This section was revised to present the updated LIP reevaluation results. Six topics and their associated results are presented:</p> <p>(1) Frequency analysis results showed the 90 percent confidence interval for 106 years return period varied between 3.60 and 2.84 inches.</p> <p>(2) Water depth above the door thresholds and areas to the west of the turbine and buttress buildings varied between 0.05 ft. and 0.68 ft., with six of the doors/areas showing no inundation.</p>	Reflects revised LIP modeling results.

Section, Table, Figure	Flooding Hazards Reanalysis Report, Revision 0	Flooding Hazards Reanalysis Report, Revision 1	Reason for Change
	<p>(3) The duration of time dependent water depths varied between 0.00 hours and 4.41 hours.</p> <p>(4) Area A3 includes commodities related to the safety-related diesel fuel oil transfer system. Area A3 showed a water depth value of 0.13 ft.</p> <p>(5) Maximum velocity values are less than 1 ft/sec for all but two commodities listed on Table 3-5. Area B1 shows a maximum velocity of 1.16 ft/sec, however, this area is proximate to the Unit 2 diesel generator air intake louvers, which are recessed and located behind a security fence. Debris ingress to the louvers is not credible. Door 191-2 shows a maximum velocity of 1.02 ft/sec, sufficiently close to the 1 ft/sec threshold so as to safely assume that debris loading will not be an issue for this door.</p> <p>(6) The total associated effect is the force (per linear foot of surface) due to hydrostatic and hydrodynamic loading of the LIP varied from 0.03 lb/ft. to 21.51 lb/ft.</p>	<p>(3) The duration of time dependent water depths varied between 0.00 hours and 7.60 hours.</p> <p>(4) Area A3 includes commodities related to the safety-related diesel fuel oil transfer system. Area A3 showed a maximum water depth value of 0.21 ft.</p> <p>(5) Maximum velocity values are less than 1 ft/sec for all commodities.</p> <p>(6) The total associated effect is the force (per linear foot of surface) due to hydrostatic and hydrodynamic loading of the LIP varied from 1 lb/ft. to 35 lb/ft. for doors and areas experiencing inundation.</p>	
Section 4.1	This section compared current LIP results with reanalyzed LIP results. The	This section was revised to reflect the updated reevaluated LIP water depth	Reflects revised LIP modeling results.

Section, Table, Figure	Flooding Hazards Reanalysis Report, Revision 0	Flooding Hazards Reanalysis Report, Revision 1	Reason for Change
	reevaluated LIP determined that the water depth above the door thresholds and areas to the west of the turbine and buttress buildings varied between 0.09 ft. and 1.4 ft., with five of the 29 doors/areas showing no inundation. The duration of time dependent water depths varied between 0.00 hours and 4.41 hours.	above the door thresholds and areas to the west of the turbine and buttress buildings, which varies between 0.05 ft. and 0.68 ft., with six of the 46 doors/areas showing no inundation, and the duration of time dependent water depths, which varies between 0.00 hours and 7.60 hours. The conclusion that the reevaluated LIP is not bounded by the current analysis did not change.	
Section 4.5	This section made a comparison to the CDB.	This section was revised to clarify that the comparison is being made to the CDB/CLB.	Aligns with the newly added clarification in Section 1.5.
Section 4.6	This section made a comparison to the CDB.	This section was revised to clarify that the comparison is being made to the CDB/CLB.	Aligns with the newly added clarification in Section 1.5.
Section 7.0	This section contained a reference to UFSAR Revision 21 as PGE, 2013.	Reference PGE, 2013 was deleted and a reference to UFSAR Revision 22 as PGE, 2015 was added.	Reflects the most current UFSAR.
Table 3-5	Table provided maximum water depth and flood duration for doors and area to the West of the turbine building and buttress buildings. Water depths ranged from 0.09 ft. – 1.4 ft., with five doors showing no inundation. The duration of time dependent water depths varied between 0.00 hours and 4.41 hours.	Table numerical values were revised. Water depths range from 0.05 ft. – 0.68 ft., with six doors showing no inundation. The duration of time dependent water depths vary between 0.00 hours and 7.60 hours.	Reflects revised LIP modeling results.
Table 3-6	Table provided hydrodynamic and total associated affects resulting from a LIP event. The total force ranged from 0.03 lb./ft. – 21.51 lb./ft.	Table numerical values were revised. For doors and areas experiencing inundation, the total force ranges from 1 lb./ft. – 35 lb./ft.	Reflects revised LIP modeling results.

<b>Section, Table, Figure</b>	<b>Flooding Hazards Reanalysis Report, Revision 0</b>	<b>Flooding Hazards Reanalysis Report, Revision 1</b>	<b>Reason for Change</b>
Table 3-7	Table included fitted precipitation estimates and 90 percent confidence interval (CI) for return periods 2 years through 1 million years. For a 1 million year return period, the 90 percent CI ranged from 2.86 inches to 3.62 inches of precipitation.	Table was revised to include fitted precipitation estimates and 90 percent CI for the 1 million year return period. For a 1 million year return period, the 90 percent CI ranged from 2.84 inches to 3.60 inches of precipitation.	Reflects revised LIP results and removes extraneous return period information not required to make a comparison to the National Research Council values.
Figure 3-2	Included figure	Figure was replaced with Figure 3-2a. Detail in figure was increased to more clearly show locations of doors, safety and nonsafety-related structures, and areas to the west of the turbine and buttress buildings evaluated for LIP.	Provides better understanding of LIP inundation results.
Figure 3-2b	Figure new to Flooding Hazards Reanalysis Report, Revision 1	Figure was added to more clearly show areas and commodities on the West side of the turbine building.	Provides better understanding of LIP inundation results.
Figure 3-3	Included figure	Figure was replaced to reflect revised water depths near the power block structures.	Reflects revised LIP modeling results.