



April 29, 2016

NG-16-0105

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Duane Arnold Energy Center
Docket No. 50-331
Renewed Op. License No. DPR-49

2015 Annual Radioactive Material Release Report

Please find as the Enclosure to this letter, a copy of NextEra Energy Duane Arnold, LLC's (hereafter, NextEra Energy Duane Arnold) 2015 Annual Radioactive Material Release Report for the Duane Arnold Energy Center (DAEC). This report satisfied the requirements of Offsite Dose Assessment Manual (ODAM) Section 8.2.1 and Technical Specification Section 5.6.3.

This letter makes no new commitments nor changes to existing commitments.

Should you have any questions regarding this matter, please contact Michael Casey at (319) 851-7606.

A handwritten signature in black ink, appearing to read "T. A. Vehec".

T. A. Vehec
Vice President, Duane Arnold Energy Center
NextEra Energy Duane Arnold, LLC

Enclosure

cc: Administrator, Region III, USNRC
Project Manager, DAEC, USNRC
Senior Resident Inspector, DAEC, USNRC

IE 25
NRR

Enclosure to NG-16-0105

Duane Arnold Energy Center
2015 Annual Radioactive Material Release Report



2015
Annual Radioactive Material
Release Report


Duane Arnold Energy Center
Cedar Rapids, Iowa
Docket No. 50-331


January 1, 2015 through December 31, 2015

Intentionally blank

2015
Annual Radioactive Material
Release Report

Duane Arnold Energy Center
DOCKET NUMBER. 50-331

Prepared By:  Date: Apr. 128, 2016

Approved By:  Date: 4/28/16

Intentionally blank

Table of Contents

| | |
|---|-----------|
| REGULATORY LIMITS | 6 |
| MAXIMUM PERMISSIBLE CONCENTRATIONS | 7 |
| AVERAGE ENERGY | 7 |
| MEASUREMENTS OF TOTAL RADIOACTIVITY | 7 |
| GASEOUS EFFLUENTS | 9 |
| Table 1A - Gaseous Effluents – Summation of All Releases | |
| Table 1B - Gaseous Effluents by Quarter | |
| Table 1C - Gaseous Effluents by Release Point | |
| Estimated Release of Gaseous of Carbon-14 | |
| Gaseous Effluents: Historical Trend | |
| LIQUID EFFLUENTS | 13 |
| Table 2A - Liquid Effluents – Summation of All Releases | |
| Table 2B - Liquid Effluents | |
| RADIOACTIVE SOLID WASTE | 15 |
| Shipments in 2015 | |
| Waste Classification per 10 CFR 61 | |
| Summary Tables of Radioactive Solid Waste | |
| RADIOLOGICAL IMPACT ON MAN | 20 |
| SUMMARY OF METEOROLOGICAL DATA | 22 |
| Stability Class Data 33' | |
| Wind Rose Data 33' | |
| Stability Class Data 156' | |
| Wind Rose Data 156' | |
| SUMMARY OF GROUND WATER PROTECTION INITIATIVE ISSUES | 25 |
| DESCRIPTION OF CHANGES TO THE OFFSITE DOSE ASSESSMENT MANUAL | 27 |
| <u>Revision 32 → Revision 35</u> | |
| ATTACHMENT 1 – GROUND WATER PROTECTION PROGRAM RESULTS | |
| ATTACHMENT 2 – OFFSITE DOSE ASSESSMENT MANUAL | |

REGULATORY LIMITS

Fission and Activation Gases

Dose Rate

- Less than 500 mrem/year to the whole body.
- Less than 3000 mrem/year to the skin.

Gamma Air Dose

- 1) Less than or equal to 5 mrad/quarter.
- 2) Less than or equal to 10 mrad/year.

Beta Air Dose

- 1) Less than or equal to 10 mrad/quarter.
- 2) Less than or equal to 20 mrad/year.

Airborne Particulates, Iodines and Tritium

Dose Rate

- Less than 1500 mrem/year.

Dose

- Less than or equal to 7.5 mrem/quarter to any organ.
- Less than or equal to 15 mrem/year to any organ.

Liquid Effluents

Dose

- Less than or equal to 1.5 mrem to the whole body during any calendar quarter.
- Less than or equal to 5 mrem to any organ during any calendar quarter.
- Less than or equal to 3 mrem to the whole body during any calendar year.
- Less than or equal to 10 mrem to any organ during any calendar year.

Concentration

- Liquid effluents released from the site to unrestricted areas shall not exceed ten times (10x) the concentrations listed in Appendix B, Table 2, Column 2 to 10 CFR 20.1001 – 20.2402.

40CFR190 and 10CFR72

Dose

- 1) Less than or equal to 25 mrem annual whole body dose.
- 2) Less than or equal to 75 mrem annual thyroid dose.
- 3) Less than or equal to 25 mrem annual dose to any other critical organ.

MAXIMUM PERMISSIBLE CONCENTRATIONS

Dose rates, rather than effluent concentrations, are used to calculate permissible release rates for gaseous effluents.

The maximum permissible dose rates for gaseous releases are defined in Duane Arnold Offsite Dose Assessment Manual (ODAM). ODAM Limiting Condition for Operation (OLCO) 6.2.2.

Liquid effluent concentrations are limited per ODAM OLCO 6.1.2 to ten times (10x) the concentration specified in 10CFR20 Appendix B, Table 2, Column 2.

AVERAGE ENERGY

The ODAM limits dose rates at or beyond the site boundary due to the release of noble gases to less than or equal to 500 mrem per year to the total body and less than or equal to 3,000 mrem per year to the skin, and average energy is not used to determine dose to the public. Compliance with these limits is demonstrated based on dose calculations using measured isotopic concentrations of effluent streams and not based on gross count rate measuring systems.

Therefore, the average beta and gamma energies (E-BAR) for gaseous effluents as described in Regulatory Guide 1.21 "Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants," are not applicable.

MEASUREMENTS OF TOTAL RADIOACTIVITY

Gaseous Effluents

- Gaseous Effluents from the Offgas Stack, Reactor Building Vents, Turbine Building Vent and the Low Level Radwaste Storage and Processing Facility (LLRPSF) are continuously sampled for iodines and particulates. Sample media is changed weekly and analyzed by gamma spectroscopy. The gross alpha analyses are performed onsite. The particulate filters are composited on a quarterly basis and sent to a vendor for Sr-89, Sr-90, Fe-55 and Ni-63. Total error is calculated based on stack flow error, sample flow error, and analytical error.
- Noble gas grab samples of the same four release points are obtained monthly and analyzed by gamma spectroscopy. Total error is based on stack flow error, analytical error, and calculated sampling error.
- Tritium samples from all four release points are obtained quarterly and analyzed by liquid scintillation. Total error is based on stack flow error, analytical error, and calculated sampling error.
- A beta sensitive radiation detector provides for continuous monitoring at each of the above described release points. For the year 2015, there were no instances where ODAM required gaseous radiation monitoring or sampling systems were inoperable on an active release point for a period of 30 (contiguous) days or more. (ODAM OLCO 6.2.1.1 A.2)

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

Liquid Effluents

- Service water systems are sampled once per week for gamma emitters. Portions of the weekly service water samples are composited for a monthly analysis for tritium and gross alpha. If there is a positive identification of reactor by-product radioactivity in these samples, analysis for Sr-89, Sr-90 and Fe-55 are performed. Total error is based on the volume discharge error and analytical error.
- ODAM defined "Clean" Systems are sampled prior to free release. Samples are collected prior to release and analyzed for gamma emitters and tritium. If reactor byproduct gamma emitters are identified, analyses for Sr-89, Sr-90 and Fe-55 are performed. "Clean Systems" include: CST Containment Pit, Transformer Pit and the Neutralizing Tank 1T022. Total error is based on the volume discharge error, dilution flow error and analytical error.
- No Radioactive Batch Releases of liquids from plant radwaste systems were performed in 2015.
- Continuous monitoring with gamma sensitive radiation detectors is provided for plant service water systems. For the year 2015, there were no instances where these liquid radiation monitoring systems were inoperable on an active release point for a period of 30 (contiguous) days or more. (ODAM OLCO 6.1.1.1 A.2)

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

GASEOUS EFFLUENTS

There were no radioactive gaseous batch releases from the Duane Arnold Energy Center during this report period. All gaseous effluent releases were continuous and resulted in a small fraction of the 10 CFR 50, Appendix I dose objectives.

For all release points, quarterly average gross alpha concentration of radioactivity measured less than 2E-10 $\mu\text{Ci}/\text{cc}$.

There were no abnormal releases of gaseous effluents during the period.

Table 1A - Gaseous Effluents – Summation of All Releases

| | Units | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter | Est. Total Error, % |
|--|-------|-------------|-------------|-------------|-------------|---------------------|
|--|-------|-------------|-------------|-------------|-------------|---------------------|

Fission and Activation Gases

| | | | | | | |
|---|---------|----------|----------|----------|----------|----------|
| 1. Total Release | Ci | 1.64R-07 | 1.16E+01 | 1.40E+01 | 1.51E+01 | 1.60E+01 |
| 2. Average Release Rate for Period | uCi/sec | 2.11E-08 | 1.47E+00 | 1.76E+00 | 1.89E+00 | |
| 3. Percent of Applicable Limit | % | * | * | * | * | |

Iodines

| | | | | | | |
|---|---------|----------|----------|----------|----------|----------|
| 1. Total I-131 | Ci | 1.35-05 | 3.23E-06 | 2.54E-06 | 2.98E-06 | 1.80E+01 |
| 2. Average Release Rate for Period | uCi/sec | 1.73E-06 | 4.11E-07 | 3.20E-07 | 3.75E-07 | |
| 3. Percent of Applicable Limit | % | * | * | * | * | |

Particulates

| | | | | | | |
|--|---------|----------|----------|----------|----------|----------|
| 1. Total Particulates w/ half life >8 days | Ci | 2.04E-04 | 4.02E-04 | 8.88E-06 | 8.56E-06 | 1.80E+01 |
| 2. Average Release Rate for Period | uCi/sec | 2.58E-05 | 5.01E-05 | 1.12E-06 | 1.08E-06 | |
| 3. Percent of Applicable Limit | % | * | * | * | * | |

Tritium

| | | | | | | |
|---|---------|----------|----------|----------|----------|----------|
| 1. Total Release | Ci | 9.51E+00 | 5.30E+00 | 2.29E+00 | 5.14E+00 | 1.60E+01 |
| 2. Average Release Rate for Period | uCi/sec | 1.22E+00 | 6.74E-01 | 2.88E-01 | 6.46E-01 | |
| 3. Percent of Applicable Limit | % | * | * | * | * | |

Carbon 14

| | | | | | |
|---|---------|----------|----------|----------|----------|
| 1. Total Carbon-14 | Ci | 2.33E+00 | 2.39E+00 | 2.44E+00 | 2.45E+00 |
| 2. Average Release Rate for Period | uCi/sec | 2.99E-01 | 3.04E-01 | 3.07E-01 | 3.08E-01 |
| 3. Percent of Applicable Limit | % | * | * | * | * |

* Applicable limits have been removed from the Technical Specifications. The comparison to ODAM limits is contained in the Radiological Impact on Man section of this report.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

Table 1B - Gaseous Effluents by Quarter

| ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT (2015) | | | | | |
|--|------|-----------------|-----------------|-----------------|-----------------|
| GASEOUS EFFLUENTS BY CALENDAR QUARTER (Curies) | | | | | |
| Nuclides Released | Unit | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
| 1. Fission gases | | | | | |
| krypton-85 | Ci | ND | ND | ND | ND |
| krypton-85m | Ci | ND | 3.13E-01 | 1.80E-01 | 4.41E+00 |
| krypton-87 | Ci | ND | 5.39E-01 | 5.36E-01 | 9.82E-01 |
| krypton-88 | Ci | ND | 4.92E-01 | 9.52E-02 | ND |
| xenon-133 | Ci | 1.64E-07 | 3.22E+00 | 1.38E+00 | 1.29E+00 |
| xenon-135 | Ci | ND | 3.41E+00 | 9.72E+00 | 8.37E+00 |
| xenon-135m | Ci | ND | 1.25E+00 | 1.18E+00 | ND |
| xenon-138 | Ci | ND | 2.31E+00 | 8.89E-01 | ND |
| argon-41 | Ci | ND | 3.50E-02 | ND | ND |
| Total for period | Ci | 1.64E-07 | 1.69E+01 | 1.63E+01 | 2.02E+01 |
| 2. Iodines | | | | | |
| iodine-131 | Ci | 1.35E-05 | 3.23E-06 | 2.54E-06 | 2.98E-06 |
| iodine-133 | Ci | 7.75E-06 | 5.56E-06 | 5.09E-06 | 5.85E-06 |
| iodine-135 | Ci | ND | ND | ND | ND |
| Total for period | Ci | 2.12E-05 | 8.79E-06 | 7.64E-06 | 8.83E-06 |
| 3. Particulates | | | | | |
| strontium-89 | Ci | 6.46E-07 | 3.86E-07 | 1.31E-06 | 1.86E-06 |
| strontium-90 | Ci | 1.34E-08 | 2.19E-08 | ND | ND |
| cesium-134 | Ci | ND | ND | ND | ND |
| cesium-137 | Ci | ND | ND | ND | ND |
| barium-lanthanum-140 | Ci | 7.55E-07 | 3.11E-07 | 1.35E-07 | 0.00E+00 |
| chromium-51 | Ci | 3.88E-07 | ND | ND | ND |
| cobalt-58 | Ci | 3.24E-07 | ND | ND | ND |
| cobalt-60 | Ci | 3.39E-06 | 3.40E-06 | 1.79E-07 | 3.43E-06 |
| manganese-54 | Ci | 3.88E-05 | 2.14E-05 | 7.26E-06 | 3.27E-06 |
| iron-55 | Ci | 1.51E-04 | 3.68E-04 | ND | ND |
| iron-59 | Ci | ND | ND | ND | ND |
| nickel-63 | Ci | 3.43E-06 | 8.37E-06 | ND | ND |
| zinc-65 | | 5.48E-06 | ND | ND | ND |
| Total for period | Ci | 2.04E-04 | 4.02E-04 | 8.88E-06 | 8.56E-06 |
| 4. Tritium | | 9.51E+00 | 5.30E+00 | 2.29E+00 | 5.14E+00 |
| Tritium Total | Ci | 9.51E+00 | 5.30E+00 | 2.29E+00 | 5.14E+00 |
| 5. Carbon-14 | | | | | |
| Carbon-14 Total | Ci | 2.33E+00 | 2.39E+00 | 2.44E+00 | 2.45E+00 |

ND means that the radionuclide was not identified in any samples and all analyses were performed with instrumentation meeting the lower limit of detection as required by the DAEC Offsite Dose Assessment Manual.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

Table 1B - Gaseous Effluents by Quarter

| ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT (2015) | | | | | |
|--|------|-----------------|-----------------|-----------------|-----------------|
| GASEOUS EFFLUENTS BY CALENDAR QUARTER (Curies) | | | | | |
| Nuclides Released | Unit | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
| 1. Fission gases | | | | | |
| krypton-85 | Ci | ND | ND | ND | ND |
| krypton-85m | Ci | ND | 3.13E-01 | 1.80E-01 | 4.41E+00 |
| krypton-87 | Ci | ND | 5.39E-01 | 5.36E-01 | 9.82E-01 |
| krypton-88 | Ci | ND | 4.92E-01 | 9.52E-02 | ND |
| xenon-133 | Ci | 1.64E-07 | 3.22E+00 | 1.38E+00 | 1.29E+00 |
| xenon-135 | Ci | ND | 3.41E+00 | 9.72E+00 | 8.37E+00 |
| xenon-135m | Ci | ND | 1.25E+00 | 1.18E+00 | ND |
| xenon-138 | Ci | ND | 2.31E+00 | 8.89E-01 | ND |
| argon-41 | Ci | ND | 3.50E-02 | ND | ND |
| Total for period | Ci | 1.64E-07 | 1.69E+01 | 1.63E+01 | 2.02E+01 |
| 2. Iodines | | | | | |
| iodine-131 | Ci | 1.35E-05 | 3.23E-06 | 2.54E-06 | 2.98E-06 |
| iodine-133 | Ci | 7.75E-06 | 5.56E-06 | 5.09E-06 | 5.85E-06 |
| iodine-135 | Ci | ND | ND | ND | ND |
| Total for period | Ci | 2.12E-05 | 8.79E-06 | 7.64E-06 | 8.83E-06 |
| 3. Particulates | | | | | |
| strontium-89 | Ci | 6.46E-07 | 3.86E-07 | 1.31E-06 | 1.86E-06 |
| strontium-90 | Ci | 1.34E-08 | 2.19E-08 | ND | ND |
| cesium-134 | Ci | ND | ND | ND | ND |
| cesium-137 | Ci | ND | ND | ND | ND |
| barium-lanthanum-140 | Ci | 7.55E-07 | 3.11E-07 | 1.35E-07 | 0.00E+00 |
| chromium-51 | Ci | 3.88E-07 | ND | ND | ND |
| cobalt-58 | Ci | 3.24E-07 | ND | ND | ND |
| cobalt-60 | Ci | 3.39E-06 | 3.40E-06 | 1.79E-07 | 3.43E-06 |
| manganese-54 | Ci | 3.88E-05 | 2.14E-05 | 7.26E-06 | 3.27E-06 |
| iron-55 | Ci | 1.51E-04 | 3.68E-04 | ND | ND |
| iron-59 | Ci | ND | ND | ND | ND |
| nickel-63 | Ci | 3.43E-06 | 8.37E-06 | ND | ND |
| zinc-65 | | 5.48E-06 | ND | ND | ND |
| Total for period | Ci | 2.04E-04 | 4.02E-04 | 8.88E-06 | 8.56E-06 |
| 4. Tritium | | 9.51E+00 | 5.30E+00 | 2.29E+00 | 5.14E+00 |
| Tritium Total | Ci | 9.51E+00 | 5.30E+00 | 2.29E+00 | 5.14E+00 |
| 5. Carbon-14 | | | | | |
| Carbon-14 Total | Ci | 2.33E+00 | 2.39E+00 | 2.44E+00 | 2.45E+00 |

ND means that the radionuclide was not identified in any samples and all analyses were performed with instrumentation meeting the lower limit of detection as required by the DAEC Offsite Dose Assessment Manual.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

Table 1C - Gaseous Effluents by Release Point

| ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT (2015) GASEOUS EFFLUENTS BY RELEASE POINT (Curies) | | | | |
|--|--------------|------------------|------------------|------------|
| RELEASE POINT: | OFFGAS STACK | REACTOR BUILDING | TURBINE BUILDING | LLRPSF |
| RELEASE HEIGHT: | 328 FEET | 156 FEET | 90 FEET | 65 FEET |
| RELEASE MODE: | ELEVATED | WAKE SPLIT | WAKE SPLIT | WAKE SPLIT |
| argon-41 | 3.50E-02 | ND | ND | ND |
| barium-140 | 2.02E-06 | ND | ND | ND |
| cesium-137 | ND | ND | ND | ND |
| chromium-51 | 3.88E-07 | ND | ND | ND |
| cerium-141 | ND | ND | ND | ND |
| cobalt-58 | ND | 3.24E-07 | ND | ND |
| cobalt-60 | ND | 1.04E-05 | ND | ND |
| iodine-131 | 2.14E-05 | 9.34E-07 | 1.50E-05 | ND |
| iodine-133 | 7.75E-06 | 4.94E+01 | 4.32E-06 | ND |
| iron-55 | ND | 1.51E-04 | ND | ND |
| krypton-85m | 7.87E-01 | ND | 4.12E+00 | ND |
| krypton-87 | 2.06E+00 | ND | ND | ND |
| manganese-54 | 4.25E-06 | 6.65E-05 | 2.16E-06 | ND |
| nickel-63 | ND | 1.18E-05 | ND | ND |
| strontium-89 | 1.06E-06 | 1.51E-06 | 1.64E-06 | ND |
| strontium-90 | 7.06E-08 | ND | ND | ND |
| Tritium | 2.92E+00 | 1.66E+01 | 2.65E+00 | 1.22E-02 |
| Xenon-133 | 5.39E+00 | 4.94E-01 | ND | ND |
| xenon-135 | 3.28E+00 | 1.54E+01 | 2.88E+00 | ND |
| xenon-135m | 2.43E+00 | ND | ND | ND |
| xenon-138 | 3.20E+00 | ND | ND | ND |
| zinc-65 | ND | 5.48E-06 | ND | ND |
| carbon-14 ** | 9.50 | - | - | - |

ND means that the radionuclide was not identified in any samples and all analyses were performed with instrumentation meeting the lower limit of detection as required by the DAEC Offsite Dose Assessment Manual.

** Carbon-14 release was estimated using methods of the EPRI document, "Estimation of Carbon-14 in Nuclear Power Plant Gaseous Effluents", Report 1021106, issued December 2010.

Estimated Release of Gaseous of Carbon-14


The estimate of gaseous carbon-14 (C-14) released from the Duane Arnold Energy Center was derived using the EPRI document, "Estimation of Carbon-14 in Nuclear Power Plant Gaseous Effluents", Report 1021106, issued December 2010. The site specific source term for the DAEC was estimated using the proxy generation rate values from Table 3-1 and the actual 2015 power history for the site.

The total amount of C-14 released from the site in 2015 was estimated to be 9.50 Curies.

Using the dose calculation methodology from Regulatory Guide 1.109, the resultant maximally exposed receptor organ from C-14 is the bone of a child, located 1760 meters towards the North. The dose is 8.9E-02 mRem (0.089 mrem). This is a fraction of the 1 mrem annual whole body dose received to the average US citizen from natural occurring carbon-14, primarily generated through cosmogenesis in the terrestrial biosphere. (Reference: National Council of Radiation Protection Report 94, "Exposure of the Population in the United States and Canada from Natural Background Radiation.")

Gaseous Effluents Trend

Curies per year, Historical Trend



DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

LIQUID EFFLUENTS

Liquid effluent release in the form of service water from the facility was continuous during the period. No reactor by-product radionuclides were identified in samples from service water.

There were no liquid releases from the plant radioactive waste handling systems during the period

There were no radioactive batch releases from the site in 2015.

There were no abnormal releases of radioactive liquids during the period.

Table 2A - Liquid Effluents – Summation of All Releases

| Units | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter | Est. Total Error, % |
|-------|-------------|-------------|-------------|-------------|---------------------|
|-------|-------------|-------------|-------------|-------------|---------------------|

Fission and Activation Gases

| | | | | | | |
|---|---------|----------|----------|----------|----------|----------|
| 1. Total Release (not including Tritium, gases, alpha) | Ci | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 2.00E+01 |
| 2. Average Release Rate for Period | uCi/sec | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | |
| 3. Percent of Applicable Limit | % | * | * | * | * | |

Tritium

| | | | | | | |
|---|---------|----------|----------|----------|----------|----------|
| 1. Total Release | Ci | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 2.00E+01 |
| 2. Average Release Rate for Period | uCi/sec | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | |
| 3. Percent of Applicable Limit | % | * | * | * | * | |

| | | | | | |
|--|--------|----------|----------|----------|----------|
| Volume of Water Release (prior to dilution) | liters | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
|--|--------|----------|----------|----------|----------|

| | | | | | |
|--|--------|----------|----------|----------|----------|
| Volume of dilution water used during period | liters | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
|--|--------|----------|----------|----------|----------|

* Applicable limits have been removed from the Technical Specifications. The comparison to ODAM limits is contained in the Radiological Impact on Man section of this report.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

Table 2B - Liquid Effluents

| ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT (2015) | | | | | |
|--|------|-------------|-------------|-------------|-------------|
| LIQUID EFFLUENTS (Curies) | | | | | |
| Nuclides Released | Unit | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
| strontium-89 | Ci | ND | ND | ND | ND |
| strontium-90 | Ci | ND | ND | ND | ND |
| cesium-134 | Ci | ND | ND | ND | ND |
| cesium-137 | Ci | ND | ND | ND | ND |
| iodine-131 | Ci | ND | ND | ND | ND |
| cobalt-58 | Ci | ND | ND | ND | ND |
| cobalt-60 | Ci | ND | ND | ND | ND |
| iron-55 | Ci | ND | ND | ND | ND |
| iron-59 | Ci | ND | ND | ND | ND |
| zinc-65 | Ci | ND | ND | ND | ND |
| manganese-54 | Ci | ND | ND | ND | ND |
| chromium-51 | Ci | ND | ND | ND | ND |
| zirconium-niobium-95 | Ci | ND | ND | ND | ND |
| molybdenum-99 | Ci | ND | ND | ND | ND |
| technetium-99m | Ci | ND | ND | ND | ND |
| barium-lanthanum-140 | Ci | ND | ND | ND | ND |
| cerium-141 | Ci | ND | ND | ND | ND |
| other | Ci | ND | ND | ND | ND |
| tritium | Ci | ND | ND | ND | ND |
| Total for period (above) | Ci | ND | ND | ND | ND |
| xenon-133 | Ci | ND | ND | ND | ND |
| xenon-135 | Ci | ND | ND | ND | ND |

ND means that the radionuclide was not identified in any samples and all analyses were performed with instrumentation meeting the lower limit of detection as required by the DAEC Offsite Dose Assessment Manual.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

RADIOACTIVE SOLID WASTE

A total of 7 solid radioactive waste shipments were made during 2015.

2 shipments of spent resin were made in 2015. These shipments of spent resin in poly liners were shipped for direct burial at Energy Solutions, located in Clive, Utah at their Containerized Waste Facility (CWF). All of these shipments contained resin from the condensate system and all were transported by highway.

5 shipments of Dry Active Waste (DAW) were shipped for processing and then to burial during the year 2015. All 5 shipments were sent to Energy Solutions Bear Creek processing facility for sorting and subsequently shipped for burial at Energy Solutions Clive, Utah facility. The transportation for this waste was by highway.

There were no shipments of liquid waste in 2015.

(

**DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT**

Shipments in 2015

Listed below are tables summarizing the Duane Arnold Energy Center's generation of Radioactive Solid Waste for the period of January 1, 2015 through December 31, 2015.

Shipments Made To Burial Facilities in 2015:

| WASTE TYPE | NO. SHIPMENTS | VOLUME (ft ³) | VOLUME (m ³) | ACTIVITY (curies) |
|-------------|--|------------------------------|-----------------------------|----------------------|
| Resin | 2 | 335 | 9.49 | 47.80 |
| DESTINATION | Energy Solutions, Containerized Waste Facility and Bulk Waste Facility Clive, Utah | | | |

See Table 3A below for Major Nuclides

Shipments Made To Processing Facilities in 2015:

| WASTE TYPE | NO. SHIPMENTS | VOLUME (ft ³) | VOLUME (m ³) | ACTIVITY (curies) |
|------------------|---|------------------------------|-----------------------------|----------------------|
| Dry Active Waste | 5 | 6350 | 179.81 | 0.34 |
| DESTINATION | Energy Solutions Bear Creek Facility, Oakridge TN The solid waste was subsequently delivered to Containerized Waste Facility and Bulk Waste Facility Clive, Utah | | | |

See Table 3B below for Major Nuclides

Total Solid Waste Disposition for 2015:

| WASTE | VOLUME (ft ³) | VOLUME (m ³) | ACTIVITY (curies) |
|---------|------------------------------|-----------------------------|----------------------|
| Shipped | 6685 | 189.30 | 48.14 |
| Buried | 6685 | 189.30 | 48.14 |

SOLIDIFICATION AGENT: None

MODE OF TRANSPORTATION: Exclusive-Use Vehicle (Trucks).

IRRADIATED COMPONENTS: There were no shipments of irradiated components or nuclear fuel in 2015

See Table 3C below for Annual Summary of Major Nuclides

| Waste Classification per 10 CFR 61 | NUMBER OF SHIPMENTS IN 2015 |
|------------------------------------|-----------------------------|
| A-Unstable | 7 |
| A-Stable | 0 |
| B | 0 |
| C | 0 |

Site Historical Comparison

| Year | Volume Buried(ft ³) | Activity (Ci) |
|------|---------------------------------|---------------|
| 2007 | 1.40E+04 | 110 |
| 2008 | 5.42E+03 | 134 |
| 2009 | 1.16E+04 | 58 |
| 2010 | 1.14E+04 | 23 |
| 2011 | 7.26E+03 | 324 |
| 2012 | 2.48E+04 | 58 |
| 2013 | 7.19E+03 | 52 |
| 2014 | 2.70E+04 | 33 |
| 2015 | 6.68E+03 | 48 |

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

Summary of Radioactive Solid Waste- Spent Resin

(January 1, 2015 - December 31, 2015)

MAJOR NUCLIDE COMPOSITION

Table 3A Spent Resin

| Principle Nuclide | 1st QTR (mCi) | 2nd QTR (mCi) | 3rd QTR (mCi) | 4th QTR (mCi) | Total (mCi) | Percent Abundance |
|-------------------|------------------|------------------|------------------|------------------|-----------------|----------------------|
| H-3 | 3.05E+01 | 2.75E+01 | | | 5.80E+01 | 0.121% |
| C-14 | 1.62E+01 | 3.66E+01 | | | 5.28E+01 | 0.110% |
| K-40 | | | | | 0.00E+00 | 0.000% |
| Cr-51 | 6.55E+01 | 5.68E+01 | | | 1.22E+02 | 0.255% |
| Mn-54 | 2.30E+03 | 1.05E+04 | | | 1.28E+04 | 26.714% |
| Fe-55 | 4.53E+03 | 9.92E+03 | | | 1.45E+04 | 30.157% |
| Co-57 | | | | | 0.00E+00 | 0.000% |
| Co-58 | 1.47E+02 | 3.74E+02 | | | 5.21E+02 | 1.087% |
| Ni-59 | | | | | 0.00E+00 | 0.000% |
| Fe-59 | 3.65E+01 | 5.37E+01 | | | 9.02E+01 | 0.188% |
| Co-60 | 1.92E+03 | 4.27E+03 | | | 6.19E+03 | 12.919% |
| Ni-63 | 2.41E+02 | 5.44E+02 | | | 7.85E+02 | 1.638% |
| Zn-65 | 1.31E+03 | 1.13E+04 | | | 1.26E+04 | 26.317% |
| Sr-89 | 1.46E+01 | 7.03E+00 | | | 2.16E+01 | 0.045% |
| Sr-90 | 3.96E+00 | 3.57E+00 | | | 7.53E+00 | 0.016% |
| Sr-91 | | | | | 0.00E+00 | 0.000% |
| Zr-95 | | | | | 0.00E+00 | 0.000% |
| Nb-95 | | 6.22E+00 | | | 6.22E+00 | 0.013% |
| Tc-99 | 4.50E+00 | 4.07E+00 | | | 8.57E+00 | 0.018% |
| Ag-110m | | | | | 0.00E+00 | 0.000% |
| Sn-113 | | | | | 0.00E+00 | 0.000% |
| Sb-124 | | | | | 0.00E+00 | 0.000% |
| Sb-125 | | | | | 0.00E+00 | 0.000% |
| I-125 | | | | | 0.00E+00 | 0.000% |
| I-129 | 1.21E+00 | 1.10E+00 | | | 2.31E+00 | 0.005% |
| Cs-137 | 8.32E+01 | 7.50E+01 | | | 1.58E+02 | 0.330% |
| Ce-144 | 1.77E+01 | 1.43E+01 | | | 3.20E+01 | 0.067% |
| Pu-239 | | | | | 0.00E+00 | 0.000% |
| Am-241 | | | | | 0.00E+00 | 0.000% |
| Totals | 1.07E+04 | 3.72E+04 | 0.00E+00 | 0.00E+00 | 4.79E+04 | 100.00% |

Note: H-3, C-14, Tc-99 and I-129 are required to be manifested per 10 CFR 20, Appendix G.

H-3, Tc-99 and I-129 represent Minimum Detectable Activity (MDA) values

These three nuclides are calculated from uCi/cc on manifest by the material volume

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

**Summary Tables of Radioactive Solid Waste
Dry Active Waste**

(January 1, 2015 - December 31, 2015)

MAJOR NUCLIDE COMPOSITION

Table 3B Dry Active Waste

| Principle Nuclide | 1st QTR (mCi) | 2nd QTR (mCi) | 3rd QTR (mCi) | 4th QTR (mCi) | Total (mCi) | Percent Abundance |
|-------------------|-----------------|-----------------|-----------------|-----------------|-----------------|-------------------|
| H-3 | 2.86E-01 | 1.22E+00 | | | 1.51E+00 | 0.439% |
| C-14 | 5.41E-03 | 2.31E-02 | | | 2.85E-02 | 0.008% |
| K-40 | 0.00E+00 | 0.00E+00 | | | 0.00E+00 | 0.000% |
| Cr-51 | 5.20E-01 | 2.81E+00 | | | 3.33E+00 | 0.969% |
| Mn-54 | 4.77E+00 | 2.09E+01 | | | 2.57E+01 | 7.469% |
| Fe-55 | 3.89E+01 | 1.67E+02 | | | 2.06E+02 | 59.981% |
| Co-57 | 2.91E-03 | 1.27E-02 | | | 1.57E-02 | 0.005% |
| Co-58 | 3.19E-01 | 1.50E+00 | | | 1.82E+00 | 0.531% |
| Ni-59 | 0.00E+00 | 0.00E+00 | | | 0.00E+00 | 0.000% |
| Fe-59 | 2.44E-01 | 1.21E+00 | | | 1.46E+00 | 0.424% |
| Co-60 | 1.79E+01 | 7.67E+01 | | | 9.46E+01 | 27.531% |
| Ni-63 | 7.50E-01 | 3.21E+00 | | | 3.96E+00 | 1.152% |
| Zn-65 | 6.48E-01 | 2.85E+00 | | | 3.50E+00 | 1.019% |
| Sr-89 | 0.00E+00 | 0.00E+00 | | | 0.00E+00 | 0.000% |
| Sr-90 | 0.00E+00 | 0.00E+00 | | | 0.00E+00 | 0.000% |
| Sr-91 | 0.00E+00 | 0.00E+00 | | | 0.00E+00 | 0.000% |
| Zr-95 | 1.38E-02 | 6.54E-02 | | | 7.92E-02 | 0.023% |
| Nb-95 | 4.31E-02 | 2.23E-01 | | | 2.66E-01 | 0.077% |
| Tc-99 | 2.75E-02 | 1.18E-01 | | | 1.46E-01 | 0.042% |
| Ag-110m | 0.00E+00 | 0.00E+00 | | | 0.00E+00 | 0.000% |
| Sn-113 | 0.00E+00 | 0.00E+00 | | | 0.00E+00 | 0.000% |
| Sb-124 | 3.33E-02 | 1.60E-01 | | | 1.93E-01 | 0.056% |
| Sb-125 | 0.00E+00 | 0.00E+00 | | | 0.00E+00 | 0.000% |
| I-125 | 0.00E+00 | 0.00E+00 | | | 0.00E+00 | 0.000% |
| I-129 | 3.58E-03 | 1.54E-02 | | | 1.89E-02 | 0.006% |
| Cs-137 | 1.49E-01 | 6.37E-01 | | | 7.86E-01 | 0.229% |
| Ce-144 | 2.45E-02 | 1.08E-01 | | | 1.32E-01 | 0.038% |
| Pu-239 | 0.00E+00 | 0.00E+00 | | | 0.00E+00 | 0.000% |
| Am-241 | 0.00E+00 | 0.00E+00 | | | 0.00E+00 | 0.000% |
| Totals | 6.46E+01 | 2.79E+02 | 0.00E+00 | 0.00E+00 | 3.44E+02 | 100.00% |

Note: H-3, C-14, Tc-99 and I-129 are required to be manifested per 10 CFR 20, Appendix G.

H-3, Tc-99 and I-129 include Minimum Detectable Activity (MDA) values

These three nuclides are calculated from uCi/cc on manifest by the material volume

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

Summary of Radioactive Solid Waste – Annual Summary

(January 1, 2015 - December 31, 2015)

MAJOR NUCLIDE COMPOSITION

Table 3C Radwaste Annual Summary

| Nuclide | Curies |
|--------------|-----------------|
| H-3 | 5.95E-02 |
| C-14 | 5.28E-02 |
| K-40 | 0.00E+00 |
| Cr-51 | 1.26E-01 |
| Mn-54 | 1.28E+01 |
| Fe-55 | 1.47E+01 |
| Co-57 | 1.57E-05 |
| Co-58 | 5.23E-01 |
| Ni-59 | 0.00E+00 |
| Fe-59 | 9.17E-02 |
| Co-60 | 6.28E+00 |
| Ni-63 | 7.89E-01 |
| Zn-65 | 1.26E+01 |
| Sr-89 | 2.16E-02 |
| Sr-90 | 7.53E-03 |
| Sr-91 | 0.00E+00 |
| Zr-95 | 7.92E-05 |
| Nb-95 | 6.49E-03 |
| Tc-99 | 8.72E-03 |
| Ag-110m | 0.00E+00 |
| Sn-113 | 0.00E+00 |
| Sb-124 | 1.93E-04 |
| Sb-125 | 0.00E+00 |
| I-125 | 0.00E+00 |
| I-129 | 2.33E-03 |
| Cs-137 | 1.59E-01 |
| Ce-144 | 3.21E-02 |
| Pu-239 | 0.00E+00 |
| Am-241 | 0.00E+00 |
| Total | 4.83E+01 |

RADIOLOGICAL IMPACT ON MAN

The annual offsite radiation dose to a member of the public was determined by assessment of environmental dosimetry results, by calculations based on monitored effluent releases and by estimating the release of gaseous carbon-14.

Dose Contribution from Direct Radiation

Direct radiation dose from the operation of the DAEC was reported by TLDs placed at locations in the surrounding environment as described in the Offsite Dose Assessment Manual (ODAM).

Pre-operational and 2015 TLD results were evaluated with a paired difference statistical test. The evaluation concluded that there were no significant differences in the TLD populations for the 0.5 mile, 1 mile and control TLD populations.

Estimated Offsite Dose from Effluent Releases

The contribution of dose to a member of the public most likely to be exposed from liquid and gaseous effluent releases was calculated using the Meteorological Information and Dose Assessment System (MIDAS) computer program in accordance with the ODAM. The calculation methods follow those prescribed by Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I".

Dose to members of the public from carbon-14 in gaseous effluent is calculated separately and is described below.

Results of the MIDAS dose calculations are displayed here:

- 1.) There were no releases of radioactive material to liquid effluents in 2015.
- 2.) The maximum dose to air at the site boundary from noble gases released was 0.0107 mrad from gamma radiation at 1176 meters towards the North.
- 3.) The maximum dose to air at the site boundary from noble gases released was 0.0134 mrad beta radiation at 1176 meters towards the North.
- 4.) The whole body dose equivalent to the hypothetical maximally exposed individual from noble gases was 0.0041 mrem, at 1760 meters towards the North.
- 5.) The skin dose equivalent to the hypothetical maximally exposed individual from noble gases was 0.0097 mrem, at 1760 meters towards the North.
- 6.) The hypothetical maximally exposed organ due to airborne iodines and particulates with half-lives greater than eight days (excluding carbon-14) was the lungs of a child at 805 meters towards the West, with an estimated dose equivalent of 0.00385 mrem.
- 7.) The hypothetical maximally exposed organ due to airborne carbon-14 was the bone of a child located 1760 meters to the North of the site. The dose was 0.089 mrem.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

Conclusion

No measurable dose due to the operation of the DAEC was detected by environmental TLDs in 2015. The calculated doses are below the regulatory limits stated in Appendix I to 10CFR50 and in 40CFR190.

Estimated Maximum Offsite Individual Doses for 2015

| Type | Age Group | Distance (meters) | Direction | Dose or Dose Equivalent (mrem) | Annual 10 CFR 50, Appendix I "Limit" |
|--|---------------|-------------------|-----------|--------------------------------|--------------------------------------|
| Direct Radiation (as measured by TLDs) | | | | None | * |
| Liquid Releases | | | | | |
| Whole Body Dose | Child | NA** | NA** | 0.000000 mrem | 3 mrem |
| Organ Dose | Child - Liver | NA** | NA** | 0.000000 mrem | 10 mrem |
| Noble Gas | | | | | |
| Gamma Air Dose | | 1176 | N | 0.0107 mrad | 10 mrad |
| Beta Air Dose | | 1176 | N | 0.0134 mrad | 20 mrad |
| Whole Body | All | 1760 | N | 0.0041 mrem | 5 mrem |
| Skin | Adult | 1760 | N | 0.0097 mrem | 15 mrem |
| Particulates & Iodines | | | | | |
| Organ Dose | Child – Lungs | 805 | W | 0.00385 mrem | 15 mrem |
| Carbon 14 | | | | | |
| Organ Dose | Child – Bone | 1760 | N | 0.089 mrem | 15 mrem |

* There is no Appendix I limit for direct radiation. It is listed here to demonstrate compliance with 40 CFR 190 limits of 25 mrem whole body and 75 mrem thyroid.

** NA, not applicable as there were no liquid releases in 2015.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

SUMMARY OF METEOROLOGICAL DATA

The following pages are a summation of meteorological data accumulated during the 2015 calendar year by the MIDAS software (Meteorological Information and Dose Assessment System) at the Duane Arnold Energy Center.

Better than 90% data recovery was obtained for combined wind speed, delta temperature and wind direction. A table summarizing data collection is printed here:

Met. Data Recovery

| Elevation and Sensors | % Joint Recovery "good" data |
|---|------------------------------|
| 10 meter Wind Direction Wind Speed Delta Temp | 97.6% |
| 50 meter Wind Direction Wind Speed Delta Temp | 97.7% |

Listed on the following pages are wind rose plots and stability class summary tables for the specified sensor heights (33 feet or 156 feet). Joint Frequency tables for each of the individual stability classes are maintained on site and are available upon request.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

Stability Class Data 33'

Joint Frequency Distribution

Summary of All Stability Classes

Period of Record: 1/1/2015 00:00 - 1/1/2016 00:00

Elevation: 33'

Speed: WS33

Direction: WD33

Lapse: DEL T (Delta Temperature)

| <u>Wind Direction</u> | Wind Speed (mph) | | | | | | <u>Total</u> |
|-----------------------|------------------|--------------|---------------|----------------|----------------|-------------|--------------|
| | <u>1 - 4</u> | <u>4 - 8</u> | <u>8 - 13</u> | <u>13 - 19</u> | <u>19 - 25</u> | <u>≥ 25</u> | |
| N | 32 | 68 | 59 | 44 | 13 | 5 | 221 |
| NNE | 39 | 76 | 55 | 43 | 14 | 2 | 229 |
| NE | 114 | 260 | 141 | 56 | 10 | 0 | 581 |
| ENE | 133 | 212 | 101 | 34 | 0 | 0 | 480 |
| E | 128 | 224 | 69 | 29 | 1 | 0 | 451 |
| ESE | 104 | 212 | 126 | 26 | 3 | 0 | 471 |
| SE | 145 | 221 | 162 | 53 | 8 | 0 | 589 |
| SSE | 189 | 381 | 184 | 41 | 5 | 0 | 800 |
| S | 216 | 439 | 304 | 94 | 11 | 5 | 1069 |
| SSW | 201 | 207 | 139 | 56 | 23 | 3 | 629 |
| SW | 142 | 211 | 83 | 46 | 14 | 6 | 502 |
| WSW | 107 | 147 | 93 | 23 | 7 | 7 | 384 |
| W | 72 | 123 | 139 | 91 | 18 | 8 | 451 |
| WNW | 30 | 95 | 147 | 120 | 51 | 18 | 461 |
| NW | 20 | 123 | 167 | 159 | 81 | 37 | 587 |
| NNW | 27 | 82 | 211 | 189 | 112 | 27 | 648 |
| Total | 1699 | 3081 | 2180 | 1104 | 371 | 118 | 8553 |

Calm Hours not Included above for :

Total Period 1

Variable Direction Hours for:

Total Period 0

Invalid Hours for:

Total Period 207


Valid Hours for this Stability Class for:

Total Period 8553

Total Hours for Period

8761

Wind Rose Data 33'



Wind Rose (Direction From)

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

Stability Class Data 156'

Joint Frequency Distribution

Summary of All Stability Classes

Period of Record: 1/1/2015 00:00 – 1/1/2016 00:00

Elevation: 156'

Speed: WS156

Direction: WD156

Lapse: DEL T (Delta Temperature)

Wind Speed (mph)

| <u>Wind Direction</u> | <u>1 - 4</u> | <u>4 - 8</u> | <u>8 - 13</u> | <u>13 - 19</u> | <u>19 - 25</u> | <u>≥ 25</u> | <u>Total</u> |
|-----------------------|--------------|--------------|---------------|----------------|----------------|-------------|--------------|
| N | 30 | 55 | 62 | 73 | 8 | 1 | 229 |
| NNE | 15 | 69 | 223 | 97 | 22 | 1 | 427 |
| NE | 16 | 93 | 205 | 72 | 13 | 4 | 403 |
| ENE | 33 | 86 | 118 | 26 | 3 | 0 | 266 |
| E | 60 | 234 | 196 | 19 | 1 | 0 | 510 |
| ESE | 24 | 159 | 234 | 76 | 7 | 1 | 501 |
| SE | 32 | 144 | 362 | 150 | 16 | 1 | 705 |
| SSE | 18 | 200 | 384 | 327 | 40 | 2 | 971 |
| S | 26 | 203 | 366 | 269 | 53 | 8 | 925 |
| SSW | 40 | 166 | 152 | 97 | 38 | 13 | 506 |
| SW | 38 | 153 | 117 | 74 | 27 | 14 | 423 |
| WSW | 25 | 120 | 125 | 67 | 28 | 9 | 374 |
| W | 26 | 102 | 177 | 129 | 67 | 30 | 531 |
| WNW | 28 | 124 | 164 | 116 | 86 | 54 | 572 |
| NW | 16 | 94 | 238 | 249 | 118 | 28 | 743 |
| NNW | 25 | 56 | 162 | 202 | 22 | 5 | 472 |
| Total | 452 | 2058 | 3285 | 2043 | 549 | 171 | 8558 |

Calm Hours not Included above for :

Total Period

0

Variable Direction Hours for:

Total Period

0

Invalid Hours for:

Total Period

203

Valid Hours for this Stability Class for:


Total Period

8558

Total Hours for Period

8761

Wind Rose Data 156'



Wind Rose (Direction From)

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

SUMMARY OF GROUND WATER PROTECTION INITIATIVE ISSUES

The Duane Arnold Energy Center has committed to the Nuclear Energy Institute's Industry Groundwater Protection Initiative - NEI 07-07. Per NEI 07-07, the following information is presented:

- Ground Water Protection Program (GWPP) samples were collected and analyzed in accordance with the requirements and guidance of the site procedure ACP 1411.35. Program results are presented in Attachment 1.
- No reactor-by-product gamma emitting isotopes were identified.
- Tritium was detected in the onsite monitoring wells with concentrations ranging from non-detectable at less than 180 pCi/L, up to an approximate concentration of 22,000 pCi/L.
- There was one instances where samples from the Ground Water Protection Program or the Radiological Environmental Monitoring Program contained contamination exceeding threshold concentration levels for reporting.
- The reporting threshold for tritium is equal to the EPA Drinking Water Standard of 20,000 pCi/L. Although the EPA standard provides a baseline for comparison, no drinking water sources are directly affected. All of the affected wells are onsite and are in shallow aquifers. No site or neighboring drinking water wells are installed in these aquifers and no tritium has been identified in deep onsite and neighboring drinking water wells. Assumptions were made for the water from monitoring well MW-09A (average concentration = 7108 pCi/L) as if was consumed by a child as drinking water for an entire year, the maximum dose consequence would be less than approximately 0.736 mrem/yr.
- There was one instances where state and local officials were notified of a spill of radioactive liquid.

COURTESY OFFSITE NOTIFICATION MADE TO STATE AND COUNTY OFFICIALS

"On April 12, at 1235 CDT, Duane Arnold Energy Center contacted officials with the State of Iowa (Bureau of Radiological Health and Department of Natural Resources) and Linn County Public Health Department in accordance with the nuclear industry voluntary reporting criteria contained in NEI 07-07 'Industry Ground Water Protection Initiative'. The site contacted the agencies as courtesy to notify them about the identification of low levels of tritium found within the site's protected area from a potential new source. Samples were taken, and no regulatory limits were exceeded. The site team is working with industry experts on pinpointing the cause and installing an extraction well to remediate the situation. "This report is being made in accordance with 10 CFR 50.72(b)(2)(xi), as a result of notification to offsite agencies.

"The Licensee has notified the NRC Resident Inspectors.

"There is no risk to plant employees, the public or drinking water."

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

See Attachment One for analyses results from samples
collected for the Ground Water Protection Program.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

DESCRIPTION OF CHANGES TO THE OFFSITE DOSE ASSESSMENT MANUAL

Before implementation of the following described changes, a review was performed to validate that the levels of radioactive effluent control required by 10 CFR 20.1302, 40 CFR 190, 10 CFR 50.36a, and 10 CFR 50, Appendix I were not affected. The review also verified that the changes did not adversely impact the accuracy or reliability of effluent dose or setpoint calculations.

Revision 32 → Revision 33

Revision 33 to the ODAM was made effective on 11/4/2015. Changes implemented included:

Table 5-1: Environmental Sample Stations

- Station #5 is revised to remove reference to Airborne Particulate and Iodine sampling due to elimination of the Air Sampler in the town of Palo, Iowa.

Revision 33 → Revision 34

Revision 34 to the ODAM was made effective on 12/18/2015. Changes implemented included:

Table 5-1: Environmental Sample Stations

- Five Ground Water Onsite Monitoring Wells were added to the GWPP Program. These Monitoring Wells are identified as Stations # 133 through 137.

Revision 34 → Revision 35

Revision 35 to the ODAM was made effective on 3/1/2016. Changes implemented included:

Section 2: LIQUID EFFLUENT

- Discussion in Section 2 is revised to reflect the plant modification the replaced the discharge canal between the Dilution Structure and the Cedar River with a discharge pipe.

Figure 2-1: Duane Arnold Energy Center Radioactive Water Effluent Diagram

- Figure 2-1 is revised to reflect the plant modification that replaced the discharge canal between the Dilution Structure and the Cedar River with a discharge pipe.

BASES 6.1.3/7.1.3 (2): Liquid Effluents

- Discussion in BASES 6.1.3/7.1.3 Item 2 is revised to reflect the plant modification the replaced the discharge canal between the Dilution Structure and the Cedar River with a discharge pipe.

ODAM Revision Date History

| Revision: | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 |
|-----------|---------|---------|---------|---------|---------|---------|---------|----------|--------|
| Date: | 11/9/09 | 1/13/11 | 9/15/11 | 3/11/13 | 8/12/14 | 3/19/15 | 11/4/15 | 12/18/15 | 3/1/16 |

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

ATTACHMENT 1: GROUND WATER PROTECTION PROGRAM RESULTS

Presented in Attachment 1A are analysis results from the site Ground Water Protection Program (GWPP) as determined by the Site Laboratory.

- Gamma Spectroscopy results for site monitoring well samples.
- Gamma Spectroscopy results for site surface water samples.
- Tritium results for site surface water samples.

The Duane Arnold chemistry laboratory participates in Cross Check Program with the firm: Eckert & Ziegler Analytics from Atlanta GA. The Radiochemistry Cross Check program results are available upon request.

Presented in Attachment 1B are analysis results from site's Ground Water Protection Program (GWPP) as determined by a contracted vendor Laboratory

- Tritium results for site monitoring well samples.
- Conditional analyses results for hard-to-detect isotopes and gamma emitters for select monitoring well and surface water samples.
- Tritium results for site precipitation samples.
- Strontium-90, Tritium and Gamma Spectroscopy results for site soil samples.

The vendor laboratory providing these GWPP sample analysis results is Environmental Inc. Midwest Laboratory of Northbrook, IL. The Environmental Inc. laboratory participates in several cross check programs. These cross check program results are presented in the 2015 Duane Arnold Energy Center Annual Radiological Environmental Operating Report or by request.

GWPP Sampling Deviations

| Sample Type | Analysis | Location | Collection Period | Comments |
|------------------|---------------|-------------------------|---------------------|--|
| Precip | Tritium | All Locations | February | No viable sample collected |
| | | D127, D128 | December | Sampler failure due to leak at bottom end cap |
| Surface Water | Tritium Gamma | D49, D50, D99 | January | Sample locations were frozen solid |
| | | D49, D50, D51, D61, D99 | February October | CE02088659 documents deviation due to work order and auditing performance gaps |
| Vault Water | Tritium Gamma | D-119 | Q4 | 555 pCi/L of tritium discovered in electrical vault; attributed to atmospheric recapture from offgas stack |
| Monitoring Wells | Tritium | All | Q3 | All Q3 quarterly, non-conditional well samples were collected late. Nine new monitoring wells installed and additional vaults sampled in Q3-Q4 |


DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

ATTACHMENT 1: GROUND WATER PROTECTION PROGRAM RESULTS

GWPP Sample Locations

| # | Description | Type |
|------|---------------------------------|---------------|
| 15a | On-site, 505 meters NNW | Soil |
| 16 | On-site, 520 meters SSE | Soil, Precip. |
| 55 | Production Well Header | GW |
| 111 | Monitoring Wells MW01A / MW01B | GW, Precip. |
| 112 | Monitoring Wells MW02A / MW02B | GW, Precip. |
| 113 | Monitoring Wells MW03A / MW03B | GW |
| 114 | Monitoring Wells MW04A / MW04B | GW, Precip. |
| 115 | Monitoring Wells MW05A / MW05B | GW |
| 116 | Monitoring Wells MW06A / MW06B | GW |
| 119 | MH209, 240 meters ESE | Vault |
| 120 | MH210, 380 meters SE | Vault |
| 121 | MH211, 530 meters SE | Vault |
| 122 | Sluice Pond | SW |
| 123 | South Drainage Ditch | SW |
| 124 | North Drainage Ditch | SW |
| 125 | Southeast Storm Drain Outfall | SW |
| 127 | Monitoring Wells MW07A / MW07B | GW, Precip. |
| 128 | Monitoring Wells MW08A / MW08B | GW, Precip. |
| 129 | Monitoring Wells MW09A / MW09B | GW |
| 130 | Monitoring Wells MW10A / MW10B | GW |
| 131 | Monitoring Wells MW11A / 11B | GW |
| 132 | Monitoring Wells MW12A / MW12B | GW |
| 133* | Monitoring Wells MW-13A / MW13B | GW |
| 134* | Monitoring Wells MW-14A / MW14B | GW |
| 135* | Monitoring Wells MW-15A / MW15B | GW |
| 136* | Monitoring Wells MW-16A / MW16B | GW |
| 137* | Monitoring Well MW-17C | GW |

P = Precipitation, GW = Ground Water, SW = Surface Water



*New wells installed in 2015

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT
ATTACHMENT 1A: GROUND WATER PROTECTION PROGRAM RESULTS-OFFSITE LAB

Groundwater Protection Program Summary

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT
ATTACHMENT 1A: GROUND WATER PROTECTION PROGRAM RESULTS-OFFSITE LAB

D-1. Groundwater Protection Program Summary.

| Precipitation samples for tritium analysis. | | | | | | Units: pCi/L |
|---|----------|-----------|----------|----------|-----------------|--------------|
| Lab Code | Date | H-3 | Lab Code | Date | H-3 | |
| D-016 | | | D-111 | | | |
| DP- 213 | 01/19/15 | < 173 | DP- 214 | 01/19/15 | < 173 | |
| DP- 960 | 03/10/15 | < 147 | DP- 961 | 03/10/15 | 483 ± 97 | |
| DP- 2012 | 04/27/15 | < 159 | DP- 2013 | 04/27/15 | < 147 | |
| DP- 2342 | 05/08/15 | < 146 | DP- 2343 | 05/08/15 | < 146 | |
| DP- 3268 | 06/26/15 | < 143 | DP- 3269 | 06/26/15 | < 143 | |
| DP- 3834 | 07/16/15 | < 155 | DP- 3835 | 07/16/15 | < 155 | |
| DP- 4793 | 08/28/15 | < 145 | DP- 4794 | 08/28/15 | < 145 | |
| DP- 5307 | 09/23/15 | < 150 | DP- 5308 | 09/23/15 | < 150 | |
| DP- 5952 | 10/21/15 | < 149 | DP- 5953 | 10/21/15 | < 149 | |
| DP- 6526 | 11/10/15 | < 143 | DP- 6528 | 11/10/15 | < 143 | |
| DP- 6960 | 12/09/15 | < 146 | DP- 6961 | 12/09/15 | 232 ± 82 | |
| D-112 | | | D-114 | | | |
| DP- 215 | 01/19/15 | < 173 | DP- 216 | 01/19/15 | < 173 | |
| DP- 962 | 03/10/15 | < 147 | DP- 964 | 03/09/15 | < 147 | |
| DP- 2014 | 04/27/15 | < 147 | DP- 2015 | 04/27/15 | < 147 | |
| DP- 2344 | 05/08/15 | < 146 | DP- 2345 | 05/08/15 | < 146 | |
| DP- 3270 | 06/26/15 | < 143 | DP- 3271 | 06/26/15 | < 143 | |
| DP- 3836 | 07/16/15 | < 155 | DP- 3837 | 07/16/15 | < 155 | |
| DP- 4795 | 08/28/15 | < 145 | DP- 4796 | 08/28/15 | < 145 | |
| DP- 5309 | 09/23/15 | < 150 | DP- 5310 | 09/23/15 | < 150 | |
| DP- 5954 | 10/21/15 | 244 ± 90 | DP- 5955 | 10/20/15 | 1029 ± 120 | |
| DP- 6529 | 11/10/15 | < 143 | DP- 6530 | 11/10/15 | < 143 | |
| DP- 6962 | 12/09/15 | < 146 | DP- 6963 | 12/09/15 | < 146 | |
| D-127 | | | D-128 | | | |
| DP- 217 | 01/20/15 | 339 ± 111 | DP- 218 | 01/20/15 | < 190 | |
| DP- 965 | 03/10/15 | 528 ± 99 | | | ND ^a | |
| DP- 2017 | 04/27/15 | 531 ± 98 | DP- 2018 | 04/27/15 | 385 ± 92 | |
| DP- 2346 | 05/08/15 | 193 ± 86 | DP- 2347 | | < 146 | |
| DP- 3272 | 06/26/15 | 617 ± 100 | DP- 3273 | 06/26/15 | 245 ± 84 | |
| DP- 3838 | 07/16/15 | 259 ± 90 | DP- 3839 | 07/16/15 | < 155 | |
| DP- 4797 | 08/28/15 | 534 ± 98 | DP- 4798 | 08/28/15 | 405 ± 92 | |
| DP- 5311 | 09/23/15 | 576 ± 102 | DP- 5312 | 09/23/15 | < 150 | |
| DP- 5956 | 10/21/15 | < 149 | DP- 5957 | 10/20/15 | < 149 | |
| DP- 6531 | 11/10/15 | 252 ± 84 | DP- 6532 | 11/10/15 | < 143 | |
| DP- 6964 | 12/09/15 | 860 ± 109 | DP- 6965 | 12/09/15 | < 149 | |

^a "ND" = No data; sample not available.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT
ATTACHMENT 1A: GROUND WATER PROTECTION PROGRAM RESULTS-OFFSITE LAB

Precipitation, monthly collections, analyses for gamma emitting isotopes.

Location: D-16

| Lab Code | Date | Concentration (pCi/L) | | | | | | | | | | | |
|----------|----------|-----------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|-------------------|-------------------|-------------------|-------------------|
| | | ⁵⁴ Mn | ⁵⁹ Fe | ⁵⁸ Co | ⁶⁰ Co | ⁶⁵ Zn | ⁹⁵ Nb | ⁹⁵ Zr | ¹³¹ I | ¹³⁴ Cs | ¹³⁷ Cs | ¹⁴⁰ Ba | ¹⁴⁰ La |
| DP- 213 | 01/19/15 | < 3.7 | < 7.8 | < 3.7 | < 1.9 | < 6.9 | < 3.8 | < 4.6 | < 6.5 | < 3.4 | < 3.1 | < 11.5 | < 4.1 |
| DP- 960 | 03/10/15 | < 3.6 | < 3.2 | < 2.9 | < 3.8 | < 4.6 | < 3.3 | < 7.2 | < 5.0 | < 3.5 | < 3.0 | < 14.7 | < 1.7 |
| DP- 2012 | 04/27/15 | < 2.6 | < 7.0 | < 2.2 | < 3.7 | < 4.2 | < 3.3 | < 4.4 | < 7.1 | < 2.9 | < 2.5 | < 13.4 | < 3.9 |
| DP- 2342 | 05/08/15 | < 2.2 | < 5.1 | < 2.6 | < 2.3 | < 4.7 | < 2.3 | < 3.3 | < 5.7 | < 2.7 | < 2.7 | < 20.2 | < 4.6 |
| DP- 3268 | 06/26/15 | < 1.9 | < 4.9 | < 1.5 | < 1.5 | < 4.0 | < 2.0 | < 5.2 | < 4.1 | < 2.9 | < 2.6 | < 9.0 | < 1.2 |
| DP- 3834 | 07/16/15 | < 3.3 | < 5.8 | < 1.7 | < 2.4 | < 5.9 | < 4.2 | < 3.6 | < 9.1 | < 4.1 | < 4.6 | < 21.7 | < 3.3 |
| DP- 4793 | 08/28/15 | < 4.5 | < 10.4 | < 6.2 | < 2.8 | < 6.9 | < 4.4 | < 9.7 | < 11.3 | < 5.5 | < 5.8 | < 28.5 | < 6.3 |
| DP- 5307 | 09/23/15 | < 2.4 | < 3.8 | < 2.5 | < 2.4 | < 1.8 | < 3.8 | < 6.1 | < 11.5 | < 3.6 | < 3.7 | < 15.5 | < 6.6 |
| DP- 5952 | 10/21/15 | < 4.8 | < 6.5 | < 4.0 | < 3.7 | < 7.3 | < 4.1 | < 7.6 | < 6.4 | < 4.0 | < 4.7 | < 20.0 | < 3.4 |
| DP- 6526 | 11/10/15 | < 4.8 | < 6.6 | < 3.1 | < 3.7 | < 4.2 | < 5.0 | < 5.8 | < 7.0 | < 4.8 | < 2.4 | < 27.6 | < 4.9 |
| DP- 6960 | 12/09/15 | < 2.9 | < 2.8 | < 3.4 | < 3.3 | < 6.4 | < 3.8 | < 6.6 | < 7.0 | < 3.6 | < 3.5 | < 16.6 | < 1.7 |

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT
ATTACHMENT 1A: GROUND WATER PROTECTION PROGRAM RESULTS-OFFSITE LAB

Ground water, Monitoring wells, analyses for tritium ^a:

| Lab Code | Date | H-3 (pCi/L) | Lab Code | Date | H-3 (pCi/L) |
|-----------|----------|-------------|-----------|----------|-------------|
| | | D-111A | | (01A) | |
| DWW- 1231 | 03/17/15 | < 147 | | | |
| DWW- 3460 | 06/29/15 | < 155 | | | |
| DWW- 6794 | 11/24/15 | < 145 | | | |
| DWW- 165 | 12/28/15 | < 143 | | | |
| | | D-111B | | (01B) | |
| DWW- 1232 | 03/17/15 | < 147 | DWW- 6795 | 11/24/15 | < 145 |
| DWW- 3461 | 06/29/15 | < 155 | DWW- 166 | 12/28/15 | < 143 |
| | | D-112A | | (02A) | |
| DWW- 1234 | 03/18/15 | < 147 | DWW- 6796 | 11/24/15 | < 145 |
| DWW- 3462 | 06/29/15 | < 155 | DWW- 167 | 12/28/15 | < 143 |
| | | D-112B | | (02B) | |
| DWW- 1235 | 03/18/15 | < 147 | DWW- 6797 | 11/24/15 | < 145 |
| DWW- 3463 | 06/29/15 | < 155 | DWW- 168 | 12/28/15 | < 143 |
| | | D-113A | | (03A) | |
| DWW- 1236 | 03/18/15 | < 147 | DWW- 169 | 12/28/15 | < 143 |
| DWW- 3464 | 06/29/15 | < 155 | | | |
| DWW- 6798 | 11/23/15 | < 145 | | | |
| | | D-113B | | (03B) | |
| DWW- 1237 | 03/18/15 | < 147 | DWW- 6799 | 11/23/15 | < 145 |
| DWW- 3465 | 06/29/15 | < 155 | DWW- 170 | 12/28/15 | < 143 |
| | | D-114A | | (04A) | |
| DWW- 1891 | 03/18/15 | 925 ± 114 | | | |
| DWW- 2349 | 04/27/15 | 610 ± 104 | | | |
| DWW- 3466 | 05/08/15 | 708 ± 110 | | | |
| DWW- 6925 | 11/30/15 | 148 ± 80 | | | |
| DWW- 171 | 12/31/15 | < 142 | | | |
| | | D-114B | | (04B) | |
| DWW- 1238 | 03/18/15 | < 147 | DWW- 6926 | 11/30/15 | < 145 |
| DWW- 3467 | 05/08/15 | < 156 | DWW- 172 | 12/31/15 | < 142 |
| | | D-115A | | (05A) | |
| DWW- 1270 | 03/18/15 | < 149 | DWW- 6801 | 11/24/15 | < 145 |
| DWW- 3468 | 06/29/15 | < 155 | DWW- 173 | 12/28/15 | < 143 |
| | | D-115B | | (05B) | |
| DWW- 1271 | 03/18/15 | < 147 | DWW- 6802 | 11/24/15 | < 145 |
| DWW- 3469 | 06/29/15 | < 155 | DWW- 174 | 12/28/15 | < 143 |
| | | D-116A | | (06A) | |
| DWW- 1272 | 03/18/15 | < 147 | DWW- 6803 | 11/24/15 | < 145 |
| DWW- 3470 | 06/29/15 | < 155 | DWW- 175 | 12/28/15 | < 143 |
| | | D-116B | | (06B) | |
| DWW- 1273 | 03/18/15 | < 147 | DWW- 6804 | 11/24/15 | < 145 |
| DWW- 3472 | 06/29/15 | < 155 | DWW- 176 | 12/28/15 | < 143 |

^a Analyses for gamma, gross alpha, Sr-89, Sr-90, Fe-55 and Ni-63 will be performed if tritium activity > 1K pCi/L.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT
ATTACHMENT 1A: GROUND WATER PROTECTION PROGRAM RESULTS-OFFSITE LAB

Ground water, Monitoring wells, analyses for tritium ^a.

| Lab Code | Date | H-3 (pCi/L) | Lab Code | Date | H-3 (pCi/L) |
|-----------|----------|-------------|-----------|----------|-------------|
| D-127A | | | | | |
| DWW- 497 | 01/30/15 | 1077 ± 150 | | | |
| DWW- 646 | 02/13/15 | 1283 ± 129 | | | |
| DWW- 1892 | 03/19/15 | 1291 ± 127 | | | |
| DWW- 2359 | 04/28/15 | 1685 ± 140 | | | |
| DWW- 3631 | 06/30/15 | 10969 ± 314 | | | |
| DWW- 4603 | 07/29/15 | 1872 ± 145 | | | |
| DWW- 4612 | 08/19/15 | 1183 ± 123 | | | |
| DWW- 5769 | 10/06/15 | 1460 ± 130 | | | |
| DWW- 7113 | 12/11/15 | 1243 ± 122 | | | |
| D-127B | | | | | |
| (07B) | | | | | |
| DWW- 484 | 01/30/15 | < 190 | | | |
| DWW- 2350 | 04/28/15 | < 146 | | | |
| DWW- 3473 | 06/30/15 | < 155 | | | |
| DWW- 6805 | 11/12/15 | < 146 | | | |
| DWW- 7214 | 12/18/15 | < 144 | | | |
| D-128A | | | | | |
| (08A) | | | | | |
| DWW- 486 | 01/30/15 | 658 ± 131 | | | |
| DWW- 1239 | 03/19/15 | 182 ± 81 | | | |
| DWW- 3474 | 06/30/15 | < 155 | | | |
| DWW- 6806 | 11/12/15 | 212 ± 81 | | | |
| DWW- 7215 | 12/18/15 | 208 ± 82 | | | |
| DWW- 7224 | 12/11/15 | 210 ± 83 | | | |
| D-128B | | | | | |
| (08B) | | | | | |
| DWW- 487 | 01/30/15 | < 190 | DWW- 6807 | 11/12/15 | 979 ± 113 |
| DWW- 647 | 02/13/15 | 1285 ± 129 | DWW- 7216 | 12/18/15 | 1186 ± 121 |
| DWW- 1893 | 03/19/15 | 1269 ± 126 | | | |
| DWW- 2348 | 04/28/15 | 1201 ± 125 | | | |
| DWW- 3475 | 06/30/15 | 832 ± 114 | | | |
| DWW- 4604 | 07/29/15 | 1100 ± 120 | | | |
| D-129A | | | | | |
| (09A) | | | | | |
| DWW- 498 | 01/30/15 | 1873 ± 180 | DWW- 4613 | 07/21/15 | 1057 ± 119 |
| DWW- 648 | 02/13/15 | 1467 ± 134 | DWW- 6552 | 08/31/15 | 687 ± 104 |
| DWW- 1894 | 03/19/15 | 2487 ± 161 | DWW- 5768 | 10/06/15 | 827 ± 109 |
| DWW- 2026 | 04/28/15 | 21991 ± 758 | DWW- 6808 | 11/12/15 | 1046 ± 116 |
| DWW- 2360 | 05/07/15 | 11275 ± 312 | DWW- 7225 | 12/11/15 | 665 ± 102 |
| DWW- 2591 | 05/14/15 | 10177 ± 302 | | | |
| DWW- 2592 | 05/22/15 | 7117 ± 257 | | | |
| DWW- 3055 | 05/28/15 | 4586 ± 208 | | | |
| DWW- 3056 | 06/12/15 | 4933 ± 215 | | | |
| DWW- 3632 | 07/06/15 | 5169 ± 225 | | | |
| D-129B | | | | | |
| (09B) | | | | | |
| DWW- 488 | 01/30/15 | 1256 ± 157 | DWW- 6809 | 11/12/15 | 579 ± 98 |
| DWW- 649 | 02/13/15 | 953 ± 118 | DWW- 7217 | 12/17/15 | 547 ± 98 |
| DWW- 1240 | 03/19/15 | 1060 ± 118 | | | |
| DWW- 2351 | 04/29/15 | 620 ± 105 | | | |
| DWW- 3476 | 06/30/15 | 745 ± 111 | | | |
| DWW- 6553 | 08/31/15 | 754 ± 107 | | | |

^a Analyses for gamma, gross alpha, Sr-89, Sr-90, Fe-55 and Ni-63 will be performed if tritium activity > 1K pCi/L.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT
ATTACHMENT 1A: GROUND WATER PROTECTION PROGRAM RESULTS-OFFSITE LAB

Ground water, Monitoring wells, analyses for tritium ^a.

| Lab Code | Date | H-3 (pCi/L) | Lab Code | Date | H-3 (pCi/L) |
|-----------|----------|-------------|-----------|----------|-------------|
| D-130A | | | | | |
| DWW- 1241 | 03/19/15 | < 147 | | | |
| DWW- 3477 | 06/30/15 | < 155 | | | |
| DWW- 6810 | 11/12/15 | < 146 | | | |
| DWW- 7218 | 12/16/15 | < 144 | | | |
| D-130B | | | | | |
| DWW- 1242 | 03/19/15 | < 147 | DWW- 7219 | 12/17/15 | < 144 |
| DWW- 3478 | 06/30/15 | < 155 | | | |
| DWW- 6811 | 11/12/15 | < 146 | | | |
| D-131A | | | | | |
| DWW- 1243 | 03/18/15 | 184 ± 81 | | | |
| DWW- 3479 | 06/30/15 | < 155 | | | |
| DWW- 6927 | 11/30/15 | 1045 ± 117 | | | |
| DWW- 177 | 12/31/15 | 534 ± 96 | | | |
| D-131B | | | | | |
| DWW- 1244 | 03/18/15 | < 147 | DWW- 6928 | 11/30/15 | < 145 |
| DWW- 3480 | 06/30/15 | < 155 | DWW- 178 | 12/31/15 | < 142 |
| D-132A | | | | | |
| DWW- 1245 | 03/18/15 | 222 ± 83 | | | |
| DWW- 3481 | 06/30/15 | < 155 | | | |
| DWW- 6929 | 11/30/15 | < 145 | | | |
| DWW- 180 | 12/31/15 | < 142 | | | |
| D-132B | | | | | |
| DWW- 1246 | 03/18/15 | < 147 | DWW- 6930 | 11/30/15 | < 145 |
| DWW- 3482 | 06/30/15 | < 155 | DWW- 181 | 12/31/15 | < 142 |
| D-133A | | | | | |
| DWW- 6931 | 12/02/15 | < 145 | | | |
| DWW- 182 | 12/31/15 | < 142 | | | |
| D-133B | | | | | |
| DWW- 6932 | 12/02/15 | < 145 | | | |
| DWW- 183 | 12/31/15 | < 142 | | | |
| D-134A | | | | | |
| DWW- 6812 | 11/12/15 | < 146 | | | |
| DWW- 7220 | 12/18/15 | 200 ± 82 | | | |
| D-134B | | | | | |
| DWW- 6813 | 11/12/15 | 1042 ± 115 | | | |
| DWW- 7221 | 12/18/15 | 1089 ± 118 | | | |
| D-135A | | | | | |
| DWW- 6969 | 10/20/15 | < 146 | | | |
| DWW- 184 | 12/31/15 | < 142 | | | |
| D-136B | | | | | |
| DWW- 6970 | 11/30/15 | < 145 | | | |
| DWW- 185 | 12/31/15 | < 142 | | | |

^a Analyses for gamma, gross alpha, Sr-89, Sr-90, Fe-55 and Ni-63 will be performed if tritium activity > 1K pCi/L .

DUANE ARNOLD ENERGY CENTER
 2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT
 ATTACHMENT 1A: GROUND WATER PROTECTION PROGRAM RESULTS-OFFSITE LAB

Ground water, Monitoring wells, analyses for tritium ^a.

| Lab Code | Date | H-3 (pCi/L) | Lab Code | Date | H-3 (pCi/L) |
|--------------------------------------|----------|-------------|----------|------|-------------|
| | | D-136A | | | (16A) |
| DWW- 7222 | 12/18/15 | < 144 | | | |
| | | D-136B | | | (16B) |
| DWW- 7223 | 12/19/15 | < 144 | | | |
| | | D-137 | | | (17C) |
| DWW- 186 | 12/19/15 | < 143 | | | |
| <hr/> | | | | | |
| Surface water, analysis for tritium. | | | | | |
| | | D-119 | | | |
| DSW- 6971 | 11/10/15 | 555 ± 99 | | | |
| | | D-122 | | | |
| DSW- 6968 | 11/10/15 | < 146 | | | |
| | | D-124 | | | |
| DSW- 6967 | 11/10/15 | < 146 | | | |
| | | MH--213 | | | |
| DSW- 6966 | 10/07/15 | < 146 | | | |

^a Analyses for gamma, gross alpha, Sr-89, Sr-90, Fe-55 and Ni-63 will be performed if tritium activity > 1K pCi/L.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT
ATTACHMENT 1A: GROUND WATER PROTECTION PROGRAM RESULTS-OFFSITE LAB

Monitoring wells, analyses for gamma-emitting isotopes.

| Lab Code | Date | Collection | | | | | | | | | | |
|------------------------|------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|-------------------|-------------------|-------------------|---------------------|
| | | ⁵⁴ Mn | ⁵⁹ Fe | ⁵⁸ Co | ⁶⁰ Co | ⁶⁵ Zn | ⁹⁵ Nb | ⁹⁵ Zr | ¹³⁴ Cs | ¹³⁷ Cs | ¹⁴⁰ Ba | ¹⁴⁰ La |
| D-131A (MW-11A) | | | | | | | | | | | | |
| DWW- 6927 | 11/30/2015 | < 1.1 | < 2.4 | < 1.4 | < 1.3 | < 1.8 | < 2.3 | < 1.9 | < 1.1 | < 1.2 | < 28.3 | < 4.8 |
| D-127A (MW-07A) | | | | | | | | | | | | |
| DWW- 497 | 1/30/2015 | < 2.2 | < 2.9 | < 2.5 | < 1.7 | < 4.1 | < 3.3 | < 4.1 | < 2.2 | < 2.6 | < 14.6 | < 3.9 |
| DWW- 646 | 2/13/2015 | < 2.0 | < 3.8 | < 2.0 | < 2.0 | < 3.2 | < 3.5 | < 2.6 | < 3.0 | < 2.2 | < 27.3 | < 3.6 |
| DWW- 1892 | 3/19/2015 | < 2.9 | < 10.6 | < 3.0 | < 2.8 | < 5.5 | < 4.3 | < 7.4 | < 2.9 | < 2.6 | < 111.4 | < 24.0 ^a |
| DWW- 2359 | 4/28/2015 | < 2.0 | < 6.6 | < 3.3 | < 1.9 | < 4.5 | < 4.8 | < 5.2 | < 2.4 | < 2.4 | < 96.0 | < 31.2 ^a |
| DWW- 3631 | 6/30/2015 | < 2.4 | < 6.4 | < 2.5 | < 3.0 | < 5.8 | < 4.0 | < 5.1 | < 2.6 | < 2.6 | < 32.2 | < 5.2 |
| DWW- 4603 | 7/29/2015 | < 2.5 | < 6.8 | < 3.6 | < 2.4 | < 4.6 | < 5.4 | < 6.7 | < 3.2 | < 2.4 | < 68.4 | < 12.8 ^b |
| DWW- 4612 | 8/19/2015 | < 1.8 | < 3.6 | < 1.9 | < 1.5 | < 2.5 | < 2.2 | < 2.9 | < 1.4 | < 1.3 | < 15.6 | < 4.4 |
| DWW- 5769 | 10/6/2015 | < 2.0 | < 7.1 | < 2.8 | < 2.8 | < 5.2 | < 3.9 | < 5.0 | < 2.6 | < 3.2 | < 20.5 | < 6.2 |
| DWW- 7113 | 12/11/2015 | < 3.1 | < 7.3 | < 2.7 | < 2.7 | < 5.4 | < 5.5 | < 4.3 | < 2.5 | < 3.1 | < 47.9 | < 5.2 |
| D-128B (MW-08B) | | | | | | | | | | | | |
| DWW- 647 | 2/13/2015 | < 1.7 | < 3.4 | < 1.5 | < 2.1 | < 1.3 | < 3.0 | < 5.6 | < 2.1 | < 2.7 | < 17.7 | < 3.3 |
| DWW- 1893 | 3/19/2015 | < 3.0 | < 11.1 | < 4.2 | < 2.8 | < 6.5 | < 7.2 | < 5.3 | < 3.0 | < 3.5 | < 96.2 | < 31.0 ^a |
| DWW- 2348 | 4/28/2015 | < 1.1 | < 3.6 | < 1.4 | < 1.0 | < 2.4 | < 2.5 | < 2.9 | < 1.1 | < 0.8 | < 50.6 | < 11.5 |
| DWW- 4604 | 7/29/2015 | < 2.9 | < 7.6 | < 2.7 | < 2.9 | < 6.0 | < 4.4 | < 6.6 | < 3.1 | < 3.2 | < 79.2 | < 10.9 ^b |
| DWW- 7216 | 12/18/2015 | < 2.0 | < 6.2 | < 2.1 | < 2.6 | < 5.1 | < 4.0 | < 8.2 | < 2.9 | < 3.3 | < 43.6 | < 7.4 |

^a LLDs for Ba/La-140 not reached due to small sample size.

^b LLD for Ba-140 not reached due to small sample size.

DUANE ARNOLD ENERGY CENTER
2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT
ATTACHMENT 1A: GROUND WATER PROTECTION PROGRAM RESULTS-OFFSITE LAB

Monitoring wells, analyses for gamma-emitting isotopes.

| Lab Code | Date | Collection | | | | | | | | | | | |
|------------------------|------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|-------------------|-------------------|-------------------|---------------------|--|
| | | ⁵⁴ Mn | ⁵⁹ Fe | ⁵⁸ Co | ⁶⁰ Co | ⁶⁵ Zn | ⁹⁵ Nb | ⁹⁵ Zr | ¹³⁴ Cs | ¹³⁷ Cs | ¹⁴⁰ Ba | ¹⁴⁰ La | |
| D-129A (MW-09A) | | | | | | | | | | | | | |
| DWW- 498 | 1/30/2015 | < 2.4 | < 2.4 | < 2.6 | < 1.4 | < 4.6 | < 2.9 | < 4.6 | < 2.1 | < 2.4 | < 13.2 | < 3.3 | |
| DWW- 648 | 2/13/2015 | < 2.7 | < 5.0 | < 3.2 | < 2.4 | < 3.9 | < 2.9 | < 4.8 | < 2.4 | < 2.9 | < 19.3 | < 4.9 | |
| DWW- 1894 | 3/19/2015 | < 2.1 | < 9.3 | < 3.5 | < 3.1 | < 6.1 | < 5.3 | < 6.3 | < 2.7 | < 2.6 | < 106.0 | < 39.8 ^a | |
| DWW- 2026 | 4/28/2015 | < 2.8 | < 3.8 | < 2.3 | < 2.5 | < 5.6 | < 3.1 | < 5.3 | < 2.7 | < 3.4 | < 12.2 | < 4.5 ^b | |
| DWW- 2360 | 5/7/2015 | < 3.2 | < 7.8 | < 3.4 | < 2.0 | < 4.7 | < 5.8 | < 3.9 | < 2.8 | < 2.4 | < 60.8 | < 12.7 ^c | |
| DWW- 2591 | 5/14/2015 | < 3.3 | < 8.9 | < 2.1 | < 2.5 | < 4.0 | < 6.3 | < 7.3 | < 3.2 | < 3.4 | < 37.7 | < 4.6 | |
| DWW- 2592 | 5/22/2015 | < 2.6 | < 7.4 | < 2.7 | < 2.4 | < 5.0 | < 3.6 | < 5.7 | < 3.0 | < 3.3 | < 31.2 | < 7.4 | |
| DWW- 3055 | 5/28/2015 | < 3.4 | < 6.1 | < 3.7 | < 2.0 | < 5.6 | < 3.5 | < 3.3 | < 2.7 | < 2.5 | < 41.7 | < 10.5 | |
| DWW- 3056 | 6/12/2015 | < 2.3 | < 4.2 | < 1.7 | < 2.4 | < 4.3 | < 3.5 | < 4.1 | < 2.6 | < 2.6 | < 16.3 | < 3.6 | |
| DWW- 3632 | 7/6/2015 | < 3.7 | < 5.2 | < 3.7 | < 2.2 | < 4.9 | < 3.7 | < 5.3 | < 2.9 | < 3.4 | < 21.8 | < 4.4 | |
| DWW- 4613 | 7/21/2015 | < 1.7 | < 5.6 | < 2.0 | < 1.8 | < 3.0 | < 3.1 | < 3.2 | < 1.4 | < 1.8 | < 56.7 | < 20.9 | |
| DWW- 6808 | 11/12/2015 | < 1.0 | < 4.9 | < 1.3 | < 1.3 | < 1.9 | < 4.1 | < 3.1 | < 1.4 | < 1.3 | < 74.4 | < 16.3 ^d | |
| D-129B (MW-09B) | | | | | | | | | | | | | |
| DWW- 488 | 1/30/2015 | < 2.0 | < 4.3 | < 2.3 | < 3.3 | < 3.4 | < 3.6 | < 4.0 | < 2.9 | < 3.0 | < 14.8 | < 3.0 | |
| DWW- 1240 | 3/19/2015 | < 0.9 | < 2.0 | < 1.2 | < 1.0 | < 2.4 | < 2.0 | < 2.2 | < 1.3 | < 1.0 | < 14.5 | < 5.0 | |
| D-134B (MW-14B) | | | | | | | | | | | | | |
| DWW- 6813 | 11/12/2015 | < 1.3 | < 5.3 | < 1.8 | < 1.2 | < 2.4 | < 3.4 | < 3.7 | < 1.3 | < 1.0 | < 107.4 | < 16.2 ^d | |
| DWW- 7221 | 12/18/2015 | < 2.0 | < 6.3 | < 2.4 | < 3.1 | < 4.4 | < 3.2 | < 5.7 | < 2.9 | < 2.9 | < 34.4 | < 9.9 | |

^a LLDs for Ba/La-140 not reached due to small sample size.

^b I-131 = 5.1 pCi/L (result requested by client).

^c LLDs for Ba-140 not reached due to small sample size.

^d LLDS for Ba/La-140 not reached due to age of sample; counted 01-12-16.

DUANE ARNOLD ENERGY CENTER
 2015 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT
 ATTACHMENT 1A: GROUND WATER PROTECTION PROGRAM RESULTS-OFFSITE LAB

Monitoring wells, conditional analyses for gross alpha, iron-55, nickel-63, strontium-89 and strontium-90^a.

| Lab Code | Date | Collection | | | | | |
|-----------|------------|-------------|------------------|------------------|------------------|------------------|-------|
| | | Gross Alpha | ⁵⁵ Fe | ⁶³ Ni | ⁸⁹ Sr | ⁹⁰ Sr | |
| DWW- 488 | 1/30/2015 | d-129b | < 1.2 | < 672 | < 109 | < 0.8 | < 0.7 |
| DWW- 497 | 1/30/2015 | d-127a | < 1.1 | < 620 | < 145 | < 1.3 | < 1.1 |
| DWW- 498 | 1/30/2015 | d-129a | < 1.1 | < 642 | < 132 | < 1.3 | < 1.3 |
| DWW- 646 | 2/13/2015 | d-127a | < 0.9 | < 671 | < 129 | < 0.7 | < 0.5 |
| DWW- 647 | 2/13/2015 | d-128b | < 1.1 | < 654 | < 150 | < 0.7 | < 0.5 |
| DWW- 648 | 2/13/2015 | d-129a | 1.2 ± 0.9 | < 675 | < 141 | < 0.6 | < 0.5 |
| DWW- 1240 | 3/19/2015 | d-129b | < 1.3 | < 642 | < 105 | < 0.7 | < 0.5 |
| DWW- 1892 | 3/19/2015 | d-127a | < 0.8 | < 673 | < 115 | < 2.0 | < 1.0 |
| DWW- 1893 | 3/19/2015 | d-128b | < 1.0 | < 694 | < 97 | < 2.2 | < 1.2 |
| DWW- 1894 | 3/19/2015 | d-129a | 1.6 ± 0.8 | < 694 | < 105 | < 1.8 | < 1.0 |
| DWW- 2026 | 4/28/2015 | d-129a | b | < 632 | < 139 | < 1.3 | < 1.7 |
| DWW- 2348 | 4/28/2015 | d-128b | < 1.1 | < 723 | < 167 | < 1.4 | < 0.5 |
| DWW- 2359 | 4/28/2015 | d-127a | 0.9 ± 0.7 | < 754 | < 171 | < 2.8 | < 1.0 |
| DWW- 2360 | 5/7/2015 | d-129a | 1.4 ± 0.7 | < 740 | < 146 | < 2.3 | < 1.0 |
| DWW- 2591 | 5/14/2015 | d-129a | < 0.9 | < 750 | < 149 | < 1.8 | < 0.9 |
| DWW- 2592 | 5/22/2015 | d-129a | 1.1 ± 0.7 | < 746 | < 149 | < 1.6 | < 1.0 |
| DWW- 3055 | 5/28/2015 | d-129a | 1.5 < 0.9 | < 762 | < 85 | < 2.4 | < 1.5 |
| DWW- 3056 | 6/12/2015 | d-129a | < 1.1 | < 769 | < 88 | < 1.5 | < 1.0 |
| DWW- 3631 | 6/30/2015 | d-127a | 1.1 ± 0.7 | < 716 | < 77 | < 1.5 | < 0.9 |
| DWW- 3632 | 7/6/2015 | d-129a | < 1.0 | < 753 | < 88 | < 1.9 | < 1.3 |
| DWW- 4603 | 7/29/2015 | d-127a | < 1.4 | < 714 | < 108 | < 1.9 | < 1.0 |
| DWW- 4604 | 7/29/2015 | d-128b | < 1.8 | < 742 | < 108 | < 1.8 | < 1.0 |
| DWW- 4612 | 8/19/2015 | d-127a | < 1.4 | < 704 | < 111 | < 0.6 | < 0.5 |
| DWW- 4613 | 7/21/2015 | d-129a | < 1.7 | < 713 | < 107 | < 1.3 | < 0.7 |
| DWW- 5769 | 10/6/2015 | d-127a | < 0.8 | < 694 | < 130 | < 1.1 | < 1.2 |
| DWW- 6808 | 11/12/2015 | d-129a | < 0.9 | < 776 | < 121 | < 1.2 | < 0.6 |
| DWW- 6813 | 11/12/2015 | d-134b | 2.0 ± 0.9 | < 781 | < 104 | < 1.0 | < 0.5 |
| DWW- 6927 | 11/30/2015 | d-131a | 1.5 ± 0.8 | < 757 | < 115 | < 0.8 | < 0.5 |
| DWW- 7113 | 12/11/2015 | d-127a | < 1.0 | < 747 | < 102 | < 1.8 | < 1.2 |
| DWW- 7216 | 12/18/2015 | d-128b | < 1.7 | < 759 | < 104 | < 0.9 | < 0.6 |
| DWW- 7221 | 12/18/2015 | d-134b | < 1.8 | < 777 | < 99 | < 0.6 | < 0.5 |

^a Analyses for gamma, gross alpha, Sr-89, Sr-90, Fe-55 and Ni-63 will be performed if tritium activity > 1K pCi/L.

^b Gross alpha analysis not requested on this sample.

Offsite Dose Assessment Manual

Revision 35

TABLE OF CONTENTS

| Section | Title | Page |
|----------------|--|-------------|
| 1.0 | INTRODUCTION | 5 |
| 2.0 | LIQUID EFFLUENT | 6 |
| 2.1 | Radioactivity In Liquid Waste | 6 |
| 2.2 | Aqueous Concentration | 6 |
| 2.3 | Basis of Mixing Ratios | 7 |
| 2.4 | Method of Establishing Alarm Setpoints | 7 |
| 2.4.1 | Setpoint for a Batch Release | 8 |
| 2.4.2 | Setpoint for a Continuous Release | 10 |
| 2.5 | Radioactivity Concentration in Water at the Restricted Area Boundary | 11 |
| 2.6 | Accumulated Personal Maximum Dose | 11 |
| 2.7 | Projected Dose to a Person Offsite | 13 |
| 2.8 | Groundwater Pathway | 14 |
| 3.0 | GASEOUS EFFLUENT | 16 |
| 3.1 | Introduction | 16 |
| 3.2 | Radioactivity in Gaseous Effluent | 16 |
| 3.3 | Main Condenser Offgas Pretreatment Monitor Alarm Setpoint | 17 |
| 3.4 | Effluent Noble Gas Monitor Alarm Setpoint | 19 |
| 3.5 | Dose Equivalent Rate Offsite | 22 |
| 3.5.1 | Noble Gas | 22 |
| 3.5.1.1 | Total Body Dose Rate | 22 |
| 3.5.1.2 | Skin Dose Rate | 23 |
| 3.5.2 | Iodine, Tritium, and Particulates | 25 |
| 3.5.2.1 | Organ Dose Rate | 25 |
| 3.5.2.2 | Rainwater Recapture of Tritium | 27 |
| 3.6 | Noble Gas Gamma Radiation Dose Accumulated in Air | 27 |
| 3.6.1 | Alternate Method of Evaluating Compliance with Gamma Air Dose Limits | 28 |
| 3.7 | Noble Gas Beta Radiation Dose Accumulated in Air | 30 |
| 3.8 | Dose Due to Iodine and Particulates in Gaseous Effluents | 30 |
| 3.8.1 | Alternate Method of Evaluating Doses Due to Iodine and Particulates in Gaseous Effluents | 34 |
| 3.9 | Dose to a Person from Noble Gases | 35 |
| 3.9.1 | Gamma Dose to Total Body | 35 |
| 3.9.2 | Dose to Skin | 36 |
| 4.0 | DOSE COMMITMENT FROM RELEASE OVER EXTENDED TIME | 45 |
| 4.1 | Dose Assessment for 10 CFR Part 50, Appendix I | 45 |
| 4.2 | Dose Assessment for 40 CFR Part 190 | 46 |
| 5.0 | ENVIRONMENTAL MONITORING PROGRAMS | 48 |
| 5.1 | Radiological Environmental Monitoring Program (REMP) | 48 |
| 5.2 | Ground Water Protection Program (GWPP) | 48 |
| 5.3 | Sampling Station Locations | 49 |

continued

TABLE OF CONTENTS

| Section | Title | Page |
|-----------------|---|-------------|
| 6.0 | RADIOLOGICAL EFFLUENT CONTROLS AND SURVEILLANCE REQUIREMENTS | 58 |
| 6.0.1 | Use and Application | 58 |
| 6.0.1.1 | Definitions | 58 |
| 6.0.1.2 | Logical Connectors | 60 |
| 6.0.1.3 | Completion Times | 61 |
| 6.0.1.4 | Frequency | 63 |
| 6.0.2 | (not used) | |
| 6.0.3 | Limiting Conditions for Operation Applicability | 64 |
| 7.0.3 | Surveillance Requirement Applicability | 66 |
| 6/7.1 | Radioactive Liquid Effluent Controls and Surveillance Requirements | 67 |
| 6.1.1 | Radioactive Liquid Effluent Instrumentation | 67 |
| 6.1.2 | Liquid Effluent Concentration | 77 |
| 6.1.3 | Dose Due to Radioactive Effluents | 76 |
| 6.1.4 | Liquid Waste Treatment | 78 |
| 6.1.5 | Liquid Holdup Tanks | 80 |
| 6/7.2 | Radioactive Gaseous Effluent Controls and Surveillance Requirements | 82 |
| 6.2.1.1 | Radioactive Gaseous Effluent Instrumentation | 84 |
| 6.2.1.2 | Offgas Radioactive Gaseous Effluent Instrumentation | 87 |
| 6.2.2 | Gaseous Effluent Dose Rate | 91 |
| 6.2.3 | Doses Due to Noble Gases | 96 |
| 6.2.4 | Doses Due to Iodine and Particulates in Air | 98 |
| 6.2.5 | Gaseous Radwaste Treatment | 100 |
| 6.2.6 | Mechanical Vacuum Pump Radiation Release Rate | 102 |
| 6/7.3 | Offsite Dose Assessment Controls and Surveillance Requirements | 104 |
| 6.3.1 | Dose | 104 |
| 6.3.2 | Radiological Environmental Monitoring Program | 106 |
| BASES | | |
| 6.1.1 and 7.1.1 | BASES | 113 |
| 6.1.2 and 7.1.2 | BASES | 114 |
| 6.1.3 and 7.1.3 | BASES | 115 |
| 6.1.4 and 7.1.4 | BASES | 115 |
| 6.1.5 and 7.1.5 | BASES | 117 |
| 6.2.1 and 7.2.1 | BASES | 118 |
| 6.2.2 and 7.2.2 | BASES | 119 |
| 6.2.3 and 7.2.3 | BASES | 120 |
| 6.2.4 and 7.2.4 | BASES | 120 |
| 6.2.5 and 7.2.5 | BASES | 120 |
| 6.3.1 and 7.3.1 | BASES | 121 |
| 6.3.2 and 7.3.2 | BASES | 121 |

continued

TABLE OF CONTENTS

| Section | Title | Page |
|---|---|------|
| 8.0 | ADMINISTRATIVE CONTROLS | 122 |
| 8.1 | Programs and Manuals | 122 |
| 8.1.1 | Radioactive Effluent Controls Program | 122 |
| 8.1.2 | The Radiological Environmental Monitoring Program | 123 |
| 8.1.3 | Interlaboratory Comparison Program | 123 |
| 8.2 | Reporting Requirements | 124 |
| 8.2.1 | Annual Radioactive Material Release Report | 124 |
| 8.2.2 | Annual Radiological Environmental Report | 127 |
| 8.2.3 | Special Reports | 128 |
| APPENDIX A: DOSE TRANSFER FACTORS FOR AIRBORNE PATHWAYS | | A-1 |
| APPENDIX B: TECHNICAL BASES FOR EFFECTIVE DOSE FACTORS | | B-1 |
| APPENDIX C: DOSE TRANSFER FOR WATERBORNE PATHWAYS | | C-1 |

OFFSITE DOSE ASSESSMENT MANUAL FOR GASEOUS AND LIQUID EFFLUENTS

1.0 INTRODUCTION

This manual provides a description of the facility's Offsite Dose Assessment Program, the Radiological Effluents Controls Program and the Radiological Environmental Monitoring Program.

EFFLUENTS CONTROLS PROGRAM

This program, conforming to 10 CFR 50.36a, provides for the control of radioactive effluents and for maintaining the doses to members of the public from radioactive effluents as low as reasonably achievable. The program is contained in sections six and seven of the ODAM, is implemented by procedures, and includes remedial actions to be taken whenever the program limits are exceeded.

Section eight of the ODAM includes the requirement for the Annual Radioactive Material Release Report. The Radioactive Material Release Report covers the operation of the unit during the previous calendar year shall be submitted prior to May 1 of each year in accordance with 10 CFR 50.36a. The report includes a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit. The material provided in the report is consistent with the objectives outlined in the ODAM and Process Control Program and in conformance with 10 CFR 50.36a and 10 CFR Part 50, Appendix I, Section IV.B.1.

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

The Radiological Environmental Monitoring Program (REMP) provides for representative measurements of radioactivity in the highest potential exposure pathways, verification of the accuracy of the effluent monitoring program and modeling of environmental exposure pathways. Additionally, the REMP is designed to demonstrate that radioactive effluents from DAEC are ALARA.

The program is described in sections five, six and seven of the ODAM and conforms to the guidance of Appendix I to 10 CFR Part 50 and 10 CFR 72. Section eight of the ODAM includes the requirement for the Annual Radiological Environmental Operating Report. The Annual Radiological Environmental Operating Report covers the operation of the unit during the previous calendar year and is submitted by May 15 of each year. The report includes summaries, interpretations, and analyses of trends of the results of the Radiological Environmental Monitoring Program for the reporting period. The material provided is consistent with the objectives outlined in the Offsite Dose Assessment Manual (ODAM), and in 10 CFR 50, Appendix I, Sections IV.B.2, IV.B.3, and IV.C.

OFFSITE DOSE ASSESSMENT PROGRAM

The methodology and parameters used in the calculation of offsite doses resulting from radioactive gaseous and liquid effluents are included in sections two, three and four of the ODAM. These chapters describe acceptable methods of calculating radioactivity concentrations in the environment and the potentially resultant committed doses to a member of the public in the unrestricted area^a that are associated with LWR liquid and gaseous effluents.

^a Unrestricted area means outside of the boundary of property owned, leased, or controlled by the Company on which DAEC is sited. The DAEC site boundary is identified by UFSAR Figure 1.2-1.

The methodology stated in this Manual is acceptable for use in demonstrating operational compliance with 10 CFR 20.1301, 10 CFR 50 Appendix I, 10 CFR 72.104, and 40 CFR 190. Only the dose attributable to the Duane Arnold Energy Center^b is considered in demonstrating compliance with 40 CFR 190 since no other nuclear facility exists within 50 miles of the Center.

Calculations are made monthly to assess the potential air doses offsite and to a nearby resident in order to guide the management of station effluents. The receptor is described such that the dose to any resident near the Station is unlikely to be underestimated. Calculations made to assess the radioactive noble gas dose to air are based on the location offsite that could be occupied by a person where the maximum air dose is expected. For these monthly-accumulated dose calculations, atmospheric dispersion and deposition of gaseous effluents may be based on reference meteorological conditions.^c More conservative conditions (i.e., location and/or exposure pathways expected to yield higher computed doses) than appropriate for the maximally exposed person may be assumed in the dose estimated.

Calculations of dose committed from radioactive releases over extended time (3 and 12 months) are also made for the purpose of verifying compliance with regulatory limits on offsite dose. For these calculations the receptor is selected on the basis of the combination of applicable exposure pathways identified in the land use census and the maximum ground level γ/Q at a residence, or on the basis of more conservative conditions such that the dose to any resident near the Station is unlikely to be underestimated.

2.0 LIQUID EFFLUENT

2.1 Radioactivity In Liquid Waste

The concentration of radionuclides in liquid waste is determined by sampling and analysis in accord with the surveillance requirements of Section 7.1.2, Table 7.1-2. When a radionuclide is identified, it is reported as being present in the sample even if the concentration is below the required LLD for the analysis.

2.2 Aqueous Concentration

Radioactive material in liquid effluent is diluted successively by water flowing in the discharge pipe and in the River. The diluted concentration of radionuclide *i* in a receiving stream is estimated with the equation

$$C_{zi} = C_i \frac{F_1}{F_2}$$

where

- C_i = concentration of radionuclide *i* in liquid radwaste released ($\mu\text{Ci/mL}$)
 C_{zi} = concentration of radionuclide *i* in the receiving stream ($\mu\text{Ci/mL}$)
 F_1 = release rate of liquid radwaste (mL/sec)^d
 F_2 = dilution flow of receiving stream of water (mL/sec)^d

For the purpose of calculating the radioactivity concentration in water at the restricted area boundary (section 2.5), the flow in the discharge pipe, F_c , is assigned to F_2 . The

^b The Duane Arnold Energy Center, also referred to henceforth as the Station, is defined as including BOTH the Nuclear Reactor Facility and the Independent Spent Fuel Storage Installation (ISFSI).

^c Reference meteorological conditions are 1971, 1974 and 1975 data composited as discussed in "Duane Arnold Energy Center, Evaluation of Liquid and Gaseous Effluent Releases in Accordance With 10 CFR 50 Appendix I," submitted to the NRC June 3, 1976.

^d F_1 , F_2 , and F_c may have any convenient units of flow (i.e., volume/time) provided the units of all are identical.

water flow in the discharge pipe may include the liquid waste effluent flow, the liquid radwaste dilution water flow, the cooling tower blowdown flow and other streams such as RHR and emergency service water discharged via the dilution structure and discharge pipe. These streams are illustrated in Figure 2-1.

In the River immediately beyond the discharge pipe and the restricted area boundary, the effective dilution is

$$F_2 = F_c \times M$$

Where

F_c = discharge pipe flow

M = factor of additional mixing in the River

A near field mixing ratio from the pipe into the near field of the River, $M = 5$, is assigned when estimating maximum potential individual doses involving exposure by eating fish or from consuming irrigated foods. In the event water is drawn from the River downstream of the Station for drinking water or another exposure pathway, F_2 represents the portion of the River flow into which the liquid effluent from the Station is effectively mixed.

2.3 Basis of Mixing Ratios

Downstream dilution of aqueous discharge from the DAEC has been estimated based on thermal plume studies conducted in 1974 at the DAEC.^e Measurements of the discharge temperature and river temperature indicated that the 1°F excess temperature isotherm was about 350 feet downstream of the discharge. This 1°F isotherm represented a dilution of the discharge by the Cedar River of about a factor of 12.

In determining additional dilution within the receiving water for evaluating doses from a plant with cooling towers, the NRC guideline^f is that the factor should be limited to a number such that the product of the number and the average blowdown flow to the receiving water body is 1000 cfs or less. At the DAEC, the discharge rate can be conservatively approximated by a cooling tower blowdown rate of 4000 gpm, or about 9 cfs. Using the NRC guideline, an additional dilution of 100 in the Cedar River could be assumed for evaluating doses due to liquid effluent. Since the average flow in the Cedar River is about 3065 cfs, the additional dilution in the River is achievable.

These results indicate both a dilution factor of 12 at a downstream distance of 350 feet and conformance to the NRC guideline.

Land Use Censuses have shown that the nearest use of river water for irrigation is 2.3 miles downstream and the nearest use of river water (from alluvial wells) is more than 6 miles downstream for the City of Cedar Rapids.

For the sake of simplification and conservatism in routine liquid dose calculations, a dilution factor of 5 is assumed for fish and irrigation pathways and a dilution factor of 10 is assumed for drinking water for the evaluation of doses during DAEC operation.

2.4 Method of Establishing Alarm Setpoints

The liquid radwaste effluent line has a monitor which provides automatic isolation when 10 times the water effluent concentration listed in 10 CFR 20 Appendix B, Table 2, is

^e IELP, Cedar River Baseline Ecological Study, DAEC, annual report, Jan. 1974-Jan.1975.

^f Boegli, J.S., et. al., Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants, NUREG-0133, p. 16, October, 1978

being exceeded in the unrestricted area. The other liquid effluent pathways have monitors which provide alarms when 10 times the 10 CFR 20 water effluent concentration is being exceeded in the unrestricted area. Given the nature and frequency of discharges, prompt action to reduce radioactive releases following an alarm, will assure the requirements of 10 CFR Part 20, 1301; 10 CFR Part 50 Appendix I, Section IV; and 40 CFR Part 190 are not exceeded.

The alarm setpoint for the liquid effluent radiation monitor is derived from the concentration limit provided in 10 CFR Part 20.1001-20.2402 Appendix B Table 2 Column 2 applied at the unrestricted area boundary where the discharge pipe flows into the river. The alarm setpoint does not consider dilution, dispersion, or decay of radioactive material beyond the site boundary. That is, the alarm setpoint is based on a concentration limit at the end of the discharge pipe. The radiation monitoring and isolation points are located in each line through which radioactive waste effluent is eventually discharged into the discharge pipe.

The alarm setpoint for effluent monitors on batch releases is based on measurements, according to Table 7.1-2. For liquids released in continuous aqueous discharge which are normally radioactively clean, the setpoint is based on the effective Water Effluent Concentration (WEC) for the most likely contaminating source, i.e., the primary coolant water. A measured spectrum from the primary coolant water is used to determine the effective WEC based on WEC fractions according to 10 CFR 20 Appendix B.

2.4.1 Setpoint for a Batch Release

A sample of each batch of liquid radwaste is analyzed for I-131 and other principal gamma emitters, or for total activity concentration prior to release. The ratio, FWEC_b, of the activity concentration in the tank to the unrestricted area WEC (10 CFR Part 20, Appendix B, Table 2, Column 2) is calculated with the equation

$$FWEC_b = \sum_i \frac{C_{bi}}{WEC_i}$$

where

$FWEC_b$ = fraction of unrestricted area WEC in batch derived from activity measured prior to release.

C_{bi} = concentration of radionuclide i (including I-131 and principal gamma emitters) in batch sample taken prior to release ($\mu\text{Ci/mL}$)

Whether radioiodine and primary gamma emitters are identified prior to a batch release or not, the liquid radwaste effluent line radiation monitor alarm setpoint is determined with the equation

$$S = 10 \times \left[\frac{A}{FWEC_b} \cdot \frac{F_{S_2}}{F_{S_1}} \cdot g \right] + Bkg$$

where

S = radiation monitor alarm setpoint (cpm)

10 = factor to account for fact that DAEC's instantaneous release limit is ten times the listed WECs

A = counting rate (cpm/mL) or activity concentration ($\mu\text{Ci/mL}$) of sample in laboratory analysis. A equals $\sum C_{bi}$ if an isotopic analysis were performed or C_b if a gross activity analysis was performed.

g = ratio of effluent radiation monitor counting rate to laboratory counting rate or activity concentration in a given batch of liquid (cpm per cpm/mL or cpm per $\mu\text{Ci/mL}$)

Bkg = monitoring instrument background (cpm)

F_{S_1} = flow in the batch release line (gal/min).^{*} Value not greater than the discharge line flow alarm maximum setpoint.

F_{S_2} = minimum flow in the discharge pipe (gal/min).^g Value not less than the discharge pipe flow alarm minimum setpoint.

^g Any suitable but identical units of flow (volume/time)

Note that $A/FWEC_b$ represents the counting rate of a solution having the same radionuclide distribution as the sample and having the water effluent concentration of that mixture.

2.4.2 Setpoint for a Continuous Release

Continuous aqueous discharges are sampled and analyzed according to the schedule in Table 7.1-2. The ratio, $FWEC_c$, of the activity concentration in each of the continuous release streams to the unrestricted area WEC is calculated with the equations

$$FWEC_c = \sum_i \frac{C_{ci}}{WEC_i}$$

where

$FWEC_c$ = fraction of unrestricted area WEC in continuous release based upon activity measured in primary coolant sample(s)

C_{ci} = concentration of radionuclide i in sample(s) ($\mu\text{Ci/mL}$)

The alarm setpoint of the radiation monitor on a continuous radioactive discharge line is determined with the equation

$$S = 10 x \left[\frac{A}{FWEC_c} \cdot \frac{F_{S_2}}{F_{S_1}} \cdot g \right] + Bkg$$

where

10 = factor to account for fact that DAEC's instantaneous release limit is ten times the listed WECs

A = activity concentration ($\mu\text{Ci/mL}$) or counting rate (cpm/mL) in laboratory of monthly reactor primary coolant sample.

F_{S_1} = Flow in the liquid discharge line (mL/sec).^h Value not greater than off discharge line flow alarm maximum setpoint.

F_{S_2} = flow in the discharge pipe (mL/sec).^h Value not less than discharge pipe flow alarm minimum setpoint.

g = ratio of effluent radiation monitor counting rate to laboratory counting rate or activity concentration in a given batch of liquid (cpm per cpm/mL or $\text{cpm per } \mu\text{Ci/mL}$)

^h Any suitable but identical units of flow (volume/time)

The radioactivity concentration in continuous aqueous effluent is usually so low that measurement of a representative radionuclide in a sample of the water is uncertain. Thus, the ratio, A/FWEC_c, which represents the WEC of a given spectrum of radionuclides, is usually derived from reactor primary coolant analysis(es). Alternatively, it may be determined from analyses of the continuous effluent itself.

In the event the concentration of radioactive material in the sample from the continuous release is below measurable levels (i.e., less than the lower limit of detection), the value of 1×10^{-8} $\mu\text{Ci/mL}$ or the equivalent counting rate (cpm/mL) may be substituted for the factor

$$\frac{A}{FWEC_c} \text{ (i.e., } \frac{A}{FWEC_c} = 1 \cdot 10^{-8}).$$

2.5 Radioactivity Concentration in Water at the Restricted Area Boundary

Section 6.1.2 provides limits on instantaneous radioactivity concentration in the unrestricted area due to aqueous effluents from DAEC. Compliance is assessed by monitoring, sampling, analyzing and establishing setpoints according to Section 7.1.2. As long as a liquid effluent monitor named in Table 6.1-1 does not exceed an alarm or trip setpoint, determined in accordance with section 2.3, or as long as the total or gross activity concentration, measured as required in Section 7.1.2, does not exceed 1×10^{-7} $\mu\text{Ci/mL}$ after dilution in the discharge pipe, Section 6.1.2 is satisfied.

In the event of an alarm, indicating concentrations in the unrestricted area in excess of section 6.1.2 limits, the release shall be terminated and dose calculations will be performed to assure the limits specified in sections 6.1.3 and 6.3.1 are not exceeded.

Compliance with 10 CFR 20.1301 shall not be demonstrated on the basis of determining the average annual liquid effluent concentration. But rather by demonstrating compliance with 40 CFR 190 (i.e., section 6.3.1). Such a practice was deemed acceptable by the NRC in their preamble to the revised 10 CFR 20.¹

2.6 Accumulated Personal Maximum Dose

Section 7.1.3 requires an assessment to be performed at least once every 30 days in any quarter in which radioactive effluent is discharged which determines whether the dose or dose commitment to a person offsite due to radioactive material released in liquid effluent calculated on a cumulative basis exceeds the limits of Section 6.1.3. The requirement is satisfied by computing the accumulated dose commitment to the most exposed organ and to the whole body of a hypothetical person exposed by eating fish or consuming irrigated strawberries and drinking water taken from the river offsite downstream of the discharge pipe.

The pathway(s) and or age group(s) selected may vary by season. For instance, fishing near the DAEC is practically non-existent during the winter; thus, a dose evaluation of the fish pathway is not required for aqueous effluent discharged during the winter months of January, February, or March.

The accumulated dose commitment is computed at least once every 30 days but may be computed as analyses become available.

Normally, DAEC employs the MIDAS computer program to calculate dose to a member of the public from aqueous effluent that uses the equations in Reg Guide 1.109¹ and

¹ Federal Register Volume 56, #98, Tuesday, May 21, 1991, p. 23360

USNRC, Regulatory Guide 1.109, revision 1, Position C.1, pp. 1.109-2 thru 1.109-4, Oct. 1977

DAEC ODAM

Page 11 of 277

Rev. 35 1/16

standard values therein for maximally exposed people. The amount of strawberries a person may eat is estimated to be one-half the amount of fresh leafy vegetable consumption. Alternatively, the amount of strawberries eaten may be assumed to equal the amount of fresh leafy vegetables eaten.

Alternatively, the dose may be calculated in the following way, for instance, in the event calculations by hand were necessary.

$$\Delta D_{ank} = 3.785 \cdot 10^{-3} \sum_i C_{ik} \cdot \Delta t_k \sum_e \frac{F1_k}{F2_{ek}} \cdot A_{eani}$$

$$D_{an} = \sum_k \Delta D_{ank}$$

where

ΔD_{ank} = the dose commitment (mrem) to organ n of age group a due to the isotopes identified in analysis k , where

the analyses are those required by Table 7.1-2. Thus the contribution to the dose from gamma emitters become available on a batch basis for batch releases and on a weekly basis for continuous releases. Similarly the contributions from H-3 is available on a monthly basis and the contributions from Fe-55, Sr-89, and Sr-90 become available on a quarterly basis.

D_{an} = the dose commitment during the quarter-to-date to organ n , including whole body, of the maximally exposed person in age group a (mrem)

A_{eani} = transfer factor relating a unit release of radionuclide i (Ci) in a unit stream flow (gal/min) to dose commitment to organ n , or whole body, of an exposed person in

age group a $\left[\frac{\text{mrem gal}}{\text{Ci min}} \right]$ via environmental pathway e .

C_{ik} = the concentration of radionuclide i in the undiluted liquid waste represented by sample k to be discharged ($\mu\text{Ci/mL}$)

Δt_k = duration of radioactive release represented by sample k which occurs within time boundaries TB and TE and during which concentration C_{ik} and flows $F1_k$ and $F2_k$ exist. (min.)

$3.785 \cdot 10^{-3}$ = conversion constant ($3785 \text{ mL/gal} \cdot 10^{-6} \text{ Ci}/\mu\text{Ci}$)

$F1_k$ = flow in the radioactive waste release line (gal/min) * represented by sample k .

$F2_{ke}$ = flow into which radioactive release represented by sample k is mixed in the river at the point of exposure or withdrawal of water for use (same units as $F1_k$)*

$$= M \times F_{ck}$$

where

F_{ck} = discharge pipe flow (gal/min)^k during release represented by sample *k*

M = factor of additional mixing in the river

Pathway-to-dose transfer factors, A_{eani} , for use in calculating the dose commitment arising from radioactive material released in aqueous effluents are tabulated in Appendix C. These dose transfer factors were derived using LADTAP II and standard values from Regulatory Guide 1.109, revision 1, except where corrections have been incorporated in LADTAP II. Appropriate tables representing applicable environmental pathways of exposure and most exposed age group(s) are selected and used in calculating the dose commitment. The pathway(s) and/or age group(s) selected may vary by season.

Pathways of Maximum Exposure to a Member of the Public:

- Ingestion of Fish taken from the river near the discharge pipe
 - Age Group: Adult
 - Dilution: $F_2 = 5F_c$
 - Food: Sport Fish
- Irrigated Food Pathway
 - Age Group: Teen
 - Dilution: $F_2 = 5F_c$
 - Food: Strawberries
- Drinking Water Pathway
 - Age Group: Infant
 - Dilution: $F_2 = 10F_c$
 - Dilution: $F_2 = 5F_c$ only when Land Use Census identifies this pathway within 3 miles of the plant

Variables F_1 , F_2 , and F_c are also defined in section 2.2.

2.7 Projected Maximum Dose to a Person Offsite

The dose commitment to a person offsite due to radioactive material released in liquid effluent may be projected by calculating the extrapolated whole body and most exposed organ dose commitments to a hypothetical person exposed via the same pathways evaluated in section 2.6. The potential dose commitments to organs and to the whole body are computed separately.

The dose commitment to a maximally exposed hypothetical person will be projected by calculating the doses accumulated during the most recent three months (according to the method described in section 2.6) and by assuming the result represents the projected doses during the current quarter. Alternatively, the quarterly dose commitment may be projected by using the equation:

$$P_{an} = \frac{92 D_{an}}{X}$$

where

^k Any suitable, identical units of flow (volume/time)


- P_{an} = projected dose commitment (mrem) to organ n (including whole body) of age group a for the current quarter
- 92 = number of days in a quarter
- X = number of days to date in current quarter
- D_{an} = dose commitment to organ n , including whole body, of the maximally exposed person in age group a based on available aqueous effluent measurements during the quarter to date (mrem)

2.8 Groundwater Pathway

Low levels of radioactive contamination have been identified in sub-surface water on site. There is the possibility that this water could represent potential exposure to the public. Hydrogeologic studies indicate that this water will migrate towards the river in sectors ranging from East-North-East to the South-South-West. The only potential exposure pathways are described in Section 2.6

To monitor for the migration of any radioactive contamination beyond the owner controlled area, sampling of on-site ground water, river water, and down gradient drinking water is performed as a function of the Radiological Environmental Monitoring Program (REMP) and the Ground Water Protection Program (GWPP). These programs are described in Section 5.0.

Figure 2-1
Duane Arnold Energy Center
Radioactive Water Effluent Diagram



3.0 GASEOUS EFFLUENT

3.1 Introduction

The Station discharges gaseous effluent through a stack and discharges ventilation air from the reactor and radwaste building through the reactor building vents. Ventilation air from the Turbine Building is discharged through the Turbine Building vent and through the Reactor Building vent. Ventilation from the LLRPSF is discharged through the LLRPSF vent. These gaseous effluent streams, radioactivity monitoring points, and effluent discharge points are shown schematically in Figure 3-1. Gaseous release point locations and elevations at the Station are described in Table 3-1. Gaseous discharges from the stack are treated as an elevated release while discharges via the building vents are assumed to be ground-level, building wake, or split wake releases.

3.2 Radioactivity in Gaseous Effluent

For the purpose of estimating offsite radionuclide concentrations and radiation doses, measured radionuclide concentrations in gaseous effluent and in ventilation air exhausted from the Station are relied upon.

The gross radioactivity of noble gases discharged is measured by the radioactive noble gas effluent monitors according to Tables 6.2-1 and 7.2-2. Radionuclides other than noble gases in gaseous effluents are measured by sampling and analyses in accordance with Table 7.2-2. Each radionuclide measured in an effluent may be assumed to be discharged uniformly during the sampling period. When radioactivity is identified at a concentration below the LLD for the analysis, that concentration is reported. When radioactivity is not identified in a sample, it is not reported as being present in that sample.

The quantity of radioactive noble gas discharged via the offgas stack or a vent during an interval of time is determined by integrating the release rate measurement of each effluent noble gas monitor. An hourly interval is normally used for dose rate assessments and a daily or longer interval is used for dose assessments. If ΔQ_j represents the gross activity of noble gas discharged via the offgas stack or a vent and g_i represents the fraction of radionuclide i in the distribution of radioactive gases in that effluent stream, then the quantity of radionuclide i released in the gaseous effluent stream during counting interval j is estimated by the relation:

$$\Delta Q_{ij} = \Delta Q_j \times g_i$$

The distribution of radioactive noble gases in gaseous effluent streams is determined by gamma spectrum analysis of gaseous effluent samples in accordance with Table 7.2-2. Results of one or more previous analyses may be averaged to obtain a representative spectrum. In the event a representative distribution is not available or is unobtainable from sample(s) of an effluent stream taken during the current quarter, it will be derived from past measurements, e.g., earlier sample results or annual radioactive material release reports. Alternatively, a noble gas spectrum for a given effluent stream in Table 3-2 herein, may be assumed.

An airborne discharge of radionuclides other than noble gases may be represented by multiple samples with each sample providing a measure of the concentration of specific radionuclides, C_i , in gaseous effluent discharged at flow, F_a , during a time increment Δt . Thus, each release is quantified according to the relation:

$$Q_{ik} = \sum_j C_{ik} F_{aj} \Delta t_j$$

where

Q_{ik} = the quantity of radionuclide i released in a given effluent stream based on analysis k (Ci)

C_{ik} = concentration of radionuclide i in gaseous effluent identified by analysis k ($\mu\text{Ci/mL}$ or Ci/m^3)

F_{aj} = effluent stream discharge rate during the increment Δt_j (m^3/sec)

Δt_j = time increment during which radionuclide i at concentration C_{ik} is being discharged (sec)

The analysis index k may represent either a grab sample, integrated sample, or a composite sample required by the effluent sampling and analysis program specified in Table 7.2-2.

3.3 Main Condenser Offgas Pretreatment Monitor Alarm Setpoint

A noble gas activity monitor is provided to measure gross gamma activity in gases from the main condenser air ejector. The pretreatment monitor includes an alarm that is set to report when the gamma radiation level in gas discharged by the main condenser air ejector indicates the gross radioactivity discharge rate, after 30 minutes delay and decay, exceeds 1 Ci/sec.

The main condenser Offgas gross gamma activity rate is an initial condition of the Steam-Line Break Accident (Roof Top Release). Restricting the gross radioactivity rate of noble gasses from the main condenser to a rate of 1 Ci/sec provides reasonable assurance that the total body exposure to an individual at the exclusion area boundary will not exceed a small fraction of the limits of 10 CFR Part 50.67 in the event this effluent is inadvertently discharged directly to the environment without treatment.

The alarm setpoint is determined with the relation:

$$S = \frac{2120 g}{F \sum_i f_i e^{-\lambda_i t}} + BKG$$

where

S = main condenser air ejector noble gas monitor alarm setpoint (cpm) or (mR/hr)

2120 = $[(1.0 \times 10^6 \mu\text{Ci/sec}) \cdot (1 \text{ ft}^3/28317 \text{ cm}^3)] \cdot 60 \text{ sec/min}$

F = air ejector discharge rate (ft^3/min)

g = noble gas monitor calibration or counting rate response for gamma radiation

$$\left(\frac{\text{cpm}}{\mu\text{Ci/cm}^3} \right) \text{ or } \left(\frac{\text{mR/hr}}{\mu\text{Ci/cm}^3} \right)$$

f_i = fraction of noble gas gross activity due to noble gas radionuclide i in a representative spectrum of noble gases at the main condenser offgas detector

λ_i = radioactive decay constant of noble gas nuclide i (min^{-1})

t = 30 min; decay time in delay line

3.4 Effluent Noble Gas Monitor Alarm Setpoint

Section 6.2.2 provides limits on dose equivalent rates associated with airborne radioactive materials concentrations in the unrestricted area due to airborne effluents from the Station. Instrumentation is provided to monitor gamma radiation in the airborne effluents according to Table 6.2-1. Each effluent noble gas monitor includes an alarm that can be set to activate when the dose rate off site or the noble gas concentration at ground level offsite is expected (calculated) to exceed a specified level. Compliance with the limits on dose rate from noble gases is demonstrated by setting each gaseous effluent monitor alarm setpoint so that an alarm will occur at or before the dose rate limit for noble gases is reached. If an alarm occurs with the setpoint at the limit, compliance with Section 6.2.2.a is assessed as described in section 3.5.

On the basis of effluent noble gases from the DAEC during recent years, the gamma dose rate to a person's whole body is expected to be a larger fraction of the limit, 500 mrem/yr, than is the beta plus gamma dose rate to skin to its limit, 3000 mrem/yr. As a result, a gaseous effluent monitor setpoint may be derived on the basis of the gamma dose rate to a person's whole body alone such that an alarm is set to occur at or before the whole body dose rate offsite exceeds 500 mrem/yr.

A noble gas monitor may be set to activate an alarm at a lower setting than the derived setpoint corresponding to the dose rate limit (or corresponding concentration limit). In the event an alarm occurs at the lower setting, the monitor record is compared with the derived setpoint. If the derived setpoint is exceeded, compliance with Section 6.2.2.a is assessed as described in section 3.5.

Each radioactive noble gas effluent monitor setpoint is derived on the basis of whole body dose equivalent rate in the unrestricted area. Setpoints for gaseous effluent monitors may be set independently because excessive effluent release via the turbine building vent is unlikely. Other releases are likely to be initiated independently and released from different levels, i.e., vent and stack releases with points of maximum concentration offsite not likely to coincide.

For the purpose of deriving a setpoint, the distribution of radioactive noble gases in an effluent stream is determined as described in section 3.2.

Setpoint Determination

The alarm setpoint of a radioactive noble gas effluent monitor may be calculated on the basis of whole body dose equivalent rate offsite, 500 mrem/yr. A setpoint of a monitor of an elevated release, e.g., from the stack, may be calculated with the equation:

$$S = \left[1.06 \cdot \frac{h}{f} \cdot \frac{\sum_i C_i}{\sum_i C_i \times DF_i^s} \right] + Bkg$$

The setpoint of a monitor of a ground-level or building release, e.g., from the turbine building vent or 3 reactor building vents or LLRPSF vent may be calculated with the equation:

$$S = \left[1.06 \cdot \frac{h}{f\left(\frac{\chi}{Q}\right)} \sum_i C_i \cdot DF_i^v \right] + Bkg$$

where

s = the alarm setpoint (cpm) or (mR/hr)

h = monitor response to activity concentration of effluent being monitored,

$$\left(\frac{cpm}{\mu Ci/cm^3} \right) \text{ or } \left(\frac{mR/hr}{\mu Ci/cm^3} \right)$$

C_i = relative concentration of noble gas radionuclide i in effluent at the point of monitoring ($\mu Ci/cm^3$)

χ/Q = atmospheric dispersion from point of ground-level or building wake release to the location of potential exposure (sec/m³)

DF_i^s = factor converting elevated release rate of radionuclide i to whole body dose equivalent rate at the location of potential exposure

$$\left(\frac{mrem}{yr \cdot \frac{\mu Ci}{sec}} \right)$$

DF_i^v = factor converting ground-level of split-wake release of radionuclide i to the whole body dose equivalent rate at the location of potential exposure

$$\left(\frac{mrem}{yr \cdot \frac{\mu Ci}{m^3}} \right)$$

f = flow of gaseous effluent stream, i.e., flow past the monitor (ft³/min)

Bkg = monitoring instrument background (cpm) or (mR/hr)

$$1.06 = 500 \frac{mrem}{yr} \cdot 60 \frac{sec}{min} \cdot 35.3 \frac{ft^3}{m^3} \cdot \frac{1 m^3}{10^6 cm^3}$$

Each monitoring channel has a unique response, h , which is determined by the instrument calibration.

The concentration of each noble gas radionuclide, C_i , in a gaseous effluent is determined as discussed earlier in this section.

Since the dose rate limits for airborne effluents apply everywhere offsite, alarm setpoints are determined and compliance is assessed at the site boundary where the minimum atmospheric dispersion (maximum χ/Q) occurs. The atmospheric dispersion factor and the dose conversion factor DF_i^s depend on local conditions. The value of χ/Q adopted in a setpoint calculation will be based either on prevailing meteorological conditions or on reference meteorological conditions at the DAEC. The minimum atmospheric dispersion offsite from a ground-level or building wake release derived from reference meteorological conditions is at the site boundary 1260 meters NNW of the Station where:

$$\left(\frac{\chi}{Q} \right)_{vent} = 4.3 \cdot 10^{-6} \text{ sec/m}^3$$

The dose conversion factors, DF_i^s , used in setpoint calculations for gaseous effluent monitors are in Table 3-4. In the event DF_i^s is derived on the basis of prevailing meteorology, it will be calculated in accordance with Regulatory Guide 1.109, Appendix B.

3.5 Dose Equivalent Rate Offsite

Section 6.2.2 provides limits on dose equivalent rates associated with airborne radioactive materials concentrations in the unrestricted area due to airborne effluents from the Station. Compliance is assessed on the basis of measurements specified in Table 7.2-2.

3.5.1 Noble Gas

Limits on radioactive noble gas in the unrestricted area are provided in Section 6.2.2.a. Each radioactive noble gas effluent monitor is set to alarm when, or below when, the noble gas in airborne effluent from a monitored stack or vent is expected to cause either dose rate limit in Section 6.2.2.a to be exceeded. In the event an airborne effluent release from the Station exceeds the derived setpoint (limit) for an effluent noble gas monitor (except when caused by the performance of a Surveillance Test Procedure), an assessment of compliance is performed as described herein.

The quantity of radioactive noble gas released in a increment of time is measured by the radioactive noble gas effluent monitors and the distribution of radioactive noble gases in a gaseous effluent stream is determined as described in section 3.2 herein.

Compliance with Section 6.2.2.a may be assessed by calculating the dose equivalent rate as described hereafter and by comparing it with the limiting dose rate in the Specification.

3.5.1.1 Total Body Dose Rate

For evaluating compliance with Effluent Control, Section 6.2.2.a, the total body dose equivalent rate due to noble gas gamma radiation is calculated with the equation:

$$\bar{D}_{\gamma} = \frac{1}{3600} \left[\sum_i \left(\frac{Qg_i}{t} \bullet DF_i^s \right)_s + \sum_v \sum_i \left(\frac{Qg_i}{t} \bullet \left(\frac{\chi}{Q} \right) \bullet DF_i^v \right)_v \right]$$

where

\bar{D}_{γ} = noble gas gamma dose rate to total body (mrem/yr)

Qg_i/t = quantity of noble gas radionuclide i discharged (μCi) during time increment t (yr)

DF_i^s = factor converting unit noble gas nuclide i stack release to total body dose at ground level received from the overhead plume

$$\left[\frac{\text{mrem}}{(\mu\text{Ci yr})/\text{sec}} \right]$$

DF_i^v = factor converting time integrated, ground level concentration of noble gas nuclide i to total body dose from gamma dose from gamma radiation

$$\left(\frac{mrem}{\mu Ci \text{ yr} / m^3} \right)$$

$$\frac{I}{3600} = \text{conversion (hr/sec)}$$

Dose factor DF_i^s , for exposure to noble gases released from an elevated stack are calculated by a finite plume model implemented in the MIDAS program.^a It assumes decay of short-lived nuclides, an air dose-to-tissue dose conversion of 1.11, and that the dose to internal organs is equivalent to the tissue dose. In this model, meteorological data concurrent with the period of release are used to evaluate the dose rate.

The dose from noble gases released from a vent (near ground level) or to skin from an elevated release is derived from a semi-infinite cloud model. Noble gas semi-infinite cloud gamma-to-total body dose factors, DF_i^v , are listed in Table 3-4.

When the total body and organ doses from noble gases are computed as required by Section 7.3.1, the nearby resident exposed to the maximal ground-level noble gas concentration (maximum χ/Q) is selected as the receptor.

Alternatively, the dose from noble gases may be computed at 1260 meters NNW of the reactor, a location identified in Figure 3-2, where the nearby resident who may be exposed to maximal ground-level noble gas concentrations (maximum χ/Q) is selected as the receptor.^c In that case, values of the dose factors DF_i^s and DF_i^v in Table 3-4 are employed.^m Total body dose factors for exposure from a plume from an elevated, stack release, DF_i^s , in Table 3-4 were computed with the aid of an NRC code, RABFIN. In those computations, reference meteorology was assumed as the basis of atmospheric dispersion. For discharge from a vent, reference meteorological dispersion at the 1260 m NNW, $(\chi/Q)_v$, is 4.3×10^{-6} sec/m³.

3.5.1.2 Skin Dose Rate

The skin dose equivalent rate due to radioactive noble gas is calculated with the equation:

$$D\beta = \frac{I}{3600} \left[\sum_i S_{\beta i} \left(\frac{\chi_i}{t} \bullet \left(\frac{\chi}{Q} \right) \right)_s + \sum_v \sum_i S_{\beta i} \left(\frac{\chi_i}{t} \bullet \left(\frac{\chi}{Q} \right) \right)_v \right]$$

where

^a David Slade, ed., Meteorology and Atomic Energy 1968, TID-24190, pp. 350-355.

^m Dose transfer factors DF_i^v in Table 3.4 are a units conversion of values in Regulatory Guide 1.109, Table B-1, column 5.

^c Due to limitations of the Midas© software used to perform these calculations, a conservative higher calculated dose may be reported. When using Annualized Average Meteorological data, the Midas system uses known X/Q values from the 1 mile radius to extrapolate X/Q values at the site boundary. The resulting maximum site boundary X/Q value is greater than 4.3×10^{-6} sec/m³ and is located on the site boundary toward the SSE.

- D_β = noble gas beta dose rate to skin (mrem/yr)
- $\frac{Q_i}{t}$ = quantity of noble gas radionuclide i (μCi) discharged during time increment t (hr)
- S_β = factor converting time integrated ground level concentration of noble gas to
 skin dose from beta radiation $\left[\frac{\text{mrem m}^3}{\mu\text{Ci yr}} \right]$
- $\frac{I}{3600}$ = conversion (hr/sec)

Compliance with Section 6.2.2.a dose rate to skin is evaluated by calculating the noble gas beta dose equivalent rate offsite at a location 1260 meters NNW of the Station, which is also identified in Figure 3-2.^d At that location, the reference atmospheric dispersion factors to be used in the calculations are:

$$\left(\frac{\chi}{Q} \right)_v = 4.3 \cdot 10^{-6} \text{ sec/m}^3 \quad \text{and} \quad \left(\frac{\chi}{Q} \right)_s = 2.8 \cdot 10^{-7} \text{ sec/m}^3$$

Alternatively, averaged meteorological dispersion data coincident with the period of release may be used to evaluate the dose rate. The semi-infinite noble gas cloud-to-skin dose equivalent factors are in Table 3-4. They are also derived from Regulatory Guide 1.109, Table B-1.

^d Due to limitations of the Midas© software used to perform these calculations, a conservative higher calculated dose may be reported. When using Annualized Average Meteorological data, the Midas system uses known X/Q values from the 1 mile radius to extrapolate X/Q values at the site boundary. The resulting maximum site boundary X/Q value is greater than $4.3 \times 10^{-6} \text{ sec/m}^3$ and is located on the site boundary toward the SSE.

3.5.2 Iodine, Tritium, and Particulates

Section 6.2.2.b provides a limit on iodine-131, iodine-133, H-3, and on radioactive particulates having 8 day or longer half-lives in air in the unrestricted area around the Station. In the event airborne effluent from the Station causes a radioactive noble gas effluent monitor to alarm (except when alarm is due to the performance of a Surveillance Test Procedure) or if the assessment required by Section 7.2.4 shows Section 6.2.4 to have been exceeded, an assessment of compliance with Section 6.2.2.b will be performed using a method described in this section.

3.5.2.1 Organ Dose Rate^e

Compliance with Section 6.2.2.b is assessed by calculating the dose rate to the most exposed organ of an assumed adult member of the public inhaling airborne I-131, I-133, H-3, and inhaling radioactive particulates having half-lives of 8 days or longer at the location in the unrestricted area having the maximum potential concentration of the effluents (i.e., the location at which reference meteorological data indicates minimum atmospheric dispersion from the Station (max χ/Q).

The organ dose rate is calculated with the following equations:

For a vent discharge:

$$\bar{D}_{anv} = \frac{8.766E - 3}{TE - TB} \sum_i \sum_k Q_{ikv} TA_{ani} \left(\frac{\chi_i}{Q} \right)_v$$

For an offgas stack discharge:

$$\bar{D}_{ans} = \frac{8.766E - 3}{TE - TB} \sum_i \sum_k Q_{iks} TA_{ani} \left(\frac{\chi_i}{Q} \right)_s$$

Combining separate release points gives

$$\bar{D}_{an} = \bar{D}_{ans} + \sum_v \bar{D}_{anv}$$

where

\bar{D}_{an} = the dose equivalent rate to organ n of a person in age group a due to radionuclides discharged in airborne effluents during time interval TB to TE (mrem/yr)

\bar{D}_{ans} = dose equivalent rate from a stack discharge (mrem/yr)

\bar{D}_{anv} = dose equivalent rate from a vent discharge (mrem/yr)

Q_{iks}, Q_{ikv} = quantity of radionuclide i released in a given effluent stream based on analysis k (μCi) during discharged time increment TB to TE (hr) of interest

Q_{iks}, Q_{ikv} = quantity of radionuclide i released in a given effluent stream based on analysis k (μCi) during discharged time increment TB to TE (hr) of interest

^eFor inhaled or ingested radioactive material, the consequent "dose" means the committed dose equivalent. The "dose rate" is the committed dose equivalent per unit of time of exposure to the radioactive material in the environment.

TA_{ani} = factor converting airborne concentration of radionuclide i to dose commitment to organ n of a person in age group a where exposure is directly to airborne material

$$\left(\frac{mrem}{(Ci\ sec)/\ m^3} \right)$$

$\left(\frac{\chi_i}{Q} \right)_s, \left(\frac{\chi_i}{Q} \right)_v$ = atmospheric dispersion from stack and vent, respectively, to ground level at location of interest (sec/m^3)

$8.766E - 3$ = Conversion $(1\ \text{Ci}/1E6\ \mu\text{Ci})(8766\ \text{hr}/\text{yr})$

Radionuclides other than noble gases airborne effluent are measured and quantified as described in section 3.2. Normally, radioactive material measured in effluent is assumed to be discharged uniformly over the period represented by the sample.

The averaging time of the measured releases used to evaluate compliance will not exceed 92 days for Sr-89 and Sr-90 and will not exceed 31 days for the other radionuclides.

The maximum offsite exposure potential is expected to occur at 1260 meters NNW of the Station where the reference atmospheric dispersion, to be used in the calculation is

$$\left(\frac{\chi}{Q} \right)_v = 4.3 \cdot 10^{-6}\ \text{sec}/\text{m}^3 \text{ and}$$

$$\left(\frac{\chi}{Q} \right)_s = 2.8 \cdot 10^{-7}\ \text{sec}/\text{m}^3$$

Currently, compliance with Section 6.2.2.b is evaluated by calculating an adult inhalation dose rate at 1260 meters NNW of the Station^f. The dose transfer factors, TA_{ani} , used in the computation are tabulated in Appendix A.

^fDue to limitations of the Midas© software used to perform these calculations, a conservative higher calculated dose may be reported. When using Annualized Average Meteorological data, the Midas system uses known X/Q values from the 1 mile radius to extrapolate X/Q values at the site boundary. The resulting maximum site boundary X/Q value is greater than $4.3 \times 10^{-6}\ \text{sec}/\text{m}^3$ and is located on the site boundary toward the SSE.

3.5.2.2 Rainwater Recapture of Tritium

The phenomenon of rainwater recapture of the tritium present in gaseous effluents has been observed on site. A liquid pathway analysis of the activity present in the rainwater runoff has been performed. The maximum dose to a member of the public from this liquid has been conservatively estimated to be less than 0.01 mrem per year.

3.6 Noble Gas Gamma Radiation Dose Accumulated in Air

Section 6.2.3 requires that the offsite air dose during any calendar quarter not exceed 5 mrad and the annual air dose not exceed 10 mrad from noble gas gamma radiation. Section 7.2.3.1 requires a monthly calculational assessment to verify that the cumulative air dose due to gamma radiation from radioactive noble gas released in gaseous effluents during the quarter and year do not exceed Section 6.2.3.

The distribution of radioactive noble gases in gaseous releases and the quantity of radioactive noble gas discharged during an interval of time are determined as described in section 3.2 herein.

The gamma radiation dose to air offsite as a consequence of noble gas discharge from DAEC is calculated with the

$$D_\gamma = \sum_i \sum_j (\Delta Q_j \cdot g_i \cdot A\gamma_i^s) + \sum_v \sum_i \left(A\gamma_i^v \sum_j \Delta Q_j \cdot g_i \cdot \left(\frac{\chi}{Q} \right)_v \right)$$

where

- D_γ = noble gas gamma dose to air due to effluent from stack and vent (mrad)
- ΔQ_j = total measured radioactivity release via stack or vent measured by noble gas effluent monitor during counting interval j (μCi)
- g_i = the fraction of radioactive gas in a given effluent stream attributable to noble gas radionuclide i .
- $A\gamma_i^s$ = factor converting unit release of noble gas radionuclide i from the stack to air dose at ground-level received from gamma radiation from the overhead plume (mrad/ μCi)
- $A\gamma_i^v$ = factor converting time integrated, ground-level concentration of noble gas to air dose from gamma radiation
- $\left(\frac{\chi}{Q} \right)_v$ = atmospheric dispersion factor for a vent (ground-level or building wake) discharge (sec/m^3)

Section 7.2.3.1 is satisfied by calculating the noble gas gamma radiation dose to air at the offsite location identified in Figure 3-2. At that location, 1260 meters NNW of the Station^h, the reference^{*g} atmospheric dispersion factor to be used is

^g Due to limitations of the Midas© software used to perform these calculations, a conservative higher calculated dose may be reported. When using Annualized Average Meteorological data, the Midas system uses known X/Q values from the 1 mile radius to extrapolate X/Q values at the site boundary. The resulting maximum site boundary X/Q value is greater than $4.3 \times 10^{-6} \text{ sec}/\text{m}^3$ and is located on the site boundary toward the SSE.

$$\left(\frac{\chi}{Q} \right)_v = 4.3 \cdot 10^{-6} \text{ sec/m}^3$$

Values of A_{γ}^s and A_{γ}^v appropriate for use at that location, assuming reference meteorological conditions, are listed in Table 3-3. An NRC code, RABFIN, modified for sector width averaged meteorology was used to calculate the air dose transfer factors,

A_{γ}^s for a stack discharge, in ODAM Table 3-3. They represent air dose at ground level 1260 meters NNW of the station from a unit release of each radionuclide i from the stack.

Dose transfer factors for vent discharges, A_{γ}^v , are equivalent to factors in Regulatory Guide 1.109, Table B-1, g-air expressed in different units.

3.6.1 Alternate Method of Evaluating Compliance with Gamma Air Dose Limits

Alternatively, the gamma radiation dose to air offsite may be calculated with the equation

$$D_{\gamma} = \frac{I}{0.8} \sum_j (\Delta Q_j \cdot A_{\gamma \text{eff}})_s + \frac{I}{0.8} \sum_v \sum_j \left(\Delta Q_j \cdot \left(\frac{\chi}{Q} \right) \cdot A_{\gamma \text{eff}} \right)_v$$

where

$A_{\gamma \text{eff}}$ = an effective dose conversion factor based on the typical radionuclide distribution in stack releases converting unit release of radioactive noble gases from the stack to air dose at ground level at a specific location (mrad/ μ Ci).

$A_{\gamma \text{eff}}$ = an effective dose conversion factor based on the typical radioactive distribution in vent releases converting a time integrated, ground level concentration of noble gases to air dose from gamma radiation

$$\left(\frac{\text{mrad}}{(\mu\text{Ci sec/m}^3)} \right)$$

0.8 = a factor of conservatism which compensates for variability in radionuclide distribution

The derivation and basis of the effective gamma air dose conversion factor are provided in Appendix B. Values of the effective factors are tabulated in Table 3-3. By inserting the appropriate values for D_{γ} (5 mrad/quarter γ -air dose) and for $A_{\gamma \text{eff}}$ (1.6×10^{-11} mrad/ μ Ci) or $A_{\gamma \text{eff}}$ (6.4×10^{-5} mrad/(μ Ci sec/m³)) into the equation above and solving for either $(\Delta Q_j)_s$ or $(\Delta Q_j)_v$, respectively, release quantities of noble gases from either the stack or vent corresponding to the technical specification limit of 5 mrad/quarter (total for all release points) may be determined. The limit of 5 mrad/quarter is described in section 6.2.3 and is for the total of all release points. At the location, 1260 meters NNW

^b Reference atmospheric conditions are summarized and discussed in "Duane Arnold Energy Center, Evaluation of Liquid and Gaseous Effluent Releases in Accordance with 10 CFR 50 Appendix I," submitted to NRC June 3, 1976. Reference atmospheric dispersion factors tabulated therein, also appear in Appendix B herein.

of the station, (which is the controlling location based on reference meteorology) the release limits are individually

| Release Point | Quarterly Limit (Ci) | Annual Limit (Ci) |
|---------------|----------------------|-------------------|
| Stack | 2.5×10^5 | 5.0×10^5 |
| Vent | 1.25×10^4 | 2.5×10^4 |

The following equations may be used to assess both the stack and vent discharges for compliance with the quarterly release limits on noble gas gamma dose to air.

$$\frac{\sum_j (\Delta Q_j)_s}{250,000} + \frac{\sum_v \sum_j (\Delta Q_j)_v}{12,500} \leq I$$

or, on a monthly rate basis (although not a requirement)

$$\frac{\sum_j (\Delta Q_j)_s}{250,000} + \frac{\sum_v \sum_j (\Delta Q_j)_v}{12,500} \leq \frac{1}{3}$$

The equations which may be used to assess both the stack and vent discharges for compliance with the annual air dose limits from noble gas are:

$$\frac{\sum_j (\Delta Q_j)_s}{500,000} + \frac{\sum_v \sum_j (\Delta Q_j)_v}{25,000} \leq I$$

or, on a monthly rate basis (although not a requirement)

$$\frac{\sum_j (\Delta Q_j)_s}{500,000} + \frac{\sum_v \sum_j (\Delta Q_j)_v}{25,000} \leq \frac{1}{12}$$

As long as these relations are satisfied for both stack and vent releases of noble gases, no additional calculations are needed to verify compliance with the gamma-air dose limits of Section 6.2.3. Calculations of beta air doses per Section 3.6 may be omitted as discussed in Appendix B.

3.7 Noble Gas Beta Radiation Dose Accumulated in Air

Section 6.2.3 requires that the offsite air dose during any calendar quarter not exceed 10 mrad from noble gas beta radiation and not exceed 20 mrad during any calendar year. Section 7.2.3.1 requires a monthly assessment to verify that the cumulative air dose due to beta radiation from radioactive noble gas released in gaseous effluents not exceed either limit of Section 6.2.3.

The radioactive noble gas distribution and activity discharged are determined as described in paragraph 3.6 herein.

The beta radiation dose to air offsite as a consequence of noble gas released from the Station is calculated with the equation:

$$D_\beta = \sum_i A_{\beta_i} \left[\Delta Q_j g_i \frac{\chi}{Q} \right]_s + \sum_v \sum_i A_{\beta_i} \sum_j \left[\Delta Q_j g_i \frac{\chi}{Q} \right]_v$$

where

D_β = noble gas beta dose to air due to stack and vent releases (mrad)

A_{β_i} = factor converting time-integrated, ground-level concentration of noble gas radionuclide i to air dose from beta radiation $\left(\frac{\text{mrad} \cdot \text{m}^3}{\mu\text{Ci} \cdot \text{sec}} \right)$

$\left(\frac{\chi}{Q} \right)_s$ = atmospheric dispersion factor for a discharge via the stack (sec/m^3)

$\left(\frac{\chi}{Q} \right)_v$ = atmospheric dispersion factor for a vent (ground level or building wake) discharge (sec/m^3).

Specification 7.2.3.1 is satisfied by calculating the noble gas beta radiation dose to air at the location identified on Figure 3-2. At that location, 1260 meters NNW of the reactor, the reference atmospheric dispersion factors to be used are

$\left(\frac{\chi}{Q} \right)_s = 2.8 \times 10^{-7}$

$\left(\frac{\chi}{Q} \right)_v = 4.3 \times 10^{-6}$

Beta radiation-to-air dose conversion factors, A_{β_i} , for noble gas radionuclides are listed in Table 3-3.

¹Due to limitations of the Midas© software used to perform these calculations, a conservative higher calculated dose may be reported. When using Annualized Average Meteorological data, the Midas system uses known X/Q values from the 1 mile radius to extrapolate X/Q values at the site boundary. The resulting maximum site boundary X/Q value is greater than $4.3 \times 10^{-6} \text{ sec}/\text{m}^3$ and is located on the site boundary toward the SSE.

3.8 Dose Due to Iodine and Particulates in Gaseous Effluents¹

Section 6.2.4 requires that I-131, I-133, H-3, and radioactive material in particulate form having half-lives greater than 8 days in gaseous effluents released to the area offsite cause no more than 7.5 mrem to any organ of a member of the public during a calendar quarter and no more than 15 mrem during any calendar year. Section 7.2.4 requires an assessment at least once every month to verify that the cumulative dose commitment does not exceed either limit of Section 6.2.4.

Airborne releases are discharged either via the offgas stack as an elevated release or via building vents and treated as a ground-level, building wake, or split wake release. Radionuclides mentioned above in airborne effluents that are measured by the sampling and analysis schedule in Table 7.2-2 are included in the release term used to calculate doses. Section 3.2 describes the quantification of these radionuclides other than noble gases.

A person may be exposed directly to an airborne concentration of radioactive material discharged in effluent and indirectly via pathways involving deposition of radioactive material onto the ground. Dose estimates account for the separate exposure pathways. The dose commitment to a person offsite associated with a gaseous release, Q_{ik} , of radioactive material other than noble gas is calculated with the appropriate one(s) of the following equations

for a stack release:

$$D_{anske} = \sum_i Q_{ik} \left[TA_{anie} \left(\frac{\chi}{Q} \right)_s + TG_{anie} \left(\frac{D}{Q} \right)_s \right]$$

for a vent release:

$$D_{anvke} = \sum_i Q_{ik} \left[TA_{anie} \left(\frac{\chi}{Q} \right)_v + TG_{anie} \left(\frac{D}{Q} \right)_v \right]$$

The dose to any organ of a person arising from radioactive iodine-131, iodine-133, tritium, and radioactive material in particulate form having half-lives greater than 8 days. Noble gases not considered.

where

$D_{ansk e}$ = the dose commitment (mrem) to organ n of a person in age group a via exposure pathway e due to radionuclides identified in analysis k of a stack release where the analysis is required by Table 7.2-2.

$D_{anv k e}$ = the dose commitment via pathway e from a vent release (mrem)

TA_{anie} = factor converting airborne concentration of radionuclide i to dose commitment to organ n of a person in any group a where exposure is directly to airborne material via exposure pathway e .

$$\left(\frac{mrem}{(Ci \text{ sec}) / m^3} \right)$$

TG_{anie} = factor converting ground deposition of radionuclide i to dose commitment organ n of a person in age group a where exposure is directly or indirectly to radioactive material that has been deposited on the ground via exposure pathway e .
 $\left(\frac{mrem}{Ci / m^2} \right)$

Q_{ik} = quantity of radionuclide i released in a given effluent stream based on analysis k (Ci)

$\left(\frac{D}{Q} \right)_s, \left(\frac{D}{Q} \right)_v =$ relative deposition factor, i.e., factor converting airborne effluent discharge from stack or vent respectively, to a real deposition on land (m^{-2}).

The analysis index k may represent either an analysis of a grab sample, a weekly composite analysis, a monthly composite analysis, or a quarterly composite analysis.

Since tritium in water vapor is absorbed directly by vegetation, the tritium concentration in growing vegetation is proportional to the airborne concentration rather than to relative deposition as in the case of particulates. Thus the dose commitment from airborne tritium via vegetation (fruit and vegetables), air-grass-cow-milk, or air-grass-cow-meat pathways is calculated with the appropriate one(s) of the equations:

for a stack release

$$D_{ansk e} = \left(\frac{\chi}{Q} \right)_s \sum_i \sum_k Q_{iks} TA_{anie}$$

for a vent release

$$D_{anve} = \left(\frac{\chi}{Q} \right)_v \sum_i \sum_k Q_{ikv} TA_{anie}$$

The dose commitment accumulated by a person offsite is computed at least every 30 days to satisfy Section 7.2.4.1 but may be calculated as analytical results of effluent measurements, performed as specified in Table 7.2-2, become available.

The dose accumulated as a result of stack discharge is computed with

$$D_{ans} = \sum_e D_{ane}$$

and the dose accumulated as a result of vent discharge is computed with

$$D_{anv} = \sum_e D_{anve}$$

Doses committed during the same time period due to discharges from the stack and vents are additive, thus

$$D_{an} = D_{ans} + \sum_v D_{anv}$$

where

$D_{an} =$ the dose commitment accumulated during the quarter to date as a result of all measured radioactive gaseous discharges except noble gases to any organ n , including total body, of a person offsite in age group a (mrem).

When the dose to a person from iodine and particulates discharged in gaseous effluents is calculated as required by Section 7.2.4, appropriate environmental pathways (from among those for which dose transfer factors are provided in Appendix A) will be evaluated. The dose calculated is to a receptor at the location of the nearby residence experiencing the minimum atmospheric dispersion at ground-level from the station, i.e.,

maximum $\frac{X}{Q}$, concurrent with the effluent discharge. Alternatively, the dose may be

calculated to a receptor at the location identified in Figure 3-2 where reference atmospheric dispersion and deposition factors are:

$$\left(\frac{\chi}{Q} \right)_s = 3.1 \cdot 10^{-7} \text{ sec/m}^3 \quad \left(\frac{D}{Q} \right)_s = 7.2 \cdot 10^{-9} \text{ m}^{-2}$$

$$\left(\frac{\chi}{Q} \right)_v = 3.9 \cdot 10^{-6} \text{ sec/m}^3 \quad \left(\frac{D}{Q} \right)_v = 1.3 \cdot 10^{-8} \text{ m}^{-2}$$

Food pathways are evaluated at the location of food production based on minimum atmospheric dispersion at ground-level concurrent with the effluent discharge or, alternatively, with reference meteorology applicable at that location. Seasonal appropriateness of pathways is considered. The air-grass (fresh or stored)-cow-milk-man pathway is evaluated where a cow is located, 2650 meters WNW of DAEC, reference atmospheric deposition factors are:

$$\left(\frac{D}{Q}\right)_s = 2.1 \cdot 10^{-9} \text{ m}^{-2} \quad \left(\frac{D}{Q}\right)_v = 4.28 \cdot 10^{-9} \text{ m}^{-2}$$

**This receptor is historical in nature. See the current land use census to verify this point as the most conservative receptor location for the pathway.

3.8.1 Alternate Method of Evaluating Doses Due to Iodine and Particulates in Gaseous Effluents

Alternatively, the dose commitment to a maximally exposed, hypothetical individual may be calculated by the equation

$$D_{inf-thy} = \frac{I}{0.8} \cdot \sum_i [Q_i \cdot TG_{inf-thy-I-131} \cdot (D/Q)]_s \\ = \frac{I}{0.8} \cdot \sum_i [Q_i \cdot TG_{inf-thy-I-131} \cdot (D/Q)]_v$$

where:

$D_{inf-thy}$ = the dose commitment accumulated during the quarter to date to a hypothetical infant's thyroid as a result of the releases of I-131 (mrem)

Q_i = the measured quantity of I-131 released in a given effluent stream, stack or vent (Ci)

$TG_{inf-thy-I-131}$ = the dose transfer factor for the infant thyroid from the cow-milk pathway f or I-131 measured in the effluent stream

$$\left(\frac{\text{mrem}}{\text{Ci} / \text{m}^2} \right)$$

$\frac{1}{0.8}$ = a factor of conservatism which accounts for the dose contribution for releases of particulate radioactive material other than I-131

When the maximum organ dose is evaluated by using the equation above, analyses of other organ doses via other pathways are not needed to demonstrate compliance within the dose limits of Section 6.2.4.

The rationale for only evaluating the dose contribution of I-131 is derived from an evaluation of the radioactive material releases and the environmental pathways. The air-grass-cow-milk-man pathway is by far the controlling pathway and the infant's thyroid is the limiting organ. This pathway typically contributes greater than 90% of the total calculated dose to the infant's thyroid and I-131 contributes essentially all of the dose (~95%). Therefore, it is possible to demonstrate compliance with the dose limits of Section 6.2.4 by the conservative calculational method presented above.

3.9 Dose to a Person from Noble Gases

Section 7.3.1 requires the calculation of the dose or dose commitment to a person offsite exposed to 12 consecutive months of radioactive liquid and gaseous effluents from the Station. One component of personal dose is total body irradiation by gamma rays from noble gases. Another is irradiation of skin by beta and gamma radiation from noble gases. The methods of calculating these doses are presented in sections 3.9.1 and 3.9.2.

The amount of radioactive noble gas discharged is determined in the manner described in section 3.2.

3.9.1 Gamma Dose to Total Body

The gamma radiation dose to the whole body of a member of the public as a consequence of noble gas released from the Station is calculated with the equation:

$$D_{\gamma} = \sum_i (Q_i \cdot P\gamma_i^s) + \sum_v \sum_i \left(Q_i \cdot \left(\frac{\chi}{Q} \right) \cdot P\gamma_i^v \right)_v$$

where:

D_{γ} = noble gas gamma dose to total body (mrem)

Q_i = quantity of noble gas nuclide i released via stack or vent (Ci)

$P\gamma_i^s$ = factor converting unit noble gas nuclide i stack release to total body dose at ground level received from the overhead plume (mrem/Ci)

$P\gamma_i^v$ = factor converting time integrated, ground level concentration of noble gas nuclide i to total body dose from gamma radiation

$$\left(\frac{\text{mrem}}{\text{Ci sec/m}^3} \right)$$

The dose to total body and organs other than skin from noble gases released from an elevated stack are calculated by a finite plume model.^k It assumes decay of short-lived nuclides, a residential shielding factor of 0.7, an air dose-to-tissue dose conversion of 1.11, and that the dose to internal organs is equivalent to the tissue dose. Dose factors

for exposure to noble gas plume gamma radiation, $P\gamma_i^s$, are computed by the MIDAS program.

^kDavid Slade, ed., Meteorology and Atomic Energy 1968, TID-24190, pp. 350-355.

The dose from noble gases released from a vent (near ground level) or to skin from an elevated release is derived from a semi-infinite cloud model. Noble gas semi-infinite cloud gamma-to-total body dose factors, $P\gamma_i^y$, are listed in Appendix A under the plume pathway.

When the total body and organ doses from noble gases are computed as required by Section 7.3.1, the nearby resident exposed to the maximal ground-level noble gas concentration (minimum χ/Q) is selected as the receptor.

Alternatively, the dose from noble gases may be computed at 1260 meters NNW of the reactor where the nearby resident who may be exposed to maximal ground-level noble gas concentrations (minimum χ/Q) is selected as the receptor. In that case, values of the dose factors $P\gamma_i^s$ and $P\gamma_i^y$ in Table 3-5 are employed.¹ Reference meteorological dispersion for vent discharges at that location, $(\chi/Q)_v$, is $4.3 \times 10^{-6} \text{ sec/m}^3$.

3.9.2 Dose to Skin

The beta radiation dose to the skin of a member of the public due to beta radiation from noble gas released from the Station may be calculated with the equation

$$D_\beta = \sum_i S_{\beta i} \left[Q_i \cdot \left(\frac{\chi}{Q} \right) \right]_s + \sum_v \sum_i S_{\beta i} \left[Q_i \cdot \left(\frac{\chi}{Q} \right) \right]_v$$

where

D_β = noble air dose to skin (mrem)

$S_{\beta i}$ = factor converting time integrated ground level concentration of noble gas to skin dose from beta radiation

$$\left(\frac{\text{mrem}}{\text{Ci sec/m}^3} \right)$$

Semi-infinite cloud noble gas beta-to-skin dose factors, $S_{\beta i}$ appear in Table 3-5.

The total dose to the skin from noble gases is approximately equal to the beta radiation dose to the skin plus the gamma radiation dose to the total body.

When the skin dose due to noble gas beta radiation is computed as required by Section 7.3.1, the receptor selected is the nearby resident exposed to maximal ground-level concentrations (maximum χ/Q).

Alternatively, the skin dose to a postulated receptor (resident) at 1260 meters NNW of the reactor may be calculated.

¹Dose transfer factors $P\gamma_i^y$ in Table 3.5 and in Appendix A under the plume pathway are the same.

Figure 3.1
Gaseous Radioactive Waste Flow Diagram





Figure 3-1 (Continued)

- R1 Main Condenser SJAЕ Offgas Post-treatment Noble Gas Activity Monitor
- R2 Main Condenser SJAЕ Offgas Hydrogen Monitor
- R3 Offgas Stack Radiation Monitoring System
- R4 Reactor Building Exhaust Vent Monitoring System
- R5 Turbine Building Exhaust Vent Monitoring System
- R6 Main Condenser SJAЕ Offgas Pretreatment Noble Gas Activity Monitor
- R7 LLRPSF Exhaust Vent Monitoring System

Figure 3-2
Dose Calculation Sites



| Site | Description |
|------|--|
| A | Noble gas gamma and beta doses to air, 1260 meters NNW |
| B | Milk cow, 2650 meters WNW |
| C | Aquatic pathways, in Cedar River |
| D | Most exposed resident, 1610 meters NNW |

Table 3-1
Atmospheric Gaseous Release Points
at the Duane Arnold Energy Center

| Parameter | RELEASE POINT | | | |
|-----------------|--|---|------------------------|--------------------------------------|
| | Offgas Stack | Reactor Building Vent | Turbine Building Vent | LLRPSF Building Vent |
| Release Height | 328 feet | 156 feet | 90 feet | 65 feet |
| Release Mode | Elevated | Wake-split | Wake-split | Wake-split |
| Effluent Source | Waste Gas System Standby Gas Treatment System | Reactor Building Radwaste Building Lower Turbine Building | Upper Turbine Building | LLRPSF Building and Storage Facility |

Table 3-2
Computed Releases of Radioactive Noble Gases in Gaseous Effluent from Duane Arnold Energy Center

| Nuclide | STACK RELEASE | | PLANT VENTS RELEASE | |
|---------|----------------------|-----------------------|----------------------|-----------------------|
| | (Ci/yr) ^a | Fraction ^b | (Ci/yr) ^a | Fraction ^b |
| Kr-83m | 4.90E+01 | 2.53E-03 | 0 | 0 |
| Kr-85m | 2.34E+03 | 1.21E-01 | 7.40E+01 | 1.98E-02 |
| Kr-85 | 1.40E+02 | 7.23E-03 | 0 | 0 |
| Kr-87 | 1.56E+02 | 8.06E-03 | 1.36E+02 | 3.64E-02 |
| Kr-88 | 1.65E+03 | 8.52E-02 | 2.36E+02 | 6.32E-02 |
| Kr-89 | 6.40E+02 | 3.31E-02 | 0 | 0 |
| Xe-131m | 4.80E+01 | 2.48E-03 | 0 | 0 |
| Xe-133m | 3.50E+01 | 1.81E-03 | 0 | 0 |
| Xe-133 | 1.24E+04 | 6.41E-01 | 3.92E+02 | 1.05E-01 |
| Xe-135m | 1.80E+01 | 9.30E-04 | 7.42E+02 | 1.99E-01 |
| Xe-135 | 5.10E+02 | 2.63E-02 | 7.43E+02 | 1.99E-01 |
| Xe-137 | 7.80E+02 | 4.03E-02 | 0 | 0 |
| Xe-138 | 5.90E+02 | 3.05E-02 | 1.41E+03 | 3.78E-01 |
| | 19356 | 1.0 | 3733. | 1.0 |

TABLE NOTATION

- ^a Releases computed by BWR-GALE for DAEC Base Case gaseous radwaste treatment. Computed releases are included only to show the basis of the radionuclide distribution.
- ^b This is the calculated distribution of radionuclides in gaseous effluents in each release pathway. To estimate radionuclide concentrations in a sample in which only the total activity concentration has been measured, multiply the total activity concentration by the fraction of respective radionuclides listed above.

Table 3-3
Transfer Factors for Maximum Offsite Air Dose

| Radionuclide | Air Dose Transfer Factors | | |
|--------------|---|---|---|
| | $A\gamma_i^s$ | $A\gamma_i^v$ | $A\beta_i$ |
| | $\left(\frac{\text{mrad}}{\mu\text{Ci}} \right)$ | $\left(\frac{\text{mrad}}{\mu\text{Ci sec/m}^3} \right)$ | $\left(\frac{\text{mrad}}{\mu\text{Ci sec/m}^3} \right)$ |
| Kr-83m | 4.3E-14 | 6.1E-7 | 9.1E-6 |
| Kr-85m | 6.0E-12 | 3.9E-5 | 6.2E-5 |
| Kr-85 | 8.4E-14 | 5.4E-7 | 6.2E-5 |
| Kr-87 | 2.3E-11 | 2.0E-4 | 3.3E-4 |
| Kr-88 | 6.4E-11 | 4.8E-4 | 9.3E-5 |
| Kr-89 | 3.0E-11 | 5.5E-4 | 3.4E-4 |
| Kr-90 | --- | 5.2E-4 | 2.5E-4 |
| Xe-131m | 1.8E-12 | 4.9E-6 | 3.5E-5 |
| Xe-133m | 1.4E-12 | 1.0E-5 | 4.7E-5 |
| Xe-133 | 1.5E-12 | 1.1E-5 | 3.3E-5 |
| Xe-135m | 1.1E-11 | 1.1E-4 | 2.3E-5 |
| Xe-135 | 9.5E-12 | 6.1E-5 | 7.8E-5 |
| Xe-137 | 2.6E-12 | 4.8E-5 | 4.0E-4 |
| Xe-138 | 3.6E-11 | 2.9E-4 | 1.5E-4 |
| Ar-41 | 4.4E-11 | 2.9E-4 | 1.0E-4 |

TABLE NOTATIONS

- ^a An NRC code, RABFIN, modified for sector width averaged meteorology, was used to calculate the air dose transfer factors, $A\gamma_i^s$ for a stack discharge. They represent air dose at ground level 1260 meters NNW of the station from a unit release of each radionuclide i from the stack and dispersed by reference meteorology at the DAEC.
- ^b Dose transfer factors for vent discharges, $A\gamma_i^v$ and $A\beta_i$ are equivalent to factors in Regulatory Guide 1.109, Table B-1, g-air and b-air, expressed in different units.

Table 3-4

Transfer Factors for Dose Equivalent Rate to A Person Offsite Due to Radioactive Noble Gases

| Radionuclide | Dose Transfer Factors | | |
|--------------|--|--|--|
| | a, b, c DF_i^s $\left[\frac{mrem}{(\mu Ci yr)/sec} \right]$ | d DF_i^v $\left[\frac{mrem}{(\mu Ci yr)/m^3} \right]$ | $S_{\beta i}$ $\left[\frac{mrem}{(\mu Ci yr)/m^3} \right]$ |
| Kr-83m | 6.27E-9 | 7.56E-2 | 0 |
| Kr-85m | 1.81E-4 | 1.17E+3 | 1.46E+3 |
| Kr-85 | 2.51E-6 | 1.61E+1 | 9.73E+3 |
| Kr-87 | 6.97E-4 | 5.92E+3 | 9.73E+3 |
| Kr-88 | 1.91E-3 | 1.47E+4 | 2.37E+3 |
| Kr-89 | 9.14E-4 | 1.66E+4 | 1.01E+4 |
| Kr-90 | --- | 1.56E+4 | 7.29E+3 |
| Xe-131m | 4.83E-5 | 9.15E+1 | 4.76E+2 |
| Xe-133m | 3.61E-5 | 2.51E+2 | 9.94E+2 |
| Xe-133 | 4.09E-5 | 2.94E+2 | 3.06E+2 |
| Xe-135m | 3.39E-4 | 3.12E+3 | 7.11E+2 |
| Xe-135 | 2.84E-4 | 1.81E+3 | 1.86E+3 |
| Xe-137 | 7.90E-5 | 1.42E+3 | 1.22E+4 |
| Xe-138 | 1.08E-3 | 8.83E+3 | 4.13E+3 |
| Ar-41 | 1.32E-3 | 8.84E+3 | 2.69E+3 |

TABLE NOTATIONS

- ^a Receptor located 1260 meters NNW of Station
- ^b Based on reference meteorology at DAEC
- ^c Factors DF_i^s computed by computer code RABFIN, modified for sector width averaged meteorology
- ^d Factors DF_i^v from Regulatory Guide 1.109, revision 1, Table B-1, column 5

Table 3-5
Transfer Factors for Dose Equivalent Rate to A
Person Offsite Due to Radioactive Noble Gases

| Radionuclide | Dose Transfer Factors | | |
|--------------|--|---|--|
| | a, b, c $P\gamma_i^s$ $\left[\frac{mrem}{Ci} \right]$ | c, d $P\gamma_i^v$ $\left[\frac{mrem}{(Ci \text{ sec})/m^3} \right]$ | d $S_{\beta i}$ $\left[\frac{mrem}{(Ci \text{ sec})/m^3} \right]$ |
| Kr-83m | 1.39E-10 | 1.68E-3 | --- |
| Kr-85m | 4.03E-6 | 2.60E+1 | 4.63E+1 |
| Kr-85 | 5.58E-8 | 3.58E-1 | 4.25E+1 |
| Kr-87 | 1.55E-5 | 1.31E+2 | 3.08E+2 |
| Kr-88 | 4.25E-5 | 3.26E+2 | 7.51E+1 |
| Kr-89 | 2.03E-5 | 3.68E+2 | 3.20E+2 |
| Kr-90 | --- | 3.46E+2 | 2.31E+2 |
| Xe-131m | 1.07E-6 | 2.03 | 1.51E+1 |
| Xe-133m | 8.05E-7 | 5.57 | 3.15E+1 |
| Xe-133 | 9.03E-7 | 6.52 | 9.70 |
| Xe-135m | 7.49E-6 | 6.92E+1 | 2.25E+1 |
| Xe-135 | 6.31E-6 | 4.01E+1 | 5.89E+1 |
| Xe-137 | 1.75E-6 | 3.15E+1 | 3.87E+2 |
| Xe-138 | 2.39E-5 | 1.96E+2 | 1.31E+2 |
| Ar-41 | 2.92E-5 | 1.96E+2 | 8.52E+1 |

4.0 DOSE COMMITMENT FROM RELEASE OVER EXTENDED TIME

TABLE NOTATIONS

^a Receptor located 1260 meters NNW of Station

^b Based on reference meteorology at DAEC

^c Factors $P\gamma_i^s$ and $P\gamma_i^v$ already account for a 0.7 residential shielding factor. Factors $P\gamma_i^s$ were computed by computer code RABFIN, modified for sector width averaged meteorology

^d Factors $P\gamma_i^v$ and $S_{\beta i}$ from Regulatory Guide 1.109, revision 1, Table B-1

4.0 DOSE COMMITMENT FROM RELEASE OVER EXTENDED TIME

4.1 Dose Assessment for 10 CFR Part 50, Appendix I

Sections 7.1.3, 7.2.3, and 7.2.4 require quarterly and annual assessments to demonstrate compliance with Appendix I dose limits. The assessment includes the following calculations of dose as described by equations for:

1. total body and maximally exposed organ doses due to liquid effluent via drinking water and eating fish from the River and from consuming food irrigated with river water as in paragraph 2.5.
2. total body and maximally exposed organ doses due to gaseous effluents^a other than noble gases as in paragraph 3.8.
3. doses to air offsite due to noble gas α as in paragraph 3.6 and due to noble gas β as in paragraph 3.7.

The dose calculations are based on liquid and gaseous effluents from the Station during each calendar quarter and for a calendar year, determined in accord with Tables 7.1-2 and 7.2-2.

Environmental concentrations depend on dispersion and dilution of the effluent. For aqueous effluents over extended time, the aquatic concentration is estimated according to section 2.2. Atmospheric dispersion and deposition factors used to estimate the dose commitment due to gaseous effluents are ordinarily derived from reference meteorological data. Otherwise, quarterly averaged or annual averaged meteorological conditions concurrent with the gaseous release being evaluated will be used to estimate atmospheric dispersion and deposition.

The receptor of the dose is described such that the dose to any resident near the Station is unlikely to be underestimated. That is, the receptor is selected on the basis of the combination of applicable pathways of exposure to gaseous effluent identified in the annual land use census and maximum ground level χ/Q at the residence. Conditions (i.e., location, χ/Q , and/or pathways) more conservative (i.e., expected to yield higher calculated doses) than appropriate for the maximally exposed individual may be assumed in the dose assessment.

^a Radioactive iodine-131, iodine-133, tritium, and radioactive material in particulate form having half-lives greater than 8 days.

Seasonal appropriateness of exposure pathways may be considered. Exposure by eating fresh vegetation or drinking milk from cows or goats fed fresh forage is an inappropriate assumption during the first or fourth calendar quarter; rather consumption of stored vegetation and stored forage is assumed during those quarters. Otherwise, during the second and third calendar quarters, exposure by eating fresh vegetation and/or drinking milk from cows or goats fed fresh forage is assumed where those pathways exist. Similarly, the liquid effluent-river-fish-man pathway is not assumed during the winter quarter.

Factors converting stack-released noble gas to gamma radiation dose from the overhead plume are calculated on the basis of reference meteorological data for the receptor location or alternatively, by the MIDAS program for a residential location offsite where maximum χ/Q at ground level occurs.

Other environmental pathway-to-dose transfer factors used in the dose calculations are provided in Appendix A.

4.2 Dose Assessment for 40 CFR Part 190 and 10 CFR 72.104

The regulations governing the maximum allowable dose or dose commitment to a member of the public from all uranium fuel cycle-sources of radiation and radioactive material in the environment is stated in 40 CFR Part 190 and 10 CFR 72.104. It requires that the dose or dose commitment to a member of the public from all sources not exceed 25 mrem/yr to the whole body or 25 mrem/yr to any organ or 75 mrem/yr to the thyroid. Section 7.3.1 requires calculation of the dose at least once every year to assess compliance with the regulation. More frequent calculations may be performed if higher than normal releases are experienced (twice the design objective rates in a single quarter).

Fuel cycle sources or nuclear power reactors other than the Station^b itself do not measurably or significantly increase the radioactivity concentration in the vicinity of the Station; therefore, only radiation and radioactivity in the environment attributable to the Station itself are considered in the assessment of compliance with 40 CFR Part 190 and 10 CFR 72.104.

Contributions to the dose due to liquid and gaseous effluent are calculated as described by the equations for:

1. total body and maximally exposed organ doses due to liquid effluent via drinking water, consuming irrigated food and from eating fish from the River as in paragraph 2.5
2. total body dose due to noble gas γ as in paragraph 3.9.1
3. skin dose due to noble gas β as in paragraph 3.9.2

^b The Station is defined as BOTH the Nuclear Reactor Facility and the Independent Spent Fuel Storage Installation (ISFSI).

4. total body and maximally exposed organ doses due to gaseous effluents^c other than noble gases as in Paragraph 3.8.

Additionally, the contribution to total dose from direct radiation is assessed annually by using environmental TLDs.

The doses are calculated on the basis of liquid and gaseous effluents from the Station during 12 consecutive months, determined in accord with Tables 7.1-2 and 7.2-2. For the purpose of the Annual Radiological Environmental Report, doses are based upon release during a calendar year.

Aqueous radioactive material concentrations are estimated according to paragraph 2.2 on the basis of annual averaged stream flow. Annual averaged meteorological conditions concurrent with gaseous releases being evaluated are used to estimate atmospheric dispersion, deposition, and elevated plume gamma exposure.

The receptor of the dose is described such that the dose to any resident near the Station is not likely to be underestimated, although conditions more conservative than appropriate for the maximally exposed person may be assumed in the dose assessment.

Ordinarily, the receptor is selected on the basis of the applicable combination of existing pathways of exposure to gaseous effluent identified in the annual land use census and the maximum ground level χ/Q at the residence.

When assessing compliance with 40 CFR 190, Radiological Environmental Monitoring Program results may be used to indicate actual radioactivity levels in the environment attributable to the DAEC. These measured levels may be used to supplement the evaluation of doses to members of the public for assessing compliance with 40 CFR 190.

Factors converting stack-released noble gas to gamma radiation dose from the overhead plume are calculated on the basis of annual averaged meteorological data for the receptor location. Other environmental pathway-to-dose transfer factors are listed in Appendices A, B and C.

^c Radioactive iodine-131, iodine-133, tritium, and radioactive material in particulate form having half-lives greater than 8 days.

5.0 ENVIRONMENTAL MONITORING PROGRAMS

Section 5.0 of the ODAM provides a description of the Radiological Environmental Monitoring Program (REMP) and the Ground Water Protection Program (GWPP). This section also contains descriptions of the Environmental Sampling Program Station Locations.

5.1 Radiological Environmental Monitoring Program

A program shall be provided to monitor the radiation and radionuclides in the environs of the station.

The program shall provide:

- (1) representative measurements of radioactivity in the highest potential exposure pathways,
- (2) verification of the accuracy of the effluent monitoring program and modeling of environmental exposure pathways.

The program shall:

- (1) be contained in the ODAM,
- (2) conform to the guidance of Appendix I to 10 CFR Part 50 and 10 CFR 72,
- (3) include the following:
 - (a) Monitoring, sampling, analysis, and reporting of radiation and radionuclides in the environment in accordance with the methodology and parameters in the ODAM.
 - (b) A Land Use Census to ensure that changes in the use of areas at and beyond the SITE BOUNDARY are identified and that modifications to the monitoring program are made if required by the results of this census.
 - (c) Participation in an Interlaboratory Comparison Program to ensure that independent checks on the precision and accuracy of the measurements of radioactive materials in environmental sample matrices are performed as part of the quality assurance program for environmental monitoring.

5.2 Ground Water Protection Program (GWPP)

A program shall be provided to prevent, detect and respond to inadvertent and radiological releases with the potential to reach ground water.

The program shall provide:

- (1) for the prevention of inadvertent/unplanned radiological releases from plant systems, structures and components (SSCs) or during plant evolutions or work practices that represent an elevated risk of experiencing a release of licensed radiological material into the environment.

- (2) aspects for monitoring, detecting and responding to unplanned/unmonitored releases of licensed radioactive material to the environment and a communications/notification plan that addresses internal notifications to management and communications/reporting to State and local stakeholders and regulators for specified events or conditions.

The program shall:

- (1) be contained in the site administrative control procedure ACP 1411.35, "The DAEC Groundwater Protection Program".
- (2) implement the Ground Water Protection Initiative Final Guidance Document, NEI-07-07[Final].

5.3 Sampling Station Locations

ODAM Table 5-1 "ENVIRONMENTAL SAMPLE STATIONS" is a list of locations where samples may be collected and does not represent a list of required samples. Environmental monitoring locations are shown on Figures 5-1 and 5-2. DAEC may conduct additional environmental monitoring exclusive of the requirements of Specifications 6.3.2 and ACP 1411.35.

Figure 5-1
Environmental Monitoring Programs
Sampling Near the Duane Arnold Energy Center




Figure 5-2
Radiological Environmental Monitoring Program
Sampling Stations Outside 0.5 Miles from DAEC




Table 5-1
ENVIRONMENTAL SAMPLE STATIONS

| Station Number | Program | Station Location and Sample Type |
|----------------|---------|---|
| 1 | REMP | Location: Cedar Rapids, 20,800 meters SE Type: TLD Control Airborne Particulate and Iodine Control – Not Currently Active |
| 2 | REMP | Location: Marion, 16,900 meters ESE Type: TLD Control Airborne Particulate and Iodine Control – Not Currently Active |
| 3 | REMP | Location: Hiawatha, 10,800 meters SE Type: TLD Control Airborne Particulate and Iodine |
| 4 | | Not used |
| 5 | REMP | Location: Palo, 4,500 meters SSW Type: TLD Control |
| 6 | REMP | Location: Center Point, 9,660 meters N Type: TLD Control Airborne Particulate and Iodine |
| 7 | REMP | Location: Shellsburg, 7,950 meters W Type: TLD Control Airborne Particulate and Iodine |
| 8 | REMP | Location: Urbana, 15,000 meters NNW Type: TLD Control Airborne Particulate and Iodine Control – Not Currently Active |
| 9 | | Not Used |
| 10 | REMP | Location: Atkins, 13,600 meters SSW Type: TLD Control Airborne Particulate and Iodine Control – Not Currently Active |
| 11 | REMP | Location: Toddville, 4,980 meters E Type: TLD Control Airborne Particulate and Iodine |
| 12 | | Not Used |
| 13 | REMP | Location: Alburnett; 14,500 meters ENE Type: TLD Control Airborne Particulate and Iodine Control |
| 14 | | Not Used |
| 15 | REMP | Location: On-site, 1,050 meters NNW Type: TLD Airborne Particulate and Iodine |
| 15 a | GWPP | Location: On-site, 505 meters NNW Type: Soil |
| 16 | REMP | Location: On-site, 520 meters SSE Type: TLD Airborne Particulate and Iodine Vegetation |
| 16 | GWPP | Location: On-site, 520 meters SSE Type: Soil Precipitation |
| 17 | REMP | Location: On-site, 1,050 meters N Type: TLD |
| 18 | REMP | Location: 630 meters NNE Type: TLD |
| 19 | REMP | Location: On-site, 590 meters NE Type: TLD |

Table 5-1
ENVIRONMENTAL SAMPLE STATIONS

| Station Number | Program | Station Location and Sample Type |
|----------------|---------|---|
| 20 | REMP | Location: On-site, 550 meters ENE Type: TLD |
| 21 | REMP | Location: On-site, 515 meters ENE Type: TLD |
| 22 | REMP | Location: On-site, -535 meters ESE Type: TLD |
| 23 | REMP | Location: On-site, -490 meters SE Type: TLD |
| 24 | | Not Used |
| 25 | | Not Used |
| 26 | | Not Used |
| 27 | | Not Used |
| 28 | REMP | Location: On-site, 730 meters WSW Type: TLD |
| 29 | REMP | Location: On-site, 630 meters W Type: TLD |
| 30 | REMP | Location: On-site, 640 meters WNW Type: TLD |
| 31 | REMP | Location: On-site, 1,020 meters NW Type: TLD |
| 32 | REMP | Location: On-site, 1,110 meters NNW Type: TLD |
| 33 | REMP | Location: 4,340 meters N Type: TLD |
| 34 | REMP | Location: 3,930 meters NNE Type: TLD |
| 35 | REMP | Location: 2,800 meters NE Type: TLD |
| 36 | REMP | Location: 3,500 meters ENE Type: TLD |
| 37 | REMP | Location: 2,960 meters E Type: TLD |
| 38 | REMP | Location: 3,180 meters ESE Type: TLD |
| 39 | REMP | Location: 2,510 meters SE Type: TLD |
| 40 | REMP | Location: Wickiup Hill Learning Center 2,430 meters SSE Type: TLD Airborne Particulate and Iodine |
| 41 | REMP | Location: 5,680 meters S Type: TLD |
| 42 | REMP | Location: 4,380 meters SSE Type: TLD |
| 43 | REMP | Location: 1,590 meters SSW Type: TLD |
| 44 | REMP | Location: 1,580 meters WSW Type: TLD |

Table 5-1
ENVIRONMENTAL SAMPLE STATIONS

| Station Number | Program | Station Location and Sample Type |
|----------------|---------|--|
| 45 | REMP | Location: 1,420 meters W Type: TLD |
| 46 | REMP | Location: 1,580 meters WNW Type: TLD |
| 47 | REMP | Location: 1,760 meters NW Type: TLD |
| 48 | REMP | Location: 1,680 meters NNW Type: TLD |
| 49 | REMP | Location: Lewis Access, upstream of DAEC 6,750 meters NNW Type: Fish Control Surface Water Control |
| 50 | REMP | Location: Plant Intake, 560 meters SE Type: Bottom Sediment Control Surface Water |
| 51 | REMP | Location: Plant Discharge, 600 meters SE Type: Bottom Sediment Surface Water |
| 52 | | Not Used |
| 53 | REMP | Location: Treated Municipal Water, 13,900 meters SE Type: Ground Water |
| 54 | REMP | Location: Inlet to Municipal Water Treatment System, 13,900 meters SE Type: Ground Water |
| 55 | REMP | Location: On-site, Production Wells Type: Ground Water |
| 56 | | Not Used |
| 57 | REMP | Location: Farm, 805 meters W Type: Ground Water Vegetation |
| 58 | REMP | Location: Farm, 974 meters WSW-SW Type: Ground Water |
| 59 | | Not Used |
| 60 | | Not Used |
| 61 | REMP | Location: Cedar River, 670 meters SSE Type: Fish Surface Water |
| 62 | | Not Used |
| 63 | | Not Used |
| 64 | | Not Used |
| 65 | | Not Used |
| 66 | | Not Used |
| 67 | | Not Used |
| 68 | | Not Used |
| 69 | | Not Used |
| 70 | | Not Used |
| 71 | | Not Used |
| 72 | REMP | Location: Farm, 3,200 meters SSW Type: Ground Water |

Table 5-1
ENVIRONMENTAL SAMPLE STATIONS

| Station Number | Program | Station Location and Sample Type |
|----------------|---------|--|
| 73 | | Not Used |
| 74 | | Not Used |
| 75 | | Not Used |
| 76 | | Not Used |
| 77 | | Not Used |
| 78 | | Not Used |
| 79 | | Not Used |
| 80 | | Not Used |
| 81 | | Not Used |
| 82 | REMP | Location: On-site, 660 meters SSE Type: TLD |
| 83 | REMP | Location: On-site, 620 meters SSE Type: TLD |
| 84 | REMP | Location: On-site, 610 meters S Type: TLD |
| 85 | REMP | Location: On-site, 660 meters SSW Type: TLD |
| 86 | REMP | Location: On-site, 850 meters SW Type: TLD |
| 87 | | Not Used |
| 88 | | Not Used |
| 89 | | Not Used |
| 90 | | Not Used |
| 91 | REMP | Location: On-site, 1,090 meters NNW Type: TLD |
| 92 | | Not Used |
| 93 | | Not Used |
| 94 | | Not Used |
| 95 | | Not Used |
| 96 | REMP | Location: Farm, 11,400 meters SSW Type: Vegetation |
| 97 | | Not Used |
| 98 | | Not Used |
| 99 | REMP | Location: Pleasant Creek Lake, 3,880 meters WNW Type: Surface Water |
| 100 | | Not Used |
| 101 | | Not Used |
| 102 | | Not Used |
| 103 | | Not Used |
| 104 | | Not Used |
| 105 | | Not Used |
| 106 | | Not Used |
| 107 | GWPP | Location: DAEC Sewage Plant Effluent Type: Surface Water |
| 107 a | REMP | Location: On-site: North Drainage Ditch Type: Bottom Sediments |
| 109 | REMP | Location: 5,890 meters SW |

Table 5-1
ENVIRONMENTAL SAMPLE STATIONS

| Station Number | Program | Station Location and Sample Type |
|----------------|---------|---|
| | | Type: Vegetation |
| 110 | REMP | Location: 12,700 meters SW Type: Milk |
| 111 | GWPP | Location: Onsite Monitoring Wells MW01A and MW01B (SSE) Type: Ground Water Precipitation |
| 112 | GWPP | Location: Onsite Monitoring Wells MW02A and MW02B (ESE) Type: Ground Water Precipitation |
| 113 | GWPP | Location: Onsite Monitoring Wells MW03A and MW03B (NW) Type: Ground Water |
| 114 | GWPP | Location: Onsite Monitoring Wells MW04A and MW04B (South) Type: Ground Water Precipitation |
| 115 | GWPP | Location: Onsite Monitoring Wells MW05A and MW05B (SSW) Type: Ground Water Precipitation |
| 116 | GWPP | Location: Onsite Monitoring Wells MW06A and MW06B (NE) Type: Ground Water Precipitation |
| 117 | | Not Used |
| 118 | REMP | Location: 2,230 meters NW Type: Vegetation |
| 119 | GWPP | Location: MH209, 240 meters ESE Type: Surface Water (Electrical Vault) |
| 120 | GWPP | Location: MH210, 380 meters SE Type: Surface Water (Electrical Vault) |
| 121 | GWPP | Location: MH211, 530 meters SE Type: Surface Water (Electrical Vault) |
| 122 | GWPP | Location: Onsite Sluice Pond, (SSW) Type: Surface Water |
| 123 | GWPP | Location: Onsite South Drainage Ditch Type: Surface Water |
| 124 | GWPP | Location: Onsite North Drainage Ditch Type: Surface Water |
| 125 | GWPP | Location: Onsite South Storm Drain Outfall Type: Surface Water |
| 127 | GWPP | Location: Protected Area, North of CST Pit, Monitoring Wells MW07A and MW07B Type: Ground Water Precipitation |
| 128 | GWPP | Location: Protected Area, CAD Shack, Monitoring Wells MW08A and MW08B Type: Ground Water Precipitation |
| 129 | GWPP | Location: Protected Area, SE Corner of CST Pit, Monitoring Wells MW09A and MW09B Type: Ground Water |
| 130 | GWPP | Location: Protected Area, SW Corner of CST Pit, Monitoring Wells MW10A and MW10B Type: Ground Water |
| 131 | GWPP | Location: On-site Monitoring Wells MW11A and 11B (South) Type: Ground Water |
| | | |

Table 5-1
ENVIRONMENTAL SAMPLE STATIONS

| Station Number | Program | Station Location and Sample Type | |
|----------------|---------|----------------------------------|--|
| 132 | GWPP | Location: | On-site Monitoring Wells MW12A and MW12B (SE) |
| | | Type: | Ground Water |
| 133 | GWPP | Location: | On-site Monitoring Wells MW13A and MW13B (SW) |
| | | Type: | Ground Water |
| 134 | GWPP | Location: | On-site Monitoring Wells MW14A and MW14B (SSE) |
| | | Type: | Ground Water |
| 135 | GWPP | Location: | On-site Monitoring Wells MW15A and MW15B (ESE) |
| | | Type: | Ground Water |
| 136 | GWPP | Location: | On-site Monitoring Wells MW16A and MW16B (ENE) |
| | | Type: | Ground Water |
| 137 | GWPP | Location: | On-site Monitoring Well MW17C (NE) |
| | | Type: | Ground Water (Limestone Aquifer) |
| 138 | REMP | Location: | 21,600 meters WSW |
| | | Type: | Milk Control |
| | | | Vegetation Control |
| 161 | REMP | Location: | On-site, ISFSI, East Fence Line |
| | | Type: | TLD |
| 162 | REMP | Location: | On-site, ISFSI, South Fence Line |
| | | Type: | TLD |
| 163 | REMP | Location: | On-site, ISFSI, West Fence Line |
| | | Type: | TLD |
| 164 | REMP | Location: | On-site, ISFSI, North Fence Line |
| | | Type: | TLD |

O 6.0.1 USE AND APPLICATION

O 6.0.1.1 Definitions

NOTE

The defined terms of this section appear in capitalized type and are applicable throughout these OLCOs and Bases

| <u>Term</u> | <u>Definition</u> |
|-------------------------|---|
| ACTIONS | ACTIONS shall be that part of a ODAM Specification that prescribes Required Actions to be taken under designated Conditions within specified Completion Times. |
| CHANNEL CALIBRATION | A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel output such that it responds within the necessary range and accuracy to known values of the parameter that the channel monitors. The CHANNEL CALIBRATION shall encompass the entire channel, including the required sensor, alarm, display, and trip functions, and shall include the CHANNEL FUNCTIONAL TEST. The CHANNEL CALIBRATION may be performed by means of any series of sequential, overlapping, or total channel steps so that the entire channel is calibrated. |
| CHANNEL | A channel is an arrangement of a sensor and associated components used to evaluate plant variables and produce discrete outputs used in logic. A channel terminates and loses its identity where individual channel outputs are combined in logic. |
| CHANNEL CHECK | A CHANNEL CHECK shall be the qualitative assessment, by observation, of channel behavior during operation. This determination shall include, where possible, comparison of the channel indication and status to other indications or status derived from independent instrument channels measuring the same parameter. |
| CHANNEL FUNCTIONAL TEST | A CHANNEL FUNCTIONAL TEST shall be the injection of a simulated or actual signal into the channel as close to the sensor as practicable to verify OPERABILITY, including required alarm, interlock, display, and trip functions, and channel failure trips. The CHANNEL FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total channel steps. |

(continued)

6.0.1.1 Definitions (continued)

| | |
|-----------------------------------|--|
| GASEOUS RADWASTE TREATMENT SYSTEM | A GASEOUS RADWASTE TREATMENT SYSTEM is any system designed and installed to reduce radioactive gaseous effluents by collecting primary coolant system offgases from the primary system and providing delay or holdup for the purpose of reducing radioactivity prior to release to the environment. |
| MEMBER(S) OF THE PUBLIC | MEMBER(S) OF THE PUBLIC are persons who are not occupationally associated with the Company and who do not normally frequent the DAEC site. The category does not include contractors, contractor employees, vendors, or persons who enter the site to make deliveries or to service equipment. |
| MODE | A MODE shall correspond to any on inclusive combination of mode switch position, average reactor coolant temperature, and reactor vessel head closure bolt tensioning specified in Technical Specifications Table 1.1-1 with fuel in the reactor vessel. |
| OPERABLE-OPERABILITY | A system, subsystem, division, component, or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified safety function(s) and when all necessary attendant instrumentation, controls, normal or emergency electrical power, cooling and seal water, lubrication, and other auxiliary equipment that are required for the system, subsystem, division, component, or device to perform its specified safety function(s) are also capable of performing their related support function(s). |
| SITE BOUNDARY | The SITE BOUNDARY is that line beyond which the land is neither owned, nor leased, nor otherwise controlled by the Company. UFSAR Figure 1.2-1 identifies the DAEC SITE BOUNDARY. |
| SOURCE CHECK | A SOURCE CHECK is the assessment of channel response when the channel sensor is exposed to a source of radiation. |
| UNRESTRICTED AREA | The UNRESTRICTED AREA is that land (offsite) beyond the SITE BOUNDARY. |

O 6.0.1 USE AND APPLICATION

O 6.0.1.2 Logical Connectors

PURPOSE

The purpose of this section is to explain the meaning of logical connectors.

Logical connectors are used in offsite Dose Assessment Manual (ODAM) to discriminate between, and yet connect, discrete Conditions, Required Actions, Completion Times, Surveillances, and Frequencies. The only logical connectors that appear in the ODAM are AND and OR. The physical arrangement of these connectors constitutes logical conventions with specific meanings.

BACKGROUND

Several levels of logic may be used to state Required Actions. These levels are identified by the placement (or nesting) of the logical connectors and by the number assigned to each Required Action. The first level of logic is identified by the first digit of the number assigned to a Required Action and the placement of the logical connector in the first level of nesting (i.e., left justified with the number of the Required Action). The successive levels of logic are identified by additional digits of the Required Action number and by successive indentations of the logical connectors. When logical connectors are used to state a Condition, Completion Time, Surveillance, or Frequency, only the first level of logic is used, and the logical connector is left justified with the statement of the Condition, Completion Time, Surveillance, or Frequency.

EXAMPLES

The ODAM uses Logical Connectors in precisely the same manner they are used in the Technical Requirements Manual (TRM) and the Technical Specifications (TS).

Examples illustrating the use of logical connectors are found in TS 1.2 and in the TRM T1.2

O 6.0.1 USE AND APPLICATION

O 6.0.1.3 Completion Times

| | |
|-------------|---|
| PURPOSE | The purpose of this section is to establish the Completion Time convention and to provide guidance for its use. |
| BACKGROUND | OLCOs specify minimum requirements for ensuring safe operation of the unit. The ACTIONS associated with a OLCO state Conditions that typically describe the ways in which the requirements of the OLCO can fail to be met. Specified with each stated Condition are Required Action(s) and Completion Times(s). |
| DESCRIPTION | <p>The Completion Time is the amount of time allowed for completing a Required Action. It is referenced to the time of discovery of a situation (e.g., inoperable equipment or variable not within limits) that requires entering an ACTIONS Condition unless otherwise specified, providing the unit is in a MODE or specified condition stated in the Applicability of the OLCO. Required Actions must be completed prior to the expiration of the specified Completion Time. An ACTIONS Condition remains in effect and the Required Actions apply until the Condition no longer exists or the unit is not within the OLCO Applicability.</p> <p>If situations are discovered that require entry into more than one Condition at a time within a single OLCO (multiple Conditions), the Required Actions for each Condition must be performed within the associated Completion Time. When in multiple Conditions, separate Completion Times are tracked for each Condition starting from the time of discovery of the situation that required entry into the Condition.</p> <p>Once a Condition has been entered, subsequent divisions, subsystems, components, or variables expressed in the Condition, discovered to be inoperable or not within limits, will not result in separate entry into the Condition unless specifically stated. The Required Actions of the Condition continue to apply to each additional failure, with Completion Times based on initial entry into the Condition.</p> |

(continued)

O 6.0.1.3 Completion Times (continued)

However, when a subsequent division, subsystem, component, or variable expressed in the Condition is discovered to be inoperable or not within limits, the Completion Time(s) may be extended. To apply this Completion Time extension, two criteria must first be met. The subsequent inoperability:

- a. Must exist concurrent with the first inoperability;
and
- b. Must remain inoperable or not within limits after the first inoperability is resolved.

The total Completion Time, as measured from discovery of the subsequent inoperability.

The above Completion Time extensions do not apply to those OLCOs that have exceptions that allow completely separate re-entry into the Condition (for each division, subsystem, component or variable expressed in the Condition) and separate tracking of Completion Times based on this re-entry. These exceptions are stated in individual OLCOs.

The above Completion Time extension does not apply to a Completion Time with a modified "time zero." This modified "time zero" may be expressed as a repetitive time (i.e., .. once per 8 hours.) where the Completion Time is referenced from a previous completion of the Required Action versus the time of Condition entry) or as a time modified by the phrase "from discovery . . ."

When "Immediately" is used as a Completion Time, the Required Action should be pursued without delay and in a controlled manner.

The ODAM implements Completion Times in precisely the same manner they are applied in the Technical Requirements Manual (TRM) and the Technical Specifications (TS).

Examples illustrating the implementation of Completion Times are found in TS 1.3 and in the TRM T1.3.

Frequency
O 6.0.1.4

O 6.0.1 USE AND APPLICATION

O 6.0.1.4 Frequency.

| | |
|-------------|---|
| PURPOSE | The purpose of this section is to define the proper use and application of Frequency Requirements. |
| DESCRIPTION | <p>Each ODAM Surveillance Requirement (OSR) has a specified Frequency in which the Surveillance must be met in order to meet the associated OLCO. An understanding of the correct application of the specified Frequency is necessary for compliance with the OSR.</p> <p>The "specified Frequency" is referred to throughout this section and each of the Specifications of Section 6.0.3.0, Surveillance Requirement (SR) Applicability. The "specified Frequency" consists of the requirements of the Frequency column of each OSR, as well as certain Notes in the Surveillance column that modify performance requirements.</p> <p>Sometimes special situations dictate when the requirements of a Surveillance are to be met. They are "otherwise stated" conditions allowed by OSR 7.0.3.0.1. They may be stated as clarifying Notes in the Surveillance, as part of the Surveillance or both.</p> <p>Situations where a Surveillance could be required (i.e., its Frequency could expire), but where it is not possible or not desired that it be performed until sometime after the associated OLCO is within its Applicability, represent potential OSR 7.0.3.0.4 conflicts. To avoid these conflicts, the OSR (i.e., the Surveillance or the Frequency) is stated such that it is only "required" when it can be and should be performed. With an OSR satisfied, OSR 6.0.3.0.4 imposes no restriction.</p> <p>The use of "met" or "performed" in these instances conveys specific meanings. A Surveillance is "met" only when the acceptance criteria are satisfied. Known failure of the requirements of a Surveillance, even without a Surveillance specifically being "performed," constitutes a Surveillance not "met." "Performance" refers only to the requirement to specifically determine the ability to meet the acceptance criteria. OSR 7.0.3.0.4 restrictions would not apply if both the following conditions are satisfied:</p> <ol style="list-style-type: none">a. The surveillance is not required to be performed; andb. The Surveillance is not required to be met or, even if required to be met, is not known to be failed. |
| EXAMPLES | The ODAM implements Frequency in precisely the same manner they as it is employed in the Technical Requirements Manual (TRM) and the Technical Specifications (TS). Examples illustrating the use of logical connectors are found in TS 1.4 and in the TRM T1.4. |

LCO Applicability
O 6.0.3.0

6.0.3 Limiting Conditions for Operation (OLCO) Applicability

OLCO 6.0.3.0.1 OLCOs shall be met during the MODES or other specified conditions in the Applicability, except as provided in OLCO 6.0.3.0.2.

OLCO 6.0.3.0.2 Upon discovery of a failure to meet an OLCO, the Required Actions of the associated Conditions shall be met, except as provided in OLCO 6.0.3.0.5. If the OLCO is met or is no longer applicable prior to expiration of the specified Completion Time(s), completion of the Required Action(s) is not required, unless otherwise stated.

OLCO 6.0.3.0.3 Not Used.

OLCO 6.0.3.0.4 When an OLCO is not met, entry into a MODE or other specified condition in the Applicability shall not be made except when the associated ACTIONS to be entered permit continued operation in the MODE or other specified condition in the Applicability for an unlimited period of time. This OLCO shall not prevent changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

OLCO 6.0.3.0.4 Exceptions to this OLCO are stated in the individual OLCOs. These exceptions allow entry into MODES or other specified conditions in the Applicability when the associated ACTIONS to be entered allow unit operation in the MODE or other specified condition in the Applicability only for a limited period of time.

OLCO 6.0.3.0.4 is only applicable for entry into a MODE or other specified condition in the Applicability in MODES 1, 2, and 3.

OLCO 6.0.3.0.5 Equipment removed from service or declared inoperable to comply with ACTIONS may be returned to service under administrative control solely to perform testing required to demonstrate its OPERABILITY or the OPERABILITY of other equipment. This is an exception to OLCO 6.0.3.0.2 for the system returned to service under administrative control to perform the testing required to demonstrate OPERABILITY.

(continued)

6.0.3 Limiting Conditions for Operation (OLCO) Applicability (continued)

- OLCO 6.0.3.0.6 When An ODAM supported system OLCO is not met solely due to a TS support system OLCO not being met, the ODAM Conditions and Required Actions associated with this supported system are not required to be entered. Only the TS support system OLCO ACTIONS are required to be entered. This is an exception to OLCO 6.0.3.0.2 for the ODAM supported system.
- When a support system's Required Action (either TS or ODAM) directs a supported system in the ODAM to be declared inoperable or directs entry into Conditions and Required Actions for a ODAM supported system, the applicable ODAM Conditions and Required Actions shall be entered in accordance with ODAM 6.0.3.0.2
- When a TS supported system OLCO is not met solely due to a ODAM support system OLCO not being met, the TS supported system Conditions and Required Actions are required to be entered Immediately, under the definition of OPERABILITY, as neither TS LCO 3.0.6 or ODAM OLCO 6.0.3.0.6 apply.
- When an inoperable Technical Specification support system, structure, or component, (SSC) provides support to a ODAM SSC, which, in turn, supports a supported SSC addressed in the Technical Specifications, Technical Specification LCO 3.0.6 remains applicable.
-

OSR Applicability
O 7.0.3.0

O 7.0.3 SURVEILLANCE REQUIREMENT (OSR) APPLICABILITY

OSR 7.0.3.0.1 OSRs shall be met during the MODES or other specified conditions in the Applicability for individual OLCOs, unless otherwise stated in the OSR. Failure to meet a Surveillance, whether such failure is experienced during the performance of the Surveillance or between performances of the Surveillance, shall be failure to meet the OLCO. Failure to perform a Surveillance within the specified Frequency shall be failure to meet the OLCO except as provided in OSR 7.0.3.0.3. Surveillances do not have to be performed on inoperable equipment or variables outside specified limits.

OSR 7.0.3.0.2 The specified Frequency for each OSR is met if the Surveillance is performed within 1.25 times the interval specified in the Frequency, as measured from the previous performance or as measured from the time a specified condition of the Frequency is met.

For Frequencies specified as "once," the above interval extension does not apply.

If a Completion Time requires periodic performance on a "once per . . ." basis, the above Frequency extension applies to each performance after the initial performance. Exceptions to this OSR are stated in the individual OLCOs.

OSR 7.0.3.0.3 If it is discovered that a Surveillance was not performed within its specified Frequency, then compliance with the requirement to declare the OLCO not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified Frequency, whichever is more. This delay period is permitted to allow performance of the Surveillance.

If the Surveillance is not performed within the delay period, the OLCO must immediately be declared not met, and the applicable Condition(s) must be entered.

When the Surveillance is performed within the delay period and the Surveillance is not met, the OLCO must immediately be declared not met, and the applicable Condition(s) must be entered.

OSR 7.0.3.0.4 Entry into a MODE or other specified condition in the Applicability of an OLCO shall not be made unless the OLCO's Surveillances have been met within their specified Frequency. This provision shall not prevent entry into MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

OSR 7.0.3.0.4 is only applicable for entry into a MODE or other specified condition in the Applicability in MODES 1, 2, and 3.

O 6.1

RADIOACTIVE LIQUID EFFLUENT CONTROLS

O 6.1.1

Radioactive Liquid Instrumentation

OLCO 6.1.1

The Radioactive Liquid Instrumentation for each function in Table 6.1-1 shall be OPERABLE with their alarm and trip setpoints set to ensure that the limits of Section 6.1.2 are not exceeded.

APPLICABILITY:

As shown in Table 6.1-1

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|--|
| A. One or more channels inoperable | <p>A.1 Enter the condition(s) referenced in Table 6.1-1 for the channel(s).</p> <p><u>AND</u></p> <p>A.2 Restore required channel(s) to OPERABLE status.</p> | Immediately 30 days |
| B. As required by Required Action A.1 and referenced in Table 6.1-1 | <p>B.1 Obtain at least two samples and analyze in accordance with Section 6.1.2 and Table 7.1-2</p> <p><u>AND</u></p> <p>B.1 Independently verify release rate calculations and discharge valving by technically qualified Facility Staff member.</p> | Prior to release Prior to release |
| C. As required by Required Action A.1 and referenced in Table 6.1-1 | C.1 Obtain sample and analyze for either gross beta/gamma or gamma radioactivity. | Once per 8 Hours |
| D. Less than the minimum required channels OPERABLE. | D.1 Estimate flow rate at least once per batch. | Immediately |

(continued)

Radioactive Liquid Instrumentation
O 6.1.1

O 6.1.1

Radioactive Liquid Instrumentation (continued)

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|--|
| E. Required Action and associated Completion Time of Condition A not met. | E.1 Explain in next Annual Radioactive Material Release Report why the instrument was not made operable in a timely manner. | Next submittal of the Annual Radioactive Material Release Report |

SURVEILLANCE REQUIREMENTS

-----NOTE-----

Instrumentation shall be OPERABLE and in service except that channels out of service are permitted for the purpose of required tests, checks, and calibrations without declaring the channel to be inoperable.

| SURVEILLANCE | | FREQUENCY |
|--------------|---------------------------------------|------------------|
| OSR 7.1.1.1 | Perform CHANNEL CHECK | 24 Hours |
| OSR 7.1.1.2 | Perform SOURCE CHECK | 24 Hours |
| OSR 7.1.1.3 | Perform SOURCE CHECK | 30 Days |
| OSR 7.1.1.4 | Perform CHANNEL FUNCTIONAL TEST | 92 Days |
| OSR 7.1.1.5 | Perform CHANNEL CALIBRATION | 18 Months |
| OSR 7.1.1.6 | Perform Monitor Setpoint Calculation. | 18 Months |
| OSR 7.1.1.7 | Perform CHANNEL FUNCTIONAL TEST | Prior to release |
| OSR 7.1.1.8 | Perform CHANNEL CALIBRATION | Prior to release |
| OSR 7.1.1.9 | Perform Monitor Setpoint Calculation. | Prior to release |

TABLE 6.1-1 / 7.1-1
RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

| Instrument | Applicability | Minimum Channels Operable | Conditions Referenced from Required Action A.1 | Surveillance Requirements |
|---|-----------------|---------------------------|--|---|
| 1. Gross Radioactive Monitors Providing Automatic Termination of Release | | | | |
| a. Liquid Radwaste Effluent Line | During Releases | 1 | B | OSR 7.1.1.1 ^(a) OSR 7.1.1.2 ^(b) OSR 7.1.1.7 ^(d) ^(e) OSR 7.1.1.8 ^(c) OSR 7.1.1.9 |
| 2. Gross Radioactive Monitors Not Providing Automatic Termination of Release | | | | |
| a. RHR Service Water System | During Releases | 1 | | OSR 7.1.1.1 ^(a) OSR 7.1.1.3 |
| b. General Service Water System | During Releases | 1 | C | OSR 7.1.1.4 ^(e) OSR 7.1.1.5 ^(c) OSR 7.1.1.6 |
| c. RHRSW/ESW Rupture Disc Effluent Line | During Releases | 1 | | |
| 3. Flow Rate Measurement Devices | | | | |
| a. Liquid Radwaste Effluent Line | During Releases | 1 | D | OSR 7.1.1.1 ^(a) ^(f) OSR 7.1.1.7 OSR 7.1.1.8 |
| b. Liquid Radwaste Dilution Line | During Releases | 1 | | |

TABLE NOTATIONS

- (a) During releases via this pathway.
- (b) On any day on which a release is made, a SOURCE CHECK shall be made at least once, prior to the first release.
- (c) The CHANNEL CALIBRATION shall include the use of a known radioactive source (traceable to the NIST radiation measurement system or acceptable non-NIST standards) positioned in a reproducible geometry with respect to the sensor and emitting beta or gamma radiation in the range measured by the channel. CHANNEL CALIBRATION may normally be done during refueling outages.
- (d) The CHANNEL FUNCTIONAL TEST shall also demonstrate that automatic isolation of this pathway if the following condition exists:
 1. Instrument indicates measured levels above the alarm/trip setpoint.
- (e) The CHANNEL FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exist:
 1. Instrument indicates measured levels above the alarm/trip setpoint.
 2. Circuit failure.
 3. Instrument indicates a downscale failure.
 4. Instrument controls not set in operate mode.
- (f) CHANNEL CHECK shall consist of verifying indication of flow during periods of release. CHANNEL CHECK shall be made at least once daily on any day on which continuous, periodic, or batch releases are made.

Radioactive Liquid Instrumentation
O 6.1.1

O 6.1

RADIOACTIVE LIQUID EFFLUENT CONTROLS

O 6.1.2

Liquid Effluent Concentration

OLCO 6.1.2

The concentration of radioactive material in liquid effluent released from the site to the UNRESTRICTED AREA shall not exceed ten times the concentrations specified in 10 CFR 20, Appendix B, Table 2, Column 2 to 10 CFR 20.1001 - 20.2402.

APPLICABILITY: At all times.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| A. Concentration of radioactive material released from site to UNRESTRICTED AREAS not within the limit. | A.1 Restore concentration to within limits. | Immediately |

SURVEILLANCE REQUIREMENTS

NOTE-----

Refer to ODAM Table 7.1-2 for details concerning Sampling and Analysis

| | SURVEILLANCE | FREQUENCY |
|-------------|--|-----------------------|
| OSR 7.1.2.1 | <p>----- NOTE-----</p> <p>Portions of each sample are "split out" and added to the Monthly and Quarterly Composite sample.</p> <p>----- Sample the Batch Release.</p> | PRIOR TO EACH RELEASE |
| OSR 7.1.2.2 | <p>The results of pre-release analyses shall be used with the calculational methods in the ODAM to establish trip setpoints for batch releases to assure that the concentration at the UNRESTRICTED AREA boundary does not exceed the limit in OLCO 6.1.2.</p> | PRIOR TO EACH RELEASE |
| OSR 7.1.2.3 | <p>----- NOTE-----</p> <p>Portions of each sample are split out and added to the Monthly and Quarterly Composite sample.</p> <p>----- NOTE-----</p> <p>In the event of a positive identification of reactor by-product radioactivity in the service water, additional sampling and analysis shall be performed as specified in Table 7.1-2, Table Items B.2 through B.5.</p> <p>----- Sample the Continuous Release during releases to the environment via this pathway. <u>AND</u></p> <p>Analyze the sample from the release for Gross Beta/Gamma.</p> <p><u>OR</u></p> <p>Analyze the sample from the release for Principal Gamma Emitters and I-131.</p> | 7 Days |

(continued)

Radioactive Liquid Effluent Concentration
O 7.1.2

| | | |
|-------------|--|-----------------------|
| OSR 7.1.2.4 | Analyze the sample from the release for Principal Gamma Emitters and I-131. | PRIOR TO EACH RELEASE |
| OSR 7.1.2.5 | Analyze the "Monthly" Composite sample for Tritium. | 30 Days |
| OSR 7.1.2.6 | <p>-----NOTE-----</p> <p>For Service Water, this OSR is only required following a positive identification of reactor by-product radioactivity in the sample as determined during OSR 7.1.2.3 or OSR 7.1.2.5.</p> <p>-----NOTE-----</p> <p>For "clean" water systems, this OSR is only required following a positive identification of reactor by-product radioactivity in the sample as determined during OSR 7.1.2.4.</p> <p>Analyze the Quarterly Composite sample for Sr-89, Sr-90, Fe-55</p> | 92 Days |
| OSR 7.1.2.7 | Analyze the "Monthly" Composite sample for Gross Alpha. | 30 Days |

Radioactive Liquid Effluent Concentration
O 6.1.2

TABLE 7.1-2
RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM

| Liquid Release Type | Surveillance Requirements | Table item/note | Type of Activity Analysis | Lower Limit of Detection (LLD) ^(a) ($\mu\text{Ci/mL}$) |
|--|------------------------------|---------------------------------|---|---|
| A. Radwaste Tanks Batch Release | OSR 7.1.2.1 | A.1: Each Batch | Principal Gamma Emitters ^c | 5×10^{-7} |
| | OSR 7.1.2.4 | | I-131 ^c | 1×10^{-6} |
| | OSR 7.1.2.2 | | | |
| | OSR 7.1.2.1 | | H-3 | 1×10^{-5} |
| | OSR 7.1.2.5 | | | |
| | OSR 7.1.2.7 | A.3: ^{(d)(b)} | Gross alpha | 1×10^{-7} |
| | OSR 7.1.2.1 | | Sr-89, Sr-90 | 5×10^{-8} |
| | OSR 7.1.2.6 | | Fe-55 | 1×10^{-6} |
| | | | | |
| | | | | |
| B. Continuous Service Water Release | OSR 7.1.2.3 | B.1: ^(d) | Gross beta/gamma | 1×10^{-7} |
| | OSR 7.1.2.3 | | Principal Gamma Emitters | 5×10^{-7} |
| | Sample Points: | | I-131 | 1×10^{-6} |
| | • General Services Water | | | |
| | • RHR Service Water System A | | H-3 | 1×10^{-5} |
| | • RHR Service Water System B | | | |
| | OSR 7.1.2.5 | B.4: ^{(b), (d)} | Gross alpha | 1×10^{-7} |
| | OSR 7.1.2.7 | | Sr-89, Sr-90 | 5×10^{-8} |
| | OSR 7.1.2.6 | | Fe-55 | 1×10^{-6} |
| | | | | |
| | | | | |
| C. "Clean" Systems Batch Release | OSR 7.1.2.1 | C.1: | Principal Gamma Emitters ^(f) | 5×10^{-7} |
| | OSR 7.1.2.4 | | I-131 ^(f) | 1×10^{-6} |
| | Sample Points: | | | |
| | OSR 7.1.2.5 | | H-3 ^(f) | 1×10^{-5} |
| | OSR 7.1.2.6 | C.3: ^{(b) (d)} | Sr-89, Sr-90 | 5×10^{-8} |
| | | | Fe-55 | 1×10^{-6} |
| | | | | |
| | | | | |
| | | | | |

TABLE NOTATIONS

- (a) The LLD is defined, for purposes of these controls, as the smallest concentration of radioactive material in a sample that will yield a net count, above system background, that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a "real" signal.

Radioactive Liquid Effluent Concentration

O 6.1.2

For a particular measurement, which may include radiochemical separation:

$$LLD = \frac{4.66 S_b}{E \times V \times 2.22E6 \times e^{-\lambda t}}$$

where:

LLD is the "a priori" lower limit of detection as defined above (microcuries per unit mass or volume)

and where:

S_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (counts per minute)

E is the counting efficiency (counts per disintegration)

V is the sample size (units of mass or volume)

2.22E6 is the number of disintegrations per minute per microcurie,

Y is the fractional radiochemical yield, when applicable,

λ is the radioactive decay constant for the particular radionuclide (sec^{-1}), and

Δt for effluents is the elapsed time between the midpoint of sample collection and the time of counting (sec^{-1}).

Alternatively, exp may be replaced by

$$\frac{\lambda t_1 e^{-\lambda t_2}}{1 - e^{-\lambda t_1}} \cdot e^{-\lambda t_2}$$

Where:

t_1 is the total sampling time or sample compositing time

t_2 is the elapsed time between the end of sample collection and the time of counting.

It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of a measurement system and not as an a posteriori (after the fact) limit for a particular measurement.

Analyses shall be performed in such a manner that the stated LLDs will be achieved under routine conditions with typical values of E, V, Y, and Dt for the radionuclides Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141, and Ce-144. Occasionally background fluctuations, unavoidably small sample sizes, interfering radionuclides, or other uncontrollable circumstances may render these LLDs unachievable.

When calculating the LLD for a radionuclide determined by gamma ray spectrometry, the background may include the typical contributions of other radionuclides normally present in the samples. The background count rate of a Ge(Li) detector is determined from background counts that are determined to be within the full width of the specific energy band used for the quantitative analysis for that radionuclide.

The principal gamma emitters for which the LLD specification will apply are exclusively the following radionuclides: Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137 and Ce-141. Ce-144 shall be measured, but with an LLD of 5E-6. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD for the analyses should not be reported as being present at the LLD level. When unusual circumstances result in LLDs higher than required, the reasons shall be documented in the Annual Radioactive Material Release Report.

- (b) A composite sample is one in which the quantity of liquid sampled is proportional to the quantity of liquid waste discharged and in which the method of sampling employed results in a specimen which is representative of the liquids released.
- (c) In the event a gross β or γ analysis is performed in lieu of an isotopic analysis before a batch is discharged, a sample shall be analyzed for principal gamma emitters afterward.
- (d) Analysis may be performed after release.
- (e) Analysis at a frequency of less than 30 days is allowed.
- (f) If liquids from these systems are released from the site via a pathway that is NOT directly to the Cedar River, the required LLDs of Table 6.3.2 are applicable.

Dose Due to Liquid Radioactive Effluents

O 6.1.3

O 6.1

RADIOACTIVE LIQUID EFFLUENT CONTROLS

O 6.1.3

Dose Due to Liquid Radioactive Effluents

OLCO 6.1.3

The dose or dose commitment to a MEMBER OF THE PUBLIC from radioactive materials in liquid effluents released to the UNRESTRICTED AREA shall not exceed:

1.5 mrem to the total body during any calendar quarter,
5.0 mrem to any organ during any calendar quarter,
3.0 mrem to the total body during any calendar year, or
10.0 mrem to any organ during any calendar year.

APPLICABILITY: At All Times

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| A. Calculated dose from the release of radioactive materials in liquid effluents exceeds limits. | A.1 Prepare and submit a Special Report to the Commission which identifies the cause(s) for exceeding the limit and defines the action to be taken. | 30 days |

Dose Due to Liquid Radioactive Effluents
O 7.1.3

SURVEILLANCE REQUIREMENTS

| | SURVEILLANCE | FREQUENCY |
|-------------|--|------------------|
| OSR 7.1.3.1 | In any quarter in which radioactive liquid effluent is discharged, an assessment shall be performed in accordance with the ODAM in order to verify that the cumulative dose commitment does not exceed the limits in OLCO 6.1.3. | 30 Days |

Liquid Waste Treatment
O 6.1.4

O 6.1

RADIOACTIVE LIQUID EFFLUENT CONTROLS

O 6.1.4

Liquid Waste Treatment

OLCO 6.1.4

Appropriate liquid radwaste equipment shall be used to treat any untreated batch of liquid waste prior to discharge when a pre-released analysis indicates a radioactivity concentration (exclusive of tritium and dissolved gases) of 0.01 $\mu\text{Ci}/\text{ml}$ or higher.

APPLICABILITY: At all times.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| A. Radioactive liquid waste being discharge without treatment and in excess of limits. | A.1 Prepare and submit a Special Report to the Commission which includes identification of inoperable equipment or subsystems and the reason, actions taken to restore the inoperable equipment, and description of action(s) taken to prevent recurrence. | 30 days |

Liquid Waste Treatment
O 7.1.4

SURVEILLANCE REQUIREMENTS

| | SURVEILLANCE | FREQUENCY |
|-------------|---|-----------------------|
| OSR 7.1.4.1 | Each radioactive liquid waste batch shall be sampled and analyzed in accordance with Section 7.1.2 and Table 7.1-2. | PRIOR TO EACH RELEASE |

Liquid Holdup Tanks
O 6.1.5

O 6.1 RADIOACTIVE EFFLUENT CONTROLS
O 6.1.5 Liquid Holdup Tanks

OLCO 6.1.5 The quantity of radioactive material contained in the unprotected outdoor tanks shall be limited to less than or equal to 50 Curies, excluding tritium and dissolved or entrained noble gases.

APPLICABILITY: At all times.

ACTIONS

NOTE

Tanks included in this specification are those outdoor tanks that are not surrounded by liners, dikes, or walls capable of holding the tanks' contents and that do not have tank overflows and surrounding area drains connected to the liquid radwaste treatment system. (The liquid radwaste storage tanks (1T-88 and 1T-269) located in the Low-Level Radwaste Processing and Storage Facility are considered unprotected outdoor tanks.)

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|--|
| A. Quantity of radioactive material in the tanks exceeding the limit. | A.1 Suspend all additions of the radioactive material to the tanks. <u>AND</u> A.2 Reduce tank contents to within the limit. <u>AND</u> A.3 Describe in next Annual Radioactive Effluent Release Report the events leading to this condition. <u>AND</u> A.4 Prepare and submit a Special Report to the Commission which identifies the cause(s) for exceeding the limit and defines the action to be taken. (10CFR20.2203) | Immediately 48 hours 1 year 30 Days |

Liquid Holdup Tanks
O 7.1.5

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|--|-----------|
| OSR 7.1.5.1 | When radioactive materials are being added to a tank, the quantity of radioactive material contained in all tanks shall be determined to be within the 50 curie limit by analyzing a representative sample of the tanks' contents. | 7 Days |

Radioactive Gaseous Effluent Instrumentation
O 6.2.1.1

O 6.2 RADIOACTIVE GASEOUS EFFLUENT CONTROLS

O 6.2.1.1 Radioactive Gaseous Effluent Instrumentation

OLCO 6.2.1.1 The Radioactive Gaseous Effluent Instrumentation for each function in Table 6.2-1 shall be OPERABLE

APPLICABILITY: During releases via this pathway.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|---|
| A. One or more channels inoperable. | A.1 Enter the condition referenced in Table 6.2-1 for the channel. <u>AND</u> A.2 Restore required channel(s) to OPERABLE status. | Immediately 30 days |
| B. As required by Required Action A.1 and referenced in Table 6.2-1 | B.1 Collect gaseous grab sample. <u>AND</u> B.2 Analyze sample for radioactivity. | once per 8 hours Within 24 hours of sample collection |
| C. As required by Required Action A.1 and referenced in Table 6.2-1 | C.1 Establish preplanned alternate monitoring method. <u>OR</u> C.2.1 Collect gaseous grab sample. <u>AND</u> C.2.2 Analyze sample for radioactivity. | 8 hours once per 8 hours Within 24 hours of sample collection |

(continued)

Radioactive Gaseous Effluent Instrumentation
O 6.2.1.1

ACTIONS (continued)

| | | | |
|---|------------|---|--------------------------------------|
| D. As required by Required Action A.1 and referenced in Table 6.2-1 | D.1 | Establish continuous sampling with auxiliary equipment. | 8 hours |
| | <u>AND</u> | | |
| | D.2 | Collect sample(s) | Once per 7 days |
| E. As required by Required Action A.1 and referenced in Table 6.2-1 | <u>AND</u> | | |
| | D.3 | Analyze sample(s) for radioactivity. | Within 24 hours of sample collection |
| E. As required by Required Action A.1 and referenced in Table 6.2-1 | E.1 | Estimate flow rate initially and whenever operation of a main exhaust fan combination is changed in the system. | 8 Hours |
| F. As required by Required Action A.1 and referenced in Table 6.2-1 | F.1 | Collect gaseous grab sample. | once per 24 hours |
| | <u>AND</u> | | |
| | F.2 | Analyze sample for radioactivity. | Within 24 hours of sample collection |
| G. Minimum required instrumentation not returned to OPERABLE status within 30 days. | G.1 | Explain in next Annual Radioactive Material Release Report why the instrument was not made operable in a timely manner. | |

Radioactive Gaseous Effluent Instrumentation
O 7.2.1.1

SURVEILLANCE REQUIREMENTS

NOTE

Instrumentation shall be OPERABLE and in service except that channels out of service are permitted for the purpose of required tests, checks and calibrations without declaring the channel to be inoperable.

| SURVEILLANCE | | FREQUENCY |
|---------------|--|-----------|
| OSR 7.2.1.1.1 | Perform CHANNEL CHECK ----- NOTE During releases via this pathway. | 24 Hours |
| OSR 7.2.1.1.2 | Perform CHANNEL CHECK | 7 Days |
| OSR 7.2.1.1.3 | Perform SOURCE CHECK | 30 Days |
| OSR 7.2.1.1.4 | Determine the monitor setpoints in accordance with the method described in the ODAM. | 92 Days |
| OSR 7.2.1.1.5 | Perform CHANNEL FUNCTIONAL TEST | 92 Days |
| OSR 7.2.1.1.6 | Determine the monitor setpoints in accordance with the method described in the ODAM. | 18 Months |
| OSR 7.2.1.1.7 | Perform CHANNEL CALIBRATION | 18 Months |

Radioactive Gaseous Effluent Instrumentation

O 6.2.1.1

| | | TABLE 6.2-1 NORMAL RANGE RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION | TABLE 7.2-1 |
|---|--|---|--|
| Instrument | Minimum Channels Operable ^{a,b} | Conditions Referenced from Required Action A.1 | Surveillance Requirements |
| 1. Offgas Stack Monitoring System | | | |
| a. Noble Gas Activity Monitor | 1 | C | OSR 7.2.1.1.1, OSR 7.2.1.1.3, OSR 7.2.1.1.4, OSR 7.2.1.1.5 ^(d) , OSR 7.2.1.1.7 ^(e) |
| b. Iodine Sampler Cartridge | 1 | D | OSR 7.2.1.1.2 |
| c. Particulate Sampler Filter | 1 | D | OSR 7.2.1.1.2 |
| d. Effluent Flow Measuring Device | 1 | E | OSR 7.2.1.1.1, OSR 7.2.1.1.5, OSR 7.2.1.1.7 |
| e. Sample Flow Measuring Device | 1 | E | OSR 7.2.1.1.1, OSR 7.2.1.1.5, OSR 7.2.1.1.7 |
| 2. Reactor Building Exhaust Vent Monitoring System | | | |
| a. Noble Gas Activity Monitor | 1 | B | OSR 7.2.1.1.1, OSR 7.2.1.1.3, OSR 7.2.1.1.5 ^(d) , OSR 7.2.1.1.6, OSR 7.2.1.1.7 ^(e) |
| b. Iodine Sampler Cartridge | 1 | D | OSR 7.2.1.1.2 |
| c. Particulate Sampler Filter | 1 | D | OSR 7.2.1.1.2 |
| d. Effluent Flow Measuring Device | 1 | E | OSR 7.2.1.1.1, OSR 7.2.1.1.5, OSR 7.2.1.1.7 |
| e. Sample Flow Measuring Device | 1 | E | OSR 7.2.1.1.1, OSR 7.2.1.1.5, OSR 7.2.1.1.7 |
| 3. Turbine Building Exhaust Vent Monitoring System | | | |
| a. Noble Gas Activity Monitor | 1 | B | OSR 7.2.1.1.1, OSR 7.2.1.1.3, OSR 7.2.1.1.5 ^(d) , OSR 7.2.1.1.6, OSR 7.2.1.1.7 ^(e) |
| b. Iodine Sampler Cartridge | 1 | D | OSR 7.2.1.1.2 |
| c. Particulate Sampler Filter | 1 | D | OSR 7.2.1.1.2 |
| d. Effluent Flow Measuring Device | 1 | E | OSR 7.2.1.1.1, OSR 7.2.1.1.5, OSR 7.2.1.1.7 |
| e. Sample Flow Measuring Device | 1 | E | OSR 7.2.1.1.1, OSR 7.2.1.1.5, OSR 7.2.1.1.7 |
| 4. Low-Level Radwaste Processing and Storage Facility Exhaust Vent Monitoring System | | | |
| a. Noble Gas Activity Monitor | 1 | F | OSR 7.2.1.1.1, OSR 7.2.1.1.3 OSR 7.2.1.1.5 ^(d) , OSR 7.2.1.1.6 OSR 7.2.1.1.7 ^(e) |
| b. Iodine Sampler Cartridge | 1 | D | OSR 7.2.1.1.2 |
| c. Particulate Sampler Filter | 1 | D | OSR 7.2.1.1.2 |
| d. Effluent Flow Measuring Device | 1 | E | OSR 7.2.1.1.1, OSR 7.2.1.1.5, OSR 7.2.1.1.7 |
| e. Sample Flow Measuring Device | 1 | E | OSR 7.2.1.1.1, OSR 7.2.1.1.5, OSR 7.2.1.1.7 |

continued

TABLE 6.2-1 NOTATIONS

- (a) During releases via this pathway.
- (b) Instrumentation shall be OPERABLE and in service except that channels out of service are permitted for the purpose of required tests, checks and calibrations without declaring the channel to be inoperable.

TABLE 7.2-1 NOTATIONS

- (c) The CHANNEL CALIBRATION shall include the use of a known radioactive source (traceable to the NIST radiation measurement system or other acceptable non-NIST standards) positioned in a reproducible geometry with respect to the sensor and emitting beta and/or gamma radiation in the range measured by the channel in accord with established station calibration procedures. Alternatively, after the initial calibration, noble gas activity monitors maybe calibrated by laboratory analyzed gas samples collected and analyzed per Table 7.2-2, item A.
- (d) The CHANNEL FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exist:
 - 1.0 Instrument indicates measured levels above the alarm setpoint.
 - 2.0 Circuit failure.
 - 3.0 Instrument indicates a downscale failure.
 - 4.0 Deleted.

Offgas Radioactive Gaseous Effluent Instrumentation
O 6.2.1.2

O 6.2 RADIOACTIVE GASEOUS EFFLUENT CONTROLS

O 6.2.1.2 Offgas Radioactive Gaseous Effluent Instrumentation

OLCO 6.2.1.2 The Offgas Radioactive Gaseous Effluent Instrumentation for each Function in Table 6.2-2 shall be OPERABLE

APPLICABILITY: When the Offgas system is operating.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|---------------------------------------|
| A. One or more channels inoperable. | A.1 Enter the Condition referenced in table 6.2-2 for the channel. | Immediately |
| B. As required by Required Action A.1 and referenced in Table 6.2-2 | B.1 Verify the charcoal bed of the offgas system is not bypassed. <u>AND</u> B.2 Verify offgas stack noble gas activity monitor is operable. <u>AND</u> B.3 Restore channel(s) to OPERABLE status. | Immediately Immediately 30 Days |

(continued)

Radioactive Gaseous Effluent Instrumentation
O 6.2.1.2

ACTIONS (continued)

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|--|
| C. As required by Required Action A.1 and referenced in Table 6.2-2 | <p>C.1 Verify the charcoal bed of the offgas system is not bypassed.</p> <p><u>AND</u></p> <p>C.2.1 Obtain a gas grab sample.</p> <p><u>AND</u></p> <p>C.2.2 Analyze the grab sample.</p> <p><u>AND</u></p> <p>C.3.1 Verify offgas stack noble gas activity monitor is operable.</p> <p><u>OR</u></p> <p>C.3.2 Verify one post-treatment monitor is OPERABLE.</p> <p><u>AND</u></p> <p>C.4 Restore channel(s) to OPERABLE status.</p> | <p>Immediately</p> <p>Once per 7 Days</p> <p>24 Hours</p> <p>Immediately</p> <p>Immediately</p> <p>30 Days</p> |
| D. Required Action and associated Completion Time of Condition B or C not met. | D.1 Submit a Special Report to the NRC identifying the cause(s) for exceeding the limit and define the corrective actions taken. | 30 Days |

Offgas Radioactive Gaseous Effluent Instrumentation
O 7.2.1.2

SURVEILLANCE REQUIREMENTS

NOTE

Instrumentation shall be OPERABLE and in service except that channels out of service are permitted for the purpose of required tests, checks and calibrations without declaring the channel to be inoperable.

| SURVEILLANCE | | FREQUENCY |
|---------------|--|-----------|
| OSR 7.2.1.2.1 | Perform CHANNEL CHECK | 24 Hours |
| OSR 7.2.1.2.2 | Perform SOURCE CHECK | 30 Days |
| OSR 7.2.1.2.3 | Perform CHANNEL FUNCTIONAL TEST | 92 Days |
| OSR 7.2.1.2.4 | Determine the monitor setpoints in accordance with the method described in the ODAM. | 92 Days |
| OSR 7.2.1.2.5 | Perform CHANNEL CALIBRATION | 18 Months |
| OSR 7.2.1.2.6 | Perform FUNCTIONAL TEST of the CHARCOAL BED BYPASS VALVE LOGIC SYSTEM | 48 Months |

Offgas Radioactive Gaseous Effluent Instrumentation
O 6.2.1.2

TABLE 6.2-2
RADIATION MONITORING INSTRUMENTATION

| Instrumentation | Minimum Channels Operable | Conditions Referenced from Required Action A.1 | Surveillance Requirements |
|---|---------------------------|--|--|
| Offgas Post-Treatment Radiation Monitors ^(a) | 1 | B | OSR 7.2.1.2.1, OSR 7.2.1.2.2, OSR 7.2.1.2.3 ^(e) , OSR 7.2.1.2.4, OSR 7.2.1.2.5, OSR 7.2.1.2.6 |
| Offgas Pre-Treatment Radiation Monitors ^(b) | 1 | C | OSR 7.2.1.2.1, OSR 7.2.1.2.2, OSR 7.2.1.2.3 ^(e) , OSR 7.2.1.2.4, OSR 7.2.1.2.5 |

TABLE 6.2.2 NOTATIONS

- (a) The monitors shall be set to initiate immediate closure of the charcoal bed bypass valve at a setting equivalent to or below the dose rate limits in ODAM Section 6.2.2.
- (b) The monitors shall be set to initiate an alarm if the monitor exceeds a trip setting equivalent to 1.0 Ci/sec of noble gases after 30 minutes delay in the offgas holdup line.
- (e) The CHANNEL FUNCTIONAL TEST for this instrument shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exist:
 - a. Instrument indicates measured levels above the alarm/trip setpoint.
 - b. Instrument indicates a downscale failure.
 - c. Instrument controls not set in operate mode.

Gaseous Effluent Dose Rate
O 6.2.2

O 6.2

RADIOACTIVE GASEOUS EFFLUENT DOSE RATE

O 6.2.2

Gaseous Effluent Dose Rate

OLCO 6.2.2

The dose rate in the UNRESTRICTED AREA due to the release of gaseous effluents shall not exceed:

- a. 500 mrem/year to the total body or 3000 mrem/year to skin due to radioactive noble gas; and
- b. 1500 mrem/year to any organ due to I-131, I-133, H-3, and to radioactive particulates having half-lives of 8 days or more.

APPLICABILITY: During Releases.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---------------------------------|---|-----------------|
| A. Dose rate not within limits. | A.1 Reduce the release rate within limit. | Immediately |

Gaseous Effluent Release Concentration
O 7.2.2

SURVEILLANCE REQUIREMENTS

NOTE

*Refer to ODAM Table 7.2-2 for details concerning Sampling and Analysis

| SURVEILLANCE | | FREQUENCY |
|--------------|---|--|
| OSR 7.2.2.1 | Monitor for Radioactive Noble Gas gamma activity. | Continuously |
| OSR 7.2.2.2 | <p>Sample the Effluent Stream for I-131.</p> <p><u>AND</u></p> <p>Analyze for I-131 within 48 hours of sample pull.</p> | <p>Continuously</p> <p>7 Days</p> <p><u>AND</u></p> <p>Following an increase of more than 50% as indicated by the Post-Treat rad. monitor*</p> |
| OSR 7.2.2.3 | <p>-----NOTE-----</p> <p>Retain samples for Quarterly Composite analysis. (OSR 7.2.2.8)</p> <p>-----</p> <p>Sample the Effluent Stream for particulates.</p> <p><u>AND</u></p> <p>Analyze for principal gamma emitters from particulates within 48 hours of sample pull*.</p> | <p>Continuously</p> <p>7 Days</p> <p><u>AND</u></p> <p>Following an increase of more than 50% as indicated by the Post-Treat rad. monitor*</p> |
| OSR 7.2.2.4 | Perform gas grab sample of the effluent stream and analyze for principal gamma emitters. | 30 Days |
| OSR 7.2.2.5 | <p>-----NOTE-----</p> <p>Applies only for the Reactor Building and Off gas Stack effluent streams.</p> <p>-----</p> <p>Perform gas grab sample of the effluent stream and analyze for principal gamma emitters.</p> | Following an increase of more than 50% as indicated by the Post-Treat rad. monitor |

(continued)

Gaseous Effluent Concentration
O 7.2.2

SURVEILLANCES (continued)

| SURVEILLANCE | | FREQUENCY |
|--------------|--|----------------------------------|
| OSR 7.2.2.6 | Perform grab sample of the effluent stream and analyze for Tritium. | 92 Days |
| OSR 7.2.2.7 | <p style="text-align: center;">-----NOTE-----</p> <p>Applies only for the Reactor Building and Off gas Stack effluent streams.</p> <p style="text-align: center;">-----</p> <p>Perform grab sample of the effluent stream and analyze for Tritium.</p> | When the Reactor Head is removed |
| OSR 7.2.2.8 | Analyze Particulate Composite sample for Sr-89, Sr-90, Gross Alpha | 92 Days |

*Refer to ODAM Table 7.2-2 for details concerning Sampling and Analysis

Gaseous Effluent Release Concentration
O 7.2.2

| TABLE 7.2-2 | | | | |
|--|----------------------------|--|---|---|
| RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM | | | | |
| Gaseous Release Type | Surveillance Requirements | Frequency | Type of Activity Analysis | Lower Limit of Detection (LLD) ^(a) |
| A. Offgas Stack, and Reactor Building Vent | OSR 7.2.2.5 ^(b) | Elevated Post-Treat Readings ^(b) | Gas Grab Sample Principal Gamma Emitters | $1 \times 10^{-4(d)}$ |
| | OSR 7.2.2.7 ^(c) | Reactor Head Removed ^(c) | Tritium Grab Sample (H-3) | 1×10^{-6} |
| B. Offgas Stack, Reactor Building Vent, Turbine Building Vent, and Low-Level Radwaste Processing Storage Facility Vent | OSR 7.2.2.2 ^(e) | Routine OR elevated Post-Treat Readings ^(f) | Charcoal Sample I-131 | 1×10^{-12} |
| | OSR 7.2.2.3 ^(e) | Routine OR elevated Post-Treat Readings ^(f) | Particulate Sample Principal Gamma Emitters (I-131, Others) | $1 \times 10^{-11(d)}$ |
| | OSR 7.2.2.4 | Routine | Gas Grab Sample Principal Gamma Emitters | $1 \times 10^{-4(d)}$ |
| | OSR 7.2.2.6 | Routine | Tritium Grab Sample (H-3) | 1×10^{-6} |
| | OSR 7.2.2.8 ^(e) | Routine ^(g) | Composite Particulate Sample Sr-89, Sr-90 Gross Alpha Fe-55 | 1×10^{-11} 1×10^{-11} 1×10^{-11} |
| C. Offgas Stack, Reactor Building Vent, Turbine Building Vent, and Low-Level Radwaste Processing and Storage Facility | OSR 7.2.2.1 | Continuous | Monitor Radioactive Noble Gas gamma activity | 1×10^{-6} |

TABLE NOTATIONS

- (a) Units for the listed values are $\mu\text{Ci}/\text{cc}$. See Table 7.1-2 for a definition of the lower limit of detection (LLD).
- (b) Monthly analyses shall be performed following an increase of more than 50% in the steady state releases as indicated by the post-treat noble gas activity monitor, after factoring out the effect due to a change in reactor power, or other minor temporary fluctuations not related to fuel integrity such as line up changes for condensate de-mineralizers or reactor water cleanup.
- (c) A H-3 grab sample will also be taken from the Offgas Stack or Reactor Building Vent when the reactor head is removed.

Gaseous Effluent Concentration
O 7.2.2

- (d) The principal gamma emitters for which the LLD will apply are exclusively the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135, and Xe-138 for gaseous emissions and Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141 and Ce-144 for particulate emissions. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD may be reported as "less than" their respective LLD and should not be reported as being present at the LLD of the nuclide. Each measured radionuclide concentration is used in a required concentration or dose calculation only if it is detected at or above the LLD. When unusual circumstances persist more than 30 days and cause LLD higher than required, the reasons shall be documented in the Annual Radioactive Material Release Report.
- (e) The ratio of the sample flow rate to the sampled stream flow rate shall be known for the time period covered by each dose or dose rate calculations made in accordance with Sections 6.2.2, 6.2.3, and 6.2.4.
- (f) Sample media shall be changed at least once per seven days and the analysis completed within 48 hours after changing (or after removal from the sampler). Analyses shall also be performed within 48 hours following an increase of more than 50% in the steady state release as indicated by the post-treat noble gas activity monitor, after factoring out the effect due to a change in reactor power. When samples collected for 24 hours or less are analyzed, the corresponding LLD may be increased by a factor of 10.
- (g) A quarterly composite sample shall include an equal fraction of each weekly particulate sample collected during the quarter.

Doses Due to Noble Gases
O 6.2.3

O 6.2 RADIOACTIVE GASEOUS EFFLUENT CONTROLS

O 6.2.3 Doses Due to Noble Gases

OLCO 6.2.3 The Air Dose in the UNRESTRICTED AREA due to noble gases released in gaseous effluents shall not exceed:

5.0 mrad from gamma radiation during any calendar quarter;
10.0 mrad from beta radiation during any calendar quarter;
10.0 mrad from gamma radiation during any calendar year; or
20.0 mrad from beta radiation during any calendar year.

APPLICABILITY: During Releases

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| A. Calculated air dose not within limits. | A.1 Submit a Special Report to the NRC identifying the cause(s) for exceeding the limit and define the corrective actions taken. | 30 days |

Doses Due to Noble Gases
O 7.2.3

SURVEILLANCE REQUIREMENTS

| | SURVEILLANCE | FREQUENCY |
|-------------|--|-----------|
| OSR 7.2.3.1 | An assessment shall be performed in accordance with the ODAM to verify that the cumulative air dose during the quarter and year due to noble gases does not exceed the limits in ODAM section 6.2.3. | 30 Days |

Doses Due to Iodine and Particulates in Air
O 6.2.4

O 6.2

RADIOACTIVE GASEOUS EFFLUENT CONTROLS

O 6.2.4

Doses Due to Iodine and Particulates in Air

OLCO 6.2.4

The dose to a MEMBER OF THE PUBLIC from Iodine-131, I-133, H-3, and from radionuclides in particulate form having half-lives greater than eight days in gaseous effluents released from the site to the UNRESTRICTED AREA shall not exceed:

7.5 mrem to any organ during any calendar quarter; or
15.0 mrem to any organ during any calendar year.

APPLICABILITY: During Releases.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---------------------------------------|--|-----------------|
| A. Calculated dose not within limits. | A.1 Submit a Special Report to the NRC identifying the cause(s) for exceeding the limit and define the corrective actions taken. | 30 days |

Doses Due to Iodine and Particulates in Air
O 7.2.4

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| OSR 7.2.4.1 An assessment shall be performed in accordance with the ODAM to verify that the cumulative dose commitment due to I-131, I-133, H-3, and radioactive particulates having half-lives greater than eight days in gaseous effluents does not exceed the limits in ODAM Section 6.2.4. | 30 Days |

Gaseous Radwaste Treatment
O 6.2.5

O 6.2

RADIOACTIVE GASEOUS EFFLUENT CONTROLS

O 6.2.5

Gaseous Radwaste Treatment

OLCO 6.2.5

At least one train of charcoal beds in the Offgas System shall be placed in operation to treat radioactive gases from the main condenser.

APPLICABILITY: During Offgas System operation.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| A. No Offgas System charcoal beds in service. -----NOTE----- Not applicable until after 4 hours of commencing operation of the main condenser air ejector. ----- | A.1 Restore Offgas System charcoal bed to service. | 7 days |
| B. Required Action and associated Completion Time not met. | B.1 Submit a Special Report to the NRC identifying the inoperable equipment or subsystem and reason for inoperability, actions taken to prevent a recurrence. | 30 days |

Gaseous Radwaste Treatment
O 7.2.5

SURVEILLANCE REQUIREMENTS

| | SURVEILLANCE | FREQUENCY |
|-------------|--|------------------|
| OSR 7.2.5.1 | The gaseous effluent monitoring systems of ODAM Sections 6.2.1 and 7.2.1 shall be used to verify the operation of the Offgas system. | N/A |

Mechanical Vacuum Pump Radiation Release Rate
O 6.2.6

O 6.2

RADIOACTIVE GASEOUS EFFLUENT CONTROLS

O 6.2.6

Mechanical Vacuum Pump Radiation Release Rate

OLCO 6.2.6

During mechanical vacuum pump operation the release rate of gross activity except for halogens and particulates with half lives longer than eight days shall not exceed 1 curie/sec.

APPLICABILITY:

During mechanical vacuum pump operation.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| A. Radioactive release rate not within limit. | A.1 Restore radioactive release rate to within limits. | Immediately |

Dose
O 6.3.1

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|---------------------|--|------------------|
| OSR 7.2.6.1 | The gaseous effluent monitoring systems of ODAM Sections 6.2.1 and 7.2.1 shall be used to verify the operation of the Offgas system. | N/A |

Dose
O 6.3.1

O 6.3

OFFSITE DOSE ASSESSMENT CONTROLS

O 6.3.1

Dose

OLCO 6.3.1

The annual dose or dose commitment to any MEMBER OF THE PUBLIC due to radiation and radioactive material in effluents from DAEC shall not exceed 75 mrem to the thyroid or 25 mrem to the total body or any other organ.

APPLICABILITY:

At all times.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| A. Calculated dose from radioactive material released in liquid or gaseous effluents exceeds twice the limits of Sections 6.1.3, 6.2.3 or 6.2.4 | A.1 Perform an assessment of compliance with 40 CFR 190 and 10 CFR 72.104 and limit subsequent releases such that the dose or dose commitment to a MEMBER OF THE PUBLIC is \leq 75 mrem to his thyroid and \leq 25 mrem to his total body or any other organ over 12 consecutive months including the period of elevated release. | 7 days |
| B. The estimated dose exceeds either limit in Section 6.3.1. | B.1 Prepare and submit a Special Report to the NRC in lieu of any other report; it shall include the cause of the release of exposure, an estimate of the dose to the likely most exposed MEMBER(s) OF THE PUBLIC, corrective actions taken or planned to prevent a recurrence, and a schedule for achieving compliance. If the condition causing the limit(s) to be exceeded has not been corrected, the Special Report may also state a request for a variance in accordance with the provisions of 40 CFR Part 190. In that event, the request is timely and a variance is granted until NRC action on the request is complete. | 30 days |

Dose
O 7.3.1

SURVEILLANCE REQUIREMENTS

| | SURVEILLANCE | FREQUENCY |
|-------------|--|------------------|
| OSR 7.3.1.1 | Cumulative dose contributions from liquid and gaseous effluents to a MEMBER OF THE PUBLIC offsite shall be evaluated as described in the ODAM. | 12 Months |

Radiological Environmental Monitoring Program
O 6.3.2

O 6.3

OFFSITE DOSE ASSESSMENT CONTROLS

O 6.3.2

Radiological Environmental Monitoring Program

OLCO 6.3.2

A radiological environmental monitoring program shall be conducted as specified in Table 6.3-1.

APPLICABILITY: At all times.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|--|-----------------|
| A. Deviation from Table 6.3-1 | A.1 Deviations are permitted from Table 6.3-1 if specimens are unobtainable due to hazardous conditions, seasonal unavailability, malfunction of automatic sampling equipment and other legitimate reasons. If specimens are unobtainable due to sampling equipment malfunction, every effort shall be made to complete corrective action prior to the end of the next sampling period. All deviations from Table 6.3-1 shall be documented in the Annual Radiological Environmental Report. | Once per year |
| B. In the event radioactivity in a sampled environmental medium, averaged over a calendar quarter, is attributable to DAEC and exceeds an appropriate value listed in Table 6.3-3 or, if not listed, causes a potential annual dose exceeding two times the quarterly dose limit in Section 6.1.3 or 6.2.4 | B.1 Prepare and submit to the Commission within 30 days after discovery a Special Report which includes an evaluation of any release conditions, environmental factors or other conditions which caused the value(s) of Table 6.3-3 or two times the quarterly dose limit to be exceeded and which defines the corrective actions to be taken. If the radioactivity in environmental sample(s) is not attributable to releases from the Station, the Special Report is not required. Instead, the sample(s) result(s) shall be reported and explained in the Annual Radiological Environmental Report. | 30 Days |

(continued)

Radiological Environmental Monitoring Program
O 6.3.2

ACTIONS (continued)

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| C. When environmental sampling medium is not available from a sampling location or the location is no longer appropriate. | C.1 The cause and the location where replacement samples were obtained and/or will be obtained shall be reported in the Annual Radiological Environmental Report. | Once per year |
| D. A location is identified at which the calculated personal dose associated with one or more exposure pathways exceeds by 20% the maximum calculated dose associated with like pathway(s) at a location where sampling is conducted as specified by Table 6.3-1 | D.1 The pathway(s) having maximum exposure potential at the newly identified location will be added to the radiological monitoring program at a subsequent Operations Committee meeting, if samples are reasonably attainable at the new location. Like pathway(s) monitored (sampled) at a location, excluding the control station location(s), having a lesser associated calculated personal dose may be deleted from the program at the time the new pathway(s) and location are added. | Once per year |

Radiological Environmental Monitoring Program
O 7.3.2

SURVEILLANCE REQUIREMENTS

| | SURVEILLANCE | FREQUENCY |
|-------------|--|------------------|
| OSR 7.3.2.1 | Sampling and analyses required in Table 6.3-1 shall be performed such that the detection capabilities specified in Table 6.3-2 are achieved under routine conditions. If a sample analysis does not meet the LLD specified, report the reason attributed in the next Annual Radiological Environmental Report. | 12 Months |
| OSR 7.3.2.2 | DAEC shall conduct annually a land use census within three miles of the Station to identify radiologically important changes in land use. | 12 Months |

Radiological Environmental Monitoring Program
O 6.3.2

| TABLE 6.3-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM | | | |
|--|-------------------------------------|---|--|
| Exposure Pathway and/or Sample Type | Minimum Number of Sampling Stations | Sampling and Collection Schedule ^(a) | Type and Frequency of Analysis |
| Airborne Particulates | Five | Continuous operation of sampler with sample collection WEEKLY or as required by dust loading | Analyze for gross beta activity \geq 72 hours after filter change. Perform gamma isotopic analysis on each sample having gross beta activity $>$ 10 times the yearly mean of control samples. Perform gamma isotopic analysis on composite (by sampling location) of samples collected during each quarter |
| Airborne Iodine | Five | Continuous operation of sampler with sample collection WEEKLY | Analyze each cartridge for I-131 within 8 days of collection. |
| Ambient Radiation | Forty two | QUARTERLY | Read gamma radiation dose quarterly. |
| Surface Water | Three | MONTHLY | Tritium and Gamma isotopic analysis of each sample. |
| Ground Water | Six | QUARTERLY | Tritium and Gamma isotopic analysis of each sample. If reactor by-product gamma emitters are identified, OR tritium concentration is $>$ MDA, then analyze for Ni-63, Sr-89, Sr-90, Fe-55 and alpha emitters. |
| River Sediment | One | SEMIANNUALLY | Gamma isotopic analysis of each sample. |
| Milk | Two | BIWEEKLY during the grazing season. MONTHLY during non-grazing season. | Gamma isotopic and I-131 analysis of each sample. |
| Fish | Two | SEMIANNUALLY | Gamma isotopic analysis on edible portion. |
| Vegetation | Six | ANNUALLY at harvest time. At least two samples of each: grain green leafy vegetation forage. | Gamma isotopic and I-131 analysis of each sample. |

^(a)The following definitions of schedule timing shall apply to Table 6.3-1 only:

WEEKLY – Not less than once per calendar week. A maximum interval of 11 days is allowed between the collection of any two consecutive samples.

BIWEEKLY – Not less than once every two calendar weeks. A maximum interval of 18 days is allowed between the collection of any two consecutive samples.

MONTHLY – Not less than once per calendar month. An interval of not less than 10 days will be provided between collection of any two consecutive samples.

QUARTERLY – Not less than once per calendar quarter. An interval of not less than 30 days will be provided between collection of any two consecutive samples.

SEMIANNUALLY – One sample each between calendar dates (January 1 – June 30) and (July 1 – December 31). An interval of not less than 60 days will be provided between collection of any two consecutive samples.

ANNUALLY – Not less than once per calendar year with an interval of not less than 120 days between collection of any two consecutive samples.

TABLE 6.3-2

 MAXIMUM VALUES OF THE LOWER LIMIT OF DETECTION FOR ENVIRONMENTAL SAMPLE ANALYSIS ^(a)

| Analysis | Medium | | | | |
|--------------|--|---|--------------------------|--------------|-----------------------------------|
| | Water (pCi/L) | Airborne Particulate or Gas (pCi/m ³) | Fish (pCi/kg, wet) | Milk (pCi/L) | Food Products (pCi/kg, wet) |
| Gross beta | 4 | 1×10^{-2} | | | |
| H-3 | 2000 ^(b) 3000 ^(c) | | | | |
| Mn-54 | 15 | | 130 | | |
| Fe-59 | 30 | | 260 | | |
| Co-58, Co-60 | 15 | | 130 | | |
| Zn-65 | 30 | | 260 | | |
| Zr-95 | 30 | | | | |
| Nb-95 | 15 | | | | |
| I-131 | 1 ^(d) | 7×10^{-2} | | 1 | 60 |
| Cs-134 | 15 | 5×10^{-2} | 130 | 15 | 60 |
| Cs-137 | 18 | 6×10^{-2} | 150 | 18 | 80 |
| Ba-140 | 60 | | | 60 | |
| La-140 | 15 | | | 15 | |

TABLE NOTATIONS Table 6.3-2

(a) The LLD is defined, for purposes of these specifications, as the smallest concentration of radioactive material in a sample that will yield a new count, above system background, that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement, which may include radiochemical separation

$$\text{LLD} = (4.66S_b)/(E \cdot V \cdot 2.22 \cdot Y \cdot e^{-\lambda t})$$

where:

- LLD is the lower limit of detection as defined above (picocuries per unit mass or volume)
- S_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (counts per minute)
- E is the counting efficiency (counts per disintegration)
- V is the sample size (units of mass or volume)
- 2.22 is the number of disintegrations per minute per picocurie,
- Y is the fractional radiochemical yield, when applicable,
- λ is the radioactive decay constant for the particular radionuclide, and D
- t for environmental samples is the elapsed time between sample collection, or end of the sample collection period, and time of counting

Analyses shall be performed in such a manner that the stated LLDs will be achieved under routine conditions. With typical values of E, V, Y, and Δt for the radionuclides named in the Table. Occasionally background fluctuations, unavoidably small sample sizes, the presence of interfering nuclides, or other uncontrollable circumstances may render these LLDs unachievable. In such cases, the contributing factors shall be identified and described in the Annual Radiological Environmental Report.
 continued

Radiological Environmental Monitoring Program

O 6.3.2

When a radionuclide attributable to DAEC but not listed in this table is measured it shall be reported.

- (b) For Drinking Water.
- (c) For samples of water not used as a source of drinking water.
- (d) If no drinking water pathway exists, a value of 15 pCi/l may be used.

Radiological Environmental Monitoring Program
O 6.3.2

| TABLE 6.3-3 | | | | | |
|--|--|--|-----------------------|--------------------------------|--------------------------------|
| REPORTING LEVELS FOR RADIOACTIVITY CONCENTRATIONS IN ENVIRONMENTAL SAMPLES | | | | | |
| Analysis | Reporting Levels ^(a) | | | | |
| | Water (pCi/liter) | Airborne Particulate or Gases (pCi/m ³) | Fish (pCi/Kg, wet) | Milk (pCi/liter) | Food Products (pCi/Kg, wet) |
| H-3 | 2×10^4 ^(b) 3×10^4 ^(c) | | | | |
| Mn-54 | 1×10^3 | | 3×10^4 | | |
| Fe-59 | 4×10^2 | | 1×10^4 | | |
| Co-58 | 1×10^3 | | 3×10^4 | | |
| Co-60 | 3×10^2 | | 1×10^4 | | |
| Zn-65 | 3×10^2 | | 2×10^4 | | |
| Zr-Nb95 | 4×10^2 ^(c) | | | | |
| I-131 | 2^d | 0.9 | | 3 | 1×10^2 |
| Cs-134 | 30 | 10 | 1×10^3 | 60 | 1×10^3 |
| Cs-137 | 50 | 20 | 2×10^3 | 70 | 2×10^3 |
| Ba-La140 | 2×10^2 ^(e) | | | 3×10^2 ^(e) | |

TABLE NOTATIONS Table 6.3-3

^(a)The reporting level is exceeded when one or more radionuclides are detected in a sample and $\Sigma[(\text{concentration})/(\text{reporting level})] \geq 1$.

^(b)For drinking water samples. This is 40 CFR Part 141 value.

^(c)For samples of water not used as a source of drinking water.

^(d)If no drinking water pathway exists, a value of 20 pCi/l may be used.

^(e)Concentration of parent or daughter.

BASES

BASES SECTION 6.1 / 7.1

6.1.1 Radioactive Liquid Effluent Instrumentation /7.1.1

The radioactive liquid effluent instrumentation is provided to monitor and control, as applicable, the release of radioactive material in liquid effluents. The OPERABILITY and use of these instruments implements the requirements of 10 CFR Part 50, Appendix A, General Design Criteria 60, 63, and 64. The alarm and/or trip setpoints for these instruments are calculated in the manner described in the ODAM to assure that the alarm and/or trip will occur before ten times the values specified in 10 CFR Part 20.2001 - 20.2402, Appendix B are exceeded. Instrumentation is expected to be OPERABLE and in service when required by controls. An instrument may be removed from service voluntarily for the purpose of tests, checks, or calibration, without declaring the channel inoperable.

The radwaste effluent line radiation monitor recorder RR3972 is not required in order to comply with the controls stated in the ODAM. It is provided for recording trends during a release and need not be maintained OPERABLE - i.e. calibrated and functionally tested - other than during a release.

BASES SECTION 6.1 / 7.1**6.1.2 / Liquid Effluent Concentration**
7.1.2

The basic requirements concerning effluents from nuclear power are stated in 10 CFR 50.36a. These requirements indicate that compliance with Technical Specifications will keep average annual releases of radioactive material in effluents to a small percentage of the limits specified in 10 CFR 20.106. These (new 10 CFR 20.1301) requirements further indicate that operational flexibility is allowed, compatible with considerations of health and safety, which may temporarily result in releases higher than such small percentages, but still within the limits specified in the old 10 CFR 20.106. These referenced concentrations are specific values which relate to an annual average dose of 500 millirems.

As stated in the Introduction to Appendix B of the new 10 CFR 20, the liquid effluent concentrations limits, given in the appendix, are based on an annual dose of 50 millirem. Prior to the issuance of the revision to Part 20, a release concentration corresponding to a limiting dose of 500 millirem had been acceptable as a TS limit for liquid effluents. The limit was applicable at all times and has been used to provide assurance that the limits of 10 CFR 50 Appendix I were not likely to be exceeded. Since the limits of 10 CFR 50 are the ultimate value to which a license must adhere, and since the old concentration limits adequately provide such assurance, it should not be necessary to reduce this limit by a factor of 10.

Conformance with the dose limits in section 6.1.3 will necessitate average annual liquid effluent concentrations being below those specified in 10 CFR 20.1001 - 20.2402 Appendix B to §§ 20.1001-20.2402.

Demonstrating compliance with section 6.1.3 will result in a de facto demonstration of compliance with 10 CFR 20 limits.

The continuous service water sample points noted in Table 7.1-2 are adequate to ensure sampling of potential liquid radioactive effluents from the service water systems. The sample points include the General Service Water System and the RHR Service Water Systems A and B. The sample point for the RHR Service Water Systems is at a location downstream of the point where Emergency Service Water discharge joins with the RHR Service Water System, and upstream of the point where the RHRSW/ESW Rupture Disc Line branches off of the RHR Service Water System. This sample point will therefore provide for sampling effluents from the RHR Service Water System, Emergency Service Water System and/or RHRSW/ESW Rupture Disc Line.

The "clean" system water sample points noted in Table 7.1-2 are adequate to ensure sampling of potential liquid radioactive effluents from systems believed to NOT contain radioactive liquids. The systems do have the potential to become contaminated by leaks from plant systems that do contain radioactive liquids. The sample points include the Transformer Pit, the CST Pit, and the Neut. Tank (1T022).

BASES SECTION 6.1 / 7.1

6.1.3 / 1. Dose Due to Radioactive Effluents
7.1.3

Section 6.1.3, 6.2.3 and 6.2.4 implement the requirements of 10 CFR Part 50.36a and of 10 CFR Part 50, Appendix I, Section IV. These sections keep levels of radioactive materials in LWR effluents as low as is reasonably achievable. Compliance with these sections will also keep average releases of radioactive material to effluent at small percentages of the limits specified in 10 CFR Part 20.106. Surveillance requirements provide for the measurement of releases and calculation of doses to verify compliance with the controls. Action statements in these sections implement the requirements of 10 CFR Part 50.36(c)(2) and 10 CFR Part 50, Appendix I, Section IV.A in the event a control is not met.

2. Liquid Effluents

With the implementation of Section 6.1.3, there is reasonable assurance that Station operation will not cause a radionuclide concentration in public drinking water taken from the River that exceeds the standard for anthropogenic radioactivity in community drinking water. The equations in the ODAM for calculating doses due to measured releases of radioactive material in liquid effluent are consistent with the methodology in Regulatory Guide 1.109 and 1.113. The assessment of personal doses will examine potential exposure pathways including, as appropriate, consumption of fish and water taken from the River downstream of the discharge pipe.

6.1.4 / Liquid Waste Treatment
7.1.4

This section implements the requirements of 10 CFR Part 50.36a (a)(1) that operating procedures be established and followed and that equipment be maintained and used to keep releases to the environment as low as is reasonably achievable. The section intends that appropriate portions of the system which were used to establish compliance with the design objectives in 10 CFR Part 50, Appendix I, Section II be used when specified to provide reasonable assurance that releases of radioactive material in liquid effluent will be kept as low as is reasonably achievable. The components in the liquid radwaste system which are appropriate to process liquid waste in order to satisfy Section 7.1.4 are the floor drain demineralizer and the radwaste demineralizer. The activity concentration, $\mu\text{Ci/mL}$, below which liquid radwaste treatment would not be cost-beneficial, and therefore not required, is demonstrated below. The quantity of radioactive material in liquid effluent released annually from the DAEC has been calculated to be:

| | |
|------------------------|------------|
| total iodines | 0.11 curie |
| total others (less H3) | 0.25 |
| Total | 0.36 curie |

The population dose commitment resulting from the radioactive material in liquid effluent released annually has been calculated to be*

| | |
|------------|---------------|
| thyroid | 0.164 man rem |
| total body | 0.114 |
| Total | 0.278 man rem |

Therefore, population doses are about 1.5 man rem per curie of iodine released and about 0.5 man rem per curie of other radionuclides (less H3) released in liquids. On the basis of gross activity, the population dose is about one man rem per curie released in liquids.

The volume of liquid waste processed and intended for discharge is estimated to be:

$$\begin{array}{ll} \text{Low Purity Waste} & 5700 \text{ gal/day} = 1.8 \times 10^6 \text{ gal/yr} \\ \text{Chemical Waste} & 600 \text{ gal/day} = 1.9 \times 10^5 \text{ gal/yr} \end{array}$$

Since the same DAEC equipment is used to process both streams, the total volume to be processed is about 2×10^6 gal/yr. The annual cost to operate the radwaste processing equipment, based on Dirty Waste Ion Exchange operation, has been estimated* (neglecting credit for capital recovery) to be \$88,000 per year. Thus the unit volume operating cost is about:

$$\frac{\$88,000 / \text{yr}}{2 \times 10^6 \text{ gal / yr}} = \$0.05 / \text{gal}$$

Thus the operating cost to treat a 4000 gallon batch of chemical waste by ion exchange would be about \$200. The operating cost to treat a 10000 gallon batch of floor drain waste by ion exchange would be about \$500. Assuming the cost-benefit balance is \$1000 expenditure per man rem reduced and assuming treatment removes all radioactivity from the liquid, then

- (1) the activity concentration in a Chemical Waste batch below which treatment is not cost-beneficial is

$$C = \frac{\$200}{4000 \text{ gal} \times 3785 \frac{\text{ml}}{\text{gal}}} \times \frac{1 \text{ curie}}{\text{man rem}} \times \frac{10^6 \mu\text{Ci}}{\text{curie}} \times \frac{1 \text{ man rem}}{\$1000}$$

$$C = 0.013 \mu\text{Ci/ml}$$

(continued)

6.1.4 /

7.1.4

- (2) the activity concentration in a batch of Floor Drain Waste below which treatment is not cost-beneficial is

$$C = \frac{\$500}{10000 \text{ gal} \times 3785 \frac{\text{ml}}{\text{gal}}} \times \frac{1 \text{ curie}}{\text{man rem}} \times \frac{10^6 \mu\text{Ci}}{\text{curie}} \times \frac{1 \text{ man rem}}{\$1000}$$

$$C = 0.013 \mu\text{Ci/ml}$$

Liquid waste treatment with the evaporator at DAEC has been shown to be neither cost-beneficial nor necessary to comply with 10 CFR 50 Appendix I, Section II. Consequently, liquid radwaste treatment to achieve an activity concentration below 0.01 $\mu\text{Ci/mL}$ in liquid effluent is not justified.

6.1.5 / Liquid Holdup Tanks

7.1.5

The tanks listed in the specification include all liquid radwaste tanks (1T-88 and 1T-269) located in the Low-Level Radwaste Processing Facility (LLRPSF). Because the LLRPSF is not seismically designed, these tanks are considered as outdoor tanks that are not surrounded by liners, dikes, or walls capable of holding the tanks' contents.

Restricting the quantity of radioactive material contained in the specified tanks provides assurance that in the event of an uncontrolled release of the tanks' contents, the resulting concentrations would be less than the limits of 10 CFR 20, Appendix B to 20.1001 - 20.2402, Table 2, Column 2, at the nearest potable water supply in an UNRESTRICTED AREA.

BASES SECTION 6.2 / 7.2

6.2.1 / 7.2.1 Radioactive Gaseous Effluent Instrumentation

The radioactive gaseous effluent instrumentation is provided to monitor the release of radioactive materials in gaseous effluents and, as appropriate, to control potential releases. The presence of instruments for monitoring radioactive effluents is depicted in ODAM Figure 3-1. The OPERABILITY and use of these instruments implements the requirements of 10 CFR Part 50, Appendix A, General Design Criteria 60, 63, and 64.

Reactor building exhaust ventilation shaft radiation monitors initiate isolation of the reactor building normal ventilation and start standby gas treatment when a high trip point is reached.

DAEC is equipped with a radioactive gaseous effluent monitoring system which includes detectors at the offgas stack (R3), the reactor building vent (R4), the turbine building vent (R5), and the LLRPSF vent (R7). A remote indication and control unit located near each detector displays the detector reading and, whenever the setpoint is exceeded, an indicator light. The data are also routed to a control computer and a control room display, but do not cause a trip to isolate the ventilated area. In the event the control computer and/or control room display fail to function or are voluntarily taken out of service, each remote indication and control unit is designed to acquire data for up to 30 hours. It is intended that each affected remote indication and control unit display be observed at least once per 24 hours (in which case the affected channel remains OPERABLE).

If an alarm trip setpoint is exceeded at the same time the control computer and/or control room display are neither functioning nor in service, alarm annunciation will still occur in the control room. In the event the detector reading and the indication of exceeding the monitor setpoint are not provided at either the control room or the remote indication and control unit, then the affected channel is not OPERABLE and DAEC will either perform the appropriate ACTION or will provide an alternate monitoring system. This permits DAEC to retain the GE gaseous monitoring system as an alternate system for normal effluent monitoring when the Kaman system is temporarily inoperable. When used as an alternate monitoring system, the GE system is subject to the requirements stated in Sections 6.2.1 and 7.2.1 and to LLD requirements stated in Table 7.2-2, Note d.

Two air ejector offgas post-treatment monitors are provided. They are designed so that an instrument failure gives a downscale trip or an inoperative trip. When both instruments reach an upscale trip point, or when one reaches an upscale and the other reaches a downscale trip point or inoperative, a trip is actuated. The post-treatment monitors have three upscale trip setpoints. The lower level upscale trip (high) will initiate charcoal bed valve closure. (CV-4134A opening and CV-4134B closing to route offgas through the charcoal.) The intermediate and upper trip points (high-high and high-high-high) are for alarm only.

BASES SECTION 6.2 / 7.2

2. Not used

3. Gaseous Effluents

Assessments of dose required by Sections 7.2.3 and 7.2.4 to verify compliance with Appendix I, Section IV are based on measured radioactivity in gaseous effluent and on calculational methods stated in the ODAM. Pathways of exposure and location of individuals are selected such that the dose to a nearby resident is unlikely to be underestimated. Dose assessment methodology described in the ODAM for gaseous effluent will be consistent with the methodology in Regulatory Guides 1.109 and 1.111. Cumulative and projected assessments of dose made during a quarter are based on historical average meteorological conditions measured at DAEC. Assessment made for the annual radiological environmental report will be based on annual averages of atmospheric conditions during the period of release.

6.2.2 / 7.2.2

Gaseous Effluent Concentration

The basic requirements concerning effluents from nuclear power are stated in 10 CFR 50.36a. These requirements indicate that compliance with Technical Specifications will keep average annual releases of radioactive material in effluents to a small percentage of the limits specified in 10 CFR 20. These (new 10 CFR 20.1301) requirements further indicate that operational flexibility is allowed, compatible with considerations of health and safety, which may temporarily result in releases higher than such small percentages, but still within the limits specified in the old 10 CFR 20.106. These referenced concentrations are specific values which relate to an annual average dose of 500 millirems.

As stated in the Introduction to Appendix B of the new 10 CFR 20, the gaseous effluent concentration limits given in the appendix are based on an annual dose of 50 millirem for isotopes for which inhalation or ingestion is limiting or 100 millirem for isotopes for which submersion (noble gases) is limiting. Prior to the issuance of the revision to Part 20 a release concentration corresponding to limiting dose rates less than or equal to 500 mrem/yr to the whole body, 3000 mrem/yr to the skin from noble gases, and 1500 mrem/yr to any organ from iodine, and tritium, had been acceptable as a TS limit for airborne effluents. This limit was applicable at all times and had been used to provide assurance that the limits of 10 CFR 50 Appendix I and 40 CFR 190 were not likely to be exceeded.

Since the limits of 10 CFR 50 Appendix I and 40 CFR 90 are more restrictive than 10 CFR 20, and because the dose limits specified have been successfully used to assure compliance with these regulations, it should not be necessary to reduce the dose rate basis to 50 or 100 millirem.

Conformance with the dose limits of 7.3.1 will necessitate the average annual airborne effluent concentrations being below those specified in 10 CFR 20 Appendix B. Demonstrating compliance with section 6.3.1 will result in a de facto demonstration of compliance with 10 CFR 20 limits. Assessment of compliance is based upon an effluents measurement program defined in Table 7.2-2 and methodology stated in the ODAM. The resolving time of the measurements, i.e., the sample integration time, bounds the minimum averaging time of the effluent measurements waste streams. The Standby Gas Treatment System is considered an Engineered Safety Feature and not an exhaust ventilation treatment system.

BASES SECTION 6.2 / 7.2

- 6.2.3 / 7.2.3 Thus the exhaust ventilation system discharges via the reactor building vent.
Doses due to Noble Gases

These specifications implement the requirements of 10 CFR Part 50, Appendix I.

- 6.2.4 / 7.2.4 Doses due to Iodine and Particulates in Air
These specifications implement 10 CFR Part 50, Appendix I. The dose calculation methods in the ODAM depend on existing pathways of exposure to a member of the public or more conservative conditions assumed (yielding a higher calculated dose). Calculations and methods are such that an estimate of the dose to a member of the public is not likely to be underestimated substantially.

- 6.2.5 / 7.2.5 Gaseous Radwaste Treatment

This specification implements the requirement of 10 CFR Part 50.36a(a)(1) that operating procedures be established and followed and that equipment be maintained and used to keep releases to the environment as low as is reasonably achievable. In order to satisfy Section 6.2.5, every reasonable effort shall be made to maintain and operate at least one train of the Offgas System charcoal adsorbers with pre- and aft-particulate filters to process radioactive gaseous effluent prior to release. The specification that the Offgas System which was used to establish compliance with the design objectives in 10 CFR Part 50, Appendix I, Section II be used when specified provides reasonable assurance that the releases of radioactive materials in gaseous effluents will be kept as low as is reasonably achievable.

ODAM Figure 3-1 is a flow diagram depicting gaseous radioactive waste streams. The Standby Gas Treatment System is considered an Engineered Safety Feature and not an exhaust ventilation treatment system.

BASES SECTION 6.3 / 7.3**6.3.1 / 7.3.1 Dose**

Section 6.3.1 is provided to comply with the dose limitation requirement of 40 CFR 190. This section requires the assessment of dose to demonstrate that a person (a nearby resident) has not received a radiation dose exceeding that specified in 40 CFR 190 including doses from direct radiation. There is no other licensed nuclear fuel cycle facility within 50 miles of DAEC, thus it is assumed that the dose from other uranium fuel cycle facilities is negligible. In the event a report is required to satisfy Action b, it shall be deemed adequate to satisfy the reporting requirement in Section 8.2.2.

By demonstrating compliance with 40 CFR 190, DAEC will be, de facto, in compliance with the dose limits specified in 10 CFR 20.1301 and 10 CFR 72.104. Such a position is in keeping with that stated by the NRC in the preamble to the revised 10 CFR 20 (56 CFR 23360).

6.3.2 / 7.3.2 Radiological Environmental Monitoring

The radiological environmental monitoring program, including the land use census, is conducted to satisfy the requirements of 10 CFR Part 50, Appendix I, Section IV.B.2 and .3. The minimum radiological monitoring program required by this specification provides measurements of radiation and of radioactive materials in those exposure pathways and for those radionuclides which lead to the highest potential radiation exposures of individuals resulting from the station operation. This monitoring program thereby supplements the radiological effluent monitoring program by verifying that the measurable concentrations of radioactive materials and levels of radiation are not higher than expected on the basis of the effluent measurements and modeling of the environmental exposure pathways.

The land use census is conducted annually to identify changes in use of the UNRESTRICTED AREA in order to recommend modifications in monitoring programs for evaluating individual doses from principal exposure pathways. It may be conducted by door-to-door survey, by aerial survey, or by consulting with local agricultural or governmental authorities.

In order that radiological environmental monitoring stations may be relocated to reflect current conditions, the locations of stations required by Table 6.3-1 are described in the Offsite Dose Assessment Manual. Revisions thereto are administered in accordance with TS 5.5.1 and ODAM 8.3.1. DAEC may conduct additional environmental monitoring exclusive of the requirements of Sections 6.3.2.

8.0 ADMINISTRATIVE CONTROLS

8.1 PROGRAMS AND MANUALS

8.1.1 RADIOACTIVE EFFLUENT CONTROLS PROGRAM

This program, conforming to 10 CFR 50.36a, provides for the control of radioactive effluents and for maintaining the doses to members of the public from radioactive effluents as low as reasonably achievable. The program shall be contained in the ODAM, shall be implemented by procedures, and shall include remedial actions to be taken whenever the program limits are exceeded. The program shall include the following elements.

- a. Limitations on the functional capacity of radioactive liquid and gaseous monitoring instrumentation including surveillance tests and setpoint determination in accordance with the methodology in the ODAM;
- b. Limitations on the concentrations of radioactive material released in liquid effluents from the site to UNRESTRICTED AREAs, conforming to ten times (10x) the concentrations listed in Appendix B, Table 2, Column 2 to 10 CFR 20.1001 - 20.2402;
- c. Monitoring, sampling, and analysis of radioactive liquid and gaseous effluents pursuant to 10 CFR 20.1302 and with the methodology and parameters in the ODAM conforming to 10CFR50, Appendix I;
- d. Limitations on the annual and quarterly doses or dose commitment to a member of the public from radioactive materials in liquid effluents released to UNRESTRICTED AREAs;
- e. Determination of cumulative and projected dose contributions from radioactive effluents for the current calendar quarter and current calendar year in accordance with the methodology and parameters in the ODAM at least every 30 days;
- f. Limitations on the functional capability and use of the liquid and gaseous effluent treatment systems to ensure that the appropriate portions of these systems which were used to establish compliance with the design objectives in 10 CFR 50, Appendix I, Section II be used when specified to provide reasonable assurance that releases of radioactive material in liquid and gaseous effluents be kept as low as reasonably achievable;
- g. Limitations on the dose rate resulting from radioactive material released in gaseous effluents to areas at or beyond the site boundary shall be limited to the following:
 1. For noble gases: less than or equal to a dose rate of 500 mrem/yr to the whole body and less than or equal to a dose rate of 3000 mrem/yr to the skin, and
 2. For iodine-131, iodine-133, tritium, and for all radionuclides in particulate form with half lives > 8 days: less than or equal to a dose rate of 1500 mrem/yr to any organ;
- h. Limitations on the annual and quarterly air doses resulting from noble gases released in gaseous effluents to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I;
- i. Limitations on the annual and quarterly doses to a member of the public from iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half lives > 8 days in gaseous effluents released to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I; and
- j. Limitations on the annual dose or dose commitment to any member of the public due to releases of radioactivity and to radiation from uranium fuel cycle sources, conforming to 40 CFR 190 and 10 CFR 72.104.

8.1.2 THE RADIOPHYSICAL ENVIRONMENTAL MONITORING PROGRAM

The Radiological Environmental Monitoring Program is described in section 5 of the ODAM. Specifications for implementation are located in section 6.3.2.

8.1.3 INTERLABORATORY COMPARISON PROGRAM

Analyses shall be performed on radioactive materials supplied in an Interlaboratory Comparison Program.

In the event analyses were not performed as required in Section 8.1.3, report the corrective actions taken to prevent a recurrence in the Annual Radiological Environmental Report.

The requirement for participation in an Interlaboratory Comparison Program is provided to ensure that independent checks on the precision and accuracy of the measurements of radioactive material in environmental sample matrices are performed as part of the quality assurance program for environmental monitoring in order to demonstrate that the results are reasonably valid.

8.2 REPORTING REQUIREMENTS

8.2.1 ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT

- (1) A report of radioactive materials released from the Station shall be submitted to the NRC on or before May 1 of each year in accordance with 10 CFR 50.36a. Each report shall include the information specified in item (2) below covering the preceding twelve months.
- (2) An Annual Radioactive Material Release Report shall include a summary by calendar quarter of the quantities of radioactive liquid and gaseous effluents and radioactive solid waste released from the Station. The data on radioactive liquid and gaseous effluents should be reported in the format in Tables 8.2-1 and 8.2-2. The data on radioactive solid waste should include:
 1. classification of the waste (per 10 CFR Part 61)
 2. total volume shipped
 3. total radioactive material shipped (curies)
 4. identification of principal radionuclides
 5. solidification agent
 6. physical description of the waste
- (3) A summary description of any changes to the ODAM.
- (4) A summary of meteorological data collected during the year will be submitted in the annual report following January 1. Alternatively, summary meteorological data may be retained by DAEC and made available to the NRC upon request.
- (5) Include all onsite ground water sample results, for samples that are being taken in support of the Industry Ground Water Protection Initiative, but are from onsite sample locations that have not been incorporated into the Radiological Environmental Monitoring Program.
- (6) Include a description for all sample analyses/conditions for which communications were made to State and Local officials due to exceeding the applicable ODAM reporting levels for environmental samples for locations that have not been added to the plant's Radiological Environmental Monitoring Program.
- (7) Include a description of all spills or leaks (of radioactive material) that were communicated to State/Local Stakeholders.

(continued)

REPORTING REQUIREMENTS (continued)

8.2

TABLE 8.2-1

ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT (YEAR)
LIQUID EFFLUENTS

| Nuclides Released | Unit | Quarter | Quarter |
|--------------------------|------|---------|---------|
| strontium-89 | Ci | . E | . E |
| strontium-90 | Ci | . E | . E |
| cesium-134 | Ci | . E | . E |
| cesium-137 | Ci | . E | . E |
| iodine-131 | Ci | . E | . E |
| cobalt-58 | Ci | . E | . E |
| cobalt-60 | Ci | . E | . E |
| iron-55 | Ci | . E | . E |
| iron-59 | Ci | . E | . E |
| zinc-65 | Ci | . E | . E |
| manganese-54 | Ci | . E | . E |
| chromium-51 | Ci | . E | . E |
| zirconium-niobium-95 | Ci | . E | . E |
| molybdenum-99 | Ci | . E | . E |
| technetium-99m | Ci | . E | . E |
| barium-lanthanum-140 | Ci | . E | . E |
| cerium-141 | Ci | . E | . E |
| Other (specify) | Ci | . E | . E |
| | Ci | . E | . E |
| | Ci | . E | . E |
| | Ci | . E | . E |
| | Ci | . E | . E |
| Total for period (above) | Ci | . E | . E |
| xenon-133 | Ci | . E | . E |
| xenon-135 | Ci | . E | . E |

REPORTING REQUIREMENTS (continued)

8.2

TABLE 8.2-2

ANNUAL RADIOACTIVE MATERIAL RELEASE REPORT (YEAR)
GASEOUS EFFLUENTS

| Nuclides Released | Unit | Quarter | Quarter |
|----------------------|------|---------|---------|
| 1. Fission gases | | | |
| krypton-85 | Ci | . E | . E |
| krypton-85m | Ci | . E | . E |
| krypton-87 | Ci | . E | . E |
| krypton-88 | Ci | . E | . E |
| xenon-133 | Ci | . E | . E |
| xenon-135 | Ci | . E | . E |
| xenon-135m | Ci | . E | . E |
| xenon-138 | Ci | . E | . E |
| Others (specify) | Ci | . E | . E |
| | Ci | . E | . E |
| | Ci | . E | . E |
| Total for period | Ci | . E | . E |
| 2. Iodines | | | |
| iodine-131 | Ci | . E | . E |
| iodine-133 | Ci | . E | . E |
| iodine-135 | Ci | . E | . E |
| Others (specify) | | | |
| Total for period | Ci | . E | . E |
| 3. Particulates | | | |
| strontium-89 | Ci | . E | . E |
| strontium-90 | Ci | . E | . E |
| cesium-134 | Ci | . E | . E |
| cesium-137 | Ci | . E | . E |
| barium-lanthanum-140 | Ci | . E | . E |
| Others (specify) | Ci | . E | . E |
| | Ci | . E | . E |

8.2.2 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT

An annual report of radiological environmental surveillance activities required by Section 6.3.2 shall be submitted to the NRC by May 15th of each year. Each report shall be consistent with the objectives outlined in the ODAM, and with 10 CFR 50, Appendix I, Sections IV.B.2, IV.B.3, and IV.C. The report shall include the following information:

- (1) A summary description of the radiological environmental monitoring program required by Section 6.3.2.
- (2) A map and a table of distances and directions of locations of sampling stations required in Table 6.3-1.
- (3) A summary of the land use census required in Section 7.3.2.2.
- (4) Results of analyses of samples required by the radiological environmental monitoring program, Table 6.3-1. In the event some results are not available, the reasons shall be explained in the report. In the event the missing results are obtained, they shall be submitted in a supplementary report as soon as is reasonable.
- (5) An assessment of radiation doses to a MEMBER OF THE PUBLIC likely to be the most exposed due to radioactive liquid and gaseous effluents released from DAEC during the year. The assessment shall be performed as described in the ODAM.
- (6) Deleted.
- (7) Results of participation in the Interlaboratory Comparison Program.
- (8) Deviation from environmental sampling schedule.
- (9) A report of all analyses in which the LLD, required by Table 6.3-2, was not achieved.
- (10) A report of any changes in sample locations.
- (11) Include a description for all sample analyses/conditions for which communications were made to State and Local Stakeholders due to exceeding the REMP reporting levels provided in the plant's OCDM/ODAM for locations that are described in the plant's REMP or GWPP programs.

8.2.3 SPECIAL REPORTS

Special reports shall be submitted to the Director of Inspection and Enforcement Regional Office within the time period specified for each report. These reports shall be submitted covering the activities identified below pursuant to the requirements of the applicable reference specification.

1. Radioactive Liquid or Gaseous Effluent - calculated dose exceeding specified limit (ODAM Sections 6.1.3, 6.2.3, and 6.2.4).
2. Off-Gas System inoperable (ODAM Section 6.2.5).
3. Measured levels of radioactivity in an environmental sampling medium determined to exceed the reporting level values of ODAM Table 6.3-3 when averaged over any calendar quarter sampling period (ODAM Section 6.3.2). Report to State and Local authorities in accordance with Administrative Control Procedure (ACP) 1402.3.
4. Annual dose to a MEMBER OF THE PUBLIC determined to exceed 40 CFR Part 190 dose limit (ODAM Section 6.3.1.1).
5. Radioactive liquid waste release without treatment when activity concentration is equal to or greater than 0.01 $\mu\text{Ci}/\text{mL}$ (ODAM Section 6.1.4).
6. Liquid Holdup Tank Instrumentation Inoperable (ODAM Section 6.1.6).

REPORTING REQUIREMENTS (continued)
8.2

8.3.1 CHANGES TO THE ODAM

- a. Shall be documented and records of reviews performed shall be retained for the duration of the facility operating license. This documentation shall contain:
 - 1) Sufficient information to support the change together with the appropriate analyses or evaluations justifying the change(s) and;
 - 2) A determination that the change will maintain the level of radioactive effluent control required by 10 CFR 20.1302, 40 CFR Part 190, 10 CFR 72.104, 10 CFR 50.36a, and Appendix I to 10 CFR Part 50 and not adversely impact the accuracy or reliability of effluent dose or setpoint calculations.
- b. Shall become effective after review and acceptance by the Onsite Review Group and approval by the DAEC Plant Manager.
- c. Shall be submitted to the commission in the form of a complete, legible copy of the entire ODAM as a part of or concurrent with the Annual Radioactive Material Release Report for the period of the report in which any change to the ODAM was made. Each change shall be identified by markings in the margin of the affected pages, clearly indicating the area of the page that was changed, and shall indicate the date the change was implemented.

Appendix A

APPENDIX A: DOSE TRANSFER FACTORS FOR AIRBORNE PATHWAYS

Environmental pathway models have been solved on the bases of unit radionuclide release in effluent (1 Ci/yr) and unit atmospheric dispersion (1 sec/m³) or deposition (1/m²) to derive dose transfer factors for airborne effluent. The dose transfer factors in this appendix were computed with the GASPAR II computer program^a, using default values of parameters applicable to the most exposed members of the public as recommended in Regulatory Guide 1.109, revision 1, with the following exceptions.

- Significant revisions of data since publication of the Regulatory Guide 1.109, revision 1 and incorporated into GASPAR II were employed. Data differing from those in the Regulatory Guide 1.109 are identified in GASPAR II documentation.^b
- After publishing Reg. Guide 1.109, the NRC recommended that soil-to-plant bioaccumulation factors, B_{IV} , of cesium and strontium be changed.^c The revised values were used to derive dose transfer factors tabulated for Sr89, Sr90, and Cs137.
- Values of environmental transit time recommended in Reg. Guide 1.109,^d namely 1440 hr from harvest of stored vegetables to ingestion, were retained in lieu of default values in GASPAR II.^e

These factors affected dose transfer factors more than 10% only for H3, Sr89, Sr90, Cs137, Ce141, and Ce144.

Dose transfer factors from C14 via inhalation and from Kr90 via irradiation by an airborne cloud are the same as in the previous MIDAS library since GASPAR II does not produce them. Skin dose transfer factors are assumed to be the same as total body dose transfer factors for H3 and C14 in exposure pathways involving inhalation or ingestion also because GASPAR II does not calculate them.

^a Strenge, D.L., et. al., GASPAR II - Technical Reference and User Guide, NUREG/CR-4653, March 1987

^b Ibid., 3.3.1.1, 3.3.2.3

^c USNRC, SECY-79-653A, January 30, 1980.

^d Regulatory Guide 1.109, rev. 1, Table E-15

^e Strenge, et. al., p. C.3.

Appendix A

Dose transfer factors are included hereafter for the following parameters.

| Pathway | Age Group | Organ |
|-----------------------------|-----------|------------|
| Inhalation | Adult | Total Body |
| Ground irradiation | Teenager | GI tract |
| Grass-cow-milk | Child | Bone |
| Grass-goat-milk | Infant | Liver |
| Grass-cow-meat | | Kidney |
| Vegetables, leafy + produce | | Thyroid |
| Plume irradiation | | Lung |
| | | Skin |

Appendix A

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR-II

AGE = ADULT

PATHWAY = INHALATION

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 2.28E+01 | 2.28E+01 | 0.00E-01 | 2.28E+01 | 2.28E+01 | 2.28E+01 | 2.28E+01 | 2.28E+01 |
| C 14 | 1.08E+02 | 1.08E+02 | 5.76E+02 | 1.08E+02 | 1.08E+02 | 1.08E+02 | 1.08E+02 | 0.00E-01 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 3.17E+00 | 1.05E+02 | 0.00E-01 | 0.00E-01 | 7.23E-01 | 1.89E+00 | 4.56E+02 | 0.00E-01 |
| MN 54 | 2.00E+02 | 2.45E+03 | 0.00E-01 | 1.25E+03 | 3.12E+02 | 0.00E-01 | 4.44E+04 | 0.00E-01 |
| FE 59 | 3.36E+02 | 5.96E+03 | 3.74E+02 | 8.81E+02 | 0.00E-01 | 0.00E-01 | 3.23E+04 | 0.00E-01 |
| CO 58 | 6.56E+01 | 3.36E+03 | 0.00E-01 | 5.01E+01 | 0.00E-01 | 0.00E-01 | 2.94E+04 | 0.00E-01 |
| CO 60 | 4.69E+02 | 9.03E+03 | 0.00E-01 | 3.64E+02 | 0.00E-01 | 0.00E-01 | 1.89E+05 | 0.00E-01 |
| ZN 65 | 1.48E+03 | 1.70E+03 | 1.03E+03 | 3.26E+03 | 2.19E+03 | 0.00E-01 | 2.74E+04 | 0.00E-01 |
| SR 89 | 2.76E+02 | 1.11E+04 | 9.63E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 4.44E+04 | 0.00E-01 |
| SR 90 | 1.83E+04 | 2.29E+04 | 9.10E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 3.04E+05 | 0.00E-01 |
| ZR 95 | 7.38E+02 | 4.75E+03 | 3.39E+03 | 1.09E+03 | 1.72E+03 | 0.00E-01 | 5.61E+04 | 0.00E-01 |
| SB124 | 3.93E+02 | 1.29E+04 | 9.89E+02 | 1.87E+01 | 0.00E-01 | 2.40E+00 | 7.86E+04 | 0.00E-01 |
| CS134 | 2.31E+04 | 3.30E+02 | 1.18E+04 | 2.69E+04 | 9.10E+03 | 0.00E-01 | 3.09E+03 | 0.00E-01 |
| CS136 | 3.49E+03 | 3.71E+02 | 1.24E+03 | 4.63E+03 | 2.71E+03 | 0.00E-01 | 3.80E+02 | 0.00E-01 |
| CS137 | 1.36E+04 | 2.66E+02 | 1.52E+04 | 1.97E+04 | 7.07E+03 | 0.00E-01 | 2.38E+03 | 0.00E-01 |
| BA140 | 8.14E+01 | 6.91E+03 | 1.24E+03 | 1.56E+00 | 5.29E-01 | 0.00E-01 | 4.02E+04 | 0.00E-01 |
| CE141 | 4.85E+01 | 3.80E+03 | 6.31E+02 | 4.28E+02 | 1.99E+02 | 0.00E-01 | 1.15E+04 | 0.00E-01 |
| CE144 | 5.83E+03 | 2.59E+04 | 1.09E+05 | 4.53E+04 | 2.69E+04 | 0.00E-01 | 2.47E+05 | 0.00E-01 |
| I 131 | 6.50E+02 | 1.99E+02 | 7.99E+02 | 1.13E+03 | 1.94E+03 | 3.77E+05 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.43E+02 | 2.81E+02 | 2.74E+02 | 4.69E+02 | 8.21E+02 | 6.81E+04 | 0.00E-01 | 0.00E-01 |

Appendix A

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = ADULT

PATHWAY = GROUND PLANE

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.74E+05 |
| MN 54 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 5.13E+07 |
| FE 59 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 1.01E+07 |
| CO 58 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.41E+07 |
| CO 60 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 8.02E+08 |
| ZN 65 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.72E+07 |
| SR 89 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 7.95E+02 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 9.03E+06 |
| SB124 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 2.19E+07 |
| CS134 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.53E+08 |
| CS136 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 5.39E+06 |
| CS137 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.80E+08 |
| BA140 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 7.45E+05 |
| CE141 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.88E+05 |
| CE144 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.55E+06 |
| I 131 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 3.33E+05 |
| I 133 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 4.72E+04 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = ADULT

PATHWAY = COW-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 1.39E+01 | 1.39E+01 | 0.00E-01 | 1.39E+01 | 1.39E+01 | 1.39E+01 | 1.39E+01 | 1.39E+01 |
| C 14 | 2.33E+03 | 2.33E+03 | 1.16E+04 | 2.33E+03 | 2.33E+03 | 2.33E+03 | 2.33E+03 | 2.33E+03 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 8.08E+02 | 2.03E+05 | 0.00E-01 | 0.00E-01 | 1.78E+02 | 4.85E+02 | 1.07E+03 | 0.00E-01 |
| MN 54 | 4.06E+04 | 6.53E+05 | 0.00E-01 | 2.13E+05 | 6.34E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 7.29E+05 | 6.34E+06 | 8.08E+05 | 1.90E+06 | 0.00E-01 | 0.00E-01 | 5.29E+05 | 0.00E-01 |
| CO 58 | 2.79E+05 | 2.52E+06 | 0.00E-01 | 1.24E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 9.10E+05 | 7.73E+06 | 0.00E-01 | 4.12E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 5.61E+07 | 7.83E+07 | 3.90E+07 | 1.25E+08 | 8.33E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.21E+06 | 6.75E+06 | 4.21E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.40E+08 | 1.76E+08 | 6.97E+09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 5.42E+00 | 2.54E+04 | 2.50E+01 | 8.02E+00 | 1.26E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 2.72E+05 | 1.95E+07 | 6.85E+05 | 1.30E+04 | 0.00E-01 | 1.66E+03 | 5.32E+05 | 0.00E-01 |
| CS134 | 2.77E+08 | 5.93E+06 | 1.43E+08 | 3.39E+08 | 1.10E+08 | 0.00E-01 | 3.64E+07 | 0.00E-01 |
| CS136 | 2.26E+07 | 3.55E+06 | 7.95E+06 | 3.14E+07 | 1.75E+07 | 0.00E-01 | 2.39E+06 | 0.00E-01 |
| CS137 | 1.76E+08 | 5.20E+06 | 1.97E+08 | 2.69E+08 | 9.13E+07 | 0.00E-01 | 3.04E+07 | 0.00E-01 |
| BA140 | 5.32E+04 | 1.68E+06 | 8.14E+05 | 1.02E+03 | 3.49E+02 | 0.00E-01 | 5.86E+02 | 0.00E-01 |
| CE141 | 1.04E+01 | 3.49E+05 | 1.35E+02 | 9.16E+01 | 4.25E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 4.82E+02 | 3.03E+06 | 8.97E+03 | 3.74E+03 | 2.22E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 3.77E+06 | 1.74E+06 | 4.63E+06 | 6.59E+06 | 1.13E+07 | 2.16E+09 | 0.00E-01 | 0.00E-01 |
| I 133 | 3.26E+04 | 9.60E+04 | 6.15E+04 | 1.07E+05 | 1.87E+05 | 1.57E+07 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = ADULT

PATHWAY = GOAT-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 2.84E+01 | 2.84E+01 | 0.00E-01 | 2.84E+01 | 2.84E+01 | 2.84E+01 | 2.84E+01 | 2.84E+01 |
| C 14 | 2.33E+03 | 2.33E+03 | 1.16E+04 | 2.33E+03 | 2.33E+03 | 2.33E+03 | 2.33E+03 | 2.33E+03 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 9.70E+01 | 2.44E+04 | 0.00E-01 | 0.00E-01 | 2.14E+01 | 5.80E+01 | 1.29E+02 | 0.00E-01 |
| MN 54 | 4.88E+03 | 7.83E+04 | 0.00E-01 | 2.55E+04 | 7.61E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 9.44E+04 | 8.21E+05 | 1.05E+05 | 2.47E+05 | 0.00E-01 | 0.00E-01 | 6.91E+04 | 0.00E-01 |
| CO 58 | 3.36E+04 | 3.02E+05 | 0.00E-01 | 1.49E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.09E+05 | 9.29E+05 | 0.00E-01 | 4.94E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 6.75E+06 | 9.41E+06 | 4.69E+06 | 1.49E+07 | 9.98E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.54E+06 | 1.42E+07 | 8.84E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 2.94E+08 | 3.68E+08 | 1.46E+10 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 6.53E-01 | 3.05E+03 | 3.00E+00 | 9.63E-01 | 1.51E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 3.26E+04 | 2.34E+06 | 8.24E+04 | 1.56E+03 | 0.00E-01 | 2.00E+02 | 6.40E+04 | 0.00E-01 |
| CS134 | 8.30E+08 | 1.78E+07 | 4.28E+08 | 1.02E+09 | 3.30E+08 | 0.00E-01 | 1.09E+08 | 0.00E-01 |
| CS136 | 6.78E+07 | 1.07E+07 | 2.38E+07 | 9.41E+07 | 5.23E+07 | 0.00E-01 | 7.16E+06 | 0.00E-01 |
| CS137 | 5.29E+08 | 1.56E+07 | 5.89E+08 | 8.08E+08 | 2.74E+08 | 0.00E-01 | 9.10E+07 | 0.00E-01 |
| BA140 | 6.40E+03 | 2.01E+05 | 9.76E+04 | 1.23E+02 | 4.18E+01 | 0.00E-01 | 7.04E+01 | 0.00E-01 |
| CE141 | 1.25E+00 | 4.18E+04 | 1.62E+01 | 1.10E+01 | 5.10E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 5.77E+01 | 3.64E+05 | 1.07E+03 | 4.50E+02 | 2.67E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 4.53E+06 | 2.09E+06 | 5.55E+06 | 7.92E+06 | 1.36E+07 | 2.60E+09 | 0.00E-01 | 0.00E-01 |
| I 133 | 3.90E+04 | 1.15E+05 | 7.38E+04 | 1.28E+05 | 2.24E+05 | 1.89E+07 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = ADULT
PATHWAY = ANIMAL-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 5.93E+00 | 5.93E+00 | 0.00E-01 | 5.93E+00 | 5.93E+00 | 5.93E+00 | 5.93E+00 | 5.93E+00 |
| C 14 | 2.13E+03 | 2.13E+03 | 1.06E+04 | 2.13E+03 | 2.13E+03 | 2.13E+03 | 2.13E+03 | 2.13E+03 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.99E+02 | 5.01E+04 | 0.00E-01 | 0.00E-01 | 4.40E+01 | 1.19E+02 | 2.65E+02 | 0.00E-01 |
| MN 54 | 4.44E+04 | 7.10E+05 | 0.00E-01 | 2.32E+05 | 6.91E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 6.50E+06 | 5.64E+07 | 7.23E+06 | 1.70E+07 | 0.00E-01 | 0.00E-01 | 4.75E+06 | 0.00E-01 |
| CO 58 | 1.08E+06 | 9.76E+06 | 0.00E-01 | 4.82E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 4.15E+06 | 3.55E+07 | 0.00E-01 | 1.89E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.46E+07 | 2.03E+07 | 1.01E+07 | 3.23E+07 | 2.16E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.51E+05 | 1.40E+06 | 8.75E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 3.74E+07 | 4.66E+07 | 1.85E+09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.08E+04 | 5.04E+07 | 4.98E+04 | 1.59E+04 | 2.50E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 2.09E+05 | 1.50E+07 | 5.26E+05 | 9.98E+03 | 0.00E-01 | 1.28E+03 | 4.12E+05 | 0.00E-01 |
| CS134 | 3.23E+07 | 6.91E+05 | 1.66E+07 | 3.93E+07 | 1.28E+07 | 0.00E-01 | 4.25E+06 | 0.00E-01 |
| CS136 | 1.03E+06 | 1.63E+05 | 3.61E+05 | 1.43E+06 | 7.95E+05 | 0.00E-01 | 1.09E+05 | 0.00E-01 |
| CS137 | 2.08E+07 | 6.15E+05 | 2.33E+07 | 3.17E+07 | 1.08E+07 | 0.00E-01 | 3.58E+06 | 0.00E-01 |
| BA140 | 5.70E+04 | 1.79E+06 | 8.71E+05 | 1.09E+03 | 3.71E+02 | 0.00E-01 | 6.27E+02 | 0.00E-01 |
| CE141 | 3.01E+01 | 1.01E+06 | 3.93E+02 | 2.65E+02 | 1.23E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.96E+03 | 1.24E+07 | 3.64E+04 | 1.53E+04 | 9.06E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.37E+05 | 6.31E+04 | 1.67E+05 | 2.39E+05 | 4.09E+05 | 7.83E+07 | 0.00E-01 | 0.00E-01 |
| I 133 | 3.11E-03 | 9.16E-03 | 5.86E-03 | 1.02E-02 | 1.78E-02 | 1.50E+00 | 0.00E-01 | 0.00E-01 |

Appendix A

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = ADULT

PATHWAY = VEGETABLES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 4.12E+01 | 4.12E+01 | 0.00E-01 | 4.12E+01 | 4.12E+01 | 4.12E+01 | 4.12E+01 | 4.12E+01 |
| C 14 | 5.74E+03 | 5.74E+03 | 2.87E+04 | 5.74E+03 | 5.74E+03 | 5.74E+03 | 5.74E+03 | 5.74E+03 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | -0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.45E+03 | 3.64E+05 | 0.00E-01 | 0.00E-01 | 3.20E+02 | 8.68E+02 | 1.93E+03 | 0.00E-01 |
| MN 54 | 1.86E+06 | 2.99E+07 | 0.00E-01 | 9.76E+06 | 2.90E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 3.52E+06 | 3.07E+07 | 3.93E+06 | 9.19E+06 | 0.00E-01 | 0.00E-01 | 2.57E+06 | 0.00E-01 |
| CO 58 | 2.13E+06 | 1.93E+07 | 0.00E-01 | 9.51E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.16E+07 | 9.92E+07 | 0.00E-01 | 5.29E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.83E+07 | 2.55E+07 | 1.27E+07 | 4.06E+07 | 2.70E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 9.19E+06 | 5.13E+07 | 3.20E+08 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.26E+09 | 1.57E+09 | 6.27E+10 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 7.89E+03 | 3.68E+07 | 3.64E+04 | 1.16E+04 | 1.83E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 1.27E+06 | 9.13E+07 | 3.20E+06 | 6.08E+04 | 0.00E-01 | 7.80E+03 | 2.50E+06 | 0.00E-01 |
| CS134 | 2.87E+08 | 6.15E+06 | 1.47E+08 | 3.52E+08 | 1.13E+08 | 0.00E-01 | 3.77E+07 | 0.00E-01 |
| CS136 | 3.83E+06 | 6.02E+05 | 1.35E+06 | 5.32E+06 | 2.96E+06 | 0.00E-01 | 4.06E+05 | 0.00E-01 |
| CS137 | 2.06E+08 | 6.08E+06 | 2.30E+08 | 3.14E+08 | 1.07E+08 | 0.00E-01 | 3.55E+07 | 0.00E-01 |
| BA140 | 2.67E+05 | 8.37E+06 | 4.06E+06 | 5.10E+03 | 1.74E+03 | 0.00E-01 | 2.92E+03 | 0.00E-01 |
| CE141 | 4.72E+02 | 1.59E+07 | 6.15E+03 | 4.15E+03 | 1.93E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 5.36E+04 | 3.39E+08 | 9.98E+05 | 4.18E+05 | 2.48E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.05E+06 | 4.82E+05 | 1.28E+06 | 1.83E+06 | 3.14E+06 | 5.99E+08 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.75E+04 | 5.17E+04 | 3.30E+04 | 5.74E+04 | 1.00E+05 | 8.43E+06 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = ADULT
 PATHWAY = PLUME

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ³)/(Ci sec) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|--|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AR 41 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 3.14E+02 |
| KR 83m | 1.68E-03 | 1.68E-03 | 1.68E-03 | 1.68E-03 | 1.68E-03 | 1.68E-03 | 9.38E-02 | 4.75E-01 |
| KR 85m | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.66E+01 | 7.67E+01 |
| KR 85 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 9.51E-01 | 4.28E+01 |
| KR 87 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.35E+02 | 4.60E+02 |
| KR 88 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 4.50E+02 |
| KR 89 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.71E+02 | 7.48E+02 |
| KR 90 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.49E+02 | 6.33E+02 |
| XE131m | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.38E+00 | 1.89E+01 |
| XE133m | 5.58E+00 | 5.58E+00 | 5.58E+00 | 5.58E+00 | 5.58E+00 | 5.58E+00 | 6.02E+00 | 3.96E+01 |
| XE133 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.85E+00 | 1.84E+01 |
| XE135m | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.94E+01 | 1.05E+02 |
| XE135 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.09E+01 | 1.06E+02 |
| XE137 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.55E+01 | 4.25E+02 |
| XE138 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.97E+02 | 3.58E+02 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = TEENAGER
PATHWAY = INHALATION

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ³)/(Ci sec) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|--|----------|----------|----------|----------|
| H 3 | 2.30E+01 | 2.30E+01 | 0.00E-01 | 2.30E+01 | 2.30E+01 | 2.30E+01 | 2.30E+01 | 2.30E+01 |
| C 14 | 1.54E+02 | 1.54E+02 | 8.24E+02 | 1.54E+02 | 1.54E+02 | 1.54E+02 | 1.54E+02 | 0.00E-01 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 4.28E+00 | 9.51E+01 | 0.00E-01 | 0.00E-01 | 9.73E-01 | 2.38E+00 | 6.65E+02 | 0.00E-01 |
| MN 54 | 2.66E+02 | 2.12E+03 | 0.00E-01 | 1.62E+03 | 4.02E+02 | 0.00E-01 | 6.27E+04 | 0.00E-01 |
| FE 59 | 4.53E+02 | 5.64E+03 | 5.04E+02 | 1.17E+03 | 0.00E-01 | 0.00E-01 | 4.85E+04 | 0.00E-01 |
| CO 58 | 8.81E+01 | 3.02E+03 | 0.00E-01 | 6.56E+01 | 0.00E-01 | 0.00E-01 | 4.25E+04 | 0.00E-01 |
| CO 60 | 6.27E+02 | 8.21E+03 | 0.00E-01 | 4.79E+02 | 0.00E-01 | 0.00E-01 | 2.76E+05 | 0.00E-01 |
| ZN 65 | 1.98E+03 | 1.48E+03 | 1.22E+03 | 4.25E+03 | 2.74E+03 | 0.00E-01 | 3.93E+04 | 0.00E-01 |
| SR 89 | 3.96E+02 | 1.18E+04 | 1.38E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 7.67E+04 | 0.00E-01 |
| SR 90 | 2.11E+04 | 2.42E+04 | 1.05E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 5.23E+05 | 0.00E-01 |
| ZR 95 | 9.98E+02 | 4.72E+03 | 4.63E+03 | 1.45E+03 | 2.14E+03 | 0.00E-01 | 8.52E+04 | 0.00E-01 |
| SB124 | 5.32E+02 | 1.26E+04 | 1.37E+03 | 2.52E+01 | 0.00E-01 | 3.09E+00 | 1.22E+05 | 0.00E-01 |
| CS134 | 1.74E+04 | 3.09E+02 | 1.59E+04 | 3.58E+04 | 1.19E+04 | 0.00E-01 | 4.63E+03 | 0.00E-01 |
| CS136 | 4.34E+03 | 3.45E+02 | 1.63E+03 | 6.15E+03 | 3.49E+03 | 0.00E-01 | 5.64E+02 | 0.00E-01 |
| CS137 | 9.86E+03 | 2.69E+02 | 2.13E+04 | 2.69E+04 | 9.63E+03 | 0.00E-01 | 3.83E+03 | 0.00E-01 |
| BA140 | 1.12E+02 | 7.26E+03 | 1.73E+03 | 2.13E+00 | 7.23E-01 | 0.00E-01 | 6.43E+04 | 0.00E-01 |
| CE141 | 6.88E+01 | 3.99E+03 | 9.00E+02 | 6.02E+02 | 2.81E+02 | 0.00E-01 | 1.95E+04 | 0.00E-01 |
| CE144 | 8.33E+03 | 2.74E+04 | 1.55E+05 | 6.40E+04 | 3.83E+04 | 0.00E-01 | 4.25E+05 | 0.00E-01 |
| I 131 | 8.37E+02 | 2.06E+02 | 1.12E+03 | 1.56E+03 | 2.66E+03 | 4.63E+05 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.97E+02 | 3.26E+02 | 3.87E+02 | 6.50E+02 | 1.14E+03 | 9.25E+04 | 0.00E-01 | 0.00E-01 |

Appendix A

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = TEENAGER
PATHWAY = GROUND PLANE

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|-----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | -0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.74E+05 |
| MN 54 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 5.13E+07 |
| FE 59 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 1.01E+07 |
| CO 58 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.41E+07 |
| CO 60 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 8.02E+08 |
| ZN 65 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.72E+07 |
| SR 89 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 7.95E+02 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 9.03E+06 |
| SB124 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 2.19E+07 |
| CS134 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.53E+08 |
| CS136 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 5.39E+06 |
| CS137 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.80E+08 |
| BA140 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 7.45E+05 |
| CE141 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.88E+05 |
| CE144 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.55E+06 |
| I 131 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 3.33E+05 |
| I 133 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 4.72E+04 |

Appendix A

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = TEENAGER
PATHWAY = COW-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ² /Ci) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 1.81E+01 | 1.81E+01 | 0.00E-01 | 1.81E+01 | 1.81E+01 | 1.81E+01 | 1.81E+01 | 1.81E+01 |
| C 14 | 4.28E+03 | 4.28E+03 | 2.15E+04 | 4.28E+03 | 4.28E+03 | 4.28E+03 | 4.28E+03 | 4.28E+03 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.41E+03 | 2.37E+05 | 0.00E-01 | 0.00E-01 | 3.10E+02 | 7.86E+02 | 2.02E+03 | 0.00E-01 |
| MN 54 | 7.04E+04 | 7.26E+05 | 0.00E-01 | 3.55E+05 | 1.06E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 1.27E+06 | 7.76E+06 | 1.41E+06 | 3.30E+06 | 0.00E-01 | 0.00E-01 | 1.04E+06 | 0.00E-01 |
| CO 58 | 4.82E+05 | 2.89E+06 | 0.00E-01 | 2.09E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.57E+06 | 9.10E+06 | 0.00E-01 | 6.97E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 9.73E+07 | 8.84E+07 | 6.02E+07 | 2.09E+08 | 1.33E+08 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.22E+06 | 9.25E+06 | 7.76E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 2.11E+08 | 2.41E+08 | 1.06E+10 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 9.51E+00 | 3.20E+04 | 4.37E+01 | 1.38E+01 | 2.03E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 4.79E+05 | 2.47E+07 | 1.22E+06 | 2.25E+04 | 0.00E-01 | 2.78E+03 | 1.07E+06 | 0.00E-01 |
| CS134 | 2.70E+08 | 7.26E+06 | 2.47E+08 | 5.83E+08 | 1.85E+08 | 0.00E-01 | 7.07E+07 | 0.00E-01 |
| CS136 | 3.58E+07 | 4.28E+06 | 1.35E+07 | 5.32E+07 | 2.90E+07 | 0.00E-01 | 4.56E+06 | 0.00E-01 |
| CS137 | 1.65E+08 | 6.75E+06 | 3.58E+08 | 4.75E+08 | 1.62E+08 | 0.00E-01 | 6.27E+07 | 0.00E-01 |
| BA140 | 9.48E+04 | 2.27E+06 | 1.47E+06 | 1.80E+03 | 6.12E+02 | 0.00E-01 | 1.21E+03 | 0.00E-01 |
| CE141 | 1.90E+01 | 4.72E+05 | 2.48E+02 | 1.65E+02 | 7.80E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 8.87E+02 | 4.15E+06 | 1.65E+04 | 6.81E+03 | 4.09E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 6.31E+06 | 2.32E+06 | 8.37E+06 | 1.17E+07 | 2.02E+07 | 3.42E+09 | 0.00E-01 | 0.00E-01 |
| I 133 | 5.80E+04 | 1.44E+05 | 1.12E+05 | 1.90E+05 | 3.33E+05 | 2.66E+07 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = TEENAGER
PATHWAY = GOAT-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 3.71E+01 | 3.71E+01 | 0.00E-01 | 3.71E+01 | 3.71E+01 | 3.71E+01 | 3.71E+01 | 3.71E+01 |
| C 14 | 4.28E+03 | 4.28E+03 | 2.15E+04 | 4.28E+03 | 4.28E+03 | 4.28E+03 | 4.28E+03 | 4.28E+03 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.70E+02 | 2.85E+04 | 0.00E-01 | 0.00E-01 | 3.71E+01 | 9.41E+01 | 2.42E+02 | 0.00E-01 |
| MN 54 | 8.43E+03 | 8.71E+04 | 0.00E-01 | 4.25E+04 | 1.27E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 1.65E+05 | 1.01E+06 | 1.83E+05 | 4.28E+05 | 0.00E-01 | 0.00E-01 | 1.35E+05 | 0.00E-01 |
| CO 58 | 5.80E+04 | 3.45E+05 | 0.00E-01 | 2.51E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.89E+05 | 1.09E+06 | 0.00E-01 | 8.37E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.17E+07 | 1.06E+07 | 7.19E+06 | 2.50E+07 | 1.60E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 4.66E+06 | 1.94E+07 | 1.63E+08 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 4.44E+08 | 5.07E+08 | 2.22E+10 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.14E+00 | 3.83E+03 | 5.26E+00 | 1.66E+00 | 2.43E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 5.74E+04 | 2.96E+06 | 1.47E+05 | 2.70E+03 | 0.00E-01 | 3.33E+02 | 1.28E+05 | 0.00E-01 |
| CS134 | 8.11E+08 | 2.17E+07 | 7.42E+08 | 1.75E+09 | 5.55E+08 | 0.00E-01 | 2.12E+08 | 0.00E-01 |
| CS136 | 1.07E+08 | 1.28E+07 | 4.06E+07 | 1.60E+08 | 8.68E+07 | 0.00E-01 | 1.37E+07 | 0.00E-01 |
| CS137 | 4.94E+08 | 2.02E+07 | 1.07E+09 | 1.42E+09 | 4.85E+08 | 0.00E-01 | 1.88E+08 | 0.00E-01 |
| BA140 | 1.14E+04 | 2.72E+05 | 1.77E+05 | 2.16E+02 | 7.32E+01 | 0.00E-01 | 1.45E+02 | 0.00E-01 |
| CE141 | 2.28E+00 | 5.67E+04 | 2.98E+01 | 1.99E+01 | 9.35E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.06E+02 | 4.98E+05 | 1.98E+03 | 8.18E+02 | 4.88E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 7.54E+06 | 2.78E+06 | 1.00E+07 | 1.41E+07 | 2.42E+07 | 4.09E+09 | 0.00E-01 | 0.00E-01 |
| I 133 | 6.97E+04 | 1.73E+05 | 1.35E+05 | 2.28E+05 | 3.99E+05 | 3.20E+07 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = TEENAGER
PATHWAY = ANIMAL-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 3.55E+00 | 3.55E+00 | 0.00E-01 | 3.55E+00 | 3.55E+00 | 3.55E+00 | 3.55E+00 | 3.55E+00 |
| C 14 | 1.80E+03 | 1.80E+03 | 9.00E+03 | 1.80E+03 | 1.80E+03 | 1.80E+03 | 1.80E+03 | 1.80E+03 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.59E+02 | 2.68E+04 | 0.00E-01 | 0.00E-01 | 3.49E+01 | 8.84E+01 | 2.28E+02 | 0.00E-01 |
| MN 54 | 3.52E+04 | 3.64E+05 | 0.00E-01 | 1.77E+05 | 5.29E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 5.20E+06 | 3.17E+07 | 5.77E+06 | 1.35E+07 | 0.00E-01 | 0.00E-01 | 4.25E+06 | 0.00E-01 |
| CO 58 | 8.56E+05 | 5.10E+06 | 0.00E-01 | 3.71E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 3.30E+06 | 1.91E+07 | 0.00E-01 | 1.46E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.16E+07 | 1.05E+07 | 7.13E+06 | 2.47E+07 | 1.58E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.12E+05 | 8.81E+05 | 7.38E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 2.57E+07 | 2.93E+07 | 1.28E+09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 8.62E+03 | 2.90E+07 | 3.99E+04 | 1.25E+04 | 1.84E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 1.68E+05 | 8.68E+06 | 4.31E+05 | 7.95E+03 | 0.00E-01 | 9.76E+02 | 3.77E+05 | 0.00E-01 |
| CS134 | 1.44E+07 | 3.87E+05 | 1.32E+07 | 3.10E+07 | 9.86E+06 | 0.00E-01 | 3.77E+06 | 0.00E-01 |
| CS136 | 7.48E+05 | 8.94E+04 | 2.83E+05 | 1.11E+06 | 6.05E+05 | 0.00E-01 | 9.54E+04 | 0.00E-01 |
| CS137 | 8.94E+06 | 3.64E+05 | 1.93E+07 | 2.57E+07 | 8.75E+06 | 0.00E-01 | 3.39E+06 | 0.00E-01 |
| BA140 | 4.63E+04 | 1.11E+06 | 7.19E+05 | 8.81E+02 | 2.99E+02 | 0.00E-01 | 5.93E+02 | 0.00E-01 |
| CE141 | 2.52E+01 | 6.27E+05 | 3.30E+02 | 2.20E+02 | 1.03E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.65E+03 | 7.73E+06 | 3.08E+04 | 1.27E+04 | 7.61E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.05E+05 | 3.83E+04 | 1.39E+05 | 1.95E+05 | 3.36E+05 | 5.67E+07 | 0.00E-01 | 0.00E-01 |
| I 133 | 2.54E-03 | 6.31E-03 | 4.91E-03 | 8.30E-03 | 1.46E-02 | 1.16E+00 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = TEENAGER
PATHWAY = VEGETABLES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 4.72E+01 | 4.72E+01 | 0.00E-01 | 4.72E+01 | 4.72E+01 | 4.72E+01 | 4.72E+01 | 4.72E+01 |
| C 14 | 9.32E+03 | 9.32E+03 | 4.66E+04 | 9.32E+03 | 9.32E+03 | 9.32E+03 | 9.32E+03 | 9.32E+03 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.93E+03 | 3.23E+05 | 0.00E-01 | 0.00E-01 | 4.21E+02 | 1.07E+03 | 2.75E+03 | 0.00E-01 |
| MN 54 | 2.81E+06 | 2.91E+07 | 0.00E-01 | 1.42E+07 | 4.21E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 5.01E+06 | 3.07E+07 | 5.58E+06 | 1.30E+07 | 0.00E-01 | 0.00E-01 | 4.09E+06 | 0.00E-01 |
| CO 58 | 3.11E+06 | 1.86E+07 | 0.00E-01 | 1.35E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.77E+07 | 1.02E+08 | 0.00E-01 | 7.86E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 2.75E+07 | 2.50E+07 | 1.70E+07 | 5.89E+07 | 3.77E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.39E+07 | 5.80E+07 | 4.88E+08 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.66E+09 | 1.90E+09 | 8.33E+10 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.15E+04 | 3.87E+07 | 5.32E+04 | 1.68E+04 | 2.47E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 1.87E+06 | 9.63E+07 | 4.79E+06 | 8.81E+04 | 0.00E-01 | 1.09E+04 | 4.18E+06 | 0.00E-01 |
| CS134 | 2.45E+08 | 6.56E+06 | 2.24E+08 | 5.29E+08 | 1.68E+08 | 0.00E-01 | 6.40E+07 | 0.00E-01 |
| CS136 | 3.64E+06 | 4.37E+05 | 1.38E+06 | 5.42E+06 | 2.95E+06 | 0.00E-01 | 4.66E+05 | 0.00E-01 |
| CS137 | 1.70E+08 | 6.94E+06 | 3.68E+08 | 4.88E+08 | 1.66E+08 | 0.00E-01 | 6.43E+07 | 0.00E-01 |
| BA140 | 2.82E+05 | 6.75E+06 | 4.37E+06 | 5.36E+03 | 1.82E+03 | 0.00E-01 | 3.61E+03 | 0.00E-01 |
| CE141 | 6.78E+02 | 1.69E+07 | 8.84E+03 | 5.89E+03 | 2.78E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 8.62E+04 | 4.02E+08 | 1.60E+06 | 6.62E+05 | 3.96E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 9.16E+05 | 3.36E+05 | 1.22E+06 | 1.70E+06 | 2.93E+06 | 4.98E+08 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.58E+04 | 3.93E+04 | 3.06E+04 | 5.20E+04 | 9.13E+04 | 7.26E+06 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = TEENAGER
PATHWAY = PLUME

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ³)/(Ci sec) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|--|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AR 41 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 3.14E+02 |
| KR 83m | 1.68E-03 | 1.68E-03 | 1.68E-03 | 1.68E-03 | 1.68E-03 | 1.68E-03 | 9.38E-02 | 4.75E-01 |
| KR 85m | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.66E+01 | 7.67E+01 |
| KR 85 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 9.51E-01 | 4.28E+01 |
| KR 87 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.35E+02 | 4.60E+02 |
| KR 88 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 4.50E+02 |
| KR 89 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.71E+02 | 7.48E+02 |
| KR 90 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.49E+02 | 6.33E+02 |
| XE131m | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.38E+00 | 1.89E+01 |
| XE133m | 5.58E+00 | 5.58E+00 | 5.58E+00 | 5.58E+00 | 5.58E+00 | 5.58E+00 | 6.02E+00 | 3.96E+01 |
| XE133 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.85E+00 | 1.84E+01 |
| XE135m | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.94E+01 | 1.05E+02 |
| XE135 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.09E+01 | 1.06E+02 |
| XE137 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.55E+01 | 4.25E+02 |
| XE138 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.97E+02 | 3.58E+02 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = CHILD

PATHWAY = INHALATION

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ³)/(Ci sec) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|--|----------|----------|----------|----------|
| H 3 | 2.03E+01 | 2.03E+01 | 0.00E-01 | 2.03E+01 | 2.03E+01 | 2.03E+01 | 2.03E+01 | 2.03E+01 |
| C 14 | 2.13E+02 | 2.13E+02 | 1.14E+03 | 2.13E+02 | 2.13E+02 | 2.13E+02 | 2.13E+02 | 0.00E-01 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 4.88E+00 | 3.42E+01 | 0.00E-01 | 0.00E-01 | 7.70E-01 | 2.71E+00 | 5.39E+02 | 0.00E-01 |
| MN 54 | 3.01E+02 | 7.26E+02 | 0.00E-01 | 1.36E+03 | 3.17E+02 | 0.00E-01 | 5.01E+04 | 0.00E-01 |
| FE 59 | 5.29E+02 | 2.24E+03 | 6.56E+02 | 1.06E+03 | 0.00E-01 | 0.00E-01 | 4.02E+04 | 0.00E-01 |
| CO 58 | 1.00E+02 | 1.09E+03 | 0.00E-01 | 5.61E+01 | 0.00E-01 | 0.00E-01 | 3.52E+04 | 0.00E-01 |
| CO 60 | 7.19E+02 | 3.05E+03 | 0.00E-01 | 4.15E+02 | 0.00E-01 | 0.00E-01 | 2.24E+05 | 0.00E-01 |
| ZN 65 | 2.23E+03 | 5.17E+02 | 1.35E+03 | 3.58E+03 | 2.26E+03 | 0.00E-01 | 3.16E+04 | 0.00E-01 |
| SR 89 | 5.45E+02 | 5.29E+03 | 1.90E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 6.85E+04 | 0.00E-01 |
| SR 90 | 2.43E+04 | 1.09E+04 | 1.22E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 4.69E+05 | 0.00E-01 |
| ZR 95 | 1.17E+03 | 1.94E+03 | 6.02E+03 | 1.32E+03 | 1.89E+03 | 0.00E-01 | 7.07E+04 | 0.00E-01 |
| SB124 | 6.34E+02 | 5.20E+03 | 1.82E+03 | 2.35E+01 | 0.00E-01 | 3.99E+00 | 1.03E+05 | 0.00E-01 |
| CS134 | 7.13E+03 | 1.22E+02 | 2.06E+04 | 3.20E+04 | 1.05E+04 | 0.00E-01 | 3.83E+03 | 0.00E-01 |
| CS136 | 3.68E+03 | 1.32E+02 | 2.06E+03 | 5.42E+03 | 3.03E+03 | 0.00E-01 | 4.60E+02 | 0.00E-01 |
| CS137 | 4.06E+03 | 1.15E+02 | 2.87E+04 | 2.61E+04 | 8.94E+03 | 0.00E-01 | 3.30E+03 | 0.00E-01 |
| BA140 | 1.37E+02 | 3.23E+03 | 2.35E+03 | 2.05E+00 | 6.69E-01 | 0.00E-01 | 5.51E+04 | 0.00E-01 |
| CE141 | 9.19E+01 | 1.79E+03 | 1.24E+03 | 6.18E+02 | 2.71E+02 | 0.00E-01 | 1.72E+04 | 0.00E-01 |
| CE144 | 1.15E+04 | 1.23E+04 | 2.15E+05 | 6.72E+04 | 3.71E+04 | 0.00E-01 | 3.80E+05 | 0.00E-01 |
| I 131 | 8.65E+02 | 9.00E+01 | 1.52E+03 | 1.52E+03 | 2.50E+03 | 5.17E+05 | 0.00E-01 | 0.00E-01 |
| I 133 | 2.44E+02 | 1.74E+02 | 5.26E+02 | 6.43E+02 | 1.07E+03 | 1.22E+05 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = CHILD

PATHWAY = GROUND PLANE

| | TOTAL BODY | GI-LI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.74E+05 |
| MN 54 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 5.13E+07 |
| FE 59 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 1.01E+07 |
| CO 58 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.41E+07 |
| CO 60 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 8.02E+08 |
| ZN 65 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.72E+07 |
| SR 89 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 7.95E+02 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 9.03E+06 |
| SB124 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 2.19E+07 |
| CS134 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.53E+08 |
| CS136 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 5.39E+06 |
| CS137 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.80E+08 |
| BA140 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 7.45E+05 |
| CE141 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.88E+05 |
| CE144 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.55E+06 |
| I 131 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 3.33E+05 |
| I 133 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 4.72E+04 |

Appendix A

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = CHILD

PATHWAY = COW-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|---------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 2.87E+01 | 2.87E+01 | 0.00E-01 | 2.87E+01 | 2.87E+01 | 2.87E+01 | 2.87E+01 | 2.87E+01 |
| C 14 | 1.06E+04 | 1.06E+04 | 5.26E+04 | 1.06E+04 | 1.06E+04 | 1.06E+04 | 1.06E+04 | 1.06E+04 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m. | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 2.88E+03 | 1.53E+05 | 0.00E-01 | 0.00E-01 | 4.37E+02 | 1.60E+03 | 2.92E+03 | 0.00E-01 |
| MN 54 | 1.41E+05 | 4.44E+05 | 0.00E-01 | 5.29E+05 | 1.49E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 2.63E+06 | 5.51E+06 | 3.26E+06 | 5.29E+06 | 0.00E-01 | 0.00E-01 | 1.53E+06 | 0.00E-01 |
| CO 58 | 9.79E+05 | 1.87E+06 | 0.00E-01 | 3.20E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 3.20E+06 | 5.99E+06 | 0.00E-01 | 1.08E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.95E+08 | 5.51E+07 | 1.18E+08 | 3.14E+08 | 1.98E+08 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 5.48E+06 | 7.45E+06 | 1.92E+08 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 4.40E+08 | 1.95E+08 | 2.18E+10 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.99E+01 | 2.33E+04 | 1.02E+02 | 2.23E+01 | 3.20E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 1.01E+06 | 1.81E+07 | 2.89E+06 | 3.74E+04 | 0.00E-01 | 6.40E+03 | 1.61E+06 | 0.00E-01 |
| CS134 | 1.97E+08 | 5.04E+06 | 5.70E+08 | 9.38E+08 | 2.90E+08 | 0.00E-01 | 1.04E+08 | 0.00E-01 |
| CS136 | 5.42E+07 | 2.95E+06 | 3.05E+07 | 8.40E+07 | 4.47E+07 | 0.00E-01 | 6.65E+06 | 0.00E-01 |
| CS137 | 1.21E+08 | 5.17E+06 | 8.59E+08 | 8.24E+08 | 2.68E+08 | 0.00E-01 | 9.63E+07 | 0.00E-01 |
| BA140 | 2.07E+05 | 1.80E+06 | 3.55E+06 | 3.11E+03 | 1.01E+03 | 0.00E-01 | 1.85E+03 | 0.00E-01 |
| CE141 | 4.53E+01 | 3.80E+05 | 6.12E+02 | 3.05E+02 | 1.33E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 2.17E+03 | 3.33E+06 | 4.06E+04 | 1.27E+04 | 7.07E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.16E+07 | 1.82E+06 | 2.03E+07 | 2.04E+07 | 3.36E+07 | 6.75E+09 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.28E+05 | 1.36E+05 | 2.73E+05 | 3.36E+05 | 5.61E+05 | 6.27E+07 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = CHILD

PATHWAY = GOAT-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 5.86E+01 | 5.86E+01 | 0.00E-01 | 5.86E+01 | 5.86E+01 | 5.86E+01 | 5.86E+01 | 5.86E+01 |
| C 14 | 1.06E+04 | 1.06E+04 | 5.26E+04 | 1.06E+04 | 1.06E+04 | 1.06E+04 | 1.06E+04 | 1.06E+04 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 3.45E+02 | 1.83E+04 | 0.00E-01 | 0.00E-01 | 5.23E+01 | 1.92E+02 | 3.52E+02 | 0.00E-01 |
| MN 54 | 1.70E+04 | 5.36E+04 | 0.00E-01 | 6.37E+04 | 1.78E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 3.42E+05 | 7.16E+05 | 4.25E+05 | 6.88E+05 | 0.00E-01 | 0.00E-01 | 1.99E+05 | 0.00E-01 |
| CO 58 | 1.18E+05 | 2.24E+05 | 0.00E-01 | 3.83E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 3.83E+05 | 7.19E+05 | 0.00E-01 | 1.30E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 2.34E+07 | 6.62E+06 | 1.41E+07 | 3.77E+07 | 2.37E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.15E+07 | 1.56E+07 | 4.02E+08 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 9.22E+08 | 4.09E+08 | 4.60E+10 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 2.39E+00 | 2.80E+03 | 1.22E+01 | 2.68E+00 | 3.83E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 1.22E+05 | 2.17E+06 | 3.49E+05 | 4.50E+03 | 0.00E-01 | 7.67E+02 | 1.93E+05 | 0.00E-01 |
| CS134 | 5.93E+08 | 1.51E+07 | 1.71E+09 | 2.81E+09 | 8.71E+08 | 0.00E-01 | 3.12E+08 | 0.00E-01 |
| CS136 | 1.63E+08 | 8.84E+06 | 9.16E+07 | 2.52E+08 | 1.34E+08 | 0.00E-01 | 2.00E+07 | 0.00E-01 |
| CS137 | 3.64E+08 | 1.55E+07 | 2.58E+09 | 2.47E+09 | 8.05E+08 | 0.00E-01 | 2.89E+08 | 0.00E-01 |
| BA140 | 2.48E+04 | 2.16E+05 | 4.25E+05 | 3.74E+02 | 1.21E+02 | 0.00E-01 | 2.22E+02 | 0.00E-01 |
| CE141 | 5.42E+00 | 4.56E+04 | 7.32E+01 | 3.64E+01 | 1.60E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 2.60E+02 | 3.99E+05 | 4.88E+03 | 1.53E+03 | 8.46E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.39E+07 | 2.18E+06 | 2.44E+07 | 2.45E+07 | 4.02E+07 | 8.11E+09 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.53E+05 | 1.63E+05 | 3.26E+05 | 4.06E+05 | 6.75E+05 | 7.51E+07 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = CHILD

PATHWAY = ANIMAL-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 4.28E+00 | 4.28E+00 | 0.00E-01 | 4.28E+00 | 4.28E+00 | 4.28E+00 | 4.28E+00 | 4.28E+00 |
| C 14 | 3.39E+03 | 3.39E+03 | 1.69E+04 | 3.39E+03 | 3.39E+03 | 3.39E+03 | 3.39E+03 | 3.39E+03 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 2.48E+02 | 1.32E+04 | 0.00E-01 | 0.00E-01 | 3.77E+01 | 1.38E+02 | 2.52E+02 | 0.00E-01 |
| MN 54 | 5.39E+04 | 1.70E+05 | 0.00E-01 | 2.02E+05 | 5.67E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 8.24E+06 | 1.72E+07 | 1.02E+07 | 1.65E+07 | 0.00E-01 | 0.00E-01 | 4.79E+06 | 0.00E-01 |
| CO 58 | 1.32E+06 | 2.53E+06 | 0.00E-01 | 4.34E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 5.13E+06 | 9.63E+06 | 0.00E-01 | 1.74E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.77E+07 | 5.01E+06 | 1.07E+07 | 2.85E+07 | 1.80E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 3.99E+05 | 5.42E+05 | 1.40E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 4.09E+07 | 1.82E+07 | 2.03E+09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.38E+04 | 1.62E+07 | 7.07E+04 | 1.55E+04 | 2.22E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 2.73E+05 | 4.88E+06 | 7.80E+05 | 1.01E+04 | 0.00E-01 | 1.72E+03 | 4.34E+05 | 0.00E-01 |
| CS134 | 8.05E+06 | 2.06E+05 | 2.33E+07 | 3.80E+07 | 1.18E+07 | 0.00E-01 | 4.25E+06 | 0.00E-01 |
| CS136 | 8.68E+05 | 4.72E+04 | 4.88E+05 | 1.34E+06 | 7.13E+05 | 0.00E-01 | 1.06E+05 | 0.00E-01 |
| CS137 | 5.01E+06 | 2.13E+05 | 3.55E+07 | 3.39E+07 | 1.11E+07 | 0.00E-01 | 3.99E+06 | 0.00E-01 |
| BA140 | 7.76E+04 | 6.72E+05 | 1.33E+06 | 1.16E+03 | 3.80E+02 | 0.00E-01 | 6.94E+02 | 0.00E-01 |
| CE141 | 4.60E+01 | 3.87E+05 | 6.21E+02 | 3.09E+02 | 1.36E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 3.10E+03 | 4.75E+06 | 5.80E+04 | 1.82E+04 | 1.01E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.47E+05 | 2.31E+04 | 2.58E+05 | 2.59E+05 | 4.25E+05 | 8.56E+07 | 0.00E-01 | 0.00E-01 |
| I 133 | 4.25E-03 | 4.53E-03 | 9.10E-03 | 1.12E-02 | 1.88E-02 | 2.09E+00 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = CHILD

PATHWAY = VEGETABLES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 7.32E+01 | 7.32E+01 | 0.00E-01 | 7.32E+01 | 7.32E+01 | 7.32E+01 | 7.32E+01 | 7.32E+01 |
| C 14 | 2.24E+04 | 2.24E+04 | 1.12E+05 | 2.24E+04 | 2.24E+04 | 2.24E+04 | 2.24E+04 | 2.24E+04 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 3.68E+03 | 1.94E+05 | 0.00E-01 | 0.00E-01 | 5.55E+02 | 2.03E+03 | 3.71E+03 | 0.00E-01 |
| MN 54 | 5.51E+06 | 1.74E+07 | 0.00E-01 | 2.07E+07 | 5.80E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 9.95E+06 | 2.08E+07 | 1.23E+07 | 2.00E+07 | 0.00E-01 | 0.00E-01 | 5.80E+06 | 0.00E-01 |
| CO 58 | 6.08E+06 | 1.16E+07 | 0.00E-01 | 1.99E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 3.52E+07 | 6.62E+07 | 0.00E-01 | 1.19E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 5.39E+07 | 1.52E+07 | 3.26E+07 | 8.68E+07 | 5.45E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 3.30E+07 | 4.47E+07 | 1.16E+09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 3.39E+09 | 1.51E+09 | 1.69E+11 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 2.33E+04 | 2.73E+07 | 1.19E+05 | 2.62E+04 | 3.74E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 3.83E+06 | 6.81E+07 | 1.09E+07 | 1.42E+05 | 0.00E-01 | 2.41E+04 | 6.05E+06 | 0.00E-01 |
| CS134 | 1.75E+08 | 4.47E+06 | 5.07E+08 | 8.30E+08 | 2.58E+08 | 0.00E-01 | 9.25E+07 | 0.00E-01 |
| CS136 | 4.63E+06 | 2.50E+05 | 2.59E+06 | 7.13E+06 | 3.80E+06 | 0.00E-01 | 5.67E+05 | 0.00E-01 |
| CS137 | 1.22E+08 | 5.20E+06 | 8.65E+08 | 8.27E+08 | 2.70E+08 | 0.00E-01 | 9.70E+07 | 0.00E-01 |
| BA140 | 5.10E+05 | 4.44E+06 | 8.78E+06 | 7.67E+03 | 2.50E+03 | 0.00E-01 | 4.56E+03 | 0.00E-01 |
| CE141 | 1.52E+03 | 1.27E+07 | 2.05E+04 | 1.02E+04 | 4.47E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 2.06E+05 | 3.16E+08 | 3.87E+06 | 1.21E+06 | 6.69E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.29E+06 | 2.03E+05 | 2.27E+06 | 2.28E+06 | 3.74E+06 | 7.54E+08 | 0.00E-01 | 0.00E-01 |
| I 133 | 2.61E+04 | 2.78E+04 | 5.58E+04 | 6.91E+04 | 1.15E+05 | 1.28E+07 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = CHILD
PATHWAY = PLUME

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ³)/(Ci sec) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|--|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AR 41 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 3.14E+02 |
| KR 83m | 1.68E-03 | 1.68E-03 | 1.68E-03 | 1.68E-03 | 1.68E-03 | 1.68E-03 | 9.38E-02 | 4.75E-01 |
| KR 85m | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.66E+01 | 7.67E+01 |
| KR 85 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 9.51E-01 | 4.28E+01 |
| KR 87 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.35E+02 | 4.60E+02 |
| KR 88 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 4.50E+02 |
| KR 89 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.71E+02 | 7.48E+02 |
| KR 90 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.49E+02 | 6.33E+02 |
| XE131m | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.38E+00 | 1.89E+01 |
| XE133m | 5.58E+00 | 5.58E+00 | 5.58E+00 | 5.58E+00 | 5.58E+00 | 5.58E+00 | 6.02E+00 | 3.96E+01 |
| XE133 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.85E+00 | 1.84E+01 |
| XE135m | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.94E+01 | 1.05E+02 |
| XE135 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.09E+01 | 1.06E+02 |
| XE137 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.55E+01 | 4.25E+02 |
| XE138 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.97E+02 | 3.58E+02 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = INFANT

PATHWAY = INHALATION

| | TOTAL BODY | GI-LI | BONE | LIVER (mrem m ³)/(Ci sec) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|--|----------|----------|----------|----------|
| H 3 | 1.17E+01 | 1.17E+01 | 0.00E-01 | 1.17E+01 | 1.17E+01 | 1.17E+01 | 1.17E+01 | 1.17E+01 |
| C 14 | 1.68E+02 | 1.68E+02 | 8.39E+02 | 1.68E+02 | 1.68E+02 | 1.68E+02 | 1.68E+02 | 0.00E-01 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 2.84E+00 | 1.13E+01 | 0.00E-01 | 0.00E-01 | 4.18E-01 | 1.83E+00 | 4.06E+02 | 0.00E-01 |
| MN 54 | 1.58E+02 | 2.24E+02 | 0.00E-01 | 8.05E+02 | 1.58E+02 | 0.00E-01 | 3.17E+04 | 0.00E-01 |
| FE 59 | 3.00E+02 | 7.86E+02 | 4.31E+02 | 7.45E+02 | 0.00E-01 | 0.00E-01 | 3.23E+04 | 0.00E-01 |
| CO 58 | 5.77E+01 | 3.52E+02 | 0.00E-01 | 3.87E+01 | 0.00E-01 | 0.00E-01 | 2.46E+04 | 0.00E-01 |
| CO 60 | 3.74E+02 | 1.01E+03 | 0.00E-01 | 2.54E+02 | 0.00E-01 | 0.00E-01 | 1.43E+05 | 0.00E-01 |
| ZN 65 | 9.86E+02 | 1.63E+03 | 6.12E+02 | 1.98E+03 | 1.03E+03 | 0.00E-01 | 2.05E+04 | 0.00E-01 |
| SR 89 | 3.61E+02 | 2.03E+03 | 1.26E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 6.43E+04 | 0.00E-01 |
| SR 90 | 9.89E+03 | 4.15E+03 | 4.91E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 3.55E+05 | 0.00E-01 |
| ZR 95 | 6.43E+02 | 6.88E+02 | 3.64E+03 | 8.84E+02 | 9.86E+02 | 0.00E-01 | 5.55E+04 | 0.00E-01 |
| SB124 | 3.80E+02 | 1.87E+03 | 1.20E+03 | 1.76E+01 | 0.00E-01 | 3.20E+00 | 8.40E+04 | 0.00E-01 |
| CS134 | 2.36E+03 | 4.21E+01 | 1.25E+04 | 2.23E+04 | 6.02E+03 | 0.00E-01 | 2.53E+03 | 0.00E-01 |
| CS136 | 1.68E+03 | 4.53E+01 | 1.53E+03 | 4.28E+03 | 1.79E+03 | 0.00E-01 | 3.74E+02 | 0.00E-01 |
| CS137 | 1.44E+03 | 4.21E+01 | 1.74E+04 | 1.94E+04 | 5.45E+03 | 0.00E-01 | 2.26E+03 | 0.00E-01 |
| BA140 | 9.19E+01 | 1.22E+03 | 1.77E+03 | 1.77E+00 | 4.25E-01 | 0.00E-01 | 5.07E+04 | 0.00E-01 |
| CE141 | 6.31E+01 | 6.85E+02 | 8.78E+02 | 5.29E+02 | 1.66E+02 | 0.00E-01 | 1.64E+04 | 0.00E-01 |
| CE144 | 5.58E+03 | 4.69E+03 | 1.01E+05 | 3.83E+04 | 1.70E+04 | 0.00E-01 | 3.12E+05 | 0.00E-01 |
| I 131 | 6.21E+02 | 3.36E+01 | 1.20E+03 | 1.41E+03 | 1.64E+03 | 4.69E+05 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.77E+02 | 6.85E+01 | 4.18E+02 | 6.08E+02 | 7.10E+02 | 1.13E+05 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = INFANT

PATHWAY = GROUND PLANE

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.47E+05 | 1.74E+05 |
| MN 54 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 4.37E+07 | 5.13E+07 |
| FE 59 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 8.65E+06 | 1.01E+07 |
| CO 58 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.20E+07 | 1.41E+07 |
| CO 60 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 6.81E+08 | 8.02E+08 |
| ZN 65 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.36E+07 | 2.72E+07 |
| SR 89 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 6.85E+02 | 7.95E+02 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 7.76E+06 | 9.03E+06 |
| SB124 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 1.90E+07 | 2.19E+07 |
| CS134 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.17E+08 | 2.53E+08 |
| CS136 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 4.75E+06 | 5.39E+06 |
| CS137 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.26E+08 | 3.80E+08 |
| BA140 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 6.50E+05 | 7.45E+05 |
| CE141 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.34E+05 | 4.88E+05 |
| CE144 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.21E+06 | 2.55E+06 |
| I 131 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 2.73E+05 | 3.33E+05 |
| I 133 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 3.90E+04 | 4.72E+04 |

Appendix A

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = INFANT
PATHWAY = COW-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 4.34E+01 | 4.34E+01 | 0.00E-01 | 4.34E+01 | 4.34E+01 | 4.34E+01 | 4.34E+01 | 4.34E+01 |
| C 14 | 2.21E+04 | 2.21E+04 | 1.03E+05 | 2.21E+04 | 2.21E+04 | 2.21E+04 | 2.21E+04 | 2.21E+04 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 4.56E+03 | 1.33E+05 | 0.00E-01 | 0.00E-01 | 6.50E+02 | 2.98E+03 | 5.80E+03 | 0.00E-01 |
| MN 54 | 2.23E+05 | 3.61E+05 | 0.00E-01 | 9.86E+05 | 2.19E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 4.18E+06 | 5.10E+06 | 6.08E+06 | 1.06E+07 | 0.00E-01 | 0.00E-01 | 3.15E+06 | 0.00E-01 |
| CO 58 | 1.60E+06 | 1.59E+06 | 0.00E-01 | 6.40E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 5.23E+06 | 5.26E+06 | 0.00E-01 | 2.21E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 2.50E+08 | 4.60E+08 | 1.58E+08 | 5.42E+08 | 2.63E+08 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.05E+07 | 7.51E+06 | 3.64E+08 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 4.88E+08 | 1.97E+08 | 2.41E+10 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 3.12E+01 | 2.19E+04 | 1.80E+02 | 4.40E+01 | 4.75E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 1.73E+06 | 1.72E+07 | 5.58E+06 | 8.21E+04 | 0.00E-01 | 1.48E+04 | 3.49E+06 | 0.00E-01 |
| CS134 | 1.73E+08 | 4.66E+06 | 9.19E+08 | 1.71E+09 | 4.40E+08 | 0.00E-01 | 1.81E+08 | 0.00E-01 |
| CS136 | 6.56E+07 | 2.66E+06 | 5.96E+07 | 1.75E+08 | 7.00E+07 | 0.00E-01 | 1.43E+07 | 0.00E-01 |
| CS137 | 1.14E+08 | 5.01E+06 | 1.37E+09 | 1.61E+09 | 4.31E+08 | 0.00E-01 | 1.75E+08 | 0.00E-01 |
| BA140 | 3.77E+05 | 1.79E+06 | 7.29E+06 | 7.29E+03 | 1.73E+03 | 0.00E-01 | 4.50E+03 | 0.00E-01 |
| CE141 | 8.68E+01 | 3.80E+05 | 1.21E+03 | 7.38E+02 | 2.28E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 3.26E+03 | 3.33E+06 | 5.83E+04 | 2.38E+04 | 9.63E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 2.20E+07 | 1.78E+06 | 4.25E+07 | 5.01E+07 | 5.83E+07 | 1.64E+10 | 0.00E-01 | 0.00E-01 |
| I 133 | 2.46E+05 | 1.42E+05 | 5.77E+05 | 8.40E+05 | 9.86E+05 | 1.52E+08 | 0.00E-01 | 0.00E-01 |

Appendix A

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = INFANT
PATHWAY = GOAT-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ² /Ci) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 8.87E+01 | 8.87E+01 | 0.00E-01 | 8.87E+01 | 8.87E+01 | 8.87E+01 | 8.87E+01 | 8.87E+01 |
| C 14 | 2.21E+04 | 2.21E+04 | 1.03E+05 | 2.21E+04 | 2.21E+04 | 2.21E+04 | 2.21E+04 | 2.21E+04 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 5.48E+02 | 1.60E+04 | 0.00E-01 | 0.00E-01 | 7.80E+01 | 3.58E+02 | 6.94E+02 | 0.00E-01 |
| MN 54 | 2.68E+04 | 4.34E+04 | 0.00E-01 | 1.19E+05 | 2.62E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 5.45E+05 | 6.62E+05 | 7.92E+05 | 1.38E+06 | 0.00E-01 | 0.00E-01 | 4.09E+05 | 0.00E-01 |
| CO 58 | 1.91E+05 | 1.91E+05 | 0.00E-01 | 7.67E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 6.27E+05 | 6.31E+05 | 0.00E-01 | 2.66E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 3.00E+07 | 5.51E+07 | 1.90E+07 | 6.53E+07 | 3.16E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.20E+07 | 1.58E+07 | 7.67E+08 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.03E+09 | 4.15E+08 | 5.07E+10 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 3.74E+00 | 2.63E+03 | 2.16E+01 | 5.29E+00 | 5.67E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 2.08E+05 | 2.07E+06 | 6.69E+05 | 9.86E+03 | 0.00E-01 | 1.78E+03 | 4.18E+05 | 0.00E-01 |
| CS134 | 5.20E+08 | 1.40E+07 | 2.76E+09 | 5.13E+09 | 1.32E+09 | 0.00E-01 | 5.42E+08 | 0.00E-01 |
| CS136 | 1.96E+08 | 7.99E+06 | 1.79E+08 | 5.26E+08 | 2.10E+08 | 0.00E-01 | 4.28E+07 | 0.00E-01 |
| CS137 | 3.42E+08 | 1.51E+07 | 4.12E+09 | 4.82E+09 | 1.29E+09 | 0.00E-01 | 5.23E+08 | 0.00E-01 |
| BA140 | 4.50E+04 | 2.15E+05 | 8.78E+05 | 8.78E+02 | 2.08E+02 | 0.00E-01 | 5.39E+02 | 0.00E-01 |
| CE141 | 1.04E+01 | 4.56E+04 | 1.45E+02 | 8.87E+01 | 2.73E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 3.93E+02 | 4.02E+05 | 7.00E+03 | 2.86E+03 | 1.16E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 2.63E+07 | 2.14E+06 | 5.07E+07 | 5.99E+07 | 7.00E+07 | 1.97E+10 | 0.00E-01 | 0.00E-01 |
| I 133 | 2.95E+05 | 1.70E+05 | 6.91E+05 | 1.01E+06 | 1.18E+06 | 1.83E+08 | 0.00E-01 | 0.00E-01 |

Appendix A

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = INFANT

PATHWAY = ANIMAL-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = INFANT

PATHWAY = VEGETABLES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ²)/Ci | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AR 41 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 83m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 87 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| KR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE131m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135m | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| XE138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT AIR
Computed by GASPAR II

AGE = INFANT
PATHWAY = PLUME

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem m ³)/(Ci sec) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|--|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AR 41 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 3.14E+02 |
| KR 83m | 1.68E-03 | 1.68E-03 | 1.68E-03 | 1.68E-03 | 1.68E-03 | 1.68E-03 | 9.38E-02 | 4.75E-01 |
| KR 85m | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.60E+01 | 2.66E+01 | 7.67E+01 |
| KR 85 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 3.58E-01 | 9.51E-01 | 4.28E+01 |
| KR 87 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.35E+02 | 4.60E+02 |
| KR 88 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 4.50E+02 |
| KR 89 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.68E+02 | 3.71E+02 | 7.48E+02 |
| KR 90 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.46E+02 | 3.49E+02 | 6.33E+02 |
| XE131m | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.03E+00 | 2.38E+00 | 1.89E+01 |
| XE133m | 5.58E+00 | 5.58E+00 | 5.58E+00 | 5.58E+00 | 5.58E+00 | 5.58E+00 | 6.02E+00 | 3.96E+01 |
| XE133 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.53E+00 | 6.85E+00 | 1.84E+01 |
| XE135m | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.91E+01 | 6.94E+01 | 1.05E+02 |
| XE135 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.02E+01 | 4.09E+01 | 1.06E+02 |
| XE137 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.15E+01 | 3.55E+01 | 4.25E+02 |
| XE138 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.96E+02 | 1.97E+02 | 3.58E+02 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SB124 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

APPENDIX B: TECHNICAL BASES FOR EFFECTIVE DOSE FACTORS

Overview

The evaluation of doses due to releases of radioactive material to the atmosphere can be simplified by the use of effective dose transfer factors instead of using dose factors which are radionuclide specific. These effective factors, which are based on the total radioactivity released to approximate the dose in the environment, i.e., instead of having to sum the isotopic distribution multiplied by the isotope specific dose factor only a single multiplication times the total quantity of radioactive material released would be needed. This approach provides a reasonable estimate of the actual dose while eliminating the need for a detailed calculational technique.

Determination of Effective Dose Factors

The effective dose transfer factors are based on past operating data. The radioactive effluent distribution for the past years can be used to derive single effective factors by the following equations:

$$A\gamma_{s\text{eff}} = \sum_i A\gamma_i \times f_i$$

where

$A\gamma_{s\text{eff}}$ = the effective gamma-air dose factor due to stack releases of noble gases
(mrad/ μCi)

$A\gamma_i$ = the gamma-air dose factor due to stack releases of each noble gas radionuclide i
(mrad/ μCi)

f_i = the fraction of noble gas radioactivity constituted by radionuclide i

$$A\gamma_{v\text{eff}} = \sum_i A\gamma_{vi} \times f_i$$

where

$A\gamma_{v\text{eff}}$ = the effective gamma-air dose factor due to vent releases of all noble gases
 $\left(\frac{\text{mrad}}{\mu\text{Ci sec/ m}^3} \right)$

$A\gamma_{vi}$ = the gamma-air dose factor due to vent releases of each noble gas
radionuclide i $\left(\frac{\text{mrad}}{\mu\text{Ci sec/ m}^3} \right)$

$$A\beta_{v\text{eff}} = \sum_i A\beta_i \times f_i$$

where

$A\beta_{eff}$ = the effective beta-air dose factor due to either vent or stack releases of all noble gases $\left(\frac{mrad}{\mu Ci \text{ sec}/ m^3} \right)$

$A\beta_i$ = the beta air dose factor due to either vent or stack releases of each noble gas radionuclide $i \left(\frac{mrad}{\mu Ci \text{ sec}/ m^3} \right)$

To determine the appropriate effective factors to be used and to evaluate the degree of variability, the atmospheric radioactive effluents for the past 3 years have been evaluated.

Table B-1 presents the radionuclide distribution for stack and vent releases as measured by isotopic analysis of periodic grab samples from the respective effluent release points. Table B-2 presents the effective dose factors (gamma-air and beta-air) derived on the basis of the radionuclide distribution.

Except for the year 1981, the variability of the effective factors is minor. For 1981, Xe-138 contributes significantly to the derivation of the effective factors for stack releases. The Xe-138 contribution for the years 1979 and 1980 is not so significant. This increase in Xe-138 from 1981 results in a larger variability of the yearly values from the average than what is considered typical. Therefore, in order to assure adequate conservatism, the effective dose factors for stack releases will be based on the radionuclide distribution for the year 1981. Because this is considered an atypical distribution resulting in higher doses, use of the data will provide dose estimates which are conservative. As more data become available to further establish a typical radionuclide distribution, the effective dose factors for stack releases may be reevaluated.

To provide an additional degree of conservatism, a factor of 0.8 is introduced into the dose calculational process when the effective dose transfer factor is used. This added conservatism provides additional assurance that the evaluation of doses by the use of a single effective factor will not significantly underestimate any actual doses in the environment.

By evaluating doses using these effective dose factors, maximum allowable releases of noble gases for any calendar quarter may be determined. As discussed in Section 3.6.1, the maximum allowable releases based on the gamma-air effective dose factor have been determined to be 250,000 Ci/quarter for stack releases and 12,700 Ci/quarter for vent releases.

For the beta air effective dose factors, the releases of noble gases corresponding to the quarterly limit of 10 mrads corresponds to 307,000 Ci/quarter for stack releases and 29,600 Ci/quarter for vent releases. Comparing these values for allowable releases with the values based on the gamma-air effective dose factors, it is demonstrated that the gamma-air doses are more restrictive than the beta-air doses. In other words, the doses calculated by using the gamma-air effective dose factors represent a larger fraction of the allowable dose than does the dose calculated by using the beta-air effective dose factors. Therefore, when using the effective dose factors for evaluating compliance with the quarterly dose limits of Section 6.2.3, only the gamma-air dose need be evaluated; compliance with the gamma-air dose limit represents a de facto compliance with the beta-air dose limit.

Reevaluation

The doses due to the gaseous effluents are evaluated by the more detailed calculational methods (i.e., use of nuclide specific dose factors) on a yearly basis. At that time, a comparison can be made between the simplified method and the detailed method to assure the overall reasonableness of this limited analysis approach. If the comparison indicates that the radionuclide distribution has changed significantly, thereby causing the simplified method to underestimate the doses, the value of the effective factors will need to be reexamined to assure the overall acceptability of this approach. However, this reexamination will only be needed if the doses as calculated by the detailed analysis exceed 50% of the design bases doses (i.e., greater than 50% of the 10 mrad gamma air dose or 20 mrad beta air dose).

Appendix B

Table B-1

RADIONUCLIDE DISTRIBUTION OF STACK AND VENT RELEASES

| Radionuclide | Fraction of Total Releases | | | | | |
|--------------|----------------------------|------|------|------|------|------|
| | Stack | | | Vent | | |
| | 1979 | 1980 | 1981 | 1979 | 1980 | 1981 |
| Kr-85m | .11 | .05 | .09 | .02 | --- | --- |
| Kr-87 | .01 | --- | .02 | --- | .01 | --- |
| Kr-88 | .07 | .04 | .08 | --- | --- | --- |
| Xe-133 | .76 | .82 | .45 | .24 | .24 | .14 |
| Xe-135 | .01 | .02 | .03 | .72 | .50 | .59 |
| Xe-135m | --- | .02 | .08 | .02 | .22 | .21 |
| Xe-138 | .02 | .06 | .25 | --- | .03 | .05 |

Table B-2

EFFECTIVE DOSE FACTORS NOBLE GASES - AIR DOSES

| Year | Stack Releases | | Vent Releases | |
|---------|--|---|--|---|
| | Gamma-Air Effective Dose Factor | Beta-Air Effective Dose Factor | Gamma-Air Effective Dose Factor | Beta-Air Effective Dose Factor |
| | $A\gamma_{seff}$ $\left(\frac{mrad}{\mu Ci} \right)$ | $A\beta_{seff}$ $\left(\frac{mrad}{\mu Ci \ sec/m^3} \right)$ | $A\gamma_{veff}$ $\left(\frac{mrad}{\mu Ci \ sec/m^3} \right)$ | $A\beta_{veff}$ $\left(\frac{mrad}{\mu Ci \ sec/m^3} \right)$ |
| 1979 | 7.0×10^{-12} | 5.9×10^{-5} | 5.0×10^{-5} | 6.5×10^{-5} |
| 1980 | 6.7×10^{-12} | 5.3×10^{-5} | 6.7×10^{-5} | 6.0×10^{-5} |
| 1981 | 1.6×10^{-11} | 9.3×10^{-12} | 6.4×10^{-5} | 6.3×10^{-5} |
| Average | 9.9×10^{-12} | 6.8×10^{-5} | 6.4×10^{-5} | 6.3×10^{-5} |

Appendix C

APPENDIX C: DOSE TRANSFER FACTORS FOR WATERBORNE PATHWAYS

Dose transfer factors for waterborne effluent have been derived by solving environmental pathway models on the bases of unit radionuclide release in effluent (1 Ci/yr) discharged in 1 gallon/minute of water. The dose transfer factors in this appendix were computed with the LADTAP II computer program, using default values of parameters applicable to the most exposed members of the public as recommended in Regulatory 1.109, revision 1, with the following exceptions:

- In order to account for significant revisions of data since publication of the Regulatory Guide, data differing from those in Regulatory Guide 1.109, revision 1 are identified in LADTAP II documentation.¹⁴
- After publishing Reg. Guide 1.109, the NRC recommended that soil-to-plant bioaccumulation factors, B_{IV} , of cesium and strontium be changed.¹⁵
- The revised values were used to derive dose transfer factors tabulated for Sr89, Sr90, and Cs137 in irrigated vegetation.
- Values of environmental transit time recommended in Reg. Guide 1.109¹⁶, namely 1440 hr from harvest of stored vegetables to ingestion, were retained.
- LADTAP II divergence from Reg. Guide 1.109 is reflected in tritium dose transfer factors that are typically 43% lower than those described in the Reg. Guide.

Dose transfer factors are included hereafter for the following parameters. Only those pathways applicable at the time of a radioactive liquid effluent release will be used for dose calculations. Likely pathways would include potable water, freshwater fish and irrigated fresh leafy vegetables (including strawberries).

¹⁴ Strenge, D.L., et. al., LADTAP II - Technical Reference and User guide, NUREG/CR-4013, April 1986.

¹⁵ NRC, SECY-79-653A, January 30, 1980.

¹⁶ Regulatory Guide 1.109, rev. 1, Table E-15.

Appendix C

| Pathway | Age Group | Organ |
|---|-----------|------------|
| Potable water | Adult | Total Body |
| Freshwater fish | Teenager | GI tract |
| Freshwater invertebrates | Child | Bone |
| Irrigated fresh leafy vegetables | Infant | Liver |
| Irrigated stored vegetables, fruit, and grain | | Kidney |
| Irrigated grass-cow-milk | | Thyroid |
| Irrigated grass-cow-meat | | Lung |
| Irrigated stored forage-cow-milk | | Skin |
| Irrigated stored forage-cow-meat | | |
| Animal drinks river water-milk | | |
| Animal drinks river water-meat | | |
| River shoreline deposits-irradiation | | |
| Swimming | | |
| Boating | | |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT
PATHWAY = POTABLE WATER

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 2.19E+01 | 2.19E+01 | 0.00E-01 | 2.19E+01 | 2.19E+01 | 2.19E+01 | 2.19E+01 | 0.00E-01 |
| C 14 | 2.08E+02 | 2.08E+02 | 1.04E+03 | 2.08E+02 | 2.08E+02 | 2.08E+02 | 2.08E+02 | 0.00E-01 |
| NA 24 | 2.06E+02 | 2.06E+02 | 2.06E+02 | 2.06E+02 | 2.06E+02 | 2.06E+02 | 2.06E+02 | 0.00E-01 |
| P 32 | 2.60E+03 | 7.57E+03 | 6.73E+04 | 4.19E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 9.50E-01 | 2.39E+02 | 0.00E-01 | 0.00E-01 | 2.09E-01 | 5.68E-01 | 1.26E+00 | 0.00E-01 |
| MN 54 | 3.19E+02 | 5.12E+03 | 0.00E-01 | 1.67E+03 | 4.97E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 1.15E-02 | 2.06E+00 | 0.00E-01 | 6.46E-02 | 8.20E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 1.62E+02 | 3.99E+02 | 1.01E+03 | 6.95E+02 | 0.00E-01 | 0.00E-01 | 3.88E+02 | 0.00E-01 |
| FE 59 | 1.41E+03 | 1.23E+04 | 1.56E+03 | 3.68E+03 | 0.00E-01 | 0.00E-01 | 1.03E+03 | 0.00E-01 |
| CO 58 | 6.06E+02 | 5.48E+03 | 0.00E-01 | 2.70E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.73E+03 | 1.47E+04 | 0.00E-01 | 7.84E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.60E+03 | 6.89E+02 | 4.76E+04 | 3.30E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.56E-02 | 8.66E-01 | 2.63E-01 | 3.42E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 3.85E+00 | 6.99E+02 | 0.00E-01 | 8.21E+00 | 2.07E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 2.54E+03 | 3.54E+03 | 1.77E+03 | 5.62E+03 | 3.76E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 1.21E-08 | 2.62E-08 | 9.11E-08 | 1.74E-07 | 1.13E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.40E-02 | 2.02E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 3.47E+03 | 1.47E+03 | 0.00E-01 | 7.45E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 3.19E+03 | 1.78E+04 | 1.11E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 6.41E+04 | 8.02E+04 | 3.19E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.45E+01 | 1.71E+03 | 3.59E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 7.38E-02 | 3.38E+01 | 1.71E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 7.29E-02 | 2.88E+04 | 2.72E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 1.37E+00 | 2.81E+04 | 5.10E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 8.37E-05 | 5.02E+01 | 2.86E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 5.20E-03 | 5.98E+03 | 1.89E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 2.39E+00 | 1.12E+04 | 1.10E+01 | 3.53E+00 | 5.54E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 2.12E-02 | 1.44E+04 | 2.30E-01 | 4.64E-02 | 7.00E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 6.68E-01 | 7.54E+03 | 2.23E+00 | 1.24E+00 | 1.23E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 2.33E+02 | 2.84E+03 | 0.00E-01 | 1.23E+03 | 2.78E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 2.05E-01 | 9.53E+00 | 5.70E-03 | 1.61E-02 | 2.45E-01 | 0.00E-01 | 7.89E-03 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = POTABLE WATER

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 2.87E+01 | 7.77E+03 | 6.66E+01 | 0.00E-01 | 2.54E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 5.24E-02 | 8.12E+01 | 1.33E-01 | 0.00E-01 | 1.72E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 1.27E+02 | 6.51E+04 | 1.00E+03 | 0.00E-01 | 1.94E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 3.21E+01 | 2.21E+04 | 5.85E+01 | 5.41E+01 | 1.06E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 1.30E+02 | 3.87E+03 | 9.70E+02 | 3.51E+02 | 3.94E+03 | 2.92E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 3.00E+02 | 8.26E+03 | 2.46E+03 | 8.81E+02 | 1.00E+04 | 6.30E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.47E+00 | 5.36E+02 | 6.80E+00 | 2.44E+00 | 2.77E+01 | 5.03E+00 | 0.00E-01 | 0.00E-01 |
| TE129M | 6.53E+02 | 2.08E+04 | 4.13E+03 | 1.54E+03 | 1.72E+04 | 1.42E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 1.66E-06 | 5.13E-06 | 6.79E-06 | 2.55E-06 | 2.85E-05 | 5.21E-06 | 0.00E-01 | 0.00E-01 |
| TE131M | 1.48E+02 | 1.77E+04 | 3.64E+02 | 1.78E+02 | 1.80E+03 | 2.82E+02 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 4.53E+02 | 2.28E+04 | 7.46E+02 | 4.83E+02 | 4.65E+03 | 5.33E+02 | 0.00E-01 | 0.00E-01 |
| I 130 | 8.37E+01 | 1.83E+02 | 7.19E+01 | 2.12E+02 | 3.31E+02 | 1.80E+04 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.15E+03 | 5.28E+02 | 1.40E+03 | 2.00E+03 | 3.43E+03 | 6.55E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 5.03E-02 | 2.70E-02 | 5.38E-02 | 1.44E-01 | 2.29E-01 | 5.03E+00 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.24E+02 | 3.66E+02 | 2.34E+02 | 4.07E+02 | 7.10E+02 | 5.98E+04 | 0.00E-01 | 0.00E-01 |
| I 134 | 2.10E-07 | 5.11E-10 | 2.16E-07 | 5.86E-07 | 9.32E-07 | 1.02E-05 | 0.00E-01 | 0.00E-01 |
| I 135 | 1.26E+01 | 3.85E+01 | 1.30E+01 | 3.41E+01 | 5.47E+01 | 2.25E+03 | 0.00E-01 | 0.00E-01 |
| CS134 | 4.43E+04 | 9.48E+02 | 2.28E+04 | 5.42E+04 | 1.75E+04 | 0.00E-01 | 5.82E+03 | 0.00E-01 |
| CS136 | 6.43E+03 | 1.01E+03 | 2.26E+03 | 8.93E+03 | 4.97E+03 | 0.00E-01 | 6.81E+02 | 0.00E-01 |
| CS137 | 2.61E+04 | 7.73E+02 | 2.92E+04 | 3.99E+04 | 1.35E+04 | 0.00E-01 | 4.50E+03 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 5.81E-06 | 3.52E-04 | 1.98E-04 | 1.41E-07 | 1.32E-07 | 0.00E-01 | 8.02E-08 | 0.00E-01 |
| BA140 | 4.61E+02 | 1.45E+04 | 7.04E+03 | 8.85E+00 | 3.01E+00 | 0.00E-01 | 5.07E+00 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 8.07E-02 | 2.24E+04 | 6.06E-01 | 3.05E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 1.08E-07 | 3.18E-03 | 9.57E-07 | 4.35E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 2.57E-01 | 8.68E+03 | 3.36E+00 | 2.27E+00 | 1.05E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 2.99E-02 | 1.01E+04 | 3.66E-01 | 2.70E+02 | 1.19E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 9.57E+00 | 6.03E+04 | 1.78E+02 | 7.46E+01 | 4.42E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.59E-01 | 1.40E+04 | 3.20E+00 | 1.28E+00 | 7.42E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.50E-01 | 1.20E+04 | 2.16E+00 | 2.50E+00 | 1.46E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 5.50E+00 | 5.15E+03 | 1.88E+01 | 1.57E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 1.76E-02 | 6.55E+03 | 3.25E-01 | 3.20E-02 | 9.97E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = FRESH WATER FISH

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 5.68E-01 | 5.68E-01 | 0.00E-01 | 5.68E-01 | 5.68E-01 | 5.68E-01 | 5.68E-01 | 0.00E-01 |
| C 14 | 2.75E+04 | 2.75E+04 | 1.38E+05 | 2.75E+04 | 2.75E+04 | 2.75E+04 | 2.75E+04 | 0.00E-01 |
| NA 24 | 5.90E+02 | 5.90E+02 | 5.90E+02 | 5.90E+02 | 5.90E+02 | 5.90E+02 | 5.90E+02 | 0.00E-01 |
| P 32 | 7.49E+06 | 2.18E+07 | 1.94E+08 | 1.20E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 5.47E+00 | 1.37E+03 | 0.00E-01 | 0.00E-01 | 1.20E+00 | 3.27E+00 | 7.26E+00 | 0.00E-01 |
| MN 54 | 3.67E+03 | 5.89E+04 | 0.00E-01 | 1.92E+04 | 5.72E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 1.28E-01 | 2.31E+01 | 0.00E-01 | 7.24E-01 | 9.19E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 4.66E+02 | 1.15E+03 | 2.90E+03 | 2.00E+03 | 0.00E-01 | 0.00E-01 | 1.12E+03 | 0.00E-01 |
| FE 59 | 4.06E+03 | 3.53E+04 | 4.50E+03 | 1.06E+04 | 0.00E-01 | 0.00E-01 | 2.96E+03 | 0.00E-01 |
| CO 58 | 8.71E+02 | 7.88E+03 | 0.00E-01 | 3.89E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 2.49E+03 | 2.12E+04 | 0.00E-01 | 1.13E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 4.59E+03 | 1.98E+03 | 1.37E+05 | 9.49E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 4.36E-02 | 2.42E+00 | 7.36E-01 | 9.56E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 5.51E+00 | 1.00E+03 | 0.00E-01 | 1.17E+01 | 2.96E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.46E+05 | 2.04E+05 | 1.02E+05 | 3.24E+05 | 2.16E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 6.48E-07 | 1.40E-06 | 4.87E-06 | 9.32E-06 | 6.05E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.65E-01 | 2.37E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.00E+05 | 8.45E+04 | 0.00E-01 | 4.28E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.76E+03 | 1.54E+04 | 9.60E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 5.53E+04 | 6.92E+04 | 2.75E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.24E+01 | 1.47E+03 | 3.08E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 6.21E-02 | 2.85E+01 | 1.44E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 5.24E-02 | 2.07E+04 | 1.95E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 9.81E-01 | 2.02E+04 | 3.67E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 5.90E-05 | 3.54E+01 | 2.02E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 3.72E-03 | 4.27E+03 | 1.35E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 2.27E-01 | 1.06E+03 | 1.05E+00 | 3.35E-01 | 5.26E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 2.00E-03 | 1.36E+03 | 2.17E-02 | 4.38E-03 | 6.62E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 5.76E+02 | 6.51E+06 | 1.93E+03 | 1.07E+03 | 1.06E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 6.71E+01 | 8.17E+02 | 0.00E-01 | 3.52E+02 | 7.98E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 8.75E-02 | 4.07E+00 | 2.43E-03 | 6.87E-03 | 1.04E-01 | 0.00E-01 | 3.37E-03 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = FRESH WATER FISH

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 8.25E+00 | 2.24E+03 | 1.91E+01 | 0.00E-01 | 7.31E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.48E-02 | 2.30E+01 | 3.76E-02 | 0.00E-01 | 4.86E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 3.66E+01 | 1.87E+04 | 2.89E+02 | 0.00E-01 | 5.58E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 2.12E+00 | 1.46E+03 | 3.87E+00 | 3.58E+00 | 7.03E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 1.49E+03 | 4.46E+04 | 1.12E+04 | 4.04E+03 | 4.54E+04 | 3.36E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 3.45E+03 | 9.51E+04 | 2.83E+04 | 1.01E+04 | 1.15E+05 | 7.25E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.68E+01 | 6.12E+03 | 7.76E+01 | 2.79E+01 | 3.16E+02 | 5.75E+01 | 0.00E-01 | 0.00E-01 |
| TE129M | 7.51E+03 | 2.39E+05 | 4.75E+04 | 1.77E+04 | 1.98E+05 | 1.63E+04 | 0.00E-01 | 0.00E-01 |
| TE129 | 1.79E-05 | 5.56E-05 | 7.36E-05 | 2.77E-05 | 3.09E-04 | 5.65E-05 | 0.00E-01 | 0.00E-01 |
| TE131M | 1.70E+03 | 2.03E+05 | 4.18E+03 | 2.04E+03 | 2.07E+04 | 3.24E+03 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 5.21E+03 | 2.62E+05 | 8.58E+03 | 5.55E+03 | 5.35E+04 | 6.13E+03 | 0.00E-01 | 0.00E-01 |
| I 130 | 3.59E+01 | 7.84E+01 | 3.09E+01 | 9.11E+01 | 1.42E+02 | 7.72E+03 | 0.00E-01 | 0.00E-01 |
| I 131 | 4.94E+02 | 2.28E+02 | 6.03E+02 | 8.62E+02 | 1.48E+03 | 2.83E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 2.11E-02 | 1.13E-02 | 2.25E-02 | 6.02E-02 | 9.60E-02 | 2.11E+00 | 0.00E-01 | 0.00E-01 |
| I 133 | 5.33E+01 | 1.57E+02 | 1.01E+02 | 1.75E+02 | 3.05E+02 | 2.57E+04 | 0.00E-01 | 0.00E-01 |
| I 134 | 8.36E-08 | 2.04E-10 | 8.60E-08 | 2.34E-07 | 3.72E-07 | 4.05E-06 | 0.00E-01 | 0.00E-01 |
| I 135 | 5.37E+00 | 1.64E+01 | 5.56E+00 | 1.46E+01 | 2.33E+01 | 9.60E+02 | 0.00E-01 | 0.00E-01 |
| CS134 | 2.55E+06 | 5.45E+04 | 1.31E+06 | 3.12E+06 | 1.01E+06 | 0.00E-01 | 3.35E+05 | 0.00E-01 |
| CS136 | 3.70E+05 | 5.84E+04 | 1.30E+05 | 5.14E+05 | 2.86E+05 | 0.00E-01 | 3.92E+04 | 0.00E-01 |
| CS137 | 1.50E+06 | 4.45E+04 | 1.68E+06 | 2.30E+06 | 7.80E+05 | 0.00E-01 | 2.59E+05 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 6.35E-07 | 3.85E-05 | 2.17E-05 | 1.55E-08 | 1.45E-08 | 0.00E-01 | 8.77E-09 | 0.00E-01 |
| BA140 | 5.31E+01 | 1.67E+03 | 8.10E+02 | 1.02E+00 | 3.46E-01 | 0.00E-01 | 5.83E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 5.80E-02 | 1.61E+04 | 4.35E-01 | 2.19E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 7.45E-08 | 2.18E-03 | 6.58E-07 | 2.99E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 7.41E-03 | 2.50E+02 | 9.65E-02 | 6.53E-02 | 3.03E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 8.59E-04 | 2.90E+02 | 1.05E-02 | 7.77E+00 | 3.42E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 2.75E-01 | 1.73E+03 | 5.13E+00 | 2.14E+00 | 1.27E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.14E-01 | 1.01E+04 | 2.30E+00 | 9.24E-01 | 5.33E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.08E-01 | 8.63E+03 | 1.56E+00 | 1.80E+00 | 1.05E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 1.89E+02 | 1.77E+05 | 6.48E+02 | 5.41E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 5.06E-03 | 1.88E+03 | 9.34E-02 | 9.18E-03 | 2.86E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = FRESH WATER INVERTEBRATES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.35E-01 | 1.35E-01 | 0.00E-01 | 1.35E-01 | 1.35E-01 | 1.35E-01 | 1.35E-01 | 0.00E-01 |
| C 14 | 1.30E+04 | 1.30E+04 | 6.48E+04 | 1.30E+04 | 1.30E+04 | 1.30E+04 | 1.30E+04 | 0.00E-01 |
| NA 24 | 2.81E+02 | 2.81E+02 | 2.81E+02 | 2.81E+02 | 2.81E+02 | 2.81E+02 | 2.81E+02 | 0.00E-01 |
| P 32 | 3.57E+05 | 1.04E+06 | 9.22E+06 | 5.73E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.30E+01 | 3.27E+03 | 0.00E-01 | 0.00E-01 | 2.87E+00 | 7.78E+00 | 1.73E+01 | 0.00E-01 |
| MN 54 | 1.96E+05 | 3.15E+06 | 0.00E-01 | 1.03E+06 | 3.06E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 6.88E+00 | 1.24E+03 | 0.00E-01 | 3.88E+01 | 4.92E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 3.55E+03 | 8.74E+03 | 2.21E+04 | 1.52E+04 | 0.00E-01 | 0.00E-01 | 8.50E+03 | 0.00E-01 |
| FE 59 | 3.09E+04 | 2.69E+05 | 3.43E+04 | 8.06E+04 | 0.00E-01 | 0.00E-01 | 2.25E+04 | 0.00E-01 |
| CO 58 | 8.30E+02 | 7.50E+03 | 0.00E-01 | 3.70E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 2.37E+03 | 2.02E+04 | 0.00E-01 | 1.07E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.09E+03 | 4.72E+02 | 3.26E+04 | 2.26E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.04E-02 | 5.77E-01 | 1.75E-01 | 2.28E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 1.05E+01 | 1.91E+03 | 0.00E-01 | 2.24E+01 | 5.64E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.74E+05 | 2.43E+05 | 1.21E+05 | 3.85E+05 | 2.58E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 7.71E-07 | 1.67E-06 | 5.80E-06 | 1.11E-05 | 7.21E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 3.08E-02 | 4.44E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.38E+04 | 1.01E+04 | 0.00E-01 | 5.10E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.19E+03 | 1.22E+04 | 7.62E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 4.39E+04 | 5.49E+04 | 2.18E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 9.87E+00 | 1.16E+03 | 2.44E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 4.93E-02 | 2.26E+01 | 1.14E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 4.99E-01 | 1.97E+05 | 1.86E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 9.35E+00 | 1.92E+05 | 3.50E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 5.62E-04 | 3.37E+02 | 1.92E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 3.54E-02 | 4.07E+04 | 1.28E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.10E-01 | 5.14E+02 | 5.06E-01 | 1.62E-01 | 2.54E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 9.69E-04 | 6.56E+02 | 1.05E-02 | 2.12E-03 | 3.20E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 4.58E-01 | 5.17E+03 | 1.53E+00 | 8.51E-01 | 8.41E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 1.60E+01 | 1.95E+02 | 0.00E-01 | 8.39E+01 | 1.90E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 6.94E-03 | 3.23E-01 | 1.93E-04 | 5.45E-04 | 8.28E-03 | 0.00E-01 | 2.67E-04 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = FRESH WATER INVERTEBRATES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 5.89E+01 | 1.60E+04 | 1.37E+02 | 0.00E-01 | 5.22E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.06E-01 | 1.64E+02 | 2.68E-01 | 0.00E-01 | 3.47E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 2.61E+02 | 1.34E+05 | 2.07E+03 | 0.00E-01 | 3.99E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 1.69E+02 | 1.16E+05 | 3.08E+02 | 2.85E+02 | 5.61E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 5.43E+03 | 1.62E+05 | 4.05E+04 | 1.47E+04 | 1.65E+05 | 1.22E+04 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.25E+04 | 3.45E+05 | 1.03E+05 | 3.68E+04 | 4.18E+05 | 2.63E+04 | 0.00E-01 | 0.00E-01 |
| TE127 | 6.10E+01 | 2.22E+04 | 2.82E+02 | 1.01E+02 | 1.15E+03 | 2.09E+02 | 0.00E-01 | 0.00E-01 |
| TE129M | 2.73E+04 | 8.68E+05 | 1.72E+05 | 6.43E+04 | 7.19E+05 | 5.92E+04 | 0.00E-01 | 0.00E-01 |
| TE129 | 6.51E-05 | 2.02E-04 | 2.67E-04 | 1.00E-04 | 1.12E-03 | 2.05E-04 | 0.00E-01 | 0.00E-01 |
| TE131M | 6.18E+03 | 7.37E+05 | 1.52E+04 | 7.42E+03 | 7.51E+04 | 1.17E+04 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 1.89E+04 | 9.53E+05 | 3.12E+04 | 2.01E+04 | 1.94E+05 | 2.22E+04 | 0.00E-01 | 0.00E-01 |
| I 130 | 2.85E+00 | 6.22E+00 | 2.45E+00 | 7.23E+00 | 1.13E+01 | 6.12E+02 | 0.00E-01 | 0.00E-01 |
| I 131 | 3.92E+01 | 1.81E+01 | 4.79E+01 | 6.84E+01 | 1.17E+02 | 2.24E+04 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.67E-03 | 8.98E-04 | 1.79E-03 | 4.78E-03 | 7.62E-03 | 1.67E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 4.23E+00 | 1.25E+01 | 7.98E+00 | 1.39E+01 | 2.42E+01 | 2.04E+03 | 0.00E-01 | 0.00E-01 |
| I 134 | 6.64E-09 | 1.62E-11 | 6.83E-09 | 1.86E-08 | 2.95E-08 | 3.21E-07 | 0.00E-01 | 0.00E-01 |
| I 135 | 4.26E-01 | 1.30E+00 | 4.41E-01 | 1.15E+00 | 1.85E+00 | 7.62E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 3.03E+05 | 6.49E+03 | 1.56E+05 | 3.71E+05 | 1.20E+05 | 0.00E-01 | 3.99E+04 | 0.00E-01 |
| CS136 | 4.40E+04 | 6.95E+03 | 1.55E+04 | 6.11E+04 | 3.40E+04 | 0.00E-01 | 4.66E+03 | 0.00E-01 |
| CS137 | 1.79E+05 | 5.29E+03 | 2.00E+05 | 2.73E+05 | 9.28E+04 | 0.00E-01 | 3.09E+04 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 7.56E-06 | 4.58E-04 | 2.58E-04 | 1.84E-07 | 1.72E-07 | 0.00E-01 | 1.04E-07 | 0.00E-01 |
| BA140 | 6.32E+02 | 1.99E+04 | 9.65E+03 | 1.21E+01 | 4.12E+00 | 0.00E-01 | 6.94E+00 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 5.52E-01 | 1.53E+05 | 4.14E+00 | 2.09E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 7.10E-07 | 2.08E-02 | 6.26E-06 | 2.85E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 1.76E+00 | 5.94E+04 | 2.30E+01 | 1.56E+01 | 7.22E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 2.05E-01 | 6.91E+04 | 2.50E+00 | 1.85E+03 | 8.14E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 6.56E+01 | 4.13E+05 | 1.22E+03 | 5.11E+02 | 3.03E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.09E+00 | 9.61E+04 | 2.19E+01 | 8.80E+00 | 5.08E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.02E+00 | 8.22E+04 | 1.48E+01 | 1.71E+01 | 1.00E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 3.76E-01 | 3.52E+02 | 1.28E+00 | 1.07E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 4.82E-02 | 1.79E+04 | 8.89E-01 | 8.74E-02 | 2.73E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = IRRIGATED FRESH LEAFY VEGETABLES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.92E+00 | 1.92E+00 | 0.00E-01 | 1.92E+00 | 1.92E+00 | 1.92E+00 | 1.92E+00 | 0.00E-01 |
| C 14 | 2.03E+03 | 2.03E+03 | 1.01E+04 | 2.03E+03 | 2.03E+03 | 2.03E+03 | 2.03E+03 | 0.00E-01 |
| NA 24 | 6.22E+00 | 6.22E+00 | 6.22E+00 | 6.22E+00 | 6.22E+00 | 6.22E+00 | 6.22E+00 | 0.00E-01 |
| P 32 | 9.84E+02 | 2.86E+03 | 2.54E+04 | 1.58E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 4.60E-01 | 1.16E+02 | 0.00E-01 | 0.00E-01 | 1.01E-01 | 2.75E-01 | 6.10E-01 | 0.00E-01 |
| MN 54 | 2.16E+02 | 3.47E+03 | 0.00E-01 | 1.13E+03 | 3.37E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 4.90E-05 | 8.81E-03 | 0.00E-01 | 2.76E-04 | 3.50E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 1.12E+02 | 2.76E+02 | 6.97E+02 | 4.81E+02 | 0.00E-01 | 0.00E-01 | 2.68E+02 | 0.00E-01 |
| FE 59 | 7.75E+02 | 6.74E+03 | 8.61E+02 | 2.02E+03 | 0.00E-01 | 0.00E-01 | 5.65E+02 | 0.00E-01 |
| CO 58 | 3.63E+02 | 3.28E+03 | 0.00E-01 | 1.62E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.21E+03 | 1.03E+04 | 0.00E-01 | 5.50E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.16E+03 | 5.02E+02 | 3.47E+04 | 2.41E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 6.50E-05 | 3.62E-03 | 1.10E-03 | 1.42E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 9.79E-02 | 1.78E+01 | 0.00E-01 | 2.08E-01 | 5.26E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.80E+03 | 2.51E+03 | 1.25E+03 | 3.99E+03 | 2.67E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 1.22E-11 | 2.63E-11 | 9.14E-11 | 1.75E-10 | 1.14E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 5.52E-05 | 7.94E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 1.45E-16 | 1.14E-21 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 3.62E-37 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 1.46E+03 | 6.17E+02 | 0.00E-01 | 3.13E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 3.95E-28 | 1.03E-38 | 0.00E-01 | 7.45E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 3.31E-30 | 2.73E-43 | 0.00E-01 | 4.71E-30 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.82E+03 | 1.01E+04 | 6.33E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 6.25E+04 | 7.82E+04 | 3.11E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 2.74E-01 | 3.23E+01 | 6.78E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 3.38E-04 | 1.55E-01 | 7.82E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 8.54E-03 | 3.37E+03 | 3.18E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 1.82E-15 | 1.38E-13 | 4.71E-14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 7.92E-01 | 1.63E+04 | 2.96E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 5.32E-07 | 3.19E-01 | 1.82E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 1.04E-04 | 1.20E+02 | 3.78E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.41E+00 | 6.60E+03 | 6.49E+00 | 2.08E+00 | 3.27E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 7.19E-04 | 4.87E+02 | 7.79E-03 | 1.57E-03 | 2.37E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 3.47E-01 | 3.92E+03 | 1.16E+00 | 6.45E-01 | 6.38E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 2.80E+01 | 3.41E+02 | 0.00E-01 | 1.47E+02 | 3.33E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 2.38E-03 | 1.11E-01 | 6.61E-05 | 1.87E-04 | 2.83E-03 | 0.00E-01 | 9.15E-05 | 0.00E-01 |
| TC101 | 3.20E-31 | 9.81E-44 | 2.26E-32 | 3.26E-32 | 5.87E-31 | 0.00E-01 | 1.67E-32 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = IRRIGATED FRESH LEAFY VEGETABLES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.54E+01 | 4.16E+03 | 3.56E+01 | 0.00E-01 | 1.36E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 4.31E-04 | 6.68E-01 | 1.09E-03 | 0.00E-01 | 1.41E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 8.73E+01 | 4.47E+04 | 6.90E+02 | 0.00E-01 | 1.33E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 2.20E+01 | 1.51E+04 | 4.00E+01 | 3.70E+01 | 7.28E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 7.96E+01 | 2.37E+03 | 5.94E+02 | 2.15E+02 | 2.42E+03 | 1.79E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 2.08E+02 | 5.72E+03 | 1.71E+03 | 6.10E+02 | 6.93E+03 | 4.36E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 2.76E-02 | 1.01E+01 | 1.27E-01 | 4.57E-02 | 5.19E-01 | 9.44E-02 | 0.00E-01 | 0.00E-01 |
| TE129M | 3.47E+02 | 1.10E+04 | 2.19E+03 | 8.18E+02 | 9.15E+03 | 7.53E+02 | 0.00E-01 | 0.00E-01 |
| TE129 | 2.33E-09 | 7.23E-09 | 9.59E-09 | 3.60E-09 | 4.03E-08 | 7.36E-09 | 0.00E-01 | 0.00E-01 |
| TE131M | 8.86E+00 | 1.06E+03 | 2.17E+01 | 1.06E+01 | 1.08E+02 | 1.69E+01 | 0.00E-01 | 0.00E-01 |
| TE131 | 2.02E-21 | 9.06E-22 | 6.40E-21 | 2.67E-21 | 2.80E-20 | 5.26E-21 | 0.00E-01 | 0.00E-01 |
| TE132 | 6.34E+01 | 3.20E+03 | 1.04E+02 | 6.76E+01 | 6.51E+02 | 7.46E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 2.07E+00 | 4.52E+00 | 1.78E+00 | 5.25E+00 | 8.19E+00 | 4.45E+02 | 0.00E-01 | 0.00E-01 |
| I 131 | 3.07E+02 | 1.41E+02 | 3.75E+02 | 5.36E+02 | 9.19E+02 | 1.76E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.87E-04 | 1.00E-04 | 2.00E-04 | 5.34E-04 | 8.51E-04 | 1.87E-02 | 0.00E-01 | 0.00E-01 |
| I 133 | 5.16E+00 | 1.52E+01 | 9.74E+00 | 1.69E+01 | 2.96E+01 | 2.49E+03 | 0.00E-01 | 0.00E-01 |
| I 134 | 1.82E-10 | 4.44E-13 | 1.87E-10 | 5.09E-10 | 8.10E-10 | 8.82E-09 | 0.00E-01 | 0.00E-01 |
| I 135 | 1.61E-01 | 4.92E-01 | 1.67E-01 | 4.36E-01 | 6.99E-01 | 2.87E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 3.07E+04 | 6.56E+02 | 1.58E+04 | 3.75E+04 | 1.21E+04 | 0.00E-01 | 4.03E+03 | 0.00E-01 |
| CS136 | 2.28E+03 | 3.60E+02 | 8.04E+02 | 3.17E+03 | 1.76E+03 | 0.00E-01 | 2.42E+02 | 0.00E-01 |
| CS137 | 1.86E+04 | 5.51E+02 | 2.08E+04 | 2.85E+04 | 9.67E+03 | 0.00E-01 | 3.21E+03 | 0.00E-01 |
| CS138 | 2.37E-16 | 2.04E-21 | 2.42E-16 | 4.78E-16 | 3.52E-16 | 0.00E-01 | 3.47E-17 | 0.00E-01 |
| BA139 | 1.05E-08 | 6.39E-07 | 3.60E-07 | 2.57E-10 | 2.40E-10 | 0.00E-01 | 1.46E-10 | 0.00E-01 |
| BA140 | 1.62E+02 | 5.09E+03 | 2.47E+03 | 3.11E+00 | 1.06E+00 | 0.00E-01 | 1.78E+00 | 0.00E-01 |
| BA141 | 7.72E-29 | 1.08E-36 | 2.29E-27 | 1.73E-30 | 1.61E-30 | 0.00E-01 | 9.81E-31 | 0.00E-01 |
| BA142 | 3.45E-32 | 0.00E-01 | 5.48E-31 | 5.63E-34 | 4.76E-34 | 0.00E-01 | 3.19E-34 | 0.00E-01 |
| LA140 | 6.27E-03 | 1.74E+03 | 4.70E-02 | 2.37E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 2.33E-10 | 6.82E-06 | 2.05E-09 | 9.34E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 1.31E-01 | 4.41E+03 | 1.71E+00 | 1.15E+00 | 5.35E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 1.94E-03 | 6.56E+02 | 2.37E-02 | 1.75E+01 | 7.72E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 6.44E+00 | 4.05E+04 | 1.20E+02 | 5.01E+01 | 2.97E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 5.75E-02 | 5.08E+03 | 1.16E+00 | 4.65E-01 | 2.68E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 2.51E-33 | 7.11E-39 | 4.94E-32 | 2.05E-32 | 1.16E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 4.87E-02 | 3.90E+03 | 7.03E-01 | 8.13E-01 | 4.75E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 2.62E-01 | 2.45E+02 | 8.97E-01 | 7.49E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 1.85E-03 | 6.89E+02 | 3.42E-02 | 3.36E-03 | 1.05E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = IRRIGATED STORED FRUIT, VEGETABLES, GRAIN

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.55E+01 | 1.55E+01 | 0.00E-01 | 1.55E+01 | 1.55E+01 | 1.55E+01 | 1.55E+01 | 0.00E-01 |
| C 14 | 1.65E+04 | 1.65E+04 | 8.23E+04 | 1.65E+04 | 1.65E+04 | 1.65E+04 | 1.65E+04 | 0.00E-01 |
| NA 24 | 1.34E-24 | 1.34E-24 | 1.34E-24 | 1.34E-24 | 1.34E-24 | 1.34E-24 | 1.34E-24 | 0.00E-01 |
| P 32 | 4.58E+02 | 1.33E+03 | 1.18E+04 | 7.36E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 8.52E-01 | 2.14E+02 | 0.00E-01 | 0.00E-01 | 1.88E-01 | 5.09E-01 | 1.13E+00 | 0.00E-01 |
| MN 54 | 1.54E+03 | 2.47E+04 | 0.00E-01 | 8.08E+03 | 2.40E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 2.27E-27 | 4.09E-25 | 0.00E-01 | 1.28E-26 | 1.63E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 8.75E+02 | 2.15E+03 | 5.43E+03 | 3.75E+03 | 0.00E-01 | 0.00E-01 | 2.09E+03 | 0.00E-01 |
| FE 59 | 2.52E+03 | 2.19E+04 | 2.79E+03 | 6.57E+03 | 0.00E-01 | 0.00E-01 | 1.83E+03 | 0.00E-01 |
| CO 58 | 1.66E+03 | 1.50E+04 | 0.00E-01 | 7.39E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 9.66E+03 | 8.23E+04 | 0.00E-01 | 4.38E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 9.45E+03 | 4.08E+03 | 2.82E+05 | 1.95E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 3.40E-27 | 1.89E-25 | 5.74E-26 | 7.46E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 2.59E-26 | 4.70E-24 | 0.00E-01 | 5.51E-26 | 1.39E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.24E+04 | 1.73E+04 | 8.62E+03 | 2.74E+04 | 1.83E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 3.58E-29 | 7.74E-29 | 2.69E-28 | 5.15E-28 | 3.35E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 4.12E-27 | 5.93E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 4.30E-28 | 3.38E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 2.95E-36 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 1.33E+03 | 5.63E+02 | 0.00E-01 | 2.85E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 5.32E-29 | 1.39E-39 | 0.00E-01 | 1.00E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 2.69E-29 | 2.22E-42 | 0.00E-01 | 3.83E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 6.56E+03 | 3.67E+04 | 2.29E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 5.06E+05 | 6.33E+05 | 2.52E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.13E-25 | 1.33E-23 | 2.79E-24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 1.11E-26 | 5.09E-24 | 2.57E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 1.58E-08 | 6.26E-03 | 5.90E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 7.18E-32 | 5.44E-30 | 1.85E-30 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 3.20E+00 | 6.59E+04 | 1.20E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 4.09E-30 | 2.45E-24 | 1.40E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 3.87E-29 | 4.44E-23 | 1.40E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 6.05E+00 | 2.83E+04 | 2.79E+01 | 8.94E+00 | 1.40E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 3.38E-28 | 2.29E-22 | 3.66E-27 | 7.38E-28 | 1.12E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 8.82E-01 | 9.95E+03 | 2.95E+00 | 1.64E+00 | 1.62E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 7.80E-05 | 9.51E-04 | 0.00E-01 | 4.10E-04 | 9.29E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 2.69E-27 | 1.25E-25 | 7.46E-29 | 2.11E-28 | 3.20E-27 | 0.00E-01 | 1.03E-28 | 0.00E-01 |
| TC101 | 2.60E-30 | 7.96E-43 | 1.84E-31 | 2.65E-31 | 4.77E-30 | 0.00E-01 | 1.35E-31 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = IRRIGATED STORED FRUIT, VEGETABLES, GRAIN

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 4.41E+01 | 1.19E+04 | 1.02E+02 | 0.00E-01 | 3.90E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.30E-27 | 2.02E-24 | 3.30E-27 | 0.00E-01 | 4.27E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 6.35E+02 | 3.25E+05 | 5.02E+03 | 0.00E-01 | 9.69E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 1.52E+02 | 1.04E+05 | 2.76E+02 | 2.55E+02 | 5.02E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 3.20E+02 | 9.53E+03 | 2.39E+03 | 8.65E+02 | 9.71E+03 | 7.18E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.16E+03 | 3.19E+04 | 9.52E+03 | 3.40E+03 | 3.87E+04 | 2.43E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.16E-26 | 4.24E-24 | 5.37E-26 | 1.93E-26 | 2.19E-25 | 3.98E-26 | 0.00E-01 | 0.00E-01 |
| TE129M | 8.34E+02 | 2.65E+04 | 5.27E+03 | 1.97E+03 | 2.20E+04 | 1.81E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 2.81E-28 | 8.72E-28 | 1.16E-27 | 4.34E-28 | 4.86E-27 | 8.86E-28 | 0.00E-01 | 0.00E-01 |
| TE131M | 4.41E-13 | 5.25E-11 | 1.08E-12 | 5.29E-13 | 5.36E-12 | 8.38E-13 | 0.00E-01 | 0.00E-01 |
| TE131 | 2.86E-29 | 1.28E-29 | 9.04E-29 | 3.78E-29 | 3.96E-28 | 7.44E-29 | 0.00E-01 | 0.00E-01 |
| TE132 | 1.84E-03 | 9.30E-02 | 3.04E-03 | 1.97E-03 | 1.89E-02 | 2.17E-03 | 0.00E-01 | 0.00E-01 |
| I 130 | 5.67E-25 | 1.24E-24 | 4.87E-25 | 1.44E-24 | 2.24E-24 | 1.22E-22 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.54E+01 | 7.10E+00 | 1.88E+01 | 2.69E+01 | 4.61E+01 | 8.81E+03 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.84E-26 | 9.87E-27 | 1.96E-26 | 5.25E-26 | 8.37E-26 | 1.84E-24 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.40E-19 | 4.11E-19 | 2.63E-19 | 4.58E-19 | 7.99E-19 | 6.73E-17 | 0.00E-01 | 0.00E-01 |
| I 134 | 2.33E-27 | 5.68E-30 | 2.40E-27 | 6.52E-27 | 1.04E-26 | 1.13E-25 | 0.00E-01 | 0.00E-01 |
| I 135 | 1.43E-25 | 4.37E-25 | 1.48E-25 | 3.87E-25 | 6.20E-25 | 2.55E-23 | 0.00E-01 | 0.00E-01 |
| CS134 | 2.36E+05 | 5.05E+03 | 1.21E+05 | 2.89E+05 | 9.34E+04 | 0.00E-01 | 3.10E+04 | 0.00E-01 |
| CS136 | 8.20E+02 | 1.29E+02 | 2.88E+02 | 1.14E+03 | 6.34E+02 | 0.00E-01 | 8.68E+01 | 0.00E-01 |
| CS137 | 1.51E+05 | 4.46E+03 | 1.69E+05 | 2.30E+05 | 7.82E+04 | 0.00E-01 | 2.60E+04 | 0.00E-01 |
| CS138 | 4.57E-28 | 3.94E-33 | 4.67E-28 | 9.23E-28 | 6.78E-28 | 0.00E-01 | 6.70E-29 | 0.00E-01 |
| BA139 | 1.35E-28 | 8.14E-27 | 4.59E-27 | 3.27E-30 | 3.06E-30 | 0.00E-01 | 1.86E-30 | 0.00E-01 |
| BA140 | 5.38E+01 | 1.69E+03 | 8.22E+02 | 1.03E+00 | 3.51E-01 | 0.00E-01 | 5.91E-01 | 0.00E-01 |
| BA141 | 2.85E-30 | 3.98E-38 | 8.43E-29 | 6.37E-32 | 5.93E-32 | 0.00E-01 | 3.62E-32 | 0.00E-01 |
| BA142 | 2.80E-31 | 0.00E-01 | 4.45E-30 | 4.58E-33 | 3.87E-33 | 0.00E-01 | 2.59E-33 | 0.00E-01 |
| LA140 | 1.33E-12 | 3.70E-07 | 1.00E-11 | 5.04E-12 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 8.11E-31 | 2.38E-26 | 7.16E-30 | 3.26E-30 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 3.02E-01 | 1.02E+04 | 3.93E+00 | 2.66E+00 | 1.24E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 2.16E-15 | 7.31E-10 | 2.65E-14 | 1.96E-11 | 8.61E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 4.53E+01 | 2.85E+05 | 8.44E+02 | 3.53E+02 | 2.09E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 2.31E-02 | 2.04E+03 | 4.65E-01 | 1.87E-01 | 1.08E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 2.27E-33 | 6.41E-39 | 4.46E-32 | 1.85E-32 | 1.04E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 9.92E-03 | 7.95E+02 | 1.43E-01 | 1.66E-01 | 9.69E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 3.21E-18 | 3.01E-15 | 1.10E-17 | 9.18E-18 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 4.47E-10 | 1.66E-04 | 8.25E-09 | 8.11E-10 | 2.53E-09 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = IRRIGATED FRESH FORAGE--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 4.24E+00 | 4.24E+00 | 0.00E-01 | 4.24E+00 | 4.24E+00 | 4.24E+00 | 4.24E+00 | 0.00E-01 |
| C 14 | 6.45E+03 | 6.45E+03 | 3.23E+04 | 6.45E+03 | 6.45E+03 | 6.45E+03 | 6.45E+03 | 0.00E-01 |
| NA 24 | 5.70E+01 | 5.70E+01 | 5.70E+01 | 5.70E+01 | 5.70E+01 | 5.70E+01 | 5.70E+01 | 0.00E-01 |
| P 32 | 1.52E+04 | 4.43E+04 | 3.94E+05 | 2.45E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 6.17E-01 | 1.55E+02 | 0.00E-01 | 0.00E-01 | 1.36E-01 | 3.69E-01 | 8.18E-01 | 0.00E-01 |
| MN 54 | 3.07E+01 | 4.93E+02 | 0.00E-01 | 1.61E+02 | 4.79E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 1.30E-08 | 2.34E-06 | 0.00E-01 | 7.32E-08 | 9.30E-08 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 7.62E+01 | 1.87E+02 | 4.73E+02 | 3.27E+02 | 0.00E-01 | 0.00E-01 | 1.82E+02 | 0.00E-01 |
| FE 59 | 5.55E+02 | 4.83E+03 | 6.16E+02 | 1.45E+03 | 0.00E-01 | 0.00E-01 | 4.05E+02 | 0.00E-01 |
| CO 58 | 2.13E+02 | 1.92E+03 | 0.00E-01 | 9.48E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 6.82E+02 | 5.81E+03 | 0.00E-01 | 3.09E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 4.30E+03 | 1.85E+03 | 1.28E+05 | 8.89E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 4.10E-07 | 2.28E-05 | 6.91E-06 | 8.98E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 2.55E-01 | 4.63E+01 | 0.00E-01 | 5.43E-01 | 1.37E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 3.88E+04 | 5.41E+04 | 2.70E+04 | 8.59E+04 | 5.74E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 7.91E-18 | 1.71E-17 | 5.94E-17 | 1.14E-16 | 7.39E-17 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.81E-06 | 2.61E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 1.82E-27 | 1.43E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 1.25E-35 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.71E+04 | 1.15E+04 | 0.00E-01 | 5.81E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 1.36E-28 | 3.54E-39 | 0.00E-01 | 2.56E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 6.87E-29 | 5.68E-42 | 0.00E-01 | 9.77E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 8.69E+02 | 4.86E+03 | 3.03E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 3.73E+04 | 4.67E+04 | 1.86E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 2.63E-02 | 3.10E+00 | 6.50E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 4.06E-07 | 1.86E-04 | 9.39E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 4.56E-05 | 1.80E+01 | 1.70E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 2.28E-26 | 1.73E-24 | 5.89E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 4.67E-03 | 9.62E+01 | 1.75E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 3.40E-11 | 2.04E-05 | 1.16E-09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 1.39E-07 | 1.59E-01 | 5.02E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 4.15E-03 | 1.94E+01 | 1.91E-02 | 6.12E-03 | 9.61E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 9.29E-07 | 6.29E-01 | 1.01E-05 | 2.03E-06 | 3.07E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 5.23E-01 | 5.90E+03 | 1.75E+00 | 9.72E-01 | 9.61E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 1.13E+02 | 1.37E+03 | 0.00E-01 | 5.93E+02 | 1.34E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 2.59E-03 | 1.20E-01 | 7.19E-05 | 2.03E-04 | 3.08E-03 | 0.00E-01 | 9.95E-05 | 0.00E-01 |
| TC101 | 5.52E-30 | 1.69E-42 | 3.91E-31 | 5.63E-31 | 1.01E-29 | 0.00E-01 | 2.88E-31 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = IRRIGATED FRESH FORAGE--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 9.19E-03 | 2.49E+00 | 2.13E-02 | 0.00E-01 | 8.15E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 7.01E-09 | 1.09E-05 | 1.78E-08 | 0.00E-01 | 2.30E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 4.93E-02 | 2.52E+01 | 3.90E-01 | 0.00E-01 | 7.53E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 6.19E+02 | 4.25E+05 | 1.13E+03 | 1.04E+03 | 2.05E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 4.55E+01 | 1.35E+03 | 3.39E+02 | 1.23E+02 | 1.38E+03 | 1.02E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.14E+02 | 3.14E+03 | 9.37E+02 | 3.35E+02 | 3.80E+03 | 2.39E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 3.19E-03 | 1.16E+00 | 1.48E-02 | 5.30E-03 | 6.01E-02 | 1.09E-02 | 0.00E-01 | 0.00E-01 |
| TE129M | 2.05E+02 | 6.53E+03 | 1.30E+03 | 4.84E+02 | 5.41E+03 | 4.45E+02 | 0.00E-01 | 0.00E-01 |
| TE129 | 9.47E-16 | 2.94E-15 | 3.89E-15 | 1.46E-15 | 1.63E-14 | 2.99E-15 | 0.00E-01 | 0.00E-01 |
| TE131M | 3.50E+00 | 4.16E+02 | 8.58E+00 | 4.20E+00 | 4.25E+01 | 6.64E+00 | 0.00E-01 | 0.00E-01 |
| TE131 | 2.41E-30 | 1.08E-30 | 7.65E-30 | 3.20E-30 | 3.35E-29 | 6.29E-30 | 0.00E-01 | 0.00E-01 |
| TE132 | 3.52E+01 | 1.77E+03 | 5.79E+01 | 3.75E+01 | 3.61E+02 | 4.14E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 2.23E+00 | 4.87E+00 | 1.92E+00 | 5.66E+00 | 8.83E+00 | 4.79E+02 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.15E+03 | 5.30E+02 | 1.40E+03 | 2.01E+03 | 3.44E+03 | 6.58E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 5.61E-07 | 3.01E-07 | 6.00E-07 | 1.60E-06 | 2.56E-06 | 5.61E-05 | 0.00E-01 | 0.00E-01 |
| I 133 | 9.64E+00 | 2.84E+01 | 1.82E+01 | 3.16E+01 | 5.52E+01 | 4.65E+03 | 0.00E-01 | 0.00E-01 |
| I 134 | 4.20E-18 | 1.02E-20 | 4.32E-18 | 1.17E-17 | 1.87E-17 | 2.04E-16 | 0.00E-01 | 0.00E-01 |
| I 135 | 5.36E-02 | 1.64E-01 | 5.54E-02 | 1.45E-01 | 2.33E-01 | 9.57E+00 | 0.00E-01 | 0.00E-01 |
| CS134 | 2.08E+05 | 4.45E+03 | 1.07E+05 | 2.54E+05 | 8.23E+04 | 0.00E-01 | 2.73E+04 | 0.00E-01 |
| CS136 | 1.72E+04 | 2.71E+03 | 6.05E+03 | 2.39E+04 | 1.33E+04 | 0.00E-01 | 1.82E+03 | 0.00E-01 |
| CS137 | 1.25E+05 | 3.69E+03 | 1.39E+05 | 1.91E+05 | 6.47E+04 | 0.00E-01 | 2.15E+04 | 0.00E-01 |
| CS138 | 4.67E-28 | 4.02E-33 | 4.78E-28 | 9.43E-28 | 6.93E-28 | 0.00E-01 | 6.85E-29 | 0.00E-01 |
| BA139 | 1.63E-14 | 9.87E-13 | 5.57E-13 | 3.97E-16 | 3.71E-16 | 0.00E-01 | 2.25E-16 | 0.00E-01 |
| BA140 | 4.06E+01 | 1.28E+03 | 6.20E+02 | 7.79E-01 | 2.65E-01 | 0.00E-01 | 4.46E-01 | 0.00E-01 |
| BA141 | 9.70E-32 | 1.35E-39 | 2.87E-30 | 2.17E-33 | 2.02E-33 | 0.00E-01 | 1.23E-33 | 0.00E-01 |
| BA142 | 9.54E-33 | 0.00E-01 | 1.52E-31 | 1.56E-34 | 1.32E-34 | 0.00E-01 | 8.82E-35 | 0.00E-01 |
| LA140 | 1.43E-05 | 3.98E+00 | 1.08E-04 | 5.43E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 1.64E-17 | 4.81E-13 | 1.45E-16 | 6.59E-17 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 7.91E-03 | 2.67E+02 | 1.03E-01 | 6.98E-02 | 3.24E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 8.13E-05 | 2.75E+01 | 9.94E-04 | 7.35E-01 | 3.23E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 3.67E-01 | 2.31E+03 | 6.84E+00 | 2.86E+00 | 1.70E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.80E-04 | 1.59E+01 | 3.63E-03 | 1.46E-03 | 8.41E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 9.64E-37 | 2.73E-42 | 1.90E-35 | 7.88E-36 | 4.44E-36 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.53E-04 | 1.23E+01 | 2.21E-03 | 2.55E-03 | 1.49E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 4.52E-02 | 4.24E+01 | 1.55E-01 | 1.29E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 4.77E-06 | 1.78E+00 | 8.81E-05 | 8.66E-06 | 2.70E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = IRRIGATED FRESH FORAGE--MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.65E+00 | 1.65E+00 | 0.00E-01 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 0.00E-01 |
| C 14 | 5.91E+03 | 5.91E+03 | 2.96E+04 | 5.91E+03 | 5.91E+03 | 5.91E+03 | 5.91E+03 | 0.00E-01 |
| NA 24 | 3.43E-08 | 3.43E-08 | 3.43E-08 | 3.43E-08 | 3.43E-08 | 3.43E-08 | 3.43E-08 | 0.00E-01 |
| P 32 | 4.15E+03 | 1.21E+04 | 1.07E+05 | 6.68E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.52E-01 | 3.82E+01 | 0.00E-01 | 0.00E-01 | 3.35E-02 | 9.09E-02 | 2.02E-01 | 0.00E-01 |
| MN 54 | 3.35E+01 | 5.38E+02 | 0.00E-01 | 1.75E+02 | 5.22E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 5.49E-29 | 9.88E-27 | 0.00E-01 | 3.09E-28 | 3.93E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 8.90E+02 | 2.19E+03 | 5.52E+03 | 3.82E+03 | 0.00E-01 | 0.00E-01 | 2.13E+03 | 0.00E-01 |
| FE 59 | 4.96E+03 | 4.31E+04 | 5.51E+03 | 1.29E+04 | 0.00E-01 | 0.00E-01 | 3.62E+03 | 0.00E-01 |
| CO 58 | 8.23E+02 | 7.44E+03 | 0.00E-01 | 3.67E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 3.13E+03 | 2.66E+04 | 0.00E-01 | 1.42E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.21E+04 | 5.20E+03 | 3.60E+05 | 2.49E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 5.45E-27 | 3.03E-25 | 9.20E-26 | 1.20E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 2.80E-12 | 5.08E-10 | 0.00E-01 | 5.96E-12 | 1.50E-11 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.01E+04 | 1.40E+04 | 7.00E+03 | 2.23E+04 | 1.49E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 3.24E-29 | 7.00E-29 | 2.44E-28 | 4.66E-28 | 3.03E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 3.22E-27 | 4.64E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 3.37E-28 | 2.64E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 2.30E-36 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 5.10E+03 | 2.16E+03 | 0.00E-01 | 1.09E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 4.98E-29 | 1.30E-39 | 0.00E-01 | 9.39E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 2.52E-29 | 2.08E-42 | 0.00E-01 | 3.58E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.81E+02 | 1.01E+03 | 6.29E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 9.93E+03 | 1.24E+04 | 4.94E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.36E-16 | 1.60E-14 | 3.37E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 2.02E-28 | 9.24E-26 | 4.66E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 7.00E-05 | 2.77E+01 | 2.61E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 9.98E-33 | 7.57E-31 | 2.58E-31 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 6.16E-01 | 1.27E+04 | 2.30E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 5.68E-31 | 3.41E-25 | 1.94E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 2.85E-18 | 3.27E-12 | 1.03E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 8.23E+00 | 3.85E+04 | 3.79E+01 | 1.22E+01 | 1.91E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 4.47E-11 | 3.03E-05 | 4.85E-10 | 9.78E-11 | 1.48E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 1.46E+01 | 1.64E+05 | 4.87E+01 | 2.71E+01 | 2.68E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 4.55E-01 | 5.54E+00 | 0.00E-01 | 2.39E+00 | 5.42E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 3.58E-24 | 1.66E-22 | 9.94E-26 | 2.81E-25 | 4.27E-24 | 0.00E-01 | 1.38E-25 | 0.00E-01 |
| TC101 | 3.13E-29 | 9.61E-42 | 2.22E-30 | 3.20E-30 | 5.76E-29 | 0.00E-01 | 1.63E-30 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = IRRIGATED FRESH FORAGE-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 9.50E+02 | 2.58E+05 | 2.21E+03 | 0.00E-01 | 8.42E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.57E-26 | 2.44E-23 | 3.99E-26 | 0.00E-01 | 5.16E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 6.77E+03 | 3.46E+06 | 5.35E+04 | 0.00E-01 | 1.03E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 7.11E+01 | 4.88E+04 | 1.29E+02 | 1.20E+02 | 2.35E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 1.00E+03 | 2.99E+04 | 7.48E+03 | 2.71E+03 | 3.04E+04 | 2.25E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 2.78E+03 | 7.65E+04 | 2.28E+04 | 8.16E+03 | 9.27E+04 | 5.83E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.07E-15 | 3.88E-13 | 4.92E-15 | 1.77E-15 | 2.01E-14 | 3.65E-15 | 0.00E-01 | 0.00E-01 |
| TE129M | 3.86E+03 | 1.23E+05 | 2.44E+04 | 9.11E+03 | 1.02E+05 | 8.39E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 6.50E-28 | 2.01E-27 | 2.67E-27 | 1.00E-27 | 1.12E-26 | 2.05E-27 | 0.00E-01 | 0.00E-01 |
| TE131M | 4.40E-03 | 5.25E-01 | 1.08E-02 | 5.28E-03 | 5.35E-02 | 8.37E-03 | 0.00E-01 | 0.00E-01 |
| TE131 | 6.60E-29 | 2.96E-29 | 2.09E-28 | 8.73E-29 | 9.15E-28 | 1.72E-28 | 0.00E-01 | 0.00E-01 |
| TE132 | 2.10E+01 | 1.06E+03 | 3.45E+01 | 2.23E+01 | 2.15E+02 | 2.46E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 1.11E-11 | 2.43E-11 | 9.56E-12 | 2.82E-11 | 4.40E-11 | 2.39E-09 | 0.00E-01 | 0.00E-01 |
| I 131 | 4.18E+01 | 1.92E+01 | 5.10E+01 | 7.29E+01 | 1.25E+02 | 2.39E+04 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.61E-27 | 8.65E-28 | 1.72E-27 | 4.60E-27 | 7.33E-27 | 1.61E-25 | 0.00E-01 | 0.00E-01 |
| I 133 | 9.35E-07 | 2.76E-06 | 1.76E-06 | 3.07E-06 | 5.35E-06 | 4.51E-04 | 0.00E-01 | 0.00E-01 |
| I 134 | 2.04E-28 | 4.98E-31 | 2.10E-28 | 5.71E-28 | 9.08E-28 | 9.89E-27 | 0.00E-01 | 0.00E-01 |
| I 135 | 1.74E-22 | 5.33E-22 | 1.80E-22 | 4.72E-22 | 7.57E-22 | 3.11E-20 | 0.00E-01 | 0.00E-01 |
| CS134 | 2.42E+04 | 5.18E+02 | 1.24E+04 | 2.96E+04 | 9.57E+03 | 0.00E-01 | 3.18E+03 | 0.00E-01 |
| CS136 | 7.85E+02 | 1.24E+02 | 2.76E+02 | 1.09E+03 | 6.07E+02 | 0.00E-01 | 8.32E+01 | 0.00E-01 |
| CS137 | 1.48E+04 | 4.36E+02 | 1.65E+04 | 2.25E+04 | 7.65E+03 | 0.00E-01 | 2.54E+03 | 0.00E-01 |
| CS138 | 5.53E-29 | 4.76E-34 | 5.65E-29 | 1.12E-28 | 8.20E-29 | 0.00E-01 | 8.10E-30 | 0.00E-01 |
| BA139 | 1.30E-29 | 7.88E-28 | 4.44E-28 | 3.16E-31 | 2.96E-31 | 0.00E-01 | 1.79E-31 | 0.00E-01 |
| BA140 | 4.35E+01 | 1.37E+03 | 6.64E+02 | 8.34E-01 | 2.84E-01 | 0.00E-01 | 4.78E-01 | 0.00E-01 |
| BA141 | 2.75E-31 | 3.84E-39 | 8.15E-30 | 6.16E-33 | 5.73E-33 | 0.00E-01 | 3.50E-33 | 0.00E-01 |
| BA142 | 2.71E-32 | 0.00E-01 | 4.30E-31 | 4.42E-34 | 3.74E-34 | 0.00E-01 | 2.51E-34 | 0.00E-01 |
| LA140 | 1.20E-07 | 3.34E-02 | 9.03E-07 | 4.55E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 4.90E-33 | 1.44E-28 | 4.33E-32 | 1.97E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 2.29E-02 | 7.73E+02 | 2.99E-01 | 2.02E-01 | 9.40E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 4.12E-08 | 1.39E-02 | 5.04E-07 | 3.73E-04 | 1.64E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.50E+00 | 9.42E+03 | 2.79E+01 | 1.16E+01 | 6.91E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 2.40E-02 | 2.12E+03 | 4.84E-01 | 1.94E-01 | 1.12E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 3.22E-34 | 9.11E-40 | 6.33E-33 | 2.63E-33 | 1.48E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.16E-02 | 9.33E+02 | 1.68E-01 | 1.94E-01 | 1.14E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 1.52E-07 | 1.43E-04 | 5.22E-07 | 4.36E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 3.42E-07 | 1.27E-01 | 6.32E-06 | 6.21E-07 | 1.94E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = IRRIGATED STORED FEED--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 4.24E+00 | 4.24E+00 | 0.00E-01 | 4.24E+00 | 4.24E+00 | 4.24E+00 | 4.24E+00 | 0.00E-01 |
| C 14 | 6.67E+03 | 6.67E+03 | 3.34E+04 | 6.67E+03 | 6.67E+03 | 6.67E+03 | 6.67E+03 | 0.00E-01 |
| NA 24 | 5.70E+01 | 5.70E+01 | 5.70E+01 | 5.70E+01 | 5.70E+01 | 5.70E+01 | 5.70E+01 | 0.00E-01 |
| P 32 | 1.60E+04 | 4.66E+04 | 4.14E+05 | 2.58E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 6.83E-01 | 1.72E+02 | 0.00E-01 | 0.00E-01 | 1.50E-01 | 4.08E-01 | 9.06E-01 | 0.00E-01 |
| MN 54 | 3.72E+01 | 5.97E+02 | 0.00E-01 | 1.95E+02 | 5.80E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 1.30E-08 | 2.34E-06 | 0.00E-01 | 7.32E-08 | 9.30E-08 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 9.31E+01 | 2.29E+02 | 5.78E+02 | 3.99E+02 | 0.00E-01 | 0.00E-01 | 2.23E+02 | 0.00E-01 |
| FE 59 | 6.34E+02 | 5.51E+03 | 7.04E+02 | 1.65E+03 | 0.00E-01 | 0.00E-01 | 4.62E+02 | 0.00E-01 |
| CO 58 | 2.48E+02 | 2.25E+03 | 0.00E-01 | 1.11E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 8.35E+02 | 7.11E+03 | 0.00E-01 | 3.78E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 5.26E+03 | 2.27E+03 | 1.57E+05 | 1.09E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 4.10E-07 | 2.28E-05 | 6.91E-06 | 8.98E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 2.55E-01 | 4.63E+01 | 0.00E-01 | 5.43E-01 | 1.37E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 4.67E+04 | 6.51E+04 | 3.25E+04 | 1.03E+05 | 6.91E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 7.91E-18 | 1.71E-17 | 5.94E-17 | 1.14E-16 | 7.39E-17 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.81E-06 | 2.61E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 1.82E-27 | 1.43E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 1.25E-35 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.91E+04 | 1.23E+04 | 0.00E-01 | 6.25E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 1.36E-28 | 3.54E-39 | 0.00E-01 | 2.56E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 6.87E-29 | 5.68E-42 | 0.00E-01 | 9.77E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 9.97E+02 | 5.57E+03 | 3.48E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 4.19E+04 | 5.25E+04 | 2.09E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 2.63E-02 | 3.10E+00 | 6.50E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 4.06E-07 | 1.86E-04 | 9.39E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 4.56E-05 | 1.80E+01 | 1.70E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 2.28E-26 | 1.73E-24 | 5.89E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 5.42E-03 | 1.11E+02 | 2.03E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 3.40E-11 | 2.04E-05 | 1.16E-09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 1.39E-07 | 1.59E-01 | 5.02E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 4.82E-03 | 2.26E+01 | 2.22E-02 | 7.13E-03 | 1.12E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 9.29E-07 | 6.29E-01 | 1.01E-05 | 2.03E-06 | 3.07E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 5.88E-01 | 6.64E+03 | 1.97E+00 | 1.09E+00 | 1.08E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 1.13E+02 | 1.37E+03 | 0.00E-01 | 5.93E+02 | 1.34E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 2.59E-03 | 1.20E-01 | 7.19E-05 | 2.03E-04 | 3.08E-03 | 0.00E-01 | 9.95E-05 | 0.00E-01 |
| TC101 | 5.52E-30 | 1.69E-42 | 3.91E-31 | 5.63E-31 | 1.01E-29 | 0.00E-01 | 2.88E-31 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = IRRIGATED STORED FEED--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.04E-02 | 2.83E+00 | 2.42E-02 | 0.00E-01 | 9.23E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 7.01E-09 | 1.09E-05 | 1.78E-08 | 0.00E-01 | 2.30E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 5.98E-02 | 3.06E+01 | 4.73E-01 | 0.00E-01 | 9.13E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 7.47E+02 | 5.13E+05 | 1.36E+03 | 1.26E+03 | 2.47E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 5.25E+01 | 1.56E+03 | 3.92E+02 | 1.42E+02 | 1.59E+03 | 1.18E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.35E+02 | 3.71E+03 | 1.10E+03 | 3.95E+02 | 4.49E+03 | 2.82E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 3.19E-03 | 1.16E+00 | 1.48E-02 | 5.30E-03 | 6.01E-02 | 1.09E-02 | 0.00E-01 | 0.00E-01 |
| TE129M | 2.30E+02 | 7.31E+03 | 1.45E+03 | 5.42E+02 | 6.06E+03 | 4.99E+02 | 0.00E-01 | 0.00E-01 |
| TE129 | 9.47E-16 | 2.94E-15 | 3.89E-15 | 1.46E-15 | 1.63E-14 | 2.99E-15 | 0.00E-01 | 0.00E-01 |
| TE131M | 3.50E+00 | 4.16E+02 | 8.58E+00 | 4.20E+00 | 4.25E+01 | 6.64E+00 | 0.00E-01 | 0.00E-01 |
| TE131 | 2.41E-30 | 1.08E-30 | 7.65E-30 | 3.20E-30 | 3.35E-29 | 6.29E-30 | 0.00E-01 | 0.00E-01 |
| TE132 | 3.52E+01 | 1.77E+03 | 5.80E+01 | 3.75E+01 | 3.61E+02 | 4.14E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 2.23E+00 | 4.87E+00 | 1.92E+00 | 5.66E+00 | 8.83E+00 | 4.79E+02 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.17E+03 | 5.39E+02 | 1.43E+03 | 2.04E+03 | 3.50E+03 | 6.69E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 5.61E-07 | 3.01E-07 | 6.00E-07 | 1.60E-06 | 2.56E-06 | 5.61E-05 | 0.00E-01 | 0.00E-01 |
| I 133 | 9.64E+00 | 2.84E+01 | 1.82E+01 | 3.16E+01 | 5.52E+01 | 4.65E+03 | 0.00E-01 | 0.00E-01 |
| I 134 | 4.20E-18 | 1.02E-20 | 4.32E-18 | 1.17E-17 | 1.87E-17 | 2.04E-16 | 0.00E-01 | 0.00E-01 |
| I 135 | 5.36E-02 | 1.64E-01 | 5.54E-02 | 1.45E-01 | 2.33E-01 | 9.57E+00 | 0.00E-01 | 0.00E-01 |
| CS134 | 2.54E+05 | 5.43E+03 | 1.30E+05 | 3.10E+05 | 1.00E+05 | 0.00E-01 | 3.33E+04 | 0.00E-01 |
| CS136 | 1.80E+04 | 2.84E+03 | 6.33E+03 | 2.50E+04 | 1.39E+04 | 0.00E-01 | 1.91E+03 | 0.00E-01 |
| CS137 | 1.53E+05 | 4.52E+03 | 1.71E+05 | 2.33E+05 | 7.92E+04 | 0.00E-01 | 2.63E+04 | 0.00E-01 |
| CS138 | 4.67E-28 | 4.02E-33 | 4.78E-28 | 9.43E-28 | 6.93E-28 | 0.00E-01 | 6.85E-29 | 0.00E-01 |
| BA139 | 1.63E-14 | 9.87E-13 | 5.57E-13 | 3.97E-16 | 3.71E-16 | 0.00E-01 | 2.25E-16 | 0.00E-01 |
| BA140 | 4.25E+01 | 1.33E+03 | 6.48E+02 | 8.14E-01 | 2.77E-01 | 0.00E-01 | 4.66E-01 | 0.00E-01 |
| BA141 | 9.70E-32 | 1.35E-39 | 2.87E-30 | 2.17E-33 | 2.02E-33 | 0.00E-01 | 1.23E-33 | 0.00E-01 |
| BA142 | 9.54E-33 | 0.00E-01 | 1.52E-31 | 1.56E-34 | 1.32E-34 | 0.00E-01 | 8.82E-35 | 0.00E-01 |
| LA140 | 1.43E-05 | 3.98E+00 | 1.08E-04 | 5.43E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 1.64E-17 | 4.81E-13 | 1.45E-16 | 6.59E-17 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 8.86E-03 | 2.98E+02 | 1.16E-01 | 7.81E-02 | 3.63E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 8.13E-05 | 2.75E+01 | 9.94E-04 | 7.35E-01 | 3.23E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 4.44E-01 | 2.80E+03 | 8.27E+00 | 3.46E+00 | 2.05E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.89E-04 | 1.67E+01 | 3.81E-03 | 1.53E-03 | 8.82E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 9.64E-37 | 2.73E-42 | 1.90E-35 | 7.88E-36 | 4.44E-36 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.58E-04 | 1.27E+01 | 2.29E-03 | 2.64E-03 | 1.55E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 4.52E-02 | 4.24E+01 | 1.55E-01 | 1.29E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 4.77E-06 | 1.78E+00 | 8.81E-05 | 8.66E-06 | 2.70E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = IRRIGATED STORED FEED-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.65E+00 | 1.65E+00 | 0.00E-01 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 0.00E-01 |
| C 14 | 6.12E+03 | 6.12E+03 | 3.06E+04 | 6.12E+03 | 6.12E+03 | 6.12E+03 | 6.12E+03 | 0.00E-01 |
| NA 24 | 3.43E-08 | 3.43E-08 | 3.43E-08 | 3.43E-08 | 3.43E-08 | 3.43E-08 | 3.43E-08 | 0.00E-01 |
| P 32 | 4.37E+03 | 1.27E+04 | 1.13E+05 | 7.03E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.68E-01 | 4.23E+01 | 0.00E-01 | 0.00E-01 | 3.71E-02 | 1.01E-01 | 2.23E-01 | 0.00E-01 |
| MN 54 | 4.06E+01 | 6.51E+02 | 0.00E-01 | 2.13E+02 | 6.33E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 5.49E-29 | 9.88E-27 | 0.00E-01 | 3.09E-28 | 3.93E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 1.09E+03 | 2.67E+03 | 6.75E+03 | 4.66E+03 | 0.00E-01 | 0.00E-01 | 2.60E+03 | 0.00E-01 |
| FE 59 | 5.67E+03 | 4.93E+04 | 6.29E+03 | 1.48E+04 | 0.00E-01 | 0.00E-01 | 4.13E+03 | 0.00E-01 |
| CO 58 | 9.62E+02 | 8.69E+03 | 0.00E-01 | 4.29E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 3.82E+03 | 3.26E+04 | 0.00E-01 | 1.73E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.48E+04 | 6.36E+03 | 4.40E+05 | 3.05E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 5.45E-27 | 3.03E-25 | 9.20E-26 | 1.20E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 2.80E-12 | 5.08E-10 | 0.00E-01 | 5.96E-12 | 1.50E-11 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.21E+04 | 1.69E+04 | 8.42E+03 | 2.68E+04 | 1.79E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 3.24E-29 | 7.00E-29 | 2.44E-28 | 4.66E-28 | 3.03E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 3.22E-27 | 4.64E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 3.37E-28 | 2.64E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 2.30E-36 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 5.48E+03 | 2.32E+03 | 0.00E-01 | 1.18E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 4.98E-29 | 1.30E-39 | 0.00E-01 | 9.39E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 2.52E-29 | 2.08E-42 | 0.00E-01 | 3.58E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.07E+02 | 1.16E+03 | 7.22E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.11E+04 | 1.39E+04 | 5.55E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.36E-16 | 1.60E-14 | 3.37E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 2.02E-28 | 9.24E-26 | 4.66E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 7.01E-05 | 2.77E+01 | 2.61E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 9.98E-33 | 7.57E-31 | 2.58E-31 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 7.14E-01 | 1.47E+04 | 2.67E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 5.68E-31 | 3.41E-25 | 1.94E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 2.85E-18 | 3.27E-12 | 1.03E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 9.58E+00 | 4.49E+04 | 4.41E+01 | 1.42E+01 | 2.22E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 4.47E-11 | 3.03E-05 | 4.85E-10 | 9.78E-11 | 1.48E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 1.64E+01 | 1.85E+05 | 5.48E+01 | 3.05E+01 | 3.02E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 4.55E-01 | 5.54E+00 | 0.00E-01 | 2.39E+00 | 5.42E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 3.58E-24 | 1.66E-22 | 9.94E-26 | 2.81E-25 | 4.27E-24 | 0.00E-01 | 1.38E-25 | 0.00E-01 |
| TC101 | 3.13E-29 | 9.61E-42 | 2.22E-30 | 3.20E-30 | 5.76E-29 | 0.00E-01 | 1.63E-30 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = IRRIGATED STORED FEED-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.08E+03 | 2.92E+05 | 2.50E+03 | 0.00E-01 | 9.54E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.57E-26 | 2.44E-23 | 3.99E-26 | 0.00E-01 | 5.16E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 8.21E+03 | 4.20E+06 | 6.49E+04 | 0.00E-01 | 1.25E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 8.57E+01 | 5.89E+04 | 1.56E+02 | 1.44E+02 | 2.84E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 1.16E+03 | 3.45E+04 | 8.64E+03 | 3.13E+03 | 3.51E+04 | 2.60E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 3.28E+03 | 9.03E+04 | 2.69E+04 | 9.63E+03 | 1.09E+05 | 6.88E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.07E-15 | 3.88E-13 | 4.92E-15 | 1.77E-15 | 2.01E-14 | 3.65E-15 | 0.00E-01 | 0.00E-01 |
| TE129M | 4.33E+03 | 1.38E+05 | 2.74E+04 | 1.02E+04 | 1.14E+05 | 9.40E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 6.50E-28 | 2.01E-27 | 2.67E-27 | 1.00E-27 | 1.12E-26 | 2.05E-27 | 0.00E-01 | 0.00E-01 |
| TE131M | 4.40E-03 | 5.25E-01 | 1.08E-02 | 5.28E-03 | 5.35E-02 | 8.37E-03 | 0.00E-01 | 0.00E-01 |
| TE131 | 6.60E-29 | 2.96E-29 | 2.09E-28 | 8.73E-29 | 9.15E-28 | 1.72E-28 | 0.00E-01 | 0.00E-01 |
| TE132 | 2.10E+01 | 1.06E+03 | 3.45E+01 | 2.23E+01 | 2.15E+02 | 2.47E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 1.11E-11 | 2.43E-11 | 9.56E-12 | 2.82E-11 | 4.40E-11 | 2.39E-09 | 0.00E-01 | 0.00E-01 |
| I 131 | 4.25E+01 | 1.96E+01 | 5.19E+01 | 7.42E+01 | 1.27E+02 | 2.43E+04 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.61E-27 | 8.65E-28 | 1.72E-27 | 4.60E-27 | 7.33E-27 | 1.61E-25 | 0.00E-01 | 0.00E-01 |
| I 133 | 9.35E-07 | 2.76E-06 | 1.76E-06 | 3.07E-06 | 5.35E-06 | 4.51E-04 | 0.00E-01 | 0.00E-01 |
| I 134 | 2.04E-28 | 4.98E-31 | 2.10E-28 | 5.71E-28 | 9.08E-28 | 9.89E-27 | 0.00E-01 | 0.00E-01 |
| I 135 | 1.74E-22 | 5.33E-22 | 1.80E-22 | 4.72E-22 | 7.57E-22 | 3.11E-20 | 0.00E-01 | 0.00E-01 |
| CS134 | 2.95E+04 | 6.31E+02 | 1.52E+04 | 3.61E+04 | 1.17E+04 | 0.00E-01 | 3.88E+03 | 0.00E-01 |
| CS136 | 8.21E+02 | 1.30E+02 | 2.89E+02 | 1.14E+03 | 6.35E+02 | 0.00E-01 | 8.70E+01 | 0.00E-01 |
| CS137 | 1.81E+04 | 5.34E+02 | 2.02E+04 | 2.76E+04 | 9.36E+03 | 0.00E-01 | 3.11E+03 | 0.00E-01 |
| CS138 | 5.53E-29 | 4.76E-34 | 5.65E-29 | 1.12E-28 | 8.20E-29 | 0.00E-01 | 8.10E-30 | 0.00E-01 |
| BA139 | 1.30E-29 | 7.88E-28 | 4.44E-28 | 3.16E-31 | 2.96E-31 | 0.00E-01 | 1.79E-31 | 0.00E-01 |
| BA140 | 4.55E+01 | 1.43E+03 | 6.94E+02 | 8.72E-01 | 2.96E-01 | 0.00E-01 | 4.99E-01 | 0.00E-01 |
| BA141 | 2.75E-31 | 3.84E-39 | 8.15E-30 | 6.16E-33 | 5.73E-33 | 0.00E-01 | 3.50E-33 | 0.00E-01 |
| BA142 | 2.71E-32 | 0.00E-01 | 4.30E-31 | 4.42E-34 | 3.74E-34 | 0.00E-01 | 2.51E-34 | 0.00E-01 |
| LA140 | 1.20E-07 | 3.34E-02 | 9.03E-07 | 4.55E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 4.90E-33 | 1.44E-28 | 4.33E-32 | 1.97E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 2.57E-02 | 8.66E+02 | 3.35E-01 | 2.26E-01 | 1.05E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 4.12E-08 | 1.39E-02 | 5.04E-07 | 3.73E-04 | 1.64E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.81E+00 | 1.14E+04 | 3.37E+01 | 1.41E+01 | 8.36E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 2.52E-02 | 2.22E+03 | 5.08E-01 | 2.04E-01 | 1.18E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 3.22E-34 | 9.11E-40 | 6.33E-33 | 2.63E-33 | 1.48E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.20E-02 | 9.65E+02 | 1.74E-01 | 2.01E-01 | 1.17E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 1.52E-07 | 1.43E-04 | 5.22E-07 | 4.36E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 3.42E-07 | 1.27E-01 | 6.32E-06 | 6.21E-07 | 1.94E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = ANIMAL DRINKING WATER-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 5.08E+00 | 5.08E+00 | 0.00E-01 | 5.08E+00 | 5.08E+00 | 5.08E+00 | 5.08E+00 | 0.00E-01 |
| C 14 | 6.36E+01 | 6.36E+01 | 3.18E+02 | 6.36E+01 | 6.36E+01 | 6.36E+01 | 6.36E+01 | 0.00E-01 |
| NA 24 | 6.64E+01 | 6.64E+01 | 6.64E+01 | 6.64E+01 | 6.64E+01 | 6.64E+01 | 6.64E+01 | 0.00E-01 |
| P 32 | 1.58E+03 | 4.59E+03 | 4.08E+04 | 2.54E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 5.19E-02 | 1.31E+01 | 0.00E-01 | 0.00E-01 | 1.14E-02 | 3.10E-02 | 6.89E-02 | 0.00E-01 |
| MN 54 | 2.03E+00 | 3.25E+01 | 0.00E-01 | 1.06E+01 | 3.16E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 8.55E-08 | 1.54E-05 | 0.00E-01 | 4.82E-07 | 6.12E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 4.95E+00 | 1.22E+01 | 3.08E+01 | 2.12E+01 | 0.00E-01 | 0.00E-01 | 1.19E+01 | 0.00E-01 |
| FE 59 | 4.24E+01 | 3.69E+02 | 4.71E+01 | 1.11E+02 | 0.00E-01 | 0.00E-01 | 3.09E+01 | 0.00E-01 |
| CO 58 | 1.53E+01 | 1.38E+02 | 0.00E-01 | 6.82E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 4.40E+01 | 3.75E+02 | 0.00E-01 | 2.00E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 2.73E+02 | 1.18E+02 | 8.13E+03 | 5.63E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 2.75E-06 | 1.53E-04 | 4.63E-05 | 6.02E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 3.50E-01 | 6.35E+01 | 0.00E-01 | 7.45E-01 | 1.88E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 2.52E+03 | 3.51E+03 | 1.75E+03 | 5.57E+03 | 3.73E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 1.40E-16 | 3.03E-16 | 1.05E-15 | 2.01E-15 | 1.31E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.28E-05 | 1.84E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 5.76E-26 | 4.52E-31 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 4.38E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.55E+03 | 1.08E+03 | 0.00E-01 | 5.48E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 7.66E-27 | 2.00E-37 | 0.00E-01 | 1.44E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 4.53E-27 | 3.74E-40 | 0.00E-01 | 6.44E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 6.42E+01 | 3.59E+02 | 2.24E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.31E+03 | 1.63E+03 | 6.50E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 4.76E-02 | 5.61E+00 | 1.18E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 2.52E-06 | 1.16E-03 | 5.84E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 1.42E-05 | 5.61E+00 | 5.29E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 4.64E-25 | 3.52E-23 | 1.20E-23 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 3.43E-04 | 7.07E+00 | 1.28E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 1.62E-10 | 9.73E-05 | 5.56E-09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 2.38E-07 | 2.73E-01 | 8.61E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 3.01E-04 | 1.41E+00 | 1.39E-03 | 4.45E-04 | 6.98E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 9.68E-07 | 6.56E-01 | 1.05E-05 | 2.12E-06 | 3.20E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 4.17E-02 | 4.71E+02 | 1.39E-01 | 7.76E-02 | 7.67E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 3.43E+01 | 4.18E+02 | 0.00E-01 | 1.80E+02 | 4.08E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 7.34E-03 | 3.41E-01 | 2.04E-04 | 5.76E-04 | 8.74E-03 | 0.00E-01 | 2.82E-04 | 0.00E-01 |
| TC101 | 3.92E-28 | 1.20E-40 | 2.77E-29 | 3.99E-29 | 7.19E-28 | 0.00E-01 | 2.04E-29 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = ANIMAL DRINKING WATER-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 7.18E-04 | 1.94E-01 | 1.67E-03 | 0.00E-01 | 6.36E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 2.69E-08 | 4.16E-05 | 6.80E-08 | 0.00E-01 | 8.79E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 3.24E-03 | 1.65E+00 | 2.56E-02 | 0.00E-01 | 4.94E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 4.08E+01 | 2.80E+04 | 7.42E+01 | 6.87E+01 | 1.35E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 3.27E+00 | 9.75E+01 | 2.44E+01 | 8.85E+00 | 9.93E+01 | 7.34E+00 | 0.00E-01 | 0.00E-01 |
| TE127M | 7.60E+00 | 2.09E+02 | 6.24E+01 | 2.23E+01 | 2.53E+02 | 1.59E+01 | 0.00E-01 | 0.00E-01 |
| TE127 | 5.87E-03 | 2.14E+00 | 2.71E-02 | 9.74E-03 | 1.10E-01 | 2.01E-02 | 0.00E-01 | 0.00E-01 |
| TE129M | 1.63E+01 | 5.18E+02 | 1.03E+02 | 3.84E+01 | 4.29E+02 | 3.53E+01 | 0.00E-01 | 0.00E-01 |
| TE129 | 1.37E-14 | 4.24E-14 | 5.62E-14 | 2.11E-14 | 2.36E-13 | 4.31E-14 | 0.00E-01 | 0.00E-01 |
| TE131M | 2.12E+00 | 2.53E+02 | 5.20E+00 | 2.54E+00 | 2.58E+01 | 4.03E+00 | 0.00E-01 | 0.00E-01 |
| TE131 | 9.67E-29 | 4.34E-29 | 3.06E-28 | 1.28E-28 | 1.34E-27 | 2.52E-28 | 0.00E-01 | 0.00E-01 |
| TE132 | 9.25E+00 | 4.66E+02 | 1.52E+01 | 9.86E+00 | 9.49E+01 | 1.09E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 3.14E+00 | 6.86E+00 | 2.70E+00 | 7.97E+00 | 1.24E+01 | 6.75E+02 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.60E+02 | 7.37E+01 | 1.95E+02 | 2.79E+02 | 4.79E+02 | 9.16E+04 | 0.00E-01 | 0.00E-01 |
| I 132 | 4.12E-06 | 2.21E-06 | 4.40E-06 | 1.18E-05 | 1.88E-05 | 4.12E-04 | 0.00E-01 | 0.00E-01 |
| I 133 | 8.25E+00 | 2.43E+01 | 1.56E+01 | 2.71E+01 | 4.72E+01 | 3.98E+03 | 0.00E-01 | 0.00E-01 |
| I 134 | 8.07E-17 | 1.97E-19 | 8.31E-17 | 2.26E-16 | 3.59E-16 | 3.91E-15 | 0.00E-01 | 0.00E-01 |
| I 135 | 1.39E-01 | 4.25E-01 | 1.44E-01 | 3.76E-01 | 6.04E-01 | 2.48E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.35E+04 | 2.89E+02 | 6.95E+03 | 1.65E+04 | 5.35E+03 | 0.00E-01 | 1.78E+03 | 0.00E-01 |
| CS136 | 1.86E+03 | 2.94E+02 | 6.54E+02 | 2.58E+03 | 1.44E+03 | 0.00E-01 | 1.97E+02 | 0.00E-01 |
| CS137 | 8.00E+03 | 2.36E+02 | 8.92E+03 | 1.22E+04 | 4.14E+03 | 0.00E-01 | 1.38E+03 | 0.00E-01 |
| CS138 | 1.46E-26 | 1.26E-31 | 1.49E-26 | 2.95E-26 | 2.16E-26 | 0.00E-01 | 2.14E-27 | 0.00E-01 |
| BA139 | 2.00E-13 | 1.21E-11 | 6.82E-12 | 4.86E-15 | 4.54E-15 | 0.00E-01 | 2.76E-15 | 0.00E-01 |
| BA140 | 4.45E+00 | 1.40E+02 | 6.78E+01 | 8.52E-02 | 2.90E-02 | 0.00E-01 | 4.88E-02 | 0.00E-01 |
| BA141 | 5.34E-30 | 7.46E-38 | 1.58E-28 | 1.20E-31 | 1.11E-31 | 0.00E-01 | 6.79E-32 | 0.00E-01 |
| BA142 | 8.97E-31 | 0.00E-01 | 1.43E-29 | 1.47E-32 | 1.24E-32 | 0.00E-01 | 8.30E-33 | 0.00E-01 |
| LA140 | 6.69E-06 | 1.86E+00 | 5.02E-05 | 2.53E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 1.80E-16 | 5.26E-12 | 1.59E-15 | 7.21E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 6.42E-04 | 2.16E+01 | 8.36E-03 | 5.66E-03 | 2.63E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 4.52E-05 | 1.53E+01 | 5.53E-04 | 4.09E-01 | 1.80E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 2.43E-02 | 1.53E+02 | 4.53E-01 | 1.90E-01 | 1.12E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.92E-05 | 1.70E+00 | 3.87E-04 | 1.55E-04 | 8.96E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 5.62E-35 | 1.59E-40 | 1.11E-33 | 4.60E-34 | 2.59E-34 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.79E-05 | 1.43E+00 | 2.58E-04 | 2.99E-04 | 1.75E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 3.40E-02 | 3.18E+01 | 1.16E-01 | 9.71E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 1.65E-06 | 6.15E-01 | 3.05E-05 | 3.00E-06 | 9.35E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = ANIMAL DRINKING WATER-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3. | 1.65E+00 | 1.65E+00 | 0.00E-01 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 0.00E-01 |
| C 14 | 4.86E+01 | 4.86E+01 | 2.43E+02 | 4.86E+01 | 4.86E+01 | 4.86E+01 | 4.86E+01 | 0.00E-01 |
| NA 24 | 3.33E-08 | 3.33E-08 | 3.33E-08 | 3.33E-08 | 3.33E-08 | 3.33E-08 | 3.33E-08 | 0.00E-01 |
| P 32 | 3.58E+02 | 1.04E+03 | 9.27E+03 | 5.77E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.07E-02 | 2.68E+00 | 0.00E-01 | 0.00E-01 | 2.35E-03 | 6.37E-03 | 1.42E-02 | 0.00E-01 |
| MN 54 | 1.84E+00 | 2.96E+01 | 0.00E-01 | 9.65E+00 | 2.87E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 3.01E-28 | 5.42E-26 | 0.00E-01 | 1.70E-27 | 2.16E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 4.82E+01 | 1.19E+02 | 2.99E+02 | 2.07E+02 | 0.00E-01 | 0.00E-01 | 1.15E+02 | 0.00E-01 |
| FE 59 | 3.16E+02 | 2.75E+03 | 3.51E+02 | 8.24E+02 | 0.00E-01 | 0.00E-01 | 2.30E+02 | 0.00E-01 |
| CO 58 | 4.93E+01 | 4.45E+02 | 0.00E-01 | 2.20E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.68E+02 | 1.43E+03 | 0.00E-01 | 7.62E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 6.37E+02 | 2.75E+02 | 1.90E+04 | 1.32E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 3.05E-26 | 1.69E-24 | 5.14E-25 | 6.67E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 3.20E-12 | 5.81E-10 | 0.00E-01 | 6.82E-12 | 1.72E-11 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 5.44E+02 | 7.59E+02 | 3.78E+02 | 1.20E+03 | 8.06E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 4.78E-28 | 1.03E-27 | 3.60E-27 | 6.88E-27 | 4.47E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.89E-26 | 2.72E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 8.86E-27 | 6.96E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 6.73E-34 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 4.00E+02 | 1.69E+02 | 0.00E-01 | 8.59E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 2.34E-27 | 6.10E-38 | 0.00E-01 | 4.41E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 1.38E-27 | 1.14E-40 | 0.00E-01 | 1.97E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.11E+01 | 6.21E+01 | 3.87E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 2.89E+02 | 3.62E+02 | 1.44E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 2.06E-16 | 2.42E-14 | 5.09E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 1.04E-27 | 4.78E-25 | 2.41E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 1.82E-05 | 7.18E+00 | 6.77E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 1.69E-31 | 1.28E-29 | 4.37E-30 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 3.77E-02 | 7.77E+02 | 1.41E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 2.26E-30 | 1.35E-24 | 7.73E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 4.07E-18 | 4.67E-12 | 1.47E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 4.99E-01 | 2.33E+03 | 2.30E+00 | 7.37E-01 | 1.16E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 3.89E-11 | 2.63E-05 | 4.21E-10 | 8.50E-11 | 1.28E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 9.69E-01 | 1.09E+04 | 3.24E+00 | 1.80E+00 | 1.78E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 1.15E-01 | 1.40E+00 | 0.00E-01 | 6.06E-01 | 1.37E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 8.45E-24 | 3.93E-22 | 2.35E-25 | 6.64E-25 | 1.01E-23 | 0.00E-01 | 3.25E-25 | 0.00E-01 |
| TC101 | 1.85E-27 | 5.68E-40 | 1.31E-28 | 1.89E-28 | 3.40E-27 | 0.00E-01 | 9.65E-29 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = ANIMAL DRINKING WATER-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 6.18E+01 | 1.67E+04 | 1.43E+02 | 0.00E-01 | 5.47E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 5.03E-26 | 7.79E-23 | 1.27E-25 | 0.00E-01 | 1.65E-24 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 3.70E+02 | 1.89E+05 | 2.92E+03 | 0.00E-01 | 5.64E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 3.90E+00 | 2.68E+03 | 7.10E+00 | 6.57E+00 | 1.29E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 6.01E+01 | 1.79E+03 | 4.48E+02 | 1.62E+02 | 1.82E+03 | 1.35E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.54E+02 | 4.25E+03 | 1.27E+03 | 4.53E+02 | 5.14E+03 | 3.24E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.63E-15 | 5.95E-13 | 7.54E-15 | 2.71E-15 | 3.07E-14 | 5.58E-15 | 0.00E-01 | 0.00E-01 |
| TE129M | 2.56E+02 | 8.13E+03 | 1.62E+03 | 6.03E+02 | 6.74E+03 | 5.55E+02 | 0.00E-01 | 0.00E-01 |
| TE129 | 7.83E-27 | 2.43E-26 | 3.21E-26 | 1.21E-26 | 1.35E-25 | 2.47E-26 | 0.00E-01 | 0.00E-01 |
| TE131M | 2.23E-03 | 2.65E-01 | 5.46E-03 | 2.67E-03 | 2.71E-02 | 4.23E-03 | 0.00E-01 | 0.00E-01 |
| TE131 | 2.20E-27 | 9.87E-28 | 6.97E-27 | 2.91E-27 | 3.06E-26 | 5.73E-27 | 0.00E-01 | 0.00E-01 |
| TE132 | 4.59E+00 | 2.31E+02 | 7.57E+00 | 4.89E+00 | 4.71E+01 | 5.40E+00 | 0.00E-01 | 0.00E-01 |
| I 130 | 1.31E-11 | 2.85E-11 | 1.12E-11 | 3.31E-11 | 5.17E-11 | 2.81E-09 | 0.00E-01 | 0.00E-01 |
| I 131 | 4.85E+00 | 2.23E+00 | 5.91E+00 | 8.46E+00 | 1.45E+01 | 2.77E+03 | 0.00E-01 | 0.00E-01 |
| I 132 | 9.85E-27 | 5.29E-27 | 1.05E-26 | 2.81E-26 | 4.48E-26 | 9.85E-25 | 0.00E-01 | 0.00E-01 |
| I 133 | 6.67E-07 | 1.96E-06 | 1.26E-06 | 2.19E-06 | 3.82E-06 | 3.21E-04 | 0.00E-01 | 0.00E-01 |
| I 134 | 3.27E-27 | 7.97E-30 | 3.36E-27 | 9.14E-27 | 1.45E-26 | 1.58E-25 | 0.00E-01 | 0.00E-01 |
| I 135 | 3.76E-22 | 1.15E-21 | 3.90E-22 | 1.02E-21 | 1.64E-21 | 6.73E-20 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.31E+03 | 2.81E+01 | 6.74E+02 | 1.60E+03 | 5.19E+02 | 0.00E-01 | 1.72E+02 | 0.00E-01 |
| CS136 | 7.08E+01 | 1.12E+01 | 2.49E+01 | 9.83E+01 | 5.47E+01 | 0.00E-01 | 7.50E+00 | 0.00E-01 |
| CS137 | 7.87E+02 | 2.33E+01 | 8.79E+02 | 1.20E+03 | 4.08E+02 | 0.00E-01 | 1.36E+02 | 0.00E-01 |
| CS138 | 1.44E-27 | 1.24E-32 | 1.47E-27 | 2.90E-27 | 2.13E-27 | 0.00E-01 | 2.11E-28 | 0.00E-01 |
| BA139 | 1.33E-28 | 8.04E-27 | 4.53E-27 | 3.23E-30 | 3.02E-30 | 0.00E-01 | 1.83E-30 | 0.00E-01 |
| BA140 | 3.97E+00 | 1.25E+02 | 6.05E+01 | 7.60E-02 | 2.58E-02 | 0.00E-01 | 4.35E-02 | 0.00E-01 |
| BA141 | 1.26E-29 | 1.76E-37 | 3.74E-28 | 2.83E-31 | 2.63E-31 | 0.00E-01 | 1.61E-31 | 0.00E-01 |
| BA142 | 2.12E-30 | 0.00E-01 | 3.37E-29 | 3.47E-32 | 2.93E-32 | 0.00E-01 | 1.96E-32 | 0.00E-01 |
| LA140 | 4.67E-08 | 1.30E-02 | 3.51E-07 | 1.77E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 4.47E-32 | 1.31E-27 | 3.94E-31 | 1.79E-31 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 1.55E-03 | 5.23E+01 | 2.02E-02 | 1.37E-02 | 6.35E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 1.91E-08 | 6.45E-03 | 2.34E-07 | 1.73E-04 | 7.60E-08 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 8.26E-02 | 5.20E+02 | 1.54E+00 | 6.43E-01 | 3.82E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 2.13E-03 | 1.88E+02 | 4.30E-02 | 1.72E-02 | 9.95E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 1.56E-32 | 4.42E-38 | 3.08E-31 | 1.28E-31 | 7.20E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.13E-03 | 9.09E+01 | 1.64E-02 | 1.89E-02 | 1.11E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 9.54E-08 | 8.94E-05 | 3.26E-07 | 2.73E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 9.88E-08 | 3.67E-02 | 1.82E-06 | 1.79E-07 | 5.59E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = RIVER SHORELINE DEPOSITS

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 1.88E+00 | 1.88E+00 | 1.88E+00 | 1.88E+00 | 1.88E+00 | 1.88E+00 | 1.88E+00 | 2.18E+00 |
| P 32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 7.33E-01 | 7.33E-01 | 7.33E-01 | 7.33E-01 | 7.33E-01 | 7.33E-01 | 7.33E-01 | 8.66E-01 |
| MN 54 | 2.18E+02 | 2.18E+02 | 2.18E+02 | 2.18E+02 | 2.18E+02 | 2.18E+02 | 2.18E+02 | 2.56E+02 |
| MN 56 | 1.38E-01 | 1.38E-01 | 1.38E-01 | 1.38E-01 | 1.38E-01 | 1.38E-01 | 1.38E-01 | 1.63E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 4.29E+01 | 4.29E+01 | 4.29E+01 | 4.29E+01 | 4.29E+01 | 4.29E+01 | 4.29E+01 | 5.04E+01 |
| CO 58 | 5.98E+01 | 5.98E+01 | 5.98E+01 | 5.98E+01 | 5.98E+01 | 5.98E+01 | 5.98E+01 | 7.01E+01 |
| CO 60 | 3.38E+03 | 3.38E+03 | 3.38E+03 | 3.38E+03 | 3.38E+03 | 3.38E+03 | 3.38E+03 | 3.98E+03 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 4.55E-02 | 4.55E-02 | 4.55E-02 | 4.55E-02 | 4.55E-02 | 4.55E-02 | 4.55E-02 | 5.29E-02 |
| CU 64 | 9.48E-02 | 9.48E-02 | 9.48E-02 | 9.48E-02 | 9.48E-02 | 9.48E-02 | 9.48E-02 | 1.07E-01 |
| ZN 65 | 1.17E+02 | 1.17E+02 | 1.17E+02 | 1.17E+02 | 1.17E+02 | 1.17E+02 | 1.17E+02 | 1.35E+02 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 7.46E-04 | 7.46E-04 | 7.46E-04 | 7.46E-04 | 7.46E-04 | 7.46E-04 | 7.46E-04 | 1.08E-03 |
| BR 84 | 2.80E-02 | 2.80E-02 | 2.80E-02 | 2.80E-02 | 2.80E-02 | 2.80E-02 | 2.80E-02 | 3.27E-02 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 1.42E+00 | 1.42E+00 | 1.42E+00 | 1.42E+00 | 1.42E+00 | 1.42E+00 | 1.42E+00 | 1.62E+00 |
| RB 88 | 4.14E-03 | 4.14E-03 | 4.14E-03 | 4.14E-03 | 4.14E-03 | 4.14E-03 | 4.14E-03 | 4.73E-03 |
| RB 89 | 1.46E-02 | 1.46E-02 | 1.46E-02 | 1.46E-02 | 1.46E-02 | 1.46E-02 | 1.46E-02 | 1.75E-02 |
| SR 89 | 3.40E-03 | 3.40E-03 | 3.40E-03 | 3.40E-03 | 3.40E-03 | 3.40E-03 | 3.40E-03 | 3.95E-03 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 3.35E-01 | 3.35E-01 | 3.35E-01 | 3.35E-01 | 3.35E-01 | 3.35E-01 | 3.35E-01 | 3.92E-01 |
| SR 92 | 1.19E-01 | 1.19E-01 | 1.19E-01 | 1.19E-01 | 1.19E-01 | 1.19E-01 | 1.19E-01 | 1.33E-01 |
| Y 90 | 7.08E-04 | 7.08E-04 | 7.08E-04 | 7.08E-04 | 7.08E-04 | 7.08E-04 | 7.08E-04 | 8.36E-04 |
| Y 91M | 1.45E-02 | 1.45E-02 | 1.45E-02 | 1.45E-02 | 1.45E-02 | 1.45E-02 | 1.45E-02 | 1.68E-02 |
| Y 91 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.90E-01 |
| Y 92 | 2.80E-02 | 2.80E-02 | 2.80E-02 | 2.80E-02 | 2.80E-02 | 2.80E-02 | 2.80E-02 | 3.32E-02 |
| Y 93 | 2.86E-02 | 2.86E-02 | 2.86E-02 | 2.86E-02 | 2.86E-02 | 2.86E-02 | 2.86E-02 | 3.92E-02 |
| ZR 95 | 3.86E+01 | 3.86E+01 | 3.86E+01 | 3.86E+01 | 3.86E+01 | 3.86E+01 | 3.86E+01 | 4.48E+01 |
| ZR 97 | 4.64E-01 | 4.64E-01 | 4.64E-01 | 4.64E-01 | 4.64E-01 | 4.64E-01 | 4.64E-01 | 5.40E-01 |
| NB 95 | 2.16E+01 | 2.16E+01 | 2.16E+01 | 2.16E+01 | 2.16E+01 | 2.16E+01 | 2.16E+01 | 2.54E+01 |
| MO 99 | 6.28E-01 | 6.28E-01 | 6.28E-01 | 6.28E-01 | 6.28E-01 | 6.28E-01 | 6.28E-01 | 7.27E-01 |
| TC 99M | 2.87E-02 | 2.87E-02 | 2.87E-02 | 2.87E-02 | 2.87E-02 | 2.87E-02 | 2.87E-02 | 3.28E-02 |
| TC101 | 2.39E-03 | 2.39E-03 | 2.39E-03 | 2.39E-03 | 2.39E-03 | 2.39E-03 | 2.39E-03 | 2.66E-03 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT

PATHWAY = RIVER SHORELINE DEPOSITS

| | TOTAL | BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|----------|----------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.70E+01 | 1.70E+01 | 1.70E+01 | 1.70E+01 | 1.70E+01 | 1.70E+01 | 1.70E+01 | 1.70E+01 | 1.99E+01 |
| RU105 | 9.86E-02 | 9.86E-02 | 9.86E-02 | 9.86E-02 | 9.86E-02 | 9.86E-02 | 9.86E-02 | 9.86E-02 | 1.12E-01 |
| RU106 | 6.65E+01 | 6.65E+01 | 6.65E+01 | 6.65E+01 | 6.65E+01 | 6.65E+01 | 6.65E+01 | 6.65E+01 | 7.97E+01 |
| AG110M | 5.43E+02 | 5.43E+02 | 5.43E+02 | 5.43E+02 | 5.43E+02 | 5.43E+02 | 5.43E+02 | 5.43E+02 | 6.34E+02 |
| TE125M | 2.45E-01 | 2.45E-01 | 2.45E-01 | 2.45E-01 | 2.45E-01 | 2.45E-01 | 2.45E-01 | 2.45E-01 | 3.36E-01 |
| TE127M | 1.44E-02 | 1.44E-02 | 1.44E-02 | 1.44E-02 | 1.44E-02 | 1.44E-02 | 1.44E-02 | 1.44E-02 | 1.71E-02 |
| TE127 | 4.65E-04 | 4.65E-04 | 4.65E-04 | 4.65E-04 | 4.65E-04 | 4.65E-04 | 4.65E-04 | 4.65E-04 | 5.12E-04 |
| TE129M | 3.11E+00 | 3.11E+00 | 3.11E+00 | 3.11E+00 | 3.11E+00 | 3.11E+00 | 3.11E+00 | 3.11E+00 | 3.64E+00 |
| TE129 | 3.89E-03 | 3.89E-03 | 3.89E-03 | 3.89E-03 | 3.89E-03 | 3.89E-03 | 3.89E-03 | 3.89E-03 | 4.60E-03 |
| TE131M | 1.26E+00 | 1.26E+00 | 1.26E+00 | 1.26E+00 | 1.26E+00 | 1.26E+00 | 1.26E+00 | 1.26E+00 | 1.49E+00 |
| TE131 | 3.90E-03 | 3.90E-03 | 3.90E-03 | 3.90E-03 | 3.90E-03 | 3.90E-03 | 3.90E-03 | 3.90E-03 | 4.61E+00 |
| TE132 | 6.67E-01 | 6.67E-01 | 6.67E-01 | 6.67E-01 | 6.67E-01 | 6.67E-01 | 6.67E-01 | 6.67E-01 | 7.85E-01 |
| I 130 | 8.62E-01 | 8.62E-01 | 8.62E-01 | 8.62E-01 | 8.62E-01 | 8.62E-01 | 8.62E-01 | 8.62E-01 | 1.05E+00 |
| I 131 | 2.71E+00 | 2.71E+00 | 2.71E+00 | 2.71E+00 | 2.71E+00 | 2.71E+00 | 2.71E+00 | 2.71E+00 | 3.29E+00 |
| I 132 | 1.90E-01 | 1.90E-01 | 1.90E-01 | 1.90E-01 | 1.90E-01 | 1.90E-01 | 1.90E-01 | 1.90E-01 | 2.24E-01 |
| I 133 | 3.85E-01 | 3.85E-01 | 3.85E-01 | 3.85E-01 | 3.85E-01 | 3.85E-01 | 3.85E-01 | 3.85E-01 | 4.68E-01 |
| I 134 | 6.49E-02 | 6.49E-02 | 6.49E-02 | 6.49E-02 | 6.49E-02 | 6.49E-02 | 6.49E-02 | 6.49E-02 | 7.71E-02 |
| I 135 | 3.93E-01 | 3.93E-01 | 3.93E-01 | 3.93E-01 | 3.93E-01 | 3.93E-01 | 3.93E-01 | 3.93E-01 | 4.58E-01 |
| CS134 | 1.08E+03 | 1.08E+03 | 1.08E+03 | 1.08E+03 | 1.08E+03 | 1.08E+03 | 1.08E+03 | 1.08E+03 | 1.26E+03 |
| CS136 | 2.37E+01 | 2.37E+01 | 2.37E+01 | 2.37E+01 | 2.37E+01 | 2.37E+01 | 2.37E+01 | 2.37E+01 | 2.68E+01 |
| CS137 | 1.62E+03 | 1.62E+03 | 1.62E+03 | 1.62E+03 | 1.62E+03 | 1.62E+03 | 1.62E+03 | 1.62E+03 | 1.89E+03 |
| CS138 | 4.98E-02 | 4.98E-02 | 4.98E-02 | 4.98E-02 | 4.98E-02 | 4.98E-02 | 4.98E-02 | 4.98E-02 | 5.69E-02 |
| BA139 | 1.58E-02 | 1.58E-02 | 1.58E-02 | 1.58E-02 | 1.58E-02 | 1.58E-02 | 1.58E-02 | 1.58E-02 | 1.77E-02 |
| BA140 | 3.23E+00 | 3.23E+00 | 3.23E+00 | 3.23E+00 | 3.23E+00 | 3.23E+00 | 3.23E+00 | 3.23E+00 | 3.70E+00 |
| BA141 | 5.24E-03 | 5.24E-03 | 5.24E-03 | 5.24E-03 | 5.24E-03 | 5.24E-03 | 5.24E-03 | 5.24E-03 | 5.97E-03 |
| BA142 | 4.79E-03 | 4.79E-03 | 4.79E-03 | 4.79E-03 | 4.79E-03 | 4.79E-03 | 4.79E-03 | 4.79E-03 | 5.46E-03 |
| LA140 | 3.03E+00 | 3.03E+00 | 3.03E+00 | 3.03E+00 | 3.03E+00 | 3.03E+00 | 3.03E+00 | 3.03E+00 | 3.43E+00 |
| LA142 | 1.11E-01 | 1.11E-01 | 1.11E-01 | 1.11E-01 | 1.11E-01 | 1.11E-01 | 1.11E-01 | 1.11E-01 | 1.33E-01 |
| CE141 | 2.15E+00 | 2.15E+00 | 2.15E+00 | 2.15E+00 | 2.15E+00 | 2.15E+00 | 2.15E+00 | 2.15E+00 | 2.42E+00 |
| CE143 | 3.65E-01 | 3.65E-01 | 3.65E-01 | 3.65E-01 | 3.65E-01 | 3.65E-01 | 3.65E-01 | 3.65E-01 | 4.15E-01 |
| CE144 | 1.10E+01 | 1.10E+01 | 1.10E+01 | 1.10E+01 | 1.10E+01 | 1.10E+01 | 1.10E+01 | 1.10E+01 | 1.27E+01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 2.27E-04 | 2.27E-04 | 2.27E-04 | 2.27E-04 | 2.27E-04 | 2.27E-04 | 2.27E-04 | 2.27E-04 | 2.61E-04 |
| ND147 | 1.34E+00 | 1.34E+00 | 1.34E+00 | 1.34E+00 | 1.34E+00 | 1.34E+00 | 1.34E+00 | 1.34E+00 | 1.60E+00 |
| W 187 | 3.71E-01 | 3.71E-01 | 3.71E-01 | 3.71E-01 | 3.71E-01 | 3.71E-01 | 3.71E-01 | 3.71E-01 | 4.31E-01 |
| NP239 | 2.70E-01 | 2.70E-01 | 2.70E-01 | 2.70E-01 | 2.70E-01 | 2.70E-01 | 2.70E-01 | 2.70E-01 | 3.12E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT
 PATHWAY = SWIMMING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 3.12E+01 | 3.12E+01 | 3.12E+01 | 3.12E+01 | 3.12E+01 | 3.12E+01 | 3.12E+01 | 0.00E-01 |
| P 32 | 2.57E-02 | 2.57E-02 | 2.57E-02 | 2.57E-02 | 2.57E-02 | 2.57E-02 | 2.57E-02 | 0.00E-01 |
| CR 51 | 2.09E-01 | 2.09E-01 | 2.09E-01 | 2.09E-01 | 2.09E-01 | 2.09E-01 | 2.09E-01 | 0.00E-01 |
| MN 54 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 0.00E-01 |
| MN 56 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 0.00E-01 |
| FE 55 | 2.57E-04 | 2.57E-04 | 2.57E-04 | 2.57E-04 | 2.57E-04 | 2.57E-04 | 2.57E-04 | 0.00E-01 |
| FE 59 | 8.83E+00 | 8.83E+00 | 8.83E+00 | 8.83E+00 | 8.83E+00 | 8.83E+00 | 8.83E+00 | 0.00E-01 |
| CO 58 | 7.23E+00 | 7.23E+00 | 7.23E+00 | 7.23E+00 | 7.23E+00 | 7.23E+00 | 7.23E+00 | 0.00E-01 |
| CO 60 | 1.85E+01 | 1.85E+01 | 1.85E+01 | 1.85E+01 | 1.85E+01 | 1.85E+01 | 1.85E+01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 3.90E+00 | 3.90E+00 | 3.90E+00 | 3.90E+00 | 3.90E+00 | 3.90E+00 | 3.90E+00 | 0.00E-01 |
| CU 64 | 1.48E+00 | 1.48E+00 | 1.48E+00 | 1.48E+00 | 1.48E+00 | 1.48E+00 | 1.48E+00 | 0.00E-01 |
| ZN 65 | 4.42E+00 | 4.42E+00 | 4.42E+00 | 4.42E+00 | 4.42E+00 | 4.42E+00 | 4.42E+00 | 0.00E-01 |
| ZN 69 | 5.97E-03 | 5.97E-03 | 5.97E-03 | 5.97E-03 | 5.97E-03 | 5.97E-03 | 5.97E-03 | 0.00E-01 |
| BR 83 | 6.63E-02 | 6.63E-02 | 6.63E-02 | 6.63E-02 | 6.63E-02 | 6.63E-02 | 6.63E-02 | 0.00E-01 |
| BR 84 | 1.23E+01 | 1.23E+01 | 1.23E+01 | 1.23E+01 | 1.23E+01 | 1.23E+01 | 1.23E+01 | 0.00E-01 |
| BR 85 | 1.32E-02 | 1.32E-02 | 1.32E-02 | 1.32E-02 | 1.32E-02 | 1.32E-02 | 1.32E-02 | 0.00E-01 |
| RB 86 | 6.82E-01 | 6.82E-01 | 6.82E-01 | 6.82E-01 | 6.82E-01 | 6.82E-01 | 6.82E-01 | 0.00E-01 |
| RB 88 | 3.82E+00 | 3.82E+00 | 3.82E+00 | 3.82E+00 | 3.82E+00 | 3.82E+00 | 3.82E+00 | 0.00E-01 |
| RB 89 | 1.38E+01 | 1.38E+01 | 1.38E+01 | 1.38E+01 | 1.38E+01 | 1.38E+01 | 1.38E+01 | 0.00E-01 |
| SR 89 | 1.85E-02 | 1.85E-02 | 1.85E-02 | 1.85E-02 | 1.85E-02 | 1.85E-02 | 1.85E-02 | 0.00E-01 |
| SR 90 | 2.17E-03 | 2.17E-03 | 2.17E-03 | 2.17E-03 | 2.17E-03 | 2.17E-03 | 2.17E-03 | 0.00E-01 |
| SR 91 | 7.57E+00 | 7.57E+00 | 7.57E+00 | 7.57E+00 | 7.57E+00 | 7.57E+00 | 7.57E+00 | 0.00E-01 |
| SR 92 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 0.00E-01 |
| Y 90 | 5.21E-02 | 5.21E-02 | 5.21E-02 | 5.21E-02 | 5.21E-02 | 5.21E-02 | 5.21E-02 | 0.00E-01 |
| Y 91M | 3.69E+00 | 3.69E+00 | 3.69E+00 | 3.69E+00 | 3.69E+00 | 3.69E+00 | 3.69E+00 | 0.00E-01 |
| Y 91 | 2.69E-02 | 2.69E-02 | 2.69E-02 | 2.69E-02 | 2.69E-02 | 2.69E-02 | 2.69E-02 | 0.00E-01 |
| Y 92 | 1.81E+00 | 1.81E+00 | 1.81E+00 | 1.81E+00 | 1.81E+00 | 1.81E+00 | 1.81E+00 | 0.00E-01 |
| Y 93 | 7.57E-01 | 7.57E-01 | 7.57E-01 | 7.57E-01 | 7.57E-01 | 7.57E-01 | 7.57E-01 | 0.00E-01 |
| ZR 95 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 0.00E-01 |
| ZR 97 | 6.00E+00 | 6.00E+00 | 6.00E+00 | 6.00E+00 | 6.00E+00 | 6.00E+00 | 6.00E+00 | 0.00E-01 |
| NB 95 | 5.62E+00 | 5.62E+00 | 5.62E+00 | 5.62E+00 | 5.62E+00 | 5.62E+00 | 5.62E+00 | 0.00E-01 |
| MO 99 | 1.88E+00 | 1.88E+00 | 1.88E+00 | 1.88E+00 | 1.88E+00 | 1.88E+00 | 1.88E+00 | 0.00E-01 |
| TC 99M | 9.52E-01 | 9.52E-01 | 9.52E-01 | 9.52E-01 | 9.52E-01 | 9.52E-01 | 9.52E-01 | 0.00E-01 |
| TC101 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT
PATHWAY = SWIMMING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 3.57E+00 | 3.57E+00 | 3.57E+00 | 3.57E+00 | 3.57E+00 | 3.57E+00 | 3.57E+00 | 0.00E-01 |
| RU105 | 4.74E+00 | 4.74E+00 | 4.74E+00 | 4.74E+00 | 4.74E+00 | 4.74E+00 | 4.74E+00 | 0.00E-01 |
| RU106 | 1.52E+00 | 1.52E+00 | 1.52E+00 | 1.52E+00 | 1.52E+00 | 1.52E+00 | 1.52E+00 | 0.00E-01 |
| AG110M | 1.97E+01 | 1.97E+01 | 1.97E+01 | 1.97E+01 | 1.97E+01 | 1.97E+01 | 1.97E+01 | 0.00E-01 |
| TE125M | 1.48E-02 | 1.48E-02 | 1.48E-02 | 1.48E-02 | 1.48E-02 | 1.48E-02 | 1.48E-02 | 0.00E-01 |
| TE127M | 1.04E-03 | 1.04E-03 | 1.04E-03 | 1.04E-03 | 1.04E-03 | 1.04E-03 | 1.04E-03 | 0.00E-01 |
| TE127 | 1.12E-02 | 1.12E-02 | 1.12E-02 | 1.12E-02 | 1.12E-02 | 1.12E-02 | 1.12E-02 | 0.00E-01 |
| TE129M | 8.43E-01 | 8.43E-01 | 8.43E-01 | 8.43E-01 | 8.43E-01 | 8.43E-01 | 8.43E-01 | 0.00E-01 |
| TE129 | 7.19E-01 | 7.19E-01 | 7.19E-01 | 7.19E-01 | 7.19E-01 | 7.19E-01 | 7.19E-01 | 0.00E-01 |
| TE131M | 8.81E+00 | 8.81E+00 | 8.81E+00 | 8.81E+00 | 8.81E+00 | 8.81E+00 | 8.81E+00 | 0.00E-01 |
| TE131 | 2.52E+00 | 2.52E+00 | 2.52E+00 | 2.52E+00 | 2.52E+00 | 2.52E+00 | 2.52E+00 | 0.00E-01 |
| TE132 | 1.60E+00 | 1.60E+00 | 1.60E+00 | 1.60E+00 | 1.60E+00 | 1.60E+00 | 1.60E+00 | 0.00E-01 |
| I 130 | 1.56E+01 | 1.56E+01 | 1.56E+01 | 1.56E+01 | 1.56E+01 | 1.56E+01 | 1.56E+01 | 0.00E-01 |
| I 131 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 0.00E-01 |
| I 132 | 1.71E+01 | 1.71E+01 | 1.71E+01 | 1.71E+01 | 1.71E+01 | 1.71E+01 | 1.71E+01 | 0.00E-01 |
| I 133 | 3.84E+00 | 3.84E+00 | 3.84E+00 | 3.84E+00 | 3.84E+00 | 3.84E+00 | 3.84E+00 | 0.00E-01 |
| I 134 | 1.56E+01 | 1.56E+01 | 1.56E+01 | 1.56E+01 | 1.56E+01 | 1.56E+01 | 1.56E+01 | 0.00E-01 |
| I 135 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 0.00E-01 |
| CS134 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 0.00E-01 |
| CS136 | 1.65E+01 | 1.65E+01 | 1.65E+01 | 1.65E+01 | 1.65E+01 | 1.65E+01 | 1.65E+01 | 0.00E-01 |
| CS137 | 4.01E+00 | 4.01E+00 | 4.01E+00 | 4.01E+00 | 4.01E+00 | 4.01E+00 | 4.01E+00 | 0.00E-01 |
| CS138 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 0.00E-01 |
| BA139 | 2.94E-01 | 2.94E-01 | 2.94E-01 | 2.94E-01 | 2.94E-01 | 2.94E-01 | 2.94E-01 | 0.00E-01 |
| BA140 | 1.97E+00 | 1.97E+00 | 1.97E+00 | 1.97E+00 | 1.97E+00 | 1.97E+00 | 1.97E+00 | 0.00E-01 |
| BA141 | 3.52E+00 | 3.52E+00 | 3.52E+00 | 3.52E+00 | 3.52E+00 | 3.52E+00 | 3.52E+00 | 0.00E-01 |
| BA142 | 5.99E+00 | 5.99E+00 | 5.99E+00 | 5.99E+00 | 5.99E+00 | 5.99E+00 | 5.99E+00 | 0.00E-01 |
| LA140 | 1.64E+01 | 1.64E+01 | 1.64E+01 | 1.64E+01 | 1.64E+01 | 1.64E+01 | 1.64E+01 | 0.00E-01 |
| LA142 | 1.73E+01 | 1.73E+01 | 1.73E+01 | 1.73E+01 | 1.73E+01 | 1.73E+01 | 1.73E+01 | 0.00E-01 |
| CE141 | 5.22E-01 | 5.22E-01 | 5.22E-01 | 5.22E-01 | 5.22E-01 | 5.22E-01 | 5.22E-01 | 0.00E-01 |
| CE143 | 2.28E+00 | 2.28E+00 | 2.28E+00 | 2.28E+00 | 2.28E+00 | 2.28E+00 | 2.28E+00 | 0.00E-01 |
| CE144 | 3.45E-01 | 3.45E-01 | 3.45E-01 | 3.45E-01 | 3.45E-01 | 3.45E-01 | 3.45E-01 | 0.00E-01 |
| PR143 | 6.42E-03 | 6.42E-03 | 6.42E-03 | 6.42E-03 | 6.42E-03 | 6.42E-03 | 6.42E-03 | 0.00E-01 |
| PR144 | 1.77E-01 | 1.77E-01 | 1.77E-01 | 1.77E-01 | 1.77E-01 | 1.77E-01 | 1.77E-01 | 0.00E-01 |
| ND147 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 0.00E-01 |
| W 187 | 3.32E+00 | 3.32E+00 | 3.32E+00 | 3.32E+00 | 3.32E+00 | 3.32E+00 | 3.32E+00 | 0.00E-01 |
| NP239 | 9.62E-01 | 9.62E-01 | 9.62E-01 | 9.62E-01 | 9.62E-01 | 9.62E-01 | 9.62E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT
PATHWAY = BOATING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 5.65E+01 | 5.65E+01 | 5.65E+01 | 5.65E+01 | 5.65E+01 | 5.65E+01 | 5.65E+01 | 0.00E-01 |
| P 32 | 4.66E-02 | 4.66E-02 | 4.66E-02 | 4.66E-02 | 4.66E-02 | 4.66E-02 | 4.66E-02 | 0.00E-01 |
| CR 51 | 3.78E-01 | 3.78E-01 | 3.78E-01 | 3.78E-01 | 3.78E-01 | 3.78E-01 | 3.78E-01 | 0.00E-01 |
| MN 54 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 0.00E-01 |
| MN 56 | 2.27E+01 | 2.27E+01 | 2.27E+01 | 2.27E+01 | 2.27E+01 | 2.27E+01 | 2.27E+01 | 0.00E-01 |
| FE 55 | 4.66E-04 | 4.66E-04 | 4.66E-04 | 4.66E-04 | 4.66E-04 | 4.66E-04 | 4.66E-04 | 0.00E-01 |
| FE 59 | 1.60E+01 | 1.60E+01 | 1.60E+01 | 1.60E+01 | 1.60E+01 | 1.60E+01 | 1.60E+01 | 0.00E-01 |
| CO 58 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 0.00E-01 |
| CO 60 | 3.35E+01 | 3.35E+01 | 3.35E+01 | 3.35E+01 | 3.35E+01 | 3.35E+01 | 3.35E+01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 7.08E+00 | 7.08E+00 | 7.08E+00 | 7.08E+00 | 7.08E+00 | 7.08E+00 | 7.08E+00 | 0.00E-01 |
| CU 64 | 2.68E+00 | 2.68E+00 | 2.68E+00 | 2.68E+00 | 2.68E+00 | 2.68E+00 | 2.68E+00 | 0.00E-01 |
| ZN 65 | 8.00E+00 | 8.00E+00 | 8.00E+00 | 8.00E+00 | 8.00E+00 | 8.00E+00 | 8.00E+00 | 0.00E-01 |
| ZN 69 | 1.08E-02 | 1.08E-02 | 1.08E-02 | 1.08E-02 | 1.08E-02 | 1.08E-02 | 1.08E-02 | 0.00E-01 |
| BR 83 | 1.20E-01 | 1.20E-01 | 1.20E-01 | 1.20E-01 | 1.20E-01 | 1.20E-01 | 1.20E-01 | 0.00E-01 |
| BR 84 | 2.24E+01 | 2.24E+01 | 2.24E+01 | 2.24E+01 | 2.24E+01 | 2.24E+01 | 2.24E+01 | 0.00E-01 |
| BR 85 | 2.39E-02 | 2.39E-02 | 2.39E-02 | 2.39E-02 | 2.39E-02 | 2.39E-02 | 2.39E-02 | 0.00E-01 |
| RB 86 | 1.24E+00 | 1.24E+00 | 1.24E+00 | 1.24E+00 | 1.24E+00 | 1.24E+00 | 1.24E+00 | 0.00E-01 |
| RB 88 | 6.92E+00 | 6.92E+00 | 6.92E+00 | 6.92E+00 | 6.92E+00 | 6.92E+00 | 6.92E+00 | 0.00E-01 |
| RB 89 | 2.49E+01 | 2.49E+01 | 2.49E+01 | 2.49E+01 | 2.49E+01 | 2.49E+01 | 2.49E+01 | 0.00E-01 |
| SR 89 | 3.35E-02 | 3.35E-02 | 3.35E-02 | 3.35E-02 | 3.35E-02 | 3.35E-02 | 3.35E-02 | 0.00E-01 |
| SR 90 | 3.93E-03 | 3.93E-03 | 3.93E-03 | 3.93E-03 | 3.93E-03 | 3.93E-03 | 3.93E-03 | 0.00E-01 |
| SR 91 | 1.37E+01 | 1.37E+01 | 1.37E+01 | 1.37E+01 | 1.37E+01 | 1.37E+01 | 1.37E+01 | 0.00E-01 |
| SR 92 | 1.84E+01 | 1.84E+01 | 1.84E+01 | 1.84E+01 | 1.84E+01 | 1.84E+01 | 1.84E+01 | 0.00E-01 |
| Y 90 | 9.45E-02 | 9.45E-02 | 9.45E-02 | 9.45E-02 | 9.45E-02 | 9.45E-02 | 9.45E-02 | 0.00E-01 |
| Y 91M | 6.69E+00 | 6.69E+00 | 6.69E+00 | 6.69E+00 | 6.69E+00 | 6.69E+00 | 6.69E+00 | 0.00E-01 |
| Y 91 | 4.87E-02 | 4.87E-02 | 4.87E-02 | 4.87E-02 | 4.87E-02 | 4.87E-02 | 4.87E-02 | 0.00E-01 |
| Y 92 | 3.28E+00 | 3.28E+00 | 3.28E+00 | 3.28E+00 | 3.28E+00 | 3.28E+00 | 3.28E+00 | 0.00E-01 |
| Y 93 | 1.37E+00 | 1.37E+00 | 1.37E+00 | 1.37E+00 | 1.37E+00 | 1.37E+00 | 1.37E+00 | 0.00E-01 |
| ZR 95 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 0.00E-01 |
| ZR 97 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 0.00E-01 |
| NB 95 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 0.00E-01 |
| MO 99 | 3.42E+00 | 3.42E+00 | 3.42E+00 | 3.42E+00 | 3.42E+00 | 3.42E+00 | 3.42E+00 | 0.00E-01 |
| TC 99M | 1.73E+00 | 1.73E+00 | 1.73E+00 | 1.73E+00 | 1.73E+00 | 1.73E+00 | 1.73E+00 | 0.00E-01 |
| TC101 | 3.69E+00 | 3.69E+00 | 3.69E+00 | 3.69E+00 | 3.69E+00 | 3.69E+00 | 3.69E+00 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = ADULT
PATHWAY = BOATING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 6.47E+00 | 6.47E+00 | 6.47E+00 | 6.47E+00 | 6.47E+00 | 6.47E+00 | 6.47E+00 | 0.00E-01 |
| RU105 | 8.60E+00 | 8.60E+00 | 8.60E+00 | 8.60E+00 | 8.60E+00 | 8.60E+00 | 8.60E+00 | 0.00E-01 |
| RU106 | 2.77E+00 | 2.77E+00 | 2.77E+00 | 2.77E+00 | 2.77E+00 | 2.77E+00 | 2.77E+00 | 0.00E-01 |
| AG110M | 3.57E+01 | 3.57E+01 | 3.57E+01 | 3.57E+01 | 3.57E+01 | 3.57E+01 | 3.57E+01 | 0.00E-01 |
| TE125M | 2.69E-02 | 2.69E-02 | 2.69E-02 | 2.69E-02 | 2.69E-02 | 2.69E-02 | 2.69E-02 | 0.00E-01 |
| TE127M | 1.89E-03 | 1.89E-03 | 1.89E-03 | 1.89E-03 | 1.89E-03 | 1.89E-03 | 1.89E-03 | 0.00E-01 |
| TE127 | 2.02E-02 | 2.02E-02 | 2.02E-02 | 2.02E-02 | 2.02E-02 | 2.02E-02 | 2.02E-02 | 0.00E-01 |
| TE129M | 1.53E+00 | 1.53E+00 | 1.53E+00 | 1.53E+00 | 1.53E+00 | 1.53E+00 | 1.53E+00 | 0.00E-01 |
| TE129 | 1.30E+00 | 1.30E+00 | 1.30E+00 | 1.30E+00 | 1.30E+00 | 1.30E+00 | 1.30E+00 | 0.00E-01 |
| TE131M | 1.60E+01 | 1.60E+01 | 1.60E+01 | 1.60E+01 | 1.60E+01 | 1.60E+01 | 1.60E+01 | 0.00E-01 |
| TE131 | 4.56E+00 | 4.56E+00 | 4.56E+00 | 4.56E+00 | 4.56E+00 | 4.56E+00 | 4.56E+00 | 0.00E-01 |
| TE132 | 2.91E+00 | 2.91E+00 | 2.91E+00 | 2.91E+00 | 2.91E+00 | 2.91E+00 | 2.91E+00 | 0.00E-01 |
| I 130 | 2.82E+01 | 2.82E+01 | 2.82E+01 | 2.82E+01 | 2.82E+01 | 2.82E+01 | 2.82E+01 | 0.00E-01 |
| I 131 | 5.67E+00 | 5.67E+00 | 5.67E+00 | 5.67E+00 | 5.67E+00 | 5.67E+00 | 5.67E+00 | 0.00E-01 |
| I 132 | 3.11E+01 | 3.11E+01 | 3.11E+01 | 3.11E+01 | 3.11E+01 | 3.11E+01 | 3.11E+01 | 0.00E-01 |
| I 133 | 6.96E+00 | 6.96E+00 | 6.96E+00 | 6.96E+00 | 6.96E+00 | 6.96E+00 | 6.96E+00 | 0.00E-01 |
| I 134 | 2.82E+01 | 2.82E+01 | 2.82E+01 | 2.82E+01 | 2.82E+01 | 2.82E+01 | 2.82E+01 | 0.00E-01 |
| I 135 | 2.38E+01 | 2.38E+01 | 2.38E+01 | 2.38E+01 | 2.38E+01 | 2.38E+01 | 2.38E+01 | 0.00E-01 |
| CS134 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 0.00E-01 |
| CS136 | 2.98E+01 | 2.98E+01 | 2.98E+01 | 2.98E+01 | 2.98E+01 | 2.98E+01 | 2.98E+01 | 0.00E-01 |
| CS137 | 7.28E+00 | 7.28E+00 | 7.28E+00 | 7.28E+00 | 7.28E+00 | 7.28E+00 | 7.28E+00 | 0.00E-01 |
| CS138 | 2.56E+01 | 2.56E+01 | 2.56E+01 | 2.56E+01 | 2.56E+01 | 2.56E+01 | 2.56E+01 | 0.00E-01 |
| BA139 | 5.33E-01 | 5.33E-01 | 5.33E-01 | 5.33E-01 | 5.33E-01 | 5.33E-01 | 5.33E-01 | 0.00E-01 |
| BA140 | 3.56E+00 | 3.56E+00 | 3.56E+00 | 3.56E+00 | 3.56E+00 | 3.56E+00 | 3.56E+00 | 0.00E-01 |
| BA141 | 6.37E+00 | 6.37E+00 | 6.37E+00 | 6.37E+00 | 6.37E+00 | 6.37E+00 | 6.37E+00 | 0.00E-01 |
| BA142 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 1.09E+01 | 0.00E-01 |
| LA140 | 2.98E+01 | 2.98E+01 | 2.98E+01 | 2.98E+01 | 2.98E+01 | 2.98E+01 | 2.98E+01 | 0.00E-01 |
| LA142 | 3.13E+01 | 3.13E+01 | 3.13E+01 | 3.13E+01 | 3.13E+01 | 3.13E+01 | 3.13E+01 | 0.00E-01 |
| CE141 | 9.46E-01 | 9.46E-01 | 9.46E-01 | 9.46E-01 | 9.46E-01 | 9.46E-01 | 9.46E-01 | 0.00E-01 |
| CE143 | 4.14E+00 | 4.14E+00 | 4.14E+00 | 4.14E+00 | 4.14E+00 | 4.14E+00 | 4.14E+00 | 0.00E-01 |
| CE144 | 6.26E-01 | 6.26E-01 | 6.26E-01 | 6.26E-01 | 6.26E-01 | 6.26E-01 | 6.26E-01 | 0.00E-01 |
| PR143 | 1.16E-02 | 1.16E-02 | 1.16E-02 | 1.16E-02 | 1.16E-02 | 1.16E-02 | 1.16E-02 | 0.00E-01 |
| PR144 | 3.20E-01 | 3.20E-01 | 3.20E-01 | 3.20E-01 | 3.20E-01 | 3.20E-01 | 3.20E-01 | 0.00E-01 |
| ND147 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 0.00E-01 |
| W 187 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 6.02E+00 | 0.00E-01 |
| NP239 | 1.74E+00 | 1.74E+00 | 1.74E+00 | 1.74E+00 | 1.74E+00 | 1.74E+00 | 1.74E+00 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER
 PATHWAY = POTABLE WATER

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.54E+01 | 1.54E+01 | 0.00E-01 | 1.54E+01 | 1.54E+01 | 1.54E+01 | 1.54E+01 | 0.00E-01 |
| C 14 | 2.08E+02 | 2.08E+02 | 1.04E+03 | 2.08E+02 | 2.08E+02 | 2.08E+02 | 2.08E+02 | 0.00E-01 |
| NA 24 | 1.95E+02 | 1.95E+02 | 1.95E+02 | 1.95E+02 | 1.95E+02 | 1.95E+02 | 1.95E+02 | 0.00E-01 |
| P 32 | 2.61E+03 | 5.66E+03 | 6.73E+04 | 4.17E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 8.99E-01 | 1.51E+02 | 0.00E-01 | 0.00E-01 | 1.97E-01 | 4.99E-01 | 1.28E+00 | 0.00E-01 |
| MN 54 | 2.99E+02 | 3.09E+03 | 0.00E-01 | 1.51E+03 | 4.49E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 1.10E-02 | 4.08E+00 | 0.00E-01 | 6.20E-02 | 7.85E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 1.60E+02 | 2.97E+02 | 9.67E+02 | 6.85E+02 | 0.00E-01 | 0.00E-01 | 4.35E+02 | 0.00E-01 |
| FE 59 | 1.33E+03 | 8.16E+03 | 1.48E+03 | 3.45E+03 | 0.00E-01 | 0.00E-01 | 1.09E+03 | 0.00E-01 |
| CO 58 | 5.68E+02 | 3.40E+03 | 0.00E-01 | 2.46E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.62E+03 | 9.36E+03 | 0.00E-01 | 7.19E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.53E+03 | 5.09E+02 | 4.53E+04 | 3.20E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.52E-02 | 1.80E+00 | 2.61E-01 | 3.33E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 3.72E+00 | 6.14E+02 | 0.00E-01 | 7.91E+00 | 2.00E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 2.38E+03 | 2.16E+03 | 1.47E+03 | 5.10E+03 | 3.27E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 1.21E-08 | 3.19E-07 | 9.08E-08 | 1.73E-07 | 1.13E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.40E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 3.45E+03 | 1.09E+03 | 0.00E-01 | 7.35E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 3.18E+03 | 1.32E+04 | 1.11E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 5.22E+04 | 5.96E+04 | 2.61E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.42E+01 | 1.62E+03 | 3.57E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 7.21E-02 | 4.31E+01 | 1.69E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 7.29E-02 | 2.23E+04 | 2.70E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 1.36E+00 | 2.08E+04 | 5.08E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 8.29E-05 | 7.86E+01 | 2.86E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 5.16E-03 | 5.75E+03 | 1.88E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 2.26E+00 | 7.59E+03 | 1.04E+01 | 3.29E+00 | 4.84E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 2.06E-02 | 1.21E+04 | 2.27E-01 | 4.48E-02 | 6.80E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 6.30E-01 | 4.89E+03 | 2.06E+00 | 1.14E+00 | 1.11E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 2.29E+02 | 2.15E+03 | 0.00E-01 | 1.20E+03 | 2.74E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 1.93E-01 | 9.80E+00 | 5.35E-03 | 1.49E-02 | 2.22E-01 | 0.00E-01 | 8.29E-03 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER
 PATHWAY = POTABLE WATER

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 2.74E+01 | 5.36E+03 | 6.41E+01 | 0.00E-01 | 2.26E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 5.09E-02 | 1.06E+02 | 1.31E-01 | 0.00E-01 | 1.65E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 1.26E+02 | 4.80E+04 | 1.00E+03 | 0.00E-01 | 1.93E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 3.01E+01 | 1.39E+04 | 5.23E+01 | 4.95E+01 | 9.44E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 1.29E+02 | 2.86E+03 | 9.68E+02 | 3.49E+02 | 0.00E-01 | 2.71E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 2.92E+02 | 6.13E+03 | 2.46E+03 | 8.72E+02 | 9.97E+03 | 5.85E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.47E+00 | 5.27E+02 | 6.82E+00 | 2.42E+00 | 2.76E+01 | 4.70E+00 | 0.00E-01 | 0.00E-01 |
| TE129M | 6.47E+02 | 1.53E+04 | 4.09E+03 | 1.52E+03 | 1.71E+04 | 1.32E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 1.65E-06 | 3.70E-05 | 6.77E-06 | 2.52E-06 | 2.84E-05 | 4.83E-06 | 0.00E-01 | 0.00E-01 |
| TE131M | 1.43E+02 | 1.38E+04 | 3.59E+02 | 1.72E+02 | 1.79E+03 | 2.59E+02 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 4.30E+02 | 1.45E+04 | 7.22E+02 | 4.57E+02 | 4.39E+03 | 4.82E+02 | 0.00E-01 | 0.00E-01 |
| I 130 | 7.91E+01 | 1.52E+02 | 6.85E+01 | 1.98E+02 | 3.05E+02 | 1.62E+04 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.03E+03 | 3.80E+02 | 1.37E+03 | 1.92E+03 | 3.31E+03 | 5.61E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 4.85E-02 | 5.89E-02 | 5.16E-02 | 1.35E-01 | 2.13E-01 | 4.55E+00 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.20E+02 | 2.97E+02 | 2.31E+02 | 3.92E+02 | 6.88E+02 | 5.48E+04 | 0.00E-01 | 0.00E-01 |
| I 134 | 1.98E-07 | 7.25E-09 | 2.08E-07 | 5.50E-07 | 8.68E-07 | 9.17E-06 | 0.00E-01 | 0.00E-01 |
| I 135 | 1.19E+01 | 3.57E+01 | 1.25E+01 | 3.22E+01 | 5.09E+01 | 2.07E+03 | 0.00E-01 | 0.00E-01 |
| CS134 | 2.34E+04 | 6.26E+02 | 2.14E+04 | 5.04E+04 | 1.60E+04 | 0.00E-01 | 6.11E+03 | 0.00E-01 |
| CS136 | 5.51E+03 | 6.60E+02 | 2.08E+03 | 8.20E+03 | 4.47E+03 | 0.00E-01 | 7.04E+02 | 0.00E-01 |
| CS137 | 1.33E+04 | 5.42E+02 | 2.87E+04 | 3.81E+04 | 1.30E+04 | 0.00E-01 | 5.04E+03 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 5.79E-06 | 1.77E-03 | 1.99E-04 | 1.40E-07 | 1.32E-07 | 0.00E-01 | 9.63E-08 | 0.00E-01 |
| BA140 | 4.44E+02 | 1.06E+04 | 6.88E+03 | 8.44E+00 | 2.86E+00 | 0.00E-01 | 5.67E+00 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 7.71E-02 | 1.66E+04 | 5.89E-01 | 2.90E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 1.03E-07 | 1.26E-02 | 9.35E-07 | 4.15E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 2.55E-01 | 6.36E+03 | 3.33E+00 | 2.22E+00 | 1.05E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 2.96E-02 | 7.96E+03 | 3.64E-01 | 2.65E+02 | 1.19E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 9.55E+00 | 4.47E+04 | 1.78E+02 | 7.35E+01 | 4.39E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.59E-01 | 1.05E+04 | 3.19E+00 | 1.27E+00 | 7.39E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.47E-01 | 8.85E+03 | 2.26E+00 | 2.45E+00 | 1.44E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 5.32E+00 | 4.11E+03 | 1.86E+01 | 1.52E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 1.76E-02 | 5.09E+03 | 3.36E-01 | 3.17E-02 | 9.94E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = FRESH WATER FISH

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 4.36E-01 | 4.36E-01 | 0.00E-01 | 4.36E-01 | 4.36E-01 | 4.36E-01 | 4.36E-01 | 0.00E-01 |
| C 14 | 3.00E+04 | 3.00E+04 | 1.50E+05 | 3.00E+04 | 3.00E+04 | 3.00E+04 | 3.00E+04 | 0.00E-01 |
| NA 24 | 6.08E+02 | 6.08E+02 | 6.08E+02 | 6.08E+02 | 6.08E+02 | 6.08E+02 | 6.08E+02 | 0.00E-01 |
| P 32 | 8.18E+06 | 1.77E+07 | 2.11E+08 | 1.31E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 5.64E+00 | 9.47E+02 | 0.00E-01 | 0.00E-01 | 1.24E+00 | 3.13E+00 | 8.05E+00 | 0.00E-01 |
| MN 54 | 3.75E+03 | 3.88E+04 | 0.00E-01 | 1.89E+04 | 5.64E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 1.35E-01 | 4.99E+01 | 0.00E-01 | 7.57E-01 | 9.59E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 5.01E+02 | 9.31E+02 | 3.03E+03 | 2.15E+03 | 0.00E-01 | 0.00E-01 | 1.36E+03 | 0.00E-01 |
| FE 59 | 4.18E+03 | 2.56E+04 | 4.64E+03 | 1.08E+04 | 0.00E-01 | 0.00E-01 | 3.41E+03 | 0.00E-01 |
| CO 58 | 8.90E+02 | 5.33E+03 | 0.00E-01 | 3.86E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 2.54E+03 | 1.47E+04 | 0.00E-01 | 1.13E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 4.82E+03 | 1.60E+03 | 1.42E+05 | 1.00E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 4.63E-02 | 5.51E+00 | 7.95E-01 | 1.02E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 5.81E+00 | 9.58E+02 | 0.00E-01 | 1.24E+01 | 3.12E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.49E+05 | 1.36E+05 | 9.22E+04 | 3.20E+05 | 2.05E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 7.06E-07 | 1.86E-05 | 5.30E-06 | 1.01E-05 | 6.59E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.79E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.17E+05 | 6.82E+04 | 0.00E-01 | 4.61E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.99E+03 | 1.24E+04 | 1.04E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 4.91E+04 | 5.61E+04 | 2.46E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.33E+01 | 1.51E+03 | 3.34E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 6.61E-02 | 3.95E+01 | 1.55E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 5.71E-02 | 1.75E+04 | 2.12E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 1.07E+00 | 1.63E+04 | 3.99E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 6.37E-05 | 6.05E+01 | 2.20E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 4.02E-03 | 4.48E+03 | 1.47E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 2.34E-01 | 7.86E+02 | 1.08E+00 | 3.41E-01 | 5.01E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 2.13E-03 | 1.25E+03 | 2.34E-02 | 4.62E-03 | 7.01E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 5.93E+02 | 4.60E+06 | 1.94E+03 | 1.08E+03 | 1.04E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 7.17E+01 | 6.73E+02 | 0.00E-01 | 3.76E+02 | 8.60E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 9.00E-02 | 4.56E+00 | 2.49E-03 | 6.94E-03 | 1.04E-01 | 0.00E-01 | 3.85E-03 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER
 PATHWAY = FRESH WATER FISH

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 8.60E+00 | 1.68E+03 | 2.01E+01 | 0.00E-01 | 7.09E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.57E-02 | 3.27E+01 | 4.05E-02 | 0.00E-01 | 5.11E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 3.96E+01 | 1.51E+04 | 3.14E+02 | 0.00E-01 | 6.06E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 2.17E+00 | 1.00E+03 | 3.78E+00 | 3.57E+00 | 6.81E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 1.62E+03 | 3.59E+04 | 1.21E+04 | 4.38E+03 | 0.00E-01 | 3.39E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 3.67E+03 | 7.69E+04 | 3.09E+04 | 1.09E+04 | 1.25E+05 | 7.34E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.83E+01 | 6.56E+03 | 8.49E+01 | 3.01E+01 | 3.44E+02 | 5.86E+01 | 0.00E-01 | 0.00E-01 |
| TE129M | 8.12E+03 | 1.92E+05 | 5.13E+04 | 1.90E+04 | 2.14E+05 | 1.65E+04 | 0.00E-01 | 0.00E-01 |
| TE129 | 1.95E-05 | 4.38E-04 | 8.00E-05 | 2.98E-05 | 3.36E-04 | 5.72E-05 | 0.00E-01 | 0.00E-01 |
| TE131M | 1.80E+03 | 1.73E+05 | 4.49E+03 | 2.15E+03 | 2.24E+04 | 3.24E+03 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 5.40E+03 | 1.82E+05 | 9.05E+03 | 5.73E+03 | 5.50E+04 | 6.04E+03 | 0.00E-01 | 0.00E-01 |
| I 130 | 3.70E+01 | 7.12E+01 | 3.20E+01 | 9.27E+01 | 1.43E+02 | 7.56E+03 | 0.00E-01 | 0.00E-01 |
| I 131 | 4.86E+02 | 1.79E+02 | 6.46E+02 | 9.04E+02 | 1.56E+03 | 2.64E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 2.21E-02 | 2.69E-02 | 2.36E-02 | 6.17E-02 | 9.72E-02 | 2.08E+00 | 0.00E-01 | 0.00E-01 |
| I 133 | 5.61E+01 | 1.39E+02 | 1.08E+02 | 1.84E+02 | 3.23E+02 | 2.57E+04 | 0.00E-01 | 0.00E-01 |
| I 134 | 8.60E-08 | 3.15E-09 | 9.03E-08 | 2.39E-07 | 3.77E-07 | 3.99E-06 | 0.00E-01 | 0.00E-01 |
| I 135 | 5.56E+00 | 1.66E+01 | 5.83E+00 | 1.50E+01 | 2.37E+01 | 9.66E+02 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.47E+06 | 3.93E+04 | 1.34E+06 | 3.16E+06 | 1.00E+06 | 0.00E-01 | 3.83E+05 | 0.00E-01 |
| CS136 | 3.46E+05 | 4.14E+04 | 1.31E+05 | 5.15E+05 | 2.80E+05 | 0.00E-01 | 4.42E+04 | 0.00E-01 |
| CS137 | 8.33E+05 | 3.40E+04 | 1.80E+06 | 2.39E+06 | 8.14E+05 | 0.00E-01 | 3.16E+05 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 6.90E-07 | 2.11E-04 | 2.37E-05 | 1.67E-08 | 1.57E-08 | 0.00E-01 | 1.15E-08 | 0.00E-01 |
| BA140 | 5.57E+01 | 1.33E+03 | 8.64E+02 | 1.06E+00 | 3.59E-01 | 0.00E-01 | 7.12E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 6.03E-02 | 1.30E+04 | 4.61E-01 | 2.27E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 7.75E-08 | 9.47E-03 | 7.01E-07 | 3.11E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 8.02E-03 | 2.00E+02 | 1.05E-01 | 6.98E-02 | 3.29E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 9.26E-04 | 2.49E+02 | 1.14E-02 | 8.29E+00 | 3.72E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 2.99E-01 | 1.40E+03 | 5.57E+00 | 2.31E+00 | 1.38E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.24E-01 | 8.22E+03 | 2.50E+00 | 9.97E-01 | 5.80E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.15E-01 | 6.94E+03 | 1.77E+00 | 1.92E+00 | 1.13E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 2.00E+02 | 1.54E+05 | 7.00E+02 | 5.70E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 5.51E-03 | 1.60E+03 | 1.05E-01 | 9.92E-03 | 3.11E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = FRESH WATER INVERTEBRATES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.04E-01 | 1.04E-01 | 0.00E-01 | 1.04E-01 | 1.04E-01 | 1.04E-01 | 1.04E-01 | 0.00E-01 |
| C 14 | 1.41E+04 | 1.41E+04 | 7.04E+04 | 1.41E+04 | 1.41E+04 | 1.41E+04 | 1.41E+04 | 0.00E-01 |
| NA 24 | 2.89E+02 | 2.89E+02 | 2.89E+02 | 2.89E+02 | 2.89E+02 | 2.89E+02 | 2.89E+02 | 0.00E-01 |
| P 32 | 3.89E+05 | 8.43E+05 | 1.00E+07 | 6.21E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.34E+01 | 2.25E+03 | 0.00E-01 | 0.00E-01 | 2.93E+00 | 7.44E+00 | 1.91E+01 | 0.00E-01 |
| MN 54 | 2.00E+05 | 2.07E+06 | 0.00E-01 | 1.01E+06 | 3.01E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 7.20E+00 | 2.66E+03 | 0.00E-01 | 4.05E+01 | 5.12E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 3.81E+03 | 7.07E+03 | 2.30E+04 | 1.63E+04 | 0.00E-01 | 0.00E-01 | 1.04E+04 | 0.00E-01 |
| FE 59 | 3.18E+04 | 1.95E+05 | 3.53E+04 | 8.23E+04 | 0.00E-01 | 0.00E-01 | 2.59E+04 | 0.00E-01 |
| CO 58 | 8.46E+02 | 5.06E+03 | 0.00E-01 | 3.67E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 2.41E+03 | 1.39E+04 | 0.00E-01 | 1.07E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.14E+03 | 3.79E+02 | 3.37E+04 | 2.38E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.10E-02 | 1.31E+00 | 1.89E-01 | 2.41E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 1.10E+01 | 1.82E+03 | 0.00E-01 | 2.35E+01 | 5.94E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.77E+05 | 1.61E+05 | 1.09E+05 | 3.80E+05 | 2.43E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 8.39E-07 | 2.21E-05 | 6.29E-06 | 1.20E-05 | 7.83E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 3.35E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.57E+04 | 8.10E+03 | 0.00E-01 | 5.47E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.37E+03 | 9.85E+03 | 8.27E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 3.89E+04 | 4.44E+04 | 1.94E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.05E+01 | 1.20E+03 | 2.64E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 5.24E-02 | 3.13E+01 | 1.23E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 5.42E-01 | 1.66E+05 | 2.01E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 1.02E+01 | 1.55E+05 | 3.79E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 6.06E-04 | 5.74E+02 | 2.09E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 3.82E-02 | 4.25E+04 | 1.39E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.13E-01 | 3.79E+02 | 5.21E-01 | 1.64E-01 | 2.41E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 1.03E-03 | 6.03E+02 | 1.13E-02 | 2.23E-03 | 3.38E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 4.69E-01 | 3.64E+03 | 1.54E+00 | 8.53E-01 | 8.26E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 1.70E+01 | 1.60E+02 | 0.00E-01 | 8.92E+01 | 2.04E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 7.12E-03 | 3.61E-01 | 1.97E-04 | 5.50E-04 | 8.19E-03 | 0.00E-01 | 3.05E-04 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = FRESH WATER INVERTEBRATES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 6.13E+01 | 1.20E+04 | 1.43E+02 | 0.00E-01 | 5.05E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.12E-01 | 2.33E+02 | 2.89E-01 | 0.00E-01 | 3.64E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 2.82E+02 | 1.07E+05 | 2.24E+03 | 0.00E-01 | 4.32E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 1.73E+02 | 7.98E+04 | 3.00E+02 | 2.84E+02 | 5.42E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 5.88E+03 | 1.30E+05 | 4.40E+04 | 1.59E+04 | 0.00E-01 | 1.23E+04 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.33E+04 | 2.78E+05 | 1.12E+05 | 3.96E+04 | 4.53E+05 | 2.66E+04 | 0.00E-01 | 0.00E-01 |
| TE127 | 6.62E+01 | 2.38E+04 | 3.08E+02 | 1.09E+02 | 1.25E+03 | 2.12E+02 | 0.00E-01 | 0.00E-01 |
| TE129M | 2.94E+04 | 6.97E+05 | 1.86E+05 | 6.89E+04 | 7.77E+05 | 5.99E+04 | 0.00E-01 | 0.00E-01 |
| TE129 | 7.05E-05 | 1.58E-03 | 2.90E-04 | 1.08E-04 | 1.22E-03 | 2.07E-04 | 0.00E-01 | 0.00E-01 |
| TE131M | 6.50E+03 | 6.26E+05 | 1.63E+04 | 7.80E+03 | 8.13E+04 | 1.17E+04 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 1.95E+04 | 6.58E+05 | 3.28E+04 | 2.08E+04 | 1.99E+05 | 2.19E+04 | 0.00E-01 | 0.00E-01 |
| I 130 | 2.93E+00 | 5.64E+00 | 2.54E+00 | 7.34E+00 | 1.13E+01 | 5.98E+02 | 0.00E-01 | 0.00E-01 |
| I 131 | 3.85E+01 | 1.42E+01 | 5.12E+01 | 7.16E+01 | 1.23E+02 | 2.09E+04 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.75E-03 | 2.13E-03 | 1.87E-03 | 4.89E-03 | 7.70E-03 | 1.65E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 4.44E+00 | 1.10E+01 | 8.59E+00 | 1.46E+01 | 2.55E+01 | 2.03E+03 | 0.00E-01 | 0.00E-01 |
| I 134 | 6.81E-09 | 2.50E-10 | 7.15E-09 | 1.90E-08 | 2.99E-08 | 3.16E-07 | 0.00E-01 | 0.00E-01 |
| I 135 | 4.40E-01 | 1.32E+00 | 4.62E-01 | 1.19E+00 | 1.88E+00 | 7.64E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.74E+05 | 4.67E+03 | 1.59E+05 | 3.75E+05 | 1.19E+05 | 0.00E-01 | 4.55E+04 | 0.00E-01 |
| CS136 | 4.10E+04 | 4.92E+03 | 1.55E+04 | 6.11E+04 | 3.33E+04 | 0.00E-01 | 5.24E+03 | 0.00E-01 |
| CS137 | 9.90E+04 | 4.04E+03 | 2.13E+05 | 2.84E+05 | 9.67E+04 | 0.00E-01 | 3.76E+04 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 8.20E-06 | 2.51E-03 | 2.81E-04 | 1.98E-07 | 1.87E-07 | 0.00E-01 | 1.36E-07 | 0.00E-01 |
| BA140 | 6.61E+02 | 1.58E+04 | 1.03E+04 | 1.26E+01 | 4.26E+00 | 0.00E-01 | 8.45E+00 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 5.73E-01 | 1.24E+05 | 4.38E+00 | 2.15E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 7.36E-07 | 9.00E-02 | 6.66E-06 | 2.96E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 1.90E+00 | 4.74E+04 | 2.48E+01 | 1.66E+01 | 7.80E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 2.20E-01 | 5.92E+04 | 2.71E+00 | 1.97E+03 | 8.83E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 7.11E+01 | 3.33E+05 | 1.32E+03 | 5.48E+02 | 3.27E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.18E+00 | 7.81E+04 | 2.37E+01 | 9.48E+00 | 5.51E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.09E+00 | 6.59E+04 | 1.68E+01 | 1.83E+01 | 1.07E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 3.96E-01 | 3.05E+02 | 1.38E+00 | 1.13E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 5.24E-02 | 1.52E+04 | 9.99E-01 | 9.43E-02 | 2.96E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = IRRIGATED FRESH LEAFY VEGETABLES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.27E+00 | 1.27E+00 | 0.00E-01 | 1.27E+00 | 1.27E+00 | 1.27E+00 | 1.27E+00 | 0.00E-01 |
| C 14 | 1.90E+03 | 1.90E+03 | 9.50E+03 | 1.90E+03 | 1.90E+03 | 1.90E+03 | 1.90E+03 | 0.00E-01 |
| NA 24 | 5.53E+00 | 5.53E+00 | 5.53E+00 | 5.53E+00 | 5.53E+00 | 5.53E+00 | 5.53E+00 | 0.00E-01 |
| P 32 | 9.26E+02 | 2.01E+03 | 2.39E+04 | 1.48E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 4.08E-01 | 6.86E+01 | 0.00E-01 | 0.00E-01 | 8.95E-02 | 2.27E-01 | 5.83E-01 | 0.00E-01 |
| MN 54 | 1.90E+02 | 1.97E+03 | 0.00E-01 | 9.60E+02 | 2.86E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 4.43E-05 | 1.64E-02 | 0.00E-01 | 2.49E-04 | 3.15E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 1.04E+02 | 1.93E+02 | 6.28E+02 | 4.46E+02 | 0.00E-01 | 0.00E-01 | 2.83E+02 | 0.00E-01 |
| FE 59 | 6.88E+02 | 4.22E+03 | 7.64E+02 | 1.78E+03 | 0.00E-01 | 0.00E-01 | 5.62E+02 | 0.00E-01 |
| CO 58 | 3.19E+02 | 1.91E+03 | 0.00E-01 | 1.39E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.07E+03 | 6.18E+03 | 0.00E-01 | 4.74E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.05E+03 | 3.49E+02 | 3.10E+04 | 2.19E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 5.94E-05 | 7.08E-03 | 1.02E-03 | 1.31E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 8.88E-02 | 1.46E+01 | 0.00E-01 | 1.89E-01 | 4.78E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.59E+03 | 1.44E+03 | 9.80E+02 | 3.40E+03 | 2.18E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 1.14E-11 | 3.01E-10 | 8.56E-11 | 1.63E-10 | 1.07E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 5.17E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 1.32E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 3.39E-37 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 1.36E+03 | 4.29E+02 | 0.00E-01 | 2.90E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 3.67E-28 | 5.90E-35 | 0.00E-01 | 6.88E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 3.00E-30 | 6.50E-39 | 0.00E-01 | 4.24E-30 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.70E+03 | 7.07E+03 | 5.93E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 4.78E+04 | 5.46E+04 | 2.39E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 2.52E-01 | 2.87E+01 | 6.33E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 3.10E-04 | 1.85E-01 | 7.28E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 8.01E-03 | 2.45E+03 | 2.98E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 1.68E-15 | 2.07E-12 | 4.39E-14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 7.43E-01 | 1.14E+04 | 2.77E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 4.94E-07 | 4.69E-01 | 1.71E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 9.72E-05 | 1.08E+02 | 3.55E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.25E+00 | 4.20E+03 | 5.77E+00 | 1.82E+00 | 2.68E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 6.57E-04 | 3.86E+02 | 7.21E-03 | 1.43E-03 | 2.16E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 3.07E-01 | 2.39E+03 | 1.01E+00 | 5.58E-01 | 5.41E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 2.58E+01 | 2.42E+02 | 0.00E-01 | 1.35E+02 | 3.09E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 2.11E-03 | 1.07E-01 | 5.83E-05 | 1.63E-04 | 2.42E-03 | 0.00E-01 | 9.02E-05 | 0.00E-01 |
| TC101 | 2.94E-31 | 5.11E-39 | 2.10E-32 | 2.99E-32 | 5.41E-31 | 0.00E-01 | 1.82E-32 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = IRRIGATED FRESH LEAFY VEGETABLES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.38E+01 | 2.69E+03 | 3.22E+01 | 0.00E-01 | 1.14E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 3.94E-04 | 8.19E-01 | 1.01E-03 | 0.00E-01 | 1.28E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 8.13E+01 | 3.10E+04 | 6.45E+02 | 0.00E-01 | 1.24E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 1.94E+01 | 8.95E+03 | 3.37E+01 | 3.19E+01 | 6.07E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 7.45E+01 | 1.64E+03 | 5.57E+02 | 2.01E+02 | 0.00E-01 | 1.56E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.90E+02 | 3.98E+03 | 1.60E+03 | 5.67E+02 | 6.48E+03 | 3.80E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 2.58E-02 | 9.27E+00 | 1.20E-01 | 4.26E-02 | 4.86E-01 | 8.28E-02 | 0.00E-01 | 0.00E-01 |
| TE129M | 3.23E+02 | 7.66E+03 | 2.04E+03 | 7.57E+02 | 8.53E+03 | 6.58E+02 | 0.00E-01 | 0.00E-01 |
| TE129 | 2.18E-09 | 4.91E-08 | 8.97E-09 | 3.35E-09 | 3.77E-08 | 6.41E-09 | 0.00E-01 | 0.00E-01 |
| TE131M | 8.05E+00 | 7.75E+02 | 2.01E+01 | 9.65E+00 | 1.01E+02 | 1.45E+01 | 0.00E-01 | 0.00E-01 |
| TE131 | 1.86E-21 | 4.88E-22 | 5.94E-21 | 2.45E-21 | 2.60E-20 | 4.58E-21 | 0.00E-01 | 0.00E-01 |
| TE132 | 5.66E+01 | 1.90E+03 | 9.50E+01 | 6.01E+01 | 5.77E+02 | 6.34E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 1.84E+00 | 3.54E+00 | 1.59E+00 | 4.60E+00 | 7.09E+00 | 3.75E+02 | 0.00E-01 | 0.00E-01 |
| I 131 | 2.60E+02 | 9.58E+01 | 3.46E+02 | 4.84E+02 | 8.34E+02 | 1.41E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.69E-04 | 2.05E-04 | 1.80E-04 | 4.71E-04 | 7.42E-04 | 1.59E-02 | 0.00E-01 | 0.00E-01 |
| I 133 | 4.68E+00 | 1.16E+01 | 9.05E+00 | 1.54E+01 | 2.69E+01 | 2.14E+03 | 0.00E-01 | 0.00E-01 |
| I 134 | 1.61E-10 | 5.92E-12 | 1.69E-10 | 4.49E-10 | 7.08E-10 | 7.48E-09 | 0.00E-01 | 0.00E-01 |
| I 135 | 1.44E-01 | 4.29E-01 | 1.50E-01 | 3.87E-01 | 6.12E-01 | 2.49E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.52E+04 | 4.07E+02 | 1.39E+04 | 3.28E+04 | 1.04E+04 | 0.00E-01 | 3.97E+03 | 0.00E-01 |
| CS136 | 1.84E+03 | 2.20E+02 | 6.96E+02 | 2.74E+03 | 1.49E+03 | 0.00E-01 | 2.35E+02 | 0.00E-01 |
| CS137 | 8.90E+03 | 3.63E+02 | 1.92E+04 | 2.55E+04 | 8.69E+03 | 0.00E-01 | 3.38E+03 | 0.00E-01 |
| CS138 | 2.15E-16 | 1.95E-19 | 2.24E-16 | 4.29E-16 | 3.17E-16 | 0.00E-01 | 3.69E-17 | 0.00E-01 |
| BA139 | 9.87E-09 | 3.02E-06 | 3.39E-07 | 2.38E-10 | 2.25E-10 | 0.00E-01 | 1.64E-10 | 0.00E-01 |
| BA140 | 1.46E+02 | 3.50E+03 | 2.27E+03 | 2.78E+00 | 9.43E-01 | 0.00E-01 | 1.87E+00 | 0.00E-01 |
| BA141 | 7.14E-29 | 4.56E-33 | 2.14E-27 | 1.60E-30 | 1.48E-30 | 0.00E-01 | 1.09E-30 | 0.00E-01 |
| BA142 | 3.10E-32 | 1.55E-42 | 5.04E-31 | 5.04E-34 | 4.27E-34 | 0.00E-01 | 3.36E-34 | 0.00E-01 |
| LA140 | 5.62E-03 | 1.21E+03 | 4.30E-02 | 2.11E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 2.08E-10 | 2.55E-05 | 1.88E-09 | 8.37E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 1.22E-01 | 3.04E+03 | 1.59E+00 | 1.06E+00 | 5.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 1.80E-03 | 4.85E+02 | 2.22E-02 | 1.61E+01 | 7.24E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 6.03E+00 | 2.82E+04 | 1.12E+02 | 4.64E+01 | 2.77E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 5.39E-02 | 3.56E+03 | 1.08E+00 | 4.32E-01 | 2.51E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 2.35E-33 | 5.11E-35 | 4.63E-32 | 1.90E-32 | 1.09E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 4.48E-02 | 2.70E+03 | 6.88E-01 | 7.49E-01 | 4.40E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 2.38E-01 | 1.84E+02 | 8.34E-01 | 6.80E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 1.74E-03 | 5.03E+02 | 3.32E-02 | 3.13E-03 | 9.81E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = IRRIGATED STORED FRUIT, VEGETABLES, GRAIN

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.89E+01 | 1.89E+01 | 0.00E-01 | 1.89E+01 | 1.89E+01 | 1.89E+01 | 1.89E+01 | 0.00E-01 |
| C 14 | 2.85E+04 | 2.85E+04 | 1.43E+05 | 2.85E+04 | 2.85E+04 | 2.85E+04 | 2.85E+04 | 0.00E-01 |
| NA 24 | 2.19E-24 | 2.19E-24 | 2.19E-24 | 2.19E-24 | 2.19E-24 | 2.19E-24 | 2.19E-24 | 0.00E-01 |
| P 32 | 7.96E+02 | 1.72E+03 | 2.05E+04 | 1.27E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.40E+00 | 2.35E+02 | 0.00E-01 | 0.00E-01 | 3.06E-01 | 7.76E-01 | 1.99E+00 | 0.00E-01 |
| MN 54 | 2.50E+03 | 2.59E+04 | 0.00E-01 | 1.26E+04 | 3.77E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 3.79E-27 | 1.40E-24 | 0.00E-01 | 2.13E-26 | 2.70E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 1.49E+03 | 2.77E+03 | 9.04E+03 | 6.41E+03 | 0.00E-01 | 0.00E-01 | 4.07E+03 | 0.00E-01 |
| FE 59 | 4.12E+03 | 2.53E+04 | 4.58E+03 | 1.07E+04 | 0.00E-01 | 0.00E-01 | 3.37E+03 | 0.00E-01 |
| CO 58 | 2.69E+03 | 1.61E+04 | 0.00E-01 | 1.17E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.57E+04 | 9.07E+04 | 0.00E-01 | 6.97E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.58E+04 | 5.23E+03 | 4.65E+05 | 3.28E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 5.74E-27 | 6.84E-25 | 9.87E-26 | 1.26E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 4.34E-26 | 7.15E-24 | 0.00E-01 | 9.22E-26 | 2.33E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 2.01E+04 | 1.83E+04 | 1.24E+04 | 4.32E+04 | 2.76E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 6.21E-29 | 1.63E-27 | 4.66E-28 | 8.87E-28 | 5.80E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 7.12E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 7.22E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 5.09E-36 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.29E+03 | 7.23E+02 | 0.00E-01 | 4.88E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 9.12E-29 | 1.47E-35 | 0.00E-01 | 1.71E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 4.50E-29 | 9.74E-38 | 0.00E-01 | 6.36E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.13E+04 | 4.71E+04 | 3.96E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 7.14E+05 | 8.16E+05 | 3.57E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.91E-25 | 2.18E-23 | 4.81E-24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 1.88E-26 | 1.12E-23 | 4.41E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 2.74E-08 | 8.40E-03 | 1.02E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 1.22E-31 | 1.50E-28 | 3.19E-30 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 5.54E+00 | 8.47E+04 | 2.07E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 7.02E-30 | 6.66E-24 | 2.43E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 6.65E-29 | 7.41E-23 | 2.43E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 9.94E+00 | 3.33E+04 | 4.58E+01 | 1.44E+01 | 2.12E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 5.70E-28 | 3.35E-22 | 6.25E-27 | 1.24E-27 | 1.88E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 1.44E+00 | 1.12E+04 | 4.72E+00 | 2.62E+00 | 2.54E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 1.33E-04 | 1.25E-03 | 0.00E-01 | 6.95E-04 | 1.59E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 4.39E-27 | 2.22E-25 | 1.21E-28 | 3.39E-28 | 5.05E-27 | 0.00E-01 | 1.88E-28 | 0.00E-01 |
| TC101 | 4.41E-30 | 7.67E-38 | 3.16E-31 | 4.49E-31 | 8.12E-30 | 0.00E-01 | 2.73E-31 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = IRRIGATED STORED FRUIT, VEGETABLES, GRAIN

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 7.30E+01 | 1.43E+04 | 1.71E+02 | 0.00E-01 | 6.02E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 2.20E-27 | 4.57E-24 | 5.66E-27 | 0.00E-01 | 7.14E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 1.09E+03 | 4.15E+05 | 8.66E+03 | 0.00E-01 | 1.67E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 2.47E+02 | 1.14E+05 | 4.29E+02 | 4.06E+02 | 7.74E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 5.53E+02 | 1.22E+04 | 4.13E+03 | 1.49E+03 | 0.00E-01 | 1.15E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.96E+03 | 4.11E+04 | 1.65E+04 | 5.85E+03 | 6.68E+04 | 3.92E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 2.01E-26 | 7.22E-24 | 9.35E-26 | 3.31E-26 | 3.79E-25 | 6.45E-26 | 0.00E-01 | 0.00E-01 |
| TE129M | 1.43E+03 | 3.40E+04 | 9.05E+03 | 3.36E+03 | 3.79E+04 | 2.92E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 4.86E-28 | 1.09E-26 | 2.00E-27 | 7.44E-28 | 8.38E-27 | 1.43E-27 | 0.00E-01 | 0.00E-01 |
| TE131M | 7.40E-13 | 7.12E-11 | 1.85E-12 | 8.87E-13 | 9.25E-12 | 1.33E-12 | 0.00E-01 | 0.00E-01 |
| TE131 | 4.85E-29 | 1.27E-29 | 1.55E-28 | 6.39E-29 | 6.78E-28 | 1.20E-28 | 0.00E-01 | 0.00E-01 |
| TE132 | 3.04E-03 | 1.02E-01 | 5.10E-03 | 3.23E-03 | 3.10E-02 | 3.41E-03 | 0.00E-01 | 0.00E-01 |
| I 130 | 9.29E-25 | 1.79E-24 | 8.04E-25 | 2.33E-24 | 3.58E-24 | 1.90E-22 | 0.00E-01 | 0.00E-01 |
| I 131 | 2.41E+01 | 8.87E+00 | 3.20E+01 | 4.49E+01 | 7.72E+01 | 1.31E+04 | 0.00E-01 | 0.00E-01 |
| I 132 | 3.07E-26 | 3.73E-26 | 3.27E-26 | 8.56E-26 | 1.35E-25 | 2.88E-24 | 0.00E-01 | 0.00E-01 |
| I 133 | 2.34E-19 | 5.79E-19 | 4.51E-19 | 7.66E-19 | 1.34E-18 | 1.07E-16 | 0.00E-01 | 0.00E-01 |
| I 134 | 3.81E-27 | 1.40E-28 | 4.00E-27 | 1.06E-26 | 1.67E-26 | 1.77E-25 | 0.00E-01 | 0.00E-01 |
| I 135 | 2.35E-25 | 7.03E-25 | 2.46E-25 | 6.34E-25 | 1.00E-24 | 4.08E-23 | 0.00E-01 | 0.00E-01 |
| CS134 | 2.16E+05 | 5.79E+03 | 1.98E+05 | 4.65E+05 | 1.48E+05 | 0.00E-01 | 5.65E+04 | 0.00E-01 |
| CS136 | 1.22E+03 | 1.46E+02 | 4.61E+02 | 1.81E+03 | 9.88E+02 | 0.00E-01 | 1.56E+02 | 0.00E-01 |
| CS137 | 1.33E+05 | 5.43E+03 | 2.87E+05 | 3.82E+05 | 1.30E+05 | 0.00E-01 | 5.05E+04 | 0.00E-01 |
| CS138 | 7.65E-28 | 6.94E-31 | 7.96E-28 | 1.53E-27 | 1.13E-27 | 0.00E-01 | 1.31E-28 | 0.00E-01 |
| BA139 | 2.32E-28 | 7.11E-26 | 7.98E-27 | 5.61E-30 | 5.29E-30 | 0.00E-01 | 3.87E-30 | 0.00E-01 |
| BA140 | 8.97E+01 | 2.15E+03 | 1.39E+03 | 1.71E+00 | 5.79E-01 | 0.00E-01 | 1.15E+00 | 0.00E-01 |
| BA141 | 4.86E-30 | 3.10E-34 | 1.45E-28 | 1.09E-31 | 1.01E-31 | 0.00E-01 | 7.44E-32 | 0.00E-01 |
| BA142 | 4.66E-31 | 2.32E-41 | 7.57E-30 | 7.57E-33 | 6.40E-33 | 0.00E-01 | 5.04E-33 | 0.00E-01 |
| LA140 | 2.21E-12 | 4.76E-07 | 1.69E-11 | 8.29E-12 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 1.34E-30 | 1.64E-25 | 1.21E-29 | 5.39E-30 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 5.19E-01 | 1.29E+04 | 6.77E+00 | 4.52E+00 | 2.13E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 3.71E-15 | 9.99E-10 | 4.57E-14 | 3.32E-11 | 1.49E-14 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 7.83E+01 | 3.67E+05 | 1.46E+03 | 6.03E+02 | 3.60E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 4.00E-02 | 2.64E+03 | 8.03E-01 | 3.20E-01 | 1.86E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 3.91E-33 | 8.50E-35 | 7.71E-32 | 3.16E-32 | 1.81E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.69E-02 | 1.02E+03 | 2.59E-01 | 2.82E-01 | 1.65E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 5.39E-18 | 4.16E-15 | 1.89E-17 | 1.54E-17 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 7.74E-10 | 2.24E-04 | 1.48E-08 | 1.39E-09 | 4.37E-09 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = IRRIGATED FRESH FORAGE--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 5.51E+00 | 5.51E+00 | 0.00E-01 | 5.51E+00 | 5.51E+00 | 5.51E+00 | 5.51E+00 | 0.00E-01 |
| C 14 | 1.19E+04 | 1.19E+04 | 5.95E+04 | 1.19E+04 | 1.19E+04 | 1.19E+04 | 1.19E+04 | 0.00E-01 |
| NA 24 | 9.95E+01 | 9.95E+01 | 9.95E+01 | 9.95E+01 | 9.95E+01 | 9.95E+01 | 9.95E+01 | 0.00E-01 |
| P 32 | 2.82E+04 | 6.11E+04 | 7.27E+05 | 4.50E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.08E+00 | 1.81E+02 | 0.00E-01 | 0.00E-01 | 2.36E-01 | 5.98E-01 | 1.54E+00 | 0.00E-01 |
| MN 54 | 5.31E+01 | 5.50E+02 | 0.00E-01 | 2.68E+02 | 7.99E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 2.31E-08 | 8.55E-06 | 0.00E-01 | 1.30E-07 | 1.64E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 1.39E+02 | 2.57E+02 | 8.39E+02 | 5.95E+02 | 0.00E-01 | 0.00E-01 | 3.77E+02 | 0.00E-01 |
| FE 59 | 9.69E+02 | 5.93E+03 | 1.07E+03 | 2.51E+03 | 0.00E-01 | 0.00E-01 | 7.91E+02 | 0.00E-01 |
| CO 58 | 3.68E+02 | 2.20E+03 | 0.00E-01 | 1.60E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.18E+03 | 6.83E+03 | 0.00E-01 | 5.24E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 7.64E+03 | 2.53E+03 | 2.25E+05 | 1.59E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 7.36E-07 | 8.76E-05 | 1.26E-05 | 1.62E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 4.55E-01 | 7.50E+01 | 0.00E-01 | 9.67E-01 | 2.45E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 6.71E+04 | 6.10E+04 | 4.15E+04 | 1.44E+05 | 9.21E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 1.46E-17 | 3.84E-16 | 1.09E-16 | 2.09E-16 | 1.36E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 3.34E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 3.26E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 2.30E-35 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 4.98E+04 | 1.57E+04 | 0.00E-01 | 1.06E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 2.48E-28 | 3.99E-35 | 0.00E-01 | 4.66E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 1.22E-28 | 2.65E-37 | 0.00E-01 | 1.73E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.60E+03 | 6.65E+03 | 5.58E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 5.62E+04 | 6.42E+04 | 2.81E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 4.75E-02 | 5.42E+00 | 1.20E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 7.33E-07 | 4.38E-04 | 1.72E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 8.41E-05 | 2.58E+01 | 3.12E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 4.12E-26 | 5.09E-23 | 1.08E-24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 8.62E-03 | 1.32E+02 | 3.22E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 6.22E-11 | 5.90E-05 | 2.15E-09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 2.54E-07 | 2.83E-01 | 9.26E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 7.24E-03 | 2.43E+01 | 3.34E-02 | 1.05E-02 | 1.55E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 1.67E-06 | 9.82E-01 | 1.83E-05 | 3.63E-06 | 5.50E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 9.10E-01 | 7.07E+03 | 2.98E+00 | 1.65E+00 | 1.60E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 2.04E+02 | 1.92E+03 | 0.00E-01 | 1.07E+03 | 2.45E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 4.51E-03 | 2.28E-01 | 1.25E-04 | 3.48E-04 | 5.18E-03 | 0.00E-01 | 1.93E-04 | 0.00E-01 |
| TC101 | 9.99E-30 | 1.74E-37 | 7.15E-31 | 1.02E-30 | 1.84E-29 | 0.00E-01 | 6.19E-31 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = IRRIGATED FRESH FORAGE--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.62E-02 | 3.17E+00 | 3.80E-02 | 0.00E-01 | 1.34E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.26E-08 | 2.62E-05 | 3.25E-08 | 0.00E-01 | 4.09E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 9.04E-02 | 3.44E+01 | 7.17E-01 | 0.00E-01 | 1.38E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 1.07E+03 | 4.95E+05 | 1.86E+03 | 1.76E+03 | 3.36E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 8.37E+01 | 1.85E+03 | 6.26E+02 | 2.25E+02 | 0.00E-01 | 1.75E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 2.05E+02 | 4.30E+03 | 1.73E+03 | 6.12E+02 | 7.00E+03 | 4.11E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 5.89E-03 | 2.11E+00 | 2.74E-02 | 9.70E-03 | 1.11E-01 | 1.89E-02 | 0.00E-01 | 0.00E-01 |
| TE129M | 3.75E+02 | 8.90E+03 | 2.37E+03 | 8.80E+02 | 9.92E+03 | 7.65E+02 | 0.00E-01 | 0.00E-01 |
| TE129 | 1.74E-15 | 3.91E-14 | 7.16E-15 | 2.67E-15 | 3.00E-14 | 5.11E-15 | 0.00E-01 | 0.00E-01 |
| TE131M | 6.24E+00 | 6.01E+02 | 1.56E+01 | 7.49E+00 | 7.81E+01 | 1.13E+01 | 0.00E-01 | 0.00E-01 |
| TE131 | 4.37E-30 | 1.15E-30 | 1.40E-29 | 5.76E-30 | 6.11E-29 | 1.08E-29 | 0.00E-01 | 0.00E-01 |
| TE132 | 6.17E+01 | 2.08E+03 | 1.03E+02 | 6.56E+01 | 6.29E+02 | 6.91E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 3.90E+00 | 7.50E+00 | 3.37E+00 | 9.76E+00 | 1.50E+01 | 7.95E+02 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.92E+03 | 7.05E+02 | 2.55E+03 | 3.57E+03 | 6.14E+03 | 1.04E+06 | 0.00E-01 | 0.00E-01 |
| I 132 | 9.99E-07 | 1.21E-06 | 1.06E-06 | 2.78E-06 | 4.38E-06 | 9.38E-05 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.72E+01 | 4.26E+01 | 3.32E+01 | 5.63E+01 | 9.88E+01 | 7.86E+03 | 0.00E-01 | 0.00E-01 |
| I 134 | 7.32E-18 | 2.68E-19 | 7.69E-18 | 2.04E-17 | 3.21E-17 | 3.39E-16 | 0.00E-01 | 0.00E-01 |
| I 135 | 9.40E-02 | 2.81E-01 | 9.85E-02 | 2.54E-01 | 4.00E-01 | 1.63E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 2.03E+05 | 5.43E+03 | 1.86E+05 | 4.37E+05 | 1.39E+05 | 0.00E-01 | 5.30E+04 | 0.00E-01 |
| CS136 | 2.72E+04 | 3.26E+03 | 1.03E+04 | 4.05E+04 | 2.21E+04 | 0.00E-01 | 3.48E+03 | 0.00E-01 |
| CS137 | 1.17E+05 | 4.79E+03 | 2.53E+05 | 3.36E+05 | 1.14E+05 | 0.00E-01 | 4.45E+04 | 0.00E-01 |
| CS138 | 8.32E-28 | 7.55E-31 | 8.67E-28 | 1.66E-27 | 1.23E-27 | 0.00E-01 | 1.43E-28 | 0.00E-01 |
| BA139 | 3.00E-14 | 9.18E-12 | 1.03E-12 | 7.24E-16 | 6.83E-16 | 0.00E-01 | 4.99E-16 | 0.00E-01 |
| BA140 | 7.22E+01 | 1.73E+03 | 1.12E+03 | 1.37E+00 | 4.65E-01 | 0.00E-01 | 9.23E-01 | 0.00E-01 |
| BA141 | 1.76E-31 | 1.12E-35 | 5.28E-30 | 3.94E-33 | 3.66E-33 | 0.00E-01 | 2.70E-33 | 0.00E-01 |
| BA142 | 1.69E-32 | 8.44E-43 | 2.75E-31 | 2.75E-34 | 2.32E-34 | 0.00E-01 | 1.83E-34 | 0.00E-01 |
| LA140 | 2.53E-05 | 5.46E+00 | 1.93E-04 | 9.51E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 2.89E-17 | 3.54E-12 | 2.62E-16 | 1.16E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 1.45E-02 | 3.61E+02 | 1.89E-01 | 1.26E-01 | 5.94E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 1.48E-04 | 4.00E+01 | 1.83E-03 | 1.33E+00 | 5.96E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 6.76E-01 | 3.16E+03 | 1.26E+01 | 5.20E+00 | 3.11E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 3.32E-04 | 2.20E+01 | 6.67E-03 | 2.67E-03 | 1.55E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 1.77E-36 | 3.86E-38 | 3.50E-35 | 1.43E-35 | 8.22E-36 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 2.77E-04 | 1.67E+01 | 4.25E-03 | 4.62E-03 | 2.71E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 8.08E-02 | 6.24E+01 | 2.83E-01 | 2.31E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 8.81E-06 | 2.55E+00 | 1.68E-04 | 1.59E-05 | 4.98E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = IRRIGATED FRESH FORAGE-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 9.85E-01 | 9.85E-01 | 0.00E-01 | 9.85E-01 | 9.85E-01 | 9.85E-01 | 9.85E-01 | 0.00E-01 |
| C 14 | 5.00E+03 | 5.00E+03 | 2.50E+04 | 5.00E+03 | 5.00E+03 | 5.00E+03 | 5.00E+03 | 0.00E-01 |
| NA 24 | 2.74E-08 | 2.74E-08 | 2.74E-08 | 2.74E-08 | 2.74E-08 | 2.74E-08 | 2.74E-08 | 0.00E-01 |
| P 32 | 3.52E+03 | 7.63E+03 | 9.08E+04 | 5.63E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.22E-01 | 2.04E+01 | 0.00E-01 | 0.00E-01 | 2.67E-02 | 6.76E-02 | 1.74E-01 | 0.00E-01 |
| MN 54 | 2.65E+01 | 2.75E+02 | 0.00E-01 | 1.34E+02 | 3.99E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 4.47E-29 | 1.65E-26 | 0.00E-01 | 2.51E-28 | 3.18E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 7.42E+02 | 1.38E+03 | 4.49E+03 | 3.18E+03 | 0.00E-01 | 0.00E-01 | 2.02E+03 | 0.00E-01 |
| FE 59 | 3.97E+03 | 2.43E+04 | 4.40E+03 | 1.03E+04 | 0.00E-01 | 0.00E-01 | 3.24E+03 | 0.00E-01 |
| CO 58 | 6.52E+02 | 3.90E+03 | 0.00E-01 | 2.83E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 2.48E+03 | 1.43E+04 | 0.00E-01 | 1.10E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 9.82E+03 | 3.26E+03 | 2.90E+05 | 2.04E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 4.49E-27 | 5.34E-25 | 7.71E-26 | 9.85E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 2.29E-12 | 3.77E-10 | 0.00E-01 | 4.86E-12 | 1.23E-11 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 7.97E+03 | 7.24E+03 | 4.92E+03 | 1.71E+04 | 1.09E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 2.74E-29 | 7.21E-28 | 2.05E-28 | 3.91E-28 | 2.56E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 2.72E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 2.76E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 1.94E-36 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 4.29E+03 | 1.35E+03 | 0.00E-01 | 9.13E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 4.17E-29 | 6.70E-36 | 0.00E-01 | 7.82E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 2.05E-29 | 4.45E-38 | 0.00E-01 | 2.90E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.52E+02 | 6.33E+02 | 5.31E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 6.84E+03 | 7.81E+03 | 3.42E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.13E-16 | 1.28E-14 | 2.83E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 1.67E-28 | 9.95E-26 | 3.91E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 5.92E-05 | 1.81E+01 | 2.20E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 8.26E-33 | 1.02E-29 | 2.16E-31 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 5.21E-01 | 7.96E+03 | 1.94E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 4.76E-31 | 4.51E-25 | 1.64E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 2.39E-18 | 2.66E-12 | 8.71E-17 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 6.59E+00 | 2.21E+04 | 3.04E+01 | 9.58E+00 | 1.41E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 3.68E-11 | 2.17E-05 | 4.04E-10 | 8.00E-11 | 1.21E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 1.16E+01 | 9.03E+04 | 3.81E+01 | 2.11E+01 | 2.05E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 3.77E-01 | 3.54E+00 | 0.00E-01 | 1.98E+00 | 4.53E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 2.86E-24 | 1.45E-22 | 7.90E-26 | 2.20E-25 | 3.28E-24 | 0.00E-01 | 1.22E-25 | 0.00E-01 |
| TC101 | 2.60E-29 | 4.52E-37 | 1.86E-30 | 2.64E-30 | 4.78E-29 | 0.00E-01 | 1.61E-30 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = IRRIGATED FRESH FORAGE--MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 7.68E+02 | 1.50E+05 | 1.80E+03 | 0.00E-01 | 6.33E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.30E-26 | 2.70E-23 | 3.34E-26 | 0.00E-01 | 4.21E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 5.68E+03 | 2.16E+06 | 4.51E+04 | 0.00E-01 | 8.69E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 5.64E+01 | 2.60E+04 | 9.79E+01 | 9.27E+01 | 1.77E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 8.45E+02 | 1.86E+04 | 6.32E+03 | 2.28E+03 | 0.00E-01 | 1.76E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 2.29E+03 | 4.80E+04 | 1.93E+04 | 6.83E+03 | 7.81E+04 | 4.58E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 8.99E-16 | 3.23E-13 | 4.18E-15 | 1.48E-15 | 1.69E-14 | 2.88E-15 | 0.00E-01 | 0.00E-01 |
| TE129M | 3.24E+03 | 7.68E+04 | 2.05E+04 | 7.59E+03 | 8.56E+04 | 6.60E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 5.47E-28 | 1.23E-26 | 2.25E-27 | 8.39E-28 | 9.44E-27 | 1.61E-27 | 0.00E-01 | 0.00E-01 |
| TE131M | 3.60E-03 | 3.47E-01 | 9.01E-03 | 4.32E-03 | 4.50E-02 | 6.50E-03 | 0.00E-01 | 0.00E-01 |
| TE131 | 5.47E-29 | 1.44E-29 | 1.75E-28 | 7.21E-29 | 7.65E-28 | 1.35E-28 | 0.00E-01 | 0.00E-01 |
| TE132 | 1.68E+01 | 5.66E+02 | 2.82E+01 | 1.79E+01 | 1.72E+02 | 1.89E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 8.90E-12 | 1.71E-11 | 7.70E-12 | 2.23E-11 | 3.43E-11 | 1.82E-09 | 0.00E-01 | 0.00E-01 |
| I 131 | 3.19E+01 | 1.17E+01 | 4.24E+01 | 5.93E+01 | 1.02E+02 | 1.73E+04 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.31E-27 | 1.59E-27 | 1.40E-27 | 3.66E-27 | 5.76E-27 | 1.23E-25 | 0.00E-01 | 0.00E-01 |
| I 133 | 7.63E-07 | 1.89E-06 | 1.47E-06 | 2.50E-06 | 4.39E-06 | 3.49E-04 | 0.00E-01 | 0.00E-01 |
| I 134 | 1.63E-28 | 5.98E-30 | 1.71E-28 | 4.54E-28 | 7.15E-28 | 7.56E-27 | 0.00E-01 | 0.00E-01 |
| I 135 | 1.40E-22 | 4.18E-22 | 1.47E-22 | 3.78E-22 | 5.96E-22 | 2.43E-20 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.08E+04 | 2.89E+02 | 9.89E+03 | 2.33E+04 | 7.39E+03 | 0.00E-01 | 2.82E+03 | 0.00E-01 |
| CS136 | 5.69E+02 | 6.82E+01 | 2.15E+02 | 8.47E+02 | 4.61E+02 | 0.00E-01 | 7.27E+01 | 0.00E-01 |
| CS137 | 6.34E+03 | 2.59E+02 | 1.37E+04 | 1.82E+04 | 6.19E+03 | 0.00E-01 | 2.41E+03 | 0.00E-01 |
| CS138 | 4.51E-29 | 4.09E-32 | 4.69E-29 | 9.01E-29 | 6.65E-29 | 0.00E-01 | 7.74E-30 | 0.00E-01 |
| BA139 | 1.10E-29 | 3.36E-27 | 3.76E-28 | 2.65E-31 | 2.49E-31 | 0.00E-01 | 1.82E-31 | 0.00E-01 |
| BA140 | 3.54E+01 | 8.47E+02 | 5.49E+02 | 6.73E-01 | 2.28E-01 | 0.00E-01 | 4.52E-01 | 0.00E-01 |
| BA141 | 2.29E-31 | 1.46E-35 | 6.86E-30 | 5.12E-33 | 4.76E-33 | 0.00E-01 | 3.51E-33 | 0.00E-01 |
| BA142 | 2.20E-32 | 1.10E-42 | 3.57E-31 | 3.57E-34 | 3.02E-34 | 0.00E-01 | 2.38E-34 | 0.00E-01 |
| LA140 | 9.71E-08 | 2.10E-02 | 7.43E-07 | 3.65E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 3.96E-33 | 4.84E-28 | 3.58E-32 | 1.59E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 1.93E-02 | 4.80E+02 | 2.51E-01 | 1.68E-01 | 7.89E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 3.45E-08 | 9.28E-03 | 4.24E-07 | 3.09E-04 | 1.38E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.26E+00 | 5.90E+03 | 2.35E+01 | 9.72E+00 | 5.80E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 2.03E-02 | 1.34E+03 | 4.07E-01 | 1.63E-01 | 9.45E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 2.71E-34 | 5.89E-36 | 5.34E-33 | 2.19E-33 | 1.26E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 9.65E-03 | 5.81E+02 | 1.48E-01 | 1.61E-01 | 9.46E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 1.25E-07 | 9.64E-05 | 4.37E-07 | 3.56E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 2.89E-07 | 8.38E-02 | 5.52E-06 | 5.21E-07 | 1.63E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = IRRIGATED STORED FEED--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 5.51E+00 | 5.51E+00 | 0.00E-01 | 5.51E+00 | 5.51E+00 | 5.51E+00 | 5.51E+00 | 0.00E-01 |
| C 14 | 1.23E+04 | 1.23E+04 | 6.16E+04 | 1.23E+04 | 1.23E+04 | 1.23E+04 | 1.23E+04 | 0.00E-01 |
| NA 24 | 9.95E+01 | 9.95E+01 | 9.95E+01 | 9.95E+01 | 9.95E+01 | 9.95E+01 | 9.95E+01 | 0.00E-01 |
| P 32 | 2.96E+04 | 6.43E+04 | 7.65E+05 | 4.74E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.19E+00 | 2.00E+02 | 0.00E-01 | 0.00E-01 | 2.61E-01 | 6.62E-01 | 1.70E+00 | 0.00E-01 |
| MN 54 | 6.44E+01 | 6.66E+02 | 0.00E-01 | 3.25E+02 | 9.68E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 2.31E-08 | 8.55E-06 | 0.00E-01 | 1.30E-07 | 1.64E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 1.69E+02 | 3.15E+02 | 1.02E+03 | 7.27E+02 | 0.00E-01 | 0.00E-01 | 4.61E+02 | 0.00E-01 |
| FE 59 | 1.11E+03 | 6.78E+03 | 1.23E+03 | 2.87E+03 | 0.00E-01 | 0.00E-01 | 9.04E+02 | 0.00E-01 |
| CO 58 | 4.30E+02 | 2.57E+03 | 0.00E-01 | 1.87E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.44E+03 | 8.35E+03 | 0.00E-01 | 6.41E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 9.34E+03 | 3.10E+03 | 2.75E+05 | 1.94E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 7.36E-07 | 8.76E-05 | 1.26E-05 | 1.62E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 4.55E-01 | 7.50E+01 | 0.00E-01 | 9.67E-01 | 2.45E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 8.07E+04 | 7.33E+04 | 4.98E+04 | 1.73E+05 | 1.11E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 1.46E-17 | 3.84E-16 | 1.09E-16 | 2.09E-16 | 1.36E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 3.34E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 3.26E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 2.30E-35 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 5.35E+04 | 1.68E+04 | 0.00E-01 | 1.14E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 2.48E-28 | 3.99E-35 | 0.00E-01 | 4.66E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 1.22E-28 | 2.65E-37 | 0.00E-01 | 1.73E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.83E+03 | 7.63E+03 | 6.41E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 6.31E+04 | 7.20E+04 | 3.15E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 4.75E-02 | 5.42E+00 | 1.20E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 7.33E-07 | 4.38E-04 | 1.72E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 8.41E-05 | 2.58E+01 | 3.12E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 4.12E-26 | 5.09E-23 | 1.08E-24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 9.99E-03 | 1.53E+02 | 3.73E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 6.22E-11 | 5.90E-05 | 2.15E-09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 2.54E-07 | 2.83E-01 | 9.26E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 8.43E-03 | 2.83E+01 | 3.88E-02 | 1.23E-02 | 1.80E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 1.67E-06 | 9.82E-01 | 1.83E-05 | 3.63E-06 | 5.50E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 1.02E+00 | 7.96E+03 | 3.36E+00 | 1.86E+00 | 1.80E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 2.04E+02 | 1.92E+03 | 0.00E-01 | 1.07E+03 | 2.45E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 4.51E-03 | 2.28E-01 | 1.25E-04 | 3.48E-04 | 5.18E-03 | 0.00E-01 | 1.93E-04 | 0.00E-01 |
| TC101 | 9.99E-30 | 1.74E-37 | 7.15E-31 | 1.02E-30 | 1.84E-29 | 0.00E-01 | 6.19E-31 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = IRRIGATED STORED FEED--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.84E-02 | 3.59E+00 | 4.30E-02 | 0.00E-01 | 1.52E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.26E-08 | 2.62E-05 | 3.25E-08 | 0.00E-01 | 4.09E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 1.10E-01 | 4.17E+01 | 8.70E-01 | 0.00E-01 | 1.68E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 1.29E+03 | 5.97E+05 | 2.25E+03 | 2.13E+03 | 4.06E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 9.66E+01 | 2.13E+03 | 7.23E+02 | 2.60E+02 | 0.00E-01 | 2.02E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 2.42E+02 | 5.08E+03 | 2.04E+03 | 7.23E+02 | 8.26E+03 | 4.84E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 5.89E-03 | 2.11E+00 | 2.74E-02 | 9.70E-03 | 1.11E-01 | 1.89E-02 | 0.00E-01 | 0.00E-01 |
| TE129M | 4.20E+02 | 9.97E+03 | 2.66E+03 | 9.86E+02 | 1.11E+04 | 8.57E+02 | 0.00E-01 | 0.00E-01 |
| TE129 | 1.74E-15 | 3.91E-14 | 7.16E-15 | 2.67E-15 | 3.00E-14 | 5.11E-15 | 0.00E-01 | 0.00E-01 |
| TE131M | 6.24E+00 | 6.01E+02 | 1.56E+01 | 7.49E+00 | 7.81E+01 | 1.13E+01 | 0.00E-01 | 0.00E-01 |
| TE131 | 4.37E-30 | 1.15E-30 | 1.40E-29 | 5.76E-30 | 6.11E-29 | 1.08E-29 | 0.00E-01 | 0.00E-01 |
| TE132 | 6.17E+01 | 2.08E+03 | 1.04E+02 | 6.56E+01 | 6.29E+02 | 6.92E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 3.90E+00 | 7.50E+00 | 3.37E+00 | 9.76E+00 | 1.50E+01 | 7.95E+02 | 0.00E-01 | 0.00E-01 |
| I 131 | 1.95E+03 | 7.17E+02 | 2.59E+03 | 3.63E+03 | 6.24E+03 | 1.06E+06 | 0.00E-01 | 0.00E-01 |
| I 132 | 9.99E-07 | 1.21E-06 | 1.06E-06 | 2.78E-06 | 4.38E-06 | 9.38E-05 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.72E+01 | 4.26E+01 | 3.32E+01 | 5.63E+01 | 9.88E+01 | 7.86E+03 | 0.00E-01 | 0.00E-01 |
| I 134 | 7.32E-18 | 2.68E-19 | 7.69E-18 | 2.04E-17 | 3.21E-17 | 3.39E-16 | 0.00E-01 | 0.00E-01 |
| I 135 | 9.40E-02 | 2.81E-01 | 9.85E-02 | 2.54E-01 | 4.00E-01 | 1.63E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 2.47E+05 | 6.63E+03 | 2.26E+05 | 5.33E+05 | 1.69E+05 | 0.00E-01 | 6.46E+04 | 0.00E-01 |
| CS136 | 2.85E+04 | 3.41E+03 | 1.08E+04 | 4.24E+04 | 2.31E+04 | 0.00E-01 | 3.64E+03 | 0.00E-01 |
| CS137 | 1.43E+05 | 5.86E+03 | 3.09E+05 | 4.12E+05 | 1.40E+05 | 0.00E-01 | 5.44E+04 | 0.00E-01 |
| CS138 | 8.32E-28 | 7.55E-31 | 8.67E-28 | 1.66E-27 | 1.23E-27 | 0.00E-01 | 1.43E-28 | 0.00E-01 |
| BA139 | 3.00E-14 | 9.18E-12 | 1.03E-12 | 7.24E-16 | 6.83E-16 | 0.00E-01 | 4.99E-16 | 0.00E-01 |
| BA140 | 7.54E+01 | 1.80E+03 | 1.17E+03 | 1.43E+00 | 4.86E-01 | 0.00E-01 | 9.64E-01 | 0.00E-01 |
| BA141 | 1.76E-31 | 1.12E-35 | 5.28E-30 | 3.94E-33 | 3.66E-33 | 0.00E-01 | 2.70E-33 | 0.00E-01 |
| BA142 | 1.69E-32 | 8.44E-43 | 2.75E-31 | 2.75E-34 | 2.32E-34 | 0.00E-01 | 1.83E-34 | 0.00E-01 |
| LA140 | 2.53E-05 | 5.46E+00 | 1.93E-04 | 9.51E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 2.89E-17 | 3.54E-12 | 2.62E-16 | 1.16E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 1.62E-02 | 4.04E+02 | 2.12E-01 | 1.41E-01 | 6.65E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 1.48E-04 | 4.00E+01 | 1.83E-03 | 1.33E+00 | 5.96E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 8.18E-01 | 3.83E+03 | 1.52E+01 | 6.30E+00 | 3.76E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 3.49E-04 | 2.30E+01 | 7.00E-03 | 2.80E-03 | 1.63E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 1.77E-36 | 3.86E-38 | 3.50E-35 | 1.43E-35 | 8.22E-36 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 2.87E-04 | 1.73E+01 | 4.40E-03 | 4.78E-03 | 2.81E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 8.08E-02 | 6.24E+01 | 2.83E-01 | 2.31E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 8.81E-06 | 2.55E+00 | 1.68E-04 | 1.59E-05 | 4.98E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = IRRIGATED STORED FEED-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 9.85E-01 | 9.85E-01 | 0.00E-01 | 9.85E-01 | 9.85E-01 | 9.85E-01 | 9.85E-01 | 0.00E-01 |
| C 14 | 5.17E+03 | 5.17E+03 | 2.58E+04 | 5.17E+03 | 5.17E+03 | 5.17E+03 | 5.17E+03 | 0.00E-01 |
| NA 24 | 2.74E-08 | 2.74E-08 | 2.74E-08 | 2.74E-08 | 2.74E-08 | 2.74E-08 | 2.74E-08 | 0.00E-01 |
| P 32 | 3.71E+03 | 8.03E+03 | 9.56E+04 | 5.92E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.35E-01 | 2.26E+01 | 0.00E-01 | 0.00E-01 | 2.95E-02 | 7.48E-02 | 1.92E-01 | 0.00E-01 |
| MN 54 | 3.22E+01 | 3.33E+02 | 0.00E-01 | 1.62E+02 | 4.84E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 4.47E-29 | 1.65E-26 | 0.00E-01 | 2.51E-28 | 3.18E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 9.06E+02 | 1.68E+03 | 5.48E+03 | 3.89E+03 | 0.00E-01 | 0.00E-01 | 2.47E+03 | 0.00E-01 |
| FE 59 | 4.53E+03 | 2.77E+04 | 5.03E+03 | 1.17E+04 | 0.00E-01 | 0.00E-01 | 3.70E+03 | 0.00E-01 |
| CO 58 | 7.62E+02 | 4.56E+03 | 0.00E-01 | 3.31E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 3.03E+03 | 1.75E+04 | 0.00E-01 | 1.35E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.20E+04 | 3.98E+03 | 3.54E+05 | 2.50E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 4.49E-27 | 5.34E-25 | 7.71E-26 | 9.85E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 2.29E-12 | 3.77E-10 | 0.00E-01 | 4.86E-12 | 1.23E-11 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 9.59E+03 | 8.71E+03 | 5.92E+03 | 2.06E+04 | 1.32E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 2.74E-29 | 7.21E-28 | 2.05E-28 | 3.91E-28 | 2.56E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 2.72E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 2.76E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 1.94E-36 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 4.61E+03 | 1.45E+03 | 0.00E-01 | 9.81E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 4.17E-29 | 6.70E-36 | 0.00E-01 | 7.82E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 2.05E-29 | 4.45E-38 | 0.00E-01 | 2.90E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.75E+02 | 7.26E+02 | 6.10E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 7.68E+03 | 8.77E+03 | 3.84E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.13E-16 | 1.28E-14 | 2.83E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 1.67E-28 | 9.95E-26 | 3.91E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 5.92E-05 | 1.81E+01 | 2.20E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 8.26E-33 | 1.02E-29 | 2.16E-31 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 6.04E-01 | 9.23E+03 | 2.25E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 4.76E-31 | 4.51E-25 | 1.64E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 2.39E-18 | 2.66E-12 | 8.71E-17 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 7.67E+00 | 2.57E+04 | 3.53E+01 | 1.11E+01 | 1.64E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 3.68E-11 | 2.17E-05 | 4.04E-10 | 8.00E-11 | 1.21E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 1.31E+01 | 1.02E+05 | 4.28E+01 | 2.38E+01 | 2.30E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 3.77E-01 | 3.54E+00 | 0.00E-01 | 1.98E+00 | 4.53E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 2.86E-24 | 1.45E-22 | 7.90E-26 | 2.20E-25 | 3.28E-24 | 0.00E-01 | 1.22E-25 | 0.00E-01 |
| TC101 | 2.60E-29 | 4.52E-37 | 1.86E-30 | 2.64E-30 | 4.78E-29 | 0.00E-01 | 1.61E-30 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = IRRIGATED STORED FEED--MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 8.70E+02 | 1.70E+05 | 2.04E+03 | 0.00E-01 | 7.18E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.30E-26 | 2.70E-23 | 3.34E-26 | 0.00E-01 | 4.21E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 6.89E+03 | 2.62E+06 | 5.47E+04 | 0.00E-01 | 1.05E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 6.80E+01 | 3.14E+04 | 1.18E+02 | 1.12E+02 | 2.13E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 9.75E+02 | 2.15E+04 | 7.30E+03 | 2.63E+03 | 0.00E-01 | 2.04E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 2.70E+03 | 5.67E+04 | 2.27E+04 | 8.06E+03 | 9.21E+04 | 5.41E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 8.99E-16 | 3.23E-13 | 4.18E-15 | 1.48E-15 | 1.69E-14 | 2.88E-15 | 0.00E-01 | 0.00E-01 |
| TE129M | 3.63E+03 | 8.60E+04 | 2.29E+04 | 8.50E+03 | 9.59E+04 | 7.39E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 5.47E-28 | 1.23E-26 | 2.25E-27 | 8.39E-28 | 9.44E-27 | 1.61E-27 | 0.00E-01 | 0.00E-01 |
| TE131M | 3.60E-03 | 3.47E-01 | 9.01E-03 | 4.32E-03 | 4.50E-02 | 6.50E-03 | 0.00E-01 | 0.00E-01 |
| TE131 | 5.47E-29 | 1.44E-29 | 1.75E-28 | 7.21E-29 | 7.65E-28 | 1.35E-28 | 0.00E-01 | 0.00E-01 |
| TE132 | 1.68E+01 | 5.67E+02 | 2.82E+01 | 1.79E+01 | 1.72E+02 | 1.89E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 8.90E-12 | 1.71E-11 | 7.70E-12 | 2.23E-11 | 3.43E-11 | 1.82E-09 | 0.00E-01 | 0.00E-01 |
| I 131 | 3.24E+01 | 1.19E+01 | 4.31E+01 | 6.03E+01 | 1.04E+02 | 1.76E+04 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.31E-27 | 1.59E-27 | 1.40E-27 | 3.66E-27 | 5.76E-27 | 1.23E-25 | 0.00E-01 | 0.00E-01 |
| I 133 | 7.63E-07 | 1.89E-06 | 1.47E-06 | 2.50E-06 | 4.39E-06 | 3.49E-04 | 0.00E-01 | 0.00E-01 |
| I 134 | 1.63E-28 | 5.98E-30 | 1.71E-28 | 4.54E-28 | 7.15E-28 | 7.56E-27 | 0.00E-01 | 0.00E-01 |
| I 135 | 1.40E-22 | 4.18E-22 | 1.47E-22 | 3.78E-22 | 5.96E-22 | 2.43E-20 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.32E+04 | 3.53E+02 | 1.21E+04 | 2.84E+04 | 9.02E+03 | 0.00E-01 | 3.44E+03 | 0.00E-01 |
| CS136 | 5.95E+02 | 7.13E+01 | 2.25E+02 | 8.87E+02 | 4.83E+02 | 0.00E-01 | 7.61E+01 | 0.00E-01 |
| CS137 | 7.76E+03 | 3.17E+02 | 1.67E+04 | 2.23E+04 | 7.58E+03 | 0.00E-01 | 2.95E+03 | 0.00E-01 |
| CS138 | 4.51E-29 | 4.09E-32 | 4.69E-29 | 9.01E-29 | 6.65E-29 | 0.00E-01 | 7.74E-30 | 0.00E-01 |
| BA139 | 1.10E-29 | 3.36E-27 | 3.76E-28 | 2.65E-31 | 2.49E-31 | 0.00E-01 | 1.82E-31 | 0.00E-01 |
| BA140 | 3.70E+01 | 8.84E+02 | 5.73E+02 | 7.03E-01 | 2.38E-01 | 0.00E-01 | 4.73E-01 | 0.00E-01 |
| BA141 | 2.29E-31 | 1.46E-35 | 6.86E-30 | 5.12E-33 | 4.76E-33 | 0.00E-01 | 3.51E-33 | 0.00E-01 |
| BA142 | 2.20E-32 | 1.10E-42 | 3.57E-31 | 3.57E-34 | 3.02E-34 | 0.00E-01 | 2.38E-34 | 0.00E-01 |
| LA140 | 9.71E-08 | 2.10E-02 | 7.43E-07 | 3.65E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 3.96E-33 | 4.84E-28 | 3.58E-32 | 1.59E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 2.16E-02 | 5.37E+02 | 2.81E-01 | 1.88E-01 | 8.83E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 3.45E-08 | 9.28E-03 | 4.24E-07 | 3.09E-04 | 1.38E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.53E+00 | 7.15E+03 | 2.84E+01 | 1.18E+01 | 7.02E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 2.13E-02 | 1.41E+03 | 4.27E-01 | 1.71E-01 | 9.92E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 2.71E-34 | 5.89E-36 | 5.34E-33 | 2.19E-33 | 1.26E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 9.98E-03 | 6.01E+02 | 1.53E-01 | 1.67E-01 | 9.79E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 1.25E-07 | 9.64E-05 | 4.37E-07 | 3.56E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 2.89E-07 | 8.38E-02 | 5.52E-06 | 5.21E-07 | 1.63E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = ANIMAL DRINKING WATER-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 6.61E+00 | 6.61E+00 | 0.00E-01 | 6.61E+00 | 6.61E+00 | 6.61E+00 | 6.61E+00 | 0.00E-01 |
| C 14 | 1.17E+02 | 1.17E+02 | 5.87E+02 | 1.17E+02 | 1.17E+02 | 1.17E+02 | 1.17E+02 | 0.00E-01 |
| NA 24 | 1.16E+02 | 1.16E+02 | 1.16E+02 | 1.16E+02 | 1.16E+02 | 1.16E+02 | 1.16E+02 | 0.00E-01 |
| P 32 | 2.92E+03 | 6.33E+03 | 7.53E+04 | 4.66E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 9.06E-02 | 1.52E+01 | 0.00E-01 | 0.00E-01 | 1.99E-02 | 5.03E-02 | 1.29E-01 | 0.00E-01 |
| MN 54 | 3.51E+00 | 3.63E+01 | 0.00E-01 | 1.77E+01 | 5.28E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 1.52E-07 | 5.62E-05 | 0.00E-01 | 8.54E-07 | 1.08E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 9.02E+00 | 1.67E+01 | 5.45E+01 | 3.87E+01 | 0.00E-01 | 0.00E-01 | 2.45E+01 | 0.00E-01 |
| FE 59 | 7.41E+01 | 4.54E+02 | 8.22E+01 | 1.92E+02 | 0.00E-01 | 0.00E-01 | 6.05E+01 | 0.00E-01 |
| CO 58 | 2.64E+01 | 1.58E+02 | 0.00E-01 | 1.15E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 7.62E+01 | 4.40E+02 | 0.00E-01 | 3.38E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 4.84E+02 | 1.61E+02 | 1.43E+04 | 1.01E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 4.94E-06 | 5.87E-04 | 8.48E-05 | 1.08E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 6.25E-01 | 1.03E+02 | 0.00E-01 | 1.33E+00 | 3.36E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 4.36E+03 | 3.95E+03 | 2.69E+03 | 9.34E+03 | 5.98E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 2.58E-16 | 6.80E-15 | 1.94E-15 | 3.69E-15 | 2.41E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 2.35E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 1.03E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 8.05E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 4.69E+03 | 1.48E+03 | 0.00E-01 | 9.98E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 1.40E-26 | 2.25E-33 | 0.00E-01 | 2.62E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 8.07E-27 | 1.75E-35 | 0.00E-01 | 1.14E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.18E+02 | 4.91E+02 | 4.12E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.96E+03 | 2.24E+03 | 9.83E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 8.61E-02 | 9.82E+00 | 2.16E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 4.56E-06 | 2.72E-03 | 1.07E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 2.62E-05 | 8.02E+00 | 9.72E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 8.39E-25 | 1.04E-21 | 2.19E-23 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 6.34E-04 | 9.69E+00 | 2.36E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 2.97E-10 | 2.82E-04 | 1.03E-08 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 4.35E-07 | 4.85E-01 | 1.59E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 5.27E-04 | 1.77E+00 | 2.43E-03 | 7.66E-04 | 1.12E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 1.74E-06 | 1.02E+00 | 1.91E-05 | 3.78E-06 | 5.73E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 7.26E-02 | 5.64E+02 | 2.38E-01 | 1.32E-01 | 1.28E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 6.21E+01 | 5.83E+02 | 0.00E-01 | 3.25E+02 | 7.45E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 1.28E-02 | 6.47E-01 | 3.53E-04 | 9.86E-04 | 1.47E-02 | 0.00E-01 | 5.47E-04 | 0.00E-01 |
| TC101 | 7.08E-28 | 1.23E-35 | 5.07E-29 | 7.21E-29 | 1.30E-27 | 0.00E-01 | 4.39E-29 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = ANIMAL DRINKING WATER-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.27E-03 | 2.48E-01 | 2.96E-03 | 0.00E-01 | 1.04E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 4.82E-08 | 1.00E-04 | 1.24E-07 | 0.00E-01 | 1.57E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 5.93E-03 | 2.26E+00 | 4.70E-02 | 0.00E-01 | 9.07E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 7.07E+01 | 3.26E+04 | 1.23E+02 | 1.16E+02 | 2.21E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 6.02E+00 | 1.33E+02 | 4.50E+01 | 1.62E+01 | 0.00E-01 | 1.26E+01 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.37E+01 | 2.86E+02 | 1.15E+02 | 4.08E+01 | 4.66E+02 | 2.73E+01 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.08E-02 | 3.88E+00 | 5.03E-02 | 1.78E-02 | 2.04E-01 | 3.47E-02 | 0.00E-01 | 0.00E-01 |
| TE129M | 2.98E+01 | 7.07E+02 | 1.88E+02 | 6.98E+01 | 7.87E+02 | 6.07E+01 | 0.00E-01 | 0.00E-01 |
| TE129 | 2.52E-14 | 5.66E-13 | 1.03E-13 | 3.86E-14 | 4.34E-13 | 7.39E-14 | 0.00E-01 | 0.00E-01 |
| TE131M | 3.79E+00 | 3.64E+02 | 9.47E+00 | 4.54E+00 | 4.73E+01 | 6.83E+00 | 0.00E-01 | 0.00E-01 |
| TE131 | 1.75E-28 | 4.59E-29 | 5.60E-28 | 2.31E-28 | 2.45E-27 | 4.31E-28 | 0.00E-01 | 0.00E-01 |
| TE132 | 1.62E+01 | 5.46E+02 | 2.72E+01 | 1.72E+01 | 1.65E+02 | 1.82E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 5.49E+00 | 1.06E+01 | 4.75E+00 | 1.37E+01 | 2.12E+01 | 1.12E+03 | 0.00E-01 | 0.00E-01 |
| I 131 | 2.67E+02 | 9.82E+01 | 3.54E+02 | 4.96E+02 | 8.54E+02 | 1.45E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 7.33E-06 | 8.89E-06 | 7.80E-06 | 2.04E-05 | 3.22E-05 | 6.88E-04 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.47E+01 | 3.65E+01 | 2.84E+01 | 4.82E+01 | 8.45E+01 | 6.73E+03 | 0.00E-01 | 0.00E-01 |
| I 134 | 1.41E-16 | 5.16E-18 | 1.48E-16 | 3.91E-16 | 6.17E-16 | 6.52E-15 | 0.00E-01 | 0.00E-01 |
| I 135 | 2.44E-01 | 7.29E-01 | 2.55E-01 | 6.57E-01 | 1.04E+00 | 4.23E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.32E+04 | 3.53E+02 | 1.21E+04 | 2.84E+04 | 9.03E+03 | 0.00E-01 | 3.45E+03 | 0.00E-01 |
| CS136 | 2.94E+03 | 3.53E+02 | 1.11E+03 | 4.38E+03 | 2.39E+03 | 0.00E-01 | 3.76E+02 | 0.00E-01 |
| CS137 | 7.50E+03 | 3.06E+02 | 1.62E+04 | 2.15E+04 | 7.33E+03 | 0.00E-01 | 2.85E+03 | 0.00E-01 |
| CS138 | 2.60E-26 | 2.36E-29 | 2.71E-26 | 5.20E-26 | 3.84E-26 | 0.00E-01 | 4.46E-27 | 0.00E-01 |
| BA139 | 3.67E-13 | 1.12E-10 | 1.26E-11 | 8.87E-15 | 8.36E-15 | 0.00E-01 | 6.11E-15 | 0.00E-01 |
| BA140 | 7.89E+00 | 1.89E+02 | 1.22E+02 | 1.50E-01 | 5.09E-02 | 0.00E-01 | 1.01E-01 | 0.00E-01 |
| BA141 | 9.71E-30 | 6.20E-34 | 2.91E-28 | 2.17E-31 | 2.02E-31 | 0.00E-01 | 1.49E-31 | 0.00E-01 |
| BA142 | 1.59E-30 | 7.93E-41 | 2.58E-29 | 2.58E-32 | 2.19E-32 | 0.00E-01 | 1.72E-32 | 0.00E-01 |
| LA140 | 1.18E-05 | 2.55E+00 | 9.02E-05 | 4.43E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 3.16E-16 | 3.87E-11 | 2.86E-15 | 1.27E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 1.18E-03 | 2.93E+01 | 1.53E-02 | 1.02E-02 | 4.82E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 8.25E-05 | 2.22E+01 | 1.02E-03 | 7.39E-01 | 3.31E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 4.48E-02 | 2.10E+02 | 8.34E-01 | 3.45E-01 | 2.06E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 3.54E-05 | 2.34E+00 | 7.11E-04 | 2.84E-04 | 1.65E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 1.03E-34 | 2.25E-36 | 2.04E-33 | 8.35E-34 | 4.79E-34 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 3.24E-05 | 1.95E+00 | 4.97E-04 | 5.41E-04 | 3.18E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 6.07E-02 | 4.69E+01 | 2.13E-01 | 1.73E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 3.05E-06 | 8.83E-01 | 5.82E-05 | 5.49E-06 | 1.72E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = ANIMAL DRINKING WATER--MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem/gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 9.85E-01 | 9.85E-01 | 0.00E-01 | 9.85E-01 | 9.85E-01 | 9.85E-01 | 9.85E-01 | 0.00E-01 |
| C 14 | 4.10E+01 | 4.10E+01 | 2.05E+02 | 4.10E+01 | 4.10E+01 | 4.10E+01 | 4.10E+01 | 0.00E-01 |
| NA 24 | 2.66E-08 | 2.66E-08 | 2.66E-08 | 2.66E-08 | 2.66E-08 | 2.66E-08 | 2.66E-08 | 0.00E-01 |
| P 32 | 3.04E+02 | 6.59E+02 | 7.84E+03 | 4.86E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 8.53E-03 | 1.43E+00 | 0.00E-01 | 0.00E-01 | 1.87E-03 | 4.74E-03 | 1.22E-02 | 0.00E-01 |
| MN 54 | 1.46E+00 | 1.51E+01 | 0.00E-01 | 7.36E+00 | 2.20E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 2.45E-28 | 9.07E-26 | 0.00E-01 | 1.38E-27 | 1.74E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 4.02E+01 | 7.46E+01 | 2.43E+02 | 1.72E+02 | 0.00E-01 | 0.00E-01 | 1.09E+02 | 0.00E-01 |
| FE 59 | 2.53E+02 | 1.55E+03 | 2.80E+02 | 6.54E+02 | 0.00E-01 | 0.00E-01 | 2.06E+02 | 0.00E-01 |
| CO 58 | 3.90E+01 | 2.34E+02 | 0.00E-01 | 1.69E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.33E+02 | 7.70E+02 | 0.00E-01 | 5.91E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 5.18E+02 | 1.72E+02 | 1.53E+04 | 1.08E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 2.51E-26 | 2.98E-24 | 4.31E-25 | 5.50E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 2.62E-12 | 4.32E-10 | 0.00E-01 | 5.56E-12 | 1.41E-11 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 4.31E+02 | 3.91E+02 | 2.66E+02 | 9.24E+02 | 5.92E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 4.04E-28 | 1.06E-26 | 3.03E-27 | 5.78E-27 | 3.77E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.60E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 7.26E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 5.67E-34 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 3.37E+02 | 1.06E+02 | 0.00E-01 | 7.17E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 1.96E-27 | 3.15E-34 | 0.00E-01 | 3.67E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 1.13E-27 | 2.45E-36 | 0.00E-01 | 1.60E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 9.36E+00 | 3.89E+01 | 3.27E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.99E+02 | 2.28E+02 | 9.97E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.70E-16 | 1.94E-14 | 4.28E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 8.63E-28 | 5.16E-25 | 2.02E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 1.54E-05 | 4.70E+00 | 5.70E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 1.40E-31 | 1.73E-28 | 3.66E-30 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 3.19E-02 | 4.88E+02 | 1.19E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 1.89E-30 | 1.79E-24 | 6.54E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 3.41E-18 | 3.80E-12 | 1.24E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 3.99E-01 | 1.34E+03 | 1.84E+00 | 5.81E-01 | 8.53E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 3.20E-11 | 1.88E-05 | 3.51E-10 | 6.95E-11 | 1.05E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 7.72E-01 | 6.00E+03 | 2.53E+00 | 1.40E+00 | 1.36E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 9.56E-02 | 8.97E-01 | 0.00E-01 | 5.01E-01 | 1.15E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 6.74E-24 | 3.42E-22 | 1.87E-25 | 5.20E-25 | 7.75E-24 | 0.00E-01 | 2.89E-25 | 0.00E-01 |
| TC101 | 1.53E-27 | 2.67E-35 | 1.10E-28 | 1.56E-28 | 2.82E-27 | 0.00E-01 | 9.51E-29 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = ANIMAL DRINKING WATER-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 4.99E+01 | 9.76E+03 | 1.17E+02 | 0.00E-01 | 4.12E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 4.13E-26 | 8.60E-23 | 1.06E-25 | 0.00E-01 | 1.34E-24 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 3.10E+02 | 1.18E+05 | 2.46E+03 | 0.00E-01 | 4.75E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 3.10E+00 | 1.43E+03 | 5.38E+00 | 5.09E+00 | 9.70E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 5.06E+01 | 1.12E+03 | 3.79E+02 | 1.36E+02 | 0.00E-01 | 1.06E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.27E+02 | 2.66E+03 | 1.07E+03 | 3.79E+02 | 4.33E+03 | 2.54E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.38E-15 | 4.94E-13 | 6.40E-15 | 2.27E-15 | 2.59E-14 | 4.41E-15 | 0.00E-01 | 0.00E-01 |
| TE129M | 2.14E+02 | 5.08E+03 | 1.35E+03 | 5.02E+02 | 5.66E+03 | 4.37E+02 | 0.00E-01 | 0.00E-01 |
| TE129 | 6.59E-27 | 1.48E-25 | 2.71E-26 | 1.01E-26 | 1.14E-25 | 1.94E-26 | 0.00E-01 | 0.00E-01 |
| TE131M | 1.82E-03 | 1.75E-01 | 4.55E-03 | 2.18E-03 | 2.28E-02 | 3.28E-03 | 0.00E-01 | 0.00E-01 |
| TE131 | 1.82E-27 | 4.79E-28 | 5.84E-27 | 2.41E-27 | 2.55E-26 | 4.50E-27 | 0.00E-01 | 0.00E-01 |
| TE132 | 3.69E+00 | 1.24E+02 | 6.19E+00 | 3.92E+00 | 3.76E+01 | 4.13E+00 | 0.00E-01 | 0.00E-01 |
| I 130 | 1.04E-11 | 2.01E-11 | 9.04E-12 | 2.62E-11 | 4.03E-11 | 2.13E-09 | 0.00E-01 | 0.00E-01 |
| I 131 | 3.70E+00 | 1.36E+00 | 4.91E+00 | 6.88E+00 | 1.18E+01 | 2.01E+03 | 0.00E-01 | 0.00E-01 |
| I 132 | 8.03E-27 | 9.74E-27 | 8.55E-27 | 2.24E-26 | 3.52E-26 | 7.54E-25 | 0.00E-01 | 0.00E-01 |
| I 133 | 5.44E-07 | 1.35E-06 | 1.05E-06 | 1.78E-06 | 3.13E-06 | 2.49E-04 | 0.00E-01 | 0.00E-01 |
| I 134 | 2.61E-27 | 9.57E-29 | 2.74E-27 | 7.26E-27 | 1.14E-26 | 1.21E-25 | 0.00E-01 | 0.00E-01 |
| I 135 | 3.02E-22 | 9.04E-22 | 3.17E-22 | 8.16E-22 | 1.29E-21 | 5.25E-20 | 0.00E-01 | 0.00E-01 |
| CS134 | 5.85E+02 | 1.57E+01 | 5.36E+02 | 1.26E+03 | 4.01E+02 | 0.00E-01 | 1.53E+02 | 0.00E-01 |
| CS136 | 5.13E+01 | 6.15E+00 | 1.94E+01 | 7.64E+01 | 4.16E+01 | 0.00E-01 | 6.56E+00 | 0.00E-01 |
| CS137 | 3.38E+02 | 1.38E+01 | 7.30E+02 | 9.71E+02 | 3.30E+02 | 0.00E-01 | 1.28E+02 | 0.00E-01 |
| CS138 | 1.17E-27 | 1.06E-30 | 1.22E-27 | 2.35E-27 | 1.73E-27 | 0.00E-01 | 2.01E-28 | 0.00E-01 |
| BA139 | 1.12E-28 | 3.42E-26 | 3.84E-27 | 2.70E-30 | 2.55E-30 | 0.00E-01 | 1.86E-30 | 0.00E-01 |
| BA140 | 3.22E+00 | 7.72E+01 | 5.00E+01 | 6.13E-02 | 2.08E-02 | 0.00E-01 | 4.12E-02 | 0.00E-01 |
| BA141 | 1.05E-29 | 6.72E-34 | 3.15E-28 | 2.35E-31 | 2.18E-31 | 0.00E-01 | 1.61E-31 | 0.00E-01 |
| BA142 | 1.72E-30 | 8.59E-41 | 2.80E-29 | 2.80E-32 | 2.37E-32 | 0.00E-01 | 1.86E-32 | 0.00E-01 |
| LA140 | 3.77E-08 | 8.14E-03 | 2.89E-07 | 1.42E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 3.61E-32 | 4.41E-27 | 3.26E-31 | 1.45E-31 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 1.30E-03 | 3.24E+01 | 1.70E-02 | 1.13E-02 | 5.33E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 1.60E-08 | 4.30E-03 | 1.96E-07 | 1.43E-04 | 6.41E-08 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 6.97E-02 | 3.26E+02 | 1.30E+00 | 5.37E-01 | 3.21E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.80E-03 | 1.19E+02 | 3.62E-02 | 1.44E-02 | 8.39E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 1.32E-32 | 2.86E-34 | 2.60E-31 | 1.06E-31 | 6.10E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 9.40E-04 | 5.66E+01 | 1.44E-02 | 1.57E-02 | 9.22E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 7.81E-08 | 6.03E-05 | 2.74E-07 | 2.23E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 8.34E-08 | 2.42E-02 | 1.59E-06 | 1.50E-07 | 4.71E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = RIVER SHORELINE DEPOSITS

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 1.05E+01 | 1.05E+01 | 1.05E+01 | 1.05E+01 | 1.05E+01 | 1.05E+01 | 1.05E+01 | 1.22E+01 |
| P 32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 4.09E+00 | 4.09E+00 | 4.09E+00 | 4.09E+00 | 4.09E+00 | 4.09E+00 | 4.09E+00 | 4.84E+00 |
| MN 54 | 1.22E+03 | 1.22E+03 | 1.22E+03 | 1.22E+03 | 1.22E+03 | 1.22E+03 | 1.22E+03 | 1.43E+03 |
| MN 56 | 7.70E-01 | 7.70E-01 | 7.70E-01 | 7.70E-01 | 7.70E-01 | 7.70E-01 | 7.70E-01 | 9.10E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 2.40E+02 | 2.40E+02 | 2.40E+02 | 2.40E+02 | 2.40E+02 | 2.40E+02 | 2.40E+02 | 2.82E+02 |
| CO 58 | 3.34E+02 | 3.34E+02 | 3.34E+02 | 3.34E+02 | 3.34E+02 | 3.34E+02 | 3.34E+02 | 3.91E+02 |
| CO 60 | 1.89E+04 | 1.89E+04 | 1.89E+04 | 1.89E+04 | 1.89E+04 | 1.89E+04 | 1.89E+04 | 2.22E+04 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 2.54E-01 | 2.54E-01 | 2.54E-01 | 2.54E-01 | 2.54E-01 | 2.54E-01 | 2.54E-01 | 2.95E-01 |
| CU 64 | 5.29E-01 | 5.29E-01 | 5.29E-01 | 5.29E-01 | 5.29E-01 | 5.29E-01 | 5.29E-01 | 6.00E-01 |
| ZN 65 | 6.56E+02 | 6.56E+02 | 6.56E+02 | 6.56E+02 | 6.56E+02 | 6.56E+02 | 6.56E+02 | 7.54E+02 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 4.16E-03 | 4.16E-03 | 4.16E-03 | 4.16E-03 | 4.16E-03 | 4.16E-03 | 4.16E-03 | 6.05E-03 |
| BR 84 | 1.56E-01 | 1.56E-01 | 1.56E-01 | 1.56E-01 | 1.56E-01 | 1.56E-01 | 1.56E-01 | 1.83E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 7.92E+00 | 7.92E+00 | 7.92E+00 | 7.92E+00 | 7.92E+00 | 7.92E+00 | 7.92E+00 | 9.05E+00 |
| RB 88 | 2.31E-02 | 2.31E-02 | 2.31E-02 | 2.31E-02 | 2.31E-02 | 2.31E-02 | 2.31E-02 | 2.64E-02 |
| RB 89 | 8.14E-02 | 8.14E-02 | 8.14E-02 | 8.14E-02 | 8.14E-02 | 8.14E-02 | 8.14E-02 | 9.76E-02 |
| SR 89 | 1.90E-02 | 1.90E-02 | 1.90E-02 | 1.90E-02 | 1.90E-02 | 1.90E-02 | 1.90E-02 | 2.21E-02 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.87E+00 | 1.87E+00 | 1.87E+00 | 1.87E+00 | 1.87E+00 | 1.87E+00 | 1.87E+00 | 2.19E+00 |
| SR 92 | 6.66E-01 | 6.66E-01 | 6.66E-01 | 6.66E-01 | 6.66E-01 | 6.66E-01 | 6.66E-01 | 7.40E-01 |
| Y 90 | 3.95E-03 | 3.95E-03 | 3.95E-03 | 3.95E-03 | 3.95E-03 | 3.95E-03 | 3.95E-03 | 4.67E-03 |
| Y 91M | 8.09E-02 | 8.09E-02 | 8.09E-02 | 8.09E-02 | 8.09E-02 | 8.09E-02 | 8.09E-02 | 9.36E-02 |
| Y 91 | 9.45E-01 | 9.45E-01 | 9.45E-01 | 9.45E-01 | 9.45E-01 | 9.45E-01 | 9.45E-01 | 1.06E+00 |
| Y 92 | 1.56E-01 | 1.56E-01 | 1.56E-01 | 1.56E-01 | 1.56E-01 | 1.56E-01 | 1.56E-01 | 1.85E-01 |
| Y 93 | 1.60E-01 | 1.60E-01 | 1.60E-01 | 1.60E-01 | 1.60E-01 | 1.60E-01 | 1.60E-01 | 2.19E-01 |
| ZR 95 | 2.16E+02 | 2.16E+02 | 2.16E+02 | 2.16E+02 | 2.16E+02 | 2.16E+02 | 2.16E+02 | 2.50E+02 |
| ZR 97 | 2.59E+00 | 2.59E+00 | 2.59E+00 | 2.59E+00 | 2.59E+00 | 2.59E+00 | 2.59E+00 | 3.02E+00 |
| NB 95 | 1.21E+02 | 1.21E+02 | 1.21E+02 | 1.21E+02 | 1.21E+02 | 1.21E+02 | 1.21E+02 | 1.42E+02 |
| MO 99 | 3.51E+00 | 3.51E+00 | 3.51E+00 | 3.51E+00 | 3.51E+00 | 3.51E+00 | 3.51E+00 | 4.06E+00 |
| TC 99M | 1.60E-01 | 1.60E-01 | 1.60E-01 | 1.60E-01 | 1.60E-01 | 1.60E-01 | 1.60E-01 | 1.83E-01 |
| TC101 | 1.33E-02 | 1.33E-02 | 1.33E-02 | 1.33E-02 | 1.33E-02 | 1.33E-02 | 1.33E-02 | 1.48E-02 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER

PATHWAY = RIVER SHORELINE DEPOSITS

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 9.52E+01 | 9.52E+01 | 9.52E+01 | 9.52E+01 | 9.52E+01 | 9.52E+01 | 9.52E+01 | 1.11E+02 |
| RU105 | 5.50E-01 | 5.50E-01 | 5.50E-01 | 5.50E-01 | 5.50E-01 | 5.50E-01 | 5.50E-01 | 6.24E-01 |
| RU106 | 3.71E+02 | 3.71E+02 | 3.71E+02 | 3.71E+02 | 3.71E+02 | 3.71E+02 | 3.71E+02 | 4.45E+02 |
| AG110M | 3.03E+03 | 3.03E+03 | 3.03E+03 | 3.03E+03 | 3.03E+03 | 3.03E+03 | 3.03E+03 | 3.54E+03 |
| TE125M | 1.37E+00 | 1.37E+00 | 1.37E+00 | 1.37E+00 | 1.37E+00 | 1.37E+00 | 1.37E+00 | 1.88E+00 |
| TE127M | 8.06E-02 | 8.06E-02 | 8.06E-02 | 8.06E-02 | 8.06E-02 | 8.06E-02 | 8.06E-02 | 9.53E-02 |
| TE127 | 2.60E-03 | 2.60E-03 | 2.60E-03 | 2.60E-03 | 2.60E-03 | 2.60E-03 | 2.60E-03 | 2.86E-03 |
| TE129M | 1.74E+01 | 1.74E+01 | 1.74E+01 | 1.74E+01 | 1.74E+01 | 1.74E+01 | 1.74E+01 | 2.03E+01 |
| TE129 | 2.17E-02 | 2.17E-02 | 2.17E-02 | 2.17E-02 | 2.17E-02 | 2.17E-02 | 2.17E-02 | 2.57E-02 |
| TE131M | 7.04E+00 | 7.04E+00 | 7.04E+00 | 7.04E+00 | 7.04E+00 | 7.04E+00 | 7.04E+00 | 8.30E+00 |
| TE131 | 2.18E-02 | 2.18E-02 | 2.18E-02 | 2.18E-02 | 2.18E-02 | 2.18E-02 | 2.18E-02 | 2.58E+01 |
| TE132 | 3.72E+00 | 3.72E+00 | 3.72E+00 | 3.72E+00 | 3.72E+00 | 3.72E+00 | 3.72E+00 | 4.38E+00 |
| I 130 | 4.81E+00 | 4.81E+00 | 4.81E+00 | 4.81E+00 | 4.81E+00 | 4.81E+00 | 4.81E+00 | 5.84E+00 |
| I 131 | 1.51E+01 | 1.51E+01 | 1.51E+01 | 1.51E+01 | 1.51E+01 | 1.51E+01 | 1.51E+01 | 1.84E+01 |
| I 132 | 1.06E+00 | 1.06E+00 | 1.06E+00 | 1.06E+00 | 1.06E+00 | 1.06E+00 | 1.06E+00 | 1.25E+00 |
| I 133 | 2.15E+00 | 2.15E+00 | 2.15E+00 | 2.15E+00 | 2.15E+00 | 2.15E+00 | 2.15E+00 | 2.62E+00 |
| I 134 | 3.62E-01 | 3.62E-01 | 3.62E-01 | 3.62E-01 | 3.62E-01 | 3.62E-01 | 3.62E-01 | 4.30E-01 |
| I 135 | 2.19E+00 | 2.19E+00 | 2.19E+00 | 2.19E+00 | 2.19E+00 | 2.19E+00 | 2.19E+00 | 2.56E+00 |
| CS134 | 6.01E+03 | 6.01E+03 | 6.01E+03 | 6.01E+03 | 6.01E+03 | 6.01E+03 | 6.01E+03 | 7.01E+03 |
| CS136 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.32E+02 | 1.50E+02 |
| CS137 | 9.06E+03 | 9.06E+03 | 9.06E+03 | 9.06E+03 | 9.06E+03 | 9.06E+03 | 9.06E+03 | 1.06E+04 |
| CS138 | 2.78E-01 | 2.78E-01 | 2.78E-01 | 2.78E-01 | 2.78E-01 | 2.78E-01 | 2.78E-01 | 3.18E-01 |
| BA139 | 8.79E-02 | 8.79E-02 | 8.79E-02 | 8.79E-02 | 8.79E-02 | 8.79E-02 | 8.79E-02 | 9.89E-02 |
| BA140 | 1.81E+01 | 1.81E+01 | 1.81E+01 | 1.81E+01 | 1.81E+01 | 1.81E+01 | 1.81E+01 | 2.06E+01 |
| BA141 | 2.92E-02 | 2.92E-02 | 2.92E-02 | 2.92E-02 | 2.92E-02 | 2.92E-02 | 2.92E-02 | 3.33E-02 |
| BA142 | 2.67E-02 | 2.67E-02 | 2.67E-02 | 2.67E-02 | 2.67E-02 | 2.67E-02 | 2.67E-02 | 3.05E-02 |
| LA140 | 1.69E+01 | 1.69E+01 | 1.69E+01 | 1.69E+01 | 1.69E+01 | 1.69E+01 | 1.69E+01 | 1.91E+01 |
| LA142 | 6.19E-01 | 6.19E-01 | 6.19E-01 | 6.19E-01 | 6.19E-01 | 6.19E-01 | 6.19E-01 | 7.43E-01 |
| CE141 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.35E+01 |
| CE143 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.04E+00 | 2.32E+00 |
| CE144 | 6.12E+01 | 6.12E+01 | 6.12E+01 | 6.12E+01 | 6.12E+01 | 6.12E+01 | 6.12E+01 | 7.08E+01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 1.27E-03 | 1.27E-03 | 1.27E-03 | 1.27E-03 | 1.27E-03 | 1.27E-03 | 1.27E-03 | 1.46E-03 |
| ND147 | 7.46E+00 | 7.46E+00 | 7.46E+00 | 7.46E+00 | 7.46E+00 | 7.46E+00 | 7.46E+00 | 8.95E+00 |
| W 187 | 2.07E+00 | 2.07E+00 | 2.07E+00 | 2.07E+00 | 2.07E+00 | 2.07E+00 | 2.07E+00 | 2.40E+00 |
| NP239 | 1.50E+00 | 1.50E+00 | 1.50E+00 | 1.50E+00 | 1.50E+00 | 1.50E+00 | 1.50E+00 | 1.74E+00 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER
PATHWAY = SWIMMING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 1.75E+02 | 1.75E+02 | 1.75E+02 | 1.75E+02 | 1.75E+02 | 1.75E+02 | 1.75E+02 | 0.00E-01 |
| P 32 | 1.45E-01 | 1.45E-01 | 1.45E-01 | 1.45E-01 | 1.45E-01 | 1.45E-01 | 1.45E-01 | 0.00E-01 |
| CR 51 | 1.17E+00 | 1.17E+00 | 1.17E+00 | 1.17E+00 | 1.17E+00 | 1.17E+00 | 1.17E+00 | 0.00E-01 |
| MN 54 | 3.39E+01 | 3.39E+01 | 3.39E+01 | 3.39E+01 | 3.39E+01 | 3.39E+01 | 3.39E+01 | 0.00E-01 |
| MN 56 | 7.03E+01 | 7.03E+01 | 7.03E+01 | 7.03E+01 | 7.03E+01 | 7.03E+01 | 7.03E+01 | 0.00E-01 |
| FE 55 | 1.44E-03 | 1.44E-03 | 1.44E-03 | 1.44E-03 | 1.44E-03 | 1.44E-03 | 1.44E-03 | 0.00E-01 |
| FE 59 | 4.97E+01 | 4.97E+01 | 4.97E+01 | 4.97E+01 | 4.97E+01 | 4.97E+01 | 4.97E+01 | 0.00E-01 |
| CO 58 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 0.00E-01 |
| CO 60 | 1.04E+02 | 1.04E+02 | 1.04E+02 | 1.04E+02 | 1.04E+02 | 1.04E+02 | 1.04E+02 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 2.20E+01 | 2.20E+01 | 2.20E+01 | 2.20E+01 | 2.20E+01 | 2.20E+01 | 2.20E+01 | 0.00E-01 |
| CU 64 | 8.31E+00 | 8.31E+00 | 8.31E+00 | 8.31E+00 | 8.31E+00 | 8.31E+00 | 8.31E+00 | 0.00E-01 |
| ZN 65 | 2.48E+01 | 2.48E+01 | 2.48E+01 | 2.48E+01 | 2.48E+01 | 2.48E+01 | 2.48E+01 | 0.00E-01 |
| ZN 69 | 3.36E-02 | 3.36E-02 | 3.36E-02 | 3.36E-02 | 3.36E-02 | 3.36E-02 | 3.36E-02 | 0.00E-01 |
| BR 83 | 3.73E-01 | 3.73E-01 | 3.73E-01 | 3.73E-01 | 3.73E-01 | 3.73E-01 | 3.73E-01 | 0.00E-01 |
| BR 84 | 6.93E+01 | 6.93E+01 | 6.93E+01 | 6.93E+01 | 6.93E+01 | 6.93E+01 | 6.93E+01 | 0.00E-01 |
| BR 85 | 7.41E-02 | 7.41E-02 | 7.41E-02 | 7.41E-02 | 7.41E-02 | 7.41E-02 | 7.41E-02 | 0.00E-01 |
| RB 86 | 3.84E+00 | 3.84E+00 | 3.84E+00 | 3.84E+00 | 3.84E+00 | 3.84E+00 | 3.84E+00 | 0.00E-01 |
| RB 88 | 2.15E+01 | 2.15E+01 | 2.15E+01 | 2.15E+01 | 2.15E+01 | 2.15E+01 | 2.15E+01 | 0.00E-01 |
| RB 89 | 7.74E+01 | 7.74E+01 | 7.74E+01 | 7.74E+01 | 7.74E+01 | 7.74E+01 | 7.74E+01 | 0.00E-01 |
| SR 89 | 1.04E-01 | 1.04E-01 | 1.04E-01 | 1.04E-01 | 1.04E-01 | 1.04E-01 | 1.04E-01 | 0.00E-01 |
| SR 90 | 1.22E-02 | 1.22E-02 | 1.22E-02 | 1.22E-02 | 1.22E-02 | 1.22E-02 | 1.22E-02 | 0.00E-01 |
| SR 91 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 0.00E-01 |
| SR 92 | 5.72E+01 | 5.72E+01 | 5.72E+01 | 5.72E+01 | 5.72E+01 | 5.72E+01 | 5.72E+01 | 0.00E-01 |
| Y 90 | 2.93E-01 | 2.93E-01 | 2.93E-01 | 2.93E-01 | 2.93E-01 | 2.93E-01 | 2.93E-01 | 0.00E-01 |
| Y 91M | 2.08E+01 | 2.08E+01 | 2.08E+01 | 2.08E+01 | 2.08E+01 | 2.08E+01 | 2.08E+01 | 0.00E-01 |
| Y 91 | 1.51E-01 | 1.51E-01 | 1.51E-01 | 1.51E-01 | 1.51E-01 | 1.51E-01 | 1.51E-01 | 0.00E-01 |
| Y 92 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 0.00E-01 |
| Y 93 | 4.26E+00 | 4.26E+00 | 4.26E+00 | 4.26E+00 | 4.26E+00 | 4.26E+00 | 4.26E+00 | 0.00E-01 |
| ZR 95 | 3.39E+01 | 3.39E+01 | 3.39E+01 | 3.39E+01 | 3.39E+01 | 3.39E+01 | 3.39E+01 | 0.00E-01 |
| ZR 97 | 3.37E+01 | 3.37E+01 | 3.37E+01 | 3.37E+01 | 3.37E+01 | 3.37E+01 | 3.37E+01 | 0.00E-01 |
| NB 95 | 3.16E+01 | 3.16E+01 | 3.16E+01 | 3.16E+01 | 3.16E+01 | 3.16E+01 | 3.16E+01 | 0.00E-01 |
| MO 99 | 1.06E+01 | 1.06E+01 | 1.06E+01 | 1.06E+01 | 1.06E+01 | 1.06E+01 | 1.06E+01 | 0.00E-01 |
| TC 99M | 5.36E+00 | 5.36E+00 | 5.36E+00 | 5.36E+00 | 5.36E+00 | 5.36E+00 | 5.36E+00 | 0.00E-01 |
| TC101 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER
 PATHWAY = SWIMMING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 2.01E+01 | 2.01E+01 | 2.01E+01 | 2.01E+01 | 2.01E+01 | 2.01E+01 | 2.01E+01 | 0.00E-01 |
| RU105 | 2.67E+01 | 2.67E+01 | 2.67E+01 | 2.67E+01 | 2.67E+01 | 2.67E+01 | 2.67E+01 | 0.00E-01 |
| RU106 | 8.58E+00 | 8.58E+00 | 8.58E+00 | 8.58E+00 | 8.58E+00 | 8.58E+00 | 8.58E+00 | 0.00E-01 |
| AG110M | 1.11E+02 | 1.11E+02 | 1.11E+02 | 1.11E+02 | 1.11E+02 | 1.11E+02 | 1.11E+02 | 0.00E-01 |
| TE125M | 8.33E-02 | 8.33E-02 | 8.33E-02 | 8.33E-02 | 8.33E-02 | 8.33E-02 | 8.33E-02 | 0.00E-01 |
| TE127M | 5.87E-03 | 5.87E-03 | 5.87E-03 | 5.87E-03 | 5.87E-03 | 5.87E-03 | 5.87E-03 | 0.00E-01 |
| TE127 | 6.28E-02 | 6.28E-02 | 6.28E-02 | 6.28E-02 | 6.28E-02 | 6.28E-02 | 6.28E-02 | 0.00E-01 |
| TE129M | 4.74E+00 | 4.74E+00 | 4.74E+00 | 4.74E+00 | 4.74E+00 | 4.74E+00 | 4.74E+00 | 0.00E-01 |
| TE129 | 4.04E+00 | 4.04E+00 | 4.04E+00 | 4.04E+00 | 4.04E+00 | 4.04E+00 | 4.04E+00 | 0.00E-01 |
| TE131M | 4.96E+01 | 4.96E+01 | 4.96E+01 | 4.96E+01 | 4.96E+01 | 4.96E+01 | 4.96E+01 | 0.00E-01 |
| TE131 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 0.00E-01 |
| TE132 | 9.02E+00 | 9.02E+00 | 9.02E+00 | 9.02E+00 | 9.02E+00 | 9.02E+00 | 9.02E+00 | 0.00E-01 |
| I 130 | 8.76E+01 | 8.76E+01 | 8.76E+01 | 8.76E+01 | 8.76E+01 | 8.76E+01 | 8.76E+01 | 0.00E-01 |
| I 131 | 1.76E+01 | 1.76E+01 | 1.76E+01 | 1.76E+01 | 1.76E+01 | 1.76E+01 | 1.76E+01 | 0.00E-01 |
| I 132 | 9.64E+01 | 9.64E+01 | 9.64E+01 | 9.64E+01 | 9.64E+01 | 9.64E+01 | 9.64E+01 | 0.00E-01 |
| I 133 | 2.16E+01 | 2.16E+01 | 2.16E+01 | 2.16E+01 | 2.16E+01 | 2.16E+01 | 2.16E+01 | 0.00E-01 |
| I 134 | 8.76E+01 | 8.76E+01 | 8.76E+01 | 8.76E+01 | 8.76E+01 | 8.76E+01 | 8.76E+01 | 0.00E-01 |
| I 135 | 7.37E+01 | 7.37E+01 | 7.37E+01 | 7.37E+01 | 7.37E+01 | 7.37E+01 | 7.37E+01 | 0.00E-01 |
| CS134 | 6.55E+01 | 6.55E+01 | 6.55E+01 | 6.55E+01 | 6.55E+01 | 6.55E+01 | 6.55E+01 | 0.00E-01 |
| CS136 | 9.26E+01 | 9.26E+01 | 9.26E+01 | 9.26E+01 | 9.26E+01 | 9.26E+01 | 9.26E+01 | 0.00E-01 |
| CS137 | 2.26E+01 | 2.26E+01 | 2.26E+01 | 2.26E+01 | 2.26E+01 | 2.26E+01 | 2.26E+01 | 0.00E-01 |
| CS138 | 7.94E+01 | 7.94E+01 | 7.94E+01 | 7.94E+01 | 7.94E+01 | 7.94E+01 | 7.94E+01 | 0.00E-01 |
| BA139 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 0.00E-01 |
| BA140 | 1.11E+01 | 1.11E+01 | 1.11E+01 | 1.11E+01 | 1.11E+01 | 1.11E+01 | 1.11E+01 | 0.00E-01 |
| BA141 | 1.98E+01 | 1.98E+01 | 1.98E+01 | 1.98E+01 | 1.98E+01 | 1.98E+01 | 1.98E+01 | 0.00E-01 |
| BA142 | 3.37E+01 | 3.37E+01 | 3.37E+01 | 3.37E+01 | 3.37E+01 | 3.37E+01 | 3.37E+01 | 0.00E-01 |
| LA140 | 9.24E+01 | 9.24E+01 | 9.24E+01 | 9.24E+01 | 9.24E+01 | 9.24E+01 | 9.24E+01 | 0.00E-01 |
| LA142 | 9.71E+01 | 9.71E+01 | 9.71E+01 | 9.71E+01 | 9.71E+01 | 9.71E+01 | 9.71E+01 | 0.00E-01 |
| CE141 | 2.93E+00 | 2.93E+00 | 2.93E+00 | 2.93E+00 | 2.93E+00 | 2.93E+00 | 2.93E+00 | 0.00E-01 |
| CE143 | 1.28E+01 | 1.28E+01 | 1.28E+01 | 1.28E+01 | 1.28E+01 | 1.28E+01 | 1.28E+01 | 0.00E-01 |
| CE144 | 1.94E+00 | 1.94E+00 | 1.94E+00 | 1.94E+00 | 1.94E+00 | 1.94E+00 | 1.94E+00 | 0.00E-01 |
| PR143 | 3.61E-02 | 3.61E-02 | 3.61E-02 | 3.61E-02 | 3.61E-02 | 3.61E-02 | 3.61E-02 | 0.00E-01 |
| PR144 | 9.94E-01 | 9.94E-01 | 9.94E-01 | 9.94E-01 | 9.94E-01 | 9.94E-01 | 9.94E-01 | 0.00E-01 |
| ND147 | 6.32E+00 | 6.32E+00 | 6.32E+00 | 6.32E+00 | 6.32E+00 | 6.32E+00 | 6.32E+00 | 0.00E-01 |
| W 187 | 1.87E+01 | 1.87E+01 | 1.87E+01 | 1.87E+01 | 1.87E+01 | 1.87E+01 | 1.87E+01 | 0.00E-01 |
| NP239 | 5.41E+00 | 5.41E+00 | 5.41E+00 | 5.41E+00 | 5.41E+00 | 5.41E+00 | 5.41E+00 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER
 PATHWAY = BOATING

| | TOTAL BODY | GI-LI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 1.01E+02 | 1.01E+02 | 1.01E+02 | 1.01E+02 | 1.01E+02 | 1.01E+02 | 1.01E+02 | 0.00E-01 |
| P 32 | 8.35E-02 | 8.35E-02 | 8.35E-02 | 8.35E-02 | 8.35E-02 | 8.35E-02 | 8.35E-02 | 0.00E-01 |
| CR 51 | 6.78E-01 | 6.78E-01 | 6.78E-01 | 6.78E-01 | 6.78E-01 | 6.78E-01 | 6.78E-01 | 0.00E-01 |
| MN 54 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 0.00E-01 |
| MN 56 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 0.00E-01 |
| FE 55 | 8.35E-04 | 8.35E-04 | 8.35E-04 | 8.35E-04 | 8.35E-04 | 8.35E-04 | 8.35E-04 | 0.00E-01 |
| FE 59 | 2.87E+01 | 2.87E+01 | 2.87E+01 | 2.87E+01 | 2.87E+01 | 2.87E+01 | 2.87E+01 | 0.00E-01 |
| CO 58 | 2.35E+01 | 2.35E+01 | 2.35E+01 | 2.35E+01 | 2.35E+01 | 2.35E+01 | 2.35E+01 | 0.00E-01 |
| CO 60 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.27E+01 | 1.27E+01 | 1.27E+01 | 1.27E+01 | 1.27E+01 | 1.27E+01 | 1.27E+01 | 0.00E-01 |
| CU 64 | 4.80E+00 | 4.80E+00 | 4.80E+00 | 4.80E+00 | 4.80E+00 | 4.80E+00 | 4.80E+00 | 0.00E-01 |
| ZN 65 | 1.44E+01 | 1.44E+01 | 1.44E+01 | 1.44E+01 | 1.44E+01 | 1.44E+01 | 1.44E+01 | 0.00E-01 |
| ZN 69 | 1.94E-02 | 1.94E-02 | 1.94E-02 | 1.94E-02 | 1.94E-02 | 1.94E-02 | 1.94E-02 | 0.00E-01 |
| BR 83 | 2.15E-01 | 2.15E-01 | 2.15E-01 | 2.15E-01 | 2.15E-01 | 2.15E-01 | 2.15E-01 | 0.00E-01 |
| BR 84 | 4.01E+01 | 4.01E+01 | 4.01E+01 | 4.01E+01 | 4.01E+01 | 4.01E+01 | 4.01E+01 | 0.00E-01 |
| BR 85 | 4.28E-02 | 4.28E-02 | 4.28E-02 | 4.28E-02 | 4.28E-02 | 4.28E-02 | 4.28E-02 | 0.00E-01 |
| RB 86 | 2.22E+00 | 2.22E+00 | 2.22E+00 | 2.22E+00 | 2.22E+00 | 2.22E+00 | 2.22E+00 | 0.00E-01 |
| RB 88 | 1.24E+01 | 1.24E+01 | 1.24E+01 | 1.24E+01 | 1.24E+01 | 1.24E+01 | 1.24E+01 | 0.00E-01 |
| RB 89 | 4.47E+01 | 4.47E+01 | 4.47E+01 | 4.47E+01 | 4.47E+01 | 4.47E+01 | 4.47E+01 | 0.00E-01 |
| SR 89 | 6.00E-02 | 6.00E-02 | 6.00E-02 | 6.00E-02 | 6.00E-02 | 6.00E-02 | 6.00E-02 | 0.00E-01 |
| SR 90 | 7.04E-03 | 7.04E-03 | 7.04E-03 | 7.04E-03 | 7.04E-03 | 7.04E-03 | 7.04E-03 | 0.00E-01 |
| SR 91 | 2.46E+01 | 2.46E+01 | 2.46E+01 | 2.46E+01 | 2.46E+01 | 2.46E+01 | 2.46E+01 | 0.00E-01 |
| SR 92 | 3.31E+01 | 3.31E+01 | 3.31E+01 | 3.31E+01 | 3.31E+01 | 3.31E+01 | 3.31E+01 | 0.00E-01 |
| Y 90 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 0.00E-01 |
| Y 91M | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 0.00E-01 |
| Y 91 | 8.74E-02 | 8.74E-02 | 8.74E-02 | 8.74E-02 | 8.74E-02 | 8.74E-02 | 8.74E-02 | 0.00E-01 |
| Y 92 | 5.89E+00 | 5.89E+00 | 5.89E+00 | 5.89E+00 | 5.89E+00 | 5.89E+00 | 5.89E+00 | 0.00E-01 |
| Y 93 | 2.46E+00 | 2.46E+00 | 2.46E+00 | 2.46E+00 | 2.46E+00 | 2.46E+00 | 2.46E+00 | 0.00E-01 |
| ZR 95 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 0.00E-01 |
| ZR 97 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 0.00E-01 |
| NB 95 | 1.83E+01 | 1.83E+01 | 1.83E+01 | 1.83E+01 | 1.83E+01 | 1.83E+01 | 1.83E+01 | 0.00E-01 |
| MO 99 | 6.12E+00 | 6.12E+00 | 6.12E+00 | 6.12E+00 | 6.12E+00 | 6.12E+00 | 6.12E+00 | 0.00E-01 |
| TC 99M | 3.10E+00 | 3.10E+00 | 3.10E+00 | 3.10E+00 | 3.10E+00 | 3.10E+00 | 3.10E+00 | 0.00E-01 |
| TC101 | 6.62E+00 | 6.62E+00 | 6.62E+00 | 6.62E+00 | 6.62E+00 | 6.62E+00 | 6.62E+00 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = TEENAGER
 PATHWAY = BOATING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 0.00E-01 |
| RU105 | 1.54E+01 | 1.54E+01 | 1.54E+01 | 1.54E+01 | 1.54E+01 | 1.54E+01 | 1.54E+01 | 0.00E-01 |
| RU106 | 4.96E+00 | 4.96E+00 | 4.96E+00 | 4.96E+00 | 4.96E+00 | 4.96E+00 | 4.96E+00 | 0.00E-01 |
| AG110M | 6.39E+01 | 6.39E+01 | 6.39E+01 | 6.39E+01 | 6.39E+01 | 6.39E+01 | 6.39E+01 | 0.00E-01 |
| TE125M | 4.81E-02 | 4.81E-02 | 4.81E-02 | 4.81E-02 | 4.81E-02 | 4.81E-02 | 4.81E-02 | 0.00E-01 |
| TE127M | 3.39E-03 | 3.39E-03 | 3.39E-03 | 3.39E-03 | 3.39E-03 | 3.39E-03 | 3.39E-03 | 0.00E-01 |
| TE127 | 3.63E-02 | 3.63E-02 | 3.63E-02 | 3.63E-02 | 3.63E-02 | 3.63E-02 | 3.63E-02 | 0.00E-01 |
| TE129M | 2.74E+00 | 2.74E+00 | 2.74E+00 | 2.74E+00 | 2.74E+00 | 2.74E+00 | 2.74E+00 | 0.00E-01 |
| TE129 | 2.34E+00 | 2.34E+00 | 2.34E+00 | 2.34E+00 | 2.34E+00 | 2.34E+00 | 2.34E+00 | 0.00E-01 |
| TE131M | 2.86E+01 | 2.86E+01 | 2.86E+01 | 2.86E+01 | 2.86E+01 | 2.86E+01 | 2.86E+01 | 0.00E-01 |
| TE131 | 8.18E+00 | 8.18E+00 | 8.18E+00 | 8.18E+00 | 8.18E+00 | 8.18E+00 | 8.18E+00 | 0.00E-01 |
| TE132 | 5.21E+00 | 5.21E+00 | 5.21E+00 | 5.21E+00 | 5.21E+00 | 5.21E+00 | 5.21E+00 | 0.00E-01 |
| I 130 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 0.00E-01 |
| I 131 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 0.00E-01 |
| I 132 | 5.57E+01 | 5.57E+01 | 5.57E+01 | 5.57E+01 | 5.57E+01 | 5.57E+01 | 5.57E+01 | 0.00E-01 |
| I 133 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 0.00E-01 |
| I 134 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 0.00E-01 |
| I 135 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 0.00E-01 |
| CS134 | 3.78E+01 | 3.78E+01 | 3.78E+01 | 3.78E+01 | 3.78E+01 | 3.78E+01 | 3.78E+01 | 0.00E-01 |
| CS136 | 5.35E+01 | 5.35E+01 | 5.35E+01 | 5.35E+01 | 5.35E+01 | 5.35E+01 | 5.35E+01 | 0.00E-01 |
| CS137 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 0.00E-01 |
| CS138 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 0.00E-01 |
| BA139 | 9.55E-01 | 9.55E-01 | 9.55E-01 | 9.55E-01 | 9.55E-01 | 9.55E-01 | 9.55E-01 | 0.00E-01 |
| BA140 | 6.39E+00 | 6.39E+00 | 6.39E+00 | 6.39E+00 | 6.39E+00 | 6.39E+00 | 6.39E+00 | 0.00E-01 |
| BA141 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 0.00E-01 |
| BA142 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 0.00E-01 |
| LA140 | 5.34E+01 | 5.34E+01 | 5.34E+01 | 5.34E+01 | 5.34E+01 | 5.34E+01 | 5.34E+01 | 0.00E-01 |
| LA142 | 5.61E+01 | 5.61E+01 | 5.61E+01 | 5.61E+01 | 5.61E+01 | 5.61E+01 | 5.61E+01 | 0.00E-01 |
| CE141 | 1.70E+00 | 1.70E+00 | 1.70E+00 | 1.70E+00 | 1.70E+00 | 1.70E+00 | 1.70E+00 | 0.00E-01 |
| CE143 | 7.42E+00 | 7.42E+00 | 7.42E+00 | 7.42E+00 | 7.42E+00 | 7.42E+00 | 7.42E+00 | 0.00E-01 |
| CE144 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 0.00E-01 |
| PR143 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 0.00E-01 |
| PR144 | 5.74E-01 | 5.74E-01 | 5.74E-01 | 5.74E-01 | 5.74E-01 | 5.74E-01 | 5.74E-01 | 0.00E-01 |
| ND147 | 3.65E+00 | 3.65E+00 | 3.65E+00 | 3.65E+00 | 3.65E+00 | 3.65E+00 | 3.65E+00 | 0.00E-01 |
| W 187 | 1.08E+01 | 1.08E+01 | 1.08E+01 | 1.08E+01 | 1.08E+01 | 1.08E+01 | 1.08E+01 | 0.00E-01 |
| NP239 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD
PATHWAY = POTABLE WATER

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 2.97E+01 | 2.97E+01 | 0.00E-01 | 2.97E+01 | 2.97E+01 | 2.97E+01 | 2.97E+01 | 0.00E-01 |
| C 14 | 6.19E+02 | 6.19E+02 | 3.10E+03 | 6.19E+02 | 6.19E+02 | 6.19E+02 | 6.19E+02 | 0.00E-01 |
| NA 24 | 4.91E+02 | 4.91E+02 | 4.91E+02 | 4.91E+02 | 4.91E+02 | 4.91E+02 | 4.91E+02 | 0.00E-01 |
| P 32 | 7.75E+03 | 5.56E+03 | 2.01E+05 | 9.41E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 2.22E+00 | 1.18E+02 | 0.00E-01 | 0.00E-01 | 3.37E-01 | 1.23E+00 | 2.25E+00 | 0.00E-01 |
| MN 54 | 7.28E+02 | 2.29E+03 | 0.00E-01 | 2.73E+03 | 7.66E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 2.96E-02 | 1.90E+01 | 0.00E-01 | 1.31E-01 | 1.59E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 4.83E+02 | 2.89E+02 | 2.94E+03 | 1.56E+03 | 0.00E-01 | 0.00E-01 | 8.82E+02 | 0.00E-01 |
| FE 59 | 3.35E+03 | 7.00E+03 | 4.16E+03 | 6.73E+03 | 0.00E-01 | 0.00E-01 | 1.95E+03 | 0.00E-01 |
| CO 58 | 1.40E+03 | 2.66E+03 | 0.00E-01 | 4.56E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 3.99E+03 | 7.50E+03 | 0.00E-01 | 1.35E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 4.68E+03 | 4.96E+02 | 1.38E+05 | 7.37E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 4.24E-02 | 8.90E+00 | 7.72E-01 | 7.27E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 1.02E+01 | 7.91E+02 | 0.00E-01 | 1.69E+01 | 4.07E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 5.79E+03 | 1.64E+03 | 3.50E+03 | 9.31E+03 | 5.87E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 3.61E-08 | 2.47E-05 | 2.71E-07 | 3.91E-07 | 2.37E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 4.17E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 1.02E+04 | 1.06E+03 | 0.00E-01 | 1.65E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 9.52E+03 | 1.29E+04 | 3.33E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.32E+05 | 5.86E+04 | 6.55E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 4.01E+01 | 2.35E+03 | 1.06E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 2.01E-01 | 9.48E+01 | 5.01E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 2.17E-01 | 2.31E+04 | 8.12E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 4.07E+00 | 2.03E+04 | 1.52E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 2.44E-04 | 2.46E+02 | 8.52E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 1.54E-02 | 8.35E+03 | 5.60E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 5.75E+00 | 6.73E+03 | 2.94E+01 | 6.46E+00 | 9.24E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 5.70E-02 | 1.46E+04 | 6.68E-01 | 9.65E-02 | 1.39E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 1.57E+00 | 4.06E+03 | 5.65E+00 | 2.20E+00 | 2.07E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 6.54E+02 | 2.19E+03 | 0.00E-01 | 2.64E+03 | 5.65E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 4.84E-01 | 1.66E+01 | 1.49E-02 | 2.92E-02 | 4.24E-01 | 0.00E-01 | 1.48E-02 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = POTABLE WATER

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 7.07E+01 | 4.75E+03 | 1.84E+02 | 0.00E-01 | 4.63E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.41E-01 | 2.53E+02 | 3.88E-01 | 0.00E-01 | 3.41E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 3.73E+02 | 4.65E+04 | 2.99E+03 | 0.00E-01 | 4.04E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 7.43E+01 | 1.10E+04 | 1.38E+02 | 9.29E+01 | 1.73E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 3.84E+02 | 2.78E+03 | 2.88E+03 | 7.81E+02 | 0.00E-01 | 8.09E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 8.72E+02 | 5.95E+03 | 7.35E+03 | 1.98E+03 | 2.09E+04 | 1.76E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 4.36E+00 | 7.94E+02 | 2.03E+01 | 5.48E+00 | 5.78E+01 | 1.41E+01 | 0.00E-01 | 0.00E-01 |
| TE129M | 1.89E+03 | 1.49E+04 | 1.22E+04 | 3.41E+03 | 3.58E+04 | 3.94E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 4.81E-06 | 1.26E-03 | 2.02E-05 | 5.65E-06 | 5.92E-05 | 1.44E-05 | 0.00E-01 | 0.00E-01 |
| TE131M | 3.89E+02 | 1.48E+04 | 1.06E+03 | 3.66E+02 | 3.54E+03 | 7.52E+02 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 1.12E+03 | 9.31E+03 | 2.09E+03 | 9.25E+02 | 8.59E+03 | 1.35E+03 | 0.00E-01 | 0.00E-01 |
| I 130 | 2.02E+02 | 1.83E+02 | 1.94E+02 | 3.92E+02 | 5.86E+02 | 4.32E+04 | 0.00E-01 | 0.00E-01 |
| I 131 | 2.31E+03 | 3.61E+02 | 4.04E+03 | 4.06E+03 | 6.67E+03 | 1.34E+06 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.25E-01 | 3.20E-01 | 1.48E-01 | 2.72E-01 | 4.17E-01 | 1.26E+01 | 0.00E-01 | 0.00E-01 |
| I 133 | 3.19E+02 | 3.39E+02 | 6.81E+02 | 8.42E+02 | 1.40E+03 | 1.56E+05 | 0.00E-01 | 0.00E-01 |
| I 134 | 5.09E-07 | 7.34E-07 | 5.96E-07 | 1.11E-06 | 1.69E-06 | 2.55E-05 | 0.00E-01 | 0.00E-01 |
| I 135 | 3.06E+01 | 4.93E+01 | 3.59E+01 | 6.47E+01 | 9.92E+01 | 5.73E+03 | 0.00E-01 | 0.00E-01 |
| CS134 | 2.07E+04 | 5.29E+02 | 5.98E+04 | 9.82E+04 | 3.04E+04 | 0.00E-01 | 1.09E+04 | 0.00E-01 |
| CS136 | 1.01E+04 | 5.51E+02 | 5.70E+03 | 1.57E+04 | 8.35E+03 | 0.00E-01 | 1.24E+03 | 0.00E-01 |
| CS137 | 1.18E+04 | 5.02E+02 | 8.37E+04 | 8.01E+04 | 2.61E+04 | 0.00E-01 | 9.39E+03 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 1.71E-05 | 3.41E-02 | 5.91E-04 | 3.16E-07 | 2.76E-07 | 0.00E-01 | 1.86E-07 | 0.00E-01 |
| BA140 | 1.18E+03 | 1.02E+04 | 2.01E+04 | 1.76E+01 | 5.74E+00 | 0.00E-01 | 1.05E+01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 2.01E-01 | 1.67E+04 | 1.71E+00 | 5.98E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 2.73E-07 | 1.73E-01 | 2.74E-06 | 8.72E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 7.37E-01 | 6.19E+03 | 9.94E+00 | 4.96E+00 | 2.17E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 8.51E-02 | 8.60E+03 | 1.08E+00 | 5.87E+02 | 2.46E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 2.83E+01 | 4.34E+04 | 5.31E+02 | 1.66E+02 | 9.22E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 4.74E-01 | 1.03E+04 | 9.56E+00 | 2.87E+00 | 1.55E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 4.21E-01 | 8.61E+03 | 6.71E+00 | 5.43E+00 | 2.98E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 1.46E+01 | 4.56E+03 | 5.48E+01 | 3.24E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 5.05E-02 | 5.32E+03 | 1.00E+00 | 7.19E-02 | 2.08E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = FRESH WATER FISH

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 3.61E-01 | 3.61E-01 | 0.00E-01 | 3.61E-01 | 3.61E-01 | 3.61E-01 | 3.61E-01 | 0.00E-01 |
| C 14 | 3.85E+04 | 3.85E+04 | 1.93E+05 | 3.85E+04 | 3.85E+04 | 3.85E+04 | 3.85E+04 | 0.00E-01 |
| NA 24 | 6.61E+02 | 6.61E+02 | 6.61E+02 | 6.61E+02 | 6.61E+02 | 6.61E+02 | 6.61E+02 | 0.00E-01 |
| P 32 | 1.05E+07 | 7.52E+06 | 2.72E+08 | 1.27E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 6.01E+00 | 3.19E+02 | 0.00E-01 | 0.00E-01 | 9.12E-01 | 3.34E+00 | 6.09E+00 | 0.00E-01 |
| MN 54 | 3.94E+03 | 1.24E+04 | 0.00E-01 | 1.48E+04 | 4.15E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 1.56E-01 | 1.00E+02 | 0.00E-01 | 6.91E-01 | 8.35E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 6.54E+02 | 3.91E+02 | 3.98E+03 | 2.11E+03 | 0.00E-01 | 0.00E-01 | 1.19E+03 | 0.00E-01 |
| FE 59 | 4.53E+03 | 9.48E+03 | 5.62E+03 | 9.10E+03 | 0.00E-01 | 0.00E-01 | 2.64E+03 | 0.00E-01 |
| CO 58 | 9.45E+02 | 1.80E+03 | 0.00E-01 | 3.09E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 2.70E+03 | 5.07E+03 | 0.00E-01 | 9.15E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 6.34E+03 | 6.72E+02 | 1.86E+05 | 9.97E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 5.58E-02 | 1.17E+01 | 1.02E+00 | 9.57E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 6.85E+00 | 5.32E+02 | 0.00E-01 | 1.13E+01 | 2.74E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.57E+05 | 4.43E+04 | 9.46E+04 | 2.52E+05 | 1.59E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 9.09E-07 | 6.20E-04 | 6.81E-06 | 9.84E-06 | 5.97E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 2.30E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.75E+05 | 2.88E+04 | 0.00E-01 | 4.47E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 3.86E+03 | 5.23E+03 | 1.35E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 5.35E+04 | 2.38E+04 | 2.66E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.62E+01 | 9.46E+02 | 4.28E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 7.94E-02 | 3.75E+01 | 1.98E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 7.34E-02 | 7.81E+03 | 2.74E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 1.38E+00 | 6.86E+03 | 5.15E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 8.09E-05 | 8.17E+01 | 2.83E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 5.17E-03 | 2.81E+03 | 1.88E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 2.57E-01 | 3.01E+02 | 1.31E+00 | 2.88E-01 | 4.12E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 2.53E-03 | 6.50E+02 | 2.97E-02 | 4.29E-03 | 6.16E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 6.37E+02 | 1.65E+06 | 2.29E+03 | 8.92E+02 | 8.38E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 8.84E+01 | 2.96E+02 | 0.00E-01 | 3.57E+02 | 7.63E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 9.70E-02 | 3.33E+00 | 2.98E-03 | 5.85E-03 | 8.51E-02 | 0.00E-01 | 2.97E-03 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD
 PATHWAY = FRESH WATER FISH

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 9.56E+00 | 6.43E+02 | 2.49E+01 | 0.00E-01 | 6.26E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.88E-02 | 3.38E+01 | 5.17E-02 | 0.00E-01 | 4.55E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 5.05E+01 | 6.29E+03 | 4.04E+02 | 0.00E-01 | 5.46E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 2.31E+00 | 3.44E+02 | 4.28E+00 | 2.89E+00 | 5.38E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 2.08E+03 | 1.50E+04 | 1.56E+04 | 4.23E+03 | 0.00E-01 | 4.38E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 4.72E+03 | 3.22E+04 | 3.98E+04 | 1.07E+04 | 1.13E+05 | 9.51E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 2.34E+01 | 4.27E+03 | 1.09E+02 | 2.95E+01 | 3.11E+02 | 7.56E+01 | 0.00E-01 | 0.00E-01 |
| TE129M | 1.03E+04 | 8.06E+04 | 6.61E+04 | 1.84E+04 | 1.94E+05 | 2.13E+04 | 0.00E-01 | 0.00E-01 |
| TE129 | 2.45E-05 | 6.42E-03 | 1.03E-04 | 2.88E-05 | 3.02E-04 | 7.36E-05 | 0.00E-01 | 0.00E-01 |
| TE131M | 2.10E+03 | 8.01E+04 | 5.71E+03 | 1.98E+03 | 1.91E+04 | 4.06E+03 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 6.04E+03 | 5.03E+04 | 1.13E+04 | 5.00E+03 | 4.64E+04 | 7.28E+03 | 0.00E-01 | 0.00E-01 |
| I 130 | 4.08E+01 | 3.70E+01 | 3.92E+01 | 7.92E+01 | 1.18E+02 | 8.72E+03 | 0.00E-01 | 0.00E-01 |
| I 131 | 4.68E+02 | 7.33E+01 | 8.19E+02 | 8.24E+02 | 1.35E+03 | 2.72E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 2.46E-02 | 6.31E-02 | 2.92E-02 | 5.36E-02 | 8.20E-02 | 2.49E+00 | 0.00E-01 | 0.00E-01 |
| I 133 | 6.45E+01 | 6.87E+01 | 1.38E+02 | 1.70E+02 | 2.84E+02 | 3.17E+04 | 0.00E-01 | 0.00E-01 |
| I 134 | 9.55E-08 | 1.38E-07 | 1.12E-07 | 2.07E-07 | 3.17E-07 | 4.77E-06 | 0.00E-01 | 0.00E-01 |
| I 135 | 6.14E+00 | 9.90E+00 | 7.22E+00 | 1.30E+01 | 1.99E+01 | 1.15E+03 | 0.00E-01 | 0.00E-01 |
| CS134 | 5.60E+05 | 1.43E+04 | 1.62E+06 | 2.66E+06 | 8.23E+05 | 0.00E-01 | 2.95E+05 | 0.00E-01 |
| CS136 | 2.74E+05 | 1.49E+04 | 1.54E+05 | 4.24E+05 | 2.26E+05 | 0.00E-01 | 3.37E+04 | 0.00E-01 |
| CS137 | 3.20E+05 | 1.36E+04 | 2.26E+06 | 2.17E+06 | 7.06E+05 | 0.00E-01 | 2.54E+05 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 8.82E-07 | 1.76E-03 | 3.04E-05 | 1.62E-08 | 1.42E-08 | 0.00E-01 | 9.56E-09 | 0.00E-01 |
| BA140 | 6.36E+01 | 5.52E+02 | 1.09E+03 | 9.55E-01 | 3.11E-01 | 0.00E-01 | 5.69E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 6.80E-02 | 5.63E+03 | 5.77E-01 | 2.02E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 8.83E-08 | 5.59E-02 | 8.85E-07 | 2.82E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 9.96E-03 | 8.37E+01 | 1.34E-01 | 6.71E-02 | 2.94E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 1.15E-03 | 1.16E+02 | 1.46E-02 | 7.93E+00 | 3.32E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 3.83E-01 | 5.87E+02 | 7.18E+00 | 2.25E+00 | 1.25E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.60E-01 | 3.49E+03 | 3.23E+00 | 9.70E-01 | 5.25E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.42E-01 | 2.91E+03 | 2.27E+00 | 1.84E+00 | 1.01E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 2.36E+02 | 7.38E+04 | 8.86E+02 | 5.25E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 6.83E-03 | 7.19E+02 | 1.35E-01 | 9.72E-03 | 2.81E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = FRESH WATER INVERTEBRATES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 8.90E-02 | 8.90E-02 | 0.00E-01 | 8.90E-02 | 8.90E-02 | 8.90E-02 | 8.90E-02 | 0.00E-01 |
| C 14 | 1.88E+04 | 1.88E+04 | 9.39E+04 | 1.88E+04 | 1.88E+04 | 1.88E+04 | 1.88E+04 | 0.00E-01 |
| NA 24 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 3.26E+02 | 0.00E-01 |
| P 32 | 5.17E+05 | 3.70E+05 | 1.34E+07 | 6.27E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.48E+01 | 7.85E+02 | 0.00E-01 | 0.00E-01 | 2.25E+00 | 8.22E+00 | 1.50E+01 | 0.00E-01 |
| MN 54 | 2.18E+05 | 6.88E+05 | 0.00E-01 | 8.20E+05 | 2.30E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 8.64E+00 | 5.55E+03 | 0.00E-01 | 3.83E+01 | 4.63E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 5.16E+03 | 3.08E+03 | 3.14E+04 | 1.66E+04 | 0.00E-01 | 0.00E-01 | 9.41E+03 | 0.00E-01 |
| FE 59 | 3.57E+04 | 7.47E+04 | 4.43E+04 | 7.18E+04 | 0.00E-01 | 0.00E-01 | 2.08E+04 | 0.00E-01 |
| CO 58 | 9.31E+02 | 1.77E+03 | 0.00E-01 | 3.04E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 2.66E+03 | 5.00E+03 | 0.00E-01 | 9.02E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.56E+03 | 1.65E+02 | 4.59E+04 | 2.46E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.38E-02 | 2.89E+00 | 2.50E-01 | 2.36E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 1.35E+01 | 1.05E+03 | 0.00E-01 | 2.24E+01 | 5.40E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.93E+05 | 5.45E+04 | 1.16E+05 | 3.10E+05 | 1.96E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 1.12E-06 | 7.64E-04 | 8.39E-06 | 1.21E-05 | 7.35E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 4.46E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 3.39E+04 | 3.54E+03 | 0.00E-01 | 5.51E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 3.17E+03 | 4.30E+03 | 1.11E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 4.39E+04 | 1.95E+04 | 2.18E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.33E+01 | 7.77E+02 | 3.52E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 6.52E-02 | 3.08E+01 | 1.63E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 7.23E-01 | 7.69E+04 | 2.70E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 1.36E+01 | 6.76E+04 | 5.07E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 7.97E-04 | 8.05E+02 | 2.79E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 5.09E-02 | 2.76E+04 | 1.85E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.28E-01 | 1.50E+02 | 6.56E-01 | 1.44E-01 | 2.06E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 1.27E-03 | 3.25E+02 | 1.49E-02 | 2.15E-03 | 3.08E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 5.24E-01 | 1.35E+03 | 1.88E+00 | 7.33E-01 | 6.88E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 2.18E+01 | 7.28E+01 | 0.00E-01 | 8.81E+01 | 1.88E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 7.97E-03 | 2.74E-01 | 2.45E-04 | 4.81E-04 | 6.98E-03 | 0.00E-01 | 2.44E-04 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = FRESH WATER INVERTEBRATES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 7.07E+01 | 4.75E+03 | 1.84E+02 | 0.00E-01 | 4.63E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.39E-01 | 2.49E+02 | 3.82E-01 | 0.00E-01 | 3.36E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 3.73E+02 | 4.65E+04 | 2.99E+03 | 0.00E-01 | 4.04E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 1.91E+02 | 2.84E+04 | 3.53E+02 | 2.38E+02 | 4.44E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 7.81E+03 | 5.66E+04 | 5.86E+04 | 1.59E+04 | 0.00E-01 | 1.64E+04 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.77E+04 | 1.21E+05 | 1.49E+05 | 4.02E+04 | 4.26E+05 | 3.57E+04 | 0.00E-01 | 0.00E-01 |
| TE127 | 8.80E+01 | 1.60E+04 | 4.10E+02 | 1.11E+02 | 1.17E+03 | 2.84E+02 | 0.00E-01 | 0.00E-01 |
| TE129M | 3.85E+04 | 3.03E+05 | 2.48E+05 | 6.93E+04 | 7.29E+05 | 8.00E+04 | 0.00E-01 | 0.00E-01 |
| TE129 | 9.20E-05 | 2.41E-02 | 3.88E-04 | 1.08E-04 | 1.14E-03 | 2.77E-04 | 0.00E-01 | 0.00E-01 |
| TE131M | 7.90E+03 | 3.01E+05 | 2.15E+04 | 7.42E+03 | 7.18E+04 | 1.53E+04 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 2.27E+04 | 1.89E+05 | 4.25E+04 | 1.88E+04 | 1.74E+05 | 2.74E+04 | 0.00E-01 | 0.00E-01 |
| I 130 | 3.35E+00 | 3.04E+00 | 3.22E+00 | 6.50E+00 | 9.72E+00 | 7.16E+02 | 0.00E-01 | 0.00E-01 |
| I 131 | 3.85E+01 | 6.02E+00 | 6.73E+01 | 6.77E+01 | 1.11E+02 | 2.24E+04 | 0.00E-01 | 0.00E-01 |
| I 132 | 2.02E-03 | 5.18E-03 | 2.40E-03 | 4.40E-03 | 6.73E-03 | 2.04E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 5.30E+00 | 5.64E+00 | 1.13E+01 | 1.40E+01 | 2.33E+01 | 2.60E+03 | 0.00E-01 | 0.00E-01 |
| I 134 | 7.84E-09 | 1.13E-08 | 9.18E-09 | 1.70E-08 | 2.61E-08 | 3.92E-07 | 0.00E-01 | 0.00E-01 |
| I 135 | 5.04E-01 | 8.13E-01 | 5.93E-01 | 1.07E+00 | 1.64E+00 | 9.45E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 6.90E+04 | 1.76E+03 | 1.99E+05 | 3.27E+05 | 1.01E+05 | 0.00E-01 | 3.64E+04 | 0.00E-01 |
| CS136 | 3.38E+04 | 1.84E+03 | 1.90E+04 | 5.23E+04 | 2.78E+04 | 0.00E-01 | 4.15E+03 | 0.00E-01 |
| CS137 | 3.94E+04 | 1.67E+03 | 2.79E+05 | 2.67E+05 | 8.70E+04 | 0.00E-01 | 3.13E+04 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 1.09E-05 | 2.16E-02 | 3.75E-04 | 2.00E-07 | 1.75E-07 | 0.00E-01 | 1.18E-07 | 0.00E-01 |
| BA140 | 7.84E+02 | 6.80E+03 | 1.34E+04 | 1.18E+01 | 3.83E+00 | 0.00E-01 | 7.01E+00 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 6.70E-01 | 5.54E+04 | 5.69E+00 | 1.99E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 8.70E-07 | 5.51E-01 | 8.72E-06 | 2.78E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 2.45E+00 | 2.06E+04 | 3.32E+01 | 1.65E+01 | 7.25E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 2.83E-01 | 2.86E+04 | 3.60E+00 | 1.95E+03 | 8.19E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 9.45E+01 | 1.45E+05 | 1.77E+03 | 5.55E+02 | 3.07E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.58E+00 | 3.44E+04 | 3.19E+01 | 9.56E+00 | 5.18E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.40E+00 | 2.87E+04 | 2.24E+01 | 1.81E+01 | 9.94E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 4.84E-01 | 1.51E+02 | 1.82E+00 | 1.08E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 6.73E-02 | 7.09E+03 | 1.33E+00 | 9.58E-02 | 2.77E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = IRRIGATED FRESH LEAFY VEGETABLES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.51E+00 | 1.51E+00 | 0.00E-01 | 1.51E+00 | 1.51E+00 | 1.51E+00 | 1.51E+00 | 0.00E-01 |
| C 14 | 3.51E+03 | 3.51E+03 | 1.75E+04 | 3.51E+03 | 3.51E+03 | 3.51E+03 | 3.51E+03 | 0.00E-01 |
| NA 24 | 8.63E+00 | 8.63E+00 | 8.63E+00 | 8.63E+00 | 8.63E+00 | 8.63E+00 | 8.63E+00 | 0.00E-01 |
| P 32 | 1.70E+03 | 1.22E+03 | 4.42E+04 | 2.07E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 6.25E-01 | 3.32E+01 | 0.00E-01 | 0.00E-01 | 9.48E-02 | 3.47E-01 | 6.33E-01 | 0.00E-01 |
| MN 54 | 2.87E+02 | 9.05E+02 | 0.00E-01 | 1.08E+03 | 3.02E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 7.35E-05 | 4.72E-02 | 0.00E-01 | 3.26E-04 | 3.94E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 1.94E+02 | 1.16E+02 | 1.18E+03 | 6.28E+02 | 0.00E-01 | 0.00E-01 | 3.55E+02 | 0.00E-01 |
| FE 59 | 1.07E+03 | 2.24E+03 | 1.33E+03 | 2.15E+03 | 0.00E-01 | 0.00E-01 | 6.24E+02 | 0.00E-01 |
| CO 58 | 4.86E+02 | 9.27E+02 | 0.00E-01 | 1.59E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.63E+03 | 3.06E+03 | 0.00E-01 | 5.53E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.99E+03 | 2.11E+02 | 5.84E+04 | 3.13E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.03E-04 | 2.16E-02 | 1.87E-03 | 1.76E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 1.50E-01 | 1.17E+01 | 0.00E-01 | 2.49E-01 | 6.02E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 2.39E+03 | 6.75E+02 | 1.44E+03 | 3.84E+03 | 2.42E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 2.11E-11 | 1.44E-08 | 1.58E-10 | 2.28E-10 | 1.38E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 9.53E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 2.23E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 6.28E-37 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.48E+03 | 2.60E+02 | 0.00E-01 | 4.04E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 6.60E-28 | 4.66E-29 | 0.00E-01 | 9.50E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 4.96E-30 | 4.87E-32 | 0.00E-01 | 5.58E-30 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 3.15E+03 | 4.27E+03 | 1.10E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 7.47E+04 | 3.32E+04 | 3.71E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 4.40E-01 | 2.57E+01 | 1.17E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 5.35E-04 | 2.53E-01 | 1.33E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 1.48E-02 | 1.57E+03 | 5.53E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 2.93E-15 | 1.57E-10 | 8.04E-14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 1.37E+00 | 6.84E+03 | 5.14E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 9.01E-07 | 9.09E-01 | 3.15E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 1.79E-04 | 9.75E+01 | 6.54E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.97E+00 | 2.31E+03 | 1.01E+01 | 2.21E+00 | 3.17E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 1.12E-03 | 2.88E+02 | 1.32E-02 | 1.90E-03 | 2.73E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 4.74E-01 | 1.23E+03 | 1.71E+00 | 6.64E-01 | 6.24E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 4.56E+01 | 1.52E+02 | 0.00E-01 | 1.84E+02 | 3.94E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 3.26E-03 | 1.12E-01 | 1.00E-04 | 1.97E-04 | 2.86E-03 | 0.00E-01 | 9.99E-05 | 0.00E-01 |
| TC101 | 5.14E-31 | 1.29E-31 | 3.87E-32 | 4.05E-32 | 6.91E-31 | 0.00E-01 | 2.14E-32 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = IRRIGATED FRESH LEAFY VEGETABLES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 2.20E+01 | 1.48E+03 | 5.72E+01 | 0.00E-01 | 1.44E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 6.74E-04 | 1.21E+00 | 1.86E-03 | 0.00E-01 | 1.63E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 1.49E+02 | 1.85E+04 | 1.19E+03 | 0.00E-01 | 1.61E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 2.96E+01 | 4.40E+03 | 5.48E+01 | 3.70E+01 | 6.89E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 1.37E+02 | 9.90E+02 | 1.03E+03 | 2.78E+02 | 0.00E-01 | 2.88E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 3.51E+02 | 2.39E+03 | 2.96E+03 | 7.96E+02 | 8.43E+03 | 7.07E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 4.75E-02 | 8.66E+00 | 2.22E-01 | 5.97E-02 | 6.31E-01 | 1.53E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 5.86E+02 | 4.60E+03 | 3.77E+03 | 1.05E+03 | 1.11E+04 | 1.22E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 3.94E-09 | 1.03E-06 | 1.66E-08 | 4.64E-09 | 4.86E-08 | 1.19E-08 | 0.00E-01 | 0.00E-01 |
| TE131M | 1.35E+01 | 5.16E+02 | 3.68E+01 | 1.27E+01 | 1.23E+02 | 2.61E+01 | 0.00E-01 | 0.00E-01 |
| TE131 | 3.26E-21 | 5.75E-20 | 1.09E-20 | 3.34E-21 | 3.31E-20 | 8.38E-21 | 0.00E-01 | 0.00E-01 |
| TE132 | 9.10E+01 | 7.58E+02 | 1.70E+02 | 7.53E+01 | 6.99E+02 | 1.10E+02 | 0.00E-01 | 0.00E-01 |
| I 130 | 2.90E+00 | 2.64E+00 | 2.79E+00 | 5.64E+00 | 8.43E+00 | 6.21E+02 | 0.00E-01 | 0.00E-01 |
| I 131 | 3.60E+02 | 5.64E+01 | 6.30E+02 | 6.33E+02 | 1.04E+03 | 2.09E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 2.70E-04 | 6.91E-04 | 3.20E-04 | 5.87E-04 | 8.99E-04 | 2.72E-02 | 0.00E-01 | 0.00E-01 |
| I 133 | 7.72E+00 | 8.22E+00 | 1.65E+01 | 2.04E+01 | 3.40E+01 | 3.79E+03 | 0.00E-01 | 0.00E-01 |
| I 134 | 2.57E-10 | 3.71E-10 | 3.01E-10 | 5.59E-10 | 8.55E-10 | 1.29E-08 | 0.00E-01 | 0.00E-01 |
| I 135 | 2.27E-01 | 3.66E-01 | 2.67E-01 | 4.81E-01 | 7.37E-01 | 4.26E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 8.34E+03 | 2.13E+02 | 2.41E+04 | 3.95E+04 | 1.22E+04 | 0.00E-01 | 4.40E+03 | 0.00E-01 |
| CS136 | 2.10E+03 | 1.14E+02 | 1.18E+03 | 3.24E+03 | 1.72E+03 | 0.00E-01 | 2.57E+02 | 0.00E-01 |
| CS137 | 4.90E+03 | 2.08E+02 | 3.47E+04 | 3.32E+04 | 1.08E+04 | 0.00E-01 | 3.89E+03 | 0.00E-01 |
| CS138 | 3.58E-16 | 2.60E-16 | 4.07E-16 | 5.65E-16 | 3.98E-16 | 0.00E-01 | 4.28E-17 | 0.00E-01 |
| BA139 | 1.81E-08 | 3.61E-05 | 6.25E-07 | 3.34E-10 | 2.91E-10 | 0.00E-01 | 1.96E-10 | 0.00E-01 |
| BA140 | 2.40E+02 | 2.08E+03 | 4.11E+03 | 3.60E+00 | 1.17E+00 | 0.00E-01 | 2.15E+00 | 0.00E-01 |
| BA141 | 1.28E-28 | 2.25E-27 | 3.95E-27 | 2.21E-30 | 1.91E-30 | 0.00E-01 | 1.30E-29 | 0.00E-01 |
| BA142 | 5.10E-32 | 1.19E-32 | 9.13E-31 | 6.57E-34 | 5.32E-34 | 0.00E-01 | 3.87E-34 | 0.00E-01 |
| LA140 | 9.10E-03 | 7.52E+02 | 7.72E-02 | 2.70E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 3.41E-10 | 2.16E-04 | 3.42E-09 | 1.09E-09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 2.18E-01 | 1.83E+03 | 2.94E+00 | 1.47E+00 | 6.42E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 3.21E-03 | 3.24E+02 | 4.08E-02 | 2.21E+01 | 9.29E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.11E+01 | 1.70E+04 | 2.08E+02 | 6.51E+01 | 3.60E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 9.98E-02 | 2.17E+03 | 2.01E+00 | 6.04E-01 | 3.27E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 4.33E-33 | 5.73E-29 | 8.60E-32 | 2.66E-32 | 1.41E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 7.95E-02 | 1.63E+03 | 1.27E+00 | 1.03E+00 | 5.63E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 4.03E-01 | 1.26E+02 | 1.52E+00 | 8.98E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 3.09E-03 | 3.25E+02 | 6.12E-02 | 4.40E-03 | 1.27E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = IRRIGATED STORED FRUIT, VEGETABLES, GRAIN

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 3.00E+01 | 3.00E+01 | 0.00E-01 | 3.00E+01 | 3.00E+01 | 3.00E+01 | 3.00E+01 | 0.00E-01 |
| C 14 | 7.01E+04 | 7.01E+04 | 3.51E+05 | 7.01E+04 | 7.01E+04 | 7.01E+04 | 7.01E+04 | 0.00E-01 |
| NA 24 | 4.57E-24 | 4.57E-24 | 4.57E-24 | 4.57E-24 | 4.57E-24 | 4.57E-24 | 4.57E-24 | 0.00E-01 |
| P 32 | 1.95E+03 | 1.40E+03 | 5.06E+04 | 2.37E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 2.85E+00 | 1.51E+02 | 0.00E-01 | 0.00E-01 | 4.32E-01 | 1.58E+00 | 2.89E+00 | 0.00E-01 |
| MN 54 | 5.04E+03 | 1.59E+04 | 0.00E-01 | 1.89E+04 | 5.30E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 8.39E-27 | 5.39E-24 | 0.00E-01 | 3.72E-26 | 4.50E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 3.73E+03 | 2.23E+03 | 2.27E+04 | 1.20E+04 | 0.00E-01 | 0.00E-01 | 6.81E+03 | 0.00E-01 |
| FE 59 | 8.56E+03 | 1.79E+04 | 1.06E+04 | 1.72E+04 | 0.00E-01 | 0.00E-01 | 4.98E+03 | 0.00E-01 |
| CO 58 | 5.47E+03 | 1.04E+04 | 0.00E-01 | 1.79E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 3.19E+04 | 5.99E+04 | 0.00E-01 | 1.08E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 3.97E+04 | 4.21E+03 | 1.17E+06 | 6.25E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.33E-26 | 2.78E-24 | 2.41E-25 | 2.27E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 9.80E-26 | 7.61E-24 | 0.00E-01 | 1.62E-25 | 3.92E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 4.04E+04 | 1.14E+04 | 2.44E+04 | 6.50E+04 | 4.10E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 1.53E-28 | 1.04E-25 | 1.15E-27 | 1.65E-27 | 1.00E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.75E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 1.63E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 1.26E-35 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 5.57E+03 | 5.83E+02 | 0.00E-01 | 9.06E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 2.19E-28 | 1.55E-29 | 0.00E-01 | 3.15E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 9.92E-29 | 9.73E-31 | 0.00E-01 | 1.12E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.80E+04 | 3.79E+04 | 9.80E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.49E+06 | 6.62E+05 | 7.40E+07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 4.45E-25 | 2.60E-23 | 1.18E-23 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 4.32E-26 | 2.04E-23 | 1.08E-24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 6.75E-08 | 7.18E-03 | 2.52E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 2.83E-31 | 1.53E-26 | 7.79E-30 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 1.37E+01 | 6.81E+04 | 5.11E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 1.71E-29 | 1.72E-23 | 5.96E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 1.64E-28 | 8.89E-23 | 5.96E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 2.08E+01 | 2.44E+04 | 1.06E+02 | 2.34E+01 | 3.35E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 1.30E-27 | 3.33E-22 | 1.52E-26 | 2.20E-27 | 3.16E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 2.97E+00 | 7.68E+03 | 1.07E+01 | 4.15E+00 | 3.90E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 3.13E-04 | 1.05E-03 | 0.00E-01 | 1.27E-03 | 2.70E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 9.06E-27 | 3.11E-25 | 2.79E-28 | 5.47E-28 | 7.95E-27 | 0.00E-01 | 2.78E-28 | 0.00E-01 |
| TC101 | 1.03E-29 | 2.58E-30 | 7.74E-31 | 8.10E-31 | 1.38E-29 | 0.00E-01 | 4.28E-31 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = IRRIGATED STORED FRUIT, VEGETABLES, GRAIN

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.55E+02 | 1.04E+04 | 4.04E+02 | 0.00E-01 | 1.02E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 5.02E-27 | 9.03E-24 | 1.38E-26 | 0.00E-01 | 1.22E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 2.66E+03 | 3.32E+05 | 2.13E+04 | 0.00E-01 | 2.88E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 5.02E+02 | 7.48E+04 | 9.31E+02 | 6.28E+02 | 1.17E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 1.35E+03 | 9.80E+03 | 1.02E+04 | 2.75E+03 | 0.00E-01 | 2.85E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 4.82E+03 | 3.29E+04 | 4.07E+04 | 1.09E+04 | 1.16E+05 | 9.72E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 4.93E-26 | 8.99E-24 | 2.30E-25 | 6.20E-26 | 6.55E-25 | 1.59E-25 | 0.00E-01 | 0.00E-01 |
| TE129M | 3.46E+03 | 2.72E+04 | 2.23E+04 | 6.23E+03 | 6.55E+04 | 7.19E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 1.17E-27 | 3.07E-25 | 4.93E-27 | 1.38E-27 | 1.44E-26 | 3.52E-27 | 0.00E-01 | 0.00E-01 |
| TE131M | 1.66E-12 | 6.32E-11 | 4.50E-12 | 1.56E-12 | 1.51E-11 | 3.20E-12 | 0.00E-01 | 0.00E-01 |
| TE131 | 1.13E-28 | 2.00E-27 | 3.81E-28 | 1.16E-28 | 1.15E-27 | 2.91E-28 | 0.00E-01 | 0.00E-01 |
| TE132 | 6.51E-03 | 5.43E-02 | 1.22E-02 | 5.39E-03 | 5.01E-02 | 7.85E-03 | 0.00E-01 | 0.00E-01 |
| I 130 | 1.96E-24 | 1.78E-24 | 1.88E-24 | 3.80E-24 | 5.68E-24 | 4.19E-22 | 0.00E-01 | 0.00E-01 |
| I 131 | 4.44E+01 | 6.96E+00 | 7.77E+01 | 7.82E+01 | 1.28E+02 | 2.59E+04 | 0.00E-01 | 0.00E-01 |
| I 132 | 6.54E-26 | 1.67E-25 | 7.74E-26 | 1.42E-25 | 2.18E-25 | 6.60E-24 | 0.00E-01 | 0.00E-01 |
| I 133 | 5.13E-19 | 5.47E-19 | 1.10E-18 | 1.36E-18 | 2.26E-18 | 2.52E-16 | 0.00E-01 | 0.00E-01 |
| I 134 | 8.10E-27 | 1.17E-26 | 9.48E-27 | 1.76E-26 | 2.69E-26 | 4.05E-25 | 0.00E-01 | 0.00E-01 |
| I 135 | 4.96E-25 | 8.00E-25 | 5.83E-25 | 1.05E-24 | 1.61E-24 | 9.30E-23 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.58E+05 | 4.04E+03 | 4.56E+05 | 7.49E+05 | 2.32E+05 | 0.00E-01 | 8.33E+04 | 0.00E-01 |
| CS136 | 1.85E+03 | 1.01E+02 | 1.04E+03 | 2.86E+03 | 1.52E+03 | 0.00E-01 | 2.27E+02 | 0.00E-01 |
| CS137 | 9.77E+04 | 4.14E+03 | 6.92E+05 | 6.62E+05 | 2.16E+05 | 0.00E-01 | 7.76E+04 | 0.00E-01 |
| CS138 | 1.70E-27 | 1.24E-27 | 1.93E-27 | 2.68E-27 | 1.89E-27 | 0.00E-01 | 2.03E-28 | 0.00E-01 |
| BA139 | 5.68E-28 | 1.13E-24 | 1.96E-26 | 1.05E-29 | 9.14E-30 | 0.00E-01 | 6.16E-30 | 0.00E-01 |
| BA140 | 1.96E+02 | 1.70E+03 | 3.36E+03 | 2.95E+00 | 9.59E-01 | 0.00E-01 | 1.76E+00 | 0.00E-01 |
| BA141 | 1.17E-29 | 2.04E-28 | 3.58E-28 | 2.01E-31 | 1.74E-31 | 0.00E-01 | 1.18E-30 | 0.00E-01 |
| BA142 | 1.02E-30 | 2.38E-31 | 1.83E-29 | 1.31E-32 | 1.06E-32 | 0.00E-01 | 7.73E-33 | 0.00E-01 |
| LA140 | 4.76E-12 | 3.94E-07 | 4.04E-11 | 1.41E-11 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 2.93E-30 | 1.85E-24 | 2.93E-29 | 9.34E-30 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 1.24E+00 | 1.04E+04 | 1.67E+01 | 8.32E+00 | 3.65E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 8.80E-15 | 8.90E-10 | 1.12E-13 | 6.08E-11 | 2.55E-14 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.92E+02 | 2.94E+05 | 3.60E+03 | 1.13E+03 | 6.24E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 9.86E-02 | 2.14E+03 | 1.99E+00 | 5.97E-01 | 3.23E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 9.61E-33 | 1.27E-28 | 1.91E-31 | 5.91E-32 | 3.12E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 3.99E-02 | 8.16E+02 | 6.36E-01 | 5.15E-01 | 2.83E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 1.22E-17 | 3.81E-15 | 4.58E-17 | 2.71E-17 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 1.84E-09 | 1.93E-04 | 3.64E-08 | 2.61E-09 | 7.55E-09 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = IRRIGATED FRESH FORAGE--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 8.73E+00 | 8.73E+00 | 0.00E-01 | 8.73E+00 | 8.73E+00 | 8.73E+00 | 8.73E+00 | 0.00E-01 |
| C 14 | 2.93E+04 | 2.93E+04 | 1.46E+05 | 2.93E+04 | 2.93E+04 | 2.93E+04 | 2.93E+04 | 0.00E-01 |
| NA 24 | 2.07E+02 | 2.07E+02 | 2.07E+02 | 2.07E+02 | 2.07E+02 | 2.07E+02 | 2.07E+02 | 0.00E-01 |
| P 32 | 6.91E+04 | 4.95E+04 | 1.79E+06 | 8.38E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 2.20E+00 | 1.16E+02 | 0.00E-01 | 0.00E-01 | 3.33E-01 | 1.22E+00 | 2.23E+00 | 0.00E-01 |
| MN 54 | 1.07E+02 | 3.36E+02 | 0.00E-01 | 4.01E+02 | 1.12E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 5.11E-08 | 3.28E-05 | 0.00E-01 | 2.26E-07 | 2.74E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 3.46E+02 | 2.07E+02 | 2.11E+03 | 1.12E+03 | 0.00E-01 | 0.00E-01 | 6.32E+02 | 0.00E-01 |
| FE 59 | 2.01E+03 | 4.20E+03 | 2.49E+03 | 4.03E+03 | 0.00E-01 | 0.00E-01 | 1.17E+03 | 0.00E-01 |
| CO 58 | 7.47E+02 | 1.42E+03 | 0.00E-01 | 2.44E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 2.40E+03 | 4.51E+03 | 0.00E-01 | 8.14E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.92E+04 | 2.04E+03 | 5.65E+05 | 3.02E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.70E-06 | 3.57E-04 | 3.09E-05 | 2.91E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 1.03E+00 | 7.98E+01 | 0.00E-01 | 1.70E+00 | 4.11E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.35E+05 | 3.81E+04 | 8.13E+04 | 2.17E+05 | 1.37E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 3.59E-17 | 2.45E-14 | 2.69E-16 | 3.89E-16 | 2.36E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 8.21E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 7.38E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 5.67E-35 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 1.21E+05 | 1.26E+04 | 0.00E-01 | 1.97E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 5.95E-28 | 4.20E-29 | 0.00E-01 | 8.57E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 2.70E-28 | 2.64E-30 | 0.00E-01 | 3.03E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 3.95E+03 | 5.35E+03 | 1.38E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.17E+05 | 5.20E+04 | 5.82E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.11E-01 | 6.47E+00 | 2.93E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 1.68E-06 | 7.95E-04 | 4.20E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 2.07E-04 | 2.20E+01 | 7.73E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 9.59E-26 | 5.16E-21 | 2.63E-24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 2.13E-02 | 1.06E+02 | 7.94E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 1.51E-10 | 1.53E-04 | 5.28E-09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 6.25E-07 | 3.39E-01 | 2.28E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.52E-02 | 1.78E+01 | 7.76E-02 | 1.70E-02 | 2.44E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 3.80E-06 | 9.76E-01 | 4.46E-05 | 6.44E-06 | 9.25E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 1.87E+00 | 4.85E+03 | 6.73E+00 | 2.62E+00 | 2.46E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 4.82E+02 | 1.61E+03 | 0.00E-01 | 1.95E+03 | 4.16E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 9.29E-03 | 3.19E-01 | 2.86E-04 | 5.61E-04 | 8.15E-03 | 0.00E-01 | 2.85E-04 | 0.00E-01 |
| TC101 | 2.32E-29 | 5.83E-30 | 1.75E-30 | 1.83E-30 | 3.13E-29 | 0.00E-01 | 9.69E-31 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = IRRIGATED FRESH FORAGE--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 3.45E-02 | 2.32E+00 | 8.98E-02 | 0.00E-01 | 2.26E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 2.87E-08 | 5.17E-05 | 7.92E-08 | 0.00E-01 | 6.96E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 2.20E-01 | 2.75E+01 | 1.77E+00 | 0.00E-01 | 2.38E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 2.18E+03 | 3.25E+05 | 4.04E+03 | 2.73E+03 | 5.08E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 2.05E+02 | 1.48E+03 | 1.54E+03 | 4.17E+02 | 0.00E-01 | 4.31E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 5.05E+02 | 3.45E+03 | 4.26E+03 | 1.15E+03 | 1.21E+04 | 1.02E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.44E-02 | 2.63E+00 | 6.73E-02 | 1.81E-02 | 1.91E-01 | 4.66E-02 | 0.00E-01 | 0.00E-01 |
| TE129M | 9.07E+02 | 7.13E+03 | 5.84E+03 | 1.63E+03 | 1.72E+04 | 1.88E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 4.19E-15 | 1.10E-12 | 1.77E-14 | 4.93E-15 | 5.17E-14 | 1.26E-14 | 0.00E-01 | 0.00E-01 |
| TE131M | 1.40E+01 | 5.33E+02 | 3.80E+01 | 1.31E+01 | 1.27E+02 | 2.70E+01 | 0.00E-01 | 0.00E-01 |
| TE131 | 1.02E-29 | 1.80E-28 | 3.43E-29 | 1.05E-29 | 1.04E-28 | 2.62E-29 | 0.00E-01 | 0.00E-01 |
| TE132 | 1.32E+02 | 1.10E+03 | 2.47E+02 | 1.09E+02 | 1.02E+03 | 1.59E+02 | 0.00E-01 | 0.00E-01 |
| I 130 | 8.21E+00 | 7.45E+00 | 7.89E+00 | 1.59E+01 | 2.38E+01 | 1.76E+03 | 0.00E-01 | 0.00E-01 |
| I 131 | 3.53E+03 | 5.53E+02 | 6.18E+03 | 6.21E+03 | 1.02E+04 | 2.05E+06 | 0.00E-01 | 0.00E-01 |
| I 132 | 2.13E-06 | 5.44E-06 | 2.52E-06 | 4.62E-06 | 7.07E-06 | 2.14E-04 | 0.00E-01 | 0.00E-01 |
| I 133 | 3.78E+01 | 4.02E+01 | 8.07E+01 | 9.98E+01 | 1.66E+02 | 1.85E+04 | 0.00E-01 | 0.00E-01 |
| I 134 | 1.55E-17 | 2.24E-17 | 1.82E-17 | 3.38E-17 | 5.17E-17 | 7.77E-16 | 0.00E-01 | 0.00E-01 |
| I 135 | 1.99E-01 | 3.20E-01 | 2.33E-01 | 4.20E-01 | 6.43E-01 | 3.72E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.48E+05 | 3.79E+03 | 4.28E+05 | 7.02E+05 | 2.18E+05 | 0.00E-01 | 7.81E+04 | 0.00E-01 |
| CS136 | 4.13E+04 | 2.24E+03 | 2.32E+04 | 6.39E+04 | 3.40E+04 | 0.00E-01 | 5.07E+03 | 0.00E-01 |
| CS137 | 8.60E+04 | 3.65E+03 | 6.09E+05 | 5.83E+05 | 1.90E+05 | 0.00E-01 | 6.83E+04 | 0.00E-01 |
| CS138 | 1.85E-27 | 1.35E-27 | 2.10E-27 | 2.92E-27 | 2.05E-27 | 0.00E-01 | 2.21E-28 | 0.00E-01 |
| BA139 | 7.33E-14 | 1.46E-10 | 2.53E-12 | 1.35E-15 | 1.18E-15 | 0.00E-01 | 7.94E-16 | 0.00E-01 |
| BA140 | 1.58E+02 | 1.37E+03 | 2.70E+03 | 2.37E+00 | 7.71E-01 | 0.00E-01 | 1.41E+00 | 0.00E-01 |
| BA141 | 4.23E-31 | 7.40E-30 | 1.30E-29 | 7.27E-33 | 6.29E-33 | 0.00E-01 | 4.27E-32 | 0.00E-01 |
| BA142 | 3.70E-32 | 8.64E-33 | 6.62E-31 | 4.76E-34 | 3.86E-34 | 0.00E-01 | 2.80E-34 | 0.00E-01 |
| LA140 | 5.46E-05 | 4.51E+00 | 4.63E-04 | 1.62E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 6.30E-17 | 3.99E-11 | 6.32E-16 | 2.01E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 3.45E-02 | 2.90E+02 | 4.66E-01 | 2.32E-01 | 1.02E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 3.52E-04 | 3.56E+01 | 4.48E-03 | 2.43E+00 | 1.02E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.65E+00 | 2.53E+03 | 3.10E+01 | 9.72E+00 | 5.38E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 8.20E-04 | 1.78E+01 | 1.65E-02 | 4.96E-03 | 2.69E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 4.35E-36 | 5.76E-32 | 8.66E-35 | 2.68E-35 | 1.42E-35 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 6.54E-04 | 1.34E+01 | 1.04E-02 | 8.45E-03 | 4.64E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 1.82E-01 | 5.71E+01 | 6.86E-01 | 4.06E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 2.09E-05 | 2.20E+00 | 4.14E-04 | 2.97E-05 | 8.59E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD
 PATHWAY = IRRIGATED FRESH FORAGE--MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem/gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.19E+00 | 1.19E+00 | 0.00E-01 | 1.19E+00 | 1.19E+00 | 1.19E+00 | 1.19E+00 | 0.00E-01 |
| C 14 | 9.39E+03 | 9.39E+03 | 4.70E+04 | 9.39E+03 | 9.39E+03 | 9.39E+03 | 9.39E+03 | 0.00E-01 |
| NA 24 | 4.37E-08 | 4.37E-08 | 4.37E-08 | 4.37E-08 | 4.37E-08 | 4.37E-08 | 4.37E-08 | 0.00E-01 |
| P 32 | 6.60E+03 | 4.73E+03 | 1.71E+05 | 8.01E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.90E-01 | 1.01E+01 | 0.00E-01 | 0.00E-01 | 2.88E-02 | 1.05E-01 | 1.92E-01 | 0.00E-01 |
| MN 54 | 4.08E+01 | 1.28E+02 | 0.00E-01 | 1.53E+02 | 4.29E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 7.56E-29 | 4.86E-26 | 0.00E-01 | 3.35E-28 | 4.05E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 1.41E+03 | 8.46E+02 | 8.61E+03 | 4.57E+03 | 0.00E-01 | 0.00E-01 | 2.58E+03 | 0.00E-01 |
| FE 59 | 6.29E+03 | 1.31E+04 | 7.80E+03 | 1.26E+04 | 0.00E-01 | 0.00E-01 | 3.66E+03 | 0.00E-01 |
| CO 58 | 1.01E+03 | 1.93E+03 | 0.00E-01 | 3.30E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 3.85E+03 | 7.24E+03 | 0.00E-01 | 1.31E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.89E+04 | 2.00E+03 | 5.55E+05 | 2.97E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 7.92E-27 | 1.66E-24 | 1.44E-25 | 1.36E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 3.95E-12 | 3.07E-10 | 0.00E-01 | 6.53E-12 | 1.58E-11 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.22E+04 | 3.46E+03 | 7.39E+03 | 1.97E+04 | 1.24E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 5.16E-29 | 3.52E-26 | 3.86E-28 | 5.58E-28 | 3.39E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 5.11E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 4.77E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 3.66E-36 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 7.96E+03 | 8.33E+02 | 0.00E-01 | 1.29E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 7.64E-29 | 5.39E-30 | 0.00E-01 | 1.10E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 3.46E-29 | 3.40E-31 | 0.00E-01 | 3.90E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.87E+02 | 3.89E+02 | 1.00E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.09E+04 | 4.84E+03 | 5.41E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 2.01E-16 | 1.17E-14 | 5.31E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 2.93E-28 | 1.38E-25 | 7.30E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 1.11E-04 | 1.18E+01 | 4.16E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 1.47E-32 | 7.90E-28 | 4.04E-31 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 9.81E-01 | 4.89E+03 | 3.67E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 8.83E-31 | 8.92E-25 | 3.09E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 4.49E-18 | 2.44E-12 | 1.64E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.06E+01 | 1.24E+04 | 5.39E+01 | 1.19E+01 | 1.70E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 6.41E-11 | 1.65E-05 | 7.52E-10 | 1.09E-10 | 1.56E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 1.83E+01 | 4.73E+04 | 6.57E+01 | 2.56E+01 | 2.40E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 6.80E-01 | 2.28E+00 | 0.00E-01 | 2.75E+00 | 5.87E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 4.50E-24 | 1.54E-22 | 1.39E-25 | 2.72E-25 | 3.95E-24 | 0.00E-01 | 1.38E-25 | 0.00E-01 |
| TC101 | 4.62E-29 | 1.16E-29 | 3.48E-30 | 3.65E-30 | 6.22E-29 | 0.00E-01 | 1.93E-30 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD
 PATHWAY = IRRIGATED FRESH FORAGE--MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.25E+03 | 8.40E+04 | 3.25E+03 | 0.00E-01 | 8.18E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 2.26E-26 | 4.07E-23 | 6.23E-26 | 0.00E-01 | 5.48E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 1.06E+04 | 1.32E+06 | 8.48E+04 | 0.00E-01 | 1.15E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 8.77E+01 | 1.30E+04 | 1.62E+02 | 1.10E+02 | 2.04E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 1.58E+03 | 1.14E+04 | 1.19E+04 | 3.22E+03 | 0.00E-01 | 3.33E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 4.31E+03 | 2.94E+04 | 3.63E+04 | 9.78E+03 | 1.04E+05 | 8.68E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.68E-15 | 3.07E-13 | 7.86E-15 | 2.12E-15 | 2.23E-14 | 5.44E-15 | 0.00E-01 | 0.00E-01 |
| TE129M | 5.98E+03 | 4.70E+04 | 3.85E+04 | 1.08E+04 | 1.13E+05 | 1.24E+04 | 0.00E-01 | 0.00E-01 |
| TE129 | 1.01E-27 | 2.64E-25 | 4.24E-27 | 1.19E-27 | 1.24E-26 | 3.03E-27 | 0.00E-01 | 0.00E-01 |
| TE131M | 6.17E-03 | 2.35E-01 | 1.68E-02 | 5.80E-03 | 5.61E-02 | 1.19E-02 | 0.00E-01 | 0.00E-01 |
| TE131 | 9.76E-29 | 1.72E-27 | 3.28E-28 | 1.00E-28 | 9.92E-28 | 2.51E-28 | 0.00E-01 | 0.00E-01 |
| TE132 | 2.76E+01 | 2.30E+02 | 5.16E+01 | 2.28E+01 | 2.12E+02 | 3.32E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 1.43E-11 | 1.30E-11 | 1.38E-11 | 2.78E-11 | 4.16E-11 | 3.07E-09 | 0.00E-01 | 0.00E-01 |
| I 131 | 4.49E+01 | 7.04E+00 | 7.86E+01 | 7.90E+01 | 1.30E+02 | 2.61E+04 | 0.00E-01 | 0.00E-01 |
| I 132 | 2.14E-27 | 5.47E-27 | 2.53E-27 | 4.64E-27 | 7.11E-27 | 2.16E-25 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.28E-06 | 1.37E-06 | 2.74E-06 | 3.39E-06 | 5.65E-06 | 6.30E-04 | 0.00E-01 | 0.00E-01 |
| I 134 | 2.65E-28 | 3.81E-28 | 3.10E-28 | 5.75E-28 | 8.80E-28 | 1.32E-26 | 0.00E-01 | 0.00E-01 |
| I 135 | 2.26E-22 | 3.64E-22 | 2.66E-22 | 4.78E-22 | 7.33E-22 | 4.23E-20 | 0.00E-01 | 0.00E-01 |
| CS134 | 6.03E+03 | 1.54E+02 | 1.74E+04 | 2.86E+04 | 8.87E+03 | 0.00E-01 | 3.18E+03 | 0.00E-01 |
| CS136 | 6.61E+02 | 3.59E+01 | 3.72E+02 | 1.02E+03 | 5.44E+02 | 0.00E-01 | 8.11E+01 | 0.00E-01 |
| CS137 | 3.56E+03 | 1.51E+02 | 2.52E+04 | 2.41E+04 | 7.86E+03 | 0.00E-01 | 2.83E+03 | 0.00E-01 |
| CS138 | 7.67E-29 | 5.57E-29 | 8.70E-29 | 1.21E-28 | 8.51E-29 | 0.00E-01 | 9.16E-30 | 0.00E-01 |
| BA139 | 2.05E-29 | 4.08E-26 | 7.07E-28 | 3.77E-31 | 3.29E-31 | 0.00E-01 | 2.22E-31 | 0.00E-01 |
| BA140 | 5.91E+01 | 5.13E+02 | 1.01E+03 | 8.88E-01 | 2.89E-01 | 0.00E-01 | 5.29E-01 | 0.00E-01 |
| BA141 | 4.20E-31 | 7.36E-30 | 1.29E-29 | 7.23E-33 | 6.25E-33 | 0.00E-01 | 4.25E-32 | 0.00E-01 |
| BA142 | 3.68E-32 | 8.58E-33 | 6.58E-31 | 4.74E-34 | 3.83E-34 | 0.00E-01 | 2.79E-34 | 0.00E-01 |
| LA140 | 1.60E-07 | 1.32E-02 | 1.36E-06 | 4.75E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 6.59E-33 | 4.17E-27 | 6.60E-32 | 2.11E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 3.50E-02 | 2.94E+02 | 4.73E-01 | 2.36E-01 | 1.03E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 6.25E-08 | 6.32E-03 | 7.96E-07 | 4.31E-04 | 1.81E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 2.36E+00 | 3.62E+03 | 4.43E+01 | 1.39E+01 | 7.68E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 3.82E-02 | 8.31E+02 | 7.71E-01 | 2.31E-01 | 1.25E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 5.09E-34 | 6.73E-30 | 1.01E-32 | 3.13E-33 | 1.65E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.74E-02 | 3.57E+02 | 2.78E-01 | 2.25E-01 | 1.23E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 2.15E-07 | 6.74E-05 | 8.10E-07 | 4.80E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 5.25E-07 | 5.52E-02 | 1.04E-05 | 7.46E-07 | 2.16E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = IRRIGATED STORED FEED-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 8.73E+00 | 8.73E+00 | 0.00E-01 | 8.73E+00 | 8.73E+00 | 8.73E+00 | 8.73E+00 | 0.00E-01 |
| C 14 | 3.03E+04 | 3.03E+04 | 1.51E+05 | 3.03E+04 | 3.03E+04 | 3.03E+04 | 3.03E+04 | 0.00E-01 |
| NA 24 | 2.07E+02 | 2.07E+02 | 2.07E+02 | 2.07E+02 | 2.07E+02 | 2.07E+02 | 2.07E+02 | 0.00E-01 |
| P 32 | 7.27E+04 | 5.21E+04 | 1.89E+06 | 8.83E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 2.43E+00 | 1.29E+02 | 0.00E-01 | 0.00E-01 | 3.69E-01 | 1.35E+00 | 2.46E+00 | 0.00E-01 |
| MN 54 | 1.29E+02 | 4.08E+02 | 0.00E-01 | 4.86E+02 | 1.36E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 5.11E-08 | 3.28E-05 | 0.00E-01 | 2.26E-07 | 2.74E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 4.23E+02 | 2.53E+02 | 2.57E+03 | 1.36E+03 | 0.00E-01 | 0.00E-01 | 7.72E+02 | 0.00E-01 |
| FE 59 | 2.29E+03 | 4.80E+03 | 2.85E+03 | 4.61E+03 | 0.00E-01 | 0.00E-01 | 1.34E+03 | 0.00E-01 |
| CO 58 | 8.73E+02 | 1.66E+03 | 0.00E-01 | 2.85E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 2.94E+03 | 5.52E+03 | 0.00E-01 | 9.96E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 2.35E+04 | 2.49E+03 | 6.91E+05 | 3.70E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.70E-06 | 3.57E-04 | 3.09E-05 | 2.91E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 1.03E+00 | 7.98E+01 | 0.00E-01 | 1.70E+00 | 4.11E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.62E+05 | 4.58E+04 | 9.78E+04 | 2.61E+05 | 1.64E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 3.59E-17 | 2.45E-14 | 2.69E-16 | 3.89E-16 | 2.36E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 8.21E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 7.38E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 5.67E-35 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 1.30E+05 | 1.36E+04 | 0.00E-01 | 2.11E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 5.95E-28 | 4.20E-29 | 0.00E-01 | 8.57E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 2.70E-28 | 2.64E-30 | 0.00E-01 | 3.03E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 4.53E+03 | 6.14E+03 | 1.59E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.31E+05 | 5.84E+04 | 6.53E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 1.11E-01 | 6.47E+00 | 2.93E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 1.68E-06 | 7.95E-04 | 4.20E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 2.07E-04 | 2.20E+01 | 7.73E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 9.59E-26 | 5.16E-21 | 2.63E-24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 2.46E-02 | 1.23E+02 | 9.20E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 1.51E-10 | 1.53E-04 | 5.28E-09 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 6.25E-07 | 3.39E-01 | 2.28E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.77E-02 | 2.07E+01 | 9.03E-02 | 1.98E-02 | 2.84E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 3.80E-06 | 9.76E-01 | 4.46E-05 | 6.44E-06 | 9.25E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 2.11E+00 | 5.45E+03 | 7.58E+00 | 2.95E+00 | 2.77E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 4.82E+02 | 1.61E+03 | 0.00E-01 | 1.95E+03 | 4.16E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 9.29E-03 | 3.19E-01 | 2.86E-04 | 5.61E-04 | 8.15E-03 | 0.00E-01 | 2.85E-04 | 0.00E-01 |
| TC101 | 2.32E-29 | 5.83E-30 | 1.75E-30 | 1.83E-30 | 3.13E-29 | 0.00E-01 | 9.69E-31 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = IRRIGATED STORED FEED--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 3.91E-02 | 2.63E+00 | 1.02E-01 | 0.00E-01 | 2.56E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 2.87E-08 | 5.17E-05 | 7.92E-08 | 0.00E-01 | 6.96E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 2.67E-01 | 3.33E+01 | 2.14E+00 | 0.00E-01 | 2.89E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 2.63E+03 | 3.92E+05 | 4.87E+03 | 3.29E+03 | 6.13E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 2.37E+02 | 1.71E+03 | 1.77E+03 | 4.81E+02 | 0.00E-01 | 4.98E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 5.96E+02 | 4.07E+03 | 5.02E+03 | 1.35E+03 | 1.43E+04 | 1.20E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.44E-02 | 2.63E+00 | 6.73E-02 | 1.81E-02 | 1.91E-01 | 4.66E-02 | 0.00E-01 | 0.00E-01 |
| TE129M | 1.02E+03 | 7.98E+03 | 6.55E+03 | 1.83E+03 | 1.92E+04 | 2.11E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 4.19E-15 | 1.10E-12 | 1.77E-14 | 4.93E-15 | 5.17E-14 | 1.26E-14 | 0.00E-01 | 0.00E-01 |
| TE131M | 1.40E+01 | 5.33E+02 | 3.80E+01 | 1.31E+01 | 1.27E+02 | 2.70E+01 | 0.00E-01 | 0.00E-01 |
| TE131 | 1.02E-29 | 1.80E-28 | 3.43E-29 | 1.05E-29 | 1.04E-28 | 2.62E-29 | 0.00E-01 | 0.00E-01 |
| TE132 | 1.32E+02 | 1.10E+03 | 2.47E+02 | 1.09E+02 | 1.02E+03 | 1.59E+02 | 0.00E-01 | 0.00E-01 |
| I 130 | 8.21E+00 | 7.45E+00 | 7.89E+00 | 1.59E+01 | 2.38E+01 | 1.76E+03 | 0.00E-01 | 0.00E-01 |
| I 131 | 3.59E+03 | 5.63E+02 | 6.28E+03 | 6.32E+03 | 1.04E+04 | 2.09E+06 | 0.00E-01 | 0.00E-01 |
| I 132 | 2.13E-06 | 5.44E-06 | 2.52E-06 | 4.62E-06 | 7.07E-06 | 2.14E-04 | 0.00E-01 | 0.00E-01 |
| I 133 | 3.78E+01 | 4.02E+01 | 8.07E+01 | 9.98E+01 | 1.66E+02 | 1.85E+04 | 0.00E-01 | 0.00E-01 |
| I 134 | 1.55E-17 | 2.24E-17 | 1.82E-17 | 3.38E-17 | 5.17E-17 | 7.77E-16 | 0.00E-01 | 0.00E-01 |
| I 135 | 1.99E-01 | 3.20E-01 | 2.33E-01 | 4.20E-01 | 6.43E-01 | 3.72E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.81E+05 | 4.62E+03 | 5.22E+05 | 8.57E+05 | 2.65E+05 | 0.00E-01 | 9.53E+04 | 0.00E-01 |
| CS136 | 4.33E+04 | 2.35E+03 | 2.43E+04 | 6.69E+04 | 3.56E+04 | 0.00E-01 | 5.31E+03 | 0.00E-01 |
| CS137 | 1.05E+05 | 4.47E+03 | 7.45E+05 | 7.14E+05 | 2.33E+05 | 0.00E-01 | 8.37E+04 | 0.00E-01 |
| CS138 | 1.85E-27 | 1.35E-27 | 2.10E-27 | 2.92E-27 | 2.05E-27 | 0.00E-01 | 2.21E-28 | 0.00E-01 |
| BA139 | 7.33E-14 | 1.46E-10 | 2.53E-12 | 1.35E-15 | 1.18E-15 | 0.00E-01 | 7.94E-16 | 0.00E-01 |
| BA140 | 1.65E+02 | 1.43E+03 | 2.82E+03 | 2.47E+00 | 8.05E-01 | 0.00E-01 | 1.48E+00 | 0.00E-01 |
| BA141 | 4.23E-31 | 7.40E-30 | 1.30E-29 | 7.27E-33 | 6.29E-33 | 0.00E-01 | 4.27E-32 | 0.00E-01 |
| BA142 | 3.70E-32 | 8.64E-33 | 6.62E-31 | 4.76E-34 | 3.86E-34 | 0.00E-01 | 2.80E-34 | 0.00E-01 |
| LA140 | 5.46E-05 | 4.51E+00 | 4.63E-04 | 1.62E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 6.30E-17 | 3.99E-11 | 6.32E-16 | 2.01E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 3.86E-02 | 3.24E+02 | 5.21E-01 | 2.60E-01 | 1.14E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 3.52E-04 | 3.56E+01 | 4.48E-03 | 2.43E+00 | 1.02E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 2.00E+00 | 3.07E+03 | 3.75E+01 | 1.18E+01 | 6.52E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 8.60E-04 | 1.87E+01 | 1.73E-02 | 5.20E-03 | 2.82E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 4.35E-36 | 5.76E-32 | 8.66E-35 | 2.68E-35 | 1.42E-35 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 6.77E-04 | 1.39E+01 | 1.08E-02 | 8.75E-03 | 4.80E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 1.82E-01 | 5.71E+01 | 6.86E-01 | 4.06E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 2.09E-05 | 2.20E+00 | 4.14E-04 | 2.97E-05 | 8.59E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = IRRIGATED STORED FEED--MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.19E+00 | 1.19E+00 | 0.00E-01 | 1.19E+00 | 1.19E+00 | 1.19E+00 | 1.19E+00 | 0.00E-01 |
| C 14 | 9.72E+03 | 9.72E+03 | 4.86E+04 | 9.72E+03 | 9.72E+03 | 9.72E+03 | 9.72E+03 | 0.00E-01 |
| NA 24 | 4.37E-08 | 4.37E-08 | 4.37E-08 | 4.37E-08 | 4.37E-08 | 4.37E-08 | 4.37E-08 | 0.00E-01 |
| P 32 | 6.95E+03 | 4.98E+03 | 1.80E+05 | 8.43E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 2.10E-01 | 1.11E+01 | 0.00E-01 | 0.00E-01 | 3.18E-02 | 1.16E-01 | 2.13E-01 | 0.00E-01 |
| MN 54 | 4.94E+01 | 1.56E+02 | 0.00E-01 | 1.85E+02 | 5.20E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 7.56E-29 | 4.86E-26 | 0.00E-01 | 3.35E-28 | 4.05E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 1.73E+03 | 1.03E+03 | 1.05E+04 | 5.58E+03 | 0.00E-01 | 0.00E-01 | 3.16E+03 | 0.00E-01 |
| FE 59 | 7.18E+03 | 1.50E+04 | 8.91E+03 | 1.44E+04 | 0.00E-01 | 0.00E-01 | 4.18E+03 | 0.00E-01 |
| CO 58 | 1.18E+03 | 2.25E+03 | 0.00E-01 | 3.86E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 4.71E+03 | 8.85E+03 | 0.00E-01 | 1.60E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 2.31E+04 | 2.45E+03 | 6.79E+05 | 3.63E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 7.92E-27 | 1.66E-24 | 1.44E-25 | 1.36E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 3.95E-12 | 3.07E-10 | 0.00E-01 | 6.53E-12 | 1.58E-11 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.47E+04 | 4.16E+03 | 8.88E+03 | 2.37E+04 | 1.49E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 5.16E-29 | 3.52E-26 | 3.86E-28 | 5.58E-28 | 3.39E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 5.11E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 4.77E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 3.66E-36 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 8.56E+03 | 8.95E+02 | 0.00E-01 | 1.39E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 7.64E-29 | 5.39E-30 | 0.00E-01 | 1.10E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 3.46E-29 | 3.40E-31 | 0.00E-01 | 3.90E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 3.29E+02 | 4.47E+02 | 1.15E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.22E+04 | 5.44E+03 | 6.08E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 2.01E-16 | 1.17E-14 | 5.31E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 2.93E-28 | 1.38E-25 | 7.30E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 1.11E-04 | 1.18E+01 | 4.16E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 1.47E-32 | 7.90E-28 | 4.04E-31 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 1.14E+00 | 5.66E+03 | 4.25E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 8.83E-31 | 8.92E-25 | 3.09E-29 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 4.49E-18 | 2.44E-12 | 1.64E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.23E+01 | 1.44E+04 | 6.28E+01 | 1.38E+01 | 1.97E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 6.41E-11 | 1.65E-05 | 7.52E-10 | 1.09E-10 | 1.56E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 2.06E+01 | 5.32E+04 | 7.39E+01 | 2.88E+01 | 2.70E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 6.80E-01 | 2.28E+00 | 0.00E-01 | 2.75E+00 | 5.87E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 4.50E-24 | 1.54E-22 | 1.39E-25 | 2.72E-25 | 3.95E-24 | 0.00E-01 | 1.38E-25 | 0.00E-01 |
| TC101 | 4.62E-29 | 1.16E-29 | 3.48E-30 | 3.65E-30 | 6.22E-29 | 0.00E-01 | 1.93E-30 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = IRRIGATED STORED FEED-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.41E+03 | 9.52E+04 | 3.68E+03 | 0.00E-01 | 9.27E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 2.26E-26 | 4.07E-23 | 6.23E-26 | 0.00E-01 | 5.48E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 1.28E+04 | 1.60E+06 | 1.03E+05 | 0.00E-01 | 1.39E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 1.06E+02 | 1.57E+04 | 1.96E+02 | 1.32E+02 | 2.46E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 1.83E+03 | 1.32E+04 | 1.37E+04 | 3.71E+03 | 0.00E-01 | 3.85E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 5.09E+03 | 3.47E+04 | 4.28E+04 | 1.15E+04 | 1.22E+05 | 1.02E+04 | 0.00E-01 | 0.00E-01 |
| TE127 | 1.68E-15 | 3.07E-13 | 7.86E-15 | 2.12E-15 | 2.23E-14 | 5.44E-15 | 0.00E-01 | 0.00E-01 |
| TE129M | 6.70E+03 | 5.27E+04 | 4.32E+04 | 1.21E+04 | 1.27E+05 | 1.39E+04 | 0.00E-01 | 0.00E-01 |
| TE129 | 1.01E-27 | 2.64E-25 | 4.24E-27 | 1.19E-27 | 1.24E-26 | 3.03E-27 | 0.00E-01 | 0.00E-01 |
| TE131M | 6.17E-03 | 2.35E-01 | 1.68E-02 | 5.80E-03 | 5.61E-02 | 1.19E-02 | 0.00E-01 | 0.00E-01 |
| TE131 | 9.76E-29 | 1.72E-27 | 3.28E-28 | 1.00E-28 | 9.92E-28 | 2.51E-28 | 0.00E-01 | 0.00E-01 |
| TE132 | 2.76E+01 | 2.30E+02 | 5.16E+01 | 2.28E+01 | 2.12E+02 | 3.32E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 1.43E-11 | 1.30E-11 | 1.38E-11 | 2.78E-11 | 4.16E-11 | 3.07E-09 | 0.00E-01 | 0.00E-01 |
| I 131 | 4.57E+01 | 7.16E+00 | 7.99E+01 | 8.04E+01 | 1.32E+02 | 2.66E+04 | 0.00E-01 | 0.00E-01 |
| I 132 | 2.14E-27 | 5.47E-27 | 2.53E-27 | 4.64E-27 | 7.11E-27 | 2.16E-25 | 0.00E-01 | 0.00E-01 |
| I 133 | 1.28E-06 | 1.37E-06 | 2.74E-06 | 3.39E-06 | 5.65E-06 | 6.30E-04 | 0.00E-01 | 0.00E-01 |
| I 134 | 2.65E-28 | 3.81E-28 | 3.10E-28 | 5.75E-28 | 8.80E-28 | 1.32E-26 | 0.00E-01 | 0.00E-01 |
| I 135 | 2.26E-22 | 3.64E-22 | 2.66E-22 | 4.78E-22 | 7.33E-22 | 4.23E-20 | 0.00E-01 | 0.00E-01 |
| CS134 | 7.36E+03 | 1.88E+02 | 2.13E+04 | 3.49E+04 | 1.08E+04 | 0.00E-01 | 3.88E+03 | 0.00E-01 |
| CS136 | 6.92E+02 | 3.76E+01 | 3.89E+02 | 1.07E+03 | 5.69E+02 | 0.00E-01 | 8.49E+01 | 0.00E-01 |
| CS137 | 4.36E+03 | 1.85E+02 | 3.08E+04 | 2.95E+04 | 9.62E+03 | 0.00E-01 | 3.46E+03 | 0.00E-01 |
| CS138 | 7.67E-29 | 5.57E-29 | 8.70E-29 | 1.21E-28 | 8.51E-29 | 0.00E-01 | 9.16E-30 | 0.00E-01 |
| BA139 | 2.05E-29 | 4.08E-26 | 7.07E-28 | 3.77E-31 | 3.29E-31 | 0.00E-01 | 2.22E-31 | 0.00E-01 |
| BA140 | 6.18E+01 | 5.36E+02 | 1.06E+03 | 9.27E-01 | 3.02E-01 | 0.00E-01 | 5.53E-01 | 0.00E-01 |
| BA141 | 4.20E-31 | 7.36E-30 | 1.29E-29 | 7.23E-33 | 6.25E-33 | 0.00E-01 | 4.25E-32 | 0.00E-01 |
| BA142 | 3.68E-32 | 8.58E-33 | 6.58E-31 | 4.74E-34 | 3.83E-34 | 0.00E-01 | 2.79E-34 | 0.00E-01 |
| LA140 | 1.60E-07 | 1.32E-02 | 1.36E-06 | 4.75E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 6.59E-33 | 4.17E-27 | 6.60E-32 | 2.11E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 3.92E-02 | 3.29E+02 | 5.29E-01 | 2.64E-01 | 1.16E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 6.25E-08 | 6.32E-03 | 7.96E-07 | 4.31E-04 | 1.81E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 2.86E+00 | 4.38E+03 | 5.36E+01 | 1.68E+01 | 9.30E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 4.01E-02 | 8.72E+02 | 8.08E-01 | 2.43E-01 | 1.32E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 5.09E-34 | 6.73E-30 | 1.01E-32 | 3.13E-33 | 1.65E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.80E-02 | 3.69E+02 | 2.88E-01 | 2.33E-01 | 1.28E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 2.15E-07 | 6.74E-05 | 8.10E-07 | 4.80E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 5.25E-07 | 5.52E-02 | 1.04E-05 | 7.46E-07 | 2.16E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = ANIMAL DRINKING WATER--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.05E+01 | 1.05E+01 | 0.00E-01 | 1.05E+01 | 1.05E+01 | 1.05E+01 | 1.05E+01 | 0.00E-01 |
| C 14 | 2.88E+02 | 2.88E+02 | 1.44E+03 | 2.88E+02 | 2.88E+02 | 2.88E+02 | 2.88E+02 | 0.00E-01 |
| NA 24 | 2.41E+02 | 2.41E+02 | 2.41E+02 | 2.41E+02 | 2.41E+02 | 2.41E+02 | 2.41E+02 | 0.00E-01 |
| P 32 | 7.15E+03 | 5.13E+03 | 1.86E+05 | 8.68E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.85E-01 | 9.80E+00 | 0.00E-01 | 0.00E-01 | 2.80E-02 | 1.03E-01 | 1.87E-01 | 0.00E-01 |
| MN 54 | 7.05E+00 | 2.22E+01 | 0.00E-01 | 2.65E+01 | 7.42E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 3.36E-07 | 2.16E-04 | 0.00E-01 | 1.49E-06 | 1.80E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 2.25E+01 | 1.34E+01 | 1.37E+02 | 7.26E+01 | 0.00E-01 | 0.00E-01 | 4.11E+01 | 0.00E-01 |
| FE 59 | 1.54E+02 | 3.21E+02 | 1.91E+02 | 3.08E+02 | 0.00E-01 | 0.00E-01 | 8.94E+01 | 0.00E-01 |
| CO 58 | 5.37E+01 | 1.02E+02 | 0.00E-01 | 1.75E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 1.55E+02 | 2.91E+02 | 0.00E-01 | 5.25E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.22E+03 | 1.29E+02 | 3.58E+04 | 1.92E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.14E-05 | 2.39E-03 | 2.07E-04 | 1.95E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 1.41E+00 | 1.09E+02 | 0.00E-01 | 2.33E+00 | 5.64E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 8.74E+03 | 2.47E+03 | 5.28E+03 | 1.41E+04 | 8.86E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 6.36E-16 | 4.34E-13 | 4.76E-15 | 6.89E-15 | 4.18E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 5.78E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 2.33E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 1.99E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 1.14E+04 | 1.19E+03 | 0.00E-01 | 1.85E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 3.35E-26 | 2.37E-27 | 0.00E-01 | 4.83E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 1.78E-26 | 1.75E-28 | 0.00E-01 | 2.00E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 2.91E+02 | 3.95E+02 | 1.02E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 4.09E+03 | 1.82E+03 | 2.03E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 2.01E-01 | 1.17E+01 | 5.31E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 1.05E-05 | 4.94E-03 | 2.61E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 6.44E-05 | 6.85E+00 | 2.40E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 1.95E-24 | 1.05E-19 | 5.36E-23 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 1.56E-03 | 7.78E+00 | 5.84E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 7.21E-10 | 7.28E-04 | 2.52E-08 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 1.07E-06 | 5.81E-01 | 3.90E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.10E-03 | 1.29E+00 | 5.64E-03 | 1.24E-03 | 1.77E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 3.96E-06 | 1.02E+00 | 4.65E-05 | 6.72E-06 | 9.64E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 1.49E-01 | 3.86E+02 | 5.37E-01 | 2.09E-01 | 1.96E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 1.46E+02 | 4.90E+02 | 0.00E-01 | 5.92E+02 | 1.26E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 2.64E-02 | 9.05E-01 | 8.11E-04 | 1.59E-03 | 2.31E-02 | 0.00E-01 | 8.07E-04 | 0.00E-01 |
| TC101 | 1.65E-27 | 4.13E-28 | 1.24E-28 | 1.30E-28 | 2.22E-27 | 0.00E-01 | 6.87E-29 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = ANIMAL DRINKING WATER-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 2.69E-03 | 1.81E-01 | 7.01E-03 | 0.00E-01 | 1.76E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.10E-07 | 1.98E-04 | 3.03E-07 | 0.00E-01 | 2.67E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 1.44E-02 | 1.80E+00 | 1.16E-01 | 0.00E-01 | 1.56E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 1.44E+02 | 2.14E+04 | 2.66E+02 | 1.80E+02 | 3.35E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 1.47E+01 | 1.07E+02 | 1.10E+02 | 3.00E+01 | 0.00E-01 | 3.10E+01 | 0.00E-01 | 0.00E-01 |
| TE127M | 3.36E+01 | 2.29E+02 | 2.83E+02 | 7.63E+01 | 8.08E+02 | 6.78E+01 | 0.00E-01 | 0.00E-01 |
| TE127 | 2.65E-02 | 4.83E+00 | 1.24E-01 | 3.33E-02 | 3.52E-01 | 8.56E-02 | 0.00E-01 | 0.00E-01 |
| TE129M | 7.20E+01 | 5.66E+02 | 4.64E+02 | 1.29E+02 | 1.36E+03 | 1.49E+02 | 0.00E-01 | 0.00E-01 |
| TE129 | 6.06E-14 | 1.59E-11 | 2.55E-13 | 7.13E-14 | 7.47E-13 | 1.82E-13 | 0.00E-01 | 0.00E-01 |
| TE131M | 8.48E+00 | 3.23E+02 | 2.30E+01 | 7.97E+00 | 7.72E+01 | 1.64E+01 | 0.00E-01 | 0.00E-01 |
| TE131 | 4.09E-28 | 7.21E-27 | 1.37E-27 | 4.19E-28 | 4.15E-27 | 1.05E-27 | 0.00E-01 | 0.00E-01 |
| TE132 | 3.48E+01 | 2.90E+02 | 6.50E+01 | 2.88E+01 | 2.67E+02 | 4.19E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 1.16E+01 | 1.05E+01 | 1.11E+01 | 2.24E+01 | 3.35E+01 | 2.47E+03 | 0.00E-01 | 0.00E-01 |
| I 131 | 4.91E+02 | 7.70E+01 | 8.60E+02 | 8.65E+02 | 1.42E+03 | 2.86E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.56E-05 | 3.99E-05 | 1.85E-05 | 3.39E-05 | 5.19E-05 | 1.57E-03 | 0.00E-01 | 0.00E-01 |
| I 133 | 3.23E+01 | 3.44E+01 | 6.90E+01 | 8.53E+01 | 1.42E+02 | 1.59E+04 | 0.00E-01 | 0.00E-01 |
| I 134 | 2.99E-16 | 4.30E-16 | 3.50E-16 | 6.49E-16 | 9.93E-16 | 1.49E-14 | 0.00E-01 | 0.00E-01 |
| I 135 | 5.15E-01 | 8.29E-01 | 6.04E-01 | 1.09E+00 | 1.67E+00 | 9.64E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 9.64E+03 | 2.46E+02 | 2.78E+04 | 4.57E+04 | 1.42E+04 | 0.00E-01 | 5.08E+03 | 0.00E-01 |
| CS136 | 4.47E+03 | 2.43E+02 | 2.51E+03 | 6.91E+03 | 3.68E+03 | 0.00E-01 | 5.49E+02 | 0.00E-01 |
| CS137 | 5.51E+03 | 2.34E+02 | 3.90E+04 | 3.73E+04 | 1.22E+04 | 0.00E-01 | 4.37E+03 | 0.00E-01 |
| CS138 | 5.78E-26 | 4.20E-26 | 6.56E-26 | 9.12E-26 | 6.42E-26 | 0.00E-01 | 6.91E-27 | 0.00E-01 |
| BA139 | 8.98E-13 | 1.79E-09 | 3.10E-11 | 1.65E-14 | 1.44E-14 | 0.00E-01 | 9.72E-15 | 0.00E-01 |
| BA140 | 1.73E+01 | 1.50E+02 | 2.96E+02 | 2.59E-01 | 8.43E-02 | 0.00E-01 | 1.54E-01 | 0.00E-01 |
| BA141 | 2.33E-29 | 4.08E-28 | 7.15E-28 | 4.01E-31 | 3.47E-31 | 0.00E-01 | 2.35E-30 | 0.00E-01 |
| BA142 | 3.48E-30 | 8.13E-31 | 6.23E-29 | 4.48E-32 | 3.63E-32 | 0.00E-01 | 2.64E-32 | 0.00E-01 |
| LA140 | 2.54E-05 | 2.10E+00 | 2.16E-04 | 7.55E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 6.89E-16 | 4.36E-10 | 6.91E-15 | 2.20E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 2.80E-03 | 2.35E+01 | 3.78E-02 | 1.88E-02 | 8.26E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 1.96E-04 | 1.98E+01 | 2.49E-03 | 1.35E+00 | 5.67E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.10E-01 | 1.68E+02 | 2.06E+00 | 6.45E-01 | 3.57E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 8.73E-05 | 1.90E+00 | 1.76E-03 | 5.28E-04 | 2.86E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 2.54E-34 | 3.36E-30 | 5.05E-33 | 1.56E-33 | 8.26E-34 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 7.65E-05 | 1.57E+00 | 1.22E-03 | 9.88E-04 | 5.42E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 1.37E-01 | 4.29E+01 | 5.15E-01 | 3.05E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 7.23E-06 | 7.61E-01 | 1.43E-04 | 1.03E-05 | 2.97E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = ANIMAL DRINKING WATER-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.19E+00 | 1.19E+00 | 0.00E-01 | 1.19E+00 | 1.19E+00 | 1.19E+00 | 1.19E+00 | 0.00E-01 |
| C 14 | 7.72E+01 | 7.72E+01 | 3.86E+02 | 7.72E+01 | 7.72E+01 | 7.72E+01 | 7.72E+01 | 0.00E-01 |
| NA 24 | 4.24E-08 | 4.24E-08 | 4.24E-08 | 4.24E-08 | 4.24E-08 | 4.24E-08 | 4.24E-08 | 0.00E-01 |
| P 32 | 5.70E+02 | 4.08E+02 | 1.48E+04 | 6.91E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 1.33E-02 | 7.05E-01 | 0.00E-01 | 0.00E-01 | 2.02E-03 | 7.38E-03 | 1.35E-02 | 0.00E-01 |
| MN 54 | 2.24E+00 | 7.07E+00 | 0.00E-01 | 8.42E+00 | 2.36E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 4.15E-28 | 2.66E-25 | 0.00E-01 | 1.84E-27 | 2.22E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 7.67E+01 | 4.58E+01 | 4.67E+02 | 2.47E+02 | 0.00E-01 | 0.00E-01 | 1.40E+02 | 0.00E-01 |
| FE 59 | 4.01E+02 | 8.38E+02 | 4.97E+02 | 8.04E+02 | 0.00E-01 | 0.00E-01 | 2.33E+02 | 0.00E-01 |
| CO 58 | 6.06E+01 | 1.15E+02 | 0.00E-01 | 1.98E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 2.07E+02 | 3.89E+02 | 0.00E-01 | 7.02E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 9.97E+02 | 1.06E+02 | 2.93E+04 | 1.57E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 4.42E-26 | 9.28E-24 | 8.05E-25 | 7.58E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 4.52E-12 | 3.51E-10 | 0.00E-01 | 7.48E-12 | 1.81E-11 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 6.62E+02 | 1.87E+02 | 3.99E+02 | 1.06E+03 | 6.70E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 7.61E-28 | 5.19E-25 | 5.70E-27 | 8.24E-27 | 5.00E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 3.00E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 1.25E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 1.07E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 6.25E+02 | 6.54E+01 | 0.00E-01 | 1.02E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 3.59E-27 | 2.53E-28 | 0.00E-01 | 5.17E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 1.90E-27 | 1.87E-29 | 0.00E-01 | 2.14E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.77E+01 | 2.40E+01 | 6.19E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 3.17E+02 | 1.41E+02 | 1.58E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 3.03E-16 | 1.77E-14 | 8.03E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 1.51E-27 | 7.16E-25 | 3.78E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 2.89E-05 | 3.07E+00 | 1.08E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 2.49E-31 | 1.34E-26 | 6.84E-30 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 6.01E-02 | 2.99E+02 | 2.25E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 3.51E-30 | 3.55E-24 | 1.23E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 6.41E-18 | 3.48E-12 | 2.34E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 6.39E-01 | 7.49E+02 | 3.27E+00 | 7.18E-01 | 1.03E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 5.57E-11 | 1.43E-05 | 6.53E-10 | 9.44E-11 | 1.36E-10 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 1.22E+00 | 3.14E+03 | 4.37E+00 | 1.70E+00 | 1.60E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 1.72E-01 | 5.77E-01 | 0.00E-01 | 6.97E-01 | 1.49E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 1.06E-23 | 3.65E-22 | 3.27E-25 | 6.42E-25 | 9.32E-24 | 0.00E-01 | 3.26E-25 | 0.00E-01 |
| TC101 | 2.73E-27 | 6.85E-28 | 2.06E-28 | 2.15E-28 | 3.67E-27 | 0.00E-01 | 1.14E-28 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = ANIMAL DRINKING WATER-MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 8.12E+01 | 5.46E+03 | 2.11E+02 | 0.00E-01 | 5.32E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 7.21E-26 | 1.30E-22 | 1.99E-25 | 0.00E-01 | 1.75E-24 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 5.78E+02 | 7.21E+04 | 4.64E+03 | 0.00E-01 | 6.26E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 4.82E+00 | 7.16E+02 | 8.92E+00 | 6.02E+00 | 1.12E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 9.48E+01 | 6.86E+02 | 7.11E+02 | 1.93E+02 | 0.00E-01 | 2.00E+02 | 0.00E-01 | 0.00E-01 |
| TE127M | 2.39E+02 | 1.63E+03 | 2.01E+03 | 5.42E+02 | 5.75E+03 | 4.82E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 2.58E-15 | 4.70E-13 | 1.20E-14 | 3.24E-15 | 3.42E-14 | 8.32E-15 | 0.00E-01 | 0.00E-01 |
| TE129M | 3.96E+02 | 3.11E+03 | 2.55E+03 | 7.12E+02 | 7.49E+03 | 8.22E+02 | 0.00E-01 | 0.00E-01 |
| TE129 | 1.21E-26 | 3.18E-24 | 5.11E-26 | 1.43E-26 | 1.50E-25 | 3.65E-26 | 0.00E-01 | 0.00E-01 |
| TE131M | 3.12E-03 | 1.19E-01 | 8.47E-03 | 2.93E-03 | 2.84E-02 | 6.03E-03 | 0.00E-01 | 0.00E-01 |
| TE131 | 3.26E-27 | 5.75E-26 | 1.10E-26 | 3.34E-27 | 3.31E-26 | 8.38E-27 | 0.00E-01 | 0.00E-01 |
| TE132 | 6.04E+00 | 5.03E+01 | 1.13E+01 | 5.00E+00 | 4.64E+01 | 7.28E+00 | 0.00E-01 | 0.00E-01 |
| I 130 | 1.68E-11 | 1.53E-11 | 1.62E-11 | 3.27E-11 | 4.88E-11 | 3.60E-09 | 0.00E-01 | 0.00E-01 |
| I 131 | 5.21E+00 | 8.16E-01 | 9.11E+00 | 9.17E+00 | 1.51E+01 | 3.03E+03 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.31E-26 | 3.34E-26 | 1.55E-26 | 2.84E-26 | 4.35E-26 | 1.32E-24 | 0.00E-01 | 0.00E-01 |
| I 133 | 9.14E-07 | 9.73E-07 | 1.95E-06 | 2.41E-06 | 4.03E-06 | 4.49E-04 | 0.00E-01 | 0.00E-01 |
| I 134 | 4.24E-27 | 6.10E-27 | 4.96E-27 | 9.20E-27 | 1.41E-26 | 2.12E-25 | 0.00E-01 | 0.00E-01 |
| I 135 | 4.88E-22 | 7.87E-22 | 5.74E-22 | 1.03E-21 | 1.58E-21 | 9.14E-20 | 0.00E-01 | 0.00E-01 |
| CS134 | 3.27E+02 | 8.36E+00 | 9.45E+02 | 1.55E+03 | 4.81E+02 | 0.00E-01 | 1.72E+02 | 0.00E-01 |
| CS136 | 5.96E+01 | 3.24E+00 | 3.35E+01 | 9.21E+01 | 4.90E+01 | 0.00E-01 | 7.32E+00 | 0.00E-01 |
| CS137 | 1.90E+02 | 8.06E+00 | 1.34E+03 | 1.29E+03 | 4.19E+02 | 0.00E-01 | 1.51E+02 | 0.00E-01 |
| CS138 | 2.00E-27 | 1.45E-27 | 2.26E-27 | 3.15E-27 | 2.21E-27 | 0.00E-01 | 2.38E-28 | 0.00E-01 |
| BA139 | 2.09E-28 | 4.16E-25 | 7.21E-27 | 3.85E-30 | 3.36E-30 | 0.00E-01 | 2.26E-30 | 0.00E-01 |
| BA140 | 5.39E+00 | 4.68E+01 | 9.24E+01 | 8.09E-02 | 2.63E-02 | 0.00E-01 | 4.82E-02 | 0.00E-01 |
| BA141 | 1.93E-29 | 3.38E-28 | 5.93E-28 | 3.32E-31 | 2.87E-31 | 0.00E-01 | 1.95E-30 | 0.00E-01 |
| BA142 | 2.88E-30 | 6.73E-31 | 5.16E-29 | 3.71E-32 | 3.01E-32 | 0.00E-01 | 2.18E-32 | 0.00E-01 |
| LA140 | 6.23E-08 | 5.15E-03 | 5.28E-07 | 1.85E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 6.01E-32 | 3.80E-26 | 6.02E-31 | 1.92E-31 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 2.37E-03 | 1.99E+01 | 3.20E-02 | 1.59E-02 | 6.99E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 2.90E-08 | 2.93E-03 | 3.69E-07 | 2.00E-04 | 8.39E-08 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.31E-01 | 2.00E+02 | 2.44E+00 | 7.66E-01 | 4.24E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 3.39E-03 | 7.38E+01 | 6.84E-02 | 2.05E-02 | 1.11E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 2.47E-32 | 3.27E-28 | 4.91E-31 | 1.52E-31 | 8.04E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.70E-03 | 3.47E+01 | 2.71E-02 | 2.19E-02 | 1.20E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 1.35E-07 | 4.22E-05 | 5.07E-07 | 3.00E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 1.51E-07 | 1.59E-02 | 3.00E-06 | 2.15E-07 | 6.22E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = RIVER SHORELINE DEPOSITS

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 2.19E+00 | 2.19E+00 | 2.19E+00 | 2.19E+00 | 2.19E+00 | 2.19E+00 | 2.19E+00 | 2.54E+00 |
| P 32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 8.55E-01 | 8.55E-01 | 8.55E-01 | 8.55E-01 | 8.55E-01 | 8.55E-01 | 8.55E-01 | 1.01E+00 |
| MN 54 | 2.54E+02 | 2.54E+02 | 2.54E+02 | 2.54E+02 | 2.54E+02 | 2.54E+02 | 2.54E+02 | 2.98E+02 |
| MN 56 | 1.61E-01 | 1.61E-01 | 1.61E-01 | 1.61E-01 | 1.61E-01 | 1.61E-01 | 1.61E-01 | 1.90E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 5.01E+01 | 5.01E+01 | 5.01E+01 | 5.01E+01 | 5.01E+01 | 5.01E+01 | 5.01E+01 | 5.88E+01 |
| CO 58 | 6.98E+01 | 6.98E+01 | 6.98E+01 | 6.98E+01 | 6.98E+01 | 6.98E+01 | 6.98E+01 | 8.18E+01 |
| CO 60 | 3.95E+03 | 3.95E+03 | 3.95E+03 | 3.95E+03 | 3.95E+03 | 3.95E+03 | 3.95E+03 | 4.65E+03 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 5.31E-02 | 5.31E-02 | 5.31E-02 | 5.31E-02 | 5.31E-02 | 5.31E-02 | 5.31E-02 | 6.17E-02 |
| CU 64 | 1.11E-01 | 1.11E-01 | 1.11E-01 | 1.11E-01 | 1.11E-01 | 1.11E-01 | 1.11E-01 | 1.25E-01 |
| ZN 65 | 1.37E+02 | 1.37E+02 | 1.37E+02 | 1.37E+02 | 1.37E+02 | 1.37E+02 | 1.37E+02 | 1.58E+02 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 8.70E-04 | 8.70E-04 | 8.70E-04 | 8.70E-04 | 8.70E-04 | 8.70E-04 | 8.70E-04 | 1.26E-03 |
| BR 84 | 3.27E-02 | 3.27E-02 | 3.27E-02 | 3.27E-02 | 3.27E-02 | 3.27E-02 | 3.27E-02 | 3.81E-02 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 1.65E+00 | 1.89E+00 |
| RB 88 | 4.83E-03 | 4.83E-03 | 4.83E-03 | 4.83E-03 | 4.83E-03 | 4.83E-03 | 4.83E-03 | 5.52E-03 |
| RB 89 | 1.70E-02 | 1.70E-02 | 1.70E-02 | 1.70E-02 | 1.70E-02 | 1.70E-02 | 1.70E-02 | 2.04E-02 |
| SR 89 | 3.97E-03 | 3.97E-03 | 3.97E-03 | 3.97E-03 | 3.97E-03 | 3.97E-03 | 3.97E-03 | 4.61E-03 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 3.91E-01 | 3.91E-01 | 3.91E-01 | 3.91E-01 | 3.91E-01 | 3.91E-01 | 3.91E-01 | 4.57E-01 |
| SR 92 | 1.39E-01 | 1.39E-01 | 1.39E-01 | 1.39E-01 | 1.39E-01 | 1.39E-01 | 1.39E-01 | 1.55E-01 |
| Y 90 | 8.25E-04 | 8.25E-04 | 8.25E-04 | 8.25E-04 | 8.25E-04 | 8.25E-04 | 8.25E-04 | 9.76E-04 |
| Y 91M | 1.69E-02 | 1.69E-02 | 1.69E-02 | 1.69E-02 | 1.69E-02 | 1.69E-02 | 1.69E-02 | 1.96E-02 |
| Y 91 | 1.97E-01 | 1.97E-01 | 1.97E-01 | 1.97E-01 | 1.97E-01 | 1.97E-01 | 1.97E-01 | 2.22E-01 |
| Y 92 | 3.26E-02 | 3.26E-02 | 3.26E-02 | 3.26E-02 | 3.26E-02 | 3.26E-02 | 3.26E-02 | 3.87E-02 |
| Y 93 | 3.34E-02 | 3.34E-02 | 3.34E-02 | 3.34E-02 | 3.34E-02 | 3.34E-02 | 3.34E-02 | 4.57E-02 |
| ZR 95 | 4.51E+01 | 4.51E+01 | 4.51E+01 | 4.51E+01 | 4.51E+01 | 4.51E+01 | 4.51E+01 | 5.23E+01 |
| ZR 97 | 5.41E-01 | 5.41E-01 | 5.41E-01 | 5.41E-01 | 5.41E-01 | 5.41E-01 | 5.41E-01 | 6.30E-01 |
| NB 95 | 2.52E+01 | 2.52E+01 | 2.52E+01 | 2.52E+01 | 2.52E+01 | 2.52E+01 | 2.52E+01 | 2.96E+01 |
| MO 99 | 7.33E-01 | 7.33E-01 | 7.33E-01 | 7.33E-01 | 7.33E-01 | 7.33E-01 | 7.33E-01 | 8.48E-01 |
| TC 99M | 3.34E-02 | 3.34E-02 | 3.34E-02 | 3.34E-02 | 3.34E-02 | 3.34E-02 | 3.34E-02 | 3.83E-02 |
| TC101 | 2.79E-03 | 2.79E-03 | 2.79E-03 | 2.79E-03 | 2.79E-03 | 2.79E-03 | 2.79E-03 | 3.10E-03 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD

PATHWAY = RIVER SHORELINE DEPOSITS

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.99E+01 | 1.99E+01 | 1.99E+01 | 1.99E+01 | 1.99E+01 | 1.99E+01 | 1.99E+01 | 2.32E+01 |
| RU105 | 1.15E-01 | 1.15E-01 | 1.15E-01 | 1.15E-01 | 1.15E-01 | 1.15E-01 | 1.15E-01 | 1.30E-01 |
| RU106 | 7.75E+01 | 7.75E+01 | 7.75E+01 | 7.75E+01 | 7.75E+01 | 7.75E+01 | 7.75E+01 | 9.31E+01 |
| AG110M | 6.34E+02 | 6.34E+02 | 6.34E+02 | 6.34E+02 | 6.34E+02 | 6.34E+02 | 6.34E+02 | 7.39E+02 |
| TE125M | 2.86E-01 | 2.86E-01 | 2.86E-01 | 2.86E-01 | 2.86E-01 | 2.86E-01 | 2.86E-01 | 3.92E-01 |
| TE127M | 1.68E-02 | 1.68E-02 | 1.68E-02 | 1.68E-02 | 1.68E-02 | 1.68E-02 | 1.68E-02 | 1.99E-02 |
| TE127 | 5.43E-04 | 5.43E-04 | 5.43E-04 | 5.43E-04 | 5.43E-04 | 5.43E-04 | 5.43E-04 | 5.97E-04 |
| TE129M | 3.63E+00 | 3.63E+00 | 3.63E+00 | 3.63E+00 | 3.63E+00 | 3.63E+00 | 3.63E+00 | 4.24E+00 |
| TE129 | 4.54E-03 | 4.54E-03 | 4.54E-03 | 4.54E-03 | 4.54E-03 | 4.54E-03 | 4.54E-03 | 5.37E-03 |
| TE131M | 1.47E+00 | 1.47E+00 | 1.47E+00 | 1.47E+00 | 1.47E+00 | 1.47E+00 | 1.47E+00 | 1.73E+00 |
| TE131 | 4.56E-03 | 4.56E-03 | 4.56E-03 | 4.56E-03 | 4.56E-03 | 4.56E-03 | 4.56E-03 | 5.38E+00 |
| TE132 | 7.78E-01 | 7.78E-01 | 7.78E-01 | 7.78E-01 | 7.78E-01 | 7.78E-01 | 7.78E-01 | 9.15E-01 |
| I 130 | 1.01E+00 | 1.01E+00 | 1.01E+00 | 1.01E+00 | 1.01E+00 | 1.01E+00 | 1.01E+00 | 1.22E+00 |
| I 131 | 3.16E+00 | 3.16E+00 | 3.16E+00 | 3.16E+00 | 3.16E+00 | 3.16E+00 | 3.16E+00 | 3.84E+00 |
| I 132 | 2.22E-01 | 2.22E-01 | 2.22E-01 | 2.22E-01 | 2.22E-01 | 2.22E-01 | 2.22E-01 | 2.61E-01 |
| I 133 | 4.49E-01 | 4.49E-01 | 4.49E-01 | 4.49E-01 | 4.49E-01 | 4.49E-01 | 4.49E-01 | 5.46E-01 |
| I 134 | 7.57E-02 | 7.57E-02 | 7.57E-02 | 7.57E-02 | 7.57E-02 | 7.57E-02 | 7.57E-02 | 8.99E-02 |
| I 135 | 4.58E-01 | 4.58E-01 | 4.58E-01 | 4.58E-01 | 4.58E-01 | 4.58E-01 | 4.58E-01 | 5.35E-01 |
| CS134 | 1.26E+03 | 1.26E+03 | 1.26E+03 | 1.26E+03 | 1.26E+03 | 1.26E+03 | 1.26E+03 | 1.46E+03 |
| CS136 | 2.76E+01 | 2.76E+01 | 2.76E+01 | 2.76E+01 | 2.76E+01 | 2.76E+01 | 2.76E+01 | 3.13E+01 |
| CS137 | 1.89E+03 | 1.89E+03 | 1.89E+03 | 1.89E+03 | 1.89E+03 | 1.89E+03 | 1.89E+03 | 2.21E+03 |
| CS138 | 5.81E-02 | 5.81E-02 | 5.81E-02 | 5.81E-02 | 5.81E-02 | 5.81E-02 | 5.81E-02 | 6.64E-02 |
| BA139 | 1.84E-02 | 1.84E-02 | 1.84E-02 | 1.84E-02 | 1.84E-02 | 1.84E-02 | 1.84E-02 | 2.07E-02 |
| BA140 | 3.77E+00 | 3.77E+00 | 3.77E+00 | 3.77E+00 | 3.77E+00 | 3.77E+00 | 3.77E+00 | 4.31E+00 |
| BA141 | 6.11E-03 | 6.11E-03 | 6.11E-03 | 6.11E-03 | 6.11E-03 | 6.11E-03 | 6.11E-03 | 6.96E-03 |
| BA142 | 5.59E-03 | 5.59E-03 | 5.59E-03 | 5.59E-03 | 5.59E-03 | 5.59E-03 | 5.59E-03 | 6.37E-03 |
| LA140 | 3.53E+00 | 3.53E+00 | 3.53E+00 | 3.53E+00 | 3.53E+00 | 3.53E+00 | 3.53E+00 | 4.00E+00 |
| LA142 | 1.29E-01 | 1.29E-01 | 1.29E-01 | 1.29E-01 | 1.29E-01 | 1.29E-01 | 1.29E-01 | 1.55E-01 |
| CE141 | 2.51E+00 | 2.51E+00 | 2.51E+00 | 2.51E+00 | 2.51E+00 | 2.51E+00 | 2.51E+00 | 2.83E+00 |
| CE143 | 4.26E-01 | 4.26E-01 | 4.26E-01 | 4.26E-01 | 4.26E-01 | 4.26E-01 | 4.26E-01 | 4.84E-01 |
| CE144 | 1.28E+01 | 1.28E+01 | 1.28E+01 | 1.28E+01 | 1.28E+01 | 1.28E+01 | 1.28E+01 | 1.48E+01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 2.65E-04 | 2.65E-04 | 2.65E-04 | 2.65E-04 | 2.65E-04 | 2.65E-04 | 2.65E-04 | 3.04E-04 |
| ND147 | 1.56E+00 | 1.56E+00 | 1.56E+00 | 1.56E+00 | 1.56E+00 | 1.56E+00 | 1.56E+00 | 1.87E+00 |
| W 187 | 4.33E-01 | 4.33E-01 | 4.33E-01 | 4.33E-01 | 4.33E-01 | 4.33E-01 | 4.33E-01 | 5.02E-01 |
| NP239 | 3.15E-01 | 3.15E-01 | 3.15E-01 | 3.15E-01 | 3.15E-01 | 3.15E-01 | 3.15E-01 | 3.64E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD
PATHWAY = SWIMMING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 1.09E+02 | 1.09E+02 | 1.09E+02 | 1.09E+02 | 1.09E+02 | 1.09E+02 | 1.09E+02 | 0.00E-01 |
| P 32 | 8.99E-02 | 8.99E-02 | 8.99E-02 | 8.99E-02 | 8.99E-02 | 8.99E-02 | 8.99E-02 | 0.00E-01 |
| CR 51 | 7.30E-01 | 7.30E-01 | 7.30E-01 | 7.30E-01 | 7.30E-01 | 7.30E-01 | 7.30E-01 | 0.00E-01 |
| MN 54 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 0.00E-01 |
| MN 56 | 4.38E+01 | 4.38E+01 | 4.38E+01 | 4.38E+01 | 4.38E+01 | 4.38E+01 | 4.38E+01 | 0.00E-01 |
| FE 55 | 8.99E-04 | 8.99E-04 | 8.99E-04 | 8.99E-04 | 8.99E-04 | 8.99E-04 | 8.99E-04 | 0.00E-01 |
| FE 59 | 3.09E+01 | 3.09E+01 | 3.09E+01 | 3.09E+01 | 3.09E+01 | 3.09E+01 | 3.09E+01 | 0.00E-01 |
| CO 58 | 2.53E+01 | 2.53E+01 | 2.53E+01 | 2.53E+01 | 2.53E+01 | 2.53E+01 | 2.53E+01 | 0.00E-01 |
| CO 60 | 6.46E+01 | 6.46E+01 | 6.46E+01 | 6.46E+01 | 6.46E+01 | 6.46E+01 | 6.46E+01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.37E+01 | 1.37E+01 | 1.37E+01 | 1.37E+01 | 1.37E+01 | 1.37E+01 | 1.37E+01 | 0.00E-01 |
| CU 64 | 5.17E+00 | 5.17E+00 | 5.17E+00 | 5.17E+00 | 5.17E+00 | 5.17E+00 | 5.17E+00 | 0.00E-01 |
| ZN 65 | 1.55E+01 | 1.55E+01 | 1.55E+01 | 1.55E+01 | 1.55E+01 | 1.55E+01 | 1.55E+01 | 0.00E-01 |
| ZN 69 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 0.00E-01 |
| BR 83 | 2.32E-01 | 2.32E-01 | 2.32E-01 | 2.32E-01 | 2.32E-01 | 2.32E-01 | 2.32E-01 | 0.00E-01 |
| BR 84 | 4.32E+01 | 4.32E+01 | 4.32E+01 | 4.32E+01 | 4.32E+01 | 4.32E+01 | 4.32E+01 | 0.00E-01 |
| BR 85 | 4.61E-02 | 4.61E-02 | 4.61E-02 | 4.61E-02 | 4.61E-02 | 4.61E-02 | 4.61E-02 | 0.00E-01 |
| RB 86 | 2.39E+00 | 2.39E+00 | 2.39E+00 | 2.39E+00 | 2.39E+00 | 2.39E+00 | 2.39E+00 | 0.00E-01 |
| RB 88 | 1.34E+01 | 1.34E+01 | 1.34E+01 | 1.34E+01 | 1.34E+01 | 1.34E+01 | 1.34E+01 | 0.00E-01 |
| RB 89 | 4.81E+01 | 4.81E+01 | 4.81E+01 | 4.81E+01 | 4.81E+01 | 4.81E+01 | 4.81E+01 | 0.00E-01 |
| SR 89 | 6.46E-02 | 6.46E-02 | 6.46E-02 | 6.46E-02 | 6.46E-02 | 6.46E-02 | 6.46E-02 | 0.00E-01 |
| SR 90 | 7.59E-03 | 7.59E-03 | 7.59E-03 | 7.59E-03 | 7.59E-03 | 7.59E-03 | 7.59E-03 | 0.00E-01 |
| SR 91 | 2.65E+01 | 2.65E+01 | 2.65E+01 | 2.65E+01 | 2.65E+01 | 2.65E+01 | 2.65E+01 | 0.00E-01 |
| SR 92 | 3.56E+01 | 3.56E+01 | 3.56E+01 | 3.56E+01 | 3.56E+01 | 3.56E+01 | 3.56E+01 | 0.00E-01 |
| Y 90 | 1.83E-01 | 1.83E-01 | 1.83E-01 | 1.83E-01 | 1.83E-01 | 1.83E-01 | 1.83E-01 | 0.00E-01 |
| Y 91M | 1.29E+01 | 1.29E+01 | 1.29E+01 | 1.29E+01 | 1.29E+01 | 1.29E+01 | 1.29E+01 | 0.00E-01 |
| Y 91 | 9.41E-02 | 9.41E-02 | 9.41E-02 | 9.41E-02 | 9.41E-02 | 9.41E-02 | 9.41E-02 | 0.00E-01 |
| Y 92 | 6.34E+00 | 6.34E+00 | 6.34E+00 | 6.34E+00 | 6.34E+00 | 6.34E+00 | 6.34E+00 | 0.00E-01 |
| Y 93 | 2.65E+00 | 2.65E+00 | 2.65E+00 | 2.65E+00 | 2.65E+00 | 2.65E+00 | 2.65E+00 | 0.00E-01 |
| ZR 95 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 2.11E+01 | 0.00E-01 |
| ZR 97 | 2.10E+01 | 2.10E+01 | 2.10E+01 | 2.10E+01 | 2.10E+01 | 2.10E+01 | 2.10E+01 | 0.00E-01 |
| NB 95 | 1.97E+01 | 1.97E+01 | 1.97E+01 | 1.97E+01 | 1.97E+01 | 1.97E+01 | 1.97E+01 | 0.00E-01 |
| MO 99 | 6.60E+00 | 6.60E+00 | 6.60E+00 | 6.60E+00 | 6.60E+00 | 6.60E+00 | 6.60E+00 | 0.00E-01 |
| TC 99M | 3.33E+00 | 3.33E+00 | 3.33E+00 | 3.33E+00 | 3.33E+00 | 3.33E+00 | 3.33E+00 | 0.00E-01 |
| TC101 | 7.13E+00 | 7.13E+00 | 7.13E+00 | 7.13E+00 | 7.13E+00 | 7.13E+00 | 7.13E+00 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD
PATHWAY = SWIMMING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 0.00E-01 |
| RU105 | 1.66E+01 | 1.66E+01 | 1.66E+01 | 1.66E+01 | 1.66E+01 | 1.66E+01 | 1.66E+01 | 0.00E-01 |
| RU106 | 5.34E+00 | 5.34E+00 | 5.34E+00 | 5.34E+00 | 5.34E+00 | 5.34E+00 | 5.34E+00 | 0.00E-01 |
| AG110M | 6.88E+01 | 6.88E+01 | 6.88E+01 | 6.88E+01 | 6.88E+01 | 6.88E+01 | 6.88E+01 | 0.00E-01 |
| TE125M | 5.18E-02 | 5.18E-02 | 5.18E-02 | 5.18E-02 | 5.18E-02 | 5.18E-02 | 5.18E-02 | 0.00E-01 |
| TE127M | 3.65E-03 | 3.65E-03 | 3.65E-03 | 3.65E-03 | 3.65E-03 | 3.65E-03 | 3.65E-03 | 0.00E-01 |
| TE127 | 3.91E-02 | 3.91E-02 | 3.91E-02 | 3.91E-02 | 3.91E-02 | 3.91E-02 | 3.91E-02 | 0.00E-01 |
| TE129M | 2.95E+00 | 2.95E+00 | 2.95E+00 | 2.95E+00 | 2.95E+00 | 2.95E+00 | 2.95E+00 | 0.00E-01 |
| TE129 | 2.52E+00 | 2.52E+00 | 2.52E+00 | 2.52E+00 | 2.52E+00 | 2.52E+00 | 2.52E+00 | 0.00E-01 |
| TE131M | 3.08E+01 | 3.08E+01 | 3.08E+01 | 3.08E+01 | 3.08E+01 | 3.08E+01 | 3.08E+01 | 0.00E-01 |
| TE131 | 8.81E+00 | 8.81E+00 | 8.81E+00 | 8.81E+00 | 8.81E+00 | 8.81E+00 | 8.81E+00 | 0.00E-01 |
| TE132 | 5.61E+00 | 5.61E+00 | 5.61E+00 | 5.61E+00 | 5.61E+00 | 5.61E+00 | 5.61E+00 | 0.00E-01 |
| I 130 | 5.45E+01 | 5.45E+01 | 5.45E+01 | 5.45E+01 | 5.45E+01 | 5.45E+01 | 5.45E+01 | 0.00E-01 |
| I 131 | 1.10E+01 | 1.10E+01 | 1.10E+01 | 1.10E+01 | 1.10E+01 | 1.10E+01 | 1.10E+01 | 0.00E-01 |
| I 132 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 0.00E-01 |
| I 133 | 1.34E+01 | 1.34E+01 | 1.34E+01 | 1.34E+01 | 1.34E+01 | 1.34E+01 | 1.34E+01 | 0.00E-01 |
| I 134 | 5.45E+01 | 5.45E+01 | 5.45E+01 | 5.45E+01 | 5.45E+01 | 5.45E+01 | 5.45E+01 | 0.00E-01 |
| I 135 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 0.00E-01 |
| CS134 | 4.07E+01 | 4.07E+01 | 4.07E+01 | 4.07E+01 | 4.07E+01 | 4.07E+01 | 4.07E+01 | 0.00E-01 |
| CS136 | 5.76E+01 | 5.76E+01 | 5.76E+01 | 5.76E+01 | 5.76E+01 | 5.76E+01 | 5.76E+01 | 0.00E-01 |
| CS137 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 1.41E+01 | 0.00E-01 |
| CS138 | 4.94E+01 | 4.94E+01 | 4.94E+01 | 4.94E+01 | 4.94E+01 | 4.94E+01 | 4.94E+01 | 0.00E-01 |
| BA139 | 1.03E+00 | 1.03E+00 | 1.03E+00 | 1.03E+00 | 1.03E+00 | 1.03E+00 | 1.03E+00 | 0.00E-01 |
| BA140 | 6.88E+00 | 6.88E+00 | 6.88E+00 | 6.88E+00 | 6.88E+00 | 6.88E+00 | 6.88E+00 | 0.00E-01 |
| BA141 | 1.23E+01 | 1.23E+01 | 1.23E+01 | 1.23E+01 | 1.23E+01 | 1.23E+01 | 1.23E+01 | 0.00E-01 |
| BA142 | 2.10E+01 | 2.10E+01 | 2.10E+01 | 2.10E+01 | 2.10E+01 | 2.10E+01 | 2.10E+01 | 0.00E-01 |
| LA140 | 5.75E+01 | 5.75E+01 | 5.75E+01 | 5.75E+01 | 5.75E+01 | 5.75E+01 | 5.75E+01 | 0.00E-01 |
| LA142 | 6.04E+01 | 6.04E+01 | 6.04E+01 | 6.04E+01 | 6.04E+01 | 6.04E+01 | 6.04E+01 | 0.00E-01 |
| CE141 | 1.83E+00 | 1.83E+00 | 1.83E+00 | 1.83E+00 | 1.83E+00 | 1.83E+00 | 1.83E+00 | 0.00E-01 |
| CE143 | 7.99E+00 | 7.99E+00 | 7.99E+00 | 7.99E+00 | 7.99E+00 | 7.99E+00 | 7.99E+00 | 0.00E-01 |
| CE144 | 1.21E+00 | 1.21E+00 | 1.21E+00 | 1.21E+00 | 1.21E+00 | 1.21E+00 | 1.21E+00 | 0.00E-01 |
| PR143 | 2.25E-02 | 2.25E-02 | 2.25E-02 | 2.25E-02 | 2.25E-02 | 2.25E-02 | 2.25E-02 | 0.00E-01 |
| PR144 | 6.18E-01 | 6.18E-01 | 6.18E-01 | 6.18E-01 | 6.18E-01 | 6.18E-01 | 6.18E-01 | 0.00E-01 |
| ND147 | 3.93E+00 | 3.93E+00 | 3.93E+00 | 3.93E+00 | 3.93E+00 | 3.93E+00 | 3.93E+00 | 0.00E-01 |
| W 187 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 0.00E-01 |
| NP239 | 3.37E+00 | 3.37E+00 | 3.37E+00 | 3.37E+00 | 3.37E+00 | 3.37E+00 | 3.37E+00 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD
PATHWAY = BOATING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 1.01E+02 | 1.01E+02 | 1.01E+02 | 1.01E+02 | 1.01E+02 | 1.01E+02 | 1.01E+02 | 0.00E-01 |
| P 32 | 8.35E-02 | 8.35E-02 | 8.35E-02 | 8.35E-02 | 8.35E-02 | 8.35E-02 | 8.35E-02 | 0.00E-01 |
| CR 51 | 6.78E-01 | 6.78E-01 | 6.78E-01 | 6.78E-01 | 6.78E-01 | 6.78E-01 | 6.78E-01 | 0.00E-01 |
| MN 54 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 0.00E-01 |
| MN 56 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 4.06E+01 | 0.00E-01 |
| FE 55 | 8.35E-04 | 8.35E-04 | 8.35E-04 | 8.35E-04 | 8.35E-04 | 8.35E-04 | 8.35E-04 | 0.00E-01 |
| FE 59 | 2.87E+01 | 2.87E+01 | 2.87E+01 | 2.87E+01 | 2.87E+01 | 2.87E+01 | 2.87E+01 | 0.00E-01 |
| CO 58 | 2.35E+01 | 2.35E+01 | 2.35E+01 | 2.35E+01 | 2.35E+01 | 2.35E+01 | 2.35E+01 | 0.00E-01 |
| CO 60 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 6.00E+01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 1.27E+01 | 1.27E+01 | 1.27E+01 | 1.27E+01 | 1.27E+01 | 1.27E+01 | 1.27E+01 | 0.00E-01 |
| CU 64 | 4.80E+00 | 4.80E+00 | 4.80E+00 | 4.80E+00 | 4.80E+00 | 4.80E+00 | 4.80E+00 | 0.00E-01 |
| ZN 65 | 1.44E+01 | 1.44E+01 | 1.44E+01 | 1.44E+01 | 1.44E+01 | 1.44E+01 | 1.44E+01 | 0.00E-01 |
| ZN 69 | 1.94E-02 | 1.94E-02 | 1.94E-02 | 1.94E-02 | 1.94E-02 | 1.94E-02 | 1.94E-02 | 0.00E-01 |
| BR 83 | 2.15E-01 | 2.15E-01 | 2.15E-01 | 2.15E-01 | 2.15E-01 | 2.15E-01 | 2.15E-01 | 0.00E-01 |
| BR 84 | 4.01E+01 | 4.01E+01 | 4.01E+01 | 4.01E+01 | 4.01E+01 | 4.01E+01 | 4.01E+01 | 0.00E-01 |
| BR 85 | 4.28E-02 | 4.28E-02 | 4.28E-02 | 4.28E-02 | 4.28E-02 | 4.28E-02 | 4.28E-02 | 0.00E-01 |
| RB 86 | 2.22E+00 | 2.22E+00 | 2.22E+00 | 2.22E+00 | 2.22E+00 | 2.22E+00 | 2.22E+00 | 0.00E-01 |
| RB 88 | 1.24E+01 | 1.24E+01 | 1.24E+01 | 1.24E+01 | 1.24E+01 | 1.24E+01 | 1.24E+01 | 0.00E-01 |
| RB 89 | 4.47E+01 | 4.47E+01 | 4.47E+01 | 4.47E+01 | 4.47E+01 | 4.47E+01 | 4.47E+01 | 0.00E-01 |
| SR 89 | 6.00E-02 | 6.00E-02 | 6.00E-02 | 6.00E-02 | 6.00E-02 | 6.00E-02 | 6.00E-02 | 0.00E-01 |
| SR 90 | 7.04E-03 | 7.04E-03 | 7.04E-03 | 7.04E-03 | 7.04E-03 | 7.04E-03 | 7.04E-03 | 0.00E-01 |
| SR 91 | 2.46E+01 | 2.46E+01 | 2.46E+01 | 2.46E+01 | 2.46E+01 | 2.46E+01 | 2.46E+01 | 0.00E-01 |
| SR 92 | 3.31E+01 | 3.31E+01 | 3.31E+01 | 3.31E+01 | 3.31E+01 | 3.31E+01 | 3.31E+01 | 0.00E-01 |
| Y 90 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 1.69E-01 | 0.00E-01 |
| Y 91M | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 1.20E+01 | 0.00E-01 |
| Y 91 | 8.74E-02 | 8.74E-02 | 8.74E-02 | 8.74E-02 | 8.74E-02 | 8.74E-02 | 8.74E-02 | 0.00E-01 |
| Y 92 | 5.89E+00 | 5.89E+00 | 5.89E+00 | 5.89E+00 | 5.89E+00 | 5.89E+00 | 5.89E+00 | 0.00E-01 |
| Y 93 | 2.46E+00 | 2.46E+00 | 2.46E+00 | 2.46E+00 | 2.46E+00 | 2.46E+00 | 2.46E+00 | 0.00E-01 |
| ZR 95 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 1.96E+01 | 0.00E-01 |
| ZR 97 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 0.00E-01 |
| NB 95 | 1.83E+01 | 1.83E+01 | 1.83E+01 | 1.83E+01 | 1.83E+01 | 1.83E+01 | 1.83E+01 | 0.00E-01 |
| MO 99 | 6.12E+00 | 6.12E+00 | 6.12E+00 | 6.12E+00 | 6.12E+00 | 6.12E+00 | 6.12E+00 | 0.00E-01 |
| TC 99M | 3.10E+00 | 3.10E+00 | 3.10E+00 | 3.10E+00 | 3.10E+00 | 3.10E+00 | 3.10E+00 | 0.00E-01 |
| TC101 | 6.62E+00 | 6.62E+00 | 6.62E+00 | 6.62E+00 | 6.62E+00 | 6.62E+00 | 6.62E+00 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = CHILD
PATHWAY = BOATING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 1.16E+01 | 0.00E-01 |
| RU105 | 1.54E+01 | 1.54E+01 | 1.54E+01 | 1.54E+01 | 1.54E+01 | 1.54E+01 | 1.54E+01 | 0.00E-01 |
| RU106 | 4.96E+00 | 4.96E+00 | 4.96E+00 | 4.96E+00 | 4.96E+00 | 4.96E+00 | 4.96E+00 | 0.00E-01 |
| AG110M | 6.39E+01 | 6.39E+01 | 6.39E+01 | 6.39E+01 | 6.39E+01 | 6.39E+01 | 6.39E+01 | 0.00E-01 |
| TE125M | 4.81E-02 | 4.81E-02 | 4.81E-02 | 4.81E-02 | 4.81E-02 | 4.81E-02 | 4.81E-02 | 0.00E-01 |
| TE127M | 3.39E-03 | 3.39E-03 | 3.39E-03 | 3.39E-03 | 3.39E-03 | 3.39E-03 | 3.39E-03 | 0.00E-01 |
| TE127 | 3.63E-02 | 3.63E-02 | 3.63E-02 | 3.63E-02 | 3.63E-02 | 3.63E-02 | 3.63E-02 | 0.00E-01 |
| TE129M | 2.74E+00 | 2.74E+00 | 2.74E+00 | 2.74E+00 | 2.74E+00 | 2.74E+00 | 2.74E+00 | 0.00E-01 |
| TE129 | 2.34E+00 | 2.34E+00 | 2.34E+00 | 2.34E+00 | 2.34E+00 | 2.34E+00 | 2.34E+00 | 0.00E-01 |
| TE131M | 2.86E+01 | 2.86E+01 | 2.86E+01 | 2.86E+01 | 2.86E+01 | 2.86E+01 | 2.86E+01 | 0.00E-01 |
| TE131 | 8.18E+00 | 8.18E+00 | 8.18E+00 | 8.18E+00 | 8.18E+00 | 8.18E+00 | 8.18E+00 | 0.00E-01 |
| TE132 | 5.21E+00 | 5.21E+00 | 5.21E+00 | 5.21E+00 | 5.21E+00 | 5.21E+00 | 5.21E+00 | 0.00E-01 |
| I 130 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 0.00E-01 |
| I 131 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 1.02E+01 | 0.00E-01 |
| I 132 | 5.57E+01 | 5.57E+01 | 5.57E+01 | 5.57E+01 | 5.57E+01 | 5.57E+01 | 5.57E+01 | 0.00E-01 |
| I 133 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 1.25E+01 | 0.00E-01 |
| I 134 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 5.06E+01 | 0.00E-01 |
| I 135 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 4.26E+01 | 0.00E-01 |
| CS134 | 3.78E+01 | 3.78E+01 | 3.78E+01 | 3.78E+01 | 3.78E+01 | 3.78E+01 | 3.78E+01 | 0.00E-01 |
| CS136 | 5.35E+01 | 5.35E+01 | 5.35E+01 | 5.35E+01 | 5.35E+01 | 5.35E+01 | 5.35E+01 | 0.00E-01 |
| CS137 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 1.31E+01 | 0.00E-01 |
| CS138 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 4.59E+01 | 0.00E-01 |
| BA139 | 9.55E-01 | 9.55E-01 | 9.55E-01 | 9.55E-01 | 9.55E-01 | 9.55E-01 | 9.55E-01 | 0.00E-01 |
| BA140 | 6.39E+00 | 6.39E+00 | 6.39E+00 | 6.39E+00 | 6.39E+00 | 6.39E+00 | 6.39E+00 | 0.00E-01 |
| BA141 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 1.14E+01 | 0.00E-01 |
| BA142 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 1.95E+01 | 0.00E-01 |
| LA140 | 5.34E+01 | 5.34E+01 | 5.34E+01 | 5.34E+01 | 5.34E+01 | 5.34E+01 | 5.34E+01 | 0.00E-01 |
| LA142 | 5.61E+01 | 5.61E+01 | 5.61E+01 | 5.61E+01 | 5.61E+01 | 5.61E+01 | 5.61E+01 | 0.00E-01 |
| CE141 | 1.70E+00 | 1.70E+00 | 1.70E+00 | 1.70E+00 | 1.70E+00 | 1.70E+00 | 1.70E+00 | 0.00E-01 |
| CE143 | 7.42E+00 | 7.42E+00 | 7.42E+00 | 7.42E+00 | 7.42E+00 | 7.42E+00 | 7.42E+00 | 0.00E-01 |
| CE144 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 1.12E+00 | 0.00E-01 |
| PR143 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 2.09E-02 | 0.00E-01 |
| PR144 | 5.74E-01 | 5.74E-01 | 5.74E-01 | 5.74E-01 | 5.74E-01 | 5.74E-01 | 5.74E-01 | 0.00E-01 |
| ND147 | 3.65E+00 | 3.65E+00 | 3.65E+00 | 3.65E+00 | 3.65E+00 | 3.65E+00 | 3.65E+00 | 0.00E-01 |
| W 187 | 1.08E+01 | 1.08E+01 | 1.08E+01 | 1.08E+01 | 1.08E+01 | 1.08E+01 | 1.08E+01 | 0.00E-01 |
| NP239 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 3.13E+00 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = POTABLE WATER

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 2.91E+01 | 2.91E+01 | 0.00E-01 | 2.91E+01 | 2.91E+01 | 2.91E+01 | 2.91E+01 | 0.00E-01 |
| C 14 | 8.38E+02 | 8.38E+02 | 3.92E+03 | 8.38E+02 | 8.38E+02 | 8.38E+02 | 8.38E+02 | 0.00E-01 |
| NA 24 | 5.53E+02 | 5.53E+02 | 5.53E+02 | 5.53E+02 | 5.53E+02 | 5.53E+02 | 5.53E+02 | 0.00E-01 |
| P 32 | 1.04E+04 | 3.63E+03 | 2.68E+05 | 1.58E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 2.28E+00 | 6.64E+01 | 0.00E-01 | 0.00E-01 | 3.25E-01 | 1.49E+00 | 2.89E+00 | 0.00E-01 |
| MN 54 | 7.45E+02 | 1.21E+03 | 0.00E-01 | 3.29E+03 | 7.29E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 3.58E-02 | 1.89E+01 | 0.00E-01 | 2.08E-01 | 1.79E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 3.97E+02 | 1.89E+02 | 2.30E+03 | 1.49E+03 | 0.00E-01 | 0.00E-01 | 7.26E+02 | 0.00E-01 |
| FE 59 | 3.46E+03 | 4.19E+03 | 5.02E+03 | 8.77E+03 | 0.00E-01 | 0.00E-01 | 2.59E+03 | 0.00E-01 |
| CO 58 | 1.47E+03 | 1.47E+03 | 0.00E-01 | 5.90E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 4.22E+03 | 4.25E+03 | 0.00E-01 | 1.79E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 3.64E+03 | 3.23E+02 | 1.05E+05 | 6.49E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 5.45E-02 | 9.11E+00 | 1.06E+00 | 1.20E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 1.26E+01 | 5.57E+02 | 0.00E-01 | 2.71E+01 | 4.59E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 4.80E+03 | 8.80E+03 | 3.04E+03 | 1.04E+04 | 5.05E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 5.00E-08 | 5.48E-05 | 3.73E-07 | 6.72E-07 | 2.79E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 5.73E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 1.34E+04 | 6.94E+02 | 0.00E-01 | 2.71E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 1.18E+04 | 8.43E+03 | 4.10E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 9.50E+04 | 3.82E+04 | 4.69E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 5.19E+01 | 1.70E+03 | 1.43E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 2.56E-01 | 7.43E+01 | 6.89E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 2.98E-01 | 1.53E+04 | 1.11E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 4.93E+00 | 1.33E+04 | 1.85E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 3.29E-04 | 2.24E+02 | 1.17E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 2.11E-02 | 6.10E+03 | 7.73E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 5.83E+00 | 4.09E+03 | 3.37E+01 | 8.22E+00 | 8.86E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 7.17E-02 | 1.00E+04 | 9.15E-01 | 1.57E-01 | 1.58E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 1.62E+00 | 2.37E+03 | 6.82E+00 | 2.81E+00 | 2.01E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 8.53E+02 | 1.44E+03 | 0.00E-01 | 4.37E+03 | 6.54E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 5.32E-01 | 1.20E+01 | 2.00E-02 | 4.13E-02 | 4.44E-01 | 0.00E-01 | 2.16E-02 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT
PATHWAY = POTABLE WATER

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 8.05E+01 | 2.93E+03 | 2.41E+02 | 0.00E-01 | 5.01E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 1.78E-01 | 2.11E+02 | 5.30E-01 | 0.00E-01 | 3.89E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 4.97E+02 | 3.02E+04 | 3.98E+03 | 0.00E-01 | 4.71E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 7.94E+01 | 6.23E+03 | 1.64E+02 | 1.20E+02 | 1.72E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 5.15E+02 | 1.82E+03 | 3.81E+03 | 1.27E+03 | 0.00E-01 | 1.28E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.16E+03 | 3.88E+03 | 9.63E+03 | 3.19E+03 | 2.37E+04 | 2.78E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 6.01E+00 | 5.86E+02 | 2.79E+01 | 9.36E+00 | 6.82E+01 | 2.27E+01 | 0.00E-01 | 0.00E-01 |
| TE129M | 2.50E+03 | 9.68E+03 | 1.62E+04 | 5.56E+03 | 4.05E+04 | 6.23E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 6.48E-06 | 2.22E-03 | 2.78E-05 | 9.57E-06 | 6.91E-05 | 2.33E-05 | 0.00E-01 | 0.00E-01 |
| TE131M | 4.80E+02 | 9.79E+03 | 1.44E+03 | 5.82E+02 | 4.00E+03 | 1.18E+03 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 1.29E+03 | 5.10E+03 | 2.78E+03 | 1.38E+03 | 8.62E+03 | 2.03E+03 | 0.00E-01 | 0.00E-01 |
| I 130 | 2.28E+02 | 1.22E+02 | 2.58E+02 | 5.68E+02 | 6.24E+02 | 6.37E+04 | 0.00E-01 | 0.00E-01 |
| I 131 | 2.83E+03 | 2.29E+02 | 5.45E+03 | 6.43E+03 | 7.50E+03 | 2.11E+06 | 0.00E-01 | 0.00E-01 |
| I 132 | 1.44E-01 | 3.27E-01 | 1.99E-01 | 4.04E-01 | 4.50E-01 | 1.89E+01 | 0.00E-01 | 0.00E-01 |
| I 133 | 3.97E+02 | 2.29E+02 | 9.31E+02 | 1.35E+03 | 1.59E+03 | 2.46E+05 | 0.00E-01 | 0.00E-01 |
| I 134 | 5.83E-07 | 1.69E-06 | 8.00E-07 | 1.64E-06 | 1.83E-06 | 3.82E-05 | 0.00E-01 | 0.00E-01 |
| I 135 | 3.51E+01 | 3.48E+01 | 4.84E+01 | 9.62E+01 | 1.07E+02 | 8.62E+03 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.17E+04 | 3.16E+02 | 6.24E+04 | 1.16E+05 | 2.99E+04 | 0.00E-01 | 1.23E+04 | 0.00E-01 |
| CS136 | 7.92E+03 | 3.22E+02 | 7.21E+03 | 2.12E+04 | 8.45E+03 | 0.00E-01 | 1.73E+03 | 0.00E-01 |
| CS137 | 7.17E+03 | 3.16E+02 | 8.64E+04 | 1.01E+05 | 2.72E+04 | 0.00E-01 | 1.10E+04 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 2.36E-05 | 5.16E-02 | 8.14E-04 | 5.40E-07 | 3.24E-07 | 0.00E-01 | 3.27E-07 | 0.00E-01 |
| BA140 | 1.38E+03 | 6.59E+03 | 2.68E+04 | 2.68E+01 | 6.37E+00 | 0.00E-01 | 1.65E+01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 2.35E-01 | 1.07E+04 | 2.31E+00 | 9.12E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 3.27E-07 | 2.32E-01 | 3.72E-06 | 1.37E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 9.16E-01 | 4.02E+03 | 1.28E+01 | 7.78E+00 | 2.40E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 1.12E-01 | 5.74E+03 | 1.48E+00 | 9.84E+02 | 2.87E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 2.76E+01 | 2.82E+04 | 4.92E+02 | 2.01E+02 | 8.14E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 6.34E-01 | 6.75E+03 | 1.28E+01 | 4.78E+00 | 1.78E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 5.41E-01 | 5.60E+03 | 8.60E+00 | 8.84E+00 | 3.41E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 1.79E+01 | 3.05E+03 | 7.46E+01 | 5.19E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 6.93E-02 | 3.54E+03 | 1.37E+00 | 1.23E-01 | 2.44E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = FRESH WATER FISH

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| P 32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT
 PATHWAY = FRESH WATER FISH

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 130 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = FRESH WATER INVERTEBRATES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| P 32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = FRESH WATER INVERTEBRATES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 130 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = IRRIGATED FRESH LEAFY VEGETABLES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| P 32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = IRRIGATED FRESH LEAFY VEGETABLES

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 130 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = IRRIGATED STORED FRUIT, VEGETABLES, GRAIN

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| P 32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = IRRIGATED STORED FRUIT, VEGETABLES, GRAIN

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 130 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = IRRIGATED FRESH FORAGE--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.32E+01 | 1.32E+01 | 0.00E-01 | 1.32E+01 | 1.32E+01 | 1.32E+01 | 1.32E+01 | 0.00E-01 |
| C 14 | 6.12E+04 | 6.12E+04 | 2.87E+05 | 6.12E+04 | 6.12E+04 | 6.12E+04 | 6.12E+04 | 0.00E-01 |
| NA 24 | 3.60E+02 | 3.60E+02 | 3.60E+02 | 3.60E+02 | 3.60E+02 | 3.60E+02 | 3.60E+02 | 0.00E-01 |
| P 32 | 1.43E+05 | 5.00E+04 | 3.69E+06 | 2.17E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 3.48E+00 | 1.01E+02 | 0.00E-01 | 0.00E-01 | 4.96E-01 | 2.27E+00 | 4.42E+00 | 0.00E-01 |
| MN 54 | 1.69E+02 | 2.74E+02 | 0.00E-01 | 7.46E+02 | 1.65E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 9.56E-08 | 5.04E-05 | 0.00E-01 | 5.54E-07 | 4.76E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 4.39E+02 | 2.09E+02 | 2.54E+03 | 1.64E+03 | 0.00E-01 | 0.00E-01 | 8.04E+02 | 0.00E-01 |
| FE 59 | 3.20E+03 | 3.88E+03 | 4.65E+03 | 8.13E+03 | 0.00E-01 | 0.00E-01 | 2.40E+03 | 0.00E-01 |
| CO 58 | 1.22E+03 | 1.22E+03 | 0.00E-01 | 4.88E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 3.92E+03 | 3.96E+03 | 0.00E-01 | 1.66E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 2.31E+04 | 2.05E+03 | 6.66E+05 | 4.12E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 3.37E-06 | 5.64E-04 | 6.55E-05 | 7.41E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 1.96E+00 | 8.67E+01 | 0.00E-01 | 4.22E+00 | 7.14E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.73E+05 | 3.16E+05 | 1.09E+05 | 3.75E+05 | 1.82E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 7.68E-17 | 8.41E-14 | 5.73E-16 | 1.03E-15 | 4.29E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.74E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 1.42E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 1.20E-34 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.46E+05 | 1.28E+04 | 0.00E-01 | 4.99E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 1.23E-27 | 2.19E-27 | 0.00E-01 | 2.24E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 5.11E-28 | 2.53E-28 | 0.00E-01 | 7.42E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 7.54E+03 | 5.40E+03 | 2.63E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.30E+05 | 5.25E+04 | 6.43E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 2.21E-01 | 7.23E+00 | 6.11E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 3.32E-06 | 9.63E-04 | 8.93E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 4.38E-04 | 2.26E+01 | 1.63E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 1.90E-25 | 1.86E-20 | 5.59E-24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 3.97E-02 | 1.07E+02 | 1.49E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 3.15E-10 | 2.14E-04 | 1.12E-08 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 1.32E-06 | 3.83E-01 | 4.85E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 2.38E-02 | 1.67E+01 | 1.38E-01 | 3.36E-02 | 3.62E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 7.40E-06 | 1.03E+00 | 9.44E-05 | 1.62E-05 | 1.63E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 2.99E+00 | 4.37E+03 | 1.26E+01 | 5.18E+00 | 3.71E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 9.71E+02 | 1.64E+03 | 0.00E-01 | 4.98E+03 | 7.44E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 1.58E-02 | 3.56E-01 | 5.95E-04 | 1.23E-03 | 1.32E-02 | 0.00E-01 | 6.41E-04 | 0.00E-01 |
| TC101 | 4.63E-29 | 7.96E-28 | 3.72E-30 | 4.68E-30 | 5.57E-29 | 0.00E-01 | 2.55E-30 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = IRRIGATED FRESH FORAGE--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 6.08E-02 | 2.21E+00 | 1.82E-01 | 0.00E-01 | 3.78E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 5.62E-08 | 6.64E-05 | 1.67E-07 | 0.00E-01 | 1.23E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 4.54E-01 | 2.76E+01 | 3.64E+00 | 0.00E-01 | 4.30E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 3.61E+03 | 2.83E+05 | 7.47E+03 | 5.45E+03 | 7.80E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 4.25E+02 | 1.50E+03 | 3.14E+03 | 1.05E+03 | 0.00E-01 | 1.06E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.04E+03 | 3.48E+03 | 8.62E+03 | 2.86E+03 | 2.12E+04 | 2.49E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 3.07E-02 | 3.00E+00 | 1.43E-01 | 4.79E-02 | 3.49E-01 | 1.16E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 1.85E+03 | 7.16E+03 | 1.20E+04 | 4.12E+03 | 3.00E+04 | 4.61E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 8.74E-15 | 2.99E-12 | 3.74E-14 | 1.29E-14 | 9.32E-14 | 3.14E-14 | 0.00E-01 | 0.00E-01 |
| TE131M | 2.67E+01 | 5.44E+02 | 8.02E+01 | 3.23E+01 | 2.22E+02 | 6.54E+01 | 0.00E-01 | 0.00E-01 |
| TE131 | 2.04E-29 | 2.94E-27 | 7.27E-29 | 2.69E-29 | 1.86E-28 | 6.49E-29 | 0.00E-01 | 0.00E-01 |
| TE132 | 2.35E+02 | 9.32E+02 | 5.09E+02 | 2.52E+02 | 1.58E+03 | 3.72E+02 | 0.00E-01 | 0.00E-01 |
| I 130 | 1.43E+01 | 7.64E+00 | 1.62E+01 | 3.57E+01 | 3.92E+01 | 4.00E+03 | 0.00E-01 | 0.00E-01 |
| I 131 | 6.68E+03 | 5.42E+02 | 1.29E+04 | 1.52E+04 | 1.77E+04 | 4.99E+06 | 0.00E-01 | 0.00E-01 |
| I 132 | 3.77E-06 | 8.58E-06 | 5.22E-06 | 1.06E-05 | 1.18E-05 | 4.97E-04 | 0.00E-01 | 0.00E-01 |
| I 133 | 7.27E+01 | 4.20E+01 | 1.70E+02 | 2.48E+02 | 2.92E+02 | 4.51E+04 | 0.00E-01 | 0.00E-01 |
| I 134 | 2.75E-17 | 7.99E-17 | 3.77E-17 | 7.73E-17 | 8.64E-17 | 1.80E-15 | 0.00E-01 | 0.00E-01 |
| I 135 | 3.52E-01 | 3.49E-01 | 4.85E-01 | 9.65E-01 | 1.08E+00 | 8.65E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.30E+05 | 3.49E+03 | 6.90E+05 | 1.29E+06 | 3.31E+05 | 0.00E-01 | 1.36E+05 | 0.00E-01 |
| CS136 | 4.98E+04 | 2.03E+03 | 4.54E+04 | 1.33E+05 | 5.32E+04 | 0.00E-01 | 1.09E+04 | 0.00E-01 |
| CS137 | 8.06E+04 | 3.56E+03 | 9.72E+05 | 1.14E+06 | 3.05E+05 | 0.00E-01 | 1.24E+05 | 0.00E-01 |
| CS138 | 3.49E-27 | 1.15E-26 | 4.43E-27 | 7.21E-27 | 3.59E-27 | 0.00E-01 | 5.61E-28 | 0.00E-01 |
| BA139 | 1.56E-13 | 3.41E-10 | 5.38E-12 | 3.57E-15 | 2.14E-15 | 0.00E-01 | 2.16E-15 | 0.00E-01 |
| BA140 | 2.87E+02 | 1.37E+03 | 5.56E+03 | 5.56E+00 | 1.32E+00 | 0.00E-01 | 3.42E+00 | 0.00E-01 |
| BA141 | 8.70E-31 | 3.37E-28 | 2.76E-29 | 1.89E-32 | 1.14E-32 | 0.00E-01 | 1.15E-32 | 0.00E-01 |
| BA142 | 6.86E-32 | 5.75E-30 | 1.39E-30 | 1.16E-33 | 6.67E-34 | 0.00E-01 | 7.01E-34 | 0.00E-01 |
| LA140 | 9.81E-05 | 4.48E+00 | 9.68E-04 | 3.81E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 1.17E-16 | 8.27E-11 | 1.33E-15 | 4.87E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 6.63E-02 | 2.91E+02 | 9.23E-01 | 5.63E-01 | 1.74E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 7.18E-04 | 3.67E+01 | 9.49E-03 | 6.30E+00 | 1.83E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 2.49E+00 | 2.55E+03 | 4.44E+01 | 1.82E+01 | 7.35E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.69E-03 | 1.80E+01 | 3.42E-02 | 1.28E-02 | 4.75E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 9.26E-36 | 3.31E-30 | 1.84E-34 | 7.11E-35 | 2.58E-35 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.30E-03 | 1.35E+01 | 2.07E-02 | 2.12E-02 | 8.19E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 3.47E-01 | 5.90E+01 | 1.44E+00 | 1.00E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 4.42E-05 | 2.26E+00 | 8.75E-04 | 7.83E-05 | 1.56E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = IRRIGATED FRESH FORAGE--MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| P 32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = IRRIGATED FRESH FORAGE--MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 130 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = IRRIGATED STORED FEED--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.32E+01 | 1.32E+01 | 0.00E-01 | 1.32E+01 | 1.32E+01 | 1.32E+01 | 1.32E+01 | 0.00E-01 |
| C 14 | 6.33E+04 | 6.33E+04 | 2.96E+05 | 6.33E+04 | 6.33E+04 | 6.33E+04 | 6.33E+04 | 0.00E-01 |
| NA 24 | 3.60E+02 | 3.60E+02 | 3.60E+02 | 3.60E+02 | 3.60E+02 | 3.60E+02 | 3.60E+02 | 0.00E-01 |
| P 32 | 1.51E+05 | 5.26E+04 | 3.89E+06 | 2.29E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 3.85E+00 | 1.12E+02 | 0.00E-01 | 0.00E-01 | 5.49E-01 | 2.51E+00 | 4.89E+00 | 0.00E-01 |
| MN 54 | 2.05E+02 | 3.32E+02 | 0.00E-01 | 9.03E+02 | 2.00E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 9.56E-08 | 5.04E-05 | 0.00E-01 | 5.54E-07 | 4.76E-07 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 5.37E+02 | 2.55E+02 | 3.11E+03 | 2.01E+03 | 0.00E-01 | 0.00E-01 | 9.82E+02 | 0.00E-01 |
| FE 59 | 3.66E+03 | 4.44E+03 | 5.32E+03 | 9.28E+03 | 0.00E-01 | 0.00E-01 | 2.74E+03 | 0.00E-01 |
| CO 58 | 1.42E+03 | 1.42E+03 | 0.00E-01 | 5.70E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 4.80E+03 | 4.84E+03 | 0.00E-01 | 2.03E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 2.82E+04 | 2.50E+03 | 8.14E+05 | 5.03E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 3.37E-06 | 5.64E-04 | 6.55E-05 | 7.41E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 1.96E+00 | 8.67E+01 | 0.00E-01 | 4.22E+00 | 7.14E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 2.08E+05 | 3.81E+05 | 1.31E+05 | 4.51E+05 | 2.18E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 7.68E-17 | 8.41E-14 | 5.73E-16 | 1.03E-15 | 4.29E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.74E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 1.42E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 1.20E-34 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.65E+05 | 1.37E+04 | 0.00E-01 | 5.36E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 1.23E-27 | 2.19E-27 | 0.00E-01 | 2.24E-27 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 5.11E-28 | 2.53E-28 | 0.00E-01 | 7.42E-28 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 8.65E+03 | 6.20E+03 | 3.01E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 1.46E+05 | 5.89E+04 | 7.22E+06 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 2.21E-01 | 7.23E+00 | 6.11E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 3.32E-06 | 9.63E-04 | 8.93E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 4.38E-04 | 2.26E+01 | 1.63E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 1.90E-25 | 1.86E-20 | 5.59E-24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 4.60E-02 | 1.24E+02 | 1.73E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 3.15E-10 | 2.14E-04 | 1.12E-08 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 1.32E-06 | 3.83E-01 | 4.85E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 2.77E-02 | 1.95E+01 | 1.60E-01 | 3.91E-02 | 4.21E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 7.40E-06 | 1.03E+00 | 9.44E-05 | 1.62E-05 | 1.63E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 3.37E+00 | 4.92E+03 | 1.41E+01 | 5.82E+00 | 4.18E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 9.71E+02 | 1.64E+03 | 0.00E-01 | 4.98E+03 | 7.44E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 1.58E-02 | 3.56E-01 | 5.95E-04 | 1.23E-03 | 1.32E-02 | 0.00E-01 | 6.41E-04 | 0.00E-01 |
| TC101 | 4.63E-29 | 7.96E-28 | 3.72E-30 | 4.68E-30 | 5.57E-29 | 0.00E-01 | 2.55E-30 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = IRRIGATED STORED FEED--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 6.89E-02 | 2.51E+00 | 2.06E-01 | 0.00E-01 | 4.29E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 5.62E-08 | 6.64E-05 | 1.67E-07 | 0.00E-01 | 1.23E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 5.51E-01 | 3.35E+01 | 4.41E+00 | 0.00E-01 | 5.22E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 4.35E+03 | 3.41E+05 | 9.01E+03 | 6.58E+03 | 9.41E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 4.90E+02 | 1.73E+03 | 3.63E+03 | 1.21E+03 | 0.00E-01 | 1.22E+03 | 0.00E-01 | 0.00E-01 |
| TE127M | 1.23E+03 | 4.10E+03 | 1.02E+04 | 3.37E+03 | 2.50E+04 | 2.94E+03 | 0.00E-01 | 0.00E-01 |
| TE127 | 3.07E-02 | 3.00E+00 | 1.43E-01 | 4.79E-02 | 3.49E-01 | 1.16E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 2.07E+03 | 8.02E+03 | 1.34E+04 | 4.61E+03 | 3.36E+04 | 5.16E+03 | 0.00E-01 | 0.00E-01 |
| TE129 | 8.74E-15 | 2.99E-12 | 3.74E-14 | 1.29E-14 | 9.32E-14 | 3.14E-14 | 0.00E-01 | 0.00E-01 |
| TE131M | 2.67E+01 | 5.44E+02 | 8.02E+01 | 3.23E+01 | 2.22E+02 | 6.54E+01 | 0.00E-01 | 0.00E-01 |
| TE131 | 2.04E-29 | 2.94E-27 | 7.27E-29 | 2.69E-29 | 1.86E-28 | 6.49E-29 | 0.00E-01 | 0.00E-01 |
| TE132 | 2.35E+02 | 9.33E+02 | 5.09E+02 | 2.52E+02 | 1.58E+03 | 3.72E+02 | 0.00E-01 | 0.00E-01 |
| I 130 | 1.43E+01 | 7.64E+00 | 1.62E+01 | 3.57E+01 | 3.92E+01 | 4.00E+03 | 0.00E-01 | 0.00E-01 |
| I 131 | 6.79E+03 | 5.52E+02 | 1.31E+04 | 1.54E+04 | 1.80E+04 | 5.08E+06 | 0.00E-01 | 0.00E-01 |
| I 132 | 3.77E-06 | 8.58E-06 | 5.22E-06 | 1.06E-05 | 1.18E-05 | 4.97E-04 | 0.00E-01 | 0.00E-01 |
| I 133 | 7.27E+01 | 4.20E+01 | 1.70E+02 | 2.48E+02 | 2.92E+02 | 4.51E+04 | 0.00E-01 | 0.00E-01 |
| I 134 | 2.75E-17 | 7.99E-17 | 3.77E-17 | 7.73E-17 | 8.64E-17 | 1.80E-15 | 0.00E-01 | 0.00E-01 |
| I 135 | 3.52E-01 | 3.49E-01 | 4.85E-01 | 9.65E-01 | 1.08E+00 | 8.65E+01 | 0.00E-01 | 0.00E-01 |
| CS134 | 1.58E+05 | 4.26E+03 | 8.41E+05 | 1.57E+06 | 4.04E+05 | 0.00E-01 | 1.66E+05 | 0.00E-01 |
| CS136 | 5.22E+04 | 2.12E+03 | 4.75E+04 | 1.40E+05 | 5.57E+04 | 0.00E-01 | 1.14E+04 | 0.00E-01 |
| CS137 | 9.87E+04 | 4.35E+03 | 1.19E+06 | 1.39E+06 | 3.74E+05 | 0.00E-01 | 1.51E+05 | 0.00E-01 |
| CS138 | 3.49E-27 | 1.15E-26 | 4.43E-27 | 7.21E-27 | 3.59E-27 | 0.00E-01 | 5.61E-28 | 0.00E-01 |
| BA139 | 1.56E-13 | 3.41E-10 | 5.38E-12 | 3.57E-15 | 2.14E-15 | 0.00E-01 | 2.16E-15 | 0.00E-01 |
| BA140 | 2.99E+02 | 1.43E+03 | 5.81E+03 | 5.81E+00 | 1.38E+00 | 0.00E-01 | 3.57E+00 | 0.00E-01 |
| BA141 | 8.70E-31 | 3.37E-28 | 2.76E-29 | 1.89E-32 | 1.14E-32 | 0.00E-01 | 1.15E-32 | 0.00E-01 |
| BA142 | 6.86E-32 | 5.75E-30 | 1.39E-30 | 1.16E-33 | 6.67E-34 | 0.00E-01 | 7.01E-34 | 0.00E-01 |
| LA140 | 9.81E-05 | 4.48E+00 | 9.68E-04 | 3.81E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 1.17E-16 | 8.27E-11 | 1.33E-15 | 4.87E-16 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 7.42E-02 | 3.26E+02 | 1.03E+00 | 6.30E-01 | 1.94E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 7.18E-04 | 3.67E+01 | 9.49E-03 | 6.30E+00 | 1.83E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 3.01E+00 | 3.09E+03 | 5.38E+01 | 2.20E+01 | 8.90E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.78E-03 | 1.89E+01 | 3.58E-02 | 1.34E-02 | 4.98E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 9.26E-36 | 3.31E-30 | 1.84E-34 | 7.11E-35 | 2.58E-35 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.35E-03 | 1.39E+01 | 2.14E-02 | 2.20E-02 | 8.48E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 3.47E-01 | 5.90E+01 | 1.44E+00 | 1.00E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 4.42E-05 | 2.26E+00 | 8.75E-04 | 7.83E-05 | 1.56E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = IRRIGATED STORED FEED--MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| P 32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = IRRIGATED STORED FEED--MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 130 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = ANIMAL DRINKING WATER-MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 1.59E+01 | 1.59E+01 | 0.00E-01 | 1.59E+01 | 1.59E+01 | 1.59E+01 | 1.59E+01 | 0.00E-01 |
| C 14 | 6.03E+02 | 6.03E+02 | 2.83E+03 | 6.03E+02 | 6.03E+02 | 6.03E+02 | 6.03E+02 | 0.00E-01 |
| NA 24 | 4.20E+02 | 4.20E+02 | 4.20E+02 | 4.20E+02 | 4.20E+02 | 4.20E+02 | 4.20E+02 | 0.00E-01 |
| P 32 | 1.48E+04 | 5.17E+03 | 3.82E+05 | 2.25E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 2.93E-01 | 8.54E+00 | 0.00E-01 | 0.00E-01 | 4.17E-02 | 1.91E-01 | 3.72E-01 | 0.00E-01 |
| MN 54 | 1.11E+01 | 1.81E+01 | 0.00E-01 | 4.92E+01 | 1.09E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 6.29E-07 | 3.31E-04 | 0.00E-01 | 3.65E-06 | 3.14E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 2.86E+01 | 1.36E+01 | 1.65E+02 | 1.07E+02 | 0.00E-01 | 0.00E-01 | 5.23E+01 | 0.00E-01 |
| FE 59 | 2.45E+02 | 2.97E+02 | 3.56E+02 | 6.21E+02 | 0.00E-01 | 0.00E-01 | 1.84E+02 | 0.00E-01 |
| CO 58 | 8.75E+01 | 8.74E+01 | 0.00E-01 | 3.51E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 2.53E+02 | 2.55E+02 | 0.00E-01 | 1.07E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 1.46E+03 | 1.30E+02 | 4.22E+04 | 2.61E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 2.26E-05 | 3.78E-03 | 4.39E-04 | 4.97E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 2.69E+00 | 1.19E+02 | 0.00E-01 | 5.80E+00 | 9.81E+00 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 1.12E+04 | 2.05E+04 | 7.09E+03 | 2.43E+04 | 1.18E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 1.36E-15 | 1.49E-12 | 1.02E-14 | 1.83E-14 | 7.59E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 1.23E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 4.50E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 4.22E-32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 2.32E+04 | 1.20E+03 | 0.00E-01 | 4.70E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 6.94E-26 | 1.23E-25 | 0.00E-01 | 1.27E-25 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 3.37E-26 | 1.67E-26 | 0.00E-01 | 4.89E-26 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 5.56E+02 | 3.99E+02 | 1.94E+04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 4.56E+03 | 1.84E+03 | 2.25E+05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 4.01E-01 | 1.31E+01 | 1.11E+01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 2.06E-05 | 5.98E-03 | 5.55E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 1.36E-04 | 7.02E+00 | 5.09E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 3.87E-24 | 3.79E-19 | 1.14E-22 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 2.92E-03 | 7.86E+00 | 1.10E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 1.50E-09 | 1.02E-03 | 5.35E-08 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 2.26E-06 | 6.56E-01 | 8.31E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 1.73E-03 | 1.22E+00 | 1.00E-02 | 2.44E-03 | 2.63E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 7.71E-06 | 1.08E+00 | 9.84E-05 | 1.69E-05 | 1.70E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 2.39E-01 | 3.48E+02 | 1.00E+00 | 4.13E-01 | 2.96E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 2.95E+02 | 4.99E+02 | 0.00E-01 | 1.51E+03 | 2.26E+03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 4.48E-02 | 1.01E+00 | 1.69E-03 | 3.48E-03 | 3.74E-02 | 0.00E-01 | 1.82E-03 | 0.00E-01 |
| TC101 | 3.29E-27 | 5.64E-26 | 2.64E-28 | 3.32E-28 | 3.95E-27 | 0.00E-01 | 1.81E-28 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = ANIMAL DRINKING WATER--MILK

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 4.74E-03 | 1.72E-01 | 1.42E-02 | 0.00E-01 | 2.95E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 2.15E-07 | 2.54E-04 | 6.40E-07 | 0.00E-01 | 4.70E-06 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 2.98E-02 | 1.81E+00 | 2.38E-01 | 0.00E-01 | 2.82E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 2.38E+02 | 1.86E+04 | 4.92E+02 | 3.59E+02 | 5.14E+02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 3.05E+01 | 1.08E+02 | 2.26E+02 | 7.55E+01 | 0.00E-01 | 7.60E+01 | 0.00E-01 | 0.00E-01 |
| TE127M | 6.94E+01 | 2.31E+02 | 5.74E+02 | 1.90E+02 | 1.41E+03 | 1.66E+02 | 0.00E-01 | 0.00E-01 |
| TE127 | 5.64E-02 | 5.51E+00 | 2.62E-01 | 8.79E-02 | 6.40E-01 | 2.14E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 1.47E+02 | 5.69E+02 | 9.52E+02 | 3.27E+02 | 2.38E+03 | 3.66E+02 | 0.00E-01 | 0.00E-01 |
| TE129 | 1.26E-13 | 4.33E-11 | 5.41E-13 | 1.86E-13 | 1.35E-12 | 4.54E-13 | 0.00E-01 | 0.00E-01 |
| TE131M | 1.62E+01 | 3.30E+02 | 4.87E+01 | 1.96E+01 | 1.35E+02 | 3.97E+01 | 0.00E-01 | 0.00E-01 |
| TE131 | 8.17E-28 | 1.18E-25 | 2.91E-27 | 1.08E-27 | 7.45E-27 | 2.60E-27 | 0.00E-01 | 0.00E-01 |
| TE132 | 6.19E+01 | 2.45E+02 | 1.34E+02 | 6.63E+01 | 4.15E+02 | 9.78E+01 | 0.00E-01 | 0.00E-01 |
| I 130 | 2.02E+01 | 1.08E+01 | 2.28E+01 | 5.02E+01 | 5.52E+01 | 5.63E+03 | 0.00E-01 | 0.00E-01 |
| I 131 | 9.30E+02 | 7.55E+01 | 1.79E+03 | 2.11E+03 | 2.47E+03 | 6.95E+05 | 0.00E-01 | 0.00E-01 |
| I 132 | 2.77E-05 | 6.30E-05 | 3.83E-05 | 7.78E-05 | 8.68E-05 | 3.65E-03 | 0.00E-01 | 0.00E-01 |
| I 133 | 6.22E+01 | 3.59E+01 | 1.46E+02 | 2.12E+02 | 2.49E+02 | 3.86E+04 | 0.00E-01 | 0.00E-01 |
| I 134 | 5.28E-16 | 1.53E-15 | 7.25E-16 | 1.48E-15 | 1.66E-15 | 3.46E-14 | 0.00E-01 | 0.00E-01 |
| I 135 | 9.12E-01 | 9.05E-01 | 1.26E+00 | 2.50E+00 | 2.79E+00 | 2.24E+02 | 0.00E-01 | 0.00E-01 |
| CS134 | 8.45E+03 | 2.27E+02 | 4.49E+04 | 8.37E+04 | 2.15E+04 | 0.00E-01 | 8.83E+03 | 0.00E-01 |
| CS136 | 5.39E+03 | 2.19E+02 | 4.91E+03 | 1.44E+04 | 5.76E+03 | 0.00E-01 | 1.18E+03 | 0.00E-01 |
| CS137 | 5.16E+03 | 2.28E+02 | 6.22E+04 | 7.28E+04 | 1.95E+04 | 0.00E-01 | 7.92E+03 | 0.00E-01 |
| CS138 | 1.09E-25 | 3.60E-25 | 1.38E-25 | 2.25E-25 | 1.12E-25 | 0.00E-01 | 1.75E-26 | 0.00E-01 |
| BA139 | 1.91E-12 | 4.17E-09 | 6.59E-11 | 4.37E-14 | 2.63E-14 | 0.00E-01 | 2.65E-14 | 0.00E-01 |
| BA140 | 3.14E+01 | 1.49E+02 | 6.08E+02 | 6.08E-01 | 1.45E-01 | 0.00E-01 | 3.74E-01 | 0.00E-01 |
| BA141 | 4.79E-29 | 1.86E-26 | 1.52E-27 | 1.04E-30 | 6.26E-31 | 0.00E-01 | 6.33E-31 | 0.00E-01 |
| BA142 | 6.46E-30 | 5.41E-28 | 1.31E-28 | 1.09E-31 | 6.28E-32 | 0.00E-01 | 6.60E-32 | 0.00E-01 |
| LA140 | 4.57E-05 | 2.09E+00 | 4.51E-04 | 1.78E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 1.28E-15 | 9.04E-10 | 1.45E-14 | 5.33E-15 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 5.37E-03 | 2.36E+01 | 7.49E-02 | 4.57E-02 | 1.41E-02 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 3.99E-04 | 2.04E+01 | 5.28E-03 | 3.50E+00 | 1.02E-03 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 1.65E-01 | 1.69E+02 | 2.95E+00 | 1.21E+00 | 4.87E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 1.80E-04 | 1.92E+00 | 3.64E-03 | 1.36E-03 | 5.06E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 5.40E-34 | 1.93E-28 | 1.07E-32 | 4.15E-33 | 1.50E-33 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 1.52E-04 | 1.57E+00 | 2.42E-03 | 2.48E-03 | 9.58E-04 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 2.61E-01 | 4.43E+01 | 1.08E+00 | 7.54E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 1.53E-05 | 7.83E-01 | 3.03E-04 | 2.71E-05 | 5.40E-05 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = ANIMAL DRINKING WATER-MEAT

| | TOTAL BODY | GI-LI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| P 32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT
 PATHWAY = ANIMAL DRINKING WATER--MEAT

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 130 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = RIVER SHORELINE DEPOSITS

| | TOTAL BODY | GI-LI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| P .32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT

PATHWAY = RIVER SHORELINE DEPOSITS

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 130 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT
PATHWAY = SWIMMING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| P 32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT
 PATHWAY = SWIMMING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 130 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT
PATHWAY = BOATING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|-----------|----------|------------------------------|----------|----------|----------|----------|
| H 3 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| C 14 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NA 24 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| P 32 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CR 51 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 54 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MN 56 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 55 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| FE 59 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 58 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CO 60 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 63 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NI 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CU 64 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 65 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZN 69 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 83 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 84 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BR 85 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 86 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 88 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RB 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 89 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 90 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| SR 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 90 | 0.00E-01 | -0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 91 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 92 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| Y 93 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ZR 97 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NB 95 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| MO 99 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC 99M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TC101 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |

Appendix C

DOSE TRANSFER FACTORS FOR RADIONUCLIDES IN EFFLUENT WATER

AGE = INFANT
PATHWAY = BOATING

| | TOTAL BODY | GI-LLI | BONE | LIVER (mrem gal)/(Ci min) | KIDNEY | THYROID | LUNG | SKIN |
|--------|------------|----------|----------|------------------------------|----------|----------|----------|----------|
| RU103 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU105 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| RU106 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| AG110M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE125M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE127 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE129 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131M | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| TE132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 130 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 131 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 132 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 133 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| I 135 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS134 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS136 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS137 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CS138 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA139 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| BA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA140 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| LA142 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE141 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| CE144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR143 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| PR144 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| ND147 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| W 187 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |
| NP239 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 | 0.00E-01 |