

Entergy Nuclear Vermont Yankee, LLC Vermont Yankee 320 Governor Hunt Rd. Vernon, VT 05354 (802) 257-7711

> Coley C. Chappell Manager, Design and Programs

BVY 16-020

May 12, 2016

ATTN: Document Control Desk U.S. Nuclear Regulatory Commission Washington, D.C. 20555-0001

SUBJECT:

2015 Radioactive Effluent Release Report

Vermont Yankee Nuclear Power Station

Docket No. 50-271 License No. DPR-28

Dear Sir or Madam,

In accordance with Vermont Yankee (VY) Technical Specifications (TS) 6.6.D, enclosed is a copy of the annual 2015 Radioactive Effluent Release Report.

In addition, VY TS 6.7.B requires reporting of changes to the Off-Site Dose Calculation Manual (ODCM). There were no changes made to the ODCM during 2015 as noted in Appendix H of the subject report.

There are no new regulatory commitments being made in this submittal.

Should you have any questions or require additional information concerning this submittal, please contact me at (802) 451-3374.

Sincerely.

[CCC/TBS]

Enclosure:

Radioactive Effluent Release Report for 2015

cc listing (next page)

CC:

Mr. Daniel Dorman, Region 1 Administrator

IEH8 NRR U.S. Nuclear Regulatory Commission 2100 Renaissance Blvd., Suite 100 King of Prussia, PA 19406-2713

Mr. Jack D. Parrott, Senior Project Manager U.S. Nuclear Regulatory Commission Mail Stop T-8F5 11555 Rockville Pike Rockville, MD 20852-2378

Mr. Christopher Recchia, Commissioner VT Department of Public Service 112 State Street – Drawer 20 Montpelier, VT 05620

Vermont Department of Health Division of Radiological Health Attn: Bill Irwin P.O. Box 70 Burlington, VT 05402-0070

Massachusetts Department of Public Health Jack Priest, Director Radiation Control Program 529 Main Street, Suite 1M2A Charlestown, MA 02129

Augustinus Ong, Administrator Department of Health and Human Services Radiological Health Section 29 Hazen Drive Concord, NH 03301-6504

John Giarrusso Nuclear Preparedness and Planning Manager 400 Worcester Road Framingham, MA 01702

Tony Honnellio
Radiation Program Manager, Health and Safety Coordinator
EPA, New England, Region 1
5 Post Office Square, Suite 100 (OSRR02-2).
Boston, Massachusetts 02109

# RADIOACTIVE EFFLUENT RELEASE REPORT FOR 2015 INCLUDING ANNUAL RADIOLOGICAL IMPACT ON MAN

Entergy Nuclear Vermont Yankee, LLC Docket No. 50-271 License No. DPR-28

Prepared by:	Am Peleau	15/5/16
(7)	Jo-Ann Pelczar, Advisory Scientist, AREVA, I	
Preparation coordinated by:	White Chamistry Synanian	15/5/2016
Ann	Kevah Whippie, Chemistry Supervisor	Date
Reviewed by:	Scort Dorwal, R.P. Supervisor	1 5 10/10
Anneared for Distribution:	Springer Supervisor	16/5/16
Approved for Distribution:	Mike-Pletcher, RP/Chemistry Manager	Date

#### TABLE OF CONTENTS

<u>ra</u>	<u>ige</u>
1.0 INTRODUCTION	1
2.0 METEOROLOGICAL DATA	2
3.0 DOSE ASSESSMENT	3
3.1 Doses From Liquid Effluents	3
3.2 Doses From Noble Gases	4
3.3 Doses From Iodine-131, Iodine-133, Tritium, Carbon-14, and Radionuclides in Particulate Form with Half-Lives Greater Than 8 Days	4
3.4 WHOLE BODY DOSES IN UNRESTRICTED AREAS FROM DIRECT RADIATION	5
3.5 Doses From On-Site Disposal of Septic Waste, Cooling Tower Silt and Soil	6
3.6 ON-SITE RECREATIONAL ACTIVITIES	6
REFERENCES	
APPENDIX A -SUPPLEMENTAL INFORMATION	<b>A-</b> 1
APPENDIX B - LIQUID HOLDUP TANKS	B-1
APPENDIX C - RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION	C-1
APPENDIX D -RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION	<b>D-</b> 1
APPENDIX E - RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM	.E-1
APPENDIX F - LAND USE CENSUS	.F-1
APPENDIX G -PROCESS CONTROL PROGRAM	G-1
APPENDIX H -OFF-SITE DOSE CALCULATION MANUAL	H-1
APPENDIX I - RADIOACTIVE LIQUID, GASEOUS AND SOLID WASTE TREATMENT SYSTEMS	I-1
APPENDIX J - ON-SITE DISPOSAL OF SEPTIC/SILT/SOIL WASTE	. J-1

#### LIST OF TABLES

1 <b>A</b>	Gaseous Effluents - Summation of All Releases	8
1B	Gaseous Effluents - Elevated Releases	10
1C	Gaseous Effluents - Ground Level Releases	12
1D	Gaseous Effluents – Non-routine Releases	14
2A	Liquid Effluents - Summation of All Releases	15
2B	Liquid Effluents – Routine Releases	17
3	Solid Waste and Irradiated Fuel Shipments	19
4A	Maximum Quarterly and Annual Off-Site Doses from Direct Radiation and Liquid and Gaseous Effluents for 2015 (10CFR50, Appendix I)	21
4B	Maximum Annual Off-Site Doses from Direct Radiation and and Liquid and Gaseous Effluents for 2015 (40CFR190)	22
4C	Receptor Locations	23
4D	Usage Factors for Environmental Pathways	24
4E	Environmental Parameters for Gaseous Effluents	25
4F	Environmental Parameters for Liquid Releases (Tritium) Via Groundwater	27
5A to 5H	Annual (2015) Summary of Lower Level Joint Frequency Distribution	28-35
6A to 6H	Annual (2015) Summary of Upper Level Joint Frequency Distribution	36-43

#### Radiological Effluent Release Report for 2015

[Including Annual Radiological Impact on Man] Entergy Nuclear Vermont Yankee, LLC

#### 1.0 INTRODUCTION

Tables 1 through 3 list the recorded radioactive liquid and gaseous effluents and solid waste shipments for the year, with data summarized on a quarterly basis for both liquids and gases. Table 4A summarizes the estimated radiological dose commitments from all radioactive liquid and gaseous effluents released during the year 2015 in response to the ALARA objectives of 10 CFR Part 50, Appendix I. Also included in Table 4A is the estimate of direct dose from fixed station sources along the limiting west site boundary line. Tables 5A through 6H report the cumulative joint frequency distributions of wind speed, wind direction, and atmospheric stability for the 12-month period, January to December 2015. Radioactive effluents reported in Tables 1 and 2 were used to determine the dose to the maximum exposed individual for 2015.

Dose commitments resulting from the release of radioactive materials in liquids and gases during the reporting period were estimated in accordance with the plant's Off-Site Dose Calculation Manual (ODCM), Section 10.1 (Reference 1). These dose estimates were made using a "Method II" analysis as described in the ODCM, and as reported in Tables 4A and 4B of this report. A "Method II" analysis incorporates the methodology of Regulatory Guide 1.109 (Reference 2) and actual measured meteorological data recorded concurrently with the quarterly reporting period.

As required by ODCM Section 10.1, this report shall also include an assessment of the radiation doses from radioactive effluents to member(s) of the public due to allowed recreational activities inside the site boundary during the year. As discussed in Section 3.6, there were no such recreational activities permitted and, therefore, there is no associated dose assessment.

An assessment of radiation doses (including direct radiation) to the likely most exposed real member(s) of the public for the calendar year for the purposes of demonstrating conformance with 40 CFR Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operations," is also required to be included in this report if the conditions indicated in ODCM 3/4.4, "Total Dose," have been exceeded during the year. Since the conditions indicated in the action statement under ODCM 3/4.4 were not entered into during the year, no additional radiation dose assessment is required. However, Table 4B does provide the combination of off-site doses and dose commitments from plant effluents and direct radiation sources for the limiting member of the public as a demonstration of compliance with the dose standards of 40 CFR Part 190.

All calculated dose estimates for members of the public at the site boundary or beyond for the 2015 annual reporting period are below the dose criteria of 10 CFR Part 50, Appendix I, and 40 CFR Part 190.

Appendices B through H indicate the status of reportable items per the requirements of ODCM Section 10.1.

#### 2.0 METEOROLOGICAL DATA

Meteorological data were collected in 2015 from the site's 300-foot meteorological tower located approximately 2,200 feet northwest of the reactor building, and about 1,400 feet from the plant stack. The 300-foot tower is approximately the same height as the primary plant stack (308 feet) and is designed to meet the requirements of Safety Guide 23 (Reference 3) for meteorological monitoring. In mid-2009, the tower was moved to a location approximately 200 feet northwest of the original location.

χ/Q and D/Q values for elevated releases were derived for all receptor points from the site meteorological record for each quarter using a straight-line airflow model. All dispersion factors have been calculated employing appropriate source configuration considerations, as described in Regulatory Guide 1.111 (Reference 4). A source depletion model as described in "Meteorology and Atomic Energy - 1968" (Reference 5) was used to generate deposition factors, assuming a constant deposition velocity of 0.01 m/sec for all stack (elevated) releases. Changes in terrain elevations in the site environment were also factored into the meteorological models as appropriate.

In the event of a ground-level release,  $\chi/Q$  and D/Q values would be derived for the site boundary receptor points from the site meteorological record for each quarter using a straight-line airflow model. During this reporting period, there were no ground-level releases and therefore no associated dose impact.

Table 4C lists the distances from the plant stack to the nearest site boundary, resident, and milk animal in each of the 16 principle compass directions as determined during the 2015 land use census. These locations were used in the calculation of atmospheric dispersion factors. The meteorological model was also executed for each calendar quarter to determine the location of the predicted maximum ground level air concentration from elevated releases from the plant's primary vent stack. These locations were included in the assessment of effluent doses along with identified points of interest from the annual land use census.

#### 3.0 DOSE ASSESSMENT

#### 3.1 Doses From Liquid Effluents

ODCM 3/4.2.2 limits total body doses (1.5 mrem per quarter, and 3 mrem per year) and organ doses (5 mrem per quarter, and 10 mrem per year) from liquid effluents to a member of the public to those specified in 10 CFR Part 50, Appendix I. By implementing the requirements of 10 CFR Part 50, Appendix I, ODCM 3/4.2.2 assures that the release of radioactive material in liquid effluents will be kept "as low as is reasonably achievable."

There were no recorded routine liquid radioactive waste discharges during the report period. However, an abnormal release to the Connecticut River is postulated due to a past leak in an underground pipe tunnel that runs between the Advanced Offgas (AOG) system building and other plant buildings which allowed accumulated piping system leakage to enter the subsurface groundwater adjacent to the plant structures. The existence of the leak was first recognized in January 2010, when a river shoreline Protected Area Boundary monitoring well sample was reported to have detectable tritium. The addition of other monitoring wells and subsequent analysis defined the extent of the affected groundwater plume moving toward the river and helped locate the source of the leak, which was stopped in February 2010.

Estimates of tritium-contaminated ground water released from the site are based on Protected Area Boundary monitoring well data collected throughout 2015, and hydrological modeling of ground water movement in the affected zone impacted by the pipe tunnel leak. Using a conservative estimate of groundwater flow through the affected area toward the river on a quarterly basis, an estimate of the total potential tritium released from the site during each quarter of 2015 was generated and reported in Table 2A.

For the projected ground water flow into the Connecticut River in 2015, the dose impact to the maximum exposed individual (MEI) assumed the following exposure pathways: (1) ingestion of fish (taken from Vernon Pond), (2) ingestion of vegetables and fresh leafy produce irrigated by water taken from the river below Vernon Dam, (3) ingestion of milk and meat from animals that were fed irrigated crops and drinking water taken from the river below Vernon Dam, and (4) potable water for a hypothetical individual drawing drinking water fed by the river below Vernon Dam. For Vernon Pond (river area adjacent to the plant property), the near shore mixing zone associated with the fish ingestion pathway is conservatively taken as 1% of the minimum recorded monthly river flow (3,107 cfs in September 2015) for dilution. All irrigation exposure pathways for the consumption of food products grown with irrigated water occur below Vernon Dam and assume the lowest 2015 quarterly average growing season river flow value (5394 cfs in the third quarter) for environmental mixing. For the drinking water pathway, river flow mixing is assumed to occur below Vernon Dam and uses the lowest annual quarterly average river flow (5394 cfs in the third quarter) as a conservative estimate of river dilution for all four quarters of the year. The dose models are taken from Regulatory Guide 1.109 (Reference 2) and use environmental parameters for exposure pathways listed in Tables 4D and 4F.

The maximum estimated quarterly and annual whole body and organ doses to the limiting age group from liquid releases are reported in Table 4A. These estimated doses are well below the 10 CFR Part 50, Appendix I dose criteria of ODCM 3/4.2.2. Table 4B provides an estimate of the total annual dose impact (including contribution from liquids) associated with the highest exposed member of the public for demonstration of compliance to the dose standard contained in 40 CFR Part 190 for the uranium fuel cycle.

#### 3.2 Doses From Noble Gases

ODCM 3/4.3.2 limits the gamma air dose (5 mrad per quarter, and 10 mrad per year) and beta air (10 mrad per quarter, and 20 mrad per year) dose from noble gases released in gaseous effluents from the site to areas at and beyond the site boundary to those specified in 10 CFR Part 50, Appendix I. By implementing these, ODCM 3/4.3.2 assures that the releases of radioactive noble gases in gaseous effluents will be kept "as low as is reasonably achievable."

Dose estimates due to the release of noble gases to the atmosphere are typically calculated at the site boundary, at the nearest resident in each of the sixteen principal compass directions, at the point of highest off-site ground level air concentration of radioactive materials, and at each of the milk animal locations located within five miles of the plant. For 2015, there were no noble gases detected in effluents released from the plant stack.

## 3.3 <u>Doses From Iodine-131, Iodine-133, Tritium, Carbon-14, and Radionuclides in Particulate Form with</u> Half-Lives Greater Than 8 Days

ODCM 3/4.3.3 limits the organ dose to a member of the public from Iodine-131, Iodine-133, Tritium, Carbon-14, and radionuclides in particulate form with half-lives greater than 8 days (hereafter called "iodines and particulates") in gaseous effluents released from the site to areas at and beyond the site boundary to those specified in 10 CFR Part 50, Appendix I (7.5 mrem per quarter and 15 mrem per year). By implementing the requirements of 10 CFR Part 50, Appendix I, ODCM 3/4.3.3 assures that the releases of iodines and particulates in gaseous effluents will be kept "as low as is reasonably achievable."

During 2015, a single frac tank was used on the Vermont Yankee site to temporarily store (outdoors) tritium-contaminated water extracted from onsite groundwater wells. The quantity of tritium released to the atmosphere through the evaporation of water from this frac tank was estimated, and the dose consequence to the maximally exposed individual was calculated.

Exposure pathways that could exist as a result of the planned (routine) release of iodines and particulates to the atmosphere include external irradiation from activity deposited onto the ground surface, inhalation, and ingestion of vegetables, meat and milk. Dose estimates were made at the site boundary and nearest resident in each of the sixteen principal compass directions, as well as all milk animal locations within five miles of the plant. The nearest resident and milk animals in each sector were identified by the most recent annual land use census as required by ODCM 3/4.5.2 (see Table 4C). Conservatively, a vegetable garden was assumed to exist at each milk animal and nearest resident location. Furthermore, the meat pathway was assumed to exist at each milk cow location since this data category is not part of the annual land use census. Doses were also calculated at the point of maximum ground level air concentration of radioactive materials in gaseous effluents and included the assumption that the inhalation, vegetable garden, and ground plane exposure pathways exist for an individual with a 100 percent occupancy factor.

It is assumed that milk and meat animals are free to graze on open pasture during the second and third quarters with no supplemental feeding. This assumption is conservative since most of the milk animals inventoried in the site vicinity are fed stored feed throughout the entire year with only limited grazing allowed during the growing season. It has also been assumed that only 50 percent of the iodine deposited from gaseous effluent is in elemental form (I<sub>2</sub>) and is available for uptake (see p. 6, Reference 2).

During the non-growing season (first and fourth quarters), the milk animals are assumed to receive only stored feed. During the growing season (second and third quarters), all animal feed is assumed to be derived from fresh pasture. Usage factors for gaseous effluents are listed by age group and pathway in Table 4D. Table 4E provides other dose model parameter assumptions used in the dose assessments.

In June 2009, the NRC issued Revision 2 of Regulatory Guide 1.21 (Reference 6) which introduced the term "principal radionuclide" in a risk-informed or dose context. A radionuclide can be considered a principal radionuclide if it contributes either (1) greater than 1 percent of the 10 CFR Part 50, Appendix I design objective dose for all radionuclides in the type of effluent being considered, or (2) greater than 1 percent of the activity of all radionuclides in the type of effluent being considered. In addition to natural production in the environment, Carbon-14 is also produced in nuclear reactors as a function of power output, but at amounts much less than those generated naturally or from past weapons testing. Since the time of the earlier publication of Regulatory Guide 1.21 (Revision 1) in 1974, commercial nuclear power plants have decreased total radioactive effluents (other than Carbon-14) through improved fuel performance and waste management practices to the point today that Carbon-14 could be considered a principal radionuclide under today's definition. With the plant permanently shut down since December of 2014, there was no plant related Carbon-14 production or associated dose impact for 2015.

#### 3.4 Whole Body Doses in Unrestricted Areas From Direct Radiation

As opposed to previous years where the majority of the dose in the unrestricted area consisted of direct and skyshine radiation from N-16 decay in the Turbine Building steam cycle during power operations, there was no such source during 2015 due to the plant being permanently shut down.

The other fixed sources of direct and scatter radiation to the site boundary are the Independent Spent Fuel Storage Installation (ISFSI), the low level radioactive materials stored in the North Warehouse, the Low Level Waste Storage Pad Facility (no radioactive waste material stored on the pad in 2015), and old turbine rotors and casings in the Turbine Storage Facility. The annual dose is based on dose rate measurements in these storage facilities and is projected to impact the same most restrictive site boundary dose location.

The estimated direct radiation dose from all major sources combined for the most limiting site boundary location is listed in Table 4A. These site boundary doses assume a 100 percent occupancy factor, and take no credit for the shielding effect of any residential structure.

Table 4B lists the combination of direct radiation doses at the limiting site boundary location and the maximum offsite dose from gaseous and liquid effluents for the purpose of demonstrating compliance with the dose standards contained in 40 CFR Part 190. For 2015, this annual dose was below the 25 mrem total body and organ limit, as well as the 75 mrem thyroid limit, of 40 CFR Part 190.

#### 3.5 Doses From On-Site Disposal of Septic Waste, Cooling Tower Silt and Soil

ODCM Appendices B, F, and I require that all septic waste, cooling tower silt, and sand/soil applied within the approved designated disposal areas be controlled to ensure the dose to a maximally exposed individual during the period of Vermont Yankee site control is limited to less than 1 mrem/year to the whole body and any organ. After the period associated with Vermont Yankee operational control, the dose to the inadvertent intruder is to be limited to 5 mrem/year. The projected dose from on-site disposals of septic waste, cooling tower silt, and sand/soil mixes is given in Appendix J of this report.

The dose limits applicable to the on-site spreading of materials were met for the single spreading of septic waste in 2015, based on the combined dose from this spreading and all past spreadings.

#### 3.6 On-Site Recreational Activities

During 2015, no access to the on-site boat launching ramp located north of the intake structure was permitted for employees, their families, and guests. As such, there was no associated dose impact to members of the public.

#### **REFERENCES**

- 1. Off-site Dose Calculation Manual (ODCM), Revision 35, Entergy Nuclear Vermont Yankee, LLC, dated October 9, 2014.
- 2. Regulatory Guide 1.109, "Calculation of Annual Doses to Man From Routine Release of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," U. S. Nuclear Regulatory Commission, Office of Standards Development, Revision 1, October 1977.
- 3. Safety Guide 1.23, "Onsite Meteorological Programs," U.S. Atomic Energy Commission, February 17, 1972.
- 4. Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors," U.S. Nuclear Regulatory Commission, Office of Standards Development, March 1976.
- 5. Meteorology and Atomic Energy, 1968, Section 5-3.2.2, "Cloud Depletion," page 204, U. S. Atomic Energy Commission, July 1968.
- 6. Regulatory guide 1.21, "Measuring, Evaluating, and Reporting Radioactive Material in Liquid and Gaseous Effluents and Solid Waste," U.S. Nuclear Regulatory Commission, Office of Nuclear Regulatory Research, Revision 2, June 2009.

#### TABLE 1A

## Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Gaseous Effluents - Summation of All Releases

		Unit	Quarter 1	Quarter 2	Est. Total Error, %
A.	Fission and Activation Gases				
1.	Total release	Ci	ND	ND	±2.30E+01
2.	Average release rate for period	μCi/sec	ND	ND	N/A
3.	Percent of ODCM limit (1)	%	ND	ND	N/A
В.	Iodines				
1.	Total Iodine	Ci	ND	ND	±1.80E+01
2.	Average release rate for period	μCi/sec	ND	ND	N/A
3.	Percent of ODCM limit (3)	%	(3)	(3)	N/A
C.	Particulates		<del></del>		
1.	Particulates with T-1/2>8 days	Ci	ND	ND	±1.80E+01
2.	Average release rate for period	μCi/sec	ND	ND	N/A
3.	Percent of ODCM limit (3)	%	(3)	(3)	N/A
4.	Gross alpha radioactivity	Ci	. ND	ND	N/A
D.	Tritium (4)				
1.	Total release	Ci	7.34E-02	7.09E-02	±1.80E+0l
2.	Average release rate for period	μCi/sec	9.63E-03	9.22E-03	N/A
3.	Percent of ODCM limit (3)	%	(3)	(3)	N/A
E.	Carbon-14				
1.	Total release	Ci	ND	ND	N/A
2.	Percent of ODCM limit (2)	%	4.99E-04	4.53E-04	N/A

ND = Not Detected, or in the case of C-14, no power operations in 2015 leads to a zero estimate of C-14 production/release.

- (1) ODCM Control 3.3.2. for the most limiting of beta air or gamma air dose. Percentage of ODCM limit calculated using Method I dose results.
- (2) ODCM Control 3.3.3. for dose from 1-131, 1-133, Tritium, Carbon-14 and radionuclides in particulate form. Percentage of ODCM limit calculated using Method I dose results.
- (3) Per ODCM Control 3.3.3, the dose contribution from Tritium, Iodines, and particulates are included with Carbon-14 in Part E.
- (4) Tritium released through evaporation from the onsite frac tank is included in these totals.

### TABLE 1A (Continued)

## Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Gaseous Effluents - Summation of All Releases

		Unit	Quarter 3	Quarter 4	Est. Total Error, %
A.	Fission and Activation Gases				
1.	Total release	Ci	ND	ND	±2.30E+01
2.	Average release rate for period	μCi/sec	ND	ND	N/A
3.	Percent of ODCM limit (1)	%	ND	ND	N/A
B.	Iodines				
1.	Total Iodine	Ci	ND	ND	±1.80E+01
2.	Average release rate for period	μCi/sec	ND	ND	N/A
3.	Percent of ODCM limit (3)	%	(3)	(3)	N/A
C.	Particulates				
1.	Particulates with T-1/2>8 days	Ci	ND	ND	±1.80E+0I
2.	Average release rate for period	μCi/sec	ND	ND	N/A
3.	Percent of ODCM limit (3)	%	(3)	(3)	N/A
4.	Gross alpha radioactivity	Ci	ND	ND	N/A
D.	Tritium (4)				
1.	Total release	Ci	1.14E-01	7.87E-02	±1.80E+01
2.	Average release rate for period	μCi/sec	1.46E-02	2.78E-02	N/A
3.	Percent of ODCM limit (3)	%	(3)	(3)	N/A
E.	Carbon-14				
1.	Total release	Ci	ND	ND	N/A
2.	Percent of ODCM limit (2)	%	7.29E-04	5.03E-04	N/A

ND = Not Detected, or in the case of C-14, no power operations in 2015 leads to a zero estimate of C-14 production/release.

<sup>(1)</sup> ODCM Control 3.3.2. for the most limiting of beta air or gamma air dose. Percentage of ODCM limit calculated using Method I dose results.

<sup>(2)</sup> ODCM Control 3.3.3. for dose from 1-131, 1-133, Tritium, Carbon-14 and radionuclides in particulate form. Percentage of ODCM limit calculated using Method I dose results.

<sup>(3)</sup> Per ODCM Control 3.3.3, the dose contribution from Tritium, Iodines, and particulates are included with Carbon-14 in Part E.

<sup>(4)</sup> Tritium released through evaporation from the onsite frac tank is included in these totals.

#### TABLE IB

### Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Gaseous Effluents - Elevated Releases

			Continuous Mode  Quarter		Batch Mode (1)	
					Qua	arter
-	Nuclides Released	Units	1	2	1	2
1.	Fission Gases					
	Argon-41	Ci	ND	ND		
	Krypton-85	Ci	ND	ND		
	Krypton-85m	Ci	ND_	ND		
	Krypton-87	Ci	ND	ND		
	Krypton-88	Ci	ND	ND		
	Xenon-133	Ci	ND	ND		
	Xenon-133m	Ci	ND	ND		
	Xenon-135	Ci	ND	ND		
	Xenon-135m	Ci	ND	ND		
	Xenon-138	Ci	ND	ND		
	Unidentified	Ci	ND	ND		
	Total for Period	Ci	ND	ND	(1)	(1)
2.	Iodines					
	Iodine-131	Ci	ND	ND		
	Iodine-133	Ci	ND	ND		
	Iodine-135	Ci	ND	ND		
	Total for Period	Ci	ND	ND	(1)	(1)
3.	Particulates					
	Strontium-89	Ci	ND	ND		
	Strontium-90	Ci	ND	ND		
	Cesium-134	Ci	ND	ND		
	Cesium-137	Ci	ND	ND		
	Barium-Lanthanum-140	Ci	ND	ND		
	Manganese-54	Ci	ND	ND		
_	Chromium-51	Ci	ND	ND		
	Cobalt-57	Ci	ND	ND		
	Cobalt-58	Ci	ND	ND		
	Cobalt-60	Ci	ND	ND		
	Cerium-141	Ci	ND	ND		
	Zinc-65	Ci	ND	ND		
	Total for Period	Ci	ND	ND	(1)	(1)

ND

Not Detected at the plant stack
There were no batch mode gaseous releases for this reporting period. (1)

## TABLE 1B (Continued)

## Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Gaseous Effluents - Elevated Releases

	T	Continuous Mode Quarter		Batch Mode (1)  Quarter	
Nuclides Released	Units	3	4.	3	4
1. Fission Gases		ſ			
Krypton-85	Ci	ND	ND		
Krypton-85m	Çi	ND	ND		
Krypton-87	Ci	ND	ND		
Krypton-88	Ci	ND	ND		
Xenon-133	Ci	ND	NĎ		
Xenon-133m	Ci	ND	ND		
Xenon-135	Ci '	ND	ND		
Xenon-135m	Ci	ND	ND		
Xenon-138	Ci	ND	ND		
Unidentified	Ci	ND	ND		
Total for Period	Ci	ND	ND	(1)	(1)
2. Iodines					
Iödine-131	Ci	ND	ND		
Iodine-133	Ci	ND	ND		
Iodine-135	Ci	ND	ND		
Total for Period	Ci	ND	ND	(1)	(1)
3. Particulates					
Strontium-89	Ci	ND	ND		
Strontium-90	Ci	ND	ND		
Cesium-134	Ci	ND	ND		
Cesium-137	Ci	ND	ND		
Barium-Lanthanum-140	Ci	ND	ND		
Manganese-54	Ci	ND	ND		
Chromium-51	Ci	ND	ND		
Cobalt-58	Ci	ND	ND		
Cobalt-60	Ci	ND	ND		,
Cerium-141	Ci	ND	ND		
Cerium-144	Ci	ND	ND		
Zinc-65	Ci	ND	ND		
Total for Period	Ci	ND	ND	(1)	(1)

ND Not Detected at the Plant Stack

<sup>(1)</sup> There were no batch mode gaseous releases for this reporting period.

#### TABLE 1C

#### Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Gaseous Effluents – (Routine) Ground Level Releases (2)

			Continuo	ous Mode	Batch Mode Quarter	
			Qua	arter		
-	Nuclides Released	Units	1(1)	2(1)	1(1)	2(1)
1.	Fission Gases					
	Krypton-85	Ci	, -			
	Krypton-85m	Ci				
	Krypton-87	Ci				
	Krypton-88	Ci				
	Xenon-133	Ĉi				
	Xenon-135	Ci				
	Xenon-135m	Ci				
	Xenon-138	Ci				•
	Unidentified	Ci				
-	Total for Period	Ci				
2.	Iodines					
	Iodine-131	Ci				
	Iodine-133	Ci				
	Iodine-I 35	Ci				
	Total for Period	Ci				
3.	Particulates				i	
	Strontium-89	Ci				
	Strontium-90	Ci				
	Cesium-134	Ci		,		
	Cesium- 137	Ci				
	Barium-Lanthanum-140	Ci				
	Manganese-54	Ci				
	Chromium-51	Ci				
	Cobalt-58	Ci				,
	Cobalt-60	Ci				
	Cerium-141	Ci				
	Zinc-65	Ci				
	Iron-55	Ci				
	Total for Period	Ci				

There were no routine ground level gaseous releases for this reporting period.
 No radioactively contaminated used oil was burned during 2015.

#### **TABLE IC** (Continued)

### Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Gaseous Effluents - (Routine) Ground Level Releases<sup>(2)</sup>

	·		Continuo	ous Mode	Batch Mode	
		<u>                                       </u>	Quarter		Quarter	
	Nuclides Released	Units	3 (1)	4 (1)	3 (1)	4 (1)
1.	Fission Gases					
	Krypton-85	Ci				
	Krypton-85m	Ci				
	Krypton-87	Ci			,	
	Krypton-88	Ci				
	Xenon-133	Ci	,			
	Xenon-135	Ci			,	
	Xenon-135m	Ci				
	Xenon-138	Ci				
	Unidentified	Ci	-			
	Total for Period	Ci				`
2.	Iodines					
	Iodine-131	Ci				
	Iodine-133	Ċi				
	Iodine-135	Ci				
	Total for Period	Ci				
3.	Particulates					
	Strontium-89	Ci				
	Strontium-90	Ci				
	Cesium- 134	<sup>°</sup> Ci				_
	Cesium-137	Ci			•	
	Barium-Lanthanum- 140	Ci				
	Manganese-54	Ci				
	Chromium-51	Ci				
	Cobalt-58	Ci			·	
	Cobalt-60	Ci				
	Cerium-141	Ci				
	Zinc-65	Ci				
	Iron-55	CI				
	Total for Period	Ci				

There were no ground level gaseous releases for this reporting period.
 No radioactively contaminated used oil was burned during 2015.

#### TABLE 1D

## Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Gaseous Effluents –Non-routine Releases

				•		
			Quarter		Quarter	
	Nuclides Released	Units	1(1)	2(1)	3(1)	4(1)
1.	Fission Gases					
	Krypton-85	Ci				
	Krypton-85m	Ci	1			
	Krypton-87	Ci			*	
	Krypton-88	Ci				
	Xenon-133	Ci				
- ,	Xenon-135	Ci				
	Xenon-135m	Ci				
	Xenon-138	Ci				
	Unidentified	Ci .				
	Total for Period	Ci	£.			
2.	Iodines					
	Iodine-131	Ci				
	Iodine-133	Ci				
	Iodine-I 35	Ci				
	Total for Period	Ci				ī
3. :	Particulates	<del></del> .				
	Strontium-89	Ci		<del> </del>		
	Strontium-90	Ci		<del> </del>		
	Cesium-134	Ci		<del> </del>		
	Cesium- 137	Ci		<u> </u>	· · · · · · · · · · · · · · · · · · ·	
	Barium-Lanthanum-140	Ci	,	_	, , , , , , , , , , , , , , , , , , ,	
	Manganese-54	Ci		<u> </u>		
	Chromium-51	Ci	, ,		· ,	V
	Cobalt-58	Ci				
	Cobalt-60	Ci				
	Cerium-141	Ci		† - · · · ·		
	Zinc-65	Ci	` .	<del>                                     </del>		
	Iron-55	Cl		<u> </u>	-	
_	Total for Period	Ci	<del> </del>	<del>†</del>		<del></del>

<sup>(1)</sup> There were no non-routine ground level gaseous releases for this reporting period.

#### TABLE 2A

## Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Liquid Effluents - Summation of All Releases

		Units	Quarter 1	Quarter 2	Est. Total Error, %		
A.	Fission and Activation Products						
	Total Release (not including tritium, gases, alpha)	Ci	ND	ND	N/A		
	Average Diluted Concentration During Period	μCi/ml	ND	ND	ļ		
	3. Percent of Applicable Limit (1)	%	ND	ND _			
В.	Tritium	1					
<u></u>	1. Total Release	Ci	8.85E-03	9.05E-03	±2.00E+01		
	2. Average Diluted Concentration During Period	μCi/ml	1.67E-06	1.66E-06			
	Percent of Applicable Limit (1)	%	5.90E-05	6.03E-05			
C.	Dissolved and Entrained Gases		<del></del>		· · · · · · · · · · · · · · · · · · ·		
	1. Total Release	Ci	ND	ND	N/A		
	2. Average Diluted Concentration During Period	μCi/ml	ND	ND	_		
	3. Percent of Applicable Limit	%	ND	ND			
D.	D. Gross Alpha Radioactivity						
	1. Total Release	Ci	ND	NDND	N/A		
			<b>,</b>		· · · · · · · · · · · · · · · · · · ·		
E.	Volume of Waste Release (prior to dilution)	Liters	(2)	(2)	N/A		
F.	Volume of Dilution Water Used During Period	Liters	3.89E+06	3.89E+06	(3)		

- ND Not detected in liquid effluents.
- (1) The percent of limit is based on the ODCM Control 3.2.2 limiting dose (1.5 mrem/quarter to the total body) from liquid effluents and is related to the abnormal leakage of tritiated plant water into the underground environment.
  - The percent of the concentration limits specified in Appendix B to 10CFR20.1001 20.2402, Table 2, Column 2 (ODCM Control 3. 2.1) were estimated to be 0.17%, 0.17%, 0.15%, and 0.14% for the first, second, third, and fourth quarters, respectively.
- (2) Leakage of contaminated plant water to subsurface areas was stopped in February 2010. The release of contaminated ground water to the Connecticut River is based on site boundary monitoring well data collected during 2015.
- (3) Dilution due to groundwater flow through the affected subsurface plume area toward the Connecticut River was estimated to be 7.83 gpm (or 3.89E+06 liters per quarter) during 2015. An Estimated Total Error is not applicable.

### TABLE 2A (Continued)

## Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Liquid Effluents - Summation of All Releases

		Units	Quarter 3	Quarter 4	Est. Total Error, %
A. Fissio	on and Activation Products				
1. T	otal Release (not including tritium, gases, alpha)	Ci	ND	ND	N/A
2. A	Average Diluted Concentration During Period	μCi/ml	ND	ND	
3. F	Percent of Applicable Limit (1)	%	ND	ND	
B. Tritiu	m				
1. T	otal Release	Ci	8.02E-03	7.50E-03	±2.00E+01
2. A	Average Diluted Concentration During Period	μCi/ml	1.46E-06	1.36E-06	
3. F	Percent of Applicable Limit (1)	%	5.35E-05	5.00E-05	
C. Disso	olved and Entrained Gases				
1. T	otal Release	Ci	ND	ND	N/A
2. A	Average Diluted Concentration During Period	μCi/ml	ND	ND	
3. F	Percent of Applicable Limit	%	ND	ND	
D. Gross	s Alpha Radioactivity	<del>y</del>	·	,	,
1. T	otal Release	Ci	ND	ND	N/A
E. Volur	ne of Waste Release (prior to dilution)	Liters	(2)	(2)	N/A
F. Volur	ne of Dilution Water Used During Period	Liters	3.89E+06	3.89E+06	(3)

ND Not detected in liquid effluents.

(1) The percent of limit is based on the ODCM Control 3.2.2 limiting dose (1.5 mrem/quarter to the total body) from liquid effluents and is related to the abnormal leakage of tritiated plant water into the underground environment.

The percent of the concentration limits specified in Appendix B to 10CFR20.1001 – 20.2402, Table 2, Column 2 (ODCM Control 3. 2.1) were estimated to be 0.17%, 0.17%, 0.15%, and 0.14% for the first, second, third, and fourth quarters, respectively.

- (2) Leakage of contaminated plant water to subsurface areas was stopped in February 2010. The release of contaminated ground water to the Connecticut River is based on site boundary monitoring well data collected during 2015.
- (3) Dilution due to groundwater flow through the affected subsurface plume area toward the Connecticut River was estimated to be 7.83 gpm (or 3.89E+06 liters per quarter) during 2015. An Estimated Total Error is not applicable.

#### TABLE 2B

# Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Liquid Effluents - Routine Releases

		Continuo	Continuous Mode		Batch Mode	
Nuclides Released	Units	Quarter 1	Quarter 2	Quarter 1	Quarter 2	
······································						
Strontium-89	Ci		_			
Strontium-90	Ci	_ =	-	-		
Cesium-134	Çi	<u>-</u>	-		_	
Cesium-137	Ci	<u>-</u>	- "			
lodine-131	Ci	-		<u>-</u>		
Oakak CO			<u> </u>		<u> </u>	
Cobalt-58	Ci	<u>-</u>	-	-	<u>-</u>	
Cobalt-60	Ci	-	<u>-</u>	<del></del>	-	
Iron-59	Ci	-	-	-	-	
Zinc-65	Ci	-	-	-		
Manganese-54	Ci	-			-	
Zirconium-Niobium-95	. Ci	_	_	-	_	
Molybdenum-99	Ci	-	-	<b>.</b>	-	
Technetium-99	Ci	_	-	-	-	
Barium-Lanthanum-140	Ci	_	-	-	_	
Cerium-141						
011 ( 15)		i	<u> </u>		I · · · · · · · · · · · · · · · · · · ·	
Other (specify)	, Ci	<del></del>	-			
<del> </del>	Ci		<u>-</u>	-	-	
11.11.15	Ci	-	-	<del>-</del>	<del></del>	
Unidentified	Ci	-		<del>-</del>	<u>-</u>	
Total for Period (above)	Ci	<u>-</u>	-		-	
Xe-133	Ci	_	-		_	
Xe-135	Ci	-	_	1	-	

ND Not detected in liquid effluents.Dash indicates no release of this type.

## TABLE 2B (Continued)

#### Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Liquid Effluents - Routine Releases

		Continuous Mode		Batch Mode	
Nuclides Released	Units	Quarter 3	Quarter 4	Quarter 3	Quarter 4
		1			
Strontium-89	Ci	-	-	-	-
Strontium-90	Ci	<del>-</del>	<del></del>		<del>-</del>
Cesium-134	Ci	<u> </u>	-	<u>-</u>	<u>-</u>
Cesium-137	Ci			<u>-</u>	-
lodine-131	. Ci	-	-		- A1
Cobalt-58	Ci			<u> </u>	<del></del>
Cobalt-60	Ci		-	-	_
Iron-59	Ci	-	-	<b></b>	-
Zinc-65	Ci		-	_	-
Manganese-54	Ci		-	<u>-</u>	_
Zirconium-Niobium-95	Ci	-	•	1	-
Molybdenum-99	Ci	_	4		-
Technetium-99	Ci		-	-	-
Barium-Lanthanum-140	Ci		-	<u>-</u>	-
Cerium-141					
	r	1	•		
Other (specify)	Ci	-	, <b>-</b>	-	-
	Ci	-	-	-	-
,	Ci	-	-		-
Unidentified	Ci			<u>.</u> .	-
Total for Period (above)	Ci	<u> </u>	_	· <u>-</u>	_
Total to Fellou (above)		·		<u> </u>	<u> </u>
Xe-133	Ci	vi	-	-	-
Xe-135	Ci	_	-	-	-

ND Not detected in liquid effluents.Dash indicates no release of this type.

#### TABLE 3

#### Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Solid Waste and Irradiated Fuel Shipments

Table-3

Entergy Nuclear Vermont Yankeo

Effluent and Wasto Disposal Annual Report

First and Second Quarters for 2015

Solld Waste and Irrodiated Fuel Shipments

#### A. Solid Waste Shipped ON-Site for Burial or Disposal (not irradiated fuel)

1. Type of Waste		Guardine 1 & 2	
Alleged Proce VY Services III	1998	-	to local from to
n Spena rosina, lifter chalges, orc	m)	4.845+00	±25%
	C	1.096-01	.175%
> Dry Compressible water, equipment, etc.	mi	Hone	N/A
	CI	None	N/A
c. bradused components, control ruds, etc.	m)	None	N/A
	CI	None	. N/A.
d (0.5es (0.4)	m3	Hone	R/A
	<u> a</u>	None	N/A.
Saran pod Fransk Processor Porton Burlish	The state of	Courters 1 & 7.	Lat Total trigit %
a. Specia serina, filter sludges, ptc.	m3	Nose	N/Á
	a	None	N/A
b Dry Cornyretsfolmwasie, equipment.etc	rn3	10+360.6	±25%
	Ci Ci	6.758-02	125%
C. Stradigued exceptions has temperate pely, vic.	m3	Mone	N/A
	Ö.	None	N/A
d Gifter (CIV)	m3	4.70E+03	125%
	a	7.00E-08	±25%

2. Estimate of Major Nuclide Composition (By Type of Waste)

anternes tills falsty		to Dry Compressible yea	***************************************	CUTANA PROPERTY OF STREET		S Ditter tweete	T
Nutido	Percent (1)	Nuclide	Percent (1)	Nuclide	Percent (2)	Nuclide	Percent (1
Carbon 14	0.33%	Cobsit-58	1,25%	None		Cobalt-60	3%
Cobalt-18	7.09%	Cobalt 60	51.33%			Cesium 533	3%
Cobett 60	80,46%	Chromium-S1	1.73%			Tinc-68	94%
Cranum-137	30.19%	Cessure-137	0.17%				
Manganese-54	g.40%	kon-55	. 76.51%		L		
Nickel 63	0.25%	tron 5.9	2.59%				
Antimony-124	2,39%	Manganere-54	5.04%		L		
Zme-65	11.16%	Nichlum-95	0,20%				
		Model-63	1.14%				
		Anikaony 174	0.19%		,		
		Antimoty-125	0.67%				
		Line-65	9.57%				
						• .	
					·	· · · · · · · · · · · · · · · · · · ·	

[1] includes only those nucleus that are greater than 0.1% of the total activity

				·
From VI	From Pracestor	Mode	To Provessor	To Borue
×		Truck	ES BCO, TN	
<u> </u>		Fruck	ES GR, TN	
X		Truck		WCS (CWF)
	X	7 nick		Clive LT
	1			
			X Truck X Indek X Indek	From VT   From Fracesson   Mode   SETO Processon   X   Truck   ES BCO, TN   X   Truck   CS GR, TN   Truck   Truck   CS GR, TN   Truck   Truck

6. tradiated Fuel Shipments (Disposition): None

C. Additional Oats (1st & End Quarters)

1	Specification Aront or Absorbert Used	Pone	nene .	93.00
	Type of Containers Used	690, tope 6	60C,7yp+A	GOC, Type A
1	Class of Solid Waste Shipped	AU	AU .	AU
-	Supplemental information	W to inocessor	VV to Both	hardian album

GR + Guilaber Boad BCD a Bear Creek Operations WCS+ Watte Control Specialists ES + Frency Solutions GDC + General Design Container

#### TABLE 3 (continued)

### Entergy Nuclear Vermont Yankee Effluent and Waste Disposal Annual Report for 2015 Solid Waste and Irradiated Fuel Shipments

Table-3
Entergy Nuclear Vermont Yankee
Effluent and Waste Disposal Annual Report
Third and Foorth Quarters for 2015 Solid Waste and Irradiated Fuel Shipments

#### A. Solid Waste Shipped Off-Site for Burisl or Disposal (not irradiated fuel)

Shipped from VV for Build it	Unit 1	Queners 3 & 4	Est Total Error %
a Speni reuns, filter sludges, etc.	m3	1.456+01	±25%
	CI	3 006+01	±75%
b. Dry Compressible waste, equipment, étc.	m3	None	N/A
	a	None	H/A
e irradiated components, control rods, etc.	m3	Nose	N/A
	O	None	N/A
d Other (OI)	m3:	None	N/A
	<u> </u>	None	H/A
Shipped from Protessoris) for Burisl	- Tunit	Quarters 3 & 4	Est, Total Error Is
a Sornt reson, litter skidges, etc	m3	None	N/A
	· a	None	N/A
b. Dry Comprissible waste, equipment, etc.	m3	2.80E+03	1/5%
	CI	9.328-02	225%
g. Bradisted components, control rods, etc.	m3	None	N/A
	а	None	N/A
d Other (GB)	m3	2.35F101	£25%

2. Estimate of Major Nuclide Composition (By Type of Waste)

Nuclide	Percent (1)	Nuclide	Percent (1)	Nuclide .	Percent (1)	Nuclide	Percent (1)
Carbon-14	3.79%	Cobalt-58	1.33%	None		Coball-60	30.58%
Cobalt 58	0.93%	Cubati 60	52.75%	<u> L</u>		Cestum-137	20.05%
Cohall-60	39.11%	Chromhim-51	1.32%	<u> </u>		Manganese-\$4	531%
Cosium-137	3.02%	Cesium-137	0.20%			2nc 65	43 26%
tron-55	18.95%	krom-55	29 74%				
Manganose-54	2.13%	fron-19	0.23%	L			
Nichel-63	23.82%	Manganese-54	2.10%				
Zec 65	10.14%	Mobium-93	0.27%				
	<u> </u>	Hickel-63	1.28%		<u> </u>		
		Antimony-124	0.20%		<u> </u>		
		Antimony-125	0.75%				
		Znc-65	9.80%				
					1		

[1] includes only those nuclides that are greater than U.1% of the total activity

3. Orsposition of Solid V	Disposition of Solid Waste Shipments (3rd& 4th Quarters)							
No. of Shipments.	From VY	From Processor	. /Wede	To Processor	To Burial			
7	×		Truck	ES-BCO, TN				
3	X		Fruck		Wcs (CWF)			
3		×	Truck		Dive UT			
<u> </u>								

B. Irradiated Fuel Shipments (Disposition): None

C. Additional Data (Sed& 4th Quarters)

So	rid Festion Agent or Absorbent Used	hótia	กษาย	pong.
5	pe of Containers Used	GOC Type A	GOC. Type A	GOL Type A
a	ess of Sord Waste Shipped	AU	AU	AU
s	ppemental Information	VV to Processor	W to Botal	Processors to the half

GR = Gallaher Road 8CO > Bear Ceech Operations WCS= Waste Control Specialists 55 > Energy Solutions GDC = Gameral Design Container

#### **TABLE 4A**

# Entergy Nuclear Vermont Yankee Maximum\* Quarterly and Annual Off-Site Doses from Direct Radiation and Liquid and Gaseous Effluents for 2015 (10CFR50, Appendix I)

	Dose (mrem) <sup>(a)</sup>							
Source	1 <sup>st</sup> Quarter	2 <sup>nd</sup> Quarter	3 <sup>rd</sup> Quarter	4 <sup>th</sup> Quarter	Year(b)			
	Liquid Effluents							
Total Body Dose	9.80E-07	1.00E-06	8.88E-07	8.31E-07	3.70E-06			
Footnotes	(c)	(c)	(c)	(c)	(c)			
Organ Dose	9.80E-07	1.00E-06	8.88E-07	8.31E-07	3.70E-06			
Footnotes	(c)	(c)	(c)	(c)	(c)			
	Ai	rborne Efflu	ents :					
Iodines, H-3, C-14, and Particulates	2.18E-05	1.64E-05	4.24E-05	2.67E-05	1.07E-04			
Footnotes	(f)	(g)	(f)	(f)				
		Noble Gase	S					
Beta Air (mrad)								
Footnotes	(d)	(d)	(d)	(d)				
Gamma Air (mrad)								
Footnotes	(d)	(d)	(d)	(d)				
		irect Radiat	ion					
	0.71	0.72	0.72	0.72	2.88 (e)			

- \* "Maximum" means the largest fraction of the corresponding 10CFR50, Appendix I dose design objective.
- (a) The lettered footnotes indicate the age group, organ, and location of the dose receptor, where appropriate.
- (b) The yearly dose is the sum of the doses for each quarter, or a full annual assessment.
- (c) The critical age group/organ for the Maximum Exposed Individual (MEI) is the Adult/Total Body and all organs (except Bone) from the release of H-3 to groundwater.
- (d) There were no noble gas releases in this quarter.
- (e) Maximum direct dose point located on the old west site boundary, approximately 208 meters from the Turbine Building (per ODCM, Rev. 35, Sect. 6.11.1).
- (f) The critical age group/organ for the MEI is the Child/all organs (except Bone), at a location WNW, 2400 meters from the stack.
- (g) The critical age group/organ for the MEI is the Child/all organs (except Bone), at a location NW, 2900 meters from the stack.

#### **TABLE 4B**

# Entergy Nuclear Vermont Yankee Maximum\* Annual Off-Site Doses from Direct Radiation and Liquid and Gaseous Effluents for 2015 (40CFR190)

Pathway	Total Body (mrem)	Maximum Organ (mrem)	Thyroid (mrem)
Direct External (a) (b)	2.88	2.88	2.88
Liquids (c)	3.70E-06	3.70E-06	3.70E-06
Gases (c)'	1.07E-04	1.07E-04	1.07E-04
Annual Total (d)	2.88	2.88	2.88

- \* The location of the projected maximum individual doses from combined direct radiation plus liquid and gaseous effluents correspond to residences at the southwest boundary relative to the Turbine Hall.
- (a) No residential shielding credit or occupancy time fraction (i.e., occupancy is assumed to be 100%) is used. Expected direct external radiation doses would be reduced by approximately 54% with a realistic residential shielding credit and occupancy time (i.e., by using a 0.7 shielding factor from Regulatory Guide 1.109 (Reference 2) and an annual occupancy time of 6760 hours).
- (b) The direct dose reported here was calculated using the current ODCM methodology and represents the dose to the former nearest residence, which was located in the South sector at 385 meters from the stack prior to the vacancy of this residence in 2008 and the purchase of land by Vermont Yankee.
- (c) Maximum dose to any organ over all age groups for each release.
- (d) Annual dose limits contained in 40 CFR Part 190 are 25 mrem to the total body and any organ, and 75 mrem to the thyroid for any real member of the public.

Receptor Locations

### Receptor Locations Entergy Nuclear Vermont Yankee

**TABLE 4C** 

Sector	Site Boundary (1) (meters)	Nearest Resident <sup>(2)</sup> (meters)	Nearest Milk Animal <sup>(2)</sup> (meters)
N	400	1400	<del></del>
NNE	350	1384	5520 (cows)
NE	350	1255	<u></u>
ENE	400	966	
Е	500	933	
ESE	700	1915	<b></b>
SÈ	750	1963	3600 (cows)
SSE	850	2044	
S	385	644	
SSW	300	451	
SW	250	418	<del></del>
WSW	250	451	9730 (cows)
W	300	628	820 (cows)
WNW	400	1062	
NW	550	2253	
NNW	550	1738	

<sup>(1)</sup> Site boundary locations taken from Table 6.10.2 of the ODCM.

The location(s) given are based on information from the Vermont Yankee 2015 Land Use Census and Table 7.1 of the ODCM and are relative to the plant stack. Gardens are assumed to be present at all resident locations.

TABLE 4D

Usage Factors for Environmental Pathways
Entergy Nuclear Vermont Yankee\*

Age Group	Fish (kg/yr)	Potable Water (l/yr)	Veg. (kg/yr)	Leafy Veg. (kg/yr)	Milk (l/yr)	Meat (kg/yr)	Inhalation (m³/yr)
Adult	21	730	520	64	310	110	8,000
Teen	16	510	630	42	400	65	8,000
Child	6.9	510	520	26	330	41	3,700
Infant	0	330	0	0	330	0	1,400

<sup>\*</sup> Regulatory Guide 1.109, Table E-5 (Reference 2).

TABLE 4E

Environmental Parameters for Gaseous Effluents \*

Entergy Nuclear Vermont Yankee

	,	Vege	etables	Cow 1	Milk	Goat	Milk	Meat		
	Variable	Stored	Leafy	Pasture	Stored	Pasture	Stored	Pasture	Stored	
YV	Agricultural Productivity (kg/m²)	2	2	0.70	2	0.70	2	0.70	2	
P	Soil Surface Density (kg/m²)	240	240	240	240	240	240	240	240	
T	Transport Time to User (hrs)			48	48	48	48	480	480	
ТВ	Soil Exposure Time <sup>(a)</sup> (hrs)	131,400	131,400	131,400	131,400	131,400	131,400	131,400	131,400	
TE	Crop Exposure Time to Plume (hrs)	1,440	1,440	720	1,440	720	1,440	720	1,440	
TH	Holdup After Harvest (hrs)	1,440	24	0	2,160	0	2,160	0	2,160	
QF	Animals Daily Feed (kg/day)		14	50	50	6	6 4	50	50	
FP	Fraction of Year on Pasture			(b)		(b)		(b)		
FS	Fraction Pasture Feed When on Pasture <sup>(c)</sup>			1		1		1		

Note: Footnotes on following page.

#### TABLE 4E (Continued)

#### Environmental Parameters for Gaseous Effluents Entergy Nuclear Vermont Yankee

		Vege	etables	Cow	Milk	Goat	Milk	Meat		
	Variable	Stored	Leafy	Pasture	Stored	Pasture	Stored	Pasture	Stored	
FG	Fraction of Stored Vegetables Grown in Garden	0.76								
FL	Fraction of Leafy Vegetables Grown in Garden		1.0		1					
FI	Fraction Elemental Iodine = 0.5									
Н	Absolute Humidity = $5.6^{(d)}$							,		

- \* From VY ODCM, Table 6.9.1 (Reference 1).
- (a) For Method II dose/dose rate analyses of identified radioactivity releases of less than one year, the soil exposure time for that release may be set at 8,760 hours (one year) for all pathways.
- (b) For Method II dose/dose rate analyses performed for releases occurring during the first or fourth calendar quarters, the fraction of time animals are assumed to be on pasture is zero (non-growing season). For the second and third calendar quarters, the fraction of time on pasture (FP) will be set at 1.0. FP may also be adjusted for specific farm locations if this information is so identified and reported as part of the land use census.
- (c) For Method II analyses, the fraction of pasture feed while on pasture may be set to less than 1.0 for specific farm locations if this information is so identified and reported as part of the land use census.
- (d) For all Method II analyses, an absolute humidity value equal to 5.6 (gm/m<sup>3</sup>) shall be used to reflect conditions in the Northeast (Reference: Health Physics Journal, Volume 39 (August), 1980; Pages 318-320, Pergammon Press).

TABLE 4F

Environmental Parameters for Liquid Releases (Tritium) Via Groundwater
Entergy Nuclear Vermont Yankee

Variable	Potable Water	Aquatic Food	Stored Veg.	Leafy Veg.	Meat	Cow Milk
Name (Units)	Totable Water	Aquatic 1 ood	Biolog vog.	Leary veg.	Wicat	COW WHIK
Mixing Ratio	3.23E-06	5.62E-04	3.23E-06	3.23E-06	3.23E-06	3.23E-06
Transit Time (hrs)*	12	24	0	0	0	0 .
Water Uptake** (animal) (L/day)					50.0	60.0
Feed Uptake** (animal) (kg/day)		-			50.0	50.0

<sup>\*</sup> Values are from Regulatory Guide 1.109, Table E-15 (Reference 2)

<sup>\*\*</sup> Values are from Regulatory Guide 1.109, Table E-3 (Reference 2)

TABLE 5A

35.0 FT WIND DATA STA

STABILITY CLASS A

CLASS FREQUENCY (PERCENT) = 1.15

SPEED MPH	N	NNE	NE	ENE	Е	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	MNM	VRBL	TOTAL
CALM (1) (2)	4 4.00 .05	0 .00 .00	0 .00 .00	0 .00 .00	.00	.00 .00	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	.00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00	0 .00 .00	4 4.00 .05
C-3- (1) (2)	2 2.00 .02	0 .00 .00	1 1.00 .01	1.00 .01	6 6.00 .07	3 3.00 .03	2 2.00 .02	0 .00 .00	00.00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	4 4.00 .05	0 .00 .00	19 19.00 .22
4-7 (1) (2)	1 1.00 .01	1 1.00 .01	0 .00 .00	5 5.00 .06	18 18.00 .21	14 14.00 .16	3 3.00 .03	3 3.00 .03	1 1.00 .01	0 .00 .00	2 2.00 .02	0 .00 .00	1 1.00 .01	0 .00 .00	2 2.00 .02	3 3.00 .03	0 .00 .00	54 54.00 .62
8-12 (1) (2)	0 .00 .00	1 1.00 .01	0 .00 .00	.00	0 .00 .00	8.00 8.09	5 5.00 .06	3 3.00 .03	1 1.00 .01	0 .00	0 .00 .00	1 1.00 .01	0 .00 .00	0 .00 .00	00.00	3.00 .03	0 .00 .00	22 22.00 .25
13-18 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	1.00 .01	0 .00 .00	0 .00 .00	0 .00 .00	1 1.00 .01
19-24 (1) (2)	0 .00 .00	0 .00	0 .00 .00	.00	0 .00 .00	.00 .00	0 .00	0 .00 .00	.00 .00	.00 .00	.00 .00	0 .00 .00	00.00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00
GT 24 (1) (2)	.00 .00	0 .00 .00	.00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	,00 ,00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	00.00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00
ALL SPEEDS (1) (2)	7 7.00 .08	2 2.00 .02	1 1.00 .01	6.00 .07	24 24.00 .28	25 25.00 .29	10 10.00 .11	6.00 .07	2 2.00 .02	0 .00 .00	2 2.00 .02	1 1.00 .01	1 1.00 .01	1 1.00 .01	2 2.00 .02	10 10.00 .11	0 .00 .00	100 100.00 1.15

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2)=</sup>PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 5B

35.0 FT WIND DATA

STABILITY CLASS B

CLASS FREQUENCY (PERCENT) = 2.05

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	sw	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM (1) (2)	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	00.00	0. • 00 • 00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	0 .00 .00
C-3 (1) (2)	2.25 .05	5 2.81 .06	5 2.81 .06	2 1.12 .02	1 .56 .01	3 1.69 .03	.00 .00	2 1.12 .02	1 .56 .01	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	2 1.12 .02	0 .00 .00	1.12 .02	0 .00 .00	27 15.17 .31
4-7 (1) (2)	10 5.62 .11	2 1.12 .02	3 1.69 .03	6 3.37 .07	19 10.67 .22	18 10.11 .21	11 6.18 .13	15 8.43 .17	5 2.81 .06	1 .56 .01	0 .00 .00	0 .00	0 .00 .00	.56 .01	.56 .01	4 2.25 .05	.00 .00	96 53.93 1.10
8-12 (1) (2)	1.12 .02	1 .56 .01	0 .00 .00	.00 .00	0 .00 .00	1.12 .02	4 2.25 .05	17 9.55 .20	8 4.49 .09	0 .00 .00	0 .00 .00	0 .00	1.12 .02	1.12 .02	1.12 .02	5 2.81 .06	0 .00 .00	45 25.28 .52
13-18 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	2 1.12 .02	2 1.12 .02	0 .00 .00	0 .00 .00	.00	.00 .00	0 .00 .00	0 .00 .00	5 2.81 .06	0 .00 .00	5.06 .10
19-24 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	1 .56 .01	0 .00 .00	0 .00	1 .56 .01
GT 24 (1) (2)	.00 .00	0 .00 .00	0 .00 .00	.00 .00	.00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00	.00 .00	.00 .00	.00 .00	.00 .00
ALL SPEEDS (1) (2)	16 8.99 .18	8 4.49 .09	8 4.49 .09	8 4.49 .09	20 11.24 .23	23 12,92 .26	15 8.43 .17	36 20.22 .41	16 8.99 .18	1 .56 .01	0 .00 .00	0 .00	2 1.12 .02	5 2.81 .06	4 2.25 .05	16 8.99 .18	0 .00	178 100.00 2.05

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 5C

35.0 FT WIND DATA

STABILITY CLASS C

CLASS FREQUENCY (PERCENT) = 3.60

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	MNM	NW	NNW	VRBL	TOTAL
CALM (1) (2)	0 .00	1 .32 .01	0 .00	0 .00	0 .00	5 1.60 .06	0 .00	0 .00 .00	0 .00	0 .00 .00	.00	0 .00	.00	0 .00 .00	0 .00	0 .00	.00	6 1.92 .07
C-3 (1) (2)	6 1.92	5 1.60	5 1.60 .06	5 1.60	4 1.28 .05	13 4.15 .15	7 2.24 .08	4 1.28 .05	. 64 . 02	0.00	0.00	0.00	0.00	.32 .01	.64 .02	0 .00	00.00	54 17.25 .62
4-7 (1) (2)	13 4.15 .15	9 2.88 .10	4 1.28 .05	10 3.19 .11	13 4.15 .15	18 5.75 .21	25 7.99 .29	29 9.27 .33	7 2.24 .08	2 .64 .02	1 .32 /	.00	0 .00	1 .32 .01	9 2.88 .10	18 5.75 .21	0 .00 .00	159 50.80 1.83
8-12 (1) (2)	11 3.51 .13	3 .96 .03	2 .64 .02	0 .00 .00	0 .00 .00	2 .64 .02	1 .32 .01	17 5.43 .20	19 6.07 .22	2 .64 .02	0 .00 .00	00. .00	3 .96 .03	3 .96 .03	6 1.92 .07	12 3.83 .14	0 .00 .00	81 25.88 .93
13-18 (1) (2)	1 .32 .01	.00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.32 .01	.32 .01	.00 .00	0 .00 .00	0 .00 .00	1 .32 .01	0 .00 .00	3 .96 .03	6 1.92 .07	0 .00 .00	13 4.15 .15
19-24 (1) (2)	0 .00 .00	0 .00	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00	0 .00	0 .00	0 .00 .00	0 .00	0 .00	.00 .00	0 .00 .00	.00	0 .00	0 .00 .00
GT 24 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00
ALL SPEEDS (1) (2)	31 9.90 .36	18 5.75 .21	11 3.51 .13	15 4.79 .17	17 5.43 .20	38 12.14 .44	33 10.54 .38	51 16.29 .59	29 9.27 .33	4 1.28 .05	1 .32 .01	0 .00 .00	4 1.28 .05	5 1.60 .06	20 6.39 .23	36 11.50 .41	0 .00 .00	313 100.00 3.60

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 5D

35.0 FT WIND DATA

STABILITY CLASS D

CLASS FREQUENCY (PERCENT) = 46.37

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	wsw	M	WNW	MM	NNW	VRBL	TOTAL
CALM (1) (2)	26 .64 .30	19 .47 .22	21 .52 .24	31 .77 .36	49 1.21 .56	91 2.25 1.05	99 2.45 1.14	74 1.83 .85	24 .59 .28	.10 .05	4 .10 .05	5 .12 .06	4 .10 .05	1 .02 .01	7 .17 .08	27 .67 .31	0 .00 .00	486 12.04 5.58
C-3 (1) (2)	74 1.83 .85	41 1.02 .47	42 1.04 .48	31 .77 .36	55 1.36 .63	73 1.81 .84	73 1.81 .84	94 2.33 1.08	73 1.81 .84	41 1.02 .47	22 .55 .25	26. .64 .30	34 .84 .39	47 1.16 .54	63 1.56 .72	107 2.65 1.23	0 .00 .00	896 22.20 10.30
4-7 (1) (2)	120 2.97 1.38	35 .87 .40	9 .22 .10	9 .22 .10	19 .47 .22	55 1.36 .63	119 2.95 1.37	162 4.01 1.86	84 2.08 .97	26 .64 .30	22 .55 .25	28 .69 .32	62 1.54 .71	61 1.51 .70	148 3.67 1.70	244 6.05 2.80	.00 .00	1203 29.81 13.82
8-12 (1) (2)	110 2.73 1.26	19 .47 .22	.02 .01	0 .00 .00	.02 .01	10 .25 .11	8 .20 .09	89 2.21 1.02	82 2.03 .94	18 .45 .21	17 .42 .20	18 .45 .21	147 3.64 1.69	150 3.72 1.72	142 3.52 1.63	218 5.40 2.50	0 .00 .00	1030 25.52 11.84
13-18 (1) (2)	21 .52 .24	0 .00 .00	.00 .00	0 .00 .00	.00 .00	.02 .01	0 .00 .00	8 .20 .09	16 .40 .18	.05 .02	0 .00 .00	.10 .05	67 1.66 .77	80 1.98 .92	77 1.91 .88	96 2.38 1.10	0 .00 .00	372 9.22 4.27
19-24 (1) (2)	0 .00 .00	.00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	4 .10 .05	10 .25 .11	16 .40 .18	17 .42 .20	0 .00 .00	47 1.16 .54
GT 24 (1) (2)	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	.00 .00	0 .00 .00	.00 .00	2 .05 .02	.00 .00	00. 00.	2 .05 .02
ALL SPEEDS (1) (2)	351 8.70 4.03	114 2.82 1.31	73 1.81 .84	71 1.76 .82	124 3.07 1.42	230 5.70 2.64	299 7.41 3.44	427 10.58 4.91	279 6.91 3.21	91 2.25 1.05	65 1.61 .75	81 2.01 .93	318 7.88 3.65	349 8.65 4.01	455 11.27 5.23	709 17.57 8.15	0 .00 .00	4036 100.00 46.37

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2)=</sup>PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 5E

35.0 FT WIND DATA

STABILITY CLASS E

CLASS FREQUENCY (PERCENT) = 28.16

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	MM	NNW	VRBL	TOTAL
CALM (1) (2)	30 1.22 .34	- 18 .73 .21	12 .49 .14	12 .49 .14	10 .41 .11	21 .86 .24	64 2.61 .74	74 3.02 .85	41 1.67 .47	32 1.31 .37	30 1.22 .34	13 .53 .15	11 .45 .13	16 .65 .18	17 .69 .20	25 1.02 .29	0 .00 .00	426 17.38 4.89
C-3 (1) (2)	30 1.22 .34	25 1.02 .29	12 .49 .14	14 .57 .16	21 .86 .24	31 1.26 .36	44 1.80 .51	77 3.14 .88	79 3.22 .91	110 4.49 1.26	170 6.94 1.95	145 5.92 1.67	135 5.51 1.55	92 3.75 1.06	104 4.24 1.19	60 2.45 .69	0 .00 .00	1149 46.88 13.20
4-7 (1) (2)	40 1.63 .46	8 .33 .09	.04 .01	0 .00 .00	.12 .03	.33 .09	34 1.39 .39	53 2.16 .61	28 1.14 .32	.20 .06	14 .57 .16	43 1.75 .49	80 3.26 .92	59 2.41 .68	84 3.43 .97	133 5.43 1.53	0 .00 .00	593 24.19 6.81
8-12 (1) (2)	14 .57 .16	1 .04 .01	.00 .00	.00 .00	.00 .00	.00 .00	.04 .01	16 .65 .18	21 .86 .24	.08 .02	1 .04 .01	3 .12 .03	4.6 1.88 .53	36 1.47 .41	20 .82 .23	52 2.12 .60	0 .00 .00	213 8.69 2.45
13-18 (1) (2)	.16 .05	0 .00 .00	.00	.00	0 .00 .00	0 .00 .00	.00	1 .04 .01	.04 .01	00.00	.04 .01	0 .00 .00	9 .37 .10	24 .98 .28	.16 .05	21 .86 .24	0 .00 .00	65 2.65 .75
19-24 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	.00 .00	0 .00 .00	.00 .00	.00	0 .00 .00	.00 .00	0 .00 .00	.08 .02	0 .00 .00	0 .00 .00	3 .12 .03	0 .00 .00	.20 .06
GT 24 (1) (2)	.00 .00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00
ALL SPEEDS (1) (2)	118 4.81 1.36	52 2.12 .60	25 1.02 .29	26 1.06 .30	34 1.39 .39	60 2.45 .69	143 5.83 1.64	221 9.02 2.54	170 6.94 1.95	149 6.08 1.71	216 8.81 2.48	204 8.32 2.34	283 11.55 3.25	227 9.26 2.61	229 9.34 2.63	294 12.00 3.38	0 .00	2451 100.00 28.16

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 5F

VERMONT YANKEE JAN 15 - DEC 15 METEOROLOGICAL DATA JOINT FREQUENCY DISTRIBUTION

35.0 FT WIND DATA

STABILITY CLASS F

CLASS FREQUENCY (PERCENT) = 14.03

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	. WSW	W.	WNW	ИM	NNW	VRBL	TOTAL
CALM (1) (2)	5 .41 .06	7 .57 .08	5 .41 .06	5 .41 .06	6 .49 .07	12 .98 .14	16 1.31 .18	17 1.39 .20	28 2.29 .32	49 4.01 .56	31 2.54 .36	26 2.13 .30	10 .82 .11	11 .90 .13	13 1.06 .15	22 1.80 .25	0 .00 .00	263 21.54 3.02
C-3 (1) (2)	16 1.31 .18	5 .41 .06	5 .41 .06	2 .16 .02	6 .49 .07	8 .66 .09	15 1.23 .17	27 2.21 .31	53 4.34 .61	84 6.88 .97	195 15.97 2.24	173 14.17 1.99	116 9.50 1.33	76 6.22 .87	40 3.28 .46	20 1.64 .23	0 .00 .00	841 68.88 9.66
4-7 (1) (2)	.33 .05	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.08 .01	3 .25 .03	5 .41 .06	3 .25 .03	12 .98 .14	11 .90 .13	12 .98 .14	14 1.15 .16	17 1.39 .20	15 1.23 .17	17 1.39 .20	0 .00 .00	114 9.34 1.31
8-12 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.08 .01	2 .16 .02	0 .00 .00	3 .25 .03
13-18 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00
19-24 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	. 0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00
GT 24 (1) (2)	.00 .00	.00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	.00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	.00 .00
ALL SPEEDS (1) (2)	25 2.05 .29	12 .98 .14	10 .82 .11	7 .57 .08	12 .98 .14	21 1.72 .24	34 2.78 .39	49 4.01 .56	84 6.88 .97	145 11.88 1.67	237 19.41 2.72	211 17.28 2.42	140 11.47 1.61	104 8.52 1.19	69 5.65 .79	61 5.00 .70	0 .00 .00	1221 100.00 14.03

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 5G

STABILITY CLASS G

#### WIND DIRECTION FROM

CLASS FREQUENCY (PERCENT) = 4.64

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM (1) (2)	6 1.49 .07	10 2.48 .11	.99 .05	1 .25 .01	5 1.24 .06	9 2.23 .10	10 2.48 .11	10 2.48 .11	22 5.45 .25	19 4.70 .22	7 1.73 .08	7 1.73 .08	.99 .05	7 1.73 .08	6 1.49 .07	5 1.24 .06	0 .00 .00	132 32.67 1.52
C-3 (1) (2)	5 1.24 .06	.50 .02	.99 .05	.50 .02	7 1.73 .08	7 1.73 .08	5 1.24 .06	13 3.22 .15	12 2.97 .14	29 7.18 .33	32 7.92 .37	44 10.89 .51	30 7.43 .34	24 5.94 .28	13 3.22 .15	8 1.98 .09	0 .00 .00	237 58.66 2.72
4-7 (1) (2)	1 .25 .01	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	1 .25 .01	0 .00 .00	1 .25 .01	1 .25 .01	5 1.24 .06	4 .99 .05	1 .25 .01	8 1.98 .09	3 .74 .03	5 1.24 .06	5 1.24 .06	0 .00 .00	35 8.66 .40
8-12 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	.00 .00	0 .00 .00	.00 .00
13-18 (1) (2)	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00
19-24 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00
GT 24 (1) (2)	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00	.00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	.00 .00	0 .00 .00	0 .00 .00
ALL SPEEDS (1) (2)	12 2.97 .14	12 2.97 .14	8 1.98 .09	3 .74 .03	12 2.97 .14	17 4.21 .20	15 3.71 .17	24 5.94 .28	35 8.66 .40	53 13.12 .61	43 10.64 .49	52 12.87 .60	10.40 .48	34 8.42 .39	24 5.94 .28	18 4.46 .21	0 .00 .00	404 100.00 4.64

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

35.0 FT WIND DATA

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 5H

VERMONT YANKEE JAN 15 - DEC 15 METEOROLOGICAL DATA JOINT FREQUENCY DISTRIBUTION

STABILITY CLASS ALL

WIND DIRECTION FROM

CLASS FREQUENCY (PERCENT) = 100.00

SPEED MPH	N	NNE	NE	ENE	Е	ESE	SE	SSE	s	SSW	SW ·	wsw	W	WNW	MM	WNN	VRBL	TOTAL
CALM (1) (2)	71 .82 .82	55 .63 .63	42 .48 .48	49 .56 .56	70 .80 .80	138 1.59 1.59	189 2.17 2.17	175 2.01 2.01	115 1.32 1.32	104 1.19 1.19	72 .83 .83	51 .59 .59	29 .33 .33	35 .40 .40	43 .49 .49	.91 .91 91	0 .00 .00	1317 15.13 15.13
C-3 (1) (2)	137 1.57 1.57	83 .95 .95	74 .85 .85	57 .65 .65	100 1.15 1.15	138 1.59 1.59	146 1.68 1.68	217 2.49 2.49	220 2.53 2.53	264 3.03 3.03	419 4.81 4.81	388 4.46 4.46	315 3.62 3.62	242 2.78 2.78	222 2.55 2.55	201 2.31 2.31	.00	3223 37.03 37.03
4-7 (1) (2)	189 2.17 2.17	55 .63 .63	17 .20 .20	30 .34 .34	72 .83 .83	115 1.32 1.32	195 2.24 2.24	268 3.08 3.08	129 1.48 1.48	51 .59 .59	54 .62 .62	84 .97 .97	165 1.90 1.90	142 1.63 1.63	264 3.03 3.03	424 4.87 4.87	0 .00 .00	2254 25.90 25.90
8-12 (1) (2)	137 1.57 1.57	25 .29 .29	3 .03 .03	0 .00 .00	.01 .01	22 .25 .25	19 .22 .22	142 1.63 1.63	131 1.51 1.51	22 .25 .25	18 .21 .21	22 .25 .25	198 2.28 2.28	191 2.19 2.19	171 1.96 1.96	292 3.36 3.36	0 .00 .00	1394 16.02 16.02
13-18 (1) (2)	26 .30 .30	0 .00 .00	.00 .00	0 .00 .00	.00 .00	.01 .01	0 .00 .00	12 .14 .14	20 .23 .23	.02 .02	.01 .01	.05 .05	77 .88 .88	105 1.21 1.21	84 .97 .97	128 1.47 1.47	0 .00 .00	460 5.29 5.29
19-24 (1) (2)	0 .00 .00	.00 .00	0 .00 .00	.00	0 .00 .00	6 .07 .07	10 .11 .11	17 .20 .20	20 .23 .23	0 .00 .00	53 .61 .61							
GT 24 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	.00 .00	.00 .00	0 .00 .00	.02 .02	0 .00 .00	0 .00 .00	.02 .02
ALL SPEEDS (1) (2)	560 6.43 6.43	218 2.50 2.50	136 1.56 1.56	136 1.56 1.56	243 2.79 2.79	414 4.76 4.76	549 6.31 6.31	814 9.35 9.35	615 7.07 7.07	443 5.09 5.09	564 6.48 6.48	549 6.31 6.31	790 9.08 9.08	725 8.33 8.33		1144 13.14 13.14	0 .00 .00	8703 100.00 100.00

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

35.0 FT WIND DATA

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 6A

297.0 FT WIND DATA STA

STABILITY CLASS A

CLASS FREQUENCY (PERCENT) = .32

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM (1) (2)	4 14.29 .05	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00	.00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	4 14.29 .05
C-3 (1) (2)	3.57 .01	1 3.57 .01	0 .00 .00	.00	.00 .00	3.57 .01	0 .00 .00	1 3.57 .01	1 3.57 .01	0 .00 .00	0 .00 .00	.00 .00	.00 .00	.00	3.57 .01	3.57 .01	0 .00 .00	7 25.00 .08
4-7 (1) (2)	.00 .00	0 .00	0 .00 .00	3.57 .01	0 .00 .00	0 .00 .00	5 17.86 .06	3 10.71 .03	7.14 .02	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	11 39.29 .13
8-12 (1) (2)	3.57 .01	1 3.57 .01	0 .00	0 .00 .00	0 .00	0 .00 .00	1 3.57 .01	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	3.57 .01	3.57 .01	0 .00 .00	5 17.86 .06
13-18 (1) (2)	.00 .00	0 .00 .00	0 .00	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	3.57 .01	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	1 3.57 .01
19-24 (1) (2)	0 .00 .00	.00 .00	.00	.00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	00. 00.	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00
GT 24 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	.00 .00	.00	0 .00 .00	.00 .00
ALL SPEEDS (1) (2)	6 21.43 .07	2 7.14 .02	0 .00	3.57 .01	0 .00	1 3.57 .01	6 21.43 .07	4 14.29 .05	3 10.71 .03	0 .00	0 .00 .00	0 .00	1 3.57 .01	0 .00 .00	7.14 .02	2 7.14 .02	0 .00 .00	28 100.00 .32

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 6B

VERMONT YANKEE JAN 15 - DEC 15 METEOROLOGICAL DATA JOINT FREQUENCY DISTRIBUTION

STABILITY CLASS B

WIND DIRECTION FROM

CLASS FREQUENCY (PERCENT) =

.23

SPEED MPH	N	NNE	NE	ENE	. Е	ESE	SE	SSE	s	SSW	sw	wsw	W	WNW	ИW	NNW .	VRBL	TOTAL
CALM (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00
C-3 (1) (2)	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	.00	0 .00 .00	0 .00 .00	0 .00	.00 .00	0 .00	0 .00 .00	0 .00	.00	0 .00 .00
4-7 (1) (2)	. 5.00 .01	1 5.00 .01	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	10.00 .02	.00 .00	.00 .00	0 .00 .00	0 .00 .00	.00 .00	.00 .00	0 .00 .00	5.00 .01	5.00 .01	0 .00 .00	30.00 .07
8-12 (1). (2)	3 15.00 .03	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	1 5.00 .01	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	5.00 .01	0 .00 .00	.00 .00	10.00 .02	0 .00 .00	7 35.00 .08
13-18 (1) (2)	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	1 5.00 .01	.00 .00	00.00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00	0 .00 .00	5.00 .01	20.00 .05	0 .00 .00	30.00 .07
19-24 (1) (2)	0 .00 .00	0 .00 .00	.00	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	5.00 .01	0 .00 .00	5.00 .01
GT 24 (1) (2)	.00 .00	0. .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	.00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00
ALL SPEEDS (1) (2)	20.00 .05	1 5.00 .01	0 .00 .00	0 .00 .00	0 .00	2 10.00 .02	2 10.00 .02	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	1 5.00 .01	0 .00	2 10.00 .02	8 40.00 .09	0 .00 .00	20 100.00 .23

<sup>(1)=</sup>PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

297.0 FT WIND DATA

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 6C

WIND DIRECTION OF

STABILITY CLASS C

297.0 FT WIND DATA

#### WIND DIRECTION FROM

CLASS FREQUENCY (PERCENT) = 1.59

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	wsw	. <b>W</b>	WNW	MM	WNN	VRBL	TOTAL
CALM (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	0 .00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00
C-3 (1) (2)	.72 .01	0 .00 .00	0 .00 .00	.72 .01	1 .72 .01	1 .72 .01	.72 .01	0 .00 .00	1 .72 .01	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00	1 .72 .01	0 .00 .00	7 5.07 .08
4-7 (1) (2)	3 2.17 .03	3 2.17 .03	2 1.45 .02	.72 .01	.72 .01	9 6.52 .10	5 3.62 .06	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	1 .72 .01	8 5.80 .09	.00	33 23.91 .38
8-12 (1) (2)	10 7.25 .11	2 1.45 .02	2.90 .05	2 1.45 .02	.72 .01	7 5.07 .08	5 3.62 .06	2.90 .05	0 .00 .00	0 .00 .00	0 .00 .00	.72 .01	0 .00	.3 2.17 .03	3 2.17 .03	17 12.32 .20	0 .00 .00	59 42.75 .68
13-18 (1) (2)	8 5.80 .09	2 1.45 .02	.00 .00	0 .00 .00	0 .00 .00	1 .72 .01	2 1.45 .02	.72 .01	.72 .01	0 .00 .00	0 .00 .00	0 .00 .00	.72 .01	.72 .01	1 .72 .01	10 7.25 .11	0 .00 .00	28 20.29 .32
19-24 (1) (2)	.00 .00	.00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00	.72 .01	0 .00 .00	3 2.17 .03	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	.00 .00	.00 .00	7 5.07 .08	0 .00 .00	11 7.97 .13
GT 24 (1) (2)	.00 .00	.00 .00	00. 00.	.00 .00	0 .00 .00	0 .00 .00	.00 .00	00. 00.	0 .00 .00	0 .00 .00	.00	0 .00 .00	0 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00
ALL SPEEDS (1) (2)	22 15.94 .25	7 5.07 .08	6 4.35 .07	4 2.90 .05	3 2.17 .03	18 13.04 .21	14 10.14 .16	5 3.62 .06	5 3.62 .06	0 .00 .00	0 .00 .00	.72 .01	.72 .01	2.90 .05	5 3.62 .06	43 31.16 .49	00.00	138 100.00 1.59

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 6D

297.0 FT WIND DATA

STABILITY CLASS D

CLASS FREQUENCY (PERCENT) = 52.26

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM (1) (2)	5 .11 .06	.04 .02	0 .00 .00	.02 .01	.07 .03	.04 .02	16 .35 .18	3 .07 .03	.02 .01	.02 .01	00. 00.	0 .00 .00	.02 .01	0 .00 .00	0 .00	6 .13 .07	0 .00 .00	41 .90 .47
C-3 (1) (2)	55 1.21 .63	32 .70 .37	37 .81 .43	39 .86 .45	49 1.08 .56	.46 1.01 .53	85 1.87 .98	59 1.30 .68	23 .51 .26	8 .18 .09	10 .22 .11	9 .20 .10	5 .11 .06	16 .35 .18	29 .64 .33	55 1.21 .63	0 .00 .00	557 12.25 6.40
4-7 (1) (2)	90 1.98 1.03	36 .79 .41	27 .59 .31	.48 .25	45 .99 .52	131 2.88 1.51	203 4.46 2.33	158 3.47 1.82	71 1.56 .82	19 .42 .22	14 .31 .16	14 .31 .16	17 .37 .20	19 .42 .22	64 1.41 .74	173 3.80 1.99	.00 .00	1103 24.25 12.67
8-12 (1) (2)	113 2.48 1.30	38 .84 .44	11 .24 .13	6 .13 .07	14 .31 .16	36 .79 .41	113 2.48 1.30	234 5.15 2.69	247 5.43 2.84	49 1.08 .56	28 .62 .32	36 .79 .41	109 2.40 1.25	123 2.70 1.41	68 1.50 .78	249 5.47 2.86	.00 .00	1474 32.41 16.94
13-18 (1) (2)	93 2.04 1.07	16 .35 .18	.07 .03	.02 .01	.09 .05	.20 .10	.18 .09	54 1.19 .62	134 2.95 1.54	16 .35 .18	.18 .09	8 .18 .09	134 2.95 1.54	137 3.01 1.57	109 2.40 1.25	212 4.66 2.44	.00 .00	946 20.80 10.87
19-24 (1) (2)	34 .75 .39	.07 .03	00. 00.	0 .00 .00	0 .00 .00	0 .00 .00	.02 .01	5 .11 .06	19 .42 .22	.02 .01	.02 .01	.04 .02	52 1.14 .60	52 1.14 .60	50 1.10 .57	114 2.51 1.31	.00 .00	334 7.34 3.84
GT 24 (1) (2)	.02 .01	.02 .01	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.02 .01	0 .00 .00	0 .00 .00	.04 .02	.09 .05	5 .11 .06	21 .46 .24	58 1.28 .67	0 .00 .00	93 2.04 1.07
ALL SPEEDS (1) (2)	391 8.60 4.49	128 2.81 1.47	78 1.72 .90	69 1.52 .79	115 2.53 1.32	224 4.93 2.57	426 9.37 4.89	513 11.28 5.89	496 10.91 5.70	94 2.07 1.08	61 1.34 .70	71 1.56 .82	322 7.08 3.70	352 7.74 4.04	341 7.50 3.92	867 19.06 9.96	0 .00 .00	4548 100.00 52.26

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 6E

297.0 FT WIND DATA

STABILITY CLASS E

CLASS FREQUENCY (PERCENT) = 30.52

SPEED MPH	N	NNE	NE	ENE	Е	ESE	SE	SSE	s	SSW	SW	wsw	W	MNM	NW	NNW	VRBL	TOTAL
CALM (1) (2)	3 .11 .03	4 .15 .05	.08 .02	1 .04 .01	4 .15 .05	9 .34 .10	13 .49 .15	3 .11 .03	.08 .02	.04 .01	0 .00 .00	1 .04 .01	1 .04 .01	1 .04 .01	0 .00	.08 .02	0 .00	47 1.77 .54
C-3 (1) (2)	95 3.58 1.09	73 2.75 .84	56 2.11 .64	35 1.32 .40	86 3.24 .99	91 3.43 1.05	100 3.77 1.15	51 1.92 .59	37 1.39 .43	18 .68 .21	10 .38 .11	10 .38 .11	10 .38 .11	23 .87 .26	43 1.62 .49	81 3.05 .93	0 .00 .00	819 30.84 9.41
4-7 (1) (2)	88 3.31 1.01	11 .41 .13	6 .23 .07	6 .23 .07	18 .68 .21	50 1.88 .57	172 6.48 1.98	142 5.35 1.63	35 1.32 .40	26 .98 .30	16 .60 .18	21 .79 .24	23 .87 .26	26 .98 .30	55 2.07 .63	271 10.20 3.11	0 .00 .00	966 36.37 11.10
8-12 (1) (2)	37 1.39 .43	6 .23 .07	.00 .00	0 .00 .00	.04 .01	4 .15 .05	38 1.43 .44	57 2.15 .65	63 2.37 .72	18 .68 .21	9 .34 .10	19 .72 .22	70 2.64 .80	55 2.07 .63	40 1.51 .46	191 7.19 2.19	0 .00 .00	608 22.89 6.99
13-18 (1) (2)	16 .60 .18	0 .00 .00	.00 .00	0 .00 .00	.00 .00	0 .00 .00	.04 .01	.19 .06	.83 .25	6 .23 .07	.15 .05	5 .19 .06	32 1.20 .37	24 .90 .28	9 .34 .10	64 2.41 .74	0 .00 .00	188 7.08 2.16
19-24 (1) (2)	.04 .01	0 .00 .00	.00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.08 .02	1 .04 .01	.00	.04 .01	.08 .02	7 .26 .08	1 .04 .01	10 .38 .11	0 .00 .00	25 .94 .29
GT 24 (1) (2)	0 .00 .00	0.0.0 .00	.00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	.00 .00	0 .00 .00	3 .11 .03	0 .00 .00	3 .11 .03
ALL SPEEDS (1) (2)	240 9.04 2.76	94 3.54 1.08	64 2.41 .74	42 1.58 .48	109 4.10 1.25	154 5.80 1.77	324 12.20 3.72	258 9.71 2.96	161 6.06 1.85	70 2.64 .80	39 1.47 .45	57 2.15 .65	138 5.20 1.59	136 5.12 1.56	148 5.57 1.70	622 23.42 7.15	0 .00 .00	2656 100.00 30.52

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 6F

STABILITY CLASS F

297.0 FT WIND DATA

#### WIND DIRECTION FROM

CLASS FREQUENCY (PERCENT) = 12.57

SPEED MPH	Ŋ	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	MNM	NW	NNW	VRBL	TOTAL
CALM (1) (2)	2 .18 .02	1 .09 .01	0 .00 .00	.09 .01	3 .27 .03	3 .27 .03	2 .18 .02	.00 .00	1 .09 .01	1 .09 .01	.09 .01	0 .00 .00	0 .00 .00	0 .00 .00	1 .09 .01	.09 .01	0 .00	17 1.55 .20
C-3 (1) (2)	40 3.66 .46	29 2.65 .33	37 3.38 .43	22 2.01 .25	29 2.65 .33	39 3.56 .45	43 3.93 .49	42 3.84 .48	20 1.83 .23	22 2.01 .25	13 1.19 .15	5 .46 .06	14 1.28 .16	9 .82 .10	24 2.19 .28	40 ; 3.66 .46	.00 .00	428 39.12 4.92
4-7 (1) (2)	35 3.20 .40	5 .46 .06	0 .00 .00	6 .55 .07	13 1.19 .15	28 2.56 .32	95 8.68 1.09	62 5.67 .71	34 3.11 .39	8 .73 .09	19 1.74 .22	15 1.37 .17	16 1.46 .18	14 1.28 .16	37 3.38 .43	94 8.59 1.08	.00 .00	481 43.97 5.53
8-12 (1) (2)	.37 .05	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	6 .55 .07	21 1.92 .24	15 1.37 .17	12 1.10 .14	8 .73 .09	3 .27 .03	.82 .10	13 1.19 .15	14 1.28 .16	7 .64 .08	46 4.20 .53	0 .00 .00	158 14.44 1.82
13-18 (1) (2)	.09 .01	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.09 .01	.00 .00	0 .00 .00	.00 .00	3 .27 .03	0 .00 .00	0 .00 .00	5 .46 .06	0 .00 .00	10 .91 .11
19-24 (1) (2)	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	.00	.00 .00						
GT 24 (1) (2)	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	0 .00 .00	0 .00 .00	.00	.00 .00	00. 00.	.00 .00
ALL SPEEDS (1) (2)	82 7.50 .94	35 3.20 .40	37 3.38 .43	29 2.65 .33	45 4.11 .52	76 6.95 .87	161 14.72 1.85	119 10.88 1.37	68 6.22 .78	39 3.56 .45	36 3.29 .41	29 2.65 .33	46 4.20 .53	37 3.38 .43	69 6.31 .79	186 17.00 2.14	0 .00 .00	1094 100.00 12.57

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 6G

297.0 -FT WIND DATA

STABILITY CLASS G

CLASS FREQUENCY (PERCENT) = 2.52

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM (1) (2)	0 .00 .00	.00	0 .00 .00	0 .00 .00	1 .46 .01	0 .00 .00	0 .00	0 .00 .00	1 .46 .01	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00	2 .91 .02
C-3 (1) (2)	4 1.83 .05	2 .91 .02	.91 .02	4 1.83 .05	.91 .02	4 1.83 .05	6 2.74 .07	8 3.65 .09	4 1.83 .05	1 .46 .01	4 1.83 .05	7 3.20 .08	3 1.37 .03	3 1.37 .03	9 4.11 .10	6 2.74 .07	0 .00 .00	69 31.51 .79
4-7 · (1) (2)	3 1.37 .03	0 .00 .00	1 .46 .01	1 .46 .01	3 1.37 .03	3 1.37 .03	12 5.48 .14	13 5.94 .15	9 4.11 .10	8 3.65 .09	5 2.28 .06	9 4.11 .10	6 2.74 .07	5 2.28 .06	9 4.11 .10	8 3.65 .09	.00 .00	95 43.38 1.09
8-12 (1) (2)	1 .46 .01	0 .00	.00	0 .00 .00	.00 .00	.00 .00	1 .46 .01	4 1.83 .05	.91 .02	.91 .02	6 2.74 .07	9 4.11 .10	10 4.57 .11	8 3.65 .09	4 1.83 .05	4 1.83 .05	.00 .00	51 23.29 .59
13-18· (1) (2)	00.00	0 .00 .00	.00 .00	0 .00 .00	00.00	.00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00	.46 .01	.46 .01	0 .00 .00	0 .00 .00	0 .00 .00	.91 .02
19-24 (1) (2)	.00 .00	0 .00	.00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	.00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	.00 .00
GT 24 (1) (2)	.00 .00	0 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0. .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00 .00	0 .00 .00	.00 .00
ALL SPEEDS (1) (2)	8 3.65 .09	.91 .02	3 1.37 .03	5 2.28 .06	6 2.74 .07	7 3.20 .08	19 8.68 .22	25 11.42 .29	16 7.31 .18	11 5.02 .13	15 6.85 .17	25 11.42 .29	20 9.13 .23	17 7.76 .20	22 10.05 .25	18 8.22 .21	0 .00	219 100.00 2.52

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

TABLE 6H

297.0 FT WIND DATA

STABILITY CLASS ALL

CLASS FREQUENCY (PERCENT) = 100.00

	SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	sw	WSW	W	WNW	NW	NNW	VRBL	TOTAL
	CALM (1) (2)	14 .16 .16	7 .08 .08	.02 .02	3 .03 .03	11 .13 .13	14 .16 .16	31 .36 .36	6 .07 .07	5 .06 .06	3 .03 .03	.01 .01	.01 .01	.02 .02	.01 .01	.01 .01	9 .10 .10	0 .00 .00	111 1.28 1.28
	C-3 (1) (2)	196 2.25 2.25	137 1.57 1.57	132- 1.52 1.52	101 1.16 1.16	167 1.92 1.92	182 2.09 2.09	235 2.70 2.70	161 1.85 1.85	86 .99 .99	49 .56 .56	37 .43 43	31 .36 .36	32 .37 .37	51 .59 .59	106 1.22 1.22	184 2.11 2.11	0 .00 .00	1887 21.68 21.68
	4-7 (1) (2)	220 2.53 2.53	56 .64 .64	36 .41 .41	37 .43 .43	80 .92 .92	221 2.54 2.54	494 5.68 5.68	378 4.34 4.34	151 1.74 1.74	61 .70 .70	54 .62 .62	59 .68 .68	62 .71 .71	64 .74 .74	167 1.92 1.92	555 6.38 6.38	.00	2695 30.97 30.97
e.	8-12 (1) (2)	169 1.94 1.94	47 .54 .54	15 .17 .17	.09 .09	16 .18 .18	54 .62 .62	179 2.06 2.06	314 3.61 3.61	324 3.72 3.72	77 .88 .88	46 .53 .53	74 .85 .85	203 2.33 2.33	203 2.33 2.33	123 1.41 1.41	510 5.86 5.86	0 .00 .00	2362 27.14 27.14
	13-18 (1) (2)	118 1.36 1.36	18 .21 .21	.03 .03	.01 .01	.05 .05	11 , .13 .13	11 .13 · .13	60 .69 .69	158 1.82 1.82	22 .25 .25	12 .14 .14	13 .15 .15	172 1.98 1.98	163 1.87 1.87	120 1.38 1.38	295 3.39 3.39	0 .00 .00	1181 13.57 13.57
	19-24 (1) (2)	35 .40 .40	.03 .03	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.02 .02	5 .06 .06	24 .28 .28	.02 .02	.01 .01	.03 .03	54 .62 .62	59 .68 .68	51 .59 .59	132 1.52 1.52	0 .00 .00	371 4.26 4.26
	GT 24 (1) (2)	1 .01 .01	.01 .01	0 .00 .00	0 .00 .00	0 .00 .00	0 .00 .00	.00	.00 .00	.01 .01	0 .00 .00	0 .00 .00	.02 .02	4 .05 .05	5 .06 .06	21 .24 .24	61 .70 .70	.00 .00	96 1.10 1.10
ALL	SPEEDS (1) (2)	753 8.65 8.65	269 3.09 3.09	188 2.16 2.16	150 1.72 1.72	278 3.19 3.19		952 10.94 10.94	924 10.62 10.62	749 8.61 8.61	214 2.46 2.46	151 1.74 1.74	183 2.10 2.10	529 6.08 6.08	546 6.27 6.27		1746 20.06 20.06	00. 00.	8703 100.00 100.00

<sup>(1) =</sup> PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

<sup>(2)=</sup>PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

## APPENDIX A

## SUPPLEMENTAL INFORMATION

Facility: Vermont Yankee Nuclear Power Station

Licensee: Entergy Nuclear Vermont Yankee

2A.

b.

# 1A. ODCM DOSE AND DOSE RATE LIMITS -

	ODCM Controls	Dose Limit	
a.	Noble Gases	·	
	3/4.3.1 Total body dose rate 3/4.3.1 Skin dose rate 3/4.3.2 Gamma air dose 3/4.3.2 Gamma air dose 3/4.3.2 Beta air dose 3/4.3.2 Beta air dose	500 mrem/yr 3000 mrem/yr 5 mrad in a quarter 10 mrad in a year 10 mrad in a quarter 20 mrad in a year	
b.	<u>Iodine-131, Iodine-133, Tritium and Radionuclides in Particulate Form With Half-Lives Greater Than 8 Days</u>		
c.	3/4.3.1 Organ dose rate 3/4.3.3 Organ dose 3/4.3.3 Organ dose Liquids	1500 mrem/yr 7.5 mrem in a quarter 15 mrem in a year	
	3/4.2.2 Total body dose 3/4.2.2 Total body dose 3/4.2.2 Organ dose 3/4.2.2 Organ dose	1.5 mrem in a quarter 3 mrem in a year 5 mrem in a quarter 10 mrem in a year	
ODCM LIMITS - CONCENTRATION			
	ODCM Control	<u>Limit</u>	
á.	Noble Gases	No ECL Limits	

Half-Lives Greater Than 8 Days

<u>Iodine-131</u>, <u>Iodine-133</u>, <u>Tritium and Radionuclides in Particulate Form With</u>

No ECL Limits

## c. <u>Liquids</u>

3/4.2.1 Sum of the fractions of ECL excluding noble gases (10CFR20, Appendix B, Table 2, Column 2):

< 1.0E+01

3/4.2.1 Total noble gas concentration:

 $< 2E-04 \mu Ci/cc$ 

## 3. AVERAGE ENERGY

Provided below are the average energy (E) of the radionuclide mixture in releases of fission and activation gases, if applicable.

a. Average gamma energy: Not Applicable

b. Average beta energy: Not Applicable

#### 4. MEASUREMENTS AND APPROXIMATIONS OF TOTAL RADIOACTIVITY

Provided below are the methods used to measure or approximate the total radioactivity in effluents and the methods used to determine radionuclide composition.

### a. Fission and Activation Gases

Continuous stack monitors monitor the gross Noble Gas radioactivity released from the plant stack. Because release rates are normally below the detection limit of these monitors, periodic grab samples are taken and analyzed for the gaseous isotopes present. These are used to calculate the individual isotopic releases indicated in Table 1B and the totals of Table 1A. The error involved in these steps may be approximately  $\pm 23$  percent.

#### b. Iodines

Continuous isokinetic samples are drawn from the plant stack through a particulate filter and charcoal cartridge. The filters and cartridges are normally removed weekly and are analyzed for Iodine-131, 132, 133, 134, and 135. The error involved in these steps may be approximately ±18 percent.

#### c. Particulates

The particulate filters described in b. above are also counted for particulate radioactivity. The error involved in this sample is also approximately  $\pm 18$  percent.

#### d. Tritium

ODCM Table 4.3.1 requires as a minimum that grab samples from the plant stack be taken monthly and analyzed for tritium. The stack tritium collection has been upgraded with silica gel columns and continuous sampling of stack effluents. The error involved in this sample is approximately +18 percent.

### e. Waste Oil

Prior to issuing the permit to burn a drum of radioactively contaminated waste oil, one liter of the oil is analyzed by gamma spectroscopy to determine concentrations of radionuclides that meet or exceed the LLD for all of the liquid phase radionuclides listed in ODCM Table 4.2.1.

Monthly, samples from drums that were issued burn permits are sent to the contracted laboratory for compositing and analysis. The lab analyzes for tritium, alpha, Fe-55, Sr-89, and Sr-90 on the composite sample.

The error involved in this sample is approximately  $\pm 15$  percent.

## f. Liquid Effluents

If radioactive liquid effluents are to be released from the facility, they are continuously monitored. Measurements are also required on a representative sample of each batch of radioactive liquid effluents released. For each batch, station records are retained of the total activity (mCi) released, concentration ( $\mu$ Ci/ml) of gross radioactivity, volume (liters), and approximate total quantity of water (liters) used to dilute the liquid effluent prior to release to the Connecticut River.

Each batch of radioactive liquid effluents to be released is analyzed for gross gamma and gamma isotopic radioactivity. A monthly proportional composite sample, comprising an aliquot of each batch released during a month, is analyzed for tritium and gross alpha radioactivity. A quarterly proportional composite sample, comprising an aliquot of each batch released during a quarter, is analyzed for Sr-89, Sr-90, and Fe-55.

## 5. BATCH RELEASES

### a. <u>Liquid</u>

There were no routine liquid batch releases during the reporting period.

### b. Gaseous

There were no routine gaseous batch releases during the reporting period.

### 6. ABNORMAL RELEASES

### a. <u>Liquid</u>

- 1) In 2015 there was a continuous release due to the residual radioactivity in groundwater from a previously undetected leak from a subsurface structure. The leak condition was identified through monitoring well data in January 2010. The leak was stopped in February 2010.
- 2) For 2015, the total Tritium radioactivity conservatively estimated to be released to the Connecticut River is 0.0334 Curies. No other plant-related radionuclides were detected in ground water.

### b. Gaseous

There were no non-routine gaseous releases (measured) during the reporting period.

#### APPENDIX B

### LIQUID HOLDUP TANKS

### Requirement

Technical Specification 3.1.A.1 limits the quantity of radioactive material contained in any outside tank. With the quantity of radioactive material in any outside tank exceeding the limits of Technical Specification 3.1.A.1, a description of the events leading to this condition is required in the next annual Radioactive Effluent Release Report per ODCM Section 10.1.

## Response:

The limits of Technical Specification 3.1.A.1 were not exceeded during this reporting period. (Note that during 2015 the section numbering of the Technical Specifications changed due to the implementation of an NRC-approved License Amendment following permanent shutdown and defueling of the plant, but there were no changes made to the limits in Technical Specification 3.1.A.1 from those previously contained in Technical Specification 3.8.D.1)

### APPENDIX C

## RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

Requirement: Radioactive liquid effluent monitoring instrumentation channels are required to

be operable in accordance with ODCM Table 3.1.1. If an inoperable

radioactive liquid effluent monitoring instrument is not returned to operable status prior to a release pursuant to Note 4 of Table 3.1.1, an explanation in the next annual Radioactive Effluent Release Report of the reason(s) for delay in

correcting the inoperability are required per ODCM Section 10.1.

Response: Since the requirements of ODCM Table 3.1.1 governing the operability of

radioactive liquid effluent monitoring instrumentation were met for this

reporting period, no response is required.

## APPENDIX D

## RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

Requirement: Radioactive gaseous effluent monitoring instrumentation channels are required

to be operable in accordance with ODCM Table 3.1.2. If inoperable gaseous effluent monitoring instrumentation is not returned to operable status within 30

days pursuant to Note 5 of Table 3.1.2, an explanation in the next annual

Radioactive Effluent Release Report of the reason(s) for the delay in correcting

the inoperability is required per ODCM Section 10.1.

Response: Since the requirements of ODCM Table 3.1.2 governing the operability of

radioactive gaseous effluent monitoring instrumentation were met for this

reporting period, no response is required.

#### APPENDIX E

### RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

## Requirement:

The radiological environmental monitoring program is conducted in accordance with ODCM Control 3/4.5.1. With milk samples no longer available from one or more of the sample locations required by ODCM Table 3.5.1, ODCM 10.1 requires the following to be included in the next annual Radioactive Effluent Release Report: (1) identify the cause(s) of the sample(s) no longer being available, (2) identify the new location(s) for obtaining available replacement samples and (3) include revised ODCM figure(s) and table(s) reflecting the new location(s).

### Response:

Milk and silage collection at the Vern-Mont Farm (TM-20) was discontinued in August 2015 due to the permanently shut down and defueled status of the plant. It is noted that this was not a required sampling station in the ODCM.

#### APPENDIX F

#### LAND USE CENSUS

Requirement: A land use census is conducted in accordance with ODCM Control 3/4.5.2.

With a land use census identifying a location(s) that yields at least a 20 percent greater dose or dose commitment than the values currently being calculated pursuant to ODCM Control 4.3.3, the new location(s) must be identified in the

next Annual Radioactive Effluent Release Report.

Response: The Land-Use Census was completed during the third quarter of 2015. No

locations were identified which yielded a 20 percent greater dose or dose commitment than the values currently being calculated pursuant to ODCM Control 4.3.3. See Table 4C for a listing of nearest residents and milk animals

in the site area as determined in the 2015 Land Use Census.

## APPENDIX G

# PROCESS CONTROL PROGRAM

Requirement: ODCM Section 10.1 requires that licensee initiated changes to the Process

Control Program (PCP) be submitted to the Commission in the annual

Radioactive Effluent Release Report for the period in which the change(s) was

made.

Response: There were no changes made to the Process Control Program during this

reporting period.

## APPENDIX H

# OFF-SITE DOSE CALCULATION MANUAL

Requirement: Technical Specification 6.7.B.1 requires that licensee initiated changes to the

Off-Site Dose Calculation Manual (ODCM) be submitted to the Commission in the annual Radioactive Effluent Release Report for the period in which the

change(s) was made effective.

Response: No revisions were made to the ODCM during the reporting period.

### APPENDIX I

# RADIOACTIVE LIQUID, GASEOUS, AND SOLID WASTE TREATMENT SYSTEMS

Requirement: ODCM Section 10.4 requires that licensee initiated major changes to the

radioactive waste systems (liquid, gaseous, and solid) be reported to the

Commission in the annual Radioactive Effluent Release Report for the period in which the evaluation was reviewed by the Plant Operation Review Committee.

Response: There were no licensee-initiated major changes to the radioactive waste systems

during this reporting period.

#### APPENDIX J

#### ON-SITE DISPOSAL OF SEPTIC/SILT/SOIL WASTE

### Requirement:

Off-Site Dose Calculation Manual, Appendices B, F and I require that the dose impact due to on-site disposal of septic waste, cooling tower silt, and sand/soil type materials during the reporting year and from previous years be reported to the Nuclear Regulatory Commission in the Annual Radioactive Effluent Release Report if disposals occur during the reporting year. Entergy Nuclear Vermont Yankee will report in the Annual Radioactive Effluent Release Report a list of the radionuclides present and the total radioactivity associated with the disposal activities on the Vermont Yankee site.

### Response:

There was one on-site disposal spreading of 11,000 gallons of septic waste during October of 2015, and no spreading activities for cooling tower silt or sand/soil type materials. The total radioactivity spread on the 1.9 acres (southern) on-site disposal field from this and previous years was as follows:

Radionuclide	Activity Spread in 2015 (Ci)	Activity from All Past and Current Disposals Decayed to 10/20/2015 (Ci)
Mn-54	8.00E-11	1.17E-08
Co-60	2.43E-09	9.67E-06
Zn-65	2.68E-10	3.67E-09
Cs-134	0.00E+00	6.68E-10
Cs-137	1.10E-10	7.50E-05

The maximum organ dose from all past and current spreading operations totaled 1.09E-01 mrem/year. This calculated value is within the 1 mrem/year limit applied during the period of operational control of the site. The projected hypothetical "intruder" dose for the period following the loss of operational control of the site area, due to all spreading operations to-date, is 2.08E-01 mrem/year versus a 5 mrem/year dose limit. The "intruder dose" period begins on the date that the plant operating license expires, March 21, 2032.