



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 20, 2016

Mr. Bryan C. Hanson
President and Chief Nuclear Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: NINE MILE POINT NUCLEAR STATION, UNIT 2– STAFF REVIEW OF
MITIGATION STRATEGIES ASSESSMENT REPORT OF THE IMPACT OF THE
REEVALUATED SEISMIC HAZARD DEVELOPED IN RESPONSE TO THE
MARCH 12, 2012, 50.54(f) LETTER

Dear Mr. Hanson:

The purpose of this letter is to provide the U.S. Nuclear Regulatory Commission's (NRC) assessment of the seismic hazard mitigation strategies assessment (MSA), as described in the May 25, 2016, letter (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16147A149), submitted by Exelon Generation Company, LLC, (Exelon, the licensee) for Nine Mile Point Nuclear Station, Unit 2 (NMP2). The mitigation strategies assessment confirms that the licensee has adequately addressed the reevaluated seismic hazard within its mitigating strategies for beyond-design-basis external events.

BACKGROUND

By letter dated March 12, 2012 (ADAMS Accession No. ML12053A340), the NRC issued a request for information pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR), Section 50.54(f) (hereafter referred to as the 50.54(f) letter). The 50.54(f) letter was issued as part of implementing lessons-learned from the accident at the Fukushima Dai-ichi nuclear power plant. Enclosure 1 to the 50.54(f) letter requested licensees reevaluate the seismic hazard using present-day methodologies and guidance. Concurrent with the reevaluation of seismic hazards, the NRC issued Order EA-12-049, "Issuance of Order to Modify Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events" (ADAMS Accession No. ML12054A736). The order requires holders of operating power reactor licenses and construction permits issued under 10 CFR Part 50 to develop, implement, and maintain guidance and strategies to maintain or restore core cooling, containment, and spent fuel pool cooling following a beyond-design-basis external event.

By letter dated March 31, 2014 (ADAMS Accession No. ML14099A196), the licensee provided its reevaluated seismic hazard for NMP2 in response to the 50.54(f) letter.

On December 10, 2015 (ADAMS Accession No. ML16005A621), the Nuclear Energy Institute (NEI) submitted Revision 2 to NEI 12-06, including guidance for conducting MSAs using the reevaluated hazard information. The NRC subsequently endorsed NEI 12-06, Revision 2, with

exceptions, clarifications, and additions, in Japan Lessons-Learned Division (JLD) interim staff guidance (ISG) JLD-ISG-2012-01, Revision 1, "Compliance with Order EA-12-049, Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events" (ADAMS Accession No. ML15357A163).

MITIGATION STRATEGIES ASSESSMENT

By letter dated June 16, 2015 (ADAMS Accession No. ML15153A660), the NRC staff documented its review of the licensee's reevaluated seismic hazard, also referred to as the mitigating strategies seismic hazard information. The staff confirmed the licensee's conclusion that its reevaluated seismic hazard is bounded by the safe shutdown earthquake (SSE) over the 1 to 10 Hertz (Hz) frequency range, but exceeds the SSE above 10 Hz, meriting a high frequency confirmation. In addition, the staff concluded that the Ground Motion Response Spectrum (GMRS) determined by the licensee adequately characterizes the reevaluated seismic hazard for the NMP2 site.

By letter dated December 4, 2015 (ADAMS Accession No. ML15338A004), Exelon submitted a High Frequency Confirmation Report for NMP2. By letter dated February 18, 2016 (ADAMS Accession No. ML15364A544), the NRC staff confirmed the NMP2 GMRS exceedance above the current design-basis is on the order of 10 percent or less of the area under the SSE curve over the frequency range of exceedance and met the criterion described in Section 3.1.2, "Limited High Frequency Exceedance Screening," in Electric Power Research Institute (EPRI) Report 3002004396. The EPRI report concluded, and the staff agreed, that these types of minor exceedances over limited frequency ranges do not represent a significant high frequency concern. Therefore, the methodology used by the licensee is appropriate to disposition the GMRS exceedance above the current design basis.

The licensee stated that the NMP2 MSA was performed consistent with NEI 12-06, Revision 2. Appendix H of NEI 12-06, Revision 2, describes acceptable methods for demonstrating that the reevaluated seismic hazard is addressed within the NMP2 mitigation strategies for beyond-design-basis external events. The NRC staff confirmed that the licensee's seismic hazard MSA is consistent with the guidance in Appendix H.4.2 of NEI 12-06, Revision 2, as endorsed, by JLD-ISG-2012-01, Revision 1. Therefore, the methodology used by the licensee is appropriate to perform an assessment of the mitigation strategies that addresses the reevaluated seismic hazard.

The NRC staff has reviewed the seismic hazard MSA for NMP2. The NRC staff concludes that sufficient information has been provided to demonstrate that the licensee's plans for the development and implementation of guidance and strategies under Order EA-12-049 appropriately address the reevaluated seismic hazard information stemming from the 50.54(f) letter.

B. Hanson

- 3 -

If you have any questions, please contact me at (301) 415-3041 or via e-mail at Stephen.Wyman@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to be 'S. Wyman', with a long horizontal line extending to the right across the page.

Stephen Wyman, Project Manager
Hazards Management Branch
Japan Lessons-Learned Division
Office of Nuclear Reactor Regulation

Docket No. 50-410

cc: Distribution via Listserv

B. Hanson

- 3 -

If you have any questions, please contact me at (301) 415-3041 or via e-mail at Stephen.Wyman@nrc.gov.

Sincerely,

/RA

Stephen Wyman, Project Manager
Hazards Management Branch
Japan Lessons-Learned Division
Office of Nuclear Reactor Regulation

Docket No. 50-410

cc: Distribution via Listserv

DISTRIBUTION:

PUBLIC
JHMB R/F
RidsNrrDorLPL1-1 Resource
RidsNrrPMNineMilePoint Resource
RidsNrrLASLent Resource
RidsAcrsAcnw_MailCTR Resource

SWyman, NRR
BTitus, NRR
EBowman, NRR
GBowman, NRR

ADAMS Accession No. ML16166A312

* via e-mail

OFFICE	NRR/JLD/JHMB/PM	NRR/JLD/LA	NRR/JLD/JHMB/PM
NAME	SWyman	SLent	BTitus
DATE	06/14/2016	06/15/2016	06/15/2016
OFFICE	NRR/JLD/JHMB/BC(A)	NRR/JLD/JHMB/PM	
NAME	GBowman	SWyman	
DATE	06/17/2016	06/20/2016	

OFFICIAL RECORD COPY