



# International Agreement Report

## Validation of RELAP5 Model of Ringhals 4 Against a Load Step Test at Up-rated Power

Prepared by:

J. Bánáti and A. Stathis

Chalmers University of Technology  
Department of Applied Physics  
Division of Nuclear Engineering  
SE – 41 296 Gothenburg, Sweden

K. Tien, NRC Project Manager

**Division of Systems Analysis  
Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001**

**Manuscript Completed:** December 2015

**Date Published:** September 2016

Prepared as part of  
The Agreement on Research Participation and Technical Exchange  
Under the Thermal-Hydraulic Code Applications and Maintenance Program (CAMP)

**Published by  
U.S. Nuclear Regulatory Commission**

## AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

### NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Library at [www.nrc.gov/reading-rm.html](http://www.nrc.gov/reading-rm.html). Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and Title 10, "Energy," in the *Code of Federal Regulations* may also be purchased from one of these two sources.

#### 1. The Superintendent of Documents

U.S. Government Publishing Office  
Mail Stop IDCC  
Washington, DC 20402-0001  
Internet: [bookstore.gpo.gov](http://bookstore.gpo.gov)  
Telephone: (202) 512-1800  
Fax: (202) 512-2104

#### 2. The National Technical Information Service

5301 Shawnee Rd., Alexandria, VA 22312-0002  
[www.ntis.gov](http://www.ntis.gov)  
1-800-553-6847 or, locally, (703) 605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

#### Address: U.S. Nuclear Regulatory Commission

Office of Administration  
Publications Branch  
Washington, DC 20555-0001  
E-mail: [distribution.resource@nrc.gov](mailto:distribution.resource@nrc.gov)  
Facsimile: (301) 415-2289

Some publications in the NUREG series that are posted at NRC's Web site address [www.nrc.gov/reading-rm/doc-collections/nuregs](http://www.nrc.gov/reading-rm/doc-collections/nuregs) are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

### Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

#### The NRC Technical Library

Two White Flint North  
11545 Rockville Pike  
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

#### American National Standards Institute

11 West 42nd Street  
New York, NY 10036-8002  
[www.ansi.org](http://www.ansi.org)  
(212) 642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

**DISCLAIMER:** This report was prepared under an international cooperative agreement for the exchange of technical information. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.



# International Agreement Report

## Validation of RELAP5 Model of Ringhals 4 Against a Load Step Test at Up-rated Power

Prepared by:

J. Bánáti and A. Stathis

Chalmers University of Technology  
Department of Applied Physics  
Division of Nuclear Engineering  
SE – 41 296 Gothenburg, Sweden

K. Tien, NRC Project Manager

**Division of Systems Analysis  
Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001**

**Manuscript Completed:** December 2015

**Date Published:** September 2016

Prepared as part of  
The Agreement on Research Participation and Technical Exchange  
Under the Thermal-Hydraulic Code Applications and Maintenance Program (CAMP)

**Published by  
U.S. Nuclear Regulatory Commission**



## ABSTRACT

After finishing the large component replacement project of the steam generators and the pressurizer, the Unit 4 of the Ringhals Nuclear Power Plant was operated in test mode between 2011 and 2014. In order to reach the ultimate goal of power uprate, and obtain a license for operation at the new nominal conditions, a series of tests had to be accomplished.

The R4-QP-101 maneuverability test was performed on March 3, 2015. The test was focusing on evaluation of the system responses for  $\pm 10\%$  perturbances in the load. The data collected during test provided a good opportunity for verification of the full plant model, which is being developed for the RELAP5/Mod3.3 Patch04 computer code, with incorporation of the new component models.

The present International Agreement Report introduces the test procedure and shows an overview on the key parameters that are utilized. There is a brief summary given on the applicability field of the computer code. Preparation of the input deck and the nodalization of the primary and secondary sides are touched upon.

Strategies applied for achievement of steady-state conditions are addressed in the document. The steady-state results are presented in plotted format, demonstrating how the control system brought the entire unit to stable conditions. The calculated steady-state parameters were very close to the measured plant data, before the transient initiation.

A chapter summarizes the results of the validation study using the transient data to simulate the startup test. Quantification of simulation accuracy has proven that the stand-alone RELAP5 thermal-hydraulic model is capable of reproduction of the key features and events of the test. Sufficiently good agreement between the measured and simulated data resulted in a successful verification of the plant model. The Ringhals 4 model is suitable for analysis of other types of transients already in its current state of development. Nevertheless, further refinement in the input is planned as soon as new test data will be available.

*Keywords: Ringhals 4, Load Step, RELAP5, code validation*



## FOREWORD

The present International Agreement Report was prepared with the intention to provide feedback to the developers and the user community of the NRC computer codes in order to demonstrate the capabilities of RELAP5/Mod3.3 Patch 4. The authors made intensive efforts to build an up-to-date model of the recently uprated Ringhals 4 unit for analyses of transients using best estimate methods. As the results reveal in the current document, the code has successfully been validated against a start-up and maneuverability test conducted at relevant NPP.

I am convinced that the modeling strategies and main conclusions in this study will contribute to better understanding of a number of key thermal-hydraulic phenomena and will broaden the knowledge-base of safety authorities, as well as that of the code users worldwide.

**Prof. Imre Pázsit**  
Division of Nuclear Engineering  
Chalmers University of Technology  
Gothenburg, Sweden





# CONTENTS

	<u>Page</u>
<b>ABSTRACT</b> .....	<b>iii</b>
<b>FOREWORD</b> .....	<b>v</b>
<b>FIGURES</b> .....	<b>ix</b>
<b>TABLES</b> .....	<b>xi</b>
<b>ACKNOWLEDGMENTS</b> .....	<b>xiii</b>
<b>ABBREVIATIONS</b> .....	<b>xv</b>
<b>1. INTRODUCTION</b> .....	<b>1-1</b>
1.1 Power Upgrades .....	1-1
1.2 Plant Modernizations at Ringhals .....	1-1
1.3 Objectives of the Test.....	1-3
1.4 Motivations for the Model Verification .....	1-3
<b>2. PROCEDURE OF THE TEST</b> .....	<b>2-1</b>
2.1 Test Phases .....	2-1
2.1.1 Part A: Steady-State.....	2-1
2.1.2 Part B: Power Decrease .....	2-1
2.1.3 Part C: Operation at Reduced Power .....	2-1
2.1.4 Part D: Power Increase .....	2-1
2.1.5 Part E: Restored Power Level .....	2-1
2.2 Test Results.....	2-1
2.2.1 Database of Measured Quantities .....	2-1
2.2.2 Plots of the Measured Parameters .....	2-1
<b>3. DESCRIPTION OF THE CODE AND THE MODEL</b> .....	<b>3-1</b>
3.1 The RELAP5 Code as an Analytical Tool .....	3-1
3.2 Development of the R4 Model.....	3-1
3.2.1 The R3 Model as a Starting Point.....	3-1
3.2.2 Status of the Current R4 Model .....	3-1
3.3 Description of the Primary Side .....	3-2
3.3.1 The Reactor Pressure Vessel Internals .....	3-3
3.3.2 Heat Structures in the Fuel.....	3-7
3.3.3 Axial Power Distribution.....	3-7
3.3.4 The Main Circulation Pump Model.....	3-8
3.3.5 The Safety Systems .....	3-8
3.3.6 Primary Side of the Steam Generators .....	3-8
3.4 Description of the Secondary Side .....	3-9
3.4.1 Secondary Side of the Steam Generators .....	3-9
3.4.2 The Feedwater and Steam Lines.....	3-9

<b>4. STEADY-STATE RESULTS .....</b>	<b>4-1</b>
4.1 Energy and Mass Balance Calculation.....	4-1
4.1.1 Balance Equations of the Secondary Side.....	4-1
4.1.2 Balance Equations of the Primary Side .....	4-2
4.1.3 Strategies to Reach Steady-State .....	4-2
4.2 Plots of the Steady-State Convergence.....	4-4
<b>5. ANALYSIS OF THE TRANSIENT .....</b>	<b>5-1</b>
5.1 Boundary Conditions.....	5-1
5.1.1 Heat Source Boundary Condition .....	5-1
5.1.2 Turbine Pressure Boundary Condition.....	5-1
5.1.3 Turbine Control Valve Opening Boundary Condition .....	5-1
5.1.4 Feedwater Temperature Boundary Condition .....	5-1
5.2 Discussion of the Transient Results .....	5-4
5.3 Plots of the Transient Calculation.....	5-6
5.4 Modeling Problems with the PRZ Level and the Charging Flow .....	5-12
5.5 Run Statistics.....	5-14
<b>6. QUANTIFICATION OF SIMULATION ACCURACY.....</b>	<b>6-1</b>
6.1 Fast Fourier Transform Based Method (FFTBM) Analysis.....	6-1
6.1.1 Average Amplitude .....	6-1
6.1.2 Additional Measures for Accuracy Quantification.....	6-2
6.1.3 Signal Mirroring .....	6-2
6.1.4 FFTBM Analysis Methodology.....	6-2
6.2 Results of the FFTBM Analysis .....	6-3
<b>7. CONCLUSIONS.....</b>	<b>7-1</b>
<b>8. REFERENCES.....</b>	<b>8-1</b>

# FIGURES

		<u>Page</u>
Figure 1	Aerial View of the Four Units at Ringhals .....	1-1
Figure 2	Ringhals 2, 3, and 4 – Similar Type of 3-Loop Westinghouse-Design Reactor.....	1-2
Figure 3	Timeline of the Ringhals 4 Power Uprate .....	1-2
Figure 4	Electric Power from the 2 Generators .....	2-2
Figure 5	Pressure in the Impulse Chamber .....	2-2
Figure 6	Position of Control Rod Bank D .....	2-3
Figure 7	Neutronic Power .....	2-3
Figure 8	Cold Leg Temperature .....	2-4
Figure 9	Hot Leg Temperature .....	2-4
Figure 10	Loop Average Temperature .....	2-5
Figure 11	Loop Flowrate .....	2-5
Figure 12	Drainage Flowrate .....	2-6
Figure 13	Charging Flowrate for PRZ Level Control.....	2-6
Figure 14	Pressure in the Pressurizer.....	2-7
Figure 15	Output Signal for PRZ Pressure Control .....	2-7
Figure 16	PRZ Proportional Heater Control Signal.....	2-8
Figure 17	Control Signal for PRZ Spray Valve .....	2-8
Figure 18	Level in the PRZ .....	2-9
Figure 19	Output Signal for PRZ Level Control .....	2-9
Figure 20	Pressure in the SG Steam Dome .....	2-10
Figure 21	Temperature of Feedwater.....	2-10
Figure 22	Turbine Control Valve Position.....	2-11
Figure 23	Feedwater Flowrate .....	2-11
Figure 24	Steam Flowrate.....	2-12
Figure 25	Narrow Range Level in the SG .....	2-12
Figure 26	Process of model Development for Ringhals 4.....	3-2
Figure 27	Internal Structure of a Westinghouse-Type PWR Pressure Vessel .....	3-3
Figure 28	Numbering Scheme of the Radial Nodalization .....	3-4
Figure 29	Nodalization of the RPV Internals .....	3-5
Figure 30	Nodalization of the Entire Primary Side.....	3-6
Figure 31	Geometry of the Fuel Rods with Radial Mesh Points .....	3-7
Figure 32	Power Distribution in the 8 Axial Nodes .....	3-8
Figure 33	Nodalization Scheme of SG 1 .....	3-10
Figure 34	Nodalization Scheme of the Entire Secondary Side .....	3-11
Figure 35	Fluid Conditions in the SG by the SNAP Visualization Tool .....	3-12
Figure 36	Void Fractions in the SG by the SNAP Visualization Tool .....	3-13
Figure 37	Pressure in the Pressurizer.....	4-4
Figure 38	Collapsed Level in the Pressurizer.....	4-4
Figure 39	PRZ Pressure Control Signal .....	4-5
Figure 40	PRZ Proportional Heater Signal .....	4-5
Figure 41	Charging Flowrate of the PRZ.....	4-6
Figure 42	Average Temperature in the Loop.....	4-6
Figure 43	Temperature in the Hot Leg .....	4-7
Figure 44	Temperature in the Cold Leg .....	4-7
Figure 45	Feedwater Flowrate to the SG .....	4-8
Figure 46	Steam Flowrate from SG .....	4-8
Figure 47	Narrow Range Level in the SG .....	4-9

Figure 48	Pressure in the SG.....	4-9
Figure 49	Temperature Difference in the Loop.....	5-2
Figure 50	Normalized Thermal Power as a Boundary Condition .....	5-2
Figure 51	Turbine Pressure as a Boundary Condition.....	5-3
Figure 52	Turbine Control Valve Position as a Boundary Condition .....	5-3
Figure 53	Feedwater Temperature as a Boundary Condition .....	5-4
Figure 54	Pressure in the PRZ.....	5-6
Figure 55	PRZ Pressure Control Signal .....	5-6
Figure 56	PRZ Proportional Heater Signal .....	5-7
Figure 57	PRZ Spray Valve Lift with Zooming on a Large Peak at ~345 s .....	5-7
Figure 58	Level in the PRZ .....	5-8
Figure 59	PRZ Charging Flowrate .....	5-8
Figure 60	Loop Average Temperature .....	5-9
Figure 61	Hot Leg Temperature .....	5-9
Figure 62	Cold Leg Temperature .....	5-10
Figure 63	Pressure in the SG.....	5-10
Figure 64	Feedwater Flowrate .....	5-11
Figure 65	Steam Flowrate.....	5-11
Figure 66	Narrow Range Level in the SG .....	5-12
Figure 67	Actual and Desired Levels in the PRZ.....	5-13
Figure 68	Measured Levels and the Setpoint vs. Loop Average Temperature .....	5-13
Figure 69	Actual and Courant Limit Time Steps.....	5-14
Figure 70	AA of Feedwater Flowrate.....	6-5
Figure 71	AA of Steam Flowrate .....	6-5
Figure 72	AA of SG Pressure.....	6-5
Figure 73	AA of SG Level .....	6-5
Figure 74	AA of PRZ Pressure.....	6-5
Figure 75	AA of PRZ Level .....	6-5
Figure 76	AA of Average Temperature .....	6-5
Figure 77	AA of PRZ Prop. Heater Signal .....	6-5
Figure 78	AA of PRZ Spray Signal.....	6-6
Figure 79	AA of Charging Flow .....	6-6
Figure 80	Total Average Accuracy.....	6-6

## TABLES

	<b><u>Page</u></b>
Table 1 Parameters at the End of the Steady-State Run .....	4-3
Table 2 Variables, Weighting Factors and Results of the 0-4500 s Interval.....	6-3



## **ACKNOWLEDGMENTS**

The present study has been prepared within a project in close collaboration between Chalmers University of Technology and the Swedish Radiation Safety Authority. SSM is kindly acknowledged for providing financial support for this project. The Document Number of the Contract is SSM2015-686-3 and the Activity Number is 2030076-00.

The authors wish to thank Magnus Holmgren at Vattenfall Ringhals AB for providing the measured test data, as well as for his personal communication on the operation of the control systems.

Last but not least, special thanks are due to Dr. Andrej Prošek at the Institute “Jožef Stefan” in Ljubljana, Slovenia. He has given valuable information and generous help on application of FFTBM methodology for quantification of simulation accuracy.





## ABBREVIATIONS

AA	Average Amplitude
BC	Boundary Condition
BWR	Boiling Water Reactor
CAMP	Code Applications and Maintenance Program
CL	Cold Leg
CVCS	Chemical and Volume Control System
DC	Downcomer
DFT	Discrete Fourier Transformation
ECCS	Emergency Core Cooling System
FA	Fuel Assembly
FCV	Feed Control Valve
FFT	Fast Fourier Transform
FFTBM	Fast Fourier Transform Based Method
FSAR	Final Safety Analysis Report
FW	Feed Water
HL	Hot Leg
HS	Heat Structure
INEL	Idaho National Engineering Laboratory
JSI	Jožef Stefan Institute
LB-LOCA	Large Break Loss of Coolant Accident
LOCA	Loss of Coolant Accident
LP	Lower Plenum
MCP	Main Circulation Pump
MSIV	Main Steam Isolation Valve
NPP	Nuclear Power Plant
NRC	Nuclear Regulatory Commission
NSSS	Nuclear Steam Supply System
PARCS	Purdue Advanced Reactor Core Simulator
PI	Proportional Integral
PLS	Precautions, Limitations, and Setpoints
PRZ	Pressurizer
PWR	Pressurized Water Reactor
RCP	Reactor Coolant Pump
RCS	Reactor Coolant System
RAB	Ringhals AB
RPV	Reactor Pressure Vessel
RELAP	Reactor Excursion and Leakage Analysis Program
RTA	Relevant Thermal-hydraulic Aspects
R3	Ringhals Unit 3
R4	Ringhals Unit 4
SB-LOCA	Small Break Loss of Coolant Accident
SG	Steam Generator
SL	Steam Line
SNAP	Symbolic Nuclear Analysis Package
SSM	Swedish Radiation Safety Authority
TCV	Turbine Control Valve
WH	Westinghouse Electric Company



# 1. INTRODUCTION

## 1.1 Power Uprates

During the last decades, power utilities made enormous efforts into modernization of their plants in order to increase the amount of produced electricity in a more cost-effective and competitive way. The process of increasing the licensed power level of a commercial nuclear power plant is called a *power uprate* [1]. Power uprates are generally categorized based on the magnitude and the methods used to achieve the power increase. Power uprates have been implemented at a number of nuclear power plants (NPPs) in many countries. Currently, there are also a significant number of NPPs that have plans for larger or smaller power uprates. The increase in the electricity produced at an NPP can be achieved in several ways:

- Increase the thermal power in the reactor;
- Improve the thermal conversion efficiency in the secondary side of the power plant by refurbishing or replacing the steam generators (SGs), the high pressure or low pressure turbine units, or by a combination of these actions.

## 1.2 Plant Modernizations at Ringhals

The Ringhals NPP (Figure 1) is situated at the Swedish West Coast and it comprises four units: one boiling water reactor (BWR) and three Westinghouse-type (Figure 2) pressurized water reactors (PWRs). The latest-built Unit 4 was commissioned for commercial operation in 1983. It went through a number of extensive modifications and modernizations in 2011. Within the project of “QUATTRO/R4”, the SGs, the pressurizer (PRZ), and large parts of the turbine plant have been replaced. Refurbishment of these components affected also the relevant control and protection systems. The new nominal (100 %) thermal power of the unit is 3300 MW<sub>th</sub> in the current upgraded state. However, the permitted maximal power was still limited to 2773 MW<sub>th</sub> after the component replacement and a test operational mode was maintained between 2011 and 2014. Finally, the Swedish Radiation Safety Authority (SSM) permitted to increase the power and issued the license for the upgrade during the spring of 2015. Figure 3 shows a timeline of the power uprate process.



**Figure 1 Aerial View of the Four Units at Ringhals**




Figure 2 Ringhals 2, 3, and 4 – Similar Type of 3-Loop Westinghouse-Design Reactor




Figure 3 Timeline of the Ringhals 4 Power Uprate

### **1.3 Objectives of the Test**

To ensure the continued safe operation of the plant, several tests, such as a load step, a full scram, and a load rejection test have successfully been conducted after installation of the new components but still operating at the ordinary power (2773 MW<sub>th</sub>). When the license was obtained for operation at the uprated power (~3000 MW<sub>th</sub>), a new series of tests were repeated. One of them was a  $\pm 10\%$  load step test (R4 – QP-101-b), which is the object of the present study. The main purpose of the current maneuverability test was to verify that the unit, including the recently installed components with the automations and control systems, are able to handle a perturbation of the power in a satisfactory manner.

Specifically, two key issues were highlighted in the investigations:

- Checking the ability of the rod control system to adapt the reactor power according to the turbine power needs, without activation of the steam dump.
- Collecting data on the PRZ level changes due to the temperature variations in the reactor coolant system (RCS).

The magnitude of the power step was carefully set to remain within a  $\pm 10\%$  margin because this change is large enough to generate a challenge for the control systems, but still it remains under the level, which would trigger safety of protection systems, such as a reactor scram or opening a safety valve.

### **1.4 Motivations for the Model Verification**

A new stand-alone RELAP5 computer code model has been built in order to simulate the entire unit 4 at Ringhals by utilizing the experience gained with unit 3 modeling. Comprehensive descriptions of the full-plant models of R3 and R4 are published in [2] and [3], respectively. The new code input includes the replaced component models of the SGs and the PRZ models, which were prepared on the basis of technical details provided by manufacturer. The engineering database specified by the designer reflects the nominal parameters for 100 %, i.e. 3300 MW thermal power, and the model is built accordingly. However, the operation at a lower power needed some modifications and adaptations in the input.

The present validation study on a new load step test is a follow-up to the work, formerly published in a scientific report [4], which discussed a similar subject. Also, a conference paper [5] summarized the results of a startup test performed at a lower power. This test gave the very first opportunity for verification of the model performance against a real plant transient. Within this progression, the current activity is a part of the process in which the ultimate goal is to provide a thoroughly verified, “multi-purpose” R4 model that is suitable for a wide scope of transient analyses. Quantification of simulation accuracy is investigated in Chapter 6, which has been prepared by the co-author of this Report, Athanasios Stathis. The topic is a part of his Master of Sciences Thesis [6].

Last but not least, sharing the knowledge and experiences with verification of the RELAP5 code can be an important feedback for the code developers, as well as essential information for the entire code user community. The work presented in the current study is a Swedish in-kind contribution in a form of an International Agreement Report for the US Nuclear Regulatory Commission (US NRC).



## 2. PROCEDURE OF THE TEST

### 2.1 Test Phases

The R4 Load Step Test was performed on March 3, 2015. Preparation for the test began earlier but the data acquisition started at 09 h 25 m 43 s (0 s) and finished at 10 h 40 m 43 s (4500 s). This means that the length of the recorded data is one and a half hours. The test consist of 5 distinct phases, as described in the followings.

#### 2.1.1 Part A: Steady-State

The plant was operated in a steady-state. Obviously, this does not mean that the parameters are “mathematically” stable. Beyond the stochastic noise, most of the measured quantities reflect a continuously oscillating nature, partly due to the control systems. Between 0 s and 333 s, the electric generators T41 and T42 produced a steady value of 533.5 MW (Figure 4).

#### 2.1.2 Part B: Power Decrease

The transient was initiated with an instant decrease of steam demand at 334 s. As a consequence, the generated electric power and the pressure of the turbine impulse chamber started to fall (Figure 5). In a short period of time, the control rod drive mechanism inserted the rods to the core with maximal speed (Figure 6). This is reflected also in decrease of the neutronic power, from 90.5 % to approx. 82 % (Figure 7). During this transition period, as it can be observed on the plots, many parameters show large “undershoots” or “overshoots”, represented by huge peaks.

#### 2.1.3 Part C: Operation at Reduced Power

It is difficult to determine the exact starting point when the plant reached a quasi-steady condition. Some kind of stabilization began at approx. 450 s. However, the rod control system continued moving the rods until 2100 s and the position was finally kept constant after that.

#### 2.1.4 Part D: Power Increase

Up-step of the power started with a sudden increase of steam demand at ~3918 s. The control rods were pulled up, while the electric power was increasing to its original level. This transition period lasted until approx. 4000 s.

#### 2.1.5 Part E: Restored Power Level

Despite the fact that the power was restored by 4000 s of transient time, most of the other parameters did not completely stabilize before the end of the data recording.

### 2.2 Test Results

#### 2.2.1 Database of Measured Quantities

The test database was provided by Ringhals in a set of 533 ASCII files (1 file per measured channel). Frequency of the data sampling was 1 Hz. Due to different interpretation of the engineering units at the plant and in the code simulation, a MATLAB script was prepared for conversion between, for instance overpressure and absolute pressure (Pa), or deg. C and Kelvin.

#### 2.2.2 Plots of the Measured Parameters




Figure 4 Electric Power from the 2 Generators




Figure 5 Pressure in the Impulse Chamber



R4 Load Step Test - 2015-03-03 - Control Rod Position




Figure 6 Position of Control Rod Bank D

R4 Load Step Test - 2015-03-03 - Neutronic Power




Figure 7 Neutronic Power

R4 Load Step Test 2015 - Cold Leg Temperature




Figure 8 Cold Leg Temperature

R4 Load Step Test 2015 - Hot Leg Temperature




Figure 9 Hot Leg Temperature




Figure 10 Loop Average Temperature




Figure 11 Loop Flowrate




Figure 12 Drainage Flowrate




Figure 13 Charging Flowrate for PRZ Level Control

R4 Load Step Test 2015 - Pressure in the PRZ




Figure 14 Pressure in the Pressurizer

R4 Load Step Test 2015 - Output Signal for PRZ Pressure Control






Figure 15 Output Signal for PRZ Pressure Control



**Figure 16 PRZ Proportional Heater Control Signal**



**Figure 17 Control Signal for PRZ Spray Valve**

R4 Load Step Test 2015 - Level in the PRZ




Figure 18 Level in the PRZ

R4 Load Step Test 2015 - Output Signal for PRZ Level Control




Figure 19 Output Signal for PRZ Level Control

R4 Load Step Test 2015 - Pressure in SGs




Figure 20 Pressure in the SG Steam Dome

R4 Load Step Test 2015 - Temperature of Feedwater




Figure 21 Temperature of Feedwater



R4 Load Step Test 2015 - Turbine Control Valve Position




Figure 22 Turbine Control Valve Position

R4 Load Step Test 2015 - Feedwater Flowrate




Figure 23 Feedwater Flowrate

R4 Load Step Test 2015 - Steam Flowrate




Figure 24 Steam Flowrate

R4 Load Step Test 2015 - Narrow Range Level in the SG




Figure 25 Narrow Range Level in the SG

## **3. DESCRIPTION OF THE CODE AND THE MODEL**

### **3.1 The RELAP5 Code as an Analytical Tool**

In prior agreement with SSM, the RELAP5 code has been selected as the numerical tool for the transient analysis. It has been developed for best-estimate transient simulation of light water reactor coolant systems during postulated accidents. The code originates from the Idaho National Engineering Laboratory (INEL) and first it was created for the U.S. Nuclear Regulatory Commission (NRC). Code uses include analyses required to support rulemaking, licensing audit calculations, evaluation of accident mitigation strategies, evaluation of operator guidelines, and experiment planning analysis. RELAP5 has also been used as basis for a nuclear plant analyzer (NPA). The code models specific simulations of transients in LWR systems, e.g., the coupled behavior of the reactor coolant system and the core for loss-of-coolant accidents and, operational transients such as anticipated transient without scram, loss of offsite power, loss of feedwater, station blackout, turbine trip and, loss of flow. RELAP5 is a highly generic code that, in addition to calculating the behavior of a reactor coolant system during a transient, can be used for simulation of a wide variety of hydraulic and thermal transients in both nuclear and nonnuclear systems involving mixtures of steam, water, non-condensable, and solute.

RELAP5/MOD3.3 Patch-04-jm was the latest installed version of the code [7] at the time of the analysis and it was used without any modification in the source code. RELAP5 is maintained jointly by the NRC and a consortium consisting of several countries and U.S. organizations that were members of the International Code Assessment and Applications Program (ICAP) and its successor organization, Code Applications and Maintenance Program (CAMP). Sweden is a signatory member country of the CAMP Agreement.

The RELAP5/MOD3 code is based on a one-dimensional, nonhomogeneous and non-equilibrium six-equation hydrodynamic model for the two-phase systems. The mass, momentum and energy balance equations are solved by a fast, partially implicit numerical scheme to permit economical calculation of system transients. The objective of the RELAP5 development effort from the outset was to produce a code that included important first-order effects necessary for accurate prediction of system transients but that was sufficiently simple and cost effective so that parametric of sensitivity studies were possible. The code includes many generic component models from which general systems can be simulated. The component models include pumps, valves, and pipes, heat releasing or absorbing structures, reactor point kinetics, electric heaters, jet pumps, turbines, separators, accumulators, and control system components. In addition, special process models are included for effects such as form loss, flow at an abrupt area change, branching, choked flow, boron tracking, and non-condensable gas transport.

### **3.2 Development of the R4 Model**

#### **3.2.1 The R3 Model as a Starting Point**

A very simplified RELAP5 model was created for R3/4 by J. Eriksson [8] at Studsvik EcoSafe in 1994. About a decade later, Chalmers University of Technology took over the developmental efforts on the legacy input. The former coarse nodalization has been refined, thoroughly updated, extended, and a coupled neutron kinetic model has been prepared. A technical description of the coupled R3 model is summarized in [2]. Results of the validations have been published in a number of technical reports, international conferences, and scientific journals [9], [10], and [11].

#### **3.2.2 Status of the Current R4 Model**

The current RELAP5 model of the R4 was built on the basis of the R3 (Figure 26). Since the layouts of the R3 and the R4 units are similar, the main intention was to keep as many elements from the R3 model as possible. However, the steam generators and the pressurizer were replaced with the new AREVA-design components in 2011. The structures of these parts, especially the SGs are significantly different from those that are installed in R3. Consequently, building a new full-plant model became necessary.




Figure 26 Process of model Development for Ringhals 4


The current R4 model represents the “state-of-the-art” and the practical experiences that have been gained by the modeling efforts over the last few years. Quality assurance is guaranteed by the results of the extensive verification and validation tests that the Ringhals models have passed successfully. A number of *startup* and *maneuverability* tests were performed with using 2783 MW<sub>th</sub> before the power uprate at the end of 2011. In particular, a transient with a stepwise change of load by  $\pm 10\%$  was used for validation of the new components and the related control system responses to the perturbations. The results are summarized in a conference paper [5].

The plant parameters, details of the control system data, setpoints, technical specifications and operational data were obtained from the Precautions, Limitations, and Setpoints (PLS) document of R4 [12].

### 3.3 Description of the Primary Side

### 3.3.1 The Reactor Pressure Vessel Internals


The complex structure of the reactor pressure vessel (RPV) internals of a Westinghouse-type PWR is shown in Figure 27 [13]. The core consists of 157 fuel assemblies. The fuel rods are arranged into a 17x17 matrix. The length of a fuel rod is 3.66 m.



**Figure 27 Internal Structure of a Westinghouse-Type PWR Pressure Vessel**

In the core region, each of the 157 fuel assemblies is modeled individually, both for the hydrodynamics and for the heat structures. Such a detailed nodalization has been chosen in order to allow 1:1 coupling between the thermal hydraulic and neutron kinetic calculations.

It is assumed that a 1/3 radial section of the core of is connected to 1 loop out of 3 loops, marked with red, green, and blue colors, respectively in Figure 28. In principle, 52 and 1/3 assemblies belong to 1 loop. This means that, due to lacking triangular (120°) symmetry, the assembly in the center (no. 364) is equally split between the 3 loops. In axial direction, the active core was discretized into eight levels.



**Figure 28 Numbering Scheme of the Radial Nodalization**

The core inlet and outlet needed special considerations due to a limitation in RELAP5, that a “branch” component may be connected to a maximum of 9 other volumes. To overcome this limitation, 6 branches per loop were inserted to the core inlet and outlet. (Components 171-176, 271-276, 371-376 at the inlet, and 191-196, 291-296, 391-396 at the outlet on Figure 29).

It is essential that some specific phenomena, for instance an asymmetric behavior of the loops can be properly captured. For this reason, the downcomer (DC), the way as the core is split into three parallel channels in order to retain the 3-loop structure of the primary side even within the reactor pressure vessel.




Figure 29 Nodalization of the RPV Internals




Figure 30 Nodalization of the Entire Primary Side

It has to be underlined that the DC is modeled in a realistic manner, including the material properties and the wall thicknesses of metallic structures. Application of 6 axial nodes in an



“annulus” component provides adequate resolution for level tracking and thermal stratification. Modeling of heat transfer between the fuel assemblies, the baffle, the barrel, the DC wall, the RPV wall, and the ambient assures that the DC-related thermal hydraulic phenomena are simulated with high fidelity.

It is also important to distinguish between the coolant flowing through the fuel assemblies while being heated, and the remaining part of the main loop flow. Thus, the core has been extended with altogether three bypass channels per loop in the following manner:

- the first one is representing the baffle-barrel space,
- the second one is modeling the open guide thimbles, and
- the third channel is created for the flow path at the core periphery.

The flow resistances were set according to the plant data and therefore resulted in a realistic distribution of the pressure losses. Figure 30 shows the nodalization of the entire primary side.

### 3.3.2 Heat Structures in the Fuel

The radial description of the fuel rods consists of 3 materials:

- the pellet with UO<sub>2</sub> fuel,
- the gap with He gas, and
- the cladding with zircaloy.

Altogether 9 mesh points are defined in the heat structures accordingly (Figure 31). The radial coordinates of the mesh points are indicated as distances from the center line.




Figure 31 Geometry of the Fuel Rods with Radial Mesh Points

### 3.3.3 Axial Power Distribution

Distribution of the relative power in axial direction is shown in Figure 32. Altogether 8 axial nodes

are used for the heat source in the active part of the core, which is the same number as of the corresponding hydrodynamic cells.




Figure 32 Power Distribution in the 8 Axial Nodes

### 3.3.4 The Main Circulation Pump Model

The MCPs are modeled with “pump” components available in RELAP5. The homologous curves, torque and head data were obtained from plant documentation. The model was adopted from R3 input without any modification in the updated version of the R4 input deck. Maintaining the primary side loop flowrate is achieved with controlling the velocity of the pump. A dedicated control variable (cntrivar-180) stores the deviation of the actual loop flowrate from the setpoint value of the desired loop flowrate in kg/s. A PI controller (cntrivar-181) determines the pump velocity in order to approach the setpoint value as close as possible.

### 3.3.5 The Safety Systems

One hydro-accumulator component (901, 903, and 905) is connected to each loop of the primary system through an emergency core cooling mixer component (x86). X denotes here the number of loop, i.e. 1, 2, or 3. These ECC mixers are operating in tandem with the other mixers (x85) that may inject water either from the boron tank (916) or from the residual heat removal system (930 and 940).

The primary side model is extended with a time dependent junction (498) simulating the normal letdown, and a charging line (450) and the corresponding charging valve (451).

### 3.3.6 Primary Side of the Steam Generators

The coolant enters to the inlet plenum (120) from the hot leg (Figure 33). The inverted U-shaped heat exchanger tubes are modeled with a single channel (130). The tube bundle model has altogether 22 cells. The cells from 130-01 to 130-10 are vertical and upwards directed. The cells

130-11 and 130-12 are simulating the U-turn of the tubes with tilted volumes at the top. The cells between 130-13 and 130-22 are again vertical but pointing downwards on the cold leg side. The outlet plenum is modeled with a branch component (140).

### **3.4 Description of the Secondary Side**

#### **3.4.1 Secondary Side of the Steam Generators**

The feedwater is injected through the distributor, and enters to the top volume of the inner DC (505-01). The flow is downwards directed in the channel and reaches the connection junction (508) at the tube plate. It turns upwards at cold side of the riser (510). The boiler section starts with a component (530) having 4 internal cells above the divider plate. The evaporator has 2 components (535 and 538). Phase separation takes place in the separator (540).

The water droplets are diverted from the separator to the upper part of the DC, which is connected to the inlet of cell 545-04. The volume (554) is a downwards directed channel, ending in a junction (548), which connects to the outer DC component (550). The fluid is recirculated in this volume and fed into the hot side of the riser (520) at the bottom of the SG. The volume (520) is thermally associated with the hot leg side of the heat exchanger tube bundle, and also with the cold side of the riser through the divider plate. In those secondary volumes where the heat exchanger tubes are led through (510, 520, and 530) the “bundle friction” option is applied. The steam drum, the dryer, and the steam dome are modeled with 2 volumes (560 and 570) at the top of the SG. In fact, (570) is a branch component and its exit junction is connected to steam line. The upper part of the outer DC (545) appears both on the left and right sides of the nodalization.

#### **3.4.2 The Feedwater and Steam Lines**

The nodalization scheme of the entire secondary side is shown in Figure 34. The boundary conditions for the normal FW are set in a time dependent volume (581). Distribution of the FW takes place in a branch component (854). The normal FW line consists of a control valve (862, 872, and 882) and an isolation valve (864, 874, and 884), respectively in each loop. The auxiliary FW is taken from the boundary volumes (891, 893, and 895). The flowrate of the injected auxiliary FW is controlled by time dependent junctions (892, 894, and 896).

The steam line is split into 2 parts (x85 and x95), each partitioned to 10 volumes. “X” is again associated with the loop number, i.e. x = 5, 6, and 7 mean loops 1, 2, and 3, respectively. The main steam isolation valve (x94) is connecting the 2 parts together. Relatively high resolution of meshing was chosen in order to capture propagation of pressure pulses along the steam lines. Altogether 6 safety valves (x86...x91) and a relief valve (x92) are connected to the steam line, in parallel with each other. The steam lines are merging at a branch component (800). The Ringhals-4 unit has 2 turbines and 4 turbine dumps. These components are modeled in a simplified way in the current RELAP5 model. Turbine 1 and 2, and their control valves are simulated with time dependent junctions (814 and 824) and motor valves (813 and 823), respectively.




Figure 33 Nodalization Scheme of SG 1




Figure 34 Nodalization Scheme of the Entire Secondary Side





Figure 35 Fluid Conditions in the SG by the SNAP Visualization Vool



**Figure 36 Void Fractions in the SG by the SNAP Visualization Tool**





## 4. STEADY-STATE RESULTS

It is essentially important that a numerical simulation should reach perfect steady-state before initiating a transient calculation. However, looking at the measured plant data, this goal seems to be theoretical because even in the most stable and normal operation of a plant, in fact, it is in a “quasi-steady-state” condition. Consequently, the term “steady” can mean minor oscillations around a setpoint value.

### 4.1 Energy and Mass Balance Calculation

Exact calorimetric details of the thermal power were not available from the plant at the time of the simulations. One of the possible approaches to determine a consistent dataset is to make an estimate, using averaged data over the measured stable period of time. This “hand-calculated” dataset can satisfy the energy and mass balance equations, which will be entered to the RELAP5 input as initial conditions.

The balance calculations help also to determine those parameters that are not directly available from the measure database. For instance, the primary loop flowrate is recorded as percentage of the nominal flow but the reference (i.e. 100 %) value is not known. Still, it is necessary to enter the flowrate data in SI units (kg/s) into the RELAP5 input.

Knowing the flowrate  $\dot{m}_{FW}$ , temperature  $T_{FW}$ , and pressure  $p_{FW}$  of the feedwater, the enthalpy  $h_{FW}$  can be determined. With assumption of saturated steam ( $x_{steam} = 1$ ) the enthalpy of the steam  $h_{steam}$  can also be determined. With neglecting the small amount of blowdown steam and averaging of the flowrates, the thermal energy  $Q_{SG,sec}$  of the steam generators can be calculated.

By taking into account the considerations above, the following, reasonably simplified balance equations can be set up:

#### 4.1.1 Balance Equations of the Secondary Side

$$\dot{m}_{FW} = 524.57 \text{ kg/s}$$

$$T_{FW} = 480.92 \text{ K}$$

$$p_{FW} = 70.0 \text{ bar}$$

$$h_{FW} = 0.889723 \cdot 10^6 \text{ J/kg}$$

$$\dot{m}_{steam} = 518.17 \text{ kg/s}$$

$$p_{steam} = 64.31 \text{ bar}$$

$$x_{steam} = 1$$

$$h_{steam} = h'' = 2.7797 \cdot 10^6 \text{ J/kg}$$

$$\bar{m} = \frac{\dot{m}_{FW} + \dot{m}_{steam}}{2} = 521.37 \text{ kg/s}$$

$$Q_{SG,sec} = \bar{m}(h_{steam} - h_{FW}) = 985.377 \text{ MW}$$

$$\sum_{i=1}^3 Q_{SG,sec,i} = 3 \cdot N_{SG} = 2956.132 \text{ MW}$$

#### 4.1.2 Balance Equations of the Primary Side

With assumption of the PRZ pressure  $p_{PRZ}$  to be the primary system pressure, and knowing the temperatures of the hot leg  $T_{HL}$  and of the cold leg  $T_{CL}$ , the enthalpy difference  $\Delta h$  can be determined. Neglecting the losses of heat transfer between the primary and secondary sides, as well as the additional heat generated by the main circulation pumps, we can calculate the loop flowrate  $\dot{m}_{loop}$  from the SG thermal energy  $Q_{SG}$ , according to the following simplified equations:

$$\begin{aligned}p_{PRZ} &= 154.99 \text{ bar} \\T_{HL} &= 593.68 \text{ K} \\T_{CL} &= 556.51 \text{ K} \\h_{HL} &= 1.45632 \cdot 10^6 \text{ J/kg} \\h_{CL} &= 1.24997 \cdot 10^6 \text{ J/kg} \\\Delta h &= h_{HL} - h_{CL} = 0.20635 \cdot 10^6 \text{ J/kg} \\Q_{SG,prim} &= \dot{m}_{loop} \Delta h \\Q_{SG,prim} &= Q_{SG,sec} = 385.377 \cdot 10^6 \text{ W} \\\dot{m}_{loop} &= \frac{Q_{SG,prim}}{\Delta h} = \frac{985.377 \cdot 10^6 \text{ W}}{0.20635 \cdot 10^6 \text{ J/kg}} \\\dot{m}_{loop} &= 4775.27 \text{ kg/s} \\\dot{m}_{total} &= \sum_{i=1}^3 \dot{m}_{loop,i} = 3 \cdot \dot{m}_{loop} = 14\,325.81 \text{ kg/s}\end{aligned}$$

#### 4.1.3 Strategies to Reach Steady-State

As in any numerical plant analysis, the basic assumption is that the unit is operating under steady-state before moving out from stable conditions. Therefore, it is essential to provide a set of proper initial conditions prior to the transient initiation. This aim can be achieved by running the code long enough, while the control systems are actuated and converging the system to a sufficiently stable condition. This method is in accordance with the procedure suggested by the code User Guidelines, instead of using the “steady-state” option of the input, which may result in premature termination of the run.

The following strategies have been applied:

- The core heating power (2956.1 MW) is kept constant by the user-given heat source data in a fuel bundle. Control variable 001 specifies this boundary condition (BC).
- For maintaining the primary system pressure (Figure 37) close to the setpoint value, the PRZ pressure control system is driven by a control signal (Figure 39), the same way as in the plant: i.e. by spraying of coolant taken from the cold legs or heating the system up by the proportional heaters (Figure 40).
- The desired primary side level (Figure 38) is achieved by controlling the PRZ level control system. Charging of the coolant (Figure 41) is provided from the chemical and volume control system (CVCS). The PRZ level program is always a function of the actual average loop temperature (Figure 42).
- The temperatures in the hot leg (Figure 43) and cold leg (Figure 44) are not controlled. These are derived quantities in the code calculation.
- Concerning the primary side loop flowrate, the pump speed is controlled by monitoring the

difference between the actual loop flowrate and the prescribed value. The pump rotation is adjusted by a PI controller accordingly.

- On the secondary side, the SG level control system is regulating the feedwater flowrate (Figure 45) and steam flowrate (Figure 46) in order to keep the SG level (Figure 47) at the necessary elevation. Deviations between the feedwater flows and the steam flows are sensed, and the level is compared to the actual setpoint value, which is a function of the reactor power. The feedwater control valve (FCV) is then actuated by modifying its cross-sectional area for injection of the appropriate amount of feedwater.
- The secondary side pressure (Figure 48) is given by a constant boundary condition. The turbine model is a simplified time dependent volume with a pressure boundary.

The parameters of the steady-state case are summarized in Table 1. Deviations of the achieved values from the desired ones are very small. Therefore, it can be concluded that the plant parameters have converged to a stable condition, which satisfies the expected heat balance between the primary and secondary sides.

Plots of the initial search run are shown in Figure 37 ... Figure 48.

**Table 1 Parameters at the End of the Steady-State Run**

Parameter	Unit	Desired	Achieved	Diff. [%]	Parameter in RELAP
Reactor power	MW <sub>th</sub>	2956.1	2956.1	0.0000	cntrlvar-001 (BC)
Primary pressure	bar	154.99	154.998	0.0052	p-435120000
PRZ level	%	41.94	42.33	0.9213	cntrlvar-430
PRZ charging flow	kg/s	5.6011	5.5981	0.0536	mflowj-451000000
PRZ prop. heater	%	53.14	54.02	1.6560	cntrlvar-411
Hot leg temperature	K	593.68	593.67	0.0017	tempf-120010000
Cold leg temperature	K	556.51	556.42	0.0162	tempf-140010000
Average temperature	°C	301.94	301.98	0.0132	cntrlvar-434
Loop mass flowrate	kg/s	4775.27	4772.56	0.0568	mflowj-180010000
Feedwater flowrate	kg/s	521.37	519.32	0.3932	mflowj-868000000
Steam flowrate	kg/s	521.37	519.39	0.3798	mflowj-594000000
SG level	%	66.71	66.71	0.0000	cntrlvar-502
SG pressure	bar	64.31	64.40	0.1399	p-570010000

## 4.2 Plots of the Steady-State Convergence




Figure 37 Pressure in the Pressurizer






Figure 38 Collapsed Level in the Pressurizer



**Figure 39 PRZ Pressure Control Signal**



**Figure 40 PRZ Proportional Heater Signal**

R4 Load Step Test 2015 - PRZ Charging Flowrate




Figure 41 Charging Flowrate of the PRZ

R4 Load Step Test 2015 - Loop Average Temperature




Figure 42 Average Temperature in the Loop

R4 Load Step Test 2015 - Hot Leg Temperature




Figure 43 Temperature in the Hot Leg

R4 Load Step Test 2015 - Cold Leg Temperature






Figure 44 Temperature in the Cold Leg



**Figure 45 Feedwater Flowrate to the SG**



**Figure 46 Steam Flowrate from SG**



R4 Load Step Test 2015 - Narrow Range Level in the SG




Figure 47 Narrow Range Level in the SG

R4 Load Step Test 2015 - Pressure in the SG




Figure 48 Pressure in the SG



## 5. ANALYSIS OF THE TRANSIENT

### 5.1 Boundary Conditions

In many computer code calculations attempting to simulate full-plant transients it is obvious that some parameters are not available due to lacking measurement, documentation, or inaccessible information. In some cases, this shortcoming can be bypassed with derivation of the missing data from other known variables. In a few calculations, it is enough to approximate unavailable data with constants or simple functions. Applications of boundary conditions are natural parts of the transient simulations, and this approach is discussed in the following paragraphs.

#### 5.1.1 Heat Source Boundary Condition

It is important to emphasize that the simulation in the current study used a so called *stand-alone* model of Ringhals 4. It means that only the thermal-hydraulic features of RELAP5 were applied, without any internal neutronic feedback or without coupling to an external neutronic code, such as PARCS. (There are intentions to prepare a neutron kinetic model of Unit 4 in the future). This fact has put some limitation on the present analysis because it was not possible to take the minor power changes into account, which were originating from control rod movements. Note that with changing coolant temperatures, the density, the moderation, and the power are also changing. These effects were interacting with the power control and the rod drive mechanism, which was not modeled in this stand-alone simulation. Nevertheless, the core heating power is also in strong correlation with the temperature difference ( $\Delta T$ ) of the loop (Figure 49), and both the hot leg temperature and cold leg temperature were measured quantities. Consequently, the thermal power was approximated with a user-given input, based on the loop  $\Delta T$ , as an estimation. The normalized heat source is shown in Figure 50, with respect to 2956.13 MW.

#### 5.1.2 Turbine Pressure Boundary Condition

As it has been mentioned before, the secondary side model of Ringhals 4 is not a closed loop as it is in the plant. A real turbine is far too complex to model in the present analysis. Therefore, the components between the turbine and the feedwater pump are modeled in a simplified manner. The turbine is replaced with a pressure boundary condition, assuming saturated steam and pressure, according to the curve in Figure 51.

#### 5.1.3 Turbine Control Valve Opening Boundary Condition

Features of the turbine control valve (TCV), such as opening vs. stem position, are not known. In fact, throttling of the turbine is driven by a very sophisticated mechanism. Adequate modeling of the TCV and the related controls are beyond the scope of the present study. For achievement of proper conditions, position of the TCV was assumed according to the curve in Figure 52.

#### 5.1.4 Feedwater Temperature Boundary Condition

Temperature of the feedwater is always a function of the actual load. Due to the simplifications mentioned before, the turbine discharges and the feedwater pre-heaters are not part of the current model. Consequently, temperature of the feedwater is provided for the input with a boundary condition. The time function of the temperature is depicted in Figure 53.




Figure 49 Temperature Difference in the Loop






Figure 50 Normalized Thermal Power as a Boundary Condition



**Figure 51 Turbine Pressure as a Boundary Condition**



**Figure 52 Turbine Control Valve Position as a Boundary Condition**

R4 Load Step Test 2015 - Feedwater Temperature BC




Figure 53 Feedwater Temperature as a Boundary Condition

## 5.2 Discussion of the Transient Results

Calculation of the transient began with restarting the simulation from the end point of the steady-state run. In the transient input, the “reset” option was used on card number 100 and restart number of “-1” was given on card number 103. The SSDTT flag was set to “00032” on card 201.

The main characteristic periods of the transient can be observed in the calculation, namely:

1. Stable operation at high power
2. Power reduction
3. Operation at reduced power
4. Power increase
5. Operation at restored power

The first period of stable operation is basically an extension of steady-state. At approx. 333 s, the instant power reduction resulted in a large peak, followed by a sudden fall of the PRZ pressure (Figure 54). The control system of the PRZ generates a signal from the setpoint deviation. The signal shown in Figure 55 drives the opening of pressurizer spray valve, the power of the proportional heaters, and the on/off heaters. The magnitude of pressure changes first deactivated the PRZ proportional heaters (Figure 56) temporarily reaching zero power. Soon after that, the sudden pressure increase triggered the PRZ spray system (Figure 57) for a few seconds. Simultaneously, the proportional heaters became powered at their maximal capacity. A peak was experienced in the PRZ level (Figure 58) during the power reduction. While the primary system level was modeled with good accuracy, the charging flowrate (Figure 59) showed larger deviations limited to *the period of power changes*. This discrepancy is discussed further in section 5.4.

Concerning the coolant temperatures, a similar behavior can be observed. The loop average temperature (Figure 60, note in [°C]) and the cold leg temperature (Figure 62) show higher peaks,

while the hot leg temperature (Figure 61) increase is almost negligible. With respect to the fluid temperatures, a general trend of slow decrease characterizes the quasi-steady period at reduced power.

When the power was suddenly restored, the PRZ parameters reacted the opposite way, compared to the up-step. A large negative peak was followed by a surge in the pressure within a few tens of seconds. Just before 4000 s of transient time, the low PRZ pressure required energizing of the proportional heaters. This had an immediate effect on the primary side pressure and activation of the spray system became necessary. Injection of cold water by the spray system was maintained for ~250 s, which brought the PRZ pressure constantly down until the end of the transient.

On the secondary side, the pressures measured in the SG steam dome (Figure 63) and in the steam line are very well simulated by the code, though the latter is somewhat underestimated. This indicates that sources of pressure losses (such as the flow restrictor or the main steam isolation valve) have to be carefully examined and adjusted.

While the feedwater flowrate (Figure 64) is almost perfectly calculated, the corresponding steam flowrate (Figure 65) is a bit higher than the measured value. This can be explained by the fact that the “missing” few kg/s is nearly the same amount as a blow-down, which is extracted from the secondary system for purification. Since the blow-down discharge is not part of the model, the real mass flows are accurately calculated by the code.

Large peaks are often present in many numerical simulations. In some cases these are not realistic, or at least their sources are unknown. Such peaks can be observed both in the calculated flowrates of feedwater and steam. This phenomenon may be a consequence of a sudden closure or opening of a valve. Alternatively, it can be attributed to the derivative component of the modeled SG feed control system, which is reacting to large instant changes in such a way. Further investigations are necessary on this issue.

Another parameter, the SG level (Figure 66) is a good indicator for good simulation of the mass balance in the secondary side. The simulated narrow range SG level follows very well the dynamical changes of measured level. This is an evidence for properly designed and well-functioning model of the SG level control system.

It has to be noted that most of the measured signals contained high level of noise, making the comparison very difficult. For reduction of the measurement noise in the previous plots, the Savitzky-Golay filtering algorithm was applied with using MATLAB. The unfiltered, raw test data were plotted in Chapter 2 of this document.

### 5.3 Plots of the Transient Calculation




Figure 54 Pressure in the PRZ




Figure 55 PRZ Pressure Control Signal






Figure 56 PRZ Proportional Heater Signal




Figure 57 PRZ Spray Valve Lift with Zooming on a Large Peak at ~345 s

R4 Load Step Test 2015 - Level in the PRZ




Figure 58 Level in the PRZ

R4 Load Step Test 2015 - PRZ Charging Flowrate




Figure 59 PRZ Charging Flowrate

R4 Load Step Test 2015 - Loop Average Temperature




Figure 60 Loop Average Temperature

R4 Load Step Test 2015 - Hot Leg Temperature




Figure 61 Hot Leg Temperature




Figure 62 Cold Leg Temperature




Figure 63 Pressure in the SG

R4 Load Step Test 2015 - Feedwater Flowrate




Figure 64 Feedwater Flowrate

R4 Load Step Test 2015 - Steam Flowrate





Figure 65 Steam Flowrate




**Figure 66 Narrow Range Level in the SG**

#### **5.4 Modeling Problems with the PRZ Level and the Charging Flow**


As it was shown in Figure 58, the code managed to simulate the PRZ level with a good accuracy. However, this was achieved with much lower charging flowrate during the down-step of the power and on the contrary, with overestimated charging flow during the power up-step (Figure 59). No explanation has been found, yet for such a behavior. In particular, it is interesting that the necessary charging flow is simulated quite well in the other periods of the transient.

Another mismatch was detected in connection to the PRZ. As it can be clearly recognized in Figure 67, the actual measured levels are scattered within a bounding range of more than 1.5%. Most likely, these signals (40313LT-459, 40313LT-460, and 40313LT-461) were calibrated purposely in such a way. However, the signal of the desired setpoint level (i.e. the “level program”, which is a function of the loop average temperature) is always out of measured bounding range. The value determined by the level program is practically less than the lowest measured signal of 40313LT-460. This phenomenon caused difficulties in proper modeling of the PRZ level.

Mismatching between the level setpoint and the actual levels is further confirmed in Figure 68. It can be observed that the lowest measured level signal (40313LT-460) shows the strongest correlation with the setpoint value documented in the PLS. However, even this relatively good correlation is limited to a small range of loop average temperatures. Consequently, the modeled control system may struggle to find the correct level setpoint for the PRZ. This is affecting the amount of charging water to be injected into the primary system. As a future activity, this phenomenon will be investigated and improved at a later stage of the R4 RELAP5 model development.




**Figure 67 Actual and Desired Levels in the PRZ**



**Figure 68 Measured Levels and the Setpoint vs. Loop Average Temperature**

## 5.5 Run Statistics

In a numerical simulation of a transient, it is always important to have information about the stability and smoothness of the calculation. The two plots in Figure 69 describe the relationship between the actual time step and the Courant-limit time step. The former one is practically constant (0.025 s), which is the same as the requested time step. The latter one is nearly constant, and it is just slightly higher than the actual time step. The fact, that the actually used time step is never reduced, it indicates that the calculation is running smoothly. On the other hand, the two time steps values were very close to each other. Consequently, the calculation was performed quite “economically” because the requested time step was set to just 0.002 s less than the value allowed by the Courant-limit. The initial reduction of the time step is due to resetting from the end-point of the steady-state. The final reduction is a consequence of the requested termination of the run exactly at 4500 s, resulting in a shortened time step.



**Figure 69 Actual and Courant Limit Time Steps**

The calculations were performed on a computer with a 3.5 GHz 4 cores Intel i7 4770K processor and 32 GB RAM running Ubuntu version of Linux. The total consumed CPU time was 3167 s for altogether 300121 attempted advancements. The ratio between the CPU time and the transient time is  $3167 \text{ s} / 4500 \text{ s} = 0.7038$ .



## 6. QUANTIFICATION OF SIMULATION ACCURACY

### 6.1 Fast Fourier Transform Based Method (FFTBM) Analysis

Fast Fourier Transform Based Method (FFTBM) is a method used for the quantification of “goodness” both for a particular variable prediction and overall model predictions. The basis of FFTBM is the calculation of the relative error between calculated and measured (test) data in the frequency domain. Thus, FFTBM can become a very useful aid on the search of discrepancy sources. In addition it can be used as an aid to tackle practical issues related with the models used, such as the fidelity of the nodalization needed, margin for simplifications or further improvements, etc. [14].

For the FFTBM analysis JSI FFTBM Add-in 2007 is used. It is an Excel-2007 add-in developed by Jožef Stefan Institute in Ljubljana by Dr. Andrej Prošek.

#### 6.1.1 Average Amplitude

Average Amplitude ( $AA$ ) is the basic measure used for FFTBM analysis. Supposing that the difference between the calculated  $F_{cal}(t)$  signal and the experimental one  $F_{exp}(t)$  reads in the time domain as:

$$\Delta F = F_{cal}(t) - F_{exp}(t),$$

then the average amplitude  $AA$  is calculated as:

$$AA = \frac{\sum_{n=0}^{2^m} |\tilde{\Delta F}(f_n)|}{\sum_{n=0}^{2^m} |\tilde{F}_{exp}(f_n)|},$$

where  $\tilde{\Delta F}(f_n)$  and  $\tilde{F}_{exp}(f_n)$  the discrete Fourier transformation of  $\Delta F$  and  $F_{exp}$  as calculated by FFT algorithm respectively. Average amplitude could be interpreted as an integral measure that keeps track of the relative magnitude of the discrepancy between the experimental and calculated variable over a time interval.

The following statements can be made for variables predictions based on average amplitude:

- $AA \leq 0.3$  corresponds to very good variable prediction.
- $0.3 < AA \leq 0.5$  corresponds to good variable prediction.
- $0.5 < AA \leq 0.7$  corresponds to poor variable prediction.
- $AA > 0.7$  corresponds to very poor variable prediction.

This criterion refers to one variable. However, it is often needed to assess the overall prediction capability of a model based on  $N_{var}$  number of variables. Thus, the total average amplitude  $AA_{tot}$  for all of the variables of interest can be computed as:

$$AA_{tot} = \sum_{i=1}^{N_{var}} (w_f)_i \cdot AA_i,$$

where  $(w_f)_i$  the (normalized) weighting factor of the  $i - th$  variable of interest. The selection of weighting factors is a matter of subjective engineering judgment and should be specified for the transient of interest. The  $AA$  criterion mentioned above can be applied for  $AA_{tot}$  to assess the overall prediction “goodness” of the model.

### 6.1.2 Additional Measures for Accuracy Quantification

The following additional measures can assist the accuracy quantification within the FFTBM context:

- variable accuracy  $VA_i$ ,  $i = 1, 2, \dots, N_{var}$
- minimal and maximal variable accuracy  $VA_{min}$  and  $VA_{max}$
- number of discrepancies  $ND$

Variable accuracy  $VA_i$  of the  $i - th$  variable of interest shows what the total average amplitude  $AA_{tot}$  would be if the rest of the chosen variables all have the same weighting factor  $(w_f)_i$  and average amplitude  $AA_i$ . Therefore, it is designated as:

$$VA_i = AA_i \cdot (w_f)_i \cdot N_{var}$$

It should be mentioned that the criterion for  $AA$  is applicable for  $VA_i$  too. Minimal variable accuracy  $VA_{min}$  and maximal variable accuracy  $VA_{max}$  indicate the minimum and the maximum variable accuracy among the accuracy amplitudes  $AA_i$ ,  $i = 1, \dots, N_{var}$  of the  $N_{var}$  chosen variables. Consequently, they are defined as:

$$VA_{min} = \max\{VA_i\}, i = 1, \dots, N_{var}$$

and

$$VA_{max} = \min\{VA_i\}, i = 1, \dots, N_{var}.$$

Minimal variable accuracy  $VA_{min}$  is used to define the number of discrepancies  $ND$ . It is accepted that the acceptability limit for a calculation is 0.4 and thus,  $AA_{tot} < 0.4$ . Hence, the number of discrepancies  $ND$  is equal with the number of variables for which  $VA_i > 0.4$ . It is obvious that  $ND = 0$  when  $VA_{min} < 0.4$ . It should be mentioned that a prerequisite for the application of FFTBM is that the average amplitude of the primary pressure is  $AA < 0.1$  due to the significant influence of this variable in the system.

### 6.1.3 Signal Mirroring

Discrete calculated and discrete experimental signals are mirrored in the time domain in order to avoid an inherent weakness of the original FFTBM method that produced unphysical  $AA$  results [15].  $AA$  ( $AA_i$  or  $AA_{tot}$ ) should exhibit an overall increasing monotonous trend with increasing time window, since it is an integral discrepancy measure throughout the increasing time window interval. Consequently as time window increases, addition of discrepancies of the newly added time slots occur, which is why  $AA$  should monotonically increase. However this does not happen when the last and the first point of the discrete signal differ significantly. FFT multiplies the discrete signal so as to create a periodic infinite signal. As a result, any difference between the first sample of each period with the last sample of the previous period increases the frequency content of  $AA$ , distorting it significantly.

### 6.1.4 FFTBM Analysis Methodology

The transient is divided in phenomenological windows for which the relevant thermal-hydraulic

aspects (RTA) are identified. Variables that best describe the RTA are chosen. Then the weighting factors of the variables are set. Average amplitude  $AA_i$  for each of the chosen variables as well as the total average amplitude  $AA_{tot}$  are calculated using the increasing time window approach. In increasing time window approach the transient is divided in equal and successive time slots. Increasing time windows are then constructed by addition of successive time slots so that the first time window corresponds to the first time slot, the second time window to the addition of the two first time slots etc. Hence, the last time window corresponds to the whole duration of the transient.  $AA_i$  for  $i = 1, \dots, N_{var}$  and  $AA_{tot}$  are calculated for each time window and plotted as function of time [16]. This time window approach allows better tracking of the evolution of  $AA_i$  or  $AA_{tot}$ , especially for transients with few phenomenological windows.

The transient is separated in five phenomenological windows same as it was described in the previous sections. Since the purpose of the Load Step Test is, among others, to check the ability of the control systems to mitigate the transient, selection of variables and their weighting factors takes place accordingly. Hence, 20 variables were chosen (Table 2) that are descriptive also for the most important RTAs. Most of them appear as inputs or outputs in the modelled PRZ level and pressure controllers, as well as in SG level controller.

Concerning the selection of weighting factors, a scale between 0 and 4 is used to assess the importance of the selected variables. Input variables of the controllers are assigned to a significance factor of 4. Variables appearing as controller outputs are assigned to a significance factor of 3 and the rest of the selected variables to a significance factor of 2. Then the significance factors are normalized (so that their summation equals one). For the FFTBM calculations 15 increasing time windows are considered with 300 s increments.

## 6.2 Results of the FFTBM Analysis

Evolution of each variable of average amplitude as function of time and in addition, of the total average amplitude, are presented in the following figures. The average amplitude and variable accuracy results for the last time window, 0 - 4500 s, representative of the whole transient, are presented in Table 2.

It can be observed in Figure 71 - Figure 79 that jumps of average amplitudes occur in most of the variables, as well as in total average amplitude, during the second increasing time window of 0 – 600 s. This time window includes the sudden power *decrease* phase of the transient. However, such a significant average amplitude variations could not be observed in the increasing time window including the power *increase* phase. Thus, it seems that the model performs better after the step of power reduction.

As Table 2 and Figure 80 indicate, the total average amplitude is below 0.3. Consequently, the overall model predictions can be characterized as “*very good*”. Furthermore, it can be seen that the first 14 variables have average amplitude below 0.3 and their predictions can be marked as “*very good*”. Among those 14 variables, 11 are static quantities, such as pressures, temperatures and PRZ/SG collapsed levels, which have average amplitude equal or below 0.1. This demonstrates an excellent ability of the code to predict static variables. For the rest of the variables, comprising of steam mass flowrates, charging flowrate and spraying control signal, the average amplitudes remain under the acceptability limit 0.4, and their predictions can be marked as “*good*”, except the charging flowrate.

**Table 2 Variables, Weighting Factors and Results of the 0-4500 s Interval**

No.	Variable			0 – 4500 s
		$w_f$	AA	VA

1	Primary pressure	0.06	0.017848	0.019831
2	Level in PRZ	0.06	0.090816	0.100907
3	Pressure in SG-1	0.03	0.024022	0.013345
4	Pressure in SG-2	0.03	0.027866	0.015481
5	Pressure in SG-3	0.03	0.026025	0.014458
6	Level in SG-1	0.06	0.089762	0.099736
7	Level in SG-2	0.06	0.096436	0.107151
8	Level in SG-3	0.06	0.093780	0.104200
9	Average temp. in loop-1	0.06	0.007577	0.008419
10	Average temp. in loop-2	0.06	0.007702	0.008557
11	Average temp. in loop-3	0.06	0.007964	0.008849
12	Feedwater flow in SG-1	0.06	0.263144	0.292382
13	Feedwater flow in SG-2	0.06	0.250198	0.277998
14	Feedwater flow in SG-3	0.06	0.266469	0.296077
15	Spraying control signal	0.04	0.495459	0.412882
16	Steam line-1 flow-rate	0.06	0.316915	0.352128
17	Steam line-2 flow-rate	0.06	0.363501	0.403890
18	Steam line-3 flow-rate	0.06	0.335377	0.372641
19	Charging flow-rate	0.06	1.050899	1.167666
20	Proportional heaters capacity	0.04	0.356188	0.296824
Total			0.22	

Charging flowrate is the only variable that is very poorly predicted which consolidates the suspicions about the PRZ level controller. The spraying output signal lies in the “good” prediction margin but above the acceptability limit. The level and the pressure in the PRZ and as a result the amount of spraying, are affected by the quantity of the water injected in the primary side and thus, by the PRZ level controller.

Looking at the  $VA$  data column of Table 2, it can be observed that the variable accuracies of 17 among the 20 chosen variables have variable accuracies below the acceptability limit, 15 of which exhibit  $VA < 0.3$ . Thus it also reflects the good quality and maturity of the model. The number of discrepancies  $ND$  in most of increasing time windows is equal to 2, mostly due to charging flow and secondly due to the spraying control signal. In the time window of 0 - 3000 s and beyond,  $ND = 3$  due to the two variables mentioned above plus the steam flowrate in loop-2.

It is worth mentioning that the predictions of steam flows are considered “good” ( $AA < 0.4$ ) but they can be further improved. The plant operators admit that the pressure losses in the steam line is greater than they expected. Thus, improvement of this factor should improve the agreement between measured and calculated steam flows which will culminate in the steam flows average amplitudes to become less than 0.3.

To conclude, the overall code predictions are very good as indicated by the total average amplitude diagram ( $AA_{tot} < 0.3$  throughout the duration of the transient) and the code can be characterized as very reliable and of high quality. Nonetheless, there is still a margin for improvements, especially regarding the modeled PRZ level controllers.




Figure 70 AA of Feedwater Flowrate




Figure 71 AA of Steam Flowrate




Figure 72 AA of SG Pressure




Figure 73 AA of SG Level




Figure 74 AA of PRZ Pressure




Figure 75 AA of PRZ Level




Figure 76 AA of Average Temperature




Figure 77 AA of PRZ Prop. Heater Signal




Figure 78 AA of PRZ Spray Signal




Figure 79 AA of Charging Flow




Figure 80 Total Average Accuracy

## 7. CONCLUSIONS

An important stage of the R4 model development process has been summarized in the current study. Incorporation of the new components (i.e. the AREVA design SGs and the PRZ) into the full plant model was a challenging task and this was the second opportunity to validate the new model against a startup test. Prior experiences with the prototype geometries could be utilized in the present Report.

On the basis of the presented steady-state and transient results, it can be concluded that the over-all performance of the R4 RELAP5 model is good. The general trends during the 5 distinguishable parts of the transient were well predicted by the code. Quantitative matching of the parameters was satisfactory, which resulted in a successful validation of the model, as well as the code. The primary to secondary side energy transfer was sufficiently well simulated. The Ringhals 4 model is suitable for analysis of other types of transients already in its current state of development.

However, as always, there is a margin for improvement. For instance, application of FFTBM tool has revealed that characteristics of some control valves need to be obtained and examined because this is a critical parameter, which is influencing the general behavior of the transients. The calculated charging flow showed the largest deviations during the sudden power changes. This can be partly attributed to the problematic level program of the PRZ.





## 8. REFERENCES

1. IAEA Technical Working Group, *Power uprate in nuclear power plants : guidelines and experience*. IAEA nuclear energy series, 2011, Vienna, International Atomic Energy Agency. 104 p.
2. Agung, A. and Bánáti, J., *Technical Description of the Coupled PARCS/RELAP5 Model for the Ringhals-3 NPP*. Division of Nuclear Engineering, Chalmers University of Technology, Gothenburg, Sweden. 2013. p. 41.
3. Bánáti, J., *Technical Description of the RELAP5 Model for the Ringhals 4 NPP*. 2013, Division of Nuclear Engineering, Chalmers University of Technology. p. 53.
4. Bánáti, J., *Validation of the RELAP5 Model of Ringhals 4 against the 2011-12-14 ± 10% Load Step Test*. Division of Nuclear Engineering, Chalmers University of Technology. Report No.: CTH-NT-315. 2013. p. 42.
5. Bánáti, J. and M. Holmgren, *Validation of RELAP5/Mod3.3 against a Load Step Transient at Ringhals 4 NPP*, in *16th International Meeting on Nuclear Reactor Thermal Hydraulics (NURETH-16)*. ANS. Chicago, IL, USA, Aug. 30 - Sep. 4, 2015. p. 4548-4561.
6. Stathis, A., *Analysis of a Load Step Test at Ringhals 4 using RELAP5 - Code Validation and Verification*, Division of Nuclear Engineering. Chalmers University of Technology, Gothenburg, Sweden. 2015
7. Information Systems Laboratories Inc., *RELAP5/MOD3.3 code manual, Patch 04, Vols. 1 to 8*. 2010, US Nuclear Regulatory Commission
8. Eriksson, J., *RELAP/MOD3 base model for the Ringhals 3/4 plants*. Report STUDSVIK/ES-94/14, Studsvik Eco & Safety AB. 1994.
9. Bánáti, J., et al. *Analysis of a Loss of Feedwater Case at the Ringhals-3 NPP Using RELAP5/PARCS Coupled Codes*. ICONE-16 Proceedings of the 16th International Conference on Nuclear Engineering, Paper No.: ICONE16-48116, Vol 3. Orlando, Florida, USA. May 11–15, 2008. ASME.
10. Bánáti, J., et al., *Analysis of a Loss of Normal Feedwater Transient at the Ringhals-3 NPP using RELAP5/Mod3.3*, International Agreement Report (NUREG/IA-0234). 2010, U. S. Nuclear Regulatory Commission.
11. Agung, A., et al., *Validation of PARCS/RELAP5 coupled codes against a load rejection transient at the Ringhals-3 NPP*. Nuclear Engineering and Design, 2013. **257**: p. 31-44.
12. Vattenfall, *Ringhals 4 Reactor PLS - Precautions, Limitations and Setpoints for Nuclear Steam Supply and Balance of Plant Systems (v.35.0)*. 2015.
13. USNRC, *Pressurized Water Reactor Systems - Reactor Concepts Manual*. 2003.
14. Prošek, A., F. D'Auria, and B. Mavko, *Review of quantitative accuracy assessments with fast Fourier transform based method (FFTBM)*. Nuclear Engineering and Design, 2002. **217**(1–2): p. 179-206.
15. Prošek, A., M. Leskovar, and B. Mavko, *Quantitative assessment with improved fast Fourier transform based method by signal mirroring*. Nuclear Engineering and Design, 2008. **238**(10): p. 2668-2677.
16. Prošek A., M.B., *Quantitative Code Assessment with Fast Fourier Transform Based Method Improved by Signal Mirroring*, International Agreement Report (NUREG/IA-0220). 2009, U.S. Nuclear Regulatory Commission.







**BIBLIOGRAPHIC DATA SHEET**

(See instructions on the reverse)

2. TITLE AND SUBTITLE

Validation of RELAP5 Model of Ringhals 4 against a Load Step Test at Uprated Power

3. DATE REPORT PUBLISHED

MONTH

YEAR

September

2016

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

J. Bánáti and A. Stathis

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION NAME AND ADDRESS (If NRC, provide Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Chalmers University of Technology  
Department of Applied Physics  
Division of Nuclear Engineering  
SE - 41 296 Gothenburg, Sweden

9. SPONSORING ORGANIZATION NAME AND ADDRESS (If NRC, type "Same as above" if contractor, provide NRC Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address.)

Division of Systems Analysis  
Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

10. SUPPLEMENTARY NOTES

K.Tien, NRC Project Manager

11. ABSTRACT (200 words or less)

After finishing the large component replacement project of the steam generators and the pressurizer, the Unit 4 of the Ringhals Nuclear Power Plant was operated in test mode between 2011 and 2014. In order to reach the ultimate goal of power uprate, and obtain a license for operation at the new nominal conditions, a series of tests had to be accomplished. The R4-QP-101 maneuverability test was performed on March 3, 2015. The test was focusing on evaluation of the system responses for  $\pm 10\%$  perturbances in the load. The data collected during test provided a good opportunity for verification of the full plant model, which is being developed for the RELAP5/Mod3.3 Patch04 computer code, with incorporation of the new component models. The present International Agreement Report introduces the test procedure and shows an overview on the key parameters that are utilized. There is a brief summary given on the applicability field of the computer code. Preparation of the input deck and the nodalization of the primary and secondary sides are touched upon. Strategies applied for achievement of steady-state conditions are addressed in the document. The steady-state results are presented in plotted format, demonstrating how the control system brought the entire unit to stable conditions. Quantification of simulation accuracy has proven that the stand-alone RELAP5 thermal-hydraulic model is capable of reproduction of the key features and events of the test. Sufficiently good agreement between the measured and simulated data resulted in a successful verification of the plant model. The Ringhals 4 model is suitable for analysis of other types of transients already in its current state of development. Nevertheless, further refinement in the input is planned as soon as new test data will be available.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

Ringhals 4 NPP  
Power Uprate  
Load Step  
Relap5  
SNAP  
Westinghouse 3-loop Pressurized Water Reactor  
Code Validation

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program





**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**  
WASHINGTON, DC 20555-0001  
\_\_\_\_\_  
OFFICIAL BUSINESS





**NUREG/IA-0468**

**Validation of RELAP5 Model of Ringhals 4 Against a Load Step  
Test at Uprated Power**

**September 2016**