



Byron Generating Station

4450 North German Church Rd
Byron, IL 61010-9794

www.exeloncorp.com

May 3, 2018

LTR: BYRON 2018-0042
File: 1.10.0101 (1D.101)
2.12.1523 (2C.111)

United States Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Byron Station, Units 1 and 2
Renewed Facility Operating License Nos. NPF-37 and NPF-66
NRC Docket Nos. STN 50-454 and STN 50-455

Subject: 2017 Annual Radiological Environmental Operating Report (AREOR)

In accordance with Technical Specification 5.6.2, "Annual Radiological Environmental Operating Report," we are submitting the Annual Radiological Environmental Operating Report (AREOR) for Byron Station. This report is required to be submitted to the NRC by May 15th of each year and contains the results of the radiological environmental and meteorological monitoring programs. The Radioactive Effluent Release Report was submitted under separate cover. Also included are the results of groundwater monitoring conducted in accordance with Exelon's Radiological Groundwater Protection Program (RGPP), which is a voluntary program implemented in 2006. This information is being reported in accordance with a nuclear industry initiative.

If you have any questions regarding this information, please contact Mr. Douglas Spitzer, Regulatory Assurance Manager, at (815) 406-2800.

Respectfully,

A handwritten signature in black ink, appearing to read "Mark E. Kanavos", with a long horizontal flourish extending to the right.

Mark E. Kanavos
Site Vice President
Byron Generating Station

MEK/JG/LZ/rm

Attachment: AREOR Report

cc: Regional Administrator – NRC Region III

NRC.Docket No: 50-454
50-455

BYRON NUCLEAR GENERATING STATION UNITS 1 and 2

**Annual Radiological
Environmental Operating Report**

1 January Through 31 December 2017

Prepared By

**Teledyne Brown Engineering
Environmental Services**



**Byron Nuclear Generating Station
Byron, IL 61010**

April 2018

Intentionally left blank

Table Of Contents

I. Summary and Conclusions.....	1
II. Introduction.....	2
A. Objectives of the REMP	2
B. Implementation of the Objectives.....	2
III. Program Description	2
A. Sample Collection	2
B. Sample Analysis.....	5
C. Data Interpretation	5
D. Program Exceptions.....	6
E. Program Changes	7
IV. Results and Discussion	7
A. Aquatic Environment	7
1. Surface Water.....	7
2. Ground Water	8
3. Fish	9
4. Sediment.....	9
B. Atmospheric Environment.....	10
1. Airborne	10
a. Air Particulates	10
b. Airborne Iodine	11
2. Terrestrial.....	11
a. Milk	11
b. Vegetation	11
C. Ambient Gamma Radiation.....	12
D. Land Use Survey.....	12
E. Errata Data	12
F. Summary of Results – Inter-laboratory Comparison Program	13

Appendices

Appendix A Radiological Environmental Monitoring Report Summary

Tables

Table A-1 Radiological Environmental Monitoring Program Annual Summary for Byron Nuclear Generating Station, 2017

Appendix B Location Designation, Distance & Direction, and Sample Collection & Analytical Methods

Tables

Table B-1 Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Byron Nuclear Generating Station, 2017

Table B-2 Radiological Environmental Monitoring Program - Summary of Sample Collection and Analytical Methods, Byron Nuclear Generating Station, 2017

Figures

Figure B-1 Inner Ring and Special Interest OSLD Locations of the Byron Nuclear Generating Station, 2017

Figure B-2 Outer Ring OSLD Locations of the Byron Nuclear Generating Station, 2017

Figure B-3 Onsite Air Sampling Locations of the Byron Nuclear Generating Station, 2017

Figure B-4 Offsite Air Sampling Locations of the Byron Nuclear Generating Station, 2017

Figure B-5 Ingestion and Waterborne Exposure Pathway Sampling Locations of the Byron Nuclear Generating Station, 2017

Appendix C Data Tables and Figures - Primary Laboratory

Tables

Table C-I.1 Concentrations of Gross Beta in Surface Water Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017.

Table C-I.2 Concentrations of Tritium in Surface Water Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017.

Table C-I.3 Concentrations of Nickel-63 in Surface Water Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017

Table C-I.4 Concentrations of Gamma Emitters in Surface Water Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017

Table C-II.1	Concentrations of Tritium in Ground Water Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017
Table C-II.2	Concentrations of Gamma Emitters in Ground Water Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017
Table C-III.1	Concentrations of Nickel-63 and Gamma Emitters in Fish Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017
Table C-IV.1	Concentrations of Nickel-63 and Gamma Emitters in Sediment Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017
Table C-V.1	Concentrations of Gross Beta in Air Particulate Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017
Table C-V.2	Monthly and Yearly Mean Values of Gross Beta Concentrations in Air Particulate Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017
Table C-V.3	Concentrations of Gamma Emitters in Air Particulate Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017
Table C-VI.1	Concentrations of I-131 in Air Iodine Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017
Table C-VII.1	Concentrations of I-131 in Milk Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017
Table C-VII.2	Concentrations of Gamma Emitters in Milk Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017
Table C-VIII.1	Concentrations of Gamma Emitters in Vegetation Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017
Table C-IX.1	Quarterly OSLD Results for Byron Nuclear Generating Station, 2017
Table C-IX.2	Mean Quarterly OSLD Results for the Inner Ring, Outer Ring, Special Interest, Other and Control Locations for Byron Nuclear Generating Station, 2017
Table C-IX.3	Summary of the Ambient Dosimetry Program for Byron Nuclear Generating Station, 2017

Figures

Figure C-1	Surface Water - Gross Beta – Stations BY-12 and BY-29 (C) Collected in the Vicinity of BNGS, 2000 - 2017
Figure C-2	Surface Water - Tritium – Stations BY-12 and BY-29 (C) Collected in the Vicinity of BNGS, 2000 – 2017
Figure C-3	Ground Water - Tritium – Station BY-14-1 Collected in the Vicinity of BNGS, 2000 – 2017

- Figure C-4 Ground Water - Tritium – Station BY-18-1 Collected in the Vicinity of BNGS, 2010 – 2017
- Figure C-5 Ground Water - Tritium – Station BY-32 Collected in the Vicinity of BNGS, 2006 – 2017
- Figure C-6 Ground Water - Tritium – Stations BY-35 Collected in the Vicinity of BNGS, 2006 – 2017
- Figure C-7 Ground Water - Tritium – Stations BY-37 and BY-38 Collected in the Vicinity of BNGS, 2006 – 2017
- Figure C-8 Air Particulate – Gross Beta – Stations BY-08 (C) and BY-21 Collected in the Vicinity of BNGS, 2000 - 2017
- Figure C-9 Air Particulate – Gross Beta – Stations BY-22 and BY-23 Collected in the Vicinity of BNGS, 2000 - 2017
- Figure C-10 Air Particulate – Gross Beta – Station BY-24 Collected in the Vicinity of BNGS, 2000 - 2017
- Figure C-11 Air Particulate – Gross Beta – Stations BY-01 and BY-04 Collected in the Vicinity of BNGS, 2005 - 2017
- Figure C-12 Air Particulate – Gross Beta – Station BY-06 Collected in the Vicinity of BNGS, 2005 – 2017

Appendix D Inter-Laboratory Comparison Program

Tables

- Table D-1 Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering, 2017
- Table D-2 DOE’s Mixed Analyte Performance Evaluation Program (MAPEP)
Teledyne Brown Engineering, 2017
- Table D-3 ERA Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering, 2017

Appendix E Effluent Report

Appendix E-1 Data Tables and Figures

Appendix F Meteorological Data

Appendix G Errata data

Appendix H Annual Radiological Groundwater Protection Program Report (ARGPPR)

Intentionally left blank

I. Summary and Conclusions

This report on the Radiological Environmental Monitoring Program conducted for the Byron Nuclear Generating Station by Exelon covers the period 1 January 2017 through 31 December 2017. During that time period, 1,471 analyses were performed on 1,307 samples. In assessing all the data gathered for this report and comparing these results with preoperational data, it was concluded that the operation of BNGS had no adverse radiological impact on the environment.

Surface water samples were analyzed for concentrations of gross beta, tritium, Nickel-63 (Ni-63), and gamma-emitting nuclides. Ground water samples were analyzed for concentrations of tritium and gamma-emitting nuclides. Gross beta activities detected were consistent with those detected in previous years. All surface water samples analyzed for Ni-63 were less than the minimum detectable concentration. Tritium detected in downstream surface water was well below reportable limits and consistent with expected levels as a result of permitted liquid discharges.

Fish (commercially and/or recreationally important species) and sediment samples were analyzed for concentrations of Ni-63 and gamma-emitting nuclides. Non-plant produced Cesium-137 (Cs-137) activity was detected at one sediment location at a concentration of 202 pCi/kg. Low levels of Cs-137 are detected occasionally and are consistent with data from previous years and are not a result of plant effluents.

Air particulate samples were analyzed for concentrations of gross beta and gamma-emitting nuclides. No fission or activation products were detected.

High sensitivity Iodine-131 (I-131) analyses were performed on weekly air samples. All results were less than the minimum detectable concentration for I-131.

Cow milk samples were analyzed for concentrations of I-131 and gamma-emitting nuclides. All I-131 results were below the minimum detectable activity. No fission or activation products were found.

Food Product samples were analyzed for concentrations of gamma-emitting nuclides. No fission or activation products were detected.

Environmental gamma radiation measurements were performed quarterly using Optically Stimulated Luminescence Dosimeters (OSLD). Beginning in 2012, Exelon changed the type of dosimetry used for the Radiological Environmental Monitoring Program (REMP). Optically Stimulated Luminescent Dosimetry were deployed and Thermoluminescent Dosimetry (TLD) were discontinued. This change may result in a step change in readings, up or down, depending on site characteristics. The relative comparison to control locations remains valid. OSLD technology is different than that used in a TLD but has the same purpose (to measure direct radiation).

Intentionally left blank

II. Introduction

Byron Station, a two-unit PWR station, is located about two miles east of the Rock River and approximately three miles southwest of Byron in Ogle County, Illinois. The reactors are designed to have capacities of 1,268 and 1,241 MW gross, respectively. Unit One loaded fuel in November 1984 and went on line February 2, 1985. Unit Two went on line January 9, 1987. The station has been designed to keep releases to the environment at levels below those specified in the codes of federal regulations.

This report covers those analyses performed by Teledyne Brown Engineering (TBE) and Landauer on samples collected during the period 1 January 2017 through 31 December 2017.

A. Objectives of the REMP

The objectives of the REMP are to:

1. Provide data on measurable levels of radiation and radioactive materials in the site environs.
2. Evaluate the relationship between quantities of radioactive material released from the plant and resultant radiation doses to individuals from principal pathways of exposure.

B. Implementation of the Objectives

The implementation of the objectives is accomplished by:

1. Identifying significant exposure pathways
2. Establishing baseline radiological data of media within those pathways
3. Continuously monitoring those media before and during Station operation to assess Station radiological effects (if any) on man and the environment

III. Program Description

A. Sample Collection

Samples for the BNGS REMP were collected for Exelon Nuclear by Environmental Inc. (Midwest Labs). This section describes the general collection methods used by Environmental Inc. to obtain environmental samples for the BNGS REMP in 2017. Sample locations and descriptions

can be found in Table B-1 and Figures B-1 through B-5, Appendix B.

Aquatic Environment

The aquatic environment was evaluated by performing radiological analyses on samples of surface water, ground water, fish and sediment. Two gallon water samples were collected weekly from two surface water locations (BY-12 and BY-29 [Control location]) and quarterly from six ground water locations (BY-14-1, BY-18-1, BY-32, BY-35, BY-37 and BY-38). All samples were collected in new unused plastic bottles, which were rinsed with source water prior to collection. Fish samples comprising the flesh of freshwater drum, silver redhorse, golden redhorse, river carpsucker, bigmouth buffalo and common carp were collected semiannually at two locations, BY-29 (control) and BY-31. Sediment samples composed of recently deposited substrate were collected at two locations semiannually, BY-12 and BY-34 (control).

Atmospheric Environment

The atmospheric environment was evaluated by performing radiological analyses on samples of air particulate, and airborne iodine. Airborne iodine and particulate samples were collected and analyzed weekly at eight locations (BY-01, BY-04, BY-06, BY-08, BY-21, BY-22, BY-23 and BY-24). The control location was BY-08. Airborne iodine and air particulate samples were obtained at each location, using a vacuum pump with charcoal and glass fiber filters attached. The pumps ran continuously and sampled air at the rate of approximately one cubic foot per minute. The air filters and air iodine samples were replaced weekly and sent to the laboratory for analysis.

Terrestrial Environment

The terrestrial environment was evaluated by performing radiological analyses on samples of milk and food products. Milk samples were collected monthly from January through April and November through December, and biweekly May through October. The control location was BY-26-2 and the indicator location was BY-20-1. All samples were collected in new unused two gallon plastic bottles from the bulk tank at each location, preserved with sodium bisulfite and shipped promptly to the laboratory.

Food products were collected annually in August at five locations (BY-Control, BY-Quad 1, BY-Quad 2, BY-Quad 3 and BY-Quad 4). Various types of samples were collected and placed in new unused plastic bags, and sent to the laboratory for analysis.

Ambient Gamma Radiation

Beginning in 2012, Exelon changed the type of dosimetry used for the Radiological Environmental Monitoring Program (REMP). Optically Stimulated Luminescent Dosimetry (OSLD) were deployed and Thermoluminescent Dosimetry (TLD) were discontinued. This change may result in a step change in readings, up or down, depending on site characteristics. The relative comparison to control locations remains valid. OSLD technology is different than that used in a TLD but has the same purpose (to measure direct radiation).

Each location consisted of 2 OSLD sets. The OSLDs were exchanged quarterly and sent to Landauer for analysis. The OSLDs were placed at locations on and around the BNGS Station site as follows:

An inner ring consisting of 16 locations (BY-101, BY-102, BY-103, BY-104, BY-105, BY-106, BY-107, BY-108, BY-109, BY-110, BY-111, BY-112, BY-113, BY-114, BY-115 and BY-116) near and within the site perimeter representing fence post doses (i.e., at locations where the doses will be potentially greater than maximum annual off-site doses) from BNGS releases.

An outer ring consisting of 16 locations (BY-201, BY-202, BY-203, BY-204, BY-205, BY-206, BY-207, BY-208, BY-209, BY-210, BY-211, BY-212, BY-213, BY-214, BY-215 and BY-216) extending to approximately 5 miles from the site designed to measure possible exposures to close-in population.

A special interest set consisting of seven locations (BY-301-1, BY-301-2, BY-309-1, BY-309-2, BY-309-3, BY-309-4, and BY-314-2) to measure possible exposures from on-site storage facilities.

An other set consisting of seven locations (BY-01, BY-04, BY-06, BY-21, BY-22, BY-23 and BY-24) at locations where air samplers are present.

The balance of one location (BY-08) representing the control area.

The specific OSLD locations were determined by the following criteria:

1. The presence of relatively dense population;
2. Site meteorological data taking into account distance and elevation for each of the sixteen–22 1/2 degree sectors around the site, where estimated annual dose from BNGS, if any, would be most significant;

3. On hills free from local obstructions and within sight of the vents (where practical);
4. And near the closest dwelling to the vents in the prevailing downwind direction if applicable.

Two OSLDs were placed at each location located at a minimum of five feet above ground level. The OSLDs were exchanged quarterly and sent to Landauer for analysis.

B. Sample Analysis

This section describes the general analytical methodologies used by TBE to analyze the environmental samples for radioactivity for the BNGS REMP in 2017. The analytical procedures used by the laboratory are listed in Table B-2.

In order to achieve the stated objectives, the current program includes the following analyses:

1. Concentrations of beta emitters in surface water and air particulates
2. Concentrations of gamma emitters in ground and surface water, air particulates, milk, fish, sediment and vegetation
3. Concentrations of tritium in ground and surface water
4. Concentrations of Iodine-131 in air and milk
5. Concentrations of Nickel-63 in surface water, fish and sediment
6. Ambient gamma radiation levels at various site environs

C. Data Interpretation

The radiological and direct radiation data collected prior to Byron Nuclear Generating Station becoming operational were used as a baseline with which these operational data were compared. For the purpose of this report, Byron Nuclear Generating Station was considered operational at initial criticality. In addition, data were compared to previous years' operational data for consistency and trending. Several factors were important in the interpretation of the data:

1. Lower Limit of Detection and Minimum Detectable Concentration

The lower limit of detection (LLD) was defined as the smallest concentration of radioactive material in a sample that would yield a net count (above background) that would be detected with only a 5% probability of falsely concluding that a blank observation represents a "real" signal. The LLD was intended as a before-the-fact estimate of a system (including instrumentation, procedure and sample type) and not as an after-the-fact criteria for the presence of activity. All analyses were designed to achieve the required BNGS detection capabilities for environmental sample analysis. The minimum detectable concentration (MDC) is defined above with the exception that the measurement is an after-the-fact estimate of the presence of activity.

2. Net Activity Calculation and Reporting of Results

Net activity for a sample was calculated by subtracting background activity from the sample activity. Since the REMP measures extremely small changes in radioactivity in the environment, background variations may result in sample activity being lower than the background activity, effecting a negative number. An MDC was reported in all cases where positive activity was not detected.

Gamma spectroscopy results for each type of sample were grouped as follows:

For surface water, ground water and vegetation twelve nuclides, Mn-54, Co-58, Fe-59, Co-60, Zn-65, Nb-95, Zr-95, I-131, Cs-134, Cs-137, Ba-140 and La-140 were reported.

For fish, sediment, air particulate and milk eleven nuclides, Mn-54, Co-58, Fe-59, Co-60, Zn-65, Nb-95, Zr-95, Cs-134, Cs-137, Ba-140 and La-140 were reported.

Means and standard deviations of the results were calculated. The standard deviations represent the variability of measured results for different samples rather than single analysis uncertainty.

D. Program Exceptions

For 2017, the BNGS REMP had a sample recovery rate in excess of 99%. Sample anomalies and missed samples are listed in the tables below:

TABLE D-1 LISTING OF SAMPLE ANOMALIES

Sample Type	Location Code	Collection Date	Reason
OLSD	BY-22-2	01/09/18	4 th Qtr dosimeter found on ground during exchange

TABLE D-2 LISTING OF MISSED SAMPLES

Sample Type	Location Code	Collection Date	Reason
SW	BY-29	01/03/17	No sample, water frozen
SW	BY-29	01/10/17	No sample, water frozen
OLSD	BY-213-4	05/01/17	Dosimeter missing during monthly checks; replaced with Spare #1
SW	BY-29	12/12/17	No sample, water frozen
SW	BY-12 BY-19	12/27/17	No sample, water frozen

Each program exception was reviewed to understand the causes of the program exception. Sampling and maintenance errors were reviewed with the personnel involved to prevent recurrence. Occasional equipment breakdowns and power outages were unavoidable.

The overall sample recovery rate indicates that the appropriate procedures and equipment are in place to assure reliable program implementation.

E. Program Changes

There were no program changes in 2017.

IV. Results and Discussion

A. Aquatic Environment

1. Surface Water

Samples were taken weekly and composited monthly at two locations (BY-12 and BY-29). Of these locations only BY-12 located downstream, could be affected by Byron Nuclear Generating Station's effluent releases. The following analyses

were performed:

Gross Beta

Samples from both locations were analyzed for concentrations of gross beta (Table C–I.1, Appendix C). The values ranged from 2.5 to 6.7 pCi/l. Concentrations detected were consistent with those detected in previous years (Figure C–1, Appendix C).

Tritium

Quarterly composites of weekly collections were analyzed for tritium activity (Table C–I.2, Appendix C). Tritium was detected in two samples. The concentrations ranged from 293 – 6110 pCi/L (Figure C–2, Appendix C). Tritium detected in downstream surface water was well below reportable limits and consistent with expected levels as a result of permitted liquid discharges.

Nickel

Samples from both locations were analyzed for concentration of Ni-63 (Table C–I.3, Appendix C). All results were less than the minimum detectable concentration.

Gamma Spectrometry

Samples from both locations were analyzed for gamma-emitting nuclides (Table C–I.4, Appendix C). No nuclides were detected, and all required LLDs were met.

2. Ground Water

Quarterly grab samples were collected at six locations (BY-14-1, BY-18-1, BY-32, BY-35, BY-37 and BY-38). These locations could be affected by Byron Nuclear Generating Station's effluent releases. The following analyses were performed:

Tritium

Quarterly grab samples from the locations were analyzed for tritium activity (Table C–II.1, Appendix C). No tritium was detected, and the required LLD was met (Figures C–3 through C–7, Appendix C).

Gamma Spectrometry

Samples from all locations were analyzed for gamma-emitting nuclides (Table C–II.2 Appendix C). No nuclides were detected, and all required LLDs were met.

3. Fish

Fish samples comprised of freshwater drum, silver redhorse, golden redhorse, river carpsucker, bigmouth buffalo and common carp were collected at two locations (BY-29 and BY-31) semiannually. Location BY-31 could be affected by Byron Nuclear Generating Station's effluent releases. The following analyses were performed:

Nickel

The edible portion of fish samples from both locations was analyzed for Ni-63 (Table C–III.1, Appendix C). Nickel-63 was not detected and the required LLD was met.

Gamma Spectrometry

The edible portion of fish samples from both locations was analyzed for gamma-emitting nuclides (Table C–III.1, Appendix C). No nuclides were detected, and all required LLDs were met.

4. Sediment

Aquatic sediment samples were collected at two locations (BY-12 and BY-34) semiannually. BY-12, located downstream, could be affected by Byron Nuclear Generating Station's effluent releases. The following analyses were performed:

Nickel

Sediment samples from both locations were analyzed for Ni-63 (Table C–IV.1, Appendix C). Ni-63 was not detected and the required LLD was met.

Gamma Spectrometry

Sediment samples from both locations were analyzed for gamma-emitting nuclides (Table C–IV.1, Appendix C). Cesium-137 was detected in one sample. The concentration was 202 pCi/kg dry. The concentrations detected was consistent with those detected in

previous years and is not a result of plant effluents. No other nuclides were detected, and all required LLDs were met.

B. Atmospheric Environment

1. Airborne

a. Air Particulates

Continuous air particulate samples were collected from eight locations on a weekly basis. The eight locations were separated into three groups: Nearsite samplers within 4 km of the site (BY-21, BY-22, BY-23 and BY-24), Far Field samplers between 4 and 10 km of the site (BY-01, BY-04 and BY-06) and the Control sampler between 10 and 30 km from the site (BY-08). The following analyses were performed:

Gross Beta

Weekly samples were analyzed for concentrations of beta emitters (Table C-V.1 and C-V.2, Appendix C). Detectable gross beta activity was observed at all locations. Comparison of results among the three groups aid in determining the effects, if any, resulting from the operation of BNGS.

The results from the Nearsite locations (Group I) ranged from 5 to 32E-3 pCi/m³ with a mean of 17E-3 pCi/m³. The results from the Far Field locations (Group II) ranged from 6 to 27E-3 pCi/m³ with a mean of 17E-3 pCi/m³. The results from the Control location (Group III) ranged from 8 to 31 E-3 pCi/m³ with a mean of 18 E-3 pCi/m³. Comparison of the 2017 air particulate data with previous year's data indicate no effects from the operation of BNGS. In addition, a comparison of the weekly mean values for 2017 indicate no notable differences among the three groups (Figures C-8 through C-12, Appendix C).

Gamma Spectrometry

Weekly samples were composited quarterly and analyzed for gamma-emitting nuclides (Table C-V.3, Appendix C). No nuclides were detected, and all required LLDs were met.

b. Airborne Iodine

Continuous air samples were collected from eight locations (BY-01, BY-04, BY-06, BY-08, BY-21, BY-22, BY-23 and BY-24) and analyzed weekly for I-131 (Table C–VI.1, Appendix C). All results were less than the minimum detectable concentration for I-131.

2. Terrestrial

a. Milk

Samples were collected from two locations (BY-20-1 and BY-26-2) monthly from January to April and November through December, and biweekly May through October. The following analyses were performed:

Iodine-131

Milk samples from all locations were analyzed for concentrations of I-131 (Table C–VII.1, Appendix C). No nuclides were detected, and all required LLDs were met.

Gamma Spectrometry

Each milk sample was analyzed for concentrations of gamma-emitting nuclides (Table C–VII.2, Appendix C). No nuclides were detected, and all required LLDs were met.

b. Vegetation

Vegetation samples were collected at five locations (BY-Control, BY-Quad 1, BY-Quad 2, BY-Quad 3 and BY-Quad 4). Four locations (BY-Quad 1, BY-Quad 2, BY-Quad 3 and BY-Quad 4) could be affected by Byron Nuclear Generating Station's effluent releases. The following analysis was performed:

Gamma Spectrometry

Samples from all locations were analyzed for gamma-emitting nuclides (Table C–VIII.1, Appendix C). No nuclides were detected, and all required LLDs were met.

C. Ambient Gamma Radiation

Ambient gamma radiation levels were measured utilizing OSLDs. Ninety-one OSLD locations were established around the site. Results of OSLD measurements are listed in Tables C–IX.1 to C–IX.3, Appendix C.

All OSLD measurements were below 31 mR/standard quarter, with a range of 15 to 31 mR/standard quarter. A comparison of the Inner Ring, Outer Ring, Special Interest, Other and Control Location data indicate that the ambient gamma radiation levels were comparable among the groups.

D. Land Use Survey

A Land Use Survey conducted during August 2017 around the Byron Nuclear Generating Station (BNGS) was performed by Environmental Inc. (Midwest Labs) for Exelon Nuclear to comply with the Byron Nuclear Generating Station’s Offsite Dose Calculation Manual. The purpose of the survey was to document the nearest resident, livestock, and milk producing animals in each of the sixteen 22 ½ degree sectors. The results of this survey are summarized below:

Distance in Miles from the BNGS Vent Stacks			
Sector	Residence Miles	Livestock Miles	Milk Farm Miles
A N	1.2	5.9	-
B NNE	1.6	1.6	-
C NE	1.1	4.6	-
D ENE	1.4	3.5	-
E E	1.2	4.2	-
F ESE	1.5	1.5	-
G SE	1.7	4.3	-
H SSE	0.7	3.3	-
J S	0.6	0.7	-
K SSW	0.7	1.0	-
L SW	0.8	2.0	-
M WSW ^(a)	1.6	0.8	4.5
N W	1.8	3.4	-
P WNW	1.6	5.3	11.5
Q NW	0.8	1.5	-
R NNW	0.9	1.4	-

^(a) Denotes the nearest industrial facility located at 1.5 miles

E. Errata Data

There was no errata data for 2017.

F. Summary of Results – Inter-Laboratory Comparison Program

The TBE Laboratory analyzed Performance Evaluation (PE) samples of air particulate, air iodine (charcoal), milk, soil, vegetation and water (including fish) matrices (Appendix D). The PE sample matrices were chosen based on the types of samples submitted to the primary laboratory for analysis. The selected parameters for the PE samples are based on the appropriate matrices, methodologies and geometries, which include geometries that are comparable. The PE samples, supplied by Analytics Inc., Environmental Resource Associates (ERA) and DOE's Mixed Analyte Performance Program (MAPEP) were evaluated against the following pre-set acceptance criteria:

1. Analytics Evaluation Criteria

Analytics' evaluation report provides a ratio of laboratory results and Analytics' known value. Since flag values are not assigned by Analytics, TBE-ES evaluates the reported ratios based on internal QC requirements, which are based on the DOE MAPEP criteria.

2. ERA Evaluation Criteria

ERA's evaluation report provides an acceptance range for control and warning limits with associated flag values. ERA's acceptance limits are established per the USEPA, NELAC, state specific PT program requirements or ERA's SOP for the Generation of Performance Acceptance Limits, as applicable. The acceptance limits are either determined by a regression equation specific to each analyte or a fixed percentage limit promulgated under the appropriate regulatory document.

3. DOE Evaluation Criteria

MAPEP's evaluation report provides an acceptance range with associated flag values. MAPEP defines three levels of performance:

- Acceptable (flag = "A") - result within $\pm 20\%$ of the reference value
- Acceptable with Warning (flag = "W") - result falls in the $\pm 20\%$ to $\pm 30\%$ of the reference value
- Not Acceptable (flag = "N") - bias is greater than 30% of the reference value

Note: The Department of Energy (DOE) Mixed Analyte Performance Evaluation Program (MAPEP) samples are created to mimic conditions found at DOE sites which do not resemble typical environmental samples obtained at commercial nuclear power

facilities.

For the TBE laboratory, 168 out of 173 analyses performed met the specified acceptance criteria. Five analyses did not meet the specified acceptance criteria for the following reasons and were addressed through the TBE Corrective Action Program.

1. The ERA April 2017 two nuclides in water were evaluated as *Not Acceptable*. (NCR 17-09)
 - a. The Zn-65 result of 39.3 pCi/L, exceeded the lower acceptance limit of 47.2. The known value was unusually low for this study. The sample was run in duplicate on two different detectors. The results of each were 39.3 ± 18.2 pCi/L (46% error and lower efficiency) and 59.3 ± 8.23 pCi/L (13.9% error and higher efficiency). The result from the 2nd detector would have been well within the acceptable range (47.2 – 65.9) and 110.2% of the known value of 53.8 pCi/L.
 - b. The Sr-89 result of 40.7 pCi/L exceeded the lower acceptance limit of 53.8. All associated QC and recoveries were reviewed and no apparent cause could be determined for the failure. The prior three cross-check results were from 99 – 115% of the known values and the one that followed this sample (November, 2017) was 114% of the known value.
2. The DOE MAPEP August 2017 air particulate U-238 result of 0.115 ± 0.025 Bq/sample was higher than the known value of 0.087 ± 0.002 with a ratio of 1.32, therefore the upper ratio of 1.30 (acceptable with warning) was exceeded. TBE's result with error easily overlaps with the acceptable range. MAPEP does not evaluate results with any associated error. Also, the spike level for this sample was very low (2.35 pCi) compared to TBE's normal LCS of 6 pCi. TBE considers this result as passing. (NCR 17-15)
3. The Analytics September 2017 soil Cr-51 result was evaluated as *Not Acceptable* (Ratio of TBE to known result at 0.65). The reported value was 0.230 ± 0.144 pCi/g and the known value was 0.355 ± 0.00592 pCi/g. The sample was counted overnight for 14 hours, however the Cr-51 was spiked at a very low level and had a counting error of 65%. Cr-51 has a 27-day half-life, making low-level quantification even more difficult. The error does not appear to have been taken into consideration for this result. If it had been evaluated with the error, the highest result would have been 105% of the reference value, which is acceptable. Also, the known value is significantly lower than TBE's typical MDC for this nuclide in a soil matrix and would typically not be reported to clients (unless

specified). The results of all of the previous cross-checks have been in the acceptable (80 – 120%) range. TBE will evaluate further upon completion of the next ICP sample. (NCR 17-16)

4. The ERA November 2017 water Sr-90 sample was evaluated as *Not Acceptable*. TBE's result of 27.1 pCi/L exceeded the lower acceptance range (30.8 – 48.0 pCi/L). After reviewing the associated QC data for this sample, it was determined that although the spike recovery for Sr-90 was within our laboratory guidelines (70% -130%), both the spike result and our ERA result were biased low. The original cross-check sample was completely consumed and we were unable to reanalyze before submitting the result. We have modified our preparation process to avoid this situation for future cross-check samples. We also have enhanced LIMS programming to force a LCSD when a workgroup includes cross-check samples (as opposed to running a DUP). (NCR 17-19)

The Inter-Laboratory Comparison Program provides evidence of “in control” counting systems and methods, and that the laboratories are producing accurate and reliable data.

Intentionally left blank

APPENDIX A

RADIOLOGICAL ENVIRONMENTAL MONITORING REPORT SUMMARY

Intentionally left blank

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR
BYRON NUCLEAR GENERATING STATION, 2017**

NAME OF FACILITY:		BYRON NUCLEAR GENERATING STATION		DOCKET NUMBER:		50-454 & 50-455			
LOCATION OF FACILITY:		BYRON, IL		REPORTING PERIOD:				2017	
MEDIUM OR PATHWAY SAMPLED <i>(Unit of Measurement)</i>	TYPES OF ANALYSIS PERFORMED	NUMBER OF ANALYSIS PERFORMED	REQUIRED LOWER LIMIT OF DETECTION (LLD)	INDICATOR		CONTROL		LOCATION WITH HIGHEST ANNUAL MEAN (M) MEAN (M) STATION # NAME DISTANCE AND DIRECTION	NUMBER OF NONROUTINE REPORTED MEASUREMENTS
				LOCATIONS MEAN (M) (F) RANGE	LOCATIONS MEAN (M) (F) RANGE	LOCATIONS MEAN (M) (F) RANGE	LOCATIONS MEAN (M) (F) RANGE		
SURFACE WATER <i>(PC/LITER)</i>	GR-B	24	4	4.2 (9/12) 3.1 - 5.6	4.3 (10/12) 2.5 - 6.7	4.3 (10/12) 2.5 - 6.7	4.3 (10/12) 2.5 - 6.7	BY-29 CONTROL Byron - Upstream 3.0 MILES N OF SITE	0
	H-3	8	200	3202 (2/4) 293 - 6110	<LLD	<LLD	3202 (2/4) 293 - 6110	BY-12 INDICATOR Oregon Pool of Rock River - Downstream 4.5 MILES SSW OF SITE	0
	NI-63	24	30	<LLD	<LLD	<LLD	-		0
	GAMMA	24							
			15	<LLD	<LLD	<LLD	-		0
			15	<LLD	<LLD	<LLD	-		0
			30	<LLD	<LLD	<LLD	-		0
			15	<LLD	<LLD	<LLD	-		0
			30	<LLD	<LLD	<LLD	-		0
			15	<LLD	<LLD	<LLD	-		0
			30	<LLD	<LLD	<LLD	-		0
			15	<LLD	<LLD	<LLD	-		0
			15	<LLD	<LLD	<LLD	-		0
			18	<LLD	<LLD	<LLD	-		0
			60	<LLD	<LLD	<LLD	-		0
			15	<LLD	<LLD	<LLD	-		0
GROUND WATER <i>(PC/LITER)</i>	H-3	24	200	<LLD	NA	NA	-		0
	GAMMA	24							
			15	<LLD	NA	NA	-		0
			15	<LLD	NA	NA	-		0
			30	<LLD	NA	NA	-		0
			15	<LLD	NA	NA	-		0
			30	<LLD	NA	NA	-		0
			15	<LLD	NA	NA	-		0
			30	<LLD	NA	NA	-		0
			15	<LLD	NA	NA	-		0
			15	<LLD	NA	NA	-		0
			18	<LLD	NA	NA	-		0
			60	<LLD	NA	NA	-		0
			15	<LLD	NA	NA	-		0

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR
BYRON NUCLEAR GENERATING STATION, 2017

NAME OF FACILITY:		BYRON NUCLEAR GENERATING STATION		DOCKET NUMBER:		50-454 & 50-455			
LOCATION OF FACILITY:		BYRON, IL		REPORTING PERIOD:				2017	
MEDIUM OR PATHWAY SAMPLED <i>(Unit of Measurement)</i>	TYPES OF ANALYSIS PERFORMED	NUMBER OF ANALYSIS PERFORMED	REQUIRED LOWER LIMIT OF DETECTION (LLD)	INDICATOR		CONTROL		LOCATION WITH HIGHEST ANNUAL MEAN (M) STATION # NAME	NUMBER OF NONROUTINE REPORTED MEASUREMENTS
				LOCATIONS MEAN (M) (F) RANGE	LOCATION MEAN (M) (F) RANGE	LOCATION WITH HIGHEST ANNUAL MEAN (M) STATION # NAME	DISTANCE AND DIRECTION		
FISH <i>(PCI/KG WET)</i>		8	260	<LLD	<LLD	<LLD	-		0
	GAMMA	8							
	MN-54		130	<LLD	<LLD	<LLD	-		0
	CO-58		130	<LLD	<LLD	<LLD	-		0
	FE-59		260	<LLD	<LLD	<LLD	-		0
	CO-60		130	<LLD	<LLD	<LLD	-		0
	ZN-65		260	<LLD	<LLD	<LLD	-		0
	NB-95		NA	<LLD	<LLD	<LLD	-		0
	ZR-95		NA	<LLD	<LLD	<LLD	-		0
	CS-134		130	<LLD	<LLD	<LLD	-		0
	CS-137		150	<LLD	<LLD	<LLD	-		0
	BA-140		NA	<LLD	<LLD	<LLD	-		0
	LA-140		NA	<LLD	<LLD	<LLD	-		0
SEDIMENT <i>(PCI/KG DRY)</i>		4	260	<LLD	<LLD	<LLD	-		0
	NI-63	4	260	<LLD	<LLD	<LLD	-		0
	GAMMA	4							
	MN-54		NA	<LLD	<LLD	<LLD	-		0
	CO-58		NA	<LLD	<LLD	<LLD	-		0
	FE-59		NA	<LLD	<LLD	<LLD	-		0
	CO-60		NA	<LLD	<LLD	<LLD	-		0
	ZN-65		NA	<LLD	<LLD	<LLD	-		0
	NB-95		NA	<LLD	<LLD	<LLD	-		0
	ZR-95		NA	<LLD	<LLD	<LLD	-		0
	CS-134		150	<LLD	<LLD	<LLD	-		0
	CS-137		180	<LLD	<LLD	<LLD	-		0
				202 (1/2)	202 (1/2)	202 (1/2)	BY-12 INDICATOR Oregon Pool of Rock River - Downstream 4.5 MILES SSW OF SITE		0
	BA-140		NA	<LLD	<LLD	<LLD	-		0
	LA-140		NA	<LLD	<LLD	<LLD	-		0

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR
BYRON NUCLEAR GENERATING STATION, 2017**

NAME OF FACILITY:		BYRON NUCLEAR GENERATING STATION		DOCKET NUMBER: 50-454 & 50-455		REPORTING PERIOD: 2017			
LOCATION OF FACILITY:		BYRON, IL							
MEDIUM OR PATHWAY SAMPLED <i>(Unit of Measurement)</i>	TYPES OF ANALYSIS PERFORMED	NUMBER OF ANALYSIS PERFORMED	REQUIRED LOWER LIMIT OF DETECTION (LLD)	INDICATOR		CONTROL		LOCATION WITH HIGHEST ANNUAL MEAN (M) STATION # NAME DISTANCE AND DIRECTION	NUMBER OF NONROUTINE REPORTED MEASUREMENTS
				LOCATIONS MEAN (M) (F) RANGE	LOCATIONS MEAN (M) (F) RANGE	LOCATIONS MEAN (M) (F) RANGE	LOCATIONS MEAN (M) (F) RANGE		
AIR PARTICULATE (E-3 PC/CU.METER)	GR-B	416	10	17 (360/364) 5 - 32	18 (51/52) 8 - 31	18 (51/52) 8 - 31	BY-08 CONTROL LEAF RIVER 7.0 MILES WNW OF SITE	0	
	GAMMA	32	NA	<LLD	<LLD	<LLD		0	
	MN-54		NA	<LLD	<LLD	<LLD		0	
	CO-58		NA	<LLD	<LLD	<LLD		0	
	FE-59		NA	<LLD	<LLD	<LLD		0	
	CO-60		NA	<LLD	<LLD	<LLD		0	
	ZN-65		NA	<LLD	<LLD	<LLD		0	
	NB-95		NA	<LLD	<LLD	<LLD		0	
	ZR-95		NA	<LLD	<LLD	<LLD		0	
	CS-134		150	<LLD	<LLD	<LLD		0	
	CS-137		180	<LLD	<LLD	<LLD		0	
	BA-140		NA	<LLD	<LLD	<LLD		0	
	LA-140		NA	<LLD	<LLD	<LLD		0	
AIR IODINE (E-3 PC/CU.METER)	GAMMA	416	70	<LLD	<LLD	<LLD		0	
	I-131 (GELI)								
MILK (PC/LITER)	I-131 (LOW LVL)	40	1	<LLD	<LLD	<LLD		0	
	GAMMA	40	NA	<LLD	<LLD	<LLD		0	
	MN-54		NA	<LLD	<LLD	<LLD		0	
	CO-58		NA	<LLD	<LLD	<LLD		0	
	FE-59		NA	<LLD	<LLD	<LLD		0	
	CO-60		NA	<LLD	<LLD	<LLD		0	
	ZN-65		NA	<LLD	<LLD	<LLD		0	
	NB-95		NA	<LLD	<LLD	<LLD		0	
	ZR-95		NA	<LLD	<LLD	<LLD		0	
	CS-134		15	<LLD	<LLD	<LLD		0	
	CS-137		18	<LLD	<LLD	<LLD		0	
	BA-140		60	<LLD	<LLD	<LLD		0	
	LA-140		15	<LLD	<LLD	<LLD		0	

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR
BYRON NUCLEAR GENERATING STATION, 2017

NAME OF FACILITY:		BYRON NUCLEAR GENERATING STATION		DOCKET NUMBER: 50-454 & 50-455					
LOCATION OF FACILITY:		BYRON, IL		REPORTING PERIOD: 2017					
MEDIUM OR PATHWAY SAMPLED (Unit of Measurement)	TYPES OF ANALYSIS PERFORMED	NUMBER OF ANALYSIS PERFORMED	REQUIRED LOWER LIMIT OF DETECTION (LLD)	INDICATOR LOCATIONS MEAN (M) (F) RANGE	CONTROL LOCATION MEAN (M) (F) RANGE	LOCATION WITH HIGHEST ANNUAL MEAN (M) MEAN (M) (F) RANGE	STATION # NAME	DISTANCE AND DIRECTION	NUMBER OF NONROUTINE REPORTED MEASUREMENTS
VEGETATION (PCI/KG WET)	GAMMA	11							
	MN-54		NA	<LLD	<LLD	-			0
	CO-58		NA	<LLD	<LLD	-			0
	FE-59		NA	<LLD	<LLD	-			0
	CO-60		NA	<LLD	<LLD	-			0
	ZN-65		NA	<LLD	<LLD	-			0
	NB-95		NA	<LLD	<LLD	-			0
	ZR-95		NA	<LLD	<LLD	-			0
	I-131		60	<LLD	<LLD	-			0
	CS-134		60	<LLD	<LLD	-			0
	CS-137		80	<LLD	<LLD	-			0
	BA-140		NA	<LLD	<LLD	-			0
	LA-140		NA	<LLD	<LLD	-			0
DIRECT RADIATION (MILLIREM/QTR.)	OSLD-QUARTERLY	364	NA	23.7 (356/356) 15.4 - 31.2	21.2 (8/8) 18.1 - 25.0	27.5 (4/4) 24.3 - 30.2		BY-208-1 INDICATOR 4.0 MILES SSE	0

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

APPENDIX B

LOCATION DESIGNATION, DISTANCE & DIRECTION, AND SAMPLE COLLECTION & ANALYTICAL METHODS

Intentionally Left Blank

TABLE B-1: Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Byron Nuclear Generating Station, 2017

Location	Location Description	Distance & Direction From Site
<u>A. Surface Water</u>		
BY-12	Oregon Pool of Rock River, Downstream	4.5 miles SSW
BY-29	Byron, Upstream (control)	3.0 miles N
<u>B. Ground/Well Water</u>		
BY-14-1	3200 North German Church Road	1.0 miles SSE
BY-18-1	Calhoun	0.7 miles SSW
BY-32	Krueger Well	1.9 miles W
BY-35	Vancko Well	1.9 miles WNW
BY-37	Kavage Well	2.0 miles WNW
BY-38	Steve Storz Well	2.0 miles WNW
<u>C. Milk</u>		
BY-20-1	Ron Snodgrass Farm	4.8 miles WSW
BY-26-2	Joseph Akins Farm (control)	12.2 miles WNW
<u>D. Air Particulates / Air Iodine</u>		
BY-01	Byron	3.0 miles N
BY-04	Paynes Point	5.0 miles SE
BY-06	Oregon	4.7 miles SSW
BY-08	Leaf River (control)	7.0 miles WNW
BY-21	Byron Nearsite North	0.3 miles N
BY-22	Byron Nearsite Southeast	0.4 miles SE
BY-23	Byron Nearsite South	0.6 miles S
BY-24	Byron Nearsite Southwest	0.7 miles SW
<u>E. Fish</u>		
BY-29	Byron, Upstream (control)	3.0 miles N
BY-31	Byron, Discharge	2.6 miles WNW
<u>F. Sediment</u>		
BY-12	Oregon Pool of Rock River, Downstream	4.6 miles SSW
BY-34	Rock River, Upstream of Discharge (control)	2.6 miles WNW
<u>G. Vegetation</u>		
Quadrant 1	5186 N. Cox Road, Stillman Valley	4.8 miles ENE
Quadrant 2	5671 Brick Road, Oregon	4.4 miles SE
Quadrant 3	2002 Deer Path Road, Oregon	0.9 miles SW
Quadrant 4	2770 Breckenridge Dr., Byron	5.3 miles N
Control	17311 E. Edson Rd., Rockford	14.8 miles ENE
<u>H. Environmental Dosimetry - OSLD</u>		
<u>Inner Ring</u>		
BY-101-1 and -2		0.3 miles N
BY-102-1		1.0 miles NNE
BY-102-2		1.0 miles NNE

TABLE B-1: Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Byron Nuclear Generating Station, 2017

Location	Location Description	Distance & Direction From Site
<u>H. Environmental Dosimetry – OSLD (continued)</u>		
<u>Inner Ring</u>		
BY-103-1 and -2		1.7 miles NE
BY-103-3		0.4 miles NE
BY-104-1 and -2		1.4 miles ENE
BY-104-3		0.3 miles ENE
BY-105-1 and -2		1.3 miles E
BY-106-1 and -2		1.4 miles ESE
BY-107-1 and -2		1.4 miles SE
BY-107-3		0.4 miles SE
BY-108-1		0.7 miles SSE
BY-108-2		0.6 miles SSE
BY-109-1 and -2		0.6 miles S
BY-110-1 and -2		0.7 miles SSW
BY-111-3		0.8 miles SW
BY-111-4		0.9 miles SW
BY-112-3 and -4		0.8 miles WSW
BY-113-1 and -2		0.7 miles W
BY-114-1 and -2		0.8 miles WNW
BY-115-1 and -2		1.0 miles NW
BY-116-1 and -2		1.4 miles NNW
BY-116-3		0.9 miles NNW
<u>Outer Ring</u>		
BY-201-3		4.4 miles N
BY-201-4		4.4 miles N
BY-202-1		4.4 miles NNE
BY-202-2		4.8 miles NNE
BY-203-1		4.8 miles NE
BY-203-2		4.7 miles NE
BY-204-1		4.1 miles ENE
BY-204-2		4.0 miles ENE
BY-205-1 and -2		3.8 miles E
BY-206-1		4.0 miles ESE
BY-206-2		4.3 miles ESE
BY-207-1		4.2 miles SE
BY-207-2		3.9 miles SE
BY-208-1		4.0 miles SSE
BY-208-2		3.8 miles SSE
BY-209-1 and -4		4.0 miles S
BY-210-3 and -4		3.9 miles SSW
BY-211-1 and -4		4.9 miles SW
BY-212-1 and -4		4.7 miles WSW
BY-213-1		4.7 miles W
BY-213-4		4.7 miles W
BY-214-1		4.7 miles WNW
BY-214-4		4.6 miles WNW
BY-215-1		4.2 miles NW
BY-215-4		4.2 miles NW
BY-216-1		4.5 miles NNW
BY-216-2		4.7 miles NNW

TABLE B-1: Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Byron Nuclear Generating Station, 2017

Location	Location Description	Distance & Direction From Site
<u>Special Interest</u>		
BY-301-1		0.3 miles N
BY-301-2		0.2 miles N
BY-309-1		0.3 miles S
BY-309-2		0.4 miles S
BY-309-3		0.4 miles S
BY-309-4		0.4 miles SSW
BY-314-2		0.3 miles WNW
<u>Other</u>		
BY-01-1 and -2		3.0 miles N
BY-04-1 and -2		5.0 miles SE
BY-06-1 and -2		4.7 miles SSW
BY-21-1 and -2		0.3 miles N
BY-22-1 and -2		0.4 miles SE
BY-23-1 and -2		0.6 miles S
BY-24-1 and -2		0.7 miles SW
<u>Control</u>		
BY-08-1 and -2		7.0 miles WNW

TABLE B-2: Radiological Environmental Monitoring Program – Summary of Sample Collection and Analytical Methods, Byron Nuclear Generating Station, 2017

Sample Medium	Analysis	Sampling Method	Analytical Procedure Number
Surface Water	Gamma Spectroscopy	Monthly composite from weekly grab samples.	TBE, TBE-2007 Gamma emitting radioisotope analysis
Surface Water	Gross Beta	Monthly composite from weekly grab samples.	TBE, TBE-2008 Gross Alpha and/or gross beta activity in various matrices
Surface Water	Nickel-63	Monthly composite from weekly grab samples.	TBE, TBE-2013 Radionickel activity in various matrices
Surface Water	Tritium	Quarterly composite from weekly grab samples.	TBE, TBE-2011 Tritium analysis in drinking water by liquid scintillation
Ground Water	Gamma Spectroscopy	Quarterly grab samples.	TBE, TBE-2007 Gamma emitting radioisotope analysis
Ground Water	Tritium	Quarterly grab samples.	TBE, TBE-2011 Tritium analysis in drinking water by liquid scintillation
Fish	Gamma Spectroscopy	Semi-annual samples collected via electroshocking or other techniques	TBE-2007 Gamma emitting radioisotope analysis
Fish	Nickel-63	Semi-annual samples collected via electroshocking or other techniques	TBE, TBE-2013 Radionickel activity in various matrices
Sediment	Gamma Spectroscopy	Semi-annual grab samples	TBE, TBE-2007 Gamma emitting radioisotope analysis
Sediment	Nickel-63	Semi-annual grab samples	TBE, TBE-2013 Radionickel activity in various matrices
Air Particulates	Gross Beta	One-week composite of continuous air sampling through glass fiber filter paper	TBE, TBE-2008 Gross Alpha and/or gross beta activity in various matrices
Air Particulates	Gamma Spectroscopy	Quarterly composite of each station	TBE, TBE-2007 Gamma emitting radioisotope analysis
Air Iodine	Gamma Spectroscopy	One-week composite of continuous air sampling through charcoal filter	TBE, TBE-2007 Gamma emitting radioisotope analysis
Milk	I-131	Bi-weekly grab sample when cows are on pasture. Monthly all other times	TBE, TBE-2012 Radioiodine in various matrices
Milk	Gamma Spectroscopy	Bi-weekly grab sample when cows are on pasture. Monthly all other times	TBE, TBE-2007 Gamma emitting radioisotope analysis
Vegetation	Gamma Spectroscopy	Annual grab samples.	TBE, TBE-2007 Gamma emitting radioisotope analysis
OSLD	Optically Stimulated Luminescence Dosimetry	Quarterly OSLDs comprised of two Al ₂ O ₃ :C Landauer Incorporated elements.	Landauer Incorporated




Figure B-1
 Inner Ring and Special Interest OSLD Locations of the
 Byron Nuclear Generating Station, 2017




Figure B-2
 Outer Ring OSLD Locations of the
 Byron Nuclear Generating Station, 2017




Figure B-3
 Onsite Air Sampling Locations of the
 Byron Nuclear Generating Station, 2017




Figure B-4
 Offsite Air Sampling Locations of the
 Byron Nuclear Generating Station, 2017




Figure B-5
Ingestion and Waterborne Exposure Pathway Sampling Locations
of the Byron Nuclear Generating Station, 2017

Intentionally left blank

APPENDIX C

DATA TABLES AND FIGURES PRIMARY LABORATORY

Intentionally left blank

Table C-1.1

**CONCENTRATIONS OF GROSS BETA IN SURFACE WATER SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017**
RESULTS IN UNITS OF PCI/LITER \pm 2 SIGMA

COLLECTION PERIOD	BY-12	BY-29
01/03/17 - 01/31/17	3.1 \pm 1.9	6.7 \pm 2.1
02/07/17 - 02/28/17	5.6 \pm 2.3	4.5 \pm 2.2
03/07/17 - 03/28/17	4.4 \pm 2.0	4.0 \pm 2.0
04/04/17 - 04/25/17	4.4 \pm 1.8	5.5 \pm 1.9
05/02/17 - 05/30/17	< 2.5	3.3 \pm 1.8
06/06/17 - 06/27/17	< 2.5	< 2.6
07/03/17 - 07/25/17	4.6 \pm 1.8	5.0 \pm 1.8
08/01/17 - 08/29/17	3.1 \pm 1.8	3.1 \pm 1.8
09/05/17 - 09/26/17	4.0 \pm 1.9	3.3 \pm 1.9
10/03/17 - 10/31/17	3.7 \pm 2.0	< 2.8
11/07/17 - 11/28/17	< 2.4	2.5 \pm 1.7
12/05/17 - 12/19/17	5.1 \pm 2.1	4.9 \pm 2.1
<i>MEAN \pm 2 STD DEV</i>	4.2 \pm 1.7	4.3 \pm 2.6

Table C-1.2

**CONCENTRATIONS OF TRITIUM IN SURFACE WATER SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017**
RESULTS IN UNITS OF PCI/LITER \pm 2 SIGMA

COLLECTION PERIOD	BY-12	BY-29
01/03/17 - 03/28/17	6110 \pm 665	< 190
04/04/17 - 06/27/17	< 192	< 191
07/03/17 - 09/26/17	293 \pm 127	< 190
10/03/17 - 12/19/17	< 198	< 193
<i>MEAN \pm 2 STD DEV</i>	3202 \pm 8226	-

Table C-1.3

**CONCENTRATIONS OF NI-63 IN SURFACE WATER SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017**
RESULTS IN UNITS OF PCI/LITER \pm 2 SIGMA

COLLECTION PERIOD	BY-12	BY-29
01/03/17 - 01/31/17	< 13	< 14
02/07/17 - 02/28/17	< 26	< 25
03/07/17 - 03/28/17	< 15	< 13
04/04/17 - 04/25/17	< 11	< 11
05/02/17 - 05/30/17	< 13	< 13
06/06/17 - 06/27/17	< 14	< 15
07/03/17 - 07/25/17	< 14	< 14
08/01/17 - 08/29/17	< 17	< 17
09/05/17 - 09/26/17	< 13	< 14
10/03/17 - 10/31/17	< 18	< 18
11/07/17 - 11/28/17	< 11	< 12
12/05/17 - 12/19/17	< 20	< 26
<i>MEAN</i>	-	-

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

Table C-I.4

**CONCENTRATIONS OF GAMMA EMITTERS IN SURFACE WATER SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017**
RESULTS IN UNITS OF PC/LITER ± 2 SIGMA

SITE	COLLECTION PERIOD	RESULTS IN UNITS OF PC/LITER ± 2 SIGMA											
		Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	I-131	Cs-134	Cs-137	Ba-140	La-140
BY-12	01/03/17 - 01/31/17	< 2	< 2	< 5	< 2	< 4	< 2	< 4	< 8	< 2	< 2	< 15	< 5
	02/07/17 - 02/28/17	< 3	< 4	< 7	< 3	< 7	< 4	< 7	< 14	< 4	< 4	< 30	< 9
	03/07/17 - 03/28/17	< 3	< 3	< 8	< 3	< 5	< 3	< 7	< 14	< 3	< 3	< 25	< 9
	04/04/17 - 04/25/17	< 2	< 2	< 4	< 2	< 3	< 2	< 4	< 8	< 2	< 2	< 15	< 5
	05/02/17 - 05/30/17	< 1	< 2	< 4	< 1	< 3	< 2	< 3	< 15	< 1	< 1	< 22	< 7
	06/06/17 - 06/27/17	< 3	< 4	< 9	< 3	< 9	< 5	< 8	< 14	< 4	< 5	< 23	< 9
	07/03/17 - 07/25/17	< 2	< 3	< 6	< 2	< 4	< 3	< 4	< 10	< 2	< 2	< 18	< 5
	08/01/17 - 08/29/17	< 2	< 2	< 5	< 2	< 4	< 2	< 4	< 12	< 2	< 2	< 21	< 7
	09/05/17 - 09/26/17	< 2	< 2	< 5	< 2	< 4	< 2	< 4	< 10	< 2	< 2	< 20	< 7
	10/03/17 - 10/31/17	< 3	< 4	< 7	< 4	< 7	< 4	< 7	< 15	< 4	< 4	< 29	< 10
	11/07/17 - 11/28/17	< 3	< 3	< 6	< 3	< 6	< 3	< 5	< 9	< 3	< 3	< 20	< 7
	12/05/17 - 12/19/17	< 2	< 3	< 6	< 2	< 4	< 3	< 4	< 14	< 2	< 2	< 25	< 9
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-29	01/17/17 - 01/31/17	< 6	< 7	< 13	< 5	< 13	< 8	< 13	< 15	< 6	< 7	< 32	< 9
	02/07/17 - 02/28/17	< 3	< 3	< 7	< 4	< 7	< 4	< 6	< 13	< 3	< 3	< 27	< 8
	03/07/17 - 03/28/17	< 3	< 3	< 8	< 4	< 6	< 4	< 7	< 14	< 3	< 4	< 27	< 8
	04/04/17 - 04/25/17	< 2	< 2	< 5	< 2	< 4	< 2	< 4	< 9	< 2	< 2	< 18	< 5
	05/02/17 - 05/30/17	< 1	< 1	< 3	< 1	< 2	< 2	< 3	< 15	< 1	< 1	< 20	< 6
	06/06/17 - 06/27/17	< 5	< 6	< 11	< 5	< 11	< 6	< 9	< 14	< 6	< 6	< 33	< 10
	07/03/17 - 07/25/17	< 3	< 3	< 7	< 3	< 6	< 3	< 6	< 14	< 3	< 3	< 27	< 7
	08/01/17 - 08/29/17	< 2	< 2	< 6	< 2	< 4	< 2	< 4	< 13	< 2	< 2	< 23	< 7
	09/05/17 - 09/26/17	< 2	< 2	< 5	< 2	< 4	< 3	< 4	< 11	< 2	< 2	< 21	< 7
	10/03/17 - 10/31/17	< 4	< 4	< 7	< 3	< 7	< 3	< 6	< 14	< 4	< 3	< 29	< 10
	11/07/17 - 11/28/17	< 3	< 3	< 8	< 4	< 7	< 4	< 6	< 11	< 4	< 3	< 23	< 7
	12/05/17 - 12/19/17	< 2	< 3	< 6	< 3	< 5	< 3	< 5	< 15	< 2	< 2	< 25	< 10
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-

Table C-II.1

**CONCENTRATIONS OF TRITIUM IN GROUND WATER SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017**
RESULTS IN UNITS OF PCI/LITER \pm 2 SIGMA

COLLECTION PERIOD	BY-14-1	BY-18-1	BY-32	BY-35	BY-37	BY-38
01/10/17 - 01/24/17	< 189	< 185	< 188	< 183	< 196	< 189
04/11/17 - 04/11/17	< 192	< 189	< 193	< 190	< 189	< 192
07/11/17 - 07/11/17	< 192	< 194	< 193	< 193	< 195	< 190
10/10/17 - 10/10/17	< 187	< 183	< 185	< 182	< 187	< 177
<i>MEAN</i>	-	-	-	-	-	-

Table C-II.2 **CONCENTRATIONS OF GAMMA EMITTERS IN GROUND WATER SAMPLES**
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017
 RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

SITE	COLLECTION PERIOD	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	I-131	Cs-134	Cs-137	Ba-140	La-140
BY-14-1	01/10/17 - 01/10/17	< 7	< 6	< 12	< 7	< 14	< 8	< 10	< 11	< 7	< 7	< 30	< 14
	04/11/17 - 04/11/17	< 7	< 6	< 10	< 9	< 17	< 8	< 10	< 12	< 7	< 7	< 17	< 9
	07/11/17 - 07/11/17	< 7	< 6	< 17	< 9	< 18	< 9	< 15	< 12	< 8	< 8	< 33	< 10
	10/10/17 - 10/10/17	< 11	< 11	< 23	< 11	< 24	< 12	< 18	< 13	< 10	< 7	< 41	< 15
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-18-1	01/24/17 - 01/24/17	< 4	< 6	< 9	< 4	< 10	< 6	< 11	< 7	< 5	< 6	< 23	< 5
	04/11/17 - 04/11/17	< 8	< 5	< 14	< 5	< 13	< 8	< 10	< 12	< 8	< 7	< 29	< 9
	07/11/17 - 07/11/17	< 5	< 6	< 13	< 6	< 12	< 7	< 9	< 11	< 7	< 6	< 27	< 10
	10/10/17 - 10/10/17	< 8	< 8	< 16	< 9	< 17	< 9	< 14	< 12	< 11	< 8	< 35	< 9
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-32	01/10/17 - 01/10/17	< 8	< 6	< 13	< 8	< 14	< 6	< 12	< 11	< 5	< 8	< 30	< 10
	04/11/17 - 04/11/17	< 8	< 6	< 11	< 6	< 13	< 8	< 13	< 13	< 8	< 7	< 38	< 12
	07/11/17 - 07/11/17	< 6	< 8	< 15	< 5	< 11	< 8	< 11	< 11	< 7	< 7	< 29	< 9
	10/10/17 - 10/10/17	< 10	< 10	< 17	< 9	< 24	< 11	< 17	< 13	< 11	< 10	< 41	< 11
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-35	01/17/17 - 01/17/17	< 7	< 8	< 14	< 8	< 15	< 6	< 10	< 8	< 7	< 6	< 32	< 9
	04/11/17 - 04/11/17	< 7	< 7	< 11	< 8	< 15	< 8	< 10	< 11	< 7	< 7	< 31	< 11
	07/11/17 - 07/11/17	< 6	< 7	< 16	< 10	< 22	< 8	< 8	< 9	< 8	< 8	< 37	< 11
	10/10/17 - 10/10/17	< 8	< 6	< 14	< 11	< 15	< 7	< 15	< 9	< 8	< 7	< 39	< 12
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-37	01/10/17 - 01/10/17	< 8	< 7	< 18	< 8	< 12	< 8	< 12	< 13	< 8	< 7	< 34	< 14
	04/11/17 - 04/11/17	< 5	< 6	< 11	< 5	< 11	< 5	< 10	< 8	< 7	< 6	< 28	< 7
	07/11/17 - 07/11/17	< 8	< 7	< 15	< 9	< 15	< 8	< 16	< 12	< 6	< 8	< 43	< 12
	10/10/17 - 10/10/17	< 7	< 8	< 14	< 8	< 13	< 6	< 12	< 10	< 8	< 7	< 19	< 11
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-38	01/17/17 - 01/17/17	< 8	< 7	< 15	< 9	< 14	< 6	< 9	< 11	< 7	< 8	< 25	< 9
	04/11/17 - 04/11/17	< 7	< 6	< 12	< 5	< 14	< 9	< 11	< 11	< 8	< 4	< 32	< 12
	07/11/17 - 07/11/17	< 5	< 6	< 10	< 5	< 6	< 5	< 9	< 8	< 6	< 7	< 20	< 6
	10/10/17 - 10/10/17	< 7	< 6	< 13	< 6	< 15	< 9	< 12	< 9	< 8	< 8	< 30	< 7
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-

Table C-III.1

**CONCENTRATIONS OF NICKEL-63 AND GAMMA EMITTERS IN FISH SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017**

RESULTS IN UNITS OF PCI/KG WET ± 2 SIGMA

SITE	COLLECTION		Ni-63	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	Cs-134	Cs-137	Ba-140	La-140
	PERIOD													
BY-29														
Freshwater Drum	05/25/17 - 05/25/17		< 188	< 69	< 77	< 184	< 80	< 120	< 89	< 149	< 88	< 81	< 463	< 118
Silver Redhorse	05/25/17 - 05/25/17		< 189	< 55	< 39	< 86	< 38	< 97	< 57	< 72	< 44	< 43	< 265	< 119
Freshwater Drum	10/26/17 - 10/26/17		< 53	< 43	< 29	< 101	< 54	< 107	< 40	< 77	< 50	< 48	< 210	< 66
Golden Redhorse	10/26/17 - 10/26/17		< 58	< 70	< 79	< 154	< 68	< 157	< 79	< 140	< 88	< 79	< 350	< 107
		MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-31														
River Carpsucker	05/25/17 - 05/25/17		< 141	< 55	< 49	< 144	< 63	< 117	< 52	< 114	< 66	< 66	< 302	< 82
Silver Redhorse	05/25/17 - 05/25/17		< 144	< 69	< 74	< 155	< 69	< 123	< 71	< 116	< 74	< 68	< 427	< 143
Bigmouth Buffalo	10/26/17 - 10/26/17		< 54	< 44	< 32	< 99	< 41	< 99	< 45	< 64	< 44	< 40	< 202	< 75
Common Carp	10/26/17 - 10/26/17		< 53	< 67	< 69	< 136	< 61	< 135	< 75	< 101	< 78	< 73	< 301	< 85
		MEAN	-	-	-	-	-	-	-	-	-	-	-	-

Table C-IV.1 **CONCENTRATIONS OF NICKEL-63 AND GAMMA EMITTERS IN SEDIMENT SAMPLES COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017**
RESULTS IN UNITS OF PCI/KG DRY \pm 2 SIGMA

SITE	COLLECTION PERIOD	Ni-63	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	Cs-134	Cs-137	Ba-140	La-140
BY-12	05/23/17 - 05/23/17	< 207	< 83	< 81	< 189	< 70	< 181	< 90	< 156	< 102	202 \pm 88	< 416	< 102
	10/25/17 - 10/25/17	< 168	< 87	< 90	< 170	< 82	< 214	< 91	< 141	< 100	< 106	< 381	< 97
	MEAN \pm 2 STD DEV	-	-	-	-	-	-	-	-	-	202 \pm 0	-	-
BY-34	05/23/17 - 05/23/17	< 223	< 89	< 87	< 191	< 84	< 230	< 99	< 155	< 100	< 116	< 419	< 131
	10/25/17 - 10/25/17	< 175	< 41	< 39	< 86	< 42	< 81	< 46	< 67	< 40	< 38	< 133	< 39
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

Table C-V.1

**CONCENTRATIONS OF GROSS BETA IN AIR PARTICULATE SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017
RESULTS IN UNITS OF E-3 PCI/CU METER \pm 2 SIGMA**

COLLECTION PERIOD	GROUP I				GROUP II			GROUP III
	BY-21	BY-22	BY-23	BY-24	BY-01	BY-04	BY-06	BY-08
01/03/17 - 01/10/17	24 \pm 5	16 \pm 4	20 \pm 4	23 \pm 5	20 \pm 4	26 \pm 5	24 \pm 5	20 \pm 4
01/10/17 - 01/17/17	23 \pm 5	24 \pm 5	24 \pm 5	22 \pm 4	23 \pm 5	27 \pm 5	20 \pm 4	26 \pm 5
01/17/17 - 01/24/17	22 \pm 5	24 \pm 5	20 \pm 4	21 \pm 5	18 \pm 4	16 \pm 4	18 \pm 4	22 \pm 4
01/24/17 - 01/31/17	16 \pm 4	16 \pm 4	19 \pm 4	20 \pm 4	14 \pm 4	18 \pm 4	17 \pm 4	17 \pm 4
01/31/17 - 02/07/17	16 \pm 4	17 \pm 4	16 \pm 4	16 \pm 4	15 \pm 4	16 \pm 4	15 \pm 4	15 \pm 4
02/07/17 - 02/14/17	16 \pm 4	17 \pm 4	12 \pm 4	19 \pm 4	15 \pm 4	17 \pm 4	15 \pm 4	17 \pm 4
02/14/17 - 02/21/17	16 \pm 4	17 \pm 4	16 \pm 4	18 \pm 4	18 \pm 4	19 \pm 4	17 \pm 4	16 \pm 4
02/21/17 - 02/28/17	12 \pm 4	13 \pm 4	13 \pm 4	12 \pm 4	12 \pm 4	13 \pm 4	11 \pm 4	10 \pm 4
02/28/17 - 03/07/17	18 \pm 4	18 \pm 4	18 \pm 4	17 \pm 4	17 \pm 4	20 \pm 4	16 \pm 4	17 \pm 4
03/07/17 - 03/14/17	9 \pm 4	12 \pm 4	12 \pm 4	10 \pm 4	15 \pm 4	14 \pm 4	11 \pm 4	12 \pm 4
03/14/17 - 03/21/17	17 \pm 4	18 \pm 4	17 \pm 4	19 \pm 4	19 \pm 4	20 \pm 4	18 \pm 4	22 \pm 4
03/21/17 - 03/28/17	13 \pm 4	17 \pm 4	11 \pm 4	16 \pm 4	14 \pm 4	12 \pm 4	12 \pm 4	14 \pm 4
03/28/17 - 04/04/17	11 \pm 4	11 \pm 4	7 \pm 3	11 \pm 4	11 \pm 4	9 \pm 3	11 \pm 4	8 \pm 3
04/04/17 - 04/11/17	15 \pm 4	10 \pm 4	12 \pm 4	12 \pm 4	13 \pm 4	11 \pm 4	12 \pm 4	9 \pm 4
04/11/17 - 04/18/17	11 \pm 4	14 \pm 4	11 \pm 4	15 \pm 4	13 \pm 4	18 \pm 4	13 \pm 4	13 \pm 4
04/18/17 - 04/25/17	8 \pm 4	9 \pm 4	10 \pm 4	9 \pm 4	9 \pm 4	12 \pm 4	9 \pm 4	12 \pm 4
04/25/17 - 05/02/17	< 5	5 \pm 4	< 5	6 \pm 4	6 \pm 4	< 5	< 5	< 5
05/02/17 - 05/09/17	16 \pm 4	16 \pm 4	15 \pm 4	21 \pm 4	17 \pm 4	16 \pm 4	20 \pm 4	16 \pm 4
05/09/17 - 05/16/17	13 \pm 5	18 \pm 5	17 \pm 5	19 \pm 5	17 \pm 5	18 \pm 5	19 \pm 5	21 \pm 5
05/16/17 - 05/23/17	12 \pm 4	13 \pm 4	9 \pm 3	11 \pm 4	9 \pm 3	7 \pm 3	14 \pm 4	14 \pm 4
05/23/17 - 05/30/17	14 \pm 4	13 \pm 4	14 \pm 4	12 \pm 4	15 \pm 4	16 \pm 4	15 \pm 4	16 \pm 4
05/30/17 - 06/06/17	21 \pm 4	19 \pm 4	18 \pm 4	20 \pm 4	20 \pm 4	20 \pm 4	19 \pm 4	19 \pm 4
06/06/17 - 06/13/17	14 \pm 4	15 \pm 4	17 \pm 4	19 \pm 4	15 \pm 4	15 \pm 4	18 \pm 4	16 \pm 4
06/13/17 - 06/20/17	14 \pm 4	11 \pm 4	8 \pm 4	11 \pm 4	11 \pm 4	13 \pm 4	8 \pm 4	12 \pm 4
06/20/17 - 06/27/17	13 \pm 4	8 \pm 4	11 \pm 4	11 \pm 4	13 \pm 4	11 \pm 4	7 \pm 3	12 \pm 4
06/27/17 - 07/03/17	10 \pm 4	12 \pm 4	11 \pm 4	14 \pm 5	11 \pm 4	18 \pm 5	13 \pm 5	13 \pm 4
07/03/17 - 07/11/17	20 \pm 4	20 \pm 4	16 \pm 4	22 \pm 4	23 \pm 4	18 \pm 4	20 \pm 4	16 \pm 4
07/11/17 - 07/18/17	12 \pm 4	12 \pm 4	13 \pm 4	16 \pm 4	12 \pm 4	16 \pm 4	11 \pm 4	15 \pm 4
07/18/17 - 07/25/17	13 \pm 4	17 \pm 4	15 \pm 4	16 \pm 4	16 \pm 4	17 \pm 4	16 \pm 4	19 \pm 4
07/25/17 - 08/01/17	17 \pm 4	15 \pm 4	15 \pm 4	17 \pm 4	18 \pm 4	14 \pm 4	16 \pm 4	14 \pm 4
08/01/17 - 08/08/17	22 \pm 4	22 \pm 4	21 \pm 4	15 \pm 4	16 \pm 4	21 \pm 4	17 \pm 4	21 \pm 4
08/08/17 - 08/16/17	17 \pm 4	21 \pm 4	20 \pm 4	19 \pm 4	22 \pm 4	21 \pm 4	19 \pm 4	23 \pm 4
08/16/17 - 08/22/17	20 \pm 5	21 \pm 5	18 \pm 5	21 \pm 5	23 \pm 5	19 \pm 5	17 \pm 5	18 \pm 5
08/22/17 - 08/29/17	17 \pm 4	17 \pm 4	17 \pm 4	17 \pm 4	18 \pm 4	16 \pm 4	17 \pm 4	19 \pm 4
08/29/17 - 09/05/17	17 \pm 4	14 \pm 4	19 \pm 4	16 \pm 4	16 \pm 4	18 \pm 4	14 \pm 4	17 \pm 4
09/05/17 - 09/12/17	13 \pm 4	16 \pm 4	13 \pm 4	14 \pm 4	14 \pm 4	11 \pm 4	13 \pm 4	14 \pm 4
09/12/17 - 09/19/17	30 \pm 5	28 \pm 5	28 \pm 5	25 \pm 5	22 \pm 5	26 \pm 5	24 \pm 5	30 \pm 5
09/19/17 - 09/26/17	28 \pm 5	28 \pm 5	28 \pm 5	28 \pm 5	25 \pm 5	23 \pm 4	25 \pm 5	31 \pm 5
09/26/17 - 10/03/17	15 \pm 4	13 \pm 4	16 \pm 4	16 \pm 4	15 \pm 4	18 \pm 4	16 \pm 4	21 \pm 4
10/03/17 - 10/10/17	22 \pm 5	20 \pm 4	23 \pm 5	18 \pm 4	19 \pm 4	23 \pm 5	18 \pm 4	20 \pm 4
10/10/17 - 10/17/17	13 \pm 4	12 \pm 4	13 \pm 4	8 \pm 4	14 \pm 4	13 \pm 4	13 \pm 4	12 \pm 4
10/17/17 - 10/25/17	18 \pm 4	14 \pm 3	16 \pm 4	20 \pm 4	19 \pm 4	15 \pm 4	15 \pm 3	17 \pm 4
10/25/17 - 10/31/17	7 \pm 4	11 \pm 4	7 \pm 4	9 \pm 4	10 \pm 4	10 \pm 4	11 \pm 4	9 \pm 4
10/31/17 - 11/07/17	14 \pm 4	15 \pm 4	15 \pm 4	15 \pm 4	17 \pm 4	16 \pm 4	19 \pm 4	14 \pm 4
11/07/17 - 11/14/17	21 \pm 4	21 \pm 4	21 \pm 4	19 \pm 4	21 \pm 4	17 \pm 4	21 \pm 4	24 \pm 5
11/14/17 - 11/21/17	25 \pm 5	20 \pm 4	20 \pm 4	22 \pm 4	21 \pm 4	22 \pm 4	20 \pm 4	20 \pm 4
11/21/17 - 11/28/17	23 \pm 5	25 \pm 5	22 \pm 5	28 \pm 5	27 \pm 5	23 \pm 5	18 \pm 4	23 \pm 5
11/28/17 - 12/05/17	24 \pm 5	21 \pm 4	23 \pm 4	17 \pm 4	23 \pm 4	23 \pm 4	23 \pm 4	24 \pm 5
12/05/17 - 12/12/17	25 \pm 5	20 \pm 5	17 \pm 4	19 \pm 5	19 \pm 5	16 \pm 4	21 \pm 5	21 \pm 5
12/12/17 - 12/19/17	19 \pm 5	22 \pm 5	18 \pm 5	20 \pm 5	17 \pm 5	21 \pm 5	19 \pm 5	20 \pm 5
12/19/17 - 12/27/17	20 \pm 4	17 \pm 4	17 \pm 4	15 \pm 4	17 \pm 4	19 \pm 4	17 \pm 4	19 \pm 4
12/27/17 - 01/02/18	29 \pm 5	24 \pm 5	26 \pm 5	32 \pm 6	24 \pm 5	26 \pm 5	24 \pm 5	27 \pm 5
MEAN \pm 2 STD DEV	17 \pm 11	17 \pm 10	16 \pm 10	17 \pm 11	17 \pm 9	17 \pm 9	16 \pm 9	18 \pm 10

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

Table C-V.2 MONTHLY AND YEARLY MEAN VALUES OF GROSS BETA CONCENTRATIONS IN AIR PARTICULATE SAMPLES COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017
RESULTS IN UNITS OF E-3 PCI/CU METER ± 2 SIGMA

GROUP I - NEARSITE LOCATIONS					GROUP II - FAR FIELD LOCATIONS					GROUP III - CONTROL LOCATIONS				
COLLECTION PERIOD	MIN	MAX	MEAN ± 2SD		COLLECTION PERIOD	MIN	MAX	MEAN ± 2SD		COLLECTION PERIOD	MIN	MAX	MEAN ± 2SD	
01/03/17 - 01/31/17	16	24	21 ± 6		01/03/17 - 01/31/17	14	27	20 ± 8		01/03/17 - 01/31/17	17	26	21 ± 8	
01/31/17 - 02/28/17	12	19	16 ± 4		01/31/17 - 02/28/17	11	19	15 ± 4		01/31/17 - 02/28/17	10	17	14 ± 6	
02/28/17 - 04/04/17	7	19	14 ± 8		02/28/17 - 04/04/17	9	20	15 ± 7		02/28/17 - 04/04/17	8	22	15 ± 11	
04/04/17 - 05/02/17	5	15	10 ± 6		04/04/17 - 05/02/17	6	18	12 ± 6		04/04/17 - 04/25/17	9	13	11 ± 4	
05/02/17 - 05/30/17	9	21	14 ± 6		05/02/17 - 05/30/17	7	20	15 ± 8		05/02/17 - 05/30/17	14	21	16 ± 6	
05/30/17 - 07/03/17	8	21	14 ± 8		05/30/17 - 07/03/17	7	20	14 ± 8		05/30/17 - 07/03/17	12	19	14 ± 6	
07/03/17 - 08/01/17	12	22	16 ± 6		07/03/17 - 08/01/17	11	23	16 ± 6		07/03/17 - 08/01/17	14	19	16 ± 4	
08/01/17 - 08/29/17	15	22	19 ± 4		08/01/17 - 08/29/17	16	23	19 ± 5		08/01/17 - 08/29/17	18	23	20 ± 4	
08/29/17 - 10/03/17	13	30	20 ± 13		08/29/17 - 10/03/17	11	26	19 ± 10		08/29/17 - 10/03/17	14	31	22 ± 15	
10/03/17 - 10/31/17	7	23	14 ± 10		10/03/17 - 10/31/17	10	23	15 ± 8		10/03/17 - 10/31/17	9	20	15 ± 10	
10/31/17 - 11/28/17	14	28	20 ± 8		10/31/17 - 11/28/17	16	27	20 ± 6		10/31/17 - 11/28/17	14	24	20 ± 9	
11/28/17 - 01/02/18	15	32	21 ± 9		11/28/17 - 01/02/18	16	26	21 ± 6		11/28/17 - 01/02/18	19	27	22 ± 7	
01/03/17 - 01/02/18	5	32	17 ± 10		01/03/17 - 01/02/18	6	27	17 ± 9		01/03/17 - 01/02/18	8	31	18 ± 10	

Table C-V.3 **CONCENTRATIONS OF GAMMA EMITTERS IN AIR PARTICULATE SAMPLES**
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017
 RESULTS IN UNITS OF E-3 PCI/CU METER ± 2 SIGMA

SITE	COLLECTION PERIOD	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	Cs-134	Cs-137	Ba-140	La-140
BY-01	01/03/17 - 04/04/17	< 3	< 4	< 11	< 2	< 6	< 4	< 8	< 3	< 2	< 164	< 62
	04/04/17 - 07/03/17	< 4	< 5	< 17	< 2	< 10	< 7	< 10	< 4	< 4	< 192	< 85
	07/03/17 - 10/03/17	< 4	< 5	< 20	< 4	< 12	< 9	< 14	< 4	< 3	< 821	< 303
	10/03/17 - 01/02/18	< 2	< 2	< 7	< 2	< 5	< 3	< 6	< 2	< 2	< 123	< 45
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-04	01/03/17 - 04/04/17	< 5	< 6	< 17	< 4	< 8	< 7	< 13	< 4	< 4	< 253	< 54
	04/04/17 - 07/03/17	< 3	< 5	< 14	< 2	< 8	< 4	< 6	< 3	< 3	< 91	< 78
	07/03/17 - 10/03/17	< 2	< 5	< 18	< 2	< 5	< 4	< 7	< 2	< 2	< 346	< 197
	10/03/17 - 01/02/18	< 2	< 4	< 11	< 3	< 4	< 4	< 7	< 2	< 2	< 127	< 77
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-06	01/03/17 - 04/04/17	< 2	< 4	< 9	< 1	< 6	< 4	< 5	< 2	< 2	< 164	< 47
	04/04/17 - 07/03/17	< 4	< 4	< 13	< 4	< 8	< 6	< 10	< 4	< 3	< 208	< 57
	07/03/17 - 10/03/17	< 2	< 3	< 14	< 2	< 5	< 4	< 8	< 3	< 2	< 421	< 234
	10/03/17 - 01/02/18	< 3	< 4	< 10	< 2	< 6	< 5	< 8	< 3	< 2	< 191	< 46
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-08	01/03/17 - 04/04/17	< 3	< 4	< 12	< 3	< 4	< 5	< 6	< 2	< 2	< 149	< 97
	04/04/17 - 07/03/17	< 2	< 4	< 10	< 2	< 7	< 4	< 7	< 2	< 2	< 143	< 47
	07/03/17 - 10/03/17	< 3	< 5	< 17	< 2	< 8	< 6	< 11	< 3	< 3	< 421	< 196
	10/03/17 - 01/02/18	< 4	< 6	< 11	< 4	< 10	< 7	< 13	< 4	< 3	< 239	< 97
	MEAN	-	-	-	-	-	-	-	-	-	-	-

**Table C-V.3 CONCENTRATIONS OF GAMMA EMITTERS IN AIR PARTICULATE SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017**
RESULTS IN UNITS OF E-3 PCI/CU METER ± 2 SIGMA

SITE	COLLECTION PERIOD	RESULTS IN UNITS OF E-3 PCI/CU METER ± 2 SIGMA										
		Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	Cs-134	Cs-137	Ba-140	La-140
BY-21	01/03/17 - 04/04/17	< 2	< 3	< 10	< 3	< 5	< 4	< 7	< 3	< 2	< 191	< 56
	04/04/17 - 07/03/17	< 3	< 3	< 9	< 2	< 7	< 4	< 8	< 3	< 3	< 171	< 47
	07/03/17 - 10/03/17	< 3	< 5	< 16	< 3	< 8	< 5	< 10	< 2	< 3	< 485	< 214
	10/03/17 - 01/02/18	< 2	< 4	< 8	< 3	< 5	< 3	< 7	< 3	< 2	< 105	< 54
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-22	01/03/17 - 04/04/17	< 3	< 5	< 17	< 2	< 8	< 4	< 8	< 3	< 3	< 215	< 81
	04/04/17 - 07/03/17	< 3	< 5	< 14	< 4	< 7	< 5	< 9	< 3	< 3	< 184	< 44
	07/03/17 - 10/03/17	< 3	< 4	< 14	< 3	< 7	< 4	< 6	< 3	< 2	< 427	< 177
	10/03/17 - 01/02/18	< 3	< 5	< 13	< 2	< 8	< 4	< 6	< 3	< 3	< 181	< 62
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-23	01/03/17 - 04/04/17	< 4	< 5	< 15	< 4	< 9	< 5	< 10	< 3	< 3	< 263	< 84
	04/04/17 - 07/03/17	< 3	< 3	< 10	< 2	< 5	< 4	< 6	< 2	< 2	< 134	< 40
	07/03/17 - 10/03/17	< 3	< 4	< 16	< 3	< 5	< 5	< 7	< 3	< 2	< 502	< 208
	10/03/17 - 01/02/18	< 4	< 6	< 16	< 4	< 9	< 5	< 10	< 4	< 3	< 273	< 71
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-24	01/03/17 - 04/04/17	< 2	< 3	< 11	< 3	< 4	< 4	< 7	< 2	< 2	< 131	< 68
	04/04/17 - 07/03/17	< 4	< 6	< 17	< 4	< 10	< 7	< 12	< 4	< 4	< 177	< 86
	07/03/17 - 10/03/17	< 4	< 8	< 22	< 4	< 9	< 8	< 14	< 4	< 4	< 685	< 252
	10/03/17 - 01/02/18	< 2	< 4	< 8	< 2	< 7	< 5	< 6	< 2	< 2	< 146	< 75
	MEAN	-	-	-	-	-	-	-	-	-	-	-

Table C-VI.1

**CONCENTRATIONS OF I-131 IN AIR IODINE SAMPLES COLLECTED
IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017**
RESULTS IN UNITS OF E-3 PCI/CU METER \pm 2 SIGMA

COLLECTION PERIOD	GROUP I				GROUP II			GROUP III
	BY-21	BY-22	BY-23	BY-24	BY-01	BY-04	BY-06	BY-08
01/03/17 - 01/10/17	< 58	< 58	< 58	< 58	< 60	< 59	< 58	< 57
01/10/17 - 01/17/17	< 44	< 43	< 43	< 43	< 62	< 61	< 62	< 62
01/17/17 - 01/24/17	< 55	< 55	< 56	< 56	< 48	< 47	< 47	< 47
01/24/17 - 01/31/17	< 44	< 44	< 44	< 44	< 60	< 63	< 62	< 62
01/31/17 - 02/07/17	< 41	< 41	< 41	< 41	< 50	< 51	< 51	< 52
02/07/17 - 02/14/17	< 61	< 61	< 61	< 62	< 65	< 63	< 63	< 62
02/14/17 - 02/21/17	< 54	< 54	< 53	< 53	< 48	< 48	< 48	< 48
02/21/17 - 02/28/17	< 53	< 53	< 53	< 53	< 35	< 36	< 36	< 36
02/28/17 - 03/07/17	< 68	< 68	< 68	< 68	< 68	< 68	< 69	< 70
03/07/17 - 03/14/17	< 46	< 46	< 46	< 47	< 35	< 34	< 34	< 14
03/14/17 - 03/21/17	< 47	< 47	< 47	< 47	< 53	< 52	< 52	< 52
03/21/17 - 03/28/17	< 54	< 54	< 54	< 55	< 54	< 56	< 56	< 57
03/28/17 - 04/04/17	< 50	< 50	< 50	< 50	< 50	< 50	< 50	< 51
04/04/17 - 04/11/17	< 46	< 46	< 46	< 46	< 68	< 66	< 66	< 66
04/11/17 - 04/18/17	< 44	< 44	< 44	< 44	< 55	< 54	< 54	< 53
04/18/17 - 04/25/17	< 47	< 47	< 48	< 21	< 51	< 50	< 51	< 51
04/25/17 - 05/02/17	< 32	< 32	< 32	< 32	< 43	< 44	< 44	< 44
05/02/17 - 05/09/17	< 62	< 62	< 62	< 62	< 54	< 53	< 53	< 53
05/09/17 - 05/16/17	< 36	< 36	< 13	< 36	< 35	< 36	< 36	< 36
05/16/17 - 05/23/17	< 37	< 37	< 37	< 37	< 44	< 44	< 43	< 16
05/23/17 - 05/30/17	< 67	< 67	< 67	< 67	< 50	< 51	< 52	< 52
05/30/17 - 06/06/17	< 28	< 28	< 28	< 28	< 47	< 48	< 47	< 47
06/06/17 - 06/13/17	< 41	< 41	< 41	< 41	< 47	< 47	< 48	< 48
06/13/17 - 06/20/17	< 48	< 47	< 48	< 48	< 55	< 53	< 53	< 52
06/20/17 - 06/27/17	< 50	< 50	< 50	< 49	< 47	< 48	< 49	< 49
06/27/17 - 07/03/17	< 60	< 60	< 60	< 60	< 61	< 62	< 61	< 60
07/03/17 - 07/11/17	< 55	< 55	< 54	< 21	< 61	< 62	< 63	< 63
07/11/17 - 07/18/17	< 34	< 34	< 34	< 34	< 61	< 59	< 59	< 25
07/18/17 - 07/25/17	< 46	< 46	< 46	< 46	< 46	< 47	< 47	< 48
07/25/17 - 08/01/17	< 49	< 49	< 49	< 49	< 55	< 53	< 53	< 53
08/01/17 - 08/08/17	< 48	< 48	< 49	< 49	< 50	< 50	< 51	< 51
08/08/17 - 08/16/17	< 62	< 62	< 60	< 60	< 65	< 66	< 65	< 64
08/16/17 - 08/22/17	< 52	< 52	< 53	< 52	< 53	< 54	< 54	< 55
08/22/17 - 08/29/17	< 40	< 40	< 40	< 40	< 46	< 47	< 46	< 45
08/29/17 - 09/05/17	< 54	< 54	< 54	< 23	< 64	< 64	< 64	< 66
09/05/17 - 09/12/17	< 51	< 51	< 51	< 51	< 66	< 64	< 64	< 63
09/12/17 - 09/19/17	< 44	< 44	< 43	< 43	< 50	< 51	< 52	< 52
09/19/17 - 09/26/17	< 46	< 46	< 46	< 25	< 59	< 59	< 59	< 30
09/26/17 - 10/03/17	< 37	< 37	< 20	< 37	< 60	< 25	< 61	< 61
10/03/17 - 10/10/17	< 41	< 41	< 41	< 34	< 42	< 43	< 43	< 43
10/10/17 - 10/17/17	< 47	< 47	< 48	< 48	< 57	< 55	< 57	< 57
10/17/17 - 10/25/17	< 26	< 26	< 26	< 26	< 40	< 40	< 39	< 38
10/25/17 - 10/31/17	< 51	< 51	< 50	< 50	< 59	< 60	< 61	< 62
10/31/17 - 11/07/17	< 33	< 39	< 39	< 39	< 42	< 42	< 42	< 41
11/07/17 - 11/14/17	< 37	< 37	< 37	< 37	< 53	< 54	< 54	< 55
11/14/17 - 11/21/17	< 41	< 41	< 41	< 41	< 64	< 62	< 62	< 62
11/21/17 - 11/28/17	< 23	< 27	< 27	< 27	< 43	< 43	< 43	< 43
11/28/17 - 12/05/17	< 37	< 37	< 37	< 37	< 20	< 49	< 49	< 49
12/05/17 - 12/12/17	< 58	< 58	< 59	< 59	< 47	< 46	< 45	< 45
12/12/17 - 12/19/17	< 44	< 44	< 43	< 43	< 47	< 47	< 47	< 47
12/19/17 - 12/27/17	< 58	< 59	< 59	< 58	< 49	< 48	< 48	< 47
12/27/17 - 01/02/18	< 51	< 50	< 50	< 50	< 59	< 61	< 61	< 63
MEAN	-	-	-	-	-	-	-	-

Table C-VII.1

**CONCENTRATIONS OF I-131 IN MILK SAMPLES COLLECTED IN
THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017**

RESULTS IN UNITS OF PCI/LITER \pm 2 SIGMA

COLLECTION PERIOD	CONTROL FARM BY-26-2	INDICATOR FARM BY-20-1
01/03/17	< 0.7	< 0.8
02/07/17	< 0.5	< 0.5
03/07/17	< 0.8	< 0.7
04/04/17	< 0.6	< 0.7
05/02/17	< 0.8	< 0.7
05/16/17	< 0.9	< 0.9
05/30/17	< 0.5	< 0.4
06/13/17	< 0.9	< 0.5
06/27/17	< 0.6	< 0.6
07/11/17	< 0.6	< 0.7
07/25/17	< 0.7	< 0.8
08/08/17	< 0.9	< 0.4
08/22/17	< 0.8	< 0.5
09/05/17	< 0.6	< 0.5
09/19/17	< 0.4	< 0.4
10/03/17	< 0.9	< 0.5
10/17/17	< 0.4	< 0.7
10/31/17	< 0.8	< 0.8
11/14/17	< 0.3	< 0.6
12/05/17	< 0.7	< 0.8
<i>MEAN</i>	-	-

Table C-VII.2

**CONCENTRATIONS OF GAMMA EMITTERS IN MILK SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017**
RESULTS IN UNITS OF PC/LITER ± 2 SIGMA

SITE	COLLECTION		Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	Cs-134	Cs-137	Ba-140	La-140
	PERIOD												
BY-20-1	01/03/17		< 5	< 5	< 11	< 6	< 12	< 5	< 8	< 5	< 5	< 20	< 5
	02/07/17		< 5	< 6	< 13	< 7	< 12	< 6	< 11	< 5	< 6	< 25	< 7
	03/07/17		< 8	< 8	< 20	< 7	< 22	< 7	< 14	< 10	< 10	< 31	< 11
	04/04/17		< 7	< 7	< 16	< 9	< 18	< 8	< 16	< 7	< 8	< 31	< 8
	05/02/17		< 6	< 7	< 15	< 7	< 16	< 6	< 12	< 7	< 7	< 28	< 9
	05/16/17		< 6	< 6	< 11	< 6	< 11	< 5	< 9	< 6	< 6	< 20	< 7
	05/30/17		< 7	< 9	< 17	< 7	< 21	< 9	< 16	< 11	< 8	< 42	< 7
	06/13/17		< 10	< 9	< 21	< 8	< 22	< 8	< 15	< 9	< 10	< 39	< 9
	06/27/17		< 10	< 9	< 21	< 10	< 17	< 10	< 19	< 11	< 8	< 35	< 12
	07/11/17		< 5	< 6	< 16	< 8	< 17	< 6	< 13	< 7	< 7	< 30	< 6
	07/25/17		< 7	< 8	< 20	< 7	< 20	< 8	< 14	< 9	< 9	< 37	< 8
	08/08/17		< 8	< 7	< 19	< 7	< 19	< 8	< 15	< 8	< 9	< 30	< 8
	08/22/17		< 7	< 8	< 17	< 8	< 18	< 8	< 14	< 8	< 8	< 33	< 8
	09/05/17		< 7	< 8	< 18	< 7	< 17	< 8	< 15	< 9	< 9	< 36	< 9
09/19/17		< 9	< 10	< 17	< 10	< 18	< 10	< 15	< 10	< 9	< 44	< 13	
10/03/17		< 6	< 7	< 14	< 9	< 18	< 6	< 12	< 9	< 8	< 37	< 11	
10/17/17		< 8	< 9	< 19	< 9	< 20	< 9	< 14	< 9	< 8	< 43	< 9	
10/31/17		< 10	< 11	< 21	< 11	< 23	< 11	< 19	< 11	< 10	< 52	< 14	
11/14/17		< 5	< 6	< 12	< 6	< 16	< 7	< 9	< 6	< 5	< 24	< 5	
12/05/17		< 6	< 6	< 14	< 6	< 14	< 7	< 9	< 6	< 7	< 24	< 6	
	MEAN		-	-	-	-	-	-	-	-	-	-	-
BY-26-2	01/03/17		< 6	< 7	< 14	< 6	< 16	< 6	< 12	< 6	< 6	< 25	< 10
	02/07/17		< 6	< 6	< 13	< 6	< 13	< 6	< 10	< 5	< 6	< 25	< 7
	03/07/17		< 8	< 8	< 20	< 10	< 18	< 8	< 14	< 11	< 9	< 38	< 8
	04/04/17		< 5	< 7	< 15	< 7	< 17	< 7	< 10	< 9	< 8	< 30	< 8
	05/02/17		< 9	< 9	< 24	< 7	< 22	< 8	< 16	< 8	< 9	< 46	< 11
	05/16/17		< 8	< 7	< 17	< 7	< 17	< 8	< 15	< 8	< 8	< 30	< 8
	05/30/17		< 8	< 8	< 18	< 10	< 15	< 8	< 13	< 7	< 8	< 36	< 10
	06/13/17		< 7	< 8	< 16	< 7	< 18	< 7	< 12	< 8	< 7	< 31	< 8
	06/27/17		< 10	< 10	< 23	< 10	< 19	< 8	< 17	< 11	< 12	< 41	< 14
	07/11/17		< 9	< 8	< 22	< 11	< 17	< 11	< 18	< 8	< 9	< 50	< 10
	07/25/17		< 11	< 10	< 23	< 10	< 22	< 10	< 18	< 12	< 11	< 38	< 11
	08/08/17		< 7	< 7	< 15	< 7	< 15	< 7	< 9	< 8	< 6	< 26	< 8
	08/22/17		< 6	< 6	< 16	< 7	< 13	< 6	< 10	< 7	< 7	< 29	< 8
	09/05/17		< 8	< 8	< 18	< 9	< 20	< 8	< 15	< 10	< 9	< 39	< 10
09/19/17		< 8	< 10	< 22	< 10	< 21	< 11	< 18	< 9	< 11	< 49	< 15	
10/03/17		< 9	< 9	< 20	< 10	< 24	< 11	< 18	< 10	< 10	< 44	< 12	
10/17/17		< 8	< 8	< 19	< 9	< 23	< 8	< 14	< 9	< 9	< 38	< 13	
10/31/17		< 7	< 6	< 18	< 8	< 16	< 7	< 12	< 7	< 7	< 38	< 10	
11/14/17		< 9	< 7	< 14	< 10	< 15	< 8	< 12	< 10	< 8	< 31	< 8	
12/05/17		< 6	< 8	< 13	< 7	< 18	< 6	< 10	< 6	< 7	< 26	< 9	
	MEAN		-	-	-	-	-	-	-	-	-	-	-

Table C-VIII.1

**CONCENTRATIONS OF GAMMA EMITTERS IN VEGETATION SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017**
RESULTS IN UNITS OF PCI/KG WET ± 2 SIGMA

SITE	COLLECTION PERIOD	CONCENTRATIONS (PCI/KG WET ± 2 SIGMA)																	
		Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	I-131	Cs-134	Cs-137	Ba-140	La-140						
BY-CONTROL																			
<i>Lettuce</i>	08/02/17	< 30	< 31	< 62	< 36	< 74	< 32	< 54	< 50	< 33	< 29	< 150	< 42						
<i>Onions</i>	08/02/17	< 29	< 29	< 66	< 27	< 58	< 33	< 50	< 53	< 33	< 38	< 148	< 35						
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-						
BY-QUAD 1																			
<i>Cabbage</i>	08/02/17	< 28	< 32	< 47	< 30	< 78	< 37	< 57	< 57	< 38	< 35	< 157	< 44						
<i>Potatoes</i>	08/02/17	< 24	< 25	< 46	< 18	< 47	< 25	< 40	< 41	< 29	< 27	< 114	< 29						
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-						
BY-QUAD 2																			
<i>Beet greens</i>	08/02/17	< 39	< 47	< 92	< 34	< 78	< 38	< 70	< 57	< 47	< 36	< 150	< 56						
<i>Beets</i>	08/02/17	< 39	< 39	< 86	< 36	< 74	< 36	< 62	< 57	< 41	< 34	< 157	< 52						
<i>Onions</i>	08/02/17	< 31	< 29	< 70	< 31	< 73	< 33	< 57	< 57	< 32	< 33	< 174	< 52						
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-						
BY-QUAD 3																			
<i>Carrots/Kohlrabi</i>	08/02/17	< 23	< 25	< 56	< 22	< 64	< 29	< 46	< 43	< 31	< 24	< 128	< 29						
<i>Lettuce</i>	08/02/17	< 34	< 31	< 60	< 31	< 69	< 39	< 48	< 55	< 32	< 34	< 147	< 49						
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-						
BY-QUAD 4																			
<i>Kale</i>	08/02/17	< 31	< 33	< 70	< 42	< 68	< 43	< 59	< 59	< 42	< 41	< 160	< 50						
<i>Potatoes</i>	08/02/17	< 31	< 35	< 69	< 32	< 86	< 37	< 64	< 59	< 33	< 33	< 181	< 41						
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-						

Table C-IX.1 QUARTERLY OSLD RESULTS FOR BYRON NUCLEAR GENERATING STATION, 2017
 RESULTS IN UNITS OF MREM/QUARTER ± 2 STANDARD DEVIATIONS

STATION CODE	MEAN ± 2 S.D.	JAN - MAR	APR - JUN	JUL - SEP	OCT - DEC
BY-01-1	21 ± 3	19	20	22	22
BY-01-2	20 ± 4	18	21	22	19
BY-04-1	24 ± 4	22	24	27	23
BY-04-2	23 ± 2	23	22	24	22
BY-06-1	21 ± 5	19	19	23	24
BY-06-2	20 ± 5	17	21	21	22
BY-21-1	18 ± 2	17	19	19	19
BY-21-2	19 ± 5	16	20	21	20
BY-22-1	25 ± 4	22	25	27	25
BY-22-2	24 ± 6	21	23	28	23
BY-23-1	25 ± 5	22	24	28	25
BY-23-2	24 ± 5	21	22	27	24
BY-24-1	22 ± 6	19	20	26	22
BY-24-2	23 ± 5	19	22	25	24
BY-101-1	19 ± 3	17	19	21	19
BY-101-2	18 ± 5	15	18	21	20
BY-102-1	25 ± 6	22	24	29	24
BY-102-2	26 ± 5	23	24	29	27
BY-103-1	24 ± 5	21	24	27	26
BY-103-2	25 ± 2	24	25	27	25
BY-103-3	24 ± 3	22	24	25	24
BY-104-1	26 ± 4	23	25	28	27
BY-104-2	25 ± 7	21	24	29	27
BY-104-3	24 ± 3	23	23	25	25
BY-105-1	26 ± 4	24	23	27	28
BY-105-2	27 ± 7	23	27	31	25
BY-106-1	26 ± 4	24	26	28	25
BY-106-2	24 ± 7	20	22	26	27
BY-107-1	26 ± 3	24	25	27	28
BY-107-2	27 ± 6	24	26	31	27
BY-107-3	22 ± 3	20	22	23	24
BY-108-1	25 ± 5	22	27	27	25
BY-108-2	23 ± 4	21	21	25	24
BY-109-1	23 ± 3	21	22	24	24
BY-109-2	24 ± 4	23	22	27	23
BY-110-1	23 ± 3	21	23	23	25
BY-110-2	23 ± 2	23	23	25	22
BY-111-3	25 ± 6	21	23	28	27
BY-111-4	24 ± 3	23	23	25	25
BY-112-3	24 ± 5	22	22	27	24
BY-112-4	25 ± 4	22	25	26	26
BY-113-1	24 ± 5	22	25	27	23
BY-113-2	22 ± 4	20	21	25	23
BY-114-1	21 ± 5	18	22	22	23
BY-114-2	23 ± 5	20	22	26	24
BY-115-1	24 ± 4	22	24	26	26
BY-115-2	22 ± 5	19	22	25	24
BY-116-1	22 ± 4	20	21	24	21
BY-116-2	21 ± 4	19	22	23	22

Table C-IX.1 QUARTERLY OSLD RESULTS FOR BYRON NUCLEAR GENERATING STATION, 2017
 RESULTS IN UNITS OF MREM/QUARTER ± 2 STANDARD DEVIATIONS

STATION CODE	MEAN ± 2 S.D.	JAN - MAR	APR - JUN	JUL - SEP	OCT - DEC
BY-116-3	22 ± 3	20	23	23	23
BY-201-3	25 ± 4	23	24	27	27
BY-201-4	25 ± 5	23	23	28	26
BY-202-1	23 ± 2	21	23	23	24
BY-202-2	26 ± 5	23	24	29	26
BY-203-1	21 ± 6	17	20	24	22
BY-203-2	23 ± 4	21	22	24	24
BY-204-1	22 ± 5	19	21	25	23
BY-204-2	26 ± 4	23	27	27	25
BY-205-1	26 ± 5	23	25	26	29
BY-205-2	23 ± 5	20	23	25	23
BY-206-1	25 ± 5	23	25	29	26
BY-206-2	26 ± 5	23	25	28	28
BY-207-1	27 ± 6	25	25	31	29
BY-207-2	25 ± 5	22	24	28	25
BY-208-1	27 ± 6	24	25	30	30
BY-208-2	26 ± 4	23	26	27	28
BY-209-1	26 ± 5	23	24	28	28
BY-209-4	26 ± 5	24	24	29	27
BY-210-3	24 ± 6	21	23	27	27
BY-210-4	24 ± 3	21	23	25	25
BY-211-1	25 ± 4	23	24	27	26
BY-211-4	26 ± 4	23	28	28	26
BY-212-1	25 ± 7	22	23	29	26
BY-212-4	27 ± 8	22	26	31	30
BY-213-1	25 ± 4	23	25	27	27
BY-213-4	25 ± 6	22	24	29	27
BY-214-1	25 ± 4	23	24	28	24
BY-214-4	26 ± 4	24	25	28	27
BY-215-1	26 ± 4	23	25	27	28
BY-215-4	27 ± 3	26	25	29	27
BY-216-1	27 ± 5	23	26	29	29
BY-216-2	26 ± 6	21	26	29	27
BY-301-1	19 ± 4	17	18	21	21
BY-301-2	21 ± 5	18	20	24	21
BY-309-1	24 ± 5	22	23	27	23
BY-309-2	24 ± 4	22	24	26	24
BY-309-3	22 ± 4	20	21	25	21
BY-309-4	21 ± 4	19	21	24	19
BY-314-2	20 ± 3	18	19	21	21
BY-08-1 (Ctrl)	22 ± 4	19	21	23	23
BY-08-2 (Ctrl)	21 ± 6	19	18	25	21

TABLE C-IX.2 MEAN QUARTERLY OSLD RESULTS FOR THE INNER RING, OUTER RING, OUTER RING, SPECIAL INTEREST, OTHER, AND CONTROL LOCATIONS FOR BYRON NUCLEAR GENERATING STATION, 2017

RESULTS IN UNITS OF MILLIREM/STD. QUARTER ± 2 STANDARD DEVIATION

COLLECTION PERIOD	INNER RING ± 2 S.D.	OUTER RING ± 2 S.D.	SPECIAL INTEREST ± 2 S.D.	OTHER ± 2 S.D.	CONTROL ± 2 S.D.
JAN-MAR	21 ± 4	22 ± 3	19 ± 4	20 ± 4	19 ± 0
APR-JUN	23 ± 4	24 ± 3	21 ± 4	21 ± 4	20 ± 4
JUL-SEP	26 ± 5	28 ± 4	24 ± 4	24 ± 6	24 ± 3
OCT-DEC	24 ± 4	26 ± 4	21 ± 3	22 ± 4	22 ± 3

TABLE C-IX.3 SUMMARY OF THE AMBIENT DOSIMETRY PROGRAM FOR BYRON NUCLEAR GENERATING STATION, 2017

RESULTS IN UNITS OF MILLIREM/STD. QUARTER ± 2 STANDARD DEVIATION

LOCATION	SAMPLES ANALYZED	PERIOD MINIMUM	PERIOD MAXIMUM	PERIOD MEAN ± 2 S.D.
INNER RING	144	15	31	24 ± 5
OUTER RING	128	17	31	25 ± 5
SPECIAL INTEREST	28	17	27	21 ± 5
OTHER	56	16	28	22 ± 6
CONTROL	8	18	25	21 ± 5

INNER RING STATIONS - BY-101-1, BY-101-2, BY-102-1, BY-102-2, BY-103-1, BY-103-2, BY-103-3, BY-104-1, BY-104-2, BY-104-3, BY-105-1, BY-105-2, BY-106-1, BY-106-2, BY-107-1, BY-107-2, BY-107-3, BY-108-1, BY-108-2, BY-109-1, BY-109-2, BY-110-1, BY-110-2, BY-111-3, BY-111-4, BY-112-3, BY-112-4, BY-113-1, BY-113-2, BY-114-1, BY-114-2, BY-115-1, BY-115-2, BY-116-1, BY-116-2, BY-116-3

OUTER RING STATIONS - BY-201-3, BY-201-4, BY-202-1, BY-202-2, BY-203-1, BY-203-2, BY-204-1, BY-204-2, BY-205-1, BY-205-2, BY-206-1, BY-206-2, BY-207-1, BY-207-2, BY-208-1, BY-208-2, BY-209-1, BY-209-4, BY-210-3, BY-210-4, BY-211-1, BY-211-4, BY-212-1, BY-212-4, BY-213-1, BY-213-4, BY-214-1, BY-214-4, BY-215-1, BY-215-4, BY-216-1, BY-216-2

SPECIAL INTEREST STATIONS - BY-301-1, BY-301-2, BY-309-1*, BY-309-2*, BY-309-3*, BY-309-4*, BY-314-2

OTHER STATIONS - BY-01-1, BY-01-2, BY-04-1, BY-04-2, BY-06-1, BY-06-2, BY-21-1, BY-21-2, BY-22-1, BY-22-2, BY-23-1, BY-23-2, BY-24-1, BY-24-2


CONTROL STATIONS - BY-08-1, BY-08-2

*For ISFSI Monitoring


FIGURE C-1

Surface Water - Gross Beta - Stations BY-12 and BY-29 (C) Collected in the Vicinity of BNGS, 2000 - 2017

BY-12 Oregon Pool of Rock River, Downstream




BY-29 (C) Byron, Rock River Upstream




*DUE TO VENDOR CHANGE IN 2005, < VALUES ARE LLD VALUES JANUARY THROUGH JUNE 2005
AND MDC VALUES AFTER JUNE 2005*

FIGURE C-2 Surface Water - Tritium - Stations BY-12 and BY-29 (C) Collected in the Vicinity of BNGS, 2000 - 2017

BY-12 Oregon Pool of Rock River, Downstream




BY-29 (C) Byron, Rock River Upstream



*DUE TO VENDOR CHANGE IN 2005, < VALUES ARE LLD VALUES JANUARY THROUGH JUNE 2005
AND MDC VALUES AFTER JUNE 2005*

FIGURE C-3
Ground Water - Tritium - Station BY-14-1
Collected in the Vicinity of BNGS, 2000 - 2017

BY-14-1 3200 N. German Church Road Well



*DUE TO VENDOR CHANGE IN 2005, < VALUES ARE LLD VALUES JANUARY THROUGH JUNE 2005
AND MDC VALUES AFTER JUNE 2005*

FIGURE C-4
Ground Water - Tritium - Stations BY-18-1
Collected in the Vicinity of BNGS, 2010 - 2017

BY-18-1 Calhoun Well




FIGURE C-5
Ground Water - Tritium - Station BY-32
Collected in the Vicinity of BNGS, 2000 - 2017

BY-32 Krueger Well




FIGURE C-6
Ground Water - Tritium - Station BY-35
Collected in the Vicinity of BNGS, 2006 - 2017

BY-35 Vancko Well





FIGURE C-7
Ground Water - Tritium - Station BY-37
Collected in the Vicinity of BNGS, 2006 - 2017

BY-37 Kavage Well



Ground Water - Tritium - Station BY-38
Collected in the Vicinity of BNGS, 2006 - 2017

BY-38 Steve Storz Well





FIGURE C-8
Air Particulate - Gross Beta - Stations BY-08 (C) and BY-21
Collected in the Vicinity of BNGS, 2000 - 2017

BY-08 (C) Leaf River WNW



BY-21 Byron Nearsite N





FIGURE C-9
Air Particulate - Gross Beta - Stations BY-22 and BY-23
Collected in the Vicinity of BNGS, 2000 - 2017

BY-22 Byron Nearsite SE



BY-23 Byron Nearsite S




FIGURE C-10
Air Particulate - Gross Beta - Stations BY-24
Collected in the Vicinity of BNGS, 2000 - 2017

BY-24 Byron Nearsite SW






FIGURE C-11
Air Particulate - Gross Beta - Stations BY-01 and BY-04
Collected in the Vicinity of BNGS, 2005 - 2017

BY-01 Byron N




BY-04 Paynes Point SE



Regular analysis of far field air particulate & gross beta did not take place prior to 2005

FIGURE C-12
Air Particulate - Gross Beta - Station BY-06
Collected in the Vicinity of BNGS, 2005 - 2017

BY-06 Oregon SSW



Regular analysis of far field air particulate & gross beta did not take place prior to 2005

Intentionally left blank

APPENDIX D

INTER-LABORATORY COMPARISON PROGRAM

Intentionally left blank

TABLE D.1

**Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering, 2017**

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Reported Value	Known Value ^(a)	Ratio of TBE to Analytics Result	Evaluation ^(b)		
March 2017	E11811	Milk	Sr-89	pCi/L	87	97.7	0.89	A		
			Sr-90	pCi/L	12.4	16.2	0.77	W		
March 2017	E11812	Milk	Ce-141	pCi/L	135	145	0.93	A		
			Co-58	pCi/L	153	150	1.02	A		
			Co-60	pCi/L	182	183	1.00	A		
			Cr-51	pCi/L	258	290	0.89	A		
			Cs-134	pCi/L	104	120	0.87	A		
			Cs-137	pCi/L	142	140	1.02	A		
			Fe-59	pCi/L	135	129	1.05	A		
			I-131	pCi/L	92.6	97.9	0.95	A		
			Mn-54	pCi/L	173	164	1.05	A		
			Zn-65	pCi/L	208	199	1.04	A		
			E11813	Charcoal	I-131	pCi	92	93.9	0.98	A
			E11814	AP	Ce-141	pCi	99.9	101	0.99	A
					Co-58	pCi	95.4	104	0.92	A
Co-60	pCi	140			127	1.10	A			
Cr-51	pCi	211			201	1.05	A			
Cs-134	pCi	82.1			83.2	0.99	A			
Cs-137	pCi	92.8			97.0	0.96	A			
Fe-59	pCi	107			89.3	1.20	A			
Mn-54	pCi	106			114	0.93	A			
E11816	Soil	Ce-141	pCi/g	0.258	0.250	1.03	A			
		Co-58	pCi/g	0.241	0.258	0.93	A			
		Co-60	pCi/g	0.312	0.315	0.99	A			
		Cr-51	pCi/g	0.439	0.500	0.88	A			
		Cs-134	pCi/g	0.176	0.207	0.85	A			
		Cs-137	pCi/g	0.304	0.317	0.96	A			
		Fe-59	pCi/g	0.210	0.222	0.95	A			
		Mn-54	pCi/g	0.292	0.283	1.03	A			
Zn-65	pCi/g	0.353	0.344	1.03	A					
E11815	Water	Fe-55	pCi/L	1600	1890	0.85	A			

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

TABLE D.1

**Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering, 2017**

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Reported Value	Known Value ^(a)	Ratio of TBE to Analytics Result	Evaluation ^(b)		
June 2017	E11844	Milk	Sr-89	pCi/L	81.3	92.6	0.88	A		
			Sr-90	pCi/L	12.1	13.5	0.90	A		
June 2017	E11846	Milk	Ce-141	pCi/L	142	151	0.94	A		
			Co-58	pCi/L	147	155	0.95	A		
			Co-60	pCi/L	185	191	0.97	A		
			Cr-51	pCi/L	321	315	1.02	A		
			Cs-134	pCi/L	168	188	0.89	A		
			Cs-137	pCi/L	148	150	0.99	A		
			Fe-59	pCi/L	116	115	1.01	A		
			I-131	pCi/L	102	93.6	1.09	A		
			Mn-54	pCi/L	168	172	0.98	A		
			Zn-65	pCi/L	195	204	0.96	A		
			E11847	Charcoal	I-131	pCi	87.9	84.8	1.04	A
			E11845	AP	Sr-89	pCi	70.8	79.1	0.90	A
					Sr-90	pCi	9.10	11.5	0.79	W
E11848	AP	Ce-141	pCi	112	116	0.96	A			
		Co-58	pCi	119	119	1.00	A			
		Co-60	pCi	171	146	1.17	A			
		Cr-51	pCi	270	241	1.12	A			
		Cs-134	pCi	152	144	1.05	A			
		Cs-137	pCi	114	115	0.99	A			
		Fe-59	pCi	94.1	88.3	1.07	A			
		Mn-54	pCi	139	132	1.06	A			
		Zn-65	pCi	141	156	0.90	A			
E11849	Water	Fe-55	pCi/L	1840	1890	0.97	A			
July 2017	E11901	AP	GR-A	pCi	50.1	44.2	1.13	A		
			GR-B	pCi	218	233	0.93	A		

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

TABLE D.1

**Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering, 2017**

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Reported Value	Known Value ^(a)	Ratio of TBE to Analytics Result	Evaluation ^(b)		
September 2017	E11914	Milk	Sr-89	pCi/L	84.3	82.7	1.02	A		
			Sr-90	pCi/L	12.6	12.1	1.04	A		
	E11915	Milk	Ce-141	pCi/L	93.9	87.0	1.08	A		
			Co-58	pCi/L	115	117	0.98	A		
			Co-60	pCi/L	265	262	1.01	A		
			Cr-51	pCi/L	273	217	1.26	W		
			Cs-134	pCi/L	186	201	0.93	A		
			Cs-137	pCi/L	175	172	1.02	A		
			Fe-59	pCi/L	137	125	1.09	A		
			I-131	pCi/L	78.0	71.0	1.10	A		
			Mn-54	pCi/L	128	123	1.04	A		
			Zn-65	pCi/L	206	184	1.12	A		
			E11916	Charcoal	I-131	pCi	71.9	64.4	1.12	A
			E11917	AP	Ce-141	pCi	80.1	86.3	0.93	A
Co-58	pCi	110			116	0.95	A			
Co-60	pCi	277			260	1.07	A			
Cr-51	pCi	275			215	1.28	W			
Cs-134	pCi	192			199	0.96	A			
Cs-137	pCi	165			170	0.97	A			
Fe-59	pCi	122			124	0.98	A			
Mn-54	pCi	120			122	0.99	A			
Zn-65	pCi	175	183	0.96	A					
E11918	Water	Fe-55	pCi/L	1630	1630	1.00	A			
E11919	Soil	Ce-141	pCi/g	0.136	0.142	0.96	A			
		Co-58	pCi/g	0.179	0.191	0.94	A			
		Co-60	pCi/g	0.405	0.429	0.94	A			
		Cr-51	pCi/g	0.230	0.355	0.65	N ⁽¹⁾			
		Cs-134	pCi/g	0.272	0.328	0.83	A			
		Cs-137	pCi/g	0.336	0.356	0.94	A			
		Fe-59	pCi/g	0.210	0.205	1.02	A			
		Mn-54	pCi/g	0.210	0.201	1.05	A			
Zn-65	pCi/g	0.301	0.301	1.00	A					

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

(1) See NCR 17-16

TABLE D.1

**Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering, 2017**

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Reported Value	Known Value ^(a)	Ratio of TBE to Analytics Result	Evaluation ^(b)
December 2017	E12054	Milk	Sr-89	pCi/L	92.1	92.3	1.00	A
			Sr-90	pCi/L	18.3	16.9	1.09	A
	E12055	Milk	Ce-141	pCi/L	97.8	98.3	0.99	A
			Co-58	pCi/L	92.3	89.9	1.03	A
			Co-60	pCi/L	176	173	1.02	A
			Cr-51	pCi/L	226	242	0.93	A
			Cs-134	pCi/L	118	125	0.95	A
			Cs-137	pCi/L	148	141	1.05	A
			Fe-59	pCi/L	123	113	1.08	A
			I-131	pCi/L	66.0	57.8	1.14	A
			Mn-54	pCi/L	173	161	1.08	A
			Zn-65	pCi/L	233	211	1.10	A
				E12056	Charcoal	I-131	pCi	48.1
	E12057A	AP	Ce-141	pCi	108	111	0.97	A
			Co-58	pCi	89.5	102	0.88	A
			Co-60	pCi	223	196	1.14	A
			Cr-51	pCi	311	274	1.13	A
			Cs-134	pCi	141	142	1.00	A
			Cs-137	pCi	162	160	1.01	A
			Fe-59	pCi	121	129	0.94	A
			Mn-54	pCi	177	182	0.97	A
			Zn-65	pCi	203	239	0.85	A
	E12058	Water	Fe-55	pCi/L	1970	1740	1.13	A
	E12059	AP	Sr-89	pCi	71.2	87.4	0.81	A
			Sr-90	pCi	12.9	16.0	0.81	A

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

TABLE D.2

DOE's Mixed Analyte Performance Evaluation Program (MAPEP)
Teledyne Brown Engineering, 2017

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Reported Value	Known Value ^(a)	Acceptance Range	Evaluation ^(b)	
February 2017	17-MaS36	Soil	Ni-63	Bq/kg	-5.512		(1)	A	
			Sr-90	Bq/kg	571	624	437 - 811	A	
	17-MaW36	Water	Am-241	Bq/L	0.693	0.846	0.592 - 1.100	A	
			Ni-63	Bq/L	13.4	12.2	8.5 - 15.9	A	
			Pu-238	Bq/L	0.7217	0.703	0.492 - 0.914	A	
			Pu-239/240	Bq/L	0.9277	0.934	0.654 - 1.214	A	
	17-RdF36	AP	U-234/233	Bq/sample	0.0911	0.104	0.073 - 0.135	A	
			U-238	Bq/sample	0.0967	0.107	0.075 - 0.139	A	
	17-RdV36	Vegetation	Cs-134	Bq/sample	6.44	6.95	4.87 - 9.04	A	
			Cs-137	Bq/sample	4.61	4.60	3.22 - 5.98	A	
			Co-57	Bq/sample	-0.0229		(1)	A	
			Co-60	Bq/sample	8.52	8.75	6.13 - 11.38	A	
			Mn-54	Bq/sample	3.30	3.28	2.30 - 4.26	A	
			Sr-90	Bq/sample	1.30	1.75	1.23 - 2.28	W	
			Zn-65	Bq/sample	5.45	5.39	3.77 - 7.01	A	
	August 2017	17-MaS37	Soil	Ni-63	Bq/kg	1130	1220	854 - 1586	A
				Sr-90	Bq/kg	296	289	202 - 376	A
17-MaW37		Water	Am-241	Bq/L	0.838	0.892	0.624 - 1.160	A	
			Ni-63	Bq/L	-0.096		(1)	A	
			Pu-238	Bq/L	0.572	0.603	0.422 - 0.784	A	
			Pu-239/240	Bq/L	0.863	0.781	0.547 - 1.015	A	
17-RdF37		AP	U-234/233	Bq/sample	0.103	0.084	0.059 - 0.109	W	
			U-238	Bq/sample	0.115	0.087	0.061 - 0.113	N ⁽²⁾	
17-RdV37		Vegetation	Cs-134	Bq/sample	2.34	2.32	1.62 - 3.02	A	
			Cs-137	Bq/sample	0.05		(1)	A	
			Co-57	Bq/sample	3.32	2.8	2.0 - 3.6	A	
			Co-60	Bq/sample	2.09	2.07	1.45 - 2.69	A	
			Mn-54	Bq/sample	2.90	2.62	1.83 - 3.41	A	
			Sr-90	Bq/sample	1.17	1.23	0.86 - 1.60	A	
			Zn-65	Bq/sample	6.07	5.37	3.76 - 6.98	A	

(a) The MAPEP known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) DOE/MAPEP evaluation:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

(1) False positive test

(2) See NCR 17-15

TABLE D.3

**ERA Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering, 2017**

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Reported Value	Known Value ^(a)	Acceptance Limits	Evaluation ^(b)
March 2017	MRAD-26	AP	GR-A	pCi/sample	76.3	85.5	28.6 - 133	A
April 2017	RAD-109	Water	Ba-133	pCi/L	49.2	49.7	40.8 - 55.1	A
			Cs-134	pCi/L	83.2	90.1	74.0 - 99.1	A
			Cs-137	pCi/L	202	206	185 - 228	A
			Co-60	pCi/L	51.2	54.7	49.2 - 62.7	A
			Zn-65	pCi/L	39.3	53.8	47.2 - 65.9	N ⁽¹⁾
			GR-A	pCi/L	53.6	75.0	39.5 - 92.3	A
			GR-B	pCi/L	42.7	38.5	25.5 - 46.0	A
			U-Nat	pCi/L	50.1	55.6	45.2 - 61.7	A
			H-3	pCi/L	7080	6850	5920 - 7540	A
			Sr-89	pCi/L	40.7	66.2	53.8 - 74.3	N ⁽¹⁾
			Sr-90	pCi/L	26.9	26.7	19.3 - 31.1	A
			I-131	pCi/L	26.7	29.9	24.9 - 34.9	A
September 2017	MRAD-27	AP	GR-A	pCi/sample	40.9	50.1	16.8 - 77.8	A
		AP	GR-B	pCi/sample	58.0	61.8	39.1 - 90.1	A
October 2017	RAD-111	Water	Ba-133	pCi/L	71.3	73.7	61.7 - 81.1	A
			Cs-134	pCi/L	43.0	53.0	42.8 - 58.3	A
			Cs-137	pCi/L	48.2	52.9	47.6 - 61.1	A
			Co-60	pCi/L	69.0	69.5	62.6 - 78.9	A
			Zn-65	pCi/L	335	348	313 - 406	A
			GR-A	pCi/L	32.5	35.6	18.3 - 45.8	A
			GR-B	pCi/L	24.3	25.6	16.0 - 33.6	A
			U-Nat	pCi/L	36.6	37.0	30.0 - 40.9	A
			H-3	pCi/L	6270	6250	5390 - 6880	A
			I-131	pCi/L	26.4	24.2	20.1 - 28.7	A
November 2017	1113170	Water	Sr-89	pCi/L	57.1	50.0	39.4 - 57.5	A
			Sr-90	pCi/L	27.1	41.8	30.8 - 48.0	N ⁽²⁾

(a) The ERA known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.

(b) ERA evaluation:

A = Acceptable - Reported value falls within the Acceptance Limits

N = Not Acceptable - Reported value falls outside of the Acceptance Limits

(1) See NCR 17-09

(2) See NCR 17-19

APPENDIX E

EFFLUENT REPORT

Intentionally left blank

TABLE OF CONTENTS

<u>SUMMARY</u>	1
<u>INTRODUCTION</u>	2
<u>1.0. EFFLUENTS</u>	3
<u>1.1. Gaseous Effluents to the Atmosphere</u>	3
<u>1.2. Liquids Released to Rock River</u>	3
<u>2.0. SOLID RADIOACTIVE WASTE</u>	4
<u>3.0. DOSE TO MAN</u>	4
<u>3.1. Gaseous Effluent Pathways</u>	4
<u>3.1.1. Noble Gases</u>	4
<u>3.1.1.1. Gamma Dose Rates</u>	4
<u>3.1.1.2. Beta Air and Skin Dose Rate</u>	4
<u>3.1.2. Radioactive Iodine & Particulate</u>	5
<u>3.1.3. Gaseous Total Dose</u>	5
<u>3.2. Liquid Effluent Pathways</u>	6
<u>3.3. Total Dose</u>	6
<u>3.4. Assessment of Dose to Member of Public</u>	6
<u>4.0. SITE METEOROLOGY</u>	7

Table of Contents (cont.)

APPENDIX E-1 DATA TABLES AND FIGURES

Station Releases

Table 1.1-1 Gaseous Effluents	E-1-1
Table 1.2-1 Liquid Effluents	E-1-3
Table 3.1-1 40CFR190 Maximum Doses Resulting from Liquid Releases	E-1-5
Table 3.2-1 40CFR190 Maximum Doses Resulting from Gaseous Releases..	E-1-7
Table 3.3-1 40CFR190 Uranium Fuel Cycle Report – Total Dose	E-1-9
Table 3.4-1 Maximum Doses Resulting from Airborne Releases Based On Concurrent Meteorological Data	E-1-11

SUMMARY

Calculations based on gaseous and liquid effluents and meteorological data indicate that public dose due to radioactive material attributable to Byron Station during the period does not exceed regulatory or Offsite Dose Calculation Manual (ODCM) limits.

The Total Effective Dose Equivalent (TEDE) due to licensed activities at Byron Station calculated for the maximum exposed individual for the period is 2.56E-01 mrem. The annual limit on TEDE is 100 mrem.

The assessment of radiation doses to the public is performed in accordance with the ODCM. The results of these analyses confirm that the station is operating in compliance with 10CFR50 Appendix I, 10CFR20 and 40CFR190.

There were no additional operational controls implemented which affected the areas of radiological effluents in 2017.

There were no measurements which exceeded the reporting levels, including any which would not have been attributable to station effluents.

The results of the current radiological environmental monitoring program are approximately the same as those found during the pre-operational studies conducted at Byron Station.

INTRODUCTION

Liquid effluents from Byron Station are released to the Rock River in controlled batches after radioassay of each batch. Gaseous effluents are released to the atmosphere and are calculated on the basis of analyses of weekly grab samples and grab samples of batch releases prior to the release of noble gases as well as continuously collected composite samples of iodine and particulate radioactivity sampled during the course of the year. The results of effluent analyses are summarized on a monthly basis. Airborne concentrations of noble gases, I-131, and particulate radioactivity in offsite areas are calculated using isotopic composition of effluents and meteorological data. C-14 concentration in offsite areas is calculated based on industry-approved methodology for estimation of the amount released and meteorological data.

Environmental monitoring is conducted by sampling at indicator and control (background) locations in the vicinity of Byron Station to measure changes in radiation or radioactivity levels that may be attributable to station operation. If significant changes attributable to Byron Station are measured, these changes are correlated with effluent releases. An environmental monitoring program is conducted which also includes all potential pathways at the site. Gaseous pathways include ground plane (direct), inhalation, vegetation, meat, and milk. Liquid pathways include potable water and freshwater fish. The critical pathway for 2017 gaseous dose was vegetation. The critical pathway for 2017 liquid dose was freshwater fish.

1.0 EFFLUENTS

1.1 Gaseous Effluents to the Atmosphere

Measured concentrations and isotopic composition of noble gases, radioiodine, tritium and particulate radioactivity released to the atmosphere during the year are listed in Table 1.1-1.

A total of $8.90\text{E-}01$ curies of fission and activation gases were released with a maximum average quarterly release rate of $3.87\text{E-}02$ $\mu\text{Ci/sec}$.

A total of $1.55\text{E-}06$ curies of $1\text{-}131$ were released during the year with a maximum average quarterly release rate of $1.99\text{E-}07$ $\mu\text{Ci/sec}$.

A total of $2.39\text{E-}06$ curies were released as airborne particulate matter with a maximum average quarterly release rate of $3.01\text{E-}07$ $\mu\text{Ci/sec}$.

A total of $8.39\text{E+}00$ curies of other (C-14) radioisotopes were released with a maximum average quarterly release rate of $2.87\text{E-}01$ $\mu\text{Ci/sec}$.

A total of $3.96\text{E+}01$ curies of tritium were released with a maximum average quarterly release rate of $1.44\text{E+}00$ $\mu\text{Ci/sec}$.

Gross alpha-emitting radionuclides were below detectable limits.

1.2 Liquids Released to Rock River

A total of $2.82\text{E+}10$ liters of radioactive liquid wastes containing $1.84\text{E-}02$ curies of fission and activation products were discharged with a maximum quarterly average concentration of $1.20\text{E-}09$ $\mu\text{Ci/ml}$.

A total of $1.98\text{E+}03$ curies of tritium were discharged with a maximum quarterly average concentration of $1.44\text{E-}04$ uCi/ml .

A total of $6.58\text{E-}04$ curies of dissolved and entrained gases were discharged with a maximum quarterly average concentration of $6.82\text{E-}11$ uCi/ml .

Gross alpha-emitting radionuclides were below detectable limits.

Quarterly release totals of principal radionuclides in liquid effluents are given in Table 1.2-1.

2.0 SOLID RADIOACTIVE WASTE

Solid radioactive wastes were shipped by truck. For detail, refer to Byron Station 2017 Annual Radiological Effluent Release Report.

3.0 DOSE TO MAN

3.1 Gaseous Effluent Pathways

Table 3.2-1 summarizes the doses resulting from releases of airborne radioactivity via the different exposure pathways.

3.1.1 Noble Gases

3.1.1.1 Gamma Dose Rates

Offsite Gamma air and whole body dose rates are shown in Table 3.2-1 and were calculated based on measured release rates, isotopic composition of the noble gases, and average meteorological data for the period. Dose rates based on concurrent meteorological data are shown in Table 3.4-1. Based on measured effluents and average meteorological data, the maximum gamma air dose was $3.72\text{E-}05$ mrad based on measured effluents and average meteorological data, and $7.54\text{E-}06$ mrad based on measured effluents and concurrent meteorological data. (Table 3.4-1).

3.1.1.2 Beta Air and Skin Dose Rates

The range of beta particles in air is relatively small (on the order of a few meters or less); consequently, plumes of gaseous effluents may be considered "semi-infinite" for purpose of calculating the dose from beta radiation incident on the skin. However, the actual dose to sensitive skin tissues is difficult to calculate due to the effect of the beta particle energies, thickness of inert skin and clothing covering sensitive tissues. For purposes of this report the skin is taken to have a thickness of 7.0 mg/cm^2 and an occupancy factor of 1.0 is used. The skin dose based on measured effluents and average meteorological data was $1.83\text{E-}05$ mrem, and $1.47\text{E-}05$ mrem based on measured effluents and concurrent meteorological data.

The maximum offsite beta air dose for the year based on measured effluents and average meteorological data was 1.93E-05 mrad. The beta air dose based on measured effluents and concurrent meteorological data was 1.61E-05 mrad.

3.1.2 Radioactive Iodine & Particulate

The human thyroid exhibits a significant capacity to concentrate ingested or inhaled iodine. I-131 released during routine operation of the station may be made available to man resulting in a dose to the thyroid. C-14 is also included in this category. C-14 exhibits a capacity to concentrate in bone. C-14 is released in gaseous form and is absorbed into vegetation through photosynthesis. The principal pathways of interest for C-14 are the consumption of vegetation by humans and milk from which animals have ingested C-14 through the consumption of vegetation. With the addition of C-14 to plant effluents, human dose in this category is primarily driven by the release of C-14 from the plant.

The hypothetical dose to the maximum exposed individual living near the station via ingestion of milk and vegetation was calculated. The source of milk and vegetation was assumed to be at the nearest site boundary with the cows pastured and vegetation grown from May through October. The maximum dose from radioactive iodine and particulate (including C-14) to any organ was 6.84E-01 mrem (child/bone) based on measured effluents and average meteorological data and 7.30E-01 mrem based on measured effluents and concurrent meteorological data. The maximum dose from radioactive iodine and particulate (including C-14) to the whole body was 1.39E-01 mrem (child) based on measured effluents and average meteorological data and 1.49E-01 mrem based on measured effluents and concurrent meteorological data.

3.1.3 Gaseous Total Dose

The maximum total dose from gaseous releases to any organ was 6.84E-01 mrem (child/bone) based on measured effluents and average meteorological data, and 7.30E-01 mrem (child/bone) based on measured effluents and concurrent meteorological data. The maximum total dose from gaseous releases to the whole body was 1.39E-01 mrem (child) based on measured effluents and average meteorological data, and 1.49E-01 mrem (child) based on measured effluents and concurrent meteorological data.

3.2 Liquid Effluent Pathways

The principal pathways through the aquatic environment for potential doses to man from liquid waste are ingestion of potable water and eating aquatic foods. Liquid dose was calculated based on the ingestion of potable water and sport fish. It should be noted, however, there were no communities within 10 km downstream of the plant using the Rock River for drinking water. NRC-developed equations were used to calculate the doses to the whole body, bone, liver, thyroid, kidney, lung, lower GI tract, and skin. Specific parameters for use in the equations are given in the Exelon Offsite Dose Calculation Manual (ODCM). The maximum dose from liquid releases to any organ was 1.88E-01 mrem (adult/gilli). The maximum dose from liquid releases to the whole body was 1.38E-01 mrem (adult).

3.3 Total Dose

The maximum total dose to any organ via both gaseous and liquid effluents to any organ is 7.55E-01 mrem (child/bone). The maximum dose to the whole body via both gaseous and liquid effluents is 2.56E-01 mrem (child).

3.4 Assessment of Dose to Member of Public

Byron Station did not exceed any of the dose limits as shown below based on concurrent or historical meteorological data.

- The RETS limits on dose or dose commitment to a member of the public due to radioactive materials in liquid effluents from each reactor is 1.5 mrem to the whole body or 5 mrem to any organ during any calendar quarter and 3 mrem to the whole body or 10 mrem to any organ during a calendar year.
- The RETS limits on air dose in noble gases released in gaseous effluents to a member of the public from each reactor is 5 mrad for gamma radiation or 10 mrad for beta radiation during any calendar quarter and 10 mrad for gamma radiation or 20 mrad for beta radiation during a calendar year.
- The RETS limits on dose to a member of the public due to radioactive iodine & particulate with half-lives greater than eight days in gaseous effluents released from each reactor is 7.5 mrem to any organ during any calendar quarter and 15 mrem during a calendar year.

- The 10CFR20 limit on Total Effective Dose Equivalent to individual members of the public is 100 mrem during a calendar year.
- The 40CFR190 limits on individual members of the public is 25 mrem to the whole body, 25 mrem to any organ (except thyroid), and 75 mrem to the thyroid.

4.0 SITE METEOROLOGY

Detailed records of the site meteorological measurements taken during each calendar quarter of the year are maintained by the meteorological vendor, retained on site, and are available upon request. The data are presented as cumulative joint frequency distributions of the wind direction for the 250' level and wind speed class by atmospheric stability class determined from the temperature difference between the 250' and 30' levels. Data recovery for all measurements on the meteorological tower was 99.9% during 2017.

Intentionally left blank

APPENDIX E-1

DATA TABLES AND FIGURES

Intentionally left blank

Table 1.1-1

**RG 1.21 EFFLUENT AND WASTE DISPOSAL REPORT
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES
Unit 1**

REPORT FOR 2017	Units	QTR 1	QTR 2	QTR 3	QTR 4	YEAR
Fission and Activation Gases						
1. Total Release	Ci	8.64E-02	9.98E-02	1.49E-01	2.54E-02	3.61E-01
2. Avg. Release Rate	uCi/sec	1.11E-02	1.27E-02	1.87E-02	3.20E-03	1.14E-02
Iodine-131						
1. Total Release	Ci	2.83E-07	(1)	(1)	(1)	2.83E-07
2. Avg. Release Rate	uCi/sec	3.64E-08	(1)	(1)	(1)	8.98E-09
Particulates Half Life >= 8 days						
1. Total Release	Ci	(1)	(1)	(1)	(1)	(1)
2. Avg. Release Rate	uCi/sec	(1)	(1)	(1)	(1)	(1)
Others						
1. Total Release	Ci	7.42E-01	1.15E+00	1.12E+00	1.16E+00	4.17E+00
2. Avg. Release Rate	uCi/sec	9.55E-02	1.46E-01	1.40E-01	1.46E-01	1.32E-01
Tritium						
1. Total Release	Ci	2.82E+00	2.20E+00	2.42E+00	1.92E+00	9.37E+00
2. Avg. Release Rate	uCi/sec	3.63E-01	2.80E-01	3.05E-01	2.42E-01	2.97E-01
Gross Alpha Radioactivity						
1. Total Release	Ci	(1)	(1)	(1)	(1)	(1)
2. Avg. Release Rate	uCi/sec	(1)	(1)	(1)	(1)	(1)

(1) Less than minimum detectable activity which meets the lower limit of detection (LLD) requirements of TRM Section 3.11

Table 1.1-1 (cont.)

RG 1.21 EFFLUENT AND WASTE DISPOSAL REPORT
 GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES
 Unit 2

REPORT FOR 2017	Units	QTR 1	QTR 2	QTR 3	QTR 4	YEAR
Fission and Activation Gases						
1. Total Release	Ci	1.88E-02	8.84E-02	1.40E-01	2.82E-01	5.29E-01
2. Avg. Release Rate	uCi/sec	2.42E-03	1.12E-02	1.76E-02	3.55E-02	1.68E-02
Iodine-131						
1. Total Release	Ci	1.27E-06	(1)	(1)	(1)	1.27E-06
2. Avg. Release Rate	uCi/sec	1.63E-07	(1)	(1)	(1)	4.02E-08
Particulates Half Life >= 8 days						
1. Total Release	Ci	(1)	(1)	(1)	2.39E-06	2.39E-06
2. Avg. Release Rate	uCi/sec	(1)	(1)	(1)	3.01E-07	7.59E-08
Others						
1. Total Release	Ci	1.11E+00	1.11E+00	1.11E+00	8.83E-01	4.22E+00
2. Avg. Release Rate	uCi/sec	1.43E-01	1.41E-01	1.40E-01	1.11E-01	1.34E-01
Tritium						
1. Total Release	Ci	8.37E+00	7.09E+00	8.24E+00	6.52E+00	3.02E+01
2. Avg. Release Rate	uCi/sec	1.08E+00	9.02E-01	1.04E+00	8.21E-01	9.58E-01
Gross Alpha Radioactivity						
1. Total Release	Ci	(1)	(1)	(1)	(1)	(1)
2. Avg. Release Rate	uCi/sec	(1)	(1)	(1)	(1)	(1)

(1) Less than minimum detectable activity which meets the lower limit of detection (LLD) requirements of TRM Section 3.11

Table 1.2-1

**RG 1.21 EFFLUENT AND WASTE DISPOSAL REPORT
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES
Unit 1**

REPORT FOR 2017	Units	QTR 1	QTR 2	QTR 3	QTR 4	YEAR

Fission and Activation Products						
1. Total Release	Ci	3.74E-03	1.88E-03	1.52E-03	2.71E-03	9.20E-03
2. Avg. Diluted Conc.	uCi/ml	1.20E-09	5.12E-10	3.91E-10	7.82E-10	6.51E-10
Tritium						
1. Total Release	Ci	4.49E+02	9.77E+01	3.40E+02	1.01E+02	9.88E+02
2. Avg. Diluted Conc.	uCi/ml	1.44E-04	2.67E-05	8.73E-05	2.93E-05	6.99E-05
Dissolved and Entrained Gases						
1. Total Release	Ci	2.12E-04	(1)	1.04E-04	1.21E-05	3.29E-04
2. Avg. Diluted Conc.	uCi/ml	6.82E-11	(1)	2.68E-11	3.50E-12	2.32E-11
Gross Alpha Radioactivity						
1. Total Release	Ci	(1)	(1)	(1)	(1)	(1)
Volume of liquid waste liters						
		3.11E+09	3.66E+09	3.89E+09	3.47E+09	1.41E+10

(1) Less than minimum detectable activity which meets the lower limit of detection (LLD) requirements of TRM Section 3.11

Table 1.2-1 (cont.)

RG 1.21 EFFLUENT AND WASTE DISPOSAL REPORT
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES
Unit 2

REPORT FOR 2017	Units	QTR 1	QTR 2	QTR 3	QTR 4	YEAR
Fission and Activation Products						
1. Total Release	Ci	3.74E-03	1.88E-03	1.52E-03	2.71E-03	9.20E-03
2. Avg. Diluted Conc.	uCi/ml	1.20E-09	5.12E-10	3.91E-10	7.82E-10	6.51E-10
Tritium						
1. Total Release	Ci	4.49E+02	9.77E+01	3.40E+02	1.01E+02	9.88E+02
2. Avg. Diluted Conc.	uCi/ml	1.44E-04	2.67E-05	8.73E-05	2.93E-05	6.99E-05
Dissolved and Entrained Gases						
1. Total Release	Ci	2.12E-04	(1)	1.04E-04	1.21E-05	3.29E-04
2. Avg. Diluted Conc.	uCi/ml	6.82E-11	(1)	2.68E-11	3.50E-12	2.32E-11
Gross Alpha Radioactivity						
1. Total Release	Ci	(1)	(1)	(1)	(1)	(1)
Volume of liquid waste liters		3.11E+09	3.66E+09	3.89E+09	3.47E+09	1.41E+10

(1) Less than minimum detectable activity which meets the lower limit of detection (LLD) requirements of TRM Section 3.11

Table 3.1-1

40CFR190 URANIUM FUEL CYCLE DOSE REPORT

LIQUID DOSE SUMMARY

Units 1 & 2

Report for: 2017

Unit Range - From: 1 To: 2

Liquid Receptor

=== PERIOD DOSE BY ORGAN AND AGE GROUP (mrem) ===== ANNUAL 2017 =====

Agegrp	Bone	Liver	Thyroid	Kidney	Lung	GI-LLI	Skin	TB
ADULT	5.35E-02	1.39E-01	1.35E-01	1.35E-01	1.35E-01	1.88E-01	0.00E+00	1.38E-01
TEEN	5.50E-02	1.06E-01	1.01E-01	1.01E-01	1.01E-01	1.39E-01	0.00E+00	1.05E-01
CHILD	7.16E-02	1.17E-01	1.13E-01	1.13E-01	1.13E-01	1.26E-01	0.00E+00	1.17E-01
INFANT	4.55E-04	5.00E-02	5.00E-02	5.00E-02	5.00E-02	5.00E-02	0.00E+00	5.00E-02

=== SITE DOSE LIMIT ANALYSIS ===== ANNUAL 2017 =====

Annual - Limit	Age Group	Organ	Dose (mrem)	Limit (mrem)	Max % of Limit
2017 - Admin. Any Organ	ADULT	GILLI	1.88E-01	7.50E+00	2.51E+00
2017 - Admin. Total Body	ADULT	TBODY	1.38E-01	2.25E+00	6.15E+00

2017 - T.Spc. Any Organ ADULT GILLI 1.88E-01 1.00E+01 1.88E+00

Critical Pathway: Fresh Water Fish - Sport (FFSP)

Major Contributors (0% or greater to total)

Nuclide	Percentage
H-3	7.18E+01
CR-51	1.46E-01
MN-54	2.30E-01
FE-55	5.69E-02
FE-59	1.31E-01
CO-58	3.29E+00
CO-60	4.27E+00
NI-63	3.77E-01
SR-89	2.54E-02
SR-90	5.21E-02
ZR-95	2.86E-04
ZR-97	5.92E-04
NB-95	1.96E+01
MO-99	1.30E-04
AG-110M	3.23E-03
SB-124	5.25E-04
SB-125	2.72E-03
TE-132	7.18E-02

2017 - T.Spc. Total Body ADULT TBODY 1.38E-01 3.00E+00 4.61E+00

Critical Pathway: Fresh Water Fish - Sport (FFSP)

Major Contributors (0% or greater to total)

Nuclide	Percentage
-----	-----

Table 3.1-1 (cont.)
40CFR190 URANIUM FUEL CYCLE DOSE REPORT
LIQUID DOSE SUMMARY

Units 1 & 2

Nuclide -----	Percentage -----
H-3	9.75E+01
CR-51	7.89E-04
MN-54	1.94E-02
FE-55	3.14E-02
FE-59	2.04E-02
CO-58	4.94E-01
CO-60	6.82E-01
NI-63	1.19E+00
SR-89	6.18E-03
SR-90	5.66E-02
ZR-95	8.30E-08
ZR-97	1.19E-09
NB-95	2.36E-03
MO-99	1.45E-05
AG-110M	6.39E-06
SB-124	9.93E-06
SB-125	8.00E-05
TE-132	1.94E-03

Table 3.2-1

40CFR190 URANIUM FUEL CYCLE DOSE REPORT

GASEOUS DOSE SUMMARY

Units 1 & 2

Report for: 2017

Unit Range - From: 1 To: 2

=== I&P DOSE LIMIT ANALYSIS ===== ANNUAL 2017 =====

Annual - Limit	Age Group	Organ	Dose (mrem)	Limit (mrem)	Max % of Limit
2017 - Admin. Any Organ	CHILD	BONE	6.84E-01	1.13E+01	6.08E+00
2017 - Admin. Total Body	CHILD	TBODY	1.39E-01	1.05E+01	1.32E+00

2017 - T.Spc. Any Organ CHILD BONE 6.84E-01 1.50E+01 4.56E+00

Receptor: Composite Crit. Receptor - IP

Distance: 800 (meters) Compass Point: SSE

Critical Pathway: Vegetation

Major Contributors (0% or greater to total)

Nuclide	Percentage
H-3	0.00E+00
C-14	1.00E+02
CO-58	1.59E-05
I-131	4.01E-05
I-132	2.91E-06

H-3 0.00E+00

C-14 1.00E+02

CO-58 1.59E-05

I-131 4.01E-05

I-132 2.91E-06

2017 - T.Spc. Total Body CHILD TBODY 1.39E-01 1.50E+01 9.26E-01

Receptor: Composite Crit. Receptor - IP

Distance: 800 (meters) Compass Point: SSE

Critical Pathway: Vegetation

Major Contributors (0% or greater to total)

Nuclide	Percentage
H-3	1.61E+00
C-14	9.84E+01
CO-58	1.37E-04
I-131	1.14E-04
I-132	1.41E-05

H-3 1.61E+00

C-14 9.84E+01

CO-58 1.37E-04

I-131 1.14E-04

I-132 1.41E-05

Table 3.2-1 (cont.)

40CFR190 URANIUM FUEL CYCLE DOSE REPORT

GASEOUS DOSE SUMMARY

Units 1 & 2

Report for: 2017
 Unit Range - From: 1 To: 2

=== NG DOSE LIMIT ANALYSIS =====		ANNUAL 2017 =====		
Annual - Limit		Dose (mrad)	Limit (mrad)	Max % of Limit
2017 - Admin. Gamma		3.72E-05	7.50E+00	4.97E-04
2017 - Admin. Beta		1.93E-05	1.50E+01	1.29E-04
2017 - T.Spc. Gamma		3.72E-05	1.00E+01	3.72E-04
Receptor: Composite Crit. Receptor - NG				
Distance: 800 (meters) Compass Point: SSE				
Nuclide	Percentage			
-----	-----			
AR-41	5.05E+01			
KR-85	7.34E-01			
KR-85M	4.29E-03			
XE-135	2.06E+01			
XE-133M	4.92E-02			
XE-133	2.81E+01			
2017 - T.Spc. Beta		1.93E-05	2.00E+01	9.66E-05
Receptor: Composite Crit. Receptor - NG				
Distance: 800 (meters) Compass Point: SSE				
Nuclide	Percentage			
-----	-----			
AR-41	8.44E+00			
KR-85	3.94E+01			
KR-85M	3.25E-03			
XE-135	1.25E+01			
XE-133M	1.05E-01			
XE-133	3.96E+01			

Table 3.3-1

40CFR190 URANIUM FUEL CYCLE DOSE REPORT

Units 1 & 2

Report for: 2017
 Unit Range - From: 1 To: 2

=== MAXIMUM DOSE ANALYSIS ===== ANNUAL 2017 =====

Dose Type	Age Group	Organ	Dose (mrem)
Any Organ	CHILD	BONE	7.55E-01

Liquid Receptor: Liquid Receptor
 Gaseous Receptor: Composite Crit. Receptor - IP
 Distance: 800 (meters) Compass Point: SSE

Liquid Dose: 7.16E-02 % of Total: 9.48E+00
 Critical Pathway: Fresh Water Fish - Sport (FFSP)
 Major Contributors (0% or greater to total)

Nuclide	Percentage
H-3	0.00E+00
CR-51	0.00E+00
MN-54	0.00E+00
FE-55	5.20E-01
FE-59	5.50E-02
CO-58	0.00E+00
CO-60	0.00E+00
NI-63	9.35E+01
SR-89	5.94E-01
SR-90	5.33E+00
ZR-95	1.03E-06
ZR-97	3.77E-08
NB-95	1.81E-02
MO-99	0.00E+00
AG-110M	2.86E-05
SB-124	8.14E-05
SB-125	1.10E-03
TE-132	8.13E-03

Gaseous Dose: 6.84E-01 % of Total: 9.06E+01
 Critical Pathway: Vegetation (VEG)
 Major Contributors (0% or greater to total)

Nuclide	Percentage
H-3	0.00E+00
C-14	1.00E+02
CO-58	1.59E-05
I-131	4.01E-05
I-132	2.91E-06

Table 3.3-1 (cont.)

40CFR190 URANIUM FUEL CYCLE DOSE REPORT

Units 1 & 2

=== MAXIMUM DOSE ANALYSIS ===== ANNUAL 2017 =====

Dose Type	Age Group	Organ	Dose (mrem)
Total Body	CHILD	TBODY	2.56E-01

Liquid Receptor: Liquid Receptor
 Gaseous Receptor: Composite Crit. Receptor - IP
 Distance: 800 (meters) Compass Point: SSE

Liquid Dose: 1.17E-01 % of Total: 4.57E+01
 Critical Pathway: Fresh Water Fish - Sport (FFSP)
 Major Contributors (0% or greater to total)

Nuclide	Percentage
H-3	9.64E+01
CR-51	1.03E-03
MN-54	2.47E-02
FE-55	5.23E-02
FE-59	2.71E-02
CO-58	6.38E-01
CO-60	8.82E-01
NI-63	1.94E+00
SR-89	1.04E-02
SR-90	6.55E-02
ZR-95	1.23E-07
ZR-97	1.96E-09
NB-95	3.08E-03
MO-99	2.34E-05
AG-110M	9.43E-06
SB-124	1.74E-05
SB-125	1.41E-04
TE-132	2.66E-03

Gaseous Dose: 1.39E-01 % of Total: 5.43E+01
 Critical Pathway: Vegetation (VEG)
 Major Contributors (0% or greater to total)

Nuclide	Percentage
H-3	1.61E+00
C-14	9.84E+01
CO-58	1.37E-04
I-131	1.14E-04
I-132	1.41E-05

Table 3.4-1

The following are the maximum annual calculated cumulative offsite doses resulting from Byron airborne releases in 2017 based on concurrent meteorological data:

Unit 1:

<u>Dose</u>	<u>Maximum Value</u>	<u>Sector Affected</u>
gamma air ⁽¹⁾	4.36 x10 ⁻⁶ mrad	North-Northwest
beta air ⁽²⁾	6.02 x10 ⁻⁶ mrad	North-Northwest
whole body ⁽³⁾	7.33 x10 ⁻² mrem	North-Northwest
skin ⁽⁴⁾	6.35 x10 ⁻⁶ mrem	North-Northwest
organ ⁽⁵⁾ (child-bone)	3.63 x10 ⁻¹ mrem	North-Northwest

Unit 1 Compliance Status

10 CFR 50 Appendix I	Yearly Objective	% of Appendix I
gamma air	10.0 mrad	0.00
beta air	20.0 mrad	0.00
whole body	5.0 mrem	1.47
skin	15.0 mrem	0.00
organ	15.0 mrem	2.42

Unit 2:

<u>Dose</u>	<u>Maximum Value</u>	<u>Sector Affected</u>
gamma air ⁽¹⁾	3.18 x10 ⁻⁶ mrad	North-Northwest
beta air ⁽²⁾	1.01 x10 ⁻⁵ mrad	North-Northwest
whole body ⁽³⁾	7.55 x10 ⁻² mrem	North-Northwest
skin ⁽⁴⁾	8.37 x10 ⁻⁶ mrem	North-Northwest
organ ⁽⁵⁾ (child-bone)	3.67 x10 ⁻¹ mrem	North-Northwest

Unit 2 Compliance Status

10 CFR 50 Appendix I	Yearly Objective	% of Appendix I
gamma air	10.0 mrad	0.00
beta air	20.0 mrad	0.00
whole body	5.0 mrem	1.51
skin	15.0 mrem	0.00
organ	15.0 mrem	2.45

-
- (1) Gamma Air Dose - GASPAR II, NUREG-0597
 - (2) Beta Air Dose - GASPAR II, NUREG-0597
 - (3) Whole Body Dose - GASPAR II, NUREG-0597
 - (4) Skin Dose - GASPAR II, NUREG-0597
 - (5) Inhalation and Food Pathways Dose - GASPAR II, NUREG-0597

Data recovery: 99.9%

Intentionally left blank

APPENDIX F

METEOROLOGICAL DATA

Intentionally left blank

Byron Generating Station

Period of Record: January - March, 2017

Stability Class - Extremely Unstable - 250Ft - 30Ft Delta-T (F)
Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	3	5	1	0	0	10
NNE	1	6	1	5	0	0	13
NE	1	3	2	8	2	0	16
ENE	2	7	12	12	2	0	35
E	2	7	8	0	0	0	17
ESE	0	3	0	0	0	0	3
SE	0	4	0	0	0	0	4
SSE	1	1	6	0	0	0	8
S	0	0	3	1	1	0	5
SSW	0	0	6	1	0	0	7
SW	1	5	1	1	0	0	8
WSW	0	1	4	0	0	0	5
W	0	1	17	2	0	0	20
WNW	0	4	4	4	1	0	13
NW	0	3	13	1	0	0	17
NNW	0	2	6	0	0	0	8
Variable	0	0	0	0	0	0	0
Total	9	50	88	36	6	0	189

Hours of calm in this stability class: 0
Hours of missing wind measurements in this stability class: 0
Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Moderately Unstable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	1	0	0	1
NE	0	0	0	4	0	0	4
ENE	0	1	2	1	0	0	4
E	0	1	1	0	0	0	2
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	1	0	0	0	1
S	0	1	1	0	1	0	3
SSW	0	0	0	0	0	0	0
SW	0	1	0	1	0	0	2
WSW	0	0	0	0	0	0	0
W	0	0	4	0	1	0	5
WNW	0	0	0	2	0	0	2
NW	0	0	0	0	0	0	0
NNW	0	0	0	1	0	0	1
Variable	0	0	0	0	0	0	0
Total	0	4	9	10	2	0	25

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Slightly Unstable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	2	1	0	3
ENE	0	0	0	0	0	0	0
E	0	1	2	0	0	0	3
ESE	0	0	1	0	0	0	1
SE	0	1	0	0	0	0	1
SSE	0	0	2	1	0	0	3
S	0	2	0	2	1	0	5
SSW	0	0	0	0	0	0	0
SW	0	1	0	1	0	0	2
WSW	0	0	0	0	0	0	0
W	0	2	2	1	1	0	6
WNW	0	0	2	2	0	0	4
NW	0	3	2	3	0	0	8
NNW	0	1	1	1	0	0	3
Variable	0	0	0	0	0	0	0
Total	0	11	12	13	3	0	39

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Neutral - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	3	22	49	23	0	0	97
NNE	1	13	20	5	0	0	39
NE	1	13	14	12	2	0	42
ENE	0	18	20	12	2	0	52
E	3	42	16	1	0	0	62
ESE	1	13	25	7	5	0	51
SE	1	8	20	8	2	0	39
SSE	0	3	26	35	1	0	65
S	0	6	31	42	8	0	87
SSW	1	13	18	18	1	1	52
SW	1	8	13	8	0	0	30
WSW	2	7	7	7	9	2	34
W	2	14	23	27	3	13	82
WNW	3	11	66	88	11	0	179
NW	4	16	87	88	11	3	209
NNW	2	20	44	20	0	0	86
Variable	0	0	0	0	0	0	0
Total	25	227	479	401	55	19	1206

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Slightly Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	8	14	2	0	0	0	24
NNE	2	8	7	0	0	0	17
NE	2	8	4	1	0	0	15
ENE	2	4	3	1	0	0	10
E	3	20	2	0	0	0	25
ESE	2	12	8	7	4	0	33
SE	2	7	19	12	0	0	40
SSE	2	13	12	18	1	0	46
S	0	10	6	14	4	1	35
SSW	1	7	6	11	0	0	25
SW	7	10	17	5	0	0	39
WSW	5	9	15	7	3	2	41
W	6	15	13	12	3	1	50
WNW	8	24	14	10	1	0	57
NW	4	27	10	5	1	0	47
NNW	6	13	9	1	0	0	29
Variable	0	0	0	0	0	0	0
Total	60	201	147	104	17	4	533

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Moderately Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	0	0	0	0	0	2
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	2	0	0	0	2
E	2	10	1	0	0	0	13
ESE	0	2	3	0	0	0	5
SE	0	13	8	0	0	0	21
SSE	0	5	4	0	0	0	9
S	2	10	1	1	0	0	14
SSW	4	7	2	0	0	0	13
SW	5	9	0	1	0	0	15
WSW	0	2	1	0	0	0	3
W	4	7	0	0	0	0	11
WNW	8	4	0	0	0	0	12
NW	5	6	0	0	0	0	11
NNW	2	2	0	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	34	77	22	2	0	0	135

Hours of calm in this stability class: 1
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Extremely Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	2	1	0	0	0	0	3
ESE	0	3	1	0	0	0	4
SE	1	1	4	0	0	0	6
SSE	3	1	0	0	0	0	4
S	0	2	0	0	0	0	2
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	1	0	0	0	0	0	1
W	2	0	0	0	0	0	2
WNW	1	0	0	0	0	0	1
NW	0	1	0	0	0	0	1
NNW	3	1	0	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	13	10	5	0	0	0	28

Hours of calm in this stability class: 1
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Extremely Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	3	5	1	1	0	10
NNE	0	5	2	3	5	0	15
NE	0	3	0	2	7	1	13
ENE	0	2	2	7	10	4	25
E	0	2	17	7	1	0	27
ESE	0	2	1	0	0	0	3
SE	0	2	4	0	0	0	6
SSE	0	1	1	2	1	0	5
S	0	1	1	3	0	2	7
SSW	0	0	0	6	0	1	7
SW	0	0	3	2	0	1	6
WSW	0	1	2	4	0	0	7
W	0	1	3	18	0	0	22
WNW	0	2	2	7	0	1	12
NW	0	1	8	6	0	0	15
NNW	1	1	4	3	0	0	9
Variable	0	0	0	0	0	0	0
Total	1	27	55	71	25	10	189

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Moderately Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	1	3	1	5
ENE	0	0	1	1	1	0	3
E	0	0	1	1	0	0	2
ESE	0	0	0	1	0	0	1
SE	0	0	0	0	0	0	0
SSE	0	0	0	1	0	0	1
S	0	0	0	0	0	1	1
SSW	0	0	0	2	0	0	2
SW	0	0	0	1	1	0	2
WSW	0	0	0	0	0	0	0
W	0	0	2	1	1	1	5
WNW	0	0	1	0	1	0	2
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	1	0	1
Variable	0	0	0	0	0	0	0
Total	0	0	5	9	8	3	25

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Slightly Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	1	0	0	0	1
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	2	1	3
ENE	0	0	0	0	0	0	0
E	0	0	1	1	1	0	3
ESE	0	0	1	0	0	0	1
SE	0	0	0	0	0	0	0
SSE	0	0	1	2	1	0	4
S	0	1	0	0	2	1	4
SSW	0	0	0	1	0	0	1
SW	0	1	0	0	0	1	2
WSW	0	0	0	0	0	0	0
W	0	0	2	2	2	0	6
WNW	0	0	0	3	1	0	4
NW	0	0	4	4	0	0	8
NNW	0	0	0	2	0	0	2
Variable	0	0	0	0	0	0	0
Total	0	2	10	15	9	3	39

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Neutral - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	12	31	46	4	0	94
NNE	0	5	18	18	6	0	47
NE	0	10	12	11	2	1	36
ENE	0	6	11	10	16	5	48
E	2	8	39	21	2	0	72
ESE	1	5	7	22	10	4	49
SE	1	2	9	19	12	1	44
SSE	1	3	11	23	26	5	69
S	0	4	23	14	32	12	85
SSW	1	5	18	13	9	3	49
SW	3	5	12	10	6	1	37
WSW	0	3	6	6	7	11	33
W	1	6	15	29	17	17	85
WNW	2	3	22	100	50	6	183
NW	2	5	42	112	27	9	197
NNW	2	7	32	34	3	0	78
Variable	0	0	0	0	0	0	0
Total	17	89	308	488	229	75	1206

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Slightly Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	4	12	5	0	0	21
NNE	1	1	9	7	1	0	19
NE	0	6	13	2	0	0	21
ENE	0	3	8	2	1	0	14
E	0	3	8	5	0	0	16
ESE	0	2	6	6	8	10	32
SE	0	2	3	10	18	1	34
SSE	1	5	7	13	17	8	51
S	0	3	2	8	18	7	38
SSW	0	1	3	12	9	4	29
SW	0	2	1	12	12	5	32
WSW	0	1	10	13	6	8	38
W	0	1	13	19	12	6	51
WNW	0	3	18	19	7	3	50
NW	2	2	31	17	6	0	58
NNW	1	1	14	12	1	0	29
Variable	0	0	0	0	0	0	0
Total	5	40	158	162	116	52	533

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Moderately Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	2	1	0	0	4
NNE	0	0	2	0	0	0	2
NE	0	0	1	0	0	0	1
ENE	0	0	0	0	0	0	0
E	0	1	3	4	3	0	11
ESE	0	1	2	1	2	0	6
SE	0	3	1	1	5	0	10
SSE	0	3	3	4	6	0	16
S	0	2	1	3	1	0	7
SSW	1	1	3	7	2	1	15
SW	0	2	0	7	1	0	10
WSW	0	0	2	7	0	0	9
W	1	2	7	0	0	0	10
WNW	0	3	7	3	0	0	13
NW	0	3	7	2	0	0	12
NNW	0	1	5	4	0	0	10
Variable	0	0	0	0	0	0	0
Total	2	23	46	44	20	1	136

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: January - March, 2017
 Stability Class - Extremely Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	1	0	0	1
NNE	0	0	1	1	0	0	2
NE	0	0	0	0	0	0	0
ENE	0	1	0	0	0	0	1
E	0	1	0	0	0	0	1
ESE	0	3	0	0	0	0	3
SE	1	0	2	1	1	0	5
SSE	0	0	0	2	2	0	4
S	0	2	1	0	0	0	3
SSW	0	0	1	1	0	0	2
SW	0	0	0	1	0	0	1
WSW	0	0	1	0	0	0	1
W	0	0	0	0	0	0	0
WNW	0	0	1	0	0	0	1
NW	0	1	0	0	0	0	1
NNW	0	0	2	1	0	0	3
Variable	0	0	0	0	0	0	0
Total	1	8	9	8	3	0	29

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June, 2017

Stability Class - Extremely Unstable - 250Ft - 30Ft Delta-T (F)
Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017
 Stability Class - Moderately Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	1	0	0	0	1
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	1	0	0	0	1
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	0	2	0	0	0	2

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017

Stability Class - Slightly Unstable - 250Ft - 30Ft Delta-T (F)
Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	4	0	0	4
NE	0	0	2	0	0	0	2
ENE	0	0	2	0	0	0	2
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	3	0	0	3
S	0	0	2	0	1	0	3
SSW	0	1	2	5	1	0	9
SW	0	0	3	1	0	0	4
WSW	0	0	0	0	0	0	0
W	0	0	2	0	0	0	2
WNW	0	0	2	7	0	0	9
NW	0	0	0	1	0	0	1
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	1	15	21	2	0	39

Hours of calm in this stability class: 0
Hours of missing wind measurements in this stability class: 0
Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017
 Stability Class - Neutral - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	15	46	21	1	0	83
NNE	3	8	30	18	0	0	59
NE	0	11	25	36	5	1	78
ENE	2	8	26	21	0	0	57
E	4	18	30	1	0	0	53
ESE	0	14	19	7	0	0	40
SE	0	8	13	6	0	0	27
SSE	2	14	19	12	1	0	48
S	1	1	18	29	12	0	61
SSW	0	14	27	26	5	0	72
SW	0	24	29	18	0	0	71
WSW	2	18	32	30	2	0	84
W	2	22	32	51	6	0	113
WNW	5	19	41	59	9	0	133
NW	1	13	16	21	1	0	52
NNW	0	15	28	11	2	0	56
Variable	0	0	0	0	0	0	0
Total	22	222	431	367	44	1	1087

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017
 Stability Class - Slightly Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	9	11	6	0	0	28
NNE	1	14	8	2	0	0	25
NE	8	13	15	1	0	0	37
ENE	3	15	21	1	0	0	40
E	9	51	25	0	0	0	85
ESE	5	21	15	6	0	0	47
SE	3	8	19	1	0	0	31
SSE	2	10	26	15	0	0	53
S	7	14	17	20	1	0	59
SSW	4	20	52	27	1	0	104
SW	3	20	9	5	0	0	37
WSW	5	18	15	2	0	0	40
W	14	29	10	0	0	0	53
WNW	5	19	10	1	0	0	35
NW	5	7	7	3	0	0	22
NNW	5	9	11	2	0	0	27
Variable	0	0	0	0	0	0	0
Total	81	277	271	92	2	0	723

Hours of calm in this stability class: 1
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017
 Stability Class - Moderately Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	5	1	0	0	0	8
NNE	2	3	0	0	0	0	5
NE	1	1	0	0	0	0	2
ENE	2	2	1	0	0	0	5
E	6	4	0	0	0	0	10
ESE	5	20	4	2	0	0	31
SE	3	15	9	1	0	0	28
SSE	2	22	7	0	0	0	31
S	6	13	5	0	0	0	24
SSW	5	6	0	0	0	0	11
SW	10	8	0	0	0	0	18
WSW	10	2	1	0	0	0	13
W	16	4	2	0	0	0	22
WNW	10	3	0	0	0	0	13
NW	4	3	0	0	0	0	7
NNW	3	6	0	0	0	0	9
Variable	0	0	0	0	0	0	0
Total	87	117	30	3	0	0	237

Hours of calm in this stability class: 6
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017
 Stability Class - Extremely Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	2	0	0	0	0	2
ESE	0	6	1	0	0	0	7
SE	2	2	0	0	0	0	4
SSE	4	1	2	0	0	0	7
S	5	6	1	0	0	0	12
SSW	7	2	0	0	0	0	9
SW	9	0	0	0	0	0	9
WSW	5	0	0	0	0	0	5
W	8	0	0	0	0	0	8
WNW	3	0	0	0	0	0	3
NW	8	0	0	0	0	0	8
NNW	2	1	0	0	0	0	3
Variable	0	0	0	0	0	0	0
Total	53	20	4	0	0	0	77

Hours of calm in this stability class: 7
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017

Stability Class - Extremely Unstable - 250Ft - 30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0

Hours of calm in this stability class: 0
Hours of missing wind measurements in this stability class: 0
Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017
 Stability Class - Moderately Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	1	0	0	1
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	1	0	0	1
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	0	0	2	0	0	2

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017
 Stability Class - Slightly Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	1	0	0	1
NE	0	0	1	2	2	0	5
ENE	0	0	2	0	0	0	2
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	3	1	1	5
S	0	0	1	0	0	0	1
SSW	0	0	0	5	2	1	8
SW	0	1	0	3	1	0	5
WSW	0	0	0	0	0	0	0
W	0	0	0	2	0	0	2
WNW	0	0	0	5	5	0	10
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	1	4	21	11	2	39

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017
 Stability Class - Neutral - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	8	23	44	8	0	83
NNE	0	3	14	21	10	6	54
NE	1	4	21	27	24	10	87
ENE	1	4	12	20	15	2	54
E	2	11	20	22	7	0	62
ESE	0	10	8	13	6	1	38
SE	1	3	19	9	2	0	34
SSE	1	5	16	14	4	3	43
S	0	3	3	18	22	16	62
SSW	0	8	8	23	19	7	65
SW	0	12	21	25	14	5	77
WSW	0	13	20	22	26	2	83
W	1	12	21	28	44	7	113
WNW	4	8	27	52	34	8	133
NW	2	6	8	18	11	0	45
NNW	1	8	20	14	11	0	54
Variable	0	0	0	0	0	0	0
Total	14	118	261	370	257	67	1087

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017
 Stability Class - Slightly Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	4	10	7	0	23
NNE	0	3	4	12	1	0	20
NE	0	6	15	15	3	0	39
ENE	3	5	15	17	2	0	42
E	4	10	34	40	6	1	95
ESE	1	5	9	15	10	1	41
SE	3	4	10	9	6	0	32
SSE	1	0	4	11	23	3	42
S	1	3	5	17	23	11	60
SSW	0	3	7	34	52	3	99
SW	1	4	13	12	10	4	44
WSW	0	2	13	16	4	0	35
W	0	5	18	28	0	0	51
WNW	2	5	18	24	1	0	50
NW	0	8	10	7	2	0	27
NNW	0	4	4	14	2	0	24
Variable	0	0	0	0	0	0	0
Total	16	69	183	281	152	23	724

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017

Stability Class - Moderately Stable - 250Ft - 30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	2	1	0	0	4
NNE	1	1	0	1	0	0	3
NE	0	3	2	3	0	0	8
ENE	0	3	4	0	0	0	7
E	1	5	3	3	0	0	12
ESE	0	1	7	6	2	2	18
SE	2	2	8	10	5	1	28
SSE	0	0	5	11	5	1	22
S	0	2	5	13	7	0	27
SSW	0	4	5	16	2	0	27
SW	0	1	5	5	1	0	12
WSW	1	0	1	6	0	0	8
W	0	3	8	14	3	0	28
WNW	0	6	14	2	0	0	22
NW	0	0	6	0	0	0	6
NNW	0	0	3	7	0	0	10
Variable	0	0	0	0	0	0	0
Total	5	32	78	98	25	4	242

Hours of calm in this stability class: 1
Hours of missing wind measurements in this stability class: 0
Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: April - June, 2017
 Stability Class - Extremely Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	0	3	0	0	0	4
NNE	0	1	1	0	0	0	2
NE	0	1	0	0	0	0	1
ENE	1	0	0	0	0	0	1
E	2	0	0	0	0	0	2
ESE	0	0	1	0	0	0	1
SE	0	0	1	6	1	0	8
SSE	0	1	2	2	1	0	6
S	0	0	0	5	0	0	5
SSW	0	2	2	7	1	0	12
SW	0	1	1	6	0	0	8
WSW	0	2	4	2	0	0	8
W	0	1	5	1	0	0	7
WNW	1	1	0	1	0	0	3
NW	2	4	0	0	0	0	6
NNW	0	2	8	0	0	0	10
Variable	0	0	0	0	0	0	0
Total	7	16	28	30	3	0	84

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 5

Byron Generating Station

Period of Record: July - September, 2017
 Stability Class - Extremely Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	1	0	0	0	1
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	3	0	0	0	0	3
ESE	0	2	4	0	0	0	6
SE	0	0	1	0	0	0	1
SSE	0	0	2	0	0	0	2
S	0	0	7	2	0	0	9
SSW	0	1	3	0	0	0	4
SW	0	0	2	0	0	0	2
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	1	0	0	0	0	1
NW	0	0	1	0	0	0	1
NNW	0	0	1	0	0	0	1
Variable	0	0	0	0	0	0	0
Total	0	7	22	2	0	0	31

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017
 Stability Class - Moderately Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	3	0	0	0	3
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	3	0	0	0	0	3
E	0	3	4	0	0	0	7
ESE	0	1	3	0	0	0	4
SE	0	2	1	0	0	0	3
SSE	0	0	0	0	0	0	0
S	0	1	5	1	0	0	7
SSW	0	2	6	0	0	0	8
SW	0	1	0	0	0	0	1
WSW	0	0	0	0	0	0	0
W	0	2	0	0	0	0	2
WNW	0	1	2	1	0	0	4
NW	0	0	5	0	0	0	5
NNW	0	0	2	0	0	0	2
Variable	0	0	0	0	0	0	0
Total	0	16	31	2	0	0	49

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017
 Stability Class - Slightly Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	2	0	0	0	2
NNE	0	1	1	0	0	0	2
NE	0	1	0	0	0	0	1
ENE	0	3	0	0	0	0	3
E	0	3	2	0	0	0	5
ESE	0	5	2	0	0	0	7
SE	0	3	2	0	0	0	5
SSE	0	0	1	0	0	0	1
S	0	2	3	0	0	0	5
SSW	0	3	0	0	0	0	3
SW	0	3	1	0	0	0	4
WSW	0	2	0	0	0	0	2
W	0	1	1	0	0	0	2
WNW	0	1	2	0	0	0	3
NW	0	0	4	1	0	0	5
NNW	0	0	3	0	0	0	3
Variable	0	0	0	0	0	0	0
Total	0	28	24	1	0	0	53

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017
 Stability Class - Neutral - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	17	22	1	0	0	40
NNE	2	23	28	0	0	0	53
NE	3	14	11	0	0	0	28
ENE	2	27	5	0	0	0	34
E	11	43	1	0	0	0	55
ESE	3	13	6	0	0	0	22
SE	8	17	11	0	0	0	36
SSE	5	33	22	0	0	0	60
S	6	29	31	2	0	0	68
SSW	6	24	20	1	0	0	51
SW	6	21	20	0	0	0	47
WSW	3	36	9	9	0	0	57
W	8	33	22	7	0	0	70
WNW	9	27	33	2	0	0	71
NW	7	25	30	15	0	0	77
NNW	5	20	33	2	0	0	60
Variable	0	0	0	0	0	0	0
Total	84	402	304	39	0	0	829

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017
 Stability Class - Slightly Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	10	3	2	0	0	17
NNE	7	8	4	1	0	0	20
NE	6	14	8	0	0	0	28
ENE	3	21	7	0	0	0	31
E	4	56	3	0	0	0	63
ESE	4	17	7	0	0	0	28
SE	8	17	12	0	0	0	37
SSE	7	36	9	0	0	0	52
S	6	22	6	1	0	0	35
SSW	8	13	11	3	0	0	35
SW	7	19	5	0	0	0	31
WSW	16	19	8	0	0	0	43
W	19	26	4	0	0	0	49
WNW	16	16	7	1	0	0	40
NW	5	25	6	1	0	0	37
NNW	7	30	5	0	0	0	42
Variable	0	0	0	0	0	0	0
Total	125	349	105	9	0	0	588

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017
 Stability Class - Moderately Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	4	7	1	0	0	0	12
NNE	7	8	1	0	0	0	16
NE	8	4	0	0	0	0	12
ENE	3	12	1	0	0	0	16
E	11	31	0	0	0	0	42
ESE	7	25	1	0	0	0	33
SE	4	27	3	0	0	0	34
SSE	7	43	17	0	0	0	67
S	3	17	3	0	0	0	23
SSW	11	10	0	0	0	0	21
SW	12	1	0	0	0	0	13
WSW	16	2	0	0	0	0	18
W	19	14	0	0	0	0	33
WNW	14	6	0	0	0	0	20
NW	13	2	0	0	0	0	15
NNW	8	8	0	0	0	0	16
Variable	0	0	0	0	0	0	0
Total	147	217	27	0	0	0	391

Hours of calm in this stability class: 8
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017
 Stability Class - Extremely Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	3	0	0	0	0	0	3
NNE	2	0	0	0	0	0	2
NE	2	0	0	0	0	0	2
ENE	1	1	0	0	0	0	2
E	7	8	0	0	0	0	15
ESE	8	25	0	0	0	0	33
SE	2	31	0	0	0	0	33
SSE	2	26	0	0	0	0	28
S	14	7	1	0	0	0	22
SSW	8	2	0	0	0	0	10
SW	7	0	0	0	0	0	7
WSW	12	1	0	0	0	0	13
W	13	2	0	0	0	0	15
WNW	17	0	0	0	0	0	17
NW	20	3	0	0	0	0	23
NNW	4	1	0	0	0	0	5
Variable	0	0	0	0	0	0	0
Total	122	107	1	0	0	0	230

Hours of calm in this stability class: 26
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017
 Stability Class - Extremely Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	1	0	0	1
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	2	1	0	0	0	3
ESE	0	0	4	2	0	0	6
SE	0	0	1	0	0	0	1
SSE	0	0	0	1	0	0	1
S	0	0	1	7	2	0	10
SSW	0	0	1	3	0	0	4
SW	0	0	0	2	0	0	2
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	1	0	0	0	1
NW	0	0	1	0	0	0	1
NNW	0	0	1	0	0	0	1
Variable	0	0	0	0	0	0	0
Total	0	2	11	16	2	0	31

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017

Stability Class - Moderately Unstable - 250Ft - 30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	3	0	0	0	3
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	1	1	0	0	0	2
E	0	3	3	2	0	0	8
ESE	0	1	2	1	0	0	4
SE	0	0	3	0	0	0	3
SSE	0	0	0	1	0	0	1
S	0	0	3	2	1	0	6
SSW	0	0	7	1	0	0	8
SW	0	1	0	0	0	0	1
WSW	0	0	0	0	0	0	0
W	0	0	2	0	0	0	2
WNW	0	1	1	2	1	0	5
NW	0	0	1	3	0	0	4
NNW	0	0	1	1	0	0	2
Variable	0	0	0	0	0	0	0
Total	0	7	27	13	2	0	49

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017
 Stability Class - Slightly Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	2	0	0	0	2
NNE	0	0	1	0	0	0	1
NE	0	2	0	0	0	0	2
ENE	0	1	1	0	0	0	2
E	0	4	3	0	0	0	7
ESE	0	1	5	1	0	0	7
SE	0	0	4	0	0	0	4
SSE	0	0	1	0	0	0	1
S	0	2	2	1	0	0	5
SSW	0	0	3	0	0	0	3
SW	0	3	2	0	0	0	5
WSW	0	0	1	0	0	0	1
W	0	0	1	2	0	0	3
WNW	0	0	1	2	0	0	3
NW	0	0	1	2	1	0	4
NNW	0	0	1	2	0	0	3
Variable	0	0	0	0	0	0	0
Total	0	13	29	10	1	0	53

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017
 Stability Class - Neutral - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	11	13	5	0	0	31
NNE	2	10	31	17	0	0	60
NE	1	8	10	10	0	0	29
ENE	6	12	16	6	0	0	40
E	2	25	24	3	0	0	54
ESE	3	11	11	3	0	0	28
SE	3	12	15	6	2	0	38
SSE	2	16	23	15	1	0	57
S	0	13	32	15	2	1	63
SSW	3	9	22	16	1	1	52
SW	2	19	24	10	3	0	58
WSW	0	14	23	7	9	0	53
W	2	16	23	13	4	2	60
WNW	2	27	19	27	1	0	76
NW	2	13	28	26	12	0	81
NNW	3	7	27	12	0	0	49
Variable	0	0	0	0	0	0	0
Total	35	223	341	191	35	4	829

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017

Stability Class - Slightly Stable - 250Ft - 30Ft Delta-T (F)

Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	5	5	5	1	0	16
NNE	0	3	6	8	3	0	20
NE	1	8	7	7	0	0	23
ENE	2	11	10	19	1	0	43
E	1	12	35	19	0	0	67
ESE	1	1	9	6	4	0	21
SE	0	8	6	9	7	0	30
SSE	2	11	10	19	5	0	47
S	0	7	13	11	7	0	38
SSW	0	2	10	16	8	2	38
SW	1	2	19	18	2	0	42
WSW	0	7	17	15	0	0	39
W	1	3	32	6	1	0	43
WNW	0	5	18	14	2	0	39
NW	0	3	21	14	0	0	38
NNW	2	3	17	21	1	0	44
Variable	0	0	0	0	0	0	0
Total	11	91	235	207	42	2	588

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017
 Stability Class - Moderately Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	3	6	6	0	0	15
NNE	3	2	5	6	1	0	17
NE	0	3	9	5	1	0	18
ENE	3	9	10	4	4	0	30
E	1	4	9	12	5	0	31
ESE	0	3	4	8	10	0	25
SE	0	3	12	10	4	0	29
SSE	0	4	6	14	14	0	38
S	1	2	4	25	15	0	47
SSW	0	5	5	16	5	0	31
SW	0	1	5	10	0	0	16
WSW	0	1	8	4	0	0	13
W	0	0	17	8	0	0	25
WNW	1	3	16	9	0	0	29
NW	1	5	14	3	0	0	23
NNW	0	4	6	2	0	0	12
Variable	0	0	0	0	0	0	0
Total	10	52	136	142	59	0	399

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September, 2017
 Stability Class - Extremely Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	4	5	1	0	0	11
NNE	5	2	2	1	0	0	10
NE	2	1	3	2	0	0	8
ENE	2	4	5	1	0	0	12
E	2	6	11	1	0	0	20
ESE	3	3	2	1	5	1	15
SE	1	4	3	16	8	0	32
SSE	0	4	5	21	11	0	41
S	1	4	6	12	5	0	28
SSW	0	4	5	5	0	0	14
SW	1	2	6	2	0	0	11
WSW	1	3	7	1	0	0	12
W	1	1	8	0	0	0	10
WNW	0	2	3	8	0	0	13
NW	0	3	4	0	0	0	7
NNW	0	2	9	1	0	0	12
Variable	0	0	0	0	0	0	0
Total	20	49	84	73	29	1	256

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Extremely Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	1	0	0	0	0	2
NNE	1	0	0	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	1	0	0	0	0	1
ESE	0	2	0	0	0	0	2
SE	1	2	0	0	0	0	3
SSE	1	1	1	1	0	0	4
S	1	0	1	0	0	0	2
SSW	1	0	0	0	0	0	1
SW	1	0	1	0	0	0	2
WSW	0	1	0	0	0	0	1
W	2	0	2	0	0	0	4
WNW	2	2	1	0	0	0	5
NW	1	3	2	1	0	0	7
NNW	1	0	0	0	0	0	1
Variable	0	0	0	0	0	0	0
Total	13	13	8	2	0	0	36

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Moderately Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	1	0	0	0	2
NNE	0	1	0	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	0	1	0	0	0	0	1
E	0	2	0	0	0	0	2
ESE	0	2	0	0	0	0	2
SE	0	0	0	0	0	0	0
SSE	1	0	0	0	0	0	1
S	0	0	3	4	0	0	7
SSW	0	1	1	2	0	0	4
SW	0	1	3	0	0	0	4
WSW	1	0	1	0	0	0	2
W	1	2	3	0	0	0	6
WNW	0	0	2	0	0	0	2
NW	0	1	0	0	0	0	1
NNW	1	2	1	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	4	14	15	6	0	0	39

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Slightly Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	0	0	0	0	0	1
NNE	0	1	0	0	0	0	1
NE	0	0	1	0	0	0	1
ENE	0	1	0	1	0	0	2
E	0	3	1	0	0	0	4
ESE	0	1	0	0	0	0	1
SE	1	0	1	0	0	0	2
SSE	0	1	2	2	0	0	5
S	0	0	2	1	0	0	3
SSW	0	4	5	2	0	0	11
SW	2	2	3	1	0	0	8
WSW	0	0	2	0	0	0	2
W	0	1	1	0	0	0	2
WNW	0	2	0	2	0	0	4
NW	0	2	0	0	0	0	2
NNW	0	1	2	1	0	0	4
Variable	0	0	0	0	0	0	0
Total	4	19	20	10	0	0	53

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Neutral - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	10	41	7	0	0	59
NNE	1	12	33	1	0	0	47
NE	5	6	8	6	0	0	25
ENE	6	22	13	2	0	0	43
E	4	24	1	0	0	0	29
ESE	1	12	13	0	0	0	26
SE	2	11	23	8	0	0	44
SSE	3	20	59	16	1	0	99
S	0	7	25	22	5	0	59
SSW	2	12	15	16	3	0	48
SW	3	20	28	4	0	0	55
WSW	1	22	37	21	3	0	84
W	8	17	35	35	7	6	108
WNW	5	21	54	69	8	0	157
NW	7	31	56	60	13	0	167
NNW	2	12	28	24	4	0	70
Variable	0	0	0	0	0	0	0
Total	51	259	469	291	44	6	1120

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Slightly Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	3	13	10	0	0	0	26
NNE	1	3	9	0	0	0	13
NE	1	3	5	1	0	0	10
ENE	1	1	8	1	0	0	11
E	6	18	2	0	0	0	26
ESE	4	5	8	0	0	0	17
SE	4	14	12	1	0	0	31
SSE	1	20	49	30	0	0	100
S	10	25	41	16	3	0	95
SSW	4	20	35	20	5	0	84
SW	8	31	25	5	0	0	69
WSW	5	13	18	5	1	3	45
W	9	23	23	4	1	2	62
WNW	9	19	26	7	0	0	61
NW	5	24	25	5	0	0	59
NNW	4	24	11	0	0	0	39
Variable	0	0	0	0	0	0	0
Total	75	256	307	95	10	5	748

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Moderately Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	0	0	0	0	1
NNE	1	0	0	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	1	0	0	0	0	0	1
E	2	1	0	0	0	0	3
ESE	1	6	5	0	0	0	12
SE	0	17	5	0	0	0	22
SSE	0	9	9	0	0	0	18
S	3	20	6	0	0	0	29
SSW	3	8	2	0	0	0	13
SW	6	0	0	0	0	0	6
WSW	4	0	0	0	0	0	4
W	6	2	0	0	0	0	8
WNW	4	2	0	0	0	0	6
NW	5	0	0	0	0	0	5
NNW	1	4	1	0	0	0	6
Variable	0	0	0	0	0	0	0
Total	37	70	28	0	0	0	135

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Extremely Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	0	0	0	0	0	1
NNE	0	1	0	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	1	0	0	0	0	0	1
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	3	8	0	0	0	0	11
SSE	2	8	0	0	0	0	10
S	6	13	1	0	0	0	20
SSW	3	1	0	0	0	0	4
SW	6	0	0	0	0	0	6
WSW	1	0	0	0	0	0	1
W	3	0	0	0	0	0	3
WNW	6	0	0	0	0	0	6
NW	7	0	0	0	0	0	7
NNW	4	1	0	0	0	0	5
Variable	0	0	0	0	0	0	0
Total	43	32	1	0	0	0	76

Hours of calm in this stability class: 1
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Extremely Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	0	0	0	0	1
NNE	0	0	0	0	0	0	0
NE	1	0	0	0	0	0	1
ENE	0	0	0	0	0	0	0
E	0	0	1	0	0	0	1
ESE	0	0	2	0	0	0	2
SE	0	2	1	0	0	0	3
SSE	0	2	0	2	0	0	4
S	0	0	0	1	0	0	1
SSW	1	1	0	0	0	0	2
SW	2	0	1	0	0	0	3
WSW	0	1	0	0	0	0	1
W	0	1	3	0	0	0	4
WNW	3	1	0	0	0	0	4
NW	0	3	2	0	1	0	6
NNW	0	2	1	0	0	0	3
Variable	0	0	0	0	0	0	0
Total	7	14	11	3	1	0	36

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Moderately Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	0	0	0	0	1
NNE	0	0	1	1	0	0	2
NE	0	0	0	0	0	0	0
ENE	0	0	1	0	0	0	1
E	0	1	0	1	0	0	2
ESE	0	0	1	1	0	0	2
SE	0	0	0	0	0	0	0
SSE	0	1	0	0	1	0	2
S	0	0	0	3	3	0	6
SSW	0	0	1	1	2	0	4
SW	1	0	1	0	3	0	5
WSW	0	1	1	0	0	0	2
W	0	1	5	0	0	0	6
WNW	0	0	2	0	0	0	2
NW	0	0	0	0	0	0	0
NNW	0	2	2	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	1	7	15	7	9	0	39

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Slightly Unstable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	0	0	0	0	0	1
NNE	0	0	1	0	0	0	1
NE	0	0	1	0	0	0	1
ENE	0	1	0	0	1	0	2
E	0	0	1	3	0	0	4
ESE	0	1	0	0	0	0	1
SE	0	1	0	1	1	0	3
SSE	0	0	0	3	1	0	4
S	0	0	2	1	1	0	4
SSW	0	0	6	2	2	0	10
SW	0	4	0	3	1	0	8
WSW	0	0	1	1	0	0	2
W	0	0	3	0	0	0	3
WNW	0	1	0	0	1	1	3
NW	0	1	1	1	0	0	3
NNW	0	0	2	0	1	0	3
Variable	0	0	0	0	0	0	0
Total	1	9	18	15	9	1	53

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Neutral - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	6	15	14	8	0	44
NNE	0	11	14	38	3	0	66
NE	0	1	8	6	6	0	21
ENE	0	9	13	15	3	0	40
E	3	9	20	1	0	0	33
ESE	1	4	14	10	1	0	30
SE	1	5	14	12	13	2	47
SSE	0	5	23	47	18	3	96
S	0	5	12	14	16	6	53
SSW	1	4	12	13	15	8	53
SW	0	8	20	22	8	0	58
WSW	3	11	19	41	11	6	91
W	1	11	11	33	27	16	99
WNW	4	5	20	78	33	13	153
NW	2	12	28	66	33	9	150
NNW	2	15	16	26	24	3	86
Variable	0	0	0	0	0	0	0
Total	19	121	259	436	219	66	1120

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Slightly Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	13	8	0	0	23
NNE	0	3	3	18	0	0	24
NE	1	2	1	5	0	0	9
ENE	1	1	2	10	1	0	15
E	1	2	9	7	1	0	20
ESE	0	0	4	7	4	0	15
SE	1	1	1	8	6	1	18
SSE	0	6	10	24	46	11	97
S	0	6	12	22	24	17	81
SSW	1	1	15	26	29	18	90
SW	1	4	18	35	23	4	85
WSW	2	1	16	23	6	5	53
W	0	3	10	22	8	3	46
WNW	0	5	19	40	7	0	71
NW	0	3	20	32	7	0	62
NNW	0	4	17	15	3	0	39
Variable	0	0	0	0	0	0	0
Total	8	44	170	302	165	59	748

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Moderately Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	0	4	3	1	0	9
NNE	0	0	0	1	0	0	1
NE	0	0	1	0	0	0	1
ENE	0	0	0	0	0	0	0
E	0	1	1	0	0	0	2
ESE	0	1	0	0	3	0	4
SE	0	2	2	1	8	1	14
SSE	0	2	4	6	8	1	21
S	0	0	1	6	6	0	13
SSW	0	0	1	11	9	0	21
SW	0	0	2	9	4	0	15
WSW	0	0	7	1	0	0	8
W	0	0	4	2	0	0	6
WNW	0	1	4	5	0	0	10
NW	1	0	3	0	0	0	4
NNW	0	3	3	0	0	0	6
Variable	0	0	0	0	0	0	0
Total	2	10	37	45	39	2	135

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December, 2017
 Stability Class - Extremely Stable - 250Ft - 30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	1	1	0	0	3
NNE	1	0	3	2	0	0	6
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	1	0	0	0	0	0	1
ESE	0	1	0	0	0	0	1
SE	0	1	1	0	3	0	5
SSE	0	1	1	2	0	0	4
S	0	0	0	2	3	0	5
SSW	1	1	3	3	5	0	13
SW	0	1	6	2	1	0	10
WSW	0	2	4	0	0	0	6
W	0	3	0	0	0	0	3
WNW	0	1	0	0	0	0	1
NW	0	2	10	1	0	0	13
NNW	0	2	2	2	0	0	6
Variable	0	0	0	0	0	0	0
Total	3	16	31	15	12	0	77

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

APPENDIX G

ERRATA DATA

Intentionally left blank

There is no errata data for 2017.

Intentionally left blank

APPENDIX H

ANNUAL RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM REPORT (ARGPPR)

Intentionally left blank

NRC.Docket No: 50-454
50-455

BYRON NUCLEAR GENERATING STATION UNITS 1 and 2

**Annual Radiological
Groundwater Protection Program Report**

1 January Through 31 December 2017

Prepared By

**Teledyne Brown Engineering
Environmental Services**



**Byron Nuclear Generating Station
Byron, IL 61010**

April 2018

Intentionally left blank

Table Of Contents

I. Summary and Conclusions	1
II. Introduction.....	3
A. Objectives of the RGPP	3
B. Implementation of the Objectives.....	3
C. Program Description.....	4
D. Characteristics of Tritium (H-3)	4
III. Program Description.....	5
A. Sample Analysis	5
B. Data Interpretation.....	5
C. Background Analysis.....	6
1. Background Concentrations of Tritium.....	7
IV. Results and discussion	8
A. Groundwater Results.....	8
B. Drinking Water Well Survey	10
C. Summary of Results – Inter-laboratory Comparison Program	10
D. Leaks, Spills, and Releases	10
E. Trends.....	10
F. Investigations	10
G. Actions Taken.....	10

Appendices

Appendix A Location Designation

Tables

Table A-1 Radiological Groundwater Protection Program - Sampling Locations, Distance and Direction, Byron Nuclear Generating Station, 2017

Figures

Figure A-1 Monitoring Well Locations, Byron Nuclear Generating Station, 2017
(Extra wells noted on map are for reference only.)

Appendix B Data Tables

Tables

Table B-I.1 Concentrations of Tritium, Strontium, Gross Alpha, and Gross Beta in Groundwater Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017

Table B-I.2 Concentrations of Gamma Emitters in Groundwater Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2017

I. Summary and Conclusions

In 2006, Exelon instituted a comprehensive monitoring program to evaluate the impact of station operations on groundwater in the vicinity of Byron Nuclear Generating Station. The monitoring was conducted in two phases. Phase 1 of the monitoring was part of a comprehensive study initiated by Exelon to determine whether groundwater or surface water at and in the vicinity of Byron Nuclear Generating Station had been adversely impacted by any releases of radionuclides. Phase 1 was conducted by Conestoga Rovers and Associates (CRA) and the conclusions were made available to state and federal regulators as well as the public.

Phase 2 of the RGPP was conducted by Exelon corporate and station personnel to initiate follow up of Phase 1 and begin long-term monitoring at groundwater locations selected during Phase 1. This is the ninth in a series of annual reports on the status of the Radiological Groundwater Protection Program (RGPP) conducted at Byron Nuclear Generating Station. This report covers groundwater and surface water samples collected from the environment both on and off station property in 2017. During that time period, 121 analyses were performed on 54 samples from 16 locations.

Gamma-emitting radionuclides associated with licensed plant operations were not detected at concentrations greater than their respective Lower Limits of Detection (LLDs) as specified in the Offsite Dose Calculation Manual (ODCM) in any of the groundwater samples tested. In the case of tritium, Exelon specified that its laboratories achieve a lower limit of detection 10 times lower than that required by federal regulation.

In 2017, one surface water and fifteen (15) Radiological Groundwater Protection Program (RGPP) monitoring wells were sampled. The samples were obtained throughout the year and analyzed for tritium. In addition, for the samples obtained in June, a study of gamma, beta, and alpha radioisotopes was performed in accordance with Nuclear Energy Institute (NEI) 07-07, Groundwater Protection Initiative. Three wells contained levels of tritium above the lower limit of detection (LLD) of 200 pCi/L. They were: AR-4, with concentrations ranging from 239 - 443 pCi/L; AR-7, with concentrations ranging from <178 - 431 pCi/L; and AR-11, with concentrations ranging from 554 - 785 pCi/L. Wells AR-4 and AR-11 are near the Circulating Water Blowdown piping, where historical leakage through vacuum breakers was known to have occurred. Tritium concentrations in these wells have gradually decreased since being first sampled in 2006. Well AR-7 is located on-site, just west of plant structures. Tritium has been measured in this well just above detectable limits on an intermittent basis since the well was first drilled in 2006. The tritium present in this well is at or below tritium levels that have been measured in rainwater as a result of precipitation recapture from permitted gaseous releases and it is not believed to be the result of new leak(s). In August 2014, a break in the AR-7 well piping was discovered about six feet below the surface that could have served as the entry point for tritium in the

recapture water. Should the water in these aquifers migrate to off-site wells used for drinking, the off-site dose consequence from tritium present in any of these three wells would be negligible. There are no existing or new leaks evident at the site and all groundwater well sample results are well below the drinking water standard of 20,000 pCi/L tritium.

Strontium-89 (Sr-89) and Strontium-90 (Sr-90) were not detected in any samples above their respective LLDs of 10 and 1 pCi/L.

Gross Alpha and Gross Beta analyses in the dissolved and suspended fractions were performed on groundwater samples during the second quarter sampling in 2017.

Gross Alpha (dissolved) was not detected in any groundwater locations. Gross Alpha (suspended) was not detected in any groundwater locations.

Gross Beta (dissolved) was detected in six of fifteen groundwater locations. The concentrations ranged from 2.3 to 19.5 pCi/L. Gross Beta (suspended) was not detected in any groundwater locations.

The concentrations of Gross Alpha and Gross Beta, which are slightly above detectable levels, are considered to be background and are not the result of plant effluents.

Hard-To-Detect analyses were not performed in 2017.

In assessing all the data gathered for this report, it was concluded that the operation of Byron Nuclear Generating Station had no adverse radiological impact on the environment, and there are no known active releases into the groundwater at Byron Nuclear Generating Station.

II. Introduction

The Byron Station, a two-unit PWR station, is located about two miles east of the Rock River and approximately three miles southwest of Byron in Ogle County, Illinois. The reactors are designed to have capacities of 1,268 and 1,241 MW gross, respectively. Unit One loaded fuel in November 1984 and went on line February 2, 1985. Unit Two went on line January 9, 1987.

This report covers those analyses performed by Teledyne Brown Engineering (TBE) on samples collected in 2017.

A. Objectives of the RGPP

The long-term objectives of the RGPP are as follows:

1. Identify suitable locations to monitor and evaluate potential impacts from station operations before significant radiological impact to the environment and potential drinking water sources
2. Understand the local hydrogeologic regime in the vicinity of the station and maintain up-to-date knowledge of flow patterns on the surface and shallow subsurface
3. Perform routine water sampling and radiological analysis of water from selected locations
4. Report new leaks, spills, or other detections with potential radiological significance to stakeholders in a timely manner
5. Regularly assess analytical results to identify adverse trends
6. Take necessary corrective actions to protect groundwater resources

B. Implementation of the Objectives

The objectives identified have been implemented at Byron Nuclear Generating Station as discussed below:

1. Exelon and its consultant identified locations as described in the Phase 1 study. Phase 1 studies were conducted by Conestoga Rovers and Associates (CRA) and the results and conclusions were made available to state and federal regulators as well as the public.
2. The Byron Nuclear Generating Station reports describe the local hydrogeologic regime. Periodically, the flow patterns on the surface and shallow subsurface are updated based on ongoing measurements.
3. Byron Nuclear Generating Station will continue to perform routine

sampling and radiological analysis of water from selected locations.

4. Byron Nuclear Generating Station has implemented new procedures to identify and report new leaks, spills, or other detections with potential radiological significance in a timely manner.
5. Byron Nuclear Generating Station staff and consulting hydrogeologist assess analytical results on an ongoing basis to identify adverse trends.

C. Program Description

1. Sample Collection

Sample locations can be found in Table A-1 and Figure A-1, Appendix A.

Groundwater

Samples of water are collected, managed, transported and analyzed in accordance with approved procedures following EPA methods. Only groundwater is collected. Sample locations, sample collection frequencies and analytical frequencies are controlled in accordance with approved station procedures. Contractor and/or station personnel are trained in the collection, preservation management, and shipment of samples, as well as in documentation of sampling events. Analytical laboratories are subject to internal quality assurance programs, industry cross-check programs, as well as nuclear industry audits. Station personnel review and evaluate all analytical data deliverables as data are received.

Analytical data results are reviewed by both station personnel and an independent hydrogeologist for adverse trends or changes to hydrogeologic conditions.

D. Characteristics of Tritium (H-3)

Tritium (chemical symbol H-3) is a radioactive isotope of hydrogen. The most common form of tritium is tritium oxide, which is also called "tritiated water." The chemical properties of tritium are essentially those of ordinary hydrogen.

Tritiated water behaves the same as ordinary water in both the environment and the body. Tritium can be taken into the body by drinking water, breathing air, eating food, or absorption through skin. Once tritium enters the body, it disperses quickly and is uniformly distributed

throughout the body. Tritium is excreted primarily through urine with a clearance rate characterized by an effective biological half-life of about 14 days. Within one month or so after ingestion, essentially all tritium is cleared. Organically bound tritium (tritium that is incorporated in organic compounds) can remain in the body for a longer period.

Tritium is produced naturally in the upper atmosphere when cosmic rays strike air molecules. Tritium is also produced during nuclear weapons explosions, as a by-product in reactors producing electricity, and in special production reactors, where the isotopes lithium-7 and/or boron-10 are activated to produce tritium. Like normal water, tritiated water is colorless and odorless. Tritiated water behaves chemically and physically like non-tritiated water in the subsurface, and therefore tritiated water will travel at the same velocity as the average groundwater velocity.

Tritium has a half-life of approximately 12.3 years. It decays spontaneously to Helium-3 (^3He). This radioactive decay releases a beta particle (low-energy electron). The radioactive decay of tritium is the source of the health risk from exposure to tritium. Tritium is one of the least dangerous radionuclides because it emits very weak radiation and leaves the body relatively quickly. Since tritium is almost always found as water, it goes directly into soft tissues and organs. The associated dose to these tissues is generally uniform and is dependent on the water content of the specific tissue.

III. Program Description

A. Sample Analysis

This section describes the general analytical methodologies used by TBE to analyze the environmental samples for radioactivity for the Byron Nuclear Generating Station RGPP in 2017.

In order to achieve the stated objectives, the current program includes the following analyses (as required by procedure):

1. Concentrations of gamma emitters in groundwater
2. Concentrations of strontium in groundwater
3. Concentrations of tritium in groundwater
4. Concentrations of gross alpha and gross beta in groundwater

B. Data Interpretation

The radiological data collected prior to Byron Nuclear Generating Station

becoming operational were used as a baseline with which these operational data were compared. For the purpose of this report, Byron Nuclear Generating Station was considered operational at initial criticality. Several factors were important in the interpretation of the data:

1. Lower Limit of Detection and Minimum Detectable Concentration

The lower limit of detection (LLD) is specified by federal regulation as a minimum sensitivity value that must be achieved routinely by the analytical parameter.

2. Laboratory Measurements Uncertainty

The estimated uncertainty in measurement of tritium in environmental samples is frequently on the order of 50% of the measurement value.

Statistically, the exact value of a measurement is expressed as a range with a stated level of confidence. The convention is to report results with a 95% level of confidence. The uncertainty comes from calibration standards, sample volume or weight measurements, sampling uncertainty and other factors. Exelon reports the uncertainty of a measurement created by statistical process (counting error) as well as all sources of error (Total Propagated Uncertainty or TPU). Each result has two values calculated. Exelon reports the TPU by following the result with plus or minus \pm the estimated sample standard deviation, as TPU, that is obtained by propagating all sources of analytical uncertainty in measurements.

Analytical uncertainties are reported at the 95% confidence level in this report for reporting consistency with the AREOR.

C. Background Analysis

A pre-operational radiological environmental monitoring program (pre-operational REMP) was conducted to establish background radioactivity levels prior to operation of the Station. The environmental media sampled and analyzed during the pre-operational REMP were atmospheric radiation, fall-out, domestic water, surface water, marine life, and foodstuffs. The results of the monitoring were detailed in the report entitled, *Environmental Radiological Monitoring for Byron Nuclear Generating Nuclear Power Station, Commonwealth Edison Company, Annual Report 1984, April, 1985.*

The pre-operational REMP contained analytical results from samples collected from the surface water and groundwater. All groundwater samples listed in the pre-Operational REMP report were <200 pCi/L.

1. Background Concentrations of Tritium

The purpose of the following discussion is to summarize background measurements of tritium in various media performed by others. Additional detail may be found by consulting references (CRA 2006).

a. Tritium Production

Tritium is created in the environment from naturally occurring processes both cosmic and subterranean, as well as from anthropogenic (i.e., man-made) sources. In the upper atmosphere, "Cosmogenic" tritium is produced from the bombardment of stable nuclides and combines with oxygen to form tritiated water, which will then enter the hydrologic cycle. Below ground, "lithogenic" tritium is produced by the bombardment of natural lithium present in crystalline rocks by neutrons produced by the radioactive decay of naturally abundant uranium and thorium. Lithogenic production of tritium is usually negligible compared to other sources due to the limited abundance of lithium in rock. The lithogenic tritium is introduced directly to groundwater.

A major anthropogenic source of tritium and Sr-90 comes from the former atmospheric testing of thermonuclear weapons. Levels of tritium in precipitation increased significantly during the 1950s and early 1960s, and later with additional testing, resulting in the release of significant amounts of tritium to the atmosphere. The Canadian heavy water nuclear power reactors, other commercial power reactors, nuclear research and weapons production continue to influence tritium concentrations in the environment.

b. Precipitation Data

Precipitation samples are routinely collected at stations around the world for the analysis of tritium and other radionuclides. Two publicly available databases that provide tritium concentrations in precipitation are Global Network of Isotopes in Precipitation (GNIP) and USEPA's RadNet database. GNIP provides tritium precipitation concentration data for samples collected worldwide from 1960 to 2006. RadNet provides tritium precipitation concentration data for samples collected at stations throughout the U.S. from 1960 up to and including 2006. Based on GNIP data for sample stations located in the U.S. Midwest, tritium concentrations peaked around 1963. This peak, which approached 10,000

pCi/L for some stations, coincided with the atmospheric testing of thermonuclear weapons. Tritium concentrations in surface water showed a sharp decline up until 1975 followed by a gradual decline since that time. Tritium concentrations in Midwest precipitation have typically been below 100 pCi/L since around 1980. Tritium concentrations in wells may still be above the 200 pCi/L detection limit from the external causes described above. Water from previous years and decades is naturally captured in groundwater, so some well water sources today are affected by the surface water from the 1960s that was elevated in tritium.

c. Surface Water Data

Tritium concentrations are routinely measured in large surface water bodies, including Lake Michigan and the Mississippi River. Illinois surface water data were typically less than 100 pCi/L.

The USEPA RadNet surface water data typically has a reported 'Combined Standard Uncertainty' of 35 to 50 pCi/L. According to USEPA, this corresponds to a ± 70 to 100 pCi/L 95% confidence bound on each given measurement. Therefore, the typical background data provided may be subject to measurement uncertainty of approximately ± 70 to 100 pCi/L.

The radio-analytical laboratory is counting tritium results to an Exelon specified LLD of 200 pCi/L. Typically, the lowest positive measurement will be reported within a range of 40 – 240 pCi/L or 140 ± 100 pCi/L. Clearly, these sample results cannot be distinguished as different from background at this concentration.

IV. Results and Discussion

A. Groundwater Results

Groundwater

Samples were collected from on- and off-site wells throughout the year in accordance with the station radiological groundwater protection program. Analytical results and anomalies are discussed below:

Tritium

Samples from all locations were analyzed for tritium activity (Table B-I.1, Appendix B). Tritium values ranged from less than the detection limit to

785 pCi/L. Outside of the station boundary, tritium concentrations were all less than detection limit (<200 pCi/L). This is based on evaluation of groundwater sample results obtained as part of the Byron Station REMP. In 2017, fifteen (15) Radiological Groundwater Protection Program (RGPP) monitoring wells were sampled. The samples were obtained throughout the year and analyzed for tritium.

In addition, a study of gamma, beta and alpha radioisotopes was performed in accordance with Nuclear Energy Institute (NEI) 07-07, Groundwater Protection Initiative, for the samples obtained in June. Three wells contained levels of tritium above the lower limit of detection (LLD) of 200 pCi/L. They were: AR-4, with concentrations ranging from 239 - 443 pCi/L; AR-7, with concentrations ranging from <178 - 431 pCi/L; and AR-11, with concentrations ranging from 554 - 785 pCi/L. Wells AR-4 and AR-11 are near the Circulating Water Blowdown piping, where historical leakage through vacuum breakers was known to have occurred. Tritium concentrations in these wells have gradually decreased since being first sampled in 2006. Well AR-7 is located on-site, just west of plant structures. Tritium has been measured in this well just above detectable limits on an intermittent basis since the well was first drilled in 2006. The tritium present in this well is at or below tritium levels that have been measured in rainwater as a result of precipitation recapture from permitted gaseous releases and it is not believed to be the result of new leak(s). In August 2014, a break in the AR-7 well piping was discovered about six feet below the surface that could have served as the entry point for tritium in the recapture water. There are no existing or new leaks evident at the site and all groundwater well sample results are well below the drinking water standard of 20,000 pCi/L tritium. The tritium detected in groundwater samples has been isolated to the Galena- Platteville aquifer, which is isolated from the deeper regional groundwater aquifer by the semi-confining Glenwood Formation. Groundwater quality data from production wells and monitoring wells at the station located below this aquifer do not indicate concentrations of tritium greater than the LLD of 200 pCi/L. As such, the tritium impact is limited to the Galena- Platteville aquifer.

Strontium

Strontium-89 (Sr-89) and Strontium-90 (Sr-90) were not detected in any samples above their respective LLDs of 10 and 1 pCi/L.

Gross Alpha and Gross Beta (dissolved and suspended)

Gross Alpha and Gross Beta analyses in the dissolved and suspended fractions were performed on groundwater samples during the second quarter sampling in 2017.

Gross Alpha (dissolved) was not detected in any groundwater locations. Gross Alpha (suspended) was not detected in any groundwater locations.

Gross Beta (dissolved) was detected in six of fifteen groundwater locations. The concentrations ranged from 2.3 to 19.5 pCi/L. Gross Beta (suspended) was not detected in any groundwater locations.

The concentrations of Gross Alpha and Gross Beta, which are slightly above detectable levels, are considered to be background and are not the result of plant effluents.

Gamma Emitters

Gamma-emitting radionuclides associated with licensed plant operations were not detected at concentrations greater than their respective LLDs in any of the samples during 2017.

Hard-To-Detect

Hard-To-Detect analyses were not performed in 2017.

B. Drinking Water Well Survey

No drinking water well surveys were conducted in 2017.

C. Summary of Results – Inter-Laboratory Comparison Program

Inter-Laboratory Comparison Program results for TBE are presented in the AREOR.

D. Leaks, Spills, and Releases

There are no new previously unidentified leaks or plumes at Byron Station. There were no new leaks, spills or releases at Byron Station in 2017.

E. Trends

Wells AR-4 and AR-11 have shown an overall decrease in tritium concentration since first sampled in 2006. Tritium has been measured in Well AR-7 since 2012, however, tritium has been previously measured in this well and it is believed to be the result of precipitation recapture, not the result of a new spill or leak.

F. Investigations

There were no investigations that took place in 2017 as a result of groundwater sample results.

G. Actions Taken

1. Compensatory Actions

No compensatory actions were initiated in 2017.

2. Installation of Monitoring Wells

No new monitoring wells were installed in 2017.

3. Actions to Recover/Reverse Plumes

No actions were undertaken to recover/reverse plumes in 2017.

Intentionally left blank

APPENDIX A

LOCATION DESIGNATION

Intentionally Left Blank

TABLE A-1:

Radiological Groundwater Protection Program - Sampling Locations, Distance and Direction, Byron Nuclear Generating Station, 2017

Site	Site Type	Temporary/Permanent	Distance and Direction
AR-1	Monitoring Well	Permanent	0.36 miles/NNW
AR-10	Monitoring Well	Permanent	0.28 miles/NE
AR-11	Monitoring Well	Permanent	1.36 miles/WNW
AR-2	Monitoring Well	Permanent	0.6 miles/NW
AR-3	Monitoring Well	Permanent	0.8 miles/NW
AR-4	Monitoring Well	Permanent	1.36 miles/WNW
AR-5	Monitoring Well	Permanent	1.92 miles/WNW
AR-6	Monitoring Well	Permanent	2.04 miles/WNW
AR-7	Monitoring Well	Permanent	0.04 miles/W
AR-8	Monitoring Well	Permanent	0.12 miles/S
AR-9	Monitoring Well	Permanent	0.24 miles/E
CAR-1	Monitoring Well	Permanent	2.25 miles/WNW
CAR-2	Monitoring Well	Permanent	1.52 miles/WNW
CAR-3	Monitoring Well	Permanent	0.16 miles/SE
DF-24 (EPA well)	Monitoring Well	Permanent	1.36 miles/WNW
GW-9	Monitoring Well	Permanent	0.9 miles/WNW
MW-1 (EPA well)	Monitoring Well	Permanent	0.6 miles/NW
MW-3 (EPA well)	Monitoring Well	Permanent	0.8 miles/NW
TW-13	Monitoring Well	Permanent	2.3 miles/WNW
TW-14	Monitoring Well	Permanent	2.25 miles/WNW
TW-15	Monitoring Well	Permanent	2.2 miles/WNW
Well 7	Monitoring Well	Permanent	0.4 miles/SE
CROP	Surface Water	Permanent	0.2 miles NE




Figure A-1
Monitoring Well Locations, Byron Nuclear Generating Station, 2017

APPENDIX B

DATA TABLES

Intentionally left blank

TABLE B-I.1 CONCENTRATIONS OF TRITIUM, STRONTIUM, GROSS ALPHA AND GROSS BETA IN GROUNDWATER SAMPLES COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2017

RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

SITE	COLLECTION DATE	H-3	Sr-89	Sr-90	Gr-A (Dis)	Gr-A (Sus)	Gr-B (Dis)	Gr-B (Sus)
AR-1	03/09/17	< 200						
AR-1	05/31/17	< 171	< 7.1	< 0.8	< 1.1	< 0.6	< 1.4	< 1.4
AR-1	09/13/17	< 179						
AR-1	11/01/17	< 175						
AR-2	05/31/17	< 174						
AR-2	10/23/17	< 181						
AR-3	03/06/17	< 191						
AR-3	05/31/17	< 176	< 5.9	< 0.9	< 1.1	< 0.5	5.7 ± 1.2	< 1.5
AR-3	09/11/17	< 177						
AR-3	10/23/17	< 177						
AR-4	03/06/17	443 ± 134						
AR-4	05/31/17	372 ± 126	< 4.7	< 0.7	< 1.4	< 0.5	3.8 ± 1.3	< 1.5
AR-4	09/11/17	239 ± 120						
AR-4	10/23/17	317 ± 126						
AR-7	03/09/17	298 ± 136						
AR-7	05/31/17	431 ± 128	< 4.5	< 0.7	< 3.7	< 0.6	19.5 ± 2.1	< 1.4
AR-7	09/13/17	230 ± 118						
AR-7	10/31/17	< 178						
AR-8	03/09/17	< 195						
AR-8	05/31/17	< 170	< 5.1	< 0.7	< 0.9	< 0.6	2.3 ± 0.8	< 1.4
AR-8	09/13/17	< 183						
AR-8	10/31/17	< 176						
AR-9	03/09/17	< 192						
AR-9	05/31/17	< 168	< 4.4	< 0.7	< 1.7	< 0.6	< 1.6	< 1.4
AR-9	09/13/17	< 184						
AR-9	10/31/17	< 177						
AR-10	03/09/17	< 194						
AR-10	05/31/17	< 172	< 6.9	< 0.9	< 4.4	< 0.5	< 2.2	< 1.5
AR-10	09/13/17	< 185						
AR-10	11/01/17	< 175						
AR-11	03/06/17	785 ± 158						
AR-11	05/31/17	624 ± 141	< 5.0	< 0.8	< 1.3	< 1.6	5.1 ± 1.3	< 2.0
AR-11	09/11/17	603 ± 136						
AR-11	10/23/17	554 ± 137						
CAR-1	05/31/17	< 172						
CAR-1	10/23/17	< 188						
CAR-3	03/09/17	< 196						
CAR-3	05/31/17	< 172	< 4.6	< 0.6	< 1.9	< 0.5	3.3 ± 1.2	< 1.5
CAR-3	09/13/17	< 188						
CAR-3	10/31/17	< 170						
DF-24	03/06/17	< 192						
DF-24	05/31/17	< 171						
DF-24	09/11/17	< 180						
DF-24	10/23/17	< 184						
MW-1	05/31/17	< 172						
MW-1	10/23/17	< 184						
MW-3	05/31/17	< 170						
MW-3	10/23/17	< 177						
TW-13	05/31/17	< 174						
TW-13	10/23/17	< 184						
CROP*	03/09/17	< 191						
CROP*	05/31/17	< 174						
CROP*	09/13/17	< 185						
CROP*	10/31/17	< 173						

*Surface Water Sample

Bolded values indicate LLD was not met due to high solids content in the sample

TABLE B-I.2 **CONCENTRATIONS OF GAMMA EMITTERS IN GROUNDWATER SAMPLES**
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATION STATION, 2017
 RESULTS IN UNITS OF PCI/LITER + 2 SIGMA

SITE	COLLECTION DATE	RESULTS IN UNITS OF PCI/LITER + 2 SIGMA													
		Be-7	K-40	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	I-131	Cs-134	Cs-137	Ba-140	La-140
AR-1	05/31/17	< 62	< 149	< 7	< 9	< 12	< 6	< 10	< 7	< 10	< 15	< 6	< 35	< 13	
AR-2	05/31/17	< 66	< 59	< 7	< 8	< 19	< 10	< 17	< 11	< 14	< 13	< 10	< 35	< 9	
AR-3	05/31/17	< 43	< 88	< 5	< 4	< 9	< 5	< 8	< 5	< 9	< 12	< 5	< 27	< 10	
AR-4	05/31/17	< 57	< 97	< 6	< 7	< 15	< 7	< 11	< 6	< 11	< 11	< 5	< 32	< 15	
AR-7	05/31/17	< 64	< 63	< 7	< 8	< 16	< 8	< 16	< 8	< 13	< 14	< 7	< 39	< 11	
AR-8	05/31/17	< 61	< 127	< 7	< 7	< 16	< 7	< 16	< 8	< 11	< 14	< 9	< 41	< 14	
AR-9	05/31/17	< 63	< 112	< 7	< 6	< 15	< 6	< 15	< 7	< 12	< 14	< 8	< 35	< 9	
AR-10	05/31/17	< 73	< 46	< 5	< 6	< 11	< 7	< 11	< 7	< 11	< 14	< 8	< 29	< 15	
AR-11	05/31/17	< 69	< 124	< 7	< 9	< 18	< 7	< 12	< 9	< 16	< 14	< 9	< 40	< 13	
CAR-1	05/31/17	< 77	< 56	< 7	< 8	< 18	< 7	< 18	< 8	< 11	< 14	< 6	< 40	< 12	
CAR-3	05/31/17	< 68	< 136	< 7	< 6	< 16	< 7	< 15	< 7	< 12	< 15	< 7	< 33	< 14	
TW-13	05/31/17	< 54	< 63	< 8	< 7	< 16	< 8	< 11	< 7	< 12	< 14	< 6	< 37	< 12	
CROP*	05/31/17	< 71	< 125	< 8	< 8	< 18	< 8	< 21	< 9	< 16	< 14	< 8	< 36	< 12	

*Surface Water Sample