



Three Mile Island Unit 1  
Route 441 South, P.O. Box 480  
Middletown, PA 17057  
Telephone 717-948-8000

April 30, 2019  
TMI-19-032

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Three Mile Island Nuclear Station Unit 1 and Unit 2  
Renewed Facility Operating License No. DPR-50 and Possession Only License No. DPR 73  
NRC Docket Nos. 50-289 and 50-320

SUBJECT: 2018 Annual Radiological Environmental Operating Report

In accordance with TMI-1 Technical Specification 6.9.3.1, TMI-2 Technical Specifications 6.8.1.1, enclosed is the Annual Radiological Environmental Operating Report covering the time period of January 1 through December 31, 2018, for the Three Mile Island Nuclear Station.

Please contact Dani Brookhart of TMI Chemistry at (717) 948-8017 if you have questions regarding this submittal.

Respectfully,

A handwritten signature in black ink, appearing to read "Dullinger", with a long horizontal stroke extending to the right.

Joseph A. Dullinger  
Plant Manager, Three Mile Island  
Exelon Generation Co., LLC

Attachment/Enclosure

cc: Regional Administrator, NRC Region I  
NRC Senior Resident Inspector – Three Mile Island Nuclear Station, Unit 1  
NRC Project Manager, NRR – Three Mile Island Nuclear Station, Unit 1  
NRC Project Manager, NRR – Three Mile Island Nuclear Station, Unit 2  
R. R. Janati, Commonwealth of Pennsylvania  
S. L. Martin, PA Department of Environmental Protection, Bureau of Radiation Protection –  
Nuclear Safety Division

Docket No: 50-289  
50-320

# **THREE MILE ISLAND NUCLEAR STATION UNITS 1 AND 2**

Annual Radiological  
Environmental Operating Report

1 January through 31 December 2018

**Prepared By**  
Teledyne Brown Engineering  
Environmental Services



Three Mile Island Nuclear Station  
Middletown, PA 17057

**April 2019**

Intentionally left blank

# Table Of Contents

|   |    |
|---|----|
| I. Summary and Conclusions.....                                   | 1  |
| II. Introduction .....  | 3  |
| A. Objectives of the REMP .....                                   | 3  |
| B. Implementation of the Objectives.....                          | 3  |
| III. Program Description .....                                    | 4  |
| A. Sample Collection .....  | 4  |
| B. Sample Analysis.....   | 6  |
| C. Data Interpretation .....                                      | 7  |
| D. Program Exceptions.....  | 8  |
| E. Program Changes .....  | 10 |
| IV. Results and Discussion .....                                  | 10 |
| A. Aquatic Environment .....                                      | 10 |
| 1. Surface Water.....   | 10 |
| 2. Drinking Water.....  | 11 |
| 3. Effluent Water.....  | 12 |
| 4. Storm Water .....  | 13 |
| 5. Ground Water .....   | 13 |
| 6. Fish .....   | 13 |
| 7. Sediment.....  | 13 |
| B. Atmospheric Environment .....                                  | 14 |
| 1. Airborne Particulates .....                                    | 14 |
| a. Air Particulates.....  | 14 |
| b. Airborne Iodine .....  | 15 |
| 2. Terrestrial.....   | 15 |
| a. Milk.....  | 15 |
| b. Food Products .....  | 15 |
| C. Ambient Gamma Radiation.....                                   | 16 |
| D. Land Use Survey.....   | 16 |
| E. Radiological Impact of TMINS Operations.....                   | 17 |
| F. Errata Data .....  | 24 |
| G. Summary of Results – Inter-Laboratory Comparison Program ..... | 24 |
| V. References .....   | 27 |

## Appendices

Appendix A Radiological Environmental Monitoring Report Summary

### Tables

Table A-1 Radiological Environmental Monitoring Program Annual Summary for the Three Mile Island Nuclear Station, 2018

Appendix B Location Designation, Distance & Direction And Sample Collection & Analytical Methods

### Tables

Table B-1 Location Designation and Identification System for the Three Mile Island Nuclear Station

Table B-2 Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Three Mile Island Nuclear Station, 2018

Table B-3 Radiological Environmental Monitoring Program - Summary of Sample Collection and Analytical Methods, Three Mile Island Nuclear Station, 2018

### Figures

Figure B-1 Environmental Sampling Locations Within One Mile of the Three Mile Island Nuclear Station, 2018

Figure B-2 Environmental Sampling Locations Between One and Five Miles from the Three Mile Island Nuclear Station, 2018

Figure B-3 Environmental Sampling Locations Greater Than Five Miles from the Three Mile Island Nuclear Station, 2018

Appendix C Data Tables and Figures - Primary Laboratory

### Tables

Table C-I.1 Concentrations of Tritium in Surface Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018

Table C-I.2 Concentrations of I-131 in Surface Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018

Table C-I.3 Concentrations of Gamma-Emitters in Surface Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018

|                |  |
|----------------|--|
| Table C-II.1   | Concentrations of Gross Beta in Drinking Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018  |
| Table C-II.2   | Concentrations of I-131 in Drinking Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018   |
| Table C-II.3   | Concentrations of Tritium in Drinking Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018   |
| Table C-II.4   | Concentrations of Gamma-Emitters in Drinking Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018  |
| Table C-III.1  | Concentrations of Gross Beta, I-131, Tritium, and Strontium in Effluent Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018                     |
| Table C-III.2  | Concentrations of Gamma-Emitters in Effluent Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018  |
| Table C-IV.1   | Concentrations of Strontium in Predator and Bottom Feeder (Fish) Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018                                  |
| Table C-IV.2   | Concentrations of Gamma-Emitters in Predator and Bottom Feeder (Fish) Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018                             |
| Table C-V.1    | Concentrations of Gamma-Emitters in Sediment Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018  |
| Table C-VI.1   | Concentrations of Gross Beta in Air Particulate Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018   |
| Table C-VI.2   | Monthly and Yearly Mean Values of Gross Beta Concentrations (E-3 pCi/cu meter) in Air Particulate Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018 |
| Table C-VI.3   | Concentrations of Gamma-Emitters in Air Particulate Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018   |
| Table C-VII.1  | Concentrations of I-131 in Air Iodine Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018   |
| Table C-VIII.1 | Concentrations of I-131 in Milk Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018   |
| Table C-VIII.2 | Concentrations of Strontium in Milk Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018   |
| Table C-VIII.3 | Concentrations of Gamma-Emitters in Milk Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018  |
| Table C-IX.1   | Concentrations of Strontium and Gamma-Emitters in Food Product Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018                                    |

|             |  |
|-------------|--|
| Table C-X.1 | Quarterly OSLD Results for Three Mile Island Nuclear Station, 2018   |
| Table C-X.2 | Mean Quarterly OSLD Results for the Site Boundary, Indicator and Control Locations for Three Mile Island Nuclear Station, 2018 |
| Table C-X.3 | Summary of the Ambient Dosimetry Program for Three Mile Island Nuclear Station, 2018   |

### Figures

|            |  |
|------------|--|
| Figure C-1 | Monthly Tritium Concentrations in Surface Water and Effluent Water Three Mile Island Nuclear Station, 2018       |
| Figure C-2 | Mean Quarterly Tritium Concentrations in Surface Water Three Mile Island Nuclear Station, 1974 - 2018            |
| Figure C-3 | Mean Monthly Gross Beta Concentrations in Drinking Water Three Mile Island Nuclear Station, 2018                 |
| Figure C-4 | Mean Monthly Tritium Concentrations in Drinking Water and Effluent Water Three Mile Island Nuclear Station, 2018 |
| Figure C-5 | Mean Cesium-137 Concentrations in Aquatic Sediments Three Mile Island Nuclear Station, 1984 - 2018               |
| Figure C-6 | Mean Quarterly Gross Beta Concentrations in Air Particulates Three Mile Island Nuclear Station, 1972 - 2018      |
| Figure C-7 | Mean Weekly Gross Beta Concentrations in Air Particulates Three Mile Island Nuclear Station, 2007 - 2018         |
| Figure C-8 | Mean Quarterly Strontium-90 Concentrations in Cow Milk Three Mile Island Nuclear Station, 1979 - 2018            |

|            |   |
|------------|---|
| Appendix D | Data Tables and Figures – Comparison Laboratory |
|------------|---|

### Tables

|               |   |
|---------------|---|
| Table D-I.1   | Concentrations of Gross Beta in Drinking Water Samples Collected in the Vicinity Of Three Mile Island Nuclear Station, 2018         |
| Table D-I.2   | Concentration of Tritium in Drinking Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018             |
| Table D-I.3   | Concentrations of Iodine-131 in Drinking Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018         |
| Table D-I.4   | Concentrations of Gamma-Emitters in Drinking Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018     |
| Table D-II.1  | Concentrations of Strontium and Gamma-Emitters in Fish Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018 |
| Table D-III.1 | Concentrations of Gamma-Emitters in Sediment Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018           |

|              |  |
|--------------|--|
| Table D-IV.1 | Concentrations of Gamma-Emitters and Strontium in Food Product Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018                        |
| Table D-V.1  | Concentrations of Gross Beta in Air Particulate and I-131 in Air Iodine Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018               |
| Table D-V.2  | Concentrations of Gamma-Emitters in Air Particulate Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018                                   |
| Table D-VI.1 | Concentrations of I-131 by Chemical Separation, Gamma-Emitters, and Strontium in Milk Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018 |

Figures

|            |   |
|------------|---|
| Figure D-1 | Monthly Gross Beta Concentrations in Drinking Water Samples Collected From TMINS Location Q9-1Q, 2018 |
| Figure D-2 | Weekly Gross Beta Concentrations in Air Particulate Samples Collected from TMINS Location E1-2Q, 2018 |

Appendix E Inter-Laboratory Comparison Program

Tables

|           |  |
|-----------|--|
| Table E-1 | Analytics Environmental Radioactivity Cross Check Program<br>Teledyne Brown Engineering, 2018  |
| Table E-2 | DOE's Mixed Analyte Performance Evaluation Program (MAPEP)<br>Teledyne Brown Engineering, 2018 |
| Table E-3 | ERA Environmental Radioactivity Cross Check Program<br>Teledyne Brown Engineering, 2018        |
| Table E-4 | Analytics Environmental Radioactivity Cross Check Program<br>Exelon Industrial Services, 2018  |
| Table E-5 | ERA Environmental Radioactivity Cross Check Program<br>Exelon Industrial Services, 2018        |
| Table E-6 | DOE's Mixed Analyte Performance Evaluation Program (MAPEP)<br>GEL Laboratories, Inc., 2018     |
| Table E-7 | ERA Environmental Radioactivity Cross Check Program<br>GEL Laboratories, Inc., 2018            |
| Table E-8 | Analytics Environmental Radioactivity Cross Check Program<br>GEL Laboratories, Inc., 2018      |

|            |  |
|------------|--|
| Appendix F | Annual Radiological Groundwater Protection Program Report (ARGPPR) |
|------------|--|



Intentionally Left Blank

## I. Summary and Conclusions

This report on the Radiological Environmental Monitoring Program conducted for the Three Mile Island Nuclear Station (TMINS) by Exelon covers the period 1 January 2018 through 31 December 2018. During that time period, 1,691 analyses were performed on 1,287 samples. In assessing all the data gathered for this report and comparing these results with preoperational data and operational REMP data, it was concluded that the operation of TMINS had no adverse radiological impact on the environment.

Surface, drinking and effluent water samples were analyzed for concentrations of tritium and gamma-emitting nuclides. Surface, drinking and effluent water samples were also analyzed for concentrations of Iodine-131 (I-131). Drinking and effluent water samples were also analyzed for concentrations of gross beta. Effluent water samples were analyzed for concentrations of Strontium-89 (Sr-89) and Strontium-90 (Sr-90). All groundwater, precipitation water, and storm water results are reported in the ARGPPR, Appendix F. No I-131, Sr-89 or Sr-90 activities were detected. Gross beta concentrations detected were consistent with those detected in previous years. Tritium activity in 9 surface water samples and 10 monthly effluent water samples was due to TMINS activities or releases. No other fission or activation products potentially attributed to TMI liquid releases were detected.

Fish (predator and bottom feeder) and sediment samples were analyzed for concentrations of gamma-emitting nuclides. Fish samples were also analyzed for concentrations of Sr-90. No Sr-90 activity was detected. No fission or activation products were detected in fish or sediment samples. Occasionally, Cs-137 is detected at very low levels (just above LLD) and is not distinguishable from background levels.

Air particulate samples were analyzed for concentrations of gross beta and gamma-emitting nuclides. Gross beta activity is consistent with data from previous years. Cosmogenic Beryllium-7 (Be-7) was detected at levels consistent with those detected in previous years. No other activation products were detected.

High sensitivity I-131 analyses were performed on weekly air samples. All results were less than the minimum detectable activity for I-131.

Cow milk samples were analyzed for concentrations of I-131, gamma-emitting nuclides, Sr-89, and Sr-90. Concentrations of naturally-occurring Potassium-40 (K-40) were consistent with those detected in previous years. No I-131 or Sr-89 activities were detected. Sr-90 activity was detected in one indicator sample. Occasionally Sr-90 activities are detected and are consistent with those detected in previous years and were attributed to fallout from nuclear weapons testing. No other fission or activation products were found.

Food Product samples were analyzed for concentrations of gamma-emitting nuclides including I-131 and Sr-90. Strontium-90 activity was detected in both indicator and control samples. This was a result of plant uptake of Sr-90 in soil

as a result of past nuclear weapons testing. Concentrations of naturally-occurring Be-7 and K-40 were consistent with those detected in previous years. No other fission or activation products were detected.

Beginning in 2012, Exelon changed the type of dosimetry used for the Radiological Environmental Monitoring Program (REMP). Optically Stimulated Luminescent Dosimetry (OSLD) were deployed and Thermo-luminescent Dosimetry (TLD) were discontinued. This change resulted in a slight change in process and reporting of quarterly results. The relative comparison to control locations remains valid. OSLD technology is different than that used in a TLD but has the same purpose (to measure direct radiation).

In conclusion, radioactive materials related to TMINS operations were detected in environmental samples, but the measured concentrations were low and consistent with measured effluents. The environmental sample results verified that the doses received by the public from TMINS effluents in 2018 were well below applicable dose limits and only a small fraction of the doses received from natural background radiation. Additionally, the results indicated that there was no permanent buildup of radioactive materials in the environment and no increase in background radiation levels.

Therefore, based on the results of the radiological environmental monitoring program (REMP) and the doses calculated from measured effluents, TMINS operations in 2018 did not have any adverse effects on the health of the public or on the environment.

## II. Introduction

The Three Mile Island Nuclear Station (TMINS), consisting of two pressurized water reactors (PWR), is located on the northern end of Three Mile Island in the Susquehanna River approximately 2.5 miles south of Middletown in Londonderry Township, Dauphin County, Pennsylvania. TMI-1 is owned and operated by Exelon and became operational in 1974. TMI-2 is operated by GPU Nuclear, Inc. and owned by Metropolitan Edison (50%), Pennsylvania Electric (25%) and Jersey Central Power & Light (25%). TMI-2 became operational in 1978 and was shut down following the 1979 accident. At the end of 1993 TMI-2 was placed in a condition called Post-Defueling Monitored Storage. TMI-2 is maintained by Exelon under contract with GPU Nuclear.

A Radiological Environmental Monitoring Program (REMP) for TMINS was initiated in 1974. This report covers those analyses performed by Teledyne Brown Engineering (TBE), Landauer and Exelon Industrial Services (EIS)/GEL Laboratories on samples collected during the period 1 January 2018 through 31 December 2018.

### A. Objectives of the REMP

The objectives of the REMP are to:

1. Evaluate the relationship between quantities of radioactive material released from the plant and resultant radiation doses to individuals from principal pathways of exposure.
2. Provide data on measurable levels of radiation and radioactive materials in the site environs.
3. To verify in-plant controls for the containment of radioactive materials.
4. To determine buildup of long-lived radionuclides in the environment and changes in background radiation levels.
5. To provide reassurance to the public that the program is capable of adequately assessing impacts and identifying noteworthy changes in the radiological status of the environment.
6. To fulfill the requirements of the TMI-1 and TMI-2 Technical Specifications.

### B. Implementation of the Objectives

The implementation of the objectives is accomplished by:

1. Identifying significant exposure pathways.
2. Establishing baseline radiological data of media within those pathways.
3. Continuously monitoring those media before and during Station operation to assess Station radiological effects (if any) on man and the environment.

### III. Program Description

#### A. Sample Collection

Samples for the TMINS REMP were collected for Exelon by Exelon Industrial Services, LLC (EIS) and Normandeau Associates, Inc. (NAI). This section describes the general collection methods used by EIS & NAI to obtain environmental samples for the TMINS REMP in 2018. Sample locations and descriptions can be found in Tables B-1 and B-2, and Figures B-1 through B-3, Appendix B. The collection procedures used by EIS & NAI are listed in Table B-3.

#### Aquatic Environment

The aquatic environment was evaluated by performing radiological analyses on samples of surface water, drinking water, effluent water, fish and sediment. Two gallon water samples were collected monthly from continuous samplers located at two surface water locations (J1-2 and Q9-1), three drinking water locations (G15-2, G15-3 and Q9-1), and one effluent water location (K1-1). A composite of weekly grab samples at one surface water location (A3-2) were collected. The control locations were A3-2 and Q9-1. All groundwater and storm water results are reported in the ARGPPR, Appendix F.

All water samples were collected in unused plastic bottles, which were rinsed at least twice with source water prior to collection. Fish samples comprising the flesh of two groups, bottom feeders and predators, were collected semiannually at an upstream control (BKG) and a downstream indicator (IND) location. Location IND could be affected by TMINS' effluent releases. Sediment samples composed of recently deposited substrate were collected semiannually at three locations (A1-3, J2-1 and K1-3). In addition, one sediment sample was collected annually at the East Dike Catch Basin (EDCB). Location A1-3 was the control.

### Atmospheric Environment

The atmospheric environment was evaluated by performing radiological analyses on samples of air particulates and airborne iodine. Airborne iodine and particulate samples were collected and analyzed weekly at seven locations (A3-1, E1-2, F1-3, G2-1, H3-1, M2-1 and Q15-1). The control location was Q15-1. Airborne iodine and particulate samples were obtained at each location, using a vacuum pump with charcoal and glass fiber filters attached. The pumps were run continuously and sampled air at the rate of approximately one cubic foot per minute. The filters were replaced weekly and sent to the laboratory for analysis.

### Terrestrial Environment

The terrestrial environment was evaluated by performing radiological analyses on samples of milk and food product. Milk samples were collected biweekly at five locations (E2-2, F4-1, G2-1, K15-3 and P4-1) from March through November, and monthly from December through February. The control location was K15-3. All samples were collected in new unused two gallon plastic bottles from the bulk tank at each location, preserved with sodium bisulfite and shipped promptly to the laboratory.

Food products were collected from June through October at three locations (B10-2, E1-2 and H1-2), in lieu of milk sampling and annually from the four food product groups at two locations (B10-2 and H1-2). B10-2 was the control location for both annual and monthly sampling. Six different kinds of vegetation samples and eight different kinds of vegetation leaves were collected, placed in new unused plastic bags, and sent to the laboratory for analysis.

### Ambient Gamma Radiation

Beginning in 2012, Exelon changed the type of dosimetry used for the Radiological Environmental Monitoring Program (REMP). Optically Stimulated Luminescent Dosimetry (OSLD) were deployed and Thermo-luminescent Dosimetry (TLD) were discontinued. This change may result in a step change in readings, up or down, depending on site characteristics. The relative comparison to control locations remains valid. OSLD technology is different than that used in a TLD but has the same purpose (to measure direct radiation). The OSLDs were placed at locations on and around the TMINS site as follows:

A site boundary ring consisting of 19 locations (A1-4, B1-2, C1-2, D1-1, E1-4, F1-2, F1-4, G1-3, G1-5, G1-6, H1-1, J1-3, K1-4, L1-1, M1-1, N1-3, P1-2, Q1-2 and R1-1) near and within the site perimeter representing fence post doses (i.e., at locations where the doses will be potentially

greater than maximum annual off-site doses) from TMINS release.

An indicator ring consisting of 60 locations (A3-1, A5-1, A9-3, B1-1, B2-1, B5-1, B10-1, C1-1, C2-1, C5-1, C8-1, D1-2, D2-2, D6-1, E1-2, E2-3, E5-1, E7-1, F1-1, F2-1, F5-1, F10-1, G1-2, G2-4, G5-1, H3-1, H5-1, H8-1, J1-1, J3-1, J5-1, J7-1, K2-1, K3-1, K5-1, K8-1, L1-2, L2-1, L5-1, L8-1, M1-2, M2-1, M5-1, M9-1, N1-1, N2-1, N5-1, N8-1, P1-1, P2-1, P5-1, P8-1, Q1-1, Q2-1, Q5-1, Q9-1, R1-2, R3-1, R5-1 and R9-1) extending to approximately 10 miles from the site, designed to measure possible exposures to close-in population.

The balance of 11 locations (D15-1, F25-1, G10-1, G15-1, H15-1, J15-1, K15-1, L15-1, N15-2, Q15-1 and R15-1) represent control areas.

The specific dosimeter locations were determined by the following criteria:

1. The presence of relatively dense population
2. Site meteorological data taking into account distance and elevation for each of the sixteen 22½ degree sectors around the site, where estimated annual dose from TMINS, if any, would be most significant
3. On hills free from local obstructions and within sight of the vents (where practical)
4. And near the closest dwelling to the vents in the prevailing downwind direction

Each station has two Al<sub>2</sub>O<sub>3</sub>:C Optically Stimulated Luminescence Dosimeters enclosed in plastic placed at each location in a frame located approximately 3-6 feet above ground level. Since each OSLD responds to radiation independently, this provides two independent detectors at each station.

## B. Sample Analysis

This section describes the general analytical methods used by TBE and EIS to analyze the environmental samples for radioactivity for the TMINS REMP in 2018. The analytical procedures used by the laboratories are listed in Table B-3.

In order to achieve the stated objectives the current program includes the following analyses:

1. Concentrations of beta emitters in drinking and effluent water and air particulates
2. Concentrations of Gamma-Emitters in surface, drinking, and effluent water, air particulates, milk, fish, sediment and food products
3. Concentrations of tritium in surface, drinking and effluent water
4. Concentrations of I-131 in surface, drinking and effluent water, air, milk and food products
5. Concentrations of strontium in effluent water, fish, milk and food products
6. Ambient gamma radiation levels at various site environs

C. Data Interpretation

Data were compared to previous years' operational data for consistency and trending. In addition, comparison to pre-operational data is sometimes made. For the purpose of this report, TMINS was considered operational at initial criticality. Several factors were important in the interpretation of the data:

1. Lower Limit of Detection and Minimum Detectable Concentration

The lower limit of detection (LLD) was defined as the smallest concentration of radioactive material in a sample that would yield a net count (above background) that would be detected with only a 5% probability of falsely concluding that a blank observation represents a "real" signal. The LLD was intended as a before the fact estimate of a system (including instrumentation, procedure and sample type) and not as an after the fact criteria for the presence of activity. All analyses were designed to achieve the required TMINS detection capabilities for environmental sample analysis.

The minimum detectable concentration (MDC) is defined above with the exception that the measurement is an after the fact estimate of the presence of activity.

2. Net Activity Calculation and Reporting of Results

Net activity for a sample was calculated by subtracting background activity from the sample activity. Since the REMP measures extremely small changes in radioactivity in the environment,



background variations may result in sample activity being lower than the background activity affecting a negative number. An MDC was reported in all cases where positive activity was not detected. Gamma spectroscopy results for each type of sample were grouped as follows:

For surface, drinking, and effluent water 11 nuclides, Mn-54, Co-58, Fe-59, Co-60, Zn-65, Nb-95, Zr-95, Cs-134, Cs-137, Ba-140 and La-140 MDC's were reported.

For fish eight nuclides, K-40, Mn-54, Co-58, Fe-59, Co-60, Zn-65, Cs-134 and Cs-137 MDC's were reported.

For sediment six nuclides, K-40, Mn-54, Co-58, Co-60, Cs-134 and Cs-137 MDC's were reported.

For air particulate eight nuclides, Be-7, Mn-54, Co-58, Co-60, Nb-95, Zn-95, Cs-134 and Cs-137 MDC's were reported.

For milk five nuclides, K-40, Cs-134, Cs-137, Ba-140 and La-140 MDC's were reported.

For food products five nuclides, Be-7, K-40, I-131, Cs-134 and Cs-137 MDC's were reported.

Means and standard deviations of the results were calculated. The standard deviations represent the variability of measured results for different samples rather than single analysis uncertainty.

#### D. Program Exceptions

For 2018, the TMINS REMF had a sample recovery rate of 99.7%. Issue Reports (IR) were initiated to document significant exceptions and missing samples. All exceptions are listed below:

##### Water

##### 1. J1-2 (Surface Water)

For the sampling periods 12/31/17 - 1/6/18 and 1/6/18 – 1/13/18, compensatory grab samples were required due to frozen sample line. (IR 4124985)

##### 2. J1-2 (Surface Water)

For the sampling periods 3/10/18 – 3/17/18 and 3/17/18 – 3/24/18,

compensatory grab samples were required due to the sample line being clogged. Tubing was replaced and calibration verified. (IR 4124985)

3. K1-1 (Effluent Water)

For the sampling period 6/6/18 - 6/23/18, samples was missed due to hose being pinched, thus not allowing flow to sampler. Tubing could not be replaced at time of service. (IR 4153601)

Dosimetry

1. R1-2, K2-1, N1-1, Q1-1, P1-1, M1-2, L1-2

OSLD stations above could not be exchanged on 12/20/17 due to ice pack on the river. Ice did not melt enough for the exchange to happen in the fourth quarter. OSLDs were exchanged during the exchange of OSDs in First Quarter 2018 OSLDs on 03/19/18. (IR 04091766)

Air

1. G2-1

For the 5/26/18 – 6/2/18 sampling period, sample was missed due to the tubing from the restricted orifice not being attached to the sample capsule. (IR 4153601)

2. E2-1

For the sampling period 6/28/18 – 7/5/18, the sample was missed due to an insect being pulled through the filter and was left impacted on the iodine cartridge. (IR 4182844)

Milk

1. E2-2

IR 04146690 addressed the deviation for this site (sampling period 4/18/18 – 12/1/18).

Vegetation

1. B10-2

For the sampling period 8/19/18 - 8/26/18, the normal plants to be sampled were under water and no longer growing. Alternative plants

were sampled at the same site. (IR 4182844)

Each program exception was reviewed to understand the causes of the program exception. Sampling and maintenance errors were reviewed with the personnel involved to prevent recurrence. Occasional equipment breakdowns and power outages were unavoidable.

The overall sample recovery rate (99%) indicates that the appropriate procedures and equipment are in place to assure reliable program implementation.

E. Program Changes

There were no changes to the program in 2018.

IV. Results and Discussion

A. Aquatic Environment

1. Surface Water

Samples were taken weekly from a continuous sampler at two locations (J1-2 and Q9-1) and weekly grab samples from one location (A3-2). Weekly samples were composited on a monthly schedule. Of these locations only J1-2 located downstream could be affected by TMINS' effluent releases. The following analyses were performed:

Tritium

Monthly samples from J1-2 and Q9-1 were analyzed for tritium activity (Table C-1.1, Appendix C). Positive tritium activity was detected in 5 of 12 samples at location J1-2, which is located immediately downstream of the TMINS effluent outfall. The concentrations ranged from 348 to 1,440 pCi/L. The increased tritium concentrations detected were a result of TMINS releasing radwaste treatment system effluent water under permitted discharges in accordance with NRC regulations. The indicator surface water sample is taken just downstream of the liquid discharge outfall where mixing of liquid effluents with the river water is incomplete. More complete mixing is not achieved until liquid effluents pass over the York Haven Dam. This water is normally not consumed by humans. The concentrations detected were well below any regulatory limits. (Figures C-1 and C-2, Appendix C)

### Iodine

Monthly samples were taken from location A3-2. This is a control or background station sampled because known medical discharges of radiopharmaceuticals occur into the surface water upstream of TMI from a nearby hospital. Monthly samples were taken from A3-2 and analyzed for I-131. (Table C–I.2, Appendix C). I-131 activity was not detected in any samples.

### Gamma Spectrometry

Locations J1-2 and Q9-1 were analyzed for gamma-emitting nuclides (Table C–I.3, Appendix C). All nuclides were less than the MDC.

## 2. Drinking Water

Monthly samples were collected from continuous water samplers at three locations (G15-2, G15-3 and Q9-1). Two locations (G15-2 and G15-3) could be affected by TMINS effluent releases. The following analyses were performed:

### Gross Beta

Monthly samples from all locations were analyzed for concentrations of gross beta (Tables C–II.1, Appendix C). Gross beta activity was detected in 23 of 36 samples. The concentrations ranged from 2.1 to 5.2 pCi/L. Concentrations detected were consistent with those detected in previous years. (Figure C–3, Appendix C)

### Iodine

Monthly samples from all locations were analyzed for concentrations of I-131. I-131 activity was not detected in any samples. (Table C–II.2, Appendix C)

### Tritium

Monthly samples from all locations were analyzed for tritium activity (Table C–II.3, Appendix C). Tritium was not detected any of the 36 samples. (Figures C–4, Appendix C)

### Gamma Spectrometry

Samples from all locations were analyzed for gamma-emitting nuclides. All nuclides were less than the MDC. (Table C–II.4,

## Appendix C)

### 3. Effluent Water

Monthly samples were collected from a continuous water sampler at one location (K1-1). The following analyses were performed:

#### Gross Beta

Monthly samples from location K1-1 were analyzed for concentrations of gross beta (Tables C–III.1, Appendix C). Gross beta was detected in 12 of 12 samples. The concentrations ranged from 2.0 to 6.8 pCi/L. Concentrations detected were consistent with those detected in previous years.

#### Iodine-131

Monthly samples from location K1-1 were analyzed for concentrations of I-131 (Tables C–III.1, Appendix C). I-131 was not detected in any of the samples.

#### Tritium

Monthly samples from location K1-1 were analyzed for tritium activity (Table C–III.1, Appendix C). Tritium activity was detected in 5 of 12 samples. The concentrations ranged from 203 to 26,700 pCi/L. The elevated results were a result of TMI releasing radwaste treatment system effluent water under permitted discharges in accordance with NRC regulations. These results were from the liquid discharge mixing basin. The concentrations detected agree with those obtained from the TMINS Effluent Monitoring Program. (Figure C-4, Appendix C)

#### Strontium

Semiannual composite samples from location K1-1 were analyzed for Sr-89 and Sr-90 (Table C–III.1, Appendix C). No strontium activity was detected. The highest MDC was calculated at <4.0 pCi/L for Sr-89 and at <0.8 pCi/L for Sr-90.

#### Gamma Spectrometry

Samples from location K1-1 were analyzed for gamma-emitting nuclides (Table C–III.2, Appendix C). All nuclides were less than the MDC.

4. Storm Water

Storm water results are included in the Annual Radiological Groundwater Protection Program (ARGPPR), Appendix F.

5. Ground Water

Groundwater results are included in the Annual Radiological Groundwater Protection Program (ARGPPR), Appendix F.

6. Fish

Fish samples comprised of bottom feeders and predators were collected at two locations (IND and BKG) semiannually. Location IND could be affected by TMINS' effluent releases. The following analyses were performed:

Strontium

The edible portions of fish samples from both locations were analyzed for Sr-90 (Table C-IV.1, Appendix C). No strontium activity was detected. The highest MDC was calculated at <4.3 pCi/kg wet for Sr-90.

Gamma Spectrometry

The edible portions of fish samples from both locations were analyzed for gamma-emitting nuclides (Table C-IV.2, Appendix C). Naturally-occurring K-40 was found in all fish samples and ranged from 2,405 to 3,841 pCi/kg wet and was consistent with levels detected in previous years. No fission or activation products were detected.

7. Sediment

Aquatic sediment samples were collected at three locations (A1-3, J2-1 and K1-3) semiannually. Of these locations two (J2-1 and K1-3) could be affected by TMINS' effluent releases. The following analysis was performed:

Gamma Spectrometry

Sediment samples from all locations were analyzed for gamma-emitting nuclides (Table C-V.1, Appendix C). Potassium-40 was found in all sediment samples and ranged from 7,201 to 19,640 pCi/kg dry. No other fission or activation products were detected.

Cs-137 is occasionally found in sediment at very low levels (just above LLD) and is not distinguishable from background levels. (Figure C-5, Appendix C)

B. Atmospheric Environment

1. Airborne Particulates

a. Air Particulates

Continuous air particulate samples were collected from seven locations on a weekly basis. Six locations (A3-1, E1-2, F1-3, G2-1, H3-1 and M2-1) were indicator stations located in the highest D/Q sectors and the nearest communities to TMI. One sample (Q15-1) represents the control location at a remote distance from TMINS. The following analyses were performed:

Gross Beta

Weekly samples were analyzed for concentrations of beta emitters (Table C-VI.1 and C-VI.2, Appendix C). Detectable gross beta activity was observed at all locations. Comparison of results aid in determining the effects, if any, resulting from the operation of TMINS. The results from the closest to the site boundary locations (Group I) ranged from 5 to 28E-3 pCi/m<sup>3</sup> with a mean of 13E-3 pCi/m<sup>3</sup>. The results from the intermediate offsite locations (Group II) ranged from 5 to 29E-3 pCi/m<sup>3</sup> with a mean of 13E-3 pCi/m<sup>3</sup>. The results from the Control location (Group III) ranged from 6 to 26E-3 pCi/m<sup>3</sup> with a mean of 14E-3 pCi/m<sup>3</sup>. Comparison of the 2018 air particulate data with previous years' data indicate no effects from the operation of TMINS (Figure C-6, Appendix C). In addition, a comparison of the weekly mean values for 2018 indicate no notable differences between indicator and control stations. (Figure C-7, Appendix C)

Gamma Spectrometry

Weekly samples were composited quarterly and analyzed for gamma-emitting nuclides (Table C-VI.3, Appendix C). Naturally-occurring Be-7 due to cosmic ray activity was detected in 24 of 28 samples. These concentrations ranged from 47 to 140E-3 pCi/m<sup>3</sup>. All other nuclides were less than MDC.

b. Airborne Iodine

Continuous air samples were collected from seven (A3-1, E1-2, F1-3, G2-1, H3-1, M2-1 and Q15-1) locations and analyzed weekly for I-131 (Table C-VII.1, Appendix C). All results were less than the MDC for I-131.

2. Terrestrial

a. Milk

Samples were collected from five locations (K15-3, E2-2, F4-1 G2-1 and P4-1) biweekly March through November and monthly December through February. The following analyses were performed:

Iodine-131

Milk samples from all locations were analyzed for concentrations of I-131 (Table C-VIII.1, Appendix C). All results were less than the MDC.

Strontium

Milk samples from all locations were composited quarterly and analyzed for Sr-89 and Sr-90 (Table C-VIII.2, Appendix C). No Sr-89 activity was detected. Sr-90 activity was detected in 1 sample with a concentration of 1.6 pCi/L. The results are consistent with those detected in the pre-operational years (Figure C-8, Appendix C).

Gamma Spectrometry

Milk samples from all locations were analyzed for concentrations of gamma-emitting nuclides. (Table C-VIII.3, Appendix C).

Naturally-occurring K-40 activity was found in all samples. The concentrations ranged from 834 to 1,535 pCi/L. All other nuclides were less than the MDC.

b. Food Products

Food products were collected monthly at three locations (B10-2, E1-2 and H1-2), in lieu of milk sampling, and annually from the four food product groups at two locations (B10-2 and E1-2). B10-2 was the control location for both



annual and monthly sampling. The following analyses were performed:

### Strontium

Thirty-three food product samples were analyzed for concentrations of Sr-90 (Table C-IX.1, Appendix C). Sr-90 activity was detected in 20 of the 33 samples. The concentrations ranged from 1.2 to 38.0 pCi/kg wet.

### Gamma Spectrometry

Each food product sample was analyzed for concentrations of gamma-emitting nuclides (Table C-IX.1, Appendix C). Naturally-occurring Be-7 due to cosmic ray activity was detected in 26 of 33 samples. These concentrations ranged from 297 to 5,490 pCi/kg. Naturally-occurring K-40 activity was found in all samples. The concentrations ranged from 1,946 to 7,286 pCi/kg. All other nuclides were less than the MDC.

## C. Ambient Gamma Radiation

Ambient gamma radiation levels were measured utilizing Optically Stimulated Luminescence Dosimeter (OSLD). Ninety OSLD locations were established around the site. Results of OSLD measurements are listed in Tables C-X.1 to C-X.3, Appendix C

All of the OSLD measurements were below 31 mR/quarter, with a range of 9.1 to 30.4 mR/standard quarter. A comparison of the Site Boundary and Indicator data to the Control Location data, indicate that the ambient gamma radiation levels from the Control Locations D15-1, F25-1, G10-1, G15-1, H15-1, J15-1, K15-1, L15-1, N15-2, Q15-1 and R15-1 averaged higher than indicator stations. Locations D15-1, F25-1, G10-1, G15-1, H15-1, J15-1, K15-1, L15-1, N15-2, Q15-1 and R15-1 have a historical high bias, and this bias is most likely due to radon and other naturally-occurring nuclides, e.g. K-40, emanating from the ground.

## D. Land Use Survey

A Land Use Survey conducted in the September - October 2018 growing season around the Three Mile Island Nuclear Station (TMINS) was performed by Exelon Industrial Services (EIS) for Exelon to comply with Sections 8.2 of the Plant's Offsite Dose Calculation Manual (ODCM). The purpose of the survey was to document the nearest resident, milk-producing animal and garden of greater than 500 ft<sup>2</sup> in each of the sixteen

22½ degree sectors around the site. The results of these surveys are summarized below:

| Distance in Miles from the TMINS Reactor Buildings |                 |              |                 |
|--|-----------------|--------------|-----------------|
| Sector   | Residence Miles | Garden Miles | Milk Farm Miles |
| A N  | 1.0             | 1.9          | 2.1             |
| B NNE  | 0.8             | 1.2          | -               |
| C NE   | 0.5             | 1.1          | 4.2             |
| D ENE  | 0.5             | 0.5          | 4.5             |
| E E  | 0.4             | 0.5          | 1.1             |
| F ESE  | 1.1             | 1.2          | 3.2             |
| G SE   | 0.7             | 1.6          | 1.4             |
| H SSE  | 0.7             | 0.8          | -               |
| J S  | 2.2             | 2.5          | -               |
| K SSW  | 0.6             | 1.6          | 4.9, 14.4       |
| L SW   | 0.5             | 1.7          | -               |
| M WSW  | 0.5             | 1.3          | -               |
| N W  | 0.7             | 1.3          | -               |
| P WNW  | 0.4             | 1.7          | 3.7             |
| Q NW   | 0.4             | 1.2          | -               |
| R NNW  | 1.1             | 2.4          | -               |

E. Radiological Impact of TMINS Operations

An assessment of potential radiological impact indicated that radiation doses to the public from 2018 operations at TMINS were well below all applicable regulatory limits and were significantly less than doses received from natural sources of radiation. The 2018 whole body dose potentially received by an assumed maximum exposed individual from TMI-1 and TMI-2 liquid and airborne effluents was conservatively calculated to be 0.12 mrem. This dose is equivalent to 0.06% of the dose that an individual living in the TMI area receives each year from natural background radiation.

1. Determination of Radiation Doses to the Public

Dose assessments can be performed by using either effluent data and an environmental transport model or environmental sample data. To the extent possible, doses to the public are based on the direct measurement of dose rates from external sources and the measurement of radionuclide concentrations in environmental media which may contribute to an internal dose of radiation. Optically Stimulated Luminescent Dosimetry (OSLDs) positioned in the

environment around TMINS provide measurements to determine external radiation doses to humans. Samples of air, water and food products are used to determine internal doses.

The quantity of radioactive materials released during normal operations are typically too small to be measured once distributed in the offsite environment. Therefore, the potential offsite doses are more effectively calculated for TMINS operations using a computerized model that predicts concentrations of radioactive materials in the environment and subsequent radiation doses based on measured effluents.

Doses are calculated using a model that incorporates the guidelines and methodology set forth by the USNRC in Regulatory Guide 1.109 and NUREG 0133. Due to the conservative assumptions that are used in the model, the calculated doses are generally higher than the doses based on actual environmental sample concentrations.

Therefore, the model predicts doses that are higher than actual doses received by people. The type and amount of radioactivity released from TMINS is calculated using measurements from effluent sample analyses.

Airborne releases are diluted and carried away from the site by atmospheric diffusion, which continuously acts to disperse radioactivity. Variables that affect atmospheric dispersion include wind speed, temperature at different elevations, terrain, and shift in wind direction. A weather station on the north end of TMI is linked to a data logger that records the meteorological data.

Computer models also are used to predict the downstream dilution and travel times for liquid releases into the Susquehanna River. Actual monthly Susquehanna River flows are obtained from the USGS Stream gauging station 01570500 located at Harrisburg, PA.

The human exposure pathways also are included in the model and are depicted in Figure 1. The exposure pathways that are considered for the discharge of TMINS liquid effluents are consumption of drinking water and fish. The exposure pathways considered for the discharge of TMINS airborne effluents are plume exposure, inhalation, cow milk consumption, fruit and vegetable consumption, and meat consumption.

When determining the dose to humans, it is necessary to consider all applicable pathways and all exposed tissues, summing the dose from each to provide the total dose for each organ as well as the

whole body from a given radionuclide. Dose calculations involve determining the energy absorbed per unit mass in the various tissues. Thus, for radionuclides taken into the body, the metabolism of the radionuclide in the body must be known along with the physical characteristics of the nuclide such as energies, types of radiations emitted and half-life. The dose assessment model also contains dose conversion factors for the radionuclides for each of four age groups (adults, teenagers, children and infants) and eight organs (total body, thyroid, liver, skin, kidney, lung, bone and GI tract).

## 2. Result of Dose Calculations

The maximum hypothetical doses due to 2018 TMI-1 and TMI-2 liquid and airborne effluents are summarized in Tables 1 and 2. Table 1 compares the calculated maximum hypothetical individual doses to the USNRC 10 CFR 50 App. I guidelines. This table also compares the calculated doses (to an individual of the public) from effluents and direct radiation to USEPA 40 CFR 190 dose limits. Table 2 presents the maximum hypothetical whole body doses to an individual. As shown in Table 1, the doses calculated for 2018 operations at TMINS were well below the Federal dose limits (USEPA 40 CFR 190) and the guidelines of USNRC 10 CFR 50 App. I. This conclusion was supported by radionuclide concentrations detected in actual environmental samples.

Doses from natural background radiation provide a baseline for assessing the potential public health significance of radioactive effluents. Natural background radiation from cosmic, terrestrial and natural radionuclides in the human body (not including radon), averages about 81 mrem/yr (Ref. 5). Additionally, the average individual living in the United States receives an annual dose of about 2,760 mrem to the lung from natural radon gas. This lung dose is considered to be equivalent to a whole (or total) body dose of 230 mrem (Ref. 5). Therefore, the average person in the United States receives a whole body dose of about 311 mrem/yr from natural background radiation sources.

As shown on Table 2, the maximum hypothetical whole body dose received by an individual from 2018 TMI-1 and TMI-2 liquid and airborne effluents combined was conservatively calculated to be 0.12 mrem. This dose is equivalent to 0.06% percent of the dose that an individual living in the TMI area receives each year from natural background radiation (311 mrem).

The low doses calculated for 2018 TMINS operations were the result

of efforts to maintain releases "as low as reasonably achievable" (ALARA).

In conclusion, radioactive materials related to 2018 TMINS operations were detected in environmental samples, but the measured concentrations were low and consistent with measured effluents. The environmental sample results verified that the doses received by the public from TMINS effluents in 2018 were well below applicable dose limits and only a small fraction of the doses received from natural background radiation. Additionally, the results indicated that there was no permanent buildup of radioactive materials in the environment and no increase in background radiation levels.

Therefore, based on the results of the radiological environmental monitoring program (REMP) and the doses calculated from measured effluents, TMINS operations in 2018 did not have any adverse effects on the health of the public or on the environment.

**TABLE 1**

**Calculated Maximum Hypothetical Doses to an Individual  
from 2018 TMI-1 and TMI-2 Liquid and Airborne Effluents**

|   | <u>Maximum Hypothetical Doses To An Individual</u>             |  |
|---|--|--|
|   | <u>USNRC<br/>10 CFR 50 APP. I<br/>Guidelines<br/>(mrem/yr)</u> | <u>Calculated Dose<br/>(mrem/yr)<br/>TMI-1 TMI-2</u> |
| From Radionuclides<br>In Liquid Releases  | 3 total body, or<br>10 any organ                               | 1.42E-2 5.12E-4<br>1.76E-2 8.13E-4                   |
| From Radionuclides In<br>Airborne Releases (Noble Gases)                          | 5 total body, or<br>15 skin                                    | 3.14E-4 0*<br>4.61E-4 0*                             |
| From Radionuclides In Airborne<br>Releases (Iodines, Tritium and<br>Particulates) | 15 any organ   | 4.07E-1 1.28E-5                                      |

\*No noble gases were released from TMI-2.

|                 | <u>USEPA<br/>40 CFR 190<br/>Limits<br/>(mrem/yr)</u> | <u>Calculated Dose<br/>(mrem/yr)<br/>TMI-1 and TMI-2<br/>Combined**</u> |
|-----------------|--|---|
| Total from Site | 75 thyroid   | 0.11  |
|                 | 25 total body<br>or other organs                     | 0.43  |

\*\*This sums together TMI-1 and TMI-2 maximum doses regardless of age group for different pathways. The combined doses include those due to radioactive effluents and direct radiation from TMINS. The direct radiation dose is calculated from environmental dosimeter data. For this calculation, exposure is assumed to be equal to dose.

The direct radiation dose from 2018 TMINS operations was less than detectable based on calculations from ANSI/HI Standard N13.37.

**TABLE 2**

**Calculated Whole Body Doses to the Maximum Individual  
From 2018 TMI-1 and TMI-2 Liquid and Airborne Effluents**

|   | Calculated Maximum<br>Individual Whole Body<br>Dose (mrem/yr) |              |
|---|---|--------------|
|   | <u>TMI-1</u>  | <u>TMI-2</u> |
| From Radionuclides In Liquid Releases   | 1.42E-2   | 5.12E-4      |
| From Radionuclides in Airborne Releases<br>(Noble Gases)                          | 3.14E-4   | 0*           |
| From Radionuclides In Airborne<br>Releases (Iodines, Tritium and<br>Particulates) | 1.02E-1   | 1.28E-5      |

\*No noble gases were released from TMI-2.


Individual Whole Body Dose Due to TMI-1 and TMI-2 Operations:                      0.12 mrem/yr

Individual Whole Body Dose Due to Natural Background Radiation (1)                      311 mrem/yr

**(1) NCRP 160 – (2009)**

Figure 1

### Exposure Pathways For Radionuclides Routinely Released From TMINS



#### PREDOMINANT RADIONUCLIDES

**NOBLE GASES (Xe,Kr)**  
Plume exposure

**RADIOIODINES (I-131, I-133)**  
Inhalation and consumption of milk, water, fruits, and vegetables

**RADIOSTRONTIUMS (Sr-89, Sr-90)**  
Consumption of milk, meat, fruits, and vegetables

**ACTIVATION PRODUCTS (Co-60, Mn-54)**  
Shoreline exposure

**RADIOCESIUMS (Cs-134, Cs-137)**  
Shoreline exposure and consumption of milk, meat, fish, water, fruits, and vegetables

**TRITIUM (H-3)**  
Inhalation and consumption of water, milk, fruits, and vegetables



F. Errata Data

There is no errata data for 2018

G. Summary of Results – Inter-Laboratory Comparison Program

The primary and other secondary laboratories analyzed Performance Evaluation (PE) samples of air particulate, air iodine, milk, soil, vegetation and water matrices (Appendix E). The PE samples, supplied by Analytics Inc., Environmental Resource Associates (ERA) and DOE's MAPEP, were evaluated against the following pre-set acceptance criteria:

1. Analytics Evaluation Criteria

Analytics' evaluation report provides a ratio of TBE's result and Analytics' known value. Since flag values are not assigned by Analytics, TBE-ES evaluates the reported ratios based on internal QC requirements, which are based on the DOE MAPEP criteria.

2. ERA Evaluation Criteria

ERA's evaluation report provides an acceptance range for control and warning limits with associated flag values. ERA's acceptance limits are established per the USEPA, NELAC, state specific PT program requirements or ERA's SOP for the Generation of Performance Acceptance Limits, as applicable. The acceptance limits are either determined by a regression equation specific to each analyte or a fixed percentage limit promulgated under the appropriate regulatory document.

3. DOE Evaluation Criteria

MAPEP's evaluation report provides an acceptance range with associated flag values.

The MAPEP defines three levels of performance: Acceptable (flag = "A"), Acceptable with Warning (flag = "W"), and Not Acceptable (flag = "N"). Performance is considered acceptable when a mean result for the specified analyte is  $\pm 20\%$  of the reference value. Performance is acceptable with warning when a mean result falls in the range from  $\pm 20\%$  to  $\pm 30\%$  of the reference value (i.e.,  $20\% < \text{bias} < 30\%$ ). If the bias is greater than 30%, the results are deemed not acceptable.

*Note: The Department of Energy (DOE) Mixed Analyte Performance Evaluation Program (MAPEP) samples are created to*

*mimic conditions found at DOE sites which do not resemble typical environmental samples obtained at commercial nuclear power facilities.*

For the TBE laboratory, 164 out of 172 analyses performed met the specified acceptance criteria. Six analyses did not meet the specified acceptance criteria for the following reasons and were addressed through the TBE Corrective Action Program:

1. TBE was unable to report the February 2018 DOE MAPEP vegetation Sr-90 result due to QC failure and limited sample amount. (NCR 18-09)
2. The Analytics September 2018 milk Fe-59 result was evaluated as *Not Acceptable* (Ratio of TBE to known result at 133%). The reported value was  $158 \pm 17.6$  pCi/L and the known value was  $119 \pm 19.9$  pCi/L. No cause for the failure could be determined. TBE has passed 24 of the previous 27 milk cross-check results since 2012. This sample was run in duplicate on a different detector with comparable results ( $162 \pm 16$  pCi/L). *NOTE: TBE's 4<sup>th</sup> Qtr result passed at 105%* (NCR 18-20)
3. The Analytics September milk I-131 result was evaluated as *Not Acceptable* (Ratio of TBE to known result at 143%). Due to a personnel change in the gamma prep lab, the sample was not prepped/counted in a timely manner such as to accommodate the I-131 8-day half-life. Analysts have been made aware of the urgency for this analysis and it will be monitored more closely by QA. *NOTE: TBE's 4<sup>th</sup> Qtr result passed at 101%* (NCR 18-24)
4. The Analytics September soil Cr-51 result was evaluated as *Not Acceptable* (Ratio of TBE to known result at 131%). As with #3 above, the sample was not prepped/counted in a timely manner such as to accommodate the Cr-51 27-day half-life. The same corrective action applies here as in #3. (NCR 18-21)
5. The MAPEP November vegetation Sr-90 result of 0.338 Bq/sample was evaluated as *Not Acceptable* (Lower acceptable range was 0.554 Bq/sample). It appears that there has been incomplete dissolution of Sr-90 due to the composition of the MAPEP vegetation "matrix". To resolve this issue, the TBE-2018 procedure has been modified to add H<sub>2</sub>O<sub>2</sub> to assist in breaking down the organic material that comprises this "matrix". This corrective action will be monitored closely by QA. (NCR 18-25).

6. The ERA November 2018 water Sr-90 sample was evaluated as *Not Acceptable*. TBE's initial reported result of 36.8 pCi/L exceeded the upper acceptance range (22.9 – 36.4 pCi/L). After reviewing the data for this sample, it was discovered that there was a typographical error at the time the results were entered at the ERA website. The correct result in LIMS of 36.2 should have been submitted instead. This result is within ERA's acceptance limits. In addition to the typo error, ERA's very stringent upper acceptance limit of 116% is not a reflection of TBE's ability to successfully perform this analysis. (NCR 18-23)

For the EIS laboratory, 63 of 63 analyses met the specified acceptance criteria.

For the GEL laboratory, 545 of 552 met the specified acceptance criteria. Seven analyses did not meet the specified acceptance criteria. Of the 7, only 2 are analyses were performed for TMI during 2018 (vegetation sample for Co-60 and water sample for Fe-55). All failures were addressed through GEL's Corrective Action Program and the pertinent failures are described below:

1. The May ERA MRAD vegetation Co-60 result of 672 pCi/kg was higher than the acceptable upper limit (385 – 642 pCi/kg). The data was reviewed and no anomalies noted. The duplicate result of the original analysis met the acceptance criteria. The lab analyzed a separate aliquot of the sample and while the Co-60 was within limits, the result in general demonstrated a high bias.
2. The November 2018 ERA MRAD water Fe-55 result of 2610 pCi/L was higher than the acceptable upper limit (928 – 2300 pCi/L). The data was reviewed and no errors were noted. The lab analyzed a separate aliquot of the sample, which met the replication criteria within the analysis batch. All other QC criteria was met. Due to the high bias being nearly twice the reference value, it is suspected that the laboratory recorded an incorrect aliquot during the analysis process. The typical aliquot for this PT analysis is 20 mL and an aliquot of 10 mL was recorded as the aliquot used. A reanalysis was performed with results in the acceptable range.

The Inter-Laboratory Comparison Program provides evidence of "in control" counting systems and methods, and that the laboratories are producing accurate and reliable data. Interlaboratory Comparison results may be found in Appendix E.

## V. References

1. Three Mile Island Nuclear Station, Unit 1, Technical Specifications, DPR 50.
2. Three Mile Island Nuclear Station, Unit 2, PDMS Technical Specifications, DPR 73.
3. Radiation Management Corporation. "Three Mile Island Nuclear Station, Preoperational Radiological Environmental Monitoring Program, January 1, 1974 – June 5, 1974." RMC-TR-75-17, January 1975.
4. Exelon. "Three Mile Island Nuclear Station Offsite Dose Calculation Manual (ODCM)."
5. National Council of Radiation Protection and Measurements Report No. 160. "Ionizing Radiation Exposure of the Population of the United States." 2009.

Intentionally left blank

## **APPENDIX A**

# **RADIOLOGICAL ENVIRONMENTAL MONITORING REPORT SUMMARY**

Intentionally left blank

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR  
THE THREE MILE ISLAND NUCLEAR STATION, 2018**

| NAME OF FACILITY: THREE MILE ISLAND NUCLEAR STATION |                             | DOCKET NUMBER: 50-289 & 50-320 |       | REPORTING PERIOD: 2018                |                            |  |   |   |
|---|-----------------------------|--------------------------------|-------|---------------------------------------|----------------------------|--|---|---|
| LOCATION OF FACILITY: MIDDLETOWN COUNTY, PA         |                             | INDICATOR LOCATIONS            |       | LOCATION WITH HIGHEST ANNUAL MEAN (M) |                            | NUMBER OF NONROUTINE REPORTED MEASUREMENTS |   |   |
| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT)     | TYPES OF ANALYSIS PERFORMED | MEAN (M) (F)                   | RANGE | MEAN (M) (F)                          | RANGE                      |  |   |   |
| SURFACE WATER<br>(PC/LITER)                         | H-3                         | 24                             | 2000  | 1047<br>(5/12)<br>(348/1440)          | <LLD                       | 1047<br>(5/12)<br>(348/1440)               | 0 |   |
|   | I-131                       | 12                             | 1     | NA                                    | <LLD                       | -  | 0 |   |
|   | GAMMA                       |                                | 24    | 15                                    | <LLD                       | <LLD                                       | - | 0 |
|   |                             | MN-54                          |       | 15                                    | <LLD                       | <LLD                                       | - | 0 |
|   |                             | CO-58                          |       | 30                                    | <LLD                       | <LLD                                       | - | 0 |
|   |                             | FE-59                          |       | 15                                    | <LLD                       | <LLD                                       | - | 0 |
|   |                             | CO-60                          |       | 30                                    | <LLD                       | <LLD                                       | - | 0 |
|   |                             | ZN-65                          |       | 15                                    | <LLD                       | <LLD                                       | - | 0 |
|   |                             | NB-95                          |       | 30                                    | <LLD                       | <LLD                                       | - | 0 |
|   |                             | ZR-95                          |       | 15                                    | <LLD                       | <LLD                                       | - | 0 |
|   |                             | CS-134                         |       | 18                                    | <LLD                       | <LLD                                       | - | 0 |
|   |                             | CS-137                         |       | 60                                    | <LLD                       | <LLD                                       | - | 0 |
|   | BA-140                      |                                | 15    | <LLD                                  | <LLD                       | -  | 0 |   |
| LA-140  |                             |                                |       |                                       |                            |  |   |   |
| DRINKING WATER<br>(PC/LITER)                        | GR-B                        | 36                             | 4     | 3.3<br>(16/24)<br>(2.1/5.2)           | 2.8<br>(7/12)<br>(2.1/4.2) | 3.7<br>(10/12)<br>(2.6/5.2)                | 0 |   |
|   | I-131                       | 36                             | 1     | <LLD                                  | <LLD                       | -  | 0 |   |
|   | H-3                         | 36                             | 2000  | <LLD                                  | <LLD                       | -  | 0 |   |

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.



**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR  
THE THREE MILE ISLAND NUCLEAR STATION, 2018**

| NAME OF FACILITY: THREE MILE ISLAND NUCLEAR STATION |                             | DOCKET NUMBER: 50-289 & 50-320 |   |  |                                     |  |   |  |
|---|-----------------------------|--------------------------------|---|--|-------------------------------------|--|---|--|
| LOCATION OF FACILITY: MIDDLETOWN COUNTY, PA         |                             | REPORTING PERIOD: 2018         |   |  |                                     |  |   |  |
| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT)     | TYPES OF ANALYSIS PERFORMED | NUMBER OF ANALYSIS PERFORMED   | REQUIRED LOWER LIMIT OF DETECTION (LLD) | INDICATOR LOCATIONS MEAN (M) (F) RANGE | CONTROL LOCATION MEAN (M) (F) RANGE | LOCATION WITH HIGHEST ANNUAL MEAN (M) MEAN (M) (F) RANGE | STATION # NAME DISTANCE AND DIRECTION                   | NUMBER OF NONROUTINE REPORTED MEASUREMENTS |
| <b>DRINKING WATER (PC/LITER)</b>                    | <b>GAMMA</b>                | 36                             |   |  |                                     |  |   |  |
|   | MN-54                       |                                | 15                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | CO-58                       |                                | 15                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | FE-59                       |                                | 30                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | CO-60                       |                                | 15                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | ZN-65                       |                                | 30                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | NB-95                       |                                | 15                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | ZR-95                       |                                | 30                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | CS-134                      |                                | 15                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | CS-137                      |                                | 18                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | BA-140                      |                                | 60                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | LA-140                      |                                | 15                                      | <LLD                                   | <LLD                                | -  |   | 0  |
| <b>EFFLUENT WATER (PC/LITER)</b>                    | <b>GR-B</b>                 | 12                             | 4                                       | 4.6<br>(12/12)<br>(2.0/6.8)            | NA                                  | 4.6<br>(12/12)<br>(2.0/6.8)                              | K1-1 INDICATOR<br>MAIN STATION LIQ. DISCHARGE<br>ONSITE | 0  |
|   | <b>I-131 (LOW LVL)</b>      | 12                             | 1                                       | <LLD                                   | NA                                  | -  |   | 0  |
|   | <b>H-3</b>                  | 12                             | 2000                                    | 19061<br>(6/13)<br>(203/26700)         | NA                                  | 19061<br>(6/13)<br>(203/26700)                           | K1-1 INDICATOR<br>MAIN STATION LIQ. DISCHARGE<br>ONSITE | 0  |
|   | <b>SR-89</b>                | 2                              | 5                                       | <LLD                                   | NA                                  | -  |   | 0  |
|   | <b>SR-90</b>                | 2                              | 2                                       | <LLD                                   | NA                                  | -  |   | 0  |

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR  
THE THREE MILE ISLAND NUCLEAR STATION, 2018**

| NAME OF FACILITY: THREE MILE ISLAND NUCLEAR STATION |                             | DOCKET NUMBER: 50-289 & 50-320 |   |  |                                     |  |   |  |
|---|-----------------------------|--------------------------------|---|--|-------------------------------------|--|---|--|
| LOCATION OF FACILITY: MIDDLETOWN COUNTY, PA         |                             | REPORTING PERIOD: 2018         |   |  |                                     |  |   |  |
| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT)     | TYPES OF ANALYSIS PERFORMED | NUMBER OF ANALYSIS PERFORMED   | REQUIRED LOWER LIMIT OF DETECTION (LLD) | INDICATOR LOCATIONS MEAN (M) (F) RANGE | CONTROL LOCATION MEAN (M) (F) RANGE | LOCATION WITH HIGHEST ANNUAL MEAN (M) MEAN (M) (F) RANGE | STATION # NAME DISTANCE AND DIRECTION                 | NUMBER OF NONROUTINE REPORTED MEASUREMENTS |
| <b>EFFLUENT WATER (PC/LITER)</b>                    | <b>GAMMA</b>                | 12                             |   |  |                                     |  |   |  |
|   |                             |                                | 15                                      | <LLD                                   | NA                                  | -  |   | 0  |
|   |                             |                                | 15                                      | <LLD                                   | NA                                  | -  |   | 0  |
|   |                             |                                | 30                                      | <LLD                                   | NA                                  | -  |   | 0  |
|   |                             |                                | 15                                      | <LLD                                   | NA                                  | -  |   | 0  |
|   |                             |                                | 30                                      | <LLD                                   | NA                                  | -  |   | 0  |
|   |                             |                                | 15                                      | <LLD                                   | NA                                  | -  |   | 0  |
|   |                             |                                | 30                                      | <LLD                                   | NA                                  | -  |   | 0  |
|   |                             |                                | 15                                      | <LLD                                   | NA                                  | -  |   | 0  |
|   |                             |                                | 18                                      | <LLD                                   | NA                                  | -  |   | 0  |
|   |                             |                                | 60                                      | <LLD                                   | NA                                  | -  |   | 0  |
|   |                             |                                | 15                                      | <LLD                                   | NA                                  | -  |   | 0  |
| <b>BOTTOM FEEDER (PC/KGWET)</b>                     | <b>SR-90</b>                | 4                              | 10                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | <b>GAMMA</b>                | 4                              |   |  |                                     |  |   |  |
|   |                             |                                | NA                                      | 3123 (2/2) (2405/3841)                 | 2950 (2/2) (2799/3101)              | 3123 (2/2) (2405/3841)                                   | INDB INDICATOR YORK HAVEN DAM DOWNSTREAM OF DISCHARGE | 0  |
|   |                             |                                | 130                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | 130                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | 260                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | 130                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | 260                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | 130                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | 150                                     | <LLD                                   | <LLD                                | -  |   | 0  |
| <b>PREDATOR (PC/KGWET)</b>                          | <b>SR-90</b>                | 4                              | 10                                      | <LLD                                   | <LLD                                | -  |   | 0  |

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR  
THE THREE MILE ISLAND NUCLEAR STATION, 2018**

| NAME OF FACILITY: THREE MILE ISLAND NUCLEAR STATION |                             | DOCKET NUMBER: 50-289 & 50-320 |   | REPORTING PERIOD: 2018                 |                                     |  |   |  |
|---|-----------------------------|--------------------------------|---|--|-------------------------------------|--|---|--|
| LOCATION OF FACILITY: MIDDLETOWN COUNTY, PA         |                             | REPORTING PERIOD:              |   | REPORTING PERIOD:                      |                                     |  |   |  |
| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT)     | TYPES OF ANALYSIS PERFORMED | NUMBER OF ANALYSIS PERFORMED   | REQUIRED LOWER LIMIT OF DETECTION (LLD) | INDICATOR LOCATIONS MEAN (M) (F) RANGE | CONTROL LOCATION MEAN (M) (F) RANGE | LOCATION WITH HIGHEST ANNUAL MEAN (M) MEAN (M) (F) RANGE | STATION # NAME DISTANCE AND DIRECTION             | NUMBER OF NONROUTINE REPORTED MEASUREMENTS |
| <b>PREDATOR (PC/KGWET)</b>                          | <b>GAMMA</b>                | 4                              |   |  |                                     |  |   |  |
|   | K-40                        |                                | NA                                      | 2827 (2/2) (2524/3129)                 | 3004 (2/2) (2970/3037)              | 3004 (2/2) (2970/3037)                                   | BKGP CONTROL CITY ISLAND UPSTREAM OF DISCHARGE    | 0  |
|   | MN-54                       |                                | 130                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   | CO-58                       |                                | 130                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   | FE-59                       |                                | 260                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   | CO-60                       |                                | 130                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   | ZN-65                       |                                | 260                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   | CS-134                      |                                | 130                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   | CS-137                      |                                | 150                                     | <LLD                                   | <LLD                                | -  |   | 0  |
| <b>SEDIMENT (PC/KG DRY)</b>                         | <b>GAMMA</b>                | 7                              |   |  |                                     |  |   |  |
|   | K-40                        |                                | NA                                      | 14180 (5/5) (7201/19640)               | 12227 (2/2) (9874/14580)            | 18675 (2/2) (17710/19640)                                | J2-1 INDICATOR YORK HAVEN DAM 1.5 MILES S OF SITE | 0  |
|   | MN-54                       |                                | NA                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | CO-58                       |                                | NA                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | CO-60                       |                                | NA                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   | CS-134                      |                                | 150                                     | <LLD                                   | <LLD                                | -  |   | 0  |
|   | CS-137                      |                                | 180                                     | <LLD                                   | <LLD                                | -  |   | 0  |
| <b>AIR PARTICULATE (E-3 PC/CUMETER)</b>             | <b>GR-B</b>                 | 355                            | 10                                      | 13 (300/304) (5/29)                    | 14 (51/51) (6/26)                   | 14 (51/51) (6/26)  | Q15-1 CONTROL WEST FAIRVIEW 13.5 MILES NW OF SITE | 0  |

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR  
THE THREE MILE ISLAND NUCLEAR STATION, 2018**

| NAME OF FACILITY: THREE MILE ISLAND NUCLEAR STATION |                             | DOCKET NUMBER: 50-289 & 50-320 |   |  |                                     |  |   |  |
|---|-----------------------------|--------------------------------|---|--|-------------------------------------|--|---|--|
| LOCATION OF FACILITY: MIDDLETOWN COUNTY, PA         |                             | REPORTING PERIOD: 2018         |   |  |                                     |  |   |  |
| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT)     | TYPES OF ANALYSIS PERFORMED | NUMBER OF ANALYSIS PERFORMED   | REQUIRED LOWER LIMIT OF DETECTION (LLD) | INDICATOR LOCATIONS MEAN (M) (F) RANGE | CONTROL LOCATION MEAN (M) (F) RANGE | LOCATION WITH HIGHEST ANNUAL MEAN (M) MEAN (M) (F) RANGE | STATION # NAME DISTANCE AND DIRECTION                   | NUMBER OF NONROUTINE REPORTED MEASUREMENTS |
| <b>AIR PARTICULATE (E-3 PC/CUMETER)</b>             | <b>GAMMA</b>                | 28                             | NA                                      | 71 (20/24) (48/114) <LLD               | 78 (4/4) (47/140) <LLD              | 79 (3/4) (54/114) -                                      | A3-1 INDICATOR MIDDLETOWN 2.6 MILES N OF SITE           | 0  |
|   |                             |                                | NA                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | NA                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | NA                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | NA                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | NA                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | 50                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | 60                                      | <LLD                                   | <LLD                                | -  |   | 0  |
| <b>AIR IODINE (E-3 PC/CUMETER)</b>                  | <b>GAMMA</b>                | 355                            | 70                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                |   |  |                                     |  |   |  |
| <b>MILK (PC/LITER)</b>                              | <b>I-131</b>                | 97                             | 1                                       | <LLD                                   | <LLD                                | -  |   | 0  |
|   | <b>SR-89</b>                | 18                             | 5                                       | <LLD                                   | <LLD                                | -  |   | 0  |
|   | <b>SR-90</b>                | 18                             | 2                                       | 1.6 (1/14)                             | <LLD                                | 1.6 (1/2)  | E2-2 INDICATOR NISSLEY FARM 1.1 MILES E OF SITE         | 0  |
|   | <b>GAMMA</b>                | 97                             | NA                                      | 1244 (74/74) (834/1535) <LLD           | 1251 (23/23) (1070/1410) <LLD       | 1296 (23/23) (834/1494) -                                | F4-1 INDICATOR TURNPIKE ROAD FARM 3.0 MILES ESE OF SITE | 0  |
|   |                             |                                | 15                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | 18                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | 60                                      | <LLD                                   | <LLD                                | -  |   | 0  |
|   |                             |                                | 15                                      | <LLD                                   | <LLD                                | -  |   | 0  |

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR  
THE THREE MILE ISLAND NUCLEAR STATION, 2018**

| NAME OF FACILITY: THREE MILE ISLAND NUCLEAR STATION |                             | DOCKET NUMBER: 50-289 & 50-320 |   |  |                                     |  |  |  |
|---|-----------------------------|--------------------------------|---|--|-------------------------------------|--|--|--|
| LOCATION OF FACILITY: MIDDLETOWN COUNTY, PA         |                             | REPORTING PERIOD: 2018         |   |  |                                     |  |  |  |
| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT)     | TYPES OF ANALYSIS PERFORMED | NUMBER OF ANALYSIS PERFORMED   | REQUIRED LOWER LIMIT OF DETECTION (LLD) | INDICATOR LOCATIONS MEAN (M) (F) RANGE | CONTROL LOCATION MEAN (M) (F) RANGE | LOCATION WITH HIGHEST ANNUAL MEAN (M) MEAN (M) (F) RANGE | STATION # NAME DISTANCE AND DIRECTION                            | NUMBER OF NONROUTINE REPORTED MEASUREMENTS |
| <b>VEGETATION (PC/KG WET)</b>                       | <b>SR-90</b>                | 33                             | 10                                      | 14.4<br>(12/21)<br>(1.2/34.5)          | 12.9<br>(8/12)<br>(4.8/38)          | 19.4<br>(8/9)<br>(2.5/34.5)                              | H1-2 INDICATOR<br>RED HILL MARKET<br>1.0 MILES SSE OF SITE       | 0<br>ALONG ROUTE 441                       |
|   | <b>GAMMA</b>                | 33                             | NA                                      | 1596<br>(17/21)<br>(297/5490)          | 1453<br>(9/12)<br>(362/3476)        | 2213<br>(9/9)<br>(716/5490)                              | H1-2 INDICATOR<br>RED HILL MARKET<br>1.0 MILES SSE OF SITE       | 0  |
|   |                             |                                | NA                                      | 3594<br>(21/21)<br>(1946/5615)         | 3927<br>(12/12)<br>(2032/7286)      | 3927<br>(12/12)<br>(2032/7286)                           | B10-2 CONTROL<br>MILTON HERSHEY SCHOOL<br>10.1 MILES NNE OF SITE | 0  |
|   |                             |                                | 60                                      | <LLD                                   | <LLD                                | -  |  | 0  |
|   | I-131                       |                                | 60                                      | <LLD                                   | <LLD                                | -  |  | 0  |
|   | CS-134                      |                                | 80                                      | <LLD                                   | <LLD                                | -  |  | 0  |
|   | CS-137                      |                                |   |  |                                     |  |  |  |
| <b>DIRECT RADIATION (MILLIREM/STD.MO.)</b>          | <b>OSLD - QUARTERLY</b>     | 360                            | NA                                      | 15.8<br>(316/316)<br>(9.1/30.4)        | 18<br>(44/44)<br>(13.2/27.3)        | 26.6<br>(4/4)<br>(23.9/30.4)                             | H8-1 INDICATOR<br>SAGINAW ROAD<br>7.4 MILES SSE OF SITE          | 0<br>STARVIEW                              |

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

## **APPENDIX B**

### **LOCATION DESIGNATION, DISTANCE & DIRECTION, AND SAMPLE COLLECTION & ANALYTICAL METHODS**

Intentionally left blank

TABLE B-1: Location Designation and Identification System for the Three Mile Island Nuclear Station

|                    |   |  |
|--------------------|---|--|
| <u>XY</u> <u>Z</u> | - | General code for identification of locations, where:   |
| <u>X</u>           | - | Angular Sector of Sampling Location. The compass is divided into 16 sectors of 22 1/2 degrees each with center at Three Mile Island's Units 1 and 2 off-gas vents. Sector A is centered due North, and others are alphabetical in a clockwise direction. |
| <u>Y</u>           | - | Radial Zone of Sampling Location in miles.   |
| <u>Z</u>           | - | Station's Numerical Designation within sector and zone, using 1, 2, 3... in each sector and zone.  |



**TABLE B-2: Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Three Mile Island Nuclear Station, 2018**

| <u>Sample Medium</u> | <u>Station Code</u> | <u>Map Number</u> | <u>Distance (miles)</u> | <u>Azimuth</u> | <u>Description</u>   |
|----------------------|---------------------|-------------------|-------------------------|----------------|--|
| AQS                  | A1-3                | 1                 | 0.6                     | 359°           | N of site off north tip of TMI in Susquehanna River                          |
| ID                   | A1-4                | 1                 | 0.3                     | 6°             | N of Reactor Building on W fence adjacent to North Weather Station, TMI      |
| AP, AI, ID           | A3-1                | 2                 | 2.7                     | 357°           | N of site at Mill Street Substation  |
| SW                   | A3-2                | 2                 | 2.7                     | 356°           | N of site at Swatara Creek, Middletown                                       |
| ID                   | A5-1                | 2                 | 4.4                     | 3°             | N of site on Vine Street Exit off Route 283                                  |
| ID                   | A9-3                | 3                 | 8.0                     | 2°             | N of site at Duke Street Pumping Station, Hummelstown                        |
| ID                   | B1-1                | 1                 | 0.6                     | 25°            | NNE of site on light pole in middle of North Bridge, TMI                     |
| ID                   | B1-2                | 1                 | 0.4                     | 24°            | NNE of Reactor Building on top of dike, TMI                                  |
| ID                   | B2-1                | 2                 | 1.9                     | 17°            | NNE of site on Sunset Dr. (off Hillsdale Rd.)                                |
| ID                   | B5-1                | 2                 | 4.9                     | 19°            | NNE of site at intersection of School House and Miller Roads                 |
| ID                   | B10-1               | 3                 | 9.2                     | 21°            | NNE of site at intersection of West Areba Avenue and Mill Street, Hershey    |
| FP                   | B10-2               | 3                 | 10                      | 31°            | NNE of site at Milton Hershey School, Hershey                                |
| ID                   | C1-1                | 1                 | 0.7                     | 37°            | NE of site along Route 441 N   |
| ID                   | C1-2                | 1                 | 0.3                     | 50°            | NE of Reactor Building on top of dike, TMI                                   |
| ID                   | C2-1                | 2                 | 1.5                     | 44°            | NE of site at Middletown Junction  |
| ID                   | C5-1                | 2                 | 4.7                     | 43°            | NE of site on Kennedy Lane   |
| ID                   | C8-1                | 3                 | 7.1                     | 48°            | NE of site at Schenk's Church on School House Road                           |
| AQF                  | Control             | -                 | -                       | -              | All locations where finfish are collected above Dock St. Dam, Harrisburg     |
| ID                   | D1-1                | 1                 | 0.2                     | 76°            | ENE of Reactor Building on top of dike, TMI                                  |
| ID                   | D1-2                | 1                 | 0.5                     | 67°            | ENE of site off Route 441 along lane between garden center and residence     |
| ID                   | D2-2                | 2                 | 1.6                     | 74°            | ENE of site along Hillsdale Rd. (S of Zion Rd.)                              |
| ID                   | D6-1                | 3                 | 5.2                     | 66°            | ENE of site off Beagle Road  |
| ID                   | D15-1               | 3                 | 10.8                    | 64°            | ENE of site along Route 241, Lawn  |
| AP, AI, ID, FP       | E1-2                | 1                 | 0.4                     | 97°            | E of site at TMI Visitor's Center  |
| ID                   | E1-4                | 1                 | 0.2                     | 97°            | E of Reactor Building on top of dike, TMI                                    |
| M                    | E2-2                | 2                 | 1.1                     | 96°            | E of site at farm on Pecks Road  |
| ID                   | E2-3                | 2                 | 2.0                     | 97°            | E of site along Hillsdale Rd. (N of Creek Rd.)                               |
| ID                   | E5-1                | 2                 | 4.7                     | 82°            | E of site at intersection of North Market Street (Route 230) and Zeager Road |
| ID                   | E7-1                | 3                 | 6.7                     | 88°            | E of site along Hummelstown Street, Elizabethtown                            |
| ID                   | F1-1                | 1                 | 0.5                     | 117°           | ESE of site near entrance to 500 kV Substation                               |
| ID                   | F1-2                | 1                 | 0.2                     | 112°           | ESE of Reactor Building on top of dike midway within ISWSF, TMI              |
| AP, AI               | F1-3                | 1                 | 0.6                     | 112°           | ESE of site in 500 kV Substation   |
| ID                   | F1-4                | 1                 | 0.2                     | 122°           | ESE of Reactor Building on top of dike, TMI                                  |
| ID                   | F2-1                | 2                 | 1.3                     | 119°           | ESE of site along Engle Road   |
| M                    | F4-1                | 2                 | 3.2                     | 104°           | ESE of site at farm on Turnpike Road   |
| ID                   | F5-1                | 2                 | 4.7                     | 109°           | ESE of site along Amosite Road   |
| ID                   | F10-1               | 3                 | 9.4                     | 112°           | ESE of site along Donegal Springs Road, Donegal Springs                      |
| ID                   | F25-1               | 3                 | 22                      | 106°           | ESE of site at intersection of Steel Way and Loop Roads, Lancaster           |
| ID                   | G1-2                | 1                 | 0.7                     | 145°           | SE of site along Route 441 S   |
| ID                   | G1-3                | 1                 | 0.2                     | 130°           | SE of Reactor Building on top of dike, TMI                                   |
| ID                   | G1-5                | 1                 | 0.3                     | 143°           | SE of Reactor Building on top of dike, TMI                                   |
| ID                   | G1-6                | 1                 | 0.3                     | 139°           | SE of Reactor Building on top of dike, TMI                                   |
| AI, AP, M            | G2-1                | 2                 | 1.4                     | 126°           | SE of site at farm on Becker Road  |
| ID                   | G2-4                | 2                 | 1.7                     | 138°           | SE of site on Becker Road  |
| ID                   | G5-1                | 2                 | 4.8                     | 131°           | SE of site at intersection of Bainbridge and Risser Roads                    |
| ID                   | G10-1               | 3                 | 9.7                     | 128°           | SE of site at farm along Engles Tollgate Road, Marietta                      |
| ID                   | G15-1               | 3                 | 14.4                    | 126°           | SE of site at Columbia Water Treatment Plant                                 |
| DW                   | G15-2               | 3                 | 13.3                    | 129°           | SE of site at Wrightsville Water Treatment Plant                             |
| DW                   | G15-3               | 3                 | 15.7                    | 124°           | SE of site at Lancaster Water Treatment Plant                                |

**TABLE B-2: Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Three Mile Island Nuclear Station, 2018**

| <u>Sample Medium</u> | <u>Station Code</u> | <u>Map Number</u> | <u>Distance (miles)</u> | <u>Azimuth</u> | <u>Description</u>   |
|----------------------|---------------------|-------------------|-------------------------|----------------|--|
| ID                   | H1-1                | 1                 | 0.5                     | 167°           | SSE of site, TMI   |
| FP                   | H1-2                | 1                 | 1.0                     | 151°           | SSE of site along Route 441, Red Hill Market   |
| AP, AI, ID           | H3-1                | 2                 | 2.2                     | 160°           | SSE of site in Falmouth-Collins Substation   |
| ID                   | H5-1                | 2                 | 4.1                     | 158°           | SSE of site by Guard Shack at Brunner Island Steam Electric Station                        |
| ID                   | H8-1                | 3                 | 7.4                     | 163°           | SSE of site along Saginaw Road, Starview   |
| ID                   | H15-1               | 3                 | 13.2                    | 157°           | SSE of site at intersection of Orchard and Stonewood Roads, Wilshire Hills                 |
| AQF                  | Indicator           | -                 | -                       | -              | All locations where finfish are collected downstream of the TMINS liquid discharge outfall |
| ID                   | J1-1                | 1                 | 0.8                     | 176°           | S of site, TMI   |
| SW                   | J1-2                | 1                 | 0.5                     | 188°           | S of site downstream of the TMINS liquid discharge outfall in Susquehanna River            |
| ID                   | J1-3                | 1                 | 0.3                     | 189°           | S of Reactor Building just S of SOB, TMI   |
| AQS                  | J2-1                | 2                 | 1.4                     | 179°           | S of site in Susquehanna River just upstream of the York Haven Dam                         |
| ID                   | J3-1                | 2                 | 2.7                     | 179°           | S of site at York Haven/Cly  |
| ID                   | J5-1                | 2                 | 4.9                     | 181°           | S of site along Canal Road, Conewago Heights   |
| ID                   | J7-1                | 3                 | 6.5                     | 176°           | S of site off of Maple Street, Manchester  |
| ID                   | J15-1               | 3                 | 12.6                    | 183°           | S of site in Met-Ed York Load Dispatch Station   |
| EW                   | K1-1                | 1                 | 0.2                     | 211°           | On site at RML-7 Main Station Discharge Building   |
| AQS                  | K1-3                | 1                 | 0.2                     | 213°           | SSW of site downstream of the TMINS liquid discharge outfall in the Susquehanna River      |
| ID                   | K1-4                | 1                 | 0.2                     | 209°           | SSW of Reactor Building on top of dike behind Warehouse 2, TMI                             |
| ID                   | K2-1                | 2                 | 1.2                     | 200°           | SSW of site on S Shelley Island  |
| ID                   | K3-1                | 2                 | 2.0                     | 206°           | SSW of site along Rt. 262, N of Cly  |
| ID                   | K5-1                | 2                 | 4.9                     | 202°           | SSW of site along Conewago Creek Road, Strinestown   |
| ID                   | K8-1                | 3                 | 7.5                     | 196°           | SSW of site at intersection of Coppenhaffer Road and Route 295, Zions View                 |
| ID                   | K15-1               | 3                 | 12.8                    | 203°           | SSW of site behind McDonald's and next to child care center, Weiglestown                   |
| M                    | K15-3               | 3                 | 14.4                    | 205°           | SSW of site at farm along S Salem Church Rd, Dover   |
| ID                   | L1-1                | 1                 | 0.1                     | 236°           | SW of site on top of dike W of Mech. Draft Cooling Tower, TMI                              |
| ID                   | L1-2                | 1                 | 0.5                     | 221°           | SW of site on Beech Island   |
| ID                   | L2-1                | 2                 | 1.8                     | 224°           | SW of site along Route 262   |
| ID                   | L5-1                | 2                 | 4.1                     | 228°           | SW of site at intersection of Stevens and Wilson Roads                                     |
| ID                   | L8-1                | 3                 | 8.0                     | 225°           | SW of site along Rohlers Church Rd., Andersontown  |
| ID                   | L15-1               | 3                 | 11.8                    | 226°           | SW of site on W side of Route 74, rear of church, Mt. Royal                                |
| ID                   | M1-1                | 1                 | 0.1                     | 249°           | WSW of Reactor Building on SE corner of U-2 Screenhouse fence, TMI                         |
| ID                   | M1-2                | 1                 | 0.4                     | 252°           | WSW of site on E side of Shelley Island, Lot #157  |
| AP, AI, ID           | M2-1                | 2                 | 1.3                     | 256°           | WSW of site along Route 262 and adjacent to Fishing Creek, Goldsboro                       |
| ID                   | M5-1                | 2                 | 4.3                     | 249°           | WSW of site at intersection of Lewisberry and Roxberry Roads, Newberrytown                 |
| ID                   | M9-1                | 3                 | 8.7                     | 243°           | WSW of site along Alpine Road, Maytown   |
| ID                   | N1-1                | 1                 | 0.7                     | 274°           | W of site on W side of Shelley Island, between lots #13 and #14                            |
| ID                   | N1-3                | 1                 | 0.1                     | 274°           | W of Reactor Building on fence adjacent to Screenhouse entrance gate, TMI                  |
| ID                   | N2-1                | 2                 | 1.2                     | 261°           | W of site at Goldsboro Marina  |
| ID                   | N5-1                | 2                 | 4.9                     | 268°           | W of site off of Old York Road along Robin Hood Drive                                      |
| ID                   | N8-1                | 3                 | 7.7                     | 262°           | W of site along Route 382, 1/2 mile north of Lewisberry                                    |
| ID                   | N15-2               | 3                 | 10.4                    | 275°           | W of site at intersection of Lisburn Road and Main Street, Lisburn                         |
| ID                   | P1-1                | 1                 | 0.4                     | 303°           | WNW of site on Shelley Island  |

**TABLE B-2: Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Three Mile Island Nuclear Station, 2018**

| <u>Sample Medium</u> | <u>Station Code</u> | <u>Map Number</u> | <u>Distance (miles)</u> | <u>Azimuth</u> | <u>Description</u>  |
|----------------------|---------------------|-------------------|-------------------------|----------------|---|
| ID                   | P1-2                | 1                 | 0.1                     | 292°           | WNW of Reactor Building on fence N of Unit 1 Screenhouse, TMI             |
| ID                   | P2-1                | 2                 | 1.9                     | 283°           | WNW of site along Route 262   |
| M                    | P4-1                | 2                 | 3.6                     | 295°           | WNW of site at farm on Valley Road  |
| ID                   | P5-1                | 2                 | 5.0                     | 284°           | WNW of site at intersection of Valley Road (Route 262) and Beinhower Road |
| ID                   | P8-1                | 3                 | 7.9                     | 292°           | WNW of site along Evergreen Road, Reesers Summit                          |
| ID                   | Q1-1                | 1                 | 0.5                     | 317°           | NW of site on E side of Shelley Island                                    |
| ID                   | Q1-2                | 1                 | 0.2                     | 321°           | NW of Reactor Building on fence W of Warehouse 1, TMI                     |
| ID                   | Q2-1                | 2                 | 1.9                     | 310°           | NW of site along access road along river                                  |
| ID                   | Q5-1                | 2                 | 5.0                     | 317°           | NW of site along Lumber Street, Highspire                                 |
| SW, DW, ID           | Q9-1                | 3                 | 8.5                     | 310°           | NW of site at the Steelton Water Company                                  |
| AP, AI, ID           | Q15-1               | 3                 | 13.4                    | 309°           | NW of site behind West Fairview Fire Dept. Social Hall (abandoned)        |
| ID                   | R1-1                | 1                 | 0.2                     | 335°           | NNW of Reactor Building along W fence, TMI                                |
| ID                   | R1-2                | 1                 | 0.7                     | 334°           | NNW of site on central Henry Island                                       |
| ID                   | R3-1                | 2                 | 2.6                     | 341°           | NNW of site at Crawford Station, Middletown                               |
| ID                   | R5-1                | 2                 | 4.9                     | 339°           | NNW of site at intersection of Spring Garden Drive and Route 441          |
| ID                   | R9-1                | 3                 | 8.0                     | 341°           | NNW of site at intersection of Derry and 66th Streets, Rutherford Heights |
| ID                   | R15-1               | 3                 | 11.2                    | 332°           | NNW of site at intersection of Route 22 and Colonial Road, Colonial Park  |

#### IDENTIFICATION KEY

|   |                        |
|---|------------------------|
| ID = Immersion Dose (OSLD)                                      | EW = Effluent Water    |
| SW = Surface Water  | DW = Drinking Water    |
| AI = Air Iodine   | M = Milk (Cow)         |
| AP = Air Particulate  | AQF = Finfish          |
| FP = Food Products (Green Leafy Vegetation, Fruits, Vegetables) | AQS = Aquatic Sediment |

**TABLE B-3:**

**Radiological Environmental Monitoring Program – Summary of Sample Collection and Analytical Methods, Three Mile Island Nuclear Station, 2018**

| Sample Medium  | Analysis           | Sampling Method                                      | Collection Procedure Number   | Sample Size | Analytical Procedure Number   |
|----------------|--------------------|--|---|-------------|---|
| Surface Water  | Gamma Spectroscopy | Monthly composite from a continuous water compositor | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 2 gallon    | TBE, TBE-2007 Gamma-emitting radioisotope analysis<br>EIS, CY-ES-205, Rev. 001 Gamma Counting Using the HPGe Detector with the Genie PC Counting System |
| Surface Water  | Gross Beta         | Monthly composite from a continuous water compositor | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 2 gallon    | TBE, TBE-2008 Gross alpha and/or gross beta activity in various matrices<br>EIS, CY-ES-206, Rev. 001 Operation of the Tennelec S5E Proportional Counter |
| Surface Water  | Tritium            | Monthly composite from a continuous water compositor | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 2 gallon    | TBE, TBE-2010 Tritium and carbon-14 analysis by liquid scintillation<br>GEL, EPA906.0 Mod, for Tritium analysis by Liquid scintillation                 |
| Surface Water  | Iodine-131         | Monthly composite from a continuous water compositor | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 2 gallon    | TBE, TBE-2012 Radioiodine in various matrices<br>EIS, CY-ES-205, Rev. 001 Gamma Counting Using the HPGe Detector with the Genie PC Counting System      |
| Drinking Water | Gross Beta         | Monthly composite from a continuous water compositor | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 2 gallon    | TBE, TBE-2008 Gross alpha and/or gross beta activity in various matrices  |
| Drinking Water | Gamma Spectroscopy | Monthly composite from a continuous water compositor | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 2 gallon    | TBE, TBE-2007 Gamma-emitting radioisotope analysis  |
| Drinking Water | Iodine-131         | Monthly composite from a continuous water compositor | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 2 gallon    | TBE, TBE-2012 Radioiodine in various matrices   |
| Drinking Water | Tritium            | Monthly composite from a continuous water compositor | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 2 gallon    | TBE, TBE-2010 Tritium and carbon-14 analysis by liquid scintillation  |
| Effluent Water | Iodine-131         | Monthly composite from a continuous water compositor | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 2 gallon    | TBE, TBE-2012 Radioiodine in various matrices   |
| Effluent Water | Gamma Spectroscopy | Monthly composite from a continuous water compositor | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 2 gallon    | TBE, TBE-2007 Gamma-emitting radioisotope analysis  |


**TABLE B-3:**

**Radiological Environmental Monitoring Program – Summary of Sample Collection and Analytical Methods, Three Mile Island Nuclear Station, 2018**


| Sample Medium    | Analysis           | Sampling Method  | Collection Procedure Number   | Sample Size                                 | Analytical Procedure Number   |
|------------------|--------------------|--|---|---|---|
| Effluent Water   | Tritium            | Monthly composite from a continuous water compositor                           | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 2 gallon                                    | TBE, TBE-2010 Tritium and carbon-14 analysis by liquid scintillation  |
| Effluent Water   | Strontium-89/90    | Semi-annual composite from monthly samples                                     | TBE, TBE-2023 Compositing of samples  | 2 gallon                                    | TBE, TBE-2019 Radiostrontium analysis by ion exchange   |
| Storm Water      | Gamma Spectroscopy | Quarterly composite of monthly grab samples                                    | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 1 gallon                                    | TBE, TBE-2007 Gamma-emitting radioisotope analysis  |
| Storm Water      | Tritium            | Quarterly composite of monthly grab samples                                    | CY-ES-221, Rev. 000 EIS Collection of Surface-Drinking-Effluent Water Samples for Radiological Analysis (TMI) | 1 gallon                                    | TBE, TBE-2010 Tritium and carbon-14 analysis by liquid scintillation  |
| Fish             | Gamma Spectroscopy | Semi-annual samples collected via electroshocking or other techniques          | ER-TMI-13 Collection of fish samples for radiological analysis (TMINS)  | 1000 grams (wet)                            | TBE, TBE-2007 Gamma-emitting radioisotope analysis<br>EIS, CY-ES-205, Rev. 001 Gamma Counting Using the HPGe Detector with the Genie PC Counting System |
| Fish             | Strontium-90       | Semi-annual samples collected via electroshocking or other techniques          | ER-TMI-13 Collection of fish samples for radiological analysis (TMINS)  | 1000 grams (wet)                            | TBE, TBE-2019 Radiostrontium analysis by ion exchange<br>GEL, EPA 905.0 Mod/DOE RP501 Rev. 1 Mod  |
| Sediment         | Gamma Spectroscopy | Semi-annual grab samples   | ER-TMI-03 Collection of sediment samples for radiological analysis (TMINS)                                    | 500 grams (dry)                             | TBE, TBE-2007 Gamma-emitting radioisotope analysis<br>EIS, CY-ES-205, Rev. 001 Gamma Counting Using the HPGe Detector with the Genie PC Counting System |
| Air Particulates | Gamma Spectroscopy | Quarterly composite of each station  | TBE, TBE-2023 Compositing of samples<br>CY-ES-204, Rev. 001 Sample Preparation for Gamma and Beta Counting    | 13 filters (approx.. 3600 cubic meters)     | TBE, TBE-2007 Gamma-emitting radioisotope analysis<br>EIS, CY-ES-205, Rev. 001 Gamma Counting Using the HPGe Detector with the Genie PC Counting System |
| Air Particulates | Gross Beta         | One-week composite of continuous air sampling through glass fiber filter paper | CY-ES-219, Rev. 001 Collection of Air Iodine & Air Particulate for Radiological Analysis - TMI                | 1 filter (approx.. 280 cubic meters weekly) | TBE, TBE-2008 Gross alpha and/or gross beta activity in various matrices<br>CY-ES-206, Rev. 001 Operation of the Tennelec S5E Proportional Counter      |

**TABLE B-3: Radiological Environmental Monitoring Program – Summary of Sample Collection and Analytical Methods, Three Mile Island Nuclear Station, 2018**

| Sample Medium | Analysis                                    | Sampling Method  | Collection Procedure Number  | Sample Size                                | Analytical Procedure Number   |
|---------------|---|--|--|--|---|
| Air Iodine    | Gamma Spectroscopy                          | One-week composite of continuous air sampling through charcoal filter                              | CY-ES-219, Rev. 001 Collection of Air Iodine & Air Particulate for Radiological Analysis - TMI                       | 1 filter (approx. 280 cubic meters weekly) | TBE, TBE-2007 Gamma-emitting radioisotope analysis<br>EIS, CY-ES-205, Rev. 001 Gamma Counting Using the HPGe Detector with the Genie PC Counting System |
| Milk          | I-131                                       | Bi-weekly grab sample when cows are on pasture. Monthly all other times                            | CY-ES-220, Rev. 000 EIS Sample Collection for Gamma Counting - Milk (TMI)  | 2 gallon                                   | TBE, TBE-2012 Radiiodine in various matrices<br>EIS, CY-ES-205, Rev. 001 Gamma Counting Using the HPGe Detector with the Genie PC Counting System       |
| Milk          | Sr-89/90                                    | Quarterly composite of Bi-weekly and monthly grab samples  | TBE, TBE-2023 Compositing of samples<br>CY-ES-227, Rev. 000 Compositing Milk Samples for Radiological Analysis - TMI | 2 gallon                                   | TBE, TBE-2019 Radiostrontium analysis by ion exchange<br>GEL, EPA 905.0 Mod/DOE RP501 Rev. 1 Mod  |
| Milk          | Gamma Spectroscopy                          | Bi-weekly grab sample when cows are on pasture. Monthly all other times                            | CY-ES-220, Rev. 000 EIS Sample Collection for Gamma Counting - Milk (TMI)  | 2 gallon                                   | TBE, TBE-2007 Gamma-emitting radioisotope analysis<br>EIS, CY-ES-205, Rev. 001 Gamma Counting Using the HPGe Detector with the Genie PC Counting System |
| Vegetation    | Gamma Spectroscopy                          | Monthly and annual grab sample   | CY-ES-217, Rev. 000 Sample Collection for Gamma Counting - Vegetation (TMI)  | 1000 grams                                 | TBE, TBE-2007 Gamma-emitting radioisotope analysis<br>EIS, CY-ES-205, Rev. 001 Gamma Counting Using the HPGe Detector with the Genie PC Counting System |
| Vegetation    | Strontium-89/90                             | Monthly and annual grab sample   | CY-ES-217, Rev. 000 Sample Collection for Gamma Counting - Vegetation (TMI)  | 1000 grams                                 | TBE, TBE-2019 Radiostrontium analysis by ion exchange<br>GEL, EPA 905.0 Mod/DOE RP501 Rev. 1 Mod  |
| OSLD          | Optically Stimulated Luminescence Dosimetry | Quarterly OSLDs comprised of two Al <sub>2</sub> O <sub>3</sub> :C Landauer Incorporated elements. | ER-TMI-02 Collection of OSLD samples for radiological analysis (TMINS)   | 2 badges with 3 dosimeters                 | Landauer Incorporated   |




**Figure B-1**  
**Environmental Sampling Locations Within One**  
**Mile of the Three Mile Island Nuclear Station, 2018**



**Figure B-2**  
**Environmental Sampling Locations Between One and Five**  
**Miles of the Three Mile Island Nuclear Station, 2018**





**Figure B-3**  
**Environmental Sampling Locations Greater than Five**  
**Miles of the Three Mile Island Nuclear Station, 2018**

## **APPENDIX C**

### **DATA TABLES AND FIGURES PRIMARY LABORATORY**

Intentionally left blank

**Table C-1.1 CONCENTRATIONS OF TRITIUM IN SURFACE WATER SAMPLES COLLECTED  
IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

| COLLECTION PERIOD                      | J1-2           | Q9-1  |
|--|----------------|-------|
| 01/03/18 - 01/30/18                    | < 193          | < 195 |
| 01/30/18 - 02/27/18                    | < 187          | < 186 |
| 03/08/18 - 03/27/18                    | < 179          | < 186 |
| 03/27/18 - 05/01/18                    | 348 $\pm$ 132  | < 180 |
| 05/01/18 - 05/31/18                    | 1390 $\pm$ 212 | < 192 |
| 05/31/18 - 06/26/18                    | 868 $\pm$ 150  | < 182 |
| 06/26/18 - 07/31/18                    | 1440 $\pm$ 209 | < 190 |
| 07/31/18 - 08/29/18                    | 1190 $\pm$ 190 | < 193 |
| 08/29/18 - 09/25/18                    | < 195          | < 194 |
| 09/25/18 - 10/31/18                    | < 177          | < 183 |
| 10/31/18 - 11/29/18                    | < 190          | < 198 |
| 11/29/18 - 01/03/19                    | < 188          | < 191 |
| <i>MEAN <math>\pm</math> 2 STD DEV</i> | 1047 $\pm$ 902 | -     |

**Table C-1.2 CONCENTRATIONS OF I-131 IN SURFACE WATER SAMPLES COLLECTED  
IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

| COLLECTION PERIOD   | A3-2  |
|---------------------|-------|
| 01/03/18 - 01/30/18 | < 0.4 |
| 01/30/18 - 02/27/18 | < 0.8 |
| 03/08/18 - 03/27/18 | < 0.6 |
| 03/27/18 - 05/01/18 | < 0.7 |
| 05/01/18 - 05/31/18 | < 0.7 |
| 05/31/18 - 06/26/18 | < 0.5 |
| 06/26/18 - 07/31/18 | < 0.5 |
| 07/31/18 - 08/29/18 | < 0.8 |
| 08/29/18 - 09/25/18 | < 0.4 |
| 09/25/18 - 10/31/18 | < 0.6 |
| 10/31/18 - 11/29/18 | < 0.7 |
| 11/29/18 - 01/03/19 | < 0.9 |
| <i>MEAN</i>         | -     |

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**Table C-I.3** **CONCENTRATIONS OF GAMMA EMITTERS IN SURFACE WATER SAMPLES**  
**COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
**RESULTS IN UNITS OF PCI/LITER + 2 SIGMA**

| SITE                | COLLECTION PERIOD   | RESULTS IN UNITS OF PCI/LITER + 2 SIGMA |       |       |       |       |       |       |        |        |        |        |
|---------------------|---------------------|---|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|
|                     |                     | Mn-54                                   | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | Cs-134 | Cs-137 | Ba-140 | La-140 |
| J1-2                | 01/03/18 - 01/30/18 | < 6                                     | < 8   | < 16  | < 5   | < 19  | < 8   | < 12  | < 9    | < 7    | < 33   | < 9    |
|                     | 01/30/18 - 02/27/18 | < 7                                     | < 8   | < 16  | < 8   | < 15  | < 7   | < 13  | < 9    | < 8    | < 38   | < 13   |
|                     | 03/08/18 - 03/27/18 | < 8                                     | < 8   | < 13  | < 10  | < 14  | < 11  | < 17  | < 9    | < 9    | < 37   | < 13   |
|                     | 03/27/18 - 05/01/18 | < 4                                     | < 6   | < 12  | < 4   | < 9   | < 5   | < 8   | < 5    | < 4    | < 31   | < 10   |
|                     | 05/01/18 - 05/31/18 | < 5                                     | < 7   | < 14  | < 6   | < 10  | < 6   | < 11  | < 7    | < 6    | < 35   | < 13   |
|                     | 05/31/18 - 06/26/18 | < 6                                     | < 7   | < 14  | < 6   | < 11  | < 6   | < 8   | < 7    | < 6    | < 31   | < 15   |
|                     | 06/26/18 - 07/31/18 | < 5                                     | < 5   | < 13  | < 7   | < 13  | < 9   | < 13  | < 7    | < 6    | < 34   | < 13   |
|                     | 07/31/18 - 08/29/18 | < 7                                     | < 5   | < 15  | < 8   | < 13  | < 7   | < 12  | < 8    | < 7    | < 35   | < 9    |
|                     | 08/29/18 - 09/25/18 | < 5                                     | < 5   | < 11  | < 5   | < 9   | < 5   | < 9   | < 5    | < 4    | < 36   | < 10   |
|                     | 09/25/18 - 10/31/18 | < 4                                     | < 4   | < 12  | < 7   | < 12  | < 8   | < 12  | < 7    | < 6    | < 29   | < 11   |
|                     | 10/31/18 - 11/29/18 | < 8                                     | < 5   | < 15  | < 9   | < 9   | < 5   | < 7   | < 7    | < 8    | < 35   | < 10   |
| 11/29/18 - 01/03/19 | < 9                 | < 8                                     | < 19  | < 8   | < 16  | < 9   | < 14  | < 9   | < 9    | < 33   | < 11   |        |
|                     | MEAN                | -                                       | -     | -     | -     | -     | -     | -     | -      | -      | -      | -      |
| Q9-1                | 01/03/18 - 01/30/18 | < 7                                     | < 7   | < 14  | < 7   | < 15  | < 6   | < 12  | < 7    | < 8    | < 33   | < 9    |
|                     | 01/30/18 - 02/27/18 | < 6                                     | < 5   | < 15  | < 7   | < 9   | < 6   | < 9   | < 6    | < 7    | < 36   | < 10   |
|                     | 03/08/18 - 03/27/18 | < 8                                     | < 8   | < 16  | < 10  | < 17  | < 7   | < 15  | < 8    | < 7    | < 34   | < 11   |
|                     | 03/27/18 - 05/01/18 | < 4                                     | < 5   | < 12  | < 6   | < 8   | < 6   | < 9   | < 6    | < 5    | < 32   | < 10   |
|                     | 05/01/18 - 05/31/18 | < 5                                     | < 4   | < 10  | < 5   | < 10  | < 6   | < 9   | < 5    | < 5    | < 32   | < 10   |
|                     | 05/31/18 - 06/26/18 | < 6                                     | < 7   | < 12  | < 7   | < 13  | < 7   | < 8   | < 6    | < 6    | < 37   | < 15   |
|                     | 06/26/18 - 07/31/18 | < 6                                     | < 7   | < 14  | < 7   | < 13  | < 6   | < 10  | < 7    | < 8    | < 33   | < 10   |
|                     | 07/31/18 - 08/29/18 | < 5                                     | < 6   | < 12  | < 7   | < 11  | < 6   | < 10  | < 6    | < 6    | < 32   | < 8    |
|                     | 08/29/18 - 09/25/18 | < 5                                     | < 4   | < 11  | < 5   | < 9   | < 6   | < 11  | < 4    | < 5    | < 36   | < 13   |
|                     | 09/25/18 - 10/31/18 | < 6                                     | < 8   | < 13  | < 7   | < 10  | < 6   | < 13  | < 8    | < 7    | < 42   | < 14   |
|                     | 10/31/18 - 11/29/18 | < 6                                     | < 7   | < 13  | < 6   | < 14  | < 6   | < 12  | < 7    | < 6    | < 31   | < 9    |
| 11/29/18 - 01/03/19 | < 6                 | < 6                                     | < 11  | < 6   | < 10  | < 7   | < 9   | < 6   | < 6    | < 25   | < 6    |        |
|                     | MEAN                | -                                       | -     | -     | -     | -     | -     | -     | -      | -      | -      | -      |

Table C-II.1

**CONCENTRATIONS OF GROSS BETA IN DRINKING WATER SAMPLES  
COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA**

| COLLECTION PERIOD    | G15-2         | G15-3         | Q9-1          |
|----------------------|---------------|---------------|---------------|
| 01/03/18 - 01/30/18  | 2.7 $\pm$ 1.6 | 2.1 $\pm$ 1.4 | 2.3 $\pm$ 1.4 |
| 01/30/18 - 02/27/18  | 4.8 $\pm$ 1.8 | < 2.1         | < 2.0         |
| 03/08/18 - 03/27/18  | 5.2 $\pm$ 1.7 | 3.0 $\pm$ 1.5 | 3.4 $\pm$ 1.5 |
| 03/27/18 - 05/01/18  | 2.9 $\pm$ 1.5 | < 1.9         | 4.2 $\pm$ 1.5 |
| 05/01/18 - 05/31/18  | < 2.1         | 2.2 $\pm$ 1.4 | < 1.9         |
| 05/31/18 - 06/26/18  | 4.2 $\pm$ 1.5 | 2.1 $\pm$ 1.3 | 2.8 $\pm$ 1.4 |
| 06/26/18 - 07/31/18  | 2.6 $\pm$ 1.4 | < 1.9         | < 1.9         |
| 07/31/18 - 08/29/18  | 4.1 $\pm$ 1.7 | 3.9 $\pm$ 1.6 | 2.1 $\pm$ 1.4 |
| 08/29/18 - 09/25/18  | 3.8 $\pm$ 1.5 | 2.3 $\pm$ 1.3 | 2.2 $\pm$ 1.2 |
| 09/25/18 - 10/31/18  | 3.0 $\pm$ 1.4 | < 1.9         | 2.4 $\pm$ 1.4 |
| 10/31/18 - 11/29/18  | 3.5 $\pm$ 1.5 | < 1.9         | < 1.9         |
| 11/29/18 - 01/03/19  | < 1.8         | < 1.7         | < 1.7         |
| MEAN $\pm$ 2 STD DEV | 3.7 $\pm$ 1.8 | 2.6 $\pm$ 1.5 | 2.8 $\pm$ 1.6 |

Table C-II.2

**CONCENTRATIONS OF I-131 IN DRINKING WATER SAMPLES  
COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA**

| COLLECTION PERIOD   | G15-2 | G15-3 | Q9-1  |
|---------------------|-------|-------|-------|
| 01/03/18 - 01/30/18 | < 0.4 | < 0.6 | < 0.7 |
| 01/30/18 - 02/27/18 | < 0.6 | < 0.6 | < 0.6 |
| 03/08/18 - 03/27/18 | < 0.8 | < 0.7 | < 0.7 |
| 03/27/18 - 05/01/18 | < 0.7 | < 0.6 | < 0.8 |
| 05/01/18 - 05/31/18 | < 0.4 | < 0.4 | < 0.4 |
| 05/31/18 - 06/26/18 | < 0.6 | < 0.6 | < 0.5 |
| 06/26/18 - 07/31/18 | < 0.4 | < 0.4 | < 0.4 |
| 07/31/18 - 08/29/18 | < 0.4 | < 0.5 | < 0.5 |
| 08/29/18 - 09/25/18 | < 0.6 | < 0.6 | < 0.4 |
| 09/25/18 - 10/31/18 | < 0.9 | < 0.6 | < 0.6 |
| 10/31/18 - 11/29/18 | < 0.7 | < 0.8 | < 0.7 |
| 11/29/18 - 01/03/19 | < 0.7 | < 0.6 | < 0.6 |
| MEAN                | -     | -     | -     |

Table C-II.3

**CONCENTRATIONS OF TRITIUM IN DRINKING WATER SAMPLES COLLECTED  
IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA**

| COLLECTION PERIOD    | G15-2 | G15-3 | Q9-1  |
|----------------------|-------|-------|-------|
| 01/03/18 - 01/30/18  | < 192 | < 194 | < 197 |
| 01/30/18 - 02/27/18  | < 185 | < 187 | < 185 |
| 03/08/18 - 03/27/18  | < 182 | < 180 | < 183 |
| 03/27/18 - 05/01/18  | < 189 | < 186 | < 190 |
| 05/01/18 - 05/31/18  | < 192 | < 194 | < 194 |
| 05/31/18 - 06/26/18  | < 181 | < 177 | < 180 |
| 06/26/18 - 07/31/18  | < 195 | < 190 | < 188 |
| 07/31/18 - 08/29/18  | < 193 | < 192 | < 197 |
| 08/29/18 - 09/25/18  | < 197 | < 192 | < 194 |
| 09/25/18 - 10/31/18  | < 179 | < 179 | < 176 |
| 10/31/18 - 11/29/18  | < 193 | < 196 | < 194 |
| 11/29/18 - 01/03/19  | < 192 | < 187 | < 192 |
| MEAN $\pm$ 2 STD DEV | -     | -     | -     |

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

Table C-II.4

CONCENTRATIONS OF GAMMA EMITTERS IN DRINKING WATER SAMPLES COLLECTED COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018

RESULTS IN UNITS OF PCI/LITER + 2 SIGMA

| SITE                | COLLECTION PERIOD   | Mn-54               | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | Cs-134 | Cs-137 | Ba-140 | La-140 |      |
|---------------------|---------------------|---------------------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|------|
|                     |                     |                     |       |       |       |       |       |       |        |        |        |        |      |
| TM-DW-G15-2         | 01/03/18 - 01/30/18 | < 8                 | < 11  | < 23  | < 10  | < 19  | < 9   | < 19  | < 8    | < 12   | < 43   | < 12   |      |
|                     | 01/30/18 - 02/27/18 | < 5                 | < 8   | < 13  | < 8   | < 13  | < 7   | < 10  | < 8    | < 6    | < 34   | < 12   |      |
|                     | 03/08/18 - 03/27/18 | < 6                 | < 5   | < 10  | < 7   | < 9   | < 7   | < 11  | < 7    | < 5    | < 20   | < 7    |      |
|                     | 03/27/18 - 05/01/18 | < 1                 | < 1   | < 3   | < 1   | < 3   | < 2   | < 2   | < 1    | < 1    | < 10   | < 3    |      |
|                     | 05/01/18 - 05/31/18 | < 4                 | < 5   | < 10  | < 6   | < 11  | < 6   | < 7   | < 6    | < 5    | < 29   | < 9    |      |
|                     | 05/31/18 - 06/26/18 | < 6                 | < 5   | < 17  | < 6   | < 13  | < 7   | < 9   | < 7    | < 6    | < 35   | < 10   |      |
|                     | 06/26/18 - 07/31/18 | < 7                 | < 7   | < 15  | < 10  | < 17  | < 8   | < 10  | < 8    | < 7    | < 36   | < 15   |      |
|                     | 07/31/18 - 08/29/18 | < 8                 | < 6   | < 15  | < 6   | < 17  | < 10  | < 7   | < 7    | < 7    | < 41   | < 15   |      |
|                     | 08/29/18 - 09/25/18 | < 4                 | < 6   | < 9   | < 5   | < 8   | < 5   | < 5   | < 10   | < 5    | < 36   | < 13   |      |
|                     | 09/25/18 - 10/31/18 | < 6                 | < 6   | < 15  | < 9   | < 13  | < 7   | < 14  | < 14   | < 9    | < 33   | < 11   |      |
|                     | 10/31/18 - 11/29/18 | < 6                 | < 8   | < 12  | < 7   | < 9   | < 5   | < 11  | < 11   | < 5    | < 29   | < 13   |      |
|                     | 11/29/18 - 01/03/19 | < 4                 | < 5   | < 11  | < 6   | < 11  | < 5   | < 9   | < 9    | < 6    | < 21   | < 8    |      |
|                     |                     | MEAN                | -     | -     | -     | -     | -     | -     | -      | -      | -      | -      | -    |
|                     | TM-DW-G15-3         | 01/03/18 - 01/30/18 | < 5   | < 6   | < 15  | < 10  | < 16  | < 7   | < 12   | < 7    | < 8    | < 35   | < 12 |
| 01/30/18 - 02/27/18 |                     | < 6                 | < 7   | < 15  | < 6   | < 11  | < 7   | < 8   | < 6    | < 5    | < 33   | < 14   |      |
| 03/08/18 - 03/27/18 |                     | < 6                 | < 6   | < 14  | < 8   | < 14  | < 7   | < 11  | < 7    | < 7    | < 25   | < 10   |      |
| 03/27/18 - 05/01/18 |                     | < 2                 | < 2   | < 5   | < 2   | < 4   | < 2   | < 4   | < 2    | < 2    | < 14   | < 4    |      |
| 05/01/18 - 05/31/18 |                     | < 5                 | < 5   | < 12  | < 6   | < 12  | < 5   | < 10  | < 6    | < 6    | < 27   | < 12   |      |
| 05/31/18 - 06/26/18 |                     | < 5                 | < 6   | < 13  | < 6   | < 11  | < 6   | < 12  | < 7    | < 6    | < 31   | < 8    |      |
| 06/26/18 - 07/31/18 |                     | < 9                 | < 8   | < 16  | < 7   | < 15  | < 7   | < 14  | < 7    | < 7    | < 42   | < 12   |      |
| 07/31/18 - 08/29/18 |                     | < 4                 | < 4   | < 12  | < 3   | < 13  | < 6   | < 11  | < 7    | < 5    | < 34   | < 10   |      |
| 08/29/18 - 09/25/18 |                     | < 4                 | < 4   | < 8   | < 4   | < 8   | < 4   | < 8   | < 5    | < 4    | < 24   | < 9    |      |
| 09/25/18 - 10/31/18 |                     | < 5                 | < 6   | < 14  | < 6   | < 14  | < 7   | < 10  | < 10   | < 6    | < 32   | < 13   |      |
| 10/31/18 - 11/29/18 |                     | < 6                 | < 6   | < 13  | < 7   | < 13  | < 6   | < 11  | < 11   | < 6    | < 27   | < 11   |      |
| 11/29/18 - 01/03/19 |                     | < 4                 | < 4   | < 8   | < 6   | < 9   | < 5   | < 8   | < 8    | < 6    | < 24   | < 8    |      |
|                     |                     | MEAN                | -     | -     | -     | -     | -     | -     | -      | -      | -      | -      | -    |
| TM-DW-Q9-1          |                     | 01/03/18 - 01/30/18 | < 8   | < 8   | < 18  | < 10  | < 13  | < 8   | < 13   | < 10   | < 9    | < 43   | < 15 |
|                     | 01/30/18 - 02/27/18 | < 7                 | < 8   | < 16  | < 6   | < 16  | < 10  | < 13  | < 8    | < 8    | < 37   | < 15   |      |
|                     | 03/08/18 - 03/27/18 | < 8                 | < 8   | < 17  | < 9   | < 22  | < 12  | < 19  | < 10   | < 9    | < 42   | < 10   |      |
|                     | 03/27/18 - 05/01/18 | < 4                 | < 3   | < 9   | < 3   | < 8   | < 4   | < 6   | < 5    | < 4    | < 26   | < 8    |      |
|                     | 05/01/18 - 05/31/18 | < 5                 | < 5   | < 10  | < 6   | < 10  | < 5   | < 9   | < 5    | < 5    | < 34   | < 11   |      |
|                     | 05/31/18 - 06/26/18 | < 7                 | < 8   | < 17  | < 9   | < 14  | < 8   | < 8   | < 7    | < 8    | < 38   | < 14   |      |
|                     | 06/26/18 - 07/31/18 | < 6                 | < 6   | < 12  | < 5   | < 12  | < 7   | < 10  | < 6    | < 7    | < 33   | < 12   |      |
|                     | 07/31/18 - 08/29/18 | < 6                 | < 6   | < 13  | < 5   | < 10  | < 6   | < 10  | < 6    | < 7    | < 39   | < 8    |      |
|                     | 08/29/18 - 09/25/18 | < 5                 | < 6   | < 11  | < 5   | < 12  | < 5   | < 10  | < 6    | < 5    | < 32   | < 11   |      |
|                     | 09/25/18 - 10/31/18 | < 8                 | < 7   | < 13  | < 5   | < 14  | < 6   | < 11  | < 7    | < 8    | < 35   | < 9    |      |
|                     | 10/31/18 - 11/29/18 | < 7                 | < 5   | < 14  | < 8   | < 16  | < 6   | < 12  | < 7    | < 7    | < 27   | < 9    |      |
|                     | 11/29/18 - 01/03/19 | < 7                 | < 7   | < 13  | < 6   | < 14  | < 6   | < 12  | < 7    | < 7    | < 31   | < 9    |      |
|                     |                     | MEAN                | -     | -     | -     | -     | -     | -     | -      | -      | -      | -      | -    |

Table C-III.1

**CONCENTRATIONS OF GROSS BETA, IODINE-131, TRITIUM, AND  
STRONTIUM IN EFFLUENT WATER SAMPLES COLLECTED IN THE  
VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**

RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

| SITE | COLLECTION PERIOD   | GR-B                 | I-131         | H-3              | SR-89             | SR-90 |   |
|------|---------------------|----------------------|---------------|------------------|-------------------|-------|---|
| K1-1 | 01/03/18 - 01/30/18 | 5.2 $\pm$ 1.8        | < 0.5         | < 198            |                   |       |   |
|      | 01/30/18 - 02/27/18 | 5.3 $\pm$ 1.8        | < 0.6         | < 186            |                   |       |   |
|      | 03/08/18 - 03/27/18 | 4.0 $\pm$ 1.6        | < 0.9         | < 183            |                   |       |   |
|      | 03/27/18 - 05/01/18 | 2.0 $\pm$ 1.4        | < 0.6         | < 179            |                   |       |   |
|      | 05/01/18 - 05/31/18 | 4.3 $\pm$ 1.6        | < 0.9         | 22600 $\pm$ 2310 |                   |       |   |
|      | 05/31/18 - 06/26/18 | 5.1 $\pm$ 1.7        | < 0.8         | 24200 $\pm$ 2460 |                   |       |   |
|      | 05/31/18 - 06/26/18 | <i>Reanalysis</i>    |               | 25900 $\pm$ 2640 |                   |       |   |
|      | 01/03/18 - 06/26/18 |                      |               |                  | < 4.0             | < 0.8 |   |
|      | 06/26/18 - 07/31/18 | 5.4 $\pm$ 1.8        | < 0.4         | 21600 $\pm$ 2210 |                   |       |   |
|      | 07/31/18 - 08/29/18 | 4.8 $\pm$ 1.7        | < 0.4         | 26700 $\pm$ 2720 |                   |       |   |
|      | 08/29/18 - 09/25/18 | 6.8 $\pm$ 1.8        | < 0.7         | 203 $\pm$ 130    |                   |       |   |
|      | 09/25/18 - 10/31/18 | 5.3 $\pm$ 1.7        | < 0.6         | < 181            |                   |       |   |
|      | 10/31/18 - 11/29/18 | 3.9 $\pm$ 1.5        | < 0.7         | < 190            |                   |       |   |
|      | 11/29/18 - 01/03/19 | 3.0 $\pm$ 1.4        | < 0.9         | < 189            |                   |       |   |
|      | 06/26/18 - 01/03/19 |                      |               |                  | < 3.7             | < 0.7 |   |
|      |                     | MEAN $\pm$ 2 STD DEV | 4.6 $\pm$ 2.5 | -                | 19061 $\pm$ 21433 | -     | - |

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES



Table C-III.2

**CONCENTRATIONS OF GAMMA EMITTERS IN EFFLUENT WATER SAMPLES COLLECTED  
IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PC/LITER + 2 SIGMA

| SITE | COLLECTION PERIOD   | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | Cs-134 | Cs-137 | Ba-140 | La-140 |
|------|---------------------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|
| K1-1 | 01/03/18 - 01/30/18 | < 7   | < 8   | < 15  | < 7   | < 17  | < 8   | < 14  | < 8    | < 8    | < 34   | < 11   |
|      | 01/30/18 - 02/27/18 | < 4   | < 4   | < 10  | < 5   | < 10  | < 5   | < 9   | < 5    | < 5    | < 23   | < 8    |
|      | 03/08/18 - 03/27/18 | < 6   | < 5   | < 9   | < 7   | < 13  | < 6   | < 11  | < 7    | < 6    | < 20   | < 7    |
|      | 03/27/18 - 05/01/18 | < 4   | < 4   | < 11  | < 5   | < 8   | < 4   | < 8   | < 5    | < 5    | < 31   | < 9    |
|      | 05/01/18 - 05/31/18 | < 5   | < 5   | < 14  | < 6   | < 10  | < 5   | < 10  | < 6    | < 4    | < 37   | < 7    |
|      | 05/31/18 - 06/26/18 | < 7   | < 7   | < 16  | < 8   | < 13  | < 5   | < 14  | < 8    | < 7    | < 38   | < 10   |
|      | 06/26/18 - 07/31/18 | < 8   | < 6   | < 14  | < 6   | < 8   | < 7   | < 10  | < 8    | < 7    | < 29   | < 15   |
|      | 07/31/18 - 08/29/18 | < 5   | < 6   | < 13  | < 7   | < 11  | < 5   | < 13  | < 6    | < 7    | < 31   | < 9    |
|      | 08/29/18 - 09/25/18 | < 4   | < 4   | < 8   | < 4   | < 8   | < 5   | < 7   | < 4    | < 4    | < 32   | < 9    |
|      | 09/25/18 - 10/31/18 | < 5   | < 6   | < 12  | < 5   | < 11  | < 6   | < 10  | < 5    | < 7    | < 25   | < 12   |
|      | 10/31/18 - 11/29/18 | < 3   | < 4   | < 13  | < 5   | < 13  | < 6   | < 12  | < 5    | < 4    | < 29   | < 12   |
|      | 11/29/18 - 01/03/19 | < 7   | < 6   | < 13  | < 9   | < 15  | < 6   | < 10  | < 9    | < 6    | < 22   | < 5    |
|      | MEAN                | -     | -     | -     | -     | -     | -     | -     | -      | -      | -      | -      |

Table C-IV.1

**CONCENTRATIONS OF STRONTIUM IN PREDATOR  
AND BOTTOM FEEDER (FISH) SAMPLES COLLECTED IN THE  
VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/KG WET ± 2 SIGMA

| SITE                 |             | Sr-90 |
|----------------------|-------------|-------|
| BKGB                 | 06/06/18    | < 2.2 |
| <i>BOTTOM FEEDER</i> | 10/24/18    | < 4.3 |
|                      | <i>MEAN</i> | -     |
| BKGP                 | 06/06/18    | < 3.1 |
| <i>PREDATOR</i>      | 10/24/18    | < 2.8 |
|                      | <i>MEAN</i> | -     |
| INDB                 | 05/25/18    | < 1.2 |
| <i>BOTTOM FEEDER</i> | 10/05/18    | < 4.2 |
|                      | <i>MEAN</i> | -     |
| INDP                 | 05/25/18    | < 3.0 |
| <i>PREDATOR</i>      | 10/05/18    | < 3.4 |
|                      | <i>MEAN</i> | -     |

Table C-IV.2

**CONCENTRATIONS OF GAMMA EMITTERS IN PREDATOR AND BOTTOM FEEDER (FISH)  
 SAMPLES COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018  
 RESULTS IN UNITS OF PCI/KG WET ± 2 SIGMA**

| SITE          | COLLECTION PERIOD | K-40        | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Cs-134 | Cs-137 |
|---------------|-------------------|-------------|-------|-------|-------|-------|-------|--------|--------|
| BKGB          | 06/06/18          | 3101 ± 847  | < 64  | < 46  | < 76  | < 53  | < 99  | < 66   | < 48   |
| BOTTOM FEEDER | 10/24/18          | 2799 ± 1000 | < 57  | < 59  | < 157 | < 83  | < 142 | < 62   | < 56   |
|               | MEAN ± 2 STD DEV  | 2950 + 427  | -     | -     | -     | -     | -     | -      | -      |
| BKGP          | 06/06/18          | 3037 ± 990  | < 52  | < 54  | < 99  | < 54  | < 145 | < 71   | < 49   |
| PREDATOR      | 10/24/18          | 2970 ± 1119 | < 82  | < 73  | < 217 | < 96  | < 173 | < 85   | < 82   |
|               | MEAN ± 2 STD DEV  | 3004 + 94.8 | -     | -     | -     | -     | -     | -      | -      |
| INDB          | 05/25/18          | 2405 ± 1208 | < 45  | < 72  | < 184 | < 81  | < 154 | < 98   | < 90   |
| BOTTOM FEEDER | 10/05/18          | 3841 ± 782  | < 54  | < 50  | < 131 | < 57  | < 119 | < 60   | < 58   |
|               | MEAN ± 2 STD DEV  | 3123 + 2031 | -     | -     | -     | -     | -     | -      | -      |
| INDP          | 05/25/18          | 3129 ± 1057 | < 51  | < 43  | < 118 | < 70  | < 164 | < 79   | < 83   |
| PREDATOR      | 10/05/18          | 2524 ± 1296 | < 57  | < 56  | < 155 | < 100 | < 129 | < 89   | < 72   |
|               | MEAN ± 2 STD DEV  | 2827 ± 856  | -     | -     | -     | -     | -     | -      | -      |

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**Table C-V.1 CONCENTRATIONS OF GAMMA EMITTERS IN SEDIMENT SAMPLES COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/KG DRY  $\pm$  2 SIGMA

| SITE | COLLECTION                             |  | K-40             | Mn-54 | Co-58 | Co-60 | Cs-134 | Cs-137 |
|------|--|--|------------------|-------|-------|-------|--------|--------|
|      | PERIOD                                 |  |                  |       |       |       |        |        |
| A1-3 | 06/11/18                               |  | 14580 $\pm$ 1921 | < 97  | < 82  | < 95  | < 118  | < 107  |
|      | 10/25/18                               |  | 9874 $\pm$ 1716  | < 92  | < 83  | < 111 | < 124  | < 112  |
|      | <i>MEAN <math>\pm</math> 2 STD DEV</i> |  | 12227 $\pm$ 6655 | -     | -     | -     | -      | -      |
| EDCB | 10/25/18                               |  | 12930 $\pm$ 2191 | < 111 | < 132 | < 129 | < 145  | < 138  |
|      | <i>MEAN <math>\pm</math> 2 STD DEV</i> |  | 12930 $\pm$ 0    | -     | -     | -     | -      | -      |
|      |  |  |                  |       |       |       |        |        |
| J2-1 | 06/11/18                               |  | 17710 $\pm$ 1982 | < 90  | < 73  | < 103 | < 123  | < 103  |
|      | 10/25/18                               |  | 19640 $\pm$ 2558 | < 100 | < 100 | < 160 | < 145  | < 132  |
|      | <i>MEAN <math>\pm</math> 2 STD DEV</i> |  | 18675 $\pm$ 2729 | -     | -     | -     | -      | -      |
| K1-3 | 06/11/18                               |  | 7201 $\pm$ 1400  | < 76  | < 64  | < 80  | < 76   | < 86   |
|      | 10/25/18                               |  | 13420 $\pm$ 2195 | < 108 | < 111 | < 140 | < 145  | < 161  |
|      | <i>MEAN <math>\pm</math> 2 STD DEV</i> |  | 10311 $\pm$ 8795 | -     | -     | -     | -      | -      |

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

Table C-VI.1

**CONCENTRATIONS OF GROSS BETA IN AIR PARTICULATE SAMPLES COLLECTED  
IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**

RESULTS IN UNITS OF E-3 PCI/CU METER ± 2 SIGMA

| COLLECTION PERIOD   | GROUP I |        |        | GROUP II |        |        | GROUP III |
|---------------------|---------|--------|--------|----------|--------|--------|-----------|
|                     | E1-2    | F1-3   | A3-1   | G2-1     | H3-1   | M2-1   | Q15-1     |
| 01/04/18 - 01/11/18 | 17 ± 4  | 14 ± 4 | 8 ± 4  | 14 ± 4   | 14 ± 4 | 11 ± 4 | 14 ± 4    |
| 01/11/18 - 01/18/18 | 15 ± 4  | 14 ± 4 | 13 ± 4 | 13 ± 4   | 14 ± 4 | 14 ± 4 | 16 ± 4    |
| 01/18/18 - 01/25/18 | 19 ± 4  | 21 ± 4 | 20 ± 4 | 21 ± 4   | 21 ± 4 | 14 ± 4 | 23 ± 5    |
| 01/25/18 - 02/01/18 | 13 ± 4  | 13 ± 4 | 11 ± 4 | 9 ± 4    | 11 ± 4 | 10 ± 4 | 15 ± 4    |
| 02/01/18 - 02/08/18 | 10 ± 4  | 11 ± 4 | 9 ± 4  | 9 ± 4    | 16 ± 4 | 13 ± 4 | 12 ± 4    |
| 02/08/18 - 02/15/18 | 17 ± 4  | 16 ± 4 | 13 ± 4 | 12 ± 4   | 19 ± 5 | 19 ± 5 | 13 ± 4    |
| 02/15/18 - 02/22/18 | 15 ± 4  | 17 ± 4 | 10 ± 3 | 12 ± 4   | 14 ± 4 | 15 ± 4 | 17 ± 4    |
| 02/22/18 - 03/01/18 | 13 ± 4  | 18 ± 4 | 9 ± 3  | 9 ± 3    | 14 ± 4 | 11 ± 4 | 16 ± 4    |
| 03/01/18 - 03/08/18 | 8 ± 4   | 9 ± 4  | 6 ± 4  | 6 ± 4    | 12 ± 4 | 10 ± 4 | 11 ± 4    |
| 03/08/18 - 03/15/18 | 14 ± 4  | 8 ± 3  | 13 ± 4 | 9 ± 3    | 9 ± 3  | 12 ± 4 | 11 ± 4    |
| 03/15/18 - 03/23/18 | 13 ± 4  | 13 ± 4 | 9 ± 3  | 5 ± 3    | 11 ± 4 | 14 ± 4 | 14 ± 4    |
| 03/23/18 - 03/29/18 | 11 ± 4  | 16 ± 5 | 12 ± 5 | 9 ± 4    | 11 ± 5 | 8 ± 4  | 10 ± 4    |
| 03/29/18 - 04/05/18 | 11 ± 4  | 14 ± 4 | 16 ± 4 | 9 ± 4    | 8 ± 4  | 10 ± 4 | 12 ± 4    |
| 04/05/18 - 04/12/18 | 15 ± 4  | 14 ± 4 | 8 ± 4  | 8 ± 4    | 12 ± 4 | 9 ± 4  | 14 ± 4    |
| 04/12/18 - 04/19/18 | 13 ± 4  | 11 ± 4 | 8 ± 4  | 6 ± 3    | 11 ± 4 | 9 ± 4  | 13 ± 4    |
| 04/19/18 - 04/26/18 | 15 ± 4  | 15 ± 4 | 10 ± 4 | 8 ± 4    | 11 ± 4 | 10 ± 4 | 15 ± 4    |
| 04/26/18 - 05/03/18 | 19 ± 5  | 13 ± 4 | 11 ± 4 | 9 ± 4    | 14 ± 4 | 16 ± 5 | 19 ± 5    |
| 05/03/18 - 05/10/18 | 21 ± 5  | 17 ± 5 | 19 ± 5 | 12 ± 4   | 22 ± 5 | 23 ± 5 | 19 ± 5    |
| 05/10/18 - 05/17/18 | 9 ± 4   | 9 ± 4  | 6 ± 4  | < 5      | 9 ± 4  | 9 ± 4  | 8 ± 4     |
| 05/17/18 - 05/24/18 | 11 ± 4  | 10 ± 4 | 8 ± 3  | 8 ± 4    | 9 ± 4  | 7 ± 3  | 7 ± 3     |
| 05/24/18 - 05/31/18 | 12 ± 4  | 9 ± 3  | 9 ± 3  | (1)      | 10 ± 4 | 14 ± 4 | 15 ± 4    |
| 05/31/18 - 06/06/18 | 5 ± 3   | 6 ± 3  | 8 ± 3  | 7 ± 3    | 8 ± 4  | 8 ± 4  | 6 ± 3     |
| 06/06/18 - 06/13/18 | 10 ± 5  | 9 ± 4  | 9 ± 4  | 11 ± 5   | 11 ± 5 | 8 ± 4  | 10 ± 5    |
| 06/13/18 - 06/21/18 | 13 ± 3  | 15 ± 3 | 11 ± 3 | 14 ± 3   | 12 ± 3 | 13 ± 3 | 17 ± 4    |
| 06/21/18 - 06/28/18 | 8 ± 3   | 11 ± 3 | 11 ± 3 | 10 ± 3   | 10 ± 3 | 12 ± 4 | 11 ± 4    |
| 06/28/18 - 07/05/18 | (1)     | 14 ± 4 | 16 ± 4 | 16 ± 5   | 16 ± 4 | 18 ± 4 | 18 ± 4    |
| 07/05/18 - 07/12/18 | 12 ± 4  | 11 ± 4 | 14 ± 4 | 14 ± 4   | < 5    | 15 ± 4 | 12 ± 4    |
| 07/12/18 - 07/19/18 | 14 ± 4  | 11 ± 4 | 13 ± 4 | 16 ± 4   | < 4    | 13 ± 4 | 18 ± 4    |
| 07/19/18 - 07/26/18 | < 4     | 8 ± 3  | 5 ± 3  | 9 ± 4    | 6 ± 3  | 5 ± 3  | 7 ± 3     |
| 07/26/18 - 08/02/18 | 10 ± 4  | 12 ± 4 | 5 ± 3  | 13 ± 4   | 11 ± 4 | 11 ± 4 | 16 ± 4    |
| 08/02/18 - 08/09/18 | 23 ± 5  | 21 ± 4 | 20 ± 4 | 23 ± 5   | 23 ± 5 | 22 ± 5 | 26 ± 5    |
| 08/09/18 - 08/16/18 | 15 ± 4  | 17 ± 4 | 16 ± 4 | 19 ± 4   | 16 ± 4 | 18 ± 4 | 16 ± 4    |
| 08/16/18 - 08/23/18 | 13 ± 4  | 14 ± 4 | 14 ± 4 | 12 ± 4   | 10 ± 4 | 15 ± 4 | 17 ± 4    |
| 08/23/18 - 08/29/18 | 25 ± 5  | 23 ± 5 | 23 ± 5 | 23 ± 5   | 24 ± 5 | 22 ± 5 | 25 ± 5    |
| 08/29/18 - 09/06/18 | 14 ± 4  | 13 ± 4 | 12 ± 3 | 13 ± 4   | 12 ± 4 | 13 ± 4 | 11 ± 4    |
| 09/06/18 - 09/13/18 | 11 ± 4  | 11 ± 4 | 8 ± 3  | 12 ± 4   | 12 ± 4 | 8 ± 3  | 12 ± 4    |
| 09/13/18 - 09/19/18 | 6 ± 4   | 8 ± 4  | 9 ± 4  | 10 ± 4   | 6 ± 4  | 7 ± 4  | 8 ± 4     |
| 09/19/18 - 09/27/18 | 6 ± 3   | 10 ± 3 | 8 ± 3  | 10 ± 4   | 12 ± 4 | 10 ± 3 | 10 ± 4    |
| 09/27/18 - 10/04/18 | 13 ± 4  | 13 ± 4 | 15 ± 4 | 17 ± 4   | 14 ± 4 | 15 ± 4 | 16 ± 4    |
| 10/04/18 - 10/12/18 | 16 ± 4  | 16 ± 4 | 16 ± 4 | 15 ± 4   | 15 ± 4 | 13 ± 4 | 15 ± 4    |
| 10/12/18 - 10/18/18 | 15 ± 4  | 17 ± 4 | 12 ± 4 | 12 ± 4   | 16 ± 4 | 16 ± 4 | 14 ± 4    |
| 10/18/18 - 10/25/18 | 9 ± 4   | 9 ± 4  | 9 ± 4  | 7 ± 4    | 7 ± 4  | 10 ± 4 | 11 ± 4    |
| 10/25/18 - 10/31/18 | 11 ± 4  | 6 ± 4  | 14 ± 4 | 11 ± 4   | 9 ± 4  | 7 ± 4  | 9 ± 4     |
| 10/31/18 - 11/08/18 | 16 ± 4  | 14 ± 3 | 15 ± 3 | 15 ± 3   | 15 ± 3 | 15 ± 4 | 16 ± 4    |
| 11/08/18 - 11/15/18 | 14 ± 4  | 13 ± 4 | 9 ± 3  | 15 ± 4   | 12 ± 4 | 14 ± 4 | 17 ± 4    |
| 11/15/18 - 11/21/18 | 18 ± 5  | 18 ± 5 | 13 ± 4 | 21 ± 5   | 14 ± 4 | 15 ± 5 | 22 ± 5    |
| 11/21/18 - 11/29/18 | 14 ± 4  | 11 ± 3 | 13 ± 3 | 13 ± 4   | 10 ± 3 | 13 ± 4 | 11 ± 3    |
| 11/29/18 - 12/06/18 | 14 ± 4  | 11 ± 4 | 10 ± 3 | 13 ± 4   | 11 ± 4 | 11 ± 4 | 12 ± 4    |
| 12/06/18 - 12/13/18 | 28 ± 5  | 27 ± 5 | 23 ± 4 | 29 ± 5   | 25 ± 5 | 25 ± 5 | 26 ± 5    |
| 12/13/18 - 12/20/18 | 13 ± 4  | 15 ± 4 | 13 ± 4 | 18 ± 5   | 13 ± 4 | 17 ± 4 | 13 ± 4    |
| 12/20/18 - 12/27/18 | 17 ± 4  | 13 ± 4 | 13 ± 4 | 17 ± 4   | 15 ± 4 | 16 ± 4 | 15 ± 4    |
| MEAN ± 2 STD DEV    | 14 ± 9  | 13 ± 8 | 12 ± 8 | 13 ± 10  | 13 ± 9 | 13 ± 9 | 14 ± 9    |

(1) SEE PROGRAM EXCEPTIONS SECTION FOR INFORMATION  
THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

Table C-VI.2

MONTHLY AND YEARLY MEAN VALUES OF GROSS BETA CONCENTRATIONS IN AIR PARTICULATE  
 SAMPLES COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018

RESULTS IN UNITS OF E-3 PC/UCU METER ± 2 SIGMA

| GROUP I - CLOSEST TO THE SITE BOUNDARY |     |     |            |  | GROUP II - INTERMEDIATE OFFSITE |     |     |            |  | GROUP III - CONTROL LOCATIONS |     |     |            |  |
|--|-----|-----|------------|--|---------------------------------|-----|-----|------------|--|-------------------------------|-----|-----|------------|--|
| COLLECTION PERIOD                      | MIN | MAX | MEAN ± 2SD |  | COLLECTION PERIOD               | MIN | MAX | MEAN ± 2SD |  | COLLECTION PERIOD             | MIN | MAX | MEAN ± 2SD |  |
| 01/04/18 - 02/01/18                    | 13  | 21  | 16 ± 6     |  | 01/04/18 - 02/01/18             | 8   | 21  | 14 ± 8     |  | 01/04/18 - 02/01/18           | 14  | 23  | 17 ± 8     |  |
| 02/01/18 - 03/01/18                    | 10  | 18  | 15 ± 6     |  | 02/01/18 - 03/01/18             | 9   | 19  | 13 ± 7     |  | 02/01/18 - 03/01/18           | 12  | 17  | 15 ± 4     |  |
| 03/01/18 - 03/29/18                    | 8   | 16  | 12 ± 6     |  | 03/01/18 - 03/29/18             | 5   | 14  | 10 ± 5     |  | 03/01/18 - 03/29/18           | 10  | 14  | 11 ± 3     |  |
| 03/29/18 - 05/03/18                    | 11  | 19  | 14 ± 5     |  | 03/29/18 - 05/03/18             | 6   | 16  | 10 ± 5     |  | 03/29/18 - 05/03/18           | 12  | 19  | 14 ± 5     |  |
| 05/03/18 - 05/31/18                    | 9   | 21  | 12 ± 9     |  | 05/03/18 - 05/31/18             | 6   | 23  | 12 ± 11    |  | 05/03/18 - 05/31/18           | 7   | 19  | 12 ± 11    |  |
| 05/31/18 - 06/28/18                    | 5   | 15  | 10 ± 6     |  | 05/31/18 - 06/28/18             | 7   | 14  | 10 ± 4     |  | 05/31/18 - 06/28/18           | 6   | 17  | 11 ± 9     |  |
| 06/28/18 - 08/02/18                    | 8   | 14  | 11 ± 4     |  | 06/28/18 - 08/02/18             | 5   | 18  | 12 ± 8     |  | 06/28/18 - 08/02/18           | 7   | 18  | 14 ± 10    |  |
| 08/02/18 - 08/29/18                    | 13  | 25  | 19 ± 9     |  | 08/02/18 - 08/29/18             | 10  | 24  | 19 ± 9     |  | 08/02/18 - 08/29/18           | 16  | 26  | 21 ± 11    |  |
| 08/29/18 - 10/04/18                    | 6   | 14  | 10 ± 6     |  | 08/29/18 - 10/04/18             | 6   | 17  | 11 ± 6     |  | 08/29/18 - 10/04/18           | 8   | 16  | 11 ± 6     |  |
| 10/04/18 - 10/31/18                    | 6   | 17  | 12 ± 8     |  | 10/04/18 - 10/31/18             | 7   | 16  | 12 ± 6     |  | 10/04/18 - 10/31/18           | 9   | 15  | 12 ± 6     |  |
| 10/31/18 - 11/29/18                    | 11  | 18  | 15 ± 5     |  | 10/31/18 - 11/29/18             | 9   | 21  | 14 ± 5     |  | 10/31/18 - 11/29/18           | 11  | 22  | 17 ± 9     |  |
| 11/29/18 - 12/27/18                    | 11  | 28  | 17 ± 13    |  | 11/29/18 - 12/27/18             | 10  | 29  | 17 ± 11    |  | 11/29/18 - 12/27/18           | 12  | 26  | 17 ± 13    |  |
| 01/04/18 - 12/27/18                    | 5   | 28  | 13 ± 9     |  | 01/04/18 - 12/27/18             | 5   | 29  | 13 ± 9     |  | 01/04/18 - 12/27/18           | 6   | 26  | 14 ± 9     |  |

**Table C-VI.3 CONCENTRATIONS OF GAMMA EMITTERS IN AIR PARTICULATE SAMPLES COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF E-3 PCI/CU METER ± 2 SIGMA

| SITE  | COLLECTION          |          | Be-7 | Mn-54 | Co-58 | Co-60 | Nb-95 | Zr-95 | Cs-134 | Cs-137 |
|-------|---------------------|----------|------|-------|-------|-------|-------|-------|--------|--------|
|       | PERIOD              |          |      |       |       |       |       |       |        |        |
| A3-1  | 01/04/18 - 03/29/18 | < 56     | < 4  | < 6   | < 4   | < 6   | < 10  | < 4   | < 4    |        |
|       | 03/29/18 - 06/28/18 | 68 ± 20  | < 1  | < 2   | < 1   | < 1   | < 3   | < 2   | < 2    |        |
|       | 06/28/18 - 09/27/18 | 114 ± 40 | < 3  | < 5   | < 2   | < 7   | < 10  | < 2   | < 2    |        |
|       | 09/27/18 - 12/27/18 | 54 ± 16  | < 3  | < 3   | < 3   | < 3   | < 5   | < 3   | < 3    |        |
|       | MEAN ± 2 STD DEV    | 79 ± 63  | -    | -     | -     | -     | -     | -     | -      |        |
| E1-2  | 01/04/18 - 03/29/18 | 77 ± 22  | < 3  | < 3   | < 3   | < 4   | < 7   | < 3   | < 3    |        |
|       | 03/29/18 - 06/28/18 | 64 ± 22  | < 1  | < 1   | < 3   | < 1   | < 4   | < 1   | < 2    |        |
|       | 06/28/18 - 09/27/18 | 85 ± 40  | < 4  | < 8   | < 2   | < 7   | < 11  | < 3   | < 2    |        |
|       | 09/27/18 - 12/27/18 | 72 ± 22  | < 3  | < 2   | < 3   | < 2   | < 5   | < 2   | < 2    |        |
|       | MEAN ± 2 STD DEV    | 75 ± 18  | -    | -     | -     | -     | -     | -     | -      |        |
| F1-3  | 01/04/18 - 03/29/18 | 71 ± 30  | < 3  | < 3   | < 3   | < 4   | < 7   | < 3   | < 3    |        |
|       | 03/29/18 - 06/28/18 | 86 ± 24  | < 2  | < 2   | < 3   | < 3   | < 5   | < 2   | < 3    |        |
|       | 06/28/18 - 09/27/18 | < 71     | < 3  | < 7   | < 2   | < 7   | < 11  | < 3   | < 2    |        |
|       | 09/27/18 - 12/27/18 | 68 ± 18  | < 1  | < 3   | < 2   | < 2   | < 5   | < 2   | < 2    |        |
|       | MEAN ± 2 STD DEV    | 75 ± 19  | -    | -     | -     | -     | -     | -     | -      |        |
| G2-1  | 01/04/18 - 03/29/18 | 54 ± 26  | < 3  | < 4   | < 3   | < 4   | < 8   | < 3   | < 3    |        |
|       | 03/29/18 - 06/28/18 | 48 ± 26  | < 2  | < 2   | < 3   | < 2   | < 5   | < 3   | < 2    |        |
|       | 06/28/18 - 09/27/18 | 86 ± 45  | < 3  | < 6   | < 3   | < 8   | < 14  | < 2   | < 3    |        |
|       | 09/27/18 - 12/27/18 | 53 ± 22  | < 3  | < 3   | < 4   | < 4   | < 7   | < 3   | < 3    |        |
|       | MEAN ± 2 STD DEV    | 60 ± 34  | -    | -     | -     | -     | -     | -     | -      |        |
| H3-1  | 01/04/18 - 03/29/18 | 69 ± 31  | < 3  | < 4   | < 3   | < 4   | < 7   | < 3   | < 2    |        |
|       | 03/29/18 - 06/28/18 | 78 ± 24  | < 2  | < 2   | < 2   | < 3   | < 4   | < 3   | < 3    |        |
|       | 06/28/18 - 09/27/18 | < 96     | < 4  | < 9   | < 3   | < 9   | < 18  | < 4   | < 3    |        |
|       | 09/27/18 - 12/27/18 | 57 ± 18  | < 3  | < 2   | < 3   | < 3   | < 3   | < 2   | < 2    |        |
|       | MEAN ± 2 STD DEV    | 68 ± 21  | -    | -     | -     | -     | -     | -     | -      |        |
| M2-1  | 01/04/18 - 03/29/18 | 84 ± 23  | < 3  | < 4   | < 4   | < 3   | < 6   | < 3   | < 2    |        |
|       | 03/29/18 - 06/28/18 | 80 ± 21  | < 2  | < 2   | < 2   | < 2   | < 3   | < 2   | < 1    |        |
|       | 06/28/18 - 09/27/18 | < 66     | < 3  | < 5   | < 2   | < 7   | < 12  | < 1   | < 2    |        |
|       | 09/27/18 - 12/27/18 | 59 ± 21  | < 3  | < 2   | < 3   | < 3   | < 5   | < 2   | < 3    |        |
|       | MEAN ± 2 STD DEV    | 74 ± 27  | -    | -     | -     | -     | -     | -     | -      |        |
| Q15-1 | 01/04/18 - 03/29/18 | 56 ± 27  | < 3  | < 3   | < 4   | < 5   | < 7   | < 3   | < 2    |        |
|       | 03/29/18 - 06/28/18 | 71 ± 21  | < 2  | < 2   | < 2   | < 2   | < 4   | < 1   | < 1    |        |
|       | 06/28/18 - 09/27/18 | 140 ± 43 | < 3  | < 7   | < 3   | < 7   | < 13  | < 3   | < 2    |        |
|       | 09/27/18 - 12/27/18 | 47 ± 15  | < 3  | < 3   | < 3   | < 2   | < 5   | < 3   | < 2    |        |
|       | MEAN ± 2 STD DEV    | 78 ± 84  | -    | -     | -     | -     | -     | -     | -      |        |

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**Table C-VII.1 CONCENTRATIONS OF I-131 IN AIR IODINE SAMPLES COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF E-3 PCI/CU METER ± 2 SIGMA

| COLLECTION PERIOD   | GROUP I |      |      | GROUP II |      |      | GROUP III |
|---------------------|---------|------|------|----------|------|------|-----------|
|                     | E1-2    | F1-3 | A3-1 | G2-1     | H3-1 | M2-1 | Q15-1     |
| 01/04/18 - 01/11/18 | < 43    | < 44 | < 35 | < 44     | < 36 | < 34 | < 34      |
| 01/11/18 - 01/18/18 | < 55    | < 56 | < 39 | < 56     | < 40 | < 39 | < 39      |
| 01/18/18 - 01/25/18 | < 50    | < 51 | < 35 | < 51     | < 36 | < 35 | < 35      |
| 01/25/18 - 02/01/18 | < 24    | < 56 | < 56 | < 56     | < 56 | < 58 | < 58      |
| 02/01/18 - 02/08/18 | < 33    | < 34 | < 43 | < 34     | < 44 | < 42 | < 42      |
| 02/08/18 - 02/15/18 | < 46    | < 46 | < 32 | < 47     | < 33 | < 32 | < 31      |
| 02/15/18 - 02/22/18 | < 48    | < 49 | < 24 | < 49     | < 24 | < 24 | < 24      |
| 02/22/18 - 03/01/18 | < 41    | < 42 | < 28 | < 42     | < 29 | < 28 | < 29      |
| 03/01/18 - 03/08/18 | < 63    | < 61 | < 30 | < 64     | < 31 | < 30 | < 25      |
| 03/08/18 - 03/15/18 | < 38    | < 39 | < 26 | < 39     | < 25 | < 25 | < 26      |
| 03/15/18 - 03/23/18 | < 41    | < 42 | < 16 | < 42     | < 20 | < 20 | < 20      |
| 03/23/18 - 03/29/18 | < 47    | < 48 | < 46 | < 48     | < 47 | < 47 | < 47      |
| 03/29/18 - 04/05/18 | < 39    | < 40 | < 27 | < 40     | < 28 | < 27 | < 27      |
| 04/05/18 - 04/12/18 | < 56    | < 57 | < 31 | < 57     | < 31 | < 31 | < 31      |
| 04/12/18 - 04/19/18 | < 55    | < 55 | < 30 | < 56     | < 25 | < 31 | < 31      |
| 04/19/18 - 04/26/18 | < 30    | < 25 | < 48 | < 30     | < 31 | < 20 | < 47      |
| 04/26/18 - 05/03/18 | < 38    | < 32 | < 35 | < 38     | < 39 | < 15 | < 36      |
| 05/03/18 - 05/10/18 | < 59    | < 21 | < 56 | < 60     | < 61 | < 24 | < 56      |
| 05/10/18 - 05/17/18 | < 29    | < 30 | < 44 | < 30     | < 30 | < 45 | < 44      |
| 05/17/18 - 05/24/18 | < 54    | < 51 | < 26 | < 54     | < 65 | < 66 | < 67      |
| 05/24/18 - 05/31/18 | < 21    | < 17 | < 30 | (1)      | < 20 | < 33 | < 34      |
| 05/31/18 - 06/06/18 | < 33    | < 32 | < 18 | < 33     | < 33 | < 49 | < 50      |
| 06/06/18 - 06/13/18 | < 27    | < 26 | < 26 | < 27     | < 27 | < 67 | < 69      |
| 06/13/18 - 06/21/18 | < 20    | < 19 | < 40 | < 20     | < 20 | < 44 | < 45      |
| 06/21/18 - 06/28/18 | < 52    | < 50 | < 23 | < 52     | < 30 | < 30 | < 30      |
| 06/28/18 - 07/05/18 | (1)     | < 44 | < 24 | < 49     | < 46 | < 60 | < 62      |
| 07/05/18 - 07/12/18 | < 58    | < 56 | < 24 | < 59     | < 58 | < 62 | < 64      |
| 07/12/18 - 07/19/18 | < 43    | < 41 | < 51 | < 43     | < 42 | < 58 | < 58      |
| 07/19/18 - 07/26/18 | < 45    | < 43 | < 52 | < 45     | < 45 | < 57 | < 58      |
| 07/26/18 - 08/02/18 | < 63    | < 60 | < 52 | < 63     | < 62 | < 57 | < 57      |
| 08/02/18 - 08/09/18 | < 44    | < 43 | < 18 | < 44     | < 43 | < 47 | < 48      |
| 08/09/18 - 08/16/18 | < 33    | < 27 | < 24 | < 34     | < 33 | < 32 | < 32      |
| 08/16/18 - 08/23/18 | < 40    | < 38 | < 49 | < 40     | < 39 | < 54 | < 55      |
| 08/23/18 - 08/29/18 | < 50    | < 47 | < 61 | < 50     | < 49 | < 63 | < 65      |
| 08/29/18 - 09/06/18 | < 45    | < 44 | < 33 | < 45     | < 45 | < 37 | < 38      |
| 09/06/18 - 09/13/18 | < 54    | < 52 | < 49 | < 54     | < 53 | < 52 | < 53      |
| 09/13/18 - 09/19/18 | < 56    | < 53 | < 36 | < 57     | < 56 | < 42 | < 43      |
| 09/19/18 - 09/27/18 | < 31    | < 30 | < 17 | < 31     | < 42 | < 43 | < 43      |
| 09/27/18 - 10/04/18 | < 41    | < 40 | < 21 | < 42     | < 41 | < 39 | < 41      |
| 10/04/18 - 10/12/18 | < 36    | < 34 | < 16 | < 36     | < 35 | < 32 | < 33      |
| 10/12/18 - 10/18/18 | < 63    | < 61 | < 38 | < 63     | < 62 | < 43 | < 44      |
| 10/18/18 - 10/25/18 | < 40    | < 39 | < 23 | < 40     | < 30 | < 29 | < 30      |
| 10/25/18 - 10/31/18 | < 39    | < 38 | < 42 | < 40     | < 40 | < 45 | < 46      |
| 10/31/18 - 11/08/18 | < 20    | < 19 | < 10 | < 20     | < 19 | < 27 | < 27      |
| 11/08/18 - 11/15/18 | < 53    | < 51 | < 32 | < 54     | < 53 | < 41 | < 42      |
| 11/15/18 - 11/21/18 | < 67    | < 64 | < 30 | < 67     | < 66 | < 60 | < 61      |
| 11/21/18 - 11/29/18 | < 36    | < 35 | < 20 | < 37     | < 36 | < 22 | < 22      |
| 11/29/18 - 12/06/18 | < 48    | < 46 | < 50 | < 48     | < 48 | < 55 | < 56      |
| 12/06/18 - 12/13/18 | < 53    | < 51 | < 21 | < 53     | < 52 | < 55 | < 56      |
| 12/13/18 - 12/20/18 | < 42    | < 40 | < 52 | < 42     | < 41 | < 58 | < 59      |
| 12/20/18 - 12/27/18 | < 46    | < 44 | < 20 | < 46     | < 45 | < 51 | < 52      |
| MEAN                | -       | -    | -    | -        | -    | -    | -         |

(1) SEE PROGRAM EXCEPTIONS SECTION FOR INFORMATION



**TABLE C-VIII.1 CONCENTRATIONS OF I-131 IN MILK SAMPLES COLLECTED  
IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

| COLLECTION<br>PERIOD | CONTROL FARM | INDICATOR FARMS |       |       |       |
|----------------------|--------------|-----------------|-------|-------|-------|
|                      | K15-3        | E2-2            | F4-1  | G2-1  | P4-1  |
| 01/10/18             | < 0.8        | < 0.7           | < 0.9 | < 0.8 | < 0.7 |
| 02/07/18             | < 0.9        | < 0.5           | < 0.9 | < 0.5 | < 0.6 |
| 03/07/18             | < 0.5        | < 0.8           | < 0.6 | < 0.6 | < 0.7 |
| 03/23/18             | < 0.7        | < 0.9           | < 0.7 | < 0.8 | < 0.9 |
| 04/04/18             | < 0.8        | < 0.5           | < 0.6 | < 0.7 | < 0.5 |
| 04/18/18             | < 0.5        | (1)             | < 0.4 | < 0.8 | < 0.5 |
| 05/02/18             | < 0.6        | (1)             | < 0.6 | < 0.5 | < 0.5 |
| 05/16/18             | < 0.9        | (1)             | < 0.8 | < 0.8 | < 0.9 |
| 05/31/18             | < 0.5        | (1)             | < 0.4 | < 0.5 | < 0.5 |
| 06/14/18             | < 0.8        | (1)             | < 0.6 | < 0.6 | < 0.5 |
| 06/27/18             | < 0.5        | (1)             | < 0.5 | < 0.4 | < 1.0 |
| 07/11/18             | < 0.5        | (1)             | < 0.6 | < 0.5 | < 0.9 |
| 07/25/18             | < 0.7        | (1)             | < 0.7 | < 0.7 | < 0.6 |
| 08/08/18             | < 0.7        | (1)             | < 0.9 | < 0.5 | < 0.5 |
| 08/22/18             | < 0.9        | (1)             | < 0.6 | < 0.6 | < 0.9 |
| 09/05/18             | < 0.8        | (1)             | < 0.6 | < 0.8 | < 0.7 |
| 09/19/18             | < 0.5        | (1)             | < 0.5 | < 0.5 | < 0.5 |
| 10/03/18             | < 0.6        | (1)             | < 0.5 | < 0.5 | < 0.5 |
| 10/17/18             | < 0.8        | (1)             | < 0.8 | < 0.7 | < 0.5 |
| 10/31/18             | < 0.4        | (1)             | < 0.5 | < 0.9 | < 0.8 |
| 11/14/18             | < 0.9        | (1)             | < 0.7 | < 0.8 | < 0.7 |
| 11/29/18             | < 0.6        | (1)             | < 0.6 | < 0.5 | < 0.8 |
| 12/12/18             | < 0.5        | (1)             | < 0.4 | < 0.7 | < 0.8 |
| MEAN                 | -            | -               | -     | -     | -     |

(1) SEE PROGRAM EXCEPTIONS SECTION FOR INFORMATION

**Table C-VIII.2**

**CONCENTRATIONS OF STRONTIUM IN MILK SAMPLES COLLECTED IN  
THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

| COLLECTION PERIOD   | CONTROL FARM |       | INDICATOR FARMS |        |           |       |       |       |       |       |       |       |       |
|---------------------|--------------|-------|-----------------|--------|-----------|-------|-------|-------|-------|-------|-------|-------|-------|
|                     | Sr-89        | Sr-90 | K15-3           | E2-2   | Sr-89     | Sr-90 | F4-1  | Sr-89 | Sr-90 | G2-1  | Sr-89 | Sr-90 | P4-1  |
| 01/10/18 - 03/21/18 | < 1.5        | < 0.8 |                 | < 1.9  | < 0.8     |       | < 2.1 | < 0.6 |       | < 4.0 | < 3.6 |       | < 0.7 |
| 04/04/18 - 06/27/18 | < 2.9        | < 0.6 |                 | < 12.5 | 1.6 ± 0.6 |       | < 4.3 | < 1.0 |       | < 4.5 | < 2.7 |       | < 0.7 |
| 07/11/18 - 09/19/18 | < 3.7        | < 0.8 |                 | (1)    | (1)       |       | < 4.4 | < 0.9 |       | < 3.3 | < 4.2 |       | < 0.8 |
| 10/03/18 - 12/12/18 | < 3.7        | < 0.8 |                 | (1)    | (1)       |       | < 3.3 | < 0.9 |       | < 3.6 | < 4.2 |       | < 0.6 |
| MEAN ± 2 STD DEV    | -            | -     |                 | -      | 1.6 ± 0   |       | -     | -     |       | -     | -     |       | -     |

(1) SEE PROGRAM EXCEPTIONS SECTION FOR INFORMATION  
THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**Table C-VIII.3 CONCENTRATIONS OF GAMMA EMITTERS IN MILK SAMPLES COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

| SITE                | COLLECTION           |                      |                |        |        |        |
|---------------------|----------------------|----------------------|----------------|--------|--------|--------|
|                     | PERIOD               | K-40                 | Cs-134         | Cs-137 | Ba-140 | La-140 |
| K15-3               | 01/10/18             | 1187 $\pm$ 197       | < 7            | < 8    | < 27   | < 10   |
|                     | 02/07/18             | 1349 $\pm$ 202       | < 10           | < 8    | < 35   | < 8    |
|                     | 3/7/2018             | 1263 $\pm$ 166       | < 7            | < 6    | < 31   | < 7    |
|                     | 03/23/18             | 1357 $\pm$ 175       | < 8            | < 8    | < 28   | < 7    |
|                     | 04/04/18             | 1160 $\pm$ 206       | < 11           | < 10   | < 30   | < 9    |
|                     | 04/18/18             | 1223 $\pm$ 143       | < 8            | < 9    | < 32   | < 9    |
|                     | 05/02/18             | 1188 $\pm$ 172       | < 8            | < 7    | < 47   | < 13   |
|                     | 05/16/18             | 1199 $\pm$ 139       | < 7            | < 7    | < 29   | < 6    |
|                     | 05/30/18             | 1226 $\pm$ 149       | < 8            | < 6    | < 45   | < 14   |
|                     | 06/13/18             | 1315 $\pm$ 168       | < 8            | < 8    | < 37   | < 6    |
|                     | 06/27/18             | 1377 $\pm$ 188       | < 11           | < 8    | < 34   | < 13   |
|                     | 07/11/18             | 1311 $\pm$ 178       | < 9            | < 9    | < 37   | < 11   |
|                     | 07/25/18             | 1410 $\pm$ 153       | < 7            | < 7    | < 30   | < 6    |
|                     | 08/08/18             | 1382 $\pm$ 164       | < 8            | < 9    | < 38   | < 8    |
|                     | 08/22/18             | 1315 $\pm$ 213       | < 9            | < 8    | < 49   | < 14   |
|                     | 09/05/18             | 1070 $\pm$ 178       | < 9            | < 9    | < 42   | < 13   |
|                     | 09/19/18             | 1158 $\pm$ 172       | < 8            | < 8    | < 40   | < 8    |
| 10/03/18            | 1273 $\pm$ 172       | < 8                  | < 7            | < 53   | < 10   |        |
| 10/17/18            | 1245 $\pm$ 162       | < 8                  | < 7            | < 50   | < 14   |        |
| 10/31/18            | 1174 $\pm$ 152       | < 7                  | < 7            | < 35   | < 8    |        |
| 11/14/18            | 1135 $\pm$ 149       | < 8                  | < 8            | < 46   | < 12   |        |
| 11/28/18            | 1273 $\pm$ 151       | < 8                  | < 7            | < 44   | < 11   |        |
| 12/12/18            | 1176 $\pm$ 181       | < 7                  | < 6            | < 24   | < 8    |        |
|                     | MEAN $\pm$ 2 STD DEV | 1251 $\pm$ 180       | -              | -      | -      | -      |
| E2-2 <sup>(1)</sup> | 01/10/18             | 1188 $\pm$ 215       | < 10           | < 9    | < 38   | < 15   |
|                     | 02/07/18             | 1253 $\pm$ 214       | < 8            | < 7    | < 39   | < 13   |
|                     | 03/07/18             | 1171 $\pm$ 169       | < 8            | < 7    | < 31   | < 11   |
|                     | 03/23/18             | 1368 $\pm$ 143       | < 7            | < 6    | < 24   | < 5    |
|                     | 04/04/18             | 1031 $\pm$ 124       | < 6            | < 5    | < 18   | < 3    |
|                     |                      | MEAN $\pm$ 2 STD DEV | 1202 $\pm$ 246 | -      | -      | -      |
| F4-1                | 01/10/18             | 1127 $\pm$ 166       | < 9            | < 8    | < 38   | < 8    |
|                     | 02/07/18             | 1321 $\pm$ 184       | < 9            | < 8    | < 26   | < 9    |
|                     | 03/07/18             | 1310 $\pm$ 169       | < 12           | < 11   | < 45   | < 11   |
|                     | 03/23/18             | 1297 $\pm$ 216       | < 9            | < 8    | < 36   | < 10   |
|                     | 04/04/18             | 1281 $\pm$ 152       | < 7            | < 8    | < 17   | < 5    |
|                     | 04/18/18             | 1257 $\pm$ 139       | < 6            | < 6    | < 28   | < 7    |
|                     | 05/02/18             | 1486 $\pm$ 192       | < 7            | < 9    | < 54   | < 13   |
|                     | 05/16/18             | 1156 $\pm$ 156       | < 6            | < 7    | < 30   | < 8    |
|                     | 05/30/18             | 1491 $\pm$ 225       | < 7            | < 9    | < 43   | < 10   |
|                     | 06/13/18             | 1138 $\pm$ 167       | < 8            | < 7    | < 31   | < 11   |
|                     | 06/27/18             | 1289 $\pm$ 196       | < 10           | < 9    | < 44   | < 10   |
|                     | 07/11/18             | 1464 $\pm$ 191       | < 9            | < 8    | < 38   | < 8    |
|                     | 07/25/18             | 1324 $\pm$ 140       | < 9            | < 8    | < 33   | < 11   |
|                     | 08/08/18             | 1418 $\pm$ 171       | < 8            | < 8    | < 35   | < 8    |
|                     | 08/22/18             | 1286 $\pm$ 198       | < 11           | < 9    | < 47   | < 11   |
|                     | 09/05/18             | 1267 $\pm$ 210       | < 8            | < 7    | < 37   | < 8    |
|                     | 09/19/18             | 1462 $\pm$ 182       | < 3            | < 4    | < 26   | < 5    |
| 10/03/18            | 1494 $\pm$ 174       | < 8                  | < 7            | < 52   | < 14   |        |
| 10/17/18            | 1369 $\pm$ 145       | < 6                  | < 6            | < 41   | < 14   |        |
| 10/31/18            | 834 $\pm$ 86         | < 3                  | < 3            | < 14   | < 6    |        |
| 11/14/18            | 1254 $\pm$ 192       | < 8                  | < 7            | < 45   | < 13   |        |
| 11/29/18            | 1379 $\pm$ 159       | < 6                  | < 7            | < 42   | < 13   |        |
| 12/12/18            | 1104 $\pm$ 133       | < 7                  | < 7            | < 24   | < 6    |        |
|                     | MEAN $\pm$ 2 STD DEV | 1296 $\pm$ 309       | -              | -      | -      | -      |

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES  
(1) SEE PROGRAM EXCEPTIONS SECTION FOR INFORMATION

Table C-VIII.3

**CONCENTRATIONS OF GAMMA EMITTERS IN MILK SAMPLES COLLECTED  
IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

| SITE     | COLLECTION                             |                |        |        |        |        |
|----------|--|----------------|--------|--------|--------|--------|
|          | PERIOD                                 | K-40           | Cs-134 | Cs-137 | Ba-140 | La-140 |
| G2-1     | 1/10/2018                              | 1034 $\pm$ 206 | < 10   | < 10   | < 45   | < 12   |
|          | 02/07/18                               | 994 $\pm$ 258  | < 15   | < 10   | < 44   | < 13   |
|          | 03/07/18                               | 1335 $\pm$ 210 | < 8    | < 9    | < 36   | < 14   |
|          | 03/21/18                               | 1207 $\pm$ 186 | < 9    | < 7    | < 39   | < 12   |
|          | 04/04/18                               | 1262 $\pm$ 177 | < 8    | < 7    | < 20   | < 10   |
|          | 04/18/18                               | 1259 $\pm$ 147 | < 7    | < 8    | < 26   | < 8    |
|          | 05/02/18                               | 1096 $\pm$ 133 | < 6    | < 6    | < 41   | < 13   |
|          | 05/16/18                               | 1326 $\pm$ 138 | < 6    | < 5    | < 27   | < 8    |
|          | 05/30/18                               | 1221 $\pm$ 146 | < 6    | < 6    | < 40   | < 11   |
|          | 06/13/18                               | 1279 $\pm$ 170 | < 8    | < 7    | < 38   | < 11   |
|          | 06/27/18                               | 1181 $\pm$ 153 | < 8    | < 8    | < 31   | < 9    |
|          | 07/11/18                               | 1361 $\pm$ 201 | < 8    | < 7    | < 29   | < 11   |
|          | 07/25/18                               | 964 $\pm$ 142  | < 8    | < 8    | < 30   | < 10   |
|          | 08/08/18                               | 1262 $\pm$ 196 | < 10   | < 9    | < 32   | < 8    |
|          | 08/22/18                               | 1165 $\pm$ 196 | < 12   | < 10   | < 39   | < 10   |
|          | 09/05/18                               | 1296 $\pm$ 203 | < 9    | < 8    | < 34   | < 11   |
|          | 09/19/18                               | 1324 $\pm$ 153 | < 7    | < 6    | < 33   | < 7    |
|          | 10/03/18                               | 1147 $\pm$ 125 | < 6    | < 6    | < 39   | < 11   |
|          | 10/17/18                               | 1000 $\pm$ 151 | < 8    | < 7    | < 51   | < 12   |
|          | 10/31/18                               | 1328 $\pm$ 183 | < 8    | < 9    | < 42   | < 10   |
| 11/14/18 | 1089 $\pm$ 137                         | < 7            | < 6    | < 41   | < 11   |        |
| 11/29/18 | 1105 $\pm$ 143                         | < 6            | < 6    | < 39   | < 11   |        |
| 12/12/18 | 1149 $\pm$ 149                         | < 7            | < 6    | < 23   | < 8    |        |
|          | <i>MEAN <math>\pm</math> 2 STD DEV</i> | 1191 $\pm$ 242 | -      | -      | -      | -      |
| P4-1     | 01/10/18                               | 1286 $\pm$ 168 | < 10   | < 10   | < 44   | < 9    |
|          | 02/07/18                               | 1255 $\pm$ 181 | < 8    | < 9    | < 30   | < 10   |
|          | 03/07/18                               | 1424 $\pm$ 204 | < 6    | < 11   | < 34   | < 10   |
|          | 03/23/18                               | 1397 $\pm$ 189 | < 8    | < 7    | < 25   | < 12   |
|          | 04/04/18                               | 939 $\pm$ 171  | < 10   | < 8    | < 30   | < 11   |
|          | 04/18/18                               | 1266 $\pm$ 186 | < 7    | < 8    | < 35   | < 7    |
|          | 05/02/18                               | 1041 $\pm$ 113 | < 6    | < 6    | < 41   | < 12   |
|          | 05/16/18                               | 887 $\pm$ 133  | < 6    | < 7    | < 35   | < 9    |
|          | 05/31/18                               | 1224 $\pm$ 218 | < 10   | < 9    | < 46   | < 14   |
|          | 06/14/18                               | 1098 $\pm$ 195 | < 10   | < 8    | < 47   | < 13   |
|          | 06/27/18                               | 1354 $\pm$ 187 | < 7    | < 8    | < 33   | < 8    |
|          | 07/11/18                               | 1374 $\pm$ 201 | < 9    | < 8    | < 33   | < 11   |
|          | 07/25/18                               | 1388 $\pm$ 222 | < 10   | < 8    | < 47   | < 11   |
|          | 08/08/18                               | 1535 $\pm$ 202 | < 9    | < 6    | < 33   | < 12   |
|          | 08/22/18                               | 1524 $\pm$ 216 | < 10   | < 8    | < 37   | < 8    |
|          | 09/05/18                               | 1259 $\pm$ 179 | < 9    | < 10   | < 31   | < 12   |
|          | 09/19/18                               | 1323 $\pm$ 204 | < 9    | < 8    | < 39   | < 8    |
|          | 10/03/18                               | 936 $\pm$ 149  | < 7    | < 6    | < 45   | < 13   |
|          | 10/17/18                               | 1272 $\pm$ 121 | < 6    | < 5    | < 39   | < 12   |
|          | 10/31/18                               | 1240 $\pm$ 150 | < 8    | < 8    | < 38   | < 7    |
| 11/14/18 | 1168 $\pm$ 167                         | < 7            | < 7    | < 37   | < 11   |        |
| 11/29/18 | 1347 $\pm$ 155                         | < 7            | < 8    | < 37   | < 14   |        |
| 12/12/18 | 1288 $\pm$ 152                         | < 7            | < 6    | < 22   | < 5    |        |
|          | <i>MEAN <math>\pm</math> 2 STD DEV</i> | 1253 $\pm$ 350 | -      | -      | -      | -      |

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**Table C-IX.1 CONCENTRATIONS OF STRONTIUM AND GAMMA EMITTERS IN FOOD PRODUCT SAMPLES COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/KG WET ± 2 SIGMA

| SITE                    | COLLECTION PERIOD | Sr-90       | Be-7        | K-40        | I-131 | Cs-134 | Cs-137 |
|-------------------------|-------------------|-------------|-------------|-------------|-------|--------|--------|
| <u>B10-2</u>            |                   |             |             |             |       |        |        |
| <i>Kale</i>             | 06/28/18          | < 4.0       | 653 ± 303   | 3686 ± 550  | < 57  | < 36   | < 32   |
| <i>Cabbage</i>          | 06/28/18          | 4.8 ± 0.7   | 362 ± 222   | 3189 ± 589  | < 57  | < 39   | < 27   |
| <i>Brussels Sprouts</i> | 06/28/18          | 8.3 ± 0.9   | 697 ± 207   | 3749 ± 432  | < 56  | < 22   | < 21   |
| <i>Kale</i>             | 07/25/18          | 5.0 ± 1.2   | 3476 ± 213  | 3038 ± 323  | < 27  | < 16   | < 17   |
| <i>Cabbage</i>          | 07/25/18          | 12.8 ± 1.7  | 733 ± 349   | 4177 ± 677  | < 46  | < 38   | < 34   |
| <i>Brussels Sprouts</i> | 07/25/18          | 9.4 ± 1.4   | 814 ± 169   | 4684 ± 366  | < 31  | < 21   | < 19   |
| <i>Corn</i>             | 08/09/18          | < 2.9       | < 204       | 3489 ± 457  | < 37  | < 29   | < 26   |
| <i>Tomato</i>           | 08/09/18          | < 4.0       | < 169       | 2032 ± 435  | < 32  | < 21   | < 20   |
| <i>Watermelon</i>       | 08/22/18          | 38.0 ± 2.2  | 3431 ± 370  | 4088 ± 556  | < 40  | < 38   | < 30   |
| <i>Pumpkin</i>          | 08/22/18          | 17.4 ± 2.1  | 1001 ± 293  | 3535 ± 482  | < 33  | < 19   | < 23   |
| <i>Suflower</i>         | 08/22/18          | 7.9 ± 1.8   | 1914 ± 165  | 7286 ± 382  | < 19  | < 14   | < 13   |
| <i>Sweet Potato</i>     | 10/16/18          | < 2.3       | < 148       | 4173 ± 386  | < 34  | < 18   | < 17   |
|                         | MEAN ± 2 STD DEV  | 12.9 ± 21.9 | 1453 ± 2424 | 3927 ± 2513 | -     | -      | -      |
| <u>E1-2</u>             |                   |             |             |             |       |        |        |
| <i>Kale</i>             | 06/28/18          | 1.6 ± 0.6   | 297 ± 86    | 5615 ± 241  | < 18  | < 11   | < 10   |
| <i>Cabbage</i>          | 06/28/18          | 8.9 ± 1.9   | < 231       | 4851 ± 674  | < 44  | < 35   | < 31   |
| <i>Collards</i>         | 06/28/18          | 1.2 ± 0.6   | 398 ± 234   | 4997 ± 800  | < 53  | < 38   | < 35   |
| <i>Kale</i>             | 07/25/18          | < 1.5       | 1074 ± 330  | 2733 ± 556  | < 53  | < 34   | < 28   |
| <i>Cabbage</i>          | 07/25/18          | < 1.6       | 1253 ± 302  | 4529 ± 594  | < 45  | < 29   | < 29   |
| <i>Brussels Spouts</i>  | 07/25/18          | 6.1 ± 1.4   | 1094 ± 313  | 2837 ± 546  | < 45  | < 34   | < 23   |
| <i>Corn</i>             | 08/09/18          | < 3.7       | < 158       | 3800 ± 527  | < 37  | < 26   | < 18   |
| <i>Tomato</i>           | 08/09/18          | < 3.5       | < 170       | 1946 ± 343  | < 33  | < 21   | < 19   |
| <i>Kale</i>             | 08/22/18          | < 1.1       | 1087 ± 172  | 1993 ± 242  | < 21  | < 15   | < 14   |
| <i>Cabbage</i>          | 08/22/18          | < 2.6       | 1327 ± 283  | 4500 ± 582  | < 37  | < 30   | < 29   |
| <i>Collards</i>         | 08/22/18          | < 2.5       | 682 ± 243   | 2828 ± 439  | < 33  | < 21   | < 21   |
| <i>Sweet Potato</i>     | 10/16/18          | < 3.2       | < 102       | 4306 ± 383  | < 26  | < 14   | < 13   |
|                         | MEAN ± 2 STD DEV  | 4.4 ± 7.4   | 902 ± 783   | 3745 ± 2471 | -     | -      | -      |
| <u>H1-2</u>             |                   |             |             |             |       |        |        |
| <i>Squash</i>           | 06/28/18          | 11.3 ± 1.4  | 716 ± 87    | 3406 ± 206  | < 15  | < 9    | < 9    |
| <i>Zucchini</i>         | 06/28/18          | < 3.1       | 1313 ± 326  | 4499 ± 587  | < 44  | < 28   | < 25   |
| <i>Cucumber</i>         | 06/28/18          | 2.5 ± 1.1   | 1714 ± 133  | 4502 ± 247  | < 21  | < 12   | < 12   |
| <i>Squash</i>           | 07/25/18          | 29.2 ± 4.0  | 5490 ± 507  | 2326 ± 552  | < 55  | < 34   | < 30   |
| <i>Zucchini</i>         | 07/25/18          | 16.3 ± 1.8  | 2397 ± 455  | 3569 ± 674  | < 47  | < 37   | < 34   |
| <i>Cucumber</i>         | 07/25/18          | 34.5 ± 3.1  | 2513 ± 382  | 3441 ± 642  | < 43  | < 32   | < 30   |
| <i>Squash</i>           | 08/22/18          | 18.3 ± 2.1  | 2305 ± 496  | 2905 ± 628  | < 49  | < 31   | < 35   |
| <i>Pumpkin</i>          | 08/22/18          | 27.5 ± 3.6  | 2250 ± 317  | 2465 ± 513  | < 41  | < 31   | < 28   |
| <i>Cucumber</i>         | 08/22/18          | 15.7 ± 1.6  | 1222 ± 243  | 3423 ± 496  | < 38  | < 23   | < 27   |
|                         | MEAN ± 2 STD DEV  | 19.4 ± 20.9 | 2213 ± 2753 | 3393 ± 1537 | -     | -      | -      |

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**Table C-X.1 QUARTERLY OSLD RESULTS FOR THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF MILLIREM/QUARTER

| STATION<br>CODE | MEAN<br>± 2 S.D. | JAN - MAR | APR - JUN | JUL - SEP | OCT - DEC |
|-----------------|------------------|-----------|-----------|-----------|-----------|
| A1-4            | 13.7 ± 4.6       | 13.1      | 17.0      | 12.9      | 11.7      |
| A3-1            | 13.3 ± 4.3       | 11.9      | 16.3      | 13.2      | 11.6      |
| A5-1            | 16.6 ± 4.0       | 14.9      | 19.4      | 16.5      | 15.6      |
| A9-3            | 14.3 ± 3.5       | 14.1      | 16.5      | 14.2      | 12.2      |
| B1-1            | 14.4 ± 4.1       | 13.6      | 17.3      | 14.3      | 12.5      |
| B1-2            | 13.9 ± 3.6       | 13.4      | 16.4      | 13.6      | 12.1      |
| B2-1            | 14.6 ± 4.4       | 13.5      | 17.6      | 14.8      | 12.6      |
| B5-1            | 16.3 ± 4.4       | 14.2      | 19.0      | 17.0      | 14.8      |
| C1-1            | 16.0 ± 3.6       | 15.5      | 18.5      | 15.8      | 14.2      |
| C1-2            | 13.7 ± 4.9       | 11.9      | 17.2      | 13.5      | 12.1      |
| C2-1            | 15.7 ± 4.8       | 15.8      | 18.6      | 15.6      | 12.7      |
| C5-1            | 17.2 ± 3.2       | 17.1      | 19.4      | 16.2      | 15.9      |
| C8-1            | 18.0 ± 4.2       | 19.6      | 19.7      | 17.1      | 15.4      |
| D1-1            | 14.4 ± 3.8       | 13.9      | 17.2      | 13.4      | 13.1      |
| D1-2            | 15.7 ± 4.7       | 14.7      | 19.0      | 15.6      | 13.5      |
| D2-2            | 19.7 ± 4.1       | 18.6      | 22.3      | 20.3      | 17.7      |
| D6-1            | 19.1 ± 3.3       | 19.6      | 21.2      | 18.4      | 17.3      |
| E1-2            | 14.7 ± 4.6       | 15.1      | 17.0      | 15.1      | 11.5      |
| E1-4            | 14.1 ± 4.0       | 13.8      | 16.9      | 13.5      | 12.2      |
| E2-3            | 17.1 ± 6.2       | 14.4      | 20.8      | 18.6      | 14.7      |
| E5-1            | 18.5 ± 5.1       | 17.1      | 22.1      | 18.6      | 16.3      |
| E7-1            | 17.0 ± 4.7       | 18.9      | 19.0      | 15.4      | 14.5      |
| F1-1            | 16.2 ± 3.8       | 17.5      | 17.9      | 15.3      | 13.9      |
| F1-2            | 15.3 ± 4.4       | 14.3      | 18.4      | 15.0      | 13.4      |
| F1-4            | 14.3 ± 4.6       | 13.4      | 17.5      | 13.9      | 12.2      |
| F2-1            | 18.8 ± 4.6       | 20.4      | 21.0      | 17.4      | 16.2      |
| F5-1            | 18.9 ± 5.2       | 17.7      | 22.6      | 18.4      | 16.7      |
| G1-2            | 17.6 ± 4.3       | 19.3      | 19.2      | 17.1      | 14.7      |
| G1-3            | 13.7 ± 3.8       | 13.5      | 15.9      | 13.9      | 11.3      |
| G1-5            | 14.4 ± 6.6       | 12.5      | 19.3      | 13.6      | 12.3      |
| G1-6            | 14.6 ± 3.5       | 13.9      | 17.1      | 14.1      | 13.1      |
| G2-4            | 21.5 ± 5.2       | 24.9      | 22.0      | 19.9      | 19.0      |
| G5-1            | 17.6 ± 6.6       | 22.4      | 16.3      | 16.5      | 15.1      |
| H1-1            | 15.7 ± 5.1       | 14.4      | 18.9      | 16.4      | 13.0      |
| H3-1            | 12.9 ± 3.7       | 12.8      | 15.3      | 12.8      | 10.8      |
| H5-1            | 11.7 ± 5.2       | 10.8      | 15.3      | 11.4      | 9.1       |
| H8-1            | 26.6 ± 6.3       | 23.9      | 30.4      | 27.9      | 24.1      |
| J1-1            | 14.9 ± 3.9       | 14.9      | 17.1      | 15.2      | 12.4      |
| J1-3            | 12.0 ± 3.8       | 11.7      | 14.3      | 12.1      | 9.7       |
| J3-1            | 16.2 ± 4.0       | 14.7      | 19.1      | 15.8      | 15.0      |
| J5-1            | 17.7 ± 4.5       | 15.9      | 20.9      | 17.6      | 16.4      |
| J7-1            | 19.4 ± 4.6       | 18.4      | 22.8      | 18.9      | 17.6      |
| K1-4            | 14.8 ± 3.5       | 14.7      | 17.1      | 14.3      | 12.9      |
| K2-1            | 18.9 ± 3.1       | 17.8      | 20.8      | 17.5      | 19.6      |
| K3-1            | 14.3 ± 5.2       | 12.5      | 17.9      | 14.5      | 12.2      |
| K5-1            | 17.1 ± 4.8       | 14.3      | 20.0      | 17.6      | 16.4      |
| K8-1            | 16.2 ± 5.2       | 14.4      | 19.6      | 16.9      | 14.0      |

(1) SEE PROGRAM EXCEPTIONS SECTION FOR INFORMATION

**Table C-X.1 QUARTERLY OSLD RESULTS FOR THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF MILLIREM/QUARTER

| STATION<br>CODE | MEAN<br>± 2 S.D. | JAN - MAR | APR - JUN | JUL - SEP | OCT - DEC |
|-----------------|------------------|-----------|-----------|-----------|-----------|
| L1-1            | 14.4 ± 4.3       | 14.6      | 16.8      | 14.4      | 11.6      |
| L1-2            | 14.1 ± 3.3       | 13.9      | 16.5      | 13.0      | 13.1      |
| L2-1            | 15.3 ± 4.8       | 13.9      | 18.1      | 16.3      | 12.7      |
| L5-1            | 14.0 ± 4.6       | 12.9      | 17.3      | 13.7      | 12.1      |
| L8-1            | 15.5 ± 4.8       | 14.5      | 18.6      | 15.9      | 13.0      |
| M1-1            | 14.3 ± 4.1       | 13.0      | 17.3      | 13.9      | 12.9      |
| M1-2            | 15.5 ± 3.0       | 15.5      | 17.5      | 14.8      | 14        |
| M2-1            | 13.8 ± 4.9       | 12.4      | 17.4      | 13.3      | 12.1      |
| M5-1            | 15.6 ± 5.5       | 14.1      | 18.7      | 16.8      | 12.6      |
| M9-1            | 20.1 ± 6.0       | 18.6      | 24.3      | 20.2      | 17.4      |
| N1-1            | 15.1 ± 3.1       | 14.9      | 17.3      | 14.4      | 13.8      |
| N1-3            | 14.1 ± 4.0       | 13.4      | 16.6      | 14.4      | 11.8      |
| N2-1            | 16.6 ± 4.2       | 14.4      | 19.3      | 17.1      | 15.7      |
| N5-1            | 13.3 ± 4.3       | 12.6      | 16.4      | 12.7      | 11.4      |
| N8-1            | 16.9 ± 3.5       | 16.3      | 19.0      | 17.4      | 14.8      |
| P1-1            | 15.1 ± 2.6       | 14.9      | 16.8      | 13.7      | 15        |
| P1-2            | 14.5 ± 5.2       | 16.9      | 16.1      | 13.9      | 11.1      |
| P2-1            | 18.9 ± 5.1       | 17.1      | 22.6      | 18.6      | 17.4      |
| P5-1            | 15.7 ± 4.0       | 14.3      | 18.5      | 15.9      | 14.2      |
| P8-1            | 13.4 ± 3.8       | 12.6      | 16.2      | 11.9      | 13.0      |
| Q1-1            | 15.4 ± 3.2       | 15.2      | 17.6      | 14.8      | 13.8      |
| Q1-2            | 12.9 ± 3.9       | 13.3      | 15.3      | 12.2      | 10.7      |
| Q2-1            | 13.5 ± 5.7       | 11.3      | 17.4      | 13.9      | 11.4      |
| Q5-1            | 14.2 ± 4.0       | 13.2      | 17.0      | 14.0      | 12.5      |
| Q9-1            | 15.7 ± 4.8       | 13.8      | 18.9      | 16.0      | 13.9      |
| R1-1            | 14.4 ± 4.2       | 14.9      | 16.8      | 13.9      | 11.8      |
| R1-2            | 13.8 ± 2.8       | 13.4      | 15.9      | 12.8      | 13.2      |
| R3-1            | 18.0 ± 3.4       | 18.0      | 20.1      | 18.1      | 15.9      |
| R5-1            | 17.9 ± 3.9       | 16.5      | 20.8      | 17.3      | 17.0      |
| R9-1            | 16.6 ± 3.4       | 17.6      | 15.9      | 18.2      | 14.5      |
| B10-1           | 15.8 ± 3.2       | 16.1      | 17.9      | 15.2      | 14.1      |
| D15-1           | 16.3 ± 4.0       | 15.6      | 19.0      | 16.3      | 14.2      |
| F10-1           | 19.3 ± 5.3       | 16.2      | 22.7      | 19.3      | 19.0      |
| F25-1           | 18.4 ± 5.1       | 18.5      | 21.9      | 17.5      | 15.8      |
| G10-1           | 22.5 ± 8.5       | 17.1      | 27.3      | 23.8      | 21.9      |
| G15-1           | 22.1 ± 3.2       | 23.8      | 22.8      | 21.7      | 20.1      |
| H15-1           | 16.1 ± 5.3       | 13.2      | 19.6      | 15.9      | 15.5      |
| J15-1           | 19.5 ± 4.8       | 17.3      | 22.9      | 19.0      | 18.6      |
| K15-1           | 15.7 ± 3.4       | 13.7      | 17.8      | 15.8      | 15.6      |
| L15-1           | 16.9 ± 5.5       | 14.6      | 20.6      | 17.3      | 15.1      |
| N15-2           | 18.3 ± 3.3       | 16.7      | 20.4      | 18.8      | 17.3      |
| Q15-1           | 17.7 ± 4.7       | 15.9      | 20.5      | 18.8      | 15.6      |
| R15-1           | 15.1 ± 2.3       | 15.7      | 15.9      | 15.3      | 13.4      |

(1) SEE PROGRAM EXCEPTIONS SECTION FOR INFORMATION

**TABLE C-X.2 MEAN QUARTERLY OSLD RESULTS FOR THE SITE BOUNDARY, INDICATOR CONTROL LOCATIONS FOR THREE MILE ISLAND NUCLEAR STATION, 2018**

RESULTS IN UNITS OF MILLIREM/QUARTER  
 $\pm 2$  STANDARD DEVIATIONS OF THE STATION DATA

| COLLECTION PERIOD | SITE BOUNDARY<br>$\pm 2$ STD DEV | INDICATOR      | CONTROL        |
|-------------------|----------------------------------|----------------|----------------|
| JAN-MAR           | 13.7 $\pm$ 2.3                   | 15.8 $\pm$ 5.8 | 16.6 $\pm$ 5.7 |
| APR-JUN           | 17.0 $\pm$ 2.3                   | 19.0 $\pm$ 5.2 | 20.8 $\pm$ 6.0 |
| JUL-SEP           | 13.8 $\pm$ 1.9                   | 16.2 $\pm$ 5.2 | 18.2 $\pm$ 5.3 |
| OCT-DEC           | 12.1 $\pm$ 1.9                   | 14.6 $\pm$ 5.0 | 16.6 $\pm$ 5.2 |

**TABLE C-X.3 SUMMARY OF THE AMBIENT DOSIMETRY PROGRAM FOR THREE MILE ISLAND NUCLEAR STATION, 2018**

RESULTS IN UNITS OF MILLIREMQUARTER

| LOCATION      | SAMPLES ANALYZED | PERIOD MINIMUM | PERIOD MAXIMUM | PERIOD MEAN<br>$\pm 2$ STD DEV |
|---------------|------------------|----------------|----------------|--------------------------------|
| SITE BOUNDARY | 76               | 9.7            | 19.3           | 14.1 $\pm$ 4.1                 |
| INDICATOR     | 240              | 9.1            | 30.4           | 16.4 $\pm$ 6.2                 |
| CONTROL       | 44               | 13.2           | 27.3           | 18.0 $\pm$ 6.4                 |



**SITE BOUNDARY STATIONS** - A1-4, B1-2, C1-2, D1-1, E1-4, F1-2, F1-4, G1-3, G1-5, G1-6, H1-1, J1-3, K1-4, L1-1, M1-1, N1-3, P1-2, Q1-2, R1-1

**INDICATOR STATIONS** - A3-1, A5-1, A9-3, B1-1, B10-1, B2-1, B5-1, C1-1, C2-1, C5-1, C8-1, D1-2, D2-2, D6-1, E1-2, E2-3, E5-1, E7-1, F1-1, F10-1, F2-1, F5-1, G1-2, G2-4, G5-1, H3-1, H5-1, H8-1, J1-1, J3-1, J5-1, J7-1, K2-1, K3-1, K5-1, K8-1, L1-2, L2-1, L5-1, L8-1, M1-2, M2-1, M5-1, M9-1, N1-1, N2-1, N5-1, N8-1, P1-1, P2-1, P5-1, Q1-1, Q2-1, Q5-1, Q9-1, R1-2, R3-1, R5-1, R9-1


**CONTROL STATIONS** - D15-1, F25-1, G10-1, G15-1, H15-1, J15-1, K15-1, L15-1, N15-1, Q15-1, R15-1




**FIGURE C-1**  
**Monthly Tritium Concentrations in Surface Water and Effluent Water**  
**Three Mile Island Nuclear Station, 2018**





**FIGURE C-2**  
**Mean Quarterly Tritium Concentrations in Surface Water**  
**Three Mile Island Nuclear Station, 1974 - 2018**




**FIGURE C-3**  
**Mean Monthly Gross Beta Concentrations in Drinking Water**  
**Three Mile Island Nuclear Station, 2018**




**FIGURE C-4**  
**Mean Monthly Tritium Concentrations in Drinking Water and Effluent Water**  
**Three Mile Island Nuclear Station, 2018**




**FIGURE C-5**  
**Mean Cesium-137 Concentrations in Aquatic Sediments**  
**Three Mile Island Nuclear Station, 1984 – 2018**



**FIGURE C-6**  
**Mean Quarterly Gross Beta Concentrations in Air Particulates**  
**Three Mile Island Nuclear Station, 1972 - 2018**




**FIGURE C-7**  
**Mean Weekly Gross Beta Concentrations in Air Particulates**  
**Three Mile Island Nuclear Station, 2007 - 2018**



*The high value on 11/24/2009 was caused by an airborne release on 11/21/2009*

**FIGURE C-8**  
**Mean Quarterly Strontium-90 Concentrations in Cow Milk**  
**Three Mile Island Nuclear Station, 1979 - 2018**





Intentionally left blank

## **APPENDIX D**

### **DATA TABLES AND FIGURES COMPARISON LABORATORIES**

Intentionally left blank

The following section presents the results of data analysis performed by the QC laboratories, Exelon Industrial Services (EIS) and GEL Laboratories (GEL). Duplicate samples were obtained from several locations and media and were split with the primary laboratory, Teledyne Brown Engineering (TBE). Comparison of the results for most media were within expected ranges.

Intentionally left blank

**TABLE D-I.1**

**CONCENTRATIONS OF GROSS BETA IN DRINKING WATER SAMPLES  
COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

| LAB | COLLECTION PERIOD       | Q9-1Q     |
|-----|-------------------------|-----------|
| EIS | 01/03/18 - 01/30/18     | 2.0 ± 0.6 |
|     | 01/30/18 - 02/27/18     | 1.9 ± 0.6 |
|     | 02/27/18 - 03/27/18     | 1.1 ± 0.6 |
|     | 03/27/18 - 05/01/18     | 1.3 ± 0.6 |
|     | 05/01/18 - 05/31/18     | 2.4 ± 0.7 |
|     | 05/31/18 - 06/26/18     | 2.6 ± 0.7 |
|     | 06/26/18 - 07/31/18     | 2.1 ± 0.6 |
|     | 07/31/18 - 08/29/18     | 1.7 ± 0.7 |
|     | 08/29/18 - 09/25/18     | 1.9 ± 0.7 |
|     | 09/25/18 - 10/31/18     | 1.5 ± 0.6 |
|     | 10/31/18 - 11/29/18     | 1.5 ± 0.7 |
|     | 11/29/18 - 01/03/19     | 0.8 ± 0.6 |
|     | <i>MEAN ± 2 STD DEV</i> | 1.7 ± 1.1 |

**TABLE D-I.2**

**CONCENTRATIONS OF TRITIUM IN DRINKING WATER SAMPLES  
COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

| LAB | COLLECTION PERIOD   | Q9-1Q |
|-----|---------------------|-------|
| GEL | 01/03/18 - 03/27/18 | < 123 |
|     | 03/27/18 - 06/06/18 | < 112 |
|     | 06/06/18 - 09/25/18 | < 102 |
|     | 09/25/18 - 01/03/19 | < 141 |
|     | <i>MEAN</i>         | -     |

**TABLE D-I.3**

**CONCENTRATIONS OF IODINE-131 IN DRINKING WATER SAMPLES  
COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

| LAB | COLLECTION PERIOD   | Q9-1Q |
|-----|---------------------|-------|
| EIS | 01/03/18 - 01/30/18 | < 0.4 |
|     | 01/30/18 - 02/27/18 | < 0.6 |
|     | 02/27/18 - 03/27/18 | < 0.7 |
|     | 03/27/18 - 05/01/18 | < 0.5 |
|     | 05/01/18 - 05/31/18 | < 0.6 |
|     | 05/31/18 - 06/26/18 | < 0.9 |
|     | 06/26/18 - 07/31/18 | < 0.6 |
|     | 07/31/18 - 08/29/18 | < 0.7 |
|     | 08/29/18 - 09/25/18 | < 0.6 |
|     | 09/25/18 - 10/31/18 | < 0.5 |
|     | 10/31/18 - 11/29/18 | < 0.7 |
|     | 11/29/18 - 01/03/09 | < 0.8 |
|     | <i>MEAN</i>         | -     |

THE MEAN AND 2 STANDARD DEVIATION VALUES ARE CALCULATED USING THE POSITIVE VALUES

**TABLE D-I.4** **CONCENTRATIONS OF GAMMA EMITTERS IN DRINKING WATER SAMPLES**  
**COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
 RESULTS IN UNITS OF PC/LITER ± 2 SIGMA

| LAB | SITE  | COLLECTION PERIOD   | Mn-54 | Fe-59 | Co-58 | Co-60 | Zn-65 | Nb-95 | Zr-95 | Cs-134 | Cs-137 | Ba-140 | La-140 |
|-----|-------|---------------------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|
| EIS | Q9-1Q | 01/03/18 - 01/30/18 | < 4   | < 10  | < 5   | < 5   | < 10  | < 5   | < 7   | < 5    | < 4    | < 19   | < 8    |
|     |       | 01/30/18 - 02/27/18 | < 4   | < 12  | < 5   | < 4   | < 11  | < 5   | < 8   | < 4    | < 4    | < 20   | < 8    |
|     |       | 02/27/18 - 03/27/18 | < 4   | < 8   | < 4   | < 3   | < 9   | < 5   | < 7   | < 4    | < 5    | < 21   | < 9    |
|     |       | 03/27/18 - 05/01/18 | < 4   | < 9   | < 4   | < 5   | < 9   | < 4   | < 6   | < 4    | < 5    | < 16   | < 7    |
|     |       | 05/01/18 - 05/31/18 | < 5   | < 12  | < 4   | < 5   | < 10  | < 6   | < 9   | < 4    | < 4    | < 35   | < 13   |
|     |       | 05/31/18 - 06/26/18 | < 4   | < 8   | < 4   | < 4   | < 8   | < 4   | < 6   | < 3    | < 4    | < 17   | < 6    |
|     |       | 06/26/18 - 07/31/18 | < 4   | < 10  | < 4   | < 4   | < 8   | < 5   | < 7   | < 4    | < 4    | < 19   | < 10   |
|     |       | 07/31/18 - 08/29/18 | < 5   | < 10  | < 4   | < 4   | < 9   | < 5   | < 7   | < 4    | < 4    | < 22   | < 11   |
|     |       | 08/29/18 - 09/25/18 | < 4   | < 7   | < 4   | < 4   | < 7   | < 4   | < 7   | < 3    | < 4    | < 19   | < 7    |
|     |       | 09/25/18 - 10/31/18 | < 6   | < 10  | < 5   | < 6   | < 14  | < 5   | < 7   | < 5    | < 5    | < 20   | < 7    |
|     |       | 10/31/18 - 11/29/18 | < 3   | < 7   | < 3   | < 3   | < 7   | < 3   | < 5   | < 3    | < 3    | < 15   | < 5    |
|     |       | 11/29/18 - 01/03/19 | < 4   | < 8   | < 4   | < 4   | < 7   | < 4   | < 6   | < 4    | < 4    | < 19   | < 7    |
|     |       | MEAN                | -     | -     | -     | -     | -     | -     | -     | -      | -      | -      | -      |

**TABLE D-II.1**  
**CONCENTRATIONS OF STRONTIUM AND GAMMA EMITTERS IN FISH SAMPLES**  
**COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
 RESULTS IN UNITS OF PCI/KG WET ± 2 SIGMA

| LAB | SITE | COLLECTION PERIOD | Sr-89 | Sr-90 | K-40       | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Cs-134 | Cs-137 |
|-----|------|-------------------|-------|-------|------------|-------|-------|-------|-------|-------|--------|--------|
| EIS | INDP | 10/12/18          |       |       | 2890 ± 375 | < 25  | < 23  | < 50  | < 25  | < 64  | < 21   | < 20   |



**TABLE D-III.1      CONCENTRATIONS OF GAMMA EMITTERS IN SEDIMENT  
 SAMPLES COLLECTED IN THE VICINITY OF  
 THREE MILE ISLAND NUCLEAR STATION, 2018**

| LAB | SITE | COLLECTION<br>PERIOD | K-40         | Cs-134 | Cs-137 |
|-----|------|----------------------|--------------|--------|--------|
| EIS | J2-1 | 10/25/18             | 16028 ± 1594 | < 96   | < 120  |

**TABLE D-IV.1 CONCENTRATIONS OF GAMMA EMITTERS AND STRONTIUM IN FOOD PRODUCT SAMPLES  
COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**

RESULTS IN UNITS OF PCI/KG WET ± 2 SIGMA

| LAB | SITE   | TYPE                 | COLLECTION |  | Be-7       | K-40       | I-131 | Cs-134 | Cs-137 | Sr-89 | Sr-90 |
|-----|--------|----------------------|------------|--|------------|------------|-------|--------|--------|-------|-------|
|     |        |                      | PERIOD     |  |            |            |       |        |        |       |       |
| EIS | B10-2Q | Cabbage Leaves       | 06/28/18   |  | 379 ± 86   | 3728 ± 266 | < 47  | < 12   | < 12   | < 3.0 | < 0.7 |
| GEL | B10-2Q | Cabbage Leaves       | 06/28/18   |  |            |            |       |        |        |       |       |
| EIS | H1-2Q  | Yellow Squash Leaves | 06/28/18   |  | 701 ± 106  | 4164 ± 263 | < 48  | < 11   | < 12   | < 0.2 | < 0.2 |
| GEL | H1-2Q  | Yellow Squash Leaves | 06/28/18   |  |            |            |       |        |        |       |       |
| EIS | H1-2Q  | Yellow Squash Leaves | 07/25/18   |  | 5394 ± 250 | 2276 ± 227 | < 28  | < 15   | < 18   | < 0.3 | < 0.1 |
| GEL | H1-2Q  | Yellow Squash Leaves | 07/25/18   |  |            |            |       |        |        |       |       |
| EIS | H1-2Q  | Yellow Squash Leaves | 08/22/18   |  | 2587 ± 179 | 2381 ± 232 | < 29  | < 14   | < 15   | < 0.1 | < 0.2 |
| GEL | H1-2Q  | Yellow Squash Leaves | 08/22/18   |  |            |            |       |        |        |       |       |

**TABLE D-V.1 CONCENTRATIONS OF GROSS BETA IN AIR PARTICULATE AND I-131 IN AIR IODINE SAMPLES COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF E-3 PCI/CU METER  $\pm$  2 SIGMA

| LAB | COLLECTION PERIOD    | E1-2Q GROSS BETA | E1-2Q I-131 |
|-----|----------------------|------------------|-------------|
| EIS | 12/28/17 - 01/04/18  | 25 $\pm$ 2       | < 16        |
|     | 01/04/18 - 01/11/18  | 26 $\pm$ 2       | < 20        |
|     | 01/11/18 - 01/18/18  | 22 $\pm$ 2       | < 17        |
|     | 01/18/18 - 01/25/18  | 29 $\pm$ 3       | < 10        |
|     | 01/25/18 - 02/01/18  | 19 $\pm$ 2       | < 16        |
|     | 02/01/18 - 02/08/18  | 19 $\pm$ 2       | < 13        |
|     | 02/08/18 - 02/15/18  | 28 $\pm$ 2       | < 19        |
|     | 02/15/18 - 02/22/18  | 22 $\pm$ 2       | < 18        |
|     | 02/22/18 - 03/01/18  | 20 $\pm$ 2       | < 12        |
|     | 03/01/18 - 03/08/18  | 17 $\pm$ 2       | < 9         |
|     | 03/08/18 - 03/15/18  | 15 $\pm$ 2       | < 13        |
|     | 03/15/18 - 03/23/18  | 19 $\pm$ 2       | < 10        |
|     | 03/23/18 - 03/29/18  | 19 $\pm$ 2       | < 22        |
|     | 03/29/18 - 04/05/18  | 17 $\pm$ 2       | < 24        |
|     | 04/05/18 - 04/12/18  | 22 $\pm$ 2       | < 20        |
|     | 04/12/18 - 04/19/18  | 15 $\pm$ 2       | < 16        |
|     | 04/19/18 - 04/26/18  | 18 $\pm$ 2       | < 24        |
|     | 04/26/18 - 05/03/18  | 24 $\pm$ 2       | < 14        |
|     | 05/03/18 - 05/10/18  | 25 $\pm$ 2       | < 15        |
|     | 05/10/18 - 05/17/18  | 16 $\pm$ 2       | < 22        |
|     | 05/17/18 - 05/24/18  | 15 $\pm$ 2       | < 22        |
|     | 05/24/18 - 05/31/18  | 18 $\pm$ 2       | < 24        |
|     | 05/31/18 - 06/07/18  | 13 $\pm$ 2       | < 12        |
|     | 06/07/18 - 06/13/18  | 19 $\pm$ 2       | < 25        |
|     | 06/13/18 - 06/21/18  | 20 $\pm$ 2       | < 21        |
|     | 06/21/18 - 06/28/18  | 16 $\pm$ 2       | < 22        |
|     | 06/28/18 - 07/05/18  | 26 $\pm$ 2       | < 15        |
|     | 07/05/18 - 07/12/18  | 19 $\pm$ 2       | < 15        |
|     | 07/12/18 - 07/19/18  | 24 $\pm$ 2       | < 14        |
|     | 07/19/18 - 07/26/18  | 12 $\pm$ 2       | < 20        |
|     | 07/26/18 - 08/02/18  | 22 $\pm$ 2       | < 21        |
|     | 08/02/18 - 08/09/18  | 34 $\pm$ 3       | < 20        |
|     | 08/09/18 - 08/16/18  | 30 $\pm$ 3       | < 17        |
|     | 08/16/18 - 08/23/18  | 23 $\pm$ 2       | < 11        |
|     | 08/23/18 - 08/29/18  | 37 $\pm$ 3       | < 19        |
|     | 08/29/18 - 09/06/18  | 25 $\pm$ 2       | < 15        |
|     | 09/06/18 - 09/13/18  | 15 $\pm$ 2       | < 11        |
|     | 09/13/18 - 09/19/18  | 15 $\pm$ 2       | < 12        |
|     | 09/19/18 - 09/27/18  | 18 $\pm$ 2       | < 18        |
|     | 09/27/18 - 10/04/18  | 28 $\pm$ 2       | < 19        |
|     | 10/04/18 - 10/12/18  | 29 $\pm$ 2       | < 17        |
|     | 10/12/18 - 10/18/18  | 17 $\pm$ 2       | < 15        |
|     | 10/18/18 - 10/25/18  | 18 $\pm$ 2       | < 18        |
|     | 10/25/18 - 10/31/18  | 15 $\pm$ 2       | < 31        |
|     | 10/31/18 - 11/08/18  | 20 $\pm$ 2       | < 13        |
|     | 11/08/18 - 11/15/18  | 16 $\pm$ 2       | < 21        |
|     | 11/15/18 - 11/21/18  | 28 $\pm$ 3       | < 18        |
|     | 11/21/18 - 11/29/18  | 20 $\pm$ 2       | < 17        |
|     | 11/29/18 - 12/06/18  | 14 $\pm$ 2       | < 20        |
|     | 12/06/18 - 12/13/18  | 34 $\pm$ 3       | < 16        |
|     | 12/13/18 - 12/20/18  | 26 $\pm$ 2       | < 26        |
|     | 12/20/18 - 12/27/18  | 23 $\pm$ 2       | < 15        |
|     | MEAN $\pm$ 2 STD DEV | 21 $\pm$ 11      | -           |

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**TABLE D-V.2      CONCENTRATIONS OF GAMMA EMITTERS IN AIR PARTICULATE SAMPLES  
COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF E-3 PCI/CU METER  $\pm$  2 SIGMA

| LAB | SITE  | COLLECTION PERIOD                      | Be-7        | Cs-134 | Cs-137 |
|-----|-------|--|-------------|--------|--------|
| EIS | E1-2Q | 12/28/17 - 03/29/18                    | 61 $\pm$ 11 | < 1.0  | < 1.2  |
|     |       | 03/29/18 - 06/28/18                    | 76 $\pm$ 10 | < 0.9  | < 0.9  |
|     |       | 06/28/18 - 09/27/18                    | 78 $\pm$ 11 | < 1.0  | < 1.0  |
|     |       | 09/27/18 - 12/27/18                    | 58 $\pm$ 10 | < 1.0  | < 1.1  |
|     |       | <i>MEAN <math>\pm</math> 2 STD DEV</i> | 68 $\pm$ 21 | -      | -      |

**TABLE D-VI.1 CONCENTRATIONS OF I-131 BY CHEMICAL SEPARATION, GAMMA EMITTERS, AND STRONTIUM IN MILK SAMPLES COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

| LAB | SITE  | COLLECTION          |  | I-131            | K-40       | Cs-134 | Cs-137 | Ba-140 | La-140 | Sr-89 | Sr-90 |
|-----|-------|---------------------|--|------------------|------------|--------|--------|--------|--------|-------|-------|
|     |       | DATE                |  |                  |            |        |        |        |        |       |       |
| EIS | G2-1Q | 01/10/18            |  | < 0.8            | 1246 ± 111 | < 7    | < 8    | < 32   | < 12   |       |       |
| EIS |       | 02/07/18            |  | < 0.8            | 1218 ± 64  | < 3    | < 3    | < 40   | < 14   |       |       |
| EIS |       | 03/07/18            |  | < 0.9            | 1477 ± 86  | < 3    | < 3    | < 24   | < 8    |       |       |
| EIS |       | 03/21/18            |  | < 0.8            | 1284 ± 113 | < 6    | < 7    | < 31   | < 11   |       | < 0.8 |
| GEL |       | 01/10/18 - 03/21/18 |  |                  |            |        |        |        |        |       |       |
| EIS |       | 04/04/18            |  | < 0.7            | 1405 ± 120 | < 4    | < 6    | < 21   | < 8    |       |       |
| EIS |       | 04/18/18            |  | < 0.8            | 1199 ± 80  | < 3    | < 4    | < 24   | < 8    |       |       |
| EIS |       | 05/02/18            |  | < 0.8            | 1231 ± 83  | < 5    | < 4    | < 21   | < 7    |       |       |
| EIS |       | 05/16/18            |  | < 0.8            | 1640 ± 94  | < 4    | < 4    | < 19   | < 6    |       |       |
| EIS |       | 05/30/18            |  | < 0.7            | 1402 ± 89  | < 4    | < 4    | < 25   | < 9    |       |       |
| EIS |       | 06/13/18            |  | < 0.7            | 1394 ± 86  | < 3    | < 4    | < 23   | < 7    |       |       |
| EIS |       | 06/27/18            |  | < 0.7            | 1307 ± 92  | < 4    | < 5    | < 19   | < 7    |       | < 1.0 |
| GEL |       | 04/04/18 - 06/27/18 |  |                  |            |        |        |        |        |       |       |
| EIS |       | 07/11/18            |  | < 0.8            | 1447 ± 97  | < 4    | < 5    | < 24   | < 8    |       |       |
| EIS |       | 07/25/18            |  | < 1.0            | 1126 ± 77  | < 4    | < 4    | < 32   | < 10   |       |       |
| EIS |       | 08/08/18            |  | < 0.9            | 1423 ± 88  | < 4    | < 4    | < 22   | < 6    |       |       |
| EIS |       | 08/22/18            |  | < 0.8            | 1261 ± 112 | < 7    | < 7    | < 29   | < 11   |       |       |
| EIS |       | 09/19/18            |  | < 0.7            | 1562 ± 122 | < 6    | < 6    | < 23   | < 8    |       | < 0.8 |
| GEL |       | 07/01/18 - 09/19/18 |  |                  |            |        |        |        |        |       |       |
| EIS |       | 10/03/18            |  | < 0.9            | 1108 ± 87  | < 5    | < 5    | < 24   | < 9    |       |       |
| EIS |       | 10/17/18            |  | < 0.6            | 1028 ± 68  | < 3    | < 3    | < 25   | < 9    |       |       |
| EIS |       | 10/31/18            |  | < 0.4            | 1113 ± 77  | < 4    | < 5    | < 19   | < 6    |       |       |
| EIS |       | 11/14/18            |  | < 0.8            | 1189 ± 107 | < 6    | < 5    | < 33   | < 11   |       |       |
| EIS |       | 11/29/18            |  | < 0.5            | 1284 ± 92  | < 5    | < 6    | < 21   | < 7    |       |       |
| EIS |       | 12/12/18            |  | < 0.6            | 1118 ± 85  | < 5    | < 6    | < 25   | < 10   |       | < 0.8 |
| GEL |       | 09/25/18 - 01/03/19 |  |                  |            |        |        |        |        |       |       |
|     |       |                     |  | MEAN ± 2 STD DEV | 1294 ± 318 | -      | -      | -      | -      | -     | -     |

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

## **APPENDIX E**

### **INTER-LABORATORY COMPARISON PROGRAM**

Intentionally left blank

**TABLE E.1**

**Analytics Environmental Radioactivity Cross Check Program  
Teledyne Brown Engineering Environmental Services**

| Month/Year | Identification Number | Matrix | Nuclide | Units    | TBE Reported Value | Known Value <sup>(a)</sup> | Ratio of TBE to Analytics Result | Evaluation <sup>(b)</sup> |
|------------|-----------------------|--------|---------|----------|--------------------|----------------------------|----------------------------------|---------------------------|
| March 2018 | E12133                | Milk   | Sr-89   | pCi/L    | 76.1               | 90.1                       | 0.84                             | A                         |
|            |                       |        | Sr-90   | pCi/L    | 12.2               | 12.5                       | 0.98                             | A                         |
|            | E12134                | Milk   | Ce-141  | pCi/L    | 77.8               | 77.0                       | 1.01                             | A                         |
|            |                       |        | Co-58   | pCi/L    | 105                | 114                        | 0.92                             | A                         |
|            |                       |        | Co-60   | pCi/L    | 181                | 187                        | 0.97                             | A                         |
|            |                       |        | Cr-51   | pCi/L    | 298                | 326                        | 0.92                             | A                         |
|            |                       |        | Cs-134  | pCi/L    | 150                | 180                        | 0.84                             | A                         |
|            |                       |        | Cs-137  | pCi/L    | 164                | 172                        | 0.95                             | A                         |
|            |                       |        | Fe-59   | pCi/L    | 140                | 139                        | 1.01                             | A                         |
|            |                       |        | I-131   | pCi/L    | 105                | 108.0                      | 0.97                             | A                         |
|            |                       |        | Mn-54   | pCi/L    | 133                | 131                        | 1.01                             | A                         |
|            |                       |        | Zn-65   | pCi/L    | 242                | 244                        | 0.99                             | A                         |
|            |                       |        | E12135  | Charcoal | I-131              | pCi                        | 93.7                             | 95.4                      |
| E12136     | AP                    | Ce-141 | pCi     | 92.6     | 85.3               | 1.09                       | A                                |                           |
|            |                       | Co-58  | pCi     | 130      | 126                | 1.03                       | A                                |                           |
|            |                       | Co-60  | pCi     | 237      | 207                | 1.14                       | A                                |                           |
|            |                       | Cr-51  | pCi     | 411      | 361                | 1.14                       | A                                |                           |
|            |                       | Cs-134 | pCi     | 194      | 199                | 0.98                       | A                                |                           |
|            |                       | Cs-137 | pCi     | 200      | 191                | 1.05                       | A                                |                           |
|            |                       | Fe-59  | pCi     | 160      | 154                | 1.04                       | A                                |                           |
|            |                       | Mn-54  | pCi     | 152      | 145                | 1.05                       | A                                |                           |
| Zn-65      | pCi                   | 267    | 271     | 0.99     | A                  |                            |                                  |                           |
| E12137     | Water                 | Fe-55  | pCi/L   | 1990     | 1700               | 1.17                       | A                                |                           |
| E12138     | Soil                  | Ce-141 | pCi/g   | 0.148    | 0.118              | 1.26                       | W                                |                           |
|            |                       | Co-58  | pCi/g   | 0.171    | 0.174              | 0.98                       | A                                |                           |
|            |                       | Co-60  | pCi/g   | 0.297    | 0.286              | 1.04                       | A                                |                           |
|            |                       | Cr-51  | pCi/g   | 0.537    | 0.498              | 1.08                       | A                                |                           |
|            |                       | Cs-134 | pCi/g   | 0.274    | 0.275              | 1.00                       | A                                |                           |
|            |                       | Cs-137 | pCi/g   | 0.355    | 0.337              | 1.05                       | A                                |                           |
|            |                       | Fe-59  | pCi/g   | 0.243    | 0.212              | 1.15                       | A                                |                           |
|            |                       | Mn-54  | pCi/g   | 0.228    | 0.201              | 1.14                       | A                                |                           |
| Zn-65      | pCi/g                 | 0.395  | 0.374   | 1.06     | A                  |                            |                                  |                           |

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30



TABLE E.1

**Analytics Environmental Radioactivity Cross Check Program  
Teledyne Brown Engineering Environmental Services**

| Month/Year | Identification Number | Matrix | Nuclide   | Units  | TBE Reported Value | Known Value <sup>(a)</sup> | Ratio of TBE to Analytics Result | Evaluation <sup>(b)</sup> |
|------------|-----------------------|--------|-----------|--------|--------------------|----------------------------|----------------------------------|---------------------------|
| June 2018  | E12205                | Milk   | Sr-89     | pCi/L  | 74.9               | 84.6                       | 0.89                             | A                         |
|            |                       |        | Sr-90     | pCi/L  | 10.5               | 11.4                       | 0.92                             | A                         |
| June 2018  | E12206                | Milk   | Ce-141    | pCi/L  | 89.2               | 82.2                       | 1.08                             | A                         |
|            |                       |        | Co-58     | pCi/L  | 94.8               | 89                         | 1.07                             | A                         |
|            |                       |        | Co-60     | pCi/L  | 125                | 113                        | 1.10                             | A                         |
|            |                       |        | Cr-51     | pCi/L  | 256                | 239                        | 1.07                             | A                         |
|            |                       |        | Cs-134    | pCi/L  | 112                | 114                        | 0.99                             | A                         |
|            |                       |        | Cs-137    | pCi/L  | 107                | 98.8                       | 1.08                             | A                         |
|            |                       |        | Fe-59     | pCi/L  | 95.9               | 86.0                       | 1.12                             | A                         |
|            |                       |        | I-131     | pCi/L  | 69.8               | 71.9                       | 0.97                             | A                         |
|            |                       |        | Mn-54     | pCi/L  | 138                | 130                        | 1.06                             | A                         |
|            |                       |        | Zn-65     | pCi/L  | 186                | 157                        | 1.18                             | A                         |
|            |                       |        | June 2018 | E12207 | Charcoal           | I-131                      | pCi                              | 69.6                      |
| June 2018  | E12208                | AP     | Ce-141    | pCi    | 151                | 165                        | 0.92                             | A                         |
|            |                       |        | Co-58     | pCi    | 174                | 178                        | 0.98                             | A                         |
|            |                       |        | Co-60     | pCi    | 290                | 227                        | 1.28                             | W                         |
|            |                       |        | Cr-51     | pCi    | 452                | 478                        | 0.95                             | A                         |
|            |                       |        | Cs-134    | pCi    | 215                | 227                        | 0.95                             | A                         |
|            |                       |        | Cs-137    | pCi    | 206                | 198                        | 1.04                             | A                         |
|            |                       |        | Fe-59     | pCi    | 180                | 172                        | 1.05                             | A                         |
|            |                       |        | Mn-54     | pCi    | 265                | 260                        | 1.02                             | A                         |
|            |                       |        | Zn-65     | pCi    | 280                | 315                        | 0.89                             | A                         |
| June 2018  | E12209                | Water  | Fe-55     | pCi/L  | 1790               | 1740                       | 1.03                             | A                         |
| June 2018  | E12210                | AP     | Sr-89     | pCi    | 77.8               | 90.3                       | 0.86                             | A                         |
|            |                       |        | Sr-90     | pCi    | 9.54               | 12.2                       | 0.78                             | W                         |

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

**TABLE E.1**

**Analytics Environmental Radioactivity Cross Check Program  
Teledyne Brown Engineering Environmental Services**

| Month/Year     | Identification Number | Matrix   | Nuclide | Units | TBE Reported Value | Known Value <sup>(a)</sup> | Ratio of TBE to Analytics Result | Evaluation <sup>(b)</sup> |
|----------------|-----------------------|----------|---------|-------|--------------------|----------------------------|----------------------------------|---------------------------|
| September 2018 | E12271                | Milk     | Sr-89   | pCi/L | 79.4               | 81.7                       | 0.97                             | A                         |
|                |                       |          | Sr-90   | pCi/L | 12.2               | 14.8                       | 0.82                             | A                         |
|                | E12272                | Milk     | Ce-141  | pCi/L | 152                | 128                        | 1.19                             | A                         |
|                |                       |          | Co-58   | pCi/L | 161                | 144                        | 1.12                             | A                         |
|                |                       |          | Co-60   | pCi/L | 208                | 190                        | 1.10                             | A                         |
|                |                       |          | Cr-51   | pCi/L | 244                | 265                        | 0.92                             | A                         |
|                |                       |          | Cs-134  | pCi/L | 124                | 123                        | 1.01                             | A                         |
|                |                       |          | Cs-137  | pCi/L | 166                | 147                        | 1.13                             | A                         |
|                |                       |          | Fe-59   | pCi/L | 158                | 119                        | 1.32                             | N <sup>(1)</sup>          |
|                |                       |          | I-131   | pCi/L | 83.1               | 58.2                       | 1.43                             | N <sup>(2)</sup>          |
|                |                       |          | Mn-54   | pCi/L | 191                | 167                        | 1.14                             | A                         |
|                | Zn-65                 | pCi/L    | 229     | 201   | 1.14               | A                          |                                  |                           |
|                | E12273                | Charcoal | I-131   | pCi   | 83.0               | 80.7                       | 1.03                             | A                         |
|                | E12274                | AP       | Ce-141  | pCi   | 101                | 85.6                       | 1.18                             | A                         |
|                |                       |          | Co-58   | pCi   | 92.7               | 96.0                       | 0.97                             | A                         |
|                |                       |          | Co-60   | pCi   | 142                | 127                        | 1.12                             | A                         |
|                |                       |          | Cr-51   | pCi   | 218                | 177                        | 1.23                             | W                         |
|                |                       |          | Cs-134  | pCi   | 81.2               | 81.9                       | 0.99                             | A                         |
|                |                       |          | Cs-137  | pCi   | 99.0               | 98.5                       | 1.01                             | A                         |
|                |                       |          | Fe-59   | pCi   | 93.7               | 79.7                       | 1.18                             | A                         |
|                |                       |          | Mn-54   | pCi   | 116                | 112                        | 1.04                             | A                         |
|                | Zn-65                 | pCi      | 139     | 134   | 1.04               | A                          |                                  |                           |
|                | E12302                | Water    | Fe-55   | pCi/L | 2120               | 1820                       | 1.17                             | A                         |
|                | E12276                | Soil     | Ce-141  | pCi/g | 0.259              | 0.221                      | 1.17                             | A                         |
|                |                       |          | Co-58   | pCi/g | 0.279              | 0.248                      | 1.12                             | A                         |
|                |                       |          | Co-60   | pCi/g | 0.367              | 0.328                      | 1.12                             | A                         |
|                |                       |          | Cr-51   | pCi/g | 0.597              | 0.457                      | 1.31                             | N <sup>(3)</sup>          |
| Cs-134         |                       |          | pCi/g   | 0.261 | 0.212              | 1.23                       | W                                |                           |
| Cs-137         |                       |          | pCi/g   | 0.376 | 0.330              | 1.14                       | A                                |                           |
| Fe-59          |                       |          | pCi/g   | 0.248 | 0.206              | 1.20                       | A                                |                           |
| Mn-54          |                       |          | pCi/g   | 0.317 | 0.289              | 1.10                       | A                                |                           |
| Zn-65          | pCi/g                 | 0.407    | 0.347   | 1.17  | A                  |                            |                                  |                           |

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

(1) See **NCR 18-20**

(2) See **NCR 18-24**

(3) See **NCR 18-21**

TABLE E.1

**Analytics Environmental Radioactivity Cross Check Program  
Teledyne Brown Engineering Environmental Services**

| Month/Year    | Identification Number | Matrix | Nuclide | Units  | TBE Reported Value | Known Value <sup>(a)</sup> | Ratio of TBE to Analytics Result | Evaluation <sup>(b)</sup> |
|---------------|-----------------------|--------|---------|--------|--------------------|----------------------------|----------------------------------|---------------------------|
| December 2018 | E12313                | Milk   | Sr-89   | pCi/L  | 71.9               | 91.9                       | 0.78                             | W                         |
|               |                       |        | Sr-90   | pCi/L  | 12.1               | 13.3                       | 0.91                             | A                         |
|               | E12314                | Milk   | Ce-141  | pCi/L  | 124                | 133                        | 0.93                             | A                         |
|               |                       |        | Co-58   | pCi/L  | 110                | 119                        | 0.93                             | A                         |
|               |                       |        | Co-60   | pCi/L  | 202                | 212                        | 0.95                             | A                         |
|               |                       |        | Cr-51   | pCi/L  | 292                | 298                        | 0.98                             | A                         |
|               |                       |        | Cs-134  | pCi/L  | 146                | 171                        | 0.85                             | A                         |
|               |                       |        | Cs-137  | pCi/L  | 118                | 121                        | 0.98                             | A                         |
|               |                       |        | Fe-59   | pCi/L  | 120                | 114                        | 1.05                             | A                         |
|               |                       |        | I-131   | pCi/L  | 94.2               | 93.3                       | 1.01                             | A                         |
|               |                       |        | Mn-54   | pCi/L  | 151                | 154                        | 0.98                             | A                         |
|               |                       |        | Zn-65   | pCi/L  | 266                | 264                        | 1.01                             | A                         |
|               |                       |        |         | E12315 | Charcoal           | I-131                      | pCi                              | 94.8                      |
|               | E12316A               | AP     | Ce-141  | pCi    | 92.3               | 94.0                       | 0.98                             | A                         |
|               |                       |        | Co-58   | pCi    | 73.4               | 83.8                       | 0.88                             | A                         |
|               |                       |        | Co-60   | pCi    | 137                | 150                        | 0.91                             | A                         |
|               |                       |        | Cr-51   | pCi    | 202                | 210                        | 0.96                             | A                         |
|               |                       |        | Cs-134  | pCi    | 115                | 121                        | 0.95                             | A                         |
|               |                       |        | Cs-137  | pCi    | 85.0               | 85.4                       | 1.00                             | A                         |
|               |                       |        | Fe-59   | pCi    | 83.1               | 80.8                       | 1.03                             | A                         |
|               |                       |        | Mn-54   | pCi    | 104                | 109                        | 0.96                             | A                         |
|               |                       |        | Zn-65   | pCi    | 168                | 187                        | 0.90                             | A                         |
|               | E12317                | Water  | Fe-55   | pCi/L  | 2110               | 1840                       | 1.15                             | A                         |
|               | E12318                | AP     | Sr-89   | pCi    | 81.1               | 83.0                       | 0.98                             | A                         |
|               |                       |        | Sr-90   | pCi    | 11.4               | 12.0                       | 0.95                             | A                         |

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

TABLE E.2

**DOE's Mixed Analyte Performance Evaluation Program (MAPEP)**  
**Teledyne Brown Engineering Environmental Services**

| Month/Year    | Identification Number | Matrix     | Nuclide    | Units       | TBE Reported Value | Known Value <sup>(a)</sup> | Acceptance Range | Evaluation <sup>(b)</sup> |
|---------------|-----------------------|------------|------------|-------------|--------------------|----------------------------|------------------|---------------------------|
| February 2018 | 18-MaS38              | Soil       | Ni-63      | Bq/kg       | 9.94               |                            | (1)              | A                         |
|               |                       |            | Sr-90      | Bq/kg       | 0.846              |                            | (1)              | A                         |
|               | 18-MaW38              | Water      | Am-241     | Bq/L        | 0.785              | 0.709                      | 0.496 - 0.922    | A                         |
|               |                       |            | Ni-63      | Bq/L        | 12.6               | 14.0                       | 9.8 - 18.2       | A                         |
|               |                       |            | Pu-238     | Bq/L        | 0.0214             | 0.023                      | (2)              | A                         |
|               |                       |            | Pu-239/240 | Bq/L        | 0.544              | 0.600                      | 0.420 - 0.780    | A                         |
|               | 18-RdF38              | AP         | U-234/233  | Bq/sample   | 0.111              | 0.124                      | 0.087 - 0.161    | A                         |
|               |                       |            | U-238      | Bq/sample   | 0.123              | 0.128                      | 0.090 - 0.166    | A                         |
|               | 18-RdV38              | Vegetation | Cs-134     | Bq/sample   | 2.46               | 3.23                       | 2.26 - 4.20      | W                         |
|               |                       |            | Cs-137     | Bq/sample   | 3.14               | 3.67                       | 2.57 - 4.77      | A                         |
|               |                       |            | Co-57      | Bq/sample   | 4.12               | 4.42                       | 3.09 - 5.75      | A                         |
|               |                       |            | Co-60      | Bq/sample   | 1.86               | 2.29                       | 1.60 - 2.98      | A                         |
|               |                       |            | Mn-54      | Bq/sample   | 2.21               | 2.66                       | 1.86 - 3.46      | A                         |
|               |                       |            | Sr-90      | Bq/sample   |                    |                            |                  | NR <sup>(3)</sup>         |
| Zn-65         |                       |            | Bq/sample  | -0.201      |                    | (1)                        | A                |                           |
| November 2018 | 18-MaS39              | Soil       | Ni-63      | Bq/kg       | 703                | 765                        | 536 - 995        | A                         |
|               |                       |            | Sr-90      | Bq/kg       | 137                | 193                        | 135 - 251        | W                         |
|               | 18-MaW39              | Water      | Am-241     | Bq/L        | 0.0363             |                            | (1)              | A                         |
|               |                       |            | Ni-63      | Bq/L        | 6.18               | 7.0                        | 4.9 - 9.1        | A                         |
|               |                       |            | Pu-238     | Bq/L        | 0.73               | 0.674                      | 0.472 - 0.876    | A                         |
|               |                       |            | Pu-239/240 | Bq/L        | 0.89               | 0.928                      | 0.650 - 1.206    | A                         |
|               | 18-RdF39              | AP         | U-234/233  | Bq/sample   | 0.159              | 0.152                      | 0.106 - 0.198    | A                         |
|               |                       |            | U-238      | Bq/sample   | 0.162              | 0.158                      | 0.111 - 0.205    | A                         |
|               | 18-RdV39              | Vegetation | Cs-134     | Bq/sample   | 1.85               | 1.94                       | 1.36 - 2.52      | A                         |
|               |                       |            | Cs-137     | Bq/sample   | 2.5                | 2.36                       | 1.65 - 3.07      | A                         |
|               |                       |            | Co-57      | Bq/sample   | 3.53               | 3.31                       | 2.32 - 4.30      | A                         |
|               |                       |            | Co-60      | Bq/sample   | 1.6                | 1.68                       | 1.18 - 2.18      | A                         |
|               |                       |            | Mn-54      | Bq/sample   | 2.61               | 2.53                       | 1.77 - 3.29      | A                         |
|               |                       |            | Sr-90      | Bq/sample   | 0.338              | 0.791                      | 0.554 - 1.028    | N <sup>(4)</sup>          |
| Zn-65         | Bq/sample             | 1.32       | 1.37       | 0.96 - 1.78 | A                  |                            |                  |                           |

(a) The MAPEP known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) DOE/MAPEP evaluation:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

(1) False positive test

(2) Sensitivity evaluation

(3) See **NCR 18-09**

(4) See **NCR 18-25**

**TABLE E.3** **ERA Environmental Radioactivity Cross Check Program**  
**Teledyne Brown Engineering Environmental Services**

| Month/Year     | Identification Number | Matrix | Nuclide | Units      | TBE Reported Value | Known Value <sup>(a)</sup> | Acceptance Limits | Evaluation <sup>(b)</sup> |
|----------------|-----------------------|--------|---------|------------|--------------------|----------------------------|-------------------|---------------------------|
| March 2018     | MRAD-28               | AP     | GR-A    | pCi/sample | 65.7               | 43.4                       | 22.7 - 71.5       | A                         |
|                |                       |        | GR-B    | pCi/sample | 57.2               | 52                         | 31.5 - 78.6       | A                         |
| April 2018     | RAD-113               | Water  | Ba-133  | pCi/L      | 91.2               | 91.5                       | 77.1 - 101        | A                         |
|                |                       |        | Cs-134  | pCi/L      | 70.4               | 75.9                       | 62.0 - 83.5       | A                         |
|                |                       |        | Cs-137  | pCi/L      | 122                | 123                        | 111 - 138         | A                         |
|                |                       |        | Co-60   | pCi/L      | 64.8               | 64.3                       | 57.9 - 73.2       | A                         |
|                |                       |        | Zn-65   | pCi/L      | 98.6               | 86.7                       | 78.0 - 104        | A                         |
|                |                       |        | GR-A    | pCi/L      | 32.8               | 28.6                       | 14.6 - 37.5       | A                         |
|                |                       |        | GR-B    | pCi/L      | 62.9               | 73.7                       | 51.4 - 81.1       | A                         |
|                |                       |        | U-Nat   | pCi/L      | 6.7                | 6.93                       | 5.28 - 8.13       | A                         |
|                |                       |        | H-3     | pCi/L      | 17100              | 17200                      | 15000 - 18900     | A                         |
|                |                       |        | Sr-89   | pCi/L      | 38.6               | 48.8                       | 38.3 - 56.2       | A                         |
|                |                       |        | Sr-90   | pCi/L      | 27.1               | 26.5                       | 19.2 - 30.9       | A                         |
|                |                       |        | I-131   | pCi/L      | 26.7               | 24.6                       | 20.4 - 29.1       | A                         |
| September 2018 | MRAD-29               | AP     | GR-A    | pCi/sample | 49.7               | 55.3                       | 28.9 - 91.1       | A                         |
|                |                       | AP     | GR-B    | pCi/sample | 75.3               | 86.5                       | 52.4 - 131        | A                         |
| October 2018   | RAD-115               | Water  | Ba-133  | pCi/L      | 15.2               | 16.3                       | 11.9 - 19.4       | A                         |
|                |                       |        | Cs-134  | pCi/L      | 85.9               | 93.0                       | 76.4 - 102        | A                         |
|                |                       |        | Cs-137  | pCi/L      | 229                | 235                        | 212 - 260         | A                         |
|                |                       |        | Co-60   | pCi/L      | 81.9               | 80.7                       | 72.6 - 91.1       | A                         |
|                |                       |        | Zn-65   | pCi/L      | 348                | 336                        | 302 - 392         | A                         |
|                |                       |        | GR-A    | pCi/L      | 38.9               | 60.7                       | 31.8 - 75.4       | A                         |
|                |                       |        | GR-B    | pCi/L      | 36.5               | 41.8                       | 27.9 - 49.2       | A                         |
|                |                       |        | U-Nat   | pCi/L      | 17.48              | 20.9                       | 16.8 - 23.4       | A                         |
|                |                       |        | H-3     | pCi/L      | 2790               | 2870                       | 2410 - 3170       | A                         |
|                |                       |        | I-131   | pCi/L      | 26.9               | 27.2                       | 22.6 - 32.0       | A                         |
|                |                       |        | Sr-89   | pCi/L      | 57.2               | 56.9                       | 45.5 - 64.6       | A                         |
|                |                       |        | Sr-90   | pCi/L      | 36.8               | 31.4                       | 22.9 - 36.4       | N <sup>(1)</sup>          |

(a) The ERA known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.

(b) ERA evaluation:

A = Acceptable - Reported value falls within the Acceptance Limits

N = Not Acceptable - Reported value falls outside of the Acceptance Limits

(1) See **NCR 18-23**

**TABLE E.4 Analytics Environmental Radioactivity Cross Check Program  
Exelon Industrial Services**

| Month/Year     | Identification Number | Matrix | Nuclide    | Units      | EIS Reported Value | Known Value <sup>(a)</sup> | Ratio of Analytics to EIS Result | Evaluation <sup>(b)</sup> |
|----------------|-----------------------|--------|------------|------------|--------------------|----------------------------|----------------------------------|---------------------------|
| March 2018     | E 12085               | Water  | Gr-B       | pCi/L      | 272                | 275                        | 98.9                             | Pass                      |
|                |                       |        | E 12086 D4 | Charcoal   | I-131              | pCi                        | 85.2                             | 94.3                      |
|                | E 12084 D3            | Milk   | I-131      | pCi/L      | 106                | 108                        | 98.1                             | Pass                      |
|                |                       |        | Ce-141     | pCi/L      | 80.0               | 77.0                       | 104                              | Pass                      |
|                |                       |        | Cr-51      | pCi/L      | 317                | 326                        | 97.2                             | Pass                      |
|                |                       |        | Cs-134     | pCi/L      | 178                | 180                        | 98.9                             | Pass                      |
|                |                       |        | Cs-137     | pCi/L      | 176                | 172                        | 102                              | Pass                      |
|                |                       |        | Co-58      | pCi/L      | 118                | 114                        | 104                              | Pass                      |
|                |                       |        | Mn-54      | pCi/L      | 140                | 131                        | 107                              | Pass                      |
|                |                       |        | Fe-59      | pCi/L      | 148                | 139                        | 106                              | Pass                      |
|                |                       |        | Zn-65      | pCi/L      | 264                | 244                        | 108                              | Pass                      |
|                |                       |        | Co-60      | pCi/L      | 192                | 187                        | 103                              | Pass                      |
|                | June 2018             | E12177 | AP         | Ce-141     | pCi/Filter         | 153                        | 148                              | 103                       |
| Cr-51          |                       |        |            | pCi/Filter | 437                | 429                        | 102                              | Pass                      |
| Cs-134         |                       |        |            | pCi/Filter | 193                | 204                        | 94.6                             | Pass                      |
| Cs-137         |                       |        |            | pCi/Filter | 179                | 178                        | 101                              | Pass                      |
| Co-58          |                       |        |            | pCi/Filter | 158                | 160                        | 98.8                             | Pass                      |
| Mn-54          |                       |        |            | pCi/Filter | 236                | 233                        | 101                              | Pass                      |
| Fe-59          |                       |        |            | pCi/Filter | 173                | 155.0                      | 112                              | Pass                      |
| Zn-65          |                       |        |            | pCi/Filter | 268                | 283                        | 94.7                             | Pass                      |
| Co-60          |                       |        |            | pCi/Filter | 200                | 204                        | 98.0                             | Pass                      |
| E12176         |                       |        |            | Water      | I-131              | pCi/L                      | 77                               | 74                        |
|                |                       | Ce-141 | pCi/L      |            | 90                 | 86                         | 105                              | Pass                      |
|                |                       | Cr-51  | pCi/L      |            | 259                | 249                        | 104                              | Pass                      |
|                |                       | Cs-134 | pCi/L      |            | 101                | 119                        | 84.9                             | Pass                      |
|                |                       | Cs-137 | pCi/L      |            | 106                | 103                        | 103                              | Pass                      |
|                |                       | Co-58  | pCi/L      |            | 88                 | 93                         | 94.6                             | Pass                      |
|                |                       | Mn-54  | pCi/L      |            | 132                | 135                        | 97.8                             | Pass                      |
|                |                       | Fe-59  | pCi/L      |            | 97                 | 89.7                       | 109                              | Pass                      |
|                |                       | Zn-65  | pCi/L      |            | 171                | 164                        | 104                              | Pass                      |
|                |                       | Co-60  | pCi/L      |            | 112                | 118                        | 94.9                             | Pass                      |
| E12175         |                       | Water  | Gr-B       | pCi/L      | 215.9              | 251                        | 86.0                             | Pass                      |
| September 2018 | E12245                | AP     | Gr-B       | pCi        | 220.3              | 211                        | 104.4                            | Pass                      |

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on EIS internal QC limits in accordance with the NRC Resolution Test criteria

**TABLE E.4                      Analytics Environmental Radioactivity Cross Check Program  
Exelon Industrial Services**

| Month/Year    | Identification Number | Matrix    | Nuclide | Units      | EIS Reported Value | Known Value <sup>(a)</sup> | Ratio of Analytics to EIS Result | Evaluation <sup>(b)</sup> |
|---------------|-----------------------|-----------|---------|------------|--------------------|----------------------------|----------------------------------|---------------------------|
| December 2018 | E12343                | Water     | Gr-B    | pCi/L      | 257                | 295                        | 87.1                             | Pass                      |
|               | E12344                | Cartridge | I-131   | pCi        | 86.2               | 89.7                       | 96.1                             | Pass                      |
|               | E12342A               | AP        | Ce-141  | pCi/Filter | 97.9               | 97.0                       | 101                              | Pass                      |
|               |                       |           | Cr-51   | pCi/Filter | 226                | 217                        | 104                              | Pass                      |
|               |                       |           | Cs-134  | pCi/Filter | 112.0              | 125.0                      | 89.6                             | Pass                      |
|               |                       |           | Cs-137  | pCi/Filter | 98.8               | 88.2                       | 112                              | Pass                      |
|               |                       |           | Co-58   | pCi/Filter | 85.7               | 86.5                       | 99.1                             | Pass                      |
|               |                       |           | Mn-54   | pCi/Filter | 123                | 112.0                      | 110                              | Pass                      |
|               |                       |           | Fe-59   | pCi/Filter | 97.9               | 83.4                       | 117                              | Pass                      |
|               |                       |           | Zn-65   | pCi/Filter | 201                | 193                        | 104                              | Pass                      |
|               |                       |           | Co-60   | pCi/Filter | 158                | 155                        | 102                              | Pass                      |
|               |                       |           | E12345  | Milk       | I-131              | pCi/L                      | 95.8                             | 93.3                      |
|               | Ce-141                | pCi/L     |         |            | 145                | 133.0                      | 109                              | Pass                      |
|               | Cr-51                 | pCi/L     |         |            | 372                | 298                        | 125                              | Pass                      |
|               | Cs-134                | pCi/L     |         |            | 193                | 171                        | 113                              | Pass                      |
|               | Cs-137                | pCi/L     |         |            | 141                | 121                        | 117                              | Pass                      |
|               | Co-58                 | pCi/L     |         |            | 123.0              | 119.0                      | 103                              | Pass                      |
|               | Mn-54                 | pCi/L     |         |            | 178                | 154                        | 116                              | Pass                      |
|               | Fe-59                 | pCi/L     |         |            | 127                | 114                        | 111                              | Pass                      |
|               | Zn-65                 | pCi/L     |         |            | 242                | 264                        | 91.7                             | Pass                      |
|               | Co-60                 | pCi/L     |         |            | 215                | 212                        | 101                              | Pass                      |

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on EIS internal QC limits in accordance with the NRC Resolution Test criteria

TABLE E.5

**ERA Environmental Radioactivity Cross Check Program  
Exelon Industrial Services**

| Month/Year     | ID Number | Matrix | Nuclide | Units      | EIS<br>Reported<br>Value | Known<br>Value <sup>(a)</sup> | Acceptance<br>Limits | Acceptance<br>Ratio of ERA<br>to EIS Result | Evaluation <sup>(b)</sup> |
|----------------|-----------|--------|---------|------------|--------------------------|-------------------------------|----------------------|---|---------------------------|
| April 2018     | RAD-113   | Water  | Ba-133  | pCi/L      | 88.0                     | 91.5                          |                      | 96.2  | Pass                      |
|                |           |        | Cs-134  | pCi/L      | 81.1                     | 75.9                          |                      | 107   | Pass                      |
|                |           |        | Cs-137  | pCi/L      | 131                      | 123                           |                      | 107   | Pass                      |
|                |           |        | Co-60   | pCi/L      | 70.0                     | 64.3                          |                      | 109   | Pass                      |
|                |           |        | Zn-65   | pCi/L      | 95.9                     | 86.7                          |                      | 111   | Pass                      |
|                |           |        | I-131   | pCi/L      | 24.1                     | 24.6                          |                      | 98.0  | Pass                      |
|                |           |        | GR-B    | pCi/L      | 64.6                     | 73.7                          |                      | 87.7  | Pass                      |
| July 2018      | RAD-114   |        | H-3     | pCi/L      | 215.9                    | 251                           |                      | 86.0  | Pass                      |
| September 2018 | MRAD-29   | AP     | Am-241  | pCi/Filter | 52.3                     | 64.1                          |                      | 81.6  | Pass                      |
|                |           |        | Cs-134  | pCi/Filter | 870                      | 921                           |                      | 94.5  | Pass                      |
|                |           |        | Cs-137  | pCi/Filter | 403                      | 373                           |                      | 108   | Pass                      |
|                |           |        | Co-60   | pCi/Filter | 1178                     | 1130                          |                      | 104   | Pass                      |
|                |           |        | Zn-65   | pCi/Filter | 696                      | 660                           |                      | 105   | Pass                      |
| October 2018   | RAD-115   | Water  | Ba-133  | pCi/L      | 13.4                     | 16.3                          |                      | 82.2  | Pass                      |
|                |           |        | Cs-134  | pCi/L      | 87.9                     | 93.0                          |                      | 94.5  | Pass                      |
|                |           |        | Cs-137  | pCi/L      | 223.4                    | 235.0                         |                      | 95.1  | Pass                      |
|                |           |        | Co-60   | pCi/L      | 80.2                     | 80.7                          |                      | 99.4  | Pass                      |
|                |           |        | Zn-65   | pCi/L      | 317.8                    | 336                           |                      | 94.6  | Pass                      |
|                |           |        | I-131   | pCi/L      | 28.1                     | 27.2                          |                      | 103   | Pass                      |

(a) The ERA known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.

(b) Analytics evaluation based on EIS internal QC limits in accordance with the NRC Resolution Test criteria



TABLE E.6

**2018 DEPARTMENT OF ENERGY MIXED ANALYTE PERFORMANCE EVALUATION  
PROGRAM (MAPEP) RESULTS  
GEL LABORATORIES**

| PT Provider | Quarter / Year | Report Received Date | Sample Number  | Sample Media | Unit      | Analyte / Nuclide | GEL Value | Known value | Acceptance Range/ Ratio | Evaluation |
|-------------|----------------|----------------------|----------------|--------------|-----------|-------------------|-----------|-------------|-------------------------|------------|
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Americium-241     | 1.84      |             | False Pos Test          | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Cesium-134        | 1.85      |             | False Pos Test          | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Cesium-137        | 4.85      | 4.6         | Sens. Eval.             | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Cobalt-57         | 798       | 826         | 578-1074                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Cobalt-60         | 581       | 560         | 392-728                 | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Iron-55           | 67        |             | False Pos Test          | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Manganese-54      | 1060      | 1010        | 707-1313                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Nickel-63         | 1.05      |             | False Pos Test          | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Plutonium-238     | 42.7      | 45.2        | 31.6-58.8               | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Plutonium-239/240 | 46.9      | 50.8        | 35.6-66.0               | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Potassium-40      | 649       | 577         | 404-750                 | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Strontium-90      | -1.08     |             | False Pos Test          | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Technetium-99     | 890       | 980         | 686-1274                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | U-234/233         | 58.9      | 52.9        | 37.0-68.8               | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Uranium-238       | 134       | 141         | 99-183                  | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaS38 | Soil         | Bq/Kg     | Zinc-65           | 1060      | 960         | 672-1248                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Americium-241     | 0.685     | 0.709       | 0.496-0.922             | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Cesium-134        | 9.140     | 10.2        | 7.1-13.3                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Cesium-137        | 12.8      | 12.2        | 8.5-15.9                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Cobalt-57         | -0.042    |             | False Pos Test          | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Cobalt-60         | 12.1      | 11.5        | 8.1-15.0                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Hydrogen-3        | 1.14      |             | False Pos Test          | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Iron-55           | 11.90     | 11.1        | 7.8-14.1                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Manganese-54      | 9.35E-04  |             | False Pos Test          | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Nickel-63         | 14.5      | 14.0        | 9.8-18.2                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Plutonium-238     | 0.014     | 0.023       | Sens. Eval.             | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Plutonium-239/240 | 0.586     | 0.600       | 0.420-0.780             | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Potassium-40      | -0.23     |             | False Pos Test          | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Radium-226        | 0.249     | 0.257       | 0.180-0.334             | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Strontium-90      | 10.70     | 11.400      | 8.0-14.8                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Technetium-99     | 3.84      | 4.4         | 3.06-5.68               | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Uranium-234/233   | 0.45      | 0.43        | 0.301-0.559             | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Uranium-238       | 0.48      | 0.44        | 0.306-0.568             | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-MaW38 | Water        | Bq/L      | Zinc-65           | 15.7      | 14.30       | 0.0-18.6                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-RdF38 | Filter       | ug/sample | Uranium-235       | 0.076     | 0.0739      | 0.0517-0.0961           | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-RdF38 | Filter       | ug/sample | Uranium-238       | 10.60     | 10.4        | 7.3-13.5                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-RdF38 | Filter       | ug/sample | Uranium-Total     | 10.68     | 10.5        | 7.4-13.7                | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-RdF38 | Filter       | Bq/sample | Americium-241     | 0.0646    | 0.0670      | 0.047-0.087             | Acceptable |
| MAPEP       | 2nd/2018       | 05/31/18             | MAPEP-18-RdF38 | Filter       | Bq/sample | Cesium-134        | 0.72      | 0.675       | 0.473-0.878             | Acceptable |

|       |          |          |                |            |           |                   |         |        |                |            |
|-------|----------|----------|----------------|------------|-----------|-------------------|---------|--------|----------------|------------|
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Cesium-137        | -0.023  |        | False Pos Test | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Cobalt-57         | 1.22    | 1.18   | 0.83-1.53      | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Cobalt-60         | 0.010   |        | False Pos Test | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Manganese-54      | 1.08    | 1.03   | 0.72-1.34      | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Plutonium-238     | 0.0440  | 0.0445 | 0.0312-0.0579  | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Plutonium-239/240 | 0.0010  |        | False Pos Test | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Strontium-90      | 0.840   | 1.010  | 0.71-1.31      | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Uranium-234/233   | 0.121   | 0.124  | 0.087-0.161    | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Uranium-238       | 0.126   | 0.128  | 0.090-0.166    | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Zinc-65           | 1.54    | 1.33   | 0.93-1.73      | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Americium-241     | 0.107   | 0.106  | 0.074-0.138    | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Cesium-134        | 3.17    | 3.23   | 2.26-4.2       | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Cesium-137        | 4.03    | 3.67   | 2.57-4.77      | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Cobalt-57         | 4.76    | 4.42   | 3.09-5.75      | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Cobalt-60         | 2.49    | 2.3    | 1.60-2.98      | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Manganese-54      | 3.02    | 2.66   | 1.86-3.46      | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Plutonium-238     | 0.0005  |        | False Pos Test | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Plutonium-239/240 | 0.0679  | 0.0770 | 0.054-0.1      | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Strontium-90      | 0.61    | 0.675  | 0.473-0.878    | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Uranium-234/233   | 0.21    | 0.179  | 0.125-0.233    | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Uranium-238       | 0.197   | 0.186  | 0.130-0.242    | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Zinc-65           | 0.02    |        | False Pos Test | Acceptable |
| MAPEP | 2nd/2018 | 05/31/18 | MAPEP-18-XaW38 | Water      | Bq/L      | Iodine-129        | 2.00    | 1.93   | 1.35-2.51      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Americium-241     | 55.4    | 55.5   | 38.9-72.2      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Cesium-134        | 693.00  | 781    | 547-1015       | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Cesium-137        | 598     | 572    | 400-744        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Cobalt-57         | 1080    | 958    | 671-1245       | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Cobalt-60         | 595.000 | 608    | 426-790        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Iron-55           | 434     | 512    | 358-666        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Manganese-54      | 0.24    |        | False Pos Test | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Nickel-63         | 793     | 765    | 536-995        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Plutonium-238     | 55.2    | 57.0   | 39.9-74.1      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Plutonium-239/240 | -0.33   | 0.34   | Sens. Eval     | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Potassium-40      | 556     | 566    | 396-736        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Strontium-90      | 162     | 193    | 135-251        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Technetium-99     | 239     | 252    | 176-328        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | U-234/233         | 113     | 160    | 112-208        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Uranium-238       | 224     | 276    | 193-359        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaS39 | Soil       | Bq/Kg     | Zinc-65           | 537.0   | 500    | 350-650        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Americium-241     | 0.007   |        | False Pos Test | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Cesium-134        | 7.94    | 8.7    | 6.1-11.3       | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Cesium-137        | 7.41    | 6.9    | 4.8-9.0        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Cobalt-57         | 15.1    | 14.9   | 10.4-19.4      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Cobalt-60         | 0.0408  |        | False Pos Test | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Hydrogen-3        | 331     | 338    | 237-439        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Iron-55           | 8.41    | 9.0    | 6.3-11.7       | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Manganese-54      | 13.2    | 12.5   | 8.8-16.3       | Acceptable |

|       |          |          |                |            |           |                   |          |        |                  |            |
|-------|----------|----------|----------------|------------|-----------|-------------------|----------|--------|------------------|------------|
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Nickel-63         | 6.14     | 7.0    | 4.9-9.1          | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Plutonium-238     | 0.591    | 0.67   | 0.472-0.876      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Plutonium-239/240 | 0.801    | 0.928  | 0.650-1.206      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Potassium-40      | 0.884    |        | False Pos Test   | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Radium-226        | 0.566    | 0.44   | 0.309-0.575      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Strontium-90      | 8.24     | 9.41   | 6.59-12.23       | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Technetium-99     | 3.87     | 3.39   | 2.73-4.41        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Uranium-234/233   | 2.13     | 2.11   | 1.48-2.74        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Uranium-238       | 2.170    | 2.180  | 1.53-2.83        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-MaW39 | Water      | Bq/L      | Zinc-65           | 8.52     | 7.53   | 5.27-9.79        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | ug/sample | Uranium-235       | 0.0936   | 0.0913 | 0.0650 - 0.1208  | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | ug/sample | Uranium-238       | 13.4     | 12.7   | 8.9 - 16.5       | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | ug/sample | Uranium-Total     | 13.5     | 12.8   | 9.0 - 16.6       | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Americium-241     | 0.0919   | 0.0913 | 0.0639 - 0.1187  | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Cesium-134        | 0.431    | 0.444  | 0.311 - 0.577    | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Cesium-137        | 0.338    | 0.345  | 0.242 - 0.449    | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Cobalt-57         | 0.598    | 0.592  | 0.414 - 0.770    | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Cobalt-60         | 0.338    | 0.294  | 0.206 - 0.382    | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Manganese-54      | 0.326    | 0.266  | 0.186 - 0.346    | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Plutonium-238     | 0.000398 | 0.0011 | Sens. Evaluation | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Plutonium-239/240 | 0.0672   | 0.0698 | 0.0489 - 0.0907  | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Strontium-90      | -0.026   |        | False Pos Test   | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Uranium-234/233   | 0.148    | 0.152  | 0.106 - 0.198    | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Uranium-238       | 0.150    | 0.158  | 0.111 - 0.205    | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdF38 | Filter     | Bq/sample | Zinc-65           | 0.229    | 0.201  | Sens. Evaluation | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Americium-241     | 0.0851   | 0.0930 | 0.065-0.121      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Cesium-134        | 1.74     | 1.94   | 1.36-2.52        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Cesium-137        | 2.42     | 2.36   | 1.65-3.07        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Cobalt-57         | 3.24     | 3.31   | 2.32-4.30        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Cobalt-60         | 1.69     | 1.68   | 1.18-2.18        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Manganese-54      | 2.59     | 2.53   | 1.77-3.29        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Plutonium-238     | 0.0680   | 0.070  | 0.049-0.091      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Plutonium-239/240 | 0.0605   | 0.0620 | 0.043-0.081      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Strontium-90      | 0.718    | 0.791  | 0.554-1.028      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Uranium-234/233   | 0.136    | 0.138  | 0.097-0.179      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Uranium-238       | 0.140    | 0.143  | 0.100-0.186      | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-RdV38 | Vegetation | Bq/sample | Zinc-65           | 1.51     | 1.37   | 0.96-1.78        | Acceptable |
| MAPEP | 4th/2018 | 12/03/18 | MAPEP-18-XaW39 | Alk. Water | Bq/L      | Iodine-129        | 1.63     | 1.62   | 1.13-2.11        | Acceptable |

TABLE E.7

**2018 ERA (RAD) PROGRAM PERFORMANCE EVALUATION  
RESULTS GEL LABORATORIES**

| PT Provider | Quarter / Year | Report Received Date | Sample Number | Sample Media | Unit  | Analyte / Nuclide  | GEL Value | Known value | Acceptance Range | Evaluation     |
|-------------|----------------|----------------------|---------------|--------------|-------|--------------------|-----------|-------------|------------------|----------------|
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Barium-133         | 86.7      | 85.6        | 72.0 - 94.2      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Cesium-134         | 51.2      | 52.6        | 42.4 - 57.9      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Cesium-137         | 118       | 112         | 101 - 126        | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Cobalt-60          | 118       | 113         | 102 - 126        | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Zinc-65            | 202       | 189         | 170 - 222        | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Gross Alpha        | 71.6      | 52.3        | 27.3 - 65.5      | Not Acceptable |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Gross Alpha        | 69.6      | 52.3        | 27.3 - 65.5      | Not Acceptable |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Gross Beta         | 37.6      | 41.6        | 27.7 - 49.0      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Radium-226         | 12.3      | 12.7        | 9.48 - 14.7      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Radium-226         | 13.1      | 12.7        | 9.48 - 14.7      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Radium-226         | 14.2      | 12.7        | 9.48 - 14.7      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Radium-228         | 6.31      | 6.2         | 3.83 - 8.08      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Radium-228         | 6.36      | 6.2         | 3.83 - 8.08      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Uranium (Nat)      | 12.2      | 12.6        | 9.91 - 14.4      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | µg/L  | Uranium (Nat) mass | 19.7      | 18.4        | 14.5 - 21.1      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | µg/L  | Uranium (Nat) mass | 18.9      | 18.4        | 14.5 - 21.1      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Tritium            | 11300     | 12500       | 10900 - 13800    | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Tritium            | 11600     | 12500       | 10900 - 13800    | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Strontium-89       | 60.2      | 55.5        | 44.3 - 63.2      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Strontium-89       | 54.5      | 55.5        | 44.3 - 63.2      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Strontium-90       | 35.9      | 43.1        | 31.8 - 49.5      | Acceptable     |
| ERA         | 1st/2018       | 2/27/17              | RAD-108       | Water        | pCi/L | Strontium-90       | 37.7      | 43.1        | 31.8 - 49.5      | Acceptable     |
| ERA         | 2nd/2018       | 05/30/17             | RAD-109       | Water        | pCi/L | Gross Alpha        | 79.7      | 75          | 39.5 - 92.3      | Acceptable     |
| ERA         | 2nd/2018       | 05/30/17             | RAD-109       | Water        | pCi/L | Gross Alpha        | 72.9      | 75          | 39.5 - 92.3      | Acceptable     |
| ERA         | 2nd/2018       | 05/30/17             | RAD-109       | Water        | pCi/L | Gross Alpha        | 72.9      | 75          | 39.5 - 92.3      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Barium-133         | 68.8      | 66.3        | 55.2 - 72.9      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Cesium-134         | 24.7      | 24.4        | 18.7 - 27.2      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Cesium-137         | 51.7      | 51.6        | 46.4 - 59.6      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Cobalt-60          | 97        | 88.6        | 79.7 - 99.8      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Zinc-65            | 39.7      | 32.7        | 27.3 - 41.6      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Gross Alpha        | 26.3      | 25.7        | 13.0 - 34.1      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Gross Alpha        | 31.9      | 25.7        | 13.0 - 34.1      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Gross Beta         | 54.4      | 63          | 43.5 - 69.6      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Radium-226         | 1.6       | 1.29        | 1.07 - 1.95      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Radium-226         | 1.21      | 1.29        | 1.07 - 1.95      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Radium-228         | 6.49      | 5.66        | 3.45 - 7.47      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Radium-228         | 5.59      | 5.66        | 3.45 - 7.47      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Uranium (Nat)      | 65        | 66.7        | 54.3 - 73.9      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Uranium (Nat)      | 66.2      | 66.7        | 54.3 - 73.9      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | µg/L  | Uranium (Nat) mass | 97        | 98.1        | 79.8 - 109       | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | µg/L  | Uranium (Nat) mass | 104.7     | 98.1        | 79.8 - 109       | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Tritium            | 5120      | 5060        | 4340 - 5570      | Acceptable     |
| ERA         | 3rd/2018       | 08/28/17             | RAD - 110     | Water        | pCi/L | Tritium            | 4620      | 5060        | 4340 - 5570      | Acceptable     |

|     |          |          |           |       |       |              |      |      |             |                |
|-----|----------|----------|-----------|-------|-------|--------------|------|------|-------------|----------------|
| ERA | 3rd/2018 | 08/28/17 | RAD - 110 | Water | pCi/L | Strontium-89 | 29.9 | 26.4 | 18.4 - 32.9 | Acceptable     |
| ERA | 3rd/2018 | 08/28/17 | RAD - 110 | Water | pCi/L | Strontium-89 | 28.2 | 26.4 | 18.4 - 32.9 | Acceptable     |
| ERA | 3rd/2018 | 08/28/17 | RAD - 110 | Water | pCi/L | Strontium-90 | 37.8 | 36   | 26.4 - 41.5 | Acceptable     |
| ERA | 3rd/2018 | 08/28/17 | RAD - 110 | Water | pCi/L | Strontium-90 | 34   | 36   | 26.4 - 41.5 | Acceptable     |
| ERA | 3rd/2018 | 08/28/17 | RAD - 110 | Water | pCi/L | Iodine-131   | 28   | 25.5 | 21.2 - 30.1 | Acceptable     |
| ERA | 3rd/2018 | 08/28/17 | RAD - 110 | Water | pCi/L | Iodine-131   | 33   | 25.5 | 21.2 - 30.1 | Not Acceptable |

**2018 ERA PROGRAM (MRAD) PERFORMANCE EVALUATION RESULTS**  
**GEL LABORATORIES**

| PT Provider | Quarter / Year | Report Received Date | Sample Number | Sample Media | Unit  | Analyte / Nuclide  | GEL Value | Known value | Acceptance Range | Evaluation     |
|-------------|----------------|----------------------|---------------|--------------|-------|--------------------|-----------|-------------|------------------|----------------|
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Barium-133         | 97.6      | 95.1        | 80.2 - 105       | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Cesium-134         | 64.9      | 65.6        | 53.4 - 72.2      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Cesium-137         | 117       | 112         | 101 - 126        | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Cobalt-60          | 122       | 114         | 103 - 128        | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Zinc-65            | 320       | 277         | 249 - 324        | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Gross Alpha        | 67.7      | 72.4        | 38.1 - 89.2      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Gross Alpha        | 66.4      | 72.4        | 38.1 - 89.2      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Gross Beta         | 47.6      | 54.8        | 37.5 - 61.7      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Radium-226         | 16.2      | 14.2        | 10.6 - 16.3      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Radium-226         | 16.3      | 14.2        | 10.6 - 16.3      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Radium-226         | 5         | 4.21        | 2.43 - 5.81      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Radium-228         | 4.44      | 4.21        | 2.43 - 5.81      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Radium-228         | 65.4      | 58.6        | 47.8 - 64.5      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Uranium (Nat)      | 56.4      | 58.6        | 47.8-64.5        | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Uranium (Nat)      | 65.4      | 58.6        | 47.8 - 64.5      | Not Acceptable |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | µg/L  | Uranium (Nat) mass | 97.6      | 86.2        | 70.3 - 94.9      | Not Acceptable |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | µg/L  | Uranium (Nat) mass | 93.3      | 86.2        | 70.3 - 94.9      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Tritium            | 20000     | 21200       | 18600 - 23300    | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Tritium            | 20200     | 21200       | 18600 - 23300    | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Strontium-89       | 59.7      | 65.2        | 52.9 - 73.2      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Strontium-89       | 68.6      | 65.2        | 52.9 - 73.2      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Strontium-90       | 36.1      | 39.2        | 28.8 - 45.1      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Strontium-90       | 36.9      | 39.2        | 28.8 - 45.1      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Iodine-131         | 25.3      | 28.1        | 23.4 - 33.0      | Acceptable     |
| ERA         | 1st / 2018     | 2/26/18              | RAD-112       | Water        | pCi/L | Iodine-131         | 28.6      | 28.1        | 23.4 - 33.0      | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Barium-133         | 28.5      | 25.6        | 19.9 - 29.4      | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Cesium-134         | 15.9      | 15.7        | 11.4 - 18.2      | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Cesium-137         | 196       | 192         | 173 - 213        | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Cobalt-60          | 122       | 119         | 107 - 133        | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Zinc-65            | 196       | 177         | 159 - 208        | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Gross Alpha        | 15.5      | 16          | 7.79 - 22.6      | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Gross Alpha        | 18.2      | 16          | 7.79 - 22.6      | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Gross Beta         | 43.6      | 49          | 33.2 - 56.1      | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Radium-226         | 8.44      | 9.08        | 6.81 - 10.6      | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Radium-228         | 2.72      | 2.28        | 1.07 - 3.60      | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Radium-228         | 3.3       | 2.28        | 1.07 - 3.60      | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Uranium (Nat)      | 53.8      | 51.8        | 42.2 - 57.1      | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | pCi/L | Uranium (Nat)      | 50.3      | 51.8        | 42.2 - 57.1      | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | µg/L  | Uranium (Nat) mass | 80.3      | 75.5        | 61.5 - 83.2      | Acceptable     |
| ERA         | 3rd / 2018     | 08/23/18             | RAD-114       | Water        | µg/L  | Uranium (Nat) mass | 78.36     | 75.5        | 61.5 - 83.2      | Acceptable     |

|     |            |          |         |       |       |                       |       |       |                  |            |
|-----|------------|----------|---------|-------|-------|-----------------------|-------|-------|------------------|------------|
| ERA | 3rd / 2018 | 08/23/18 | RAD-114 | Water | µg/L  | Uranium (Nat)<br>mass | 77.8  | 75.5  | 61.5 - 83.2      | Acceptable |
| ERA | 3rd / 2018 | 08/23/18 | RAD-114 | Water | pCi/L | Tritium               | 19900 | 20400 | 17900 -<br>22400 | Acceptable |
| ERA | 3rd / 2018 | 08/23/18 | RAD-114 | Water | pCi/L | Tritium               | 21200 | 20400 | 17900 -<br>22400 | Acceptable |
| ERA | 3rd / 2018 | 08/23/18 | RAD-114 | Water | pCi/L | Strontium-89          | 61.5  | 62.7  | 50.7 - 70.6      | Acceptable |
| ERA | 3rd / 2018 | 08/23/18 | RAD-114 | Water | pCi/L | Strontium-89          | 69    | 62.7  | 50.7 - 70.6      | Acceptable |
| ERA | 3rd / 2018 | 08/23/18 | RAD-114 | Water | pCi/L | Strontium-90          | 34.4  | 40.1  | 29.5 - 46.1      | Acceptable |
| ERA | 3rd / 2018 | 08/23/18 | RAD-114 | Water | pCi/L | Strontium-90          | 36.2  | 40.1  | 29.5 - 46.1      | Acceptable |
| ERA | 3rd / 2018 | 08/23/18 | RAD-114 | Water | pCi/L | Iodine-131            | 25.6  | 28.1  | 23.4 - 33.0      | Acceptable |
| ERA | 3rd / 2018 | 08/23/18 | RAD-114 | Water | pCi/L | Iodine-131            | 28.7  | 28.1  | 23.4 - 33.0      | Acceptable |

TABLE E.8

**2018 ECKERT & ZIEGLER ANALYTICS PERFORMANCE EVALUATION RESULTS  
GEL LABORATORIES**

| PT Provider | Quarter / Year | Report Received Date | Sample Number | Sample Media | Unit  | Analyte / Nuclide | GEL Value | Known value | Acceptance Range/ Ratio | Evaluation |
|-------------|----------------|----------------------|---------------|--------------|-------|-------------------|-----------|-------------|-------------------------|------------|
| EZA         | 1st / 2018     | 05/11/18             | E12171        | Cartridge    | pCi   | Iodine-131        | 9.20E+01  | 8.52E+01    | 0.97                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12172        | Milk         | pCi/L | Strontium-89      | 9.16E+01  | 9.01E+01    | 1.02                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12172        | Milk         | pCi/L | Strontium-90      | 8.00E+01  | 1.25E+02    | 0.64                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12173        | Milk         | pCi/L | Iodine-131        | 1.05E+02  | 1.08E+02    | 0.97                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12173        | Milk         | pCi/L | Cerium-141        | 7.23E+01  | 7.70E+01    | 0.94                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12173        | Milk         | pCi/L | Cobalt-58         | 1.11E+02  | 1.14E+02    | 0.97                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12173        | Milk         | pCi/L | Cobalt-60         | 1.90E+02  | 1.87E+02    | 1.02                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12173        | Milk         | pCi/L | Chromium-51       | 3.00E+02  | 3.26E+02    | 0.92                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12173        | Milk         | pCi/L | Cesium-134        | 1.58E+02  | 1.80E+02    | 0.88                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12173        | Milk         | pCi/L | Cesium-137        | 1.75E+02  | 1.72E+02    | 1.02                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12173        | Milk         | pCi/L | Manganese-54      | 1.36E+02  | 1.31E+02    | 1.04                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12173        | Milk         | pCi/L | Iron-59           | 1.52E+02  | 1.39E+02    | 1.10                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12173        | Milk         | pCi/L | Zinc-65           | 2.73E+02  | 2.44E+02    | 1.12                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12174        | Water        | pCi/L | Iodine-131        | 9.37E+01  | 9.10E+01    | 1.03                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12174        | Water        | pCi/L | Cerium-141        | 7.86E+01  | 7.34E+01    | 1.07                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12174        | Water        | pCi/L | Chromium-51       | 3.44E+02  | 3.10E+02    | 1.11                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12174        | Water        | pCi/L | Cesium-134        | 1.61E+02  | 1.71E+02    | 0.94                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12174        | Water        | pCi/L | Cesium-137        | 1.64E+02  | 1.64E+02    | 1.00                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12174        | Water        | pCi/L | Cobalt-58         | 1.92E+02  | 1.78E+02    | 1.08                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12174        | Water        | pCi/L | Manganese-54      | 1.36E+02  | 1.25E+02    | 1.09                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12174        | Water        | pCi/L | Iron-59           | 1.48E+02  | 1.32E+02    | 1.12                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12174        | Water        | pCi/L | Zinc-65           | 2.53E+02  | 2.33E+02    | 1.09                    | Acceptable |
| EZA         | 1st / 2018     | 05/11/18             | E12174        | Water        | pCi/L | Cobalt-60         | 1.92E+02  | 1.78E+02    | 1.08                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12171        | Cartridge    | pCi   | Iodine-131        | 7.22E+01  | 7.16E+01    | 1.01                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12172        | Milk         | pCi/L | Strontium-89      | 9.58E+01  | 8.46E+01    | 1.13                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12172        | Milk         | pCi/L | Strontium-90      | 8.47E+00  | 1.14E+01    | 0.74                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12173        | Milk         | pCi/L | Iodine-131        | 7.89E+01  | 7.19E+01    | 1.10                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12173        | Milk         | pCi/L | Cerium-141        | 9.01E+01  | 8.22E+01    | 1.10                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12173        | Milk         | pCi/L | Cobalt-58         | 9.26E+01  | 8.90E+01    | 1.04                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12173        | Milk         | pCi/L | Cobalt-60         | 1.18E+02  | 1.13E+02    | 1.04                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12173        | Milk         | pCi/L | Chromium-51       | 2.58E+02  | 2.39E+02    | 1.08                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12173        | Milk         | pCi/L | Cesium-134        | 1.10E+02  | 1.14E+02    | 0.97                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12173        | Milk         | pCi/L | Cesium-137        | 1.04E+02  | 9.88E+01    | 1.05                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12173        | Milk         | pCi/L | Manganese-54      | 1.42E+02  | 1.30E+02    | 1.09                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12173        | Milk         | pCi/L | Iron-59           | 8.87E+01  | 8.60E+01    | 1.03                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12173        | Milk         | pCi/L | Zinc-65           | 1.83E+02  | 1.57E+02    | 1.16                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12174        | Water        | pCi/L | Iodine-131        | 7.31E+01  | 7.44E+01    | 0.98                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12174        | Water        | pCi/L | Cerium-141        | 1.02E+02  | 8.58E+01    | 1.19                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12174        | Water        | pCi/L | Chromium-51       | 2.73E+02  | 2.49E+02    | 1.10                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12174        | Water        | pCi/L | Cesium-134        | 1.06E+02  | 1.19E+02    | 0.89                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12174        | Water        | pCi/L | Cesium-137        | 9.86E+01  | 1.03E+02    | 0.96                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12174        | Water        | pCi/L | Cobalt-58         | 9.76E+01  | 9.29E+01    | 1.05                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12174        | Water        | pCi/L | Manganese-54      | 1.47E+02  | 1.35E+02    | 1.09                    | Acceptable |
| EZA         | 2nd/2018       | 07/07/18             | E12174        | Water        | pCi/L | Iron-59           | 1.08E+02  | 8.97E+01    | 1.20                    | Acceptable |



|     |          |          |        |           |       |              |          |          |      |            |
|-----|----------|----------|--------|-----------|-------|--------------|----------|----------|------|------------|
| EZA | 2nd/2018 | 07/07/18 | E12174 | Water     | pCi/L | Zinc-65      | 1.97E+02 | 1.64E+02 | 1.20 | Acceptable |
| EZA | 2nd/2018 | 07/07/18 | E12174 | Water     | pCi/L | Cobalt-60    | 1.22E+02 | 1.18E+02 | 1.03 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12240 | Cartridge | pCi   | Iodine-131   | 7.95E+01 | 8.03E+01 | 0.99 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12241 | Milk      | pCi/L | Strontium-89 | 8.57E+01 | 8.17E+01 | 1.05 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12241 | Milk      | pCi/L | Strontium-90 | 9.22E+00 | 1.48E+01 | 0.62 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12242 | Milk      | pCi/L | Iodine-131   | 7.18E+01 | 5.82E+01 | 1.23 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12242 | Milk      | pCi/L | Cerium-141   | 1.43E+02 | 1.28E+02 | 1.12 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12242 | Milk      | pCi/L | Chromium-51  | 2.54E+02 | 2.65E+02 | 0.96 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12242 | Milk      | pCi/L | Cesium-134   | 1.18E+02 | 1.23E+02 | 0.96 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12242 | Milk      | pCi/L | Cesium-137   | 1.53E+02 | 1.47E+02 | 1.04 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12242 | Milk      | pCi/L | Cobalt-58    | 1.54E+02 | 1.44E+02 | 1.07 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12242 | Milk      | pCi/L | Manganese-54 | 1.84E+02 | 1.67E+02 | 1.09 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12242 | Milk      | pCi/L | Iron-59      | 1.20E+02 | 1.19E+02 | 1.01 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12242 | Milk      | pCi/L | Zinc-65      | 2.44E+02 | 2.01E+02 | 1.22 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12242 | Milk      | pCi/L | Cobalt-60    | 2.02E+02 | 1.90E+02 | 1.06 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12243 | Water     | pCi/L | Iodine-131   | 6.76E+01 | 6.25E+01 | 1.08 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12243 | Water     | pCi/L | Cerium-141   | 1.48E+02 | 1.33E+02 | 1.11 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12243 | Water     | pCi/L | Chromium-51  | 2.92E+02 | 2.75E+02 | 1.06 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12243 | Water     | pCi/L | Cesium-134   | 1.20E+02 | 1.28E+02 | 0.94 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12243 | Water     | pCi/L | Cesium-137   | 1.64E+02 | 1.54E+02 | 1.07 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12243 | Water     | pCi/L | Cobalt-58    | 1.53E+02 | 1.50E+02 | 1.02 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12243 | Water     | pCi/L | Manganese-54 | 1.91E+02 | 1.74E+02 | 1.1  | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12243 | Water     | pCi/L | Iron-59      | 1.39E+02 | 1.24E+02 | 1.12 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12243 | Water     | pCi/L | Zinc-65      | 2.41E+02 | 2.09E+02 | 1.15 | Acceptable |
| EZA | 3rd/2018 | 11/12/18 | E12243 | Water     | pCi/L | Cobalt-60    | 2.09E+02 | 1.98E+02 | 1.06 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12346 | Cartridge | pCi   | Iodine-131   | 8.92E+01 | 8.98E+01 | 0.99 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12347 | Milk      | pCi/L | Strontium-89 | 8.67E+01 | 9.19E+01 | 0.94 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12347 | Milk      | pCi/L | Strontium-90 | 1.07E+01 | 1.33E+01 | 0.80 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12348 | Milk      | pCi/L | Iodine-131   | 9.58E+01 | 9.33E+01 | 1.03 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12348 | Milk      | pCi/L | Cerium-141   | 1.37E+02 | 1.33E+02 | 1.03 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12348 | Milk      | pCi/L | Chromium-51  | 2.66E+02 | 2.98E+02 | 0.89 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12348 | Milk      | pCi/L | Cesium-134   | 1.52E+02 | 1.71E+02 | 0.89 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12348 | Milk      | pCi/L | Cesium-137   | 1.25E+02 | 1.21E+02 | 1.03 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12348 | Milk      | pCi/L | Cobalt-58    | 1.19E+02 | 1.19E+02 | 1.00 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12348 | Milk      | pCi/L | Manganese-54 | 1.70E+02 | 1.54E+02 | 1.10 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12348 | Milk      | pCi/L | Iron-59      | 1.25E+02 | 1.14E+02 | 1.09 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12348 | Milk      | pCi/L | Zinc-65      | 2.75E+02 | 2.64E+02 | 1.04 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12348 | Milk      | pCi/L | Cobalt-60    | 2.12E+02 | 2.12E+02 | 1.00 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12349 | Water     | pCi/L | Iodine-131   | 8.19E+01 | 8.04E+01 | 1.02 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12349 | Water     | pCi/L | Cerium-141   | 1.26E+02 | 1.24E+02 | 1.02 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12349 | Water     | pCi/L | Chromium-51  | 3.20E+02 | 2.78E+02 | 1.15 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12349 | Water     | pCi/L | Cesium-134   | 1.41E+02 | 1.60E+02 | 0.88 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12349 | Water     | pCi/L | Cesium-137   | 1.21E+02 | 1.13E+02 | 1.07 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12349 | Water     | pCi/L | Cobalt-58    | 1.09E+02 | 1.11E+02 | 0.99 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12349 | Water     | pCi/L | Manganese-54 | 1.51E+02 | 1.44E+02 | 1.05 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12349 | Water     | pCi/L | Iron-59      | 1.16E+02 | 1.07E+02 | 1.09 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12349 | Water     | pCi/L | Zinc-65      | 2.76E+02 | 2.46E+02 | 1.12 | Acceptable |
| EZA | 4th/2018 | 01/23/19 | E12349 | Water     | pCi/L | Cobalt-60    | 2.06E+02 | 1.98E+02 | 1.04 | Acceptable |

## **APPENDIX F**

# **ANNUAL RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM REPORT (ARGPPR)**

Intentionally left blank

Docket No: 50-289  
50-320

# **THREE MILE ISLAND NUCLEAR STATION UNITS 1 AND 2**

Annual Radiological Groundwater  
Protection Program Report (ARGPPR)

1 January through 31 December 2018

**Prepared By**  
Teledyne Brown Engineering  
Environmental Services



Three Mile Island Nuclear Station  
Middletown, PA 17057

**April 2019**

Intentionally left blank

# Table Of Contents

|   |    |
|---|----|
| I. Summary and Conclusions .....          | 1  |
| II. Introduction.....                     | 3  |
| A. Objectives of the RGPP.....            | 4  |
| B. Implementation of the Objectives ..... | 4  |
| C. Program Description.....               | 5  |
| D. Characteristics of Tritium (H-3).....  | 5  |
| III. Program Description.....             | 6  |
| A. Sample Analysis .....                  | 6  |
| B. Data Interpretation .....              | 7  |
| IV. Results and Discussion .....          | 8  |
| A. Groundwater Results .....              | 8  |
| B. Surface Water Results.....             | 9  |
| C. Storm Water Results .....              | 10 |
| D. Precipitation Water Results .....      | 10 |
| E. Leaks, Spills, and Releases.....       | 11 |
| F. Actions Taken .....                    | 11 |

## Appendices

### Appendix A Location Designation

#### Tables

Table A-1 Radiological Groundwater Protection Program - Sampling Locations, Distance and Direction, Three Mile Island Nuclear Station, 2018

#### Figures

Figure A-1 Sampling Locations at the Three Mile Island Nuclear Station, 2018

### Appendix B Data Tables

#### Tables

Table B-I.1 Concentrations of Tritium, Strontium, Gross Alpha, and Gross Beta in Groundwater Samples Collected as Part of the Radiological Groundwater Protection Program, Three Mile Island Nuclear Station, 2018

Table B-I.2 Concentrations of Gamma Emitters in Groundwater Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018

Table B-I.3 Concentrations of Hard-To-Detects in Groundwater Samples Collected as Part of the Radiological Groundwater Protection Program, Three Mile Island Generating Station, 2018

Table B-II.1 Concentrations of Tritium in Surface Water Samples Collected as Part of the Radiological Groundwater Protection Program, Three Mile Island Nuclear Station, 2018

Table B-II.2 Concentrations of Gamma Emitters in Surface Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018

Table B-III.1 Concentrations of Tritium in Storm Water Samples Collected as Part of the Radiological Groundwater Protection Program, Three Mile Island Nuclear Station, 2018

Table B-III.2 Concentrations of Gamma Emitters in Storm Water Samples Collected in the Vicinity of Three Mile Island Nuclear Station, 2018

Table B-IV.1 Concentrations of Tritium in Precipitation Water Samples Collected as Part of the Radiological Groundwater Protection Program, Three Mile Island Nuclear Station, 2018

Appendix C Data Tables - Comparison

Tables

|               |   |
|---------------|---|
| Table C-I.1   | Concentrations of Tritium, Strontium, Gross Alpha and Gross Beta in Groundwater Split Samples Collected as Part of the Radiological Groundwater Protection Program, Three Mile Island Nuclear Station, 2018 |
| Table C-I.2   | Concentrations of Gamma Emitters in Groundwater Split Samples Collected as Part of the Radiological Groundwater Protection Program, Three Mile Island Nuclear Station, 2018                                 |
| Table C-I.3   | Concentrations of Hard-To-Detects in Groundwater Split Samples Collected as Part of the Radiological Groundwater Protection Program, Three Mile Island Generating Station, 2018                             |
| Table C-II.1  | Concentrations of Tritium in Surface Water Split Samples Collected as Part of the Radiological Groundwater Protection Program, Three Mile Island Nuclear Station, 2018                                      |
| Table C-II.2  | Concentrations of Gamma Emitters in Surface Water Split Samples Collected as Part of the Radiological Groundwater Protection Program, Three Mile Island Nuclear Station, 2018                               |
| Table C-III.1 | Concentrations of Tritium in Precipitation Water Split Samples Collected as Part of the Radiological Groundwater Protection Program, Three Mile Island Nuclear Station, 2018                                |



## I. Summary and Conclusions

In 2006, Exelon instituted a comprehensive program to evaluate the impact of station operations on groundwater and surface water in the vicinity of Three Mile Island Nuclear Station. This report covers groundwater, surface water, storm water, and precipitation samples collected from the environment, both on and off station property in 2018. During that time period 443 analyses were performed on 211 samples from 60 locations.

In assessing all the data gathered for this report, it was concluded that the operation of Three Mile Island Nuclear Station had no adverse radiological impact on the environment.

Gamma-emitting radionuclides associated with licensed plant operations were not detected at concentrations greater than their respective Lower Limits of Detection (LLDs) as specified in the Offsite Dose Calculation Manual (ODCM) in any of the groundwater, surface water, storm water, and precipitation samples. In the case of tritium, Exelon specified that its laboratories achieve a lower limit of detection 10 times lower than that required by federal regulation.

Strontium-89 (Sr-89) and Strontium-90 (Sr-90) were not detected at a concentration greater than their respective LLD of 10 and 1 picocurie per liter (pCi/L) in the groundwater samples tested.

Tritium was not detected in any ground water, surface water, storm water or precipitation water samples at concentrations greater than the United States Environmental Protection Agency (USEPA) drinking water standard (and the Nuclear Regulatory Commission Reporting Limit) of 20,000 pCi/L. Low levels of tritium were detected at concentrations greater than the LLD of 200 pCi/L in 32 of 52 groundwater monitoring locations. The groundwater tritium concentrations ranged from  $180 \pm 119$  pCi/L to  $4,540 \pm 507$  pCi/L. Tritium that was detected in groundwater at the Station is believed to be the result of previous tank leakage, historical releases, the recapture of gaseous tritium releases via rainwater, and/or background from external sources greater than 200 pCi/L. Tritium was not detected at any surface water location. Tritium was not detected in any storm water samples. Tritium was detected in 3 of 4 precipitation water locations. The concentrations ranged from  $204 \pm 124$  to  $469 \pm 135$  pCi/L.

Gross Alpha and Gross Beta analyses in the dissolved and suspended fractions were performed on 27 groundwater samples during the second quarter sampling in 2018. Gross Alpha (dissolved) was not detected at any of the 27 groundwater locations. Gross Alpha (suspended) was detected at 1 of the groundwater locations at a concentration of  $2.0 \pm 0.8$  pCi/L. Gross Beta (dissolved) was detected at 23 of the groundwater locations. The concentrations ranged from 1.4

to 10.2 pCi/L. Gross Beta (suspended) was detected at 2 of the 27 groundwater locations. The concentrations ranged from 2.0 to 3.9 pCi/L.

Hard-To-Detect analyses, which include Fe-55, Ni-63, Am-241, Cm-242, Cm-243/244, Pu-238, Pu-239/240, U-234, U-235 and U-238, were not analyzed in 2018.

## II. Introduction

The Three Mile Island Nuclear Station (TMINS) established a revised and more comprehensive groundwater monitoring program in 2006 as part of an Exelon Nuclear fleetwide assessment.

Conestoga Rovers & Associates (CRA) performed the initial assessment. CRA prepared a Hydrogeologic Investigation Report (HIR) for Exelon to determine whether groundwater at and near TMINS has been adversely impacted by any releases of radionuclides. The CRA report documents the results of the May 2006 Hydrogeologic Investigation Work Plan. CRA assessed groundwater quality at the Station and identified locations designated as Areas for Further Evaluation. The results and conclusions of this Phase 1 study were made available to state and federal regulators, as well as the public on an Exelon web site for station specific reports.

As a result of the Phase 1 study, the Radiological Groundwater Protection Program (RGPP) was revised to a long term monitoring program. This report covers those analyses performed by Teledyne Brown Engineering (TBE) and Exelon Industrial Services (EIS)/GEL Laboratories on well water, surface water, storm water, and precipitation water samples collected in 2018. TMINS groundwater movement is into the Susquehanna River which surrounds the station on all sides.

In September 2015, GHD completed an additional five-year update hydrogeologic investigation report for the Station (*NEI 07-07, Hydrogeologic Investigation Report*). The referenced report summarized station activities since the 2006 hydrogeologic investigation report, including changes at the Station as well as RGPP sampling activities and groundwater flow. Relevant conclusions from the report are:

- None of the Areas of Further Evaluation (AFEs) identified in 2006 indicate current impacts to groundwater and are no longer considered AFEs.
- One new AFE, AFE-TMI-6-BWST, was identified based on laboratory analytical data.
- In July 2012, elevated tritium concentrations were noted for a sample collected from an electric vault west of MS-22. The source of this elevated tritium concentration was believed to be the BWST.
- Tritium is not migrating off of the Station property at concentrations greater than the USEPA Drinking Water Standard of 20,000 pCi/L.
- Gamma-emitting radionuclides associated with licensed plant operations were not detected at concentrations greater than their respective LLDs.
- Strontium 89 or 90 were not detected at concentrations greater than their respective LLDs.

This report covers those analyses performed by Teledyne Brown Engineering (TBE) and Exelon Industrial Services (EIS)/Gel Laboratories on samples collected in 2018.

A. Objectives of the RGPP

The long-term objectives of the Radiological Groundwater Protection Program (RGPP) are as follows:

1. Identify suitable locations to monitor and evaluate potential impacts from station operations before significant radiological impact to the environment and potential drinking water sources.
2. Understand the local hydrogeologic regime in the vicinity of the station and maintain up-to-date knowledge of flow patterns on the surface and shallow subsurface.
3. Perform routine water sampling and radiological analysis of water from selected locations.
4. Notify stakeholders in a timely manner for new leaks, spills, or other detections with potential radiological significance.
5. Regularly assess analytical results to identify adverse trends.
6. Take necessary corrective actions to protect groundwater resources.

B. Implementation of the Objectives

The objectives identified have been implemented at Three Mile Island Nuclear Station as discussed below:

1. Three Mile Island Nuclear Station continues to sample and monitor the groundwater at the station in accordance with station procedures. Sample frequencies and locations are adjusted based on monitoring results and investigations.
2. The Three Mile Island Nuclear Station reports describe the local hydrogeologic regime. Periodically, the flow patterns on the surface and shallow subsurface are updated based on ongoing measurements.
3. Three Mile Island Nuclear Station will continue to perform routine sampling and radiological analysis of water from selected locations.
4. Three Mile Island Nuclear Station has implemented procedures to identify and report leaks, spills, or other detections with potential

radiological significance in a timely manner.

5. Three Mile Island Nuclear Station staff and consulting hydrogeologist assess analytical results on an ongoing basis to identify adverse trends.

C. Program Description

1. Sample Collection

Sample locations can be found in Table A-1 and Figures A-1 and A-2, Appendix A.

Groundwater, Surface Water, Storm Water, and Precipitation

Samples of water are collected, managed, transported and analyzed in accordance with approved procedures. Groundwater, surface water, storm water and precipitation are collected. Sample locations, sample collection frequencies and analytical frequencies are controlled in accordance with approved station procedures. Contractor and/or station personnel are trained in the collection, preservation management and shipment of samples, as well as in documentation of sampling events. For split samples, collectors will periodically collect samples that are sent to Exelon Industrial Services/GEL Laboratories to confirm that TBE is producing comparable data. Analytical laboratories are subject to internal quality assurance programs, industry cross-check programs, as well as nuclear industry audits. Station personnel review and evaluate all analytical data deliverables as data are received.

Analytical data results are reviewed by both station personnel and an independent hydrogeologist for adverse trends or changes to hydrogeologic conditions.

D. Characteristics of Tritium (H-3)

Tritium (chemical symbol H-3) is a radioactive isotope of hydrogen. The most common form of tritium is tritium oxide, which is also called "tritiated water." Tritiated water behaves chemically and physically like non-tritiated water in the subsurface, and therefore tritiated water will travel at the same velocity as the average groundwater velocity.

Tritium is created in the environment from naturally-occurring processes both cosmic and subterranean, as well as from anthropogenic (i.e., man-made) sources. Tritium is produced naturally in the upper atmosphere when cosmic rays strike air molecules. This "cosmogenic" tritium

combines with oxygen to form tritiated water, which will then enter the hydrologic cycle. Below ground, "lithogenic" tritium is produced by the bombardment of natural lithium present in crystalline rocks by neutrons produced by the radioactive decay of naturally abundant uranium and thorium. Lithogenic production of tritium is usually negligible compared to other sources due to the limited abundance of lithium in rock. The lithogenic tritium is introduced directly to groundwater.

A major anthropogenic source of tritium and strontium-90 comes from the former atmospheric testing of thermonuclear weapons. Levels of tritium in precipitation increased significantly during the 1950s and early 1960s and later with additional testing, resulting in the release of significant amounts of tritium to the atmosphere. The Canadian heavy water nuclear power reactors, other commercial power reactors, nuclear research and weapons production continue to influence tritium concentrations in the environment.

The chemical properties of tritium are essentially those of ordinary hydrogen. Tritium can be taken into the body by drinking water, breathing air, eating food, or absorption through skin. Once tritium enters the body, it disperses quickly and is uniformly distributed throughout the body. Tritium is excreted primarily through urine with a clearance rate characterized by an effective biological half-life of about 14 days. Within one month or so after ingestion, all tritium is essentially cleared. Organically bound tritium (tritium that is incorporated in organic compounds) can remain in the body for a longer period.

Tritium has a radiological half-life of approximately 12.3 years. It decays spontaneously to Helium-3 (He-3). This radioactive decay releases a beta particle (low-energy electron). The radioactive decay of tritium is the source of the health risk from exposure to tritium. Tritium is one of the least dangerous radionuclides, because it emits very weak radiation and leaves the body relatively quickly. Since tritium is almost always found as water, it goes directly into soft tissues and organs. The associated dose to these tissues is generally uniform and is dependent on the water content of the specific tissue.

### III. Program Description

#### A. Sample Analysis

This section describes the general analytical methodologies used by TBE and Exelon Industrial Services (EIS)/GEL Laboratories to analyze the environmental samples for radioactivity for the Three Mile Island Nuclear Station RGPP in 2018.

In order to achieve the stated objectives, the current program includes the

following analyses, as applicable:

1. Concentrations of gamma-emitters in groundwater, surface water, and storm water
2. Concentrations of strontium in groundwater
3. Concentrations of tritium in groundwater, surface water, precipitation water and storm water
4. Concentrations of Am-241 in groundwater
5. Concentrations of Cm-242 and Cm-243/244 in groundwater
6. Concentrations of Pu-238 and PU-239/240 in groundwater
7. Concentrations of U-234, U-235 and U-238 in groundwater
8. Concentrations of Fe-55 in groundwater
9. Concentrations of Ni-63 in groundwater
10. Concentrations of Gross Alpha and Gross Beta (Dissolved and Suspended) in groundwater

B. Data Interpretation

1. Lower Limit of Detection and Minimum Detectable Concentration

The lower limit of detection (LLD) is specified by federal regulation as a minimum sensitivity value that must be achieved routinely by the analytical parameter.

2. Laboratory Measurements Uncertainty

The estimated uncertainty in measurement of tritium in environmental samples is frequently on the order of 50% of the measurement value.

Statistically, the exact value of a measurement is expressed as a range with a stated level of confidence. The convention is to report results with a 95% level of confidence. The uncertainty comes from calibration standards, sample volume or weight measurements, sampling uncertainty and other factors. Exelon reports the uncertainty of a measurement created by statistical process (counting error).

Analytical uncertainties are reported at the 95% confidence level in this report for reporting consistency with the AREOR.

Gamma spectroscopy results for each type of sample were grouped as follows:

For groundwater, surface water, and storm water 13 nuclides, Be-7, K-40, Mn-54, Co-58, Fe-59, Co-60, Zn-65, Nb-95, Zr-95, Cs-134, Cs-137, Ba-140 and La-140 were reported.

The radio-analytical laboratory counts tritium results to an LLD of 200 pCi/L. Typically, the lowest positive measurement will be reported within a range of 40 – 240 pCi/L or  $140 \pm 100$  pCi/L. Clearly, these sample results cannot be distinguished as different from background at this concentration.

#### IV. Results and Discussion

##### A. Groundwater Results

Samples were collected from on and off-site wells in accordance with the station radiological groundwater protection program. Analytical results and anomalies are discussed below.

##### Tritium

Samples from 52 locations were analyzed for tritium activity. Tritium values ranged from the detection limit to 4,540 pCi/L. (Table B-I.1, Appendix B)

##### Tritium Split Samples

Tritium values ranged from 177 to 1,550 pCi/L. (Table C-I.1, Appendix C)

##### Strontium

Sr-89 and Sr-90 were not detected above their required detection limits of 10 and 1.0 pCi/L, respectively. (Table B-I.1, Appendix B)

##### Strontium Split Samples

Sr-89 and Sr-90 were not detected above the required detection limit. (Table C-I.1, Appendix C)



#### Gross Alpha and Gross Beta (dissolved and suspended)

Gross Alpha and Gross Beta analyses in the dissolved and suspended fractions were performed on 27 groundwater samples during the second quarter sampling in 2018.

Gross Alpha (dissolved) was not detected at any of the groundwater locations. Gross Alpha (suspended) was detected at 1 of the 27 groundwater locations with a concentration of 2.0 pCi/L.

Gross Beta (dissolved) was detected at 23 of 27 groundwater locations. The concentrations ranged from 1.4 to 10.2 pCi/L. Gross Beta (suspended) was detected in 2 of the 27 groundwater locations. The concentrations ranged from 2.0 to 3.9 pCi/L. (Table B-I.1, Appendix B)

#### Gross Alpha and Gross Beta (dissolved and suspended) Split Samples

One split sample was analyzed for Gross Alpha and Gross Beta in 2018. Neither Gross Alpha nor Gross Beta was detected. (Table C-I.1, Appendix C)

#### Gamma Emitters

No gamma-emitting nuclides were detected. (Table B-I.2, Appendix B)

#### Gamma Emitters Split Samples

Two locations were analyzed for gamma-emitting nuclides in 2018. No gamma-emitting nuclides were detected in any split samples. (Table C-I.2, Appendix C)

#### Hard-To-Detect

Hard-To-Detect analyses, which include Fe-55, Ni-63, Am-241, Cm-242, Cm-243/244, Pu-238, Pu-239/240, U-234, U-235 and U-238, were not analyzed in 2018. (Table B-I.3, Appendix B)

#### Hard-To-Detect Split Samples

Hard to detects were not analyzed on any split samples in 2018. (Table C-I.3, Appendix C)

### B. Surface Water Results

Samples were collected from surface water locations in accordance with the station radiological groundwater protection program. Analytical results

and anomalies are discussed below.

### Tritium

Three locations analyzed for tritium in 2018. Tritium was not detected above the required detection limit of 200 pCi/L in any of the 14 samples analyzed. (Table B-II.1, Appendix B)

### Tritium Split Samples

Two locations were analyzed for tritium in 2018. Tritium was not detected above the required detection limit of 200 pCi/L in the samples analyzed. (Table C-II.1, Appendix C)

### Gamma Emitters

Three locations analyzed for gamma-emitting nuclides in 2018. No detections of gamma-emitting nuclides were detected. (Table B-II.2, Appendix B)

### Gamma Emitters Split Samples

One surface water sample was analyzed for gamma-emitting nuclides in 2018. No gamma-emitting nuclides were detected. (Table C-II.2, Appendix C).

## C. Storm Water Results

Samples were collected from storm water locations in accordance with the station radiological groundwater protection program. Analytical results and anomalies are discussed below.

### Tritium

One location analyzed for tritium. Tritium was detected in 1 of 4 samples at a concentration of  $219 \pm 117$  pCi/L. (Table B-III.1, Appendix B)

### Gamma Emitters

Samples from one location were analyzed for gamma-emitting nuclides. No gamma emitting nuclides were detected. (Table B-III.2, Appendix B)

## D. Precipitation Water Results

Samples were collected a 4 locations. The following analyses were performed:

### Tritium

Samples from 4 locations were analyzed for tritium activity. Tritium activity was detected at 3 of 4 locations. The concentrations ranged from 204 to 469 pCi/L. (Table B–IV.1, Appendix B)

### Tritium Split Samples

Samples from one location were analyzed for tritium activity. Tritium activity was detected in 3 of 4 samples. The concentrations ranged from 216 to 398 pCi/L (Table C–III.1, Appendix C).

### Gamma Emitters

Precipitation water was not analyzed for Gamma Emitters in 2018.

### Gamma Emitters Split Samples

No gamma-emitting nuclides were analyzed in 2018.

## E. Leaks, Spills, and Releases

A potential leak was identified at TMI in 2012 due to elevated MS-22 tritium concentration readings. TMI continues to monitor MS-22 and surrounding wells, in addition to tritium plumes from previous years, and reports the activity and dose to the public in the ARERR. The elevated MS-22 well tritium concentrations were voluntarily reported under the reporting requirements for the NEI Groundwater Protection Initiative (GPI) as implemented in Exelon's Reportability procedure LS-AA-1120, RAD 1.34 ( IR 1385497/1515261).

In May and June 2015, it was determined that multiple Borated Water Storage Tank (BWST) connections (10 of 13 bolted flange connections) had evidence of leakage in the form of boron deposits in addition to the main 24-inch flange (IR 1670674/2427517/2508405/2509685).

## F. Actions Taken

### 1. Compensatory/Corrective Actions

Fully encapsulating enclosures were installed around all BWST connections including the 24-inch main outlet flange. Each enclosure was fitted with a Tygon tubing discharge point, connected to a water collection bottle to prevent tritiated water from reaching the ground surface. The outlet flange and leaking connections were repaired during the TMI refueling outage in November 2015.

TMI has an extensive groundwater monitoring program with over 50 monitoring wells. No monitoring wells outside the BWST investigation area have seen elevated tritium concentrations. TMI continues to monitor the BWST area wells closely. The leakage has been mitigated by repairing the leaking flanges, and groundwater tritium concentrations have decreased during 2018.

## **APPENDIX A**

### **LOCATION DESIGNATION & DISTANCE**

Intentionally left blank

**TABLE A-1: Radiological Groundwater Protection Program - Sampling Locations, Three Mile Island Nuclear Station, 2018**


| <b>Site</b> | <b>Site Type</b>         |
|-------------|--------------------------|
| #3          | Monitoring Well          |
| 48N         | Monitoring Well          |
| 48S         | Production Potable Well  |
| E1-2        | Monitoring Well, Offsite |
| EDCB        | Storm Water              |
| MS-1        | Monitoring Well          |
| MS-19       | Monitoring Well          |
| MS-2        | Monitoring Well          |
| MS-20       | Monitoring Well          |
| MS-21       | Monitoring Well          |
| MS-22       | Monitoring Well          |
| MS-3        | Monitoring Well          |
| MS-4        | Monitoring Well          |
| MS-5        | Monitoring Well          |
| MS-6        | Monitoring Well          |
| MS-7        | Monitoring Well          |
| MS-8        | Monitoring Well          |
| MW-1        | Monitoring Well          |
| MW-2        | Monitoring Well          |
| MW-3        | Monitoring Well          |
| MW-4        | Monitoring Well          |
| N2-1        | Monitoring Well, Offsite |
| NW-A        | Production Well          |
| NW-B        | Production Well          |
| NW-C        | Production Well          |
| NW-CW       | Clearwell                |
| OS-13B      | Monitoring Well          |
| OS-14       | Monitoring Well          |
| OS-16       | Monitoring Well          |
| OS-17       | Monitoring Well          |
| OS-18       | Monitoring Well          |
| OSF         | Production Potable Well  |
| RW-1        | Monitoring Well          |
| RW-2        | Monitoring Well          |
| SW-E-1      | Surface Water            |
| SW-E-2      | Surface Water            |
| SW-E-3      | Surface Water            |
| MW-TMI-9S*  | Monitoring Well          |
| MW-TMI-10D  | Monitoring Well          |
| MW-TMI-10I  | Monitoring Well          |
| MW-TMI-10S  | Monitoring Well          |
| MW-TMI-11S* | Monitoring Well          |
| MW-TMI-12S  | Monitoring Well          |
| MW-TMI-13I  | Monitoring Well          |
| MW-TMI-13S  | Monitoring Well          |
| MW-TMI-14D  | Monitoring Well          |
| MW-TMI-14I  | Monitoring Well          |
| MW-TMI-14S  | Monitoring Well          |
| MW-TMI-16D  | Monitoring Well          |
| MW-TMI-16I  | Monitoring Well          |
| MW-TMI-17D  | Monitoring Well          |
| MW-TMI-17I  | Monitoring Well          |
| MW-TMI-18D  | Monitoring Well          |
| MW-TMI-19D  | Monitoring Well          |
| MW-TMI-19I  | Monitoring Well          |
| MW-TMI-1D   | Monitoring Well          |
| MW-TMI-20D  | Monitoring Well          |
| MW-TMI-20I  | Monitoring Well          |
| MW-TMI-21D  | Monitoring Well          |
| MW-TMI-21I  | Monitoring Well          |
| MW-TMI-21S  | Monitoring Well          |

**TABLE A-1: Radiological Groundwater Protection Program - Sampling Locations, Three Mile Island Nuclear Station, 2018**

| <b>Site</b>      | <b>Site Type</b>        |
|------------------|-------------------------|
| MW-TMI-22D       | Monitoring Well         |
| MW-TMI-22I       | Monitoring Well         |
| MW-TMI-22S       | Monitoring Well         |
| MW-TMI-2D        | Monitoring Well         |
| MW-TMI-3I        | Monitoring Well         |
| MW-TMI-4I        | Monitoring Well         |
| MW-TMI-4S        | Monitoring Well         |
| MW-TMI-5D        | Monitoring Well         |
| MW-TMI-6D        | Monitoring Well         |
| MW-TMI-6I        | Monitoring Well         |
| MW-TMI-7S        | Monitoring Well         |
| MW-TMI-8S        | Monitoring Well         |
| MW-TMI-9I        | Monitoring Well         |
| TRAINING CENTER  | Offsite Monitoring Well |
| TM-PR-ESE        | Precipitation Water     |
| TM-PR-MS-1       | Precipitation Water     |
| TM-PR-MS-2       | Precipitation Water     |
| TM-PR-MS-20      | Precipitation Water     |
| TM-PR-MS-22      | Precipitation Water     |
| TM-PR-MS-4       | Precipitation Water     |
| TM-PR-NW-B       | Precipitation Water     |
| TM-PR-MW-TMI-22S | Precipitation Water     |

\* NO WATER PRESENT TO SAMPLE





**Figure A – 1**  
**Sampling Locations at the Three Mile Island Nuclear Station, 2018**

Intentionally left blank

## **APPENDIX B**

### **DATA TABLES**

Intentionally left blank

**TABLE B-I.1 CONCENTRATIONS OF TRITIUM, STRONTIUM, GROSS ALPHA AND GROSS BETA  
IN GROUNDWATER SAMPLES COLLECTED AS PART OF THE RADIOLOGICAL  
GROUNDWATER PROTECTION PROGRAM, THREE MILE ISLAND NUCLEAR STATION, 2018  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA**

| SITE      | COLLECTION DATE | H-3                     | Sr-89 | Sr-90 | Gr-A (Dis) | Gr-A (Sus) | Gr-B (Dis) | Gr-B (Sus) |
|-----------|-----------------|-------------------------|-------|-------|------------|------------|------------|------------|
| 48S       | 02/27/18        | < 190                   |       |       |            |            |            |            |
| 48S       | 05/22/18        | < 190                   | < 3.6 | < 0.6 | < 3.0      | < 0.8      | 4.7 ± 1.5  | < 1.4      |
| 48S       | 08/28/18        | < 184                   |       |       |            |            |            |            |
| 48S       | 11/07/18        | < 192                   |       |       |            |            |            |            |
| MS-1      | 02/26/18        | 236 ± 127               |       |       |            |            |            |            |
| MS-1      | 05/24/18        | 253 ± 120               | < 5.3 | < 0.6 | < 7.8      | < 0.5      | < 4.6      | < 1.6      |
| MS-1      | 08/28/18        | < 184                   |       |       |            |            |            |            |
| MS-1      | 11/06/18        | < 194                   |       |       |            |            |            |            |
| MS-1      | 11/06/18        | < 192                   |       |       |            |            |            |            |
| MS-2      | 02/28/18        | 231 ± 129               |       |       |            |            |            |            |
| MS-2      | 02/28/18        | 331 ± 133               |       |       |            |            |            |            |
| MS-2      | 05/22/18        | 316 ± 124               | < 4.8 | < 0.8 | < 1.2      | < 0.4      | 3.7 ± 1.0  | < 1.4      |
| MS-2      | 08/29/18        | < 189                   |       |       |            |            |            |            |
| MS-2      | 08/29/18        | 199 ± 125               |       |       |            |            |            |            |
| MS-2      | 11/07/18        | 237 ± 128               |       |       |            |            |            |            |
| MS-2      | 11/07/18        | 283 ± 131               |       |       |            |            |            |            |
| MS-3      | 02/28/18        | 299 ± 131               |       |       |            |            |            |            |
| MS-3      | 05/22/18        | 225 ± 129               | < 3.8 | < 0.5 | < 1.5      | < 0.8      | 5.9 ± 1.1  | < 1.4      |
| MS-3      | 08/29/18        | 325 ± 129               |       |       |            |            |            |            |
| MS-3      | 11/07/18        | 211 ± 132               |       |       |            |            |            |            |
| MS-4      | 05/24/18        | 180 ± 119               |       |       |            |            |            |            |
| MS-5      | 02/28/18        | < 190                   |       |       |            |            |            |            |
| MS-5      | 05/22/18        | < 195                   | < 3.8 | < 0.6 | < 1.4      | < 0.8      | 4.7 ± 1.0  | < 1.4      |
| MS-5      | 08/29/18        | < 186                   |       |       |            |            |            |            |
| MS-5      | 11/07/18        | < 196                   |       |       |            |            |            |            |
| MS-7      | 02/28/18        | < 192                   |       |       |            |            |            |            |
| MS-7      | 05/23/18        | < 193                   | < 4.0 | < 0.8 | < 1.3      | < 0.8      | 3.6 ± 0.9  | < 1.4      |
| MS-7      | 08/28/18        | 198 ± 124               |       |       |            |            |            |            |
| MS-7      | 08/28/18        | < 187                   |       |       |            |            |            |            |
| MS-7      | 11/06/18        | < 196                   |       |       |            |            |            |            |
| MS-7      | 11/06/18        | 259 ± 135               |       |       |            |            |            |            |
| MS-8      | 02/28/18        | < 191                   |       |       |            |            |            |            |
| MS-8      | 05/22/18        | < 196                   | < 3.6 | < 0.8 | < 1.2      | < 0.8      | 4.1 ± 0.9  | < 1.4      |
| MS-8      | 08/29/18        | 311 ± 129               |       |       |            |            |            |            |
| MS-8      | 11/07/18        | < 198                   |       |       |            |            |            |            |
| MS-20     | 02/27/18        | 458 ± 139               |       |       |            |            |            |            |
| MS-20     | 05/22/18        | 529 ± 135               | < 7.2 | < 0.6 | < 1.2      | < 0.4      | 5.0 ± 1.0  | < 1.5      |
| MS-20     | 08/28/18        | 559 ± 143               |       |       |            |            |            |            |
| MS-20     | 11/07/18        | 680 ± 149               |       |       |            |            |            |            |
| MS-21     | 02/27/18        | < 192                   |       |       |            |            |            |            |
| MS-21     | 05/22/18        | < 198                   | < 4.1 | < 0.6 | < 0.9      | < 0.4      | 2.2 ± 0.7  | < 1.4      |
| MS-21     | 08/28/18        | 194 ± 123               |       |       |            |            |            |            |
| MS-21     | 11/07/18        | < 196                   |       |       |            |            |            |            |
| MS-22     | 02/27/18        | 1590 ± 225              |       |       |            |            |            |            |
| MS-22     | 05/22/18        | 979 ± 178               |       |       |            |            |            |            |
| MS-22     | 05/22/18        |                         | < 5.5 | < 0.8 | < 1.2      | < 0.5      | 5.2 ± 0.9  | < 1.4      |
| MS-22     | 08/28/18        | 966 ± 162               |       |       |            |            |            |            |
| MS-22     | 11/07/18        | 1160 ± 191              |       |       |            |            |            |            |
| MS-22     | 11/07/18        | 1220 ± 198              |       |       |            |            |            |            |
| MW-1      | 05/23/18        | < 188                   |       |       |            |            |            |            |
| MW-1      | 05/23/18        | < 185                   |       |       |            |            |            |            |
| MW-2      | 05/23/18        | < 188                   |       |       |            |            |            |            |
| MW-TMI-1D | 05/23/18        | 207 ± 119               |       |       |            |            |            |            |
| MW-TMI-2D | 05/23/18        | < 176                   |       |       |            |            |            |            |
| MW-TMI-3I | 02/28/18        | 212 ± 128               |       |       |            |            |            |            |
| MW-TMI-3I | 05/24/18        | < 189                   | < 4.2 | < 0.6 | < 3.0      | < 0.8      | 7.1 ± 1.9  | < 1.4      |
| MW-TMI-3I | 05/24/18        | Recount<br>371 ± 125    |       |       |            |            |            |            |
| MW-TMI-3I | 05/24/18        | Reanalysis<br>335 ± 127 |       |       |            |            |            |            |

**TABLE B-I.1 CONCENTRATIONS OF TRITIUM, STRONTIUM, GROSS ALPHA AND GROSS BETA  
IN GROUNDWATER SAMPLES COLLECTED AS PART OF THE RADIOLOGICAL  
GROUNDWATER PROTECTION PROGRAM, THREE MILE ISLAND NUCLEAR STATION, 2018  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA**

| SITE       | COLLECTION DATE | H-3            | Sr-89 | Sr-90 | Gr-A (Dis) | Gr-A (Sus) | Gr-B (Dis) | Gr-B (Sus) |
|------------|-----------------|----------------|-------|-------|------------|------------|------------|------------|
| MW-TMI-3I  | 05/24/18        | 193 ± 124      | < 4.0 | < 0.9 | < 2.2      | < 0.7      | 4.9 ± 1.9  | < 1.5      |
| MW-TMI-3I  | 08/30/18        | 314 ± 129      |       |       |            |            |            |            |
| MW-TMI-3I  | 08/30/18        | 395 ± 134      |       |       |            |            |            |            |
| MW-TMI-3I  | 11/06/18        | 273 ± 131      |       |       |            |            |            |            |
| MW-TMI-4I  | 05/23/18        | < 181          |       |       |            |            |            |            |
| MW-TMI-4S  | 05/23/18        | 278 ± 124      |       |       |            |            |            |            |
| MW-TMI-6D  | 02/28/18        | 200 ± 128      |       |       |            |            |            |            |
| MW-TMI-6D  | 05/23/18        | < 198          | < 4.9 | < 0.6 | < 0.7      | < 0.5      | 1.8 ± 0.6  | < 1.7      |
| MW-TMI-6D  | 08/28/18        | 341 ± 132      |       |       |            |            |            |            |
| MW-TMI-6D  | 11/06/18        | < 194          |       |       |            |            |            |            |
| MW-TMI-6I  | 02/28/18        | 237 ± 128      |       |       |            |            |            |            |
| MW-TMI-6I  | 05/23/18        | < 196          | < 4.9 | < 0.7 | < 1.2      | 2.0 ± 0.8  | 2.5 ± 0.9  | 2.0 ± 1.0  |
| MW-TMI-6I  | 08/28/18        | 188 ± 122      |       |       |            |            |            |            |
| MW-TMI-6I  | 11/06/18        | < 191          |       |       |            |            |            |            |
| MW-TMI-7S  | 05/24/18        | < 179          |       |       |            |            |            |            |
| MW-TMI-8S  | 05/24/18        | < 191          |       |       |            |            |            |            |
| MW-TMI-9I  | 05/24/18        | < 180          |       |       |            |            |            |            |
| MW-TMI-9S  | 05/24/18        | < 178          |       |       |            |            |            |            |
| MW-TMI-10D | 05/23/18        | < 178          |       |       |            |            |            |            |
| MW-TMI-10I | 02/27/18        | 583 ± 144      |       |       |            |            |            |            |
| MW-TMI-10I | 02/27/18        | 556 ± 141      |       |       |            |            |            |            |
| MW-TMI-10I | 05/23/18        | 429 ± 138      |       |       |            |            |            |            |
| MW-TMI-10I | 05/23/18        | 451 ± 135      |       |       |            |            |            |            |
| MW-TMI-10I | 08/30/18        | 623 ± 144      |       |       |            |            |            |            |
| MW-TMI-10I | 11/06/18        | 395 ± 137      |       |       |            |            |            |            |
| MW-TMI-10I | 11/06/18        | 483 ± 140      |       |       |            |            |            |            |
| MW-TMI-10S | 02/27/18        | 228 ± 128      |       |       |            |            |            |            |
| MW-TMI-10S | 05/23/18        | 383 ± 138      | < 5.6 | < 0.8 | < 1.3      | < 0.7      | 5.3 ± 1.1  | < 1.9      |
| MW-TMI-10S | 08/30/18        | 666 ± 147      |       |       |            |            |            |            |
| MW-TMI-10S | 11/06/18        | 477 ± 143      |       |       |            |            |            |            |
| MW-TMI-10S | 11/06/18        | 617 ± 151      |       |       |            |            |            |            |
| MW-TMI-12S | 02/27/18        | < 193          |       |       |            |            |            |            |
| MW-TMI-12S | 05/24/18        | < 193          | < 2.3 | < 0.6 | < 1.0      | < 0.8      | 4.6 ± 0.9  | 3.9 ± 1.2  |
| MW-TMI-12S | 05/24/18        | <i>Recount</i> |       |       |            |            |            | 3.9 ± 1.7  |
| MW-TMI-12S | 08/29/18        | < 190          |       |       |            |            |            |            |
| MW-TMI-12S | 11/07/18        | < 192          |       |       |            |            |            |            |
| MW-TMI-13I | 02/26/18        | < 193          |       |       |            |            |            |            |
| MW-TMI-13I | 05/23/18        | < 194          |       |       |            |            |            |            |
| MW-TMI-13I | 05/23/18        | < 186          |       |       |            |            |            |            |
| MW-TMI-13I | 08/28/18        | < 186          |       |       |            |            |            |            |
| MW-TMI-13I | 11/06/18        | < 190          |       |       |            |            |            |            |
| MW-TMI-14D | 02/28/18        | 310 ± 132      |       |       |            |            |            |            |
| MW-TMI-14D | 05/23/18        | 213 ± 126      |       |       |            |            |            |            |
| MW-TMI-14D | 08/28/18        | 325 ± 131      |       |       |            |            |            |            |
| MW-TMI-14D | 11/06/18        | 281 ± 136      |       |       |            |            |            |            |
| MW-TMI-14I | 02/28/18        | < 193          |       |       |            |            |            |            |
| MW-TMI-14I | 02/28/18        | < 193          |       |       |            |            |            |            |
| MW-TMI-14I | 05/23/18        | < 178          |       |       |            |            |            |            |
| MW-TMI-14I | 08/28/18        | < 187          |       |       |            |            |            |            |
| MW-TMI-14I | 11/06/18        | < 192          |       |       |            |            |            |            |
| MW-TMI-14I | 11/06/18        | < 198          |       |       |            |            |            |            |
| MW-TMI-16D | 05/24/18        | 702 ± 145      | < 5.2 | < 0.6 | < 0.8      | < 0.4      | 6.4 ± 0.9  | < 1.6      |
| MW-TMI-17I | 05/24/18        | < 177          |       |       |            |            |            |            |
| MW-TMI-18D | 05/23/18        | < 182          |       |       |            |            |            |            |
| MW-TMI-19I | 05/24/18        | < 178          |       |       |            |            |            |            |
| MW-TMI-20I | 05/24/18        | 238 ± 121      |       |       |            |            |            |            |
| MW-TMI-21D | 02/27/18        | 3730 ± 432     |       |       |            |            |            |            |
| MW-TMI-21D | 05/22/18        | 3780 ± 444     |       |       |            |            |            |            |

**TABLE B-I.1 CONCENTRATIONS OF TRITIUM, STRONTIUM, GROSS ALPHA AND GROSS BETA  
IN GROUNDWATER SAMPLES COLLECTED AS PART OF THE RADIOLOGICAL  
GROUNDWATER PROTECTION PROGRAM, THREE MILE ISLAND NUCLEAR STATION, 2018  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA**

| SITE       | COLLECTION DATE | H-3        | Sr-89 | Sr-90 | Gr-A (Dis) | Gr-A (Sus) | Gr-B (Dis) | Gr-B (Sus) |
|------------|-----------------|------------|-------|-------|------------|------------|------------|------------|
| MW-TMI-21D | 08/28/18        | 4070 ± 460 |       |       |            |            |            |            |
| MW-TMI-21D | 11/07/18        | 3920 ± 454 |       |       |            |            |            |            |
| MW-TMI-21D | 11/07/18        | 3730 ± 437 |       |       |            |            |            |            |
| MW-TMI-21I | 02/27/18        | 1300 ± 197 |       |       |            |            |            |            |
| MW-TMI-21I | 02/27/18        | 1050 ± 173 |       |       |            |            |            |            |
| MW-TMI-21I | 05/22/18        | 1150 ± 190 |       |       |            |            |            |            |
| MW-TMI-21I | 08/28/18        | 1170 ± 181 |       |       |            |            |            |            |
| MW-TMI-21I | 11/07/18        | 1030 ± 179 |       |       |            |            |            |            |
| MW-TMI-21I | 11/07/18        | 911 ± 170  |       |       |            |            |            |            |
| MW-TMI-21S | 02/27/18        | 673 ± 144  |       |       |            |            |            |            |
| MW-TMI-21S | 05/22/18        | 984 ± 178  |       |       |            |            |            |            |
| MW-TMI-21S | 05/22/18        |            | < 5.9 | < 0.7 | < 1.6      | < 0.5      | 7.1 ± 1.2  | < 1.4      |
| MW-TMI-21S | 08/28/18        | 463 ± 136  |       |       |            |            |            |            |
| MW-TMI-21S | 11/07/18        | 436 ± 145  |       |       |            |            |            |            |
| MW-TMI-21S | 11/07/18        | 435 ± 140  |       |       |            |            |            |            |
| MW-TMI-22D | 02/27/18        | 3350 ± 392 |       |       |            |            |            |            |
| MW-TMI-22D | 05/22/18        | 2980 ± 364 |       |       |            |            |            |            |
| MW-TMI-22D | 08/28/18        | 3680 ± 421 |       |       |            |            |            |            |
| MW-TMI-22D | 11/07/18        | 3110 ± 374 |       |       |            |            |            |            |
| MW-TMI-22D | 11/07/18        | 3240 ± 389 |       |       |            |            |            |            |
| MW-TMI-22I | 02/27/18        | 4540 ± 507 |       |       |            |            |            |            |
| MW-TMI-22I | 05/22/18        | 2650 ± 328 |       |       |            |            |            |            |
| MW-TMI-22I | 08/28/18        | 1830 ± 243 |       |       |            |            |            |            |
| MW-TMI-22I | 11/07/18        | 1210 ± 195 |       |       |            |            |            |            |
| MW-TMI-22I | 11/07/18        | 1430 ± 216 |       |       |            |            |            |            |
| MW-TMI-22S | 02/27/18        | 2050 ± 263 |       |       |            |            |            |            |
| MW-TMI-22S | 05/22/18        | 972 ± 171  |       |       |            |            |            |            |
| MW-TMI-22S | 05/22/18        |            | < 5.4 | < 0.8 | < 1.8      | < 0.5      | 6.6 ± 1.3  | < 1.4      |
| MW-TMI-22S | 08/28/18        | 1150 ± 181 |       |       |            |            |            |            |
| MW-TMI-22S | 11/07/18        | 511 ± 142  |       |       |            |            |            |            |
| MW-TMI-22S | 11/07/18        | 431 ± 140  |       |       |            |            |            |            |
| N2-1       | 05/31/18        | < 191      |       |       |            |            |            |            |
| NW-A       | 02/27/18        | 397 ± 137  |       |       |            |            |            |            |
| NW-A       | 05/22/18        | 260 ± 128  | < 3.8 | < 0.7 | < 1.2      | < 0.8      | 3.7 ± 1.2  | < 1.4      |
| NW-A       | 08/28/18        | 403 ± 135  |       |       |            |            |            |            |
| NW-A       | 11/07/18        | 267 ± 135  |       |       |            |            |            |            |
| NW-B       | 02/27/18        | 221 ± 127  |       |       |            |            |            |            |
| NW-B       | 05/22/18        | < 187      | < 4.5 | < 0.8 | < 1.0      | < 0.8      | 3.1 ± 1.0  | < 1.4      |
| NW-B       | 08/28/18        | 286 ± 129  |       |       |            |            |            |            |
| NW-B       | 11/07/18        | < 196      |       |       |            |            |            |            |
| NW-C       | 02/27/18        | 668 ± 147  |       |       |            |            |            |            |
| NW-C       | 05/22/18        | 674 ± 147  | < 4.1 | < 0.9 | < 0.9      | < 0.8      | 1.4 ± 0.8  | < 1.4      |
| NW-C       | 08/28/18        | 1400 ± 207 |       |       |            |            |            |            |
| NW-C       | 08/28/18        | 1300 ± 200 |       |       |            |            |            |            |
| NW-C       | 11/07/18        | 523 ± 147  |       |       |            |            |            |            |
| NW-CW      | 02/27/18        | 322 ± 132  |       |       |            |            |            |            |
| NW-CW      | 05/22/18        | 246 ± 126  | < 5.0 | < 0.8 | < 1.0      | < 0.8      | 3.0 ± 1.0  | < 1.4      |
| NW-CW      | 08/28/18        | 393 ± 134  |       |       |            |            |            |            |
| NW-CW      | 11/07/18        | 380 ± 141  |       |       |            |            |            |            |
| OS-14      | 02/28/18        | < 192      |       |       |            |            |            |            |
| OS-14      | 05/22/18        | < 195      | < 4.5 | < 0.6 | < 2.1      | < 0.4      | 10.2 ± 1.5 | < 1.4      |
| OS-14      | 08/29/18        | < 184      |       |       |            |            |            |            |
| OS-14      | 11/07/18        | < 195      |       |       |            |            |            |            |
| OS-16      | 02/28/18        | 315 ± 133  |       |       |            |            |            |            |
| OS-16      | 05/22/18        | < 195      | < 6.6 | < 0.6 | < 1.0      | < 0.4      | 4.3 ± 0.8  | < 1.4      |
| OS-16      | 08/29/18        | 376 ± 133  |       |       |            |            |            |            |
| OS-16      | 11/07/18        | 281 ± 134  |       |       |            |            |            |            |
| OS-18      | 05/23/18        | < 190      |       |       |            |            |            |            |

**TABLE B-I.1 CONCENTRATIONS OF TRITIUM, STRONTIUM, GROSS ALPHA AND GROSS BETA  
IN GROUNDWATER SAMPLES COLLECTED AS PART OF THE RADIOLOGICAL  
GROUNDWATER PROTECTION PROGRAM, THREE MILE ISLAND NUCLEAR STATION, 2018  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA**

| SITE            | COLLECTION<br>DATE | H-3       | Sr-89 | Sr-90 | Gr-A<br>(Dis) | Gr-A<br>(Sus) | Gr-B<br>(Dis) | Gr-B<br>(Sus) |
|-----------------|--------------------|-----------|-------|-------|---------------|---------------|---------------|---------------|
| OSF             | 02/27/18           | 313 ± 131 |       |       |               |               |               |               |
| OSF             | 05/22/18           | 321 ± 131 | < 3.9 | < 0.6 | < 2.9         | < 0.8         | 7.7 ± 1.7     | < 1.4         |
| OSF             | 08/28/18           | 345 ± 131 |       |       |               |               |               |               |
| OSF             | 11/07/18           | < 194     |       |       |               |               |               |               |
| RW-1            | 02/27/18           | < 193     |       |       |               |               |               |               |
| RW-1            | 05/22/18           | < 189     | < 3.7 | < 0.9 | < 1.1         | < 0.8         | 8.1 ± 1.3     | < 1.4         |
| RW-1            | 08/28/18           | 196 ± 126 |       |       |               |               |               |               |
| RW-1            | 11/07/18           | < 195     |       |       |               |               |               |               |
| TRAINING CENTER | 05/21/18           | < 190     |       |       |               |               |               |               |



TABLE B-I.2

**CONCENTRATIONS OF GAMMA EMITTERS IN GROUNDWATER SAMPLES  
COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

| SITE      | COLLECTION DATE | RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA |       |       |       |       |       |       |       |       |        |        |        |        |  |
|-----------|-----------------|---|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|--|
|           |                 | Be-7                                    | K-40  | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | Cs-134 | Cs-137 | Ba-140 | La-140 |  |
| 48S       | 05/22/18        | < 32                                    | < 73  | < 3   | < 4   | < 9   | < 4   | < 7   | < 4   | < 7   | < 4    | < 4    | < 4    | < 9    |  |
| MS-1      | 05/24/18        | < 48                                    | < 87  | < 6   | < 6   | < 13  | < 7   | < 13  | < 6   | < 13  | < 6    | < 5    | < 5    | < 11   |  |
| MS-2      | 05/22/18        | < 39                                    | < 63  | < 4   | < 3   | < 9   | < 4   | < 7   | < 4   | < 7   | < 4    | < 4    | < 4    | < 8    |  |
| MS-3      | 02/28/18        | < 66                                    | < 120 | < 7   | < 8   | < 13  | < 8   | < 19  | < 9   | < 16  | < 8    | < 9    | < 9    | < 12   |  |
| MS-3      | 05/22/18        | < 30                                    | < 60  | < 3   | < 3   | < 6   | < 3   | < 6   | < 3   | < 6   | < 3    | < 3    | < 3    | < 8    |  |
| MS-3      | 08/29/18        | < 59                                    | < 56  | < 7   | < 7   | < 18  | < 7   | < 16  | < 7   | < 14  | < 8    | < 7    | < 7    | < 9    |  |
| MS-3      | 11/07/18        | < 51                                    | < 104 | < 5   | < 5   | < 12  | < 5   | < 9   | < 6   | < 9   | < 5    | < 5    | < 5    | < 12   |  |
| MS-4      | 05/24/18        | < 46                                    | < 74  | < 5   | < 5   | < 11  | < 7   | < 10  | < 5   | < 10  | < 6    | < 5    | < 5    | < 14   |  |
| MS-5      | 02/28/18        | < 61                                    | < 68  | < 8   | < 7   | < 16  | < 8   | < 16  | < 8   | < 15  | < 9    | < 8    | < 8    | < 11   |  |
| MS-5      | 05/22/18        | < 33                                    | < 59  | < 3   | < 4   | < 8   | < 3   | < 7   | < 3   | < 6   | < 4    | < 4    | < 4    | < 9    |  |
| MS-5      | 08/29/18        | < 56                                    | < 71  | < 7   | < 6   | < 17  | < 6   | < 12  | < 8   | < 14  | < 6    | < 7    | < 7    | < 9    |  |
| MS-5      | 11/07/18        | < 41                                    | < 89  | < 4   | < 5   | < 10  | < 6   | < 10  | < 6   | < 10  | < 5    | < 5    | < 5    | < 9    |  |
| MS-7      | 05/23/18        | < 35                                    | < 44  | < 4   | < 4   | < 10  | < 3   | < 8   | < 5   | < 7   | < 5    | < 4    | < 4    | < 13   |  |
| MS-8      | 02/28/18        | < 65                                    | < 66  | < 6   | < 6   | < 19  | < 8   | < 21  | < 9   | < 14  | < 9    | < 9    | < 9    | < 14   |  |
| MS-8      | 05/22/18        | < 17                                    | < 30  | < 2   | < 2   | < 4   | < 2   | < 4   | < 2   | < 3   | < 2    | < 2    | < 2    | < 6    |  |
| MS-8      | 08/29/18        | < 66                                    | < 66  | < 9   | < 7   | < 18  | < 6   | < 18  | < 8   | < 13  | < 9    | < 8    | < 8    | < 13   |  |
| MS-8      | 11/07/18        | < 41                                    | < 78  | < 4   | < 5   | < 10  | < 4   | < 8   | < 5   | < 9   | < 5    | < 4    | < 4    | < 9    |  |
| MS-20     | 05/22/18        | < 36                                    | < 37  | < 4   | < 4   | < 9   | < 3   | < 7   | < 3   | < 6   | < 3    | < 3    | < 3    | < 9    |  |
| MS-21     | 05/22/18        | < 18                                    | < 33  | < 2   | < 2   | < 5   | < 2   | < 4   | < 2   | < 4   | < 2    | < 2    | < 2    | < 5    |  |
| MS-22     | 05/22/18        | < 18                                    | < 19  | < 2   | < 2   | < 5   | < 2   | < 4   | < 2   | < 3   | < 2    | < 2    | < 2    | < 6    |  |
| MW-1      | 05/23/18        | < 26                                    | < 23  | < 2   | < 3   | < 6   | < 3   | < 5   | < 3   | < 5   | < 3    | < 3    | < 3    | < 6    |  |
| MW-1      | 05/23/18        | < 17                                    | < 38  | < 2   | < 2   | < 4   | < 2   | < 3   | < 2   | < 3   | < 2    | < 2    | < 2    | < 5    |  |
| MW-2      | 05/23/18        | < 17                                    | < 33  | < 2   | < 2   | < 5   | < 2   | < 3   | < 2   | < 3   | < 2    | < 2    | < 2    | < 5    |  |
| MW-TMI-1D | 05/23/18        | < 40                                    | < 35  | < 4   | < 4   | < 8   | < 4   | < 8   | < 4   | < 8   | < 4    | < 4    | < 4    | < 10   |  |
| MW-TMI-2D | 05/23/18        | < 41                                    | < 37  | < 4   | < 4   | < 8   | < 5   | < 9   | < 5   | < 8   | < 5    | < 4    | < 4    | < 13   |  |
| MW-TMI-3I | 05/24/18        | < 38                                    | < 78  | < 4   | < 5   | < 10  | < 5   | < 8   | < 5   | < 7   | < 4    | < 4    | < 4    | < 12   |  |
| MW-TMI-3I | 05/24/18        | < 19                                    | < 32  | < 2   | < 2   | < 5   | < 2   | < 4   | < 2   | < 4   | < 2    | < 2    | < 2    | < 6    |  |
| MW-TMI-4I | 05/23/18        | < 46                                    | < 100 | < 5   | < 5   | < 11  | < 5   | < 11  | < 5   | < 10  | < 5    | < 5    | < 5    | < 13   |  |
| MW-TMI-4S | 05/23/18        | < 43                                    | < 83  | < 3   | < 5   | < 9   | < 4   | < 7   | < 5   | < 7   | < 5    | < 4    | < 4    | < 9    |  |
| MW-TMI-6D | 05/23/18        | < 16                                    | < 30  | < 2   | < 2   | < 4   | < 2   | < 3   | < 2   | < 3   | < 2    | < 2    | < 2    | < 4    |  |
| MW-TMI-6I | 05/23/18        | < 18                                    | < 28  | < 2   | < 2   | < 4   | < 2   | < 3   | < 2   | < 3   | < 2    | < 2    | < 2    | < 5    |  |
| MW-TMI-7S | 05/24/18        | < 33                                    | < 79  | < 4   | < 4   | < 10  | < 5   | < 9   | < 4   | < 8   | < 4    | < 4    | < 4    | < 11   |  |
| MW-TMI-8S | 05/24/18        | < 17                                    | < 34  | < 2   | < 2   | < 4   | < 2   | < 3   | < 2   | < 3   | < 2    | < 2    | < 2    | < 5    |  |
| MW-TMI-9I | 05/24/18        | < 44                                    | < 79  | < 5   | < 5   | < 10  | < 6   | < 10  | < 6   | < 10  | < 6    | < 5    | < 5    | < 12   |  |

TABLE B-I.2

CONCENTRATIONS OF GAMMA EMITTERS IN GROUNDWATER SAMPLES  
 COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018  
 RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

| SITE            | COLLECTION DATE |      | Be-7 | K-40  | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | Cs-134 | Cs-137 | Ba-140 | La-140 |
|-----------------|-----------------|------|------|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|
|                 | DATE            | DATE |      |       |       |       |       |       |       |       |       |        |        |        |        |
| MW-TMI-9S       | 05/24/18        |      | < 41 | < 54  | < 5   | < 5   | < 11  | < 5   | < 9   | < 6   | < 10  | < 5    | < 5    | < 36   | < 9    |
| MW-TMI-10D      | 05/23/18        |      | < 39 | < 86  | < 4   | < 5   | < 10  | < 4   | < 10  | < 5   | < 8   | < 5    | < 4    | < 32   | < 11   |
| MW-TMI-10S      | 05/23/18        |      | < 28 | < 60  | < 3   | < 4   | < 7   | < 3   | < 6   | < 3   | < 5   | < 3    | < 3    | < 25   | < 10   |
| MW-TMI-12S      | 05/24/18        |      | < 35 | < 34  | < 4   | < 4   | < 8   | < 4   | < 7   | < 4   | < 6   | < 4    | < 4    | < 26   | < 9    |
| MW-TMI-16D      | 05/24/18        |      | < 41 | < 29  | < 4   | < 5   | < 10  | < 5   | < 8   | < 4   | < 8   | < 5    | < 4    | < 31   | < 9    |
| MW-TMI-17I      | 05/24/18        |      | < 39 | < 38  | < 4   | < 4   | < 9   | < 4   | < 9   | < 5   | < 6   | < 5    | < 5    | < 26   | < 10   |
| MW-TMI-18D      | 05/23/18        |      | < 41 | < 66  | < 4   | < 5   | < 9   | < 6   | < 9   | < 5   | < 9   | < 4    | < 4    | < 27   | < 14   |
| MW-TMI-19I      | 05/24/18        |      | < 44 | < 108 | < 5   | < 5   | < 11  | < 5   | < 11  | < 5   | < 8   | < 5    | < 5    | < 32   | < 10   |
| MW-TMI-20I      | 05/24/18        |      | < 45 | < 48  | < 4   | < 5   | < 9   | < 5   | < 8   | < 5   | < 8   | < 5    | < 5    | < 33   | < 8    |
| MW-TMI-21S      | 05/22/18        |      | < 16 | < 38  | < 2   | < 2   | < 4   | < 2   | < 3   | < 2   | < 3   | < 2    | < 2    | < 17   | < 6    |
| MW-TMI-22S      | 05/22/18        |      | < 17 | < 13  | < 1   | < 2   | < 4   | < 2   | < 3   | < 2   | < 3   | < 2    | < 2    | < 19   | < 5    |
| N2-1            | 05/31/18        |      | < 38 | < 26  | < 5   | < 5   | < 9   | < 5   | < 9   | < 5   | < 8   | < 5    | < 5    | < 30   | < 7    |
| NW-A            | 05/22/18        |      | < 29 | < 63  | < 3   | < 3   | < 8   | < 3   | < 6   | < 4   | < 6   | < 4    | < 3    | < 27   | < 9    |
| NW-B            | 05/22/18        |      | < 32 | < 62  | < 3   | < 4   | < 9   | < 4   | < 6   | < 4   | < 7   | < 3    | < 3    | < 28   | < 10   |
| NW-C            | 05/22/18        |      | < 30 | < 60  | < 3   | < 3   | < 9   | < 3   | < 7   | < 3   | < 6   | < 3    | < 3    | < 25   | < 10   |
| NW-CW           | 05/22/18        |      | < 33 | < 54  | < 3   | < 4   | < 9   | < 4   | < 8   | < 4   | < 6   | < 4    | < 3    | < 30   | < 12   |
| OS-14           | 02/28/18        |      | < 74 | < 180 | < 9   | < 8   | < 21  | < 10  | < 18  | < 10  | < 18  | < 9    | < 9    | < 35   | < 13   |
| OS-14           | 05/22/18        |      | < 16 | < 36  | < 2   | < 2   | < 4   | < 2   | < 3   | < 2   | < 3   | < 2    | < 2    | < 14   | < 5    |
| OS-14           | 08/29/18        |      | < 56 | < 56  | < 5   | < 6   | < 15  | < 6   | < 16  | < 9   | < 13  | < 8    | < 9    | < 39   | < 11   |
| OS-14           | 11/07/18        |      | < 48 | < 97  | < 4   | < 5   | < 10  | < 3   | < 10  | < 6   | < 9   | < 5    | < 5    | < 35   | < 11   |
| OS-16           | 02/28/18        |      | < 71 | < 91  | < 8   | < 9   | < 18  | < 7   | < 12  | < 8   | < 13  | < 8    | < 8    | < 46   | < 13   |
| OS-16           | 05/22/18        |      | < 13 | < 30  | < 1   | < 2   | < 4   | < 2   | < 3   | < 2   | < 3   | < 2    | < 1    | < 11   | < 4    |
| OS-16           | 08/29/18        |      | < 54 | < 91  | < 6   | < 7   | < 14  | < 7   | < 13  | < 7   | < 12  | < 7    | < 8    | < 34   | < 10   |
| OS-16           | 11/07/18        |      | < 46 | < 89  | < 5   | < 5   | < 10  | < 5   | < 10  | < 5   | < 10  | < 5    | < 5    | < 33   | < 11   |
| OS-18           | 05/23/18        |      | < 25 | < 59  | < 2   | < 3   | < 6   | < 3   | < 5   | < 3   | < 5   | < 3    | < 3    | < 21   | < 7    |
| OSF             | 05/22/18        |      | < 32 | < 59  | < 3   | < 4   | < 8   | < 4   | < 8   | < 3   | < 6   | < 4    | < 3    | < 28   | < 9    |
| RW-1            | 05/22/18        |      | < 26 | < 27  | < 3   | < 3   | < 7   | < 3   | < 6   | < 3   | < 5   | < 3    | < 3    | < 24   | < 7    |
| TRAINING CENTER | 05/21/18        |      | < 17 | < 37  | < 2   | < 2   | < 5   | < 2   | < 4   | < 2   | < 4   | < 2    | < 2    | < 16   | < 7    |

TABLE B-I.3

CONCENTRATIONS OF HARD TO DETECTS IN GROUNDWATER SAMPLES COLLECTED  
 AS PART OF THE RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM  
 THREE MILE ISLAND NUCLEAR STATION, 2018

RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

| SITE | COLLECTION DATE | Am-241 | Cm-242 | Cm-243/244 | Pu-238 | Pu-239/240 | U-234 | U-235 | U-238 | Fe-55 | Ni-63 |
|------|-----------------|--------|--------|------------|--------|------------|-------|-------|-------|-------|-------|
|------|-----------------|--------|--------|------------|--------|------------|-------|-------|-------|-------|-------|

*There were no hard to detect analyses for 2018*

**TABLE B-II.1 CONCENTRATIONS OF TRITIUM IN SURFACE WATER SAMPLES COLLECTED  
AS PART OF THE RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM  
THREE MILE ISLAND NUCLEAR STATION, 2018**

RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

| SITE   | COLLECTION |       |
|--------|------------|-------|
|        | DATE       | H-3   |
| SW-E-1 | 02/28/18   | < 193 |
| SW-E-1 | 05/23/18   | < 194 |
| SW-E-1 | 08/28/18   | < 185 |
| SW-E-1 | 11/07/18   | < 183 |
| SW-E-2 | 02/26/18   | < 193 |
| SW-E-2 | 05/21/18   | < 174 |
| SW-E-2 | 05/21/18   | < 187 |
| SW-E-2 | 08/28/18   | < 187 |
| SW-E-2 | 11/07/18   | < 192 |
| SW-E-3 | 02/26/18   | < 193 |
| SW-E-3 | 05/21/18   | < 181 |
| SW-E-3 | 08/28/18   | < 187 |
| SW-E-3 | 08/28/18   | < 187 |
| SW-E-3 | 11/07/18   | < 196 |

**TABLE B-II.2**

**CONCENTRATIONS OF GAMMA EMITTERS IN SURFACE WATER SAMPLES  
COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018  
RESULTS IN UNITS OF PCI/LITER + 2 SIGMA**

| SITE   | COLLECTION |  | Be-7 | K-40 | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | Cs-134 | Cs-137 | Ba-140 | La-140 |
|--------|------------|--|------|------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|
|        | DATE       |  |      |      |       |       |       |       |       |       |       |        |        |        |        |
| SW-E-1 | 05/23/18   |  | < 17 | < 31 | < 2   | < 2   | < 4   | < 2   | < 3   | < 2   | < 3   | < 2    | < 2    | < 15   | < 5    |
| SW-E-2 | 05/21/18   |  | < 31 | < 33 | < 3   | < 4   | < 7   | < 4   | < 7   | < 4   | < 8   | < 4    | < 4    | < 22   | < 8    |
| SW-E-2 | 05/21/18   |  | < 15 | < 23 | < 1   | < 2   | < 3   | < 2   | < 3   | < 2   | < 3   | < 2    | < 1    | < 15   | < 5    |
| SW-E-3 | 05/21/18   |  | < 28 | < 67 | < 3   | < 3   | < 7   | < 3   | < 5   | < 3   | < 6   | < 3    | < 3    | < 28   | < 7    |

**TABLE B-III.1                    CONCENTRATIONS OF TRITIUM IN STORM WATER SAMPLES  
    COLLECTED AS PART OF THE RADIOLOGICAL GROUNDWATER  
PROTECTION PROGRAM - THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER + 2 SIGMA

| SITE | COLLECTION<br>DATES | H-3       |
|------|---------------------|-----------|
| EDCB | 01/30/18 - 03/27/18 | < 181     |
| EDCB | 03/27/18 - 06/26/18 | 219 ± 117 |
| EDCB | 06/26/18 - 09/25/18 | < 197     |
| EDCB | 10/31/18 - 01/03/19 | < 190     |

**TABLE B-III.2**

**CONCENTRATIONS OF GAMMA EMITTERS IN STORM WATER SAMPLES  
COLLECTED IN THE VICINITY OF THREE MILE ISLAND NUCLEAR STATION, 2018**

RESULTS IN UNITS OF PCI/LITER + 2 SIGMA

| SITE | COLLECTION |          | Be-7 | K-40  | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | Cs-134 | Cs-137 | Ba-140 | La-140 |
|------|------------|----------|------|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|
|      | DATES      |          |      |       |       |       |       |       |       |       |       |        |        |        |        |
| EDCB | 01/30/18 - | 03/27/18 | < 73 | < 147 | < 9   | < 8   | < 15  | < 10  | < 18  | < 6   | < 14  | < 8    | < 8    | < 30   | < 12   |
| EDCB | 03/27/18 - | 06/26/18 | < 51 | < 32  | < 5   | < 7   | < 10  | < 5   | < 12  | < 5   | < 11  | < 6    | < 7    | < 33   | < 12   |
| EDCB | 06/26/18 - | 09/25/18 | < 21 | < 73  | < 3   | < 2   | < 5   | < 3   | < 5   | < 3   | < 4   | < 3    | < 3    | < 12   | < 3    |
| EDCB | 10/31/18 - | 01/03/19 | < 57 | < 60  | < 7   | < 6   | < 13  | < 6   | < 15  | < 6   | < 9   | < 5    | < 5    | < 28   | < 11   |

TABLE B-IV.1

**CONCENTRATIONS OF TRITIUM IN PRECIPITATION WATER SAMPLES  
COLLECTED AS PART OF THE RADIOLOGICAL GROUNDWATER  
PROTECTION PROGRAM THREE MILE ISLAND NUCLEAR STATION, 2018**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

| SITE       | COLLECTION |               |
|------------|------------|---------------|
|            | DATE       | H-3           |
| TM-PR-ESE  | 02/28/18   | 469 $\pm$ 135 |
| TM-PR-ESE  | 05/21/18   | < 195         |
| TM-PR-ESE  | 07/26/18   | 245 $\pm$ 128 |
| TM-PR-ESE  | 11/05/18   | 281 $\pm$ 128 |
| TM-PR-MS-1 | 02/28/18   | < 185         |
| TM-PR-MS-1 | 05/21/18   | < 194         |
| TM-PR-MS-1 | 07/26/18   | < 194         |
| TM-PR-MS-1 | 11/05/18   | < 200         |
| TM-PR-MS-2 | 02/28/18   | 409 $\pm$ 131 |
| TM-PR-MS-2 | 05/21/18   | < 193         |
| TM-PR-MS-2 | 07/26/18   | 274 $\pm$ 131 |
| TM-PR-MS-2 | 11/05/18   | 265 $\pm$ 127 |
| TM-PR-MS-4 | 02/28/18   | 204 $\pm$ 124 |
| TM-PR-MS-4 | 05/21/18   | < 196         |
| TM-PR-MS-4 | 07/26/18   | < 196         |
| TM-PR-MS-4 | 11/05/18   | < 186         |



## **APPENDIX C**

### **DATA TABLES**

### **COMPARISON LAB**

Intentionally left blank

**TABLE C-I.1 CONCENTRATIONS OF TRITIUM, STRONTIUM, GROSS ALPHA AND GROSS BETA IN GROUNDWATER SPLIT SAMPLES COLLECTED AS PART OF THE RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM, THREE MILE ISLAND NUCLEAR STATION, 2018**  
 RESULTS IN UNITS OF PCILITER ± 2 SIGMA

| LAB | SITE       | COLLECTION DATE | H-3        | Sr-89 | Sr-90 | Gross Alpha | Gross Beta |
|-----|------------|-----------------|------------|-------|-------|-------------|------------|
| GEL | MS-2       | 02/28/18        | 177 ± 88   |       |       |             |            |
|     | MS-2       | 08/29/18        | < 121      |       |       |             |            |
|     | MS-2       | 11/07/18        | 193 ± 81   |       |       |             |            |
|     | MS-7       | 08/28/18        | 250 ± 91   |       |       |             |            |
|     | MS-7       | 11/06/18        | < 116      |       |       |             |            |
|     | MW-1       | 05/23/18        | < 116      |       |       |             |            |
|     | MW-TMI-3I  | 05/24/18        | 259 ± 84   | < 0.4 | < 0.3 | < 21.5      | < 10.4     |
|     | MW-TMI-3I  | 08/30/18        | 257 ± 80   |       |       |             |            |
|     | MW-TMI-10I | 02/27/18        | 444 ± 96   |       |       |             |            |
|     | MW-TMI-10I | 05/23/18        | 456 ± 92   |       |       |             |            |
|     | MW-TMI-13I | 05/23/18        | < 113      |       |       |             |            |
|     | MW-TMI-14I | 02/28/18        | < 144      |       |       |             |            |
|     | MW-TMI-14I | 11/06/18        | < 114      |       |       |             |            |
|     | MW-TMI-21I | 02/27/18        | 1550 ± 119 |       |       |             |            |

**TABLE C-1.2 CONCENTRATIONS OF GAMMA EMITTERS IN GROUNDWATER SPLIT SAMPLES COLLECTED AS PART OF THE RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM, THREE MILE ISLAND NUCLEAR STATION, 2018**  
 RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

| LAB | SITE      | COLLECTION |  | Mn-54 | Fe-59 | Co-58 | Co-60 | Zn-65 | Zr-95 | Nb-95 | Cs-134 | Cs-137 | Ba-140 | La-140 |
|-----|-----------|------------|--|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|
|     |           | PERIOD     |  |       |       |       |       |       |       |       |        |        |        |        |
| GEL | MW-1      | 02/23/18   |  | < 1   | < 3   | < 2   | < 1   | < 3   | < 3   | < 2   | < 2    | < 2    | < 9    | < 3    |
|     | MW-TMI-3I | 05/24/18   |  | < 2   | < 4   | < 2   | < 2   | < 3   | < 3   | < 2   | < 2    | < 2    | < 10   | < 4    |

TABLE C-I.3

CONCENTRATIONS OF HARD TO DETECTS IN GROUNDWATER SAMPLES COLLECTED AS PART OF THE  
 RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM, THREE MILE ISLAND NUCLEAR STATION, 2018

RESULTS IN UNITS OF PC/LITER ± 2 SIGMA

| SITE | COLLECTION PERIOD | Am-241 | Cm-242 | Cm-243/244 | Pu-238 | Pu-239/240 | U-233/234 | U-235 | U-238 | Fe-55 | Ni-63 |
|------|-------------------|--------|--------|------------|--------|------------|-----------|-------|-------|-------|-------|
|------|-------------------|--------|--------|------------|--------|------------|-----------|-------|-------|-------|-------|

*There were no hard to detect analyses for 2018*

**TABLE C-II.1      CONCENTRATIONS OF TRITIUM IN SURFACE WATER SPLIT SAMPLES  
 COLLECTED AS PART OF THE RADIOLOGICAL GROUNDWATER PROTECTION  
 PROGRAM, THREE MILE ISLAND NUCLEAR STATION, 2018**

RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

| LAB | SITE   | COLLECTION |       |
|-----|--------|------------|-------|
|     |        | DATE       | H-3   |
| GEL | SW-E-2 | 05/21/18   | < 115 |
|     | SW-E-3 | 08/28/18   | < 103 |

**TABLE C-II.2 CONCENTRATIONS OF GAMMA EMITTERS IN GROUNDWATER SPLIT SAMPLES COLLECTED AS PART OF THE RADIOLGICAL GROUNDWATER PROTECTION PROGRAM, THREE MILE ISLAND NUCLEAR STATION, 2018**  
 RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

| LAB | SITE   | COLLECTION |       |       |       |       |       |       |       |        |        |        |        |     |      |     |
|-----|--------|------------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|-----|------|-----|
|     |        | PERIOD     | Mn-54 | Fe-59 | Co-58 | Co-60 | Zn-65 | Zr-95 | Nb-95 | Cs-134 | Cs-137 | Ba-140 | La-140 |     |      |     |
| GEL | SW-E-2 | 05/21/18   | < 2   | < 4   | < 2   | < 2   | < 3   | < 3   | < 2   | < 2    | < 3    | < 2    | < 2    | < 1 | < 11 | < 3 |

**TABLE C-III.1**

**CONCENTRATIONS OF TRITIUM IN PRECIPITATION WATER SPLIT SAMPLES  
COLLECTED AS PART OF THE RADIOLOGICAL GROUNDWATER  
PROTECTION PROGRAM, THREE MILE ISLAND NUCLEAR STATION, 2018  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA**

| LAB | SITE        | COLLECTION<br>DATES | H-3       |
|-----|-------------|---------------------|-----------|
| GEL | TM-PR-MS-2Q | 02/28/18 - 03/27/18 | 398 ± 95  |
|     | TM-PR-MS-2Q | 05/21/18 - 06/28/18 | < 161     |
|     | TM-PR-MS-2Q | 07/26/18 - 08/30/18 | 216 ± 84  |
|     | TM-PR-MS-2Q | 11/05/18 - 12/10/18 | 257 ± 115 |