

Entergy Operations, Inc. River Bend Station 5485 U.S. Highway 61N St. Francisville. LA 70775 Tel 225-381-4177

Tim Schenk Manager-Regulatory Assurance

RBG-47952

May 1, 2019

Attn: Document Control Desk U. S. Nuclear Regulatory Commission 11555 Rockville Pike Rockville, MD 20852-2738

Subject:

2018 Annual Radiological Environmental Operating Report

River Bend Station – Unit 1 License No. NPF-47 Docket No. 50-458

Enclosed is the River Bend Station (RBS) Annual Radiological Environmental Operating Report for the period of January 1, 2018 through December 31, 2018. This report is submitted in accordance with the RBS Technical Specifications, Section 5.6.2.

Should you have any questions regarding the enclosed, please contact Tim Schenk, at (225) 381-4177.

Sincerely,

Tim Schenk

TAS/tf

Enclosure:

2018 Annual Radiological Environmental Operating Report

CC:

NRC Region IV Regional Administrator, w/o Enclosure

NRC Senior Resident Inspector - River Bend Station, Unit 1

Ji Young Wiley, Department of Environmental Quality, Office of Environmental

Compliance, Radiological Emergency Planning and Response Section

Public Utility Commission of Texas, Attn: PUC Filing Clerk

NRC Project Manager

IE25 NRR



Plant: River Bend Station

Page 1 of 45

YEAR: 2018

Document Number: RBG-47952

Annual Radiological Environmental Operating Report

TABLE OF CONTENTS

1.0	EXECUTIVE SUMMARY	5
	1.1 Radiological Environmental Monitoring Program	5
	1.2 Reporting Levels	5
	1.3 Comparison to State and Federal Program	6
	1.4 Sample Deviations	6
	1.5 Program Modifications	6
2.0	INTRODUCTION	7
	2.1 Radiological Environmental Monitoring Program	7
	2.2 Pathways Monitored	7
	2.3 Land Use Census.	7
3.0	RADIOLOGICAL ENVIRONMENTAL SAMPLING PROGRAM REQUIREMENTS	8
4.0	INTERPRETATION AND TRENDS OF RESULTS	17
	4.1 Air Particulate and Radioiodine Sample Results	17
	4.2 Thermoluminescent Dosimetry (TLD) Sample Results	18
	4.3 Waterborne Sample Results	18
	4.3.1 Surface Water Results	18
	4.3.2 Groundwater Results	19
	4.3.3 Sediment Sample Results	19
	4.4 Ingestion Sample Results	19
	4.4.1 Fish Sample Results	19
	4.4.2 Food Products Sample Results	19
	4.4.3 Milk Sample Results	19
	4.5 Land Use Census Results	20
	4.6 Interlaboratory Comparison Results	22
5.0	RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY	22

Plant: River Bend Station	Year: 2018	Page 3 of 45
Annual Radiological Environme		

F	1.	Т	T	Α	C	۲	1	Ν	1	Ε	1	V	Т	S
---	----	---	---	---	---	---	---	---	---	---	---	---	---	---

ATTACHMENTO
Attachment 1 - Sample Deviations26
Attachment 2 - Monitoring Results Tables27
Attachment 3 - Interlaboratory Comparison Program Results
<u>TABLES</u>
Table 1: Exposure Pathway - Airborne8
Table 2: Exposure Pathway - Direct Radiation9
Table 3: Exposure Pathway - Waterborne12
Table 4: Exposure Pathway - Ingestion13
Table 5: Land Use Census - 2018 Nearest Residence and Milk Animal Within 5 Miles21
Table 6: Radiological Environmental Monitoring Program Summary23
Table 7: Sample Deviations Table26
Table 8: Air Particulate Data Table27
Table 9: Radioiodine Cartridge Data Table28
Table 10: Thermoluminescent Dosimeters - Indicators29
Table 11: Thermoluminescent Dosimeters - Special Interest Areas30
Table 12: Thermoluminescent Dosimeters - Controls30
Table 13: Surface Water - Gamma31
Table 14: Surface Water - Tritium32
Table 15: Groundwater - Gamma33
Table 16: Groundwater - Tritum34
Table 17: Sediment - Gamma35
Table 18: Fish - Gamma36
Table 19: Food Products - Gamma37
Table 20: Analytics Environmental Radioactivity Cross Check Program40
Table 21: DOE's Mixed Analyte Performance Evaluation Program (MAPEP)44
Table 22: ERA Environmental Radioactivity Cross Check Program45

Plant: River Bend Station	Year: 2018	Page 4 of 45
Annual Radiological Environr	nental Operating Repor	t

FIGURES

Figure 1: Exposure Pathway	.14
Figure 2: Sample Collection Sites - Near Field	.15
Figure 3: Sample Collection Sites - Far Field	.16
Figure 4: Gross Beta Indicator Results (2018)	.17
Figure 5: TLD Indicator Results (2018) Versus Control Data (1986-2018)	.18

Plant: River Bend Station	Year: 2018	Page 5 of 45					
Annual Radiological Environmental Operating Report							

1.0 EXECUTIVE SUMMARY

1.1 Radiological Environmental Monitoring Program

The Annual Radiological Environmental Operating Report presents data obtained through analyses of environmental samples collected for River Bend Station (RBS) Radiological Environmental Monitoring Program (REMP) for the period January 1 through December 31, 2018. This report fulfills the requirements of RBS Technical Specification 5.6.2 of Appendix A to RBS License Number NPF-47.

All required lower limit of detection (LLD) capabilities were achieved in all sample analyses during 2018, as required by the RBS Technical Requirement Manual (TRM). No measurable levels of radiation above baseline levels attributable to River Bend Station operation were detected in the vicinity of RBS. The 2018 Radiological Environmental Monitoring Program thus substantiated the adequacy of source control and effluent monitoring at River Bend Station with no observed impact of plant operations on the environment.

River Bend Station established the REMP prior to the station's becoming operational 1985 to provide data on background radiation and radioactivity normally present in the area. RBS has continued to monitor the environment by sampling air, water, sediment, fish and food products, as well as measuring direct radiation. RBS also samples milk if milk-producing animals used for human consumption are present within five miles (8 km) of the plant.

The REMP includes sampling indicator and control locations within an approximate 20-mile radius of the plant. The REMP utilizes indicator locations near the site to show any increases or buildup of radioactivity that might occur due to station operation and control locations farther away from the site to indicate the presence of only naturally occurring radioactivity. RBS personnel compare indicator results with control and preoperational results to assess any impact RBS operation might have had on the surrounding environment.

In 2018, environmental samples were collected for radiological analysis. The results of indicator locations were compared with control locations and previous studies. It was concluded that no significant relationship exists between RBS operation and effect on the area around the plant. The review of 2018 data showed radioactivity levels in the environment were undetectable in many locations and near background levels in significant pathways.

1.2 Reporting Levels

No samples equaled or exceeded reporting levels.

Plant: River Bend Station	Year: 2018	Page 6 of 45
Annual Radiological Environme	ental Operating Report	

1.3 Comparison to State and Federal Program

RBS personnel compared REMP data to state monitoring programs as results became available. Historically, the programs used for comparison have included the U.S. Nuclear Regulatory Commission (NRC) Thermoluminescent Dosimeter (TLD) Direct Radiation Monitoring Network and the Louisiana Department of Environmental Quality – Office of Environmental Compliance (LDEQ-OEC).

The NRC TLD Network Program was discontinued in 1998. Historically these results have compared to those from the RBS REMP. RBS TLD results continue to remain similar to the historical average and continue to verify that plant operation is not affecting the ambient radiation levels in the environment.

The LDEQ-OEC and the RBS REMP entail similar radiological environmental monitoring program requirements. These programs include co-located air samples and splitting or sharing sample media such as water, sediment and fish. Both programs have obtained similar results over previous years.

1.4 Sample Deviations

During 2018, environmental sampling was performed for five media types addressed in the ODCM and for direct radiation. A total of 120 samples of the 120 scheduled were obtained. Of the scheduled samples, 100 percent were collected and analyzed in accordance with the requirements specified in the ODCM. Attachment 1 contains the listing of sample deviations and actions taken.

1.5 **Program Modifications**

• There were no program modifications during the reporting period.

Plant: River Bend Station	Year: 2018	Page 7 of 45			
Annual Radiological Environmental Operating Report					

2.0 INTRODUCTION

2.1 <u>Radiological Environmental Monitoring Program</u>

River Bend Station established the REMP to ensure that plant operating controls properly function to minimize any associated radiation endangerment to human health or the environment. The REMP is designed for:

- Analyzing applicable pathways for anticipated types and quantities of radionuclides released into the environment.
- Considering the possibility of a buildup of long-lived radionuclides in the environment and identifying physical and biological accumulations that may contribute to human exposures.
- Considering the potential radiation exposure to plant and animal life in the environment surrounding River Bend Station.
- Correlating levels of radiation and radioactivity in the environment with radioactive releases from station operation.

2.2 Pathways Monitored

The airborne, direct radiation, waterborne and ingestion pathways are monitored as required by RBS TRM 3.12.1. A description of the REMP utilized to monitor the exposure pathways is described in the attached Tables and Figures.

Section 4.0 of this report provides a discussion of 2018 sampling results with Section 5.0 providing a summary of results for the monitored exposure pathways.

2.3 Land Use Census

RBS conducts a land use census biennially, as required by 3.12.2 of the TRM. The purpose of this census is to identify changes in uses of land within five miles of RBS that would require modifications to the REMP and the Offsite Dose Calculation Manual (ODCM/TRM). The next scheduled land use census will be performed in 2020. Section 4.5 on the report contains a narrative on the results of the 2018 land use census.

Plant: River Bend Station	Year: 2018	Page 8 of 45				
Annual Radiological Environmental Operating Report						

3.0 RADIOLOGICAL ENVIRONMENTAL SAMPLING PROGRAM REQUIREMENTS

Table 1: Exposure Pathway – Airborne

Requirement	Sample Point Description Distance and Direction	Sampling and Collection Frequency	Type and Frequency Of Analyses
RADIOIODINE AND PARTICULATES 2 samples from close to the 2 SITE BOUNDARY locations, in different sectors, of the highest calculated annual average ground level D/Q.	 AN1 (0.9 km W) - RBS site Hwy 965; 0.4 km south of Activity Center. AP1 (0.9 km WNW) - Behind River Bend Station Activity Center. 	Continuous sampler operation with sample collection every two weeks, or more frequently if required by dust loading.	 Radioiodine Canisters – I-131 analysis every two weeks. Air Particulate – Gross beta radioactivity analysis following filter change.
RADIOIODINE AND PARTICULATES 1 sample from the vicinity of a community having the highest calculated annual average ground level D/Q.	AQS2 (5.8 km NW) - St. Francis Substation on US Hwy. (Bus.) 61 in St. Francisville.	Continuous sampler operation with sample collection every two weeks, or more frequently if required by dust loading.	Radioiodine Canisters – I-131 analysis every two weeks. Air Particulate – Gross beta radioactivity analysis following filter change.
RADIOIODINE AND PARTICULATES 1 sample from a control location, as for example 15 - 30 km distance and in the least prevalent wind direction.	AGC (17.0 km SE) – Entergy Service Center compound in Zachary. (Control)	Continuous sampler operation with sample collection every two weeks, or more frequently if required by dust loading.	Radioiodine Canisters – I-131 analysis every two weeks. Air Particulate – Gross beta radioactivity analysis following filter change.

Plant: River Bend Station	Year: 2018	Page 9 of 45			
Annual Radiological Environmental Operating Report					

Table 2: Exposure Pathway – Direct Radiation

Requirement	Sample Point Description Distance and Direction	Sampling and Collection Frequency	Type and Frequency Of Analyses
TLDS One ring of stations, one in each meteorological sector in the general area of the SITE BOUNDARY.	 TA1 (1.7 km N) - River Bend Training Center. TB1 (0.5 km NNE) - Utility pole near River Bend Station cooling tower yard area. TC1 (1.7 km NE) - Telephone pole at Jct. US Hwy. 61 and Old Highway 61. TD1 (1.6 km ENE) - Stub pole along WF7, 150m S of Jct. WF7 and US Hwy. 61. TE1 (1.3 km E) - Stub pole along WF7, 1 km S of Jct. WF7 and US Hwy. 61. TF1 (1.3 km ESE) - Stub pole along WF7, 1.6 km S of Jct. WF7 and US Hwy. 61. TG1 (1.6 km SE) - Stub pole along WF7, 2 km S of Jct. WF7 and US Hwy. 61. TH1 (1.7 km SSE) - Stub pole at power line crossing of WF7 (near Grants Bayou). TJ1 (1.5 km S) - Stub pole near River Bend Station Gate #23 on Powell Station Road (LA Hwy. 965). 	Quarterly	mR exposure quarterly.

Plant: River Bend Station	Year: 2018	Page 10 of 45	
Annual Radiological Environmental Operating Report			

Table 2: Exposure Pathway – Direct Radiation

Requirement	Sample Point Description Distance and Direction	Sampling and Collection Frequency	Type and Frequency Of Analyses
TLDS One ring of stations, one in each meteorological sector in the general area of the SITE BOUNDARY.	TK1 (0.9 km SSW) – Utility pole on Powell Station Road (LA Hwy. 965), 20 m S of River Bend Station River Access Road.	Quarterly	mR exposure quarterly.
THE SITE BOOKENIKT.	TL1 (1.0 km SW) – First utility pole on Powell Station Road (LA Hwy . 965) S of former Illinois Central Gulf RR crossing.		
	TM1 (0.9 km WSW) - Third utility pole on Powell Station Road (LA Hwy. 965) N of former Illinois Central Gulf RR crossing.		
	TN1 (0.9 km W) – Utility pole along Powell Station Road (LA Hwy. 965), near garden and AN1 air sampler location.		
	TP1 (0.9 km WNW) - Behind River Bend Station Activity Center at AP1 air sampler location.		
	TQ1 (0.6 km NW) – Across from MA-1 on RBS North Access Road.		
	TR1 (0.8 km NNW) – River Bend Station North Access Road across from Main Plant entrance.		

Plant: River Bend Station	Year: 2018	Page 11 of 45		
Annual Radiological Environmental Operating Report				

Table 2: Exposure Pathway – Direct Radiation

Requirement		Sample Point Description Distance and Direction	Sampling and Collection Frequency	Type and Frequency Of Analyses
TLDS The balance of the stations (8) to be placed in special interest areas such as population	•	TAC (15.8 km N) – Utility pole at Jct. of US Hwy. 61 and LA Hwy. 421, 7.9 km north of Bains. (Control)	Quarterly	mR exposure quarterly.
centers, nearby residences, schools, and in 1 or 2 areas to serve as control locations.	•	TCS (12.3 km NE) – Utility pole at gate to East Louisiana State Hospital in Jackson. (Special)		
	•	TEC (16.0 km E) – Stub pole at jct. of Hwy. 955 and Greenbrier Road, 4.8 km North of Jct. of Hwys 955 and 964. (Control)		
	•	TGS (17.0 km SE) – Entergy Service Center compound in Zachary. (Special)		
	•	TNS (6.0 km W) – Utility pole with electrical meter at west bank ferry landing (LA Hwy. 10). (Special)		
	•	TQS1 (4.0 km NW) – Utility pole front of Pentecostal church (opposite West Feliciana Parish Hospital) near Jct. US Hwy. 61 and Commerce Street. (Special)		
	•	TQS2 (5.8 km NW) – St. Francis Substation on business US Hwy. 61 in St. Francisville. (Special)		
	•	TRS (9.2 km NNW) - Stub pole at Jct. of US Hwy. 61 and WF2 near Bains (West Feliciana High School). (Special)		

Plant: River Bend Station	Year: 2018	Page 12 of 45	
Annual Radiological Environmental Operating Report			

Table 3: Exposure Pathway – Waterborne

Requirement	Sample Point Description Distance and Direction	Sampling and Collection Frequency	Type and Frequency Of Analyses
SURFACE WATER 1 sample upstream and 1 sample downstream.	SWU (5.0 km W) - Mississippi River about 4 km upstream from the plant liquid discharge outfall, near LA Hwy. 10 ferry crossing. SWD (7.75 km S) - Mississippi River about 4 km downstream from plant liquid discharge outfall, near paper mill.	Grab samples quarterly	Gamma isotopic analysis and tritium analysis quarterly.
GROUNDWATER Samples from 1 or 2 sources only if likely to be affected.	WU (~470 m NNE) - Upland Terrace Aquifer well upgradient from plant. WD (~470 m SW) - Upland Terrace Aquifer well downgradient from plant.	Semiannually	Gamma isotopic and tritium analysis semiannually.
SEDIMENT FROM SHORELINE 1 sample from downstream area with existing or potential recreational value.	SEDD (7.75 km S) – Mississippi River about 4 km downstream from plant liquid discharge outfall, near paper mill.	Annually	Gamma isotopic analysis annually.

Plant: River Bend Station	Year: 2018	Page 13 of 45	
Annual Radiological Environmental Operating Report			

Table 4: Exposure Pathway – Ingestion

Requirement	Sample Point Description Distance and Direction	Sampling and Collection Frequency	Type and Frequency Of Analyses
MILK			
If commercially available, 1 sample from milking animals within 8 km distant where doses are calculated to be greater than 1 mrem per year.	Currently, no available milking animals within 8 km of RBS.	Quarterly when animals are on pasture.	Gamma isotopic and I-131 analysis quarterly when animals are on pasture.
1 sample from milking animals at a control location 15 – 30 km distant when an indicator location exists.	,		
 FISH AND INVERTEBRATES 1 sample of a commercially and/or recreationally important species in vicinity of plant discharge area. 1 sample of similar species in area not influenced by plant discharge. 	Tell (7.75 km S) - One sample of a commercially and/or recreationally important species from downstream area influenced by plant discharge. FU (4.0 km WSW) - One sample of a commercially and/or recreationally important species from upstream area not influenced by plant discharge.	Annually	Gamma isotopic analysis on edible portions annually
 FOOD PRODUCTS 1 sample of one type of broadleaf vegetation grown near the SITE BOUNDARY location of highest predicted annual average ground level D/Q if milk sampling is not performed. 1 sample of similar broadleaf vegetation grown 15 – 30 km distant, if milk sampling is not performed. 	GN1 (0.9 km W) – Sampling will be performed in accordance with Table 3.12.1-1 Section 4.a of the Technical Requirements Manual. GQC (32.0 km NW) - One sample of similar vegetables from LA State Penitentiary at Angola. (Control)	Quarterly during the growing season.	Gamma isotopic and I-131 analysis quarterly.

Figure 1: Exposure Pathway




Figure 2: Sample Collection Sites - Near Field





Figure 3: Sample Collection Sites - Far Field



Plant: River Bend Station	Year: 2018	Page 17 of 45
Annual Radiological Environme	ental Operating Report	


4.0 INTERPRETATION AND TRENDS OF RESULTS

4.1 <u>Air Particulate and Radioiodine Sample Results</u>

In 2018 there were no samples above the LLD for I-131. Indicator gross beta air particulate results for 2018 were comparable to results obtained from 2008-2017 of the operational REMP. Also, the 2018 gross beta annual average was less than the average for preoperational levels. Results are reported as annual average picocuries per cubic meter (pCi/m³).

Monitoring Period	Result
2008 - 2017 (Minimum Value)	0.017
2018 Average Value	0.018
2008 – 2017 (Maximum Value)	0.026
Preoperational	0.030


Gross beta activity is attributed to naturally occurring radionuclides. Table 6, which include gross beta concentrations and provide a comparison of the indicator and control means and ranges emphasizes the consistent trends seen in this pathway to support the presence of naturally occurring activity. Therefore, it can be concluded that the airborne pathway continues to be unaffected by River Bend Station operations.



Plant: River Bend Station	Year: 2018	Page 18 of 45
Annual Radiological Environme	ental Operating Report	

4.2 Thermoluminescent Dosimetry (TLD) Sample Results

River Bend Station reports measured dose as net exposure (field reading less transit reading) normalized to 90 days and relies on comparison of the indicator locations to the control as a measure of plant impact. River Bend Station's comparison of the indicator and special interest area TLD results to the control, as seen in Table 6, identified no noticeable trend that would indicate that the ambient radiation levels are being affected by plant operations. In addition, the indicator value of 13.5 millirem (mrem) shown in the TLD radiation dose comparison graph below shows the 2018 concentration is comparable to historic results. Overall, River Bend Station concluded that the ambient radiation levels are not being affected by plant operations.



4.3 Waterborne Sample Results

Analytical results for 2018 surface water and groundwater water samples were similar to those reported in previous years. Gamma radionuclides and tritium analytical results for 2018 waterborne samples were below the ODCM-required LLD similar to those reported in previous years. These results are further explained below.

4.3.1 Surface Water Results

Samples were collected from one indicator and one control location and analyzed for gamma radionuclides and tritium. Tritium and gamma radionuclides were below detectable limits which is consistent with results seen in previous operational years. Therefore, the operation of River Bend Station had no definable impact on this waterborne pathway during 2018.

Plant: River Bend Station	Year: 2018	Page 19 of 45
Annual Radiological Environme	ental Operating Report	

4.3.2 Groundwater Results

Samples were collected from one indicator and one control location. Groundwater samples were analyzed for gamma radionuclides and tritium. Gamma radionuclides and tritium concentrations were below the LLD limits at the indicator and control locations. The operation of River Bend Station had no definable impact on this waterborne pathway during 2018.

4.3.3 <u>Sediment Sample Results</u>

Sediment samples were collected from one indicator and one control location in 2018 and analyzed for gamma radionuclides. Gamma radionuclides were below the LLD limits at both indicator and control locations. River Bend Station operations had no significant impact on the environment or public by this waterborne pathway.

4.4 <u>Ingestion Sample Results</u>

4.4.1 Fish Sample Results

Fish samples were collected from one indicator and one control location and analyzed for gamma radionuclides. In 2018, gamma radionuclides were below detectable limits which are consistent with the preoperational monitoring period and operational results. Therefore, based on these measurements, River Bend Station operations had no significant radiological impact upon the environment or public by this ingestion pathway.

4.4.2 <u>Food Products Sample Results</u>

The REMP has detected radionuclides prior to 1990 that are attributable to other sources. These include the radioactive plume release due to reactor core degradation at Chernobyl Nuclear Power Plant in 1986 and atmospheric weapons testing.

In 2018, food products samples were collected when available from one indicator and one control location and analyzed for gamma radionuclides. The 2018 levels remained undetectable, as has been the case in previous years. Therefore, based on these measurements, River Bend Station operations had no significant radiological impact upon the environment or public by this ingestion pathway.

4.4.3 Milk Sample Results

In 2018 milk samples within five miles (8 km) of River Bend Station were unable to be collected due to the unavailability of milk-producing animals used for human consumption. The River Bend Station Technical Requirements Manual requires collection of milk samples if available commercially within 8 km (5 miles) of the plant. River Bend Station personnel collected food product samples to monitor the ingestion pathway, as specified in River Bend Station Technical Requirements Manual Table 3.12.1-1, because of milk unavailability. Food product sample results are in section 4.4.2.

Plant: River Bend Station	Year: 2018	Page 20 of 45			
Annual Radiological Environmental Operating Report					

4.5 <u>Land Use Census Results</u>

The latest land use census (performed in 2018) did not identify any new locations that yielded a calculated dose or dose commitment greater than those currently calculated (see Table 5).

A garden census is not conducted pursuant to the note in the TRM (TLCO 3.12.2) that allows the sampling of broad leaf vegetation in the highest calculated average ground-level D/Q sector near site boundary in lieu of the garden census.

The land use census identified one change. A new resident, located at a distance of 1.7 km in Sector A, was identified in 2018. This occupied residence is 0.2 km closer to the site than the residence reported in previous census. There were no changes in the milk cows or food products in 2018.

Plant: River Bend Station	Year: 2018	Page 21 of 45
Annual Radiological Environme	ental Operating Report	

Table 5: Land Use Census –2018 Nearest Residence And Milk Animal Within Five Miles

		Nearest	<u> </u>	-	T	
Sector	Direction		Range (Unit)	Nearest Milk Animal	Range (Unit)	Comment
		Residence	(Onit)		(Unit)	
A	N	5637 Hwy 61				
		St. Francisville, LA 70775	1.7	-	-	2
В	NNE	4549 Old Hwy 61				
		St. Francisville, LA 70775	1.4		-	, 2
С	NE	4553 Old Hwy 61				2
		St. Francisville, LA 70775	1.5	-		
D	ENE	12657 Powell Station Rd.				2
		St. Francisville, LA 70775	1.4	-		2
E	E	4635 Hwy 61		_	_	2
_		St. Francisville, LA 70775	2.4		<u> </u>	
F	ESE	12019 Fairview Way		_	_	2
		Jackson, LA 70748	2.6			
G	SE	3319 Hwy 964		<u>.</u>	_	2
		Jackson, LA 70748	3.7			
н	SSE	11813 Powell Station Rd.	1	-	_	2
		St. Francisville, LA 70775	1.7			
J	s	11649 Powell Station Rd.		-	_	2
		St. Francisville, LA 70775	1.8			
K	SSW	8909 Hwy 981		_	_	2
_		New Roads, LA 70760	6.6			
L	SW			-	-	1, 2
М	WSW	8809 Hwy 981			 	
IVI	VV3VV	New Roads, LA 70760	5.1	-	-	2
N	W			-	_	1, 2
	10000	10426 Old Field Rd.	+		 	
Р	WNW	St. Francisville, LA 70775	3.7	-	-	2
	D.D.0.4	9537 Hwy 965	 5. / 			
Q	NW	St. Francisville, LA 70775	1.3	-	-	2
R	NNW	9794 Hwy 965	1		 	
	ININVV	St. Francisville, LA 70775	1.6	-	-	2

#	Comment
1	No Residence was located within a five-mile (8 km) radius of River Bend Station 3.
2	No Milk animals were found located within a five-mile (8 km) radius of River Bend Station 3.

Plant: River Bend Station	Year: 2018	Page 22 of 45			
Annual Radiological Environmental Operating Report					

4.6 <u>Interlaboratory Comparison Results</u>

Attachment 3 contains result summary for Interlaboratory Comparison program for Teledyne Brown Engineering to fulfill the requirements of River Bend Station's Technical Requirements Manual 3.12.3.

5.0 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

1. Table 6, Radiological Environmental Monitoring Program Summary, summarizes data for the 2018 REMP program.

Plant: River Bend Station	Year: 2018	Page 23 of 45			
Annual Radiological Environmental Operating Report					

Table 6: Radiological Environmental Monitoring Program Summary

Sample Type (Units)	Type / Number of Analyses ⁽¹⁾	LLD ⁽²⁾	Indicator Locations Mean (F) ⁽³⁾ [Range]	Location ⁽⁴⁾ [Highest Annual Mean]	Mean (F) ⁽³⁾ [Range]	Control Locations Mean (F) ⁽³⁾ [Range]	Number of Non Routine Results ⁽⁵⁾
Air Particulates (pCi/m³)	GB / 104	0.01	0.0182 (78 / 78) [0.008 – 0.031]	AN1 (0.9 km W)	0.0186 (26 / 26) [0.011 - 0.028]	0.0182 (26 / 26) [0.008 - 0.028]	0
Airborne lodine (pCi/m³)	l-131 / 104	0.07	< LLD	N/A	N/A	< LLD	0
Indicator TLDs (mR/Qtr)	Gamma / 64	(6)	13.5 (64 / 64) [10.1 – 17.7]	TG1 (1.6 km SE)	15.6 (4 / 4) [15.4 – 16.0]	N/A	0
Special Interest TLDs (mR/Qtr)	Gamma / 24	(6)	13.9 (24 / 24) [12.1 – 15.8]	TGS (17.0 km SE)	15.3 (4 / 4) [14.3 – 15.8]	N/A	0
Control TLDs (mR/Qtr)	Gamma / 8	(6)	N/A	TAC (15.8 km N)	15.4 (4 / 4) (14.9-15.8	14.6 (8 / 8) [13.7 – 15.8]	0
	H-3 / 8 GS / 8	700	< LLD	N/A	N/A	< LLD	0
	Mn-54	15	< LLD	N/A	N/A	< LLD	0
	Co-58	15	< LLD	N/A	N/A	< LLD	0
	Fe-59	30	< LLD	N/A.	N/A	< LLD	0
Surface Water	Co-60	15	< LLD	N/A	N/A	< LLD	0
(pCi/L)	Zn-65	30	< LLD	N/A	N/A	< LLD	0
(50112)	Nb-95	15	< LLD	, N/A	N/A	< LLD	0
	l-131	15	< LLD	N/A	N/A	< LLD	0
	Zr-95	30	< LLD	N/A	N/A	< LLD	0
	Cs-134	15	< LLD	N/A	N/A	< LLD	0
ĺ	Cs-137	18	< LLD	N/A	N/A	< LLD	0
	Ba-140	60	< LLD	N/A	N/A	< LLD	0
	La-140	15	< LLD	N/A	N/A	< LLD	0

Plant: River Bend Station	Year: 2018	Page 24 of 45				
Annual Radiological Environmental Operating Report						

Table 6: Radiological Environmental Monitoring Program Summary

Sample Type (Units)	Type / Number of Analyses ⁽¹⁾	LLD ⁽²⁾	Indicator Locations Mean (F) ⁽³⁾ [Range]	Location ⁽⁴⁾ [Highest Annual Mean]	Mean (F) ⁽³⁾ [Range]	Control Locations Mean (F) ⁽³⁾ [Range]	Number of Non Routine Results ⁽⁵⁾
	H-3 / 4	700	< LLD	N/A	N/A	、 <lld< th=""><th>0</th></lld<>	0
Groundwater (pCi/L)	GS / 4 Mn-54 Co-58 Fe-59 Co-60 Zn-65 Nb-95 I-131 Zr-95 Cs-134 Cs-137 Ba-140	15 15 30 15 30 15 15 30 15	<pre></pre>	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A	< LLD	0 0 0 0 0 0
	La-140	15	< LLD < LLD	N/A N/A	N/A N/A	< LLD < LLD	0

Plant: River Bend Station	Year: 2018	Page 25 of 45
Annual Radiological Env		

Table 6: Radiological Environmental Monitoring Program Summary

Sample Type (Units)	Type / Number of Analyses ⁽¹⁾	LLD ⁽²⁾	Indicator Locations Mean (F) ⁽³⁾ [Range]	Location ⁽⁴⁾ [Highest Annual Mean]	Mean (F) ⁽³⁾ [Range]	Control Locations Mean (F) ⁽³⁾ [Range]	Number of Non Routine Results ⁽⁵⁾
Sediment	GS / 2						
(pCi/kg dry)	Cs-134	150	< LLD	N/A	N/A	< LLD	0
(poling dry)	Cs-137	180	< LLD	N/A	N/A	< LLD	0
	GS / 2						
	Mn-54	130	< LLD	N/A	N/A	< LLD	o
	Co-58	130	< LLD	N/A	N/A	< LLD	o
Fish	Fe-59	260	< LLD	N/A	N/A	< LLD	0
(pCi/kg wet)	Co-60	130	< LLD	N/A	N/A	< LLD	0
	Zn-65	260	< LLD	N/A	N/A	< LLD	0
	Cs-134	130	< LLD	N/A	N/A	< LLD	0
	Cs-137	150	< LLD	N/A	N/A	< LLD	0
	GS / 8						
Food Products	I-131	60	< LLD	N/A	N/A	N/A	0
(pCi/kg wet)	Cs-134	60	< LLD	N/A	N/A	N/A	0
	Cs-137	80	< LLD	N/A	N/A	N/A	0

LEGEND:

⁽¹⁾- GB = Gross beta; I-131 = Iodine-131; H-3 = Tritium; GS = Gamma scan.

^{(2) -} LLD = Required lower limit of detection based on River Bend Station TRM.

^{(3) -} Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parenthesis (F).

^{(4) -} Locations are specified (1) by name and (2) direction relative to reactor site.

^{(5) -} Non-routine results are those which exceed ten times the control station value. If no control station value is available, the result is considered non-routine if it exceeds ten times the preoperational value for the location.

^{(6) -} LLD is not defined in River Bend Station TRM.

Plant: River Bend Station	Year: 2018	Page 26 of 45			
Annual Radiological Environmental Operating Report					

Page 1 of 1

Sample Deviations

Table 7: Sample Deviations Table

Comment No.	Sample Media Affected	Sample Location	Date	Problem	Evaluation / Actions
1	Air Sample	AN1 AP1	11/01/18	Power Outage	Environmental air samplers at locations AN1 and AP1 indicated a loss of power for approximately 6.1 hours. The power outage was due to a loss of power to Grant Substation on 11-1-18. All air samplers were operating normally at the time of sample collection. Sample volumes are sufficient to meet lower limit of detection requirements. (CR-RBS-2018-6124)
2	Air Sample	AGC	11/21/18	Power Outage	Environmental air sampler at location AGC (Zachary) indicated a loss of power for approximately 50 minutes on 11/21/18. The air sampler was operating normally at the time of sample collection. The sample volume is sufficient to meet the lower limit of detection requirements. (CR-RBS-2018-6429)

Plant: River Bend Station Y	rear: 2018	Page 27 of 45
Annual Radiological Environmental Ope	erating Rep	oort

Page 1 of 11

Table 8: Air Particulate Data Table

	Analys	is: Gross Beta	Particulate Date		pCi/m³
Start Date	End Date	AN1 ⁽¹⁾ (Indicator)	AP1 (Indicator)	AQS2 (Indicator)	AGC (Control)
REQUIRE	D LLD ⋺	<u>0.01</u>	<u>0.01</u>	<u>0.01</u>	<u>0.01</u>
12/26/2017	01/09/2018	0.027	0.029	0.031	0.028
01/09/2018	01/23/2018	0.020	0.019	0.019	0.019
01/23/2018	02/06/2018	0.017	0.018	0.017	0.017
02/06/2018	02/20/2018	0.013	0.014	0.014	0.012
02/20/2018	03/06/2018	0.013	0.012	0.011	0.011
03/06/2018	03/20/2018	0.019	0.019	0.019	0.023
03/20/2018	04/03/2018	0.019	0.018	0.016	0.019
04/03/2018	04/17/2018	0.020	0.021	0.019	0.020
04/17/2018	04/30/2018	0.017	0.018	0.015	0.018
04/30/2018	05/15/2018	0.028	0.027	0.026	0.027
05/15/2018	05/29/2018	0.019	0.017	0.021	0.019
05/29/2018	06/12/2018	0.020	0.018	0.019	0.020
06/12/2018	06/26/2018	0.014	0.016	0.014	0.014
06/26/2018	07/10/2018	0.017	0.015	0.015	0.015
07/10/2018	07/24/2018	0.020	0.019	0.018	0.021
07/24/2018	08/07/2018	0.021	0.022	0.021	0.021
08/07/2018	08/21/2018	0.017	0.015	0.015	0.016
08/21/2018	09/04/2018	0.016	0.016	0.017	0.015
09/04/2018	09/18/2018	0.011	0.010	0.008	0.008
09/18/2018	10/02/2018	0.011	0.011	0.011	0.011
10/02/2018	10/16/2018	0.019	0.018	0.018	0.019
10/16/2018	10/30/2018	0.024	0.026	0.024	0.018
10/30/2018	11/13/2018	0.020 ⁽²⁾	0.018 ⁽²⁾	0.018	0.020
11/13/2018	11/27/2018	0.025	0.025	0.024	0.027 ⁽³⁾
11/27/2018	12/11/2018	0.018	0.018	0.018	0.020
12/11/2018	12/26/2018	0.018	0.018	0.016	0.016

⁽¹⁾ Station with highest annual mean.

⁽²⁾ See Attachment 1, Table 7, Sample Deviations Table, Comment 1

⁽³⁾ See Attachment 1, Table 7, Sample Deviations Table, Comment 2

Plant: River Bend Station	Year: 2018	Page 28 of 45
Annual Radiological Environmental	Operating Re	port

Page 2 of 11

Monitoring Results Tables

Table 9: Radioiodine Cartridge Data Table

		lysis: I-131	une Cartridge		pCi/m ³
Start Date	End Date	AN1 (Indicator)	AP1 (Indicator)	AQS2 (Indicator)	AGC (Control)
REQUIRE	D LLD →	<u>0.07</u>	<u>0.07</u>	<u>0.07</u>	<u>0.07</u>
12/26/2017	01/09/2018	< 0.009	< 0.022	< 0.021	< 0.022
01/09/2018	01/23/2018	< 0.008	< 0.020	< 0.020	< 0,020
01/23/2018	02/06/2018	< 0.009	< 0.020	< 0.020	< 0.020
02/06/2018	02/20/2018	< 0.009	< 0.011	< 0.011	< 0.011
02/20/2018	03/06/2018	< 0.007	< 0.016	< 0.016	< 0.016
03/06/2018	03/20/2018	< 0.006	< 0.015	< 0.015	< 0.015
03/20/2018	04/03/2018	< 0.008	< 0.020	< 0.020	< 0.019
04/03/2018	04/17/2018	< 0.008	< 0.018	< 0.018	< 0.018
04/17/2018	04/30/2018	< 0.011	< 0.025	< 0.025	< 0.025
04/30/2018	05/15/2018	< 0.006	< 0.015	< 0.016	< 0.016
05/15/2018	05/29/2018	< 0.011	< 0.011	< 0.013	< 0.013
05/29/2018	06/12/2018	< 0.018	< 0.018	< 0.013	< 0.013
06/12/2018	06/26/2018	< 0.011	< 0.011	< 0.018	< 0.018
06/26/2018	07/10/2018	< 0.011	< 0.010	< 0.020	< 0.020
07/10/2018	07/24/2018	< 0.020	< 0.020	< 0.013	< 0.013
07/24/2018	08/07/2018	< 0.007	< 0.018	< 0.013	< 0.013
08/07/2018	08/21/2018	< 0.010	< 0.011	< 0.019	< 0.020
08/21/2018	09/04/2018	< 0.010	< 0.010	< 0.020	< 0.020
09/04/2018	09/18/2018	< 0.011	< 0.011	< 0.010	< 0.022
09/18/2018	10/02/2018	< 0.007	< 0.008	< 0.013	< 0.012
10/02/2018	10/16/2018	< 0.012	< 0.012	< 0.016	< 0.017
10/16/2018	10/30/2018	< 0.011	< 0.011	< 0.017	< 0.007
10/30/2018	11/13/2018	< 0.011 ⁽¹⁾	< 0.015 ⁽¹⁾	< 0.017	< 0.016
11/13/2018	11/27/2018	< 0.011	< 0.011	< 0.022	< 0.022 ⁽²⁾
11/27/2018	12/11/2018	< 0.010	< 0.009	< 0.020	< 0.019
12/11/2018	12/26/2018	< 0.013	< 0.013	< 0.012	< 0.013

⁽¹⁾ See Attachment 1, Table 7, Sample Deviations Table, Comment 1

⁽²⁾ See Attachment 1, Table 7, Sample Deviations Table, Comment 2

Plant: River Bend Station	Year: 2018	Page 29 of 45
Annual Radiological Envir	onmental Operating Report	

Page 3 of 11

Table 10: Thermoluminescent Dosimeters - Indicators

Ana	alysis: Gamma D	Oose	Units: mrem/Std. Qtr.		
Station	1 st Qtr 2018	2 nd Qtr 2018	3 rd Qtr 2018	4 th Qtr 2018	Annual Mean 2018
TA1	11.1	10.5	10.6	12.1	11.1
TB1	14.6	14.2	14.7	15.4	14.7
TC1	15.5	14.8	14.4	15.8	15.1
TD1	15.0	15.3	15.5	15.5	15.3
TE1	13.6	13.7	14.6	13.9	14.0
TF1	14.0	14.3	14.4	14.3	14.3
TG1 ⁽¹⁾	15.5	16.0	15.4	15.4	15.6
TH1	12.5	12.6	12.1	12.2	12.4
TJ1	12.8	13.8	17.7	13.3	14.4
TK1	13.8	13.9	13.7	14.1	13.9
TL1	14.0	14.7	14.2	14.6	14.4
TM1	12.9	12.5	11.6	13.2	12.5
TN1	13.9	14.6	13.6	14.1	14.1
TP1	13.0	13.9	12.8	13.2	13.2
TQ1	10.9	10.6	10.1	11.0	10.6
TR1	10.4	10.4	10.3	10.7	10.5

⁽¹⁾ Indicator station with highest annual mean.

Plant: River Bend Station	Year: 2018	Page 30 of 45
Annual Radiological Envir	onmental Operating Report	

Page 4 of 11

Table 11: Thermoluminescent Dosimeters – Special Interest Areas

Ana	Analysis: Gamma Dose			Units: mrem/Std. Qtr.		
Station	1 st Qtr 2018	2 nd Qtr 2018	3 rd Qtr 2018	4 th Qtr 2018	Annual Mean 2018	
TCS	12.7	12.5	12.1	12.7	12.5	
TGS ⁽¹⁾	14.3	15.8	15.6	15.5	15.3	
TNS	12.9	13.9	13.4	14.2	13.6	
TRS	13.9	15.1	13.8	14.4	14.3	
TQS1	14.2	15.4	15.1	15.4	15.0	
TQS2	13.0	12.9	12.2	12.9	12.7	

⁽¹⁾ Special interest station with highest annual mean.

Table 12: Thermoluminescent Dosimeters – Control

Analysis: Gamma Dose			Units: mrem/Std. Qtr.		
Station	.1 st Qtr 2018	2 nd Qtr 2018	3 rd Qtr 4 th Qtr Annual 2018 2018 201		
TAC ⁽¹⁾	14.9	15.4	15.4	15.8	15.4
TEC	13.9	13.9	13.7	14.2	13.9

⁽¹⁾ Control station with highest annual mean.

	Plant: River Bend Station	Year: 2018	Page 31 of 45
<u></u>	Annual Radiological Environmental Operating Report		
Attachment 2		Page	5 of 11

Monitoring Results Tables

Page 5 of 11

Table 13: Surface Water – Gamma

Analysis: Gamma Isotopic						Units: pCi/L								
Location	Start Date	End Date	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	I-131	Zr-95	Cs-134	Cs-137	Ba-140	La-140
	QUIRED LLI	<u>></u>	<u>15</u>	<u>15</u>	<u>30</u>	<u>15</u>	30	<u>15</u>	<u>15</u>	<u>30</u>	<u>15</u>	<u>18</u>	<u>60</u>	<u>15</u>
SWD (Indicator)	02/22/2018	02/22/2018	< 5.16	< 6.11	< 9.73	< 4.94	< 11.0	< 6.25	< 9.38	< 11.3	< 6.65	< 5.25	< 29.1	< 10.8
SWU (Control)	02/22/2018	02/22/2018	< 7.62	< 7.06	< 15.3	< 6.46	< 15.0	< 7.69	< 13.2	< 15.1	< 9.13	< 6.58	< 37.1	< 11.7
SWD (Indicator)	05/08/2018	05/08/2018	< 2.19	< 2.57	< 5.39	< 2.90	< 5.38	< 3.05	< 7.78	< 4.67	< 2.99	< 2.65	< 18.5	< 5.98
SWU (Control)	05/08/2018	05/08/2018	< 3.88	< 3.24	< 5.90	< 3.72	< 7.56	< 3.57	< 13.2	< 7.21	< 3.73	< 4.13	< 27.2	< 8.19
SWD (Indicator)	07/31/2018	07/31/2018	< 2.07	< 2.33	< 5.54	< 2.05	< 4.26	< 2.31	< 11.8	< 4.10	< 2.26	< 2.11	< 20.6	< 7.38
SWU (Control)	07/31/2018	07/31/2018	< 2.14	< 2.40	< 5.34	< 2.29	< 4.31	< 2.50	< 14.0	< 4.40	< 2.49	< 2.33	< 24.1	< 7.48
SWD (Indicator)	11/13/2018	11/13/2018	< 6.93	< 5.81	< 16.4	< 5.37	< 17.1	< 7.53	< 11.9	< 9.50	< 4.40	< 6.66	< 34.1	< 11.3
SWU (Control)	11/13/2018	11/13/2018	< 8.03	< 7.79	< 12.7	< 7.05	< 17.1	< 7.88	< 12.1	< 15.3	< 8.65	< 6.84	< 39.3	< 12.9

Plant: River Bend Station	Year: 2018	Page 32 of 45
Annual Radiological Envi	ronmental Operat	ting Report

Page 6 of 11

Table 14: Surface Water - Tritium

Analysis:	H-3	Units	: pCi/L
Location	Location Start Date		H-3
		REQUIRED LLD →	700
SWD (Indicator)	02/22/2018	02/22/2018	< 599
SWU (Control)	02/22/2018	02/22/2018	< 590
SWD (Indicator)	05/08/2018	05/08/2018	< 547
SWU (Control)	05/08/2018	05/08/2018	< 555
SWD (Indicator)	07/31/2018	07/31/2018	< 634
SWU (Control)	07/31/2018	07/31/2018	< 641
SWD (Indicator)	11/13/2018	11/13/2018	< 624
SWU (Control)	11/13/2018	11/13/2018	< 628

1			
	Plant: River Bend Station	Year: 2018	Page 33 of 45
	Annual Radiological Environmental Operating Report		

Page 7 of 11

Monitoring Results Tables

Table 15: Groundwater - Gamma

Analysis: Gamma Isotopic							Units: pCi/L						
Location	Collection Date	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	I-131	Zr-95	Cs-134	Cs-137	Ba-140	La-140
REQUIRE	D LLD →	<u>15</u>	<u>15</u>	30	<u>15</u>	<u>30</u>	<u>15</u>	<u>15</u>	<u>30</u>	<u>15</u>	<u>18</u>	<u>60</u>	<u>15</u>
WD (Indicator)	05/08/2018	< 1.62	< 1.77	< 3.96	< 1.80	< 3.39	< 1.90	< 5.61	< 3.26	< 1.80	< 1.76	< 11.9	< 3.93
WU (Control)	05/08/2018	< 1.39	< 1.51	< 3.25	< 1.41	< 2.79	< 1.62	< 4.88	< 2.70	< 1.54	< 1.54	< 10.8	< 3.48
WD (Indicator)	11/14/2018	< 5.02	< 4.27	< 11.7	< 4.67	< 10.2	< 5.57	< 12.1	< 11.0	< 5.53	< 5.14	< 29.1	< 9.57
WU (Control)	11/14/2018	< 4.77	< 5.16	< 11.0	< 5.38	< 12.6	< 5.94	< 14.0	< 10.1	< 5.85	< 5.71	< 36.9	< 10.8

Plant: River Bend Station	Year: 2018	Page 34 of 45						
Annual Radiological Environmental Operating Report								
A441- 1.0								

Page 8 of 11

Table 16: Groundwater - Tritium

Analysis: l	1-3	Units: pCi/L			
Location	Start Date	End Date	H-3		
		REQUIRED LLD →	700		
WD (Indicator)	05/08/2018	05/08/2018	< 553		
WU (Control)	05/08/2018	05/08/2018	< 553		
WD (Indicator)	11/14/2018	11/14/2018	< 586		
WU (Control)	11/14/2018	11/14/2018	< 596		

Plant: River Bend Station	Year: 2018	Page 35 of 45
Annual Radiological Environn	nental Operatin	g Report

Page 9 of 11

Monitoring Results Tables

Table 17: Sediment - Gamma

Analysis: Gar	nma Isotopic	Units: pCi/kg (dry)			
Location	Collection Date	Cs-134	Cs-137		
	REQUIRED LLD →	<u>150</u>	180		
SEDD (Indicator)	08/16/2018	< 57.01	< 50.72		
SEDU (Control)	08/16/2018	< 87.49	< 66.75		

Plant: River Bend Station	Year: 2018	Page 36 of 45							
Annual Radiological Environme	Annual Radiological Environmental Operating Report								

Page 10 of 11

Table 18: Fish - Gamma

A	nalysis: Gan	nma Isotop	ic	Units: pCi/kg (wet)					
Location	Collection Date	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Cs-134	Cs-137	
REQUI	RED LLD →	<u>130</u>	<u>130</u>	<u>260</u>	130	<u>260</u>	<u>130</u>	<u>150</u>	
FD (Indicator)	09/24/2018	< 24.66	< 25.51	< 74.39	< 34.01	< 66.74	< 33.38	< 32.99	
FU (Control)	09/24/2018	< 49.73	< 52.67	< 115.0	< 42.44	< 133.6	< 35.62	< 43.32	

Plant: River Bend Station	Year: 2018	Page 37 of 45
Annual Radiological Env	vironmental Operating Report	t

Page 11 of 11

Table 19: Food Products - Gamma

Analysis: Ga	mma Isotopic	Units: pCi/kg (wet)					
Location	Collection Date	I-131	Cs-134	Cs-137			
	REQUIRED LLD →	60	60	80			
GN1 (Indicator)	03/08/2018	< 51.45	< 21.20	< 19.47			
GQC (Control)	03/12/2018	< 49.20	< 23.98	< 27.57			
GN1 (Indicator)	06/04/2018	< 30.33	< 10.08	< 9.025			
GQC (Control)	06/11/2018	< 24.37	< 17.33	< 13.90			
GN1 (Indicator)	08/14/2018	< 32.68	< 9.072	< 8.673			
GQC (Control)	08/16/2018	< 48.65	< 19.78	< 19.94			
GN1 (Indicator)	11/14/2018	< 57.49	< 23.79	< 24.73			
GQC (Control)	11/14/2018	< 13.73	< 5.935	< 5.393			

Plant: River Bend Station	Year: 2018	Page 38 of 45					
Annual Radiological Environmental Operating Report							

Page 1 of 8

Interlaboratory Comparison Program Results

1.0 Summary

For the Teledyne Brown Engineering (TBE) laboratory, 166 out of 172 analyses performed met the specified acceptance criteria. Six analyses did not meet the specified acceptance criteria for the following reasons and were addressed through the TBE Corrective Action Program.

Note: The Department of Energy (DOE) Mixed Analyte Performance Evaluation Program (MAPEP) samples are created to mimic conditions found at DOE sites which do not resemble typical environmental samples obtained at commercial nuclear power facilities.

- 1. TBE was unable to report the February 2018 DOE MAPEP vegetation Sr-90 result due to QC failure and limited sample amount. (NCR 18-09)
- 2. The Analytics September 2018 milk Fe-59 result was evaluated as Not Acceptable (Ratio of TBE to known result at 132%). The reported value was 158 ± 17.6 pCi/L and the known value was 119 ± 19.9 pCi/L. No cause for the failure could be determined. TBE has passed 24 of the previous 27 milk cross-check results since 2012. This sample was run in duplicate on a different detector with comparable results (162 +/- 16 pCi/L). NOTE: TBE's 4th Qtr result passed at 105% (NCR 18-20)
- 3. The Analytics September milk I-131 result was evaluated as Not Acceptable (Ratio of TBE to known result at 143%). Due to a personnel change in the gamma prep lab, the sample was not prepped/counted in a timely manner such as to accommodate the I-131 8-day half-life. Analysts have been made aware of the urgency for this analysis and it will be monitored more closely by QA. NOTE: TBE's 4th Qtr result passed at 101% (NCR 18-24)
- 4. The Analytics September soil Cr-51 result was evaluated as Not Acceptable (Ratio of TBE to known result at 131%). As with #3 above, the sample was not prepped/counted in a timely manner such as to accommodate the Cr-51 27-day half-life. The same corrective action applies here as in #3. (NCR 18-21)
- 5. The MAPEP November vegetation Sr-90 result of 0.338 Bq/sample was evaluated as Not Acceptable (Lower acceptable range was 0.554 Bq/sample). It appears that there has been incomplete dissolution of Sr-90 due to the composition of the MAPEP vegetation "matrix". To resolve this issue, the TBE-2018 procedure has been modified to add H2O2 to assist in breaking down the organic material that comprises this "matrix". This corrective action will be monitored closely by QA. (NCR 18-25).

Plant: River Bend Station	Year: 2018	Page 39 of 45					
Annual Radiological Environmental Operating Report							

Page 2 of 8

Interlaboratory Comparison Program Results

6. The ERA October 2018 water Sr-90 sample was evaluated as Not Acceptable. TBE's initial reported result of 36.8 pCi/L exceeded the upper acceptance range (22.9 – 36.4 pCi/L). After reviewing the data for this sample, it was discovered that there was a typographical error at the time the results were entered at the ERA website. The correct result in LIMS of 36.2 should have been submitted instead. This result is within ERA's acceptance limits. In addition to the typo error, ERA's very stringent upper acceptance limit of 116% is not a reflection of TBE's ability to successfully perform this analysis. (NCR 18-23)

The Inter-Laboratory Comparison Program provides evidence of "in control" counting systems and methods, and that the laboratories are producing accurate and reliable data.

Plant: River Bend Station	Year: 2018	Page 40 of 45					
Annual Radiological Environmental Operating Report							

Page 3 of 8

Table 20: Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering Environmental Services

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Reported Value	Known Value ^(a)	Ratio of TBE to Analytics Result	Evaluation (b)
March 2018	E12133	Milk	Sr-89	pCi/L	76.1	90.1	0.84	A
			Sr-90	pCi/L	12.2	12.5	0.98	Α
	E12134	Milk	Ce-141	pCi/L	77.8	77.0	1.01	Α
			Co-58	pCi/L	105	114	0.92	Α
			Co-60	pCi/L	181	187	0.97	Α
			Cr-51	pCi/L	298	326	0.92	Α
			Cs-134	pCi/L	150	180	0.84	Α
			Cs-137	pCi/L	164	172	0.95	Α
			Fe-59	pCi/L	140	139	1.01	Α
			I-131	pCi/L	105	108.0	0.97	Α
			Mn-54	pCi/L	133	131	1.01	Α
			Zn-65	pCi/L	242	244	0.99	Α
	E12135	Charcoal	I-131	pCi	93.7	95.4	0.98	Α .
	E12136	AP	Ce-141	pCi	92.6	85.3	1.09	А
			Co-58	рСі	130	126	1.03	Α
			Co-60	ˈpCi	237	207	1.14	Α
			Cr-51	pCi	411	361	1.14	Α
			Cs-134	pCi	194	199	0.98	Α
			Cs-137	pCi	200	191	1.05	· A
			Fe-59	pCi	160	154	1.04	Α
			Mn-54	pCi	152	145	1.05	Α
			Zn-65	pCi	267	271	0.99	Α
	E12137	Water	Fe-55	pCi/L	1990	1700	1.17	Α
	E12138	Soil	Ce-141	pCi/g	0.148	0.118	1.26	W
			Co-58	pCi/g	0.171	0.174	0.98	Α
			Co-60	pCi/g	0.297	0.286	1.04	Α
			Cr-51	pCi/g	0.537	0.498	1.08	Α
			Cs-134	pCi/g	0.274	0.275	1.00	Α
			Cs-137	pCi/g	0.355	0.337	1.05	Α
			Fe-59	pCi/g	0.243	0.212	1.15	Α
			Mn-54	pCi/g	0.228	0.201	1.14	Α
			Zn-65	pCi/g	0.395	0.374	1.06	Α

⁽a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

⁽b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

 $W = Acceptable \ with \ warning - reported \ result \ falls \ within \ 0.70-0.80 \ or \ 1.20-1.30$

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

Plant: River Bend Station	Year: 2018	Page 41 of 45				
Annual Radiological Environmental Operating Report						

Page 4 of 8

Table 20: Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering Environmental Services

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Reported Value	Known Value ^(a)	Ratio of TBE to Analytics Result	Evaluation ^{(t}
June 2018	E12205	Milk	Sr-89	pCi/L	74.9	84.6	0.89	Α
			Sr-90	pCi/L	10.5	11.4	0.92	Α
	E12206	Milk	Ce-141	pCi/L	89.2	82.2	1.08	Α
			Co-58	pCi/L	94.8	89	1.07	Α
			Co-60	pCi/L	125	113	1.10	Α
			Cr-51	pCi/L	256	239	1.07	Α
			Cs-134	pCi/L	112	114	0.99	Α
			Cs-137	pCi/L	107	98.8	1.08	Α
			Fe-59	pCi/L	95.9	86.0	1.12	Α
			I-131	pCi/L	69.8	71.9	0.97	Α
			Mn-54	pCi/L	138	130	1.06	Α
			Zn-65	pCi/L	186	157	1.18	Α
	E12207	Charcoal	I-131	pCi	69.6	72.2	0.96	Α
	E12208	AP	Ce-141	pCi	151	165	0.92	Α
			Co-58	pCi	174	178	0.98	Α
	-		Co-60	pCi	290	227	1.28	W
			Cr-51	pCi	452	478	0.95	Α
			Cs-134	pCi	215	227	0.95	Α
			Cs-137	pCi	206	198	1.04	Α
			Fe-59	pCi	180	172	1.05	Α
			Mn-54	pCi	265	260	1.02	Α
			Zn-65	pCi	280	315	0.89	Α
	E12209	Water	Fe-55	pCi/L	1790	1740	1.03	Α
	E12210	AP	Sr-89	pCi	77.8	90.3	0.86	Α
			Sr-90	pCi	9.54	12.2	0.78	W

⁽a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

⁽b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

Plant: River Bend Station	Year: 2018	Page 42 of 45					
Annual Radiological Environmental Operating Report							

Page 5 of 8

Table 20: Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering Environmental Services

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Reported Value	Known Value ^(a)	Ratio of TBE to Analytics Result	Evaluation ^(b)
September 2018	E12271	Milk	Sr-89	pCi/L	79.4	81.7	0.97	Α
			Sr-90	pCi/L	12.2	14.8	0.82	Α
	E12272	Milk	Ce-141	pCi/L	152	128	1.19	Α
			Co-58	pCi/L	161	144	1.12	Α
			Co-60	pCi/L	208	190	1.10	Α
			Cr-51	pCi/L	244	265	0.92	Α
			Cs-134	pCi/L	124	123	1.01	Α
			Cs-137	pCi/L	166	147	1.13	Α
			Fe-59	pCi/L	158	119	1.32	N ⁽¹⁾
•			I-131	pCi/L	83.1	58.2	1.43	N ⁽²⁾
			Mn-54	pCi/L	191	167	1.14	Α
			Zn-65	pCi/L	229	201	1.14	Α
	E12273	Charcoal	I-131	pCi	83.0	80.7	1.03	Α
	E12274	AP	Ce-141	pCi	101	85.6	1.18	Α
			Co-58	рСі	92.7	96.0	0.97	Α
			Co-60	pCi	142	127	1.12	Α
			Cr-51	pCi	218	177	1.23	W
			Cs-134	pCi	81.2	81.9	0.99	Α
			Cs-137	pCi	99.0	98.5	1.01	Α
			Fe-59	pCi	93.7	79.7	1.18	Α
			Mn-54	pCi	116	112	1.04	Α
			Zn-65	pCi	139	134	1.04	Α
	E12302	Water	Fe-55	pCi/L	2120	1820	1.17	Α
	E12276	Soil	Ce-141	pCi/g	0.259	0.221	1.17	Α
			Co-58	pCi/g	0.279	0.248	1.12	Α
			Co-60	pCi/g	0.367	0.328	1.12	Α
			Cr-51	pCi/g	0.597	0.457	1.31	N ⁽³⁾
			Cs-134	pCi/g	0.261	0.212	1.23	W
			Cs-137	pCi/g	0.376	0.330	1.14	Α
			Fe-59	pCi/g	0.248	0.206	1.20	Α
			Mn-54	pCi/g	0.317	0.289	1.10	Α
			Zn-65	pCi/g	0.407	0.347	1.17	Α

⁽a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

⁽b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

 $N = Not \ Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30$

⁽¹⁾ See NCR 18-20

⁽²⁾ See NCR 18-24

⁽³⁾ See NCR 18-21

Plant: River Bend Station	Year: 2018	Page 43 of 45					
Annual Radiological Environmental Operating Report							

Page 6 of 8

Table 20: Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering Environmental Services

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Reported Value	Known Value ^(a)	Ratio of TBE to Analytics Result	Evaluation ^(b)
December 2018	E12313	Milk	Sr-89	pCi/L	71.9	91.9	0.78	W
			Sr-90	pCi/L	12.1	13.3	0.91	Α
	E12314	Milk	Ce-141	pCi/L	124	133	0.93	Α
			Co-58	pCi/L	110	119	0.93	Α
			Co-60	pCi/L	202	212	0.95	Α
			Cr-51	pCi/L	292	298	0.98	Α
			Cs-134	pCi/L	146	171	0.85	Α
			Cs-137	pCi/L	118	121	0.98	Α
			Fe-59	pCi/L	120	114	1.05	Α
			I-131	pCi/L	94.2	93.3	1.01	Α
			Mn-54	pCi/L	151	154	0.98	Α
			Zn-65	pCi/L	266	264	1.01	Α
	E12315	Charcoal	I-131	pCi	94.8	89.9	1.05	Α
	E12316A	AP	Ce-141	pCi	92.3	94.0	0.98	Α
			Co-58	pCi	73.4	83.8	0.88	Α
			Co-60	pCi	137	150	0.91	Α
			Cr-51	pCi	202	210	0.96	Α
			Cs-134	pCi	115	121	0.95	Α
			Cs-137	pCi	85.0	85.4	1.00	Α
			Fe-59	pCi	83.1	80.8	1.03	Α
			Mn-54	pCi	104	109	0.96	Α
			Zn-65	pCi	168	187	0.90	Α
	E12317	Water	Fe-55	pCi/L	2110	1840	1.15	Α
	E12318	AP	Sr-89	рСі	81.1	83.0	0.98	Α
			Sr-90	pCi	11.4	12.0	0.95	Α

⁽a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

⁽b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

Plant: River Bend Station	Year: 2018	Page 44 of 45						
Annual Radiological Environmental Operating Report								

Page 7 of 8

Table 21: DOE's Mixed Analyte Performance Evaluation Program (MAPEP)

Teledyne Brown Engineering Environmental Services

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Reported Value	Known Value ^(a)	Acceptance Range	Evaluation (b)
February 2018	18-MaS38	Soil	Ni-63	Bq/kg	9.94		(1)	А
			Sr-90	Bq/kg	0.846		(1)	Α
	18-MaW38	Water	Am-241	Bq/L	0.785	0.709	0.496 - 0.922	Α
			Ni-63	Bq/L	12.6	14.0	9.8 - 18.2	Α
			Pu-238	Bq/L	0.0214	0.023	(2)	Α
			Pu-239/240	Bq/L	0.544	0.600	0.420 - 0.780	Α
	18-RdF38	AP	U-234/233	Bq/sample	0.111	0.124	0.087 - 0.161	Α
			U-238	Bq/sample	0.123	0.128	0.090 - 0.166	Α
	18-RdV38	Vegetation	Cs-134	Bq/sample	2.46	3.23	2.26 - 4.20	W
			Cs-137	Bq/sample	3.14	3.67	2.57 - 4.77	Α
			Co-57	Bq/sample	4.12	4.42	3.09 - 5.75	Α
			Co-60	Bq/sample	1.86	2.29	1.60 - 2.98	Α
			Mn-54	Bq/sample	2.21	2.66	1.86 - 3.46	Α
			Sr-90	Bq/sample				NR ⁽³⁾
			Zn-65	Bq/sample	-0.201		(1)	Α
November 2018	18-MaS39	Soil	Ni-63	Bq/kg	703	765	536 - 995	Α
			Sr-90	Bq/kg	137	193	135 - 251	W
	18-MaW39	Water	Am-241	Bq/L	0.0363		(1)	Α
			Ni-63	Bq/L	6.18	7.0	4.9 - 9.1	Α
			Pu-238	Bq/L	0.73	0.674	0.472 - 0.876	Α
	,		Pu-239/240	Bq/L	0.89	0.928	0.650 - 1.206	Α
	18-RdF39	AP	U-234/233	Bq/sample	0.159	0.152	0.106 - 0.198	Α
			U-238	Bq/sample	0.162	0.158	0.111 - 0.205	Α
	18-RdV39	Vegetation	Cs-134	Bq/sample	1.85	1.94	1.36 - 2.52	Α
			Cs-137	Bq/sample	2.5	2.36	1.65 - 3.07	Α
			Co-57	Bq/sample	3.53	3.31	2.32 - 4.30	Α
			Co-60	Bq/sample	1.6	1.68	1.18 - 2.18	Α
•			Mn-54	Bq/sample	2.61	2.53	1.77 - 3.29	Α
			Sr-90	Bq/sample	0.338	0.791	0.554 - 1.028	N ⁽⁴⁾
			Zn-65	Bq/sample	1.32	1.37	0.96 - 1.78	Α

⁽a) The MAPEP known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

⁽b) DOE/MAPEP evaluation:

A = Acceptable - reported result falls within ratio limits of 0.80-1,20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

NR = No result reported

⁽¹⁾ False positive test

⁽²⁾ Sensitivity evaluation

⁽³⁾ See NCR 18-09

⁽⁴⁾ See NCR 18-25

Plant: River Bend Station	Year: 2018	Page 45 of 45						
Annual Radiological Environme	Annual Radiological Environmental Operating Report							

Page 8 of 8

Table 22: ERA Environmental Radioactivity Cross Check Program Teledyne Brown Engineering Environmental Services

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Reported Value	Known Value ^(a)	Acceptance Limits	Evaluation ^{(b}
March 2018	MRAD-28	AP	GR-A	pCi/sample	65.7	43.4	22.7 - 71.5	A
			GR-B	pCi/sample	57.2	52	31.5 - 78.6	Α
April 2018	RAD-113	Water	Ba-133	pCi/L	91.2	91.5	77.1 - 101	Α
			Cs-134	pCi/L	70.4	75.9	62.0 - 83.5	Α
			Cs-137	pCi/L	122	123	111 - 138	Α
			Co-60	pCi/L	64.8	64.3	57.9 - 73.2	Α
			Zn-65	pCi/L	98.6	86.7	78.0 - 104	Α
			GR-A	pCi/L	32.8	28.6	14.6 - 37.5	Α
			GR-B	pCi/L	62.9	73.7	51.4 - 81.1	Α
			U-Nat	pCi/L	6.7	6.93	5.28 - 8.13	Α
			H-3	pCi/L	17100	17200	15000 - 18900	Α
			Sr-89	pCi/L	38.6	48.8	38.3 - 56.2	Α
			Sr-90	pCi/L	27.1	26.5	19.2 - 30.9	Α
			I-131	pCi/L	26.7	24.6	20.4 - 29.1	Α
September 2018	MRAD-29	AP	GR-A	pCi/sample	49.7	55.3	28.9 - 91.1	Α
		AP	GR-B	pCi/sample	75.3	86.5	52.4 - 131	Α
October 2018	RAD-115	Water	Ba-133	pCi/L	15.2	16.3	11.9 - 19.4	Α
			Cs-134	pCi/L	85.9	93.0	76.4 - 102	Α
			Cs-137	pCi/L	229	235	212 - 260	Α
			Co-60	pCi/L	81.9	80.7	72.6 - 91.1	Α
			Zn-65	pCi/L	348	336	302 - 392	A
			GR-A	pCi/L	38.9	60.7	31.8 - 75.4	A
			GR-B	pCi/L	36.5	41.8		
			U-Nat				27.9 - 49.2	A
				pCi/L	17.48	20.9	16.8 - 23.4	A
			H-3	pCi/L	2790	2870	2410 - 3170	Α
			I-131	pCi/L	26.9	27.2	22.6 - 32.0	Α
			Sr-89	pCi/L	57.2	56.9	45.5 - 64.6	A
			Sr-90	pCi/L	36.8	31.4	22.9- 36.4	N ⁽¹⁾

⁽a) The ERA known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.

⁽b) ERA evaluation:

A = Acceptable - Reported value falls within the Acceptance Limits

N = Not Acceptable - Reported value falls outside of the Acceptance Limits

⁽¹⁾ See NCR 18-23