

### LIST OF REGULATORY COMMITMENTS

The following table identifies those actions identified as regulatory commitments by Ameren Missouri in this document. Any other statements in this submittal are provided for information purposes and are not considered to be regulatory commitments. Please direct questions regarding these commitments to Bruce Huhman at (573) 694-6741.

<b>Regulatory Commitments and Completion Schedule</b>		
<b>Modification</b>	<b>Completion Date</b>	<b>Commitment Tracking Number</b>
Install Anchorage to the Alternate Emergency Power Supply transformer (XPB05).	December 31, 2020	50431
Provide a minimum of 1-inch clearance around two fire sprinkler heads located on the 1974' elevation of the control building at grid C4 & CC, and grid C2 & CB.	December 31, 2020	50432