

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 5, Second Renewal

Regarding Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4

Final Report

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Library at www.nrc.gov/reading-rm.html. Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and Title 10, "Energy," in the *Code of Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents

U.S. Government Publishing Office
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: (202) 512-1800
Fax: (202) 512-2104

2. The National Technical Information Service

5301 Shawnee Road
Alexandria, VA 22312-0002
www.ntis.gov
1-800-553-6847 or, locally, (703) 605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: **U.S. Nuclear Regulatory Commission**
Office of Administration
Multimedia, Graphics, and Storage &
Distribution Branch
Washington, DC 20555-0001
E-mail: distribution.resource@nrc.gov
Facsimile: (301) 415-2289

Some publications in the NUREG series that are posted at NRC's Web site address www.nrc.gov/reading-rm/doc-collections/nuregs are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library

Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute

11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
(212) 642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

DISCLAIMER: This report was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product, or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 5, Second Renewal

Regarding Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4

Final Report

Manuscript Completed: October 2019
Date Published: October 2019

COVER SHEET

Responsible Agency: U.S. Nuclear Regulatory Commission, Office of Nuclear Reactor Regulation. The U.S. National Park Service, Southeast Region, is a cooperating agency.

Title: Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 5, Second Renewal, Regarding Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4, Final Report (NUREG–1437). Turkey Point Nuclear Generating Unit Nos. 3 and 4 are located on the southeastern coast of Florida in unincorporated southeastern Miami-Dade County.

For additional information or copies of this document contact:

U.S. Nuclear Regulatory Commission, Office of Nuclear Reactor Regulation
11555 Rockville Pike, Mail Stop O-11F1
Rockville, MD 20852
Email: William.Burton@nrc.gov

ABSTRACT

The U.S. Nuclear Regulatory Commission (NRC) staff prepared this supplemental environmental impact statement (SEIS) as part of its environmental review of Florida Power & Light Company's subsequent license renewal application, to renew the operating licenses for Turkey Point Nuclear Generating Unit Nos. 3 and 4 (Turkey Point or Turkey Point Units 3 and 4) for an additional 20 years. This SEIS includes the NRC staff's evaluation of the environmental impacts of the subsequent license renewal as well as alternatives to subsequent license renewal. Alternatives to subsequent license renewal considered in this SEIS include: (1) a new nuclear power plant, (2) a new natural gas combined-cycle power plant, and (3) the combination of a new natural gas combined-cycle power plant and new solar photovoltaic power generation. In addition to replacement power alternatives, this SEIS evaluates an alternative cooling water system to mitigate potential impacts associated with the continued use of the existing cooling canal system. The NRC staff's recommendation is that the adverse environmental impacts of subsequent license renewal for Turkey Point are not so great that preserving the option of subsequent license renewal for energy-planning decisionmakers would be unreasonable. The NRC staff based its recommendation on the following:

- the analysis and findings in NUREG–1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants"
- the environmental report submitted by Florida Power & Light Company
- the NRC staff's consultation with Federal, State, Tribal, and local government agencies
- the NRC staff's independent environmental review
- the NRC staff's consideration of public comments received during the scoping process
- the NRC staff's consideration of public comments received on the draft SEIS

TABLE OF CONTENTS

ABSTRACT	iii
TABLE OF CONTENTS	v
LIST OF FIGURES	xi
LIST OF TABLES	xiii
EXECUTIVE SUMMARY	xv
ABBREVIATIONS AND ACRONYMS	xxi
1 INTRODUCTION	1-1
1.1 Proposed Federal Action	1-1
1.2 Purpose and Need for the Proposed Federal Action	1-1
1.3 Major Environmental Review Milestones	1-2
1.4 Generic Environmental Impact Statement	1-3
1.5 Supplemental Environmental Impact Statement	1-5
1.6 Decisions To Be Supported by the SEIS	1-6
1.7 Cooperating Agencies	1-6
1.8 Consultations	1-7
1.9 Correspondence	1-8
1.10 Status of Compliance	1-8
1.11 Related State and Federal Activities	1-8
2 ALTERNATIVES INCLUDING THE PROPOSED ACTION	2-1
2.1 Proposed Action	2-1
2.1.1 Plant Operations during the Subsequent License Renewal Term	2-2
2.1.2 Refurbishment and Other Activities Associated with Subsequent License Renewal	2-2
2.1.3 Termination of Nuclear Power Plant Operations and Decommissioning after the Subsequent License Renewal Term	2-3
2.2 Alternatives	2-3
2.2.1 No-Action Alternative	2-4
2.2.2 Replacement Power Alternatives	2-5
2.2.3 Cooling Water System Alternative	2-13
2.3 Alternatives Considered but Eliminated	2-14
2.3.1 Solar Power	2-14
2.3.2 Wind Power	2-15
2.3.3 Biomass Power	2-15
2.3.4 Demand-Side Management	2-16
2.3.5 Hydroelectric Power	2-16
2.3.6 Geothermal Power	2-17
2.3.7 Wave and Ocean Energy	2-17
2.3.8 Municipal Solid Waste	2-18
2.3.9 Petroleum-Fired Power	2-18

2.3.10	Coal-Fired Power	2-19
2.3.11	Fuel Cells	2-20
2.3.12	Purchased Power	2-20
2.3.13	Delayed Retirement	2-21
2.4	Comparison of Alternatives	2-21
3	AFFECTED ENVIRONMENT	3-1
3.1	Description of Nuclear Power Plant Facility and Operation.....	3-1
3.1.1	External Appearance and Setting	3-1
3.1.2	Nuclear Reactor Systems	3-3
3.1.3	Cooling and Auxiliary Water Systems	3-3
3.1.4	Radioactive Waste Management Systems.....	3-12
3.1.5	Nonradioactive Waste Management Systems	3-19
3.1.6	Utility and Transportation Infrastructure	3-20
3.1.7	Nuclear Power Plant Operations and Maintenance	3-22
3.2	Land Use and Visual Resources.....	3-23
3.2.1	Land Use	3-23
3.2.2	Visual Resources	3-24
3.3	Meteorology, Air Quality, and Noise	3-25
3.3.1	Meteorology and Climatology	3-25
3.3.2	Air Quality	3-25
3.3.3	Noise	3-28
3.4	Geologic Environment.....	3-29
3.4.1	Physiography, Geology, and Soils.....	3-29
3.4.2	Economic Resources	3-29
3.4.3	Seismic Setting	3-30
3.5	Water Resources.....	3-31
3.5.1	Surface Water	3-32
3.5.2	Groundwater Resources	3-65
3.6	Terrestrial Resources.....	3-107
3.6.1	Vegetative Communities	3-107
3.6.2	Marsh, Mangrove, and Tree Island Semiannual Monitoring	3-108
3.6.3	Wildlife	3-116
3.6.4	Important Species and Habitats.....	3-117
3.6.5	Invasive and Non-Native Species.....	3-121
3.7	Aquatic Resources	3-121
3.7.1	Southern Florida Coastal Plain Ecoregion	3-121
3.7.2	Aquatic Resources near the Turkey Point Site.....	3-122
3.7.3	Aquatic Resources on the Turkey Point Site.....	3-123
3.7.4	Biscayne Bay and Card Sound Semiannual Monitoring	3-129
3.7.5	Additional Information on Aquatic Resources	3-140

3.8	Special Status Species and Habitats	3-140
3.8.1	Federally Listed Species and Critical Habitats Protected Under the Endangered Species Act	3-141
3.8.2	Essential Fish Habitat Protected under the Magnuson–Stevens Act	3-149
3.8.3	Marine Sanctuary Resources Protected Under the National Marine Sanctuaries Act	3-150
3.9	Historic and Cultural Resources	3-153
3.9.1	Cultural Background	3-153
3.9.2	Historic and Cultural Resources at Turkey Point	3-154
3.10	Socioeconomics	3-155
3.10.1	Power Plant Employment	3-156
3.10.2	Regional Economic Characteristics	3-156
3.10.3	Demographic Characteristics	3-158
3.10.4	Housing and Community Services	3-162
3.10.5	Tax Revenues	3-164
3.10.6	Local Transportation	3-165
3.11	Human Health	3-166
3.11.1	Radiological Exposure and Risk	3-166
3.11.2	Chemical Hazards	3-168
3.11.3	Microbiological Hazards	3-168
3.11.4	Electromagnetic Fields	3-168
3.11.5	Other Hazards	3-169
3.12	Environmental Justice	3-169
3.13	Waste Management and Pollution Prevention	3-175
3.13.1	Radioactive Waste	3-175
3.13.2	Nonradioactive Waste	3-175
4	ENVIRONMENTAL CONSEQUENCES AND MITIGATING ACTIONS	4-1
4.1	Introduction	4-1
4.2	Land Use and Visual Resources	4-7
4.2.1	Proposed Action	4-7
4.2.2	No-Action Alternative	4-8
4.2.3	Replacement Power Alternatives: Common Impacts	4-8
4.2.4	New Nuclear Alternative	4-9
4.2.5	Natural Gas Combined-Cycle Alternative	4-10
4.2.6	Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)	4-11
4.2.7	Cooling Water System Alternative	4-12
4.3	Air Quality and Noise	4-12
4.3.1	Proposed Action	4-12
4.3.2	No-Action Alternative	4-13
4.3.3	Replacement Power Alternatives: Common Impacts	4-13
4.3.4	New Nuclear Alternative	4-14

4.3.5	Natural Gas Combined-Cycle Alternative.....	4-16
4.3.6	Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)	4-17
4.3.7	Cooling Water System Alternative.....	4-18
4.4	Geologic Environment.....	4-20
4.4.1	Proposed Action.....	4-20
4.4.2	No-Action Alternative	4-20
4.4.3	Replacement Power Alternatives: Common Impacts.....	4-20
4.4.4	New Nuclear Alternative	4-21
4.4.5	Natural Gas Combined-Cycle Alternative.....	4-21
4.4.6	Combination Natural Gas Combined-Cycle and Solar Photovoltaic Alternative	4-21
4.4.7	Cooling Water System Alternative.....	4-21
4.5	Water Resources.....	4-21
4.5.1	Proposed Action.....	4-21
4.5.2	No-Action Alternative	4-36
4.5.3	Replacement Power Alternatives: Common Impacts.....	4-38
4.5.4	New Nuclear Alternative	4-41
4.5.5	Natural Gas Combined-Cycle Alternative.....	4-41
4.5.6	Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)	4-42
4.5.7	Cooling Water System Alternative.....	4-43
4.6	Terrestrial Resources	4-44
4.6.1	Proposed Action.....	4-45
4.6.2	No-Action Alternative	4-49
4.6.3	Replacement Power Alternatives: Common Impacts.....	4-49
4.6.4	New Nuclear Alternative	4-50
4.6.5	Natural Gas Combined-Cycle Alternative.....	4-50
4.6.6	Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)	4-51
4.6.7	Cooling Water System Alternative.....	4-51
4.7	Aquatic Resources	4-52
4.7.1	Proposed Action.....	4-52
4.7.2	No-Action Alternative	4-60
4.7.3	Replacement Power Alternatives: Common Impacts.....	4-60
4.7.4	New Nuclear Alternative	4-62
4.7.5	Natural Gas Combined-Cycle Alternative.....	4-62
4.7.6	Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)	4-63
4.7.7	Cooling Water System Alternative.....	4-63
4.8	Special Status Species and Habitats	4-63
4.8.1	Proposed Action.....	4-63

4.8.2	No-Action Alternative	4-79
4.8.3	Replacement Power Alternatives: Common Impacts.....	4-80
4.9	Historic and Cultural Resources.....	4-83
4.9.1	Proposed Action.....	4-83
4.9.2	No-Action Alternative	4-86
4.9.3	Replacement Power Alternatives: Common Impacts.....	4-86
4.9.4	Cooling Water System Alternative.....	4-88
4.10	Socioeconomics	4-89
4.10.1	Proposed Action.....	4-89
4.10.2	No-Action Alternative	4-90
4.10.3	Replacement Power Alternatives: Common Impacts.....	4-90
4.10.4	New Nuclear Alternative	4-92
4.10.5	Natural Gas Combined-Cycle Alternative.....	4-93
4.10.6	Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)	4-94
4.10.7	Cooling Water System Alternative.....	4-95
4.11	Human Health.....	4-96
4.11.1	Proposed Action.....	4-96
4.11.2	No-Action Alternative	4-99
4.11.3	Replacement Power Alternatives: Common Impacts.....	4-99
4.11.4	New Nuclear Alternative	4-99
4.11.5	Natural Gas Combined-Cycle Alternative.....	4-100
4.11.6	Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)	4-100
4.11.7	Cooling Water System Alternative.....	4-101
4.12	Environmental Justice	4-101
4.12.1	Proposed Action.....	4-101
4.12.2	No-Action Alternative	4-104
4.12.3	Replacement Power Alternatives: Common Impacts.....	4-104
4.12.4	Cooling Water System Alternative.....	4-107
4.13	Waste Management	4-108
4.13.1	Proposed Action.....	4-108
4.13.2	No-Action Alternative	4-108
4.13.3	Replacement Power Alternatives: Common Impacts.....	4-108
4.13.4	New Nuclear Alternative	4-108
4.13.5	Natural Gas Combined-Cycle Alternative.....	4-109
4.13.6	Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)	4-109
4.13.7	Cooling Water System Alternative.....	4-110
4.14	Evaluation of New and Significant Information	4-110
4.15	Impacts Common to All Alternatives	4-112
4.15.1	Fuel Cycle	4-112

4.15.2	Terminating Power Plant Operations and Decommissioning.....	4-113
4.15.3	Greenhouse Gas Emissions and Climate Change.....	4-114
4.16	Cumulative Impacts.....	4-125
4.16.1	Air Quality.....	4-127
4.16.2	Water Resources.....	4-128
4.16.3	Terrestrial Resources.....	4-133
4.16.4	Aquatic Resources.....	4-134
4.16.5	Socioeconomics.....	4-137
4.16.6	Historic and Cultural Resources.....	4-138
4.16.7	Human Health.....	4-138
4.16.8	Environmental Justice.....	4-139
4.16.9	Waste Management and Pollution Prevention.....	4-140
4.16.10	Global Greenhouse Gas Emissions.....	4-142
4.17	Resource Commitments Associated with the Proposed Action.....	4-143
4.17.1	Unavoidable Adverse Environmental Impacts.....	4-143
4.17.2	Relationship between Short-Term Use of the Environment and Long-Term Productivity.....	4-144
4.17.3	Irreversible and Irretrievable Commitment of Resources.....	4-145
5	CONCLUSION.....	5-1
5.1	Environmental Impacts of Subsequent License Renewal.....	5-1
5.2	Comparison of Alternatives.....	5-1
5.3	Recommendation.....	5-2
6	REFERENCES.....	6-1
7	LIST OF PREPARERS.....	7-1
8	LIST OF AGENCIES, ORGANIZATIONS, AND PERSONS TO WHOM COPIES OF THIS SEIS ARE SENT.....	8-1
9	INDEX.....	9-1
APPENDIX A	COMMENTS RECEIVED ON THE TURKEY POINT NUCLEAR GENERATING UNITS 3 AND 4 ENVIRONMENTAL REVIEW.....	A-1
APPENDIX B	APPLICABLE LAWS, REGULATIONS, AND OTHER REQUIREMENTS....	B-1
APPENDIX C	CONSULTATION CORRESPONDENCE.....	C-1
APPENDIX D	CHRONOLOGY OF ENVIRONMENTAL REVIEW CORRESPONDENCE....	D-1
APPENDIX E	ENVIRONMENTAL IMPACTS OF POSTULATED ACCIDENTS.....	E-1

LIST OF FIGURES

Figure 1-2	Environmental Issues Evaluated for License Renewal.....	1-5
Figure 3-1	Map Showing the 50-mi (80-km) Radius Around the Turkey Point Site (FPL 2018f).....	3-2
Figure 3-2	Generic Cooling System with Cooling Canal System.....	3-4
Figure 3-3	Flow of Water Through the Cooling Canal System.....	3-6
Figure 3-4	Cooling Canal System and Adjacent Canals.....	3-9
Figure 3-5	Illustrated CCS Water Budget for Turkey Point Site Based on Modeling Predictions From June 2015 Through May 2017.....	3-11
Figure 3-6	Turkey Point In-Scope Transmission Lines (FPL 2018f).....	3-22
Figure 3-7	Geologic Stratigraphy and Major Aquifers Beneath the Turkey Point Site.....	3-31
Figure 3-8	Turkey Point Site, Biscayne Bay, Card Sound, and Regional Canals.....	3-33
Figure 3-9	Numeric Surface Water Criteria for Regions of Biscayne Bay.....	3-38
Figure 3-10	Sea Grass Loss Areas from 2005 to 2018 by Regions North Half of Biscayne Bay.....	3-39
Figure 3-11	Sea Grass Loss Areas from 2005 to 2018 by Regions South Half of Biscayne Bay.....	3-40
Figure 3-12	FEMA Flood Zones Map of the Turkey Point Property.....	3-46
Figure 3-13	Florida Department of Environmental Protection NPDES Permitted Outfalls.....	3-48
Figure 3-14	Locations of Surface Water Monitoring Stations.....	3-51
Figure 3-15a	Trend in Total Nitrogen Concentrations in the CCS.....	3-53
Figure 3-15b	Trend in Total Phosphorus Concentrations in the CCS.....	3-53
Figure 3-16	Generalized Diagram of the Freshwater-Saltwater Interface in a Coastal Water Table Aquifer.....	3-66
Figure 3-17	Groundwater Monitoring Locations and Saltwater Interface, Turkey Point Site.....	3-71
Figure 3-18	Chloride Concentration and Extent of Hypersalinity in the Biscayne Aquifer, 44 to 55 ft Below Ground Surface April 2018.....	3-77
Figure 3-19a	Time-Series Chart of Chloride Concentrations in Well Cluster TPGW-2, 2010-2018.....	3-78
Figure 3-19b	Time-Series Chart of Tritium Concentrations in Well Cluster TPGW-2, 2010-2018.....	3-79
Figure 3-20a	Bar Graph of Chloride Concentrations in Well Cluster TPGW-13 (CCS), 2016-2018.....	3-80
Figure 3-20b	Time Series Chart of Chloride Concentrations in Well Cluster TPGW-13 (CCS), 2010-2018.....	3-80
Figure 3-21a	Time-Series Chart of Tritium Concentrations in Well Cluster TPGW-11, 2010-2018.....	3-81
Figure 3-21b	Time-Series Chart of Chloride Concentrations in Well Cluster TPGW-11, 2010-2018.....	3-82
Figure 3-22	Extent of Tritium in the Deep Interval of the Biscayne Aquifer, 2017-2018.....	3-83

Figure 3-23a	Time-Series Chart of Chloride Concentrations in Well Cluster TPGW-7, 2010-2018.....	3-84
Figure 3-23b	Time-Series Chart of Tritium Concentrations in Well Cluster TPGW-7, 2010-2018.....	3-84
Figure 3-24a	Time-Series Chart of Chloride Concentrations in Well Cluster TPGW-10, 2010-2018.....	3-85
Figure 3-24b	Time-Series Chart of Tritium Concentrations in Well Cluster TPGW-10, 2010-2018.....	3-86
Figure 3-25	Layout of Biscayne Aquifer Recovery Well System and Injection Wells	3-93
Figure 3-26	Salinity Trends in Groundwater Monitoring Wells Near the CCS in Response to Recover Well System Operations.....	3-94
Figure 3-27	Turkey Point Groundwater Protection Initiative Monitoring Well Locations.....	3-100
Figure 3-28	Location of Groundwater Production Wells on the Turkey Point Site	3-104
Figure 3-29	Sawgrass Average Height in Freshwater Marsh Transects, 2010-2018.....	3-110
Figure 3-30	Sawgrass Average Live Biomass in Freshwater Marsh Transects, 2010-2018.....	3-111
Figure 3-31a	Red Mangrove Average Height in Mangrove Transects, 2010-2018	3-113
Figure 3-31b	Red Mangrove Average Live Biomass in Mangrove Transects, 2010-2018...	3-114
Figure 3-32	Red Mangrove Average Live Biomass Within Two Red Mangrove Plots (M1-2 and M3-2), 2010–2018.....	3-115
Figure 3-33	Turkey Point Site Fish Survey Sample Locations, June 2009	3-126
Figure 3-34	Cooling Canal System Characterization Survey Sample Locations, December 2016.....	3-128
Figure 3-35	Biscayne Bay and Card Sound Semiannual Monitoring Ecological Transect Locations	3-132
Figure 3-36a	Seagrass Mean Braun-Blanquet Coverage Abundance by Transect, 2010-2018.....	3-133
Figure 3-36b	Macrophyte Mean Braun-Blanquet Coverage Abundance by Transect, 2010-2018.....	3-134
Figure 3-36c	Macroalgae Mean Braun-Blanquet Coverage Abundance by Transect, 2010-2018.....	3-135
Figure 3-36d	Seagrass Leaf Phosphorus Content by Study Area with Reported Minimum and Maximum Values, 2012-2017.....	3-137
Figure 3-36e	Seagrass Leaf Phosphorus Content at BB-1, 2012-2017	3-138
Figure 3-36f	Seagrass Leaf Phosphorus Content at BB-2, 2012-2017	3-138
Figure 3-36g	Seagrass Leaf Phosphorus Content at BB-3, 2012-2017	3-139
Figure 3-36h	Seagrass Leaf Phosphorus Content at BB-4, 2012-2017	3-139
Figure 3-37	Florida Keys National Marine Sanctuary	3-152
Figure 3-38	2010 Census—Minority Block Groups Within a 50-mi (80-km) Radius of Turkey Point.....	3-173
Figure 3-39	2012–2016, American Community Survey 5-Year Estimates—Low-Income Block Groups Within a 50-mi (80-km) Radius of Turkey Point ...	3-174

LIST OF TABLES

Table ES-1	Summary of NRC Conclusions Relating to Site-Specific Impacts of Subsequent License Renewal at Turkey Point	xviii
Table 2-1	Summary and Key Characteristics of Replacement Power Alternatives Considered In Depth	2-7
Table 2-2	Summary of Environmental Impacts of the Proposed Action and Alternatives	2-23
Table 3-1	Ambient Air Quality Standards	3-26
Table 3-2	Permitted Air Emission Sources at Turkey Point Units 3 and 4	3-27
Table 3-3	Estimated Air Pollutant Emissions from Turkey Point Units 3 and 4.....	3-28
Table 3-4	Summary of Groundwater Monitoring Results for Key Water Quality Parameters in Select Biscayne Aquifer Wells, Turkey Point Uprate Monitoring Program, 2011 (Preuprate) and 2018	3-74
Table 3-5	Summary of Groundwater Monitoring Results for Nutrients in Select Biscayne Aquifer Wells, Turkey Point Uprate Monitoring Program	3-87
Table 3-6	Representative Groundwater and Storm Drain Monitoring Results for Tritium, Turkey Point Groundwater Protection Program, 2018 (in PicoCuries per Liter).....	3-98
Table 3-7	Groundwater Withdrawals at the Turkey Point Site	3-103
Table 3-8	Migratory Birds Protected under the Migratory Bird Treaty Act That Are Most Likely to Occur at Turkey Point	3-119
Table 3-9	Aquatic Species Reported from the Cooling Canal System, November 2007.....	3-123
Table 3-10	Number and Relative Abundance of Fish Captured at Seven Locations on the Turkey Point Site, June 2009	3-125
Table 3-11	Federally Listed Species under U.S. Fish and Wildlife Service Jurisdiction....	3-142
Table 3-12	Federally Listed Endangered or Threatened Species Under National Marine Fisheries Service Jurisdiction in Biscayne Bay.....	3-148
Table 3-13	Designated Essential Fish Habitat near the Turkey Point Site.....	3-149
Table 3-14	Residence of Permanent Turkey Point Employees by County	3-156
Table 3-15	Employment by Industry in Miami-Dade County (2016 Estimates)	3-157
Table 3-16	Estimated Income Information for Miami-Dade County and Florida (2016 Estimate)	3-158
Table 3-17	Population and Percent Growth in Miami-Dade County 1990–2060	3-159
Table 3-18	Demographic Profile of the Population in Miami-Dade County in 2010.....	3-159
Table 3-19	Demographic Profile of the Population in Miami-Dade County, 2016 Estimates.....	3-160
Table 3-20	2016 Estimated Seasonal Housing in Counties Located Within 50 mi (80 km) of Turkey Point.....	3-161
Table 3-21	2017 Migrant Farm Workers and Temporary Farm Labor in Counties Located within 50 mi of Turkey Point	3-161
Table 3-22	Housing in Miami-Dade County (2016).....	3-162
Table 3-23	Major Public Water Suppliers in Miami-Dade County.....	3-163

Table 3-24	Miami-Dade County Total Operating Revenues, Miami-Dade County School Board Revenues, and Florida Power & Light Turkey Point Property Tax Payments for Turkey Point Units 3 and 4 (2012–2017).....	3-165
Table 3-25	2017 Annual Average Daily Traffic in the Vicinity of Turkey Point	3-166
Table 4-1	Applicable Category 1 (Generic) Issues for Turkey Point.....	4-3
Table 4-2	Applicable Category 2 (Site-Specific) Issues for Turkey Point	4-6
Table 4-3	Average Maximum Daily Temperature at CCS Outfall 001	4-58
Table 4-4	Effect Determinations for Federally Listed Species Under U.S. Fish and Wildlife Service Jurisdiction	4-67
Table 4-5	Effect Determinations for Federally Listed Species Under National Marine Fisheries Service Jurisdiction	4-70
Table 4-6	Estimated Greenhouse Gas Emissions ^(a) from Operation at Turkey Point, Units 3 and 4.....	4-116
Table 4-7	Direct Greenhouse Gas Emissions from Facility Operations Under the Proposed Action and Alternatives	4-118
Table 4-8	Comparison of Greenhouse Gas Emission Inventories.....	4-143
Table 7-1	List of Preparers	7-1
Table 8-1	List of Agencies, Organizations, and Persons to Whom Copies of this SEIS Are Sent.....	8-1
Table A-1	Individuals Providing Comments During the Comment Period	A-3
Table A-2	Comment Categories	A-10
Table B-1	Federal and State Requirements	B-2
Table B-2	Federal, State, and Local Permits and Other Requirements.....	B-7
Table C-1	National Historic Preservation Act Correspondence.....	C-6
Table D-1	Environmental Review Correspondence	D-1

EXECUTIVE SUMMARY

Background

By letter dated January 30, 2018, Florida Power & Light Company (FPL) submitted to the U.S. Nuclear Regulatory Commission (NRC) an application requesting subsequent license renewal for the Turkey Point Nuclear Generating Unit Nos. 3 and 4 renewed facility operating licenses (Agencywide Documents Access and Management System (ADAMS) Package Accession No. ML18037A812). FPL subsequently supplemented its application by letters dated February 9, 2018 (ADAMS Accession No. ML18044A653), February 16, 2018 (ADAMS Package Accession No. ML18053A123), March 1, 2018 (ADAMS Package Accession No. ML18072A224), and April 10, 2018 (ADAMS Package Accession No. ML18113A132). The Turkey Point Unit No. 3 current renewed facility operating license (DPR-31) expires at midnight on July 19, 2032; the Turkey Point Unit No. 4 current renewed facility operating license (DPR-41) expires at midnight on April 10, 2033. In its application, FPL requested license renewal for a period of 20 years beyond the dates when the current renewed facility operating licenses expire, to July 19, 2052 for Turkey Point Unit No. 3 and April 10, 2053 for Turkey Point Unit No. 4.

Pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) 51.20(b)(2), the renewal of a power reactor operating license requires preparation of an environmental impact statement (EIS) or a supplement to an existing EIS. In addition, 10 CFR 51.95(c), "Operating License Renewal Stage," states that, in connection with the renewal of an operating license, the NRC shall prepare an EIS, which is a supplement to the Commission's NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants."

Once the NRC officially accepted FPL's application, the NRC staff began the environmental review process as described in 10 CFR Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions." The environmental review begins by the NRC publishing a notice of intent in the *Federal Register* to prepare a supplemental environmental impact statement (SEIS) and to conduct environmental scoping. To prepare the Turkey Point SEIS, the NRC staff performed the following:

- conducted two public scoping meetings on May 31, 2018, near the Turkey Point site in Homestead, FL
- conducted a severe accident mitigation alternatives in-office audit in Rockville, MD, from July 5 to July 13, 2018, and an onsite environmental audit at Turkey Point from June 19 to July 22, 2018
- reviewed FPL's environmental report (ER) and compared it to NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (the GEIS)
- consulted with Federal, State, Tribal, and local government agencies

- conducted a review of the issues following the guidance set forth in NUREG–1555, Supplement 1, Revision 1, “Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal,” Final Report
- published a draft SEIS for public comment on April 4, 2019, as noticed in the *Federal Register* (84 FR 13322). The draft SEIS was available for public comment through May 20, 2019
- considered public comments received during the scoping process
- considered public comments received on the draft SEIS

Proposed Action

FPL initiated the proposed Federal action (i.e., issuance of renewed facility operating licenses) by submitting an application for subsequent license renewal of Turkey Point. The existing Turkey Point renewed facility operating licenses expire at midnight on July 19, 2032, for Unit No. 3 (DPR-31) and April 10, 2033, for Unit No. 4 (DPR-41). The NRC’s Federal action is to decide whether to issue renewed licenses authorizing an additional 20 years of operation. If the NRC issues the renewed licenses, Turkey Point Unit Nos. 3 and 4 would be authorized to operate until July 19, 2052 and April 10, 2053, respectively. The regulation at 10 CFR 2.109, “Effect of Timely Renewal Application,” states that if a licensee of a nuclear power plant files an application for renewal of an operating license at least 5 years before the expiration of the existing license, the existing license will not be deemed to have expired until the NRC staff completes its safety and environmental reviews of the application, and the NRC makes a final decision on whether to issue a renewed license for the additional 20 years.

Purpose and Need for Proposed Action

The purpose and need for the proposed action (i.e., issuance of renewed licenses) is to provide an option that allows for power generation capability beyond the term of the current nuclear power plant operating licenses to meet future system generating needs. Energy-planning decisionmakers such as States, utility operators, and, where authorized, Federal agencies (other than the NRC) may determine these future system generating needs. The Atomic Energy Act of 1954, as amended, and the National Environmental Policy Act of 1969, as amended, require the NRC to perform a safety review and an environmental review of the proposed action. The above definition of purpose and need reflects the NRC’s recognition that, unless there are findings in the safety review or in the environmental review that would lead the NRC to reject a license renewal application, the NRC does not have a role in the energy-planning decisions as to whether a particular nuclear power plant should continue to operate.

Environmental Impacts of License Renewal

This SEIS evaluates the potential environmental impacts of the proposed action. The NRC designates the environmental impacts from the proposed action as SMALL, MODERATE, or LARGE. NUREG–1437, “Generic Environmental Impact Statement for License Renewal of Nuclear Plants” (the GEIS), evaluates 78 environmental issues related to plant operation and classifies each issue as either a Category 1 issue (generic to all or a distinct subset of nuclear

power plants) or a Category 2 issue (specific to individual power plants). Category 1 issues are those that meet all the following criteria:

- The environmental impacts associated with the issue apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal.
- Mitigation of adverse impacts associated with the issue is considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

SMALL: Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE: Environmental effects are sufficient to alter noticeably, but not to destabilize, important attributes of the resource.

LARGE: Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

For Category 1 issues, no additional site-specific analysis is required in this SEIS unless new and significant information is identified. As discussed below, the NRC staff did not identify any information that is both new and significant during its review of Florida Power & Light Company's (FPL's) environmental report, the site audits, the scoping period, or its review of public comments on the draft SEIS, that would change the conclusions in the GEIS. Therefore, there are no impacts related to these Category 1 issues beyond those already discussed in the GEIS.

Category 2 issues are site-specific issues that do not meet one or more of the criteria for Category 1 issues; therefore, a SEIS must include additional site-specific review for these non-generic issues. In this SEIS, the NRC staff evaluated Category 2 issues applicable to Turkey Point, as well as cumulative impacts and considered new information regarding severe accident mitigation alternatives (SAMAs).

The NRC staff identified and evaluated new and potentially significant information for two existing Category 1 issues (i.e., groundwater quality degradation (plants with cooling ponds in salt marshes) and cooling system impacts on terrestrial resources (plants with once-through cooling systems or cooling ponds)). In addition, the NRC staff identified and evaluated one new issue not categorized as Category 1 or 2 (i.e., water quality impacts on adjacent water bodies (plants with cooling ponds in salt marshes)). As described in Chapter 4 of this SEIS, the impacts of each of these issues is SMALL. Chapter 4 also presents the process for identifying new and significant information.

Table ES-1 summarizes the Category 2 issues relevant to Turkey Point and the NRC staff's findings related to those issues. If the NRC staff determined that there were no Category 2 issues applicable for a particular resource area, the findings of the GEIS, as documented in Appendix B to Subpart A, "Environmental Effect of Renewing the Operating License of a Nuclear Power Plant," of 10 CFR Part 51, are incorporated for that resource area.

Table ES-1 Summary of NRC Conclusions Relating to Site-Specific Impacts of Subsequent License Renewal at Turkey Point

Resource Area	Relevant Category 2 Issues	Impacts
Groundwater Resources	- Groundwater use conflicts (plants that withdraw more than 100 gallons per minute) - Radionuclides released to groundwater	SMALL to MODERATE SMALL
Terrestrial Resources	- Effects on terrestrial resources (non-cooling system impacts)	SMALL
Aquatic Resources	- Impingement and entrainment of aquatic organisms (plants with once-through cooling systems or cooling ponds) - Thermal impacts on aquatic organisms (plants with once-through cooling systems or cooling ponds)	SMALL to MODERATE SMALL to MODERATE
Special Status Species and Habitats	- Threatened, endangered, and protected species and essential fish habitat	Likely to adversely affect the American crocodile and eastern indigo snake ^(a) May affect, but is not likely to adversely affect or no effect to all other species May result in adverse modification to American crocodile critical habitat ^(a) No adverse modification to West Indian manatee critical habitat No adverse effects on Essential Fish Habitat No effects to sanctuary resources of the Florida Keys National Marine Sanctuary
Historic and Cultural Resources	- Historic and cultural resources	Would not adversely affect known historic properties or historic and cultural resources
Human Health	- Electric shock hazards	SMALL
Environmental Justice	- Minority and low-income populations	No disproportionately high and adverse human health and environmental effects
Cumulative Impacts	- Cumulative Impacts	See SEIS Section 4.16

^(a) This table summarizes the NRC staff's conclusions regarding special status species and habitats. Separately, in a July 25, 2019, biological opinion, the FWS concluded that the continued operation of Turkey Point through the duration of the proposed subsequent license renewal period is not likely to jeopardize the continued existence of the American crocodile or eastern indigo snake and will not adversely modify the critical habitat of the American crocodile.

Alternatives

As part of its environmental review, the NRC is required to consider alternatives to license renewal and to evaluate the environmental impacts associated with each alternative. These alternatives can include other methods of power generation (replacement power alternatives), as well as not renewing the Turkey Point operating licenses (the no-action alternative).

In total, the NRC staff initially considered 16 replacement power alternatives; the NRC staff later dismissed 13 of these because of technical, resource availability, or commercial limitations that currently exist and that the NRC staff believes are likely to still exist when the current Turkey Point licenses expire.

This left three feasible and commercially viable replacement power alternatives which, in addition to the no-action alternative, the staff evaluates in depth in this report:

- new nuclear power
- natural gas combined-cycle
- combination alternative: natural gas combined-cycle and solar photovoltaic (PV)

These are the 13 additional alternatives that the NRC staff considered but ultimately dismissed:

- solar power
- wind power
- biomass power
- demand-side management
- hydroelectric power
- geothermal power
- wave and ocean energy
- municipal solid waste
- petroleum-fired power
- coal (integrated gasification combined-cycle)
- fuel cells
- purchased power
- delayed retirement of nearby generating facilities

The NRC staff evaluated the environmental impacts of each replacement power alternative, using the same resource areas that it used in evaluating the impacts from subsequent license renewal. In addition, this SEIS evaluates the environmental impacts of an alternative cooling water system, which might be used to mitigate potential impacts associated with the continued use of the existing cooling canal system. Finally, this SEIS evaluates any new and significant information that could alter the conclusions of the SAMA analysis that was performed previously, in connection with the initial license renewal of Turkey Point Unit Nos. 3 and 4.

Recommendation

The NRC staff's recommendation is that the adverse environmental impacts of subsequent license renewal for Turkey Point are not so great that preserving the option of license renewal

for energy-planning decisionmakers would be unreasonable. The NRC staff based its recommendation on the following:

- the analysis and findings in NUREG–1437, “Generic Environmental Impact Statement for License Renewal of Nuclear Plants”
- the environmental report submitted by FPL
- the NRC staff’s consultation with Federal, State, Tribal, and local government agencies
- the NRC staff’s independent environmental review
- the NRC staff’s consideration of public comments received during the scoping process
- the NRC staff’s consideration of public comments received on the draft SEIS

ABBREVIATIONS AND ACRONYMS

°C	degree(s) Celsius
°F	degree(s) Fahrenheit
µg/m ³	micrograms per cubic meter
AA DT	average annual daily traffic
ac	acre(s)
ACHP	Advisory Council on Historic Preservation
ACR	Atlantic Coastal Ridge
ADAMS	Agencywide Documents Access and Management System
AEA	Atomic Energy Act of 1954 (as amended)
ALARA	as low as reasonable achievable
APE	Area of Potential Affects
AQCR	Air Quality Control Region
ARB	Homestead Air Reserve Base
ASLB	Atomic Safety and Licensing Board
BCG	biota concentration guide
BLM	Bureau of Land Management
bls	below land surface
BMPs	best management practices
CAA	Clean Air Act
CCS	cooling canal system
CCW	component cooling water
CDMP	Comprehensive Master Development Plan
CEQ	Council on Environmental Quality
CERP	Comprehensive Everglades Restoration Plan
CFR	<i>Code of Federal Regulations</i>
cfs	cubic foot (feet) per second
CH ₄	methane
CO	carbon monoxide
CO ₂	carbon dioxide
CO ₂ /MWh	carbon dioxide per megawatt hour
CO _{2eq}	carbon dioxide equivalents
COL	combined license
CVCS	chemical and volume control system
CWA	Clean Water Act
CZMA	Coastal Zone Management Act
dBA	A-weighted decibels
DERM	Miami-Dade County Division of Environmental Resource Management

DOE	U.S. Department of Energy
DOH	Florida Department of Health
DPS	distinct population segment
DSEIS	draft supplemental environmental impact statement
EAI	Ecological Associates, Inc.
EB	Encyclopedia Britannica
ECFAS2	East Coast Floridan Aquifer System Model - Phase 2
ECOS	Environmental Conservation Online System
EDMS	Electronic Data Management System (of Florida Power & Light)
EFH	Essential Fish Habitat
EIA	Energy Information Administration
EIS	environmental impact statement
ELF-EMF	extremely low frequency-electromagnetic field
EO	Executive Order
EPA	U.S. Environmental Protection Agency
ER	Environmental Report
ESA	Endangered Species Act of 1973, as amended
ESP	early site permit
FAC	Florida Administrative Code
FDACS	Florida Department of Agriculture and Consumer Services
FDEP	Florida Department of Environmental Protection
FDOT	Florida Department of Transportation
FE	federally listed as endangered
FEIS	final environmental impact statement
FFWCC	Florida Fish and Wildlife Conservation Commission
FLDOE	Florida Department of Education
FPL	Florida Power & Light
fps	feet per second
FKNMS	Florida Keys National Marine Sanctuary
FR	<i>Federal Register</i>
FRN	<i>Federal Register</i> notice
ft	foot (feet)
FT	federally listed as threatened
ft ³	cubic foot (feet)
FWS	U.S. Fish and Wildlife Service
g	gram(s)
gal	gallon(s)
GEIS	generic environmental impact statement
GHG	Greenhouse Gases
gpd	gallon(s) per day
gpm	gallon(s) per minute
GT	gigatons

GWP	global warming potential
H ₂ O	water vapor
ha	hectare(s)
HAP	Hazardous Air Pollutant
HFC	hydrofluorocarbons
HIC	high integrity container
ICW	intake cooling water
IPaC	Information for Planning and Conservation
IPCC	Intergovernmental Panel on Climate Change
ISFSI	independent spent fuel storage installation
IWW	industrial wastewater
kg	kilogram(s)
km	kilometer(s)
kW	kilowatt(s)
kWe	kilowatt(s) electric
L/min	liter(s) per minute
lb	pound(s)
LLRW	Low-level radioactive waste
LLW	low level waste
Lpd	liters per day
LRA	license renewal application
m	meter(s)
m/s	meter(s) per second
m ³ /day	cubic meters per day
m ³ /s	cubic meter(s) per second
MBTA	Migratory Bird Treaty Act
MDC	Miami-Dade County
MDWSD	Miami-Dade Water and Sewer Department
mg/L	milligram(s) per liter
mgd	million gallons per day
mgy	million gallons per year
mi	mile(s)
min	minute(s)
MMT	million metric tons
mph	mile(s) per hour
mrad	millirad
mrem/yr	millirem per year
MSA	Magnuson–Stevens Fishery Conservation and Management Act
MSL	mean sea level

mSv	millisievert
mSv/yr	millisieverts per year
MT	metric ton(s)
MW	megawatt(s)
MWe	megawatt(s) electric
MWh	megawatt hour(s)
MWt	megawatt(s) thermal
N ₂ O	nitrous oxide
NAAQS	National Ambient Air Quality Standards
NASA	National Aeronautics and Space Administration
NEPA	National Environmental Policy Act of 1969, as amended
NESHAP	National Emission Standards for Hazardous Air Pollutants
NGCC	natural gas combined-cycle
NHPA	National Historic Preservation Act of 1966, as amended
NIEHS	National Institute of Environmental Health Sciences
NMFS	National Marine Fisheries Service (of the National Oceanic and Atmospheric Administration)
NMSA	National Marine Sanctuaries Act
NO ₂	nitrogen dioxide
NOAA	National Oceanic and Atmospheric Administration
NOV	notice of violation
NO _x	nitrogen oxide(s)
NPDES	National Pollutant Discharge Elimination System
NPS	National Park Service
NRC	U.S. Nuclear Regulatory Commission
NRHP	National Register of Historic Places
O ₃	ozone
ODCM	offsite dose calculation manual
OSHA	Occupational Safety and Health Administration
Pb	lead
pCi/L	picocuries per liter
PFC	perfluorocarbons
PM	particulate matter
PM ₁₀	particulate matter diameter between 2.5 and 10 micrometers
PM _{2.5}	particulate matter diameter of 2.5 micrometers or less
ppb	parts per billion
ppm	parts per million
PPSA	Power Plant Siting Act
ppt	parts per thousand
PRA	probabilistic risk assessment
PSD	Prevention of Significant Deterioration
PSU	practical salinity unit

PV	photovoltaic
PWR	pressurized water reactor
r/day	rad per day
RCP	representative concentration pathway
RCS	reactor coolant system
REMP	radiological environmental monitoring program
RICE	reciprocating internal combustion engines
ROI	region of influence
RWS	recovery well system
RWST	refueling water storage tank
SAMA	severe accident mitigation alternative
SAT	federally listed due to similarity of appearance to another listed species
SDWA	Safe Drinking Water Act
SDWWTP	Miami-Dade County South District Waste Water Treatment Plant
SEIS	supplemental environmental impact statement
SER	safety evaluation report
SF ₆	sulfur hexafluoride
SFRCCC	Southeast Florida Regional Climate Change Compact
SFWMD	South Florida Water Management District
SIP	State implementation plan
SLR	subsequent license renewal
SLRA	subsequent license renewal application
SO ₂	sulfur dioxide
SPCC	Spill Prevention, Control, and Countermeasure
SSC	structure, system, and component
Sv	sievert
TDS	total dissolved solids
Turkey Point	Turkey Point Nuclear Generating Unit Nos. 3 and 4
U.S.	United States
USACE	U.S. Army Corps of Engineers
UF	University of Florida
UFA	Upper Floridan aquifer
UFSAR	updated final safety analysis report
USCB	U.S. Census Bureau
USCG	U.S. Coast Guard
USDOT	U.S. Department of Transportation
USGCRP	U.S. Global Change Research Program
USGS	U.S. Geological Survey
VOC	Volatile Organic Compounds

WHT	waste holdup tanks
yd ³	cubic yard(s)
μg	microgram
μm	micrometer

1 INTRODUCTION

The U.S. Nuclear Regulatory Commission's (NRC's) environmental protection regulations in Title 10 of the *Code of Federal Regulations* (10 CFR) Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions," implement the National Environmental Policy Act of 1969, as amended (42 U.S.C. 4321 et seq.). This Act is commonly referred to as NEPA. The regulations at 10 CFR Part 51 require the NRC to prepare an environmental impact statement (EIS) before making a decision on whether to issue an operating license or a renewed operating license for a nuclear power plant.

The Atomic Energy Act of 1954, as amended (42 U.S.C. 2011 et seq.) (AEA), specifies that licenses for commercial power reactors can be granted for up to 40 years. The initial 40-year licensing period was based on economic and antitrust considerations rather than on technical limitations of the nuclear facility. NRC regulations permit these licenses to be renewed beyond the initial 40-year term for an additional period of time, limited to 20-year increments per renewal, based on the results of an assessment to determine whether the nuclear facility can continue to operate safely during the proposed period of extended operation. There are no limitations in the AEA or NRC regulations restricting the number of times a license may be renewed.

The decision to seek a renewed license rests entirely with nuclear power facility owners and typically is based on the facility's economic viability and the investment necessary to continue to meet NRC safety and environmental requirements. The NRC makes the decision to grant or deny a renewed license based on whether the applicant has demonstrated reasonable assurance that it can meet the environmental and safety requirements in the agency's regulations during the period of extended operation.

1.1 Proposed Federal Action

Florida Power & Light Company (FPL) initiated the proposed Federal action by submitting an application for subsequent license renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4 (Turkey Point or Turkey Point Units 3 and 4). The current renewed licenses expire at midnight on July 19, 2032, for Unit No. 3 (DPR-31) and at midnight on April 10, 2033, for Unit No. 4 (DPR-41). The NRC's Federal action is to decide whether to issue renewed licenses for an additional 20 years.

1.2 Purpose and Need for the Proposed Federal Action

The purpose and need for the proposed Federal action (issuance of subsequent renewed licenses for Turkey Point Unit Nos. 3 and 4) is to provide an option that allows for power generation capability beyond the term of the current renewed nuclear power plant operating licenses to meet future system generating needs. Such needs may be determined by energy-planning decisionmakers such as State regulators, utility owners, and Federal agencies other than the NRC. This definition of purpose and need reflects the NRC's recognition that, unless there are findings in the NRC's safety review (required by the Atomic Energy Act) or findings in the NRC's environmental analysis (required by NEPA) that would lead the NRC to reject a subsequent license renewal application, the NRC does not have a role in energy-planning decisions as to whether a particular nuclear power plant should continue to operate.

1.3 Major Environmental Review Milestones

FPL submitted an environmental report (ER) (FPL 2018f) as an appendix to its subsequent license renewal application (SLRA) on January 30, 2018 (FPL 2018a). After reviewing the SLRA and environmental report, as supplemented on February 9 (FPL 2018b), February 16 (FPL 2018c), March 1 (FPL 2018d), and April 10, 2018 (FPL 2018e), the NRC staff accepted the application for a detailed technical review on April 26, 2018 (NRC 2018a). On May 2, 2018, the NRC staff published a *Federal Register* notice of acceptability and opportunity for hearing (Volume 83 of the *Federal Register* (FR), page 19304 (83 FR 19304)). On May 22, 2018, the NRC published another notice in the *Federal Register* (83 FR 23726) informing members of the public of the staff's intent to conduct an environmental scoping process, thereby beginning a 30-day scoping comment period.

The NRC staff held two public scoping meetings on May 31, 2018, near the Turkey Point site in Homestead, FL. In January 2019, the NRC issued its "Supplemental Environmental Impact Statement Scoping Process Summary Report, Turkey Point Nuclear Generating Unit Nos. 3 and 4, Miami-Dade County, Florida," which includes the comments received during the scoping process and the NRC staff's responses to those comments (NRC 2019a).

To independently verify information that FPL provided in its environmental report, the NRC staff conducted an onsite audit at Turkey Point in June 2018, and an in-office severe accident mitigation alternatives audit at NRC headquarters in July 2018. In a letter dated July 20, 2018, the staff summarized the onsite audit and listed the attendees (NRC 2018c). In a letter dated August 31, 2018, the staff summarized the in-office severe accident mitigation alternatives audit and listed the attendees (NRC 2018d). During these audits, the NRC staff held meetings with plant personnel, reviewed site-specific documentation, toured the facility, and held a government-to-government meeting hosted by the U.S. National Park Service.

Upon completion of the scoping period and audits, and completion of its review of FPL's environmental report and related documents, the NRC staff compiled its findings in a draft supplemental environmental impact statement (SEIS) issued on March 31, 2019 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML19078A330) (NRC 2019m), as noticed in the *Federal Register* (84 FR 13322) on April 4, 2019. The NRC staff made the draft SEIS available for public comment through May 20, 2019. Based on the information gathered during the public comment period and any new information received, the NRC staff amended the draft SEIS, as necessary, and published this final SEIS. Changes made to the draft SEIS in response to comments, as well as changes made to include updated information and minor corrective and editorial revisions, are marked with a change bar (vertical line) on the side margin of the page where the changes were made. Figure 1-1 shows the major milestones of the environmental review portion of the NRC's subsequent license renewal application review process.




Figure 1-1 Environmental Review Process

The NRC has established a license renewal process that can be completed in a reasonable period of time and that includes clear requirements to assure safe plant operation for up to an additional 20 years of plant life. This process consists of separate environmental and safety reviews, which the NRC staff conducts simultaneously and documents in two reports: (1) the SEIS documents the environmental review and (2) the safety evaluation report (SER) documents the safety review. The staff's findings in the SEIS and the SER are both factors in the NRC's decision to grant or deny the issuance of a renewed license. This process is used for both initial and subsequent license renewal.

1.4 Generic Environmental Impact Statement

To improve the efficiency of its license renewal review process, the NRC staff performed a generic assessment of the environmental impacts associated with license renewal. NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Power Plants" (known as the GEIS) (NRC 1996, NRC 1999, NRC 2013a), documents the results of the NRC's systematic approach to evaluating the environmental consequences of renewing the licenses of individual nuclear power plants and operating them for an additional 20 years. In the GEIS, the staff analyzed in detail and resolved those environmental issues that could be resolved generically. The NRC issued the GEIS in 1996 (NRC 1996), Addendum 1 to the GEIS in 1999 (NRC 1999), and Revision 1 to the GEIS in 2013 (NRC 2013a). Unless otherwise noted, all references to the GEIS include the original 1996 GEIS, Addendum 1, and the 2013 revision. The conclusions in the GEIS apply to both initial and subsequent license renewal.

The GEIS establishes separate environmental impact issues for the NRC staff to independently evaluate. Appendix B to Subpart A of 10 CFR Part 51, "Environmental Effect of Renewing the

Operating License of a Nuclear Power Plant,” provides a summary of the staff’s findings in the GEIS. For each environmental issue addressed in the GEIS, the NRC staff:

- describes the activity that affects the environment
- identifies the population or resource that is affected
- assesses the nature and magnitude of the impact on the affected population or resource
- characterizes the significance of the effect for both beneficial and adverse effects
- determines whether the results of the analysis apply to all plants
- considers whether additional mitigation measures would be warranted for impacts that would have the same significance level for all plants

The NRC established its standard of significance for impacts using the Council on Environmental Quality terminology for “significant.” The NRC established three levels of significance for potential impacts—SMALL, MODERATE, and LARGE—as defined below.

SMALL: Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE: Environmental effects are sufficient to alter noticeably, but not to destabilize, important attributes of the resource.

LARGE: Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

Significance indicates the importance of likely environmental impacts and is determined by considering two variables: **context** and **intensity**.

Context is the geographic, biophysical, and social context in which the effects will occur.

Intensity refers to the severity of the impact in whatever context it occurs.

The GEIS includes a determination of whether the analysis of the environmental issue could be applied to all plants (or a distinct subset of plants, as defined in the GEIS) and whether additional mitigation measures would be warranted. Issues are assigned a Category 1 (generic to all or a subset of plants) or Category 2 (site-specific) designation. As established in the GEIS, Category 1 issues are those that meet the following three criteria:

- The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants that have a specific type of cooling system or other specified plant or site characteristics.
- A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal).
- Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For generic issues (Category 1), the SEIS requires no additional site-specific evaluation unless new and significant information has been identified. Chapter 4 of this report describes the

process for identifying new and significant information for site-specific analysis. Site-specific issues (Category 2) are those that do not meet the three criteria of Category 1 issues; therefore, the GEIS requires additional site-specific review for these issues.

The 2013 GEIS evaluates 78 environmental issues, provides generically applicable findings for numerous issues (subject to the consideration of any new and significant information on a site-specific basis), and concludes that a site-specific analysis is required for 17 of the 78 issues. Figure 1-2 illustrates the license renewal environmental review process. The results of that site-specific review are documented in the SEIS.




Figure 1-2 Environmental Issues Evaluated for License Renewal

1.5 Supplemental Environmental Impact Statement

This SEIS presents the NRC staff's final analysis of the environmental effects of the continued operation of Turkey Point through the subsequent license renewal period, alternatives to subsequent license renewal, and mitigation measures for minimizing adverse environmental impacts. Chapter 4, "Environmental Consequences and Mitigating Actions," contains an analysis and comparison of the potential environmental impacts from subsequent license renewal and alternatives to subsequent license renewal. Chapter 5, "Conclusion," presents the NRC's recommendation on whether the environmental impacts of subsequent license renewal are so great that preserving the option of subsequent license renewal would be unreasonable. In issuing the final SEIS, the NRC staff considered the comments it had received on the

previously published draft SEIS. The NRC staff will make its final recommendation to the Commission on Turkey Point Units 3 and 4 subsequent license renewal in the record of decision to be issued following issuance of this final SEIS.

In the preparation of the Turkey Point SEIS, the NRC staff carried out the following activities:

- reviewed the information provided in FPL's environmental report
- consulted with Federal, State, Tribal, and local government agencies
- conducted an independent environmental review, including the environmental and severe accident mitigation analysis site audits
- considered public comments received during the scoping process
- considered public comments received on the draft SEIS

New information can come from many sources, including the applicant, the NRC, other agencies, or public comments. If the information reveals a new issue, the staff will first analyze the issue to determine whether it is within the scope of the license renewal environmental evaluation. If the staff determines that the new issue bears on the proposed action, the staff will then determine the significance of the issue for the plant and analyze the issue in the SEIS, as appropriate.

New and significant information. To merit additional review, information must be both new and significant and it must bear on the proposed action or its impacts.

1.6 Decisions To Be Supported by the SEIS

This SEIS supports the NRC's decision on whether to issue renewed operating licenses for Turkey Point for an additional 20 years. The regulation at 10 CFR 51.103(a)(5) specifies the NRC's decision standard as follows:

In making a final decision on a license renewal action pursuant to Part 54 of this chapter [10 CFR], the Commission shall determine whether or not the adverse environmental impacts of license renewal are so great that preserving the option of license renewal for energy planning decisionmakers would be unreasonable.

There are many factors that the NRC takes into consideration when deciding whether to renew the operating license of a nuclear power plant. The analyses of environmental impacts in this SEIS will provide the NRC's decisionmaker (in this case, the Commission) with important environmental information for use in the overall decisionmaking process. Other decisions are made outside the regulatory scope of license renewal, by the NRC or other decisionmakers. These include decisions related to: (1) changes to plant cooling systems, (2) disposition of spent nuclear fuel, (3) emergency preparedness, (4) safeguards and security, (5) need for power, and (6) seismicity and flooding (NRC 2013a).

1.7 Cooperating Agencies

The U.S. National Park Service, Southeast Region (NPS), is participating in the environmental review of subsequent license renewal for Turkey Point as a cooperating agency. The NPS does not have any specific regulatory actions related to the proposed subsequent license renewal;

however, NPS is providing special expertise for environmental issues pertaining to the areas in and around Biscayne National Park, which is located next to the Turkey Point site. In a letter dated March 5, 2019, the NPS provided comments to the NRC staff on preliminary sections of the draft SEIS discussing water resources, terrestrial resources, aquatic resources, and special status species and habitats (NPS 2019a). In addition, in a letter dated May 16, 2019, the NPS provided comments on the draft SEIS discussing the geologic environment, surface water, groundwater, terrestrial, and visual resources; cooling and auxiliary water systems; water quality impacts; alternatives; and various sections of the draft SEIS (NPS 2019b).

1.8 Consultations

The Endangered Species Act of 1973, as amended (16 U.S.C. 1531 et seq.) (ESA); the Magnuson–Stevens Fishery Conservation and Management Act of 1996, as amended (16 U.S.C. 1801 et seq.) (MSA); and the National Historic Preservation Act of 1966, as amended (54 U.S.C. 300101 et seq.) (NHPA), require Federal agencies to consult with applicable State and Federal agencies and organizations before taking an action that may affect endangered species, fisheries, or historic and archaeological resources, respectively. Additionally, under the National Marine Sanctuaries Act (16 U.S.C. 1431 et seq.) (NMSA), agency actions that are likely to destroy, cause the loss of, or injure any sanctuary resource are subject to consultation with the National Oceanic and Atmospheric Administration (NOAA). The NRC staff consulted with the following agencies and organizations during this environmental review:

- U.S. Fish and Wildlife Service (FWS)
- National Marine Fisheries Service (NMFS)
- Miami-Dade County Office of Historic Preservation
- Miccosukee Tribe of Indians of Florida
- Muscogee (Creek) Nation
- Poarch Band of Creek Indians
- The Seminole Nation of Oklahoma
- Seminole Tribe of Florida
- Florida Department of State, Division of Historical Resources
- Federal Advisory Council on Historic Preservation

In addition, the NRC staff determined that consultation was not warranted with regard to the Florida Keys National Marine Sanctuary (FKNMS) under the National Marine Sanctuaries Act (16 U.S.C. 1431 et seq.) (NMSA). Appendix C, “Consultation Correspondence,” of this SEIS discusses the consultations that the NRC staff conducted, or considered to be unwarranted, in support of this environmental review.

In addition, on June 18, 2018, the NRC staff participated in an interagency meeting related to the proposed subsequent license renewal action. Participating Federal, State, and local agencies included the National Park Service (NPS), U.S. Environmental Protection Agency

(EPA), FWS, NOAA, Florida Department of Environmental Protection (FDEP), and Miami-Dade County Division of Environmental Resources Management (DERM). The primary goals of the meeting included the following:

- Provide an overview of NRC's environmental review process related to FPL's application to renew the operating licenses at Turkey Point.
- Gather input from other Federal, State, and local agencies regarding available environmental data and issues.

During the meeting, the NRC staff provided an overview of the subsequent license renewal process, several agencies presented environmental data and issues related to Turkey Point, and lastly, participants held a general discussion related to the environmental review (NRC 2018I). Information provided by the meeting participants has been considered by the NRC staff in preparing this SEIS.

1.9 Correspondence

During the environmental review, the NRC staff contacted Federal, State, regional, local, and Tribal government agencies listed in Section 1.8 above. Appendix C, "Consultation Correspondence," describes correspondence between the NRC staff, the FWS, the NMFS, and Indian tribes associated with the ESA, the MSA, and the NHPA. Appendix D, "Chronology of Environmental Review Correspondence," chronologically lists all other correspondence.

1.10 Status of Compliance

FPL is responsible for complying with all NRC regulations and other applicable Federal, State, and local requirements. Appendix F of the GEIS describes some of the major applicable Federal statutes. Numerous permits and licenses are issued by Federal, State, and local authorities for activities at Turkey Point. Appendix B of this SEIS contains further information about FPL's status of compliance.

1.11 Related State and Federal Activities

The NRC reviewed the possibility that activities of other Federal agencies might affect the renewal of the operating licenses for Turkey Point. There are no Federal projects that would make it necessary for another Federal agency to become a cooperating agency in the preparation of this SEIS.

Two Indian reservations, the Miccosukee Indian Reservation (approximately 47 miles (75 km) northwest of Turkey Point) and the Seminole Tribe of Florida, Hollywood Reservation (approximately 43 mi (68 km) north of Turkey Point), are located within 50 miles (80 km) of Turkey Point. The area surrounding the Turkey Point site is low, swampy, and sparsely populated. The Turkey Point site is adjacent to waters and coastal lands that are part of the Biscayne National Park and is within 2 miles (3.2 km) of the Model Lands Basin, a South Florida Water Management District conservation area. A portion of the Biscayne Bay Aquatic Preserve is located immediately east of the Turkey Point site, and a separate portion of the preserve, along with the Florida Keys National Marine Sanctuary, is located adjacent to the south-southeastern border of the Turkey Point site boundary. The Turkey Point site is also

located just east of the 13,000-acre Everglades Mitigation Bank. The Homestead Bayfront Park, a city park, is located approximately 2 miles (3.2 km) north-northwest of Turkey Point. (FPL 2018f)

Section 102(2)(C) of NEPA requires the NRC to consult with and obtain the comments of any Federal agency that has jurisdiction by law or special expertise with respect to any environmental impact involved in the subject matter of the SEIS. In accordance with this requirement, during the course of preparing the SEIS, the NRC consulted, for example, with the FWS. Appendix D provides a chronology of environmental review correspondence with the FWS and other Federal agencies.

2 ALTERNATIVES INCLUDING THE PROPOSED ACTION

The U.S. Nuclear Regulatory Commission's (NRC's) decisionmaking authority for subsequent license renewal focuses on deciding whether or not to issue a subsequent renewed operating license to a nuclear power plant. The agency's implementation of the National Environmental Policy Act of 1969, as amended (42 U.S.C. 4321 et seq.) (NEPA), requires the NRC to consider potential alternatives to issuing a subsequent renewed operating license as well as the environmental impacts of these alternatives. Considering the environmental impacts of subsequent license renewal and comparing those impacts to the environmental impacts of alternatives allows the NRC to determine whether the environmental impacts of subsequent license renewal are so great that it would be unreasonable for the agency to preserve the option of subsequent license renewal for energy-planning decisionmakers (Title 10 of the *Code of Federal Regulations* (10 CFR) 51.95(c)(4)). Ultimately, decisionmakers such as the plant operator, State, or non-NRC Federal officials will decide whether to carry out the proposed action and continue operating the plant for an additional 20 years (if the NRC renews the license) or shut down the plant and choose an alternative power generation source. Economic and environmental considerations play important roles in the decisions of these non-NRC energy-planning decisionmakers.

In general, the NRC's responsibility is to ensure the safe operation of nuclear power facilities, not to formulate energy policy, promote nuclear power, or encourage or discourage the development of alternative power generation sources. The NRC does not engage in energy-planning decisions, and it makes no judgment as to which energy alternatives evaluated in the SEIS would be the best or most-likely alternative to be selected in any given case.

This chapter provides (1) a description of the proposed action (i.e., subsequent renewal of the operating licenses for Turkey Point Nuclear Generating Unit Nos. 3 and 4 (Turkey Point, or Turkey Point Units 3 and 4)), (2) a description of reasonable alternatives to the proposed action that the NRC staff evaluated in-depth (including the no-action alternative), and (3) a brief description of the alternatives to the proposed action that the NRC staff considered but ultimately eliminated from in-depth evaluation.

2.1 Proposed Action

As stated in Section 1.1 of this document, the NRC's proposed Federal action is to decide whether to renew the Turkey Point operating licenses for an additional 20 years. To evaluate the environmental impacts from the continued operation of Turkey Point, the staff provides an overview of the facility and the facility's operations, and then considers the affected environment and potential impacts to the affected environment.

Section 2.1.1 below provides a description of normal power plant operations during the subsequent license renewal term. In brief, Turkey Point is a two-unit, nuclear-powered, steam-electric generating facility that began commercial operation in December 1972 (Unit 3) and September 1973 (Unit 4). The nuclear reactors are both Westinghouse pressurized-water reactors (PWRs) and have a combined generating capacity of 1,632 megawatts electric (MWe). Operating at an average capacity factor of 92 percent, the reactors provide approximately 1,500 MWe of net generation (FPL 2018f).

2.1.1 Plant Operations during the Subsequent License Renewal Term

Most plant operation activities during the subsequent license renewal term would be the same as, or similar to, those occurring during the current renewed license term. NUREG–1437, Volume 1, Revision 1, “*Generic Environmental Impact Statement for License Renewal of Nuclear Plants*,” (NRC 2013a) (also known as the GEIS) describes the issues that would have the same impact at all nuclear power plants (or a distinct subset of plants, as defined in the GEIS) (i.e., generic issues) as well as those issues that may have different impact levels at different nuclear power plants (i.e., site-specific issues). The impacts of generic issues are described in NUREG–1437 as Category 1 issues; those impacts are set out in NUREG–1437 and Table B-1 of 10 CFR Part 51, Appendix B, and those determinations apply to each license renewal application for plants and sites within the designated generic classification, subject to the consideration of any new and significant information on a plant-specific basis. A second group of issues (Category 2) was identified in NUREG–1437 as having potentially different impacts at each plant, on a site-specific basis; those issues with plant-specific impact levels need to be discussed in a plant-specific supplemental environmental impact statement (SEIS) to the GEIS, like this one.

Section 2.1.1 of the GEIS, “Plant Operations during the License Renewal Term,” describes the general types of activities that are carried out during the operation of all nuclear power plants. These general types of activities include the following:

- reactor operations
- waste management
- security
- office and clerical work
- laboratory analysis
- surveillance, monitoring, and maintenance refueling and other outages

As part of its subsequent license renewal application, Florida Power & Light Company (FPL) submitted an environmental report. FPL’s environment report states that Turkey Point will continue to operate during the subsequent license renewal term in the same manner as it would during the current license term with the exception of additional aging management programs to address structure and component aging in accordance with 10 CFR Part 54, “Requirements for Renewal of Operating Licenses for Nuclear Power Plants.”

2.1.2 Refurbishment and Other Activities Associated with Subsequent License Renewal

Refurbishment activities include replacement and repair of major structures, systems, and components. The major refurbishment class of activities characterized in the GEIS is intended to encompass actions that typically take place only once in the life of a nuclear plant, if at all (NRC 2013a). For example, replacement of pressurized-water reactor steam generator systems is a refurbishment activity. Refurbishment activities may have an impact on the environment beyond those that occur during normal operations and may require evaluation, depending on the type of action and the plant-specific design.

In preparation for its subsequent license renewal application, FPL evaluated major structures, systems, and components in accordance with 10 CFR 54.21, “Contents of application—technical information,” to identify major refurbishment activities necessary for the continued operation of Turkey Point during the proposed 20-year period of extended operation (FPL 2018a).

FPL did not identify any major refurbishment activities necessary for the continued operation of Turkey Point beyond the end of the current renewed operating license term (FPL 2018f).

2.1.3 Termination of Nuclear Power Plant Operations and Decommissioning after the Subsequent License Renewal Term

NUREG-0586, Supplement 1, Volumes 1 and 2, “Final Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Regarding the Decommissioning of Nuclear Power Reactors” (NRC 2002a) (also known as the decommissioning GEIS), describes the impacts of decommissioning. The majority of plant operations activities would cease with permanent reactor shutdown. However, some activities (e.g., security and oversight of spent nuclear fuel) would remain unchanged, whereas others (e.g., waste management, office and clerical work, laboratory analysis, surveillance, monitoring, and maintenance) would continue at reduced or altered levels. Systems dedicated to reactor operations would cease operations; however, if these systems are not removed from the site after permanent reactor shutdown, their physical presence may continue to impact the environment. Impacts associated with dedicated systems that remain in place or with shared systems that continue to operate at normal capacities could remain unchanged.

Decommissioning will occur whether Turkey Point is permanently shut down at the end of its current renewed operating license term, or at the end of the subsequent period of extended operation 20 years later. There are no site-specific issues related to decommissioning. The license renewal GEIS concludes that license renewal would have a negligible (SMALL) effect on the impacts of terminating operations and decommissioning on all resources (NRC 2013a).

2.2 Alternatives

As stated above, the National Environmental Policy Act of 1969, as amended (NEPA), requires the NRC to consider reasonable alternatives to the proposed action of issuing subsequent renewed operating licenses for Turkey Point. For a replacement power alternative to be reasonable, it must be both (1) commercially viable on a utility scale and (2) operational before the reactor’s operating license expires or expected to become commercially viable on a utility scale and operational before the expiration of the reactor’s operating license (NRC 2013a). The 2013 GEIS incorporates the latest information on replacement power alternatives; however, rapidly evolving technologies are likely to outpace the information in the GEIS. As such, for each supplement to the GEIS, the NRC staff must perform a site-specific analysis of replacement power alternatives that accounts for changes in technology and science since the preparation of the most recent GEIS revision.

The first alternative to the proposed action of the NRC issuing subsequent renewed operating licenses for Turkey Point is for the NRC to not issue the licenses. This is called the no-action alternative. Section 2.2.1 below describes the no-action alternative. In addition to the no-action alternative, this chapter discusses three reasonable replacement power alternatives. These alternatives seek to replace Turkey Point’s generating capacity by meeting the region’s energy needs through other means or sources. Sections 2.2.2.1 through 2.2.2.3 describe replacement power alternatives for Turkey Point. In addition, Section 2.2.3 describes a mechanical draft cooling water system alternative, which the NRC staff evaluated as an alternative to Turkey Point’s use of the existing cooling canal system (CCS) to provide cooling water for Turkey Point Units 3 and 4.

2.2.1 No-Action Alternative

At some point, all operating nuclear power plants will permanently cease operations and undergo decommissioning. The no-action alternative represents a decision by the NRC to not issue renewed operating licenses to a nuclear power plant beyond the current operating license term. Under the no-action alternative, the NRC does not issue the subsequent renewed operating licenses for Turkey Point, such that the units would shut down at or before the expiration of the current licenses in 2032 (Unit 3) and 2033 (Unit 4). The GEIS describes the environmental impacts that arise directly from permanent plant shutdown. The NRC expects shutdown impacts to be relatively similar whether they occur at the end of the current license term (i.e., after 60 years of operation) or at the end of a subsequent renewed license term (i.e., after 80 years of operation).

After permanent shutdown, plant operators will initiate decommissioning in accordance with 10 CFR 50.82, "Termination of license." The decommissioning GEIS (NRC 2002a) describes the environmental impacts from decommissioning a nuclear power plant and related activities.

The analysis in the decommissioning GEIS bounds the environmental impacts of decommissioning at such time as FPL terminates reactor operations at Turkey Point. Chapter 4 of the license renewal GEIS (NRC 2013a) and Section 4.15.2 of this SEIS describe the incremental environmental impacts of subsequent license renewal on decommissioning activities.

Termination of operations at Turkey Point would result in the total cessation of electrical power production by Turkey Point Units 3 and 4, but not the electrical power produced by the balance of the plant (e.g., Turkey Point Unit 5). Unlike the replacement power alternatives described below in Section 2.2.2, the no-action alternative does not expressly meet the purpose and need of the proposed action, as described in Section 1.2, because the no-action alternative does not provide a means of delivering baseload power to meet future electric system needs. Assuming that a need currently exists for the power generated by Turkey Point Units 3 and 4, the no-action alternative would likely create a need for a replacement power alternative. The following section describes a wide range of replacement power alternatives, and Chapter 4 assesses their potential environmental impacts. Although the NRC's authority only extends to deciding whether to renew Turkey Point Units 3 and 4's current renewed operating licenses, the replacement power alternatives described in the following sections represent possible options for energy-planning decisionmakers if the NRC decides not to issue subsequent renewed operating licenses for Turkey Point Units 3 and 4.

Alternatives Evaluated in Depth:

- new nuclear
- natural gas combined-cycle (NGCC)
- combination alternative (NGCC and solar power)

Other Alternatives Considered but Eliminated:

- solar power
- wind power
- biomass
- demand-side management
- hydroelectric power
- geothermal power
- wave and ocean energy
- municipal solid waste
- petroleum-fired power
- coal-fired power
- fuel cells
- purchased power
- delayed retirement of other generating facilities

2.2.2 Replacement Power Alternatives

In evaluating alternatives to subsequent license renewal, the NRC considered energy technologies or options currently in commercial operation, as well as technologies not currently in commercial operation but likely to be commercially available by the time the current Turkey Point renewed operating licenses expire on July 19, 2032 (Unit 3) and April 10, 2033 (Unit 4).

The GEIS presents an overview of some alternative energy technologies but does not conclude which alternatives are most appropriate. Because alternative energy technologies are continually evolving in capability and cost and because regulatory structures have changed to either promote or impede the development of particular technologies, the analyses in this chapter rely on a variety of sources of information to determine which alternatives would be available and commercially viable when the current licenses expire. FPL's environmental report provides a discussion of replacement power alternatives. In addition to the information FPL provided in its environmental report, the NRC staff's analyses in this chapter include updated information from the following sources:

- the U.S. Department of Energy's U.S. Energy Information Administration (EIA)
- other offices within the U.S. Department of Energy (DOE)
- the U.S. Environmental Protection Agency (EPA)
- industry sources and publications

In total, the NRC staff considered 16 replacement power alternatives to the proposed action (see text box) and eliminated 13 of these, which left the three reasonable replacement power alternatives for in-depth evaluation described in Sections 2.2.2.1 through 2.2.2.3. The NRC staff's in-depth evaluation of these three alternatives is presented in Chapter 4.

The staff eliminated from in-depth evaluation those alternatives that could not provide the equivalent of Turkey Point Unit 3 and Unit 4's current generating capacity, as they would not be able to satisfy the objective of replacing the power generated by these Turkey Point units. Also, in some cases, the staff eliminated those alternatives whose costs or benefits could not justify inclusion in the range of reasonable alternatives. Further, the staff eliminated as unfeasible those alternatives not likely to be constructed and operational by the time the Turkey Point licenses expire in 2032 (Unit 3) and 2033 (Unit 4). Section 2.3 of this report contains a brief discussion of each eliminated alternative and provides the basis for its elimination. To ensure that the alternatives considered in the SEIS are consistent with State or regional energy policies, the NRC staff reviewed energy-related statutes, regulations, and policies within the Turkey Point region.

The NRC staff analyzed each alternative on a plant site or region-specific basis, and considered the process used by the applicant to identify reasonable alternatives, including whether sufficient space would be available onsite at Turkey Point to maximize the use of existing infrastructure, or whether alternatives would need to be considered at offsite locations. The evaluation of each alternative considers the environmental impacts across the following impact categories:

- land use and visual resources
- air quality and noise

- geologic environment
- water resources
- ecological resources
- historic and cultural resources
- socioeconomics, human health, environmental justice
- waste management

The GEIS assigns most site-specific issues (called Category 2 issues) a significance level of SMALL, MODERATE, or LARGE. For ecological resources subject to the Endangered Species Act of 1973, as amended (16 U.S.C. 1531 et seq.) (ESA) and the Magnuson–Stevens Fishery Conservation and Management Act of 1996, as amended (16 U.S.C. 1801 et seq.) (MSA); and historic and cultural resources subject to the National Historic Preservation Act of 1966, as amended (54 U.S.C. 300101 et seq.) (NHPA), the impact significance determination language is specific to the authorizing legislation. The order in which this SEIS presents the different alternatives does not imply increasing or decreasing level of impact; nor does the order presented imply that an energy-planning decisionmaker would be more (or less) likely to select any given alternative.

Region of Influence

If the NRC does not issue subsequent renewed licenses, procurement of replacement power for Turkey Point Units 3 and 4 would be necessary. Turkey Point is owned and operated by FPL, which provides electricity through its own bulk transmission system to a 35-county service area concentrated in Southern Florida and along Florida’s Atlantic coast (FPL 2018g). The FPL service territory constitutes the region of influence for the NRC’s analysis of Turkey Point replacement power alternatives. Because FPL has identified a critical need to maintain a balance between load and generating capacity in southeastern Florida (specifically in either Miami-Dade or Broward counties) (FPL 2018f, FPL 2019), the NRC staff accordingly assumed that replacement power alternatives evaluated in this SEIS would be sited within either of those two counties.

In 2016, electric generators in Florida had a net summer generating capacity of approximately 58,000 megawatts (MW). This capacity included units fueled by natural gas (65 percent), coal (17 percent), petroleum (9 percent), and nuclear power (6 percent). Lesser amounts associated with several other miscellaneous energy sources comprised the balance of generating capacity in the State (EIA 2018a).

The electric industry in Florida provided approximately 238 million megawatt hours (MWh) of electricity in 2016. This electrical production was dominated by natural gas (67 percent), coal (17 percent), and nuclear power (12 percent). Petroleum, biomass, and other miscellaneous energy sources collectively produced the other 4 percent of the electricity in Florida (EIA 2018b).

In the United States, natural gas generation rose from 16 percent of electricity generated in 2000 to 31 percent in 2017. Given known technological and demographic trends, the U.S. Energy Information Administration predicts that by 2050, natural gas will account for 35 percent of electricity generated in the United States (EIA 2013a, EIA 2016a, EIA 2018c). Electricity generated from renewable energy is expected to grow from 13 percent of total generation in

2015 to 30 percent in 2050 (EIA 2016a, EIA 2018d). However, Florida’s renewable energy growth may not follow nationwide forecasts. Florida currently obtains only a small portion of its energy from renewable resources, with most of that production primarily generated from biomass, and to a lesser degree from solar and hydroelectric resources (EIA 2017a). The State of Florida does not have a mandatory renewable portfolio standard, and there are other uncertainties that could affect forecasts. In particular, the implementation of policies aimed at reducing greenhouse gas (GHG) emissions could have a direct effect on fossil-fuel-based generation technologies (LBNL 2017a).

The remainder of this section describes in depth the three reasonable replacement power alternatives to Turkey Point subsequent license renewal. These three reasonable alternatives are as follows:

- a new nuclear alternative (Section 2.2.2.1)
- a natural gas combined-cycle alternative (Section 2.2.2.2)
- a combination of natural gas combined-cycle and solar power alternative (Section 2.2.2.3)

Table 2-1 below summarizes key design characteristics of these three alternative replacement power technologies. Section 2.2.3 also describes a possible cooling water system alternative.

Table 2-1 Summary and Key Characteristics of Replacement Power Alternatives Considered In Depth

	New Nuclear Alternative	Natural Gas Combined-Cycle Alternative	Natural Gas Combined-Cycle and Solar Photovoltaic Combination Alternative
Summary of Alternative	Two-unit nuclear plant, each with 750 MWe, for a total of 1,500 MWe	Three 500-MWe units for a total of approximately 1,500 MWe	Approximately 1,420 MWe from natural gas combined-cycle (three units), and 80 MWe from solar PV (four units)
Location	Located within the Turkey Point site, but outside the current footprint of Turkey Point (Units 3 and 4). Also, outside the footprint of Unit 5 (natural gas) and the proposed footprint of Units 6 and 7 (nuclear), which are assumed to be operational. Replacement plant would share existing and planned infrastructure supporting these other units (FPL 2018f).	Located within the Turkey Point site (same location as New Nuclear Alternative). Replacement plant would share existing and planned infrastructure supporting other Turkey Point units. May also require some infrastructure upgrades as well as construction of a new or upgraded pipeline. (FPL 2018f).	Partially located within the Turkey Point site (same location as New Nuclear Alternative for the natural gas combined-cycle plant and one of the four solar PV units; the other three solar PV units would be located at offsite locations within the ROI). Replacement plants would share existing and planned infrastructure supporting other Turkey Point units. May also require some infrastructure upgrades as well as construction of a

	New Nuclear Alternative	Natural Gas Combined-Cycle Alternative	Natural Gas Combined-Cycle and Solar Photovoltaic Combination Alternative
			new or upgraded pipeline. (FPL 2018f).
Cooling System	Closed cycle with mechanical draft cooling towers. Cooling water withdrawal—38 mgd; consumptive water use—29 mgd (NRC 2016a).	Closed cycle with mechanical draft cooling towers. Cooling water withdrawal—10.5 mgd; consumptive water use—8.1 mgd (NETL 2013).	Natural gas combined-cycle units would use closed-cycle cooling systems with mechanical draft cooling towers. Cooling water withdrawal for these units would be 9.9 mgd; consumptive water use would be 7.7 mgd (NETL 2013). No cooling system would be required for the solar facilities.
Land Requirements	Approximately 360 ac (150 ha). (FPL 2018f).	Approximately 75 ac (30 ha) for the plant, with up to an additional 1,200 ac (490 ha) for right-of-way to connect with existing natural gas supply lines north of the site. No new gas wells would be needed to support the facility (FPL 2018f).	Approximately 540 ac (220 ha) onsite at FPL for the natural gas combined-cycle and solar units, with up to an additional 1,200 ac (490 ha) for right-of-way to connect with existing natural gas supply lines north of the site. No new gas wells would be needed. Three offsite solar units would require approximately 470 ac (190 ha) each, for an offsite total of approximately 1,400 ac (570 ha) (FPL 2018f).
Work Force	3,900 workers during peak construction and 800 workers during operations (NRC 2016a).	1,200 workers during peak construction and 150 workers during operations (NRC 2016a).	Natural gas combined-cycle and solar units would collectively require 1,400 workers during peak construction and 160 workers during operations. (NRC 2016a, DOE 2011).

Key: ac = acres, ha = hectares, mgd = million gallons per day, MWe = megawatts electric, NGCC = natural gas combined-cycle (alternative), PV = photovoltaic, and ROI = region of influence.

2.2.2.1 *New Nuclear Alternative*

The NRC staff considers the construction of a new nuclear plant to be a reasonable alternative to Turkey Point subsequent license renewal. Nuclear generation currently provides approximately 12 percent of the electricity in Florida (EIA 2018b). One other nuclear power plant operates in the region of influence: the St. Lucie Plant, Units 1 and 2, is located approximately 130 miles (209 km) north of Turkey Point. The NRC staff determined that there may be sufficient time for FPL to prepare and submit an application, build, and operate two new nuclear units using a certified design before the Turkey Point Units 3 and 4 licenses expire in 2032 and 2033.

In evaluating the new nuclear alternative, the NRC staff assumed that FPL would build two new nuclear reactors on a portion of the approximately 9,500-acre (3,800-ha) Turkey Point property. The construction would allow for the maximum use of existing ancillary facilities (e.g., support buildings and transmission infrastructure at location). In addition to Turkey Point Units 3 and 4, the Turkey Point property currently includes Unit 5 (an operating natural gas combined-cycle unit), as well as generator components from Units 1 and 2 (two retired natural gas/oil units). The Units 1 and 2 generators remain onsite to help stabilize and optimize grid performance, but do not generate power (FPL 2018f).

In 2018, as part of a separate licensing action, the NRC issued combined licenses (COLs) to FPL for the construction and operation of two new AP1000 nuclear reactor units (Turkey Point Units 6 and 7) at the Turkey Point site (NRC 2018e). These proposed new units would have a combined net electrical output of approximately 2,200 MWe and would be constructed on approximately 220 acres (ac) (89 hectares (ha)) immediately south of Turkey Point Units 3 and 4 (NRC 2018f).

For the purpose of this subsequent license renewal analysis, the NRC staff assumed two separate Westinghouse AP1000 reactors would replace Turkey Point Units 3 and 4. The AP1000 reactors would use the same general design as that described in Chapter 3 of NUREG–2176, “Environmental Impact Statement for Combined Licenses (COLs) for Turkey Point Nuclear Plant Units 6 and 7” (NRC 2016a); however, the new nuclear alternative reactors’ location and generating capacity would differ from Turkey Point Units 6 and 7. For the new nuclear alternative, the replacement power facility would be located within the Turkey Point property, but outside the current footprints of Turkey Point Units 3 and 4 and Turkey Point Unit 5, as well as outside the proposed footprint of the not-yet-constructed Turkey Point Units 6 and 7 (FPL 2018f). In addition, the replacement nuclear power facility would be scaled to replace the Turkey Point Units 3 and 4 current net electrical output of approximately 1,500 MWe. This is approximately 32 percent less net electrical output than what the staff evaluated in NUREG–2176 for Turkey Point Units 6 and 7. Accordingly, the heat rejection demands of these new nuclear reactors would also be similar to those of Turkey Point Units 3 and 4. As stated in FPL’s environmental report, the new nuclear alternative would use a mechanical draft cooling tower system. Consistent with the approach and analyses presented in NUREG–2176 (the EIS for the Units 6 and 7 combined licenses), this closed-cycle cooling system would primarily use reclaimed wastewater from the Miami-Dade Water and Sewer Department, with saltwater produced from radial collection wells under Biscayne Bay used as a temporary backup source (FPL 2018f, NRC 2016a). The NRC staff assumes that existing Turkey Point Unit 5 and planned and licensed Turkey Point Units 6 and 7 will continue to be operational during the construction and operation of the new nuclear alternative, and that necessary infrastructure supporting Units 5, 6, and 7 will be available for shared use by the replacement nuclear power facility. Similarly, the NRC staff assumes that the existing

transportation and transmission line infrastructure at Turkey Point will be adequate to support the new nuclear alternative, since Units 3 and 4 would not be operating.

The NRC staff also considered the installation of multiple small modular reactors as a new nuclear alternative to renewing the Turkey Point Units 3 and 4 licenses. The NRC established the Advanced Reactor Program in the Office of New Reactors because of considerable interest in small modular reactors along with anticipated license applications from vendors. Small modular reactors generate approximately 300 MW or less, so they have lower initial capacity than that of traditional large-scale units. However, they have greater siting flexibility because they can fit in locations not large enough to accommodate traditional nuclear reactors (DOE 2018b). The NRC received the first design certification application for a small modular reactor in December 2016 (NRC 2017a). Following NRC certification, this design could potentially achieve operation on a commercial scale by 2026 (NuScale 2018). The NRC staff assumes that the resource requirements and key characteristics associated with constructing and operating small modular reactors would be bounded by the larger nuclear units evaluated in this SEIS.

2.2.2.2 Natural Gas Combined-Cycle Alternative

As discussed earlier, natural gas represents approximately 65 percent of the installed generation capacity and 67 percent of the electrical power generated in Florida (EIA 2018a, EIA 2018b). The NRC staff considers the construction of a natural gas combined-cycle power plant to be a reasonable alternative to Turkey Point subsequent license renewal because natural gas is a feasible, commercially available option for providing baseload electrical generating capacity beyond the expiration of Turkey Point's current licenses.

Baseload natural gas combined-cycle power plants (abbreviated in this section as natural gas plants) have proven their reliability and can have capacity factors as high as 87 percent (EIA 2015a). In a natural gas combined-cycle system, electricity is generated using a gas turbine that burns natural gas. A steam turbine uses the heat from gas turbine exhaust through a heat recovery steam generator to produce additional electricity. This two-cycle process has a high rate of efficiency because the natural gas combined-cycle system captures the exhaust heat that otherwise would be lost and reuses it. Similar to other fossil fuel sources, natural gas power plants are a source of greenhouse gases, including carbon dioxide (CO₂). However, a natural gas combined-cycle power plant produces significantly fewer greenhouse gases per unit of electrical output than conventional coal powered plants (NRC 2013a).

For this alternative, the NRC staff assumes that three natural gas units would be constructed and operated to replace Turkey Point's generating capacity. Each natural gas unit would have a gross capacity of approximately 575 MWe and be operated using an 87 percent capacity factor. Together, the three units would collectively replace Turkey Point's approximate net generating capacity of 1500 MWe. Each unit configuration would consist of two combustion turbine generators, two heat recovery steam generators, and one steam turbine generator with mechanical draft cooling towers for heat rejection. The NRC staff assumes that the natural gas power plant will incorporate a selective catalytic reduction system to minimize the plant's nitrogen oxide emissions (NETL 2007). Natural gas would be extracted from the ground through wells, treated to remove impurities, and then blended to meet pipeline gas standards before being piped through the State's pipeline system to the Turkey Point site. The natural gas alternative would produce waste, primarily in the form of spent catalysts used for control of nitrogen oxide emissions.

Similar to the new nuclear alternative (Section 2.2.2.1), the NRC staff assumes that the natural gas replacement power facility would be built on a portion of the approximately 9,500 ac (3,800 ha) Turkey Point property and would allow for the maximum use of the location's existing ancillary facilities (e.g., support buildings and transmission infrastructure). Approximately 75 ac (30 ha) would be used to construct and operate the natural gas plant (FPL 2018f). Depending on the specific site location and proximity of existing natural gas pipelines, the natural gas alternative may also require up to 1,200 ac (490 ha) of land for right-of-way to connect with existing natural gas supply lines north of the site. In its environmental report, FPL states that no new gas wells would be needed to support the natural gas combined-cycle alternative (FPL 2018f).

The NRC staff assumes that the natural gas combined-cycle plant would use a closed-cycle cooling system with mechanical draft cooling towers. To support the plant's cooling needs, this cooling system would withdraw approximately 10.5 million gallons per day (mgd) (39,000 cubic meters per day (m³/day)) of water and consume 8.1 mgd (31,000 m³/day) of water (NETL 2013). Because of the high overall thermal efficiency of this type of plant, the natural gas combined-cycle alternative would require less cooling water than Turkey Point subsequent license renewal. Onsite visible structures could include the cooling towers, exhaust stacks, intake and discharge structures, transmission lines, natural gas pipelines, and an electrical switchyard. Construction materials could be delivered by a combination of truck and barge.

2.2.2.3 Combination Alternative (Natural Gas Combined-Cycle and Solar)

This alternative combines natural gas and solar replacement power generation to meet the needs and purpose of the Turkey Point subsequent license renewal. Natural gas and solar power generating facilities currently operate within the region of influence. For the purpose of this evaluation, the NRC staff assumes that (1) a natural gas combined-cycle plant would supply 1,420 MWe, and (2) four separate solar power plants would supply approximately 80 MWe. Further, the staff assumes that the natural gas combined-cycle facility and one of the four solar plants would be located within the Turkey Point property and would use existing available site infrastructure to the extent practicable. The other three solar facilities would be located at offsite locations within the region of influence, specifically within Miami-Dade and Broward counties (FPL 2018f).

Natural Gas Combined-Cycle Portion of Combination Alternative

The natural gas portion of the combination alternative would be generated using a natural gas combined-cycle plant located in the ROI. Although similar in function and appearance to the three-unit natural gas plant described in Section 2.2.2.2, the natural gas plant considered under the combination alternative would have slightly less generating capacity. Specifically, the NRC assumes that the plant would consist of three approximately 545 MWe natural gas units that would be constructed and operated using an 87 percent capacity factor (EIA 2015a) to collectively provide an approximate net generating capacity of 1,420 MWe.

Approximately 70 ac (28 ha) of land would be required to construct and operate the natural gas units (FPL 2018f). Depending on the specific site location and proximity of existing natural gas pipelines, the natural gas portion of this alternative may also require up to 1,200 ac (490 ha) of land for right-of-way to connect with existing natural gas supply lines north of the site. In its environmental report, FPL states that no new gas wells would be needed to support a natural gas combined-cycle power plant (FPL 2018f).

The NRC staff assumes that the natural gas plant would use a closed-cycle cooling system with mechanical draft cooling towers. To support the plant's cooling needs, this system would withdraw approximately 9.9 million gallons-per-day (mgd) (37,000 m³/day) of water and consume 7.7 mgd (29,000 m³/day) of water (NETL 2013).

Solar Portion of Combination Alternative

The solar portion of the combination alternative would be generated using solar photovoltaic energy facilities located in the region of influence. For the purpose of this analysis, the NRC assumes that four, approximately 75 MWe, standalone utility-scale solar facilities would be constructed and operated to provide a gross generating capacity of 300 MWe. One of these units would be located on FPL-owned lands in the Turkey Point area, and three units would be located at offsite locations in Miami-Dade County and/or Broward County (FPL 2018f). Assuming a 26-percent capacity factor, the solar units collectively would have an approximate net generating capacity of 80 MWe (FPL 2018f).

Nationwide, growth in utility-scale solar photovoltaic facilities (greater than 1 MW) has resulted in an increase from 70 MW in 2008 to over 20,000 MW installed capacity in 2017 (EIA 2017b). Until recently, the growth of solar energy in Florida has been relatively slow. Although Florida has the third highest solar potential in the Nation, in 2017, the State only ranked 12th in installed capacity with approximately 730 MW. However, by 2019, FPL alone had installed approximately 1,200 MW of solar generating capacity in Florida. Continuing this trend, FPL recently announced plans to install approximately 6,900 MW of additional solar generation capacity over the next decade, and solar energy in Florida is projected to have the most capacity additions overall during that timeframe (EIA 2017a, FPL 2019l).

Solar photovoltaic resources across Florida range from 5.0 to 5.5 kilowatt hours per square meter per day (kWh/m²/day) (NREL 2017). The feasibility of solar energy resources serving as alternative baseload power is dependent on the location, value, accessibility, and constancy of solar radiation. Solar photovoltaic power generation uses solar panels to convert solar radiation into usable electricity. Solar cells are formed into solar panels that can then be linked into photovoltaic arrays to generate electricity. The electricity generated can be stored, used directly, fed into a large electricity grid, or combined with other electricity generators as a hybrid plant. Solar photovoltaic cells can generate electricity whenever there is sunlight, regardless of whether the sun is directly or indirectly shining on the solar panels. Therefore, solar photovoltaic technologies do not need to directly face and track the sun. This capability has allowed solar photovoltaic systems to have broader geographical use than concentrating solar power (which relies on direct sun) (DOE 2011). Because the region of influence contains above-average solar photovoltaic resources and because solar photovoltaic technology is a commercially available option for providing electrical generating capacity, the NRC staff considers the construction of solar photovoltaic facilities to be a reasonable alternative to subsequent license renewal when combined with natural gas combined-cycle facilities.

Utility-scale solar facilities require large areas of land to be cleared for the solar panels. For standalone sites, solar photovoltaic facilities may require approximately 6.2 ac per megawatt (NRC 2013a). Therefore, approximately 470 ac (190 ha) would be required for each of the four proposed solar power installations needed under this alternative (FPL 2018f). Although not all of this land would be cleared of vegetation and permanently impacted, it represents the land enclosed in the total site boundary of the solar facility (NREL 2013). Solar photovoltaic systems do not require water for cooling purposes but do require a small amount of water to clean the panels and for potable water for the workforce.

2.2.3 Cooling Water System Alternative

In addition to replacement power alternatives, this SEIS evaluates an alternative cooling water system technology (mechanical draft cooling towers) for Turkey Point Units 3 and 4 that might be used to mitigate the potential impacts associated with continued use of the existing cooling canal system. The purpose of this analysis is for the NRC staff to compare an alternative closed-cycle cooling system approach with the proposed action to inform the NRC's licensing decision, decisions by other decisionmakers and the public, as applicable, under NEPA. However, the NRC has neither the statutory nor the regulatory authority to determine which system or technology should be used, or to decide other permitting issues, for which the State of Florida has been delegated regulatory authority under the Clean Water Act.

The environmental impacts of the alternative cooling water system are described in this SEIS within the discussion of each separate resource area (e.g., Sections 4.2.7, 4.3.7, 4.4.7, 4.5.7, 4.6.7, 4.7.7, 4.9.4, 4.10.7, 4.11.7, 4.12.4, and 4.13.7). The benefits of the alternative cooling water system are that the impacts of utilizing the CCS for cooling of Turkey Point Units 3 and 4 would be avoided; those impacts are discussed extensively in this SEIS; the avoidance of those impacts of CCS operation (e.g., on groundwater resources), is discussed in Section 4.5.2 (Water Resources: "No-Action Alternative"), in that use of the CCS to cool Units 3 and 4 would cease at the end of the current license terms if the Turkey Point subsequent license renewal (SLR) application is denied.

The NRC staff's analysis of the alternative cooling water system draws upon an application which FPL submitted to the NRC in 2009, for COLs to build and operate two new onsite nuclear reactors (Turkey Point Units 6 and 7). The NRC staff conducted an environmental review of that COL application and published it as NUREG-2176. Section 3.2.2.2 of the COL EIS describes a cooling water system alternative to Turkey Point's existing cooling canal system that consists of onsite mechanical draft cooling towers (NRC 2016a). Under the cooling water system alternative that is evaluated by the NRC staff in this license renewal SEIS, Turkey Point Units 3 and 4 would each use three similar closed-cycle wet-cooling towers (six cooling towers in total) to dissipate heat from the reactor cooling water systems. These mechanical draft water towers would be octagonal in shape and extend approximately 70 feet (20 m) in height and 250 feet (75 m) in diameter (NRC 2016a).

The Units 3 and 4 cooling towers would have the same general design, construction, and operating characteristics as the cooling water system associated with the new nuclear alternative described in Section 2.2.2.1 of this SEIS, although additional engineering complexities and costs could be associated with detailed designs for retrofitting Turkey Point's cooling water system in this manner. As in the new nuclear alternative, the primary source of cooling water is assumed to be reclaimed wastewater. Similarly, as summarized in Table 2-1 of this SEIS, cooling water makeup would be approximately 38 mgd (144,000 m³/day) and consumptive water use would be approximately 29 mgd (110,000 m³/day). Other discrete resource requirements associated with constructing and operating these cooling towers would be a subset of the overall resource requirements identified in NUREG-2167 (the EIS for the Turkey Point Units 6 and 7 combined licenses) in Tables 3-4 and 3-6 (NRC 2016a).

The CCS would continue to operate regardless of the proposed Turkey Point subsequent license renewal because it supports retired fossil fuel Units 1 and 2. FPL plans to continue to use water from the CCS to support the operation of these units in synchronous condenser mode over the course of the proposed subsequent license renewal period, as described in Section 3.1.3, "Cooling and Auxiliary Water Systems." Additionally, fossil fuel Unit 5 would

remain in operation and would continue to discharge blowdown to the CCS. Furthermore, the CCS-related requirements of the October 7, 2015, Consent Agreement between FPL and Miami-Dade County (MDC 2015a) and the June 20, 2016, Consent Order between FPL and the Florida Department of Environmental Protection (FDEP 2016a), both of which are discussed in detail in Section 3.5.1.4, “Adjacent Surface Water Quality and Cooling Canal System Operation,” as well as in Section 3.5.2.2, “Groundwater Quality,” of this SEIS, would continue to apply.

2.3 Alternatives Considered but Eliminated

The NRC staff originally considered 16 replacement power alternatives to Turkey Point Unit 3 and 4’s subsequent license renewal, but ultimately eliminated 13 of these from detailed study. The staff eliminated these 13 alternatives because of technical reasons, resource availability limitations, or commercial or regulatory limitations. Many of these limitations will likely still exist when the current Turkey Point licenses expire in 2032 and 2033, such that these 13 alternatives are not expected to be reasonably available when needed to replace the power generated by Turkey Point Units 3 and 4.

2.3.1 Solar Power

Solar power, including solar photovoltaic (PV) and concentrating solar power (CSP) technologies, produce power generated from sunlight. Solar photovoltaic components convert sunlight directly into electricity using solar cells made from silicon or cadmium telluride. Concentrating solar power uses heat from the sun to boil water and produce steam. The steam then drives a turbine connected to a generator to ultimately produce electricity (NREL 2014).

Solar generators are considered an intermittent resource because their availability depends on ambient exposure to the sun, also known as solar insolation (EIA 2017c). Insolation rates of solar photovoltaic resources in Florida range from 5.0 to 5.5 kWh/m²/day (NREL 2017a). Due to higher solar insolation requirements associated with concentrating solar power, utility-scale application of this technology has generally only occurred in western States with high solar thermal resources and large, contiguous tracts of land in arid environments (i.e., California, Arizona, and Nevada) (EIA 2016c). The exception is FPL’s Martin generating station, the only concentrating solar power plant east of the Rocky Mountains, which produced approximately 22 percent of the state’s utility-scale net solar generation in 2016 (EIA 2017d).

Although Florida has abundant solar resource potential, it generates only a small part of its energy from solar or other renewable resources (EIA 2017a). In addition, Florida does not have a mandatory renewable portfolio standard that would require generators to consider solar power (EIA 2017a). To be considered a viable alternative, a solar alternative must replace the amount of electricity that Turkey Point provides. Assuming capacity factors of 25 percent (for solar photovoltaic) to 50 percent (for concentrating solar) (DOE 2011), approximately 3,000 to 6,000 MWe of additional gross solar capacity would need to be installed in locations servicing southeastern Florida. As discussed in Section 2.2.2.3, FPL plans to install approximately 6,900 MW of additional solar photovoltaic generating capacity within the next decade. This increased solar capacity, however, would be used to replace or augment existing capacity and/or meet forecasted demand, and would not be available as a reasonable alternative for replacement of Turkey Point Units 3 and 4 (FPL 2019I). Further, although FPL has announced plans to substantially increase its share of solar photovoltaic generating capacity across its service area over the next decade, the amount of this additional capacity that would be sited in

Miami-Dade or Broward Counties would be insufficient to maintain the required balance between load and generating capacity (EIA 2017a, FPL 2018f, FPL 2019l).

Considering the above factors, the NRC staff concludes that solar power energy facilities alone do not provide a reasonable alternative to Turkey Point subsequent license renewal. However, the NRC staff does consider an alternative using solar power in combination with natural gas combined-cycle power, as described above in Section 2.2.2.3.

2.3.2 Wind Power

As is the case with other renewable energy sources, the feasibility of wind power serving as alternative baseload power is dependent on the location (relative to expected electricity users), value, accessibility, and constancy of the resource. Wind energy must be converted to electricity at or near the point where it is extracted, and currently there are limited energy storage opportunities available to overcome the intermittency and variability of wind resources.

To be considered a reasonable replacement power alternative to Turkey Point subsequent license renewal, the wind power alternative must replace the amount of electricity that Turkey Point provides. Assuming a capacity factor of 35 percent for land-based wind and 40 percent for offshore wind, a combination of land-based and offshore wind energy facilities in the region of influence would have to generate a range of approximately 3,750 to 4,300 MWe of electricity.

The American Wind Energy Association reports a total of more than 90,000 MW of installed wind energy capacity nationwide as of March 31, 2018 (DOE 2018d). Texas leads all other States in installed land-based wind energy capacity with over 23,000 MW. In contrast, Florida currently has no installed land-based wind power capacity and little overall wind potential to support the development of future wind energy systems (DOE 2018a, EIA 2017a).

Similarly, Florida does not have any utility-scale offshore wind farms in operation. In 2016, a 30 MW project off the coast of Rhode Island became the first operating offshore wind farm in the United States (Energy Daily 2016). Although approximately 20 offshore wind projects representing more than 15,000 MW of capacity were in the planning and permitting process as of 2015, most of these projects are concentrated along the North Atlantic coast, and none are currently planned off the shores of Florida (EIA 2015b, DOE 2018a).

Given the amount of wind capacity necessary to replace Turkey Point, the intermittency of the resource, the current lack of any installed wind capacity in the State, and the limited potential for any new development in the region of influence, the NRC staff finds a wind-based alternative—either land based, offshore, or some combination of the two—to be an unreasonable alternative to Turkey Point subsequent license renewal.

2.3.3 Biomass Power

Using biomass-fired generation for baseload power depends on the geographic distribution, available quantities, constancy of supply, and energy content of biomass resources. For this analysis, the NRC staff assumed that biomass would be combusted for power generation in the electricity sector. Biomass is also used for space heating in residential and commercial buildings and can be converted to a liquid form for use in transportation fuels.

Biomass fuels are abundant in Florida, and currently provide the largest share of Florida's renewable electricity generation (EIA 2017a). In 2016, Florida had a total installed capacity of

approximately 1,300 MW, and approximately 2 percent of the State's total system power was produced from biomass (EIA 2018a, EIA 2018b).

For utility-scale biomass electricity generation, the NRC staff assumes that the technologies used for biomass conversion would be similar to fossil fuel plants, including the direct combustion of biomass in a boiler to produce steam (NRC 2013a). Biomass generation is generally more cost effective when co-fired with coal plants (IEA 2007). In 2013, Florida opened the 103-MW Gainesville Renewable Energy Center, one of the largest new biomass plants in the United States (EIA 2016b). Replacing the generating capacity of Turkey Point using only biomass would require the construction of approximately 15 additional facilities of this size. However, most biomass-fired generation plants generally only reach capacities of 50 MW, which means replacing the generating capacity of Turkey Point would require the construction of twice as many new average-sized biomass facilities. Sufficiently increasing biomass-fired generation capacity by expanding existing biomass units or constructing new biomass units by the time Turkey Point's licenses expire in 2032 and 2033, is unlikely. For this reason, the NRC staff does not consider biomass-fired generation to be a reasonable alternative to Turkey Point subsequent license renewal.

2.3.4 Demand-Side Management

Energy conservation can include reducing energy demand through behavioral changes or altering the shape of the electricity load, and usually does not require the addition of new generating capacity. Conservation and energy efficiency programs are more broadly referred to as demand-side management.

Conservation and energy efficiency programs can be initiated by a utility, transmission operators, the State, or other load-serving entities. In general, residential electricity consumers have been responsible for the majority of peak load reductions and participation in most programs is voluntary. Therefore, the existence of a program does not guarantee that reductions in electricity demand would occur. The GEIS concludes that, although the energy conservation or energy efficiency potential in the United States is substantial, the NRC staff is aware of no cases where an energy efficiency or conservation program alone has been implemented expressly to replace or offset a large baseload generation station (NRC 2013a).

FPL estimates that demand-side management efforts from 1978 to 2017 have resulted in a total savings of approximately 4,800 MW across its service territory (FPL 2018g). In 2014, the Florida Public Services Commission established FPL's current demand-side management goals, and FPL has accounted for these goals in its planning process through at least 2027. However, it is unlikely that further cost-effective reductions in electrical demand, particularly in Broward and Miami-Dade counties, could replace Turkey Point's generation (FPL 2018f). Therefore, the NRC staff does not consider demand-side management and energy efficiency programs to be a reasonable alternative to Turkey Point subsequent license renewal.

2.3.5 Hydroelectric Power

Currently, approximately 2,000 hydroelectric facilities operate in the United States. Hydroelectric technology captures flowing water and directs it to a turbine and generator to produce electricity (NRC 2013a). There are three variants of hydroelectric power: (1) run-of-the-river (diversion) facilities that redirect the natural flow of a river, stream, or canal through a hydroelectric facility, (2) store-and-release facilities that block the flow of the river by using dams that cause water to accumulate in an upstream reservoir, and (3) pumped storage

facilities that use electricity from other power sources to pump water to higher elevations during off-peak load periods to be released during peak load periods through the turbines to generate additional electricity.

A comprehensive survey of hydropower resources, completed in 1997, identified Florida as having only 43 MW of potential hydroelectric capacity when adjusted for environmental, legal, and institutional constraints (Conner et. al., 1998). These constraints could include (1) scenic, cultural, historical, and geological values, (2) Federal and State land use, and (3) legal protection issues, such as wild and scenic legislation and threatened or endangered fish and wildlife legislative protection. A separate DOE assessment of non-powered dams (dams that do not produce electricity) concludes that there is potential for 173 MW of electricity in Florida (ORNL 2012). These non-powered dams serve various purposes, such as providing water supply to inland navigation. However, hydroelectric power accounted for less than one percent of the State's electric power production in 2016 (EIA 2018b). Although the U.S. Energy Information Administration projects that hydropower will remain a leading source of renewable generation in the United States through 2040, there is little expected growth in hydropower capacity (EIA 2013a). The potential for future construction of large hydropower facilities has diminished because of increased public concerns over flooding, habitat alteration and loss, and destruction of natural river courses (NRC 2013a).

Given the projected lack of growth in hydroelectric power production, the low potential capacity in Florida, the competing demands for water resources, and the expected public opposition to the large environmental impacts and significant changes in land use that would result from the construction of hydroelectric facilities, the NRC staff concludes that the expansion of hydroelectric power is not a reasonable alternative to Turkey Point subsequent license renewal.

2.3.6 Geothermal Power

Geothermal technologies extract the heat contained in geologic formations to produce steam to drive a conventional steam turbine generator. Facilities producing electricity from geothermal energy have demonstrated capacity factors of 95 percent or greater, making geothermal energy a potential source of baseload electric power. However, the feasibility of geothermal power generation to provide baseload power depends on the regional quality and accessibility of geothermal resources. Utility-scale geothermal energy generation requires geothermal reservoirs with a temperature above 200 °F (93 °C). Known geothermal resources are concentrated in the western United States, specifically Alaska, Arizona, California, Colorado, Hawaii, Idaho, Montana, Nevada, New Mexico, Oregon, Utah, Washington, and Wyoming. In general, most assessments of geothermal resources have been concentrated on these western States (DOE 2013a, USGS 2008a). Geothermal resources are used in the Turkey Point region of influence for heating and cooling purposes, but no electricity is currently being produced from geothermal resources in the region of influence (EIA 2017e). Given the low resource potential in the region of influence, the NRC staff does not consider geothermal to be a reasonable alternative to Turkey Point subsequent license renewal.

2.3.7 Wave and Ocean Energy

Waves, currents, and tides are often predictable and reliable, making them attractive candidates for potential renewable energy generation. Four major technologies may be suitable to harness wave energy: (1) terminator devices that range from 500 kilowatts to 2 MW, (2) attenuators, (3) point absorbers, and (4) overtopping devices (BOEM undated). Point absorbers and attenuators use floating buoys to convert wave motion into mechanical energy, driving a

generator to produce electricity. Overtopping devices trap a portion of a wave at a higher elevation than the sea surface; waves then enter a tube and compress air that is used to drive a generator that produces electricity (NRC 2013a). Some of these technologies are undergoing demonstration testing at commercial scales, but none are currently used to provide baseload power (BOEM undated).

Resource assessments show that modest energy production potential is associated with the Florida Current of the Gulf Stream along Florida's southeastern coast (DOE 2018c). However, wave and ocean energy generation technologies are still in their infancy and currently lack commercial application. For these reasons, the NRC staff does not consider wave and ocean energy to be a reasonable alternative to Turkey Point subsequent license renewal.

2.3.8 Municipal Solid Waste

Energy recovery from municipal solid waste converts non-recyclable waste materials into usable heat, electricity, or fuel through combustion (EPA 2014a). The three types of combustion technologies include mass burning, modular systems, and refuse-derived fuel systems (EPA 2014b). Mass burning is the method used most frequently in the United States. The heat released from combustion is used to convert water to steam, which is used to drive a turbine generator to produce electricity. Ash is collected and taken to a landfill, and particulates are captured through a filtering system (EPA 2014b). As of 2016, 77 waste-to-energy plants are in operation in 22 States, processing approximately 30 million tons of waste per year. These waste-to-energy plants have an aggregate capacity of 2,547 MWe. Although some plants have expanded to handle additional waste and to produce more energy, no new plants have been built in the United States since 1995 (EPA 2014a, Michaels 2016). The average waste-to-energy plant produces about 50 MWe, with some reaching 77 MWe, and can operate at capacity factors greater than 90 percent (Michaels 2010). In 2017, municipal solid waste accounted for approximately 450 MW of Florida's electrical capacity (FDACS 2017). Approximately 30 average-sized waste-to-energy plants would be necessary to provide the same level of output as Turkey Point Units 3 and 4.

The decision to burn municipal waste to generate energy is usually driven by the need for an alternative to landfills rather than a need for energy. Given the improbability that additional stable supplies of municipal solid waste would be available to support 30 new facilities in the region of influence, the NRC staff does not consider municipal solid waste combustion to be a reasonable alternative to Turkey Point subsequent license renewal.

2.3.9 Petroleum-Fired Power

Petroleum-fired electricity generation accounted for approximately 1 percent of Florida's statewide total electricity generation in 2016 (EIA 2018b). The variable costs and environmental impacts of petroleum-fired generation tend to be greater than those of natural gas-fired generation. The historically higher cost of oil has also resulted in a steady decline in its use for electricity generation, and the U.S. Energy Information Administration forecasts no growth in capacity using petroleum-fired power plants through 2040 (EIA 2013a, EIA 2015c). Therefore, the NRC staff does not consider petroleum-fired generation to be a reasonable alternative to Turkey Point subsequent license renewal.

2.3.10 Coal-Fired Power

Although coal has historically been the largest source of electricity in the United States, the U.S. Energy Information Administration expects natural gas generation—and potentially even renewable energy generation—to surpass coal generation at the national level by 2040 (EIA 2016a). Florida exemplifies this trend, with coal historically fueling the largest share of electricity generated in the state until 2003, when it was surpassed by natural gas (EIA 2017a). In 2016, coal-fired generation accounted for approximately 17 percent of all electricity generated in Florida, a 21-percent decrease from 2000 levels (EIA 2018b).

Baseload coal units have proven their reliability and can routinely sustain capacity factors as high as 85 percent. Among the technologies available, pulverized coal boilers producing supercritical steam (supercritical pulverized coal or SCPC boilers) are increasingly common for new coal-fired plants given their generally high thermal efficiencies and overall reliability. Supercritical pulverized coal facilities are more expensive than subcritical coal-fired plants to construct, but they consume less fuel per unit output, reducing environmental impacts. In a supercritical coal-fired power plant, burning coal heats pressurized water. As the supercritical steam and water mixture moves through plant pipes to a turbine generator, the pressure drops and the mixture flashes to steam. The heated steam expands across the turbine stages, which then spin and turn the generator to produce electricity. After passing through the turbine, any remaining steam is condensed back to water in the plant's condenser. Integrated gasification combined cycle is another technology that generates electricity from coal. It combines modern coal gasification technology with both gas turbine and steam turbine power generation. The technology is cleaner than conventional pulverized coal plants because some of the major pollutants are removed from the gas stream before combustion.

An integrated gasification combined-cycle power plant consists of coal gasification and combined-cycle power generation. Coal gasifiers convert coal into a gas (synthesis gas, also referred to as syngas), which fuels the combined-cycle power generating units. Nearly 100 percent of the nitrogen from the syngas is removed before combustion in the gas turbines and this results in lower nitrogen oxide emissions when compared to conventional coal fired power plants (DOE 2010).

Although several smaller, integrated gasification combined-cycle power plants have been in operation since the mid-1990s, more recent large-scale projects using this technology have experienced a number of setbacks and opposition that have hindered the technology from fully integrating into the energy market. The most significant roadblock has been the high capital cost of an integrated gasification combined-cycle power plant as compared to conventional coal-fired power plants. Both the Duke Energy Edwardsport Generation Station project in Indiana and the Kemper County integrated gasification combined-cycle project in east central Mississippi have experienced cost and schedule overruns. The Kemper County project suspended work towards startup of the gasifier component in June 2017 (Energy Daily 2017). Other issues associated with integrated gasification combined cycle include a limited track record for reliable performance and opposition based on environmental concerns. In its environmental report, FPL states that it currently has no plans to add new coal-fired generation to its energy production portfolio (FPL 2018f). Based upon these considerations, the NRC staff concludes that coal-fired technologies do not provide a reasonable source of baseload power to replace Turkey Point Units 3 and 4 by the time their current licenses expire in 2032 and 2033.

2.3.11 Fuel Cells

Fuel cells oxidize fuels without combustion and therefore without the environmental side effects of combustion. Fuel cells use a fuel (e.g., hydrogen) and oxygen to create electricity through an electrochemical process. The only byproducts are heat, water, and carbon dioxide (depending on the hydrogen fuel type) (DOE 2013b). Hydrogen fuel can come from a variety of hydrocarbon resources. Natural gas is a typical hydrogen source.

Fuel cells are not economically or technologically competitive with other alternatives for electricity generation. The U.S. Energy Information Administration estimates that fuel cells may cost \$7,108 per installed kilowatt (total overnight capital costs in 2012 dollars), which is high compared to other alternative technologies analyzed in this section (EIA 2013b). More importantly, fuel cell units are likely to be small in size (approximately 10 MW). The world's largest fuel cell facility is a 59 MWe plant that came online in South Korea in 2014 (PEI 2017). Using fuel cells to replace the power that Turkey Point provides would be extremely costly. It would require the construction of approximately 150 average-sized units and modifications to the existing transmission system. Given the immature status and high cost of fuel cell technology, the NRC staff does not consider fuel cells to be a reasonable alternative to Turkey Point subsequent license renewal.

2.3.12 Purchased Power

It is possible that replacement power may be imported from outside the Turkey Point region of influence. Although purchased power would likely have little or no measurable environmental impact in the vicinity of Turkey Point, impacts could occur where the power is generated or anywhere along the transmission route, depending on the generation technologies used to supply the purchased power (NRC 2013a). In addition, purchased power could require the construction of new transmission facilities to import the power from outside the Turkey Point region to service Miami-Dade and Broward counties.

As discussed in its report, "2018–2027 Ten Year Power Plant Site Plan," FPL purchases power from generation sources outside of its service area (FPL 2018g). In 2016 and 2017, FPL purchased 826 MW of firm capacity generation from other such facilities. However, two coal-fired units at the St. John's River Power Park, in Jacksonville, FL, which provided 382 MW of FPL's purchased power, retired in January 2018 (FPL 2018f, FPL 2018g). FPL also projects that it will cancel a 330 MW purchase power agreement with a separate coal-fired facility by 2020 because it is no longer cost-effective. Overall, FPL's firm capacity purchases are expected to average only 250 MW over the next decade (FPL 2018g).

Additionally, purchased power is generally economically adverse because the cost of generated power historically has been less than the cost of the same power provided by a third party (NRC 2013a). Power purchase agreements also carry the inherent risk that the other plant will not deliver the contracted power.

Based on these considerations, the NRC staff concludes that purchased power does not provide a reasonable alternative to Turkey Point subsequent license renewal.

2.3.13 Delayed Retirement

The retirement of a power plant ends its ability to supply electricity. Delaying the retirement of a power plant enables it to continue supplying electricity. A delayed retirement alternative would delay the retirement of generating facilities within or near the region of influence.

Power plant retirement occurs for several reasons. Because generators are required to adhere to additional regulations that will require significant reductions in plant emissions, some power plants may opt for early retirement of older units rather than incur the cost for compliance. Additional retirements may be driven by low natural gas prices, slow growth in electricity demand, and requirements of the Mercury and Air Toxics Standards (EIA 2015c, EPA 2015).

Most units that are near or past retirement age generate more pollutants and are less efficient than new units. Often, utility owners retire units because operation is no longer economical. In some cases, the cost of environmental compliance or necessary repairs or upgrades are too great to justify continued operation.

FPL reviews its existing fleet for cost-effective opportunities to modernize the fleet and extend operations, as well as to evaluate the need to close older inefficient plants. In its “2018–2027 Ten Year Power Plant Site Plan,” FPL identifies the company’s intention to retire two large (approximately 800 MW) generating units at its Martin facility by 2019. These units have been in operation for nearly 40 years and are relatively inefficient. FPL is in the process of modernizing several of its gas-fired generation facilities within its service area, and these ongoing efforts will only partially offset the loss of the Martin units (FPL 2018g). However, FPL has not identified opportunities within its existing fleet that would provide for the replacement of Turkey Point’s net generation (FPL 2018f).

Because of these conditions, the NRC staff concludes that delayed retirement does not provide a reasonable alternative to Turkey Point subsequent license renewal.

2.4 Comparison of Alternatives

In this chapter, the NRC staff considered in depth one alternative to Turkey Point subsequent license renewal that does not replace the plant’s energy generation (the no-action alternative) and three alternatives to subsequent license renewal that may reasonably replace Turkey Point’s energy generation. These three replacement power alternatives are (1) new nuclear generation, (2) natural gas combined-cycle generation, and (3) a combination of natural gas combined-cycle generation and solar photovoltaic generation. The environmental impacts of the proposed action and of the alternatives are described and assessed in Chapter 4. Table 2-2 summarizes the environmental impacts of the three replacement power and alternate cooling water system alternatives to Turkey Point subsequent license renewal.

The environmental impacts of the proposed action (subsequent renewal of the Turkey Point operating licenses) would be SMALL for all impact categories except for groundwater resources and aquatic resources. The impacts to groundwater resources range from SMALL to MODERATE because of groundwater use conflicts and because the site-specific impacts of the Category 1 Issue, Groundwater Quality Degradation (Plants with Cooling Ponds in Salt Marshes), are assessed as MODERATE for current and continued operations during the initial license renewal term but are projected to be SMALL during subsequent license renewal. Due to

impingement, entrainment, and thermal impacts on the aquatic organisms in the canal cooling system, the impact of the Turkey Point subsequent license renewal to aquatic resources would be SMALL to MODERATE.

In comparison, each of the three reasonable replacement power alternatives have environmental impacts in at least two resource areas that are greater than the environmental impacts of the proposed action of subsequent license renewal. In addition, the replacement power alternatives also involve the environmental impacts inherent to new construction projects. If the NRC adopts the no-action alternative and does not issue subsequent renewed licenses for Turkey Point, energy-planning decisionmakers would likely implement one of the three replacement power alternatives discussed in-depth in this chapter and in Chapter 4. Based on the NRC staff's review of these three replacement power alternatives, the no-action alternative, and the proposed action, the staff concludes that the environmentally preferred alternative is the proposed action of subsequent license renewal. Therefore, the NRC staff proposes to recommend that the NRC issue subsequent renewed operating licenses for Turkey Point Units 3 and 4.

Table 2-2 Summary of Environmental Impacts of the Proposed Action and Alternatives

Impact Area (Resource)	Turkey Point Subsequent License Renewal (Proposed Action)	No-Action Alternative	New Nuclear Alternative	Natural Gas Combined-Cycle Alternative	Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic)	Cooling Water System Alternative
Land Use	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL to LARGE	SMALL
Visual Resources	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL to LARGE	SMALL to MODERATE
Air Quality	SMALL	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL
Noise	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE
Geologic Environment	SMALL	SMALL	SMALL	SMALL	MODERATE	SMALL
Surface Water Resources	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Groundwater Resources	SMALL to MODERATE	SMALL	SMALL	SMALL	SMALL	SMALL
Terrestrial Resources	SMALL	SMALL	MODERATE	MODERATE	MODERATE	MODERATE
Aquatic Resources	SMALL to MODERATE	SMALL	MODERATE to LARGE	MODERATE to LARGE	MODERATE to LARGE	MODERATE
Special Status Species and Habitats	See Note ^(a)	See Note ^(b)	See Note ^(b)	See Note ^(b)	See Note ^(b)	See Note ^(b)
Historic and Cultural Resources	See Note ^(c)	See Note ^(d)	See Note ^(e)	See Note ^(e)	See Note ^(f)	See Note ^(e)
Socioeconomics	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL	SMALL
Transportation	SMALL	SMALL	SMALL to LARGE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE
Human Health	SMALL ^(g)	SMALL ^(g)	SMALL ^(g)	SMALL ^(g)	SMALL ^(g)	SMALL ^(g)
Environmental Justice	See Note ^(h)	See Note ⁽ⁱ⁾	See Note ⁽ⁱ⁾	See Note ⁽ⁱ⁾	See Note ^(k)	See Note ^(l)
Waste Management and Pollution Prevention	SMALL ^(l)	SMALL ^(l)	SMALL ^(l)	SMALL	SMALL	SMALL

Impact Area (Resource)	Turkey Point Subsequent License Renewal (Proposed Action)	No-Action Alternative	New Nuclear Alternative	Natural Gas Combined-Cycle Alternative	Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic)	Cooling Water System Alternative
------------------------	---	-----------------------	-------------------------	--	---	----------------------------------

- (a) The NRC staff concludes that Turkey Point subsequent license renewal is likely to adversely affect the American crocodile and the eastern indigo snake, and may result in adverse modification to designated critical habitat of the American crocodile. The NRC staff concludes that proposed action may affect, but is not likely to adversely affect, the Florida panther, West Indian manatee, red knot, wood stork, loggerhead sea turtle, green sea turtle, leatherback sea turtle, hawksbill sea turtle, Kemp's ridley sea turtle, and smalltooth sawfish. The NRC staff concludes that the proposed action would result in no adverse modification to designated critical habitat of the West Indian manatee. The NRC staff's evaluation of impacts to federally listed species and critical habitats under the U.S. Fish and Wildlife Service's jurisdiction appears in the NRC's Biological Assessment (NRC 2018n). The FWS's separate evaluation and conclusions appear in a July 25, 2019, biological opinion (FWS 2019b), which is described in Section 4.8.1.1 of this SEIS. The NRC staff's evaluation of impacts to federally listed species and critical habitats under the National Marine Fisheries Service's jurisdiction appears in Section 4.8.1.1 of this SEIS. The NRC staff concludes that the proposed action would have no adverse effects on Essential Fish Habitat. The NRC staff's evaluation of impacts to Essential Fish Habitat appears in Section 4.8.1.2 of this SEIS. The NRC staff concludes that the proposed action would not affect the sanctuary resources of the Florida Keys National Marine Sanctuary. The NRC staff's evaluation of sanctuary resources appears in Section 4.8.1.3 of this SEIS.
- (b) The types and magnitudes of adverse impacts to species listed pursuant to the Endangered Species Act of 1973, as amended (16 U.S.C. 1531 et seq.), designated critical habitat, and Essential Fish Habitat would depend on Turkey Point shutdown activities, the proposed alternative site, plant design, and operation, as applicable, and on the listed species and designated critical habitats present when the alternative is implemented. Therefore, the NRC staff cannot forecast a particular level of impact for this alternative.
- (c) Based on (1) the location of National Register of Historic Places-eligible historic properties within the area of potential effect, (2) tribal input, (3) FPL's cultural resource protection plans, (4) the fact that no license renewal-related physical changes or ground-disturbing activities would occur, (5) Florida State Historic Preservation Office input, and (6) cultural resource assessment, license renewal would not adversely affect any known historic properties (Title 36 of the *Code of Federal Regulations* 800.4(d)(1), "No Historic Properties Affected").
- (d) As a result of facility shutdown, land-disturbing activities or dismantlement are not anticipated as these would be conducted during decommissioning. Therefore, facility shutdown would have no immediate effect on historic properties or historic and cultural resources.
- (e) Since the alternative would be located at the Turkey Point site, which has a low archeological potential, and avoidance of significant resources would be possible, this alternative would not adversely affect known historic properties.
- (f) The impacts from the construction and operation of the solar component would depend on where solar facilities are constructed. The historic and cultural resource impact could range from no adverse effect to adverse effect.
- (g) The chronic effects of electromagnetic fields on human health associated with operating nuclear power and other electricity generating plants are uncertain.
- (h) There would be no disproportionately high and adverse impacts to minority and low-income populations.
- (i) A reduction in tax revenue resulting from the shutdown of Turkey Point could decrease the availability of public services in the Turkey Point area. However, the effects to minority and low-income populations would not be disproportionately high and adverse.

Impact Area (Resource)	Turkey Point Subsequent License Renewal (Proposed Action)	No-Action Alternative	New Nuclear Alternative	Natural Gas Combined-Cycle Alternative	Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic)	Cooling Water System Alternative
------------------------	---	-----------------------	-------------------------	--	---	----------------------------------

- (j) Based on the analysis of human health and environmental impacts presented in this SEIS, the location of the alternative, and the assumed alternative design and characteristics, this alternative would not likely have disproportionately high and adverse human health and environmental effects on minority and low-income populations.
- (k) This alternative would not likely have disproportionately high and adverse human health and environmental effects on minority and low-income populations. However, this determination would depend on the location of the solar facilities. Therefore, the NRC staff cannot determine whether the solar portion of the combination alternative would result in disproportionately high and adverse human health and environmental effects on minority and low-income populations.
- (l) NUREG-2157, "Generic Environmental Impact Statement for Continued Storage of Spent Nuclear Fuel," (NRC 2014c) discusses the environmental impact of spent fuel storage for the timeframe beyond the licensed life for reactor operations.

3 AFFECTED ENVIRONMENT

In conducting its environmental review of the Turkey Point Nuclear Generating Unit Nos. 3 and 4 (Turkey Point, or Turkey Point Units 3 and 4) subsequent license renewal application, the U.S. Nuclear Regulatory Commission (NRC) first defines and describes the environment that could be affected by the subsequent license renewal. For this review, the NRC staff defines the affected environment as the environment that currently exists at and around the Turkey Point site. Because existing conditions are at least partially the result of past construction and operations at the plant, this chapter presents the nature and impacts of these past actions as well as ongoing actions, and evaluates how, together, these actions have shaped the current environment. The effects of ongoing reactor operations at Turkey Point have become well established as environmental conditions have adjusted to the presence of the nuclear power plant. Sections 3.2 through 3.13 describe the affected environment for each resource area. The resource discussions in this chapter include new and updated information that became available since the NRC issued the supplemental environmental impact statement (SEIS) for the initial Turkey Point license renewal in 2002, as NUREG-1437, Supplement 5 (NRC 2002c).

3.1 Description of Nuclear Power Plant Facility and Operation

The physical presence of Turkey Point buildings and facilities, as well as the plant's operations, are integral to the environment that currently exists at and around the site. This section describes Turkey Point buildings, certain nuclear power plant operating systems, and certain plant infrastructure, operations, and maintenance.

3.1.1 External Appearance and Setting

Turkey Point is located on the southeastern coast of Florida in unincorporated southeastern Miami-Dade County (Figure 3-1). The site borders Biscayne Bay and Card Sound. Turkey Point is approximately 25 miles (mi) (40 kilometers (km)) south-southwest of the city of Miami, which is the largest population center in the region with an estimated population of 424,632. Portions of Homestead Air Reserve Base and the cities of Florida City and Homestead are located within approximately 9 mi (14.5 km) of the Turkey Point site. Miami, Florida City, Homestead, Homestead Air Reserve Base, and Turkey Point are all located in Miami-Dade County, FL. Florida City is located approximately 9 mi (14.5 km) west of Turkey Point and has an estimated population of 12,000. The city of Homestead is located approximately 9 mi (14.5 km) west-northwest of Turkey Point and has an estimated population of 65,000. Homestead Air Reserve Base is located approximately 6 mi (9.7 km) northwest of Turkey Point and has an estimated population of 1,100 (FPL 2018f).

Turkey Point Units 3 and 4 are two pressurized-water nuclear reactors located on approximately 9,460 acres (ac) (38.3 kilometers squared (km²)) of FPL-owned land. In addition to nuclear generating Units 3 and 4, the Turkey Point site also houses three fossil fuel power plants: Units 1 and 2 are retired, natural-gas/oil steam-generating units; and Unit 5 is an operating, natural-gas combined-cycle steam generating unit. In addition to these five currently operating and retired units, the Turkey Point site also features a 5,900-ac (24 km²) artificial body of water called the cooling canal system (CCS). This network of canals forms a recirculating source of water that is used by Units 3 and 4 for reactor heat rejection. Unit 5 does not use the cooling canals for heat rejection but does use the CCS for stormwater discharge and cooling water blowdown. The principal structures for Turkey Point Units 3 and 4 are the reactor containments,

auxiliary building, control building, turbine building, radioactive waste management building, intake structure, discharge structures, steam generator storage compound, and administration building. The main structures outside the power block are an independent spent fuel storage installation (ISFSI), a sewage treatment plant, a 230-kilovolt (kV) switchyard, a meteorological tower, the cooling water intake canal, the cooling water discharge canal, and the 5,900-ac (24 km²) network of cooling canals between them (FPL 2018f).




Figure 3-1 Map Showing the 50-mi (80-km) Radius Around the Turkey Point Site (FPL 2018f)

3.1.2 Nuclear Reactor Systems

Turkey Point Units 3 and 4 are Westinghouse, three-loop pressurized-water reactors (PWRs) with dry, ambient pressure containments. The NRC's predecessor agency, the Atomic Energy Commission, issued the Turkey Point Unit 3 facility operating license on July 19, 1972 and the Unit 4 facility operating license on April 10, 1973. Subsequently, on June 6, 2002, the NRC issued renewed facility operating licenses for Turkey Point Units 3 and 4, authorizing an additional 20 years of operation (NRC 2002b). Turkey Point Units 3 and 4 are each rated for a reactor core power level of 2,644 megawatts thermal (MWt) (FPL 2018f). Together, Units 3 and 4 produce a combined total of 1,632 megawatts electric (MWe) (FPL 2018f).

Both the Unit 3 and Unit 4 reactor cores are composed of uranium dioxide pellets enclosed in Zircaloy-4, ZIRLO®, Optimized ZIRLO™ high-performance fuel cladding material tubes with welded end plugs. A spring clip grid structure supports the tubes in assemblies. The mechanical control rods consist of clusters of stainless steel-clad absorber rods and guide tubes located within the fuel assemblies (FPL 2018f).

3.1.3 Cooling and Auxiliary Water Systems


As mentioned earlier, Turkey Point Units 3 and 4 are both PWRs. PWRs heat water under pressure to very high temperatures to create steam. That steam turns the turbines that then generate electricity. PWRs use a closed-cycle cooling system to dissipate the heat in the water. The closed-cycle cooling system uses three heat exchange loops to cool the water: (1) the primary coolant loop, (2) the secondary loop, and (3) the cooling water loop. These are as follows.

Primary Coolant Loop: In the primary coolant loop, water is drawn into the reactor and heated to very high temperatures while under great pressure. The pressure keeps the water from turning into steam. Water in the primary loop that has been heated in the reactor passes through a steam generator where heat is transferred to water in a secondary loop. Once the heat is transferred, the water in the primary coolant loop returns to the reactor to be heated again under high pressure.

Secondary Loop: In the heat transfer process, the water in the primary loop and the water in the secondary loop do not come into contact with each other. In the steam generator, the heated water in the secondary loop is allowed to flash into steam, which is what drives the turbines that in turn produce electricity. The water in the secondary loop (now in steam form), then travels to the condenser where it transfers its heat energy to water in the third loop (called the cooling water loop). When heat is transferred, the water temperature decreases and the steam water in the secondary loop condenses back to liquid water. The liquid water in the secondary loop then returns to the steam generator to be reheated.

Cooling Water Loop: As is the case with the transfer of heat between the primary coolant loop and the secondary loop, in the condenser, the water in the secondary loop and the water in the cooling water loop do not come into contact with one another. From the condenser, water in the cooling water loop (third loop) can either flow to cooling towers (not present for Units 3 and 4) where it is cooled by evaporation or it can be discharged directly to an external body of water (NRC 2013a). Figure 3-2 below shows a simple schematic diagram of a generic PWR cooling system with a cooling canal system. At Turkey Point, water from the cooling water loop is discharged into a body of water called the cooling canal system (CCS).

The sections below describe in greater detail the cooling water loop, the CCS, the auxiliary cooling water system, the fire protection water system, and the potable water system at Turkey Point. Unless otherwise cited herein, the NRC staff drew information about Turkey Point's cooling and auxiliary water systems from the following sources: FPL's environmental report that it submitted as part of the subsequent license renewal application (FPL 2018f), the NRC staff's 2002 SEIS for the initial Turkey Point license renewal published as NUREG-1437, Supplement 5 (NRC 2002c), and the NRC staff's onsite environmental audit at Turkey Point in June 2018.



Source: Modified from NRC 2013a

Figure 3-2 Generic Cooling System with Cooling Canal System

3.1.3.1 General Description of Cooling Water Loop

In a PWR closed-cycle cooling system, the primary function of the third loop—the cooling water loop—is to transport heat from inside the reactor to the outside environment. At Turkey Point, the cooling water loop withdraws water from an artificially constructed body of water called the cooling canal system (CCS) and discharges water back to the CCS. As described earlier in this chapter, the CCS is a large body of water comprised of a network of canals spread over about 5,900 ac (24 km²). As with the rest of the Turkey Point site, FPL does not allow the public to access the CCS. The CCS does not directly connect to any other surface water bodies. It is an industrial wastewater (IWW) facility under the Clean Water Act and is not considered “waters of the United States” or “waters of the State” (Figure 3-3).


The reactors discharge heated water from the cooling water loop into the discharge canal of the CCS. From the discharge canal, the heated water travels through the length of the canal and loses heat through evaporation. By the time the water returns to the Units 3 and 4 cooling water intake canal, it is lower in temperature than when it was discharged. From the cooling water intake canal, some water is pumped back into the cooling water loop where it is used to dissipate heat from the secondary loop so that the steam water in the secondary loop condenses back into liquid water.

Figure 3-3 illustrates the location where the Units 3 and 4 discharge structure releases heated water into the CCS, the direction of water flow through the CCS, and the location where the

Units 3 and 4 intake structure draws cooling water from the CCS. Section 3.1.3.2, "Cooling Canal System (CCS)," discusses the CCS and its operation in greater detail.

At the Units 3 and 4 cooling water intake structure, water from the CCS flows through bars that prevent large objects from entering the intake structure. Then, the water flows through steel trash racks and into four separated screen wells. The trash racks protect vertical traveling screens against damage from heavy debris. The traveling screens have a 0.38-in (1-cm) mesh size to remove smaller debris. The water then flows to one of four circulating water pumps. The intake structure also contains three pumps that supply water to the condenser. Under normal plant operating conditions, either one, two, or all three of these pumps may be in operation. Inside the cooling water tubes of the condenser, plastic foam balls minimize biological growth and other fouling.

The combined intake of water at the Turkey Point intake structure is 1,872 million gallons per day (mgd) (7 million m³/day). This water is discharged back to the CCS where it is recirculated for reuse again as cooling water.



Source: FPL 2018f

Figure 3-3 Flow of Water Through the Cooling Canal System

FPL originally built the CCS to service its fossil-fueled units and nuclear generating units. The CCS currently services two nuclear generating units (Units 3 and 4), two retired fossil-fueled units (Units 1 and 2), and one currently operating fossil-fueled unit (Unit 5) in varying capacities. The NRC does not license the operation of the fossil-fueled units.

Historically, the CCS was also part of the cooling water system for Units 1 and 2. The CCS functioned for them as it does for Units 3 and 4. As mentioned earlier, FPL retired Units 1 and 2, so these units no longer generate electricity. However, these retired units still circulate water from the CCS (i.e., discharge water into and withdraw water from the CCS). FPL has placed both units into synchronous condenser mode, which means they support transmission reliability and help to stabilize and optimize electrical grid performance. FPL plans to continue operating Units 1 and 2 in this mode through the period of subsequent license renewal. While in synchronous condenser mode, Units 1 and 2 circulate 17.3 mgd (65,488 m³/day) of water from the CCS. As Units 1 and 2 no longer produce steam, unlike Units 3 and 4, they no longer discharge heated water to the CCS.

Unit 5 is a currently operating fossil fuel power plant that produces electricity through natural-gas combined-cycle steam generation. It uses four natural gas turbines and one heat-recovery steam-powered generator. It does not use the CCS as part of its cooling water system. Instead, Unit 5 uses cooling towers and obtains water for cooling from groundwater from the Upper Floridan aquifer (see Section 3.5, "Groundwater Resources"). Heat generated by Unit 5 is lost to the atmosphere by the evaporation of water in the plant's cooling towers.

While Unit 5 does not use the CCS for cooling, it does discharge blowdown water from its cooling towers into the CCS. Blowdown water is produced as a result of the evaporation of water in the cooling tower. Evaporation causes the mineral content of the remaining water that does not evaporate to increase. Blowdown is produced by draining water with high mineral concentrations from the cooling tower and replacing it with fresh water. Blowdown from Unit 5 cooling towers does not contribute heat to the CCS. At 10,000 gallons per day (gpd) (38 m³/day), the volume of blowdown water discharged from Unit 5 to the CCS is relatively small.

3.1.3.2 Cooling Canal System (CCS)

This section describes the physical dimensions of the CCS and its operation.

Layout of the Cooling Canal System

The CCS covers an area approximately 2-mi (3.2-km) wide by 5-mi (8-km) long and covers an area of approximately 5,900 ac (24 km²). It was built to act as a cooling reservoir for Units 1, 2, 3, and 4 and as an industrial wastewater facility for liquid discharges from all operations at the Turkey Point site. As previously described, while water from the CCS is circulated through Units 1 and 2, only Units 3 and 4 now use the CCS for cooling. The CCS receives heated water from Units 3 and 4 and distributes the water into 32 feeder channels (canals). Water in the feeder channels flows south into a single collector channel that distributes water to seven return channels (Figure 3-4). As the water flows through the channels, heat is lost, largely through evaporation. Water in the return channels flows north where it is used to cool Units 3 and 4. Units 3 and 4 return heated water to the CCS to repeat the cycle. Flows through the CCS are approximately 1.3 million gallons per minute (gpm) (4.9 million liters per minute (Lpm)) (FPL 2018f).

Prior to the construction of Units 3 and 4, the cooling system for Units 1 and 2 used a cooling system with a once-through design. It withdrew water from and discharged water to Biscayne Bay. However, a 1971 consent decree by the Federal District Court for the Southern District of Florida (United States v. Florida Power and Light Company) required FPL to discharge all cooling water from Turkey Point facilities into a closed-cycle cooling canal system. To comply

with this decree, FPL designed and constructed the CCS and ensured that it had no direct surface water connection to any outside water body (i.e., Biscayne Bay or Card Sound) (NRC 2016a). The CCS then replaced the previous Units 1 and 2 once-through cooling system.

The CCS consists of interconnected channels excavated into the underlying bedrock. The bedrock is limestone and forms the top of the Biscayne aquifer. It is important to note that the CCS is not built up above the land surface; instead, it was excavated into the bedrock. Water levels in the channels are below the level of the land surface and below the top of the bedrock (i.e., below the top of the Biscayne aquifer). Therefore, the limestone rock of the Biscayne aquifer forms the bottom and sides of the CCS.

Perimeter berms surround the CCS. These berms are constructed on top of the bedrock and do not contact the water in the CCS. They vary in height from 4 to 10 ft (1.2 to 3 m) above the surface of the bedrock. The widths of the perimeter berms vary from 25 feet to well over 100 feet (7.6 m to 30.5 m) with an average width of more than 50 ft (15.2 m). The perimeter berms are not in contact with water within the CCS. As mentioned previously, the water in the CCS is below the top of the bedrock, while the perimeter berms are built on top of the bedrock. The berms are not designed and built to contain CCS water; rather, these berms are designed and built to prevent surface water from entering the CCS.


Most of the channels within the CCS are about 200 feet (60 m) wide and have a water depth of 1 to 3 feet (0.3 to 1 m). The average canal depth is 2.8 ft (0.85 m) (FPL 2018f). They are separated by 90 foot (27 m) wide berms (NRC 2002c). A few of the channels within the CCS have been excavated to a depth of approximately 20 ft (6.1 m). These deep channels are:

- The east-west distribution channel along the north side of the CCS
- The east-west collection channel along the south side of the CCS
- The north-south channel within the CCS, originally built to discharge water to Card Sound
- The north-south channel along the east side of the CCS
- A few channels in the northeast corner of the CCS that connect to the intake basin (Golder 2008, Morgan & Eklund 2010)

When the CCS was constructed, the previous canals that functioned as intake and discharge canals into Biscayne Bay or Card Sound were either incorporated into the CCS or excluded from it. Those previous canals that were excluded from the CCS have now become remnant dead-end canals. The Barge Turning Basin in Biscayne Bay was walled off from the CCS. Earthen plugs were installed between the CCS and the remnant dead end canals. Within the plugs in the Turtle Point remnant canal that connects to Biscayne Bay and in the Card Sound remnant canal that connects to Card Sound (see Figure 3-4), cement and bentonite slurry walls have been constructed to prevent water seepage through them. In addition, both sides of these plugs are protected with a layer of limestone rock to prevent surface erosion of the plug. The Turtle Point remnant canal plug varies in width from 25 to 40 ft (7.6 to 12 m) and the Card Sound remnant canal plug varies in width from 25 to 50 ft (7.6 to 15 m) (FPL 2016f).

In addition to the channels (canals) within the CCS, an interceptor ditch is located outside and against the west side of the CCS. The ditch is not connected to the CCS or other surface waters. However, it is a part of CCS operations. It parallels the entire length of the west side of the CCS. It is constructed to a depth of approximately 18 ft (5.5 m) (Golder 2008). The purpose

of the interceptor ditch is to limit the amounts of saline groundwater that move from beneath the CCS to areas west of the Canal L-31E Levee, to those amounts which would have moved to those areas if the CCS did not exist (Figure 3-4) (FPL 2018f).



Source: Modified from SFWMD 2011a

Figure 3-4 Cooling Canal System and Adjacent Canals

Depending on the head levels (water levels) in the Biscayne aquifer relative to the head levels in Biscayne Bay, groundwater beneath and around the Turkey Point site can either flow towards the bay (east) or inland away from the bay (west). During wet times of the year, when groundwater levels are high, groundwater flow is usually towards the bay. During dry times of the year, when groundwater levels are low, groundwater flow is usually inland away from the bay.

When surface water and groundwater monitoring data around the Turkey Point site indicate that there is a potential for groundwater to flow inland (west), water is pumped from the interceptor ditch and discharged into the CCS. This causes near-surface groundwater to flow towards the interceptor ditch and captures near-surface groundwater below the CCS that is moving west (FPL 2018f). The capture effect is likely limited to the depth of the interceptor ditch, which, at a depth of about 18 ft (5.5 m), is a little deeper than the bottom of the L-31E Canal (Golder 2008).

Cooling Canal System Operation

Units 3 and 4 discharge heated water into the CCS. As this water travels through the length of the CCS, it loses heat through evaporation. Evaporation not only removes heat from the water in the CCS, but it also removes some of the water. Water lost through evaporation is replaced by three main sources. The single largest contributor of new water to the CCS is water from precipitation (e.g., rain). Historically, the second largest contributor has been saltwater from the Biscayne aquifer that seeps into the CCS through the limestone bedrock. However, more recently, a different water source has likely overtaken Biscayne aquifer seepage as the second largest contributor of new water to the CCS. Specifically, as further discussed in Section 3.5.2.3, “Groundwater Use,” brackish water supplied by FPL’s wells that withdraw water from the Floridan aquifer is likely a larger contributor of new water to the CCS than is provided by the seepage of water from the Biscayne aquifer.


The CCS receives relatively minor additions of water from discharges from the interceptor ditch and Unit 5 cooling tower blowdown. In extraordinary circumstances, FPL may add water to the CCS from wells (marine wells near Biscayne Bay) that withdraw saltwater from the Biscayne aquifer (see Section 3.5.2.3 for more detail). However, FPL seldom uses these marine wells (FPL 2018f).

As mentioned earlier in this chapter, water in the CCS is not in contact with other surface water bodies. However, the water in the CCS is in direct contact with the Biscayne aquifer and with earthen plugs located in the perimeter of the CCS. These plugs seal off remnant canals from the water in the CCS (FPL 2018f). As the Biscayne aquifer is highly permeable, water would be more readily transmitted through it than through the relatively small areas occupied by the low permeability earthen plugs on the perimeter of the CCS. The perimeter berms are not a likely pathway for water to seep from the CCS as they are not in contact with the CCS water.

Not only does water leave the CCS by evaporation, some of the water also leaves the CCS through the Biscayne aquifer. However, more water moves into the CCS from the Biscayne aquifer than leaves the CCS to the Biscayne aquifer. FPL estimates that the inflow of groundwater from the Biscayne aquifer into the CCS is about twice the volume of outflow of water from the CCS into the Biscayne aquifer (FPL 2018f).

Figure 3-5 shows a typical Turkey Point CCS water budget. The flow quantities shown are based on modeling predictions for the June 2015 through May 2017 period (FPL 2018f). The water balance in the CCS varies in response to hydroclimatic variability and variability in

operations of the Turkey Point generating units. Therefore, it is expected that the water balance may not completely close (i.e., inflows balance outflows) over any given time period. Nonetheless, Figure 3-5 provides relative quantities of major inflows to and outflows from the CCS.



Average Flows in Million Gallons per Day (MGD)
C.W. = Cooling Water

Source: Modified from FPL 2018f

Figure 3-5 Illustrated CCS Water Budget for Turkey Point Site Based on Modeling Predictions From June 2015 Through May 2017

Sediments can build up in the channels of the CCS. These sediments can obstruct the lateral flow of water through the CCS and can also lower the rate of water movement into the CCS from the Biscayne aquifer. Therefore, CCS maintenance activities include the removal of accumulated sediments as required to maintain adequate water flow in the CCS (FPL 2018f).

3.1.3.3 Auxiliary Cooling Water System

In addition to the cooling water loop, heat is also removed from Turkey Point operations by the auxiliary cooling water system. This system is much smaller in its water requirements than the cooling water loop. Auxiliary cooling water systems can include emergency core cooling systems, containment spray and cooling systems, emergency feedwater systems, component cooling water systems, and spent fuel pool water systems. At Turkey Point, the auxiliary cooling water system consists of three loops: (1) the component cooling loop, (2) the residual heat removal loop, and (3) the spent fuel pit cooling loop. These loops obtain water from the Miami-Dade County public water supply system and discharge water to the CCS.

3.1.3.4 Fire Protection Water System

Fire protection water protects the plant in the event of a fire. At Turkey Point, the Miami-Dade County public water supply system supplies the fire protection water as described below.

3.1.3.5 Potable Water System

Turkey Point uses approximately 1 mgd (3,800 m³/day) of water from the Miami-Dade County public water supply system. However, a water treatment plant, which supplies pure water for steam-related use, was completed in 2017. This new plant has the ability to treat brackish water at a rate of more than 1 mgd (3,800 m³/day) from onsite wells that withdraw water from the Upper Floridan aquifer (see Section 3.5.2.3, “Groundwater Use”). This will significantly reduce the volume of potable water that FPL needs to obtain from the Miami-Dade County public water supply system.

Potable water is used by the auxiliary cooling water system, fire protection system, and drinking water system. Turkey Point discharges treated waste-process waters into the CCS, and domestic wastewater is sent to an onsite sewage treatment plant. After treatment, FPL disposes of water from the sewage treatment plant into the Biscayne aquifer through an injection well. Beneath the Turkey Point site, the Biscayne aquifer contains saltwater (see Section 3.5.1.4, “Adjacent Surface Water Quality and Cooling Canal System Operation”).

3.1.4 Radioactive Waste Management Systems

As a result of normal operations, equipment repairs and replacements, and normal maintenance activities, nuclear power plants routinely generate both radioactive and nonradioactive waste. Nonradioactive waste includes hazardous and nonhazardous waste. There is also a class of waste—called mixed waste—which is both radioactive and hazardous. This section describes the systems that FPL uses to manage (i.e., treat, store, and dispose of) these wastes. This section also discusses other waste minimization and pollution prevention measures commonly employed at nuclear power plants.

The NRC licenses all nuclear plants with the expectation that they will release some radioactive material to both the air and water during normal operations. However, NRC regulations require that gaseous and liquid radioactive releases from nuclear power plants must meet radiation dose-based limits specified in Title 10 of the *Code of Federal Regulations* (10 CFR) Part 20, “Standards for Protection Against Radiation,” and the as-low-as-is-reasonably-achievable (ALARA) criteria in 10 CFR Part 50, Appendix I, “Numerical Guides for Design Objectives and Limiting Conditions for Operation to Meet the Criterion ‘As Low as is Reasonably Achievable’ for Radioactive Material in Light-Water-Cooled Nuclear Power Reactor Effluents.” In other words, the NRC places regulatory limits on the radiation dose that members of the public can receive from a nuclear power plant’s radioactive effluents. For this reason, all nuclear power plants use radioactive waste management systems to control and monitor radioactive wastes.

Turkey Point uses the waste disposal system, as needed, to collect and process radioactive materials contained in liquid, gaseous, and solid waste produced as a byproduct of plant operations. The waste disposal system ensures that the dose to members of the public from radioactive effluents is reduced to levels that are ALARA in accordance with the NRC’s regulations.

Under an agreement between FPL and the Florida Department of Health (DOH), the DOH Bureau of Radiation Control conducts the Turkey Point radiological environmental monitoring program (REMP). Through the REMP, the Bureau of Radiation Control documents the radiological impact, if any, to the public, site employees, and the environment from radioactive effluents released during operations at Turkey Point. Section 3.1.4.5 below discusses the REMP in more detail.

FPL uses its Offsite Dose Calculation Manual (ODCM) that contains the methods and parameters for calculating offsite doses resulting from liquid and gaseous radioactive effluents. These methods ensure that radioactive material discharges from Turkey Point meet NRC and U.S. Environmental Protection Agency (EPA) regulatory dose standards. The ODCM also contains the requirements for the REMP (FPL 2018f).

3.1.4.1 Radioactive Liquid Waste Management

FPL uses waste management systems to collect, analyze, and process radioactive liquids produced at Turkey Point. These systems reduce radioactive liquids before they are released to the environment. The Turkey Point Units 3 and 4 waste disposal system meets the design objectives of 10 CFR Part 50, Appendix I, and controls the processing, disposal, and release of radioactive liquid, gaseous, and solid wastes.

The plant collects liquid radioactive waste in sumps and tanks in the waste disposal system. Plant personnel then sample and analyze these collected liquid wastes to determine the level of radioactivity and to determine if subsequent treatment is necessary. Personnel then process the liquid radioactive wastes as required by 10 CFR Part 20 and release them into the CCS discharge streams. FPL uses radiation monitors and applies safety features for the discharge stream to avoid releases in excess of 10 CFR Part 20 standards (FPL 2016i).

Radioactive liquid waste entering the waste holdup tanks (WHT) via gravity feed include effluents from the chemistry laboratories, containment sumps, floor drains, showers, and other miscellaneous sources which flow to waste and monitoring holdup tanks. The laundry waste is segregated into one of two monitor tanks. In addition, other sources of liquid wastes include Turkey Point steam generator blowdown and storm drains. These liquids are then pumped to the waste monitor tank where the activity level is determined and recorded prior to discharge through the radiation monitor. The chemical and volume control system (CVCS) receives radwaste liquids from the reactor coolant loop drains, accumulators, and excess letdown.

According to FPL's environmental report submitted as part of the subsequent license renewal application, liquid requiring cleanup before being discharged to the environment is processed by the waste disposal demineralizer. Turkey Point routes the liquid from the waste disposal demineralizer directly to one of the three radwaste facility waste monitor tanks or one of two waste disposal system monitor tanks (FPL 2016i, Section 11.1.2). When one of the waste monitor tanks is filled, it is isolated, recirculated, and sampled for analysis while one of the other two tanks is in service. If analysis confirms the activity level is suitable for discharge, the liquid is pumped through a flow meter and a radiation monitor and then released to the cooling canals of the industrial wastewater facility. Otherwise, it can be returned to a waste holdup tank for reprocessing (FPL 2016i, Section 11.1.2). Turkey Point monitors radioactive liquid discharge from its systems to ensure that activity concentrations do not exceed regulatory limits.

FPL's use of these radioactive waste systems and the procedural requirements in the Offsite Dose Calculation Manual ensure that the dose from radioactive liquid effluents at Turkey Point complies with NRC and EPA regulatory dose standards.

FPL calculates dose estimates for members of the public using radioactive liquid and gaseous effluent release data and atmospheric and aquatic transport models. Unit 3 and Unit 4 share the liquid waste treatment system. Generally, FPL allocates all liquid releases on a 50/50 basis to each unit. In addition, both units also share the gaseous releases from the shared gaseous waste treatment system on a 50/50 basis. Turkey Point's annual radioactive effluent release reports contain a detailed presentation of the radioactive liquid and gaseous effluents released from Turkey Point and the resultant calculated doses. The NRC staff reviewed 5 years of radioactive effluent release data from 2013 through 2017 (FPL 2013b, 2014d, 2015a; 2016l, FPL 2017e). A 5-year period provides a dataset that covers a broad range of activities that occur at a nuclear power plant, such as refueling outages, routine operation, and maintenance that can affect the generation of radioactive effluents. The NRC staff compared the data against NRC dose limits and looked for indications of adverse trends (e.g., increasing dose levels) over the period spanning from 2013 through 2017. Since the radioactive liquid effluents are released from common areas shared by both Unit 3 and Unit 4, the resultant calculated doses presented in the effluent release are divided in half to evaluate compliance with the Appendix I to 10 CFR Part 50 dose criteria. The NRC staff's review of Turkey Point's radioactive liquid effluent control program showed that radiation doses to members of the public were controlled within the NRC's and EPA's radiation protection standards contained in Appendix I to 10 CFR Part 50, 10 CFR Part 20, and 40 CFR Part 190. No adverse trends were observed in the dose levels. Routine plant refueling and maintenance activities currently performed will continue during the license renewal term. Based on the past performance of the radioactive waste system to maintain doses from radioactive liquid effluents to be ALARA, similar performance is expected during the license renewal term. The following summarizes the calculated doses from radioactive liquid effluents released from Turkey Point Units 3 and 4 during the most recent available year (2017):

Turkey Point Unit 3 in 2017

- The total-body dose to an offsite member of the public from Turkey Point Unit 3 radioactive effluents was 2.38×10^{-4} millirem (mrem) (2.38×10^{-6} millisievert (mSv)), which is well below the 3 mrem (0.03 mSv) dose criterion in Appendix I to 10 CFR Part 50.
- The maximum organ dose (gastrointestinal tract) to an offsite member of the public from Turkey Point Unit 3 radioactive effluents was 2.76×10^{-4} mrem (2.76×10^{-6} mSv), which is well below the 10 mrem (0.1 mSv) dose criterion in Appendix I to 10 CFR Part 50.

Turkey Point Unit 4 in 2017

- The total-body dose to an offsite member of the public from Turkey Point Unit 4 radioactive effluents was 2.38×10^{-4} millirem (mrem) (2.38×10^{-6} millisievert (mSv)), which is well below the 3 mrem (0.03 mSv) dose criterion in Appendix I to 10 CFR Part 50.
- The maximum organ dose (gastrointestinal tract) to an offsite member of the public from Turkey Point Unit 4 radioactive effluents was 2.76×10^{-4} mrem (2.76×10^{-6} mSv), which is well below the 10 mrem (0.1 mSv) dose criterion in Appendix I to 10 CFR Part 50.

The NRC staff's review of FPL's radioactive liquid effluent control program shows that the applicant maintained radiation doses to members of the public that were within NRC's and

EPA's radiation protection standards in Appendix I to 10 CFR Part 50, 10 CFR Part 20, and Title 40, "Protection of Environment," of the *Code of Federal Regulations* (40 CFR) Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operations." The NRC staff observed no adverse trends in the dose levels.

Routine plant refueling and maintenance activities at Turkey Point will continue during the subsequent license renewal term. Based on FPL's past performance in operating a radioactive waste system at Turkey Point that maintains ALARA doses from radioactive liquid effluents, the NRC staff expects that FPL will maintain similar performance during the subsequent license renewal term.

3.1.4.2 Radioactive Gaseous Waste Management

Radioactive gaseous waste generated at Turkey Point is collected, processed, and stored until its radioactivity level is low enough to permit discharge to the environment at concentrations below 10 CFR Part 20 standards (FPL 2016i, Section 1.2.4) through the waste disposal system. Sources of the radioactive gaseous waste at Turkey point include gas decay tanks, containment purges, the refueling water storage tank via the vent line, the Turkey Point equipment hatch during outages, and releases incidental to plant operations. This radioactive gaseous waste is created during plant operation from degassing reactor coolant discharge to the chemical and volume control system, displacement of cover gases, miscellaneous equipment vents, relief valves, and sampling operation and gas analysis for hydrogen and oxygen in cover gases. Most of the gas received by the waste disposal system is cover gas displaced from the chemical and volume control system holdup tanks as they fill with liquid. Gaseous waste is stored in decay tanks for natural decay and is then released through the monitored plant vent. The cover gas is reused to minimize the number of tank releases. The gaseous waste is monitored and released at a permissible rate and activity as prescribed by the ODCM. Radioactive gaseous effluents from Turkey Point Units 3 and 4 are released through four monitored release points: a common plant vent via a stack above the containment building (~200 feet), the Unit 3 spent fuel pit vent (~110 feet), and the condenser air ejector vents (~51 feet) from each unit.

Gases that are vented to the vent header flow to the waste gas compressor suction header. One of two compressors is in continuous operation with the second unit instrumented to act as backup for peak load conditions or failure of the first compressor. From the compressors, gas flows to one of the gas decay tanks. Gas held in the decay tanks can either be returned to the chemical and volume control system holdup tanks or discharged to the atmosphere via the plant vent at a controlled rate through a radiation monitor if it has decayed sufficiently for release (FPL 2016i, Section 11.1.2). The gases in the tanks are sampled and analyzed to determine the radioactivity level. The radioactivity level contained in each gas decay tank is restricted (1) to ensure that if an uncontrolled release of the tank's contents were to occur, the resulting total body exposure to an individual at the exclusion area boundary would not exceed 500 millirems per year (mrem/yr) (5 millisieverts per year (mSv/yr)) and (2) to control the concentration of potentially explosive gases to below flammability limits. The decay tanks are used to contain the compressed waste gases (hydrogen, nitrogen, and fission gases) until they decay and are ready to be vented to the atmosphere.

FPL's use of this gaseous radioactive waste system and adherence to the procedural requirements in the ODCM ensure that the dose from radioactive gaseous effluents complies with NRC and EPA regulatory dose standards.

As discussed above, FPL calculates dose estimates for members of the public using radioactive liquid and gaseous effluent release data and atmospheric and aquatic transport models. Unit 3 and Unit 4 share the gaseous waste treatment system. The following summarizes the calculated doses from radioactive gaseous effluents released from Turkey Point during 2017:

Turkey Point Unit 3 in 2017

- The air dose at the site boundary from gamma radiation in gaseous effluents from Turkey Point Unit 3 was 1.30×10^{-5} millirad (mrad) (1.3×10^{-7} milligray), which is well below the 10 mrad (0.1 milligray) dose criterion in Appendix I to 10 CFR Part 50.
- The air dose at the site boundary from beta radiation in gaseous effluents from Turkey Point Unit 3 was 2.96×10^{-5} mrad (2.96×10^{-7} milligray) dose which is well below the 20 mrad (0.2 milligray) dose criterion in Appendix I to 10 CFR Part 50.
- The dose to an organ (thyroid) from radioactive iodine, radioactive particulates, and carbon from Turkey Point Unit 3 was 1.01×10^{-1} mrem (1.01×10^{-3} mSv), which is below the 15 mrem (0.15 mSv) dose criterion in Appendix I to 10 CFR Part 50.

Turkey Point Unit 4 in 2017

- The air dose at the site boundary from gamma radiation in gaseous effluents from Turkey Point Unit 4 was 9.02×10^{-6} mrad (9.02×10^{-8} milligray), which is well below the 10 mrad (0.1 milligray) dose criterion in Appendix I to 10 CFR Part 50.
- The air dose at the site boundary from beta radiation in gaseous effluents from Turkey Point Unit 4 was 2.07×10^{-5} mrad (2.07×10^{-7} milligray) dose which is well below the 20 mrad (0.2 milligray) dose criterion in Appendix I to 10 CFR Part 50.
- The dose to an organ (thyroid) from radioactive iodine, radioactive particulates, and carbon from Turkey Point Unit 4 was 1.19×10^{-1} mrem (1.19×10^{-3} mSv), which is below the 15 mrem (0.15 mSv) dose criterion in Appendix I to 10 CFR Part 50.

The NRC staff's review of Turkey Point's radioactive gaseous effluent control program showed radiation doses to members of the public that were well below NRC and EPA radiation protection standards contained in Appendix I to 10 CFR Part 50, 10 CFR Part 20, and 40 CFR Part 190. The NRC staff observed no adverse trends in the dose levels.

Routine plant refueling and maintenance activities at Turkey Point will continue during the subsequent license renewal term. FPL's past performance operating the radioactive waste system demonstrates that it is able to maintain ALARA doses from radioactive gaseous effluents. Based on this record of past performance, the NRC staff expects that FPL will maintain similar performance during the subsequent license renewal term.

3.1.4.3 Radioactive Solid Waste Management

At Turkey Point, low-level radioactive wastes (LLRW) are packaged and stored for subsequent shipment and offsite burial under the plant's waste disposal system. FPL packages Turkey Point radioactive waste shipments in accordance with NRC requirements (10 CFR Part 71, "Packaging and Transportation of Radioactive Material"), and U.S. Department of Transportation (USDOT) requirements (Title 49, "Transportation," of the *Code of Federal Regulations* Part 173, "Shippers—General Requirements for Shipments and Packagings," and Part 178, "Specifications for Packagings").

Under the waste disposal system, FPL packages all solid wastes in high-integrity containers (HICs) for removal to disposal facilities. The HICs are designed to be placed into transfer casks for shipment offsite for disposal. The HICs are also designed to be stored in the LLRW storage facility while awaiting shipment offsite for disposal. The waste disposal system has been designed as a waste process system, which includes demineralizers, monitor tanks, a condensate tank, and associated pumps. Solid radioactive waste and potentially radioactive wastes include spent resins, spent filters, and miscellaneous materials. Solid radioactive wastes also include solids recovered from the reactor coolant system (RCS), solids in contact with the liquids or gases associated with the reactor coolant process systems, and solids used in support of the reactor coolant system operation. The largest volume of solid radioactive waste is LLRW, which includes bead resin, spent filters, and dry active waste from outages and routine maintenance. Turkey Point has developed long-term plans which ensure that radioactive waste generated during the subsequent license renewal term will be sent directly for disposal, stored onsite in existing structures, or shipped to an offsite licensed facility for processing and disposal (FPL 2018f).

LLRW is classified as Class A, Class B, or Class C (minor volumes are classified as greater than Class C). Class A includes both dry active waste and processed waste (e.g., dewatered resins). Classes B and C normally include processed waste and irradiated hardware. The majority of LLRW generated at Turkey Point during the subsequent license renewal period is expected to be Class A waste and could be shipped to licensed processors, such as the Energy Solutions facility in Oak Ridge, TN, for reduction and repackaging, and then shipped to a Class A disposal facility such as the Energy Solutions facility in Clive, UT. Class B and C wastes would constitute a low percentage by volume of the total LLRW generated. The LLRW storage facility at Turkey Point can currently store approximately 5 years of Class B and Class C wastes.

Class B and C wastes can be shipped to the Energy Solutions facility in Oak Ridge, TN, where they can then be shipped to the Waste Control Specialist facility in Texas, which is licensed for disposal of Classes A, B, and C wastes. Disposal of waste greater than Class C is the responsibility of the Federal Government. The NRC licenses the storage of LLRW waste under the general license provided to power reactor licensees under 10 CFR Part 50 (FPL 2016f).

In 2017, a total of eight LLRW shipments were made from Turkey Point to the Energy Solutions, Bear Creek Road Facility (Oak Ridge, TN) (FPL 2018f) and Energy Solutions, Gallaher Road Facility (Kingston, TN) (FPL 2018f). The total volume and radioactivity of LLRW shipped offsite in 2017 was 6.00×10^2 cubic meters (m^3) (2.12×10^4 cubic feet (ft^3)) and 1.11×10^0 curies (Ci) (4.12×10^4 megabecquerels (MBq)), respectively (FPL 2018f). During the subsequent license renewal period, Turkey Point would continue with routine plant operation, refueling outages, and maintenance activities that generate radioactive solid waste. The NRC also expects Turkey Point to continue to ship radioactive solid waste offsite for disposal during the subsequent license renewal period.

3.1.4.4 Radioactive Waste Storage

At Turkey Point, LLRW is stored temporarily onsite before being shipped offsite for treatment or disposal at licensed LLRW treatment and disposal facilities. In its environmental report for the Turkey Point subsequent license renewal application, FPL states that Turkey Point has sufficient existing capability to store LLRW onsite. FPL also states in its environmental report that its long-term needs for generated LLRW storage (including during the subsequent license renewal term) do not require constructing additional onsite storage facilities (FPL 2018a).

Turkey Point stores its spent fuel in a spent fuel pool and in an onsite independent spent fuel storage installation (ISFSI). The ISFSI safely stores spent fuel onsite in licensed and approved dry cask storage containers.

If the U.S. Department of Energy does not begin to take possession of the spent nuclear fuel in 2031, FPL may need to expand the existing capacity of the Turkey Point Units 3 and 4 ISFSI. This would require FPL to construct a new ISFSI pad to accommodate additional spent nuclear fuel generated during the subsequent license renewal term (FPL 2018g). Alternatively, FPL may choose to utilize a higher density storage system to create additional storage capacity and, thereby, reduce the need to expand the ISFSI. At this time, FPL has not yet determined whether to expand the ISFSI.

3.1.4.5 Radiological Environmental Monitoring Program

As stated above, the Florida Department of Health (DOH) Bureau of Radiation Control, per an agreement between FPL and the DOH, conducts a radiological environmental monitoring program (REMP) to assess the radiological impact, if any, to the public and the environment from the operations at Turkey Point Units 3 and 4.

The REMP measures the aquatic, terrestrial, and atmospheric environment for ambient radiation and radioactivity. Monitoring is conducted for the following: direct radiation, air, water, groundwater, broad leaf vegetation, fish, shellfish, and sediment. The REMP also measures background radiation (i.e., cosmic sources, global fallout, and naturally occurring radioactive material, including radon).

In addition to the REMP, Turkey Point has an onsite groundwater protection program designed to monitor the onsite plant environment for detection of leaks from plant systems and pipes containing radioactive liquid (FPL 2018f). Information on the groundwater protection program is contained in Section 3.5.2, "Groundwater Resources," of this SEIS.

FPL states in its environmental report that it has detected tritium in groundwater but has not detected Turkey Point Units 3 and 4-related gamma-emitting isotopes since establishing its NEI 07-07, "Industry Ground Water Protection Initiative," program (FPL 2018f). Section 3.5.2.2, "Groundwater Quality," provides a summary of radionuclides detected in groundwater. For 2018, the highest observed level of tritium in Turkey Point groundwater, outside the boundaries of the CCS, was reported as 3,390 picocuries per liter (pCi/L). For comparison, the EPA primary drinking water standard or maximum contaminant level (MCL) for tritium is 20,000 pCi/L (40 CFR 141.66). Tritium is also found in surface water onsite. For 2018, the maximum level measured was 21,851 pCi/L in the CCS. While some tritium levels measured in the CCS were found to be higher than the EPA drinking water standard of 20,000 pCi/L, they were still lower than the limits prescribed by Turkey Point Unit 3 and 4's Offsite Dose Calculation Manual (FPL 2013a) for the plant, which for tritium is 30,000 pCi/L. Further, no surface water or groundwater at the site is used for potable purposes.

The NRC staff reviewed 5 years of annual radiological environmental monitoring data from 2014 through 2018 (FPL 2015b, FPL 2016j, FPL 2017d, FPL 2018k, FPL 2019c). A 5-year period provides a dataset that covers a broad range of activities that occur at a nuclear power plant, such as refueling outages, routine operation, and maintenance that can affect the generation and release of radioactive effluents into the environment. The NRC staff looked for indications of adverse trends (e.g., increasing radioactivity levels) over the period of 2014 through 2018.

Based on its review of this information, the NRC staff found no apparent increasing trend in concentration or pattern indicating either a new inadvertent release or persistently high tritium concentrations that might indicate an ongoing inadvertent release from Turkey Point Units 3 and 4. The groundwater monitoring program at Turkey Point Units 3 and 4 is robust, and any future leaks that might occur during the subsequent license renewal period should be readily detected. All spills are well monitored, characterized, and actively remediated. The data show that there were no significant radiological impacts to the environment from operations at Turkey Point Units 3 and 4.

3.1.5 Nonradioactive Waste Management Systems

Like any other industrial facility, nuclear power plants generate wastes that are not contaminated with either radionuclides or hazardous chemicals.

Turkey Point has a nonradioactive waste management system to handle its nonradioactive hazardous and nonhazardous wastes. The waste is managed in accordance with FPL's procedures. Turkey Point has a contact stabilization treatment plant for sanitary waste (FPL 2018f) which is located west of the power block area. The treated wastewater is disposed of through an approximately 25-cm (10-in.) diameter, 15-m (50-ft) deep underground injection well located adjacent to the treatment facility. FPL disposes of residuals (wet sludge) at the Miami-Dade Water and Sewer Department's (MDWSD) South District Wastewater Treatment Facility (FPL 2018f).

The Miami-Dade County Department of Solid Waste Management is responsible for solid waste collection, transport, and disposal in unincorporated portions of the county and in eight municipalities. The Department of Solid Waste Management solid waste disposal system consists of a resource recovery waste-to-energy facility and two landfills: (1) the North Dade Landfill (a trash-only facility) and (2) the South Dade Landfill (a garbage and trash facility), which are supported by three regional waste transfer stations. An approved solid waste contractor collects and transports the solid waste generated at Turkey Point for disposal at county facilities (FPL 2018f). Listed below is a summary of the types of waste materials generated and managed at Turkey Point.

- Turkey Point is classified as a small quantity, hazardous waste generator. The amounts of hazardous wastes generated are only a small percentage of the total wastes generated. These wastes consist of paint wastes; spent, off-specification, and shelf-life expired chemicals; and occasional project-specific wastes (FPL 2018f).
- Turkey Point's nonhazardous wastes include plant trash and nonradioactive waste (FPL 2018f).
- Other wastes include fluorescent lamps, batteries, and devices containing mercury; electronics; and antifreeze (FPL 2018f).

For the fossil fuel facilities (Units 1 and 2, and Unit 5) and the Turkey Point site land management facilities, FPL routes sanitary waste from showers, water closets, toilets, etc. to Miami-Dade County-approved onsite septic systems. For the nuclear generating Units 3 and 4, FPL routes domestic wastewater to an onsite, county- and State-permitted, contact stabilization sewage treatment plant. This wastewater treatment plant (WWTP) discharges effluents to an onsite, permitted, single Class V, Group 3 gravity underground injection well used to dispose of domestic wastewater effluent (FPL 2018f). Wastewater residuals generated by this plant are transported to an approved offsite facility (FPL 2018f). The clarified wastewater sludge is

monitored according to operational protocol 0-NCAP-103 to ensure that the disposed material does not present an environmental or public health risk.

3.1.6 Utility and Transportation Infrastructure

The utility and transportation infrastructure at a nuclear power plant typically interfaces with the public infrastructure systems available in the region. Such public infrastructure includes utilities, such as suppliers of electricity, fuel, and water, as well as roads and railroads that provide access to the site. The following sections briefly describe the existing utility and transportation infrastructure at Turkey Point. Unless otherwise cited, the source of the Turkey Point site-specific information in this section is FPL's environmental report submitted as part of the subsequent license renewal application (FPL 2018f).

3.1.6.1 Electricity

Nuclear power plants generate electricity for other users; however, they also use their own generated electricity to operate. In the event of a malfunction or interruption of onsite nuclear power generation at Turkey Point, the facility would depend on offsite power sources to provide power to engineered safety features and emergency equipment. If both Turkey Point nuclear power generation and offsite power sources fail, the facility will use planned independent backup power sources.

3.1.6.2 Fuel

Under its current renewed facility operating licenses, Turkey Point Units 3 and 4 are licensed for fuel that is slightly enriched uranium dioxide (up to 5.0 percent by weight uranium-235). FPL operates the reactors at an equilibrium core maximum fuel discharge burnup rate of 62,000 megawatt-days per metric ton uranium (MWD/MTU). FPL refuels each nuclear unit on an 18-month schedule, which means at least one refueling every year and two refuelings every third year. FPL loads the core fuel in three regions. New fuel is introduced into the outer region, and partially spent fuel is moved inward into a checkerboard pattern at successive refuelings when the inner region fuel is discharged to spent fuel storage (FPL 2018f).

The Turkey Point spent fuel storage pit provides underwater storage of spent fuel assemblies and control rods after their removal from the reactor. The spent fuel pit is located in the auxiliary building and can store up to 1,535 fuel assemblies, including 131 spent or fresh fuel assemblies in the cask area rack, as well as miscellaneous fuel handling tools. FPL designed the cask area of the spent fuel pit for the installation of a fuel transfer cask to allow fuel transfer operations. The Turkey Point site has an ISFSI to provide Unit 3 and Unit 4 spent fuel capacity (FPL 2018f).

3.1.6.3 Potable Water

In addition to cooling and auxiliary water (previously described in detail in Section 3.1.3), nuclear power plants require potable water for sanitary and everyday uses by personnel (e.g., drinking, showering, cleaning, laundry, toilets, and eye washes). At Turkey Point, the Miami-Dade County public water supply system supplies potable water to the site.

3.1.6.4 Transportation Systems

All nuclear power plants are served by controlled access roads. In addition to roads, many plants also have railroad connections for moving heavy equipment and other materials. Plants located on navigable waters may have facilities to receive and ship loads on barges.

The Turkey Point site transportation network includes U.S. highways, interstate highways, multilane divided State highways, and local streets. Miami-Dade County operates public transportation services including rail and bus service. Miami-Dade County also offers air transportation infrastructure including airports, heliports, and a seaplane base; a seaport for commercial freight and passenger service; and an intermodal transportation hub for air, rail, and ship (FPL 2018f). Section 3.10.6, "Local Transportation," describes these systems in more detail.

3.1.6.5 Power Transmission Systems

For license renewal, including subsequent license renewal, the NRC (2013b) evaluates as part of the proposed action the continued operation of those power transmission lines that connect the nuclear power plant to the substation where it feeds electricity into the regional power distribution system. The NRC also evaluates the continued operation of the transmission lines that supply outside power to the nuclear plant from the grid. In its environmental report, FPL stated the locations of in-scope transmission lines, which are shown in Figure 3-6 (FPL 2018f). Turkey Point is connected to the 230-kV switchyard through an approximately 590-foot (180-m) transmission line (FPL 2018f).



Figure 3-6 Turkey Point In-Scope Transmission Lines (FPL 2018f)

3.1.7 Nuclear Power Plant Operations and Maintenance

FPL’s Turkey Point maintenance activities include inspection, testing, and surveillance to maintain the current licensing basis of the facility and to ensure compliance with environmental and safety requirements. Various programs and activities are currently in place at Turkey Point to maintain, inspect, and monitor the performance of facility structures, systems, and components. These activities include, but are not limited to, (1) in-service inspections of

safety-related structures, systems, and components, (2) quality assurance program, (3) fire protection program, and (4) monitoring of radioactive and nonradioactive water chemistry.

Additional Turkey Point maintenance programs include those implemented to meet technical specification surveillance requirements and those implemented in response to NRC generic communications. Such additional programs include various periodic maintenance, testing, and inspection procedures necessary to manage the effects of aging on structures and components. FPL performs certain program activities during the operation of the units and performs others during scheduled refueling outages. As stated above, reactor refueling at Turkey Point occurs on an 18-month cycle (FPL 2018f).

3.2 Land Use and Visual Resources

Sections 2.2.1, 2.2.8.3, and 2.2.8.4 of NUREG–1437, Supplement 5 (the SEIS for the Turkey Point’s initial license renewal) describe land use and visual resources at Turkey Point Units 3 and 4 (NRC 2002c). This information is incorporated here by reference. Section 2.2 of NUREG-2176, “Environmental Impact Statement for Combined Licenses (COLs) for Turkey Point Nuclear Plant Units 6 and 7” (NRC 2016a), also describes the land use at the Turkey Point site. This information is also incorporated here by reference (NRC 2016a). No new and significant information was identified during the review of FPL’s environmental report for the Turkey Point Units 3 and 4 subsequent license renewal (FPL 2018f), during the site audit at Turkey Point, the scoping process, or the evaluation of other available information that would alter the discussion contained in the SEIS for Turkey Point’s initial license renewal.

3.2.1 Land Use

Turkey Point Units 3 and 4 are located on the shore of Biscayne Bay in south Florida’s Miami-Dade County. The plant site is approximately 25 mi (40 km) south-southwest of Miami. The nearest incorporated city limits are Homestead, which is approximately 9 mi (14.5 km) west-northwest of the plant site, and Florida City, which is approximately 9 mi (14.5 km) west of the plant site. The nearest community to the south is Key Largo, which is in Monroe County, FL and is approximately 30 mi (48 km) by road from the plant site.

3.2.1.1 Onsite Land Use

Turkey Point Units 3 and 4 and associated structures and features, including the cooling canal system, occupy approximately 8,000 ac (3,200 ha). The largest land use and land cover categories within the Turkey Point property boundary are wetlands and open water, which together compose approximately 93 percent of the site. The next largest land use category is developed land (to support Turkey Point plant operations), which is approximately 6 percent of the site (FPL 2018f).

Miami-Dade County has designated the land use zoning at the Turkey Point site, including all units, undeveloped lands, and the cooling canal system, as either IU-3 (industrial districts, unlimited manufacturing) or GU (interim district, uses depend on the character of the neighborhood). Specifically, Turkey Point Units 3 and 4 are located on land zoned IU-3. The remainder of the Turkey Point site is zoned GU, an interim district. In an interim district, zoning-assigned land uses depend on the character of the neighborhood; otherwise, EU-2 standards apply (single-family 5-ac estate district) (FPL 2018f).

3.2.1.2 Coastal Zone

Section 307(c)(3)(A) of the Coastal Zone Management Act (CZMA) (16 U.S.C. 1456(c)(3)(A)) requires that applicants for Federal licenses who conduct activities in a coastal zone provide a certification that the proposed activity complies with the enforceable policies of the State's coastal zone program. Turkey Point Units 3 and 4 are within the Florida coastal zone. The Florida Department of Environmental Protection (FDEP) issued a license that constitutes concurrence that FPL's activities at Turkey Point are consistent with the State of Florida's approved coastal management program. The most recent conditions of certification for Turkey Point Units 3 through 5 (PA 03-45) show Turkey Point Units 3 and 4 as being certified to be consistent in 2008, with several modifications since then, the most recent having been issued on March 29, 2016 (FDEP 2016b).

Land to the south and west of the Turkey Point site is in the Everglades Mitigation Bank where wetlands are created, restored, or enhanced to provide compensatory mitigation of wetland losses elsewhere. Under the joint federally and State-operated mitigation bank program, both public and private entities can own lands in the program. FPL owns the Everglades Mitigation Bank land, which comprises approximately 13,000 ac (5,300 ha) of relatively undisturbed freshwater and estuarine wetlands. The U.S. Army Corps of Engineers, the EPA, the Natural Resources Conservation Service, the U.S. Fish and Wildlife Service (FWS), and the National Marine Fisheries Service (NMFS) review and comment on mitigation bank permit applications and subsequent Mitigation Banking Instruments issued by the U.S. Army Corps of Engineers to ensure consistency with specific laws and provisions, including Section 404 of the Federal Water Pollution Control Act (also known as the Clean Water Act [CWA]) permit program, the wetland conservation provisions of the Food Security Act, the National Environmental Policy Act (NEPA), and several other statutory provisions. The FDEP permits mitigation banks for utility companies within Florida pursuant to the Florida Mitigation Banking Rule and other State authorities.

3.2.1.3 Offsite Land Use

Biscayne Bay, located immediately adjacent to Turkey Point, is the predominant natural feature in the vicinity of the Turkey Point site. As described earlier, the largest land use and land cover category at Turkey Point is wetlands and open water, of which open water is the largest component. The next largest land use and land cover category is wetland areas, comprised of woody and emergent herbaceous wetlands. And finally, the third largest land use and land cover category is developed land.

The pattern of land use and urban growth has remained essentially unchanged in Miami-Dade County since 1975, which is when the County released the original Comprehensive Master Development Plan (CMDP). The CMDP establishes a growth policy that encourages development (1) at a rate commensurate with projected county population and economic growth, (2) in a contiguous pattern around a network of high-intensity urban centers connected to transportation facilities, and (3) in locations which optimize efficiency in public service delivery and conservation of valuable natural resources (MDC 2017a).

3.2.2 Visual Resources

The Turkey Point site is relatively flat and sparsely populated with trees. The most visible features are the containment structures for Units 3 and 4. They are the tallest structures on the site at approximately 210 feet (64 m) tall (FPL 2018f). However, trees and other vegetation

screen most of Turkey Point Units 3 and 4 and supporting structures from roadways and recreational areas west of the plant site. In addition, vegetation blocks the view of Turkey Point Units 3 and 4 from the Biscayne National Park Dante Fascell Visitor Center and Homestead Bayfront Park, although the units can be clearly seen from other areas of Biscayne National Park, including much of Biscayne Bay. At night, light from Turkey Point is visible from several locations outside the site, including from the Homestead-Miami Speedway and Biscayne Bay (NRC 2016a).

3.3 Meteorology, Air Quality, and Noise

This section describes the meteorology, air quality, and noise environment in the vicinity of Turkey Point.

3.3.1 Meteorology and Climatology

The State of Florida is characterized by a humid subtropical climate, with long, hot summers and short, mild winters. The climate of Florida is largely influenced by the warm waters of the Gulf of Mexico and western Atlantic. Air from the Gulf of Mexico moderates summer heat, shortens winter cold spells, and provides moisture and heavy rainfall during all seasons. Florida is subject to frequent thunderstorms during the summer, and historically, the State experiences the highest annual number of thunderstorms in the United States. The State is also vulnerable to tornados and tropical cyclones (tropical storms and hurricanes) that develop in the Gulf of Mexico and western Atlantic. On average, tropical cyclones strike Florida three times every 5 years, and the Florida coast is vulnerable to severe flooding from these storms (NOAA 2013a, Runkle et al. 2017). Turkey Point is located on the lower east coast of Florida. The general climate in this area is subtropical marine, characterized by a long warm summer with abundant rainfall followed by a mild dry winter (NCDC 2017). The Azores-Bermuda high-pressure system dominates the circulation pattern in this region for most of the year, causing a tropical air mass to prevail. Occasional cold continental air masses displace the maritime air during winter (NRC 2016a).

Section 2.9.1 of the EIS for the Turkey Point Units 6 and 7 combined licenses (NRC 2016a) describes in detail the area's specific climatological and meteorological conditions including wind, temperature, precipitation, and severe weather. The NRC staff incorporates into this SEIS the information in Section 2.9.1 of the COL EIS by reference. The NRC staff did not identify any new and significant information relevant to the climatological and meteorological environment beyond the information described in the EIS for the Turkey Point Units 6 and 7 combined licenses that would alter the discussion contained in Section 2.9.1 of the COL EIS.

In the past 67 years (1950–2017), the following numbers of severe weather events have been reported in Miami-Dade County (NCDC 2018):

- Hurricane: 10 events
- Tornado: 137 events
- Thunderstorm: 312 events
- Flood: 13 events

3.3.2 Air Quality

Under the Clean Air Act (CAA), 42 U.S.C. 7401, et seq., the EPA has set primary and secondary National Ambient Air Quality Standards (NAAQS) (40 CFR Part 50, "National Primary

and Secondary Ambient Air Quality Standards”) for six common criteria pollutants to protect sensitive populations and the environment: carbon monoxide (CO), lead (Pb), nitrogen dioxide (NO₂), ozone (O₃), sulfur dioxide (SO₂), and particulate matter (PM). NAAQS further categorize particulate matter under two sizes—PM₁₀ (diameter between 2.5 and 10 micrometers) and PM_{2.5} (diameter of 2.5 micrometers or less). Table 3-1 presents the NAAQS for the six criteria pollutants.

Table 3-1 Ambient Air Quality Standards

Pollutant	Averaging Time	National Standard Concentration
Carbon Monoxide (CO)	8-hour	9 ppm (primary standard)
	1-hour	35 ppm (primary standard)
Lead (Pb)	Rolling 3-month average	0.15 µg/m ³
Nitrogen Dioxide (NO ₂)	1-hour	100 ppb (primary standard)
	Annual	53 ppb (primary and secondary standard)
Ozone (O ₃)	8-hour	0.070 ppm (primary and secondary standard) ^(a)
Particulate matter less than 2.5 µm (PM _{2.5})	Annual	12 µg/m ³ (secondary) 15 µg/m ³ (secondary)
	24-hour	35 µg/m ³ (primary and secondary standard)
Particulate matter less than 10 µm (PM ₁₀)	24-hour	150 µg/m ³ (primary and secondary standard)
Sulfur Dioxide (SO ₂)	1-hour	75 ppb (primary standard)
	3-hour	0.5 ppm (secondary standard)

Key: ppb = parts per billion; ppm = parts per million; µg/m³ = micrograms per cubic meter. To convert ppb to ppm, divide by 1000.

(a) Final rule signed October 1, 2015, and effective December 28, 2015. The previous (2008) ozone (O₃) standards additionally remain in effect in some areas.

Primary standards provide public health protection, including the health of sensitive populations such as asthmatics, children, and the elderly. Secondary standards provide public welfare protection, including protection against decreased visibility and damage to animals, crops, vegetation, and buildings.

Source: EPA 2018a

With respect to meeting NAAQS, the EPA designates areas that meet the standards as areas of attainment and areas that do not meet the standards as areas of nonattainment. Areas for which there is insufficient data to determine attainment or nonattainment, the EPA designates as unclassifiable. Areas that once did not meet the standards but now do meet the standards, the EPA calls maintenance areas; maintenance areas are under a 10-year monitoring plan to maintain the attainment designation status. States bear the primary responsibility for ensuring attainment and maintenance under NAAQS. Under Section 110 of the Clean Air Act and related provisions, States must submit, for EPA approval, State implementation plans (SIPs) that provide for the timely attainment and maintenance of the NAAQS.

In Florida, air quality designations are made at the county level. For the purpose of planning and maintaining ambient air quality under NAAQS, the EPA has developed air quality control regions. Air quality control regions are intrastate or interstate areas that share a common airshed. Turkey Point is located in Miami-Dade County, which is part of the EPA’s Southeast Florida Intrastate Air Quality Control Region (40 CFR 81.49, “Southeast Florida Intrastate Air Quality Control Region”). This air quality control region consists of eight Florida counties: Broward, Miami-Dade, Indian River, Martin, Monroe, Okeechobee, Palm Beach, and St. Lucie. With respect to meeting NAAQS, EPA designates Miami-Dade County as unclassifiable/attainment or better than national standards for all criteria pollutants (40 CFR 81.310, “Florida”). The nearest designated nonattainment area (for the 2010 sulfur dioxide primary standard) is in Hillsborough County, FL, which is nearly 200 mi (320 km) from Turkey Point.

The Clean Air Act, Title V, “Permits,” requires States to develop and implement an air pollution permit program. The FDEP regulates air emissions at Turkey Point under Title V air operation permits (FDEP 2018c, FDEP 2018g, FPL 2018f). Combined Turkey Point Units 1, 3, 4, and 5 are considered one facility for purposes of the Prevention of Significant Deterioration permitting program and Title V operating permits. However, FPL operates these units under two separate Title V permits: one for fossil fuel Unit 5 (Permit 0250003-030-AV) (Unit 1, which has been retired, was deleted from the permit upon its renewal in November 2018), and another for nuclear Units 3 and 4 (Permit 0250003-028-AV). The FDEP issued Title V Air Operation Permit 0250003-028-AV for Turkey Point Units 3 and 4 in April 2018, and this permit will expire in 2023 (FDEP 2018c). Table 3-2 lists permitted air pollutant emission sources and air permit specified conditions for Turkey Point Units 3 and 4.

Table 3-2 Permitted Air Emission Sources at Turkey Point Units 3 and 4

Equipment	Air Permit Condition
Five emergency diesel engines used to support plant equipment: <ul style="list-style-type: none"> • Industrial back-up instrument air compressors (2) • Backup service water feed system pump • 10-meter meteorological tower generator • Domestic wastewater system pump 	PM, CO, and NO _x limits
One emergency diesel generator engine for the South Dade meteorological tower One emergency diesel fire pump	40 CFR Part 63, Subpart A, (NESHAP General Provisions) and 40 CFR Part 63, Subpart ZZZZ (NESHAP RICE)
Four diesel-engine emergency generators Two emergency diesel engines used to support plant equipment	Unregulated

Key: PM = particulate matter, NO_x = nitrogen oxides, CO = carbon monoxide, NESHAP = National Emission Standards for Hazardous Air Pollutants, RICE = reciprocating internal combustion engines

Source: FDEP 2018c

Table 3-3 shows annual emissions from permitted sources at Turkey Point Units 3 and 4. FPL operates diesel generators/engines at Turkey Point Units 3 and 4 only intermittently (usually during testing or during outages) as these are intended to be used to supply backup emergency power. According to the 2014 National Emissions Inventory, estimated annual emissions in

tons per year for Miami-Dade County are approximately 3,650 (sulfur dioxide); 49,600 (nitrogen dioxide); 335,000 (carbon monoxide); 33,000 (particulate matter less than 10 microns); and 86,900 (volatile organic compounds) (EPA 2018b). Turkey Point Units 3 and 4 air emissions from permitted sources make up 0.05 percent or less of Miami-Dade County's total annual emissions. Greenhouse gas emissions from operation of Turkey Point Units 3 and 4 are discussed in Section 4.15.3 of this SEIS.

Table 3-3 Estimated Air Pollutant Emissions from Turkey Point Units 3 and 4

Emissions (tons/year)					
Year	SO _x	NO _x	CO	PM ₁₀	VOCs
2012	1.5	16	2.1	1.8	0.8
2013	1.5	15	1.8	1.8	0.7
2014	1.8	19	2.4	2.2	0.9
2015	2.1	21	2.7	2.5	1.0
2016	1.7	17	2.0	2.0	0.8

Key: CO = carbon monoxide, NO_x = nitrogen oxides, SO_x = sulfur dioxides, PM₁₀ = particulate matter less than 10 micrometers, VOC = volatile organic compounds
 To convert tons per year to metric tons per year, multiply by 0.90718.

Source: FPL 2018f

The EPA promulgated the Regional Haze Rule to improve and protect visibility in national parks and wilderness areas from haze, which is caused by numerous, diverse air pollutant sources located across a broad region (40 CFR 51.308–51.309). Specifically, 40 CFR Part 81, Subpart D, “Identification of Mandatory Class I Federal Areas Where Visibility Is an Important Value,” lists mandatory Federal areas where visibility is an important value. The Regional Haze Rule requires States to develop state implementation plans to reduce visibility impairment at Class I Federal areas. At Turkey Point, the nearest Class I Federal area is Everglades National Park, approximately 13 mi (21 km) west of Units 3 and 4 (FPL 2018f). Given Turkey Point Units 3 and 4’s limited air emissions as presented in Table 3-3, there is little likelihood that ongoing activities at Turkey Point Units 3 and 4 during the subsequent license renewal term would adversely affect air quality and air quality-related values (e.g., visibility or acid deposition) in any Class I Federal areas.

3.3.3 Noise

Section 2.2.8.4 of NUREG–1437, Supplement 5 (the SEIS for the Turkey Point initial license renewal), describes general noise conditions at Turkey Point Units 3 and 4 (NRC 2002c). This information is incorporated here by reference. Section 2.10.2 of the EIS for the Turkey Point Units 6 and 7 combined licenses (NRC 2016a) also describes ambient noise conditions at the Turkey Point site. This information is also incorporated here by reference (NRC 2016a). No new and significant information about noise at the Turkey Point site was identified during the review of available information, including FPL’s environmental report for the Turkey Point Units 3 and 4 subsequent license renewal (FPL 2018f), the site visit, or during the scoping process that would alter the discussion contained in the SEIS for Turkey Point’s initial license renewal.

FPL conducted a noise survey for the Turkey Point Units 6 and 7 COL application environmental report in June 2008. The survey determined baseline ambient noise conditions near the proposed Turkey Point Units 6 and 7 site (including describing noise from Turkey Point Units 3 and 4) and identified sensitive offsite noise receptors. The nearest sensitive noise receptors included residences to the northwest, a daycare facility to the west, and Homestead Bayfront Park to the north (FPL 2014a).

In general, noise from the Turkey Point site can be detected under certain conditions by visitors in Biscayne National Park. Noise is most noticeable under calm wind conditions or when the wind is blowing lightly from the Turkey Point site to the park. Noise from Turkey Point Units 3 and 4 is generally not an issue at the nearest sensitive noise receptors west of the plant (a daycare facility) due to trees, other vegetation, and attenuation by distance.

3.4 Geologic Environment

This section describes the geologic environment of the Turkey Point site and vicinity, including landforms, geology, soils, and seismic conditions.

3.4.1 Physiography, Geology, and Soils

The land surface at Turkey Point and the area around it is practically flat. Elevations rise from sea level at the site to 10 feet (3 m) mean sea level (MSL) in the Homestead area 9 mi (14.5 km) to the west of Turkey Point. South Florida is underlain by gently dipping or flat-lying sedimentary rocks. In South Florida, these sedimentary rocks are more than 15,000 ft (4,572 m) thick. Limestone is the predominant rock found in the upper 5,000 ft (1,524 m) (FPL 2018f).

The limestone rock is divided into stratigraphic units based on geologic properties. The left side of Figure 3-7 identifies the stratigraphic units beneath Turkey Point down to a depth of greater than 3,030 feet (924 m). For each stratigraphic unit, the figure also includes a brief description of the rock characteristics (lithology), thicknesses, and depth.

The surficial material under Turkey Point consists of engineered fill. The surficial material within the Turkey Point site, which includes Turkey Point Units 1, 2, 3, 4, and 5, and the CCS, consists of either engineered fill, limestone, marl, or muck. Structures and roads are built on engineered fill or limestone. Any soils within the Turkey Point site consist of marl or muck. The muck consists of herbaceous organic material over limestone. The marl consists of loamy marine deposits over limestone (FPL 2018f, USDA 2017).

Some local depressions in the surface of the limestone bedrock occur at the Turkey Point site. These depressions are not sinkholes associated with the collapse of an underground solution channel, but rather potholes, which are surficial erosion or solution features. It is possible these features formed when sea levels were lower, and the rock surface was subjected to weathering and the effects of fresh water (FPL 2018f).

3.4.2 Economic Resources

Significant deposits of oil, gas, and other mineable resources are not known to exist beneath the Turkey Point site (NRC 2016a). Large quarries extract limestone rock in south Florida. This mining area is known as the Lake Belt Region. Limestone is found at or near land surface throughout the entire area. It is used as base material for roads and airport runways, as a

construction aggregate, and in cement manufacturing (FDOT 2007, NRC 2016a, USGS 2018b, MDC 2017b). From Turkey Point, the nearest limestone quarrying is located 4.5 mi (7.2 km) west of the site (MDC 2017b). Another nearby mining area is the Atlantic Civil rock mine located about 10 mi (16 km) west of Turkey Point (NRC 2016a). Although the near-surface rock at Turkey Point is composed of limestone, the site's location near Biscayne National Park and its saltwater content makes it an unlikely choice for a future limestone mine.

3.4.3 Seismic Setting

Florida has a very small probability of experiencing damaging earthquake effects (FEMA 2018a). Based on historical or statistical seismic activity, Turkey Point is located in an inactive area for earthquakes and far from any recorded damaging shocks (FPL 2018f). Even so, the NRC evaluates the potential effects of seismic activity on a nuclear power plant in an ongoing process that is separate from the license renewal process. The NRC requires every nuclear plant to be designed for site-specific ground motions that are appropriate for its location. Nuclear power plants, including Turkey Point, are designed and built to withstand site-specific ground motion based on their location and the potential for nearby earthquake activity. The seismic design basis is established during the initial siting process, using site-specific seismic hazard assessments. For each nuclear power plant site, applicants estimate a design-basis ground motion based on potential earthquake sources, seismic wave propagations, and site responses, and then account for these factors in the plant's design. In this way, nuclear power plants are designed to safely withstand the potential effects of large earthquakes. Over time, the NRC's understanding of the seismic hazard for a given nuclear power plant may change as methods of assessing seismic hazards evolve and the scientific understanding of earthquake hazards improves (NRC 2014a). As new seismic information becomes available, the NRC expects that licensees will evaluate the new information to determine if safety systems at a plant require changes. Independently, the NRC also evaluates new seismic information and confirms that licensees appropriately consider potential changes in seismic hazards at the site.

SERIES	STRATIGRAPHIC UNIT		LITHOLOGY	TOP DEPTH (ft)	THICKNESS (ft)	HYDRO-GEOLOGIC UNIT	TOP DEPTH (ft)
HOLOCENE	organic muck		organic soil and silt	0	3	Biscayne Aquifer	0 - 3
PLEISTOCENE	Miami Formation		sandy, oolitic limestone	3	25		
	Key Largo Limestone		well indurated, vuggy, coralline limestone	28	22		
	Ft Thompson Formation		poor/well indurated fossiliferous limestone	50	65		
PLIOCENE	Tamiami Formation		sand and silt with calcarenite limestone	115	105	Intermediate Confining Unit	140
MIOCENE	Hawthorne Group	Peace River Formation	silty calcareous sand and silt	220	235		
		Arcadia Formaion	calcareous wackestone with indurated limestone, sandstone and sand	455	555		
OLIGO-CENE	Suwannee Limestone		fine-grained limestone and dolomitic limestone	1010	245	Upper Floridan Aquifer (USDW)	1010
EOCENE	Avon Park Formation		fine-grained limestone and dolomite	1255	(~445)	Middle Floridan Confining Unit	1450
			permeable limestone	(~1700)	(~75)	APPZ (?)	(1700)
			fine-grained limestone and dolomite	(1775)	745	Middle Floridan Confining Unit	1930
	Oldsmar Formation		limestone, dolomitic limestone and dolomite	2580	450		
			Boulder Zone	3030	>200	Lower Floridan Aquifer	2915
						Boulder Zone	3030

Source: NRC 2016a

Figure 3-7 Geologic Stratigraphy and Major Aquifers Beneath the Turkey Point Site

3.5 Water Resources

This section describes surface water and groundwater resources at and around the Turkey Point site, with an emphasis on Turkey Point, Units 3 and 4.

At the Turkey Point site, surface water (including the area's freshwater canals, wetlands, and the adjoining Biscayne Bay) and groundwater are closely connected. This close relationship is attributable to the very high permeability of the underlying Biscayne aquifer, which permits water to move relatively freely between the surface and subsurface. As a result, the CCS is

hydraulically connected to surface waters including Biscayne Bay via the groundwater pathway. These factors have been considered as part of the NRC staff's characterization of surface water and groundwater resources as presented in Sections 3.5.1 and 3.5.2 below, as well as in the staff's impact analyses for water resources presented in Section 4.5, "Water Resources."

3.5.1 Surface Water

Surface water encompasses all water bodies that occur above the ground surface, including rivers, streams, lakes, ponds, and man-made reservoirs or impoundments.

3.5.1.1 Surface Water Hydrology

Local and Regional Hydrology


Biscayne Bay and the area around Turkey Point are part of the South Florida Hydrologic System (Figure 3-8). This encompasses a large area that includes the Everglades and Southern Florida coastal areas. Human activities have extensively influenced this system principally by population increases and land-use changes that resulted in the conversion of wetlands to agriculture and other uses. A significant contributor to these changes was the use of canals to drain land and redistribute surface water to other areas.

The South Florida Hydrologic System and how it has changed over time is described in the EIS for the Turkey Point Units 6 and 7 combined licenses (NRC 2016a) in Section 2.3.1.1 from pages 2-25 to 2-30, including Figures 2-8, 2-9, 2-10, and 2-11. The NRC staff incorporates the above text and figures into this SEIS by reference.

The regional surface water system west of Biscayne Bay encompasses the area east and south of the section of the Atlantic Coastal Ridge (ACR) near Biscayne Bay. Historically, various natural swales or glades and sloughs conveyed freshwater eastward to the coastal wetlands adjacent to Biscayne Bay and Card Sound. From there, freshwater discharged into Biscayne Bay and Card Sound either directly by surface water from the coastal wetlands or indirectly through groundwater. Under current conditions, manmade canals crisscross the landscape. These canals drain the land for agriculture and urban use, provide flood control, and discharge their freshwater into Biscayne Bay and Card Sound (NRC 2016a).

The canals also have an indirect impact on groundwater resources. Draining the land causes the water level in near-surface aquifers to drop. This in turn has contributed to the inland movement of groundwater that contains salt (saltwater intrusion) from Biscayne Bay and Card Sound (see Section 3.5.2). The canals contain control structures to prevent the inland movement of surface water from Biscayne Bay and Card Sound. During the wet season (typically, the months of June – October), coastal control structures periodically open and discharge freshwater to Biscayne Bay. During the dry season, coastal control structures generally remain closed to maintain relatively high water levels along the coast and prevent saltwater intrusion within near-surface aquifers. (USGS 2001).

The Turkey Point Units 6 and 7 COL EIS (NRC 2016a) in Section 2.3.1.1 (on Pages 2-31 and 2-32, including Figure 2-12) describes the regional surface water system west of Biscayne Bay and how it has changed over time. The NRC staff incorporates this text and figure into this SEIS by reference.



Source: Modified from NRC 2016a

Figure 3-8 Turkey Point Site, Biscayne Bay, Card Sound, and Regional Canals

Biscayne Bay and Card Sound

Biscayne Bay is located east of and adjacent to the Turkey Point site. (Figure 3-8). Card Sound is located to the southeast of the site. Both are shallow bays that formed in depressions in the limestone bedrock. The bays are bounded on the east by coral keys that are formed from wave-resistant limestone. Both Biscayne Bay and Card Sound are in direct contact with the Biscayne aquifer as the limestone rock of the aquifer forms the bottom of both bays (see Section 3.5, "Groundwater Resources") (NPS 2015a, NPS 2012, NRC 1972, USGS 2008b).

Biscayne Bay and Card Sound are separated by Cutter Bank which is an underwater topographic rise (mud bank) (NRC 1972). Near the Turkey Point site, both Biscayne Bay and Card Sound are shallow bays. Within Biscayne Bay, over most of the distance between the Turkey Point site and the coral keys, the depth of the water generally ranges from 2 to 6 ft (0.6 to 1.8 m), reaching a maximum depth of about 7 ft (2.1 m). Within Card Sound, over most of the distance between the Turkey Point site and the coral keys, the depth of the water generally ranges from 4 to 9 ft (1.2 to 2.7 m), reaching a maximum depth of about 10 ft (3 m) (NOAA 2018a). Both Biscayne Bay and Card Sound are connected to the Atlantic Ocean by gaps between the coral keys. However, near the Turkey Point site, the enclosed configuration of the coral keys has isolated much of Biscayne Bay and Card Sound from direct marine influence (USGS 2008b).

The hydrology and hydrodynamics of Biscayne Bay and Card Sound are influenced by several factors: (1) tidal exchange of marine waters from the Atlantic Ocean, (2) surface and groundwater inflows of freshwater, (3) precipitation, and (4) evaporation (NRC 2016a). All of these factors also influence the salinity in Biscayne Bay and Card Sound. During the wet season, precipitation decreases the salinity in the bay and the sound. During dry periods, evaporation increases salinity within the bay and the sound, and salinities can become hypersaline (NRC 2016a).

The construction of drainage canals on the mainland has also impacted salinity in the bay and sound. This impact is greatest in the near-shore areas adjacent to the mainland. Prior to the construction of drainage canals, freshwater entered the bay and sound from the mainland by widespread sheet flow and groundwater discharge. This provided a more uniform and continuous supply of freshwater to the bay and the sound than the present situation. With the construction of drainage canals, freshwater was less uniformly distributed as the canals discharged freshwater at discrete locations. The result is that areas near canal discharge locations have less saline water than areas farther away from the discharge locations (NRC 2016a).

Another way that drainage canals have impacted salinity in the bay and the sound is through seasonal differences in the amount of canal discharge. The canals generally discharge the most freshwater into the bay and sound during wet times of the year and the least during dry periods. As a result, salinity concentrations throughout the year in the bay and sound are more variable in time and space than prior to the construction of drainage canals (NRC 2016a). In addition, modeling studies suggest that drainage canals may intercept surface runoff thereby preventing that runoff from infiltrating and raising the groundwater table elevation (USGS 2012). The reduced infiltration may result in reduced groundwater discharge into Biscayne Bay and Card Sound.

Around the Turkey Point site, drainage canals discharge to Biscayne Bay north of the site and to Card Sound south of the site. The Turkey Point site occupies an area of former sheet flow that

discharged into the bay. Since 1900, the hydrology of the Southern Florida Coastal Plain ecoregion, within which the Turkey Point site is located, has been highly altered by human activity to support agriculture and urban development. Under the Central and Southern Florida Flood Control Project, which was authorized by Congress in 1948, the government constructed a series of canals for flood control, water supply and retention, irrigation, and transportation. These canals drained the land, which resulted in reduced sheet flow to the Biscayne Bay and Card Sound. Development of the Turkey Point site also blocks sheet flow from reaching Biscayne Bay (NRC 2016a). One aim of the Everglades Mitigation Bank is to restore historic sheet flow south of the Turkey Point site through the construction and operation of culverts (FPL 2018f).

Pollution from human activities also impacts the water quality of Biscayne Bay. Sections of the shoreline of Biscayne Bay are highly developed. The southern end of Biscayne Bay and Card Sound is less urbanized than the northern section of Biscayne Bay. Pollutants can potentially enter Biscayne Bay from multiple sources, including boats, canals, quarrying operations, landfills, military operations, a sewage-treatment plant, urban and agricultural runoff, and submarine groundwater springs (USGS 2008b).

The inflow of fresh water that is high in nutrients thus appears to be a significant issue affecting the ecosystem in Biscayne Bay. The EIS for the Turkey Point Units 6 and 7 combined licenses (NRC 2016a) in Section 2.3.1.1 (on pages 2-33 through 2-38, including Figures 2-14, and 2-15, and Table 2-8) describes the hydrology and hydrodynamics of Biscayne Bay. The NRC staff incorporates the above text and figures into this SEIS by reference.

Management of Biscayne Bay and Card Sound Water Quality

The Florida legislature has designated Biscayne Bay and Card Sound, including Biscayne National Park, as Outstanding Florida Waters. This affords these waters the highest water quality protections in the State (NRC 2016a; Robles, et al 2005; NPS 2012). The FDEP cannot issue new permits for direct discharges to designated Outstanding Florida Waters that would lower ambient (existing) water quality and may not issue permits for indirect discharges that would significantly degrade a nearby waterbody designated as an Outstanding Florida Water (FDEP 2017a). Florida water quality rules provide exceptions for permits that were issued prior to the effective date of an Outstanding Florida Waters designation (see FAC 62-4.242(2)(a)).

Card Sound and the north half of Biscayne Bay are within the Biscayne Bay Aquatic Preserve. The FDEP's Office of Coastal and Aquatic Managed Areas manages this preserve (NRC 2016a). One of the management goals is to protect and enhance the waters of the preserve so the public may enjoy the traditional recreational uses of those waters such as swimming, boating, and fishing. No wastes or effluents which substantially inhibit the accomplishment of these purposes can be discharged into the preserve (Florida Statute 258.397).

The rest of Biscayne Bay lies within Biscayne National Park (Park), including the Biscayne Bay waters adjacent to the Turkey Point site (NRC 2016a). Biscayne National Park was established "in order to preserve and protect for the education, inspiration, recreation, and enjoyment of present and future generations a rare combination of terrestrial, marine, and amphibious life in a tropical setting of great natural beauty" (USGS 2008b). The park is managed by the U.S. National Park Service. In 2015, a Final General Management Plan was completed for the Park. This plan contains strategies on the management of the resources and activities within the Park to best fulfill Biscayne National Park's mission. It can be found under reference NPS 2015a.

Relationship of Water Quality to Biologic Communities in Biscayne Bay and Card Sound

The southern coastal system of the State of Florida is a contiguous network of coastal wetlands and estuaries that wrap around the southern end of the Florida peninsula from Biscayne Bay on the southeastern coast to the Ten Thousand Islands area on the Upper Southwest Coast. The loss of freshwater wetlands upstream, and increasing human alteration of the regional hydrology for flood protection and societal water supply, have decreased the flow of freshwater into the southern coastal systems. This has altered salinity in the shallow coastal waters and degraded habitat for valuable estuarine fish and wildlife. From 2012–2017, the inconsistent delivery of freshwater combined with periods of significant drought, hurricanes and sea level rise, have continued to impact the biologic communities of the southern coastal region (RECOVER 2019).

The Restoration Coordination and Verification program reported in its 2019 Everglades System Status Report that a local drought in 2014 and 2015 and associated elevated salinity in combination with reduced freshwater flow negatively impacted some aquatic species and submerged aquatic vegetation in Biscayne Bay and Florida Bay (Figure 3-8). Salinity measurements over the past decade indicate that freshwater flows into Biscayne Bay's southwestern perimeter lack both volume and duration to significantly improve the biological communities that reside along the shoreline and in its vicinity (RECOVER 2019).

Nutrients, particularly macronutrients such as nitrogen and phosphorous are key water quality indicators for Biscayne Bay. The Turkey Point site is located next to the South Central Mid-Bay Region of Biscayne Bay. The State of Florida has established numerical nutrient criteria for this region of 0.007 mg/L for total phosphorous, 0.35 mg/L for total nitrogen, and 0.2 micrograms/L for chlorophyll-a. These criteria are expressed as annual geometric means and are not to be exceeded more than once in a 3-year period (Figure 3-9) (FDEP 2018e).

The chlorophyll-a concentration in the surface water is related to the concentration of algae in the water column. Chlorophyll-a concentrations, in combination with a nutrient analysis, can be used to assess the health of Biscayne Bay. For example, this information can be used to monitor for algal blooms or eutrophic conditions and to identify sources of excess nutrients (BBWW 2019).

As previously mentioned, nutrients can enter Biscayne Bay and Card Sound from several sources and pathways, including urban runoff (e.g., streets, lawns), animal manure run off, sewage, leaking septic tanks, fertilizer, and erosion of land that is rich in phosphates and nitrates (BBWW_2019). Notably, storm events are often accompanied by high-volume discharges from regional canals before and after a storm. These discharges often contain high levels of nutrients (MDC 2019b).

In September 2005, a phytoplankton bloom formed in a series of shallow lagoons between Florida Bay and Biscayne Bay. The bloom lasted 3 years and spanned an area from Duck Key in Florida Bay to Card Sound in southern Biscayne Bay. Some scientists have hypothesized that the bloom was triggered by the occurrence of three hurricanes over a 3-month period (Katrina, Rita, and Wilma) combined with a major construction project on an adjacent causeway (Millette et al. 2018). The bloom had the largest impact in the region of Manatee Bay, Blackwater Sound, Long Sound, and Barnes Sound. The highest peak in chlorophyll-a concentrations (>20 microg/L) occurred in Blackwater Sound and Barnes Sound. It is unknown if the system fully shifted back to being dominated by benthic production after the bloom (Millette et al. 2018). To date, seagrass recovery is minimal and chlorophyll-a concentrations remain elevated (MDC 2019b).

Since 2008, a bloom of green macroalgae has persisted in northwestern Biscayne Bay. The bloom displaced once-healthy seagrass beds. The bloom is in an area of high levels of dissolved nutrients, as well as the presence of sucralose, which is an indicator of human waste water. In addition, an incipient bloom of green macroalgae was detected in the Deering Estate area along the western shore of central Biscayne Bay (RECOVER 2019).

Miami-Dade County has monitored seagrass and water quality in Biscayne Bay for over 30 years. Since 1985, the monitoring program has documented largely stable seagrass throughout the Bay, with only one seagrass loss event documented prior to 2005, and no significant phytoplankton or macroalgal blooms. However, since 2005, there has been a succession of algal blooms and seagrass losses with two significant phytoplankton blooms and a macroalgal bloom (RECOVER 2019).


The level of seagrass abundance over the past 10 years in western Biscayne Bay has had high seasonal fluctuations but is reasonably stable and largely unaffected by large-scale disturbances (RECOVER 2019). However, the parts of the bay receiving waters from some of the most nutrient-rich canals include basins where seagrass die-off has occurred. Miami-Dade County reports that over the past decade, three areas have experienced significant seagrass losses (Figures 3-10 and 3-11).

- 1) The Barnes Sound and Manatee Basins experienced a decrease in seagrass of approximately 93 percent.
- 2) The central portion of Biscayne Bay near Coral Gables experienced a decrease of 85 percent.
- 3) Basins north of the Rickenbacker Causeway experienced a decrease of 66 to 89 percent (MDC 2019b).

Miami-Dade County reports that chronic low-level nutrient loading and/or acute, pulsed nutrient loading is likely linked to seagrass loss in Biscayne Bay. The County is concerned that excess nutrients can lead to a shift from a seagrass-dominated habitat with clear water, low turbidity, and low levels of algae in the water column to an algae-based ecosystem that is turbid and contains reduced-quality habitat for fish (MDC 2019b).

In the 2019 Everglades System Status Report, the Restoration Coordination and Verification program states that “[l]ong-term evaluations have shown increasing trends in chlorophyll-a, total phosphorus, and total nitrogen. Looking ahead, the future of Biscayne Bay’s submerged aquatic vegetation appears bleak. Given the large areas that have been impacted by seagrass losses, with limited to no recovery and the shift to increased chlorophyll-a that follows those losses, coupled with the long-term increasing trends in nutrients and chlorophyll-a, it is likely that recovery from seagrass losses will remain limited and the Bay is at risk of further declines in the submerged aquatic vegetation community” (RECOVER 2019).

This SEIS contains additional information (see Section 3.7.4, “Biscayne Bay and Card Sound Semiannual Monitoring”) about seagrass habitat monitoring that is conducted in areas adjacent to the Turkey Point site. This monitoring is ongoing and is being carried out by FPL in connection with the FDEP Consent Order and the Consent Agreement with Miami-Dade County.




★ Turkey Point Site

Legend

- TP Total Phosphorous
- TN Total Nitrogen
- Chl-a Chlorophyll-a


Source: Modified from RECOVER 2014

Figure 3-9 Numeric Surface Water Criteria for Regions of Biscayne Bay



Source: Modified from MDC 2019b

Figure 3-10 Sea Grass Loss Areas from 2005 to 2018 by Regions North Half of Biscayne Bay



★ Turkey Point Site

Source: Modified from MDC 2019b

Figure 3-11 Sea Grass Loss Areas from 2005 to 2018 by Regions South Half of Biscayne Bay

Marshland and Mangrove Areas Adjacent to the Turkey Point Site

The Turkey Point site is adjacent to marshland outside its northwest, west, and southern boundaries and a significant portion of its eastern boundary. Surface water within the marshland lies on top of muck, which in turn lies on top of the Biscayne aquifer. The surface water hydrology of the marshlands is driven by rain, surface water runoff, freshwater canal overflows, and saltwater from Biscayne Bay and Card Sound (tides, storms, groundwater) (FPL 2016a). Mangrove areas are located adjacent to Biscayne Bay. Soil porewater samples from the marshland muck show that the marshlands adjacent to and west of the Turkey Point are filled with freshwater, whereas marshlands adjacent to and south and east of the Turkey Point site are filled with brackish water. The marshlands become more brackish the closer they are to Biscayne Bay or Card Sound (FPL 2014b, 2016a, 2017a).

Canals Adjacent to the Turkey Point Site

A network of drainage canals provides freshwater and drainage to southeastern Florida (FPL 2018f). Some of these canals can be found near the Turkey Point site (Figure 3-4). The CCS does not have a surface water connection with any of these canals. North of the Turkey Point site, the Florida City Canal runs east to west and discharges fresh water into Biscayne Bay (FPL 2014a). West of the Turkey Point site, the L-31E Canal contains freshwater and runs northeast to southwest (FPL 2016a).

South of the Turkey Point site, the S-20 Canal and the Sea Dade Canal remnant canal run east to west. The S-20 Canal runs outside the southeast corner of the CCS. It is connected to the L31E Canal by a flow control structure on its western end and connects to Card Sound south of the site. The S-20 Canal contains fresh water when water is being discharged through it and marine water when there is no fresh water discharge through it. The Sea Dade Canal once connected to the S-20 Canal; however, under the provisions of the Everglades Mitigation Bank program, the Sea Dade Canal was plugged off from the S-20 Canal. The Sea Dade Canal is currently a remnant, dead-end canal with no connection to either the Card Sound or Biscayne Bay. The Card Sound remnant canal is also adjacent to the CCS. It runs in a generally north-south direction and dead ends against the outside of the CCS. It contains marine water and connects to Card Sound.

Potential for Flooding at the Turkey Point Site

The NRC evaluates the potential effects of floods on a nuclear power plant as a safety issue in a separate and distinct process, outside of the license renewal process. The NRC addresses flood hazard issues on an ongoing basis at all licensed nuclear facilities (NRC 2013a). The NRC requires every nuclear power plant to be designed for site-specific floods, to assure protection for safety-related equipment and facilities. As new information on flood hazard issues becomes available, the NRC expects each licensee to evaluate the new information to determine if its plant requires changes to protect its safety systems. The NRC also evaluates new information important to flood projections and independently confirms that a licensee's actions appropriately consider potential changes in flooding hazards at the site.

For structures that are important to the safe operation of the nuclear units, the NRC requires that they be designed and operated in consideration of potential flooding. The NRC does not have similar requirements for nonsafety-related structures. At the Turkey Point site, such nonsafety-related structures include, for example, office buildings, the Unit 5 cooling towers, and

the CCS. Nonsafety-related structures, however, may be subject to additional requirements if their failure could impact a safety-related system, structure, or component.

FPL recently completed a new flood analysis in connection with the NRC's oversight of the current operating licenses at Turkey Point Units 3 and 4. For the current licensed period of operation, FPL submitted its analysis to the NRC in a process that was separate from subsequent license renewal. After extensive review, the NRC approved this flood analysis on June 29, 2017 (NRC 2017b)

The new flood analysis for Units 3 and 4 contained a maximum storm surge projection of 19.1 ft (5.8 m). In a separate and independent analysis, the maximum storm surge projection for the design of proposed Units 6 and 7 at the Turkey Point site was 24.8 ft (7.6 m). In the analysis for Units 3 and 4, FPL used a detailed model that contained more realism than the less detailed deterministic model used by FPL for Units 6 and 7. To account for the less detailed evaluation, more conservative assumptions were incorporated into the analysis for the Units 6 and 7 model. For example, the assumptions in the model used for Units 6 and 7 included (1) a hypothetical hurricane with an intensity much greater than has ever been observed in the Atlantic Ocean and (2) an additional 20 percent added margin to the final computed storm surge water level. This resulted in a higher maximum storm surge projection.

Class 1 structures on the Turkey Point site are flood protected up to a minimum elevation of 20 feet (6.1 m) MSL. With the exception of the intake cooling water (ICW) pumps, which are protected to 22.5 feet (6.9 m) MSL, components vital to safety are protected against flood tides and waves up to 22 feet (6.7 m) MSL on the east side of Turkey Point (FPL 2018f). In an emergency, if Turkey Point Units 3 and 4 are unable to obtain cooling water from the CCS, the reactors would be placed in a safe shutdown mode. While in this mode, the reactors would still need to be cooled, but would require much less cooling water. Should this situation ever occur, water for cooling would be supplied from a protected well that obtains brackish water from the Upper Floridan aquifer.

As part of the NRC's subsequent license renewal review for Turkey Point Units 3 and 4, a safety review is conducted in accordance with the requirements of 10 CFR Part 54 (Requirements for renewal of operating licenses for nuclear power plants). In this regard, FPL committed to develop and implement an aging management program for the CCS to protect against a structural failure of the cooling canals that could impact safety-related equipment. FPL stated in its license renewal application, that the aging management program for the CCS will be commensurate with Regulatory Guide 1.12, "Criteria and Design Features for Inspection of Water-Control Structures Associated with Nuclear Power Plants" (NRC 2016e). The aging management program proposed by FPL for the CCS will include these elements:

- 1) visual inspections performed at least once every 5 years
- 2) special inspections performed following major events such as hurricanes
- 3) photographs to document findings and trend degradation
- 4) the inspections will be consistent with the 10 elements of NUREG-2191, Section XI.S7, "Inspection of Water-Control Structures Associated with Nuclear Power Plants" (NRC 2017c)
- 5) monitored parameters include erosion and degradation

As part of the State of Florida's regulatory process, the FDEP is currently conducting a renewal process for FPL's national pollutant discharge elimination system (NPDES) permit for Turkey Point, including Units 1-5 (FDEP 2018f). The draft permit contains requirements for impoundment design, construction, operation, and maintenance. While the NRC aging management program is concerned with the safe operation of Units 3 and 4, the requirements of the State's draft NPDES permit address potential impacts on the environment from structural failure of the CCS. Some of the requirements of the draft NPDES permit are as follows.

- All impoundments used to hold or treat wastewater and stormwater, including the CCS, shall be designed, constructed, operated, and maintained to prevent the discharge of pollutants to waters of the State, except as authorized under the permit.
- Design, construction, operation, and maintenance of any impoundment shall be in accordance with all relevant State and Federal regulations and shall be certified by a qualified, State-registered professional engineer and permitted and inspected by the appropriate agency prior to use. When practicable, piezometers or other instrumentation shall be installed to aid monitoring of impoundment integrity
- In addition to other regular maintenance activities conducted for the CCS, the perimeter berms and slopes shall be maintained to protect the structural integrity. This may include removal of trees greater than 4 inches in diameter.
- The CCS periphery including the three small dams (Hotel 2, Turtle Point Canal, and the Cellular Cofferdam) shall be inspected above and below the surface waterline for the entire perimeter at a minimum of once every 5 years by an independent qualified, State-registered professional engineer. The three dams and all other aspects of the perimeter impoundments shall be inspected annually by a qualified, State-registered professional engineer. All impoundments other than the CCS shall be inspected at least monthly by qualified personnel. The term "qualified" means having successfully completed the Mine Safety and Health Administration Qualification for Impoundment Inspection course in addition to the Annual Retraining for Impoundment Qualification, or equivalent qualifications. Additional inspections by qualified personnel shall be done within 7 days after large or extended rain events (i.e., 10-year, 24-hour precipitation event).
- Inspections shall at a minimum include observations of dams, including the three dams (Hotel 2, Turtle Point Canal, and the Cellular Cofferdam) of the CCS, dikes and toe areas for erosion, corrosion, cracks or bulges, seepage, wet of soft soil, changes in geometry, the depth and elevation of the impounded water, sediment or slurry, freeboard, changes in vegetation such as overly lush, dead, or unnaturally tilted vegetation, and any other changes that may indicate a potential compromise to impoundment integrity.
- To monitor function of the cathodic protection system, suggested operation and maintenance practices described in the Operation and Maintenance Manual accompanying these devices shall be followed.
- The findings of each inspection shall be documented in a written annual inspection report.
- Within 24 hours of discovering changes that indicate a potential compromise to the structural integrity or the efficient operation of the CCS, the permittee shall begin

procedures to remediate the problem. Adherence to the six components of the Turkey Point Cooling Canal System Thermal Efficiency Plan dated December 14, 2016, shall be incorporated into the facility's best management practices.

- Within 5 days of discovering any changes in the CCS that indicate a potential compromise to the structural integrity or operation, the permittee must notify the FDEP in writing, describing the findings of the inspection, corrective measures taken since discovery of the change, other planned corrective measures and the expected outcomes. Failure to do so will be a violation of this permit.
- Other issues that may have long-term impacts on integrity, such as trees growing on the CCS or banks or vegetation blocking canals or spillways, shall be cleared within 30 days of first observation.
- During routine operational and maintenance activities around the CCS, periodic observation of the perimeter should continue reporting noted defects.
- The permittee shall submit an annual report of all impoundment inspections and maintenance activities, including corrective actions made in response to inspections, summarizing findings of all monitoring activities including the annual thermal efficiency evaluation of the CCS, remediation measures pertaining to the structural integrity, design, construction, and operation and maintenance of the CCS, and all other activities undertaken to repair or maintain the CCS and other impoundments.
- Unauthorized releases or spills reportable to the State Watch Office shall also be reported to the FDEP within 24 hours from the time the permittee becomes aware of the discharge.
- If, after providing notice, the permittee determines that a reportable unauthorized release of spill has migrated outside the property boundaries of the installation, the permittee must provide an additional notice to the FDEP that the release has migrated outside the property boundaries within 24 hours after its discovery of migration outside of the property boundaries.

The NRC's oversight process will require monitoring of CCS structural integrity over the duration of the subsequent license renewal term. As previously discussed, the new NPDES permit will likely require FPL to report any degradation of the CCS to State regulatory agencies. Acting within their respective jurisdictions, these agencies should be able to take timely regulatory actions to require that the structural integrity of the CCS be maintained.

Tidal flooding during hurricanes is the major flooding concern at the Turkey Point site. The highest tide nearest the site was recorded in September 1965 during Hurricane Betsy and reached an elevation of 10.1 ft (3.1 m) MSL. The station where the measurement was made is located north of Palm Drive on the Florida City Canal, approximately 2.3 mi (3.7 km) west of the shoreline. In 1965, debris marks from the flood tide associated with Hurricane Betsy were seen at an elevation of approximately 10 ft (3 m) MSL at the Turkey Point site (FPL 2018f).

Because of the low flat terrain, tidal floodwaters in the Turkey Point area can move inland several miles and can cover large areas. Construction of flood control projects in the area have reduced the possibility of tidal floodwaters reaching agricultural and populated areas. The L-31E Canal, which is not part of the Turkey Point site, is designed to provide flood protection to

properties further west. This canal is located west of the Turkey Point site and generally runs from southwest to northeast. It includes a levee with a crest elevation of 7 ft (2.1 m) MSL. However, it is not designed to prevent flooding from severe hurricanes with tidal flooding. Based on published storm-tide frequency studies, it is estimated that a 7 ft (2.1 m) tide may occur once every 20 to 25 years near the Turkey Point site (FPL 2018f).


The Federal Emergency Management Agency (FEMA) has prepared flood zone maps that cover the Turkey Point site and surroundings (Figure 3-12). Except for Units 3 and 4, FEMA maps most of the Turkey Point property and the surroundings as Zone A (FPL 2018f). A Zone A area has a 1-percent annual chance of flooding within any single year (FEMA 2014). The water depth of a flood with a 1-percent chance of annual flooding in any single year is called the base flood (FEMA 2018b).

Within the Turkey Point site, FEMA designates a small area near the shoreline along the northeastern property line as within the coastal flood zone with hazardous wave action, and with base flood depths of 14 to 17 feet (4.3 to 5.2 m) (NAVD88). FEMA designates approximately 27 percent of the Turkey Point property as within the coastal flood zone with base flood depths of 11 to 14 ft (3.4 to 4.3 m). However, the remaining 70 percent of the site where the canal system is located has no base flood elevations determined by FEMA. Inland from and just outside and along the western boundary of the CCS, base flood depths range from 8 to 11 ft (2.4 to 3.4 m) (FPL 2018f).

The increased potential for future coastal flooding based on climate change projections is discussed in Section 4.15.3.2 (Climate Change) of this SEIS.

3.5.1.2 Surface Water Consumption

Surface water resources are not consumed by Turkey Point operations. All water consumed by Turkey Point is derived from groundwater resources.



Source: From FPL 2018f

Figure 3-12 FEMA Flood Zones Map of the Turkey Point Property

3.5.1.3 Surface Water Discharges

Operations at Turkey Point do not discharge to surface water bodies outside of the Turkey Point site. All surface water discharges from Turkey Point activities are directed into the CCS, which does not directly connect to any other surface water bodies.

Sanitary wastewater from Turkey Point is routed to an onsite, county- and State-permitted, contact stabilization sewage treatment plant. Effluent from this wastewater treatment plant is discharged to an onsite, permitted, single Class V, Group 3 gravity underground injection well. The well is used to dispose of up to 35,000 gpd (132 m³/day) of domestic wastewater effluent. It discharges into the top of the Biscayne aquifer and is open from 42 to 62 feet (12.8 to 19 m)


below ground surface. Any wastewater residuals are transported to an approved offsite facility. FPL monitors the clarified wastewater sludge to ensure it does not present a risk to the environment or to public health (FPL 2018f). The FDEP manages sanitary waste under FDEP Sewage Treatment Facility Domestic Wastewater Facility Permit No. FLAO13612-002-DW3P and FDEP Sanitary Wastewater Disposal Well Domestic Wastewater Facility Permit No. 0127512-002-UO.

FPL discharges stormwater and all other discharges from Turkey Point Units 3 and 4 and the other facilities at the Turkey Point site to the CCS. Consistent with EPA and State determinations, neither FPL nor the State of Florida considers the CCS to be “waters of the United States” or “waters of the State” (FPL 2018f). FPL operates the CCS as an industrial wastewater (IWW) facility under National Pollutant Discharge Elimination System (NPDES)/IWW Permit No. FL0001562 (FDEP 2005). This permit is issued pursuant to the Federal NPDES program and the Florida Industrial Waste Water permitting program. FPL submitted a permit renewal application to the State of Florida on October 21, 2009. Since that time, the 2005 permit has been administratively continued and remains in effect at this time. The NPDES permit covers all plant discharges including discharges from Turkey Point Units 1, 2, 3, 4, and 5.


The NPDES permit (FDEP 2005) authorizes wastewater discharges, including stormwater, through two internal outfalls into the CCS. Internal Outfall I-001 is located on the southern bank of the discharge canal that leads to the CCS; Internal Outfall I-002 is located in the Units 1 and 2 settling basins (see Figure 3-13). Stormwater from Turkey Point discharges through Internal Outfall I 002 (FPL 2018f). Water quality parameters monitored by FPL under the Turkey Point NPDES permit include copper, iron, lead, pH, salinity, specific conductance, temperature, total suspended solids, zinc, and oil and grease (FPL 2018f).

The permit authorizes discharges to “waters of the State.” However, while the permit authorizes discharges to “groundwater of the State” it does not authorize direct discharges to surface waters of the State. The permit authorizes discharges from the CCS into the surficial aquifer, which is the Biscayne aquifer. Beneath the CCS, the groundwater in the Biscayne aquifer is classified as Class G-III groundwater (FDEP 2005, FPL 2018f). As a result of its high total dissolved solids content, Class G-III groundwater is not considered to have a reasonable potential as a future source of drinking water (FPL 2018f, FAC 62-520.410, UF 2018a).


While the State of Florida regulates nonradioactive liquid releases from Turkey Point, the NRC regulates radioactive releases from Turkey Point. Liquid releases of radionuclides within NRC allowable limits are a part of normal nuclear power plant operations. Liquid releases from Turkey Point operations are discharged into the CCS via Internal Outfall I-001 (FPL 2018f). The NRC monitors the amount and types of radionuclides and the calculated dose to the public to confirm that releases are below NRC thresholds as defined in NRC regulations.



Legend

 Site Boundary



 Feet
0 500 1,000

Source: From FPL 2018f

Figure 3-13 Florida Department of Environmental Protection NPDES Permitted Outfalls

As discussed above, the FDEP is conducting a renewal process for FPL’s NPDES permit for the Turkey Point site. The draft NPDES permit (FDEP 2018f) was issued by FDEP in December 2018 for public review and comment. The draft NPDES permit would continue to authorize the CCS to discharge to Class G-III groundwater and would prohibit surface water discharges from the CCS through a point source to the surface waters of the State. The draft NPDES permit contains numerous monitoring and reporting requirements. Many of these requirements include monitoring activities currently being conducted by FPL in accordance with

a Consent Order issued by the FDEP and a Consent Agreement with Miami-Dade County. It also contains requirements for impoundment design, construction, operation, and maintenance.

CWA Section 401 Certification

Section 401 of the Clean Water Act (33 U.S.C. 1251 et seq.) requires an applicant for a Federal license to conduct activities that may cause a discharge of regulated pollutants into navigable waters to provide the licensing agency with a water quality certification from the State. This Section 401 certification implies that discharges from the project or facility to be licensed will comply with Clean Water Act requirements and will not cause or contribute to a violation of State water quality standards. If the applicant has not received a Section 401 certification, the NRC cannot issue a license unless that State has waived the requirement. The NRC recognizes that some NPDES-delegated States explicitly integrate their Section 401 certification process with NPDES permit issuance (NRC 2013a).

The Power Plant Siting Act (PPSA) certification from the State of Florida is a non-expiring permit that remains valid for the life of the facility. Under the PPSA, FPL is not required to obtain a new certification for NRC subsequent license renewal. The certification will remain effective, as will any legal effects of the certification, including the certification's compliance with State water quality standards for the life of the facility. Therefore, there is no requirement for FPL to obtain a new determination of compliance with State water quality standard for Turkey Point Units 3 and 4 subsequent license renewal (FPL 2018f, FPL 2018g).

3.5.1.4 Adjacent Surface Water Quality and Cooling Canal System Operation

Within the Turkey Point site, the cooling canal system is the largest body of water. This section of the SEIS describes recent studies to evaluate potential effects of CCS operations via the movement of groundwater from the CCS to adjacent surface water bodies.

Pursuant to the State of Florida Department of Environmental Protection Conditions of Certification for Florida Power & Light Company Turkey Point Plant Units 3 and 4 Nuclear Power Plant Unit 5 Combined Cycle Plant Certification Number PA 03-45E (FDEP 2016b, State of Florida Siting Board 2016) and in accordance with the FPL Turkey Point Power Plant, Groundwater, Surface Water, and Ecological Monitoring Plan (SFWMD 2009), FPL conducts an extensive water quality monitoring program that includes the CCS, Biscayne Bay, Card Sound, marshland, mangrove areas, and canals adjacent to the CCS. A major objective of this program is to evaluate the effects, if any, of CCS operation on the surrounding environment. The monitoring program and some of its data and findings are contained in a number of documents that FPL submitted to the FDEP and partner agencies including the South Florida Water Management District (SFWMD) and Miami-Dade County (FPL 2010, FPL 2011a, FPL 2014b, FPL 2016a, FPL 2016f, FPL 2016g, FPL 2017a, FPL 2017b, FPL 2018p) (See Figure 3-14). Data and reports are also accessible through FPL's Electronic Data Management System (EDMS; <https://www.ptn-combined-monitoring.com>).

This water quality monitoring program monitors surface water bodies for numerous water quality parameters, including ammonia and other nutrients and salinity. Water temperature in the CCS is also monitored, but FPL has not detected CCS waters affecting temperatures in adjacent water bodies.

FDEP Administrative Order DEP #16-0111, uses tritium, in conjunction with saline water, as a tracer to estimate the spatial extent of waters originating from the CCS (FDEP 2016h). At levels

in accordance with NRC allowable limits, Turkey Point Units 3 and 4 discharge liquid water containing tritium into the CCS in batch releases. Units 3 and 4 also release tritium as a gaseous emission (steam water or vapor water) into the air.

Tritium is a hydrogen atom with an atomic mass of three instead of one (NRC 2006a); like any other hydrogen atom, it usually binds with oxygen to form a water molecule. A water molecule that contains hydrogen in the form of tritium will behave in the environment just like a water molecule that does not contain tritium. There are two possible pathways for tritium to leave the CCS and move to another surface water body: (1) through the groundwater pathway within liquid water or (2) through air within gaseous water (steam or vapor water). Therefore, for surface water samples collected in bodies of water near the CCS, these two possible pathways are considered when interpreting the data.

Tritium emits a weak form of radiation in the form of a low-energy beta particle similar to an electron. This radiation does not travel very far in air and cannot penetrate the skin. If tritium enters the body, it disperses quickly and is uniformly distributed throughout the soft tissues. Tritium has a half-life of 12.3 years. This means that after 12.3 years, half of the tritium will be gone through decay into a form that is no longer radioactive. However, if ingested, the human body excretes half of the tritium ingested within approximately 10 days (NRC 2006a). For tritium in drinking water, EPA has established a maximum contaminant level of 20,000 pCi/L (EPA 2002, NRC 2006b).

At the levels that have been measured within the CCS, tritium is not a public health concern. With the exception of rare outliers, measurements of tritium concentrations at sampling locations within the CCS have been below the EPA maximum contaminant level of 20,000 pCi/L for tritium in drinking water. Although tritium levels in some areas may somewhat exceed the EPA's maximum contaminant level of 20,000 pCi/L for tritium in drinking water, salt concentrations make the water in the CCS non-potable, and there are no drinking water wells on or near the site. Also, while tritium has been detected in adjacent water bodies, the concentrations were very low and often extremely low relative to the EPA's maximum contaminant level of 20,000 pCi/L for tritium in drinking water (FPL 2010, FPL 2011a, FPL 2014b, FPL 2016a, FPL 2016f, FPL 2016g, FPL 2017a, and FPL 2017b).

Water Quality within the Cooling Canal System

The following text describes ammonia and nutrients and salinity conditions within the CCS. As CCS water temperatures also have an effect on CCS water salinities, the following text also includes a discussion of water temperature in the CCS. Any mitigating actions within the CCS to reduce any indirect effects on groundwater, ecology, and on adjacent surface water bodies are also described.

Ammonia and Nutrients within the Cooling Canal System

Ammonia is released into the waters of the CCS by the decay of organic material within the CCS. Between June 2010 and May 2016, ammonia concentrations within the CCS ranged from below detectable levels to 0.3 mg/L and averaged 0.04 mg/L (FPL 2017a). The Miami-Dade County water quality standard for ammonia is 0.5 mg/L (FPL 2018m). The Turkey Point CCS values are all below this standard.



Source: From FPL 2017a

Figure 3-14 Locations of Surface Water Monitoring Stations

Ammonia is a nutrient. Other nutrients include phosphorus, chlorophyll, and total nitrogen. Within a surface water body, if the concentration of nutrients gets too high, the nutrients can cause algae blooms. These algae blooms can be toxic, deplete oxygen in the water, and reduce water clarity (FDEP 2018e).

Nutrients are added to the water in the CCS by the erosion of soil and vegetation that falls into the canals from the land that separates the individual channels within the CCS. Nutrients are also added by groundwater inflows, atmospheric deposition (of nitrogen) and by the relatively low levels of effluents from power plant operations. Nutrients are removed from the CCS by the growth of seagrass, the harvest of seagrasses as a CCS maintenance activity, the removal of biological material impinged on the plant intake screens, and the outflow of water from the CCS into groundwater (FPL 2018f).

Prior to 2010, the CCS operated as a seagrass-based biological system. Seagrass grew beneath the water on the bottom of the channels, covering an estimated 50 percent of the channel bottoms. The seagrass provided habitat for aquatic life, provided natural filtration of suspended material, and removed nutrients from the water within the CCS. This ecosystem helped to maintain good water quality and low nutrient concentrations in the CCS waters (FPL 2018f).


By 2010, this ecosystem had begun to change dramatically. CCS salinities had increased to the point that the seagrass meadows were dying. By 2012, few seagrass beds remained. The decomposition of the dead seagrass released a significant volume of nutrients into the waters of the CCS. This increase in nutrients facilitated seasonal algae blooms, resulting in high turbidity and generally degraded water quality within the CCS (FPL 2018f).

Nutrient Management Plan for the Cooling Canal System

In accordance with a June 20, 2016, Consent Order between FPL and the State of Florida (FDEP 2016a), FPL submitted to the FDEP a Nutrient Management Plan for the CCS (FPL 2016k). The plan is composed of three primary near-term nutrient management strategies: (1) active algae and nutrient removal, (2) canal and berm maintenance, and (3) salinity reduction and controlled flow management. On July 7, 2017, the FDEP directed FPL to implement the plan (FPL 2017b, FPL 2018p).


Under this Nutrient Management Plan, FPL (2016k) has performed bench and pilot tests to find the most appropriate active nutrient and algae removal methods for the unique ecology and water chemistry of the CCS. These nutrient and algae removal methods include using chemical flocculants/coagulants, nonchemical means (i.e., physical removal), and aeration. In addition, FPL reviewed and revised Turkey Point canal practices to integrate the goal of minimizing erosion and nutrient inputs from sediment and berm sources (FPL 2017b, FPL 2018p). FPL's reports (FPL 2018p) and available data show that nutrient management activities in the CCS, including canal sediment removal, canal berm management, vegetation management, freshening with low-nutrient groundwater, and groundwater extraction, have been effective in reducing nutrient concentrations. Specifically, total nitrogen and total phosphorous concentrations (semiannual) in the CCS exhibit substantial declines from peak concentrations as shown in Figures 3-15a and 3-15b, respectively.

Another component of the Nutrient Management Plan is the reestablishment of seagrass meadows within the CCS to provide stabilizing nutrient reduction and habitat for aquatic species. In the plan, FPL (2016k) identifies this objective to be a long-term activity. Section 3.7.3, "Aquatic Resources on the Turkey Point Site," of this SEIS describes FPL's efforts to achieve this objective.



Source: From FPL 2018p

Figure 3-15a Trend in Total Nitrogen Concentrations in the CCS



Source: From FPL 2018p

Figure 3-15b Trend in Total Phosphorus Concentrations in the CCS

Temperatures within the Cooling Canal System

The temperature of the CCS varies in response to factors such as heated water discharged by Units 3 and 4 into the CCS, air temperature, wind, precipitation, Biscayne aquifer groundwater flowing into and out of the CCS, and water that FPL adds to the CCS from wells to reduce salinity. To a lesser extent, discharges of water into the CCS from the interceptor ditch and the Turkey Point Unit 5 cooling tower blowdown can also impact the temperature of water within the CCS.

Historically, Turkey Points Units 1, 2, 3, and 4 all contributed heat to the CCS. Units 1 and 2 are now retired and no longer contribute heat to the CCS. Even under current operations (i.e., after the NRC approved the extended power uprates for Units 3 and 4 on June 15, 2012 (NRC 2012)), the heat that Units 3 and 4 discharge to the CCS is less than the amount of heat Turkey Point had discharged to the CCS when Units 1, 2, 3, and 4 were all in operation.

Due to the discharge of heat into the CCS, water temperatures in the CCS are higher than ambient air temperatures (FPL 2018f). Surface water temperatures within the CCS are warmer in the summer months and cooler in the winter months (FPL 2016a). Water temperatures within the CCS also vary based on location. As water moves from the discharge area, through the canals, and then towards the intake area, the water temperature drops (FPL 2016a). As

expected, the highest water temperatures in the CCS are found where Units 3 and 4 discharge hot water into the CCS (Station TPSWCCS-1); the lowest water temperatures are found at the cooling water intake for Units 3 and 4. From June 2010 through May 2017, average monthly temperature values collected at all seven monitoring stations within the CCS ranged from 52.7 °F (11.5 °C) to 115 °F (46.3 °C), and produced an average monthly temperature of 88 °F (30.4 °C) (FPL 2017a).

The CCS serves as the ultimate heat sink to cool Units 3 and 4. On August 8, 2014, the NRC established an ultimate heat sink temperature limit for the cooling canals of 104 °F (40 °C) (FPL 2018f, NRC 2014d, 79 FR 44464, 80 FR 76324). To judge compliance with this limit, FPL measures water temperature from a sampling location in the return canal in front of the cooling water intake structure. Data from this sampling location represent the temperature of the water after it has been cooled by the CCS. From June 2010 through May 2017, temperature measurements at this sampling location (station TWSWCCS-6) have not exceeded the NRC's ultimate heat sink limit of 104 °F (40 °C) (FPL 2017a).

Prior to August 2014, the NRC had set the ultimate heat sink limit at the slightly lower temperature of 100 °F (37.8 °C). In early July 2014, the water temperature in the cooling canals began to approach the limit of 100 °F (37.8 °C). FPL then requested an increase in the temperature limit; in response, the NRC performed a safety and environmental analysis, and then established the current heat sink temperature limit of 104 °F (40 °C) (NRC 2014b).

FPL believes that the 2014 increase in average CCS temperatures was necessitated by:

- low average precipitation into the CCS from 2011 through 2014
- poor water circulation through the CCS due to blockages and sediment accumulation
- reduced heat exchange efficiency caused by factors such as higher salinity, turbidity, and algal concentrations that reduced evaporation rates (FPL 2018f)

Since 2014, FPL has worked to reduce algae concentrations, improve canal circulation, and increase the inflow of groundwater from the Biscayne aquifer into the CCS by sediment removal from CCS channels. For a short period of time, to help lower CCS temperatures, freshwater from Canal L-31E, brackish water from the Upper Floridan aquifer, and saltwater from the Biscayne aquifer was added to the CCS.

According to its environmental report for subsequent license renewal, FPL's current plans to lower CCS temperatures and manage CCS water quality do not include the use of freshwater from State canals (FPL 2018f). In the future, should FPL need to use freshwater from State canals, FPL would need to seek permission to do so from the State and county governments. FPL states that plans to reduce CCS temperatures and manage CCS water quality include adding brackish water from the Upper Floridan aquifer, reducing algae in the CCS, continuing to remove sediment within the CCS, and, only in extraordinary circumstances, pumping saltwater from the Biscayne aquifer into the CCS (FPL 2018f).

Thermal Efficiency Plan for the Cooling Canal System

In accordance with the June 20, 2016, Consent Order between FPL and the State of Florida, FPL submitted a thermal efficiency plan for the CCS to the FDEP (FDEP 2016a). FPL has identified the maintenance of high thermal efficiency within the CCS as necessary for controlling evaporation and salinity in the CCS. The plan identified primary and secondary performance

metrics. FPL will use these metrics to guide its actions to maintain high thermal efficiencies (i.e., thermal efficiency at equal to or greater than 70 percent). On July 7, 2017, the FDEP instructed FPL to implement this thermal efficiency plan (FPL 2017b, FPL 2018p).

Since July 2017, FPL has implemented several near-term actions under this thermal efficiency plan, including (1) sediment removal in many of the CCS canals, (2) flow management within the CCS, (3) water stage management, and (4) vegetation management. As a result, thermal efficiency in the CCS during the 2017 reporting period met the objectives of the plan, which is to maintain high thermal efficiencies at equal to or greater than 70 percent. For the period between October 2016 through September 2017, FPL reported an annual CCS thermal efficiency of approximately 84 percent (FPL 2017b). For the period between October 2017 through September 2018, the thermal efficiency was 85 percent (FPL 2018p).

Salinity within the Cooling Canal System

Water in the CCS contains significant concentrations of salt. CCS water is saltier than seawater (i.e., it is hypersaline). The salinities of seawater are around 34–35 practical salinity units (PSU). For the most recent year in which data have been collected (from June 1, 2017, to May 31, 2018), the salinity of water in the CCS averaged 49.5 PSU, which is about 1.5 times the salinity of seawater (EB 2018, FPL 2018o).

Salinities in the CCS increase when water leaves the CCS via evaporation and decrease when less saline water enters the CCS. The highest salinities in the CCS are likely to occur during times of low precipitation and when evaporation rates are high. Conversely, the lowest salinities within the CCS are likely to occur during times of high precipitation and when evaporation rates are low (FPL 2012a). Salinity concentrations are usually at minimum values during the wet season, with the highest salinities at the end of the dry season (FPL 2018f).

Most of the salt in the CCS comes from the groundwater of the Biscayne aquifer, which is saltwater. As groundwater from the Biscayne aquifer moves into the CCS, the salt it contains also moves into the CCS and becomes concentrated as water is lost from the CCS because of evaporation. The Biscayne aquifer obtains its salt from Biscayne Bay, and is hydraulically connected to both the Biscayne Bay and the CCS (FPL 2018f, Tetra Tech 2014, FPL 2016a).

Salt is removed from the CCS when water containing salt moves from the CCS into the Biscayne aquifer. Water that moves from the CCS into the groundwater is likely to reflect the hypersaline conditions of the CCS. With its higher salt concentrations, this CCS water is denser than the groundwater of the Biscayne aquifer (FPL 2018f).

As previously stated, CCS salinity fluctuates throughout the year such that the CCS exhibits lower salinity concentrations in the wet season and higher salinity concentrations in the dry season. For instance, FPL (2018o) reports that from June 1, 2017 through May 31, 2018, CCS salinity ranged from a low of 40.11 PSU to a maximum of 67.35 PSU. Salinity concentrations have also decreased as FPL has implemented freshening activities. During the first full year of freshening (June 1, 2017, through May 31, 2018), the average CCS salinity was 49.5 PSU, which is 10.8 PSU lower than the previous year's (June 1, 2016, to May 31, 2017) average salinity of 60.3 PSU (FPL 2017a, FPL 2018od). FPL's freshening activities are described in detail below.

When FPL first constructed the cooling canals in the 1970s, the salinity of the CCS water and the surrounding Biscayne aquifer were about equal to the salinity in Biscayne Bay

(approximately 34 PSU) (FPL 2018f). CCS salinities are usually at minimum values during the wet season, with the highest salinities at the end of the dry season. During dry years (periods of drought) the overall salinities at the end of the year were higher than the salinities at the end of the previous year. In this way, drought years produced a ratcheting effect that caused the next year to begin the seasonal cycle of salinity concentrations at higher salinities than the previous year. As a result, average salinities in the CCS gradually increased from approximately 34 PSU in the early 1970s to approximately 90 PSU in 2014 and 2015 (FPL 2017a, FPL 2017b, FPL 2018f). As discussed above, salinity levels have decreased since then; the most recent data show an average salinity level of 49.5 PSU for the period of June 1, 2017 through May 31, 2018.

As CCS salinities increased, the seagrasses in the CCS died off. As the seagrasses died off, not only could they no longer remove nutrients from the water, their decomposition also released considerable amounts of nutrients into the water. The increased nutrient concentrations facilitated the growth of seasonal algae blooms (FPL 2018f). As previously mentioned, from 2011 through 2014, in combination with low average precipitation and poor water circulation through the CCS, the algae blooms contributed to increased temperatures and salinities within the CCS (NRC 2016a).

To help reduce the water temperatures and improve the water quality within the CCS, on June 27, 2014, the FDEP (2014) granted FPL permission to add Unit 5's excess allocation of Floridan aquifer water under an Administrative Order to the CCS. The FDEP (2016a) subsequently issued a Consent Order that superseded all requirements of its 2014 Administrative Order. In August 28, 2014, the SFWMD granted FPL permission to add freshwater from the L-31E Canal to the CCS to reduce salinity. After these additions, rainfall also added freshwater to the CCS. CCS salinities subsequently returned to pre-summer 2014 levels of around 60 PSU (FPL 2018f; NRC 2016a). The status of actions to reduce salinities within the CCS since 2014 is described in the following section titled "Application of Numerical Modeling to CCS Salinity Mitigation." At the end of May 2017, salinity concentrations in the CCS were 64.9 PSU (FPL 2017b). As previously stated, during the most recent reporting period (from June 1, 2017 through May 31, 2018), the average salinity level in the CCS was 49.5 PSU.

Salinity Management Plan

In December 2014, the FDEP issued an Administrative Order requiring FPL to submit a salinity management plan to describe how FPL would reduce and maintain the average annual salinity in the CCS at or below 34 PSU (FDEP 2014, NRC 2016a). On October 7, 2015, Miami-Dade County and FPL signed a Consent Agreement (MDC 2015a). In this agreement, it was acknowledged that FPL would supply brackish water to the CCS from the Upper Floridan aquifer and saltwater from the Biscayne aquifer via marine wells (wells located adjacent to Biscayne Bay). However, FPL would work to avoid the use of water from the marine wells, except under extraordinary circumstances. Secondly, it was acknowledged that FPL would continue to use water from the L-31E canal to lower CCS salinities until a transition was made to long-term sources of water for the CCS (i.e., brackish water from the Upper Floridan aquifer) (MDC 2015a).

On June 20, 2016, a Consent Order (FDEP 2016a) was executed by FPL and the FDEP. The Consent Order requires FPL to maintain the average annual salinity of the CCS at or below 34 PSU. Further, it states that, "[i]f FPL fails to reach an annual average salinity of at or below 34 PSU by the end of the fourth year of freshening activities, within 30 days of failing to reach the required threshold, FPL shall submit a plan to the [FDEP] detailing additional measures, and

a timeframe, that FPL will implement to achieve the threshold. Subsequent to attaining the threshold in the manner set forth above, if FPL fails more than once in a 3 year period to maintain an average annual salinity of at or below 34 PSU, FPL shall submit, within 60 days of reporting the average annual salinity, a plan containing additional measures that FPL shall implement to achieve the threshold salinity level” (FDEP 2016a).

This means that FPL has a requirement to reach the 34 PSU annual average salinity threshold in the CCS significantly before the beginning of the subsequent license renewal period. If the average annual salinity fails to reach that threshold in the fourth year of freshening activities, FPL may be required by FDEP to take additional freshening activities. While it cannot be guaranteed that the FPL will achieve the 34 PSU threshold within the 4-year timeframe; continued actions by FPL and regulatory oversight by the FDEP provide additional assurance that the CCS should reach the required PSU levels within the 13-year period prior to the beginning of the subsequent license renewal period.

In future years, it is anticipated that Upper Floridan aquifer wells will be the water source utilized for salinity reduction (FPL 2018f). As detailed in Section 3.5.2.2.3, FPL began operation of the Upper Floridan aquifer freshening well system on November 28, 2016. The addition of this brackish water (2.5 PSU) to the CCS is being used to help reduce the CCS salinity to an average annual level of 34 PSU. The addition of this water has been important in minimizing increases in CCS salinity that ordinarily occur during the dry season. Continued operation of the freshening wells during the wet season should further help to reduce CCS salinities (FPL 2018f, FPL 2018p).

Study of Water Alternatives to Reduce CCS Salinities

In the October 7, 2015, Consent Agreement between Miami-Dade County and FPL, it was acknowledged that FPL would consider the practicality and appropriateness of using reclaimed wastewater from the Miami-Dade County South District Waste Water Treatment Plant as an alternative water resource to reduce CCS salinities. To respond to this request, FPL contracted with Golder and Associates to evaluate alternative sources of water. Along with other alternatives, the evaluation considered the practicality and appropriateness of using reclaimed wastewater from the Miami-Dade County South District Waste Water Treatment Plant (SDWWTP) (Golder 2016).

The study considered the following eight alternatives:

- 1) Excess surface water from the L-31E Canal
- 2) Biscayne aquifer water from the Inland Biscayne Aquifer Wellfield
- 3) Reclaimed water from SDWWTP with nutrient removal
- 4) Reclaimed water from SDWWTP with nutrient removal and advanced treatment for other constituents of concern
- 5) Upper Floridan aquifer water using artesian wells flowing into the CCS
- 6) Direct Treatment of CCS water to remove salinity
- 7) Marine groundwater from wells on the Turkey Point Peninsula with additional fresh water from another source
- 8) Marine surface water from Biscayne Bay or Card Sound with additional fresh water from another source

The study considered technical, environmental, economic, and social criteria. Relative to the ranking criteria, it ranked Alternative Five as the best overall and the most balanced alternative. It also identified that Alternatives One and Seven should be maintained as short-term backup water options to be used when appropriate and as needed during extreme conditions. It further determined that Alternatives Two, Four, Six, and Eight did not provide a significant advantage and should not be evaluated further unless conditions change. While the study determined that Alternative Three has a high cost and very long implementation schedules; it concluded that this alternative should be further evaluated as a potential long-term solution to a regional problem (Golder 2016).

The alternatives study was reviewed by Miami-Dade County. On December 22, 2016, the County decided that the use of reclaimed water with nutrient removal and advanced treatment, described as (Alternative 4) in the referenced document, could provide a long-term, sustainable source of water to offset CCS water deficits. The County recommended that FPL revisit this alternative for further evaluation as a potential long-term solution (MDC 2016a). At the time of this report, FPL (2019e) and MDC were evaluating a potential cooperative reclaimed water use project to provide freshening water to the CCS.

Application of Numerical Modeling to CCS Salinity Mitigation

The operation of the CCS has been numerically modeled to understand and predict different aspects of the CCS (Chin 2016; Golder 2008; Tetra Tech 2014a; FPL 2012a, FPL 2014b, FPL 2016a, FPL 2016g, FPL 2017a). The most recent modeling was conducted by Tetra Tech for FPL. The focus of this modeling was to quantify the volumes of water and the mass of salt entering and exiting the CCS (FPL 2012a). Model calculations for the various components of the CCS incorporate hydrological, chemical, and meteorological data collected in and around the CCS (FPL 2012a). Selected model inputs were adjusted to calibrate the model against observed changes in CCS water and salt storage. The calibration minimized differences between simulated and observed salt and water storage changes within the CCS (FPL 2014).

The NRC staff and its contractors reviewed the underlying assumptions that formed the basis of the Tetra Tech CCS model and did not identify any significant issues. The staff's reviewers found that the model is useful in understanding the physics of the CCS and how it responds to changing conditions. It is also useful as a planning tool to refine future mitigative actions.

A good match between measured and model values gives modelers confidence that they understand how the CCS responds to meteorological conditions and freshening activities. The Tetra Tech model outputs are in good agreement with respect to measured values of CCS salinities, temperatures, water elevations, and the movement of salt and water movement into and out of the CCS (FPL 2017a). Both data measurements and modeling indicate that favorable meteorological conditions and freshening activities reduce salinities within the CCS (FPL 2017a, FPL 2017b, FPL 2018o).

The Tetra Tech model is being used by FPL to understand the effectiveness of its mitigation measures. The most recently published modeling results simulate the operation of the CCS from June 2015 through May 2017. The modelers concluded that over this time period, the addition of Upper Floridan aquifer water helped to moderate dry season salinity without significantly increasing water levels in the CCS (FPL 2017a).

In 2014, Tetra Tech used numerical models to estimate the volume of Upper Floridan aquifer water that would be required to reduce CCS water salinity to seawater range. The modeling

exercise produced an estimate that with the addition of 14 mgd (53,000 m³/day) of Upper Floridan aquifer water that had a salinity of 2 PSU it would require less than a year to reduce salinities in the CCS to 35 PSU (Tetra Tech 2014a). However, while FPL then added an average of 12.8 mgd (48,500 m³/day) of Upper Floridan aquifer brackish water to the CCS for freshening purposes from the beginning of November 2016 to the end of May 2017, salinities in the CCS did not go down to 35 PSU (FPL 2017a). Rather, at the end of May 2017, salinity concentrations in the CCS were 64.9 PSU (FPL 2017b). As discussed above, CCS salinity levels decreased from that level in 2018.

Comparing CCS data and model results, the modelers concluded that during this period (most of which occurred during the dry season), evaporation rates exceeded precipitation rates. Without the addition of brackish water from the Upper Floridan aquifer, the net evaporation versus precipitation rate would have caused the salinity in the CCS to increase more than was observed. However, the addition of Upper Floridan aquifer water helped to moderate the effects of the dry season (typically, November - April) on the CCS. For example, CCS salinities during the dry seasons of 2014 and 2015, which were not as dry as 2017, exceeded 90 PSU, while the addition of brackish water from the Upper Floridan aquifer and saltwater from the marine wells was effective in keeping CCS salinities below 70 PSU in the 2017 dry season. The modelers anticipate that under more average meteorological conditions (e.g., less severe dry seasons), the addition of Upper Floridan aquifer water should help to reduce CCS water salinities to 34 PSU (FPL 2017a, FPL 2017b, FPL 2018o).

The Turkey Point site experienced a severe dry season in late 2017 (particularly into the first quarter of 2018) that resulted in the second driest period over the last 50 years. CCS salinities increased over this period. This was mitigated in part by rainfall from Hurricane Irma in September, which produced estimated rainfall totals averaging 4.96 in. (12.6 cm) over the CCS. However, dry conditions returned after the hurricane (FPL 2018o). These events exemplify the high variability of hydrologic inputs to the CCS. Nonetheless, with continued freshening from Upper Floridan aquifer water during the period from June 2017 through May 2018, the average annual salinity of the CCS declined to 49.5 PSU (or 50.9 PSU average annual salinity as calculated pursuant to the FDEP Consent Order, see next paragraph) (FPL 2018p).

The FDEP Consent Order prescribes how a numerical average called the “average annual CCS salinity” is to be calculated to determine compliance. As previously mentioned, using the method that has historically been used to calculate average CCS salinities, the average salinity in the CCS between June 1, 2017 to May 31, 2018, was 49.5 PSU. However, using the prescribed approach, the average annual salinity for this time period was 50.9 PSU. This was the first full year that the CCS was freshened using water from the authorized Upper Floridan aquifer wells. The 50.9 PSU value is lower than the preceding year's (June 1, 2016 to May 31, 2017) average annual salinity of 61.9 PSU, during which Upper Floridan aquifer freshening wells were operational for only half of the year. Considering that the highest CCS yearly salinity was 82.5 PSU (June 2014 through May 2015), it appears that a substantial reduction in CCS salinity has occurred over the past several years, in part as a result of FPL's actions (FPL 2018p).

As previously stated, in compliance with the June 20, 2016, Consent Order executed by FPL and the FDEP, if FPL fails to reach an annual average salinity of at or below 34 PSU by the required time periods, FPL is required to submit a plan to the FDEP detailing additional measures, and a timeframe, that FPL will implement to achieve the threshold (see Salinity

Management Plan) (FDEP 2016a). Thus, continued actions by FPL and regulatory oversight by the FDEP provide assurance that the CCS should reach the required PSU levels within or close to the designated period.

Ammonia and Nutrients within Biscayne Bay and Card Sound

If the concentration of nutrients in either Biscayne Bay or Card Sound get too high, they can negatively impact the ecological environment. Excess nutrients can cause algae blooms (thick green algae mats that can be toxic), deplete oxygen in the water, and reduce water clarity. The State of Florida (with the approval of the EPA) has established numeric nutrient criteria for Biscayne Bay and Card Sound. These water quality standards help to protect the quality of the surface water in the bay and the sound, consistent with the requirements of the Clean Water Act (EPA 2014c). The numeric nutrient criteria include criteria for phosphorus, chlorophyll, and total nitrogen, of which ammonia is a contributor (FDEP 2018e).

Biscayne Bay waters are generally low in plant nutrients. This means the aquatic ecosystems respond very rapidly to small nutrient enrichment, especially to increases of phosphorous. The concentrations of ammonia from runoff tends to be higher in urban runoff than in wetland or agricultural runoff. The Biscayne Bay watershed has a diverse agricultural, urban, and wetland land use. This results in lateral differences in bay water nutrient concentrations (NPS 2011).

In general, ammonia concentrations are higher in the northern portion of Biscayne Bay, which is most urbanized, while the lowest values are next to the Turkey Point site in Biscayne Bay and in Card Sound. The lack of urban development around the Turkey Point site has helped spare the southern portion of the bay from the anthropogenic effects to which the central and northern portions of the bay have been exposed (FPL 2017c; NPL 2011).

Seasonal ammonia values in the bay are lowest late in the dry season, with higher concentrations and increased variability during the wet season (peaking in September or October) (NPS 2011). Sampling data by Miami-Dade County and FPL in the late fall and winter months of 2015–2016, revealed levels of ammonia concentrations that exceeded the County's water quality standard for ammonia (0.5 mg/L) at two surface water quality monitoring stations near the CCS in bottom samples collected from two deep non-CCS canals (MDC 2016a). The exceedances for ammonia were detected in the Barge Turning Basin and the remnant canal at Turtle Point (TPBBSW-7 and TPBBSW-8).

Both the Barge Turning Basin and the remnant canal at Turtle Point are connected to Biscayne Bay. When it was constructed, the Barge Turning Basin was excavated to a depth of approximately 30 ft (9.1 m) and the Turtle Point remnant canal was excavated to a depth of approximately 20 ft (6.1 m). In Biscayne Bay, nearby areas have a depth to the bottom of about 1 to 2 ft (0.3 to 0.6 m) (FPL 2018g) (Figure 3-4).

The ammonia exceedances were detected in samples obtained from the bottom of these excavations, close to the CCS. The low dissolved oxygen, hypersalinity, and tritium concentrations found at these locations are consistent with the interpretation that, close to the CCS, the water quality at the bottom of these excavations may be influenced by groundwater that has been in contact with CCS waters. However, the ammonia concentrations in the bottom samples were consistently higher than ammonia levels in the CCS (FPL 2016g). This implies that if groundwater from the CCS was moving into these excavations, some of the ammonia in the Turtle Point remnant canal and the Barge Turning Basin was also coming from other sources.

On April 25, 2016, FDEP issued a Warning Letter to FPL concerning sampling events that indicated that groundwater originating from beneath the CCS is reaching tidal surface waters connected to Biscayne Bay in artificial deep channels immediately adjacent to the CCS. The Warning Letter requested that FPL provide facts to assist in determining whether any violations of Florida law have occurred (FDEP 2016i).

On May 16, 2016, FPL submitted to the FDEP the nutrient monitoring results from certain surface water monitoring stations in deep channels adjacent to the CCS (FDEP 2016a). The FDEP reviewed this information and determined that no exceedances of surface water quality standards were detected in Biscayne Bay monitoring. However, to minimize the potential for future exceedances, the FDEP ordered FPL to implement restoration projects at the Barge Turning Basin and within the remnant canal at Turtle Point (FDEP 2016a).

Restoration activities at the Barge Turning Basin include backfilling the Barge Turning Basin up to a depth of 15 ft (4.6 m) below MSL. Restoration activities at the Turtle Point Canal included backfilling one-third of the remnant canal up to a depth of 0.33 ft (0.1 m) below MSL and the planting of approximately 1,700 mangrove trees (FPL 2019e). The rest of the remnant canal will be backfilled with a sloping fill to a final depth of 7 ft (2.1 m) below MSL (FPL 2017c). Planting the backfilled shallow portion with mangrove trees will reduce the accumulation of organic matter in these deep areas and reduce or eliminate the movement of groundwater from the CCS into these deep excavations connected to Biscayne Bay (FPL 2018d, FPL 2018g). The Turtle Point Canal restoration was completed in April 2019; restoration of the Barge Turning Basin began in May 2019, and was completed in September 2019 (FPL 2019e).

The ammonia exceedances in the Barge Turning Basin and in the Turtle Point Canal also led to the modification of a consent agreement between the County and FPL in 2016. The modified consent agreement requires FPL to prepare and implement a corrective action plan to address ammonia exceedances in surface water surrounding the facility including, but not limited to, waters tidally connected to Biscayne Bay (MDC 2016b, FPL 2016h).

In response to the modified consent agreement between FPL and Miami-Dade County, FPL submitted a site assessment plan to Miami-Dade County on September 14, 2016 (FPL 2016g). The plan described a program to identify the source of the ammonia and to define its vertical and horizontal extent within nearby surface waters. Under the plan, an extensive sampling and analysis program was then conducted by FPL that included numerous surface water, porewater, canal, and groundwater sampling locations, as well as stratified surface water sampling and temporal sampling based on tidal cycles. The assessment results were evaluated in detail to determine the nature and extent of ammonia at Card Sound, Turkey Point, the Barge Turning Basin, and in remnant dead-end canals. In addition, an evaluation of water quality within the CCS was performed (FPL 2016h, FPL 2017c).

The study and its conclusions are contained in a site assessment report published on March 17, 2017 (FPL 2017c). The report concluded that the elevated ammonia values are attributable to the degradation of plant and animal material under anoxic (low oxygen) conditions in areas with little or no mixing with other surface waters. The occurrence of ammonia appears to be limited to the locations of deep stagnant anoxic water bodies. Some of the deep canal sites and many of the groundwater and porewater sites were anoxic and the majority of nitrogen was in the form of ammonia. The studied areas are similar to many locations in coastal Southeast Florida. Regional studies of background surface water quality data for Biscayne Bay indicate that ammonia can be detected at many locations that are not associated with the CCS, at levels greater than 0.5 mg/L (FPL 2017c).

The 2017 report further concluded that the elevated ammonia values were not the result of contamination attributable solely to the Turkey Point site but were the result of natural microbial processes in anoxic, stagnant surface and groundwater environments (FPL 2017c). Ammonia concentrations in the CCS were found to be very low, and the report therefore concluded that the CCS was not the direct cause of the elevated ammonia concentrations in the Turtle Point remnant canal and the Barge Turning Basin. Only surface water samples collected from the bottom of the dead-end canals exceeded the Miami-Dade County standard for ammonia. Outside of these areas, no exceedance of the standard was detected in any other samples within Biscayne Bay near the CCS or in the CCS (FPL 2017c).

The 2017 report also concluded that the ammonia values are consistent with the anoxic conditions that exist at the bottom of remnant canals and the accumulation of organic matter falling into the remnant canals from surrounding areas of the bay. Based on the information obtained, additional work and a corrective action plan were not recommended (FPL 2017c).

Staff from Miami-Dade County reviewed the 2017 report on ammonia in surface waters and on July 7, 2017, requested that FPL submit more information (MDC 2017d). On July 10, 2018, the Miami-Dade County Division of Environmental Resources Management (DERM) issued a letter finding that total ammonia concentrations at the Barge Basin and the Turtle Point remnant canal exceeded the applicable Miami-Dade County surface water standard (MDC 2018a). The DERM acknowledged that the observed elevated surface water ammonia concentrations may be attributable to several contributing sources, including factors not directly related to the operation of the CCS; however, based on an evaluation of tritium concentrations and temperature data, DERM found that the CCS is a contributing source to the ammonia concentrations in those areas.

The DERM letter required FPL to submit a plan to address CCS nutrient impacts to groundwater and surface water resources beyond the boundaries of the CCS. In the letter, DERM acknowledged that management of water quality within the CCS may be effective in reducing water quality impacts observed beyond the CCS facility boundaries. DERM also required FPL to implement the proposed plan to fill the Barge Basin and the Turtle Point remnant canal (MDC 2018a).

In an October 2018, response to a July 10, 2018, DERM letter (FPL 2018r), FPL stated that ammonia concentrations in drainage canals adjacent to the CCS were found in bottom samples where dissolved oxygen levels were less than 1.0 mg/L and in the vertical middle portions of the water column within Turtle Point Canal, where the dissolved oxygen levels were also less than 1.0 mg/L. The letter also contains a detailed explanation of the FPL strategy to address CCS nutrients. This strategy consists of three elements: (1) continued implementation of CCS canal practices, (2) external canal practices, and (3) monitoring and reporting.

Individual measurements of nutrients within an open body of water can be highly variable, both spatially and temporally, making it difficult to accurately characterize prevailing conditions. However, over time, nutrients present in the water column become sequestered in the water in the bottom sediments used by seagrasses for growth. Therefore, nutrient concentrations in leaf tissue can provide a more reliable gauge of prevailing nutrient loads and limiting nutrients within the ecosystem.

The FPL monitoring program that evaluates the effects, if any, of CCS operation on the surrounding environment, has incorporated this technique in its ecologic transects in Biscayne Bay and Card Sound. This technique has been used at Turkey Point since at least 2010, and it

measures total nitrogen, total phosphorous, and total carbon values. The data collected by this technique were also evaluated for nutrient ratios. Analysis of nutrient ratios provide an indication of which elements limit seagrass growth. The nutrient ratios indicate that phosphorous is the limiting nutrient to seagrass growth. This finding is comparable to similar areas in Biscayne Bay and Florida Bay.

In general, leaf nutrient values were found to be within the range of values reported for similar areas of South Florida. Although there is considerable temporal and spatial variability in levels of leaf nutrients within the project area, the patterns observed among study areas provide no indication of any CCS influence on the seagrass community but, rather, reflect regional landscape hydrology and anthropogenic management influences (FPL 2018o, FPL 2017a, FPL 2016b, FPL 2016a, FPL 2014b, FPL 2012a).

Section 3.5.2.2, “Groundwater Quality” (“Groundwater Quality and Changes Attributable to Turkey Point Operations”) of this SEIS describes the results of FPL’s monitoring of nutrients in groundwater in and around the CCS. Section 3.7.4, “Biscayne Bay and Card Sound Semiannual Monitoring,” of this SEIS describes in more detail FPL’s ongoing efforts to monitor submerged aquatic vegetation monitoring and seagrass leaf nutrient content.

Salinity within Biscayne Bay and Card Sound

The salinity of the water in Biscayne Bay and Card Sound affects their ecosystems. Sustained lower-than-seawater salinities are required to maintain the ecology of freshwater wetland, tidal wetlands and mainland nearshore areas, to provide nursery habitat for fish and shellfish (Audubon 2016, NPS 2012). As previously mentioned, the salinities in Biscayne Bay adjacent to the Turkey Point site and Card Sound are most affected by the amount of precipitation that falls in and around the bay and the sound. Also, depending on the hydraulic head in the underlying Biscayne aquifer relative to the head (water levels) in Biscayne Bay, water in the Biscayne Bay (and therefore salt), either moves from Biscayne Bay into the underlying aquifer or from the underlying aquifer into Biscayne Bay.

Within Biscayne Bay and Card Sound, near-shore areas next to the mainland have a larger range of salinity values than mid-bay or mid-sound locations. This is because near-shore areas are more affected by freshwater inflows and evaporation than mid-bay and mid-sound locations (NRC 2016a).

The surface water monitoring program, which, in addition to surface water samples, includes porewater samples and shallow monitor well samples in the Bay, has not detected a discernable effect from the CCS on the salinity of Biscayne Bay or Card Sound (FPL 2016a, FPL 2018f).

Ammonia and Nutrients and Salinity within Marsh Land and Mangrove Areas

The monitoring program has not detected evidence in the surrounding marsh and mangroves areas of any impacts of ammonia, nutrients, or salinity from the CCS on soil porewater quality via the groundwater pathway (FPL 2014b, 2016a, 2017a, 2018f, 2018o).

Ammonia and Nutrients and Salinity within Adjacent Canals

On the west side of the CCS, the interceptor ditch (which is about 18 ft (5.5 m) deep), serves to keep groundwater under the CCS from moving west. However, there is no interceptor ditch along the southern boundary of the CCS (Figure 3-4). Within the CCS, the canal that runs

along the southern boundary is 20 ft (6.1 m) deep. The S-20 canal and the Card Sound remnant canal lie adjacent to the CCS with no intervening interceptor ditch. At these locations, the S-20 Canal is 5 ft (1.5 m) deep and the Card Sound remnant canal is more than 20 ft (6.1 m) deep (FPL 2014b). Therefore, due to their close proximity to the CCS, these are locations where CCS water may more readily move into an adjacent canal via the groundwater pathway.

During the 2018 annual monitoring period from June 1, 2017, through May 31, 2018, water in the L-31E canal exhibited significant increases in salinity. Ammonia concentrations in the section of the L-31E canal north of the partial plug also exhibited significant increases. The salinity increases occurred during and after an extended dry period; ammonia increases were also detected after Hurricane Irma in fall 2017. Increases in salinity were observed in most of the marsh sites in response to dry conditions during the drought and in response to the storm surge during Hurricane Irma. Increases in soil porewater salinities were also detected at all ecological transects, including one located approximately 4 mi (6.5 km) southwest of the CCS (FPL 2018o). The NRC staff reviewed data in FPL's Electronic Data Management System (EDMS; <https://www.ptn-combined-monitoring.com>) and agrees with the conclusion expressed in FPL (2018o) that the increases in salinity and ammonia are not believed to have been caused by a failure of the interceptor ditch or by the CCS.

During the annual monitoring period from June 1, 2017, through May 31, 2018, some ecologic transects exhibited vegetation impacts from droughts and storms. North of the CCS, all the sawgrass in plot F1-1 died after Hurricane Irma because of high porewater salinity. This likely resulted from the accompanying storm surge. In May 2018, some regrowth at this site was observed. Two mangrove-reference transect plots located approximately 5 mi (8 km) southwest of the CCS (M6-1 and M6-2) experienced a decrease in biomass and height. Hurricane Irma may have impacted these mangrove sites, because they did not have a protective fringe mangrove forest (FPL 2018o). Section 3.6.2, "Marsh, Mangrove, and Tree Island Semiannual Monitoring," of this SEIS describes the results of FPL's ecological monitoring in more detail.

With the following exceptions, no readily apparent impacts of ammonia, other nutrients, and salinity on surface water quality in canals adjacent to the Turkey Point site, from the CCS via the groundwater pathway, have been detected (FPL 2016a, FPL 2018o). During the June 2014 to May 2015 monitoring period, monitoring detected an intermittent influence from the CCS at two monitoring locations in canals immediately adjacent to the CCS. One station is located in the S-20 canal and one station is located in the Card Sound remnant canal. The identification of CCS influence was determined based on small temperature variations and higher tritium and salinity values than would normally be expected. However, no readily discernible influence from the CCS was detected at these locations during the June 2013 to May 2014 monitoring period or the June 2016 to May 2017 monitoring period (FPL 2012a, FPL 2014b, FPL 2017a). Minimal, if any, influence on surface water quality was detected where the canals connect to Card Sound (FPL 2016a).

On July 10, 2018, the Miami-Dade County DERM issued a letter stating that total ammonia concentrations at some sampling locations in the Card Sound remnant canal, the S-20 canal, and in the Sea-Dade remnant canal, exceeded the applicable Miami-Dade County surface water standard (i.e., 0.5 mg/L). This letter acknowledged that the elevated surface water ammonia concentrations may be attributable to several contributing sources, including factors not directly related to the operation of the CCS. However, based on an evaluation of tritium concentrations and temperature data, the DERM found that the CCS is a contributing source to the ammonia concentrations in these areas (MDC 2018a). The DERM also acknowledged that the

management of water quality within the CCS may be effective in reducing water quality impacts beyond the CCS boundaries, and it required FPL to submit a plan to address CCS nutrient impacts to groundwater and surface water resources beyond the boundaries of the CCS (MDC 2018a). On October 8, 2018, FPL responded to the July 10, 2018, letter and submitted a plan to address CCS nutrient impacts.

3.5.2 Groundwater Resources

Groundwater includes all water below the ground surface, usually within a zone of saturation. Aquifers contain groundwater in sufficient volume to supply wells, springs, and surface water.

3.5.2.1 Hydrogeology and Aquifers

The NRC staff's EIS for the Turkey Point, Units 6 and 7 combined licenses (NUREG–2176) contains an extensive description and evaluation of the hydrogeologic system of the southern Miami-Dade County region, focusing on the Turkey Point site (NRC 2016a). The summaries of site hydrogeology in this section of the SEIS are primarily based on NUREG–2176, as well as on FPL's environmental report submitted as part of the Turkey Point subsequent license renewal application (FPL 2018f). Where appropriate, the NRC staff has summarized referenced information or incorporated information by reference into this SEIS so that the following subsections can focus on new and potentially significant information since initial license renewal of Turkey Point Units 3 and 4 in 2002. The discussions and analyses that follow focus on aspects of the aquifer systems and the interactions with ongoing Turkey Point operations including the CCS, also called the industrial wastewater (IWW) facility. For a detailed description of the CCS, see Section 3.1.3, "Cooling and Auxiliary Water Systems," of this SEIS.

Two major aquifer systems underlie the region and the Turkey Point site: (1) the surficial aquifer system consisting of the Biscayne aquifer, and (2) the deeper Floridan aquifer system (FPL 2018f, NRC 2016a). Figure 3-7 in Section 3.4 of this SEIS shows the orientation, depths, and thicknesses of the aquifers beneath the Turkey Point site, including the named stratigraphic units and the lithologies (rock types) comprising them.

During the NRC staff's June 2018 environmental site audit (NRC 2018c), the staff toured the facilities and locations discussed below, including the CCS and related structures, Upper Floridan aquifer production (i.e., CCS freshening) well locations, hypersaline recovery wells and the associated deep injection well, and the Turtle Point and Barge Basin restoration project sites.

Biscayne Aquifer


As illustrated in Figure 3-7 (see Section 3.4) and as described in NUREG–2176 (NRC 2016a), the Biscayne aquifer is the principal aquifer beneath southeast Florida that is used for water supply. It extends from the land surface to a depth of approximately 140 feet (43 m) beneath the Turkey Point, Units 3 and 4 site. It is generally an unconfined (water table) aquifer, but it may be semiconfined or confined on a localized basis due to the occurrence of less permeable strata (FPL 2018f, NRC 2016a).

Section 2.3.1.2, "Hydraulic Properties of Biscayne Aquifer," of NUREG–2176 (NRC 2016a) describes the permeable limestones and calcareous sandstones forming the Biscayne aquifer as highly heterogeneous with varying hydraulic properties that may comprise one or more aquifers separated by locally confining units. Section 2.3.1.2 of NUREG-2176 also describes

the differences and the inherent hydrogeologic properties of the Biscayne aquifer including porosity, transmissivity, and hydraulic conductivity (NRC 2016a: 2-49-2-51). The NRC staff incorporates that information into this SEIS by reference.

The low topographic relief of the Turkey Point site relative to sea level makes the site subject to tidal inundation. As such, the waters of the Biscayne aquifer are highly saline below the Turkey Point site. To the east of the site, the Biscayne aquifer is recharged by the saline waters of Biscayne Bay. Freshwater recharge of the Biscayne aquifer occurs from precipitation primarily during the wet season (June to October) with minimal recharge during the dry season (November to May). It is likely that some freshwater recharge also occurs during the wet season from freshwater marshes and sheet flow runoff. Seepage from freshwater canals usually continues to recharge the aquifer during the dry season (NRC 2016a). In general, the Biscayne aquifer water table responds rapidly to precipitation as well as to tidal fluctuations (FPL 2018f).

Under natural conditions and with adequate inland recharge of freshwater, the water table in a surficial aquifer like the Biscayne aquifer is higher than the average sea-level elevation, which balances the higher density of seawater. In such a case, the freshwater-saltwater interface (interface), the most inland point marking the diffusion boundary between freshwater and seawater, is relatively stable near the coastline or offshore. This is conceptually illustrated in Figure 3-16.



Source: Barlow 2003

Figure 3-16 Generalized Diagram of the Freshwater-Saltwater Interface in a Coastal Water Table Aquifer

When the aquifer water table is lowered by pumping or canal drainage, saltwater can move inland, usually at the base of the aquifer because of the higher density of seawater relative to freshwater. Prior to urban and agricultural development and the construction of canals to drain inland areas, wet season recharge to groundwater was greater than it is today and subsurface flows of groundwater into Biscayne Bay adjacent to the Turkey Point site were also higher (NRC 2016a).

Regionally, reduced surface water runoff and groundwater discharge to Biscayne Bay, combined with pumping of groundwater for irrigation, water supply, and other uses, has caused saltwater to migrate inland along the base of the Biscayne aquifer. This process is known as saltwater intrusion or encroachment (FPL 2018f, NRC 2016a).

The Turkey Point cooling canal system (CCS) (described in Section 3.1.3, “Cooling and Auxiliary Water Systems”) is a large, enclosed, hypersaline (i.e., having a salinity greater than that of natural seawater, with chloride concentration exceeding 19,000 mg/L) water body, formed by excavation into the underlying bedrock. The CCS affects the hydrology and groundwater quality of the Biscayne aquifer. The CCS is unlined and hydraulically connected to the upper Biscayne aquifer because permeable aquifer strata permit the movement of water between the aquifer and the CCS. The rate and direction of this water movement depend on the head differences between the CCS and the Biscayne aquifer, hydraulic conductivity of the CCS sediments, and fluid density differences between fluids in the CCS and the Biscayne aquifer (FPL 2018f, NRC 2016a). Because of the movement of the hypersaline CCS water into the Biscayne aquifer, there is an area of higher salinity water in the aquifer beneath the CCS and adjoining portions of the Turkey Point site, called the hypersaline plume. As FPL describes in its environmental report, over the operational life of the CCS, the annual average salinity of both the waters within the CCS and within the hypersaline plume beneath it in the Biscayne aquifer have increased. Over the operational life of the CCS, the size of the hypersaline plume has also grown larger. In its environmental report, FPL states that the hypersaline plume extends out approximately 1.5 mi (2.4 km) west of the CCS boundary (FPL 2018f). The latest published FPL annual monitoring report (2018) states that hypersaline groundwater in the Biscayne aquifer extends out about 1.5 to 2.5 mi (2.4 to 4 km) west of the CCS (FPL 2018o).

In the wider vicinity of Turkey Point, the regional groundwater flow in the Biscayne aquifer is generally to the east towards the coast. However, more directly under and near the Turkey Point site, groundwater flow is affected locally by tides and drainage canals (NRC 2016a). In the NRC staff’s EIS for the Turkey Point Units 6 and 7 combined licenses, Section 2.3.1.2, “Groundwater Flow Direction,” (NUREG–2176) (NRC 2016a) describes in some detail the complex flow interactions between the CCS, the operation of the CCS interceptor ditch and adjacent L-31E Canal, and the hydrologic and density-driven dynamics of the hypersaline plume. As mentioned in the previous paragraph and further described below, the hypersaline plume has grown in size and moved laterally beyond the CCS and the bordering L-31E Canal within the deeper part of the Biscayne aquifer, predominantly to the west. The NRC staff incorporates the information in Section 2.3.1.2 of the COL EIS here by reference (NRC 2016a: 2-51, 2-53). In this SEIS, Section 3.1.3.2, “Cooling Canal System (CCS),” describes the interceptor ditch. The current extent of the hypersaline plume emanating from the CCS and its effects on groundwater quality and saltwater intrusion are further discussed below in Section 3.5.2.2, “Groundwater Quality” (see “Baseline Groundwater Quality and Changes Attributable to Turkey Point Operations”).

Intermediate Confining Unit

Separating the surficial Biscayne aquifer and the Floridan aquifer system is the hydrogeologic unit called the Intermediate Confining Unit (see Figure 3-7 in Section 3.4). This unit has a generally low permeability and is over 800 feet (240 m) thick beneath the Turkey Point site. It is comprised of extensive layers of clay-rich sediments in the upper part of the unit (NRC 2016a). Sands and limestone lenses comprise the permeable parts of this unit (Figure 3-7). Site information suggests that the thickness ranges from approximately 700 feet (210 m) just to the north of the Turkey Point site (at Unit 5 production well PW-3) to about 1,000 feet (300 m)

southwest of the site. On a regional scale, the Intermediate Confining Unit serves as an effective aquiclude (an impermeable layer or rock or stratum or sediment) for the Floridan aquifer system throughout the state of Florida (FPL 2018f).

Floridan Aquifer System

The Floridan aquifer system underlies the Intermediate Confining Unit. The system is composed principally of dolomite and limestone and is under confined conditions beneath the Turkey Point site and throughout southeastern Florida. The Floridan aquifer system at the Turkey Point site principally consists of the Upper Floridan aquifer, a middle confining unit, and the saline Lower Floridan aquifer (FPL 2018f, NRC 2016a) (Figure 3-7).

The Upper Floridan aquifer is composed of several thin water-bearing zones interlayered with thick zones of low permeability. Across most of Florida, it is a major source of potable water; however, in southeastern Florida, including Miami-Dade County, the water is brackish and requires treatment to meet drinking water standards. While the aquifer can be 400 feet (120 m) or more in thickness across southeastern Florida, at the Turkey Point site, it is approximately 200 feet (60 m) thick (FPL 2018f). Regionally, groundwater flow in the aquifer is generally west to east across the site toward the coast. This is confirmed by groundwater level data from Upper Floridan aquifer wells located near the Turkey Point site (FPL 2018f, NRC 2016a).

The middle confining unit within the Floridan aquifer system consists of beds of less permeable strata that are more than 1,000 feet (300 m) thick, separating the aquifers above and below (FPL 2018f). As described in Section 2.3.1.2 of NUREG-2176, the middle (Floridan) confining unit generally contains a relatively thin, permeable zone called the Avon Park Permeable (or Producing) Zone (APPZ), and a lower confining zone (see Figure 3-7 in Section 3.4 of this SEIS). However, the Avon Park zone thins to the south and was not identified at the EW-1 exploratory well at Turkey Point (NRC 2016a).

The upper part of the Lower Floridan aquifer is comprised of low permeability (confining layer) rocks; the deeper part of the Lower Floridan aquifer is a well-developed, highly permeable karst region of fractured carbonate rock known as the Boulder Zone (FPL 2018f, NRC 2016a). The high permeability of the Boulder Zone has been attributed to a network of horizontal caverns at varying depths connected by vertical tubes. Water quality in the Boulder Zone is similar to modern seawater. Within the Boulder Zone, it appears that seawater moves westward from a connection with the Atlantic Ocean off the coast at a depth of about 2,500 feet (760 m). At the Turkey Point site, the top of the Boulder Zone is found at a depth of 3,030 feet (994 m). This depth is consistent with statewide mapping (NRC 2016a).

3.5.2.2 Groundwater Quality

Groundwater Quality Standards and Current Designated Uses

The FDEP classifies groundwater within the State of Florida according to present and future “most beneficial uses.” The State of Florida establishes water quality standards to protect designated uses (FAC R62-520.300). Florida categorizes groundwater in one of five classes

(FAC R62-520.410). These five classes generally relate to the level of potability (i.e., use for drinking and related purposes) as determined by total dissolved solids (TDS) content.

- Class F-I: Potable water use, groundwater in a single source aquifer described in FAC R62 520.460, with a total dissolved solids content of less than 3,000 mg/L and specifically reclassified as Class F-I by the Florida Environmental Regulation Commission.
- Class G-I: Potable water use, groundwater in a single source aquifer that has a total dissolved solids content of less than 3,000 mg/L and specifically reclassified by the Florida Environmental Regulation Commission.
- Class G-II: Potable water use, groundwater in aquifers with a total dissolved solids content of less than 10,000 mg/L, unless otherwise classified by the Florida Environmental Regulation Commission.
- Class G-III: Nonpotable water use, groundwater in unconfined aquifers with a total dissolved solids content of 10,000 mg/L or greater; or with a total dissolved solids content of 3,000-10,000 mg/L and either reclassified by the Florida Environmental Regulation Commission as having no reasonable potential as a future source of drinking water or designated by the FDEP as an exempted aquifer.
- Class G-IV: Nonpotable water use, groundwater in confined aquifers with a total dissolved solids content of 10,000 mg/L or greater.

The State of Florida provides single-source aquifers—those aquifers it identifies as the only reasonably available source of potable water to a significant segment of the population—with the highest level of protection. The FDEP designates such aquifers as Class F-1 and G-I, which have TDS concentrations of less than 3,000 mg/L (FAC R62-520.410). For comparison, the Federal drinking water standard or secondary maximum contaminant level (MCL) for TDS is 500 mg/L (40 CFR 143.3). This secondary standard is based on aesthetic considerations (i.e., taste, color, and odor) and the constituent does not present a risk to human health at the specified level. The FDEP has adopted the same secondary standard for Florida drinking water (FDEP 2018b).

Beneath the Turkey Point site and across southeastern Miami-Dade County, the quality of groundwater within the Biscayne and Floridan aquifer systems varies greatly due to the interaction of natural as well as human-induced factors over time. This is most apparent in the surficial Biscayne aquifer as saltwater intrusion (encroachment) has occurred under a large area of the southeast Florida coast, including under the Turkey Point site.

The NRC staff's EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a) cites a U.S. Geological Survey (USGS) study (Prinos et al. 2014) investigating the origins and extent of saltwater intrusion in the Biscayne aquifer. In the study, the USGS presented its analysis of tritium measurements from USGS monitoring wells within about 6 mi (10 km) of the Turkey Point site, which indicated that water from the CCS may contribute to saltwater encroachment in areas northwest of the CCS (Prinos et al. 2014).

FPL states in its environmental report (FPL 2018f) that, even before construction of the CCS in the mid-1970s, the Biscayne aquifer near the Turkey Point site was saline for the full depth of the aquifer, and saltwater intrusion into the Biscayne aquifer had already occurred several miles inland (FPL 2018f). This is supported by information in the NRC staff's EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176), Section 2.3.3.2 and Figure 2-22. The NRC

staff incorporates Section 2.3.3.2 and Figure 2-22 of NUREG–2176 into this SEIS by reference. NUREG–2176, Figure 2-22 depicts various mapped estimates by the USGS and others of the saltwater interface over the period of 1951 to 2008. These USGS historic estimates depict interface locations that are no less than about 4 mi (6.6 km) west and northwest of the CCS. NUREG–2176, Section 2.3.3.2 contains the NRC staff's characterization of factors contributing to saltwater intrusion, including contributions from the CCS (NRC 2016a: 2-68, 2-69).

Inland migration of the saltwater interface within the Biscayne aquifer continues across the region. Based on a recent USGS estimate, the saltwater interface has moved inland across portions of southeastern Miami-Dade County, west and north of the Turkey Point site, at an average rate of 460 feet (140 m) per year (Prinos 2017). Figure 3-17 below depicts the current location of the saltwater interface at the base of the Biscayne aquifer in relation to the Turkey Point site, the CCS, groundwater monitoring wells maintained by FPL, and other features. The saltwater interface is currently located about 4.7 mi (7.6 km) west of the CCS at its closest point, based on the latest (2017) USGS monitoring well data. The mapped location reflects the current estimate of the 1,000 mg/L concentration boundary for chloride at the base of the Biscayne aquifer (Prinos 2017).

In 1983, the FDEP designated as Class G-III (i.e., non-potable use with TDS levels of 10,000 mg/L or greater) the surficial groundwater (Biscayne aquifer) within the Turkey Point plant property, with the west side of the CCS marking the western boundary (FPL 2018f, SFWMD 2009). The FDEP has classified surficial groundwater west of the Turkey Point site (i.e., to the west of the site boundary and CCS) as Class G-II, which means potable water use, with TDS levels of less than 10,000 mg/L (FPL 2018f). The intersection of Class G-II and underlying Class G-III groundwater marks the saltwater interface (FDEP 2016a).

In 2014, the FDEP issued an administrative order to FPL. In this 2014 administrative order, the findings of fact state that saltwater was present as early as the 1940s near the base of the Biscayne aquifer west of the Turkey Point site. It further states that groundwater data from the early 1970s (prior to completion of CCS construction in 1973) supported the determination that non-potable groundwater (TDS exceeds 10,000 mg/L) occurred beneath much of the proposed CCS at depth and within the deeper portions of the aquifer west of the site (FDEP 2014).

Through wells located inland of the saltwater interface, the Biscayne aquifer is the major public water supply source across Miami-Dade County as well as for the Florida Keys, supplied by the Florida Keys Aqueduct Authority (FKAA 2019a; NRC 2016a: 2-60). In addition, the EPA has designated the Biscayne aquifer across all of south Florida as a sole-source aquifer pursuant to Section 1424(e) of the Safe Drinking Water Act of 1974 (EPA 2016a, FPL 2018f, NRC 2016a).

The Biscayne aquifer is not the only current or potential source of drinking water in the region. The Upper Floridan aquifer is also an important source of freshwater in parts of Florida. The FDEP designates the Upper Floridan aquifer as an underground source of drinking water because its water has a TDS concentration of less than 10,000 mg/L (FAC R62-528.200, NRC 2016a). However, while the groundwater within the Upper Floridan aquifer contains less than 10,000 mg/L TDS in southeastern Florida, with TDS concentrations greater than 2,000 mg/L, water obtained from the aquifer is too saline to be used for drinking water without treatment (NRC 2016a).



Source: Modified from FPL 2018o: Fig. 1.1-2 and FPL 2018p: Fig. 2.4-1

Figure 3-17 Groundwater Monitoring Locations and Saltwater Interface, Turkey Point Site

Baseline Groundwater Quality and Changes Attributable to Turkey Point Operations

The SEIS for the Turkey Point Units 3 and 4 initial license renewal (NUREG–1437, Supplement 5) (NRC 2002c) documents the NRC staff’s environmental review of FPL’s application for the initial 20-year license renewal submitted in 2000. Section 2.1.3 of that EIS describes the likely exchange between the canals and groundwater as well as the operation of the CCS and associated interceptor ditch. As stated therein, the operation of the interceptor ditch was intended to prevent the flow of hypersaline water from the cooling canals toward the Everglades (i.e., inland to the west) (NRC 2002c).

Thus, when the NRC staff published its SEIS for the Turkey Point initial license renewal in 2002, the staff acknowledged the existence of a hypersaline plume in the Biscayne aquifer directly beneath the CCS. What was not fully understood at the time was the potential for the hypersaline plume to migrate vertically downward through the Biscayne aquifer and then to move laterally within the Biscayne aquifer beyond the CCS boundaries. The following discussion presents new information on the effects of CCS operations on hypersalinity in the Biscayne aquifer and groundwater quality.

The interaction of water in the CCS (including cooling loop water and stormwater from Turkey Point) with underlying groundwater in the Biscayne aquifer is complex. In the CCS, heat is rejected to the atmosphere primarily through evaporation, resulting in a net loss of water from the canals. As water evaporates from the CCS, the concentration of dissolved substances, principally salts, in the CCS increases. This increases the density of the CCS water. The high rate of evaporation also produces a net inflow of groundwater into the CCS, but the groundwater flux between the CCS and Biscayne aquifer varies by location. The following variables and factors also affect these groundwater interactions between CCS waters and Biscayne aquifer waters:

- precipitation, specifically seasonal precipitation variation during the wet season versus the dry season
- variations in hydraulic head (water table elevation)
- cooling water effluent discharge rate
- air temperature
- humidity
- tidal fluctuations

As a result of the above variables, the direction of water movement into or out of the CCS varies in time and space. Over time, the denser, heated, hypersaline water migrates downward from the CCS into the Biscayne aquifer. The downward movement of hypersaline water is impelled by the increased density because of the elevated salinity of the water in the CCS (NRC 2016a).

In preparing the EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG–2176) (NRC 2016a), the NRC staff reviewed modeling performed by Hughes et al. (2010), which used a two-dimensional, cross-section model to evaluate the combined effects of salinity, temperature, and other variables associated with operation of the CCS, including the CCS’s contribution to the movement of the saltwater interface. The Hughes modeling demonstrates that the downward migration of hypersaline water takes the form of “finger plumes” that form beneath the CCS and then move downward to the bottom of the permeable zone of the aquifer

in a period ranging from days to several years, depending on localized differences in aquifer properties. These finger plume structures then mix with aquifer water through advection and dispersion (NRC 2016a). The modeling also indicates that the inland migration of the saltwater interface is closely related to TDS concentrations in the CCS (Hughes et al. 2010).

FPL operates the interceptor ditch to maintain an eastward hydraulic gradient in the near surface groundwater (toward the CCS). However, this operation has not completely prevented the hypersaline CCS water that enters the Biscayne aquifer from migrating westward in the deeper part of the aquifer. This is primarily because the interceptor ditch only functions to the depth to which it was constructed, as described in Section 3.1.3.2, “Cooling Canal System (CCS),” thus enabling hypersaline water that has moved to deeper depths in the aquifer to move beyond and west of the interceptor ditch. Five historical wells (i.e., L-3, L-5, G-21, G-28, and G-35), shown in Figure 3-17, have been monitored since the 1970s to assess the impact of interceptor ditch operation on Biscayne aquifer water quality (FPL 2018o).

Since 2010, FPL has maintained an extensive, multimedia environmental (uprate-related) monitoring program in accordance with Turkey Point’s site certification conditions (i.e., Conditions IX and X), as modified (FDEP 2016b, State of Florida Siting Board 2016) pursuant to the Florida Power Plant Siting Act and related regulatory requirements, stemming from the NRC’s June 2012 approval of the Turkey Point extended power uprate project. The focus of this uprate monitoring program is to determine the horizontal and vertical effects of CCS water on the environment. FPL conducts this program in part in accordance with the 2009 monitoring plan (SFWMD 2009) under the auspices of the FDEP, SFWMD, and the Miami-Dade County Department of Environmental Resources Management (DERM).

FPL completed a period of pre-uprate monitoring in 2012, covering the period of June 2010 through June 2012, and submitted it for interagency review in October 2012 (FPL 2018f, FPL 2012a). Monitoring results are reported in publicly available annual monitoring reports submitted to the FDEP and partner agencies including the SFWMD and Miami-Dade County. Data and reports are also accessible through FPL’s Electronic Data Management System (EDMS; <https://www.ptn-combined-monitoring.com>). To date, the results of FPL’s groundwater uprate monitoring demonstrate that CCS operations have impacted groundwater quality in the Biscayne aquifer to the west of the L-31E Canal as well as beneath Biscayne Bay to the east (NRC 2016a).

For the uprate groundwater monitoring, FPL’s contractor has performed quarterly to semiannual field sampling from 14 well clusters, comprising 42 wells in total. This is in addition to automated water quality and water level measurements at each well (FPL 2017a). Each well cluster consists of three, collocated Biscayne aquifer monitoring wells (i.e., shallow, intermediate, and deep), which are shown above in Figure 3-17. For each monitoring well, FPL collects and analyzes groundwater samples for 29 separate parameters, including general water quality parameters (e.g., temperature, pH), ionic, and nutrient constituents. Tritium is used as a chemical tracer in order to determine the potential movement of CCS water within the Biscayne aquifer (FPL 2017a, FPL 2018o; SFWMD 2009). Specifically, by interagency consensus, tritium was established as a tracer for the CCS water with a threshold concentration value for tritium of 20 pCi/L in groundwater (FPL 2012a).

More recently, between 2015 and 2018, FPL expanded its groundwater monitoring network in accordance with provisions of the 2016 FDEP Consent Order (FDEP 2016a); the 2015 Consent Agreement, as amended, with Miami-Dade County (MDC 2015a); and related requirements (see “Regulatory Developments with Respect to Cooling Canal System Operations and

Groundwater Quality” in this section for more information on these documents) (FPL 2018o, FPL 2018p). The first set of new well clusters (TPGW-15 and TPGW-16) was installed in accordance with FPL’s Miami-Dade Class I permit CLI-2014-0312 (FPL 2018o). Well clusters TPGW-15 and TPGW-16 are located near the northwest and east-central boundaries of the CCS, respectively (FPL 2018o). FPL has also installed three monitoring well clusters in the Model Lands Basin, located approximately 2 miles (3.2 km) west of the CCS. These three new wells are designated TPGW-17, TPGW-18, and TPGW-19 (Figure 3-17). Additionally, FPL replaced monitoring well TPGW-8S, and constructed a new deep monitoring well (TPGW-20D) in the city of Homestead’s baseball complex (near Miami-Dade County’s Newtown Wellfield). These well construction activities were completed between September 2017 and March 2018. All of the wells are of similar design and function as the existing groundwater monitoring wells across the region, and sampling/monitoring is generally conducted in accordance with the 2009 monitoring plan (SFWMD 2009). FPL has also added monitoring data from six existing USGS wells (G-3946-S, G-3946-D, G-3900, G-3976, G-3966, and G-3699) to the EDMS (FPL 2018p).

Meanwhile, FPL, Miami-Dade County, and the FDEP have been working on potential revisions to the 2009 monitoring plan that would affect the monitoring required under the 2016 FDEP Consent Order (FDEP 2016a) and the 2015 Consent Agreement with Miami-Dade County (MDC 2015a). FPL reports that this revised monitoring plan could be finalized in 2019 (FPL 2018p).

Table 3-4 below summarizes the latest available analytical results for select wells and key monitored parameters. It provides a snapshot of groundwater quality at specific intervals at discrete locations over time.

Table 3-4 Summary of Groundwater Monitoring Results for Key Water Quality Parameters in Select Biscayne Aquifer Wells, Turkey Point Uprate Monitoring Program, 2011 (Preuprate) and 2018

Well Number and Period ^(a,b,c)	Chloride (mg/L)	TDS (mg/L)	Salinity (PSU)	Tritium (pCi/L)	Ammonia (mg/L)
TPGW-1S (2018)	19,400	34,000	32.37	954	1.35
TPGW-1M (2018)	27,000	51,200	48.46	2,173	1.75
TPGW-1D (2018)	28,500	51,8000	48.03	2,307	1.84
TPGW-1S (2011)	17,000	27,000	27.8	810	0.87
TPGW-1M (2011)	29,000	49,000	48.7	2,440	1.3
TPGW-1D (2011)	29,000	50,000	48.1	2,560	1.3
TPGW-2S (2018)	24,800*-	44,400	42.78	2,166	1.57
TPGW-2M (2018)	29,500*	52,800	50.89	3,130	3.14
TPGW-2D (2018)	31,300	52,400	51.56	3,123	2.68
TPGW-2S (2011)	30,000	50,000	52.4	3,030	1.5
TPGW-2M (2011)	34,000	52,000	50.7	3,520	1.5
TPGW-2D (2011)	32,000	52,000	54.2	3,320	1.7
TPGW-4S (2018)	2,280	4,320	4.08	17.4	M
TPGW-4M (2018)	15,100	27,400	25.38	342	M
TPGW-4D (2018)	14,800	27,500	26.34	403	M
TPGW-4S (2011)	670	1,400	1.4	19.4	M

TPGW-4M (2011)	13,000	22,000	24.0	246	M
TPGW-4D (2011)	16,000	26,000	28.0	519	M
TPGW-7S (2018)	37.0	292	0.25**	6.6	M
TPGW-7M (2018)	40.0	294	0.25*	5.2	M
TPGW-7D (2018)	3,970*	7,350	5.85*	20.3	M
TPGW-7S (2011)	35	300	0.3*	13.5	M
TPGW-7M (2011)	35	300	0.3*	12.9	M
TPGW-7D (2011)	42	310	0.3*	2.2	M
TPGW-9S (2018)	25.3	332	0.29*	5.7	M
TPGW-9M (2018)	26.1	326	0.29*	6.5	M
TPGW-9D (2018)	26.3	352	0.30*	1.5	M
TPGW-9S (2011)	20	330	0.3*	10.6	M
TPGW-9M (2011)	25	350	0.3*	8.2	M
TPGW-9D (2011)	28	350	0.3*	1.5*	M
TPGW-10S (2018)	18,900	35,600	35.91	69.1	0.43
TPGW-10M (2018)	19,600	41,600	36.67	208	0.47
TPGW-10D (2018)	28,000	50,800	48.04	1,798	1.38
TPGW-10S (2011)	19,000	33,000	33.8	18.4	0.32
TPGW-10M (2011)	22,000	37,000	37.0	2.8*U	0.24
TPGW-10D (2011)	22,000	36,000	37.4	8.2	0.22
TPGW-11S (2018)	20,700	40,800	36.49	5.7	M
TPGW-11M (2018)	22,500	38,000	38.98	277	M
TPGW-11D (2018)	24,300	48,000	45.55	1,158	M
TPGW-11S (2011)	22,000	36,000	36.9	2.4	M
TPGW-11M (2011)	23,000	39,000	37.8	33.6	M
TPGW-11D (2011)	24,000	39,000	39.3	435	M
TPGW-13S (2018)	32,800	58,600	57.86	6,016	5.58
TPGW-13M (2018)	32,700	58,400	56.52	3,277	3.40
TPGW-13D (2018)	33,700	62,800	58.48	3,130	3.36
TPGW-13S (2011)	38,000*	61,000	61.6	3,800	2.8
TPGW-13M (2011)	37,000*	57,000	58.5	4,030	1.6H
TPGW-13D (2011)	37,000*	59,000	59.2	3,830	1.6
TPGW-14S (2018)	21,200	43,400	38.45	93.1	0.54
TPGW-14M (2018)	21,500	45,000	40.01	175	0.80
TPGW-14D (2018)	28,700	52,800	49.46	2,083	2.42
TPGW-14S (2011)	24,000	39,000	40.0	247	0.54
TPGW-14M (2011)	27,000	43,000	43.6	772	0.84
TPGW-14D (2011)	32,000*	52,000	51.8	2,660	1.6*-

Notes: D=deep well; M=middle well (intermediate interval); S=shallow well; TDS=total dissolved solids; H=hold time exceeded; *=denotes result qualified as estimated (+/- indicates bias); M=missing data (analyte not collected/required); U=indicates analyzed for but not detected at the reported value.


Some results in the table may be rounded.

-
- (a) All units are reported in milligrams per liter (mg/L) except salinity (reported in practical salinity units (PSU) based on the practical salinity scale of 1978) (unitless) and tritium (picoCuries per liter (pCi/L) with 1 σ uncertainty error omitted). Ammonia is reported as total ammonia nitrogen.
 - (b) Analytical results from the March 2018 quarterly sampling event (FPL 2018o).
 - (c) Analytical results from the March 2011 quarterly sampling event (FPL 2012a).
-

Source: FPL 2012a, FPL 2017a, FPL 2018o.

Monitoring well locations (see Figure 3-17) were established based on FPL and interagency consensus and criteria as documented in the 2009 monitoring plan (SFWMD 2009). The wells are located such that monitoring will be able to detect changes in groundwater quality, including migration of the hypersaline plume, both in the near field (adjacent to the CCS) and at representative far-field locations (i.e., at distances not currently identified as having been affected by CCS water). For example, well cluster TPGW-13 is located at the approximate center of the CCS, the source of the hypersaline plume. Wells TPGW-1 through TPGW-7 are situated at various distances to the north and west of the CCS. Well cluster TPGW-7, when originally installed, was established as the FPL uprate monitoring location nearest to the Miami-Dade County's Newton Wellfield that supplies potable water to municipal customers. However, a new monitoring well (TPGW-20D), described above, is closer to the Newton Wellfield as are several wells maintained by the USGS, for which monitoring data are now being included in FPL's EDMS. Well location TPGW-9 is a reference well location reflecting groundwater conditions unaffected by the CCS and located upgradient (west) of the saltwater interface. Well locations TPGW-10, TPGW-11, and TPGW-14 are offshore in Biscayne Bay and Card Sound.

As summarized in Table 3-4 above, the analytical results from FPL's monitoring program include the deep-screened interval of the listed well locations that correspond to the base of the Biscayne aquifer, the intermediate (middle) screened-interval, as well as from the shallow (upper) interval of the aquifer, in order to identify any vertical differences in water quality parameters. It is in the lower intervals of the aquifer where hypersaline water from the CCS would be expected to preferentially move, as well as where migration of the regional saltwater interface would first be evident. Based on the results from FPL's baseline continuous surface electromagnetic survey conducted in late March and early April 2018, the hypersaline groundwater plume is generally wedge-shaped. Consequently, the hypersaline groundwater does not extend as far west in the shallow and deeper intervals of the Biscayne aquifer as it does in the intermediate interval of the aquifer. While FPL correctly states that the plume generally extends an average of 1.5 to 2.5 miles (2.4 to 4.0 km) west of the CCS (FPL 2018o), more precisely the hypersaline groundwater extends about 1 mile (1.6 km) west of the CCS at the base of the Biscayne aquifer (i.e., at 87.0 to 99.4 ft (26.5 to 30.3 m) below land surface) and about 3 miles (4.8 km) west of the CCS in a high-flow interval at depths from 47 to 55 ft (14.3 to 16.8 m) below ground surface (FPL 2018q). At more shallow depths (26 to 32 ft (7.9 to 9.8m)), the plume extends about 1.2 miles (1.9 km) west from the southern portion of the CCS. Figure 3-18 depicts the mapped areal extent from the 2018 continuous surface electromagnetic survey of chloride concentration in the Biscayne Aquifer in the high-flow interval. The extent of hypersaline groundwater is shown by the interface between the black and blue colors. The approximate locations of select monitoring wells have been added to Figure 3-18 for reference.



Source: Modified from FPL 2018q: App G Fig. 3-2 (well locations are approximate)


Figure 3-18 Chloride Concentration and Extent of Hypersalinity in the Biscayne Aquifer, 44 to 55 ft Below Ground Surface April 2018

Further, Table 3-4 compares quarterly groundwater sampling results for the same seasons (i.e., March 2011 and March 2018) so that results for monitored parameters at the well locations can be compared. March is near the end of the dry season across southeast Florida and is the timeframe where the effects of CCS water incursion would likely be more discernible. Data from March 2011 are included to provide a baseline from the pre-extended power uprate monitoring

period (June 2010 to June 2012) for comparison with recent monitoring results for Turkey Point. In addition to Table 3-4, the NRC staff has included several time-series line plots to illustrate key observations and findings.


The NRC staff's data and analyses document baseline groundwater quality as well as any changes in quality in the Biscayne aquifer within and adjacent to the Turkey Point site. The results reflect the current FDEP classification for Class G-III groundwater (i.e., TDS of 10,000 mg/L or greater) in the area of the site, corresponding to the western boundary of the CCS and encompassing the Turkey Point property to the east and extending beneath Biscayne Bay (see well clusters, TPGW-10, TPGW-11, TPGW-13, and TPGW-14). The current monitoring data (Table 3-4) also establish that TDS concentrations in groundwater to the west of the CCS boundary exceed the G-II standard (TDS of less than 10,000 mg/L) in the intermediate and deeper portions of the Biscayne aquifer (see, for example, data for well clusters TPGW-2 and TPGW-4).

Monitoring results, as confirmed by the continuous surface electromagnetic survey (see Figure 3-18 above), further show the influence of CCS operations on Biscayne aquifer groundwater quality adjacent to and west of the CCS, based on the presence of hypersaline water (chloride concentrations greater than 19,000 mg/L), in addition to elevated tritium levels. As an example, Figures 3-19a and 3-19b show chloride and tritium concentrations, respectively, in monitoring well cluster TPGW-2 for the period 2010-2018.



Source: Generated from FPL 2019g

Figure 3-19a Time-Series Chart of Chloride Concentrations in Well Cluster TPGW-2, 2010-2018




Source: Created from FPL 2019g

Figure 3-19b Time-Series Chart of Tritium Concentrations in Well Cluster TPGW-2, 2010-2018


The data presented in Table 3-4, as well as in the broader quarterly monitoring data sets (June 2013 through March 2018) (FPL 2016a, FPL 2017a, FPL 2018o), generally display an increasing vertical trend in parameter concentrations, such as in chloride, TDS, and tritium, with depth (i.e., from the shallow to the deep monitored intervals). This is illustrated in Figures 3-19a and 3-19b. The NRC staff notes that Figure 3-19b reveals an apparent spike in tritium in well TPGW-2S (4,605 pCi/L) during the June 2018 sampling event, which falls outside the timeframe included in the current (2018) published annual monitoring report (FPL 2018o). This result appears to be a localized anomaly based on the NRC staff's review of monitoring data from other wells for the same timeframe. Currently available monitoring data at this well cluster do not show any sustained changes in groundwater quality at this location. Nevertheless, and as the latest annual monitoring report results affirm (FPL 2018o), concentrations tend to increase with depth in the aquifer due to the greater density of saline water and thus can be indicative of the influence of CCS water.

Well cluster TPGW-13, centered in the CCS, has the highest chloride, TDS, tritium, and ammonia concentrations, and concentrations in shallow well TPGW-13S can approach or exceed those in the deeper or intermediate wells due to the influence of CCS surface water (see Table 3-4). As shown in Figure 3-20a, groundwater monitoring indicates a recent general decline in chloride concentrations at well cluster TPGW-13 since 2016. However, this apparent trend is less pronounced over the period of record back to 2010 (Figure 3-20b).



Source: FPL 2019o: Fig. 3.1.22

Figure 3-20a Bar Graph of Chloride Concentrations in Well Cluster TPGW-13 (CCS), 2016-2018




Source: Created from FPL 2019g

Figure 3-20b Time Series Chart of Chloride Concentrations in Well Cluster TPGW-13 (CCS), 2010-2018


Similarly, tritium levels measured in wells to the east of the CCS in Biscayne Bay (i.e., TPGW-10, TPGW-11, and TPGW-14) suggest the influence of CCS water, at least in the deeper intervals of the Biscayne aquifer (Table 3-4), with generally very low levels of tritium found in the shallow portion of the aquifer.

For most monitored parameters at these groundwater locations (TPGW-2, -4, -10, -11, and -14), the NRC staff observes that the influence of CCS water was evident prior to implementation of the extended power uprate beginning in 2012. One exception is well cluster TPGW-10 located just northeast of the CCS in Biscayne Bay, where monitoring did not reveal elevated tritium concentrations at any depth until after 2011 (see Table 3-4 and the discussion later in this section). Figures 3-21a and 3-21b show trends in tritium and chloride, respectively, in groundwater beneath Biscayne Bay at well cluster TPGW-11. At well TPGW-11, monitoring results show an increase in tritium concentrations over time, confined to the deep and intermediate intervals of the Biscayne aquifer. There is no indication of any influence of CCS water in the uppermost interval of the Biscayne aquifer at this location. Chloride concentrations at this location have remained relatively stable at all depths, with higher chloride concentrations in the deeper portion of the aquifer.



Source: Created from FPL 2019g

Figure 3-21a Time-Series Chart of Tritium Concentrations in Well Cluster TPGW-11, 2010-2018




Source: Created from FPL 2019g

Figure 3-21b Time-Series Chart of Chloride Concentrations in Well Cluster TPGW-11, 2010-2018

In summary, the NRC staff concludes that hypersaline groundwater in the Biscayne aquifer presently exists under and adjacent to the CCS, with hypersaline conditions diminishing with increased distance from the CCS. As documented in FPL’s latest (2018) annual monitoring report (FPL 2018o), the extent of “potential CCS influence” is 4.5 mi (7.2 km) west of the CCS as measured at the base (deep interval) of the Biscayne aquifer. This distance has not changed since 2017. Here, the composition of the groundwater includes ambient saline water mixed with small quantities of CCS water (including soluble salts, nutrients, and tritium), whereas the degree of CCS influence (marked by higher chloride and tritium concentrations) increases closer to the CCS (FPL 2018o). This line of influence is based on the latest available estimate of the 20 pCi/L concentration boundary for tritium in groundwater, with the mapped contour line passing just west of monitoring well TPGW-7D, which is depicted below in Figure 3-22. It should be noted that tritium readings of 20 pCi/L are not significant; for comparison, the EPA’s primary drinking water standard or maximum contaminant level for tritium is 20,000 pCi/L (40 CFR 141.66).

For the March 2018 sampling event, the maximum observed tritium concentration in any well west of the CCS was 3,130 pCi/L at well TPGW-2M (Table 3-4). The extent of potential CCS influence based on tritium levels does not extend as far west in either the shallow or intermediate intervals of the Biscayne aquifer as it does in the deep interval of the aquifer. Elevated tritium levels in the intermediate and deep monitored portions of the aquifer also indicate the potential influence of CCS water in groundwater beneath Biscayne Bay, although effects do not extend as far east as they do to the west. For the March 2018 sampling event, the maximum tritium concentration in groundwater to the east of the CCS was 2,083 pCi/L at well TPGW-14D (Table 3-4).




Source: Modified from FPL 20180: Fig. 3.4-4

Figure 3-22 Extent of Tritium in the Deep Interval of the Biscayne Aquifer, 2017-2018


As described in FPL’s annual monitoring reports, FPL had previously estimated the historical limit, prior to CCS construction, of Class G-III groundwater (non-potable water with a TDS content of 10,000 mg/L or greater). FPL based this estimate on historical TDS values from groundwater wells. Where historical TDS values were not directly available, FPL used the relationship between measurements of specific conductance and TDS to estimate historical TDS values. FPL’s recent annual monitoring reports state that most of the Biscayne aquifer currently affected by the CCS never contained potable water (FPL 2017a, FPL 2018o).

Nevertheless, FPL’s recent (2017 and 2018) annual monitoring reports state that monitoring has shown increases in one or more constituents (e.g., chloride, tritium) in several wells over the last 4 to 5 years that indicate the expansion of more saline groundwater, and possible CCS influence. These wells include TPGW-7D, TPGW-10D, and TPGW-11D. Figures 3-23a and 3-23b depict trends in chloride and tritium concentrations, respectively, in groundwater at well cluster TPGW-7. At TPGW-7D, the water transitioned from fresh water to brackish between the summer of 2013 and January 2017 (FPL 2017a), as illustrated in Figure 3-23a.



Source: Created from FPL 2019g

Figure 3-23a Time-Series Chart of Chloride Concentrations in Well Cluster TPGW-7, 2010-2018




Source: Created from FPL 2019g

Figure 3-23b Time-Series Chart of Tritium Concentrations in Well Cluster TPGW-7, 2010-2018

During the 2018 reporting period (June 1, 2017 through May 31, 2018), increases in conductance, chloride, and sodium continued at well TPGW-7D (FPL 2018o). FPL attributed


the increase in observed ion concentrations (e.g., chloride) to the advance of the saltwater interface along the base of the Biscayne aquifer (FPL 2017a, FPL 2018o). In contrast, the average tritium value for the 2018 reporting period remained low (22.2 pCi/L). The report suggests that this may indicate that CCS water has little contribution to increases observed in saline groundwater at this well (FPL 2018o). While the NRC staff observes that tritium concentrations have remained relatively low (less than 35 pCi/L) and variable over the period 2010-2018, a slight increasing trend in tritium levels in the deep monitored interval (TPGW-7D) does appear to be evident, suggestive of possible CCS influence.

Meanwhile, wells TPGW-10D and TPGW-11D, just east of the CCS in Biscayne Bay, have exhibited increases in conductance, chloride, and tritium since 2012-2013 (FPL 2018o), as illustrated in Figures 3-24a and 3-24b for well cluster TPGW-10. FPL’s 2017 annual monitoring report suggested that the increase in tritium in these wells was indicative of “a potential increase in the amount of CCS-sourced groundwater compared to the original marine groundwater” (FPL 2017a). Otherwise, FPL reports that monitoring data from FPL’s monitoring network show that groundwater quality in most wells has exhibited little change overall since the inception of the monitoring program, and the data show that the well locations are generally insulated from normal daily and seasonal influences (FPL 2018o). In 2018, two wells exhibited short-term changes that FPL attributed to the effects of Hurricane Irma (September 2017). Saltwater constituents temporarily spiked at well TPGW-4S, and specific conductance and tritium spiked at TPGW-10M (discernible in Figure 3-24b) as exhibited in monitoring results immediately after the hurricane (FPL 2018o).



Source: Created from FPL 2019g

Figure 3-24a Time-Series Chart of Chloride Concentrations in Well Cluster TPGW-10, 2010-2018



Source: Created from FPL 2019g

Figure 3-24b Time-Series Chart of Tritium Concentrations in Well Cluster TPGW-10, 2010-2018

Current (2018) water quality monitoring results and other available well data continue to show that a fresher groundwater lens (i.e., low chloride and TDS concentrations) exists in the upper (i.e., 18 to 20 ft (5.5 to 6.1 m)) interval of the Biscayne aquifer just to the west of the CCS. This lens generally thickens to over 50 feet (15 m) in depth at TPGW-7 (see Figure 3-17). Here, in the shallow interval at this monitoring location (TPGW-7S), the groundwater appears to meet the Class G-II criterion for potable water use with a TDS content of less than 10,000 mg/L (see Table 3-4 and Figure 3-17). At a distance of over 5.5 mi (8.9 km) west of the CCS (e.g., at TPGW-9, see Table 3-4 and Figure 3-17), the aquifer is presently fresh at all depths (FPL 2017a, 2018o).

As referenced throughout this section by the NRC staff and described in FPL’s annual monitoring reports, measurements of specific conductivity, salinity, and concentrations of chloride, tritium (as a tracer), and other water quality parameters can and have been used with varying degrees of difficulty to identify the potential influence of CCS water on ambient groundwater quality, as differing from natural saltwater. Consideration of the pathways for tritium transport can be problematic but is important for the purpose of source attribution (e.g., atmospheric deposition versus groundwater migration). Similarly, attribution of sources of nutrients (including ammonia, total nitrogen, and phosphorus) can be difficult and is further complicated by various processes that serve to attenuate their transport (FPL 2018o). Section 3.5.1.4, “Adjacent Surface Water Quality and Cooling Canal System Operation,” of this SEIS describes potential sources of nutrients in the CCS and surrounding waters, including FPL’s ongoing nutrient management efforts.

Table 3-5 summarizes groundwater monitoring results for nutrient concentrations in select wells in and around the CCS and compares the most recent (2018) monitoring results with the historical ranges in concentration for the nutrient.

Table 3-5 Summary of Groundwater Monitoring Results for Nutrients in Select Biscayne Aquifer Wells, Turkey Point Uprate Monitoring Program

Well Number (Location) and Monitoring Period	Monitored Interval	Ammonia (mg/L as Nitrogen)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
TPGW-1 (NW of CCS) Historical Range ^(a)	Shallow	0.38 to 1.29	1.12 to 1.91	0.004 to 0.046
	Intermediate	1.10 to 1.95	0.94 to 3.41	0.002 to 0.059
	Deep	1.30 to 2.04	1.24 to 2.78	0.08 to 0.057
March 2018 ^(b)	Shallow	1.35	2.24	0.035
	Intermediate	1.75	2.62	0.037
	Deep	1.84	2.44	0.040
TPGW-2 (WSW of CCS) Historical Range ^(a)	Shallow	1.49 to 2.90	1.34 to 3.01	0.002 to 0.043
	Intermediate	1.50 to 2.74	1.90 to 3.34	0.013 to 0.082
	Deep	0.35 to 2.48	2.00 to 3.19	0.007 to 0.062
March 2018 ^(b)	Shallow	1.57	1.95	0.015
	Intermediate	3.14	3.13	0.045
	Deep	2.68	2.77	0.056
TPGW-10 (NE offshore) Historical Range ^(a)	Shallow	0.32 to 0.92	0.31 to 1.10	0.002 to 0.085
	Intermediate	0.24 to 1.08	0.26 to 1.49	0.002 to 0.053
	Deep	0.22 to 1.45	0.33 to 1.83	0.004 to 0.051
March 2018 ^(b)	Shallow	0.43	0.85	0.017
	Intermediate	0.47	0.91	0.023
	Deep	1.38	1.68	0.056
TPGW-13 (CCS) Historical Range	Shallow	0.61 to 3.90	2.60 to 5.19	0.004 to 0.067
	Intermediate	0.76 to 3.15	1.50 to 4.22	0.004 to 0.152
	Deep	0.06 to 3.66	1.70 to 5.43	0.002 to 0.077
March 2018 ^(b)	Shallow	5.58	4.65	0.047
	Intermediate	3.40	3.38	0.069
	Deep	3.36	3.25	0.064
TPGW-14 (SE offshore) Historical Range ^(a)	Shallow	0.41 to 1.15	0.71 to 1.70	0.002 to 0.071
	Intermediate	0.66 to 1.55	1.05 to 1.91	0.003 to 0.074
	Deep	1.05 to 2.42	2.30 to 3.51	0.004 to 0.078
March 2018 ^(b)	Shallow	0.54	1.00	0.040
	Intermediate	0.80	1.09	0.062
	Deep	2.42	2.78	0.060

Note: **Bold** used for emphasis to denote peak concentrations. NE=northeast; SE=southeast; WSW=west-southwest.

(a) Historical range reflects the minimum to maximum concentrations measured for each monitoring interval for each well over the period of record (June 2010 to March 2017).

(b) March 2018 quarterly sampling event (FPL 2018o).

Source: Compiled from FPL 2018o.

Based on the nutrient data presented, the NRC staff observes the following with respect to FPL's groundwater monitoring network. In 2018, and over the period of record (beginning in 2010) for the well clusters listed in Table 3-5, the highest concentrations of ammonia (an inorganic form of nitrogen), total nitrogen, and total phosphorus occur in groundwater beneath

the CCS, as measured at well cluster TPGW-13 (located near the center of the CCS). Meanwhile, nutrient concentrations (e.g., total nitrogen and total phosphorus) in the waters of the CCS have generally been declining since about 2014, which can at least partly be attributed to FPL's freshening activities (see Section 3.5.1.4, "Adjacent Surface Water Quality and Cooling Canal System Operation"). The NRC staff's review of the data also reveals that there has been and continues to be substantial variability in measured nutrient concentrations at all monitoring well clusters, and at all depths, over the period of record. These considerations complicate attempts at correlating nutrient concentrations and other monitored parameters at groundwater monitoring locations with likely sources of the nutrients, thus giving rise to uncertainty in source attribution. Nonetheless, and as previously described in this section in relation to the groundwater monitoring results previously presented in Table 3-4, concentrations of particular water quality parameters (i.e., chloride and tritium) tend to increase with depth in the Biscayne aquifer due to the greater density of saline water. Thus, the presence of these constituents together at elevated concentrations in the intermediate and deep intervals of the aquifer can be helpful in revealing the density-driven movement and influence of CCS water through the aquifer.

For the select Biscayne aquifer well clusters immediately surrounding the CCS, the monitoring data presented in Table 3-5 reveal that nutrient levels generally increase in concentration with depth. This observation generally holds for the most recent, published monitoring results as well as for results over the period of record (2010-2018). The exception is in well cluster TPGW-13 that monitors groundwater immediately beneath the CCS, where the concentrations of ammonia and total nitrogen were highest in the shallow interval of the aquifer during the March 2018 quarterly sampling event.

Based on the March 2018, monitoring results (Table 3-5), the highest nutrient concentrations occur in the intermediate and deep intervals of the aquifer in both the well clusters immediately to the west of the CCS (TPGW-1, TPGW-2) as well as in those to the east and offshore in Biscayne Bay and Card Sound, well clusters TPGW-10 and TPGW-14, respectively. The highest chloride and tritium concentrations at these locations occur in the intermediate and deep intervals of these four wells, as shown in the expanded groundwater monitoring data summarized in Table 3-4. The highest tritium concentrations in these four wells (TPGW-1, TPGW-2, TPGW-10, and TPGW-14) are 2,307, 3,130, 1,798, and 2,083 pCi/L, respectively, as compared to a maximum of 6,016 pCi/L in TPGW-13 beneath the CCS. Additionally, the monitoring results (Table 3-4) for the four well clusters, as for TPGW-13, indicate hypersaline conditions (chloride concentrations greater than 19,000 mg/L) in the intermediate and deep intervals of the Biscayne aquifer. As previously discussed for chloride and tritium in these wells, the elevated nutrient concentrations further suggest the influence of CCS water in the intermediate and deep monitored intervals of the Biscayne aquifer at these monitoring locations.

Regulatory Developments with Respect to Cooling Canal System Operations and Groundwater Quality

As discussed above, beginning in 2010, FPL implemented an expanded groundwater monitoring program in support of Turkey Point's extended power uprate and associated regulatory approvals. This expanded groundwater monitoring program helped to identify the need for FPL to take corrective actions to address onsite and offsite impacts associated with operation of the CCS, especially involving salinity, chloride, and ammonia concentrations (FPL 2018f). In consultation with and at the direction of State and local regulatory agencies (i.e., Miami-Dade County DERM), since 2013, FPL has undertaken a number of actions to mitigate impacts associated with CCS operation. Most of these actions focus on reducing high

salinities within the CCS. Most recently, these actions have included active measures to halt and remediate the migration of the hypersaline plume from the CCS. This section of the SEIS presents a brief summary of the history, the current status, and the scope of the associated regulatory mechanisms governing FPL's actions focusing on groundwater quality issues.

In December 2014, the FDEP issued an administrative order to FPL directing, in part, that FPL develop a salinity management plan for the CCS along with additional monitoring requirements (FDEP 2014, FPL 2018f). Several entities, including Miami-Dade County, challenged the FDEP's 2014 administrative order.

On October 2, 2015, Miami-Dade County issued a notice of violation (NOV) to FPL alleging violations of county water quality standards and criteria in groundwater beyond the boundaries of the CCS and FPL property (FPL 2018f, MDC 2015a). Subsequently, on October 7, 2015, Miami-Dade County and FPL entered into a Consent Agreement (the 2015 Consent Agreement). In the 2015 Consent Agreement, the County recognized the salinity reduction efforts that FPL was already undertaking including the use of onsite marine production wells and plans to construct six wells to withdraw water from the Upper Floridan aquifer for CCS salinity reduction. The 2015 Consent Agreement requires FPL to evaluate alternative water sources to offset water deficits in the CCS and to reduce chloride concentration in the CCS, including the use of reclaimed wastewater from the Miami-Dade South District Wastewater Treatment Plant (FPL 2018f, MDC 2015a). Moreover, the 2015 Consent Agreement specifically requires FPL to maintain measures to abate hypersaline water discharges and to actively remediate the hypersaline groundwater west and north of FPL's property, without creating adverse environmental impacts. The stipulated remedial action is the installation and operation of a Biscayne aquifer recovery well system to intercept, capture, and retract the hypersaline plume from the CCS to within FPL's property boundary, along with associated deep well disposal of the extracted hypersaline groundwater. The Consent Agreement also requires that FPL conduct additional groundwater monitoring, submit annual reports and undertake surveys (i.e., continuous surface electromagnetic mapping of the hypersaline plume) to gauge progress toward meeting the terms of the agreement. The latest available mapping results are described above (see "Baseline Groundwater Quality and Changes Attributable to Turkey Point Operations"). Finally, FPL is required to review, report, and consult on any necessary changes related to the effectiveness of the recovery well system at 5-year and 10-year intervals (MDC 2015a).

On August 15, 2016, FPL and Miami-Dade County executed an addendum revising the 2015 Consent Agreement. The revised agreement (the 2016 Addendum) requires FPL to take action to evaluate and address alleged violations of Miami-Dade County water quality standards and cleanup target levels relating to the exceedance of ammonia standards in surface water, including deep remnant canals adjacent to the Turkey Point CCS. The 2016 Addendum further requires that FPL prepare a site assessment report to identify the sources of ammonia exceedances and to delineate their extent in surface water in accordance with a site assessment plan approved by Miami-Dade County (MDC 2016a). On December 29, 2016, in response to the County's comments on the draft site assessment plan, FPL submitted an amended site assessment plan, and it initiated environmental sampling on January 3, 2017, as approved by Miami-Dade County (FPL 2017b). FPL submitted its completed site assessment report to the County on March 17, 2017 (FPL 2017c, FPL 2018p).

The completed ammonia site assessment report documents the results of FPL's sampling and analysis program to assess the nature and extent of ammonia in surface waters near the Turkey Point site and in the CCS. It includes sampling results from numerous surface water,

porewater, canal water, and groundwater sampling locations as well as stratified surface water sampling. With respect to groundwater, FPL sampled nine monitoring wells completed in the Biscayne aquifer, including: (1) four wells northeast of the Turkey Point power block (FTF-SW, FTF-NW, FTF-SE, MW-5), (2) two wells east of the power block (MW-3, MW-4) adjacent to the discharge canal and Biscayne Bay, (3) two wells (South MW, North MW) southeast of the power block near FPL's sanitary injection well and discharge canal, and (4) one deeper well located south of the Turkey Point complex in the mud flat area known as Mud Island (C6-5). While all wells had detectable ammonia, the concentrations were variable, ranging from a low of 0.17 mg/L at MW-3 adjacent to the intake canal and Biscayne Bay to a high of 4.6 mg/L at the South MW, as compared to the Miami-Dade County water quality standard of 0.5 mg/L. The report states that the high concentration of ammonia at South MW and relatively fresh water in the well may be caused by the sanitary wastewater injection well. Well C6-5 had the second highest ammonia concentration (2.48 mg/L). This deeper well (C6-5) at 90 feet (27 m) was the only well sampled that also exhibited hypersalinity (52.2 PSU), indicating potential CCS influence (FPL 2017c).

In July 2017, Miami-Dade County requested that FPL collect additional data in support of the ammonia site assessment report (FPL 2017b). In November 2017, FPL responded to the County's request by submitting supplemental information (FPL 2017h). In a July 10, 2018 letter, the Miami-Dade County DERM informed FPL that it had completed its review of the site assessment report and supplemental information. The County's letter states that based on its review of FPL's ammonia data as well as its review of historical groundwater monitoring data collected from the TP-GW series uprate monitoring wells (e.g., TPGW-1, TPGW-2, TPGW-10, TPGW-13, and TPGW-14), there is a "statistically significant increasing trend" in ammonia concentrations in groundwater in the intermediate and deep intervals along with a concentration gradient emanating from the CCS. The County's letter directs FPL to undertake a number of additional actions, including development of a revised sampling plan for ammonia in surface water and groundwater and measures to reduce nutrient impacts from the CCS on surface waters and groundwater (MDC 2018a). FPL responded to the County's comments with a letter report in October 2018 (FPL 2018r). FPL stated, in part, that the ammonia concentrations in groundwater surrounding the CCS fall below the County's cleanup target levels specified in Section 24-44(2)(f)(v) of the County Code (FPL 2018r; MDC 2019c). For ammonia in groundwater, the County cleanup target level is 2,800 ug/L (equivalent to 2.8 mg/L) (MDC 2019c). FPL also reiterated its ongoing activities to implement nutrient management practices consistent with its approved Nutrient Management Plan (FPL 2018r). Surface water sampling results from the ammonia site assessment report, associated findings regarding source attribution, FPL's ongoing nutrient management efforts, and followup actions are discussed in Section 3.5.1.4, "Adjacent Surface Water Quality and Cooling Canal System Operation," of this SEIS.

Separately, the FDEP issued a modified final administrative order to FPL on April 21, 2016 (the 2016 Final Administrative Order) (FDEP 2016h, FPL 2018f). The FDEP's 2016 Final Administrative Order concludes, in part, that "the preponderance of the record evidence indicates the CCS is the major contributing cause of the continuing westward movement of the saline water interface" (FDEP 2016h).

As discussed in Section 3.5.1.4 above (regarding "Ammonia and Nutrients within Biscayne Bay and Card Sound") on April 25, 2016, the FDEP issued a warning letter (FDEP 2016c) expressing concern that CCS water was reaching Biscayne Bay. FPL responded by submitting nutrient monitoring data on May 16, 2016, to the FDEP for its review (see Section 3.5.1.4, "Adjacent Surface Water Quality and Cooling Canal System Operation." Concurrently, the

FDEP issued a notice of violation to FPL that incorporated findings from the FDEP's April 21, 2016 Final Administrative Order and specifically directed FPL to enter into consultations to develop a Consent Order for corrective actions to abate the CCS contribution to the hypersaline plume, reduce the size of the hypersaline plume, and prevent future harm to waters of the State (FDEP 2016d, FPL 2018f).

To resolve the warning letter and notice of violation, FPL and the FDEP executed a Consent Order on June 20, 2016 (the "2016 FDEP Consent Order") (FDEP 2016a). The 2016 FDEP Consent Order contains three primary objectives (FDEP 2016a; FPL 2018f) as well as the methods FPL must use to meet each objective. The three objectives are as follows (FDEP 2016a).

- **First Objective.** Cease discharges from the CCS that impair the reasonable and beneficial use of the adjacent Class G-II groundwater by maintaining the average annual salinity of the CCS at or below 34 PSU, by undertaking freshening activities, by eliminating the CCS contribution to the hypersaline plume, by halting the westward migration of hypersaline water from the CCS, and by reducing the westward extent of the hypersaline plume to the L-31E Canal within 10 years, thereby removing its influence on the saltwater interface without creating adverse environmental impacts.
- **Second Objective.** Prevent releases of groundwater from the CCS to surface waters connected to Biscayne Bay that result in exceedances of surface water quality standards in Biscayne Bay.
- **Third Objective.** Provide mitigation for impacts related to the historic operation of the CCS, including but not limited to the hypersaline plume and its influence on the saltwater interface.

The First Objective of the 2016 FDEP Consent Order primarily involves reducing salinity in the CCS and thereby also reducing the CCS contribution to the hypersaline plume in the Biscayne Aquifer and the plume's westward migration. Since 2015, FPL has been using a variety of water sources to manage salinity within the CCS. It has also implemented several additional CCS operational and surface water quality management measures as required by the 2016 FDEP Consent Order, which are discussed in Section 3.5.1.4, "Adjacent Surface Water Quality and Cooling Canal System Operation," of this SEIS.

With regard to meeting the 34 PSU salinity metric specified in the 2016 FDEP Consent Order and consistent with the requirements of the 2015 Consent Agreement with Miami-Dade County, FPL commenced operation of a new freshening well system on November 28, 2016, adding groundwater from the Upper Floridan aquifer to the CCS. The State of Florida authorizes FPL to withdraw up to 14 mgd (53,000 m³/day) from the Upper Floridan aquifer from six wells under its modified site certification for the Turkey Point site (FDEP 2016b, State of Florida Siting Board 2016). FPL has constructed five wells to date (i.e., wells F-1, F-3, F-4, F-5, and F-6). By adding relatively brackish (i.e., average of 2.5 PSU) Upper Floridan aquifer groundwater to the CCS, FPL intends to minimize the increase in salinity that can occur in the CCS during the yearly dry season, reduce average CCS salinity to meet the 2016 FDEP Consent Order metric of 34 PSU, and reduce the CCS contribution to the existing hypersaline plume (FPL 2018f). Section 3.5.2.3, "Groundwater Use," in this SEIS contains a separate discussion of groundwater withdrawals associated with salinity reduction and other activities at the Turkey Point site.

In order to stop and then retract the westward migration of hypersaline groundwater originating from the CCS, the 2016 FDEP Consent Order requires FPL to permit, construct, and operate a

recovery well system to remediate the hypersaline plume in the Biscayne aquifer (FDEP 2016a). This requirement is consistent with the 2015 Consent Agreement (MDC 2015a) between FPL and Miami-Dade County, as described previously. Additionally, the Consent Order stipulated enhancements to FPL's groundwater monitoring network by requiring the addition of new well clusters and additional monitoring data reporting (FDEP 2016a).

From September 2016 until mid-2018, FPL conducted hypersaline extraction and deep well injection testing, which had the benefit of initiating salt removal from the Biscayne aquifer. In 2013, FPL had sought and obtained permission from FDEP to permit Deep Injection Well DIW-1 as a Class I injection well by converting the existing Class V exploratory well (EW-1), originally installed for the proposed new reactors, Turkey Point Units 6 and 7 (FDEP 2013). FPL used the existing deep injection well (DIW-1) and four, 90-foot (27-m) deep Biscayne aquifer production wells constructed by FPL in the CCS for assessing flow rates for the recovery wells. The test production/extraction wells were operated from September 28, 2016, to May 7, 2018 (FPL 2017a, FPL 2018f, FPL 2018o). By letter dated June 21, 2016, FDEP authorized FPL to carry out the testing program in accordance with underground injection control Permit 293962-002-UC and Permit Modification 293962-003-UC/MM (FDEP 2013, FDEP 2016f, FDEP 2016g).

Meanwhile, in May 2017, Miami-Dade County approved FPL's remedial action plan for design and construction of the recovery well system (MDC 2017e). FPL began construction of the full-scale hypersaline groundwater recovery well system on June 19, 2017 (FPL 2017a). The recovery well system was completed on May 15, 2018, and it then became operational (FPL 2018h). Operation of the extraction well portion of the system is authorized under a SFWMD water use permit (Permit No. 13-06251-W), issued to FPL in February 2017 (SFWMD 2017a). In July 2018, FDEP issued underground injection control Permit No. 0293962-004-UO/11 to FPL for operation of deep injection well DIW-1 for disposal of hypersaline groundwater (FDEP 2018d).

The installed full-scale hypersaline groundwater recovery well system consists of 10 hypersaline groundwater recovery (extraction) wells (i.e., numbered RW-1 through RW-10), generally located along the western edge of the CCS, and the Class 1 deep injection well (DIW-1) for disposal of the recovered hypersaline groundwater (Figure 3-25). Between October 2016 and September 2018, the testing and recovery well systems have extracted and disposed of approximately 9,564 million gallons (36.2 million m³) of hypersaline groundwater, with the removal of 2.27 million tons (2.06 million metric tons) of salt from the Biscayne aquifer (FPL 2017b, 2018p). FPL further estimates that recovery well operations have had the added benefit of removing more than 27,600 lbs (12,500 kg) of ammonia (a nutrient of concern) from the aquifer (FPL 2018r). Section 3.5.2.3, "Groundwater Use," provides additional details on the recovery well system.

The latest available recovery well system status reports show that the system is reducing salinities in the shallow (upper) interval of the Biscayne aquifer adjacent to the recovery wells. Groundwater monitoring data indicate an overall declining trend in salinity in the shallow wells adjacent to the CCS (including wells TPGW-1S, TPGW-2S, and TPGW-15S), with no significant change observed in the intermediate (middle) or deep zones. This trend is evident in Figure 3-26.


In its environmental report, FPL stated that groundwater modeling of the recovery well system operation indicates that the westward migration of the hypersaline plume will be stopped in 3 years of operation, with retraction of the hypersaline plume north and west of the CCS

beginning in 5 years. FPL further projects that system operation will achieve retraction of the plume back to the FPL site boundary within 10 years, as required by the 2016 FDEP Consent Order with FDEP (FPL 2018f). FPL is required to conduct periodic continuous surface electromagnetic mapping surveys to delineate the extent of the hypersaline plume in order to measure the success of recovery and remediation efforts and report the results to FDEP.



Source: Modified from FPL 2018q

Figure 3-25 Layout of Biscayne Aquifer Recovery Well System and Injection Wells



Source: Modified from FPL 2019i

Figure 3-26 Salinity Trends in Groundwater Monitoring Wells Near the CCS in Response to Recover Well System Operations

After 5 years of system operation, FPL must provide a report to FDEP that evaluates the effectiveness of the recovery well system in retracting the hypersaline plume to the L-31E Canal within 10 years. If FPL’s report shows that the remediation efforts will not retract the hypersaline plume to the L-31E Canal within 10 years, FPL must develop and submit an alternate plan to FDEP for its approval (FDEP 2016a).

The Second Objective of the 2016 FDEP Consent Order focuses on the prevention of releases of groundwater from the CCS to surface waters connected to Biscayne Bay. To address these impacts, the 2016 FDEP Consent Order requires FPL to undertake specific environmental restoration projects at Turtle Point and at the Barge Turning Basin, as well as implement a Nutrient Management Plan for the CCS, and to complete and report on the results of an inspection of the periphery of the CCS (FDEP 2016a). For status summaries of these projects, see the discussion in Section 3.5.1.4, “Adjacent Surface Water Quality and Cooling Canal System Operation,” of this SEIS.

The Third Objective of the 2016 FDEP Consent Order requires mitigation for impacts related to the historic operation of the CCS, including but not limited to the hypersaline plume and its influence on the saltwater interface. Discrete mitigative actions specified in the 2016 FDEP Consent Order require FPL to convey specified tracks of FPL property to the SFWMD, if so requested, to facilitate the Comprehensive Everglades Restoration Plan; to make financial contributions to the State of Florida to support mitigation for saltwater intrusion; and to conduct water quality sampling in order to improve trend analysis in Biscayne Bay and Card Sound surface waters. Moreover, the 2016 FDEP Consent Order requires FPL to complete an analysis using the variable density, three-dimensional groundwater model developed in accordance with

the requirements of the 2015 Consent Agreement to “allocate relative contributions of other entities or factors to the movement of the saltwater interface” (FDEP 2016a).

In June 2018, FPL presented the results of its modeling analysis to FDEP staff. In summary, FPL commissioned Tetra Tech, a consulting and engineering services company, to conduct an attribution sensitivity analysis using its existing variable density flow and salinity transport model (Tetra Tech 2018). Modeling runs were conducted to evaluate eight regional and environmental factors as compared to a base scenario in order to assess the effects of these factors on the location of the saltwater interface. These factors included: (1) operation of the Turkey Point CCS, (2) sea level rise, (3) changes in land use, (4) decadal-scale changes in climate in terms of precipitation recharge, (5) construction of drainage structures and changes to drainage practices, (6) construction and operation of controlled freshwater canals, (7) changes to groundwater use (changes to the operation and capacity of nearby wellfields), and (8) management and operation of mining practices west of the CCS.

A number of regional and localized human-induced factors have contributed to the migration of the saltwater interface over time (see Sections 3.5.1.1 and 3.5.2.1). FPL’s modeling analysis indicates that operating the CCS with salinity in excess of 35 PSU is currently the single largest contributor to changes (movement) in the location of the saltwater interface, as measured by the areal extent of the saltwater interface. Changes were measured based on the average change in the area of salinity greater than 0.05 PSU west of the CCS over the thickness of the Biscayne aquifer. More specifically, the modeling indicates that approximately 46 percent of the change in areal extent of the saltwater interface is attributable to hypersaline conditions in the CCS. Other than CCS hypersalinity, the modeling indicates that the next-most-influential locational factors are changes in climate (23 percent), followed by the construction and operation of controlled freshwater canals over the last 50 to 60 years (14 percent) (Tetra Tech 2018).

Routine and Potential Inadvertent Releases of Radionuclides and Other Pollutants to Groundwater

Nuclear power plants and other industrial facilities can impact groundwater quality by inadvertent releases of chemicals and petroleum products. Nuclear power plants can also impact groundwater quality through inadvertent releases of radionuclides, predominantly tritium, from spills and leaks from plant systems (NRC 2013a).

Nuclear power plants routinely release dilute concentrations of radionuclides, including tritium, in effluents (liquid and gaseous wastes) subject to compliance with NRC regulations. These authorized releases are closely monitored by the plant operator and reported to the NRC, with reports made available to the public on the NRC’s Web site, in the form of annual radioactive effluent release reports. Similarly, potential impacts to the public and to the environment from plant radiological releases are evaluated and reported by NRC licensees in radiological environmental operating reports, which are also publicly available. Routine radiological effluents from Turkey Point Units 3 and 4, and FPL’s associated effluent management and radiological environmental monitoring programs are described in Section 3.1.4.1, “Radioactive Liquid Waste Management,” Section 3.1.4.2, “Radioactive Gaseous Waste Management,” and Section 3.1.4.5, “Radiological Environmental Monitoring Program,” of this SEIS.

Normal operation of Turkey Point Units 3 and 4 results in the release to the CCS of monitored and permitted effluents containing tritium. Evaporation of CCS water results in tritium being

released to the atmosphere as a component of the water vapor, while radioactive decay (with a half-life of approximately 12 years) limits the buildup of tritium concentrations over time in the waters of the CCS (NRC 2016a).

In 2018, based on the results of FPL's radiological environmental monitoring, the average tritium concentration in the waters of the CCS was 7,434 pCi/L, with a maximum level of 21,851 pCi/L in November 2018 at site T08 (on the southern shore of the CCS, west of Grand Canal Bridge) (FPL 2019c). Of the four supplemental surface water stations in FPL's REMP, the NRC staff assumes that this sampling location may be generally representative of ambient tritium levels in the CCS. For 2017, the average tritium concentration in the CCS was 10,391 pCi/L, with a maximum level of 24,483 pCi/L at site T08 in March 2017 (FPL 2018k). For comparison, the EPA's primary drinking water standard for tritium is 20,000 pCi/L (40 CFR 141.66). Section 3.5.1.4, "Adjacent Surface Water Quality and Cooling Canal System Operation," further describes surface water quality in the CCS. As discussed there and as shown in Figure 3-22, "Extent of Tritium in the Deep Interval of the Biscayne Aquifer in the Vicinity of the Turkey Point Site, 2017–2018," tritium concentrations decrease significantly with increasing distance from the site, with levels substantially below the EPA's primary drinking water standard.

Because the canals comprising the CCS are not lined, CCS water, which contains tritium, migrates into the groundwater of the underlying Biscayne aquifer (FPL 2018f, NRC 2016a). Within the highly permeable aquifer, diffusion is rapid and groundwater flow is relatively fast (FPL 2016h). Thus, tritium occurs in underlying groundwater in the Biscayne aquifer beneath the CCS as well as in adjacent areas of the aquifer that are beneath the Turkey Point, Units 3 and 4 plant complex.

An additional consideration for the presence and transport of tritium is that engineered backfill (crushed, compacted limestone) was used around the Turkey Point plant complex (nuclear island) with some structures extending to a depth of 45 feet (14 m) below land surface. On a more localized basis, subsurface structures may alter or impede the direction of groundwater flow (FPL 2016h). Further, it is likely that subsurface structures and the engineered backfill itself offer a preferential flow path for water containing tritium to reach the Biscayne aquifer beneath portions of the Turkey Point plant complex. Any inadvertent releases of liquids containing radioactive constituents from plant facilities and systems, spills, or leaks can also migrate to underlying groundwater.

Potentiometric surface (water table elevation) maps developed for the Turkey Point site and reviewed by the NRC staff show that groundwater flow across the main plant complex is tidally influenced in the shallow, intermediate, and deep monitored portions of the Biscayne aquifer. FPL states in its "Updated Final Safety Analysis Report, Turkey Point Units 3 & 4," that there is a rather consistent tidal influence on groundwater elevations across the Turkey Point site of 0.2 to 0.5 ft (0.06 to 0.15 m) maximum tidal fluctuation (FPL 2016h). Groundwater flow paths are further influenced by plant operations where operation of the circulating water system and associated intake and discharge canals generally produces radial flow across the plant site at shallow and intermediate depths during most tidal regimes. This appears to generally occur due to groundwater mounding on the discharge canal (west) side of the plant complex and a depressed water table surface on the intake (east side) of the plant. In contrast, during both low and high tides, groundwater flow in the deep portion of the Biscayne aquifer is more unidirectional, from south to north and from east to west (FPL 2018f).

FPL participates in the NEI 07-07, "Industry Ground Water Protection Initiative" (NEI 2007). The initiative identifies actions to improve management and response to instances in which the

inadvertent (i.e., unplanned, uncontrolled, and unmonitored) release of radioactive substances may result in low but detectable levels of nuclear power plant-related radioactive materials in subsurface soils and water. The initiative identifies those actions necessary for the implementation of a timely and effective groundwater protection program along with acceptance criteria to demonstrate that the objectives have been met.

Since 2010, FPL has maintained a radiological environmental sampling and analysis program for Turkey Point that meets the recommendations of NEI 07-07. FPL performs groundwater monitoring at 28 onsite locations around Turkey Point Units 3 and 4 for potential inadvertent radioactive releases through groundwater pathways at the Turkey Point site in accordance with site procedures. FPL collects samples on at least a quarterly basis or more frequently if deemed necessary (FPL 2018f). Some of the groundwater monitoring locations have multiple (two or three) depths.

FPL states in its environmental report that it has detected tritium (a beta-emitting radioactive isotope of hydrogen) in groundwater. Since establishing its NEI 07-07 program, FPL has detected no Turkey Point-related gamma-emitting isotopes (FPL 2018f).

The NRC staff reviewed FPL's annual effluent release and radiological environmental operating reports for a 5-year period (2014 through 2018). The NRC staff found that FPL has documented seven actual or potential inadvertent releases to groundwater from Turkey Point, Units 3 and 4 operations. FPL completed appropriate corrective actions and entered the events and actions taken in the plant corrective action program, as appropriate. The list below summarizes these unplanned liquid releases:

- March 19, 2014, the Turkey Point Unit 3E demineralizer fill valve leaked a small amount of reactor coolant system (RCS) water (i.e., about 1 gallon (3.8 L)) on the roof of the auxiliary building, which was promptly cleaned up.
- August 24, 2014, the Turkey Point Unit 4 refueling water storage tank (RWST) purification pump (4P209) drain line leaked 5 gallons (19 L) of reactor coolant system water to the ground. Corrective actions included increasing sampling of Turkey Point monitoring wells (i.e., PTN-MW-8S, PTN-MW-9S, and P-94-4) for gamma and tritium activity.
- September 23, 2014, the Unit 4 demineralizer resin fill valve and flange located on the roof of Turkey Point Unit 4 auxiliary building leaked about 50 gallons (190 L) of reactor coolant system water. Rainfall caused the leak to migrate to the storm drain system. Contamination included 0.132 Ci of cobalt-58 and 0.019 Ci of tritium. Corrective actions included monitoring the southeast storm drain as well as nearby monitoring wells (i.e., PTN-MW-8S and PTN-MW-9S).
- October 14, 2014, the Turkey Point Unit 4 RWST valve 4-804 B leaked during the transfer of water from the refueling cavity. Approximately 1 L of reactor coolant system water was released to the ground before the leak was stopped. Corrective actions included monitoring nearby wells (i.e., PTN-MW-8S, PTN-MW-9S, and P-94-4) monthly for gamma activity and tritium.
- November 11, 2014, a pump casing leak occurred from the 4P209 Unit 4 RWST purification pump. The total leak volume was not estimated but the pump leak was estimated to be approximately 60 drops per minute until the pump was shut down upon

discovery of the leak. Corrective actions included increasing sampling of wells in the vicinity (i.e., PTN-MW-8S, PTN-MW-9S, and P-94-4) to monthly for gamma activity and tritium.

- July 26–September 15, 2015, a leak of intake cooling water contaminated with sodium-24 from the Turkey Point Unit 3 component cooling water (CCW) system occurred. Chemical inhibitors that contain sodium become activated when the CCW travels into a neutron field. The Turkey Point Unit 3 CCW heat exchanger, cooled by intake cooling water, developed a leak, and CCW, which contained activated sodium, leaked into the tube side of the heat exchanger. The release continued until the heat exchanger was plugged. The intake cooling water discharges into the mixing basin on the western side of plant, which is the same area used as discharge for the regular liquid radwaste tanks. The total release volume was approximately 4,828 gal (18,280 L). The total estimated quantity of sodium-24 released was 6.19 micro-Curies.
- October 5, 2017, the Unit 4D demineralizer resin fill valve and flange located on the roof of the Unit 4 auxiliary building showed signs of leakage to the roof. The southeast storm drain (in the likely flow path) was sampled and showed activity. The calculated dose from the estimated activity released was determined to be well below site Offsite Dose Calculation Manual limits.
- January 21, 2018, a spill occurred on the roof of the auxiliary building when radiation workers removed the protective cover on the Unit 4D demineralizer resin fill isolation valve. The spill volume was about 0.5 gal (1.9 L) and reached the storm drain system after initial response efforts were ineffective. Corrective actions included a complete replacement of the demineralizer rubber diaphragm valve with a new ball valve with stainless steel internals in order to eliminate valve leakage. The frequency of sampling of the surrounding monitoring wells (e.g., PTN-MW-8S) was increased to weekly, and no significant impact to groundwater was observed following the release.
- On August 8, 2018, weepage was identified from two RWST locations on the Unit 4 drain line. Soil was sampled around the drain location and identified residual radioactivity. The calculated activity released resulted in an estimated dose of 3.32×10^{-6} mrem, well below Offsite Dose Calculation Manual limits (FPL 2013a, 2015a, 2015b, 2016i, 2016j, 2017d, 2017e, 2018j, 2018h, 2018k, 2019b, 2019c).

Table 3-6 summarizes the latest available radiological groundwater monitoring results that FPL has reported to the NRC for representative well locations, with the results compared to historical maximum observed concentrations. Monitoring well locations are depicted in Figure 3-27 below.

Table 3-6 Representative Groundwater and Storm Drain Monitoring Results for Tritium, Turkey Point Groundwater Protection Program, 2018 (in PicoCuries per Liter)

Well Number	First Quarter^(a,b)	Second Quarter^(a,b)	Third Quarter^(a,b)	Fourth Quarter^(a,b)	Previous 4-Year Maximum Concentration (Year-Quarter)
P-94-4	661	894	719	488	3,060 (2015-Q3)
PTN-MW-1S	<MDC	NA	<MDC	NA	80.5 (2014-Q3)
PTN-MW-1I	244	NA	433	NA	700 (2016-Q1)
PTN-MW-1D	1,540	NA	1,270	NA	2,310 (2015-Q3)
PTN-MW-4S	2.74	2.04	No result	<MDC	1,930 (2014-Q2)

Well Number	First Quarter^(a,b)	Second Quarter^(a,b)	Third Quarter^(a,b)	Fourth Quarter^(a,b)	Previous 4-Year Maximum Concentration (Year-Quarter)
PTN-MW-4I	23	2,420	2,310	<MDC	3,570 (2016-Q1)
PTN-MW-4D	2,830	2,840	2,790	<MDC	3,840 (2015-Q4)
PTN-MW-7S	936	818	603	643	1,070 (2015-Q4)
PTN-MW-7I	1,930	1,400	1,440	<MDC	2,400 (2015-Q3)
PTN-MW-7D	15.4	168	No result	178	2,370 (2014-Q1)
PTN-MW-8S	3,020	566	1,860	3,390	13,600 (2017-Q4)
PTN-MW-9S	690	775	403	943	798 (2017-Q4)
PTN-MW-11S	181	782	743	387	804 (2014-Q3)
PTN-MW-12S	755	541	907	757	1,140 (2016-Q1)
Northeast Storm Drain	545	150	473	7,470	9,990 (2017-Q4)
Southeast Storm Drain	Dry	769	858	822	13,000 (2017-Q4)
West Storm Drain	5,150	2,080	2,110	1,180	12,000 (2017-Q4)
CRF Storm Drain	No result	No result	Dry	Dry	<MDC


Notes: CRF=central receiving facility; MDC=minimum detectable concentration, value is less than the analytical MDC or less than 300 pCi/L tritium; NA=not applicable, as sampling not conducted or required for sampling period.

S, I, and D refer to approximate monitored depth below land surface: Shallow 20 feet (6 m), Intermediate 40 feet (12 m), and Deep 60 feet (18 m).

(a) FPL reports all results in pCi/L.

(b) FPL generally collects quarterly samples in January, April, July, and October.

Sources: FPL 2015b, FPL 2016j, FPL 2017d, FPL 2018k, FPL 2019c.



Source: Modified from FPL 2018k (Note: Cross-Sections Omitted)

Figure 3-27 Turkey Point Groundwater Protection Initiative Monitoring Well Locations

Based on these results, the NRC staff finds no apparent increasing trend in tritium concentration or a pattern indicating either a new inadvertent release or persistently high tritium concentrations that might indicate an ongoing inadvertent release from Turkey Point facilities to groundwater. In 2017 and 2018, the highest observed levels in Turkey Point groundwater were 13,600 pCi/L and 3,390 pCi/L, respectively, at well PTN-MW-8S. This location is near the Turkey Point Unit 3 refueling water storage tank, shown in Figure 3-27. Elevated tritium levels were also detected in storm drain locations, which likely represents tritium concentrations in the CCS during periods when storm drain outfalls are occasionally below the tidal mark in the canal system (FPL 2018k). Nevertheless, all results are less than the limits prescribed by FPL's Offsite Dose Calculation Manual (FPL 2013a) for the plant, which for tritium is 30,000 pCi/L, as groundwater at the site is not designated for potable use.

At the time of the NRC's onsite environmental audit in 2018 for the subsequent license renewal, FPL was preparing a site conceptual model as part of an effort to identify and characterize groundwater flow and the occurrence and migration of tritium at the FPL property, including locations such as: Turkey Point Units 1, 2, and 5, the diesel storage tank area, and portions of the intake and discharge canals. Other objectives of this effort include evaluation of potential human, ecological, or environmental receptors of tritium that might have been released to the groundwater and development of recommendations for additional investigations and long-term monitoring (FPL 2018h).

With respect to unplanned, non-radiological releases, FPL reported no accidental spills or similar releases of nonradioactive substances, including petroleum products, at Turkey Point over the past 5 years, nor any associated notices of violation issued to FPL for such releases (FPL 2018f, FPL 2018h). The NRC staff's review of available information and regulatory databases found no documented instances of accidental spills of chemical or petroleum products to groundwater that resulted in a regulatory action over the last 5 years.

3.5.2.3 Groundwater Use

Section 2.2.2 of NUREG-1437, Supplement 5 describes water use and sanitary wastewater management for Turkey Point operations (NRC 2002c). As indicated in that section, water for Turkey Point process makeup (e.g., primarily demineralizer water makeup), potable water, and fire protection water uses was obtained from the Miami-Dade Water and Sewer Department (MDWSD). Sanitary wastewater was being processed in an onsite treatment plant and discharged to groundwater (Biscayne aquifer) through an onsite injection well (i.e., IW-1). That section further states that no surface water or groundwater was being withdrawn for use as makeup water for the CCS at that time. The NRC staff incorporates the information in NUREG-1437, Supplement 5, Section 2.2.2 (NRC 2002c: 2-5, 2-17, 2-18), here by reference. The following discussion presents new information regarding groundwater use for Turkey Point operations, beyond the information in NUREG-1437, Supplement 5.

In southeast Florida and in Miami-Dade County where Turkey Point is located, groundwater aquifers are used both as a water supply and as a reservoir for wastewater disposal via deep well injection. Nearly all of the potable water supplied by the MDWSD to southern Miami-Dade County comes from the Biscayne aquifer (MDC 2018b, NRC 2016a) (see Section 3.5.2.2, "Groundwater Quality"). The exception is water from the County's Alexander Orr, Jr. water treatment plant, which mixes some brackish groundwater from the Upper Floridan aquifer with Biscayne aquifer groundwater (NRC 2016a).

In 2015, groundwater withdrawals in Miami-Dade County totaled 409.2 mgd (1.55 million m³/day) from freshwater sources and 40.5 mgd (153,300 m³/day) from saline sources. Withdrawals for public water supply comprised the largest use including 338.9 mgd (1.28 million m³/day) from freshwater sources and 13.0 mgd (49,200 m³/day) from saline sources. Withdrawals for power generation included 1.28 mgd (4,850 m³/day) from freshwater sources and 27.5 mgd (104,000 m³/day) from saline sources (USGS 2018a).

The MDWSD continues to supply potable water to Turkey Point for drinking and fire protection water uses. Sanitary wastewater disposal continues to be accomplished through an FDEP permitted injection well, as well as by septic tanks (FPL 2018f).

FPL completed installation of a replacement water treatment plant in 2017, which is designed to supply pure/ultrapure (demineralized) water for Turkey Point uses. The new system can treat either municipally supplied water (i.e., from the MDWSD) or groundwater from the Upper Floridan aquifer. The use of groundwater is intended to reduce FPL's use of MDWSD water by 1 mgd (3,800 m³/day) and associated costs. Wastewater from the new treatment plant is discharged to the CCS (FPL 2018f). Section 3.10.4.3, "Public Water Supply," of this SEIS describes the MDWSD public water supply system, and Section 3.1.5, "Nonradioactive Waste Management Systems," describes nonradioactive waste management systems that support Turkey Point Units 3 and 4 operations.

Currently, FPL uses onsite groundwater withdrawn from the Biscayne and Upper Floridan aquifers for a variety of applications in support of Turkey Point operations, as well as for other activities conducted on the Turkey Point site unrelated to Units 3 and 4. These principal uses include withdrawals of brackish water from the Upper Floridan aquifer for freshening of the CCS, operation of a recovery well system and associated underground injection well to extract and dispose of hypersaline groundwater from the Biscayne aquifer, operation of Biscayne aquifer marine wells that withdraw salt water to supplement CCS freshening, and operation of Upper Floridan Aquifer site production wells for various onsite uses (e.g., Unit 5 usage).

Table 3-7 summarizes FPL's reported groundwater withdrawals associated with these well systems for the period from January 2015 through December 2018, except as noted. In 2018, FPL's groundwater withdrawals from the Biscayne aquifer totaled about 4,630 mgd (17.5 million m³/year), or approximately 12.7 mgd (48,700 m³/day). For the Upper Floridan aquifer, withdrawals totaled approximately 7,397 mgd (28.0 million m³/year), or approximately 20.3 mgd (76,800 m³/day).

Table 3-7 Groundwater Withdrawals at the Turkey Point Site

Year	Withdrawals (mgy)			
	UFA Site Production Well System (PW-1, PW-3, PW-4)	Biscayne Aquifer Marine Well System (PW-1 (test), SW-1, and SW-2)	UFA Freshening Well System (F-1, F-3, F-4, F-5, F-6)	Biscayne Aquifer Testing and Recovery Well System (RW-1–RW-10)
2015	3,339.6	6,065	0.0	0.0
2016	2,237.2	0.0	1,051.6	1,326 ^(a)
2017	2,361.9	4,031.7	4,771.8	4,912.1 ^(a)
2018	2,761.8 ^(b)	0.0 ^(c)	4,634.9 ^(d)	4,630.01 ^(e)

Key: mgy=million gallons per year, UFA=Upper Floridan aquifer.

Note: Some reported values have been rounded. To convert million gallons per year (mgy) to million cubic meters (m³), divide by 264.2.

^(a) Withdrawals associated with hypersaline extraction and the deep well injection program, using four interim production/extraction wells located in the CCS, which began operations on September 28, 2016.

^(b) Production well system withdrawals for calendar year 2018 compiled from pumpage report data (SFWMD 2019a).

^(c) Marine wells were not operated during the period January through June 2018 (FPL 2018p).

^(d) Total calendar year 2018. Freshening well system withdrawals for the period January 2018 through September 2018 (FPL 2018p), supplemented by 4th quarter 2018 pumpage report data (SFWMD 2019a).

^(e) Total calendar year 2018. Hypersaline recovery well operations for the period January 2018 through September 2018, including operation of four demonstration (interim production/extraction) wells until May 7, 2018, followed by startup of recovery well system wells RW-1 through RW-10, which began full-scale operations on May 15, 2018 (FPL 2018p). Supplemented with 2018 4th quarter pumpage report data (SFWMD 2019b).

Sources: Compiled from FPL 2017b, FPL 2018h, FPL 2018i, FPL 2018o, FPL 2018p, SFWMD 2019a, SFWMD 2019b.

The nature of these withdrawals and the applicable regulatory requirements governing them are further described below.

Turkey Point Site Water Supply Systems

Water for cooling and process makeup water for Turkey Point Unit 5 is obtained from Upper Floridan aquifer site production wells PW-1, PW-3, and PW-4, depicted in Figure 3-28. These wells were commissioned in February 2007 (FPL 2018f). The wells are authorized under FPL's modified site certification and associated conditions of certification for the Turkey Point site. The wells range in depth from 1,242 to 1,247 feet (378.6 to 380.1 m), each with a pump capacity of 5,000 gpm (18,900 L/min) (State of Florida Siting Board 2016, FDEP 2016b). The 2016 Conditions of Certification specifically authorizes the withdrawal of 14.06 mgd (53,200 m³/day) of groundwater from the upper production zones of the Upper Floridan aquifer for cooling water for Unit 5 and process water for Units 1, 2, 3, 4, and 5 (FDEP 2016b). In March 2018, FPL began using approximately 1.1 mgd (4,200 m³/day) of groundwater from the

Upper Floridan aquifer site production wells as makeup water to the pure/ultrapure (demineralized) makeup water treatment system for Turkey Point Units 3 and 4 primary and secondary system uses. This usage replaced approximately 0.65 mgd (2,500 m³/day) of potable water that had been supplied by the MDWSD from the Newton Wellfield (FPL 2018h).



Source: Modified from FPL 2017b

Figure 3-28 Location of Groundwater Production Wells on the Turkey Point Site

FPL completed installation of three marine wells in the 2015 timeframe (i.e., wells PW-1 (test), SW-1, SW-2) to provide water for salinity reduction in the CCS (i.e., CCS freshening) (FPL 2018f, FPL 2018m). These wells are located on the Turkey Point peninsula and withdraw from the upper portion of the Biscayne aquifer (Figure 3-28). Consequently, the marine wells withdraw saltwater (Golder Associates 2016). Before being converted to a production well in late 2014 and early 2015, PW-1 was originally installed in 2009 as a 30-inch (76-cm) diameter test well for evaluation of a radial collector well system for proposed new reactors, Turkey Point Units 6 and 7 (FPL 2018m). Well PW-1 has a total depth of 46 feet (14 m), with an open borehole from 22 to 46 feet (6.7 to 14.0 m) below the casing (HDR Engineering 2009). It is equipped with a 7,000-gpm (26,500-L/min) pump (FPL 2018m). Marine wells SW-1 and SW-2 are 36-inches (91-cm) in diameter. The two wells are completed to total depths of 56 and 55 feet (17.1 and 16.8 m), respectively, with the lower 30 feet (9.1 m) of each well terminating in an open borehole. Each of these wells has a 12,500-gpm (47,300 L/min) rated capacity pump (FPL 2018m). Together, the three wells have a combined production capacity of approximately 45 mgd (170,300 m³/day) (FPL 2018f). Notwithstanding this nominal production capacity, the total water volume that can be withdrawn and conveyed to the intake canal area is limited by considerations associated with measurement of the ultimate heat sink temperature and compliance with the technical specifications in the Turkey Point, Units 3 and 4 operating licenses. Specifically, the total flow must be less than or equal to 23,400 gpm (88,600 L/min) when only one Turkey Point unit is operating and 41,600 gpm (157,500 L/min) when both Units 3 and 4 are operating (FPL 2018m).

Operation of the marine wells does not require a groundwater consumptive use permit from the SFWMD because saltwater is not regulated by the State (FPL 2018f). In general, users of seawater, or reclaimed water, are not required to obtain water use permits (SFWMD 2015). The water withdrawn from the marine wells has an average salinity of around 36 PSU (FPL 2017b). Historically, the salinity of marine well water has ranged from about 34 PSU to nearly 40 PSU with chloride concentrations ranging from approximately 20,000 to 23,000 mg/L (FPL 2016f). FPL has used the wells during periods of peak CCS salinity to moderate salinity rise (FPL 2018f). As stipulated under the 2015 Consent Agreement (MDC 2015a) between FPL and Miami-Dade County, the marine wells may only be used to lower salinity in the CCS under “extraordinary circumstances.” As a result, FPL reports that the wells are used in response to extraordinary circumstances or upset recovery to support regulatory requirements (FPL 2018f, FPL 2018m).

In 2016, FPL installed five additional production wells (F-1, F-3, F-4, F-5, and F-6) to provide water from the Upper Floridan aquifer for use in freshening the CCS (Figure 3-28). As previously described, the freshening wells are authorized under FPL’s modified site certification and associated conditions of certification for the Turkey Point site, which permit a total withdrawal of 14 mgd (53,000 m³/day) for salinity reduction (State of Florida Siting Board 2016, FDEP 2016b). The wells are artesian in nature (i.e., require no pumping) and flow is conveyed directly into the CCS. The 20-inch (51-cm) diameter wells range in depth from 1,000 to 1,250 feet (304.8 to 381 m) (FDEP 2016b, FPL 2018f). Each well is authorized to have a maximum flow of 2,500-gpm (9,460 L/min) (FDEP 2016b).

As described in Section 3.5.2.2, “Groundwater Quality,” in May 2018, FPL completed and began operation of a recovery well system to meet the groundwater remediation objectives specified in the 2015 Consent Agreement (MDC 2015a) with Miami-Dade County and the 2016 Consent Order with the FDEP (2016a). The system consists of 10 hypersaline groundwater recovery (extraction) wells (designated RW-1 through RW-10) completed in the Biscayne aquifer and one deep injection well (DIW-1) for disposal of hypersaline groundwater (Figure 3-25). These wells

replaced four demonstration wells that FPL used for hypersaline groundwater recovery testing from September 2016 through April 2018.

The 24-inch (61-cm) recovery wells are each drilled to a total depth of 110 feet (33.5 m) and are cased to a depth of 70 feet (21 m) below land surface. Each recovery well is equipped with a 1,042-gpm (3,900-L/min) electric pump, giving the well system a combined extraction capacity of 15 mgd (56,700 m³/day) (SFWMD 2017a). Each extraction well pump discharge is fitted with backflow prevention, a magnetic flow meter, a pressure transducer, a pump discharge pressure transmitter, sample tap, and an air release valve. Each well is also equipped with a water quality monitoring station. The wells are operated with programmable logic controllers and variable frequency driven well motor pump sets, and they are controlled and continuously monitored by remote secure radio communication telemetry to a main control building located near the deep injection well. The wells are connected in parallel by 14-inch (36-cm) diameter piping which runs to a 28-inch (71-cm) header that conveys the extracted hypersaline groundwater to deep injection well DIW-1. A total of about 9.5 mi (15 km) of pressure-rated piping is used in the conveyance system (FPL 2018h). Recovery well operations are permitted under an SFWMD-issued individual water use permit (Permit No. 13-06251-W) (FPL 2018f, SFWMD 2017a). The permit specifies a maximum monthly withdrawal allocation of 465 million gallons (1.76 million m³) (SFWMD 2017a).

The deep injection well DIW-1 discharges extracted hypersaline water to the Boulder Zone at a depth of approximately 3,200 feet (975 m). DIW-1 is constructed of concentric piping (casing strings) ranging from 64-inch (163-cm) diameter steel casing in the upper interval to 33 feet (10 m) below land surface, 24-inch (61-cm) diameter steel casing to 2,985 feet (910 m) below land surface, and followed by an 18-inch (46-cm) diameter liner to a depth of 2,975 feet (907 m) below land surface. The liner tubing is fiberglass reinforced pipe with a fluid filled annulus. The total depth of the well borehole is 3,230 feet (984.5 m) below land surface (FDEP 2013).

The deep injection well DIW-1 is paired with a dual-zone monitoring well (DZMW-1), which is completed in the Floridan aquifer with upper and lower monitoring zones at 1,450 to 1,490 ft (442 to 454 m) below land surface and 1,860 to 1,905 feet (567 to 581 m) below land surface (FDEP 2013). Operation of DIW-1 is authorized under FDEP Permit No. 293962-002-UC (FPL 2013, FDEP 2018d). The maximum permitted injection rate for DIW-1 is 10,826 gpm (41,000 L/min), or 15.59 mgd (59,000 m³/day), and the well is required to be periodically tested for injectate confinement (FDEP 2013).

The Boulder Zone is located in the Lower Floridan aquifer and is overlain by a confining layer that retards upward migration of wastewater (FPL 2018f). The FDEP permits FPL and others to discharge treated sewage and other wastes through injection wells into the Boulder Zone. All Boulder Zone underground injection wells must be permitted and monitored by the FDEP underground injection control program. As an example, the Miami-Dade Water and Sewer Department's South District Wastewater Treatment Plant located approximately 9 mi (14 km) north of the Turkey Point site disposes of municipal wastewater through as many as 13 deep injection wells into the Boulder Zone (NRC 2016a).

Other Water Supply Wells

While the Biscayne aquifer is the principal source of potable water supplied by the Miami-Dade Water and Sewer Department (see Section 3.10.4.3, "Public Water Supply"), as discussed in Section 3.5.2.2, "Groundwater Quality," the Biscayne aquifer is not a source of potable water in

the vicinity of the Turkey Point site. Other than FPL-owned water wells, described above, there are no potable water wells (drawing from either the Biscayne or Floridan aquifer systems) within the Turkey Point site boundary.

There are no registered groundwater supply wells within a 2-m (3.2-km) band of the Turkey Point site boundary (FPL 2018f). Relative to the Turkey Point site, the nearest mapped water supply wells are located about 5 mi (8 km) west of the western boundary of the CCS and are used to support mining operations (FDOH 2018a).

As for public water supply sources, the nearest wells are located about 6 mi (10 km) from the northwest corner of the CCS and approximately 7 mi (11 km) from the center of the Turkey Point plant complex. These wells are located at Newton Field (i.e., the Newton Wellfield) and are operated by Miami-Dade County (see Figure 3-17) (FDOH 2018a, MDC 2006, MDC 2018c, NRC 2016a).

Potable water supply for the Florida Keys comes from Biscayne aquifer wells and an Upper Floridan aquifer well located west of Florida City at the Florida Keys Aqueduct Authority's J. Robert Dean Water Treatment Plant. These facilities are located approximately 9.5 mi (15 km) west, northwest of the western boundary of the CCS (FDOH 2018a, FCAA 2019a, MDC 2006, MDC 2018c, NRC 2016a). The authority also maintains two seawater desalination facilities located in the Florida Keys that can be used in emergency situations to meet potable water needs (FCAA 2019a).

As required by the Safe Drinking Water Act of 1974 and in accordance with applicable Federal and State regulations and programs, Miami-Dade County as well as the Florida Keys Aqueduct Authority are responsible for providing necessary treatment of source water to potable (drinking water) standards and to protect water sources from contamination through wellhead protection and related programs (40 CFR 141, 40 CFR 143, FAC 62-528, FAC 62-521, MDC 2006). In addition, Miami-Dade County and the Florida Keys Aqueduct Authority have implemented measures to address saltwater intrusion (encroachment) (described in Section 3.5.2.2) and the effects of the CCS on water supplies, which include monitoring, mitigation, and adaptation (FCAA 2016, FCAA 2019, McThenia et al. 2017, MDC 2019a).

3.6 Terrestrial Resources

This section describes the terrestrial resources of the affected environment, including the surrounding ecoregion. The terrestrial resources include plant and animal species, vegetative communities, and important habitats present on or near the Turkey Point site. This section also describes important species and habitats that potentially may be present on or near the Turkey Point site. Plants and animals federally listed as endangered or threatened are discussed in Section 3.8, "Special Status Species and Habitats."

3.6.1 Vegetative Communities

The Turkey Point site is located on the western edge of Biscayne Bay and lies within the Mangrove and Coastal Glades physiographic province (McPherson and Halley 1996). This area includes a broad band of wetlands at or near sea level that is often flooded by tides or freshwater runoff. The region's ecology is directly tied to the natural seasonal hydrologic fluctuations. The NRC staff's EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a), Section 2.4.1.1 and Tables 2-2 and 2-3 describe the physiographic province, the general ecology of the Turkey Point site, and the characteristics of

various habitats on and near the Turkey Point site. Section 2.4.1.1 of NUREG-2176 (NRC 2016a) also summarizes the results of vegetation surveys of the Turkey Point site through 2011. The NRC staff incorporates the above information from NUREG-2176, Section 2.4.1.1 and Tables 2-2 and 2-3 into this SEIS by reference (NRC 2016a: 2-76 to 2-77; Tables 2-2 and 2-3).

3.6.2 Marsh, Mangrove, and Tree Island Semiannual Monitoring

Since 2010, FPL has commissioned Ecology and Environment, Inc. to perform ongoing, semiannual ecological monitoring of the Turkey Point site and surrounding environment as a requirement of the FDEP's Conditions of Certification in connection with the Turkey Point extended power uprate and the SFWMD's Fifth Supplemental Agreement. With respect to the terrestrial environment, Ecology and Environment monitors marsh, mangrove, and tree islands to characterize and observe changes in ecological characteristics over time. Researchers monitor a total of 32 20-m x 20-m (66-ft x 66-ft) plots (16 marsh, 4 tree island, and 12 mangrove) along 12 transects (6 marsh and 6 mangrove). Within each plot, 1-m x 1-m (3.2-ft x 3.2-ft) and 5-m x 5-m (16-ft x 16-ft) subplots have been designed to measure changes in woody species and the herbaceous community, respectively. Six plots (four marsh and two mangrove) serve as reference plots. Ecology and Environment began vegetation monitoring in October 2010, prior to the Turkey Point extended power uprate. During each survey, researchers measure the percent cover, species diversity, plant height, and biomass within each plot as well as other factors that may indicate changes in the health of the vegetation and habitat. Ecology and Environment surveyed vegetation four times each year (in February, May, August, and October) through 2013. Since 2013, FPL (2018o) has maintained the same methodology but has reduced ecological monitoring frequency, and tree island plots are now only monitored for porewater. Since that time, ecological monitoring has continued as follows:

- marsh plots: quarterly
- mangrove plots: annually
- tree island plots: semiannually (porewater only)

FPL's (2012a) report, "Turkey Point Plant Comprehensive Pre-Uprate Monitoring Report, Units 3 & 4 Uprate Project," describes FPL's ecological monitoring methodology in detail.

Marsh Monitoring

Sawgrass (*Cladium jamaicense*) marshes are the most common type of freshwater wetland near Turkey Point and within FPL's ecological monitoring plots. This type of marsh experiences flooding for most of the year. The relative abundance of sawgrass compared to other species tends to be positively correlated with both hydroperiod length (or time in which the area is flooded) as well as water depth during the hydroperiod (UF undated, Foti et al. 2012). Sawgrass thrives in harsh physiological conditions, including flooding and deep water, that few other plants can tolerate (Brown et al. 2006). Sawgrass stands grow so densely that few other species can successfully establish in the limited remaining space. For these reasons, plant diversity is generally low within sawgrass marshes.

Following sawgrass, the next most common plant species in nearby freshwater marshes is spikerush (*Eleocharis cellulose*). Within FPL's ecological monitoring plots, species diversity generally ranges from one to three plant species per plot (FPL 2012a, FPL 2014b, FPL 2016a,


FPL 2016b, FPL 2017a, FPL 2018o), which is typical for southern Everglades sawgrass marshes (Childers et. al. 2006, Foti et al. 2012).

To examine the characteristics of the freshwater marshes on and near the Turkey Point site, the NRC staff used FPL's monitoring data to evaluate several ecological metrics over time. These metrics include sawgrass percent cover, sawgrass average height, and sawgrass live biomass, among others, over the available data period of October 2010 through November 2018. The discussion below includes five freshwater marsh transects: F1 through F4 are test transects and lie adjacent to the CCS, and F6 is the reference transect and lies west of the CCS. The staff omitted transect F5 because this transect is dominated primarily by red (*Rhizophora mangle*) and white (*Laguncularia racemosa*) mangrove, and sawgrass is not present there.

Sawgrass Percent Cover. Percent cover is an ecological indicator of what species are dominating an area. It is expressed as a percent of a unit of area. Percent cover reflects the amount of soil, water, and nutrients that a species can use to create biomass. As part of FPL's ecological monitoring efforts, researchers record sawgrass percent cover by cover class (e.g., 0-1 percent, 2-5 percent, 6-25 percent, 26-50 percent, 51-75 percent, and 76-100 percent). From 2010 through 2018, all freshwater marsh transects (F1 through F4 and F6) within the study area consistently exhibited between 2 to 25 percent sawgrass cover with only small seasonal changes (FPL 2012a, FPL 2012c, FPL 2013c, FPL 2014e, FPL 2015c, FPL 2016d, FPL 2017f, FPL 2018s, FPL 2019f). Notably, plot F1-1 within transect F1 experienced a complete die-off of sawgrass in fall 2017. Researchers attributed the die-off to the storm surge associated with Hurricane Irma, which made landfall in Southern Florida in September 2017 (FPL 2018o). By May 2018, sawgrass within the F1 transect had begun recovering, and cover class was recorded as 0 to 1 percent within this plot (FPL 2018o). Researchers reported similar results in this plot in November 2018 (FPL 2019f). Within the F1 transect as a whole, FPL (2019f) reported cover to be 5.8 percent.


Sawgrass Average Height. Plant height, when compared across sites, can be a useful measure of whether local ecological conditions are inhibiting or promoting growth. Within the study area, sawgrass in freshwater marsh transects has exhibited seasonal fluctuations in height. Greater heights are generally observed in fall and winter than in spring and summer. From October 2010 through February 2012, average sawgrass height within all transects (test and reference) decreased. Sawgrass height has fluctuated ever since without showing a consistent upward or downward trend. As explained above, plot F1-1 experienced a complete die-off of sawgrass in fall 2017. By May 2018, sawgrass within this plot had begun to recover, and the newly regrown sawgrass within the F1 transect was of greater height than pre-hurricane values within the same transect. Figure 3-29 depicts average sawgrass height by transect from October 2010 through November 2018.

Sawgrass Live Biomass. Live biomass is a measure of the mass of living or recently dead biological material. For plants, live biomass is expressed as dry weight per unit of area. Biomass can be an indicator of ecological health and potential productivity of an area. Within the study area, sawgrass live biomass in test and reference transects has fluctuated throughout the available data period with no consistent upward or downward trend. More recently, live biomass decreased in August and November 2016, increased by February 2017, and remained at similar or higher levels in May 2017. The plot F1-1 die-off is reflected in the sharp decline in biomass for transect F1 in November 2017. However, by August 2018, biomass recovered to within the range of levels observed between 2015 and 2016. Figure 3-30 depicts average sawgrass biomass by transect from October 2010 through November 2018.



Sources: FPL 2012a, FPL 2012c, FPL 2013c, FPL 2014e, FPL 2015c, FPL 2016d, FPL 2017f, FPL 2018s, FPL 2019f

Figure 3-29 Sawgrass Average Height in Freshwater Marsh Transects, 2010-2018



Sources: FPL 2012a, FPL 2012c, FPL 2013c, FPL 2014e, FPL 2015c, FPL 2016d, FPL 2017f, FPL 2018s, FPL 2019f

Figure 3-30 Sawgrass Average Live Biomass in Freshwater Marsh Transects, 2010-2018

Other Ecological Metrics. In addition to the ecological metrics described above, FPL samples freshwater marsh sawgrass within the study area for annual net primary productivity, sclerophylly (a measure of leaf hardness or toughness), and leaf nutrient and stable isotopic composition. FPL also samples marsh porewater for conductance, temperature, and nutrients (nitrogen, ammonia, and phosphorus). FPL's reports for the available data period show data that are generally consistent since monitoring began with no clear upward or downward trend or differences among transects that can be attributed to proximity of transects to the CCS. FPL's ecological monitoring data suggest that the observed changes and fluctuations within freshwater marshes near Turkey Point are attributable to landscape-scale environmental factors, such as hydroperiod length, overall water depth, and storm surges, and that proximity to the CCS does not noticeably influence marsh ecology. Additionally, the observed fluctuations in sawgrass height and live biomass suggest a high degree of natural variability influenced by multiple environmental parameters.

FPL's (2018o) 2018 annual monitoring report describes the results of ecological monitoring performed from June 1, 2017, through May 31, 2018. The staff incorporated data from this monitoring report as well as data available on FPL's Electronic Data Management System (FPL 2019f) for the remainder of 2018 (i.e., June 1, 2018, through December 31, 2018) into the above discussion on freshwater marsh monitoring. Data from 2018 support the NRC staff's previous conclusion that the CCS does not have a discernable ecological impact on the surrounding areas and that there is no clear evidence of CCS water in the surrounding marsh and mangrove areas from a groundwater pathway (FPL 2018o). Although FPL found some ecological changes during the reporting period, these changes were seasonally and meteorologically driven. For instance, as explained above, one freshwater marsh plot (F1-1) experienced a complete die-off of sawgrass in connection with Hurricane Irma, which made landfall in Southern Florida in September 2017. This plot began exhibiting recovery during subsequent sampling events. As discussed in the next section below, mangroves continued to exhibit overall stable structure and composition in 2018.

Mangrove Monitoring


Red mangrove dominates the scrub mangrove habitat near Turkey Point and within FPL's ecological monitoring plots. Red mangrove forests tend to have low plant diversity due to the dominance of red mangrove and because few species have adapted to grow in the physically demanding saline environment within which these forests form. White mangrove and black mangrove (*Avicennia germinans*) are also present, but to a much lesser degree.

To examine the characteristics of the mangrove habitat on and near the Turkey Point site, the NRC staff used FPL's monitoring data to evaluate several ecological metrics over time. These metrics include mangrove percent cover, mangrove average height, and mangrove live biomass, among others, over the available data period of October 2010 through November 2018. The discussion below includes six mangrove transects: M1 through M5 are test transects and lie adjacent to the CCS to the north, east, and south; M6 is the reference transect and lies south of the CCS.

Red Mangrove Percent Cover. From 2010 through 2018, percent red mangrove cover in mangrove transects has remained consistent and has exhibited neither rapid declines nor rapid growth. Most plots exhibit 6 to 25 percent red mangrove cover. Plots M1-1, M1-2, and M2-2 exhibit 26 to 50 percent red mangrove cover.

Red Mangrove Average Height. Scrub mangrove forests typically have trees of less than 5 ft (1.5 m) in height (Lugo and Snedaker 1974). Trees measured within the six mangrove transects are consistent with this classification. From 2010 through 2018, red mangrove height has remained consistent or increased slightly within all transects. This suggests that mangroves within the study area are slow-growing and that no noticeable die-off has occurred. Slow growth is typical in dwarf mangrove habitats because of nutrient limitations, increased salinities associated with reduced tidal flushing, and other stressors that contribute to harsh growing conditions. Figure 3-31a depicts average red mangrove height by transect from October 2010 through November 2018.

Red Mangrove Live Biomass. Within the study area, red mangrove biomass has fluctuated within most transects with no consistent increasing or decreasing trend over time. In its 2017 annual monitoring report, FPL (2017a) noted decreasing biomass in mangrove plots M1-2 and M3-2 over the previous 2 years, although percent cover and height have remained relatively consistent in these plots. In its 2018 report, FPL's (2018o) data indicate that biomass in plot




Sources: FPL 2012a, FPL 2012c, FPL 2013c, FPL 2014e, FPL 2015c, FPL 2016d, FPL 2017f, FPL 2018s, FPL 2019f

Figure 3-31a Red Mangrove Average Height in Mangrove Transects, 2010-2018


M3-2 increased over the most recent monitoring period. Thus, the 2-year decreasing trend may have been part of natural ecological variation within this plot. Biomass in plot M1-2, however, continued to decrease for a third year in 2018. FPL (2017a, 2018o) intends to continue monitoring these plots in the future. The reference mangrove plots (M6-1 and M6-2), which are directly connected to Biscayne Bay, experienced a decrease in biomass (as well as height) following Hurricane Irma in 2017. The storm surge and associated winds likely impacted these sites more significantly than other mangrove plots that have fringe mangrove forests protecting them from the shoreline. FPL (2018o) also observed spatial variation in biomass among mangrove plots. For instance, plots M1-1 and M2-2 exhibit the highest biomass because of the density at which mangrove trees are growing (approximately 700 individuals per 25 m² (270 ft²)) (FPL 2018o). Conversely, plot M6-1, which has some of the tallest trees among the mangrove plots, has the third lowest biomass due to the low tree density (24 individuals per 25 m² (270 ft²)) (FPL 2018o). These differences highlight the natural landscape variations present in the local ecosystem. Figure 3-31b depicts average red mangrove live biomass by transect from October 2010 through November 2018; Figure 3-32 depicts red mangrove live biomass in plots M1-2 and M3-2 over the same period.

Other Ecological Metrics. As within freshwater marsh transects, FPL samples mangroves within the study area for annual net primary productivity, sclerophylly, and leaf nutrient and stable isotopic composition. FPL also samples mangrove porewater for conductance, temperature, and nutrients (nitrogen, ammonia, and phosphorus). FPL's reports for the available data period show data that are generally consistent since monitoring began with no clear upward or downward trend or differences among transects that can be attributed to the proximity of transects to the CCS.



Sources: FPL 2012a, FPL 2012c, FPL 2013c, FPL 2014e, FPL 2015c, FPL 2016d, FPL 2017f, FPL 2018s, FPL 2019f

Figure 3-31b Red Mangrove Average Live Biomass in Mangrove Transects, 2010-2018



Sources: FPL 2012a, FPL 2012c, FPL 2013c, FPL 2014e, FPL 2015c, FPL 2016d, FPL 2017f, FPL 2018s, FPL 2019f

Figure 3-32 Red Mangrove Average Live Biomass Within Two Red Mangrove Plots (M1-2 and M3-2), 2010–2018

FPL’s (2018o) 2018 annual monitoring report describes the results of ecological monitoring performed from June 1, 2017, through May 31, 2018. The staff incorporated data from this monitoring report as well as data available on FPL’s Electronic Data Management System (FPL 2019f) for the remainder of 2018 (i.e., June 1, 2018, through December 31, 2018) into the above discussion on mangrove monitoring. Data from 2018 support the NRC staff’s previous conclusion in the draft supplemental environmental impact statement (DSEIS) that the CCS does not have a discernable ecological impact on the surrounding areas and that there is no clear evidence of CCS water in the surrounding marsh and mangrove areas from a groundwater pathway (FPL 2018o). Overall, mangroves continued to exhibit stable structure and composition during the 2018 reporting period with the exceptions of the recent decreasing trend in biomass in one plot (M1-2).

Tree Island Monitoring

FPL monitors tree island plots semiannually for porewater only. Researchers sample porewater for chloride, sodium, nutrients (nitrogen, ammonia, and phosphorus), and tritium. Section 3.5.1.4, “Adjacent Surface Water Quality and Cooling Canal System Operation,” of this

SEIS describes porewater results. FPL's monitoring program has not detected evidence of any impacts from the CCS on soil porewater quality via the groundwater pathway (FPL 2014b, 2016a, 2017a, 2018f, 2018o).

CCS Dewatering

In 2017, the South Florida Water Management District (SFWMD) issued water use Permit No. 13-06251-W, which allows FPL to recover and extract hypersaline water within and around the CCS (SFWMD 2017a). To support this water extraction, called dewatering, FPL began constructing a full-scale recovery well system in June 2017. Dewatering has the potential to impact wetland growth because it removes water from an ecosystem where greater water depth and longer hydroperiods are directly correlated with vegetative growth and species composition (UF undated, Foti et al. 2012). As part of its permitting process, the SFWMD modeled drought conditions (up to a 1-in-10-year drought) and determined that a maximum drawdown of less than 0.3 feet (9.1 cm) of water could occur west and north of the CCS under drought conditions during operation of the wells (SFWMD 2017a). This maximum drawdown limit also applies to onsite and offsite wetlands located west of the CCS. The L-31E Canal would provide some buffering of the drawdown area because the canal stores excess rain water. In issuing the water use permit, the SFWMD (2017a) determined that the risk of adverse effects to wetlands as a result of the authorized withdrawal of the recommended allocation would be minimal.

3.6.3 Wildlife

Southern Florida lies at the southern tip of a temperate landmass, and its subtropical climate supports a wide variety of ecosystems and wildlife, including approximately 350 bird, 50 reptile, 40 mammal, and 15 amphibian species (NPS 2015b). Several tropical species inhabit Florida's mangroves and warm waters, while temperate species migrate south from other areas in the United States. Furthermore, productive wetlands provide a source of refuge and foraging grounds for numerous wildlife and bird species. Section 2.4.1.1 of the NRC staff's EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a) describes wildlife and avian studies conducted at and near Turkey Point in 1972 and from 2005 through 2009. The NRC staff incorporates the above information into this SEIS by reference (NRC 2016a: pages 2-79 to 2-80).

On May 23, 2016, FPL conducted bird and reptile surveys within the vicinity of the Turtle Point remnant canal and Barge-Turning Basin water quality improvement projects. FPL observed one reptile species, the American crocodile (*Crocodylus acutus*), and 6 bird species: common nighthawk (*Chordeiles minor*), brown pelican (*Pelecanus occidentalis*), double-crested cormorant (*Phalacrocorax auritus*), anhinga (*Anhinga anhinga*), mockingbird (*Mimus polyglottis*), and rusty blackbird (*Euphagus carolinus*) (FPL 2016c). The NRC staff (NRC 2016a) previously identified these species as occurring at the Turkey Point site in the EIS for the Turkey Point Units 6 and 7 combined licenses.

From December 5–7, 2016, FPL conducted its CCS characterization study (EAI 2017), which primarily focused on sampling the CCS for fish and invertebrates. FPL also recorded any observations of birds near and within the vicinity of the CCS. In total, FPL documented 13 bird species, many of which used the CCS as a foraging ground for fish during the study. Observed birds included snowy egrets (*Egretta thula*), little blue herons (*Egretta caerulea*), tricolored herons (*Egretta tricolor*), reddish egrets (*Egretta rufescens*), great egrets (*Ardea alba*), roseate spoonbills (*Platalea ajaja*), wood storks (*Mycteria americana*), American white pelicans (*Pelecanus erythrorhynchos*), a yellow-crowned night heron (*Nyctanassa violacea*), a double-

crested cormorant, an American avocet (*Recurvirostra americana*), great blue herons (*Ardea herodias*), belted kingfishers (*Megaceryle alcyon*), and ospreys (*Pandion haliaetus*).

The NRC staff also reviewed the Florida Fish and Wildlife Conservation Commission's (FWCC) Florida Shorebird Database, which is a database of shorebird and seabird occurrences in Florida (FWCC 2018). The Florida Shorebird Database indicated that a breeding colony of least terns (*Sterna antillarum*), which are listed by the State of Florida as a threatened species in the State, occurs at Turkey Point. Least terns are discussed in further detail in Section 3.7.3.1, "State-Listed Species."

3.6.4 Important Species and Habitats

3.6.4.1 State-Listed Species

In accordance with Chapter 68A-27 of the Florida Administrative Code (FAC), the Florida Fish and Wildlife Conservation Commission oversees the State's Threatened and Endangered Species Conservation Program. This chapter of the FAC gives the FWCC the authority to list species as State-designated threatened species; to issue regulations necessary and advisable to provide for the conservation of Florida endangered and threatened species, which include federally listed endangered and threatened species and State-designated threatened species; and to prohibit anyone from taking a species, which includes activities that would harass, harm, pursue, hunt, shoot, wound, kill, trap, capture, or collect, or to attempt to engage in such conduct. Chapter 5B-40 of the FAC authorizes the Florida Department of Agriculture and Consumer Services to list plants as endangered, threatened, and commercially exploited.

Section 2.4.1.3 and Tables 2-14 and 2-15 of the NRC staff's EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a) describe the State-listed threatened or endangered species that may occur in Miami-Dade County, not including those species that are also federally listed. This information is incorporated here by reference (NRC 2016a: pages 2-97 to 2-109). The NRC staff reviewed the list of State threatened and endangered species within Miami-Dade County that are not federally listed (FNAI 2018) and determined that Tables 2-14 and 2-15 in NUREG-2176 included all listed species as of August 2018, except for the following, which the NRC staff here adds to the list of State-listed threatened or endangered species identified in NUREG-2176. The following species are all State-listed as endangered.

- sea rosemary (*Heliotropium gnaphalodes*)
- Florida shrub thoroughwort (*Koanophyllon villosum*)
- Florida Keys ladies'-tresses (*Mesadenus lucayanus*)
- star-scale fern (*Pleopeltis astrolepis*)
- pineland spurge (*Poinsettia pinetorum*)
- mucha-gente (*Xylosma buxifolia*)

Three additional species, Simpson's prickly apple (*Harrisia simpsonii*), Fahkahatchee ladies'-tresses (*Sacoila lanceolata* var. *Paludicola*), and Florida black bear (*Ursus americanus floridanus*), were included in NUREG-2176, Tables 2-14 and 2-15. However, these species are not State-listed as endangered or threatened as of August 2018 (FNAI 2018). Florida pine snake (*Pituophis melanoleucus mugitus*), Florida burrowing owl (*Athene cunicularia Floridaana*),

little blue heron, reddish egret, tricolored heron, American oystercatcher (*Haematopus palliatus*), roseate spoonbill, and black skimmer (*Rynchops niger*) were identified as species of special concern in Table 2-15 but are State-listed as threatened as of August 2018. The change in classification of these species therefore modifies the tables of State-listed threatened or endangered species identified in NUREG-2176.

Tables 2-14 and 2-15 in the EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) also describe whether the species has been observed at the Turkey Point site. Since the NRC staff published NUREG-2176, FPL has conducted two new ecological surveys (FPL 2016c, EAI 2017) as described in Section 3.7.3, “Aquatic Resources on the Turkey Point Site.” In its May 23, 2016, survey, FPL (2016c) did not observe any State-listed species other than the American crocodile, which is State-listed as endangered and federally listed as threatened. The crocodile is addressed in Section 3.8.1.2, “Federally Listed Species and Critical Habitats under U.S. Fish and Wildlife Service’s Jurisdiction,” of this SEIS. Ecological Associates, Inc., (EAI 2017) observed five State-listed species in the 2016 CCS Characterization Study, including wood stork (also federally listed), little blue heron (*Egretta caerulea*), tricolored heron, reddish egret, and roseate spoonbill. These five species had been previously observed at the Turkey Point site, as indicated in NUREG-2176, Table 2-15.

A colony of least terns nest on berms within the CCS (FPL 2018f). The FFWCC’s shorebird monitoring program suggests that this colony at the Turkey Point CCS is one of the largest ground-nesting colonies of least terns on the eastern coast of Florida between Key West and Melbourne and that this colony also maintains high rates of nesting success (FFWCC 2016). To minimize disturbances to this nesting colony, FPL installed warning signs surrounding the berms to alert site personnel that least terns are in the vicinity. FPL also limits boat traffic near the colony during nesting season. FPL expects to continue these activities during the subsequent license renewal period of extended operation (FPL 2018g).

3.6.4.2 Migratory Birds

The FWS administers the Migratory Bird Treaty Act (MBTA), which prohibits anyone from taking native migratory birds or their eggs, feathers, or nests. Regulations under the Migratory Bird Treaty Act define “take” as “to pursue, hunt, shoot, wound, kill, trap, capture, or collect, or attempt to” carry out these activities (Title 50, “Wildlife and Fisheries,” of the *Code of Federal Regulations* (50 CFR) 10.12, “Definitions”). The act protects a total of 1,007 migratory bird species (75 FR 9282). The FWS’s (2018a) online Information Planning and Consultation System tool identifies 35 migratory birds of concern that may occur on or near the Turkey Point site. Of those 35 migratory bird species, FPL (2018h) identified 11 species that have been observed onsite at Turkey Point. FPL (2018h) also noted that 23 additional bird species protected under the MBTA have been observed onsite, although they were not included in FWS’s (FWS 2018a) database list. While FPL has not implemented a formal monitoring or survey program for migratory birds, Table 3-8 describes the birds protected under the MBTA that are most likely to occur at the Turkey Point site based on a combination of the FWS’s database list and FPL survey data and incidental observation records. The table also identifies typical use of the Turkey Point site by species (e.g., resting, foraging, and breeding).

The FWS also administers the Bald and Golden Eagle Protection Act of 1940, as amended (16 U.S.C. 668 et seq.), which prohibits anyone from taking bald eagles (*Haliaeetus leucocephalus*) or golden eagles (*Aquila chrysaetos*), including their nests or eggs, without a permit issued by the FWS. The FWS (2018a) determined that bald eagles may occur and breed near the Turkey Point site throughout the year. FPL (2018g) has observed bald eagles using the Turkey Point site for resting, although the species is rarely observed onsite.

Table 3-8 Migratory Birds Protected under the Migratory Bird Treaty Act That Are Most Likely to Occur at Turkey Point

Scientific Name	Common Name	Frequency of Onsite Observations	Onsite Habitat Use
<i>Anhinga</i>	anhinga	occasionally	resting, foraging
<i>Ardea alba</i>	great egret	frequently	resting, foraging
<i>Ardea herodias</i>	great blue heron	frequently	resting, foraging
<i>Bubo virginianus</i>	great horned owl	rarely	resting, foraging, breeding
<i>Bubulcus ibis</i>	cattle egret	frequently	resting, foraging
<i>Butorides virescens</i>	green heron	frequently	resting, foraging, breeding
<i>Charadrius vociferus</i>	killdeer	frequently	resting, foraging, breeding
<i>Chordeiles minor</i>	common nighthawk	frequently	resting, foraging, breeding
<i>Circus hudsonius</i>	northern harrier	frequently	resting, foraging
<i>Crotophaga ani</i>	smooth-billed ani	rarely	resting, foraging
<i>Egretta caerulea</i>	little blue heron	frequently	resting, foraging
<i>Egretta rufescens</i>	reddish egret	frequently	resting, foraging
<i>Egretta thula</i>	snowy egret	frequently	resting, foraging
<i>Egretta tricolor</i>	tri-colored heron	frequently	resting, foraging
<i>Elanoides forficatus</i>	swallow-tailed kite	rarely	resting, foraging
<i>Empidonax</i> sp.	flycatcher	occasionally	resting, foraging
<i>Eudocimus albus</i>	white ibis	frequently	resting, foraging
<i>Falco peregrinus</i>	peregrine falcon	occasionally	resting, foraging
<i>Gavia immer</i>	common loon	rarely	unknown
<i>Haliaeetus leucocephalus</i>	bald eagle	rarely	foraging
<i>Megaceryle alcyon</i>	belted kingfisher	frequently	resting, foraging
<i>Megascops asio</i>	Eastern screech owl	occasionally	resting, foraging, breeding
<i>Melanerpes carolinus</i>	red bellied woodpecker	frequently	resting, foraging, breeding
<i>Mycteria americana</i>	woodstork	occasionally	resting, foraging
<i>Pandion haliaetus</i>	osprey	frequently	resting, foraging
<i>Patagioenas leucocephala</i>	white-crowned pigeon	frequently	resting, foraging
<i>Pelecanus erythrorhynchos</i>	American white pelican	frequently	resting, foraging
<i>Pelecanus occidentalis</i>	brown pelican	occasionally	resting, foraging
<i>Phalacrocorax auritus</i>	double-crested cormorant	frequently	resting, foraging
<i>Platalea ajaja</i>	roseate spoonbill	frequently	resting, foraging
<i>Sterna antillarum</i>	least tern	frequently	resting, foraging, breeding
<i>Thalasseus maximus</i>	royal tern	frequently	resting, foraging
<i>Tringa flavipes</i>	lesser yellowlegs	occasionally	resting, foraging
<i>Tyrannus dominicensis</i>	grey kingbird	frequently	resting, foraging

Source: FWS 2018a; FPL 2018h

Many other migratory birds occur in the region. For instance, the National Park Service (NPS 2017b) reports 213 bird species from Biscayne National Park. In comments on the NRC's draft SEIS, the National Park Service (NPS 2019b) stated that in addition to the species identified in the table above, the following migratory birds are also likely to occur on or near the Turkey Point site: Northern mockingbird (*Mimus polyglottos*), blue jay (*Cyanocitta cristata*), Northern cardinal (*Cardinalis cardinalis*), mangrove cuckoo (*Coccyzus minor*), yellow-billed cuckoo (*Coccyzus americanus*), black-bellied plover (*Pluvialis squatarola*), red knot (*Calidris rufa*), whimbrel (*Numenius phaeopus*), Western sandpiper (*Calidris maurii*), least sandpiper (*Calidris minutilla*), laughing gull (*Larus atricilla*), ring-billed gull (*Larus delawarensis*), great black-backed gull (*Larus marinus*), lesser black-backed gull (*Larus fuscus*), downy woodpecker (*Dryobates pubescens*), black-and-white warbler (*Mniotilta varia*), American redstart (*Setophaga ruticilla*) and black-throated blue warbler (*Setophaga caerulescens*). FPL (2014a; Table 2.4-1) reported observing many of these species during avifauna surveys in connection with Turkey Point Units 6 and 7, which included the Turkey Point property as well as existing and proposed transmission line corridors. Although lack of observation does not preclude species' occurrence, FPL (2014a, 2018f, 2018h) has not observed blue jays, ring-billed gull, great or black-backed gull, downy woodpecker, black-and-white warbler, or black-throated blue warbler on the Turkey Point site. The red knot, a federally listed species, is addressed in Section 3.8.1.2, "Federally Listed Species and Critical Habitats under U.S. Fish and Wildlife Service's Jurisdiction," of the SEIS.

3.6.4.3 Important Habitats

Sections 2.2.1.6, 2.4.1.2, and 2.4.1.3 of the NRC staff's EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a) describe several important terrestrial restoration efforts and habitats located within National Parks, preserves, and other federally owned, State-owned, County-owned, and privately-owned land. These include the following:

- Biscayne National Park, which provides mangrove and other important habitat to wildlife and over 200 species of birds, 21 of which are Federally listed as threatened or endangered (NPS 2018a) (see pages 2-10 and 2-79 to 2-80 in NUREG-2176 (NRC 2016a)).
- Everglades National Park, which encompasses approximately 1.5 million ac (607,000 ha) of wetlands, open water, and other important habitats for a variety of wildlife and birds (see pages 2-11, 2-80, and 2-110 in NUREG-2176 (NRC 2016a)).
- The Comprehensive Everglades Restoration Plan (CERP) was approved by Congress in 2000 to restore, preserve, and protect the south Florida wetlands ecosystem while providing for other water-related needs of the region. The area covered by this plan includes the entire Everglades ecosystem. This interagency effort is one of the largest ecosystem restoration efforts in the country and includes multiple smaller efforts, such as the Biscayne Bay Coast Wetlands project (NPS 2018a; see page 2-11 and 2-80 in NUREG-2176 (NRC 2016a)).
- South Dade Wetlands Project, also referred to as Model Lands, which is co-managed by Miami-Dade County's Department of Environmental Resources and the Southwest Florida Water Management System. These areas include over 20,000 ac (8,000 ha) of publicly owned conservation lands, including Miami-Dade County Environmentally Endangered Lands (DERM 2018). These wetlands serve as habitat and refuge for a variety of wildlife, including numerous federally listed and State-listed threatened and endangered species (see pages 2-10 and 2-133 in NUREG-2176 (NRC 2016a)).

- Everglades Mitigation Bank, which is a 13,000 ac (5,300 ha) expanse of freshwater and estuarine wetlands west and south of the Turkey Point CCS. FPL owns the Everglades Mitigation Bank and operates it as a commercial mitigation bank offering wetland habitat credits that can be purchased to offset regional wetland impacts (see pages 2-12 and 2-133 in NUREG–2176 (NRC 2016a)).

Additionally, the Audubon Society recognizes the Biscayne Bay region encompassing all areas off the coast of Miami-Dade County stretching east of North Miami Beach to southeast of Homestead as an Important Bird Area (Audubon 2019). The Audubon recognizes this area's ornithological significance because it supports many Neotropical migrant species, significant populations of federally listed and other special concern species, and a colonial waterbird rookery.

The NRC staff's EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG–2176) (NRC 2016a) identifies other important habitats that occur within the vicinity of the Turkey Point site, such as mangrove forests (pages 2-109 to 2-110), pine rockland (page 2-110), marl prairie (page 2-110), and wetlands (page 2-110). The NRC staff incorporates this information from NUREG–2176 into this SEIS by reference (NRC 2016a: pages 2-109 to 2-110). Federally listed and State-listed threatened or endangered species that have the potential to occur within these important terrestrial habitats are described in pages 2-84 through 2-109 of NUREG–2176 (NRC 2016a), which information is also incorporated by reference herein.

3.6.5 Invasive and Non-Native Species

Several invasive and non-native species occur at Turkey Point. Although FPL does not formally record the occurrence of such species, common invasive species on the Turkey Point site include Australian pine (*Casuarina equisetifolia*), beach naupaka (*Scaevola sericea*), Brazilian pepper (*Schinus terebinthifolius*), Burma reed (*Neyraudia reynaudiana*), and melaleuca (*Melaleuca quinquenervia*) (FPL 2018f). The Argentine black-and-white tegu (*Tupanimbis merianae*) and Burmese python (*Python molurus* ssp. *bivittatus*) have also been observed at Turkey Point (FPL 2018f). The invasive Argentine black-and-white tegu, an egg-eating lizard, is an omnivore with the potential to affect many species, including alligators and crocodiles, and is the subject of a multiagency control effort in the immediate vicinity of the Turkey Point site. The invasive Burmese python is a nonvenomous constrictor whose predation threatens a wide range of native wildlife, including songbirds, deer, and alligators. As described in Section 4.6.1.1, FPL (2018f) maintains a program to remove invasive species from the CCS on an annual basis.

3.7 Aquatic Resources

This section describes the aquatic resources of the affected environment, including the Southern Florida Coastal Plain Ecoregion, the CCS, Biscayne Bay, and Card Sound.

3.7.1 Southern Florida Coastal Plain Ecoregion

The Turkey Point site is located within the Southern Florida Coastal Plain ecoregion. This ecoregion is characterized by a hydrologically interconnected, slow-flowing network of wetland and aquatic systems, including ridge and slough landscapes, sawgrass plains, cypress and mangrove swamps, and coastal lagoons and bays. The Everglades, a subtropical wetland ecosystem that hosts a rich diversity of aquatic habitats and plant and animal species, comprise much of the ecoregion. The Florida Keys, barrier islands that extend along the extreme southern coast of the Florida Peninsula, protect estuarine bays and coves from the Atlantic

Ocean and create important spawning habitats. The Southern Florida Coastal Plain ecoregion is also known for the Florida reef, the only living coral reef tract in the continental United States.

Beginning in the early 1900s, the hydrology of the ecoregion has been highly altered by human activity to support agricultural and urban development. In 1948, Congress authorized the creation of the Central and Southern Florida Flood Control Project, one of the largest water management systems in the world. Through this project, a series of canals were created across Southern Florida to drain the land for flood control, water supply and retention, irrigation, and transportation. Subsequent land drainage resulted in the loss or conversion of a substantial portion of the original wetland system, reduced sheet flow dramatically, and created point-source discharge of freshwater into estuarine waters and coastal wetlands. The coastal areas of the ecoregion have also become highly populated and dense beachfront development is common. Nevertheless, a large portion of the ecoregion remains protected at the county, State, or Federal level and is managed to maintain and restore the region's unique and sensitive habitats. Section 2.4.2, "Aquatic Ecology," of the NRC staff's EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a) provides more detailed information on the Southern Florida Coastal Plain ecoregion, including anthropogenic alterations and other past changes to the environment. The NRC staff incorporates the NUREG-2176 descriptions of the ecoregion into this SEIS by reference.

3.7.2 Aquatic Resources near the Turkey Point Site

The region surrounding Turkey Point contains shallow subtropical estuarine and marine environments, including Biscayne Bay and its associated park and preserve; Florida Keys National Marine Sanctuary; Card Sound and Canal; the Everglades Mitigation Bank, Model Lands Basin, and Southern Glades Addition; as well as Everglades National Park and the Crocodile Lake National Wildlife Refuge.

Biscayne Bay is a shallow subtropical saline lagoon that extends the length of Miami-Dade County. A series of barrier islands belonging to the Florida Keys borders the eastern edge of the bay and separates the bay from the Atlantic Ocean. The mainland forms the western and northern borders of the bay. Connection between Biscayne Bay and the Atlantic Ocean is greatest north of Boca Chita Key. Ocean access is most restricted in the southern portion of the bay at Card Sound and Barnes Sound due to the presence of Key Largo and its associated barrier islands. The average depth of the bay is approximately 5 ft (1.5 m) at mean low water, and its maximum depth is approximately 13 ft (4.0 m). Salinity is highly influenced by rainfall and ranges from 24 to 44 PSU. Annual surface water temperatures range from 59 °F to 92 °F (15 °C to 33 °C). The bay's shallow depths and low spring tidal range (3 ft (0.9 m) maximum) result in a vertically well-mixed system with weak stratification.

Within the bay, Biscayne National Park encompasses 173,000 ac (70,000 ha) of water and coastal lands as well as 42 islands. The park is home to a large segment of the Florida reef, the only living coral reef tract in the continental United States. The park supports an immense array of wildlife, including more than 600 fish species, many of which are commercially and recreationally important, and 21 federally threatened or endangered species. Notably, the bay provides habitat for the federally listed Florida manatee (*Trichechus manatus latirostris*) (a subspecies of the West Indian manatee (*T. manatus*)), smalltooth sawfish (*Pristis pectinata*), American crocodile, and Johnson's seagrass (*Halophila johnsonii*) (FDEP 2017b). Johnson's seagrass is the first and only marine plant to be listed as threatened under the Endangered Species Act.

The Biscayne Bay Aquatic Preserve includes 67,000 ac (27,000 ha) of sovereign submerged lands managed by the FDEP’s Office of Coastal and Aquatic Managed Areas. The preserve runs the length of Biscayne Bay from the headwaters of the Oleta River down to Card Sound near Key Largo. The FDEP designated the waters within the Biscayne Bay Aquatic Preserve as Outstanding Florida Waters for waters worthy of special protection because of natural attributes. Under the Outstanding Florida Waters designation, the State cannot issue permits for direct discharges that would lower ambient water quality (FDEP 2017a).

Card Sound is a shallow bay south of the Turkey Point site with limited connection to the Atlantic Ocean. It lies wholly within the boundary of the Florida Keys National Marine Sanctuary. The mangrove forests surrounding Card Sound are part of the longest continuous stretch of mangrove remaining on the east coast of Florida and provide a source of food and refuge for approximately 70 percent of the region’s commercially and recreationally important marine species. Both Biscayne Bay and Card Sound are nursery areas for the spiny lobster (*Panulirus argus*). The State of Florida has designated the area from Cape Florida near Key Biscayne south to Card Sound as the Biscayne Bay-Card Sound Lobster Sanctuary.

Section 2.4.2 of the NRC staff’s EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG–2176) (NRC 2016a) describes Biscayne Bay, Card Sound, and other nearby aquatic resources in detail. The NRC staff incorporates those descriptions from NUREG–2176 into this SEIS by reference. In addition, see Section 3.7.4 of this SEIS for a detailed discussion of FPL’s semiannual monitoring of Biscayne Bay and Card Sound.

3.7.3 Aquatic Resources on the Turkey Point Site

Within the Turkey Point site, the primary aquatic environment is the cooling canal system (CCS). The CCS occupies an area that is approximately 2 mi (3.2 km) wide by 5 mi (8 km) long and includes 168 mi (270 km) of earthen canals that cover an effective water surface area of approximately of 4,370 ac (1,770 ha) and a total surface area of 5,900 ac (24 km²) (FPL 2018f, NRC 2002c). The CCS’s channels are about 200 feet (60 m) wide and range in depth from 1 to 3 feet (0.3 to 1 m) (FPL 2018f). FPL constructed the CCS to use as an industrial wastewater facility. For a description of the CCS operations, see Section 3.1.3, “Cooling and Auxiliary Water Systems,” in this SEIS.

The CCS has historically supported a variety of fish, mollusks, crabs, and submerged aquatic vegetation that are tolerant of shallow, subtropical, hypersaline environments such as sheepshead minnow (*Cyprinodon variegatus*) and several *Fundulus* species. FPL (2014a) reported that the species identified in Table 3-9 were present in the CCS as of November 2007. Because the CCS does not directly connect to any surface water body, aquatic organisms are unable to travel between the CCS and any other water bodies. Aquatic biota in the CCS are not accessible for recreational or commercial harvest because FPL controls the entirety of the CCS and does not allow the public to access it.

Table 3-9 Aquatic Species Reported from the Cooling Canal System, November 2007

Species	Common Name
Fish	
<i>Centropomus undecimalis</i>	common snook
<i>Cyprinodon variegatus</i>	sheepshead minnow
<i>Fundulus</i> spp.	killifish

Species	Common Name
<i>Gambusia</i> spp.	mosquitofish
<i>Megalops atlanticus</i>	tarpon
<i>Mugil</i> spp.	mullet
<i>Poecilia latipinna</i>	sailfin molly
<i>Strongylura</i> spp.	needlefish
Mollusks	
<i>Busycon contrarium</i>	lightning whelk
<i>Cerithium eburneum</i>	ivory cerith
<i>Isognomon alatus</i>	flat tree oyster
<i>Isognomon radiatus</i>	Lister's tree oyster
<i>Marisa cornuarietis</i>	giant rams horn
<i>Melampus bidentatus</i>	eastern melamphus
<i>Melongena corona</i>	Florida crown conch
<i>Tellin</i> spp.	tellin
Crustaceans	
<i>Cardisoma guanhumi</i>	great land crab
<i>Uca</i> spp.	fiddler crab
Submerged Aquatic Vegetation	
<i>Acetabularia</i> spp.	mermaid's wineglass (green algae)
<i>Batophora</i> spp.	green algae
<i>Caulerpa</i> spp.	green algae
<i>Ruppia maritima</i>	widgeon grass
Source: adapted from FPL 2014a	

Other onsite aquatic resources at Turkey Point include hypersaline mudflats, remnant canals, channels, dwarf mangrove wetlands, and open water. In June 2009, Tetra Tech NUS, Inc. (Tetra Tech 2009) conducted fish surveys throughout the Turkey Point property in both CCS and non-CCS waters. Sampling locations, which are depicted in Figure 3-33, included:

- mangrove wetland west of Turkey Point (TP-1)
- sawgrass marsh/mangrove community adjacent to Palm Drive (TP-2)
- south (TP-3A) and north (TP-3B) remnant canals
- a portion of the return canal (TP-4)
- shallow flats in the east-central part of the Turkey Point plant area (TP-5)
- a dead-end canal (TP-6)
- CCS north (TP-7)
- CCS south (TP-8)

During sampling, water temperatures ranged from 75.0 to 97.7 °F (23.9 to 36.5 °C), salinity was above 50 PSU at six sampling stations (TP-3A, TP-4, TP-5, TP-6, TP-7, and TP-8), and salinity was less than or equal to 1.5 PSU at two stations in sawgrass/mangrove habitats (TP-1 and TP-2) (Tetra Tech 2009). Tetra Tech biologists collected fish with 8-foot (2.4-m) cast nets, a 20-ft (6-m) -long minnow seine, and standard “Gee”-type galvanized minnow traps. Sampling yielded a total of 433 fish representing seven species. All but one of the fish collected were small-bodied, short-lived, schooling species representative of two families: the killifishes (family Cyprinodontidae) and the livebearers (family Poeciliidae). Sheepshead minnow was the dominant species; this fish species was present in seven of the eight sampling stations and represented 63 percent of the collection. Sailfin molly (*Poecilia latipinna*) and goldspotted killifish (*Floridichthys carpio*) were present at most of the sampling stations and represented 20.8 percent and 9.9 percent of collections, respectively. No fish were collected at TP-2, a sawgrass marsh/mangrove community adjacent to Palm Drive. All fish were of hardy species common to South Florida; no rare, unusual, sensitive, or protected species were present in collections. Table 3-10 identifies the collected species, relative abundances, and collection locations.

Table 3-10 Number and Relative Abundance of Fish Captured at Seven Locations on the Turkey Point Site, June 2009


Species	Common Name	Number Collected	Collection Locations
<i>Cyprinodon variegatus</i>	sheepshead minnow	273	all locations except TP-2
<i>Poecilia latipinna</i>	sailfin molly	90	all locations except TP-2, TP-5
<i>Floridichthys carpio</i>	goldspotted killifish	43	all locations except TP-1, TP-2
<i>Fundulus confluentus</i>	marsh killifish	15	TP-1
<i>Fundulus grandis</i>	gulf killifish	6	TP-1, TP-3, TP-7, TP-8
<i>Gambusia affinis</i>	mosquitofish	5	TP-1, TP-4
<i>Opsanus beta</i>	gulf toadfish	1	TP-4

Source: Tetra Tech 2009

Prior to 2010, the CCS environment was of low turbidity and contained low and stable nutrient levels. Widgeon grass (*Ruppia maritima*) beds covered over 50 percent of the system and were especially prominent in the southern sections of the CCS and in the eastern return canals. Seagrasses underwent annual periods of stress and recovery as CCS salinities cycled between greater than 50 PSU (stress) and less than 50 PSU (recovery). Despite the harsh environment, seagrass colonies remained relatively stable from year to year (FPL 2016k).

In 2010, the CCS began experiencing a pronounced ecosystem shift. The average salinity of the CCS increased, water quality and clarity began to degrade, and average surface water temperatures increased. Seagrass colonies began to die off due to salinity- and high temperature-related stress. By 2012, very few seagrass beds remained in the CCS. The subsequent decomposition of the seagrasses released a significant volume of nutrients into the CCS, and the increased nutrient levels facilitated algae blooms, which resulted in high turbidity and degraded water quality. Algae blooms remained local and isolated in 2011 and 2012. In 2013 and 2014, continuously elevated concentrations of algae were observed throughout the CCS. By 2016, no seagrasses remained in the CCS. The CCS currently operates as an

algal-based, phosphorus-limited system such that the algae life cycle primarily dictates the movement of nutrients in and out of the water column (FPL 2016k).



Source: Tetra Tech 2009, Figure 1

Figure 3-33 Turkey Point Site Fish Survey Sample Locations, June 2009

To address CCS water quality degradation and as a requirement of the 2016 FDEP Consent Order, FPL began implementing a Nutrient Management Plan (FPL 2016k) in 2016. The plan includes short- and long-term initiatives. One initiative is to reestablish seagrass meadows

within the CCS. FPL (2016k) states in its plan that a healthy seagrass population of approximately 50 percent of the surface water acreage would help balance and sequester the CCS's nutrient content. Seagrasses require non-turbid, clear water with near-ocean salinity levels (roughly 30 to 37 PSU). Given the current turbid, hypersaline, and phosphorus-limited conditions in the CCS, FPL is concentrating its efforts on removing or binding bioavailable phosphorus to reduce algae growth, which would in turn reduce nitrogen fixation, increase water clarity, and improve the conditions for re-establishment of seagrasses. FPL is currently investigating the direct application of flocculants into the CCS, treatment of CCS water in an external system, and the use of protein skimming methods to actively remove algae and nutrients. Once FPL reduces nutrients and lowers salinities, FPL will cultivate and plant seagrass beds within areas of the CCS with appropriate depth and substrate. As CCS conditions improve, some dormant seagrass seeds in the CCS may also germinate such that seagrasses may reemerge naturally. Once re-established, a healthy seagrass population will provide a significant mechanism for uptake and retention of nutrients, thus reducing nutrient concentrations in the water. Lower nutrient concentrations in the water will deter algal blooms and fewer algal blooms will lead to greater water clarity. FPL's Nutrient Management Plan sets a seagrass colonization target at 50 percent of the CCS water acreage. Section 3.5.1.4 describes the plan in more detail under the subsection titled, "Nutrient Management Plan for the Cooling Canal System."

In September 2018, FPL (2018r) implemented a field scale pilot test planting of widgeon grass at separate locations within the CCS to determine whether the system can support seagrass under current conditions. This species was selected due to its high salinity tolerance and because it was historically the dominant species of seagrass in the CCS. FPL pre-conditioned pilot plants to withstand high salinity and then mechanically planted them in the CCS. Prior to this planting, FPL had successfully completed several smaller scale plantings in the CCS and in test tanks. Based on the results of the pilot planting, FPL will consider additional test plantings.

To determine the presence, relative abundance, and distribution of fish, invertebrate, and seagrass populations currently within the CCS, FPL commissioned Ecological Associates, Inc. (EAI) to conduct a biological characterization study in December 2016 (EAI 2017). EAI established ten sampling stations within the CCS chosen to represent different benthic habitats, salinity gradients, and temperature regimes (see Figure 3-34). Seven stations were in the main CCS area, two were located in return canals, and one was located in a dead-end canal in the northern section of the system. EAI sampled fish and mobile invertebrates, benthic macroinvertebrates, and submerged aquatic vegetation.

To identify fish and mobile invertebrates, EAI performed cast net sampling on December 5, 2016, and minnow trap sampling on December 6 and 7, 2016. Cast net sampling targets large mobile organisms throughout the water column, while minnow trap sampling selectively targets small species at the top and bottom of the water column. EAI collected a total of 4,843 individuals of 4 taxa: sheepshead minnow, sailfin molly, eastern mosquitofish (*Gambusia holbrooki*), and mudflat fiddler crabs (*Uca rapax*). Cast net samples yielded 282 fish: 259 sheepshead minnow, 22 sailfin molly, and 1 eastern mosquitofish. All fish collected during cast netting were small (less than 45 mm (1.75 inch) standard length). Minnow traps yielded 4,547 fish and 14 crabs: 3,900 sheepshead minnow, 627 sailfin mollies, 20 eastern mosquitofish, and 14 mudflat fiddler crabs. Fish ranged from 10 to 60 mm (0.4 to 2.4 inch) standard length, and crabs ranged from 8 to 11 mm (0.3 to 0.43 inch) carapace length and 11 to 15 mm (0.43 to 0.59 inch) carapace width.



Source: EAI 2017, Figure 1

Figure 3-34 Cooling Canal System Characterization Survey Sample Locations, December 2016

Sheepshead minnow were abundant throughout the CCS and were found at all 10 sampling stations during the CCS characterization study. This species can live and successfully reproduce in high salinity waters (up to 147 PSU) and high temperatures (up to 109.4 °F (43 °C)) (Johnson 1974). Sailfin mollies were moderately abundant throughout the system. This species is also able to tolerate high salinities (up to 80 PSU), high temperatures (up to 104 °F (40 °C)), and low dissolved oxygen (Fischer and Schlupp 2009, Nordlie et al. 1992, Timmerman and Chapman 2004). Eastern mosquitofish were only found at 2 of the 10 sampling stations and are likely rare in the CCS as a whole. This species can also tolerate high

temperatures (up to 100.4 °F (38 °C)), hypersaline (up to 58.8 PSU) waters with low dissolved oxygen (Chervinski 1983, Specziar 2004). Mudflat fiddler crabs were captured incidentally with sampling methods not designed to capture crabs, so EAI (2017) did not make any conclusions regarding crab abundance in its CCS characterization study report. Nevertheless, mudflat fiddler crabs have also been documented as able to withstand high temperature, high salinity, and low dissolved oxygen conditions (Costa and Soares-Gomes 2015, Vernberg and Tashian 1959, Zanders and Rojas 1996). Meroplankton sampling would be required to conclusively determine whether mudflat fiddler crabs are actively reproducing in the CCS or whether individuals were present due to recruitment by immigration into the system. EAI (2017) found no evidence that the environmental conditions within the CCS were negatively affecting the growth or reproduction of the species captured, all of which tended to be heat- and salinity-tolerant species.

To identify benthic macroinvertebrates, EAI (2017) collected benthic mini-ponar grabs on December 6, 2016, which EAI subsequently processed in a laboratory. A total of 79 individuals of 3 taxa were identified. The polychaete *Capitella capitata* was the most common taxon collected followed by marine oligochaetes (Class Oligochaeta) and midge larvae (Family Chironomidae). EAI calculated benthic macroinvertebrate densities to range from 30 to 489 individuals per square meter at stations with organisms present. Evidence of relic gastropod and bivalve shells were also present at some stations; however, no live mollusk specimens were collected.

In addition to fish and benthic sampling, EAI (2017) used underwater video on December 5 and 6, 2016, along defined video transect surveys to search for living submerged aquatic vegetation (seagrasses). Widgeon grass, which was previously the predominant submerged aquatic vegetation type present in the CCS, can grow in waters ranging from 64.4 to 86 °F (18 to 30 °C), although temperatures above 73.4 to 77 °F (23 to 25 °C) have a negative influence on photosynthesis (Arnold et al. 2017). One study on the effect of salinity on the species determined that 8- to 12-week old plants could not tolerate salinities above 21,000 parts per million (ppm) (Mayer and Low 1970). This equates to approximately 21 PSU. During the CCS characterization study, EAI observed no seagrasses. Because water clarity was poor throughout the entire project area, EAI also scanned its benthic macroinvertebrate collections for living vegetation. No samples contained living vegetation. In its report, EAI attributed the lack of submerged aquatic vegetation to the CCS's turbid water conditions, high salinity, and high temperatures.

While differences in sampling methods and effort make definitive conclusions difficult to determine, the available information on the CCS aquatic community indicates that species diversity within the system has declined over time. Submerged aquatic vegetation is no longer present in the system, and many fish species reported as present in the system in 2007 and 2009 were not collected in 2016. The current aquatic community is of low diversity and includes only those species that can withstand hot, hypersaline waters with low dissolved oxygen and poor water clarity.

3.7.4 Biscayne Bay and Card Sound Semiannual Monitoring

Since September 2010, FPL has commissioned ongoing, semiannual ecological monitoring of the Turkey Point site and surrounding environment, including Biscayne Bay, as a requirement of the FDEP's Conditions of Certification in connection with the Turkey Point extended power uprate and the SFWMD's Fifth Supplemental Agreement. Ecology & Environment, Inc. conducted the most recently reported period of monitoring for Biscayne Bay in September 2017

and May 2018 (one fall and one spring event). Ecology & Environment, Inc. summarized and compared the results of this monitoring period with corresponding past results during the historical period of record. The results appear in the 2018 Turkey Point Plant Annual Monitoring Report (FPL 2018o). This section briefly summarizes the monitoring methods and the 2016-2017 results.

FPL performs aquatic ecological sampling in three locations adjacent to the CCS within Biscayne Bay and Card Sound (BB1, BB2, and BB3) and one reference site in Barnes Sound (BB4), which lies directly south of Card Sound (see Figure 3-35). Within each of the study areas, ecological conditions are monitored along two 2-km (1.2-mi)-long shore-parallel transects (designated “a” and “b” for each study area) that lie approximately 250 and 500 m (0.16 and 0.32 mi) from shore. Each transect is divided into eight 250-m (0.16-mi)-long segments. Researchers randomly selected a 1-m² (0.6-mi²) point along each of the eight segments during the initial September 2010 sampling event to be used as the permanent location for all future sampling events. Thus, ecological monitoring encompasses a total of 16 sampling points per study area and a total of 64 sampling points across all study areas. This sampling design is based on FPL’s State-approved monitoring plan (SFWMD 2009).

At each sampling location, submerged aquatic vegetation is surveyed and categorized according to the Braun-Blanquet Cover Abundance Index. Sediment depth and general physical and surface water parameters are collected. Turtle grass (*Thalassia testudinum*) blades are collected for laboratory nutrient analysis. In addition to quantitative data, divers also record qualitative characteristics of the benthic conditions surrounding each sampling point.

In the 2018 report, ecological monitoring findings were similar to those reported in previous annual monitoring reports. Ecology and Environment Inc.’s major findings were as follows (FPL 2018o).

- The marsh and mangrove areas are representative of the hydrologically modified or nutrient-limited communities found along the coastal fringe of south Florida.
- Data collected during the reporting period continue to support the conclusion that the CCS does not have an ecological impact on the surrounding areas, and there is no clear evidence of CCS water in the surrounding marsh or mangrove areas from a groundwater pathway. Rather, ecological changes observed during the reporting period are more seasonally and meteorologically driven.

The remaining subsections within this section provide additional information on FPL’s Biscayne Bay submerged aquatic vegetation monitoring data, trends, and results that led to the two bulleted conclusions above. Section 3.6.2, “Marsh, Mangrove, and Tree Island Semiannual Monitoring,” of this SEIS describes the results of marsh and mangrove monitoring surrounding the Turkey Point site. Section 3.5.1.4, “Adjacent Surface Water Quality and Cooling Canal System Operation,” describes Biscayne Bay surface water quality monitoring results.

Submerged Aquatic Vegetation Monitoring

Submerged aquatic vegetation includes rooted vascular plants that grow up to the water surface but not above it. In estuarine and marine waters, seagrass is the primary type of submerged aquatic vegetation. Seagrass is an important component of estuarine systems like Biscayne Bay because it provides habitat, shelter, and food for fish, shellfish, sea turtles, marine mammals, and other aquatic organisms. Seagrass adds dissolved oxygen to the water through

photosynthesis, and its leaves and roots help to stabilize the shoreline against erosion and protect it from storm surges. Seagrass also absorbs nutrients, which remain locked in plant biomass throughout the spring and summer; in the fall, as the plants die and then decay, they release nutrients back into the water when phytoplankton blooms are less of a concern. The EPA (2006) recognizes seagrass and other submerged aquatic vegetation as the hallmark of a healthy estuary.

Turtle grass, a dominant seagrass species in tropical and sub-tropical coastal waters, is generally the most abundant seagrass in Biscayne Bay. Due to its shallow depths, Biscayne Bay exhibits high seagrass cover and low-standing seagrass crop (FPL 2018o). Turtle grass can only effectively colonize areas with sufficient substrate depth for its roots to establish and gather nutrients. Higher salinity levels favor turtle grass and shoal grass (*Halodule wrightii*) (Lirman et al. 2014). Generally, when a seagrass bed experiences increased nutrient inputs, the system will first exhibit increased density of existing species followed by shifts in species composition followed by loss of seagrasses as nutrient inputs continue over time (Fourqurean et al. 1995) (see the subsection below titled, “Seagrass Leaf Nutrient Analysis” for more information on seagrass bed responses to ecological change).

FPL samples Biscayne Bay and Card Sound seagrasses biannually to monitor changes in cover and faunal composition over time and with distance from the CCS. Researchers collect samples at the established test (BB-1, BB-2, and BB-3) and reference (BB-4) locations (see Figure 3-35) at the beginning (April-May) and end (September-October) of the seagrass growing season. Researchers collect samples from a total of 32 points (8 points within two transects for each of the four sample locations). Researchers score percent cover at each sampling location according to the Braun-Blanquet Cover Abundance Index. Researchers also measure sediment depth within each scored quadrant and qualitatively assess ecological conditions surrounding each sampling point for the following:

- overall conditions (open, fairly open, moderately open, mostly covered, or uniform)
- presence or absence of seagrass, green algae (*Bataphora* spp.), and drift algae (sparse, sparse to moderate, or moderate to dense)
- amount of calcareous algae, sponges, and hard and soft corals (none, few, or many)
- substrate type (sandy, shell hash, silty, or rubble)


Finally, researchers collect turtle grass blades at two sample points along each transect and process them in a laboratory for nutrient analysis.



Source: E&E 2017, Figure 1.3-1


Figure 3-35 Biscayne Bay and Card Sound Semiannual Monitoring Ecological Transect Locations

Braun-Blanquet Cover Abundance scores are semi-quantitative. Each score represents a range in percent vegetative coverage (i.e., 1 = less than 5 percent, 2 = 5 percent to 25 percent, 3 = 25 percent to 50 percent, 4 = 50 percent to 75 percent, and 5 = greater than 75 percent). Thus, this metric is designed to provide a snapshot of the relative vegetative coverage present in a given area. Within Biscayne Bay, researchers choose random quadrants around sampling points, and thus, some natural variation in numbers is expected due to the patchy nature of submerged aquatic vegetation within the study area. Seagrass coverage is generally expected to exhibit seasonal fluctuations such that coverage is greater in the fall (the end of the seagrass growing season) than in the spring (the end of the quiescent period). However, because the Braun-Blanquet Cover Abundance scores encompass a large range in percent coverage, growth or increased seagrass coverage between sampling events might not always be reflected by a higher score (i.e., a doubling of coverage from 10 percent to 20 percent would not change the coverage score of 2, which represents 5-25 percent coverage).



Sources: FPL 2012a, FPL 2012c, FPL 2013d, FPL 2014f, FPL 2015d, FPL 2016m, FPL 2017g, FPL 2018t, FPL 2019h


Figure 3-36a Seagrass Mean Braun-Blanquet Coverage Abundance by Transect, 2010-2018



Sources: FPL 2012a, FPL 2012c, FPL 2013d, FPL 2014f, FPL 2015d, FPL 2016m, FPL 2017g, FPL 2018t, FPL 2019h

Figure 3-36b Macrophyte Mean Braun-Blanquet Coverage Abundance by Transect, 2010-2018

In its most recent annual monitoring report, FPL (2018o) reported mean total macrophyte scores ranging from 1.3 (BB2 and BB4 in fall 2017) to 2.7 (BB1 in spring 2018). Macrophytes include seagrass and attached macroalgae after drift red algae has been removed. Mean total seagrass scores ranged from 0.4 (BB2 in fall 2017) to 1.5 (BB1 in spring 2017). Most mean seagrass scores were within the range of values reported in previous monitoring reports with two exceptions. At BB1, the fall 2017 mean was lower than the previous minimum, and the spring 2018 mean was higher than the previous maximum. At BB3, the fall 2017 mean was also lower than the previous minimum. Mean total attached macroalgae (i.e., all species exclusive of drift algae) scores ranged from 1.3 (BB2, BB3, and BB4 in fall 2017) to 2.4 (BB1 in spring 2018), which all fell within the range of values reported in previous monitoring reports. Figure 3-36a, Figure 3-36b, and Figure 3-36c depict seagrass, macrophyte, and macroalgae cover (respectively) by transect from fall 2010 through fall 2018.



Sources: FPL 2012a, FPL 2012c, FPL 2013d, FPL 2014f, FPL 2015d, FPL 2016m, FPL 2017g, FPL 2018t, FPL 2019h

Figure 3-36c Macroalgae Mean Braun-Blanquet Coverage Abundance by Transect, 2010-2018

Seagrass Leaf Nutrient Analyses

Seagrass growth is controlled in part by the availability of nitrogen and phosphorus within the ecosystem. Seagrasses take up these nutrients through sediment porewater and use them for growth. Studies demonstrate that humans have altered nutrient availability in both groundwater and nearshore marine waters in the Florida Keys region (Lapointe et al. 1990; Lapointe and Matzie 1996). Altering nutrient levels can alter seagrass bed structure (Powell et al. 1989, 1991; Tomasko and Lapointe 1991; Fourqurean et al. 1995). For instance, at sampling sites with nutrient additions in the form of seabird defecation, Powell et al. (1989) observed increased areal leaf production, standing crop, and above-ground biomass within a Florida Bay seagrass community composed of turtle grass and shoal grass. Enriched turtle grass exhibited longer, wider blades, while enriched shoal grass exhibited longer blades and increased short shoot density.


Within Southern Florida and the Florida Keys, phosphorus is generally recognized as the limiting nutrient for primary production in nearshore seagrass communities (Ferdie and Fourqurean 2004; Fourqurean and Zieman 2001; Powell et al. 1989). This occurs because of the strong sorption affinity of phosphorus to limestone, corals, and other calcium carbonate mineral surfaces in this ecosystem, which reduces the amount of bioavailable phosphorus for plant uptake. However, seagrass communities can become nitrogen-limited if natural sources of phosphorus, such as from atmospheric deposition and decaying organic matter, paired with anthropogenic sources of phosphorus, such as from runoff and point source effluent discharges, supply more phosphorus than can be sequestered into sediments and porewater (Erftemeijer and Middelburg 1993; Erftemeijer 1994; Jensen et al. 1998). Nutrient concentrations in seagrass leaf tissue can indicate whether a system is nitrogen- or phosphorus-limited, which can provide valuable information in determining an ecosystem's nutrient loading and relative water quality.

During FPL's (2018o) fall 2017 sampling, turtle grass phosphorus content by study area ranged from 0.068 percent (BB1) to 0.086 percent (BB4) composition by dry weight. By transect, content ranged from 0.066 percent (BB1-a and BB2-a) to 0.090 percent (BB4-a). When compared within the same study areas, seagrass samples from two of the test areas (BB1 and BB2) exhibited phosphorus content values that were slightly higher than FPL's past reported maximum values. Phosphorus values in the third test area (BB3) remained below past reported maximum values within that study area. Phosphorus values in the reference study area (BB4) also exhibited values in 2017 that exceeded past reported values. The reference study area has historically exhibited the highest phosphorus content. None of the test study areas exceeded the reference study area's past reported values in 2017 samples. Additionally, all of FPL's reported phosphorus values to date are within the range of values reported in scientific literature for turtle grass in similar areas of Southern Florida. For instance, Fourqurean and Zieman (2001) sampled turtle grass at 504 randomly chosen locations within the Florida Keys over a 9-year period (1992-2000). In laboratory dry weight analyses, the authors determined that leaf phosphorus content ranged from 0.048 percent to 0.243 percent (mean = 0.113 percent). Figure 3-36d depicts seagrass leaf phosphorus content among all study areas from 2012 through 2017 and shows past value ranges for the Biscayne Bay study areas and the Florida Keys. Figure 3-36e, Figure 3-37f, Figure 3-37g, and Figure 3-37h depict seagrass leaf phosphorus content for individual study areas over the same period.

FPL (2018o) did not report leaf nutrient content values for nitrogen and carbon from 2017. In 2016, FPL (2017g) reported nitrogen content to range from 1.83 percent (BB1) to 1.93 percent (BB4) composition by dry weight. These values are within the range reported by Fourqurean and Zieman (2001) for the Florida Keys and lie close to the authors' observed mean. Fourqurean and Zieman (2001) reported leaf nitrogen content ranging from 0.88 percent to 3.96 percent (mean = 1.82 percent). FPL (2018o) reported total carbon in 2016 to range from 26.33 (BB1) to 27.95 (BB4). Fourqurean and Zieman (2001) reported turtle grass leaf carbon content to range from 29.4 percent to 43.3 percent (mean = 36.9 percent) in the Florida Keys.


In summary, the above information supports Ecology and Environment Inc.'s major findings, which are encapsulated in two bullets at the beginning of this section. Through the 2018 reporting period, FPL's submerged aquatic vegetation monitoring and seagrass leaf nutrient analyses have consistently demonstrated that marshes and mangroves near the Turkey Point site are characteristic of south Florida's hydrologically modified, nutrient-limited coastal fringe communities. None of the data that the NRC staff reviewed indicate observable ecological impacts from the CCS on the surrounding areas. The NRC staff also identified no clear evidence in the data of CCS water in the surrounding marsh or mangrove areas from a

groundwater pathway. Rather, observed ecological changes in marsh and mangrove monitoring plots appear to be seasonally and meteorologically driven.




Sources: FPL 2012a, FPL 2012c, FPL 2014b, FPL 2016a, FPL 2016b, FPL 2018o

Figure 3-36d Seagrass Leaf Phosphorus Content by Study Area with Reported Minimum and Maximum Values, 2012-2017




Sources: FPL 2012a, FPL 2012c, FPL 2014b, FPL 2016a, FPL 2016b, FPL 2018o

Figure 3-36e Seagrass Leaf Phosphorus Content at BB-1, 2012-2017




Sources: FPL 2012a, FPL 2012c, FPL 2014b, FPL 2016a, FPL 2016b, FPL 2018o

Figure 3-36f Seagrass Leaf Phosphorus Content at BB-2, 2012-2017



Sources: FPL 2012a, FPL 2012c, FPL 2014b, FPL 2016a, FPL 2016b, FPL 2018o

Figure 3-36g Seagrass Leaf Phosphorus Content at BB-3, 2012-2017



Sources: FPL 2012a, FPL 2012c, FPL 2014b, FPL 2016a, FPL 2016b, FPL 2018o

Figure 3-36h Seagrass Leaf Phosphorus Content at BB-4, 2012-2017

3.7.5 Additional Information on Aquatic Resources

Section 2.4.2, “Aquatic Ecology,” of the NRC staff’s EIS for Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a) provides more information on the following aspects of the aquatic environment:

- Turkey Point ecoregion (pages 2-119 to 2-122)
- Historical conditions and anthropogenic alterations to the Turkey Point ecoregion (pages 2-119 to 2-122)
- Detailed descriptions of aquatic resources on the Turkey Point site (pages 2-122 to 2-128; Table 2-18 and Table 2-19)
- Descriptions of the CCS and its water quality through 2016 (pages 2-123 to 2-126)
- Summaries of macroinvertebrate and seagrass surveys performed in near-shore areas of Biscayne Bay in 2008 and 2009 to support the Turkey Point 6 and 7 combined licenses application (pages 2-123 to 2-128 and 2-159 to 2-160; Table 2-18 and Table 2-20)
- Descriptions of nearby aquatic environments, which include Biscayne Bay and its associated park and preserve, Florida Keys National Marine Sanctuary, Card Sound and Canal, the Everglades Mitigation Bank, Everglades National Park, and the Crocodile Lake National Wildlife Refuge (pages 2-128 through 2-134; Tables 2-21 through 2-25)
- Ecologically, commercially, and recreationally important species (pages 2-136 to 2-142; Table 2-27)
- State-listed threatened or endangered species and species of concern (page 2-154 to 2-157; Table 2-30)
- Nonindigenous and invasive species (page 2-142)

The NRC staff incorporates this information from NUREG–2176 as indicated by the section, page, and table numbers above, into this SEIS by reference. The NRC staff did not identify any new or updated information relevant to the description of the aquatic environment beyond the additional information previously described in this section.

3.8 Special Status Species and Habitats

This section addresses species and habitats that are federally protected under the Endangered Species Act of 1973, as amended (16 U.S.C. 1531 et seq.) (ESA), the Magnuson–Stevens Fishery Conservation and Management Act of 1996, as amended (16 U.S.C. 1801 et seq.) (MSA), and the National Marine Sanctuaries Act of 1966, as amended (16 U.S. C. 1431 et seq.) (NMSA). Prior to taking a Federal action, such as the issuance of the proposed Turkey Point subsequent renewed licenses, the NRC has direct responsibilities under these statutes. The sections of this SEIS that describe terrestrial and aquatic resources (Sections 3.6 and 3.7, respectively) address species and habitats protected by other Federal statutes and the State of Florida under which the NRC does not have such responsibilities.

3.8.1 Federally Listed Species and Critical Habitats Protected Under the Endangered Species Act

The FWS and the NMFS jointly administer the ESA. The FWS manages the protection of, and recovery effort for, listed terrestrial and freshwater species, and the NMFS manages the protection of, and recovery effort for, listed marine and anadromous species. The following sections describe the Turkey Point action area and then consider separately those species that could occur in the action area under the jurisdiction of each Service.

3.8.1.1 Turkey Point Action Area

The implementing regulations for Section 7(a)(2) of the ESA define “action area” as all areas affected directly or indirectly by the Federal action and not merely the immediate area involved in the action (50 CFR 402.02, “Definitions”). The action area effectively bounds the analysis of federally listed species and critical habitats because only species and habitats that occur within the action area may be affected by the Federal action.

For the purposes of assessing the potential impacts of Turkey Point subsequent license renewal on federally listed species, the NRC staff considers the action area to consist of the Turkey Point site, including the CCS, as well as Biscayne Bay. While most potential impacts associated with the proposed action would be confined to the Turkey Point site, continued Turkey Point operations would necessitate occasional delivery of large parts and equipment by barge over the course of the subsequent license renewal term. Such deliveries would require barge travel through Biscayne Bay, which is why the NRC staff includes this waterbody in the Turkey Point action area for subsequent license renewal.

The NRC staff recognizes that while the action area is stationary, federally listed species can move in and out of the action area. For instance, a migratory bird species could occur in the Turkey Point action area seasonally as it forages or breeds. Thus, in its analysis, the NRC staff considers not only those species known to occur within the action area, but also those species that may passively or actively move into the action area. The staff then considers whether the life history of each species makes it likely to move into the action area where it could be affected by the proposed Turkey Point subsequent license renewal.

The following sections first discuss endangered or threatened species and critical habitats under the FWS’s jurisdiction followed by a discussion of those species under the NMFS’s jurisdiction.

3.8.1.2 Federally Listed Species and Critical Habitats under U.S. Fish and Wildlife Service’s Jurisdiction

The NRC staff used the FWS’s Environmental Conservation Online System (ECOS) Information for Planning and Conservation (IPaC) tool to determine species that may be present in the Turkey Point action area. The ECOS IPaC tool identified 42 federally listed endangered or threatened species under the FWS’s sole jurisdiction with the potential to occur in the Turkey Point action area. The IPaC tool also identified designated critical habitat for two of these species in the Turkey Point action area (FWS 2018b) (see Table 3-11). No proposed species, candidate species, or proposed or designated critical habitat occurs within the action area (FWS 2018b). Table 3-11 describes the habitat requirements, occurrence patterns, and Federal status for each of the 42 federally listed species under FWS’s sole jurisdiction.

In addition to these 42 species, the FWS (2018b) identified four species for which the FWS and NMFS have joint jurisdiction, including (1) the loggerhead sea turtle (*Caretta caretta*), (2) leatherback sea turtle (*Dermochelys coriacea*), (3) hawksbill sea turtle (*Eretmochelys imbricata*), and (4) the Atlantic Sturgeon (gulf Subspecies) (*Acipenser oxyrinchus (oxyrhyinchus) desotoi*). However, the proposed action would have no effect on the nesting habitat of sea turtles or other portions of the life cycle that are under FWS’s jurisdiction for these four species (NRC 2018g). The life history and impacts to species under the jurisdiction of NMFS are described in Sections 3.8.1.3, “Federally Listed Species and Critical Habitats under National Marine Fisheries Service’s Jurisdiction,” and Section 4.8.1.1, “Federally Listed Species and Critical Habitats Protected Under the Endangered Species Act,” of this SEIS.

Table 3-11 Federally Listed Species under U.S. Fish and Wildlife Service Jurisdiction

Species	Common Name	Habitat Requirements and Occurrence Patterns	Federally Listed Status ^(a)
Mammals			
<i>Eumops floridanus</i>	Florida bonneted bat	Suitable roosting (e.g., palm trees, tree cavities, Spanish tiled roofs) and foraging habitat occurs at Turkey Point (FWS 2017a); Observed within the vicinity of Turkey Point (FPL 2018f).	FE
<i>Puma concolor coryi</i>	Florida panther	Florida Panther Focus Area occurs in the vicinity of Turkey Point (FWS 1999); Observed 2 mi west of Turkey Point (SFWMMD 2013a).	FE
<i>Puma concolor</i> (all sub species except coryi)	puma	No known occurrences in Florida (FWS 1999; NRC 2016a).	SAT
<i>Trichechus manatus</i>	West Indian manatee	Designated critical habitat occurs adjacent to Turkey Point; Observed in the vicinity of Turkey Point, including canals and nearshore seagrass beds in Biscayne Bay (FPL 2012b).	FT
Birds			
<i>Ammodramus maritimus mirabilis</i>	Cape Sable seaside sparrow	Suitable habitat (mixed marl prairie) does not occur at Turkey Point; No known occurrences at Turkey Point (NRC 2015a; FPL 2014a).	FE
<i>Ammodramus savannarum</i>	Florida Grasshopper sparrow	Extirpated from Miami-Dade County (FWS 1999).	FE
<i>Aphelocoma coerulescens</i>	Florida scrub-jay	Extirpated from Dade County (FWS 1999).	FT
<i>Caladris rufa</i>	red knot	Suitable habitat, such as mudflats, salt marshes, and mangroves occur onsite (FWS 2017a); Observed onsite (FPL 2014a).	FT
<i>Campephilus principalis</i>	ivory-billed woodpecker	Likely extirpated from the United States; No known occurrences on or near Turkey Point (FWS 1999 NRC 2016a).	FE
<i>Charadrius melodus</i>	piping plover	Suitable wintering habitat occurs onsite and within the vicinity, such as beaches, mudflats, and sandflats (FPL 2014a; FPL 2018f); No documented occurrences onsite (FPL 2014a; NRC 2015a)	FT

Species	Common Name	Habitat Requirements and Occurrence Patterns	Federally Listed Status ^(a)
<i>Mycteria americana</i>	wood stork	Suitable foraging, resting, and roosting habitat within the CCS and onsite wetlands; Regularly observed onsite (NRC 2015a; EAI 2017; FPL 2018g).	FT
<i>Picoides borealis</i>	red-cockaded woodpecker	No known occurrences within Miami-Dade County (FWS 1999; NRC 2016a).	FE
<i>Rostrhamus sociabilis</i>	Everglades snail kite	Suitable habitat (lowland freshwater marshes) occurs on and near Turkey Point (NRC 2015a); Observed within the Everglades Mitigation Bank adjacent to Turkey Point (FPL 2014a).	FE
<i>Setophaga kirtlandi</i>	Kirtland's warbler	Suitable habitat (dense mangroves) occurs on and near Turkey Point; No known observations onsite (NRC 2016a; FPL 2018f).	FE
<i>Vermivora bachmani</i>	Bachman's warbler	No observations of this species in the United States since 1988 (FWS 1999).	FE
Reptiles			
<i>Alligator mississippiensis</i>	American alligator	Suitable freshwater habitat occurs within the vicinity of Turkey Point (FPL 2018f).	SAT
<i>Crocodylus acutus</i>	American crocodile	Designated critical habitat at Turkey Point; Onsite wetlands provide habitat for nesting, rearing hatchlings, and foraging; Onsite adult and hatchling populations have existed for several decades (FPL 2018f).	FT
<i>Drymarchon corais couperi</i>	eastern indigo snake	Suitable habitat, including freshwater marshes, mangroves, and cleared areas, occurs at Turkey Point; Occasionally observed onsite (FPL 2018g).	FT
Invertebrates			
<i>Anaea troglodyta florida</i>	Florida leafwing butterfly	Suitable habitat (pineland croton plants in pine rockland) does not occur at Turkey Point (FWS 2017a; FPL 2018f).	FE
<i>Cyclargus (=Hemiargus) thomasi bethunebakeri</i>	Miami blue butterfly	Only known occurrences are within Key West National Wildlife Refuge (FFWCC undated; FPL 2018f).	FE
<i>Heraclides aristodemus ponceanus</i>	Schaus swallowtail butterfly	Suitable habitat (pineland croton plants in pine rockland) does not occur at Turkey Point (FWS 2017a; FPL 2018f).	FE
<i>Orthalicus reses</i>	Stock Island Tree Snail	Suitable habitat (hardwood hammocks primarily in keys) does not occur at Turkey Point; No known occurrence within the vicinity of Turkey Point (FWS 1999; FPL 2018f).	FT
<i>Strymon acis bartrami</i>	Bartram's hairstreak butterfly	Suitable habitat, which is limited to pine rockland where its host plant pineland croton occurs, does not occur at Turkey Point (FWS 2017a; FPL 2018f).	FE

Species	Common Name	Habitat Requirements and Occurrence Patterns	Federally Listed Status ^(a)
Flowering Plants			
<i>Amorpha crenulata</i>	crenulate lead-plant	Suitable habitat (pine rockland) does not occur at Turkey Point (FWS 2017a).	FE
<i>Argythamnia blodgettii</i>	Blodgett's silverbush	Limited suitable habitat (coastal berm) may occur onsite; Observed within the vicinity of Turkey Point (FPL 2011b; Gann et al. 2018).	FT
<i>Brickellia mosieri</i>	Florida brickell-bush	Suitable habitat (pine rockland) does not occur at Turkey Point (FWS 2017a).	FE
<i>Chamaesyce deltoidea</i> ssp. <i>deltoidea</i>	deltoid spurge	Suitable habitat (pine rockland) does not occur at Turkey Point (FWS 2017a).	FE
<i>Chamaesyce deltoidea pinetorum</i>	pineland sandmat	Suitable habitat (pine rockland) does not occur at Turkey Point (NRC 2015a; 82 FR 6691).	FT
<i>Chamaesyce garberi</i>	Garber's spurge	Suitable habitat (pine rockland) does not occur at Turkey Point (FWS 2017a).	FT
<i>Chromolaena frustrata</i>	Cape Sable thoroughwort	Limited suitable habitat (coastal rock barrens) may occur at Turkey Point. Species does not occur in disturbed areas (FWS 2010a; FPL 2018f; NRC 2016a).	FE
<i>Consolea corallicola</i>	Florida semaphore cactus	Limited suitable habitat (coastal berms) may occur at Turkey Point (78 FR 63796; NRC 2016a); No known occurrences at Turkey Point (NRC 2016a; FPL 2018f).	FE
<i>Cucurbita okeechobeensis</i> ssp. <i>okeechobeensis</i>	Okeechobee Gourd	No known occurrences in Miami-Dade County; Not likely to occur at Turkey Point due to lack of suitable habitat (NRC 2016a; Gann et al. 2018; FPL 2018g).	FE
<i>Dalea carthagenensis floridana</i>	Florida prairie-clover	Suitable habitat not likely to occur at Turkey Point because some suitable habitats (i.e. pine rocklands, edges of rockland hammocks, and marl prairies) do not occur at Turkey Point and other suitable habitat (i.e., uplands) have been previously disturbed (NRC 2016a; Gann et al. 2018; FPL 2018g).	FE
<i>Digitaria pauciflora</i>	Florida pineland crabgrass	Suitable habitat (marl prairie and pine rockland) does not occur at Turkey Point (NRC 2016a; Gann et al. 2018; FPL 2018g).	FT
<i>Galactia smallii</i>	Small's milkpea	Suitable habitat (pine rockland) does not occur at Turkey Point (FWS 2017a).	FE
<i>Jacquemontia reclinata</i>	beach jacquemontia	Suitable habitat (pine rockland) does not occur at Turkey Point (FWS 2017a).	FE
<i>Linum arenicola</i>	sand flax	Potential to occur onsite given that this species grows less than 1 mi from Turkey Point and suitable habitat (i.e., pine rocklands, marl prairie, and adjacent disturbed areas) occurs within the vicinity (FPL 2018f).	FE

Species	Common Name	Habitat Requirements and Occurrence Patterns	Federally Listed Status ^(a)
<i>Linum carteri carteri</i>	Carter's small-flowered flax	Suitable habitat (pine rockland) does not occur at Turkey Point (FWS 2017a).	FE
<i>Polygala smallii</i>	tiny polygala	Suitable habitat (pine rockland) does not occur at Turkey Point (FWS 2017a).	FE
<i>Sideroxylon reclinatum</i> ssp. <i>astrofloridense</i>	Everglades bully	Suitable habitat (pine rockland habitat, marl prairie habitat, and within the ecotone between both habitats) does not occur at Turkey Point (82 FR 46691).	FT
<i>Warea carteri</i>	Carter's mustard	Extirpated from Miami-Dade County (FWS 1999; FWS 2008a).	FE
Ferns			
<i>Trichomanes punctatum</i> ssp. <i>floridanum</i>	Florida bristle fern	Suitable habitat (rockland hammocks, sinkhole habitats, and tree trunks that are in deep shade) occurs within the vicinity (Gann et al. 2018; NRC 2016a); Potential habitat onsite, although no known occurrences onsite (FPL 2018f).	FE

^(a) FE = federally listed as endangered; FT = federally listed as threatened; and SAT = federally listed due to similarity of appearance to another listed species at 50 CFR Part 17, "Endangered and Threatened Wildlife and Plants," under provisions of the Endangered Species Act.

Source: FWS 2018b unless otherwise cited

The FWS (2018b) identifies 23 animals that could occur within the Turkey Point action area. Based on the habitat and occurrence pattern information, which is summarized in Table 3-11, the NRC staff determined that the following six species are extirpated from Miami-Dade County or are not known to occur within Miami-Dade County and, therefore, the NRC will not consider these further within this SEIS:

- Florida grasshopper sparrow (*Ammodramus savannarum*)
- Florida scrub-jay (*Aphelocoma coerulescens*)
- ivory-billed woodpecker (*Campephilus principalis*)
- red-cockaded woodpecker (*Picoides borealis*)
- Bachman's warbler (*Vermivora bachmani*)
- Miami blue butterfly (*Cyclargus* (= *Hemiargus*) *thomasi bethunebakeri*)

The NRC staff also does not consider the following five species further within this SEIS because no suitable habitat for these species occurs on the Turkey Point site, there are no known occurrences of the species on site, and the species would not be expected to occur within the action area given the lack of suitable habitat:

- Cape Sable seaside sparrow (*Ammodramus maritimus mirabilis*)
- Florida leafwing butterfly (*Anaea troglodyta floralis*)
- Schaus swallowtail butterfly (*Heraclides aristodemus ponceanus*)

- Stock Island Tree Snail (*Orthalicus reses*)
- Bartram's hairstreak butterfly (*Strymon acis bartrami*)

The following two species are federally listed because of their similarity in appearance to a federally listed endangered or threatened species. A species that is listed due to similarity of appearance is not biologically endangered or threatened and is not subject to ESA Section 7 consultation. Therefore, this SEIS does not discuss further these two species:

- Puma (*Puma concolor* (all sub species except *coryi*)) which was listed for similarity of appearance to the Florida panther (*Puma concolor coryi*)
- American alligator (*Alligator mississippiensis*) which was listed for similarity in appearance to American crocodile

The FWS (2018b) identifies 19 plant species that could occur within the action area. FPL (2018n, 2018g) is not aware of any federally listed endangered or threatened plant species on the Turkey Point site. The NRC staff did not identify any known occurrence of a federally listed plant species within the action area (FWS 1999, NRC 2016a, FWS 2017a, Gann et al. 2018), although some species have been observed within the vicinity of the action area and have the potential to occur onsite (FPL 2011b). The NRC staff also notes that not all areas of the Turkey Point site have been surveyed for federally listed plants. Based on this limited information, the NRC staff reviewed the habitat requirements for each of the 19 federally listed species in Table 3-11 to determine which plants have potential suitable habitat within the action area. The NRC staff determined that the following 14 federally listed plant species would not be expected to occur within the Turkey Point action area due to the lack of suitable habitat or because the species has been extirpated from Miami-Dade County.

- crenulate lead-plant (*Amorpha crenulata*)
- Florida brickell-bush (*Brickellia mosieri*)
- deltoid spurge (*Chamaesyce deltoidea* ssp. *deltoidea*)
- pineland sandmat (*Chamaesyce deltoidea pinetorum*)
- Garber's spurge (*Chamaesyce garberi*)
- Okeechobee gourd (*Cucurbita okeechobeensis* ssp. *okeechobeensis*)
- Florida prairie-clover (*Dalea carthagenensis floridana*)
- Florida pineland crabgrass (*Digitaria pauciflora*)
- Small's milkpea (*Galactia smallii*)
- beach Jacquemontia (*Jacquemontia reclinata*)
- Carter's small-flowered flax (*Linum carteri carteri*)
- tiny polygala (*Polygala smallii*)
- Everglades bully (*Sideroxylon reclinatum* ssp. *austrofloridense*)
- Carter's mustard (*Warea carteri*)

The remaining 15 federally listed species in Table 3-11 may occur within the action area. These are:

- Florida bonneted bat (*Eumops floridanus*)
- Florida panther
- West Indian manatee
- red knot (*Caladris rufa*)
- piping plover (*Charadrius melodus*)
- wood stork (*Mycteria americana*)
- Everglades snail kite (*Rostrhamus sociabilis*)
- Kirtland's warbler (*Setophaga kirtlandi*)
- American crocodile
- eastern indigo snake (*Drymarchon corais couperi*)
- Blodgett's silverbush (*Argythamnia blodgettii*)
- Cape Sable thoroughwort (*Chromolaena frustrata*)
- Florida semaphore cactus (*Consolea corallicola*)
- sand flax (*Linum arenicola*)
- Florida bristle fern (*Trichomanes punctatum* ssp. *floridanum*)

The NRC staff evaluated the potential for the proposed action to affect these species in a biological assessment (NRC 2018n) for the Turkey Point Units 3 and 4 subsequent license renewal. The ESA Section 7 consultation history, life histories of these 15 species, and an evaluation of impacts to these species can be found in the biological assessment. The NRC staff incorporates its biological assessment (NRC 2018n) into this SEIS by reference.

3.8.1.3 Federally Listed Species and Critical Habitats under National Marine Fisheries Service's Jurisdiction

No federally listed endangered or threatened species under the NMFS's jurisdiction occur on the Turkey Point site itself. Six federally listed species under the NMFS's jurisdiction may occur in Biscayne Bay adjacent to the Turkey Point site (see Table 3-12).

Table 3-12 Federally Listed Endangered or Threatened Species Under National Marine Fisheries Service Jurisdiction in Biscayne Bay

Species	Common Name	Distinct Population Segment(s) ^(a)	Federally Listed Status ^(b)
Fish			
<i>Pristis pectinata</i>	smalltooth sawfish	United States	FE
Sea Turtles			
<i>Caretta caretta</i>	loggerhead	—	FT
<i>Chelonia mydas</i>	green	North Atlantic and South Atlantic	FT
<i>Dermochelys coriacea</i>	leatherback	—	FE
<i>Eretmochelys imbricata</i>	hawksbill	—	FE
<i>Lepidochelys kempii</i>	Kemp's ridley	—	FE

^(a) Under the Endangered Species Act, a Distinct Population Segment is a vertebrate population or group of populations that is discrete from other populations of the species and significant in relation to the entire species.

^(b) FE = federally listed as endangered and FT = federally listed as threatened at 50 CFR Part 17, "Endangered and Threatened Wildlife and Plants," under the provisions of the Endangered Species Act.

Source: NMFS 2017a

In 2015, the NRC prepared a biological assessment for the above five species as well as other species to assess the impacts of construction and operation of proposed new reactors Turkey Point Units 6 and 7 (NRC 2015b). Section 5.0, "Baseline Conditions for Aquatic Species," of the staff's biological assessment for Turkey Point Units 6 and 7 contains life histories, habitat requirements, status and distributions, factors contributing to the species' decline, and the occurrence and status in the project area of the smalltooth sawfish and four sea turtles identified in Table 3-12 on the pages identified as follows:

- smalltooth sawfish (pages 5-15 to 5-18; Figure 5-4 and Figure 5-5)
- loggerhead sea turtle (pages 5-7 to 5-10; Figure 5-3; Table 5-3)
- green sea turtle (pages 5-5 to 5-7; Table 5-2)
- leatherback sea turtle (pages 5-12 to 5-13; Table 5-5)
- hawksbill sea turtle (pages 5-10 to 5-12; Table 5-4)
- kemp's ridley sea turtle (page 5-13 to 5-15; Table 5-6)

In that biological assessment, the NRC staff also identified sea turtle stranding information for South Florida and in the vicinity of the Turkey Point site in the assessment (pages 5-1 to 5-5; Figure 5-1 and Figure 5-2; Table 5-1). This information, as identified by page, table, and figure

numbers above, continues to accurately describe these species. Accordingly, the NRC staff incorporates that information into this SEIS by reference.

Because there are no surface water connections between the CCS and any natural surface water bodies, none of the species under the NMFS’s jurisdiction occur in the CCS or on the Turkey Point site itself. However, all five of the federally listed species may be present in Biscayne Bay and are, therefore, considered to be present in the action area. Documented occurrences of smalltooth sawfish in or near the Turkey Point action area are rare, and, if present, would likely consist of juveniles using the near-shore mangrove communities to avoid predation (NRC 2015b). Leatherback and hawksbill sea turtle stranding data indicate that these species would also rarely occur in Biscayne Bay (NRC 2015b). Loggerhead and green sea turtles are more likely to occur in Biscayne Bay based on stranding data, although occurrences of these species within the Turkey Point action area itself are not particularly common (NRC 2015b).

3.8.2 Essential Fish Habitat Protected under the Magnuson–Stevens Act

The South Atlantic Fishery Management Council and the NMFS have designated Essential Fish Habitat (EFH) pursuant to the MSA for a number of federally managed species within Biscayne Bay. During the NRC staff’s environmental review for the Turkey Point Units 6 and 7 combined license application, the NRC staff worked with the NMFS to identify those species with EFH present near the Turkey Point site. Table 3-13 identifies these species, the applicable fisheries management plan, and relevant EFH habitat designations. During the preparation of this SEIS, the NRC staff confirmed through the NMFS’s EFH Mapper that these designations remain valid and that no new EFH has been designated in the vicinity of Turkey Point since the staff’s environmental review of the Turkey Point Units 6 and 7 combined license application.

Table 3-13 Designated Essential Fish Habitat near the Turkey Point Site

Species	Common Name	Applicable Fishery Management Plan ^(a)	Essential Fish Habitat Designation ^(b)	
			Mangrove	Seagrass and Unconsolidated Bottom
<i>Farfantepenaeus duorarum</i>	pink shrimp	Shrimp Fishery	x	x
<i>Haemulon plumieri</i>	white grunt	Snapper-Grouper		x
<i>Lutianus analis</i>	mutton snapper	Snapper-Grouper		x
<i>Lutjanus griseus</i>	gray snapper	Snapper-Grouper	x	x
<i>Panulirus argus</i>	spiny lobster	Spiny Lobster	x	x

^(a) The Fishery Management Councils and the NMFS designate EFH for federally managed species through fishery management plans.

^(b) Biscayne Bay and Biscayne National Park are also EFH Habitats of Particular Concern for coral, coral reefs, and hard-bottom communities.

Sources: NMFS 201a, NRC 2015c, NRC 2016a, SAFMC and NMFS 2016a

In 2015, the NRC staff prepared an EFH assessment to assess the impacts of construction and operation of proposed Turkey Point Units 6 and 7 (NRC 2015c). Section 4.0, “EFH Species Life-History Information,” of the staff’s EFH assessment describes life histories, habitat

requirements, distributions, and population statuses of the five federally managed species identified in Table 3-13 on the pages identified as follows:

- pink shrimp (pages 4-4 to 4-5)
- white grunt (page 4-3)
- mutton snapper (page 4-3)
- gray snapper (pages 4-1 to 4-2, Figure 4-1)
- spiny lobster (pages 4 3 to 4-4, Figure 4-2)

The NRC staff also described in its EFH assessment the applicable fishery management plans for these species (page 3-2) and habitat areas of particular concern (page 3-3). This information, as identified above, continues to accurately describe these species, and the NRC staff therefore incorporates it into this SEIS by reference. The NRC staff addressed two additional species—bluestriped grunt (*Haemulon sciurus*) and dog snapper (*Lutianus jocu*)—in its 2015 EFH assessment. However, the South Atlantic Fishery Management Council and the NMFS have since removed these species from the snapper-grouper complex (77 FR 15916, 81 FR 32249). Thus, the Snapper-Grouper Fishery Management Plan no longer identifies EFH for these species.

While EFH for the species identified in Table 3-13 is designated in Biscayne Bay, neither EFH nor the species themselves occur in the CCS or on the Turkey Point site because there are no surface water connections between the CCS and any other natural surface water bodies.

3.8.3 Marine Sanctuary Resources Protected Under the National Marine Sanctuaries Act

The NMSA authorizes the Secretary of Commerce to designate and protect areas of the marine environment with special national significance due to their conservation, recreational, ecological, historical, scientific, cultural, archeological, educational, or aesthetic qualities as national marine sanctuaries. The NMSA protects nationally significant aquatic and marine resources and delegates authority to the National Oceanic and Atmospheric Administration to designate and administer marine sanctuaries. The NMSA defines “sanctuary resources” as any living or nonliving resource of a national marine sanctuary that contributes to the conservation, recreational, ecological, historical, educational, cultural, archaeological, scientific, or aesthetic value of the sanctuary (16 U.S.C. 1432(8)).


Within Southern Florida, Congress has designated the Florida Keys National Marine Sanctuary to include 2,900 nautical mi² (5,370 nautical km²) of coastal and ocean waters and submerged land surrounding the Florida Keys from south of Miami westward and encompassing the Dry Tortugas (see Figure 3-37). Congress designated the sanctuary in 1990 and through the consent of the State of Florida, the sanctuary is also effective in State waters. The National Oceanic and Atmospheric Administration and the FDEP jointly manage the sanctuary under a co-trustee agreement.

The Florida Keys ecosystem supports a unique distribution of marine organisms because the Keys serve as a partial barrier between temperate Gulf of Mexico waters and subtropical Western Atlantic Ocean waters. The region supports over 6,000 species of plants, fish, and invertebrates. Unique habitats include the Nation’s only coral reef that lies adjacent to the continent and one of the largest seagrass communities in the hemisphere. The Florida Keys

coral reef system includes 520 species of fish, including over 260 species of reef fish; 367 species of algae; 5 species of seagrasses; 117 species of sponges; 89 species of polychaete worms; 128 species of echinoderms; 2 species of fire coral; 55 species of soft corals; and 65 species of stony corals. The area's seagrass beds are among the richest, most productive, and most important submerged coastal habitats because they provide food and habitat for commercially and recreationally important species of fish and invertebrates. Mangroves are another important component of the ecosystem. Mangrove trees and forests fringe the 1,600 islands and 1,800 mi (2,900 km) of shoreline within the Florida Keys National Marine Sanctuary. Mangroves provide habitat for juvenile fish and invertebrates, stabilize sediments, and produce prop-root surfaces for attached organisms such as oysters, sponges, and algae (NOAA 2007).

The primary non-living marine resources within the sanctuary are maritime heritage areas and sites. Shipwrecks in the Keys contain a record of European and American trade routes and historic ship traffic through the Caribbean. Many of these important underwater cultural and historical sites remain undisturbed because of their relative inaccessibility (NOAA 2007).

The marine resources of the sanctuary contribute to both the quality of human life and the economy of the Florida Keys because the environment and economy are inextricably linked in this region. Tourism is the primary industry in the Florida Keys. Visitors participate in snorkeling, scuba diving, boating, recreational fishing, and wildlife viewing. Recreational and commercial fishing are the next most important sectors of the local economy (NOAA 2007).



Source: NOAA 2019

Figure 3-37 Florida Keys National Marine Sanctuary

3.9 Historic and Cultural Resources

This section describes the cultural background and the historic and cultural resources found at Turkey Point and in the surrounding area. Section 106 of the National Historic Preservation Act of 1966, as amended (NHPA) (54 U.S.C. 300101 et seq.), requires Federal agencies to consider the effects of their undertakings on historic properties and afford the Advisory Council on Historic Preservation an opportunity to review and comment on the undertaking. Undertakings denote a broad range of Federal activities, including the issuance of NRC reactor licenses and permits. Historic properties are defined as resources included on, or eligible for inclusion on, the National Register of Historic Places (National Register). The criteria for eligibility are listed in Title 36, "Parks, Forest, and Public Property," of the *Code of Federal Regulations* (36 CFR) Section 60.4, "Criteria for evaluation," and include (1) association with significant events in history, (2) association with the lives of persons significant in the past, (3) embodiment of distinctive characteristics of type, period, or method of construction, and (4) sites or places that have yielded, or are likely to yield, information important in prehistory or history.

In accordance with 36 CFR 800.8(c), "Use of the NEPA process for section 106 purposes," the NRC complies with the obligation required under Section 106 of the NHPA through its environmental review process under the National Environmental Policy Act of 1969, as amended (NEPA) (42 U.S.C. 4321 et seq). In the context of the NHPA, the area of potential effect (APE) for a license renewal action is the Turkey Point site and its immediate environs. Turkey Point is located within the 9,460 ac (3,828 ha) FPL property. This property constitutes the APE and consists primarily of developed land, open water, and wetlands. These land areas may be impacted by continued maintenance and operations activities during the subsequent license renewal term. The APE may extend beyond the immediate Turkey Point environs if FPL's maintenance and operations activities affect offsite historic properties irrespective of land ownership or control.

In accordance with the provisions of the NHPA, the NRC is required to make a reasonable effort to identify historic properties within the APE. The NRC is required to, in consultation with the SHPO, determine and document the APE and identify historic properties within the APE. If the NRC finds that either there are no historic properties within the APE or the undertaking (subsequent license renewal) would have no effects on historic properties, the NRC provides documentation of this finding to the State historic preservation officer. In addition, the NRC notifies all consulting parties, including Indian tribes, and makes this finding public (through the NEPA process) prior to issuing the renewed license. If historic properties are present and could be affected by the undertaking, the NRC is required to assess and resolve any adverse effects in consultation with the State historic preservation officer and any Indian tribe that attaches religious and cultural significance to identified historic properties. The Florida Division of Historical Resources, within the Florida Department of State, is responsible for preserving and promoting Florida's historical, archaeological, and folk culture resources.

3.9.1 Cultural Background

Humans have occupied the Southern Florida region for about 12,000 years. The NRC staff's EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176), Section 2.7.1 describes in detail the history of human occupation of the Turkey Point site and the surrounding region (NRC 2016a). The NRC staff incorporates this prehistoric occupation description,

contained in pages 2-197 through 2-198 of NUREG-2176, into this SEIS by reference. Prehistoric occupation of the area is divided into the following chronological sequence:

- Paleoindian Period (12,000-7,500 BC)
- Archaic Period (7,500-500 BC)
- Formative Period (500 BC -1513 AD)

The history of east coast Florida from European contact to the end of World War II is described on pages 2-199 through 2-201 of NUREG–2176 (NRC 2016a). The NRC staff incorporates these pages into this SEIS by reference. In brief, European arrival and contact with aboriginal people of Southern Florida occurred in 1513 when Spanish explorers arrived on Florida’s eastern coast. European colonization resulted in the loss of Tribal lands and the decline of Native American populations. In 1821, Spain ceded Florida Territory to the United States, and Florida was granted statehood in 1845. During World War I, several training facilities were set up in the State of Florida. The State’s economy was boosted by the war, primarily through shipbuilding and industrialization of port cities. During World War II, Florida became one of the Nation’s major training grounds for various military branches, and the influx of thousands of servicemen and their families increased industrial and agricultural production in Florida. With the establishment of the Everglades National Park in 1947, tourism increased in the area and became one of the major sources of the State’s economy. The NRC staff has identified no new and significant information related to the cultural history of the Turkey Point region in its review of FPL’s environmental report submitted as part of the subsequent license renewal application (FPL 2018f), during the onsite environmental audit at Turkey Point, or through the scoping process, beyond the information in the EIS for Turkey Point Units 6 and 7.

3.9.2 Historic and Cultural Resources at Turkey Point

Historic and cultural resources in the vicinity of Turkey Point can include prehistoric era and historic era archaeological sites, historic districts, and buildings, as well as any site, structure, or object that may be considered eligible for listing on the National Register of Historic Places (NRHP). Historic and cultural resources also include traditional cultural properties that are important to a living community of people for maintaining their culture. “Historic property” is the legal term for a historic or cultural resource that is included on, or eligible for inclusion on, the NRHP. The staff notes that the vicinity of a site is not equivalent to an APE; rather, it is the area within a 6-mi (9.6 km) radius of the plant, as explained in NUREG–1555, Supplement 1, Rev. 1.

A cultural resource survey was not conducted on the FPL site prior to Turkey Point Units 3 and 4 construction (FPL 2018f). Therefore, it is unknown whether any historic and archeological resources were disturbed during construction of Turkey Point Units 3 and 4. Approximately 28 percent (2,700 ac (1093 ha)) of the site is undeveloped and undisturbed (FPL 2018h). Although no comprehensive cultural resource survey has been completed for the entire Turkey Point site, several cultural resource studies of the site were conducted on portions of the site between 2004 and 2013 (FPL 2018f, Janus 2009, FPL 2018h). FPL estimates that approximately 10 percent of the Turkey Point site (approximately 950 ac (384 ha)) has been surveyed collectively between these cultural resource surveys (FPL 2018h). These cultural resource studies did not identify archeological sites or historic resources on the Turkey Point site areas that were surveyed, and they concluded that the Turkey Point site has a low archeological potential (FPL 2018f and Janus 2009).

During the NRC staff's environmental site audit, the NRC staff became aware of three wooden buildings that were part of a Boy Scouts of America camp and a cottage (known as the Range House/McGregor Smith Cottage) that are over 50 years old and could have potential historic significance (FPL 2018h). The Boy Scout camp was constructed by FPL between 1962 and 1963 (FPL 2018m). After FPL completed construction of the cooling canals in the early 1970s, the Boy Scout camp was no longer used for Boy Scout activities (FPL 2018m). FPL has maintained and repaired the three wooden structures associated with the former Boy Scout camp, and now uses these structures for storage (NRC 1972, FPL 2018h, FPL 2018m). Two of these structures have gable roofs, and the third has a pyramid roof. Although they have not yet been formally evaluated, FPL has indicated that the three structures do not appear to meet the criteria for listing on the NRHP (FPL 2018h, FPL 2018m).

The Ranger House/McGregor Smith Cottage is a wood frame elevated structure supported by large cylindrical wooden posts; the ground floor space and second level wraparound porch are enclosed with screens (MDC 2018d). The structure was built sometime between 1965 and 1968 for the purposes of housing a full-time Florida Board of Conservation ranger (FPL 2018m). The structure is named after McGregor Smith, one of Florida Power & Light's first presidents (from 1939–1954), who later served as chief executive officer. According to FPL, McGregor Smith is also known for his involvement with the Boy Scouts and Southern Florida economic development (FPL 2018h). Past use of the cottage included use as a meeting space during construction of Turkey Point and as a construction office and fish camp during the 1980s. During the 1990s, the cottage was renovated to make it a habitable residence for senior FPL staff (FPL 2018m). In 2012, FPL contacted the Miami-Dade County's Office of Historical Resources to discuss designation of the Ranger House/McGregor Smith Cottage for historical landmark status and potential restoration of the cottage. According to Miami-Dade County's Office of Historical Resources, McGregor Smith was an important figure in the history of the Florida Power & Light Company and the cottage "played a significant role in the early history of the FPL power plant at Turkey Point and is worthy of saving for future staff use and as a vestige of the flurry of activity that once took place in and around the power plant during the 1960s." However, in 2012 when FPL contacted the Miami-Dade County's Office of Historical Resources, the Ranger House/McGregor Smith Cottage had not yet met the 50-year benchmark required for consideration for eligibility for listing in the NRHP (MDC 2018d). As of the date of publication of this SEIS, FPL has not evaluated the Ranger House/McGregor Smith Cottage for eligibility for listing in the NRHP (FPL 2018h).

FPL conducted a desktop study of offsite cultural resources within the vicinity of Turkey Point. Within a 6-mi (9.6 km) radius of the Turkey Point site, there are 95 known historic and cultural resources. Of these, 28 resources are ineligible for listing, 65 resources have not been evaluated for listing, and 2 resources have been determined eligible for listing in the NRHP (FPL 2018f).

3.10 Socioeconomics

This section describes current socioeconomic factors that have the potential to be directly or indirectly affected by changes in operations at Turkey Point. Turkey Point and the communities that support it can be described as a dynamic socioeconomic system. The communities supply the people, goods, and services required to operate the nuclear power plant. Power plant operations, in turn, supply wages and benefits for people and dollar expenditures for goods and services. The measure of a community's ability to support Turkey Point operations depends on the community's ability to respond to changing environmental, social, economic, and demographic conditions.

3.10.1 Power Plant Employment

The socioeconomic region of influence (ROI) is defined by the area where Turkey Point workers and their families reside, spend their income, and use their benefits, thus affecting the economic conditions of the region. Currently, FPL employs a permanent workforce of approximately 680 workers (FPL 2018f). Approximately 85 percent of this workforce resides in Miami-Dade County (Table 3-14). The remaining workers are spread among 12 counties in Florida and Georgia, with numbers ranging from 1 worker to 49 workers per county (FPL 2018f). In addition to permanent Turkey Point plant employees, FPL hires contract workers to support plant operations. In 2017, FPL employed 366 onsite contract workers; 80 percent of the contract workers resided in Miami-Dade County. The number of contract workers employed each year has remained relatively stable for the last 5 years with the exception of one year. In 2013, FPL employed 763 onsite contract workers as a result of the extended power uprate for Turkey Point (FPL 2018h). Since the majority of permanent workers (85 percent) and contract workers (80 percent) reside in Miami-Dade County, the most significant socioeconomic effects of plant operations are likely to occur in this county. The focus of the impact analysis and region of influence, therefore, is on the socioeconomic impacts of continued Turkey Point operations during the subsequent license renewal period on Miami-Dade County.

Table 3-14 Residence of Permanent Turkey Point Employees by County

County	Number of Employees	Percentage of Total
Total	679	100
Florida		
Broward	49	7
Miami-Dade	577	85
Monroe	40	6
Palm Beach	4	1
Other states and counties	9	1

Source: FPL 2018f

Refueling outages for Turkey Point Units 3 and 4 occur on a staggered 18-month schedule for each unit and have historically lasted 25 to 35 days per unit. During refueling outages, onsite employment typically increases by an additional 1,200 workers. As there are no subsequent license renewal-related refurbishment activities, FPL has no plans to add additional employees to support plant operations during the subsequent license renewal period (FPL 2018f).

3.10.2 Regional Economic Characteristics

This section presents information on employment and income in the Turkey Point socioeconomic region of influence.

3.10.2.1 Regional Employment and Income

In 2016, the Miami-Dade County civilian labor force was approximately 1,370,950 individuals (USCB 2016a). From 2011 to 2016, the labor force in Miami-Dade County increased by

5.6 percent (USCB 2016a and USCB 2011). From 2011 to 2016, the number of employed people in Miami-Dade County increased by 14 percent.

According to the U.S. Census Bureau's (USCB's) 2016 American Community Survey 1-year Estimates, educational services, and health care and social assistance represents the largest employment sector in Miami-Dade County (approximately 20 percent), followed by professional, scientific, and management, and administrative and waste management services (approximately 13 percent). A list of employment by industry in Miami-Dade County is provided in Table 3-15. Turkey Point's permanent workforce residing in Miami-Dade County represents approximately 0.04 percent of Miami-Dade County's employed civilian labor force. Estimated income information for the Miami-Dade County and Florida, for comparison, is presented in Table 3-16. National parks in the vicinity of Turkey Point, such as Biscayne National Park and the Everglades National Park, attract visitors that support economic activity. For instance, in 2017, Biscayne National Park and the Everglades National Park supported approximately 1,680 jobs and \$65,319,000 in labor income (NPS 2018b).

Table 3-15 Employment by Industry in Miami-Dade County (2016 Estimates)

Industry	Miami-Dade County	Percent
Agriculture, forestry, fishing and hunting, and mining	9,929	0.8
Construction	103,636	8.0
Manufacturing	57,130	4.4
Wholesale trade	46,086	3.6
Retail trade	158,752	12.3
Transportation and warehousing and utilities	106,084	8.2
Information	23,941	1.9
Finance, insurance, real estate, rental, leasing	97,194	7.5
Professional, scientific, and administrative and waste management services	160,672	12.5
Educational services, and health care and social assistance	252,384	19.6
Arts, entertainment, recreation, accommodation and food services	149,588	11.6
Other services (except public administration)	79,895	6.2
Public administration	44,806	3.5
Total Employed Civilian Workers	1,290,097	

Source: USCB 2016a

Table 3-16 Estimated Income Information for Miami-Dade County and Florida (2016 Estimate)

	Miami-Dade County	Florida
Median household income (dollars) ^(a)	45,935	50,860
Per capita income (dollars) ^(a)	25,700	28,621
Families living below the poverty level (percent)	14.7	10.5
People living below the poverty level (percent)	18.3	14.7

^(a) In 2016 inflation-adjusted dollars

Source: USCB 2016a

3.10.2.2 Unemployment

According to the USCB's 2016 American Community Survey 1-Year Estimates, the unemployment rate in Miami-Dade County was 5.9 percent (USCB 2016a). Comparatively, the unemployment rate in the State of Florida in 2016 was 6.0 percent (USCB 2016b).

3.10.3 Demographic Characteristics

An estimated 702,557 people live within 20 mi (32 km) of Turkey Point, which equates to an average population density of 559 persons per square mile (FPL 2018f). This translates to a Category 4, "Least sparse" population density using NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (NRC 1996) measure of sparseness (greater than 120 persons per square mile within 20 mi). An estimated 3,472,804 people live within a 50-mi (80-km) radius of Turkey Point, which equates to an average population density of 442 persons per square mile. This translates to a Category 4, "In close proximity" measure of proximity (greater than 190 persons per square mile within 50 mi) using NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (NRC 1996). Both a Category 4 measure of sparseness and proximity results in a "High" population category based on Figure C.1 of the license renewal GEIS sparseness and proximity matrix (NRC 1996). "High" population category corresponds to the least sparse population category and sites that are in close proximity to large cities. Therefore, Turkey Point is located in a "High" population area based on the license renewal GEIS sparseness and proximity matrix. As shown in Figure 3-1, Turkey Point is located on the coast and much of the area within a 50-mi (80-km) radius around the site consists of ocean and is unpopulated. Additionally, Everglades National Park, located west of the site, is unpopulated (EPA 2019). The population living within a 50-mi (80-km) radius of Turkey Point is primarily concentrated north, north-northeast, and north-northwest of Turkey Point. The nearest resident is approximately 1.9 mi (3.0 km) away from the site at the Homestead Bayfront Park complex (FPL 2018k).

Table 3-17 shows population percent growth and projections from 1990 to 2060 in Miami-Dade County. Over the last several decades, Miami-Dade County has experienced increasing population. Based on population projections, the population in Miami-Dade County is expected to continue to increase, but at a lower rate.

Table 3-17 Population and Percent Growth in Miami-Dade County 1990–2060

Year	Miami-Dade County	
	Population	Percent Change Since Prior Entry
1990	1,937,094	–
2000	2,253,362	16.3
2010	2,496,435	10.8
2016	2,712,945	8.7 ^(a)
2020	2,872,760	15.1 ^(a)
2030	3,215,054	11.9
2040	3,477,569	8.2
2050	3,811,933	9.6
2060	4,127,087	8.3

^(a) Percent change from 2010

Source: Decennial population data for 1970–2010 (USCB 1996, USCB 2000a, USCB 2010a);
 Estimated population for 2016 (USCB 2016b); Projected population for 2020–2040 (BEBR 2017);
 Calculated projected population for 2050–2060.

The 2010 Census demographic profile of the Miami-Dade County population is presented in Table 3-18. According to the 2010 Census (USCB 2010a), minorities (race and ethnicity combined) comprised approximately 85 percent of the total population. The largest minority population was Hispanic or Latino of any race (65 percent of the total population; 77 percent of the total minority population). For comparison, according to the 2010 Census, minorities comprised approximately 42 percent of the total state of Florida population (USCB 2010b).

Table 3-18 Demographic Profile of the Population in Miami-Dade County in 2010

Miami-Dade County	
Total Population	2,496,435
Race (Percent of Total Population)	
White	73.8
Black or African American	18.9
American Indian and Alaska Native	0.2
Asian	1.5
Native Hawaiian and Other Pacific Islander	0
Some other race	3.2
Two or more races	2.4
Hispanic, Latino, or Spanish Ethnicity of Any Race	
Hispanic or Latino	1,623,589
Percent of total population	65.0
Minority Population (Including Hispanic or Latino Ethnicity)	
Total minority population	2,112,884
Percent minority	84.6

Source: USCB 2010a

According to the USCB's 2016 American Community Survey 1-Year Estimates, since 2010, minority populations in the Miami-Dade County were estimated to have increased by approximately 232,000 persons (see Table 3-19). The largest increases occurred in the Hispanic or Latino population (nearly 212,000 person increases since 2010, an increase of approximately 13 percent). According to the Census Bureau, minorities comprised 69 percent of the total Miami-Dade County population in 1990 (USCB 1990). By 2000, the county's minority population had increased to 79 percent of the population (USCB 2000b).

Table 3-19 Demographic Profile of the Population in Miami-Dade County, 2016 Estimates

Miami-Dade County	
Total Population	2,712,945
Race (Percent of Total Population)	
White	74.5
Black or African American	17.6
American Indian and Alaska Native	0.2
Asian	1.6
Native Hawaiian and Other Pacific Islander	0
Some other race	4.6
Two or more races	1.6
Hispanic, Latino, or Spanish Ethnicity of Any Race	
Hispanic or Latino	1,835,412
Percent of total population	67.8
Minority Population (Including Hispanic or Latino Ethnicity)	
Total minority population	2,344,897
Percent minority	86.4

Source: USCB 2016b

3.10.3.1 Transient Population

Miami-Dade County can experience seasonal transient population growth as a result of local tourism, recreational activities, or university attendance. For instance, in 2017, Biscayne National Park had approximately 447,000 visitors and Everglades National Park had approximately 1,019,000 visitors (NPS 2017a). In 2016, approximately 200,800 students were enrolled in college or graduate school in Miami-Dade County (USCB 2016c). A transient population creates a demand for temporary housing and services in the area.

Based on USCB's 2016 American Community Survey 1-Year Estimates (USCB 2016d), approximately 216,677 seasonal housing units are located in the four counties within a 50-mi (80-km) radius of Turkey Point (Miami-Dade, Monroe, Broward, and Collier counties). Of those, 66,528 seasonal housing units are located in Miami-Dade County. Table 3-20 presents information about seasonal housing for the counties all partly within the 50 mi (80 km) of Turkey Point. The Greater Miami Convention and Visitors Bureau estimates that in 2018, Miami-Dade County had 433 hotels/motels and approximately 55,450 rooms (GMCVB 2018).

Table 3-20 2016 Estimated Seasonal Housing in Counties Located Within 50 mi (80 km) of Turkey Point

County	Total Housing Units	Total Vacant Units	Vacant Housing Units: for Seasonal, Recreational, or Occasional Use	Percent Vacant Seasonal Housing Units
Miami-Dade	1,021,650	140,884	66,528	6.5
Monroe	53,129	22,811	14,854	27.5
Broward	822,980	141,506	78,911	9.6
Collier	210,147	70,625	56,384	26.8
Total	2,107,906	375,826	216,677	

Source: USCB 2016b and USCB 2016d

3.10.3.2 Migrant Farm Workers

Migrant farm workers are individuals whose employment requires travel to harvest agricultural crops. These workers may or may not have a permanent residence. Some migrant workers follow the harvesting of crops, particularly fruit, throughout rural areas of the United States. Migrant workers may be members of minority or low-income populations. Because they travel and can spend a significant amount of time in an area without being actual residents, migrant workers may be unavailable for counting by census takers. If uncounted, these minority and low-income workers would be underrepresented in the decennial Census population counts.

Since 2002, the Census of Agriculture reports the numbers of farms hiring migrant workers—defined as a farm worker whose employment required travel that prevented the worker from returning to his/her permanent place of residence the same day (USDA 2012). The Census of Agriculture is conducted every 5 years and results in a comprehensive compilation of agricultural production data for every county and parish in the Nation.

Information about both migrant and temporary farm labor (persons working less than 150 days) can be found in the 2017 Census of Agriculture. Table 3-21 presents information on migrant and temporary farm labor in the four counties within a 50-mi radius of Turkey Point. According to the 2017 Census, 5,042 farm workers were hired to work for less than 150 days and were employed on 945 farms in the 4 counties within 50-mi of Turkey Point. The county with the highest number of temporary farm workers (4,339) on 736 farms was Miami-Dade County. Approximately 151 farms in the 4 counties within 50-mi of Turkey Point reported hiring approximately 2,727 migrant workers (USDA 2019).

Table 3-21 2017 Migrant Farm Workers and Temporary Farm Labor in Counties Located within 50 mi of Turkey Point

County	Number of Farms with Hired Farm Labor	Number of Farms Hiring Workers for Less Than 150 Days	Number of Farm Workers Working for Less Than 150 Days	Number of Farms Reporting Migrant Farm Labor	Number of Migrant Workers
Miami-Dade	1,180	736	4,339	133	2,018
Monroe	8	5	N/A	0	0

County	Number of Farms with Hired Farm Labor	Number of Farms Hiring Workers for Less Than 150 Days	Number of Farm Workers Working for Less Than 150 Days	Number of Farms Reporting Migrant Farm Labor	Number of Migrant Workers
Broward	256	151	501	7	23
Collier	83	53	202	11	686
Total	1,527	945	5,042	151	2,727

USDA 2019; N/A= information was not disclosed

3.10.4 Housing and Community Services

This section presents information regarding housing and local public services, including education and water supply.

3.10.4.1 Housing

Table 3-22 lists the total number of occupied and vacant housing units, the housing vacancy rates, and the median value of housing units in Miami-Dade County. Based on USCB's 2016 American Community Survey 1-year estimates (USCB 2016e), there were approximately 1,022,000 housing units in Miami-Dade County, of which approximately 881,000 were occupied. The median value of owner-occupied housing units is \$265,200.

Table 3-22 Housing in Miami-Dade County (2016)

Miami-Dade County	
Total housing units	1,021,650
Occupied housing units	880,766
Total vacant housing units	140,884
Percent total vacant	13.8
Owner occupied units	446,018
Median value (dollars)	\$265,200
Owner vacancy rate (percent)	1.9
Renter occupied units	434,748
Median rent (dollars/month)	1,201
Rental vacancy rate (percent)	5.2

Source: USCB 2016e

3.10.4.2 Education

The Miami-Dade County Public School District is comprised of 472 schools and approximately 354,000 students. The Miami-Dade County Public School District is the fourth largest school district in the United States (MDCPS 2018). The 2016–2017 Miami-Dade County Public School District total revenue was \$4,232 million, of which approximately 59 percent was from local support (see discussion in Section 3.10.5, "Tax Revenues") (MDCPS 2017a).

3.10.4.3 Public Water Supply

The Miami-Dade Water and Sewer Department is the main public water supplier in Miami-Dade County. Miami-Dade County relies on groundwater withdrawn from the Biscayne aquifer and Floridian aquifer (see Section 3.5.2.1 for detailed discussion of these two major aquifer systems). Water is provided by the Miami-Dade Water and Sewer Department through four regional water treatment plants: Hialeah and John E. Preston Water Treatment Plant, the Hialeah Reverse Osmosis Water Treatment Plant, the Alexander Orr, Jr. Water Treatment Plant, and the South Dade Water Supply System (which is comprised of five smaller water treatment plants) (MDC 2014). The Newton Water Treatment Plant (part of the South Dade Water Supply System) serves Turkey Point. In addition to the Miami-Dade Water and Sewer Department, four water suppliers within Miami-Dade County provide water to parts of unincorporated Miami-Dade County and within their municipal boundaries: the City of North Miami, the City of North Miami Beach, Florida City, and City of Homestead. The capacity of wellfields and the water treatment plant facilities' installed capacity are presented in Table 3-23.

Table 3-23 Major Public Water Suppliers in Miami-Dade County

System Name	Wellfield Supply Capacity (mgd)	Installed Treatment Facility Capacity (mgd)	Population Served
City of North Miami	14.96	9.30	91,000
City of North Miami-Beach	39.97	32.0	164,000
City of Homestead	16.99	16.9	65,000
Florida City	4	4	9,700
Miami-Dade Water and Sewer Department Service Areas (Total)	634.01	497.19	2,223,000
Hialeah-Preston Treatment Plant	295	225	
Hialeah Reverse Osmosis Water Treatment Plant	12	10	
Alexander Orr, Jr. Water Treatment Plant	308	248	
South Dade Water Treatment Plants (5 plants) (Total)	19.01	14.19	
Elevated Tank	4.32	-	
Everglades Labor	5.04	-	
Leisure City	4.18	-	
Naranja	1.15	-	
Newton	4.32	-	

mgd: millions of gallons per day

Source: MDC 2014

In 2013, the Miami-Dade Water and Sewer Department system population served was 2,222,944 and annual average daily demand was 302 mgd. Despite increases in population, water use has decreased between 2004 and 2013 by 16 percent. Decrease in water use has

been attributed to Miami-Dade County's water use efficiency legislation and implementation of the County's water conservation plan (MDC 2014). According to the Miami-Dade Water Supply Facilities Work Plan (MDC 2014), when taking into consideration water conservation, by 2033, annual average daily water demand in the Miami-Dade Water and Sewer Department service area is projected to be 352 mgd (MDC 2014).

3.10.5 Tax Revenues

The State of Florida does not have a State-level property tax. Private property owners pay property taxes to the county and a local school district and may also pay taxes to regional taxing districts. In Florida, real estate property and tangible personal property are subject to property tax. Property values are set by the county property appraiser and are collected by the county tax collector. The tax rate (millage) is set by each taxing unit. County and school district governments may levy taxes up to 10 mills (\$10.00 per thousand of assessed valuation) each. As discussed below, FPL pays property taxes (real and tangible personal property) for Turkey Point to Miami-Dade County, the Miami-Dade School District, and several regional taxing districts (FPL 2018f).

The Miami-Dade County budget is comprised of appropriations from various revenues. The total Miami-Dade County operating revenues for the years 2012 through 2017 are presented in Table 3-24. Property taxes are a significant source of Miami-Dade County funding. For instance, property tax revenues have ranged from 23 to 33 percent of the total Miami-Dade County revenues between 2012 and 2017. Miami-Dade County property taxes fund four separate taxing jurisdictions: Countywide, Unincorporated Municipality Service Area, the Fire Rescue District, and the Library System. Each of the four taxing jurisdictions is responsible for different types of services (MDC 2016b). For instance, the County-wide jurisdiction provides public health and social services, transportation, regional parks, and county roads, the court systems, and the regional sheriff services and jails. Additionally, Miami-Dade County also has a countywide debt and a Fire Rescue District debt millage. The revenue raised from the debt service millage pays outstanding debt for voter-approved general or special obligation bonds. The amount of property tax received by a taxing jurisdiction is a result of the millage rate applied by each county taxing jurisdiction. For 2017, the overall property tax millage rate was 9.7074 (MDC 2016b).

The Miami-Dade County Public School District is a taxing entity separate from Miami-Dade County. The Florida Education Finance Program is the primary mechanism for funding the operating costs of Florida school districts (FLDOE 2017). The Florida Education Finance Program allocates funds to the Miami-Dade County Public School District based on student enrollment (FHR 2010). Funding for school districts comes from State, local, and Federal sources. Local funding is obtained primarily from property taxes levied by Florida's counties, each of which constitutes a school district. Property taxes on properties located within the school district are levied after the millage rate is certified. Table 3-24 presents the Miami-Dade County School Board revenues for years 2012 through 2017. Property tax revenues provided approximately 45 to 52 percent of the total Miami-Dade County School Board revenues for years 2012 through 2017.

Miami-Dade County also imposes special district millage. These include the Children's Trust Authority, the Everglades Construction Project, the Okeechobee Basin, the SFWMD, and the Florida Inland Navigation District (SFWMD 2011a). Fiscal Year 2016–2017 total special district millage for Miami-Dade County was 0.3627 (MDC 2016c).

Table 3-24 Miami-Dade County Total Operating Revenues, Miami-Dade County School Board Revenues, and Florida Power & Light Turkey Point Property Tax Payments for Turkey Point Units 3 and 4 (2012–2017)

	2012	2013	2014	2015	2016	2017
Miami-Dade County Total Operating Revenues (in billions of dollars)	5.399	5.375	5.423	5.612	5.792	4.865
Miami-Dade County School Board Revenues (in billions of dollars)	3.222	3.302	3.524	3.581	3.631	3.729
Turkey Point Units 3 and 4 total property tax paid (in millions of dollars)	6.653	29.613	40.594	38.995	37.882	36.570
Tax payment assigned to Miami-Dade County (percent of total Miami-Dade County Revenues)	3.446 (0.06)	15.280 (0.3)	21.108 (0.3)	20.394 (0.5)	20.229 (0.4)	19.858 (0.4)
Tax payment assigned to Miami-Dade County School District (percent of total Miami-Dade County School Board Revenues)	2.834 (0.08)	12.792 (0.4)	17.374 (0.5)	16.665 (0.5)	15.796 (0.4)	14.957 (0.4)
Tax payment assigned to special districts	0.372	1.629	2.070	1.911	1.856	1.755

Sources: FPL 2018f, FPL 2018h, MDC 2015b, MDC 2016b, MDC 2017f, MDCPS 2017b

FPL pays property taxes (real and tangible personal property) for Turkey Point to Miami-Dade County, the Miami-Dade County Public School District, and several regional taxing districts (FPL 2018f). Turkey Point property tax payment for 2012–2017 are presented in Table 3-24. The increase in property tax payment from 2012 to 2013 and from 2013 to 2014 is a result of plant modifications conducted to support an extended power uprate and the lien date (FPL 2018f and FPL 2018h). On June 15, 2012, the NRC granted a license amendment to FPL for an extended power uprate of Turkey Point (NRC 2012). Plant modifications and upgrades for the extended power uprate occurred in 2012 and 2013 and the valuation of the plant upgrades conducted in one year become taxable in the following year. This resulted in the Turkey Point property tax increases observed in 2013 and 2014. Turkey Point property tax payments to Miami-Dade County and Miami-Dade County Public School District have represented less than 1 percent of the Miami-Dade County revenue and of Miami-Dade County Public School District tax revenues. FPL does not expect there to be a notable or significant change to future property tax payments during the subsequent license renewal period (FPL 2018f).

In addition to property tax payments, FPL pays sales tax to Miami-Dade County for purchases. In 2017, FPL paid approximately \$224,000 in sale taxes to Miami-Dade County from Turkey Point operation expenses (FPL 2018h). FPL also contributes \$1.5 million annually to community organizations (FPL 2018h).

3.10.6 Local Transportation

The transportation network surrounding the Turkey Point site is comprised of U.S. highways, Interstate highways, local streets, and waterways. There are no ports or rail systems located within 6 mi (9.6 km) of the Turkey Point site. The nearest rail line, provided by CSX Corporation, is located approximately 10 mi (16 km) west of the Turkey Point site in Homestead, FL, and the Port of Miami is located approximately 23 mi (37 km) north of the site (CSX 2018). The NRC staff's EIS for the Turkey Point Units 6 and 7 combined license

application (NUREG–2176) describes this transportation network in Section 2.5.2.3 (NRC 2016a); the NRC staff incorporates pages 2-175 through 2-178 of NUREG–2176 into this SEIS by reference.

Access to the Turkey Point site is via East Palm Drive (SW 344 St). East Palm Drive is a four-lane road that turns into a two-lane road at its intersection with Tallahassee Road (SW 137th Avenue) as it leads to the Turkey Point site. East Palm Drive intersects with US-1 approximately 8 mi from the Turkey Point Site. East Palm Drive provides access to the Homestead-Miami Speedway and Homestead Bayfront Park. Table 3-25 lists U.S. highways and roads near Turkey Point and their average annual daily traffic (AADT) volumes. The 2017 average annual daily reported two-way traffic volume for the monitoring site closest to Turkey Point on East Palm Drive was 9,800 vehicles.

Table 3-25 2017 Annual Average Daily Traffic in the Vicinity of Turkey Point

Location	Mile Marker	Average Annual Daily Traffic
Palm Drive (SW 344 St.)		
East of SW 132nd Ave Intersection	2.2	9,800
Intersection of Krome Ave (SW-177)	8.6	23,000
US-1 (South Dixie Highway)		
South of Palm Drive Intersection	0.3	32,500
S Krome Ave		
Intersection of Canal Dr (SW 328)	1.7	16,400

Source: FDOT 2017

3.11 Human Health

Turkey Point is both an industrial facility and a nuclear power plant. Similar to any industrial facility or nuclear power plant, the operation of Turkey Point Units 3 and 4 over the subsequent license renewal period will produce various human health risks for workers and members of the public. This section describes the human health risks resulting from the operation of Turkey Point Units 3 and 4, including from radiological exposure, chemical hazards, microbiological hazards, electromagnetic fields, and other hazards.

3.11.1 Radiological Exposure and Risk

Operation of a nuclear power plant involves the use of nuclear fuel to generate electricity. Through the fission process, the nuclear reactor splits uranium atoms resulting very generally in (1) the production of heat which is then used to produce steam to drive the plant’s turbines and generate electricity and (2) the creation of radioactive byproducts. As required by NRC regulations at 10 CFR 20.1101, “Radiation protection programs,” FPL designed a radiation protection program to protect onsite personnel (including employees and contractor employees), visitors, and offsite members of the public from radiation and radioactive material at Turkey Point.

The Turkey Point Units 3 and 4 radiation protection program is extensive and includes, but is not limited to, the following:

- Organization and Administration (e.g., a radiation protection manager who is responsible for the program and who ensures trained and qualified workers for the program)
- Implementing Procedures
- ALARA (as-low-as-is-reasonably-achievable) Program to minimize dose to workers and members of the public
- Dosimetry Program (i.e., measure radiation dose of plant workers)
- Radiological Controls (e.g., protective clothing, shielding, filters, respiratory equipment, and individual work permits with specific radiological requirements)
- Radiation Area Entry and Exit Controls (e.g., locked or barricaded doors, interlocks, local and remote alarms, personnel contamination monitoring stations)
- Posting of Radiation Hazards (i.e., signs and notices alerting plant personnel of potential hazards)
- Recordkeeping and Reporting (e.g., documentation of worker dose and radiation survey data)
- Radiation Safety Training (e.g., classroom training and use of mockups to simulate complex work assignments)
- Radioactive Effluent Monitoring Management (i.e., controlling and monitoring radioactive liquid and gaseous effluents released into the environment)
- Radioactive Environmental Monitoring (e.g., sampling and analysis of environmental media, such as direct radiation, air, water, groundwater, broad leaf vegetation, fish, shellfish, and sediment to measure the levels of radioactive material in the environment that may impact human health)
- Radiological Waste Management (i.e., controlling, monitoring, processing, and disposing of radioactive solid waste)

Regarding radiation exposure to Turkey Point Units 3 and 4 personnel, the NRC staff reviewed the data contained in NUREG–0713, Volume 39, “Occupational Radiation Exposure at Commercial Nuclear Power Reactors and other Facilities 2017: Fiftieth Annual Report” (NRC 2019b). The fiftieth annual report was the most recent annual report available at the time of this environmental review. It summarizes the NRC’s Radiation Exposure Information and Reporting System database’s occupational exposure data through 2017. Nuclear power plants are required by 10 CFR 20.2206, “Reports of individual monitoring,” to report their occupational exposure data to the NRC annually. Chapter 4, “Environmental Consequences and Mitigating Actions,” in this SEIS includes further discussion of radiological doses associated with the Turkey Point Units 3 and 4 subsequent license renewal.

NUREG–0713 calculates a 3-year average collective dose per reactor for workers at all nuclear power reactors licensed by the NRC. The 3-year average collective dose is one of the metrics that the NRC uses in the reactor oversight program to evaluate the applicant’s ALARA program. Collective dose is the sum of the individual doses received by workers at a facility licensed to use radioactive material over a 1-year time period. There are no NRC or EPA standards for collective dose. Based on the data for operating pressurized-water reactors like the ones at

Turkey Point Units 3 and 4, the average annual collective dose per reactor was 37 person-rem. In comparison, Turkey Point Units 3 and 4 had a reported annual collective dose per reactor of 44 person-rem.

In addition, as reported in NUREG–0713, for 2017, no worker at Turkey Point Units 3 and 4 received an annual dose greater than 0.75 rem (0.0075 sievert (Sv)), which is much less than the NRC occupational dose limit of 5.0 rem (0.05 Sv) in 10 CFR 20.1201, “Occupational dose limits for adults.”

Offsite dose to members of the public is discussed in Section 3.1.4, “Radioactive Waste Management Systems,” of this SEIS.

3.11.2 Chemical Hazards

State and Federal environmental agencies regulate the use, storage, and discharge of chemicals, biocides, and sanitary wastes. Such environmental agencies also regulate how facilities like Turkey Point manage minor chemical spills. Chemical and hazardous wastes can potentially impact workers, members of the public, and the environment.

FPL currently controls the use, storage, and discharge of chemicals and sanitary wastes at Turkey Point Units 3 and 4 in accordance with its chemical control procedures, waste-management procedures, and Turkey Point site-specific chemical spill prevention plans. FPL monitors and controls discharges of chemical and sanitary wastes through Turkey Point Unit 3 and 4’s NPDES permit process. These plant procedures, plans, and processes are designed to prevent and minimize the potential for a chemical or hazardous waste release and, in the event of such a release, minimize impact to workers, members of the public, and the environment (FPL 2018f).

3.11.3 Microbiological Hazards

Nuclear power plants that discharge thermal effluents to cooling ponds, lakes, canals, or rivers have the potential to promote the increased growth of thermophilic microorganisms, which could result in adverse health effects for plant workers and the public. Microorganisms of particular concern include several types of bacteria (*Legionella* spp., *Salmonella* spp., *Shigella* spp., and *Pseudomonas aeruginosa*) and the free-living amoeba *Naegleria fowleri*, all of which require freshwater environments. Because Turkey Point withdraws from and discharges to the CCS, which is a saline environment, the above freshwater microorganisms are not a concern at Turkey Point, and this SEIS provides no further discussion of them. Section 3.9.3.1 of the license renewal GEIS (NUREG–1437) (NRC 2013a) provides additional background information on these microorganisms.

3.11.4 Electromagnetic Fields

Based on its evaluation in the license renewal GEIS (NUREG–1437), the NRC has not found electric shock resulting from direct access to energized conductors or from induced charges in metallic structures to be a problem at most operating plants. Generally, the NRC staff also does not expect electric shock from such sources to be a human health hazard during the subsequent license renewal period. However, a site-specific review is required to determine the significance of the electric shock potential along the portions of the transmission lines that are within the scope of this SEIS. Transmission lines that are within the scope of the NRC’s subsequent license renewal environmental review are limited to: (1) those transmission lines

that connect the nuclear plant to the substation where electricity is fed into the regional distribution system and (2) those transmission lines that supply power to the nuclear plant from the grid (NRC 2013a).

As discussed in Section 3.1.6.5, “Power Transmission Systems,” of this SEIS, the only transmission lines that are in scope for Turkey Point subsequent license renewal are onsite. Specifically, these onsite, in-scope transmission lines are approximately 590 feet (180 m) and connect Units 3 and 4 to the onsite 230-kV switchyard (FPL 2018f). Therefore, there is no potential shock hazard to offsite members of the public from these onsite transmission lines. As discussed in Section 3.11.5, “Other Hazards,” of this SEIS, Turkey Point maintains an occupational safety program, which includes protection from acute electrical shock, and is in accordance with Occupational Safety and Health Administration regulations.

3.11.5 Other Hazards

This section addresses two additional human health hazards: (1) physical occupational hazards and (2) occupational electric shock hazards.

Nuclear power plants are industrial facilities that have many of the typical occupational hazards found at any other electric power generation utility. Nuclear power plant workers may perform electrical work, electric power line maintenance, repair work, and maintenance activities and may be exposed to some potentially hazardous physical conditions (e.g., falls, excessive heat, cold, noise, electric shock, and pressure).

The Occupational Safety and Health Administration (OSHA) is responsible for developing and enforcing workplace safety regulations. Congress created OSHA by enacting the Occupational Safety and Health Act of 1970, as amended (29 U.S.C. 651 et seq.) to safeguard the health of workers. With specific regard to nuclear power plants, plant conditions that result in an occupational risk, but do not affect the safety of licensed radioactive materials, are under the statutory authority of OSHA rather than the NRC as set forth in a memorandum of understanding (NRC 2013f) between the NRC and OSHA. Occupational hazards are reduced when workers adhere to safety standards and use appropriate protective equipment; however, fatalities and injuries from accidents may still occur. Turkey Point Units 3 and 4 maintain an occupational safety program for its workers in accordance with OSHA regulations (FPL 2018f).

3.12 Environmental Justice

Under Executive Order (EO) 12898, “Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations” (59 FR 7629), Federal agencies are responsible for identifying and addressing, as appropriate, disproportionately high and adverse human health and environmental impacts on minority and low-income populations. Independent agencies, such as the NRC, are not bound by the terms of EO 12898 but are, as stated in paragraph 6-604 of the executive order, “requested to comply with the provisions of [the] order.” In 2004, the Commission issued the agency’s “Policy Statement on the Treatment of Environmental Justice Matters in NRC Regulatory and Licensing Actions” (69 FR 52040), which states, ““The Commission is committed to the general goals set forth in [EO] 12898, and strives to meet those goals as part of its NEPA review process.”

The Council on Environmental Quality (CEQ) provides the following information in its publication “Environmental Justice: Guidance Under the National Environmental Policy Act” (CEQ 1997):

Disproportionately High and Adverse Human Health Effects.

Adverse health effects are measured in risks and rates that could result in latent cancer fatalities, as well as other fatal or nonfatal adverse impacts on human health. Adverse health effects may include bodily impairment, infirmity, illness, or death. Disproportionately high and adverse human health effects occur when the risk or rate of exposure to an environmental hazard for a minority or low-income population is significant (as employed by NEPA) and appreciably exceeds the risk or exposure rate for the general population or for another appropriate comparison group (CEQ 1997).

Disproportionately High and Adverse Environmental Effects.

A disproportionately high environmental impact that is significant (as employed by NEPA) refers to an impact or risk of an impact on the natural or physical environment in a low-income or minority community that appreciably exceeds the environmental impact on the larger community. Such effects may include ecological, cultural, human health, economic, or social impacts. An adverse environmental impact is an impact that is determined to be both harmful and significant (as employed by NEPA). In assessing cultural and aesthetic environmental impacts, impacts that uniquely affect geographically dislocated or dispersed minority or low-income populations or American Indian tribes are considered (CEQ 1997).

This environmental justice analysis assesses the potential for disproportionately high and adverse human health or environmental effects on minority and low-income populations that could result from the operation of Turkey Point Units 3 and 4 during the subsequent license renewal period of extended operation. In assessing the impacts, the NRC staff used the following definitions of minority individuals, minority populations, and low-income population (CEQ 1997):

Minority Individuals

Individuals who identify themselves as members of the following population groups: Hispanic or Latino, American Indian or Alaskan Native, Asian, Black or African American, Native Hawaiian or Other Pacific Islander, or two or more races, meaning individuals who identified themselves on a Census form as being a member of two or more races, for example, White and Asian. In other words, everyone except persons who identified themselves as White, Not Hispanic or Latino are considered minority.

Minority Populations

Minority populations are identified when (1) the minority population of an affected area exceeds 50 percent or (2) the minority population percentage of the affected area is meaningfully greater than the minority population percentage in the general population or other appropriate unit of geographic analysis.

Low-income Population

Low-income populations in an affected area are identified with the annual statistical poverty thresholds from the Census Bureau's Current Population Reports, Series P60, on Income and Poverty.

In determining the location of minority and/or low-income populations, the geographic area used to perform a comparative analysis is a 50-mi (80-km) radius from the facility. The 50-mi (80-km) radius is consistent with the impact analysis conducted for human health impacts. The percentage of minority and/or low-income populations in the 50-mi geographic area is compared to the percentage of minority and/or low-income populations in each census block group to determine which block groups exceeds the percentage, thereby identifying the location of these populations (NRC 2013c).

Minority Population

According to the Census Bureau's 2010 Census data, there are a total 2,152 block groups, and approximately 78 percent of the population residing within a 50-mi (80-km) radius of Turkey Point identified themselves as minority individuals (USCB 2010b). The largest minority populations were Hispanic or Latino of any race (approximately 55 percent) followed by Black or African American (approximately 19 percent).

According to the Council on Environmental Quality guidance, a minority population exists if the percentage of the minority population of an area (e.g., census block group) exceeds 50 percent or is meaningfully greater than the minority population percentage in the general population. In this SEIS, the NRC staff's environmental justice analysis applied the meaningfully greater threshold in identifying higher concentrations of minority populations. The meaningfully greater threshold is any percentage greater than the minority population within the 50-mi radius. Therefore, for the purposes of identifying higher concentrations of minority populations, census block groups within the 50-mi (80-km) radius of Turkey Point were identified as minority population block groups if the percentage of the minority population in the block group exceeded 78 percent, which is the percent of the minority population within the 50-mi (80-km) radius of Turkey Point.

As shown in Figure 3-38, minority population block groups are notable and located throughout the 50-mi (80-km) radius of Turkey Point. Based on this analysis, there are 1,247 minority population block groups (using the "meaningfully greater" threshold of 78 percent minority population) within the 50-mi (80-km) radius of Turkey Point and minority population block groups are clustered around the cities of Miami, Miramar, Miami-Gardens, Hialeah, Homestead, Florida City, and the Everglades census county subdivision. Turkey Point is located in a minority population block group.

As presented in Section 3.10, "Socioeconomics," of this SEIS, in 2010, the minority population in Miami-Dade County was approximately 85 percent and the minority population in the State of Florida was approximately 42 percent. According to the Census Bureau's 2016 American Community Survey 1-Year Estimates, since 2010, minority populations in Miami-Dade County have increased by approximately 232,000 persons. The largest increases occurred in the Hispanic or Latino population (nearly 212,000 person increases since 2010, an increase of approximately 13 percent).


Low-Income Population

The Census Bureau's 2012–2016 American Community Survey data identify approximately 18 percent of individuals residing within a 50-mi (80-km) radius of Turkey Point as living below the Federal poverty threshold (USCB 2016f). The 2016 Federal poverty threshold was \$24,563 for a family of four (USCB 2016g).

Figure 3-39 shows the location of predominantly low-income population block groups within a 50-mi (80-km) radius of Turkey Point. In accordance with NRC guidance (NRC 2013a), census block groups were considered low-income population block groups if the percentage of individuals living below the Federal poverty threshold within the block group exceeded 18 percent, which is the percent of the individuals living below the Federal poverty threshold within the 50-mi (80-km) radius of Turkey Point.


As shown in Figure 3-39, low income population block groups are clustered in the cities of Miami, Hialeah, and Fort Lauderdale, and in the Everglades and Homestead census county subdivisions. Based on this analysis, there are 1,010 low-income population block groups (approximately 50 percent of the block groups within 50 mi (80 km) of Turkey Point) and Turkey Point is located in a low-income population block group.

As presented in Table 3-16, people living in Miami-Dade County (the socioeconomic region of influence) have lower median household and per capita incomes than average for the State of Florida and a higher percentage of families and people living below the poverty level.



Source: USCB 2010b

Figure 3-38 2010 Census—Minority Block Groups Within a 50-mi (80-km) Radius of Turkey Point



Source: USCB 2016f

Figure 3-39 2012–2016, American Community Survey 5-Year Estimates—Low-Income Block Groups Within a 50-mi (80-km) Radius of Turkey Point

3.13 Waste Management and Pollution Prevention

Like any operating nuclear power plant, Turkey Point Units 3 and 4 will produce both radioactive and nonradioactive waste during the subsequent license renewal period. This section describes waste management and pollution prevention at Turkey Point.

3.13.1 Radioactive Waste

As discussed in Section 3.1.4, “Radioactive Waste Management Systems,” of this SEIS, Turkey Point uses liquid, gaseous, and solid waste processing systems to collect and treat, as needed, radioactive materials produced as a byproduct of plant operations. Nearly all radioactive materials in liquid and gaseous effluents are reduced prior to being released into the environment so that the resultant dose to members of the public from these effluents is well within NRC and EPA dose standards. Radionuclides that can be efficiently removed from the liquid and gaseous effluents prior to release are converted to a solid waste form for disposal in a licensed disposal facility.

3.13.2 Nonradioactive Waste

Waste minimization and pollution prevention are important elements of operations at all nuclear power plants. Licensees are required to consider pollution prevention measures as dictated by the Pollution Prevention Act (Public Law 101-508) and the Resource Conservation and Recovery Act of 1976, as amended (Public Law 94-580) (NRC 2013a).

As described in Section 3.1.5, “Nonradioactive Waste Management System,” Turkey Point has a nonradioactive waste management program to handle nonradioactive waste in accordance with Federal, State, and corporate regulations and procedures. Turkey Point maintains a waste minimization program that uses material control, process control, waste management, recycling, and feedback to reduce waste.

Turkey Point has a Stormwater Pollution Prevention Plan that identifies potential sources of pollution that may affect the quality of stormwater discharges from permitted outfalls. The Stormwater Pollution Prevention Plan also describes best management practices for reducing pollutants in stormwater discharges and assure compliance with the site’s FDEP permit.

Turkey Point also has a Spill Prevention, Control, and Countermeasure (SPCC) plan (see FPL’s environmental report for subsequent license renewal, Section 9.5.3.6) to monitor areas within the site that have the potential to discharge oil into or upon navigable waters, in accordance with the regulations in 40 CFR Part 112, “Oil Pollution Prevention.” The SPCC plan identifies and describes the procedures, materials, equipment, and facilities that FPL uses to minimize the frequency and severity of oil spills at Turkey Point.

Turkey Point is subject to EPA reporting requirements in 40 CFR Part 110, “Discharge of Oil,” pursuant to Section 311(b)(4) of the Federal Water Pollution Control Act. Under these regulations, FPL must report to the National Response Center any discharges of oil if the quantity may be harmful to the public health or welfare or to the environment. From 2012 through 2018, FPL reported no oil discharges that triggered the EPA’s reporting requirements in 40 CFR Part 110.

Turkey Point is also subject to the reporting provisions of the Florida Administrative Code (FAC) at 62-780.210, Contamination Reporting, concerning the discovery of petroleum or petroleum

products contamination or a discharge of petroleum or petroleum products, as well as other FAC reporting requirements. Thus, the NRC staff expects that petroleum and petroleum product spills would be reported to the appropriate regulatory authority.

The NRC staff issued two requests for additional information to FPL regarding reportable spills at Turkey Point. In the first request, the NRC staff asked FPL to provide additional information to the NRC as to whether there have been any reportable spills (discharge of oil) that may be harmful, pursuant to Section 311(b)(4) of the Federal Water Pollution Control Act, that occurred after FPL wrote and submitted its environmental report for the subsequent license renewal application. In its August 2018 response (FPL 2018b, NRC RAI Number: WM-1), FPL stated that “based on the listing of calls received by the U.S. Coast Guard National Response Center, there have been no reportable spills triggering the 40 CFR Part 110 notification requirement at Turkey Point since the ER was written” (USCG 2018).

In its second request for additional information on reportable spills, the NRC staff asked FPL to provide additional information to the NRC as to whether, after the environmental report was written, there have been any reportable spills (discharge of oil) at Turkey Point that may have had the potential to significantly pollute surface waters or groundwater and which were not confined to a building or similar structure. FPL stated in its August 2018 response (FPL 2018g, NRC RAI Number: WM-2) that “There have been no reportable spills triggering the FAC 62-780.110 notification requirement since the ER was submitted.”

4 ENVIRONMENTAL CONSEQUENCES AND MITIGATING ACTIONS

4.1 Introduction

In this chapter, the U.S. Nuclear Regulatory Commission (NRC) staff evaluates the environmental consequences of issuing subsequent renewed licenses authorizing an additional 20 years of operation for Turkey Point Nuclear Generating Unit Nos. 3 and 4 (Turkey Point, or Turkey Point Units 3 and 4). The NRC staff's evaluation of environmental consequences includes the following:

- 1) impacts associated with continued operations similar to those impacts that have occurred during the current renewed license term
- 2) impacts of various alternatives to the proposed action, including a no-action alternative (not issuing the subsequent renewed licenses); replacement power alternatives (new nuclear; natural gas combined-cycle; and a combination of natural gas and solar power); and an alternate cooling water system alternative using mechanical draft cooling towers.
- 3) impacts from the termination of nuclear power plant operations and decommissioning after the subsequent license renewal term (with emphasis on the incremental effect caused by an additional 20 years of reactor operation)
- 4) impacts associated with the uranium fuel cycle
- 5) impacts of postulated accidents (design-basis accidents and severe accidents)
- 6) cumulative impacts of the proposed action of issuing subsequent renewed licenses for Turkey Point
- 7) resource commitments associated with the proposed action, including unavoidable adverse impacts, the relationship between short-term use and long-term productivity, and irreversible and irretrievable commitment of resources
- 8) new and potentially significant information on environmental issues related to the impacts of operation during the subsequent license renewal term

In this chapter, the NRC staff also compares the environmental impacts of subsequent license renewal with the environmental impacts of the no-action alternative and replacement power alternatives to determine whether the adverse environmental impacts of subsequent license renewal are so great that it would be unreasonable to preserve the option of subsequent license renewal for energy-planning decisionmakers. Chapter 2, "Alternatives Including the Proposed Action," of this supplemental environmental impact statement (SEIS) describes in detail the attributes of the proposed action (subsequent license renewal of Turkey Point) and the no-action alternative. Chapter 2, Section 2.2.2, "Replacement Power Alternatives," further describes the NRC staff's process for developing a range of reasonable alternatives to the proposed action and the replacement power alternatives that the staff selected for detailed analysis in this chapter, including supporting assumptions and data. As noted in Chapter 2, Table 2.1, the site location for various replacement power alternatives would be adjacent to Turkey Point Units 3 and 4. Chapter 2, Table 2.2, summarizes the environmental impacts of the proposed action and alternatives to the proposed action.

The affected environment (i.e., environmental baseline) for each resource area considered, and against which the potential environmental impacts of the alternatives are measured, is described in Chapter 3, “Affected Environment.” As documented in Chapter 3, the effects of ongoing reactor operations at Turkey Point have become well established as environmental conditions have adjusted to and reflect the presence of the nuclear power plant.

The environmental impacts of the alternative cooling water system are described in this SEIS within the discussion of each separate resource area (e.g., Sections 4.2.7, 4.3.7, 4.4.7, 4.5.7, 4.6.7, 4.7.7, 4.9.4, 4.10.7, 4.11.7, 4.12.4, and 4.13.7). The benefits of the alternative cooling water system are that the impacts of utilizing the cooling canal system (CCS) for cooling of Turkey Point Units 3 and 4 would be avoided; those impacts are discussed extensively in this SEIS; the avoidance of those impacts of CCS operation (e.g., on groundwater resources) is discussed in Subsection 4.5.2, “No-Action Alternative,” in Section 4.5, “Water Resources,” in that use of the CCS to cool Units 3 and 4 would cease at the end of the current license terms if the Turkey Point subsequent license renewal (SLR) application is denied.

This SEIS documents the NRC staff’s environmental review of the Turkey Point subsequent license renewal application and supplements the information in NUREG–1437, “Generic Environmental Impact Statement for License Renewal of Nuclear Plants” (also known as the 2013 GEIS) (NRC 2013a). The 2013 GEIS identifies 78 issues (divided into Category 1 and Category 2 issues) to be evaluated for the proposed action in the environmental review process. Section 1.4, “Generic Environmental Impact Statement,” of this SEIS provides an explanation of the criteria for Category 1 issues (i.e., those issues generic to all nuclear power plants or a distinct subset of plants) and Category 2 issues (i.e., those issues specific to individual nuclear power plants) as well as the definitions of SMALL, MODERATE, and LARGE impact significance.

For Category 1 issues, the NRC staff can rely on the analysis in the GEIS unless otherwise noted. Table 4-1 lists the Category 1 (generic) issues that apply to Turkey Point during the proposed subsequent license renewal period. For each Category 1 issue, the NRC staff considered whether there is any new and significant information that might alter the conclusions reached in the GEIS for that issue. As discussed in Section 4.14 of this SEIS, Regulatory Guide (RG) 4.2, Supplement 1, “Preparation of Environmental Reports for Nuclear Power Plant License Renewal Applications” (NRC 2013g), defines “new and significant information” as (1) information that identifies a significant environmental impact issue that was not considered or addressed in the GEIS and, consequently, not codified in Table B-1, in Appendix B to Subpart A of 10 CFR Part 51, or (2) information not considered in the assessment of impacts evaluated in the GEIS leading to a seriously different picture of the environmental consequences of the action than previously considered, such as an environmental impact finding different from that codified in Table B-1. For most issues, the NRC staff did not identify any new and significant information during its review of Florida Power & Light Company’s (FPL’s) environmental report, the site audits, or the scoping period that would change the conclusions in the GEIS. Therefore, there are no impacts related to those Category 1 issues beyond those already discussed in the GEIS. The staff’s process for evaluating new and significant information is described in Section 4.14, “Evaluation of New and Significant Information.”

The NRC staff identified and evaluated new information for two existing Category 1 issues (i.e., groundwater quality degradation (plants with cooling ponds in salt marshes) and cooling system impacts on terrestrial resources (plants with once-through cooling systems or cooling ponds)) and identified one new issue (i.e., water quality impacts on adjacent water bodies

(plants with cooling ponds in salt marshes)). The NRC staff's evaluation of these three issues is presented in Sections 4.5.1.1, 4.5.1.2, and 4.6.1 of this SEIS.

Table 4-1 Applicable Category 1 (Generic) Issues for Turkey Point

Issue	GEIS Section	Impact
Land Use		
Onsite land use	4.2.1.1	SMALL
Offsite land use	4.2.1.1	SMALL
Visual Resources		
Aesthetic impacts	4.2.1.2	SMALL
Air Quality		
Air quality impacts (all plants)	4.3.1.1	SMALL
Air quality effects of transmission lines	4.3.1.1	SMALL
Noise		
Noise impacts	4.3.1.2	SMALL
Geologic Environment		
Geology and soils	4.4.1	SMALL
Surface Water Resources		
Surface water use and quality (non-cooling system impacts)	4.5.1.1	SMALL
Discharge of metals in cooling system effluent	4.5.1.1	SMALL
Discharge of biocides, sanitary wastes, and minor chemical spills	4.5.1.1	SMALL
Effects of dredging on surface water quality	4.5.1.1	SMALL
Groundwater Resources		
Groundwater contamination and use (non-cooling system impacts)	4.5.1.2	SMALL
Groundwater quality degradation resulting from water withdrawals	4.5.1.2	SMALL
Groundwater quality degradation (plants with cooling ponds in salt marshes) ^(a)	4.5.1.2	SMALL ^(b)
Terrestrial Resources		
Exposure of terrestrial organisms to radionuclides	4.6.1.1	SMALL
Cooling system impacts on terrestrial resources (plants with once-through cooling systems or cooling ponds) ^(a)	4.6.1.1	SMALL
Bird collisions with plant structures and transmission lines	4.6.1.1	SMALL
Transmission line right-of-way management impacts on terrestrial resources ^(c)	4.6.1.1	SMALL
Electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees, wildlife, livestock)	4.6.1.1	SMALL
Aquatic Resources		
Entrainment of phytoplankton and zooplankton (all plants)	4.6.1.2	SMALL
Infrequently reported thermal impacts (all plants)	4.6.1.2	SMALL
Effects of cooling water discharge on dissolved oxygen, gas supersaturation, and eutrophication	4.6.1.2	SMALL

Issue	GEIS Section	Impact
Effects of non-radiological contaminants on aquatic organisms	4.6.1.2	SMALL
Exposure of aquatic organisms to radionuclides	4.6.1.2	SMALL
Effects of dredging on aquatic resources	4.6.1.2	SMALL
Effects on aquatic resources (non-cooling system impacts)	4.6.1.2	SMALL
Impacts of transmission line right-of-way management on aquatic resources ^(c)	4.6.1.2	SMALL
Losses from predation, parasitism, and disease among organisms exposed to sublethal stresses	4.6.1.2	SMALL
Socioeconomics		
Employment and income, recreation and tourism	4.8.1.1	SMALL
Tax revenues	4.8.1.2	SMALL
Community services and education	4.8.1.3	SMALL
Population and housing	4.8.1.4	SMALL
Transportation	4.8.1.5	SMALL
Human Health		
Radiation exposures to the public	4.9.1.1.1	SMALL
Radiation exposures to plant workers	4.9.1.1.1	SMALL
Human health impact from chemicals	4.9.1.1.2	SMALL
Microbiological hazards to plant workers	4.9.1.1.3	SMALL
Physical occupational hazards	4.9.4.1.5	SMALL
Postulated accidents		
Design-basis accidents	4.9.1.2	SMALL
Waste Management		
Low-level waste storage and disposal	4.11.1.1	SMALL
Onsite storage of spent nuclear fuel	4.11.1.2	SMALL
Offsite radiological impacts of spent nuclear fuel and high-level waste disposal	4.11.1.3	^(d)
Mixed-waste storage and disposal	4.11.1.4	SMALL
Nonradioactive waste storage and disposal	4.11.1.4	SMALL
Uranium Fuel Cycle		
Offsite radiological impacts—individual impacts from other than the disposal of spent fuel and high-level waste	4.12.1.1	SMALL
Offsite radiological impacts—collective impacts from other than the disposal of spent fuel and high-level waste	4.12.1.1	^(e)
Nonradiological impacts of the uranium fuel cycle	4.12.1.1	SMALL
Transportation	4.12.1.1	SMALL
Termination of Nuclear Power Plant Operations and Decommissioning		
Termination of plant operations and decommissioning	4.12.2.1	SMALL

Issue	GEIS Section	Impact
<p>(a) The environmental impact of this issue includes consideration of site-specific new information for Turkey Point.</p> <p>(b) The NRC staff recognizes that the current impacts on this issue are greater than SMALL (i.e., the impacts are MODERATE). However, as discussed in Section 4.5.1.2 of this chapter, in response to a 2015 Consent Agreement with the Miami-Dade County Department of Environmental Resource Management (DERM) (MDC 2015a) and a 2016 Consent Order from the Florida Department of Environmental Protection (FDEP) (FDEP 2016a), FPL has implemented a recovery well system to halt and retract the hypersaline plume and to abate and remediate the effects of the hypersaline plume from the cooling canal system. These efforts are expected to remediate the hypersaline plume prior to the commencement of the subsequent license renewal term. In addition, FPL's actions to remediate the plume are subject to continued regulatory oversight by the DERM and the FDEP. Therefore, the NRC staff expects that groundwater quality degradation impacts resulting from subsequent license renewal will be SMALL.</p> <p>(c) This issue applies only to the in-scope portion of electric power transmission lines, which are defined as transmission lines that connect the nuclear power plant to the substation where electricity is fed into the regional power distribution system and transmission lines that supply power to the nuclear plant from the grid.</p> <p>(d) The environmental impact of this issue for the time frame beyond the licensed life for reactor operations is contained in NUREG-2157, the NRC's "Generic Environmental Impact Statement for Continued Storage of Spent Nuclear Fuel" (NRC 2014c).</p> <p>(e) There are no regulatory limits applicable to collective doses to the general public from fuel-cycle facilities. The practice of estimating health effects on the basis of collective doses may not be meaningful. All fuel-cycle facilities are designed and operated to meet the applicable regulatory limits and standards. The Commission concludes that the collective impacts are acceptable. The Commission concludes that the impacts would not be sufficiently large to require the National Environmental Policy Act (NEPA) conclusion, for any plant, that the option of extended operation under Title 10 of the <i>Code of Federal Regulations</i> (10 CFR) Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants," should be eliminated. Accordingly, while the Commission has not assigned a single level of significance for the collective impacts of the uranium fuel cycle, this issue is considered Category 1.</p>		

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51 and NRC 2013a

The NRC staff analyzed the Category 2 (site-specific) issues applicable to Turkey Point during the proposed subsequent license renewal period and assigned impacts to these issues as shown below in Table 4-2.

Table 4-2 Applicable Category 2 (Site-Specific) Issues for Turkey Point

Issue	GEIS Section	Impact^(a)
Groundwater Resources		
Groundwater use conflicts (plants that withdraw more than 100 gallons per minute (gpm))	4.5.1.2	SMALL to MODERATE
Radionuclides released to groundwater	4.5.1.2	SMALL
Terrestrial Resources		
Effects on terrestrial resources (non-cooling system impacts)	4.6.1.1	SMALL
Aquatic Resources		
Impingement and entrainment of aquatic organisms (plants with once-through cooling systems or cooling ponds)	4.6.1.2	SMALL to MODERATE ^(b)
Thermal impacts on aquatic organisms (plants with once-through cooling systems or cooling ponds)	4.6.1.2	SMALL to MODERATE ^(b)
Special Status Species and Habitats		
Threatened, endangered, and protected species and essential fish habitat	4.6.1.3	Impact determinations vary by species and habitat ^(c)
Historic and Cultural Resources		
Historic and cultural resources	4.7.1	would not adversely affect known historic properties or historic and cultural resources
Human Health		
Chronic effects of electromagnetic fields ^(d)	4.9.1.1.1	Uncertain Impact
Electric shock hazards	4.9.1.1.1	SMALL
Postulated Accidents		
Severe accidents	4.9.1.2	SMALL
Environmental Justice Minority and low-income populations	4.10.1	no disproportionately high and adverse human health and environmental effects
Cumulative Impacts		
Cumulative impacts	4.13	See SEIS Section 4.16

Issue	GEIS Section	Impact ^(a)
<p>(a) Impact determinations for Category 2 issues are based on findings described in Sections 4.2 through 4.13 of this SEIS for the proposed action.</p> <p>(b) The conclusion of “SMALL to MODERATE” applies to aquatic resources in the cooling canal system. Aquatic organisms inhabiting Biscayne Bay and connected waterbodies (e.g., Card Sound, the Atlantic Ocean) are not subject to impingement and entrainment because they do not interact with the Turkey Point intake structure, and there are no thermal effects outside the cooling canal system because there are no surface water connections that allow flow between the waters of Biscayne Bay and the cooling canal system.</p> <p>(c) The NRC staff concludes that Turkey Point subsequent license renewal is likely to adversely affect the American crocodile and the eastern indigo snake, and may result in adverse modification to designated critical habitat of the American crocodile. The NRC staff concludes that proposed action may affect, but is not likely to adversely affect, the Florida panther, West Indian manatee, red knot, wood stork, loggerhead sea turtle, green sea turtle, leatherback sea turtle, hawksbill sea turtle, Kemp’s ridley sea turtle, and smalltooth sawfish. The NRC staff concludes that the proposed action would result in no adverse modification to designated critical habitat of the West Indian manatee. The NRC staff’s evaluation of impacts to federally listed species and critical habitats under the U.S. Fish and Wildlife Service’s jurisdiction appears in the NRC’s Biological Assessment (NRC 2018n). The FWS’s separate evaluation and conclusions appear in a July 25, 2019, biological opinion (FWS 2019b), which is described in Section 4.8.1.1 of this SEIS. The NRC staff’s evaluation of impacts to federally listed species and critical habitats under the National Marine Fisheries Service’s jurisdiction appears in Section 4.8.1.1 of this SEIS. The NRC staff concludes that the proposed action would have no adverse effects on Essential Fish Habitat. The NRC staff’s evaluation of impacts to Essential Fish Habitat appears in Section 4.8.1.2 of this SEIS. The NRC staff concludes that the proposed action would not affect the sanctuary resources of the Florida Keys National Marine Sanctuary. The NRC staff’s evaluation of sanctuary resources appears in Section 4.8.1.3 of this SEIS.</p> <p>(d) This issue was not designated as Category 1 or Category 2 and is discussed in Section 4.11.1, “Proposed Action.”</p>		

Source: Table B-1 in Appendix B, Subpart A, to 10 CFR Part 51 and NRC 2013a

4.2 Land Use and Visual Resources

This section describes the potential land use and visual resources impacts of the proposed action (subsequent license renewal) and alternatives to the proposed action.

4.2.1 Proposed Action

According to the GEIS (NRC 1996 and NRC 2013a), land use and visual resources would not be affected by continued operations and refurbishment associated with license renewal. In addition, nuclear plant operations at Turkey Point have not changed appreciably with time, and no change in land use and visual resources impacts are expected during the subsequent license renewal term. The NRC staff identified no new or significant information for these issues.

In this regard, no new or significant information was identified during the review of FPL’s environmental report, the NRC staff’s site visit, the scoping process, or the evaluation of other available information. The communities in the vicinity of Turkey Point have pre-established patterns of development and have adequate public services to support and guide development. Consequently, people living in the vicinity of Turkey Point would not experience any land use or

visual changes during the subsequent license renewal term beyond what has already been experienced. In addition, no adverse effects on offsite land use will occur related to the Everglades Restoration Project (conducted under the Comprehensive Everglades Restoration Plan (CERP)) or other Federal action in the proposed project area. Therefore, the land use and visual impacts of continued reactor operations during the subsequent license renewal term would not exceed the land use and visual impacts predicted in the GEIS. For these issues, the GEIS predicted that the impacts would be SMALL for all nuclear plants.

As identified in Table 4-1, the impacts of all generic land use or visual resource issues would be SMALL. Table 4-2 does not identify any site-specific (Category 2) land use or visual resource issues.

4.2.2 No-Action Alternative

4.2.2.1 Land Use

Under the no-action alternative, the NRC would not issue subsequent renewed licenses, and Turkey Point Units 3 and 4 would shut down on or before the expiration of the current renewed operating licenses (i.e., 2032 and 2033). Under this alternative, land uses would remain similar to those that would occur under the proposed subsequent license renewal except that land could be converted to other uses sooner if Turkey Point is shut down in 2032 and 2033 instead of operating for an additional 20 years. Shutdown of Turkey Point under the no-action alternative thus would not affect onsite land use. Plant structures and other facilities would remain in place until decommissioning. Most transmission lines would remain in service after the plant stops operating. Maintenance of most existing infrastructure would continue as before. Therefore, land use impacts from the termination of Turkey Point Unit Nos. 3 and 4 nuclear plant operations would be SMALL.

4.2.2.2 Visual Resources

Shutdown of Turkey Point under the no-action alternative would not significantly change the visual appearance of the Turkey Point site. At the Turkey Point site, the reactor and turbine buildings are the buildings that create the largest visual impact. Under the no-action alternative, the reactor and turbine buildings would likely remain in place for some time but would eventually be dismantled. This would reduce the visual impact. Overall, visual impacts from the termination of Turkey Point Unit Nos. 3 and 4 nuclear plant operations would be SMALL.

4.2.3 Replacement Power Alternatives: Common Impacts

4.2.3.1 Land Use

The NRC staff's analysis of land use impacts focuses on the amount of land area that would be affected by the construction and operation of a replacement power plant.

Construction

Construction would require the permanent commitment of land zoned for industrial use at the Turkey Point site for replacement power plants and associated infrastructure. Existing Turkey Point transmission lines and infrastructure would adequately support each of the replacement power alternatives, thus reducing the need for additional land commitments.

Operations

Operation of new power plants would have no land use impacts beyond land committed for the permanent use of the replacement power plant. Additional land may be required to support power plant operations including land for mining, extraction, and waste disposal activities associated with each alternative.

4.2.3.2 Visual Resources

The NRC staff's visual impact analysis focuses on the degree of contrast between the replacement power plant and the surrounding landscape and the visibility of the new power plant.

Construction

Land for any replacement power plant would require clearing, excavation, and the use of construction equipment. Temporary visual impacts may occur during construction from cranes and other construction equipment.

Operations

Visual impacts during plant operations of any of the replacement power alternatives would be similar in type and magnitude. New cooling towers (if built) and their associated plumes would be the most obvious visual impact and would likely be visible farther from the site than other buildings and infrastructure. New plant stacks may require aircraft warning lights, which would be visible at night.

4.2.4 New Nuclear Alternative

4.2.4.1 Land Use

Construction

Approximately 360 acres (ac) (150 hectares (ha)) of land would be needed to construct a new nuclear power plant. Although there is sufficient land available at the Turkey Point site, some wetlands may be temporarily displaced during construction. Land use impacts during construction would be SMALL at the Turkey Point site since the land is already zoned for industrial use.

Operations

Offsite land use impacts associated with uranium mining and fuel fabrication needed to support nuclear power plant operations would generally be no different from the amount of land needed to support Turkey Point Units 3 and 4 operations, although more land would be required for mining additional uranium for up to 40 years of operation. Based on this information, onsite and offsite land use impacts from constructing and operating a new nuclear power plant could range from SMALL to MODERATE depending on how much additional land may be needed for uranium mining and fuel fabrication.

4.2.4.2 *Visual Resources*

Construction and Operations

Visual impacts from a new nuclear alternative would be similar to the common impacts of all replacement power alternatives described in Section 4.2.3.2, “Visual Resources.” The visual appearance of the power block for the new nuclear power plant would be virtually identical to the existing Turkey Point Units 3 and 4 power blocks. Mechanical draft cooling towers and associated condensate plumes would add to the visual impact. However, the height of the mechanical draft cooling towers would not likely exceed those of other buildings at the Turkey Point site. Therefore, visual impacts during the construction and operation of a new nuclear power plant at the Turkey Point site, including steam plumes that could be visible from great distances, could range from SMALL to MODERATE depending on seasonal weather conditions.

4.2.5 Natural Gas Combined-Cycle Alternative

4.2.5.1 *Land Use*

Construction

The natural gas combined-cycle (NGCC or natural gas) power plant would require 75 ac (30 ha) of land with up to an additional 1,200 ac (490 ha) needed for right-of-way to connect with existing natural gas supply lines located approximately 100 miles (mi) (161 kilometers (km)) north of the Turkey Point site. No new gas wells would be needed to support a natural gas power plant (FPL 2018f). This land use impact would be partially offset by the elimination of land used for uranium mining to supply fuel to Turkey Point Units 3 and 4. Land use impacts caused by uranium mining and natural gas extraction and collection are described in Section 4.15.1, “Fuel Cycle.”

Constructing the natural gas power plant at the Turkey Point site would make use of available infrastructure. In addition, the land is already zoned for industrial use. However, some natural areas could be converted to industrial use if portions of the new power plant are built outside the existing industrial footprint. Although this use of the land would be noticeable, construction would not likely destabilize adjacent land use, due to the current industrial nature of the Turkey Point site. Accordingly, construction impacts could have SMALL to MODERATE land use impacts. This is primarily due to the amount of non-industrially zoned land that could be affected by this alternative.

Operations

Operation of a natural gas power plant would not cause any additional land use changes; therefore, land use impacts during operations would be SMALL. Overall land use impacts of the natural gas combined-cycle alternative, including both construction and operation, would therefore range from SMALL to MODERATE.

4.2.5.2 *Visual Resources*

Construction and Operations

Visual impacts from a natural gas power plant would be similar to the description in Section 4.2.3.2, “Visual Resources,” for the common impacts from all replacement power

alternatives. However, construction and operation of the natural gas power plant would have little to no additional visual impact. The height of the mechanical draft cooling towers would not likely exceed those of other buildings at the Turkey Point site. Therefore, visual impacts during the construction and operation of a new NGCC facility at the Turkey Point site, including steam plumes that could be visible from great distances, could range from SMALL to MODERATE depending on seasonal weather conditions.

4.2.6 Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)

4.2.6.1 Land Use

Construction and Operations

The natural gas power plant component of the combination alternative would require somewhat less land than the full-scale natural gas power plant described in Section 4.2.5.1. The natural gas power plant component would require 70 ac (28 ha) of land with up to an additional 1,200 ac (490 ha) needed for right-of-way to connect with existing natural gas supply lines located approximately 100 mi (161 km) north of the Turkey Point site. No new gas wells would be needed to support a natural gas power plant (FPL 2018f). Accordingly, land use impacts would be similar to or less than those described for the full-scale natural gas power plant alternative. However, the impacts could still range from SMALL to MODERATE.

A utility-scale solar photovoltaic (solar) facility would require approximately 470 ac (190 ha) of cleared land for the three proposed offsite solar power installations (FPL 2018f). Standalone solar facilities cannot be collocated with other land uses (such as grazing and crop-producing agricultural fields). Land use impacts would range from MODERATE to LARGE, depending on the amount and types of land uses that would be affected by construction of the four solar facilities.

Overall land use impacts of this combination natural gas and solar alternative would therefore range from SMALL to LARGE. This is primarily due to the amount and types of land uses that would be affected by the solar facilities.

4.2.6.2 Visual Resources

Construction and Operations

Visual impacts from the combination natural gas and solar alternative would be similar to the common impacts described in Section 4.2.3.2, "Visual Resources," for all replacement alternatives. However, construction and operation of the natural gas power plant would have little to no additional visual impact. The height of the mechanical draft cooling towers would likely not exceed those of other buildings at the Turkey Point site. Visual impacts of the natural gas component would be similar to the impacts described in Section 4.2.5.2.

The visual impacts of the solar components of this alternative would vary, depending on location and topography. Depending on the location, standalone solar facilities could have a MODERATE to LARGE visual impact. Visual resource impacts of the combination alternative could therefore range from SMALL to LARGE. This range is primarily due to the potential visual impacts from the solar photovoltaic components of this alternative.

4.2.7 Cooling Water System Alternative

4.2.7.1 Land Use

Construction and Operations

Construction of two mechanical draft cooling towers for a cooling water system alternative could require the relocation of existing support activities at the Turkey Point site. Because only previously disturbed industrial portions of the Turkey Point site would be used to accommodate the new cooling towers, land use impacts associated with the construction and operation of the mechanical draft cooling towers for the cooling water system alternative would be SMALL.

4.2.7.2 Visual Resources

Construction and Operations

Construction and operation of the two cooling towers for a cooling water system alternative would have little to no additional visual impact. The height of the mechanical draft cooling towers would be similar to the height of other buildings at the Turkey Point site. Temporary visual impacts may occur during construction from cranes and other construction equipment. During facility operations, cooling tower steam plumes could add to the existing visual impact. Therefore, visual impacts during the construction and operation of two new cooling towers at the Turkey Point site, including steam plumes that could be visible from great distances, could range from SMALL to MODERATE depending on seasonal weather conditions.

4.3 Air Quality and Noise

This section describes the potential air quality and noise impacts of the proposed action (subsequent license renewal) and alternatives to the proposed action.

4.3.1 Proposed Action

4.3.1.1 Air Quality

According to the GEIS (NRC 1996 and NRC 2013a), the generic issues related to air quality as identified in Table 4-1 above would not be affected by continued operations associated with license renewal. As discussed in Chapter 3, the NRC staff identified no new and significant information for these issues. Thus, as concluded in the GEIS, the impacts of those generic issues related to air quality would be SMALL. Table 4-2 does not identify any site-specific (Category 2) air quality issues for Turkey Point Units 3 and 4.

4.3.1.2 Noise

According to the GEIS (NRC 1996 and NRC 2013a), noise has not been found to be a problem at operating plants and is not expected to be a problem at any plant during the subsequent license renewal term. In addition, nuclear plant operations at Turkey Point Units 3 and 4 have not changed appreciably with time, and no change in noise levels or noise-related impacts are expected during the subsequent license renewal term.

The NRC staff identified no new or significant information during its review of the FPL environmental report, at the site visit, through the scoping process, or in the evaluation of other

available information. Consequently, people living in the vicinity of Turkey Point Units 3 and 4 would not experience any changes in noise levels during the subsequent license renewal term beyond what is currently being experienced. Therefore, the impact of continued reactor operations during the subsequent license renewal term would not exceed the noise impacts predicted in the GEIS. For these issues, the GEIS predicts that noise impacts would be SMALL for all nuclear plants.

As identified in Table 4-1, the impacts of all generic noise issues would be SMALL. Table 4-2 does not identify any site-specific (Category 2) noise issues for Turkey Point Units 3 and 4.

4.3.2 No-Action Alternative

4.3.2.1 Air Quality

Under the no-action alternative, there would be a reduction in air pollutant emissions from activities related to the cessation of Turkey Point operations, such as the use of combustion sources (diesel generators, engines) and vehicle traffic. Activity from these air emission sources would not cease, but emissions would be lower. Therefore, the NRC staff concludes that if emissions decrease, the impact on air quality from the shutdown of Turkey Point would be SMALL.

4.3.2.2 Noise

Under the no-action alternative, the NRC would not issue subsequent renewed licenses, and reactor operations at Turkey Point Units 3 and 4 would shut down on or before the expiration of the current renewed operating licenses. The termination of reactor operations would result in a reduction in noise sources throughout the nuclear facility, including noise from turbine generators, machinery, pumps, and other noise-generating equipment, and some vehicular traffic. Therefore, noise impacts resulting from the no-action alternative would be SMALL.

4.3.3 Replacement Power Alternatives: Common Impacts

4.3.3.1 Air Quality

Construction

Construction of a power station under a replacement power alternative would result in temporary impacts on local air quality. Air emissions would be intermittent and would vary based on the level and duration of specific activities throughout the construction phase. During the construction phase, the primary sources of air emissions would consist of engine exhaust and fugitive dust emissions. Engine exhaust emissions would be from heavy construction equipment and commuter, delivery, and support vehicular traffic traveling to and from the facility as well as within the site. Fugitive dust emissions would be from soil disturbances by heavy construction equipment (e.g., earthmoving, excavating, and bulldozing), vehicle traffic on unpaved surfaces, concrete batch plant operations, and wind erosion to a lesser extent. Various mitigation techniques and best management practices (e.g., watering disturbed areas, reducing equipment idle times, and using ultra-low sulfur diesel fuel) could be used to minimize air emissions and to reduce fugitive dust. Implementation of a dust-control plan would also address reasonable precautions that would be needed to prevent fugitive particulate emissions in accordance with Florida Administrative Code 62-296.320(4)(c)3. Air emissions include criteria pollutants (particulate matter, nitrogen oxides, carbon monoxide, and sulfur dioxide),

volatile organic compounds, hazardous air pollutants, and greenhouse gases (GHGs). Small quantities of volatile organic compounds and hazardous air pollutants would also be released from equipment refueling, onsite maintenance of the heavy construction equipment, and other construction finishing activities as well as from cleaning products, petroleum-based fuels, and certain paints.

Operations

The impacts on air quality as a result of operation of a power station for a replacement power alternative will depend on the energy technology (i.e., fossil-fuel based or nuclear). Fossil fuel-based power plants result in larger amounts of air emissions than nuclear power plants. Worker vehicles, auxiliary power equipment, and mechanical draft cooling tower operation will result in additional air emissions.

4.3.3.2 *Noise*

Construction

Noise levels during the construction of a replacement power facility would be similar to noise levels during the construction of any industrial facility in that all involve many noise-generating activities. In general, noise emissions would be temporary and noise levels would vary during each phase of construction, depending on the amount of activity, types of equipment and machinery used, and site-specific conditions. Typical construction equipment, such as dump trucks, loaders, bulldozers, graders, scrapers, air compressors, generators, and mobile cranes, would be used, and pile-driving and blasting activities could take place. Other noise sources include construction worker vehicle and truck delivery traffic. However, noise from vehicular traffic would be intermittent and would generate noise at levels similar to noise levels from Turkey Point Units 3 and 4 reactor operations.

Operations

Noise generated during operations could include noise from mechanical draft cooling towers, transformers, turbines, machinery, equipment, and communication announcements and sirens, as well as offsite sources, such as employee and delivery vehicular traffic. Noise from vehicles would be intermittent and at levels similar to noise levels generated by vehicles at Turkey Point. Similarly, with the exception of noise from mechanical draft cooling towers, operational noise levels at a replacement power plant would likely be similar to existing noise levels at Turkey Point Units 3 and 4.

4.3.4 New Nuclear Alternative

4.3.4.1 *Air Quality*

Construction

Air emissions and sources associated with construction of the new nuclear alternative would include those identified as common to all replacement power alternatives in Section 4.3.3.1, "Air Quality." Because air emissions from construction activities would be limited, local, and temporary, the NRC staff concludes that the associated air quality impacts from construction of a new nuclear alternative would be SMALL.

Operations

Operation of a new nuclear generating plant would result in air emissions similar in magnitude to air emissions from the operation of Turkey Point. Sources of air emissions would include stationary combustion sources (e.g., diesel generators, auxiliary boilers, and fire pumps) and mobile sources (e.g., worker vehicles, onsite heavy equipment, and support vehicles). Additional air emissions would result from the new nuclear plant's use of mechanical draft cooling towers rather than the cooling canal system currently used by Turkey Point and could contribute to impacts associated with the formation of visible plumes, fogging, and subsequent icing downwind of the towers. In general, most stationary combustion sources at a nuclear power plant would operate only for limited periods, often during periodic maintenance testing. A new nuclear power plant would need to secure a permit from the Florida Department of Environmental Protection (FDEP) for air pollutants associated with its operations (e.g., criteria pollutants, volatile organic compounds, hazardous air pollutants, and greenhouse gases). The NRC staff expects the air emissions for combustion sources from a new nuclear plant to be similar to those currently being emitted from Turkey Point Units 3 and 4 (see Section 3.2.1). Emissions from the mechanical draft cooling towers would be approximately 15 tons/year for particulate matter less than 10 microns and 0.08 tons/year for particulate matter less than 2.5 microns (NRC 2016a). Therefore, the NRC staff expects that the combined air quality impact of emissions from onsite sources would be minor. Additional air emissions would result from the approximately 800 employees commuting to and from the new nuclear facility. The NRC staff does not expect air emissions from operation of a new nuclear alternative to contribute to National Ambient Air Quality Standard violations. The NRC staff concludes that the impacts of operation of a new nuclear alternative on air quality would be SMALL.

4.3.4.2 Noise

Construction

Noise generated during the construction and operation of a new nuclear power plant would be similar to noise for all replacement power alternatives as discussed in Section 4.3.3.2, "Noise." In addition, Sections 4.8.2 and 5.8.2 of the EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a) describe noise impacts generated during construction and operation of proposed Turkey Point Units 6 and 7; those noise impacts would be similar to the noise impacts of constructing and operating new nuclear plants to replace Units 3 and 4. Accordingly, the NRC staff incorporates the information in Sections 4.8.2 and 5.8.2 of NUREG-2176 here by reference (NRC 2016a). Noise impacts during construction would be limited to the immediate vicinity of the Turkey Point site. Because of the distance of the site to potential receptors, noise impacts during the construction of a new nuclear power facility at the Turkey Point site could range from SMALL to MODERATE depending on the noise-sensitive receptor.

Operations

Mechanical draft cooling towers generate noise during operations. Other sources of noise during nuclear power plant operations would include industrial equipment, machinery, vehicles, and communications. In general, noise would be limited to the immediate vicinity of the Turkey Point site and, with the exception of the cooling towers, noise levels would be similar to noise levels generated during the operation of Turkey Point Units 3 and 4. Therefore, noise impacts during power plant operations for a new nuclear plant would be SMALL.

4.3.5 Natural Gas Combined-Cycle Alternative

4.3.5.1 Air Quality

Construction

Air emissions and sources associated with construction of the natural gas alternative would include those identified as common to all replacement power alternatives in Section 4.3.3.1, “Air Quality.” There would also be additional air emissions resulting from construction of a new or upgraded pipeline that would connect to existing natural gas supply lines north of the site. Air emissions would be localized, intermittent, and short lived, and adherence to well-developed and well-understood construction best management practices would mitigate air quality impacts. Therefore, the NRC staff concludes that construction-related impacts on air quality from a natural gas alternative would be of relatively short duration and would be SMALL.

Operations

Operation of a natural gas plant would result in emissions of criteria pollutants and greenhouse gases. The sources of air emissions during operation include gas turbines through heat recovery steam generator stacks. The staff estimated air emissions for the natural gas alternative using emission factors developed by the U.S. Department of Energy’s (DOE) National Energy Technology Laboratory (NETL 2012). Assuming a total gross capacity of 1,726 MW and a capacity factor of 0.87 (FPL 2018f), the NRC staff estimates the following air emissions would result from operation of a natural gas alternative:

- sulfur oxides—20 tons (18 metric tons (MT)) per year
- nitrogen oxides—440 tons (400 MT) per year
- carbon monoxide—45 tons (41 MT) per year
- PM₁₀—32 tons (29 MT) per year
- carbon dioxide equivalents (CO_{2eq})—5.7 million tons (5.2 million MT) per year

Operation of the mechanical draft cooling towers and up to 150 worker vehicles would also result in additional criteria emissions above those presented in the list. A new natural gas plant would qualify as a major emitting industrial facility. As such, the new natural gas plant would be subject to Prevention of Significant Deterioration (PSD) and Title V air permitting requirements under the Clean Air Act of 1970, as amended (42 U.S.C. 7651 et seq.), to ensure that air emissions are minimized and that the local air quality is not substantially degraded. Additionally, various Federal and State regulations aimed at controlling air pollution would affect a natural gas alternative.

Based on the NRC staff’s air emission estimates, nitrogen oxide and greenhouse gas emissions from a natural gas plant would be noticeable and significant. Carbon dioxide emissions would be much larger than the threshold in the U.S. Environmental Protection Agency’s (EPA’s) Greenhouse Gas Tailoring Rule, and nitrogen oxide emissions would exceed the threshold for major sources. The NRC staff concludes that the overall air quality impacts associated with operation of a natural gas alternative would be SMALL to MODERATE.

4.3.5.2 Noise

Construction

In addition to the common impacts discussed in Section 4.3.3.2, “Noise,” for all replacement power alternatives, additional noise would be generated during the construction of pipelines to support a natural gas power plant. Because of the distance involved in pipeline construction, noise impacts during the construction of a natural gas power plant and gas pipeline could range from SMALL to MODERATE depending on the location of noise-sensitive receptors along the gas pipeline.

Operations

Noise generated during the operation of a natural gas power plant would include noise from mechanical draft cooling towers, compressor stations, and pipeline blowdowns. However, the majority of noise-producing equipment (e.g., mechanical draft cooling towers, turbines, pumps) would be located inside the power block. Therefore, noise impacts during power plant operations would be SMALL.

4.3.6 Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)

4.3.6.1 Air Quality

Construction

Air emissions and sources associated with construction of both the natural gas and solar portions of this combination alternative would include those identified as common to all replacement power alternatives in Section 4.3.3.1, “Air Quality.” Air emissions from construction would be localized and intermittent, and well-understood construction best management practices would mitigate air quality impacts. Therefore, the NRC staff concludes that construction-related impacts on air quality from the combination alternative would be SMALL.

Operations

Air emissions associated with the operation of the natural gas portion of the combination alternative would be similar to those associated with the natural gas alternative. However, emissions associated with the natural gas portion of the combination alternative are slightly reduced because the electricity output of the natural gas unit under the combination alternative would be approximately 95 percent of that of the natural gas-only alternative.

The NRC staff estimates the following air emissions for the natural gas portion of the combination alternative based on emission factors developed by the DOE’s National Energy Technology Laboratory (NETL 2012):

- sulfur oxides—19 tons (18 metric tons (MT)) per year
- nitrogen oxides—420 tons (380 MT) per year
- carbon monoxide—43 tons (39 MT) per year
- PM₁₀—30 tons (28 MT) per year
- carbon dioxide equivalents (CO_{2eq})—5.4 million tons (4.9 million MT) per year

Operation of the mechanical draft cooling towers and up to 150 worker vehicles would also result in additional criteria emissions above those presented in the list. The new natural gas units would qualify as major emitting industrial facilities and would be subject to Prevention of Significant Deterioration and Title V air permitting programs aimed at controlling air pollution. Carbon dioxide emissions would be greater than the threshold in EPA's Greenhouse Gas Tailoring Rule, and nitrogen oxide and carbon monoxide emissions would exceed the threshold for major sources.

Air emissions associated with the operation of solar energy facilities are negligible because no fossil fuels are burned to generate electricity. Emissions from solar fields would include fugitive dust and engine exhaust emissions from vehicles and heavy equipment associated with site inspections, maintenance activities (panel washing or replacement), and wind erosion from cleared lands and access roads. The types of emission sources and pollutants during operation would be similar to those during construction, but much fewer emissions would be released during operation. These emissions should not cause exceedances of air quality standards or have any impacts on climate change. The NRC staff concludes that the overall air quality impacts associated with operation of the combination alternative would be SMALL to MODERATE.

4.3.6.2 *Noise*

Construction

Construction-related noise sources for the natural gas power plant portion of the combination alternative would be similar to the impacts discussed for the natural gas-only power plant alternative in Section 4.3.5.2, "Noise," and the common impacts discussed in Section 4.3.3.2, "Noise," for all replacement power alternatives. Noise impacts during the construction of a solar facility could range from SMALL to MODERATE depending on its location in proximity to noise-sensitive receptors. Therefore, construction impacts from the combination alternative could range from SMALL to MODERATE depending on the location of noise-sensitive receptors.

Operations

Noise generated during natural gas power plant operations would include noise from mechanical draft cooling towers, compressor stations, and pipeline blowdowns. Noise impacts during operation of the natural gas power plant component of the combination alternative would be similar to those described in Section 4.3.5.2. Except for maintenance activities, very little noise would be generated by the solar facility. Therefore, noise impacts during facility operations from the combination alternative would be SMALL.

4.3.7 Cooling Water System Alternative

4.3.7.1 *Air Quality*

Construction and Operations

Under the cooling water system alternative, three plume-abated wet mechanical draft cooling towers would be constructed for each reactor unit. Air emissions from construction of the cooling towers would result from the exhaust of construction equipment, worker vehicle exhaust, land disturbance activities (land-clearing, excavation), and demolition activities. Fuel

combustion exhaust would emit criteria pollutants and greenhouse gases while land-disturbance and demolition activities would result in fugitive dust.

Potential atmospheric impacts from cooling system operation include the formation of visible plume, fogging, and subsequent icing downwind of the towers. Operation of cooling towers would also result in the emission of particulate matter from cooling tower drift, with higher concentrations of dissolved solids associated with the potential use of seawater as a secondary source of cooling water. However, modern cooling towers equipped with drift eliminators would minimize the loss of water from the cooling towers via drift. As stated in Section 5.7.2 of the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176), cooling tower emissions would be required to adhere to the New Source Performance Standards (40 CFR 60.40, "Applicability and Designation of Affected Facility") and demonstrate compliance with ambient air-quality standards by acquiring a Prevention of Significant Deterioration permit under the Clean Air Act before the cooling towers could be operated (NRC 2016a).

Replacement power would be needed during both construction and operation of a mechanical draft cooling tower system at Turkey Point. Construction-related outages may result from necessary modifications to the facility. Following cooling tower construction, Turkey Point Units 3 and 4 would be offline for at least a short time during the switchover from use of the cooling canal system (CCS) to cooling towers. Therefore, during these periods, additional power would be needed to replace the generating capacity of Turkey Point Units 3 and 4. Some replacement power could also be required once Turkey Point's cooling tower system is online to compensate for the additional power needed to operate cooling tower pumps and fans. Replacement power would likely come from common types of existing technology within the region (natural gas, nuclear, or coal), but it is not likely that new facilities would be constructed. The impacts on air quality would depend on the specific location and technology of the replacement power facilities.

In Sections 4.7 and 5.7 of the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176), the NRC staff determined that air impacts from the construction and operation of Units 6 and 7, including those associated with the construction and operation of the mechanical draft cooling towers, would be SMALL (NRC 2016a). As described in Section 2.2.3, "Cooling Water System Alternative," of this SEIS, construction and operation of mechanical draft cooling towers for Units 3 and 4 would be similar to, but proportionally smaller than, the impacts described in the NUREG-2176 analysis for Units 6 and 7. Therefore, the NRC staff concludes that the air quality impacts from the construction and operation of mechanical draft cooling towers to support Turkey Point Units 3 and 4 would be SMALL.

4.3.7.2 Noise

Construction

Construction-related noise during construction of the cooling towers for the cooling water system alternative would be similar to the impacts discussed in Section 4.3.3.2, "Noise," as common to all replacement power alternatives. Because of the distance from the site to noise-sensitive receptors, noise impacts during construction of the cooling towers for the cooling water system alternative at the Turkey Point site could range from SMALL to MODERATE depending on the noise-sensitive receptor.

Operations

As previously discussed, mechanical draft cooling towers generate noise during operations. In general, noise impacts when the cooling towers for the cooling water system alternative are operating would be limited to the immediate vicinity of the Turkey Point site and would be SMALL.

4.4 Geologic Environment

This section describes the potential geology and soil resource impacts of the proposed action (subsequent license renewal) and alternatives to the proposed action.

4.4.1 Proposed Action

According to the 2013 GEIS (NRC 2013a), plant-specific environmental reviews conducted by the NRC had not identified any significant impact issues related to geology and soil resources. The NRC staff's review of the Turkey Point subsequent license renewal application has not identified any new or significant information that would change the conclusion in the GEIS. Thus, as concluded in the GEIS, the impacts of continued operation on geology and soil resources would be SMALL.

As identified in Table 4-1, the impacts of the single geologic environment issue (geology and soils) would be SMALL. Table 4-2 does not identify any site-specific (Category 2) geologic environment issues.

4.4.2 No-Action Alternative

Under the no-action alternative, the NRC would not issue subsequent renewed licenses and Turkey Point Units 3 and 4 would shut down on or before the expiration of the current renewed licenses. There would not be any impacts to the geology and soils at the Turkey Point site with the shutdown of the facility. With the shutdown of the facility, no additional land would be disturbed. Therefore, the NRC staff concludes that impacts on geology and soil resources from the no-action alternative would be SMALL.

4.4.3 Replacement Power Alternatives: Common Impacts

Under all replacement power alternatives, construction impacts would be temporary and localized. During construction for all the replacement power alternatives, sources of aggregate material (such as crushed stone, sand, and gravel) would be required to construct buildings, foundations, roads, and parking lots. The NRC staff presumes that these resources would likely be obtained from commercial suppliers using local or regional sources.

During construction of all replacement power alternatives, no previously undisturbed soils would be impacted. Organic soil or "muck" on the proposed building site would be removed and disposed of in several locations on the berms alongside the main return canal and southern canal of the CCS (also called the industrial wastewater facility). Prior to placement of spoils material, part of the surface would be excavated, and small containment berms would be created to form a shallow excavation in which to place the spoils. Material that is removed from the excavations and is not suitable for reuse would be placed in these areas for dewatering and

disposal. FPL has indicated that measures such as berms, riprap, sedimentation filters, and detention ponds would be used to control drainage from the spoils piles to the CCS (NRC 2016a).

During operation of replacement power alternatives, no additional land would be disturbed. Therefore, NRC staff concludes that the common impacts of operations of replacement power alternatives on geology and soil resources would be SMALL.

4.4.4 New Nuclear Alternative

The NRC staff did not identify any impacts to the geologic environment for the new nuclear alternative beyond those discussed above as common to all replacement power alternatives. Therefore, the NRC staff concludes that the impacts to geology and soil resources from the new nuclear alternative would be SMALL.

4.4.5 Natural Gas Combined-Cycle Alternative

The NRC staff did not identify any impacts to the geologic environment for the natural gas alternative beyond those discussed above as common to all replacement power alternatives. Therefore, the NRC staff concludes that the impacts to geology and soil resources from the natural gas alternative would be SMALL.

4.4.6 Combination Natural Gas Combined-Cycle and Solar Photovoltaic Alternative

For the natural gas component of this alternative, the NRC staff did not identify any impacts to the geologic environment beyond those discussed above as common to all replacement power alternatives. However, the solar component of this alternative would require land to be cleared for solar power installations. The corresponding impacts on soil resources would be noticeable, but they would not destabilize important attributes of the resource. Therefore, the NRC staff concludes that the impacts to geology and soil resources from the combination natural gas and solar alternative would be MODERATE.

4.4.7 Cooling Water System Alternative

The NRC staff did not identify any impacts to the geologic environment for the cooling water system alternative beyond those discussed above as common to all replacement power alternatives. Therefore, the NRC staff concludes that the impacts to geology and soil resources from the cooling water system alternative would be SMALL.

4.5 Water Resources

This section describes the potential surface water and groundwater resources impacts of the proposed action (subsequent license renewal) and alternatives to the proposed action.

4.5.1 Proposed Action

4.5.1.1 Surface Water Resources

According to the GEIS (NRC 1996 and NRC 2013a), for the most part, no significant surface water impacts for Category 1 (generic) issues are anticipated during the license renewal term that would be different from those occurring during the current license term. The NRC staff's

review of the Turkey Point SLR application has not identified any new and significant information that would change the conclusion in the GEIS. Thus, as concluded in the GEIS, for these Category 1 (generic) issues, the impacts of continued operation on surface water resources would be SMALL.

Table 4-1 in Section 4.1 lists “Applicable Category 1 (Generic) Issues for Turkey Point.” The impacts for these issues are SMALL. While no Category 2 (site-specific) issues applicable to the Turkey Point site have been identified, the NRC staff did evaluate the significance of new information for the impacts from the CCS on adjacent surface water bodies via the groundwater pathway. As discussed below, this information was determined not to be significant for Turkey Point subsequent license renewal.

New Issue, Water Quality Impacts on Adjacent Water Bodies (Plants with Cooling Ponds in Salt Marshes)

As part of its review of the Turkey Point subsequent license renewal application, the NRC staff identified new information regarding nuclear power plant operations that can act upon the environment in a manner or in an intensity or scope (context) not previously recognized. Specifically, the GEIS (NUREG–1437) did not consider how a nuclear power plant with a cooling pond in a salt marsh may indirectly impact the water quality of adjacent surface water bodies via a groundwater pathway. This constitutes a new, site-specific issue with respect to Turkey Point, for which the NRC staff has prepared the following site-specific analysis.

In its environmental report, FPL identified the Category 1 issue, “Altered salinity gradients,” as applicable to Turkey Point Units 3 and 4 operations. However, the NRC staff has determined that this issue is not applicable to Turkey Point due to the unique configuration of the Turkey Point CCS. As indicated in Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 and as further described in the GEIS (NRC 2013a), the issue, “Altered salinity gradients,” only applies to nuclear power plants located on estuaries and changes in salinity due to the operational effects of intake and discharge structures in estuaries. At Turkey Point, the intake and discharge structures associated with Units 3 and 4 are located within the enclosed CCS, which does not directly discharge to the surface waters of Biscayne Bay. Nonetheless, the NRC staff has evaluated new and potentially significant information related to the operation of the CCS and its effects on salinity within the Biscayne aquifer under the issue, “Groundwater quality degradation (plants with cooling ponds in salt marshes),” in Section 4.5.1.2 of this SEIS rather than under the new issue discussed in this section.

For this new issue (water quality impacts on adjacent water bodies), Sections 3.1.3, “Cooling and Auxiliary Water Systems,” and 3.5.1, “Surface Water Resources,” of this SEIS present relevant new information related to the water quality of surface waters adjacent to Turkey Point and the Turkey Point site. Much of this information did not become available until many years after the NRC had issued the initial renewed licenses for Units 3 and 4 in 2002 and was not available at the time that the 2013 GEIS was prepared. The following discussion is based on information summarized in the aforementioned sections of this SEIS.

Turkey Point Units 3 and 4 do not consume surface water or discharge directly to natural surface water bodies. All surface water discharges from Turkey Point flow into the CCS. As described in Section 3.1.3.2 of this SEIS, the CCS is surrounded by perimeter berms that are designed to keep water from entering the CCS. The perimeter berms are built on top of the bedrock, while water levels in the CCS are below the top of the bedrock. The perimeter berms are not in contact with water within the CCS. However, the water in the CCS is in contact with

and hydrologically connected to the Biscayne aquifer. The Biscayne aquifer, in turn, is hydrologically connected to the surrounding marsh land, mangrove areas, adjacent drainage canals, Biscayne Bay, and Card Sound.

Water in the CCS is considered industrial wastewater and is not recognized as a usable resource. Therefore, only the impacts from CCS operation on the water quality of adjacent surface water bodies via the groundwater pathway from the CCS through the Biscayne aquifer are considered in this analysis.

The Florida legislature has designated Biscayne Bay and Card Sound, including Biscayne National Park, as “Outstanding Florida Waters.” This designation affords these waters the highest water quality protections in the State.

The impact of temperature, salinity, ammonia, and nutrients on water quality has been the focus of CCS operational concerns. It has been reported that increased levels of ammonia, other nutrients, or salinity had been found in local areas adjacent to the CCS, however, as discussed below and in Chapter 3 of this SEIS, discernable effects from CCS derived temperature, ammonia, nutrients, and salinity on Biscayne Bay or Card Sound water qualities has not been detected.

As discussed in Section 3.5.1.4 of this SEIS, ammonia concentrations in the water within the CCS are below the Miami-Dade County ammonia water quality standard. Also as discussed in Section 3.5.1.4, adjacent surface water bodies contain ammonia from natural sources that occur within the water body (e.g., through decay of organic matter). Noticeable concentrations of ammonia have been found in two deep excavations outside of and adjacent to the CCS that contain stagnant water (i.e., the Barge Turning Basin and the remnant canal at Turtle Point). To prevent the movement of ammonia from the CCS into these areas, FPL is undertaking mitigation activities, as discussed below.

Thermal impacts on adjacent water bodies from the CCS have not been detected. Similarly, impacts on surrounding marsh and mangrove areas from CCS contributions of ammonia, nutrients, and salinity have not been detected. Impacts on adjacent canals from CCS contributions of ammonia, nutrients, and salinity have been slight. Water that likely originated from the CCS has sporadically been detected in two canals adjacent to the CCS (the Card Sound remnant canal and the S-20 Canal; see Section 3.5.1.4, “Ammonia and Nutrients and Salinity within Adjacent Canals”). However, the water quality in these two canals has not been degraded sufficiently to prevent these canals from achieving their intended purpose (i.e., transporting fresh water, draining the land, and flood control). Further, little if any influence on surface water quality in Card Sound was detected from the discharge of these two canals into Card Sound.

As described in Section 3.5.2, “Groundwater Resources,” hypersaline water originating in the CCS is moving eastward beneath Biscayne Bay at depth along the base of the Biscayne aquifer. Because the hypersaline groundwater is denser than seawater, the hypersaline groundwater is found at the bottom of the Biscayne aquifer and is moving down the eastward dip of the aquifer. Upward movement of this hypersaline water from the Biscayne aquifer and into Biscayne Bay and Card Sound has not been detected in either porewater or shallow monitor well samples collected in the Bay and Sound.

In accordance with agreements reached with and/or requirements imposed by the Florida DEP and Miami-Dade County DERM, FPL is implementing programs to control ammonia and

nutrients and to reduce salinities within the CCS. These programs (which include adding fresh or lower salinity water to the CCS, pumping hypersaline water from groundwater, and monitoring and reporting requirements) are expected to reduce the impact of the CCS on groundwater quality within the Biscayne aquifer. In turn, the potential impacts on surface water quality via groundwater from the CCS via the groundwater pathway would also be reduced. These programs are expected to reduce the amount of hypersaline groundwater originating from the CCS. Hypersaline groundwater flow from the CCS beneath Biscayne Bay would, however, continue to move eastward and downgradient along the base of the Biscayne aquifer.

Surface water quality data collected in and around the CCS indicate that CCS impacts on adjacent surface water bodies have been SMALL. CCS impacts on adjacent surface waters remained SMALL even when salinities in the CCS were higher and sometimes much higher than seawater salinities. These impacts remained SMALL even when a seagrass die-off caused nutrients to be released into the CCS. Furthermore, the nutrient and hypersaline water mitigative measures imposed by Florida and Miami-Dade County afford additional confidence that CCS impacts on adjacent surface water bodies will continue to remain SMALL.

For this new site-specific issue, the NRC staff concludes that the impacts on adjacent surface water bodies via the groundwater pathway from the CCS during the subsequent license renewal term would be SMALL and, therefore, the new information that has been identified is not significant.

4.5.1.2 Groundwater Resources

According to the GEIS (NRC 1996 and NRC 2013a), groundwater resources would not be significantly affected by continued operations associated with license renewal in most circumstances. As discussed in Section 3.5.2 of this SEIS, the NRC staff identified no new and significant information for most issues relating to groundwater use and quality. As identified in Table 4-1, the impacts for most applicable generic groundwater resources issues would be SMALL. However, during its review of FPL's environmental report, site visit, scoping process, and evaluation of other available information, the NRC staff identified new information regarding the generic groundwater resource issue of "Groundwater quality degradation (plants with cooling ponds in salt marshes)." The NRC staff's evaluation of the significance of this new information follows in the subsections below.

Additionally, as indicated in the following subsections, the NRC staff reviewed the descriptions of the modeling analyses that were commissioned by FPL and reported in Tetra Tech (2016, 2014b), in connection with the State of Florida's approval of FPL's groundwater withdrawals from the Biscayne and Upper Floridan aquifers, respectively. The NRC staff also reviewed related information contained in State agency files. Based on its review, the NRC staff and its contractors found the modeling to be reasonable with regard to the modeling analyses' overall technical approach and supporting assumptions. The NRC staff recognizes that the State of Florida, and its regulatory agencies, including the FDEP and the South Florida Water Management District (SFWMD), is statutorily responsible to determine the acceptability of the groundwater analyses, and the staff therefore did not conduct a detailed review of the modeling analyses, codes, input files, or calibration data. In its assessment of those analyses, the NRC staff found no reason to question the analyses' acceptability, their reliability in predicting groundwater flow and transport characteristics, or the State agencies' acceptance of those analyses in exercising their regulatory authority.

New Information, Category 1 Issue, Groundwater Quality Degradation (Plants with Cooling Ponds in Salt Marshes)

As referenced in Section 1.4 of this SEIS and as further described in Sections 1.5 and 1.8 of the GEIS (NUREG-1437) (NRC 2013a), no additional site-specific analysis is required by the NRC staff for Category 1 (generic) issues in the SEIS unless new and significant information is identified that would change the conclusions in the GEIS. Where new and significant information has been identified, the NRC staff will reconsider generic impacts in the SEIS.

The Category 1 issue, "Groundwater quality degradation (plants with cooling ponds in salt marshes)," was first evaluated in the 1996 GEIS (NRC 1996) and was reconsidered as part of the update to the GEIS, issued in June 2013 (NRC 2013a).

For the subject issue, the 2013 GEIS (NRC 2013a: 4-50, 4-51) provides the following technical basis with respect to nuclear power plants that use cooling ponds as part of their cooling water system discharge:

Nuclear plants that use cooling ponds as part of their cooling water system discharge effluent to the pond. The effluent's concentration of contaminants and other solids increases relative to that of the makeup water as it passes through the cooling system. These changes include increased total dissolved solids (or TDS), since they concentrate as a result of evaporation, increased heavy metals (because cooling water contacts the cooling system components), and increased chemical additives to prevent biofouling. Because all the ponds are unlined (NRC 1996), the water discharged to them can interact with the shallow groundwater system and may create a groundwater mound. In this case, groundwater below the pond can flow radially outward, and this groundwater would have some of the characteristics of the cooling system effluent.

In salt marsh locations, the groundwater is naturally brackish (i.e., with a TDS concentration of about 1,000 to more than 10,000 milligrams per liter [mg/L]) and, thus, is already limited in its uses. As such, this issue concerns only the potential for changing the groundwater use category of the underlying shallow and brackish groundwater due to the introduction of cooling water contaminants. Two nuclear plants, South Texas in Texas and Turkey Point in Florida, have cooling systems (man-made cooling pond and cooling canal system, respectively) located relatively near or constructed in salt marshes. Plants relying on brackish water cooling systems would not further degrade the quality of the shallow aquifer relative to its use classification. This is because groundwater quality beneath salt marshes is already too poor for human use (i.e., it is non-potable water) and is only suitable for industrial use.

The NRC staff concluded in the GEIS (NUREG-1437) (NRC 2013a: 4-50, 4-51) that operational impacts from cooling ponds located in salt marshes would have a SMALL impact on groundwater quality, and no new information was identified that would alter this conclusion.

Section 3.5.2.2, "Groundwater Quality," of this SEIS presents and considers in detail relevant new information related to groundwater quality at the Turkey Point site that supports the staff's reconsideration of the generic impacts of the subject issue. This information is summarized below. The CCS used by Turkey Point Units 3 and 4 and other generating facilities at the Turkey Point site is an expansive water body formed by excavation into the marshes and

underlying bedrock. Because the CCS is unlined, it is hydraulically connected to the upper Biscayne aquifer, permitting the movement of water between the CCS and the aquifer through the bedrock. Water in the CCS is hypersaline (i.e., the water has a salinity greater than that of natural seawater, with a chloride concentration exceeding 19,000 mg/L). Over the operational life of the CCS, the annual average salinity of the waters within the CCS and the hypersaline groundwater plume beneath it has increased. The existence of a hypersaline plume beneath the CCS was known at the time the NRC staff prepared its SEIS for the initial license renewal for Turkey Point in 2002. At the time, however, and at the time of the 2013 update to the GEIS (NRC 2013a), the potential for the hypersaline plume to migrate down through the Biscayne aquifer and then move laterally beyond the boundaries of the CCS was not known.

Beginning in 2010, FPL initiated an expanded groundwater monitoring program in accordance with State regulatory approvals of the Turkey Point extended power uprate project, to determine the horizontal and vertical effects of CCS water on the environment. Monitoring results demonstrated that CCS operations have impacted groundwater quality in the Biscayne aquifer beyond the boundaries of the CCS and FPL property, both to the west of the site as well as beneath Biscayne Bay to the east of the Turkey Point site. As discussed in Section 3.5.2.2 of this SEIS, "Groundwater Quality" (see "Baseline Groundwater Quality and Changes Attributable to Turkey Point Operations"), the hypersaline plume emanating from the CCS has migrated along the base of the Biscayne aquifer as well as within the intermediate, high-flow zone to the west. As further discussed in Section 3.5.2.2 of this SEIS, the 2018 baseline continuous surface electromagnetic survey results show that the maximum extent of hypersaline groundwater ranges from approximately 1 mi (1.6 km) west of the CCS at the base of the Biscayne aquifer (i.e., at depths of 87 to 99.4 ft (26.5 to 30.3 m)) to about 3 mi (4.8 km) west of the CCS in the intermediate interval at a depth of 47 to 55 ft (14.3 to 16.8 m) below ground surface.

The NRC staff concludes that the contribution of past CCS hypersaline water discharges to offsite groundwater quality degradation is difficult to quantify, in that statements by the State of Florida (FDEP 2014a) and analyses prepared by FPL, as referenced in Section 3.5.2.2 of this SEIS, indicate that saltwater was present as early as the 1940s near the base of the Biscayne aquifer west of the Turkey Point site (i.e., prior to completion of CCS construction in 1973). In addition, groundwater data from the early 1970s supported the determination that non-potable groundwater occurred beneath much of the area now occupied by the CCS and within the deeper portions of the aquifer west of the site. Thus, portions of the Biscayne aquifer to the west of the CCS did not meet Class G-II groundwater criteria (i.e., potable water use, with total dissolved solids (TDS) levels of less than 10,000 mg/L) prior to CCS construction. This earlier groundwater quality degradation is attributable to regional saltwater intrusion, which had already occurred across southeast Miami-Dade County and the Turkey Point site due to historic land use alterations and groundwater withdrawals that induced saltwater migration from east to west along the base of the Biscayne aquifer (FDEP 2014a, NRC 2016a).

However, the fact that CCS operations have measurably degraded groundwater quality beyond the general confines of the CCS structure and Turkey Point site boundaries is generally not in dispute. Furthermore, it is apparent that water from the CCS has migrated to the west and toward areas where groundwater within the Biscayne aquifer is of sufficient quality to support its use as a potable water supply. Vertical trends in monitoring wells for such parameters as chloride, TDS, and tritium concentrations indicate the influence of CCS water in groundwater both to the west and east of the Turkey Point site, as discussed in Section 3.5.2.2 of this SEIS. Consequently, in accordance with regulatory mechanisms imposed by Miami-Dade County

(MDC 2015a) and FDEP (2016a), FPL initiated operation of a groundwater remediation system in May 2018, to intercept, capture, and retract the hypersaline plume within a 10-year timeframe.

Groundwater monitoring results for tritium also indicate that the extent of potential influence of CCS water (based on a tritium concentration of 20 pCi/L or greater as measured near the base of the Biscayne aquifer) extends as far as 4.5 mi (7.2 km) west of the CCS at monitoring well TPGW-7 and approximately 2 mi (3.2 km) east beneath Biscayne Bay (see Figure 3-13 of this SEIS). These monitoring results show that the extent of tritium migration exceeds the extent of the hypersaline plume from the CCS (as noted above, hypersaline water extends out approximately 3.0 mi (4.8 km) west of the CCS boundary). Nonetheless, using 20 pCi/L for tritium as a standard, near monitoring well TPGW-7 to the west of the CCS, Class G-II groundwater criteria are met in the upper part of the Biscayne aquifer with the relatively fresh water band thickening to the west and away from the saltwater interface. This westward boundary (defined by the current estimate of the 20 pCi/L concentration boundary for tritium in groundwater) is approximately 2 mi (3.2 km) southeast of the Newton Wellfield that supplies potable water from the Biscayne aquifer to parts of Miami-Dade County. At no location outside the boundary of the Turkey Point site do tritium levels in groundwater approach the EPA and State primary drinking water standard for tritium (20,000 pCi/L), while the highest tritium levels observed in offsite monitoring wells near the site during the 2018 reporting period (June 1, 2017 through May 31, 2018) are approximately 15 percent of the standard.

Moreover, the northwestern-most boundary of the 20 pCi/L tritium concentration in the vicinity of monitoring well TPGW-7 closely aligns with the current location of the saltwater interface in the Biscayne aquifer in that area, as shown in Figure 3-22 of this SEIS. Both the U.S. Geological Survey (USGS) and FDEP have asserted that hypersaline water from the CCS contributes to the westward migration of the saltwater interface across southeast Miami-Dade County, as referenced in Section 3.5.2.2. Most recently, FPL reported to FDEP on the results of groundwater modeling (Tetra Tech 2018) that was performed using a variable density flow and salinity transport model to allocate relative contributions to the movement of the saltwater interface. The modeling results indicate that the operation of the CCS, in which the salinity exceeds 35 practical salinity units (PSU), is the single largest contributor to changes (movement) in the location of the saltwater interface, as measured by the areal extent of the saltwater interface (see Subsection "Regulatory Developments with Respect to Cooling Canal System Operations and Groundwater Quality" in Section 3.5.2.2).

Based on the information described above, the NRC staff finds that operation of the CCS under hypersaline conditions, and the migration of an associated hypersaline groundwater plume in the Biscayne aquifer, has contributed to the migration of the saltwater interface across portions of southeastern Miami-Dade County, to the west and north of the Turkey Point site.

Hypersaline groundwater containing tritium has migrated beyond the boundaries of the CCS and Turkey Point property at the base of the Biscayne aquifer from Class G-III groundwater (i.e., non-potable groundwater) to the west and to the east beneath Biscayne Bay. As evidenced by elevated levels of tritium, the NRC staff finds that CCS-influenced water has migrated into portions of the Biscayne aquifer that are a potential source of potable water. While the NRC staff also finds that the constituents of concern are not a human health concern at present, the water originating from the CCS has resulted in the degradation of groundwater quality to the west and east of the CCS, at least at the base of the Biscayne aquifer. In addition, as a source of hypersaline water, the discharge of CCS water to the base of the Biscayne aquifer has been and is currently contributing to the migration of the saltwater interface.

These aspects of cooling pond operations and their effects on groundwater quality were not considered in the GEIS as part of the technical basis for the Category 1 issue, "Groundwater quality degradation (plants with cooling ponds in salt marshes)." The NRC staff has determined that this information is new and significant for current operations, but is not significant for the subsequent license renewal term. Based on the information identified, the NRC staff has concluded that the site-specific impacts for this issue at the Turkey Point site are MODERATE for current operations, but will be SMALL during the subsequent license renewal term as a result of ongoing remediation measures and State and county oversight, now in place at Turkey Point. The NRC staff has assigned these significance levels because the plume of hypersaline water from the CCS has measurably altered and degraded groundwater quality in the lower part of the Biscayne aquifer beyond the CCS and Turkey Point property, but hypersalinity is projected to decrease substantially as a result of ongoing remediation efforts.

As previously referenced and as detailed in Section 3.5.2.2, FPL entered into a Consent Agreement (MDC 2015a) with the Miami-Dade County Division of Environmental Resources Management (DERM) in October 2015 and a Consent Order (FDEP 2016a) with the FDEP in June 2016. Both compliance agreements require FPL to take measures to abate hypersaline water discharges from the CCS and to actively remediate the hypersaline groundwater west and north of FPL's property. In accordance with those requirements, FPL completed construction and commenced operation in May 2018 of a Biscayne aquifer recovery well system, to intercept, capture, and retract the hypersaline plume from the CCS to within FPL's property boundary. The South Florida Water Management District (SFWMD) issued FPL a water use individual permit (Permit No. 13-06251-W) in February 2017 for operation of this system (SFWMD 2017a).

In its environmental report, FPL states that groundwater modeling of the operation of its recovery well system predicts that the system will stop the westward migration of the hypersaline plume in 3 years, begin retracting the hypersaline plume in 5 years, and achieve retraction of the hypersaline plume back to the FPL site (i.e., Turkey Point site) boundary within 10 years, as required by the 2016 Consent Order with FDEP (FPL 2018f). As referenced in Permit No. 13-06251-W, the modeling commissioned by FPL to support the design and permitting of the recovery well system consists of a three-dimensional, density-dependent, groundwater flow and saltwater transport model (Tetra Tech 2016). The modeling results for the constructed well system predict retraction of the westward plume with minor aquifer drawdown impacts. Both the 2015 Consent Agreement with the Miami-Dade County DERM (MDC 2015a) and the 2016 Consent Order from the FDEP (2016a) require that FPL monitor the effectiveness of the system and periodically report the results to the agencies. If monitoring analysis shows that the system is not achieving remediation objectives, FPL must develop and submit alternative plans to the agencies. In the SFWMD report included as part of the permit, SFWMD states that system operation should, as part of the extraction of hypersaline groundwater, pull the saltwater interface in the Biscayne aquifer to the east from its current location and increase the amount of fresh groundwater in areas surrounding the CCS (SFWMD 2017a).

Groundwater models are approximations of natural systems and are dependent on a number of input variables based on assumptions regarding present and future environmental conditions. Thus, they entail substantial uncertainty. As discussed in Section 3.5.1.4, "Adjacent Surface Water Quality and Cooling Canal System Operation" ("Application of Numerical Modeling to CCS Salinity Mitigation"), which has been updated in this SEIS, the NRC staff acknowledges that successful remediation of the hypersaline plume emanating from the CCS by means of continued freshening and operation of the recovery well system is predicated on effective salinity management within the CCS. Nonetheless, the effectiveness of the recovery well

system in halting and retracting the hypersaline plume is subject to regulatory oversight by FDEP and DERM, and the terms of the 2016 FDEP Consent Order and 2015 DERM Consent Agreement. To date, FPL's salinity management program has been effective in reducing the annual average salinity of the CCS from a high of 82.5 PSU during the period from June 2014 through May 2015 to 49.5 PSU during the period from June 2017 through May 2018 (see Section 3.5.1.4). This has had beneficial groundwater quality impacts by reducing hypersaline groundwater production. Furthermore, FPL's recovery well system status reports and associated groundwater monitoring indicate that the system is reducing the salinity in the shallow (uppermost) interval of the Biscayne aquifer adjacent to the recovery wells. FPL states that the observations to date are consistent with its groundwater modeling projections of system performance (see "Regulatory Developments with Respect to Cooling Canal System Operations and Groundwater Quality" in Section 3.5.2.2).

Therefore, the NRC staff concludes that as a result of FPL's operation of its recovery well system and continued regulatory oversight and enforcement of the terms of the 2016 FDEP Consent Order and 2015 Miami-Dade County DERM Consent Agreement, the impacts on groundwater quality from operations during the subsequent license renewal term would be SMALL. The staff's current impacts projection also considers the fact that the subsequent license renewal term does not commence until 2032 and 2033, for Units 3 and 4, respectively, affording a substantial period of time for ongoing groundwater remediation activities to be effective and improvement in groundwater quality to be accomplished prior to and during the subsequent period of extended operations.

Category 2 Issues

Table 4-2 identifies two Turkey Point site-specific (Category 2) issues related to groundwater resources during the subsequent license renewal term. These issues are analyzed below.

Groundwater Use Conflicts (Plants That Withdraw More Than 100 Gallons per Minute)

For nuclear power plants that withdraw more than 100 gpm (378 L/min) of groundwater to supply a plant's makeup cooling, service water, or potable water needs, there can be conflicts with other local groundwater users if the cone(s) of depression created by a facility's groundwater production extends to offsite well(s). This is a Category 2 issue.

In evaluating the potential impacts resulting from groundwater use conflicts associated with subsequent license renewal, the NRC staff uses as its baseline the existing groundwater resource conditions described in Sections 3.5.2.1 through 3.5.2.3 of this SEIS. These baseline conditions encompass the existing hydrogeologic framework and conditions (including aquifers) potentially affected by continued operations, as well as the nature and magnitude of groundwater withdrawals for cooling and other purposes (as compared to relevant appropriation and permitting standards). The baseline also considers other downgradient or in-aquifer uses and users of groundwater.

As described in Section 3.5.2.3, "Groundwater Use," FPL uses onsite groundwater withdrawn from the Biscayne and Upper Floridan aquifers for a variety of applications in support of Turkey Point Units 3 and 4 operations, as well as for other activities conducted on the Turkey Point site unrelated to Turkey Point Units 3 and 4 operations. Moreover, at the time of initial license renewal as documented in the NRC staff's SEIS for the Turkey Point initial license renewal (NUREG-1437, Supplement 5) (NRC 2002c), no groundwater was being withdrawn for use as makeup water or to support salinity management (i.e., freshening) in the CCS. Since 2014, FPL has substantially increased groundwater usage from both the Biscayne and Upper Floridan

aquifers to support freshening of the CCS and, most recently, as part of groundwater extraction activities for remediation of hypersaline groundwater emanating from the CCS.

Conflicts Analysis for the Biscayne Aquifer

In 2018, FPL's groundwater withdrawals from the Biscayne aquifer totaled about 4,630 mgd (17.5 million m³/yr). This equates to an average withdrawal of 12.7 mgd (48,100 m³/day) (see Section 3.5.2.3). These withdrawals were associated with the completion of hypersaline groundwater recovery testing using four demonstration wells followed by full-scale operations of the installed hypersaline groundwater recovery well system. FPL did not operate its three marine wells (i.e., wells PW-1, SW-1, and SW-2) during the 2018 reporting period, which also withdraw from the Biscayne aquifer.

FPL commenced full operation of the recovery well system on or about May 15, 2018 (Section 3.5.2.2). The installed system consists of 10 recovery (extraction) wells that FPL has numbered RW-1 through RW-10. These recovery wells are generally located along the western edge of the CCS. The wells are located and designed to extract hypersaline groundwater from near the base of the Biscayne aquifer, and to limit the influence of CCS operations on the regional saltwater interface. Under optimal conditions, the 10-well system has an extraction capacity of 15 mgd (56,700 m³/day), or 5,475 mgd (20.7 million m³/yr).

The SFWMD has issued FPL a water use individual permit (Permit No. 13-06251-W) for operation of the recovery well system. The permit specifies a maximum monthly withdrawal allocation of 465 million gal (1.76 million m³) (SFWMD 2017a). This limit bounds the total installed production capacity of the recovery wells. Additionally, the permit requires that FPL mitigate interference with existing legal uses of groundwater and mitigate harm to natural resources, including effects on surface water or groundwater that result in lateral movement of the saltwater interface or reductions in the hydroperiod of wetlands or natural water bodies, causes the movement of contaminants contrary to water quality standards, or causes harm to the natural system including habitats for rare or endangered species. In such cases, FPL would be required to reduce or otherwise alter groundwater withdrawals to mitigate impacts.

As referenced above, FPL contracted Tetra Tech to develop and perform numerical groundwater modeling to support FPL's water use permit application to SFWMD. The NRC staff reviewed the modeling report (Tetra Tech 2016) as well the SFWMD report and impacts evaluation that were included in FPL's water use individual permit (Permit No. 13-06251-W) (SFWMD 2017a).

The modeling report assessed various operational scenarios for the recovery well system using a regional, three-dimensional, density-dependent, groundwater flow and saltwater transport model to simulate the effects on conditions in the Biscayne aquifer. As described by Tetra Tech (Tetra Tech 2016) and summarized by FPL (2018n), the numerical model features an 11-layer flow system to represent the Biscayne aquifer. The model simulates interactions between the CCS, Biscayne aquifer, Biscayne Bay, and affected surface water canals. Seven recovery well scenarios, reflecting differences in recovery well locations, were modeled for a 10-year simulation period, as compared to a "no-action" scenario. The modeling scenario that Tetra Tech (Tetra Tech 2016) identifies as "alternative 3D" represents the recovery well system that has been constructed by FPL. Modeling results for alternative 3D show that the hypersaline plume within the lower high-flow zone of the aquifer will be retracted back to the eastern edge of the CCS within 10 years and that salinity concentrations are reduced to that of seawater (i.e.,

35 PSU) or less in the aquifer beneath the CCS. Predicted offsite drawdowns (i.e., west of the L-31E Canal) are less than 0.2 feet (0.06 m) (Tetra Tech 2016).

The modeling results for the constructed well system predict retraction of the westward plume to the edge of the CCS beginning within about 5 years, and complete retraction within 10 years, with minor aquifer drawdown impacts. In the impacts evaluation report for Permit No. 13-06251-W, SFWMD stated that system operation should, as part of the extraction of hypersaline groundwater, pull the saltwater interface in the Biscayne aquifer seaward (i.e., to the east) from its current location and increase the amount of fresh groundwater in areas surrounding the CCS (SFWMD 2017a).

As also documented in the SFWMD report issued as part of the permit package for Permit No. 13-06251-W and supporting documentation included in SFWMD's online application file (SFWMD 2017a), SFWMD staff reviewed the modeling submitted by FPL (Tetra Tech 2016) and also performed confirmatory analyses. In summary, SFWMD concluded that: (1) recovery well system withdrawals would have no impact on existing legal users of the Biscayne aquifer, (2) predicted drawdowns would not exceed 0.5 feet (0.15 m) with minimal potential to affect water resource availability given the aquifer's total saturated thickness, and (3) withdrawals should result in eastward retraction of the saltwater interface and increase the availability of fresh groundwater in the area of the CCS. SFWMD separately considered a modeling scenario under drought conditions. The drought scenario predicted a maximum drawdown of less than 0.3 feet (0.09 m) in the Biscayne aquifer west and north of the CCS, resulting in minimal potential to impact sawgrass marsh wetlands in the affected areas.

Consistent with the SFWMD report and the modeling results discussed above, FPL's environmental report predicts retraction of the westward plume to the edge of the CCS by about 5 years and complete retraction within 10 years (i.e., by about 2028), with minor aquifer drawdown impacts. Thus, FPL would achieve the compliance deadline for retraction of the hypersaline plume and its effect on the location of the regional saltwater interface, as set forth in its 2016 Consent Order with the FDEP (FDEP 2016a), without undue impact on groundwater resources or producing unintended groundwater use conflicts. In view of the SFWMD and Tetra Tech conclusions, the NRC staff concludes that recovery well operations will likely be successful in achieving their intended results prior to the start of the subsequent license renewal term for Turkey Point (i.e., 2032 for Unit 3 and 2033 for Unit 4). Further, the modeling results and the safeguards imposed by SFWMD through permit conditions provide reasonable assurance that any impacts on groundwater resources and users would be mitigated, while producing beneficial effects on groundwater quality.

The marine wells, used by FPL to pump seawater into the CCS, have a maximum production capacity of about 45 mgd (170,300 m³/day). FPL has used the marine wells intermittently since they were installed in 2015 to lower salinity in the CCS under abnormal conditions. For instance, while the marine wells were not used in 2016, FPL diverted marine well water into the CCS during a 6-month period in 2017 (FPL 2018m). Marine well water was most recently used in conjunction with water pumped from the newly operational Upper Floridan aquifer freshening wells (i.e., wells F-1, F-3, F-4, F-5, F-6), to manage CCS salinity levels during an exceptionally dry period. This period of very low rainfall began in November 2016 and lasted through the end of the dry season until September 2017 (FPL 2017a, FPL 2017b, FPL 2018m). While operation of the marine wells does not require a water use permit from SFWMD, their operation is subject to FPL's Consent Agreement (MDC 2015a) with Miami-Dade County DERM. The agreement specifies that the marine wells may only be used to lower salinity in the CCS under "extraordinary circumstances." For the period of October 2017 to September 2018, FPL did not

need to operate the marine wells due to improved hydrologic conditions and improved CCS salinity, despite a severe dry season in late 2017 and early 2018 (see Section 3.5.1.4, “Adjacent Surface Water Quality and Cooling Canal System Operation” for discussion).

The NRC staff does not expect that periodic use of the marine wells, as might be necessary under abnormal conditions within the CCS, during the period of continued operations extending through the subsequent license renewal term would have any substantial impact on groundwater quality or quantity. The marine wells, located on the Turkey Point peninsula on Biscayne Bay and east of Turkey Point, withdraw saltwater from the upper part of the Biscayne aquifer and would not be expected to impact any wells withdrawing water from the inland portions of the Biscayne aquifer. This is because the permeable Biscayne aquifer in this area is recharged from Biscayne Bay, and any future marine well operation on a temporary basis would be unlikely to substantially alter groundwater flow beyond the affected area or result in any substantial drawdown in the Biscayne aquifer.

Conflicts Analysis for the Upper Floridan Aquifer

In 2018, FPL’s groundwater withdrawals from the Upper Floridan aquifer totaled approximately 7,396 mgd (27.9 million m³/yr). This equates to an average withdrawal of 20.3 mgd (76,840 m³/day) (see Section 3.5.2.3). Of the total withdrawn, approximately 12.7 mgd (48,100 m³/day) was associated with operation of the site’s freshening well system (i.e., wells F-1, F-3, F-4, F-5, F-6) for the CCS, with the remainder (i.e., about 7.6 mgd (28,800 m³/yr)) associated with the use of the site’s three site production wells (PW-1, PW-3, PW-4).

FPL’s modified site certification and associated conditions of certification for the Turkey Point site authorizes the withdrawal of 14.06 mgd (53,200 m³/day) of groundwater from the upper production zones of the Upper Floridan aquifer for cooling water for Unit 5 and process water for Units 1, 2, 3, 4, and 5 (i.e., from the site production wells) and an additional 14 mgd (53,000 m³/day) for CCS salinity reduction (freshening). Thus, FPL’s State-issued site certification authorizes a total average daily withdrawal of 28.06 mgd (106,200 m³/day) from the Upper Floridan aquifer (State of Florida Siting Board 2016, FDEP 2016b) (Section 3.5.2.3). As stated above, FPL’s groundwater withdrawals from the Upper Floridan aquifer have been less than the authorized amounts.

FPL commissioned the development of a technical evaluation by Tetra Tech (Tetra Tech 2014b) in support of FPL’s proposed use of Upper Floridan aquifer water for CCS freshening as part of the 2014 site certification modification effort (FPL 2018n). The East Coast Floridan Aquifer System Model - Phase 2 (ECFAS2) was used to evaluate potential aquifer drawdown and impacts on other groundwater users from the proposed groundwater use. As Tetra Tech documented in its report (Tetra Tech 2014b), the original ECFAS2 model is a regional, density-dependent groundwater flow and transport model originally developed for the SFWMD to meet SFWMD’s minimum basis of review requirements for water use permitting. The contractor modified and adapted the ECFAS2 model so that the groundwater flow component of the model could be used and calibrated it to current regional conditions (e.g., water levels). Site-specific hydrogeologic conditions were then incorporated into the adapted model by recalibrating the model using two aquifer performance tests performed at Turkey Point. This modified regional model (FPL Floridan model) was used to assess drawdown and potential groundwater use conflicts resulting from the proposed FPL withdrawals at the Turkey Point site and at offsite, regional locations, including potentially affected municipal wellfields (FPL 2018n, Tetra Tech 2014b).

As part of the modeling effort, two sets of simulations were run to assess drawdown in the Upper Floridan aquifer commensurate with SFWMD requirements for water use permitting. The first simulation projected drawdown due to sustained withdrawal at the maximum permitted rate from the freshening system wells alone. The second simulation included the freshening system well production in combination with other existing permitted withdrawals (using permitted rates) in the region. In the simulations, the total production volume was distributed evenly among FPL's wells.

First, SFWMD's basis of review for water use permitting requires that the 1-foot (0.3-m) drawdown contour at permitted wells be determined. Based on this criterion, the modeling results obtained from the FPL Floridan model (Tetra Tech 2014b) show that operation of FPL's freshening system wells at the maximum permitted rate results in four existing aquifer users falling within the 1-foot (0.3-m) drawdown contour attributable to withdrawals from FPL's salinity reduction wells. These locations include the Sound Golf Club, Ocean Reef Club, Florida Keys Aqueduct Authority, Miami-Dade Water and Sewer Department (MDWSD) South Miami Heights wellfield, and FPL Unit 5 well (PW-1).

A maximum drawdown of 15.1 feet (4.6 m) is predicted to occur on the Turkey Point site (i.e., at salinity reduction well F-3). For offsite, non-FPL wells, the model projects a maximum drawdown of 2.26 feet (0.7 m) at the MDWSD's South Miami Heights wellfield, located approximately 10.3 mi (16.6 km) north, northwest of the center point of FPL's freshening well system. However, the incremental drawdown attributable to FPL freshening well system withdrawals constitutes less than 5 percent of the total predicted cumulative drawdown (i.e., drawdown from all permitted withdrawals from the Upper Florida aquifer) at the South Miami Heights wellfield. In contrast, at the Florida Keys Aqueduct Authority located approximately 10 mi (16 km) to the west, the projected incremental drawdown (i.e., 2.16 feet (0.66 m)) is 12 percent of the total cumulative drawdown. The incremental drawdown contribution is also higher for permitted users that are closer to the Turkey Point site. Specifically, the predicted incremental drawdown (2.21 feet (0.67 m)) at Sound Golf Club and Ocean Reef Club (about 9 mi (14 km) south of the FPL freshening wells) is 19 percent of the total cumulative drawdown. Nevertheless, as documented in the modeling report, the predicted incremental drawdowns are conservative or bounding estimates (i.e., the model overestimates the drawdown due to FPL wells at offsite locations than would likely be observed). In all, the modeling analysis performed demonstrates that operation of FPL's salinity reduction wells (freshening well system) is likely to produce measurable, incremental drawdowns in other offsite Upper Floridan aquifer wells.

Further, the modeling results indicate that operation of the FPL freshening well system would be unlikely to result in any changes to regional water quality, as the Upper Floridan aquifer is already brackish, no saltwater interface exists in the confined system, and water quality changes experienced by other aquifer users have been minor (Tetra Tech 2014b). Nonetheless, SFWMD (SFWMD 2012) has documented that wells producing from the Upper Floridan aquifer can experience a degradation in water quality due to vertical seepage (upconing) or lateral movement of more saline water over time.

In accordance with the modified site certification and associated conditions of certification for the Turkey Point site (State of Florida Siting Board 2016, FDEP 2016b), FPL is required to mitigate harm to offsite groundwater users (either related to water quantity or quality) as well as to offsite water bodies, land uses, and other beneficial uses. As necessary, the SFWMD can order FPL to reduce withdrawals or undertake other mitigative actions. FPL is also required to regularly monitor the freshening well system for a number of water quality parameters including

TDS and chlorides and report the results to FDEP and Miami-Dade County on a quarterly basis (FDEP 2016b). Additionally, the 2015 Consent Agreement with Miami-Dade County DERM requires FPL to evaluate alternative water sources for freshening the CCS, including the use of reclaimed wastewater from the County South District Wastewater Treatment Plant, as further described in Section 3.5.2.3 of this SEIS.

Summary of Groundwater Use Conflicts Evaluation

In conclusion, the NRC staff's review indicates that current and projected groundwater withdrawals associated with FPL's operation of its Biscayne aquifer marine well and recovery well systems would be unlikely to have any noticeable, adverse impact on any supply wells beyond the confines of the Turkey Point site. This is because drawdowns in the unconfined Biscayne aquifer are projected to be minor and FPL's withdrawals would induce no adverse changes in the Biscayne aquifer or affect other permitted users of the aquifer. Additionally, modeling projections indicate that FPL's operation of the recovery well system will reduce salinity in the Biscayne aquifer and reduce the westward migration of the regional saltwater interface. Modeling results further indicate that recovery well system operations will be successful in retracting the hypersaline plume to within the boundaries of the Turkey Point property during the current renewed operating license term, although the NRC staff recognizes that uncertainty exists regarding the precise time by which the recovery well system will have achieved its objectives.

FPL's continued operation of its Upper Floridan aquifer production wells, particularly the freshening well system, is likely to affect offsite well systems by increasing drawdown in the aquifer beyond that currently being experienced due to regional groundwater production alone. Currently, available information indicates that FPL will need to operate the five CCS freshening wells (i.e., wells F-1, F-3, F-4, F-5, F-6) in addition to its three site production wells (PW-1, P-3, PW-4) during the subsequent license renewal period of extended operation. The NRC staff finds that the projected drawdowns would noticeably affect the Upper Floridan aquifer, but that FPL's continued withdrawals would not destabilize the groundwater resource or impair the use of the Upper Floridan aquifer by other users and well systems during the period of subsequent license renewal.

Finally, as stated in its environmental report, FPL does not anticipate the need to withdraw groundwater at a rate exceeding its current permits and/or authorizations during the subsequent license renewal period (FPL 2018f). Accordingly, the NRC staff has assumed in this impacts assessment that FPL's groundwater withdrawals from the Upper Floridan aquifer and Biscayne aquifer would not exceed the limits specified in current authorizations and permits. In summary, based on the evaluation presented above, the NRC staff anticipates that operation of the recovery well system will not result in any interference with existing permitted uses of groundwater, will not impact natural resources, and will not result in westward lateral movement of the saltwater interface in the Biscayne aquifer. Further, infrequent operation of FPL's marine wells is not expected to substantially alter groundwater flow or result in any substantial drawdown in the Biscayne aquifer. For the Upper Floridan aquifer, groundwater modeling performed to evaluate aquifer response from continued operation of FPL's freshening well system indicates the potential for appreciable drawdowns in offsite production wells, including in potable water wells located approximately 10 mi (16 km) from the Turkey Point site. While the projected drawdowns would be noticeable in affected offsite wells, the effects would not be expected to affect water availability or impair the Upper Floridan aquifer as a resource. Consistent with these impacts, the NRC staff concludes that the potential for groundwater use

conflicts from FPL's groundwater withdrawals would be SMALL for the Biscayne aquifer and MODERATE for the Upper Floridan aquifer during the subsequent license renewal term.

Radionuclides Released to Groundwater

All commercial nuclear power plants routinely release radioactive gaseous and liquid materials into the environment. These radioactive releases are designed to be planned, monitored, documented, and released into the environment at designated discharge points. In contrast, this issue considers the potential impact to groundwater quality from the unplanned, inadvertent discharge of liquids containing radionuclides into groundwater. Such unknown, uncontrolled, and unmonitored releases of radioactive liquids have occurred at nuclear power plant sites from power plant systems, piping, spent fuel pools, valves, and tanks. The majority of the inadvertent liquid release events involved tritium, which is a radioactive isotope of hydrogen. However, other radioactive isotopes, such as cesium and strontium, have also been inadvertently released into the groundwater at some sites. The inadvertent release of radionuclides to groundwater is a Category 2 issue and requires a plant-specific assessment.

In evaluating the potential impacts on groundwater quality associated with license renewal, the NRC staff uses as its baseline the existing groundwater conditions described in Sections 3.5.2.1 through 3.5.2.3 of this SEIS. These baseline conditions encompass the existing quality of groundwater potentially affected by continued operations (as compared to relevant State or EPA primary drinking water standards), as well as the current and potential onsite and offsite uses and users of groundwater for drinking and other purposes. The baseline also considers other downgradient or in-aquifer uses and users of groundwater.

For the Turkey Point site, FPL participates in the Nuclear Energy Institute's NEI 07-07, "Industry Ground Water Protection Initiative" (NEI 2007), which is focused on actions to improve management and response to the inadvertent release of radioactive substances to subsurface soils and water. Since 2010, FPL has maintained a radiological environmental sampling and analysis program for Turkey Point to meet the recommendations of NEI 07-07. FPL performs groundwater monitoring at 28 onsite locations to monitor for potential inadvertent radioactive releases via potential groundwater pathways at the site in accordance with site procedures. Samples are collected on at least a quarterly basis, or more frequently if deemed necessary. FPL reports the results in annual radiological environmental operating reports and submits these to the NRC.

FPL reports that it has experienced a number of inadvertent releases of radionuclides at Turkey Point with the potential to reach groundwater over the last 5 years, which the NRC staff has reviewed and summarized in the subsection titled "Routine and Potential Inadvertent Releases of Radionuclides and Other Pollutants to Groundwater" under Section 3.5.2.2 of this SEIS. Nine such releases were recorded over the period of March 2014 through August 2018. FPL documents such "unplanned" releases in its annual radioactive effluent release reports, which it submits to the NRC. The NRC staff reviewed these reports as part of this environmental review. The releases generally involved water containing tritium as well as other radionuclides including cobalt-58 and sodium-24.

The largest inadvertent release, by liquid volume, involved a sustained release of component cooling water from a leaking heat exchanger, totaling an estimated 4,828 gal (18,280 L). This release occurred during the period from July 26 to September 15, 2015. As discussed in Section 3.5.2.2 of this SEIS, other releases occurred in 2014, 2015, 2017, and 2018, involving substantially smaller releases. In all cases, FPL stopped ongoing releases, surveyed the

release area, and increased groundwater sampling in potentially affected areas, as appropriate. FPL documented all such events in the Turkey Point corrective action program, as appropriate.

Table 3-6 in Section 3.5.2.2 of this SEIS summarizes the latest available radiological groundwater monitoring results for Turkey Point and compares the results to historical maximum observed concentrations at each well location. Groundwater monitoring shows that tritium is detectable in underlying groundwater in and around the Turkey Point nuclear island and in areas adjoining the intake and discharge canals. This is not unexpected given the discharge of monitored and permitted effluents containing tritium to the unlined CCS, which is in hydraulic communication with the underlying Biscayne aquifer.

As shown in Table 3-6, in 2018, tritium concentrations in groundwater at Turkey Point Units 3 and 4 ranged from below the minimum detectable concentration to a maximum of 3,390 pCi/L at monitoring well PTN-MW-8S. This maximum tritium level was observed during the fourth quarter of 2018. Monitoring well PTN-MW-8S is located near the Turkey Point Unit 3 refueling water storage tank, between Unit 3 and the cooling water intake canal coming off the CCS (see Figure 3-27). The highest measured tritium concentration in groundwater beneath the Units 3 and 4 plant complex over the last 5 years was 13,600 pCi/L in well PTN-MW-8S during the fourth quarter of 2017. As for plant storm drains, the peak concentration in 2018 was measured in the northeast storm drain at 7,470 pCi/L. This location is on the north side of the intake canal and east of Unit 3 and monitoring well PTN-MW-8S. As referenced in Section 3.5.2.2, measured tritium in storm drains is heavily influenced by the inflow of water from the CCS.

Surficial groundwater (i.e., the Biscayne aquifer) that has been affected by inadvertent releases within the Turkey Point plant property is classified by the FDEP as Class G-III waters, which means it is neither a current nor potential future source of drinking water. There are no discernible trends in the radiological groundwater protection monitoring results that would indicate either a new inadvertent release or an ongoing inadvertent release of radionuclides to groundwater at Turkey Point. Further, the data indicate that there is no occurrence or migration of tritium in groundwater at concentrations exceeding either the tritium limit (30,000 pCi/L) prescribed by the plant Offsite Dose Calculation Manual (FPL 2013a) or the EPA primary drinking water standard (20,000 pCi/L) (40 CFR 141.66, "Maximum Contaminant Levels for Radionuclides").

Based on the information presented and the NRC staff's review of groundwater monitoring data, the NRC staff finds that inadvertent releases of radionuclides (primarily tritium) have not substantially impaired site groundwater quality within the Biscayne aquifer and have not affected groundwater use beyond the Turkey Point site. Thus, the NRC staff concludes that groundwater quality impacts from inadvertent releases of radionuclides are SMALL and are projected to remain SMALL during the subsequent license renewal term.

4.5.2 No-Action Alternative

4.5.2.1 Surface Water Resources

Under the no-action alternative, the NRC would not issue subsequent renewed licenses, and Turkey Point would shut down on or before the expiration of the current renewed operating licenses. During shutdown, there would not be any surface water consumption or offsite discharges to surface water bodies and effluent discharges from Units 3 and 4 to the CCS would decrease. Storm water would continue to flow into the CCS. Other facilities at the Turkey Point site would continue to discharge to the CCS, including cooling tower blowdown

from Unit 5. Water from the CCS would continue to be circulated through retired fossil fuel Units 1 and 2. However, this circulation would not add heat to the CCS.

After shutdown, the temperature of water within the CCS would be much lower and the rate of evaporation of water from the CCS would decrease. The NRC staff expects that FPL would continue to implement State- and County-required programs to reduce salinities and to control ammonia and nutrients within the CCS, until the desired objectives are achieved. These actions would reduce the potential for waters from the CCS to impact surface water bodies via the groundwater pathway. Therefore, the NRC staff concludes that the impacts to surface water resources from the no-action alternative would be SMALL.

4.5.2.2 *Groundwater Resources*

Miami-Dade Water and Sewer Department (MDWSD) supplies potable water to Turkey Point for process water makeup, potable uses, and fire protection uses. The source of this water is groundwater pumped from the Biscayne aquifer. With the cessation of operations, FPL's use of potable water at Turkey Point for these uses would be greatly reduced but would not likely cease until sometime during decommissioning. Similarly, FPL's use of groundwater from the Upper Floridan aquifer to supply water for Turkey Point uses would also likely be reduced as a result of shutdown and would eventually cease.

Sanitary wastewater discharges to the Biscayne aquifer via Turkey Point's Class V injection well would also be reduced as the plant workforce is drawn down.

As described in Section 4.5.2.1 of this SEIS, shutdown of Turkey Point would entail a gradual reduction and eventual cessation of condenser cooling water and service water withdrawals from, and return discharges to, the CCS. However, the NRC staff expects that the CCS would continue to receive effluent discharges from Turkey Point Unit 5 for the foreseeable future as well as stormwater runoff from the Turkey Point plant complex and from the balance of the Turkey Point site. Consequently, water in the CCS would continue to be exchanged with groundwater in the underlying Biscayne aquifer.

The shutdown of Turkey Point would substantially reduce thermal discharges to the CCS as well as cooling water and other effluents from the plant's cooling water system. This flow reduction would reduce groundwater mounding (i.e., a localized increase in the water table) beneath the CCS and reduce the generation of hypersaline water. As a result, the NRC staff expects that the amount of water used to support freshening activities in accordance with the provisions of FPL's 2015 Consent Agreement with Miami-Dade County DERM (MDC 2015a) and the 2016 FDEP Consent Order (FDEP 2016a) could be reduced. Currently, the principal source of water for salinity management (i.e., freshening) in the CCS and for reducing the generation of hypersaline groundwater beneath the CCS is derived from five production wells tapping the Upper Floridan aquifer. These withdrawals are described in Section 3.5.2.3 of this SEIS and their impacts are evaluated in Section 4.5.1.2 above. Nevertheless, with the shutdown of Turkey Point Units 3 and 4, the NRC staff expects that some use of water by FPL for salinity management in the CCS would continue indefinitely, possibly at a reduced rate.

The NRC staff also expects that continued operation of the recovery well system and associated deep well injection of the recovered hypersaline water would continue during the shutdown period and at least until the initial remediation objectives of the recovery well system are achieved (i.e., plume attenuation and retraction). As described in detail in Section 4.5.1.2, "Groundwater Resources," modeling results indicate that the recovery well system will be

successful in achieving the County and State prescribed remediation objectives during the current operating license term, although uncertainty exists regarding the timing of remediation efforts. Miami-Dade County and the FDEP could as necessary require FPL to develop alternate remediation plans and systems to meet the objectives of the 2015 Consent Agreement (MDC 2015a) and the 2016 FDEP Consent Order (FDEP 2016a). Subsequently, FPL may need to operate and maintain the recovery well and associated deep well injection systems for as long as necessary to achieve and maintain compliance with County and FDEP requirements. Based on the above considerations, the NRC staff concludes that the overall impact of the no-action alternative on groundwater resources would be SMALL.

4.5.3 Replacement Power Alternatives: Common Impacts

4.5.3.1 Surface Water Resources

For all replacement power alternatives considered, the NRC staff assumes that surface water resources would not be consumed and liquid discharges to adjacent surface water bodies would not be allowed during both construction and operation. During construction, all water from dewatering and other activities would be discharged into the CCS. During operations, cooling tower blowdown and radiological liquid discharges would be deep well injected into the Boulder Zone of the Floridan aquifer. Stormwater would be discharged into the CCS.

As discussed in the no-action alternative, under a replacement power alternative, the CCS would no longer be used for cooling by Units 3 and 4 or by any of the replacement power alternatives evaluated. Consequently, the potential for impacts from the CCS on adjacent surface water bodies via the groundwater pathway would be reduced. Therefore, the NRC staff concludes that the common impacts on surface water resources would be SMALL.

4.5.3.2 Groundwater Resources

Construction

Construction activities associated with thermoelectric power facilities at the Turkey Point site would likely require groundwater dewatering, especially of deep excavations associated with emplacement of facility foundations and substructures. This would require the use of cofferdams, sheet pilings, sumps, wells, or other methods to address high water-table conditions. Use of crushed limestone fill at construction sites would reduce the relative depth of excavation work and would minimize post-construction impacts.

Excavation work and dewatering would affect the Biscayne aquifer. As previously evaluated by the NRC staff for the construction of Turkey Point Units 6 and 7, dewatered areas of the aquifer would be quickly recharged locally from surface-water features including the cooling canals, Biscayne Bay, the L-31E Canal, aquifer inflow, and infiltration of rainfall. It is possible that dewatering could induce groundwater flow from the inland portion of the aquifer through deeper permeable layers and toward the dewatering points. However, the volume of inland groundwater captured would be very small (NRC 2016a). Dewatering at the rates (400 to 1,200 gpm (1,500 to 4,500 L/min) projected in Section 4.2.1 of the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a) would require a water use permit issued by the SFWMD (FAC 40E-2). The NRC staff expects that any impacts on groundwater flow and quality within the portions of the Biscayne aquifer affected by dewatering would be highly localized and of short duration, with minor effects on other aquifer users.

Once extracted, groundwater would be managed in accordance with FDEP requirements. For example, discharge of extracted groundwater would be governed by conditions specified in an FDEP-issued NPDES general (generic) permit for stormwater discharge from large and small construction activities (FDEP 2018a, FPL 2018f). Dewatering flows could also be discharged to the CCS, which would likely require a modification of FPL's NPDES permit (i.e., industrial wastewater facility permit). A similar scenario was previously evaluated by the NRC staff in Section 4.2.1.4 of the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176). There, the NRC staff evaluated a maximum discharge rate to the CCS of 1,200 gpm (450 L/min), equivalent to 1.7 mgd (6,500 m³/day) over an assumed dewatering period of 1 year. In summary, the NRC staff determined that such a discharge rate would generally not be detectable in the CCS as that rate of discharge would equate to about 0.06 percent of the recirculating flow rate of the CCS. The NRC staff further concluded that the impacts on groundwater quality, including from additional seepage from the CCS, would be minor (NRC 2016a).

Construction of replacement power generating facilities at the Turkey Point site would increase the amount of impervious surface as well as alter the subsurface strata because of excavation work and the placement of backfill following facility completion. While an increase in impervious surface would reduce infiltration and reduce groundwater recharge, the effects on water-table elevations in the underlying Biscayne aquifer would likely be very small given the relatively small surface area affected and the high permeability of the aquifer. Below-grade portions of new power generating facilities at the site could alter the direction of groundwater flow. Such effects would likely be localized, and the NRC staff does not expect them to affect offsite groundwater users or adjacent surface water bodies, including Biscayne Bay.

Application of best management practices in accordance with a stormwater pollution prevention plan developed for the FDEP-issued NPDES generic permit, including appropriate waste management, water discharge, and spill prevention practices, would prevent or minimize any areawide groundwater quality impacts during construction.

The construction of additional onsite underground injection wells and associated monitoring wells may be necessary to support the disposal of effluent streams from operations. Such wells could also be used to dispose of any wastewaters generated during facility construction. In association with the construction of Turkey Point Units 6 and 7, the NRC staff evaluated the construction of 10 underground injection wells, 2 backup wells, and 6 dual-zone monitoring wells. The wells would be more than 3,000-feet (914-m) deep and completed in the Boulder Zone of the Lower Floridan aquifer. Construction of these wells would be subject to FDEP Class I industrial waste underground injection control permits (FAC 62-528). In Section 4.2.3 of the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176), the NRC staff determined that activities related to the construction of injection wells and monitoring wells in the Boulder Zone would have negligible effects on groundwater quality in the surficial Biscayne aquifer and the deeper Floridan aquifer system (NRC 2016a).

Water would be required for such uses as dust control and soil compaction, as well as to meet the drinking and sanitary needs of the construction workforce during the construction period for all facilities. The use of portable sanitary facilities, serviced by a commercial vendor, would serve to reduce water use and sanitary wastewater generation by the construction workforce. Consistent with the assumptions in FPL's environmental report submitted as part of this subsequent license renewal application and as previously considered in the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a), the NRC staff assumes that water would be obtained from the Miami-Dade Water and Sewer Department

(MDWSD). The principal water source for the MDWSD is the Biscayne aquifer. The NRC staff projects that maximum water use to support construction would be approximately 0.8 mgd (3,000 m³/day). The volume of water required would be a very small percentage of the capacity of the County system (NRC 2016a).

Operation

Post-construction groundwater dewatering may be required during the operational period of the onsite power generating facilities. Dewatering rates would be much lower than those projected for the construction period. Operational dewatering would be subject to water use permitting requirements administered by the SFWMD (FAC 40E-2). Once extracted, groundwater would be managed in accordance with FDEP requirements, including applicable NPDES permitting requirements.

Onsite thermoelectric power generating facilities would use mechanical draft cooling towers for condenser cooling. For the purposes of analysis and as referenced in Section 2.2 of this SEIS, the NRC staff assumes that these cooling towers would be similar to those previously described in Section 3.4.2.2 of the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a). The source of makeup water would be reclaimed wastewater supplied by the MDWSD (see Table 2-1). The NRC staff assumes that no groundwater would be directly used to support operation of replacement power generating facilities.

Replacement power facilities would also require freshwater for general service water, fire protection, demineralized water makeup, and potable and sanitary use. The NRC staff assumes that this water would be obtained from MDWSD via an existing right-of-way and/or a proposed new supply pipeline to the Turkey Point site as described in Section 3.2.3 of the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a).

The onsite thermoelectric power generating facilities would produce cooling tower blowdown, treated radiological wastewater, sanitary wastewater, and other effluent streams. Consistent with the assumptions in the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a), the NRC staff assumes that these effluent streams would be disposed of via underground injection wells to the Boulder Zone. Disposal would occur via the same or similar wells as proposed for use in support of Unit 6 and 7 operations. Any new wells would be constructed and operated in accordance with underground injection control permits issued by the FDEP (FAC R62-528).

In Sections 3.4.2, 5.2.1.3, 5.2.3, and 5.8 of the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a), the NRC staff evaluated the deep well injection of up to 90 mgd (341,000 m³/day) of cooling water blowdown and other liquid waste streams from proposed Units 6 and 7. The NRC staff concluded in part that proper well design and isolation of the Boulder Zone by low-permeability strata would prevent degradation of overlying underground sources of drinking water. The Boulder Zone deep injection wells would be permitted by FDEP. This permit would require FPL to implement institutional controls and monitoring programs to detect upward migration of injected wastewater. As a result, the NRC staff concluded that operational groundwater-quality impacts would be SMALL (NRC 2016a).

It is expected that stormwater runoff from onsite thermoelectric power generating facilities would be conveyed to the CCS. Use of the CCS would require that FPL modify its NPDES permit (i.e., industrial wastewater facility permit) for operation of the facility. Since the CCS is in hydraulic communication with the underlying Biscayne aquifer, any pollutants in stormwater

runoff could reach groundwater. Nevertheless, as facility operations would be subject to pollution prevention and best management practices required by FDEP, the NRC staff considers potential water quality impacts on groundwater quality to be minimal.

As described in Section 4.5.2.2 for the no-action alternative, the NRC staff expects that groundwater demands for CCS freshening would decrease over time for the replacement power alternatives, commensurate with a reduction in thermal discharge to the CCS, but that some use of water by FPL for salinity management in the CCS would continue indefinitely. The NRC staff expects that the volume of water needed for CCS freshening will be governed by the provisions of FPL's 2015 Consent Agreement with Miami-Dade County DERM (MDC 2015a) and the 2016 FDEP Consent Order (FDEP 2016a), recognizing that those requirements are subject to possible modification in the future. In addition, continued operation of the recovery well system, and associated deep well injection of the recovered hypersaline water, may be necessary for some period of time to maintain compliance with the above-referenced State and County regulatory agreements. System operations would remain subject to applicable permit, monitoring, and reporting requirements imposed by State agencies, as previously discussed in Section 4.5.1.2 (see "Conflicts Analysis for the Biscayne Aquifer").

4.5.4 New Nuclear Alternative

4.5.4.1 Surface Water Resources

The NRC staff did not identify any impacts to surface water resources for this alternative beyond those discussed above as common to all replacement power alternatives. Therefore, the NRC staff concludes that the impacts to surface water resources from this alternative would be SMALL.

4.5.4.2 Groundwater Resources

Groundwater use and quality impacts from construction and operations associated with the new nuclear alternative would likely be similar to but somewhat less than those described and assumed as common to all alternatives in Section 4.5.3.2. This is due to the reduced construction footprint and operational impacts. The staff projects that the use of reclaimed wastewater for cooling tower makeup and the generation of cooling tower blowdown and other effluents would be reduced by about 30 percent, as compared to the proposed Turkey Point Units 6 and 7. This would produce cooling tower blowdown along with other effluents at a rate of approximately 9 mgd (34,100 m³/day). These wastewaters would be disposed of by deep well injection into the Boulder Zone beneath the Turkey Point site (see Section 4.5.3.2). Therefore, the NRC staff concludes that the impacts on groundwater resources from construction and operations associated with the new nuclear alternative would be SMALL.

4.5.5 Natural Gas Combined-Cycle Alternative

4.5.5.1 Surface Water Resources

The NRC staff did not identify any impacts to surface water resources for this alternative beyond those discussed above as common to all replacement power alternatives. Therefore, the NRC staff concludes that the impacts to surface water resources from the natural gas combined-cycle alternative would be SMALL.

4.5.5.2 *Groundwater Resources*

Groundwater use and quality impacts from construction activities and operations associated with the natural gas combined-cycle alternative would be much smaller than those described in Section 4.5.3.2. This is because less extensive excavation work and associated dewatering would be required for construction. As for operations, the NRC staff projects that cooling water demand associated with operation of cooling towers and the generation of blowdown and other effluent streams would be reduced by approximately 80 and 70 percent, as compared to the proposed Turkey Point Units 6 and 7 and new nuclear alternative, respectively, given the comparatively lower level of cooling needed for the natural gas plant. This would produce cooling tower blowdown along with other effluents at a rate of approximately 2.4 mgd (9,100 m³/day), which would be disposed of by deep well injection into the Boulder Zone (see Section 4.5.3.2).

Construction of a new natural gas pipeline would result in additional ground-disturbing impacts and the need for dewatering areas around pipeline pad and pier supports. However, any groundwater impacts would likely be localized and temporary.

For this alternative, the NRC staff concludes that the impacts on groundwater resources from construction and operations would be SMALL.

4.5.6 Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)

4.5.6.1 *Surface Water Resources*

The NRC staff did not identify any impacts to surface water resources for this alternative, beyond those discussed above as common to all replacement power alternatives. Therefore, the NRC staff concludes that the impacts to surface water resources from this alternative would be SMALL.

4.5.6.2 *Groundwater Resources*

Groundwater use and quality impacts from construction activities and operations associated with the onsite natural gas combined-cycle component of this alternative would be very similar to those referenced in Section 4.5.5.2. This is because the construction and operational aspects of the natural gas combined-cycle power plant would be similar.

The NRC staff expects that there would be little or no groundwater use or groundwater quality impacts for construction and operations of the onsite and offsite solar facilities. This is because groundwater dewatering would likely be minimal due to the relatively small footprint of pad sites, access roads, and utility corridors where excavation, grading, and trenching might be required.

Based on the above, the NRC staff concludes that the overall impacts on groundwater resources from construction and operations associated with the combination alternative would be SMALL.

4.5.7 Cooling Water System Alternative

4.5.7.1 Surface Water Resources

The NRC staff did not identify any impacts to surface water resources for this alternative beyond those discussed above as common to all replacement power alternatives. Therefore, the NRC staff concludes that the impacts to surface water resources from this alternative would be SMALL.

4.5.7.2 Groundwater Resources

No onsite groundwater would be required to support cooling tower construction. Water would be required for such uses as dust control, soil compaction, as well as to meet the drinking and sanitary needs of the construction workforce during the construction period for all facilities. Consistent with the assumptions in the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a), the NRC staff assumes that water for such uses would be obtained from the MDWSD, which primarily uses the Biscayne aquifer as a water source. The NRC staff expects that construction water would be trucked to the point of use as needed from onsite service connections with MDWSD. Onsite water demands to support cooling tower construction could be reduced by the use of ready-mix concrete and the use of portable sanitary facilities for construction workers that are serviced offsite.

Groundwater dewatering would likely be required in excavations associated with below-grade portions of the cooling towers. Construction activities would include the use of cofferdams, sheet pilings, sumps, wells, or other methods to address high water-table conditions as they exist at the Turkey Point site. Depending on the rate and duration of dewatering activities, dewatering activities would have to be permitted under a SFWMD-issued water use permit or, more likely, under a general permit-by-rule for temporary dewatering (FAC 40E-2). The NRC staff expects that any impacts on groundwater flow and quality within the portions of the Biscayne aquifer affected by dewatering would be highly localized and of short duration, with minor effects on other aquifer users.

Once extracted, the NRC staff assumes that groundwater would be properly managed in accordance with FDEP requirements. Specifically, an FDEP-issued NPDES general permit for stormwater discharge from large and small construction activities would govern the discharge of extracted groundwater and all ground-disturbing activities. The construction contractor would be required to implement best management practices and other controls (including appropriate waste management, water discharge, and spill prevention practices) under a stormwater pollution prevention plan (FDEP 2018a). These would serve to mitigate any impacts on groundwater quality during construction.

During commissioning of the cooling water system alternative, Turkey Point may be offline for a period of time. Groundwater production on the Turkey Point site associated with the operation of the five CCS freshening wells (F-1, F-3, F-4, F-5, F-6) withdrawing from the Upper Floridan aquifer and the three site production wells (PW-1, PW-3, PW-4) would be expected to continue at current rates during the transition period.

As described in Section 4.5.2.2 for the no-action alternative, the NRC staff expects that the CCS would continue to operate under this alternative and would receive cooling tower blowdown and other effluents and runoff from Turkey Point Unit 5 as well as stormwater from the Turkey Point plant complex and other FPL facilities. While the NRC staff expects that groundwater demands

for CCS freshening would decrease over time commensurate with the reduction in thermal discharge to the CCS from Turkey Point Units 3 and 4, some use of groundwater (or other water sources) would likely continue indefinitely. The NRC staff expects that the volume of water needed for CCS freshening will be governed by the provisions of FPL's 2015 Consent Agreement with Miami-Dade County DERM (MDC 2015a) and the 2016 FDEP Consent Order (FDEP 2016a), recognizing that those requirements are subject to possible modification in the future. Further, as also described in Section 4.5.2.2, continued operation of the recovery well system and associated deep well injection of the recovered hypersaline water may be necessary for some period of time to maintain compliance with the above-referenced State and County regulatory requirements. System operations would remain subject to applicable permit, monitoring, and reporting requirements imposed by State and County agencies, as previously discussed in Section 4.5.1.2.

No onsite groundwater or MDWSD-supplied groundwater would be used during operation of the Turkey Point cooling water system alternative, as the cooling towers would be supplied by treated, reclaimed wastewater. Otherwise, onsite use of MDWSD-supplied groundwater from the Biscayne aquifer for Turkey Point Units 3 and 4 potable water and fire protection use (see Section 3.5.2.3, "Groundwater Use") would be similar to the volumes used during the current renewed license period.

Operation of the mechanical-draft cooling towers for condenser cooling would produce cooling tower blowdown at a projected rate of 11 mgd (41,600 m³/day). This effluent stream would contain cooling water treatment and conditioning chemical residuals (e.g., biocides, corrosion inhibitors) necessary for proper operation and maintenance of the cooling towers and Turkey Point Units 3 and 4 circulating water system. Additionally, Turkey Point Units 3 and 4 operations would continue to produce various process water effluents, including liquid radwaste effluents. The NRC staff assumes that these effluents would be disposed of by deep well injection into the Boulder Zone, which would be regulated under a Class I underground injection control permit issued by the FDEP (FAC 62-528).

As referenced in Section 4.5.3.2, the NRC staff previously evaluated the deep well injection of up to 90 mgd (341,000 m³/day) of cooling water blowdown and other liquid waste streams from proposed Turkey Point Units 6 and 7. The NRC staff concluded in part that proper well design and isolation of the Boulder Zone by low-permeability strata would prevent degradation of overlying underground sources of drinking water. The Boulder Zone deep injection wells would be permitted by FDEP, and FPL would be required to implement institutional controls and monitoring programs to detect upward migration of injected wastewater. As a result, the NRC staff concluded that operational groundwater-quality impacts would be SMALL (NRC 2016a). The NRC staff finds that the disposal of effluents by deep well injection of effluents under this alternative would be bounded by the cited analysis.

In consideration of the information and assumptions presented above, the NRC staff concludes that the impacts on groundwater resources from construction and operation of the cooling water system alternative would be SMALL.

4.6 Terrestrial Resources

This section describes the potential terrestrial resources impacts of the proposed action (subsequent license renewal) and alternatives to the proposed action.

4.6.1 Proposed Action

As identified in Table 4-1, “Applicable Category 1 (Generic) Issues for Turkey Point,” in Section 4.1 of this chapter, the impacts of all generic terrestrial resource issues would be SMALL. According to the GEIS (NRC 1996 and 2013a), terrestrial resources would not be significantly affected by continued operations associated with license renewal. For the terrestrial resource issues addressed in the 2013 GEIS, no new and significant information was identified that would alter the GEIS conclusions for Category 1 issues for Turkey Point subsequent license renewal. New information related to one of these categories, “Cooling system impacts on terrestrial resources (plants with once-through cooling systems or cooling ponds),” is discussed below. Also, in Section 4.1 of this chapter, Table 4-2, “Applicable Category 2 (Site-Specific) Issues for Turkey Point,” identifies one site-specific (Category 2) issue related to terrestrial resources during the subsequent license renewal term. That issue is also analyzed below.

New Information, Category 1 Issue, Cooling System Impacts on Terrestrial Resources (Plants with Once-Through Cooling Systems or Cooling Ponds)

As referenced in Section 1.4 of this SEIS and as further described under Sections 1.5 and 1.8 of the GEIS (NUREG-1437) (NRC 2013a), no additional site-specific analysis is required by the NRC staff for Category 1 (generic) issues in the SEIS unless new and significant information is identified that would change the conclusions in the GEIS. Where new and significant information has been identified, the NRC staff would reconsider generic impacts in the SEIS.

The Category 1 issue, “Cooling system impacts on terrestrial resources (plants with once-through cooling systems or cooling ponds),” was first evaluated in the 1996 GEIS (NRC 1996) under the name, “Cooling pond impacts on terrestrial resources.” This issue was modified and renamed in Revision 1 to the GEIS, which was issued in June 2013 (NRC 2013a).

For the subject issue, the 2013 GEIS (NRC 2013a: 4-64 - 4-69) considers potential impacts to terrestrial resources from contaminants and physical alterations of the environment resulting from cooling system operations. As a part of the analysis, the 2013 GEIS describes several site-specific examples of plants with cooling ponds and the NRC staff’s conclusions regarding the effects on terrestrial resources as documented in site-specific SEISs, including the potential effects from the CCS at Turkey Point. The 2013 GEIS (NRC 2013a: page 4-68) specifically states the following:

Groundwater quality can be degraded by contaminants present in cooling ponds and cooling canals. Deep-rooted terrestrial plants could be exposed to these contaminants. In addition, biota could be exposed to contaminants at locations of groundwater discharge, such as wetlands or riparian areas. However, as noted above, contaminant concentrations are typically very low, and any effects on terrestrial plants would be expected to be SMALL. Mitigation may also be implemented where sensitive resources could be affected. At the Turkey Point plant in Florida, for example, the flow of hypersaline groundwater from the cooling canals toward the Everglades to the west is prevented by an interceptor ditch, located along the west side of the canal system, from which groundwater inflow is extracted (NRC 2002b).

Since publication of the 2013 GEIS, new information has indicated that the interceptor ditch has not prevented the movement of hypersaline groundwater in the deep Biscayne aquifer west of

the Canal L-31E Levee. Section 3.6 of this SEIS presents and considers relevant new information related to terrestrial resources at the Turkey Point site concerning the subject issue.

Specifically, Section 3.6.2, “Marsh, Mangrove, and Tree Island Semiannual Monitoring,” of this SEIS summarizes results from FPL’s ecological monitoring through 2018. This monitoring is a requirement of the FDEP’s Conditions of Certification in connection with the Turkey Point extended power uprate and the SFWMD’s Fifth Supplemental Agreement. With respect to marshes and mangroves near the Turkey Point site, monitoring data support the conclusion that the CCS does not have a discernable ecological impact on the surrounding areas and that there is no clear evidence of CCS water in the surrounding marsh and mangrove areas from a groundwater pathway (FPL 2018o). Although FPL has observed some ecological changes, these changes have been seasonally and meteorologically driven. For instance, one freshwater marsh plot experienced a complete die-off of sawgrass in connection with Hurricane Irma, which made landfall in Southern Florida in September 2017. The same plot began exhibiting recovery during subsequent sampling events. Mangroves have exhibited an overall stable structure and composition. Porewater samples have indicated no evidence of impacts from the CCS on soil porewater quality via the groundwater pathway. Current data suggest that operation of the CCS does not have a noticeable impact on wetlands or any other important attribute of the terrestrial environment on or near the Turkey Point site. It also suggests that the interceptor ditch has prevented the westward movement of near surface groundwater and attendant impacts on local ecology. In conclusion, the NRC staff has determined that the new information available since the publication of the 2013 GEIS is not significant because it does not change the finding of SMALL for the Category 1 issue of “Cooling system impacts on terrestrial resources (plants with once-through cooling systems or cooling ponds).”

4.6.1.1 Category 2 Issue Related to Terrestrial Resources: Effects on Terrestrial Resources (Non-Cooling System Impacts)

According to the GEIS (NUREG-1437), non-cooling system impacts on terrestrial resources can include those impacts that result from landscape maintenance activities, stormwater management, elevated noise levels, and other ongoing operations and maintenance activities that would occur during the subsequent license renewal period on or near a plant site.

Landscape Maintenance and Operational Activities

FPL’s (FPL 2018f; FPL 2018g) landscape maintenance and operational activities during the subsequent license renewal term would remain similar to those currently conducted. These activities primarily consist of mowing, string trimming, hedge trimming, weed removal, herbicide application, tree trimming, brush removal, debris removal, and the maintenance and repair of plant infrastructure such as roadways, piping installations, fencing, and security-related structures. FPL does not anticipate performing refurbishment during the subsequent license renewal period (FPL 2018f).

Within developed portions of the site—such as near the power block, administrative buildings, and transmission lines and associated infrastructure—landscape activities generally include vegetative trimming and mowing, herbicide application, and infrastructure maintenance and repair. Herbicide treatment would primarily occur in areas connecting the collector yard to the switch yard. FPL (2018f) applies commercially approved herbicides in accordance with its Florida site certification application and applicable Federal and State regulations. For example, FPL must notify the FDEP Southeast District of the Department of Siting Coordination Office at least 60 days prior to the first use of an herbicide. Herbicide treatment, vegetative trimming and

mowing, and infrastructure maintenance in these areas could disturb or displace wildlife and birds. However, most wildlife near these areas are likely relatively tolerant of human activity given the current level of operational activities onsite. Any wildlife that become disturbed or displaced when landscape activities occur would be able to find similar habitat onsite or nearby. In addition, the displacement period would be limited to a few hours or days.

Within less-developed portions of the site that contain high-quality terrestrial habitats—such as freshwater wetlands, mangroves, or wooded areas—ground-disturbing maintenance activities include hand and mechanical vegetative control, hand and mechanical debris removal, maintenance of the CCS access roads (e.g., mechanical scrapping and aggregate placement), underground piping repair (e.g., digging and equipment staging), and equipment replacement at groundwater wells and monitoring stations. FPL annually removes exotic species, such as Australian pine (*Casuarina equisetifolia*) and Brazilian pepper (*Schinus terebinthifolius*), from within CCS canals and berms and along the access and CCS perimeter roads. FPL removes such species using an amphibious excavator backhoe and a D-3 Dozer, piling the vegetation on the CCS berms and then burning the vegetation in accordance with the FPL burn permit issued by the Florida Department of Agriculture and Consumer Services (FDACS) Permit 1373498 (FPL 2018g). Removal occurs along berms that provide habitat for federally protected species (American crocodile (*Crocodylus acutus*)), State-protected species (least terns (*Sterna antillarum*)), and other wildlife and birds. Within areas that FPL has defined as crocodile sanctuaries, FPL maintains all native species after removing exotic species. On all other berms, FPL uses power equipment to maintain a low level of small brush, grass, and weeds. Although removal and burning could disturb wildlife and result in increased sedimentation within the CCS, such impacts are likely minimized given that the burning activities occur in accordance with the FDACS permit, and that work in or around active American crocodile nests sites is prohibited from March to August. These and other potential impacts on the American crocodile are addressed in Section 4.8.1.1, “Federally Listed Species and Critical Habitats Protected Under the Endangered Species Act,” of this SEIS, and in the NRC staff’s Biological Assessment (NRC 2018n). Wildlife and birds would likely be displaced during such activities. However, displacement would be limited to the short duration of the activity and similar habitat would be accessible both on and within the vicinity of the site. In addition, the removal of the exotic species promotes the growth of native and rare species.

Environmental impacts from landscape maintenance and operational activities would also be minimized because FPL maintains environmental control procedures for any activities that result in the clearing of land, excavation, or other activity that would alter the physical environment or ecology of the site (FPL 2018f and FPL 2018g). FPL’s procedures direct personnel to obtain appropriate local, State, or Federal permits (or some combination of the three) before beginning work; implement best management practices to protect wetlands, natural heritage areas, and sensitive ecosystems (see the paragraph below, “Stormwater Management”); and consult the appropriate agencies wherever federally or State-listed species may be affected. Turkey Point’s Environmental Protection Plan contained in Appendix B of the current renewed operating licenses requires FPL to prepare an environmental evaluation for any construction or operational activities which may significantly affect the environment (NRC 2002a). If such an evaluation indicates that an activity involves an unreviewed environmental question, the Turkey Point Environmental Protection Plan requires that FPL obtain approval from the NRC before performing the activity (NRC 2002d). The subsequent renewed licenses, if issued, would include an environmental protection plan with identical or similar requirements.

Stormwater Management

Stormwater runoff from impervious surfaces can change the frequency or duration of inundation and soil infiltration within wetlands, mangroves, and neighboring terrestrial habitats. Effects of stormwater runoff may include erosion, altered hydrology, sedimentation, and other changes to plant community characteristics. Runoff may contain sediments, contaminants and oils from road or parking surfaces, or herbicides. At Turkey Point, stormwater collected in drainage channels and floor drains is discharged directly to the CCS. Turkey Point does not discharge stormwater directly into Biscayne Bay or any other surface waters other than the CCS. Use of the stormwater conveyance system, which collects stormwater, minimizes the amount of excess runoff that terrestrial habitats would receive and the associated effects. FDEP regulations require a stormwater permit and Stormwater Pollution Prevention Plan for any construction activities or activities that would result in the clearing of land, excavation, or other action that would alter the physical environment or ecology of the site. FPL's Stormwater Pollution Prevention Plan identifies potential sources of pollutants that could affect stormwater discharges and identifies best management practices that FPL uses to reduce pollutants in stormwater discharges to ensure compliance with applicable conditions of the permit (FPL 2018g). The best management practices include soil stabilization, such as seeding and structural controls (e.g., silt fences). FPL has also developed a Spill Prevention, Control, and Countermeasures Plan that identifies and describes the procedures, materials, equipment, and facilities that are utilized to minimize the frequency and severity of oil spills (FPL 2018f). Collectively, these measures ensure that the effects to terrestrial resources from pollutants carried by stormwater would be minimized during the proposed subsequent license renewal term.

Noise

The GEIS (NUREG-1437) (NRC 2013a) states that elevated noise levels from transformers and other equipment could disrupt wildlife behavioral patterns or cause animals to avoid such areas. However, limited wildlife occurs in areas of the Turkey Point site with elevated noise levels due to the developed nature of those portions of the site, associated lack of high-quality habitat, and regular presence of human activity. Wildlife that does occur in developed areas is likely tolerant of disturbance due to decades of operations. Therefore, noise associated with the continued operation of transformers and other plant equipment during the proposed subsequent license renewal term is unlikely to create noticeable impacts on terrestrial resources.

Conclusion

Based on the NRC staff's independent review, the staff concludes that the landscape maintenance activities, stormwater management, elevated noise levels, and other ongoing operations and maintenance activities that FPL might undertake during the subsequent license renewal term would primarily be confined to already-disturbed areas of the Turkey Point site. Within less-developed portions of the site, disturbances to wildlife would be minimal, and wildlife could use similar habitat nearby during the limited periods of the disturbance. Therefore, these activities would neither have noticeable effects on terrestrial resources nor would they destabilize any important attribute of the terrestrial resources on or in the vicinity of the Turkey Point site. Accordingly, the NRC staff concludes that non-cooling system impacts on terrestrial resources during the subsequent license renewal term would be SMALL.

4.6.2 No-Action Alternative

Under the no-action alternative, the NRC would not issue subsequent renewed licenses, and Turkey Point would shut down on or before the expiration of the current renewed licenses. Some impacts on terrestrial resources would cease following reactor shutdown while other impacts may continue to exist at a reduced level. For example, noise impacts and impacts associated with herbicide application and landscape maintenance could continue for some time following reactor shutdown depending on the level at which FPL continues to maintain landscaped areas. Other impacts on terrestrial resources would be the same as if the plant were still operating, such as the potential for bird collisions with plant structures and transmission lines.

The CCS would continue to operate under the no-action alternative regardless of the proposed Turkey Point subsequent license renewal because it supports retired fossil fuel Units 1 and 2. FPL plans to continue to use water from the CCS to support the operation of these units in synchronous condenser mode over the course of the proposed subsequent license renewal period, as described in Section 3.1.3, “Cooling and Auxiliary Water Systems.” Additionally, fossil fuel Unit 5 would remain in operation and would continue to discharge blowdown to the CCS. CCS conditions could change under the no-action alternative because less heat would be discharged to the system. This would potentially reduce evaporation resulting in less saline conditions that would be more favorable for birds and wildlife. On the other hand, CCS flow would likely decrease because Turkey Point Units 3 and 4 would withdraw substantially reduced quantities of water during the shutdown period, and eventually Turkey Point Units 3 and 4 would cease to circulate water through the CCS entirely. This could lead to stagnant conditions, which could be less favorable for birds and wildlife and promote algae growth. Regardless, FPL would continue CCS restoration activities, as previously described in Section 4.5.2.2 of this SEIS. The State of Florida requires these activities under FPL’s Nutrient Management Plan, which is independent of subsequent license renewal. The CCS would likely continue to provide wildlife habitat for foraging and breeding, and restoration activities would benefit wildlife that rely upon the CCS as a source of prey. Thus, shutdown itself is unlikely to noticeably alter or have more than minor effects on terrestrial resources.

The NRC staff concludes that the impacts of the no-action alternative on terrestrial resources during the proposed subsequent license renewal term would be SMALL.

4.6.3 Replacement Power Alternatives: Common Impacts

Each replacement power alternative would entail construction and operation of a new energy generating facility on FPL’s existing Turkey Point site or the surrounding area and would result in qualitatively similar impacts to terrestrial resources. During construction of a replacement power facility, the use of the Turkey Point site would allow FPL to maximize existing buildings and infrastructure. However, due to the prevalence of important terrestrial habitats onsite—such as freshwater wetlands, mangroves, and wooded habitats—it is unlikely that FPL would be able to avoid impacting sensitive and important terrestrial habitats. Impacts from construction could result in both the permanent and temporary loss of important terrestrial habitats, habitat fragmentation, and habitat degradation from runoff, erosion, and sedimentation, depending on the specific areas used for construction. Wildlife and birds would likely avoid the area during the construction of a replacement power facility due to noise and other disturbances. Limiting construction in areas near known bird nests, rookeries, or colonies (e.g., CCS berms on which least terns are known to nest) to the non-breeding season would limit behavioral avoidance and other potential impacts to locally breeding bird populations. Collisions with tall structures and

vehicles could also result in wildlife and bird mortality. Implementation of appropriate best management practices, revegetation following construction, and required compensatory mitigation for unavoidable wetland impacts would minimize such impacts.

In the GEIS (NUREG-1437) (NRC 2013a), the NRC staff concluded that for all nuclear power plants, impacts to terrestrial resources from operation of nuclear and fossil-fueled plants would be similar and would include cooling tower salt drift, noise, bird collisions with plant structures and transmission lines, as well as impacts connected with herbicide application and landscape management. Additional impacts to terrestrial resources during the operational period could occur as a result of offsite mining, extraction, or waste disposal activities associated with each plant's particular type of fuel.

As described above under the no-action alternative, the CCS would continue to operate regardless of the proposed Turkey Point license renewal because it supports retired fossil fuel Units 1 and 2. FPL plans to continue to withdraw water from the CCS to support these units' operation in synchronous condenser mode over the course of the proposed subsequent license renewal period, as described in Section 3.1.3, "Cooling and Auxiliary Water Systems." Additionally, Unit 5, which remains in operation, discharges blowdown to the CCS. CCS conditions could change with implementation of one of the replacement power alternatives because less heat would be discharged to the system. This would potentially reduce evaporation resulting in less saline conditions that would be more favorable for birds and wildlife. On the other hand, CCS flow would likely decrease because Turkey Point Units 3 and 4 would withdraw substantially reduced quantities of water during the shutdown period, and eventually all withdrawals associated with these units would cease. Less flow could lead to stagnant conditions, which could be less favorable for birds and wildlife and enhance algae growth. Regardless, FPL would continue CCS restoration activities, as previously described in Section 4.5.3.2. The State of Florida requires these activities under FPL's Nutrient Management Plan, which is independent of subsequent license renewal. The CCS would likely continue to provide wildlife habitat for foraging and breeding, and restoration activities would benefit wildlife that rely upon the CCS as a source of prey.

4.6.4 New Nuclear Alternative

The NRC staff did not identify any impacts on terrestrial resources for the new nuclear alternative beyond those discussed in the impacts common to all replacement power alternatives. However, the common impact onsite could be slightly more intense for the new nuclear alternative as compared to the natural gas alternative. This can be attributed to the larger land area required for the new nuclear power block, which could result in increased erosion and potential introduction of sediments to wetland habitats. In addition, given the prevalence of wetlands within the Turkey Point site, it is unlikely that FPL would be able to avoid permanently filling or disturbing wetlands when siting the new nuclear alternative. Given that the construction of the new nuclear alternative would result in the permanent disturbance, fragmentation, and degradation of up to 360 ac (150 ha) of important terrestrial habitats, the NRC staff concludes that the impacts to terrestrial resources from construction and operation of a new nuclear alternative would be MODERATE.

4.6.5 Natural Gas Combined-Cycle Alternative

The onsite impacts on terrestrial resources would be less intense for construction of a natural gas plant as compared to a new nuclear plant because the natural gas plant would disturb less land. However, the natural gas alternative would also require construction of a 1,200-ac

(490-ha) long right-of-way for a gas pipeline, which could result in the loss, modification, and fragmentation of important terrestrial habitats. Collocation of the right-of-way with other existing rights-of-way would minimize the amount of habitat disturbance. The natural gas alternative would also emit pollutants that could degrade wetland and other important habitats. As described above, the CCS would continue to operate regardless of whether a replacement power alternative is implemented, and the impacts discussed previously that would be associated with continued operation of the CCS would apply to this alternative. The NRC staff concludes that the impacts of constructing and operating the natural gas alternative on terrestrial resources would be MODERATE due to the permanent disturbance, fragmentation, and degradation of important terrestrial habitats.

4.6.6 Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)

The NRC staff did not identify any impacts to terrestrial resources for the natural gas portion of the combination alternative beyond those described for the natural gas-only alternative. For the solar portion of the combination alternative, the exact level of disturbance to terrestrial habitats and biota would depend on the amount of land required for each unit and the specific siting of buildings and infrastructure within the site footprint. Due to the prevalence of important terrestrial habitats within the areas where the solar units would be sited, it is likely that construction would result in the temporary and permanent disturbance, fragmentation, and degradation of important terrestrial habitats. Utility-scale solar facilities may also pose hazards to birds and their insect prey if individual birds or insects mistake a facility's reflective panel arrays for water. Birds and insects may be injured or killed from collision with solar panels if they try to land on or enter what they interpret to be water in what has been termed by researchers as the "lake effect hypothesis" (Kagan et al. 2014). The U.S. Fish and Wildlife Service (FWS) is currently developing mitigation strategies and best management practices related to birds and solar facilities (MASCWG 2016). Discussions with the FWS and other relevant agencies during the planning phases of the solar portion of the combination alternative could minimize impacts to birds and other wildlife by incorporating mitigation and best management practices into the design of the facility and construction plans. As described above, the CCS would continue to operate regardless of whether a replacement power alternative is implemented, and the impacts discussed previously that would be associated with continued operation of the CCS would apply to this alternative. The NRC staff concludes that the impacts of implementing the combination alternative on terrestrial resources would be MODERATE during construction and operation due to the impact on important terrestrial habitat.

4.6.7 Cooling Water System Alternative

The NRC staff did not identify any impacts on terrestrial resources for the cooling water system alternative beyond those discussed in the impacts common to all replacement power alternatives. In addition, the common impacts would be less intense for the cooling water system alternative due to the smaller land area required for construction and operation. Nonetheless, construction would likely result in the temporary or permanent disturbance, fragmentation, and degradation of important terrestrial habitats. As described above, the CCS would continue to operate regardless of whether cooling towers are constructed to support Turkey Point Units 3 and 4, and the impacts discussed previously that would be associated with continued operation of the CCS would apply to this alternative. The NRC staff concludes that the impacts to terrestrial resources from construction and operation of a cooling water system

alternative would be MODERATE due to the noticeable impacts from the permanent disturbance, fragmentation, and degradation of important terrestrial habitats.

4.7 Aquatic Resources

This section describes the potential aquatic resources impacts of the proposed action (subsequent license renewal) and alternatives to the proposed action.

4.7.1 Proposed Action

As identified in Table 4-1, “Applicable Category 1 (Generic) Issues for Turkey Point,” in Section 4.1 of this chapter, the impacts of all generic aquatic resource issues would be SMALL. The NRC staff analyzed Category 1 issues in the GEIS (NRC 2013a) and determined that the impacts of continued nuclear power plant operation during a license renewal term would have SMALL effects for these issues. The NRC staff has identified no new or significant information for aquatic resource Category 1 issues that would call into question the GEIS’s conclusions for subsequent license renewal of Turkey Point Units 3 and 4. Accordingly, and as concluded in the GEIS, the impacts of the Category 1 aquatic resource issues identified in Table 4-1 would be SMALL for the proposed Turkey Point subsequent license renewal. Table 4-2, “Applicable Category 2 (Site-Specific) Issues for the Turkey Point Site,” in Section 4.1 of this SEIS identifies two aquatic resources site-specific (Category 2) issues applicable to Turkey Point during the subsequent license renewal term. These issues are analyzed below.

4.7.1.1 Impingement and Entrainment of Aquatic Organisms (Plants with Once-Through Cooling Systems or Cooling Ponds)

For plants with once-through cooling systems or cooling ponds such as Turkey Point, the NRC (2013a) has determined that impingement and entrainment of aquatic organisms is a Category 2 issue that requires site-specific evaluation. In 2002, the NRC staff evaluated the impacts of the Turkey Point initial license renewal on aquatic organisms as two issues: “impingement of fish and shellfish” and “entrainment of fish and shellfish in early life stages.” For both issues, the NRC staff determined that impacts would be SMALL. In 2013, the NRC issued Revision 1 of the GEIS (NUREG-1437) (NRC 2013a), which combined these two issues into a single site-specific issue—“Impingement and entrainment of aquatic organisms (plants with once-through cooling systems or cooling ponds).” This section evaluates this consolidated issue as it applies to the proposed Turkey Point subsequent license renewal period.

Impingement is the entrapment of all life stages of fish and shellfish on the outer part of an intake structure or against a screening device during periods of water withdrawal (40 CFR 125.83, “What Special Definitions Apply to This Subpart?”). Impingement can kill organisms immediately or contribute to later mortality resulting from exhaustion, suffocation, injury, and other physical stresses. The potential for injury or death is generally related to the amount of time an organism is impinged, its susceptibility to injury, and the physical characteristics of the screen-washing system and fish return (if present) of the plant.

Entrainment is the incorporation of all life stages of fish and shellfish with intake water flow entering and passing through a cooling water intake structure and into a cooling water system (40 CFR 125.83). Organisms susceptible to entrainment are generally of smaller size than those susceptible to impingement and include ichthyoplankton (fish eggs and larvae), larval stages of shellfish and other macroinvertebrates, zooplankton, and phytoplankton. Entrained

organisms may experience physical trauma and stress, pressure changes, excess heat, and exposure to chemicals, any of which may result in injury or death (Mayhew et al. 2000).

A particular species can be subject to both impingement and entrainment if several life stages occur near a plant's intake. For instance, adults may be impinged against the screens, while larvae and eggs may be entrained. Depending on the size of the intake screen openings, juveniles can be susceptible to both impingement and entrainment: larger juveniles may be impinged, while smaller juveniles may be entrained. The magnitude of impacts on the aquatic environment resulting from impingement and entrainment depends on plant-specific characteristics of the cooling system (e.g., location of the plant intake, intake velocities, withdrawal volumes, screen technologies, and presence or absence of a fish return system) as well as characteristics of the aquatic resources (e.g., species present in the region, population distributions, species status, management objectives, and life history characteristics).

Below, the NRC staff analyzes impingement and entrainment during the proposed Turkey Point subsequent license renewal term in two parts. First, the staff considers impacts that would be experienced by the aquatic biota in the CCS, and second, the staff considers biota in adjacent natural aquatic environments, including Biscayne Bay and Card Sound.

Aquatic Organisms of the CCS

Aquatic organisms inhabiting the CCS may be impinged or entrained when water is drawn from the CCS into the Turkey Point intake structure. Water from the CCS flows from the canal system into eight intake channels and through 9.5-mm (0.37-inch) mesh intake screens at a rate of 4.48 feet per second (fps) (1.4 meters per second (m/s)). The maximum flow per intake channel is 225,375 gpm (14.2 m³/s). Debris, including fish and other aquatic organisms, that become impinged on the screens are washed off and disposed of by FPL personnel. The Turkey Point intake structure does not contain a fish return system (FPL 2018g).

FPL has not conducted any impingement or entrainment studies within the CCS. The Federal Water Pollution Control Act (i.e., the Clean Water Act of 1972, as amended (CWA)) (33 U.S.C. 1251 et seq.) does not impose ecological study requirements because the State classifies the CCS as an industrial wastewater facility and because the CCS does not directly withdraw from or discharge into any natural surface waters. Due to the lack of impingement and entrainment data, the NRC staff evaluates the effects of this potential effect on CCS aquatic organisms qualitatively in this section. First, the NRC staff considers the baseline condition of the resource (i.e., the species that would be present and susceptible to impingement and entrainment during the proposed subsequent license renewal). The staff then considers whether the life history characteristics of these species combined with the engineering parameters of the Turkey Point intake structure would make impingement or entrainment likely. The staff then makes an overall conclusion for impingement and entrainment on aquatic organisms of the CCS.

Baseline Condition of the Resource

Section 3.7.3, "Aquatic Resources on the Turkey Point Site," of this SEIS describes the aquatic resources on the Turkey Point site and summarizes the results of past ecological surveys of the CCS. In this section, the NRC staff discusses the facts that several fish species reported from the CCS in 2007 and 2009 ecological surveys were not collected in the most recent 2016 ecological survey, submerged aquatic vegetation is no longer present in the system, and species diversity has generally declined over time. The surface water quality factors that have contributed to this ecological shift are described in Section 3.5.1, "Surface Water Resources."

No direct surface water connections between the CCS and any natural waterbodies exist that would allow additional species to enter the CCS during the proposed subsequent license renewal term. Thus, the NRC staff assumes that the baseline condition of the resource is the aquatic community as it occurs in the CCS today. The current community is of low diversity and includes only those species that can withstand hot, hypersaline waters with low dissolved oxygen and poor water clarity. In 2016, Ecological Associates, Inc. (EAI 2017) collected only the following four species from the CCS:

- sheepshead minnow (*Cyprinodon variegatus*)
- sailfin molly (*Poecilia latipinna*)
- eastern mosquitofish (*Gambusia holbrooki*)
- mudflat fiddler crabs (*Uca rapax*)

Although other species may continue to occur in the CCS in small numbers that were not captured during the 2016 study, the NRC staff considers the species listed above to be representative of the current CCS aquatic community. For the purposes of this analysis, the staff assumes that these species are also representative of the aquatic community that would be present in the CCS and susceptible to impingement and entrainment during the proposed subsequent license renewal term of 2032 through 2052 (Unit 3) and 2033 through 2053 (Unit 4). Below, the staff considers the vulnerability of these species to impingement or entrainment to determine the overall impact of impingement and entrainment on CCS aquatic organisms.

Impingement

To assess the risk of impingement on CCS organisms, the NRC staff compared documented swim speeds of representative CCS species to the water velocity at the Turkey Point intake structure. In scientific literature, fish swimming speeds are characterized as burst, prolonged, or sustained. Burst speeds are the highest speeds a fish can attain over very short periods of time (typically less than 20 seconds). Burst speeds are exhibited when an individual is capturing prey, avoiding a predator, or negotiating high water velocities, such as those associated with riffles and eddies in a fast-flowing river or the draw of a power plant's intake. Sustained speeds are low speeds fish can maintain indefinitely without fatigue. These speeds are observed during routine activities, including foraging, holding, and schooling. Prolonged (or critical) speeds are those of intermediate endurance that a fish could endure for approximately 20 to 30 minutes before ending in fatigue. If a species' reported swimming ability indicates that individuals can typically swim faster than a power plant's intake velocity, the species would exhibit a low likelihood of being impinged. Certain species may not be capable of maintaining a sustained speed that would allow escape from an intake velocity, but an individual could swim in a burst to avoid impingement. Swim speeds are typically measured in centimeters per second (cm/s). Thus, the NRC staff assumes that species with a documented burst speed less than 140 cm/s (1.4 m/s; 4.48 fps), which is the velocity of the Turkey Point intake, would be susceptible to impingement, and a species with a documented burst speed equal to or greater than this velocity would generally not be susceptible to impingement.

Sheepshead minnow belong to the family Cyprinodontidae. In laboratory tests, Leavy and Bonner (Leavy and Bonner 2009) determined the burst swimming speed of two species in this family of fish, plains killifish (*Fundulus zebrinus*) and blackstripe topminnow (*F. notatus*), to be 30.7 to 43.4 cm/s (0.307 to 0.434 m/s; 1.01 to 1.42 fps). Species-specific data is not available

for sheepshead minnow. Therefore, for comparison, the NRC staff assumes that this range is comparable to the burst swim speed of sheepshead minnow. Based on this assumption, sheepshead minnow are susceptible to impingement at Turkey Point and any individuals within the area influenced by the Turkey Point intake velocity are likely to become impinged.

Sailfin molly and eastern mosquitofish both belong to the family Poeciliidae. In laboratory tests, Leavy and Bonner (Leavy and Bonner 2009) determined the burst swimming speed of two Poeciliidae species—sailfin molly and largespring gambusia (*Gambusia geiseri*)—to be 15.7 to 18.6 cm/s (0.157 to 0.186 m/s; 0.52 to 0.61 fps). In another test, Srean et al. (Srean et al. 2016) determined the critical swim speed of adult eastern mosquitofish to be 14.11 cm/s (0.1411 m/s; 0.46 fps). Based on this information, both sailfin molly and eastern mosquitofish are susceptible to impingement at Turkey Point.

Juvenile and adult mudflat fiddler crabs inhabit the intertidal zones of muddy areas of salt marshes and mangroves. Therefore, they would not generally occur in the open water of the CCS where they would be susceptible to impingement. Thus, mudflat fiddler crabs are likely not impinged or only rarely impinged by the Turkey Point intake structure.

Based on the available biometric information presented above, the NRC staff assumes that all fish in the CCS are susceptible to impingement. Because the Turkey Point intake structure does not have a fish return system, and FPL has no plans to alter the design or function of the Turkey Point cooling system under the proposed action, all impingement would result in mortality. However, most fish in the CCS are not at risk of impingement due to the layout of the system and the large size of the CCS relative to the small area influenced by the Turkey Point intake structure's withdrawal of water. Only those individuals in the CCS intake canal, specifically, would be at risk of impingement and only those individuals within the smaller area influenced by the intake velocity are likely to be impinged. Many fish in the CCS likely spend their lives in the main canals and are never exposed to impingement risk. In contrast, for a power plant whose intake draws from a river, migration or movement of fish past the plant would likely necessitate passage through the zone of the power plant intake's influence. For the reasons discussed above, the NRC staff concludes that while impingement at Turkey Point is likely to affect CCS aquatic populations, only a small portion of aquatic organisms would be susceptible to impingement at any given time.

Entrainment

A species' susceptibility to entrainment is closely related to the life history characteristics of early life stages. Species that lay adhesive eggs that sink to the bottom of the water column are less likely to be entrained than species that lay demersal eggs that float within the water column. Sheepshead minnow eggs are adhesive; these eggs stick to plants and bottom substrate and are, therefore unlikely to be entrained. Sailfin molly and eastern mosquitofish give birth to live young rather than laying a clutch of eggs. Newly born young of these species are, therefore, at risk of entrainment if young occur in the CCS intake canal and within the area influenced by the Turkey Point intake structure. Female mudflat fiddler crabs release eggs into the water column where they hatch into microscopic free-swimming larvae that then go through several molt stages. During this process, zoea would be susceptible to entrainment if they occur in water drawn into the Turkey Point intake structure. As with impingement, the NRC staff assumes that even for those species and life stages for which entrainment is possible, only a small portion of susceptible individuals occur in the CCS intake canal and, thus, entrainment risk is relatively low.

Impingement and Entrainment Conclusion for Cooling Canal System Aquatic Organisms

All fish inhabiting the CCS are likely susceptible to impingement, and early life stages of some species are also susceptible to entrainment. The large size of the CCS relative to the small area influenced by intake velocity of the Turkey Point intake structure mitigates the overall risk of impingement and entrainment. In the absence of specific studies, the extent to which impingement or entrainment may result in detectable or noticeable effects on the aquatic populations of the CCS is unknown. However, impingement and entrainment are unlikely to create effects great enough to destabilize important attributes of the aquatic environment over the course of the proposed subsequent license renewal term because the CCS aquatic community is composed of common species that exhibit no unique ecological value or niche and have no commercial or recreational value. The NRC staff, therefore, finds that impingement and entrainment during the proposed subsequent license renewal term would be of SMALL to MODERATE significance on the aquatic organisms of the CCS.

Aquatic Organisms of Biscayne Bay

Aquatic organisms inhabiting Biscayne Bay are not subject to impingement or entrainment because there are no surface water connections that allow flow between the waters of the Biscayne Bay and the CCS. Thus, aquatic organisms in Biscayne Bay and connected waterbodies (e.g., Card Sound, the Atlantic Ocean) never interact with the Turkey Point intake structure. Accordingly, the NRC staff concludes that the issue of impingement and entrainment during the proposed subsequent license renewal term does not apply to aquatic organisms in Biscayne Bay.

4.7.1.2 Thermal Impacts on Aquatic Organisms (Plants with Once-Through Cooling Systems or Cooling Ponds)

For plants with once-through cooling systems or cooling ponds such as Turkey Point, the NRC staff (NRC 2013a) has determined that thermal impacts on aquatic organisms is a Category 2 issue that requires site-specific evaluation. In 2002, the NRC staff evaluated the impacts of the Turkey Point initial license renewal on aquatic organisms as “heat shock,” and the NRC determined that impacts would be SMALL. In 2013, the NRC issued Revision 1 of the GEIS (NUREG-1437) (NRC 2013a), which renamed this issue as “Thermal impacts on aquatic organisms (plants with once-through cooling systems or cooling ponds).” This section evaluates this issue for the proposed Turkey Point subsequent license renewal period.

The primary form of thermal impacts that would be of concern at Turkey Point is heat shock, which the NRC staff (NRC 2013a) defines as occurring when the water temperature meets or exceeds the thermal tolerance of a species for some duration of exposure. In most situations, fish are capable of moving out of an area that exceeds their thermal tolerance limits, although some aquatic species lack such mobility. Heat shock is typically observable only for fish, particularly those species that float when dead.

Aquatic Organisms of the CCS

Heated water discharged from Turkey Point moves from the discharge canal on the north end of the CCS, through 32 feeder canals, and south into a single collector canal that distributes water to 7 return canals. Water in the return canals flows north to the Turkey Point intakes. Excess heat is naturally dissipated through evaporation and groundwater exchange as water flows through the system. Thus, fish and other aquatic organisms experience the highest

temperatures at the north end of the CCS within the discharge canal with gradually decreasing temperatures as water flows south through the system.

FPL has not conducted any thermal impact studies within the CCS. The Clean Water Act does not impose ecological study requirements on the CCS because the State of Florida classifies the CCS as an industrial wastewater facility and also because the CCS does not directly withdraw from or discharge into any natural surface waters. In the absence of thermal studies, the NRC staff evaluates the potential effects of thermal discharges on CCS aquatic organisms by comparing CCS discharge temperature data with the thermal tolerances of the species present in the CCS.

Baseline Condition of the Resource

As explained in the NRC staff's impingement and entrainment analysis in Section 4.7.1.1 of this SEIS, the staff assumes that the baseline condition of the resource for the proposed action is the aquatic community as it occurs in the CCS today. The current community is of low diversity and includes only those species that can withstand hot, hypersaline waters with low dissolved oxygen and poor water clarity. Only four species—sheepshead minnow, sailfin molly, eastern mosquitofish, and mudflat fiddler crab—were collected during the last ecological survey of the CCS in 2016 (EAI 2017). For the purposes of this analysis, the staff assumes that these species are also representative of the aquatic community that would be present in the CCS and susceptible to thermal stress during the proposed subsequent license renewal term.

Prior to the 2016 survey, a number of fish, mollusks, crabs, and submerged aquatic vegetation were observed or recorded as occurring in the CCS (described in Section 3.7.3, "Aquatic Resources on the Turkey Point Site," of this SEIS). These species have either been eliminated from the CCS or persist in such low numbers that they were not collected during the 2016 survey. Submerged aquatic vegetation was determined to be completely absent from the system at the time of the 2016 survey, and EAI (EAI 2017) stated in its report that temperature-related stress was one of the factors that contributed to the die-off of the CCS's seagrass beds. The NRC staff acknowledges EAI's conclusion regarding seagrass and recognizes that thermal discharges associated with Turkey Point have contributed not only to the disappearance of seagrass within the CCS, but also to the decline of fish and other aquatic biota and the observed shift towards more heat-tolerant species in recent years. The staff addresses these impacts in the cumulative impact analysis in Section 4.16.4, "Aquatic Resources," because they are past impacts associated with the current renewed license term. The analysis below focuses on future impacts that would be associated with the proposed subsequent license renewal term of 2032 through 2052 (Unit 3) and 2033 through 2053 (Unit 4).

Cooling Canal System Discharge Temperature Data

For each calendar month, FPL reports the highest average daily temperature of the cooling water discharge at Outfall 001 to the FDEP as a requirement of the Turkey Point industrial wastewater facility NPDES Permit No. FL0001562 (FDEP 2005). Table 4-3 below presents these daily maximum temperatures for the past 5 full calendar years (2012–2017). As is typical for the region, the highest temperatures occur in July, and the lowest temperatures occur in January. However, CCS discharge temperatures remain relatively high year-round and are often above the thermal tolerances of many fish (often around 95 °F (35 °C)). FPL (2018g) reports that water temperatures drop approximately 13.7 °F (7.6 °C) over the course of flow from the discharge point to the south end of the CCS. Thus, the minimum temperature likely ranged from roughly 69.9 to 97.9 °F (21.1 to 36.6 °C) with some thermal stratification occurring

such that deeper areas of the canal system would have experienced slightly lower temperatures than those measured at the surface.

Table 4-3 Average Maximum Daily Temperature at CCS Outfall 001

Month	Temperature (°F) ^(a)					
	2012	2013	2014	2015	2016	2017
January	97.3	90.6	89.9	89.1	95.7	91.0
February	94.7	68.8	106.5	100.3	94.1	98.6
March	94.7	83.6	101.1	105.0	103.2	95.4
April	91.2	93.6	106.7	109.0	90.1	94.8
May	97.1	97.6	103.2	102.7	104.6	103.4
June	90.0	109.2	107.9	112.2	109.7	104.6
July	100.2	111.6	108.2	107.2	111.5	108.3
August	89.8	106.6	106.6	110.4	110.4	110.0
September	97.6	108.4	100.2	105.2	110.4	101.9
October	97.5	101.5	99.0	94.0	94.8	101.9
November	95.0	94.2	89.0	102.6	96.3	96.8
December	93.1	94.8	103.2	94.7	100.4	97.5

^(a) To convert temperatures in degrees Fahrenheit to Celsius, subtract 32 and multiply by 5/9.

Source: FPL 2018g

Thermal Tolerances of Aquatic Species

Sheepshead minnow are part of the family Cyprinodontidae, which are known for their ability to survive extreme seasonal and diurnal shifts in water temperature. Sheepshead minnow, specifically, can be found in the harsh environments of subtropical south Texas's shallow tide pools at temperatures as high as 109.4 °F (43 °C) and when the combination of other abiotic conditions become so extreme that no other species can persist (Strawn and Dunn 1967; Harrington and Harrington 1961). In static and dynamic thermal tolerance tests of 800 sheepshead minnow collected from a shallow tidepool of the Brazos Santiago Pass in Texas, Bennet and Beitinger (Bennett and Beitinger 1997) found that the species has the largest physiological thermal tolerance range ever measured in a fish. In the tests, individuals acclimated to 69.8 °F (21.0 °C) and 100.4 °F (38.0 °C) were able to tolerate temperatures up to 104.18 °F (40.1 °C) and 111.56 °F (44.2 °C), respectively. Bennet and Beitinger (Bennett and Beitinger 1997) determined the species' critical thermal maxima—the temperature at which activity becomes disorganized and an organism loses its ability to escape conditions which will promptly lead to death—to be 113 °F (45.1 °C).

Both the sailfin molly and eastern mosquitofish are also rather heat-tolerant species. In critical thermal maxima tests, these species have been found capable of withstanding temperatures up to or slightly higher than 104 °F (40 °C) (Fischer and Schlupp 2009; Meffe et al. 1995). Mudflat fiddler crabs have been documented as tolerating waters of temperatures up to 111.4 °F (44 °C) (Smithsonian 2009). The mobility of this species also allows individuals to leave waters that are too hot and seek refuge elsewhere.

Thermal Impacts Discussion

The aquatic community of the CCS is composed of species that can survive in extreme temperatures. CCS temperature data indicate that water in the system remains below the thermal tolerances of the aquatic species present during the majority of the year. During the summer months, waters at and near the cooling water discharge at CCS Outfall 001 may approach or exceed the thermal tolerances of aquatic species. However, the CCS is a large system, and the area over which water temperatures would be uninhabitable would be relatively small. Thus, fish and other mobile aquatic organisms could seek refuge in cooler areas. Additionally, the State has required FPL to implement a thermal efficiency plan (described in detail in Section 3.5.1) as a condition of the 2016 Consent Order to control CCS salinity and temperature (FDEP 2016a). FPL has begun implementing this plan, and FPL's continued execution of the plan will ensure that CCS temperatures are moderated over the course of the proposed subsequent license renewal term. The combination of these factors (i.e., the heat-tolerant aquatic community present in the CCS, the small area of the CCS over which water temperatures typically exceed species' critical thermal maxima, and the State-mandated requirements for FPL to control CCS temperatures and salinity) make the likelihood of mortality of aquatic organisms from Turkey Point's thermal effluent during the subsequent license renewal term relatively low. Nevertheless, the high-temperature environment of the CCS is likely to exert physiological stress on aquatic organisms that could have fitness consequences, including reproductive effects, increased susceptibility to disease or infection, and reduced ability to escape predators. While these effects may be noticeable, they are unlikely to destabilize important attributes of the aquatic environment over the course of the proposed subsequent license renewal term.

Thermal Impact Conclusion for CCS Aquatic Organisms

The aquatic community that currently inhabits the CCS can withstand high temperatures and continued thermal discharges from Turkey Point over the course of the proposed subsequent license renewal period are unlikely to further alter the composition of the community. Thermal impacts may result in some degree of physiological stress on CCS aquatic organisms. In the absence of specific studies, the extent to which such stresses may result in detectable or noticeable effects is unknown. However, thermal impacts are unlikely to create effects great enough to destabilize important attributes of the aquatic environment over the course of the proposed subsequent license renewal term because the CCS aquatic community is composed of species that exhibit no unique ecological value or niche and have no commercial or recreational value. The NRC staff, therefore, finds that thermal impacts during the proposed subsequent license renewal term would be of SMALL to MODERATE significance on the aquatic organisms of the CCS.

Aquatic Organisms of Biscayne Bay

Aquatic organisms inhabiting Biscayne Bay are not subject to thermal impacts associated with Turkey Point because there are no surface water connections that allow flow between these waters and the CCS. Thus, aquatic organisms in this water body and connected waterbodies (e.g., Card Sound, the Atlantic Ocean, etc.) do not interact with Turkey Point's thermal discharge. Accordingly, the NRC staff concludes that the issue of thermal impacts during the proposed subsequent license renewal term does not apply to aquatic organisms in Biscayne Bay.

4.7.2 No-Action Alternative

Under the no-action alternative, the NRC would not issue subsequent renewed licenses, and Turkey Point Units 3 and 4 would shut down on or before the expiration of the current renewed licenses. The CCS would continue to operate to support retired fossil fuel Units 1 and 2 in synchronous condenser mode. If Turkey Point Units 3 and 4 were to cease operating, impacts to CCS aquatic resources would decrease or stop following reactor shutdown. The amount of CCS water withdrawn for cooling purposes would decrease significantly following shutdown, although some withdrawal would continue during the shutdown period as the remaining fuel cools. The reduced demand for cooling water would substantially decrease the effects of impingement, entrainment, thermal effluents, and other impacts to aquatic biota in the CCS. Withdrawals would eventually cease, which would eliminate these impacts.

The CCS would continue to operate under the no-action alternative regardless of the proposed Turkey Point subsequent license renewal because it supports retired fossil fuel Units 1 and 2. FPL plans to continue to use water from the CCS to support the operation of these units in synchronous condenser mode over the course of the proposed subsequent license renewal period, as described in Section 3.1.3, "Cooling and Auxiliary Water Systems." Additionally, fossil fuel Unit 5 would remain in operation and would continue to discharge blowdown to the CCS. CCS conditions could change under the no-action alternative because less heat would be discharged to the system. This would potentially reduce evaporation resulting in less saline conditions that would be more favorable to aquatic life. On the other hand, CCS flow would likely decrease because Turkey Point Units 3 and 4 would withdraw substantially reduced quantities of water during the shutdown period, and eventually Turkey Point Units 3 and 4 would cease to circulate water through the CCS entirely. This could lead to stagnant conditions and lower habitat quality. Stagnant conditions could potentially promote algae growth. Regardless, the CCS would continue to provide habitat for the existing aquatic community. Additionally, FPL would continue CCS restoration activities, as previously described in Section 3.5.1.4, "Adjacent Surface Water Quality and Cooling Canal System Operation," and Section 3.7, "Aquatic Resources," of this SEIS. The State of Florida requires these activities under FPL's Nutrient Management Plan, which is independent of subsequent license renewal. Restoration activities would likely eventually return portions of the CCS to a seagrass-based ecological system. These restoration activities would benefit fish and shellfish inhabiting the CCS as well as other wildlife that rely upon the CCS as a source of prey.

The no-action alternative would not affect aquatic resources in Biscayne Bay, Card Sound, or the Atlantic Ocean because there are no surface water connections that allow flow between these waters and the waters of the CCS; therefore, aquatic organisms in these waterbodies do not interact with the Turkey Point intake structure and are not subject to impingement, entrainment, thermal discharges, or any other effects.

The NRC staff concludes that the impacts of the no-action alternative on aquatic resources would be SMALL.

4.7.3 Replacement Power Alternatives: Common Impacts

Each replacement power alternative would entail construction and operation of a new energy generating facility on the existing 9,500-ac (3,800-ha) Turkey Point site but outside the footprint of Turkey Point Units 3 and 4 and outside the footprint of the proposed Turkey Point Units 6 and 7. Each replacement plant would use mechanical draft cooling towers that would draw water from reclaimed wastewater at varying rates depending on each

alternative's cooling requirements. Both alternatives involving a new natural gas plant would require a pipeline to connect the new facility to an existing natural gas supply line located approximately 100 mi (160 km) north of the Turkey Point site.

For all alternatives discussed in this section, the impacts of construction on aquatic resources would be qualitatively similar. During construction, the use of the existing Turkey Point site would allow FPL to use some existing buildings and infrastructure. However, an additional 75 to 540 ac (30 to 220 ha) of undeveloped land on or near the site would be required depending on the specific alternative. The solar component of the combination alternative may require up to 1,400 ac (570 ha) of additional offsite land, and rights-of-way and gas extraction may require additional land, as well. Given the prevalence of wetlands, mangrove forests, mudflats, and other aquatic features on and near the Turkey Point site, it is unlikely that FPL would be able to completely avoid destroying or degrading these habitats during construction of buildings, cooling towers, and other plant components associated with any of the replacement power alternatives. Thus, construction would likely result in permanent loss of some onsite aquatic habitats. The resulting habitat fragmentation could affect ecosystem function and connectivity of aquatic habitats. Habitat degradation associated with runoff, erosion, and sedimentation during construction could also occur. Additionally, direct mortality of aquatic organisms could result from dredging, wetland and mangrove filling, and other necessary in-water work. Barge traffic associated with delivery of construction supplies and plant components to the site would release pollutants into aquatic habitats and could result in collision-related injury or mortality of larger aquatic organisms, especially turtles and marine mammals.

Appropriate permits would mitigate some water quality and aquatic resource impacts by requiring FPL to implement best management practices or other mitigation measures during construction and/or operation. The U.S. Army Corps of Engineers (USACE) or the FDEP would oversee applicable Clean Water Act permitting, including Section 404 permits for dredging and fill activities, Section 401 certification, and Section 402(p) National Pollutant Discharge Elimination System (NPDES) general stormwater permitting. While adherence to these permits would minimize effects on aquatic resources, the prevalence of sensitive aquatic habitats on the Turkey Point site would make some level of impact unavoidable. Construction of any of the replacement power alternatives could affect wetland or mangrove connectivity and could degrade or reduce the value of these habitats as nurseries for fish and shellfish. Such effects would likely be noticeable and could destabilize these attributes of the aquatic environment depending on the particular alternative selected and the siting of the plant.

During operation of any of the replacement power alternatives, the potential impacts on aquatic resources would be qualitatively similar to those that would be experienced as a result of the proposed action of subsequent license renewal. Once built, operation of a replacement power plant would have minimal to no discernable impacts on aquatic resources given that a new power plant would use reclaimed wastewater for cooling. Thus, impingement, entrainment, thermal effects, and water use conflicts would not be an issue.

As described above under the no-action alternative, the CCS would continue to operate regardless of the proposed Turkey Point subsequent license renewal because it supports retired fossil fuel Units 1 and 2. FPL plans to continue to use water from the CCS to support the operation of these units in synchronous condenser mode over the course of the proposed subsequent license renewal period, as described in Section 3.1.3, "Cooling and Auxiliary Water Systems." Additionally, fossil fuel Unit 5 would remain in operation and would continue to discharge blowdown to the CCS. CCS conditions could change with implementation of one of

the replacement power alternatives because less heat would be discharged to the system. This would potentially reduce evaporation resulting in less saline conditions that would be more favorable to aquatic life. On the other hand, CCS flow would likely decrease because Turkey Point Units 3 and 4 would withdraw substantially reduced quantities of water during the shutdown period, and eventually Turkey Point Units 3 and 4 would cease to circulate water through the CCS entirely. This could lead to stagnant conditions and lower habitat quality. Stagnant conditions could potentially promote algae growth. Regardless, the CCS would continue to provide habitat for the existing aquatic community. Additionally, FPL would continue CCS restoration activities, as described in Section 3.5.1.4, "Adjacent Surface Water Quality and Cooling Canal System Operation," and Section 3.7, "Aquatic Resources," of this SEIS. The State of Florida requires these activities under FPL's Nutrient Management Plan, which is independent of subsequent license renewal. Restoration activities would likely eventually return portions of the CCS to a seagrass-based ecological system. These restoration activities would benefit fish and shellfish inhabiting the CCS as well as other wildlife that rely upon the CCS as a source of prey.

4.7.4 New Nuclear Alternative

The NRC staff did not identify any impacts to aquatic resources for the new nuclear alternative beyond those discussed in the impacts common to all replacement power alternatives. As described above, the CCS would continue to operate regardless of whether a replacement power alternative is implemented, and the impacts discussed previously that would be associated with continued operation of the CCS would apply to this alternative. However, the common impact would be more intense for the new nuclear alternative compared to the other alternatives because of the larger land area requirement, which would result in more habitat loss and the potential for higher rates of erosion and sedimentation into aquatic habitats. Impacts of this alternative would be MODERATE to LARGE in the local environs of the plant due to the sensitive nature of the wetlands, mangrove forests, mudflats, and other nearby aquatic habitats and the likelihood that construction would convert (destroy) or degrade these habitats. The permanent loss or alteration of these aquatic habitats would likely result in habitat fragmentation that could affect ecosystem function and connectivity of aquatic habitats. The exact level of impact would depend on whether the chosen site results in the permanent loss, impairment, fragmentation, or reduced ecosystem function of affected aquatic habitats.

4.7.5 Natural Gas Combined-Cycle Alternative

The common impacts described above would be less intense for the natural gas alternative compared to the new nuclear alternative. Because the natural gas alternative would disturb less land, it would, therefore, have less likelihood of impairing aquatic habitat connectivity or function. In addition to the common impacts, the natural gas alternative would require construction of a gas pipeline, which could result in erosion, sedimentation, or disturbance of aquatic habitats during the construction phase. The exact degree of impacts would depend on the amount and quality of aquatic habitat along the chosen pipeline route and the implementation of best management practices during construction. During operation, the natural gas alternative would emit pollutants that could degrade aquatic habitats. As described above, the CCS would continue to operate regardless of whether a replacement power alternative is implemented, and the impacts discussed previously that would be associated with continued operation of the CCS would apply to this alternative. The NRC staff concludes that impacts of a natural gas alternative on aquatic resources would be MODERATE to LARGE in the local environs of the plant, due to the permanent loss of aquatic habitats during plant siting and the potential for additional disturbance or loss of aquatic habitats during pipeline

construction. The exact level of impact would depend on whether the chosen plant site and pipeline route results in the permanent loss, impairment, fragmentation, or reduced ecosystem function of affected aquatic habitats.

4.7.6 Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)

The NRC staff did not identify any impacts to aquatic resources for the natural gas portion of the combination alternative beyond those already discussed above for the natural gas-only alternative. For the solar portion of the combination alternative, the exact level of disturbance or degradation that aquatic habitats would experience would depend on the specific siting of solar panels and infrastructure. Given the large area of land that the solar component would require (approximately 1,400 ac (570 ha) for three offsite solar units, in total) and the prevalence of wetlands, mangrove forests, and other important aquatic habitats within the region where the solar units would be sited, construction would likely result in permanent loss or impairment of aquatic habitats. As described above, the CCS would continue to operate regardless of whether a replacement power alternative is implemented, and the impacts discussed previously that would be associated with continued operation of the CCS would apply to this alternative. The NRC staff concludes that impacts of a combination alternative on aquatic resources would be MODERATE to LARGE in the local environs of the plant, due to the permanent loss of aquatic habitats during natural gas plant and solar panel siting. The exact level of impact would depend on whether the chosen natural gas plant site and solar panel sites result in the permanent loss, impairment, fragmentation, or reduced ecosystem function of affected aquatic habitats.

4.7.7 Cooling Water System Alternative

The NRC staff did not identify any impacts to aquatic resources for the cooling water system alternative beyond those discussed in the impacts common to all replacement power alternatives. As described above, the CCS would continue to operate regardless of whether cooling towers are constructed to support Turkey Point Units 3 and 4, and the impacts discussed previously that would be associated with continued operation of the CCS would apply to this alternative. Construction of cooling towers on the Turkey Point site would result in the permanent loss or impairment of sensitive aquatic habitats and could affect ecosystem function and connectivity. Therefore, the NRC staff concludes that the impacts of implementing the cooling water system alternative on aquatic resources would be MODERATE in the local environs of the plant.

4.8 Special Status Species and Habitats

This section describes the potential special status species and habitats impacts of the proposed action (subsequent license renewal) and alternatives to the proposed action.

4.8.1 Proposed Action

Table 4-2 identifies the one Turkey Point site-specific (Category 2) issue related to special status species and habitats applicable to the area during the subsequent license renewal term. This issue is analyzed below.

4.8.1.1 Federally Listed Species and Critical Habitats Protected Under the Endangered Species Act

Federally Listed Species and Critical Habitats under U.S. Fish and Wildlife Service Jurisdiction

Section 3.8, “Special Status Species and Habitats,” in this SEIS describes 42 federally listed species solely under the FWS’s jurisdiction that occur in the action area. In that section, the NRC staff concludes that 25 of these species would not occur in the action area because those species are extirpated from Miami-Dade County, are not known to occur within Miami-Dade County, or no suitable habitat occurs within the action area. An additional four species are under the shared jurisdiction of the FWS and the National Marine Fisheries Service (NMFS). The NRC staff has determined that continued operation of Turkey Point Units 3 and 4 would have no effect on any portions of these species’ life cycles that are under the FWS’s jurisdiction (NRC 2018g). In addition, two species are listed because of similarity of appearance to other listed species and, therefore, are not subject to the Endangered Species Act of 1973, as amended (ESA), Section 7 consultation requirement.

In a separate biological assessment, the NRC staff (2018n) analyzed the potential impacts of the proposed Turkey Point subsequent license renewal on the American crocodile, the eastern indigo snake (*Drymarchon corais couperi*), and the remaining 13 species, as well as on designated critical habitat of the American crocodile and West Indian manatee (*Trichechus manatus*). The NRC staff incorporates its biological assessment into this SEIS by reference. The NRC staff’s ESA effect determinations for each species are identified below in Table 4-4.

The NRC staff (2018) submitted its biological assessment to the FWS for review on December 19, 2018. In the accompanying letter, the staff requested to initiate formal consultation under 50 CFR 402.14 for the American crocodile and eastern indigo snake, and the staff requested the FWS’s concurrence with the NRC staff’s “may affect, but is not likely to adversely affect” determinations for other federally listed species in accordance with 50 CFR 402.12(j).

On February 25, 2019, the NRC staff and the FWS (2019a) held a teleconference to discuss the NRC staff’s effect determinations for certain federally listed species. Based on those discussions, on February 26, 2019, the NRC staff (2019c) revised its impact determinations from “may affect, but is not likely to adversely affect” to “no effect” for the following species: Florida bonneted bat (*Eumops floridanus*), piping plover (*Charadrius melodus*), Everglades snail kite (*Rostrhamus sociabilis*), Kirtland’s warbler (*Setophaga kirtlandi*), Blodgett’s silverbush (*Argythamnia blodgettii*), Cape Sable thoroughwort (*Chromolaena frustrata*), Florida semaphore cactus (*Consolea corallicola*), sand flax (*Linum arenicola*), and Florida bristle fern (*Trichomanes punctatum* ssp. *floridanum*).

Consultation between the NRC and the FWS continued until the FWS (2019b) issued a new biological opinion for Turkey Point on July 25, 2019. After reviewing and analyzing the current status of the listed species and critical habitat, the environmental baseline within the action area, the effects of the action, any effects of interrelated and interdependent activities, and cumulative effects, the FWS (2019b) concluded in the biological opinion that the continued operation of Turkey Point through the duration of the proposed subsequent license renewal period is not likely to jeopardize the continued existence of the American crocodile or eastern indigo snake and will not adversely modify the critical habitat of the American crocodile. The biological opinion includes an Incidental Take Statement that applies to the American crocodile and eastern indigo snake during operation of Turkey Point through the duration of the proposed

subsequent license renewal periods (i.e., through July 19, 2052, for Unit 3 and through April 10, 2053, for Unit 4). The Incidental Take Statement exempts incidental take that may occur from:

- harm from habitat loss (American crocodile),
- injuries or mortalities from vehicle collisions (American crocodile), and
- mortality from vegetation maintenance (eastern indigo snake).

The opinion specifies allowable numbers for such incidental take to be as follows.

- One American crocodile causal mortality per calendar year
- One indigo snake causal mortality every two calendar years

The opinion also includes the following Reasonable and Prudent Measure that the FWS (2019b) determined to be necessary or appropriate to minimize the impact of the amount of extent of incidental take.

Minimize the adverse effects of the ongoing operation of the Turkey Point Power facility by implementing measures to increase employee awareness of the presence of the crocodile and indigo snake on the site.

The FWS (2019b) states that this measure is necessary and appropriate to reduce take and to minimize the direct and indirect effects of the proposed project on the American crocodile and eastern indigo snake. The FWS identified five Terms and Conditions to implement this Reasonable and Prudent Measure, which it described as follows (FWS 2019b).

- 1) Continue crocodile nest and hatchling monitoring at Turkey Point for the duration of the NRC's licensed operations, or unless otherwise agreed upon by FPL, the Service, the NRC, and any relevant researchers. Every two years, FPL, the Service, the NRC, and any relevant researchers will meet to discuss the monitoring methods and the need for continuation.
- 2) Continue to conduct employee training for crocodiles and indigo snake awareness and posts educational signs around the plant.
- 3) The applicant must maintain four warning signs labeled as "Slow Crocodile Crossing" along Bechtel Road near the test canals on the Turkey Point Power Plant site. The signs will be installed at approximately 500-foot intervals. Based on our field inspection of the Turkey Point Power Plant site, we are aware that FPL has already installed these signs.
- 4) Provide an informational bulletin on the crocodile to all employees at the Turkey Point Power Plant once every 6 months. The bulletin should remind employees that crocodiles occur on the Turkey Point Facility grounds, include a photograph of an crocodile, and note that crocodile hatchlings can be small (12 to 18 inches total length) making them more difficult to detect. In addition, the bulletin should remind employees to be alert for crocodiles when driving or conducting activities on the site, to observe speed limits at all times, to not interact with a crocodile in any way, and to contact their supervisor if a crocodile is observed on or near a road.

- 5) Conduct a presentation on the crocodile and indigo snakes twice a year at the monthly safety meeting that all plant personnel are required to attend. The presentations will be made during the crocodile mating and nesting season when the activity of crocodiles at the site is greatest. The presentation will focus on the identification of crocodiles and indigo snakes, and areas on the Turkey Point Power Plant site where crocodiles may occur. The presentation will also remind employees to: be alert for crocodiles and indigo snakes when driving or conducting activities on the site, observe speed limits at all times, not interact with a crocodile or indigo snake in any way, and contact their supervisor if a crocodile or indigo snake is observed on or near a road.

The Terms and Conditions are nondiscretionary and must be undertaken by the NRC so that they become binding conditions of the renewed licenses, if granted, for the exemption in Section 7(o)(2) of the ESA to apply. Accordingly, the NRC staff will incorporate these terms and conditions into a license condition for the proposed subsequent renewed licenses, if issued.

With respect to all other federally listed species and critical habitats that occur or have the potential to occur in the action area, the FWS (2019b) concurred with the NRC staff's "may affect, but is not likely to adversely affect" determinations. The FWS (2019b) documented its concurrence in the body of the biological opinion. The FWS did not evaluate or make conclusions regarding those species for which the NRC staff made "no effect" determinations, and the ESA does not require Federal agencies to consult on such species or obtain FWS concurrence with such findings. Table 4-4 identifies the FWS's conclusions for each federally listed species and designated critical habitat.

The FWS's issuance of the July 25, 2019, biological opinion concluded the ESA Section 7 consultation for the proposed Turkey Point subsequent license renewal. Appendix C.1 describes the NRC staff's consultation with the FWS.

Federally Listed Species and Critical Habitats under National Marine Fisheries Service Jurisdiction

Section 3.8, "Special Status Species and Habitats," describes six federally listed species under the NMFS's jurisdiction that occur in the action area: loggerhead sea turtle (*Caretta caretta*), green sea turtle (*Chelonia mydas*), leatherback sea turtle (*Dermochelys coriacea*), hawksbill sea turtle (*Eretmochelys imbricata*), Kemp's ridley sea turtle (*Lepidochelys kempii*), and smalltooth sawfish (*Pristis pectinata*). In that section, the NRC staff concludes that all of these species occur in the action area because they inhabit Biscayne Bay but that none occur on the Turkey Point site itself, including within the CCS. The NRC staff analyzes the potential impacts of the proposed Turkey Point subsequent license renewal on these six species below. Table 4-5, below, summarizes the NRC staff's ESA effect determination for each species. Appendix C.1 describes the NRC staff's consultation with the NMFS.

Table 4-4 Effect Determinations for Federally Listed Species Under U.S. Fish and Wildlife Service Jurisdiction

Species	Common Name	Federal Status ^(a)	NRC Staff Effect Determination ^(b)	FWS Conclusion ^(c)
Mammals				
<i>Eumops floridanus</i>	Florida bonneted bat	FE	no effect ^(e)	n/a ^(f)
<i>Puma concolor coryi</i>	Florida panther	FE	may affect, but is not likely to adversely affect	may affect, but is not likely to adversely affect
<i>Puma concolor</i> (all sub species except coryi)	puma	SAT	n/a ^(e)	n/a ^(e)
<i>Trichechus manatus</i>	West Indian manatee	FT	may affect, but is not likely to adversely affect no adverse modification to designated critical habitat	may affect, but is not likely to adversely affect no adverse modification to designated critical habitat ^(g)
Birds				
<i>Ammodramus maritimus mirabilis</i>	Cape Sable seaside sparrow	FE	no effect	n/a ^(f)
<i>Ammodramus savannarum</i>	Florida Grasshopper sparrow	FE	no effect	n/a ^(f)
<i>Aphelocoma coerulescens</i>	Florida scrub-jay	FT	no effect	n/a ^(f)
<i>Caladris rufa</i>	red knot	FT	may affect, but is not likely to adversely affect	may affect, but is not likely to adversely affect
<i>Campephilus principalis</i>	ivory-billed woodpecker	FE	no effect	n/a ^(f)
<i>Charadrius melodus</i>	piping plover	FT	no effect ^(d)	n/a ^(f)
<i>Mycteria americana</i>	wood stork	FT	may affect, but is not likely to adversely affect	may affect, but is not likely to adversely affect
<i>Picoides borealis</i>	red-cockaded woodpecker	FE	no effect	n/a ^(f)
<i>Rostrhamus sociabilis</i>	Everglades snail kite	FE	no effect ^(d)	n/a ^(f)
<i>Setophaga kirtlandi</i>	Kirtland's warbler	FE	no effect ^(d)	n/a ^(f)
<i>Vermivora bachmani</i>	Bachman's warbler	FE	no effect	n/a ^(f)

Species	Common Name	Federal Status ^(a)	NRC Staff Effect Determination ^(b)	FWS Conclusion ^(c)
Reptiles				
<i>Alligator mississippiensis</i>	American alligator	SAT	n/a ^(e)	n/a ^(e)
<i>Crocodylus acutus</i>	American crocodile	FT	likely to adversely affect adverse modification to designated critical habitat	not likely to jeopardize the continued existence of no adverse modification to designated critical habitat
<i>Drymarchon corais couperi</i>	eastern indigo snake	FT	likely to adversely affect	not likely to jeopardize the continued existence of
Invertebrates				
<i>Anaea troglodyta floridalis</i>	Florida leafwing butterfly	FE	no effect	n/a ^(f)
<i>Cyclargus thomasi bethunebakeri</i>	Miami blue butterfly	FE	no effect	n/a ^(f)
<i>Heracides aristodemus ponceanus</i>	Schaus swallowtail butterfly	FE	no effect	n/a ^(f)
<i>Orthalicus reses</i>	Stock Island Tree Snail	FT	no effect	n/a ^(f)
<i>Strymon acis bartrami</i>	Bartram's hairstreak butterfly	FE	no effect	n/a ^(f)
Flowering Plants				
<i>Amorpha crenulata</i>	crenulate lead-plant	FE	no effect	n/a ^(f)
<i>Argythamnia blodgettii</i>	Blodgett's silverbush	FT	no effect ^(d)	n/a ^(f)
<i>Brickellia mosieri</i>	Florida brickell-bush	FE	no effect	n/a ^(f)
<i>Chamaesyce deltoidea</i> ssp. <i>deltoidea</i>	deltoid spurge	FE	no effect	n/a ^(f)
<i>Chamaesyce deltoidea pinetorum</i>	pineland sandmat	FT	no effect	n/a ^(f)
<i>Chamaesyce garberi</i>	Garber's spurge	FT	no effect	n/a ^(f)
<i>Chromolaena frustrata</i>	Cape Sable thoroughwort	FE	no effect ^(d)	n/a ^(f)
<i>Consolea corallicola</i>	Florida semaphore cactus	FE	no effect ^(d)	n/a ^(f)
<i>Cucurbita okeechobeensis</i> ssp. <i>okeechobeensis</i>	Okeechobee Gourd	FE	no effect	n/a ^(f)
<i>Dalea carthagenensis floridana</i>	Florida prairie-clover	FE	no effect	n/a ^(f)
<i>Digitaria pauciflora</i>	Florida pineland crabgrass	FT	no effect	n/a ^(f)

Species	Common Name	Federal Status ^(a)	NRC Staff Effect Determination ^(b)	FWS Conclusion ^(c)
<i>Galactia smallii</i>	Small's milkpea	FE	no effect	n/a ^(f)
<i>Jacquemontia reclinata</i>	beach jacquemontia	FE	no effect	n/a ^(f)
<i>Linum arenicola</i>	sand flax	FE	no effect ^(d)	n/a ^(f)
<i>Linum carteri carteri</i>	Carter's small-flowered flax	FE	no effect	n/a ^(f)
<i>Polygala smallii</i>	tiny polygala	FE	no effect	n/a ^(f)
<i>Sideroxylon reclinatum</i> ssp. <i>austrifloridense</i>	Everglades bully	FT	no effect	n/a ^(f)
<i>Warea carteri</i>	Carter's mustard	FE	no effect	n/a ^(f)
Ferns				
<i>Trichomanes punctatum</i> ssp. <i>floridanum</i>	Florida bristle fern	FE	no effect ^(d)	n/a ^(f)

^(a) SAT = federally listed due to similarity of appearance to another listed species, FE = federally listed as endangered, FT = federally listed as threatened at 50 CFR Part 17, "Endangered and Threatened Wildlife and Plants," under the provisions of the ESA.

^(b) The NRC staff's effect determinations are documented in the staff's December 19, 2018, biological assessment (NRC 2018n) except as noted in footnote (d) below.

^(c) The FWS's conclusions are documented in its July 25, 2019, biological opinion (FWS 2019b).

^(d) The NRC staff revised its impact determination from "may affect, but is not likely to adversely affect" to "no effect" for this species in consultation with the FWS. Emails exchanged between the two agencies (FWS 2019a; NRC 2019c) document the NRC staff's revised determination. The FWS's biological opinion also documents the staff's revised determination in the section titled, "Consultation history."

^(e) The ESA does not require Federal agencies to consult under Section 7 for species listed due to similarity of appearance with another species. Accordingly, the NRC staff has not made an ESA effect determination for these species, and the FWS did not address it in its biological opinion.

^(f) The ESA does not require Federal agencies to obtain FWS concurrence with "no effect" determinations, and the FWS did not evaluate or make conclusions for this species in its biological opinion.

^(g) The FWS clarified its conclusion for designated critical habitat of the West Indian manatee in an August 16, 2019, email (FWS 2019c).

Table 4-5 Effect Determinations for Federally Listed Species Under National Marine Fisheries Service Jurisdiction

Species	Common Name	Federal Status ^(a)	NRC Staff Effect Determination	NMFS Conclusion
Sea Turtles				
<i>Caretta caretta</i>	loggerhead	FT	may affect, but is not likely to adversely affect	TBD ^(c)
<i>Chelonia mydas</i>	green	FT ^(b)	may affect, but is not likely to adversely affect	TBD ^(c)
<i>Dermochelys coriacea</i>	leatherback	FE	may affect, but is not likely to adversely affect	TBD ^(c)
<i>Eretmochelys imbricata</i>	hawksbill	FE	may affect, but is not likely to adversely affect	TBD ^(c)
<i>Lepidochelys kempii</i>	Kemp's ridley	FE	may affect, but is not likely to adversely affect	TBD ^(c)
Fish				
<i>Pristis pectinata</i>	smalltooth sawfish	FE ^(b)	may affect, but is not likely to adversely affect	TBD ^(c)

^(a) FE = federally listed as endangered and FT = federally listed as threatened at 50 CFR Part 17, "Endangered and Threatened Wildlife and Plants," under the provisions of the ESA.

^(b) The identified Federal status applies to the following distinct population segment(s) (DPS): Northwest Atlantic and South Atlantic DPSs of the green turtle and United States DPS of the smalltooth sawfish.

^(c) The NMFS's conclusion for this species is to be determined (TBD) because consultation between the NRC staff and the NMFS continues at this time. The results of this consultation will be reported in the NRC's Record of Decision for the proposed Turkey Point subsequent license renewal.

Impingement, Entrainment, and Thermal Effects

In the GEIS (NUREG-1437) (NRC 2013a), the NRC staff identified a number of issues (or impacts) that the aquatic ecological environment could experience as a result of license renewal of a nuclear plant. These impacts, as they apply to the proposed Turkey Point subsequent license renewal, are identified in Table 4-1 and Table 4-2. As described in Section 4.7, "Aquatic Resources," because the CCS does not directly withdraw from or discharge to any other surface waters, the effects of impingement, entrainment, and thermal discharges are not applicable for aquatic biota in Biscayne Bay or any other natural waterbodies. Thus, federally listed sea turtles and smalltooth sawfish occurring in the action area would not be subject to these impacts.

Barge Traffic

Barge traffic associated with subsequent license renewal has the potential to impact sea turtles and smalltooth sawfish inhabiting Biscayne Bay. Continued operation of Turkey Point during the subsequent license renewal term would necessitate infrequent deliveries of large parts and equipment to the Turkey Point site. FPL (2018g) estimates that up to five barges in a single year at intervals of 4 to 5 years would travel to and from Turkey Point during the proposed

subsequent license renewal term. This level of vessel traffic would include combined deliveries associated with Turkey Point Units 3 and 4; Turkey Point Units 1, 2, and 5; and the onsite independent spent fuel storage installation (FPL 2018g).

Sea turtles and smalltooth sawfish in Biscayne Bay could be injured or killed during interactions with barge vessels as the vessels travel through the Bay. However, the infrequency of vessel traffic and the ability of sea turtles and smalltooth sawfish to move away from vessels to avoid impact make such effects extremely unlikely to occur. The NMFS assessed the impacts of barge traffic, among other effects, as part of its ESA, Section 7 consultation with the NRC for the proposed construction of Turkey Point Units 6 and 7 in 2017. Construction of the two new units would involve regular barge deliveries as well as pile driving and basin dredging, all of which the NMFS (2017a) found to be discountable. The NRC staff finds the same conclusion to be reasonable for the proposed Turkey Point Units 3 and 4 subsequent license renewal because this action would require much less frequent barge deliveries and would not involve any dredging or other in-water work. Additionally, the NRC staff is not aware of any sea turtle or smalltooth sawfish injuries or mortalities associated with Turkey Point barge traffic since the units began operating in 1972 (Unit 3) and 1974 (Unit 4). Compared to the original license and initial renewed license terms, barge traffic would continue at similar or less frequent rates during the proposed subsequent license renewal term. Accordingly, the NRC staff finds this potential impact to be discountable.

Biscayne Bay Water Quality

During the NEPA scoping and DSEIS comment periods, the NRC staff received comments recommending that the staff consider the potential impacts of interactions between the CCS and nearby surface waterbodies on federally listed species. The commenters' suggestions stemmed primarily from the concern that contaminants originating from the CCS could affect water quality in Biscayne Bay, which would in turn affect federally listed species present in the action area. The NRC staff evaluates this potential impact below. The NRC staff (2019g) also prepared detailed analyses of this issue in response to the NMFS's requests for additional information during its Section 7 consultation with the NMFS. The staff has updated this SEIS to reflect these more detailed analyses. Additionally, the staff updated the sections below to reflect the most recently available water quality monitoring data that became available following the staff's issuance of the DSEIS.

Background on Nonradiological and Radiological Contaminants. In the GEIS (NRC 2013a), the NRC staff evaluated the effects that nonradiological and radiological contaminants contained in nuclear plant effluent discharges may have on the aquatic environment under the following Category 1 license renewal issues:

- effects of nonradiological contaminants on aquatic organisms
- exposure of aquatic organisms to radionuclides

The NRC (2013a) determined that the impacts of these issues would be SMALL during the license renewal period of a nuclear power plant. In Table B-1 of 10 CFR Part 51, Appendix B, the NRC defines "SMALL" to mean that environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource. Because these potential effects that apply to all nuclear plants (rather than only to Turkey Point), the NRC staff bases its GEIS conclusions on factors that apply at all nuclear plants. For instance, with respect to nonradiological contaminants, a primary factor that led to the staff's

conclusion of SMALL is that in order to operate a nuclear plant, licensees must comply with the Clean Water Act (CWA), including requirements imposed by the EPA or the State, as part of the NPDES program under Section 402 of the Act and State water quality certification requirements under Section 401 of the Act. If these water quality criteria are not violated, the NRC assumes that nonradiological contaminant discharges would not significantly affect the aquatic environment. The NRC staff's analysis relating to the effects of nonradiological contaminants on aquatic organisms appears on pages 4-103 to 4-105 of the GEIS (NRC 2013a). For the proposed Turkey Point subsequent license renewal, the NRC staff did not identify any new and significant information during its environmental review related to the effects of nonradiological contaminants on aquatic organisms beyond what is described in the GEIS. The NRC staff adopted the GEIS's conclusions of SMALL for this issue in Section 4.7.1 of this SEIS. Such an effect level would equate to "insignificant" in ESA terminology (i.e., the effects would never reach the scale where a take would occur and, based on best judgement, a person would not be able to meaningfully measure, detect, or evaluate such effects).

With respect to radiological contaminants, the NRC staff uses DOE (2019) guidelines to evaluate the potential effects of exposure of aquatic organisms to radionuclides during a nuclear plant license renewal term. The DOE developed and published a screening methodology that includes biota concentration guides (BCGs) for surface water, sediment, and soil. The DOE developed its BCGs to be conservatively protective of nonhuman biota for 23 radionuclides, including tritium (H-3), based on limiting the potential radiological dose rate to the most sensitive receptors. For each radionuclide and exposure pathway (i.e., surface water, sediment, and soil), the most sensitive receptor (or reference organism) may be an aquatic, terrestrial, or riparian animal, or a terrestrial plant. Specific to aquatic animal reference organisms, the DOE uses a dose rate criterion of ≤ 1 rad per day (rad/d) of absorbed dose. This dose rate criterion can be applied within the DOE's graded approach to determine whether radionuclide concentrations at a specific site are likely to result in doses exceeding DOE guidelines. If the graded approach demonstrates that the absorbed dose would be ≤ 1 rad/d, aquatic biota would not experience negative population-level effects. In the GEIS, the NRC uses the DOE's dose rate criterion of ≤ 1 rad/d and the DOE's graded approach to conclude that the impacts of exposure of aquatic organisms to radionuclides resulting from license renewal of a nuclear plant would be SMALL. The NRC staff's full analysis relating to exposure of aquatic organisms to radionuclides appears on pages 4-105 to 4-107 of the GEIS. For the proposed Turkey Point license renewal, the NRC staff did not identify any new and significant information during its review related to the exposure of aquatic organisms to radionuclides beyond what is described in the GEIS. The NRC staff adopted the GEIS's conclusions of SMALL for this issue in Section 4.7.1 of the SEIS. As explained above, this effect level would equate to "insignificant" in ESA terminology.

Separate from the above-described analyses, the impacts of license renewal on federally listed species is a Category 2 (site-specific) issue in the GEIS that requires a unique analysis for each license renewal. The remainder of this section considers the impacts that sea turtles and smalltooth sawfish inhabiting Biscayne Bay may experience at the individual or species level resulting from exposure to nonradiological and radiological contaminants associated with continued operation of Turkey Point during the proposed license renewal period.

Exposure Pathway. At Turkey Point, the potential pathway for exposure of aquatic organisms that inhabit Biscayne Bay to contaminants originating from the CCS is indirect and complex. As described in Section 3.5.1, "Surface Water Hydrology," of this SEIS, the CCS is situated above the Biscayne aquifer. The porous nature of the limestone bedrock that forms the Biscayne aquifer results in some groundwater exchange between the CCS and the aquifer. This

exchange of groundwater between the CCS and the Biscayne aquifer creates a pathway through which the CCS may influence Biscayne Bay. Groundwater under the Turkey Point site flows east (towards Biscayne Bay) or west (inland and away from the Bay) depending on the head levels in the aquifer relative to the water levels in Biscayne Bay. Within the larger regional context, South Florida's water is highly influenced by a complex system of crisscrossing canals that drain surface waters from the land for agricultural and urban use, provide flood control, and discharge freshwater into Biscayne Bay and Card Sound. The State manages the canal system as a coastal control structure to maintain relatively high water levels along the coast and prevent saltwater intrusion within near-surface groundwater aquifers. The State of Florida and Miami-Dade County have required FPL to take actions to abate hypersaline water discharges from the CCS and to actively remediate the hypersaline groundwater west and north of FPL's property. Many of FPL's current and ongoing actions to address groundwater quality are specified in a June 2016 Consent Order with the FDEP and in an October 2015 Consent Agreement with the Miami-Dade County Department of Environmental Resources Management (DERM) (see Section 3.5.2.2, "Groundwater Quality" for more detailed information). Both the Consent Order and Consent Agreement contain requirements that aim to ensure that the CCS does not adversely affect the region's surface waters. Thus, the potential for contaminants originating from the CCS to affect nearby surface water quality depends on many factors, including Biscayne Bay water conditions, groundwater head levels, freshwater inflow from precipitation, the State's management of South Florida's regional canal system, and FPL's implementation of State- and County-imposed requirements.

Water Quality Monitoring Data. As part of the requirements of the State's Consent Order, FPL maintains an extensive water quality monitoring program. FPL monitors the CCS, Biscayne Bay, Card Sound, and other nearby waterbodies for ammonia, nitrogen, phosphorus, and chloride, among other nutrients and parameters. Additionally, FPL conducts ecological monitoring semiannually in Biscayne Bay and mangrove areas and quarterly in marsh areas. To date, FPL's monitoring data indicate no discernable ecological impact on the areas surrounding the CCS and no clear evidence of CCS water in the surrounding marsh and mangrove areas or in Biscayne Bay from a groundwater pathway (E&E 2017; FPL 2018o). FPL's monitoring plan and associated results are described in more detail in Section 3.5.1, "Surface Water Hydrology" of this SEIS.

While there is no evidence that the CCS is affecting Biscayne Bay, Miami-Dade County has expressed concern that groundwater underlying the CCS may be contributing nutrients (e.g., ammonia) to manmade canals adjacent to the CCS. The waters of these (non-CCS) canals are hydrologically connected to the CCS through the Biscayne aquifer and are hydrologically connected to Biscayne Bay through surface water flow (see Figure 3-4, "Cooling Canal System and Adjacent Canals"). In July 2017, the Miami-Dade County Division of Environmental Resource Management (DERM) found elevated concentrations of ammonia exceeding the applicable county surface water standard at certain sampling locations within certain canals adjacent to the CCS (MDC 2018a). The relevant sampling locations at which elevated ammonia levels were measured were at the Barge Basin, Turtle Point Canal, Card Sound Canal, S-20 Get Away Canal, and the Sea-Dade Canal. The elevated ammonia values appeared in bottom samples where dissolved oxygen was less than 1.0 mg/L (FPL 2018r). Ammonia levels in the middle and upper portions of the water column were compliant with county ammonia standards except for middle samples in the Turtle Point Canal where dissolved oxygen levels were also less than 1.0 mg/L (FPL 2018r). Thus, ammonia in the canals stratified such that concentrations exceeding county standards generally occurred only in the bottom of the water column.

In a letter to FPL on this subject, DERM stated that ammonia at these locations may be attributable to a combination of several sources, including both operation of the CCS and other unrelated factors (MDC 2018a). For instance, several bottom samples within these canals exhibited total nitrogen concentrations that greatly exceeded total nitrogen concentrations measured in the CCS and in groundwater beneath the CCS during the same period (FPL 2018r). However, this suggests that sources external to the CCS are contributing nitrogen to the canals. Because these regions of the canals are stagnant and exhibit low dissolved oxygen, decomposition of plant and animal material in these stagnant, anoxic areas creates extra nitrogen that is not able to disperse or be flushed out of the canals due to little or no mixing of the canals with other surface waters. This extra nitrogen may then contribute to ammonia formation and subsequent accumulation and may ultimately play a role in the observed exceedances of county ammonia standards in the bottom of the canals. Nevertheless, because the DERM believed that the CCS may have been one source contributing to the elevated ammonia levels, it required FPL to submit and implement a mitigation plan to address potential CCS nutrient impacts to groundwater and surface water resources beyond the boundaries of the CCS.

FPL (2018r) submitted its mitigation plan to the DERM in October 2018. In the letter accompanying the plan, FPL (2018r) explained that the data upon which the DERM had relied in making its findings do not definitively delineate the contribution of groundwater underlying the CCS to ammonia levels in the surrounding waters. FPL (2018r) stated that its data demonstrate that at most, groundwater underlying the CCS could have contributed 2 percent or less of the observed ammonia values in the samples taken from the canals. As such, FPL (2018r) concluded that the contribution of groundwater beneath the CCS to ammonia concentrations in adjacent surface waters, if any, is negligible. Nevertheless, the NRC staff undertook the following qualitative evaluation of the potential impacts of elevated ammonia levels on listed species to ensure that the staff appropriately considered all potential impacts of Turkey Point subsequent license renewal on listed species that inhabit Biscayne Bay.

Potential Effects of Ammonia on Listed Species. Elevated ammonia levels are of concern in aquatic environments because when ammonia is present at high enough levels in the environment, aquatic organisms have difficulty completely excreting excess ammonia from their bodies. This can lead to toxic build-up, health and fitness effects, and potentially death. Several water quality parameters, including pH, temperature, and salinity; the rate or duration of exposure; and a species' specific physiobiology affect the extent to which an organism experiences toxicity from a given level of ammonia.

With respect to sea turtles, data on the effects of ammonia are not currently available. In the absence of species-specific information, the NRC assumes that the relevant State water quality criteria are reasonably protective of sea turtles because under Section 303(c) of the Clean Water Act, the EPA or the States are required to adopt water quality standards to restore and maintain the chemical, physical, and biological integrity of the Nation's waters. For delegated States, the EPA must periodically certify that a State's water quality criteria, and any revisions thereto, protect the designated uses of the waterbody and that the standards are consistent with, or more protective than, the EPA's national recommended aquatic life criteria. Therefore, if waters inhabited by sea turtles meet State water quality criteria for ammonia, the NRC staff assumes that there would be no lethal effects or impairment to growth, survival, or reproduction to sea turtle individuals. As described above, the DERM identified a few sampling locations where, in 2017, the total ammonia concentrations exceeded the applicable Miami-Dade County surface water standard. However, the sampled locations were in stagnant, or dead-end canals where sea turtles are unlikely to be present rather than in Biscayne Bay itself where sea turtles

are more likely to be present. Even if sea turtles were to be present in the canals, exposure time would be limited because sea turtles are expected to only occur transiently and for short durations, if at all, in these areas.

Additionally, as described above, the DERM is requiring FPL to take action to restore water quality in the canal areas with elevated ammonia such that ammonia is not expected to be a long-term issue. As also described above, FPL (2018r) submitted a mitigation plan to the DERM in October 2018, to address the potential impacts of CCS operation on groundwater and surface water resources beyond the boundaries of the CCS. The mitigation plan specifies FPL's CCS canal practices, external canal practices, and applicable monitoring and reporting. One FPL action related to the mitigation plan entails the restoration and partial filling of the Barge Canal Turning Basin and the planting of mangroves in and partial filling of the Turtle Point Canal (FPL 2018r). These restoration activities will improve water flow in these canals, which will reduce the potential for ammonia and other nutrients to accrue in these areas in the future. FPL (2018r) began the canal restoration and partial filling project in October 2018. FPL (2019e) completed Turtle Point Canal restoration in April 2019 and completed the Barge Canal Turning Basin in September 2019. The 2016 Consent Order (FDEP 2016a) between FPL and the FDEP also requires FPL to undertake and complete this project. Section 3.5.1.4 of this SEIS discusses this project in more detail under "Ammonia and Nutrients within Biscayne Bay and Card Sound." These fill and restoration projects will reduce access of sea turtles to these areas because the subject areas will be filled. The projects will also improve flow such that decomposing plant and animal matter and stagnant conditions in the canals should no longer exist.

As discussed elsewhere in this SEIS, another action that FPL (2018r) is taking is the implementation of its groundwater recovery well system, which removes up to 15 mgd (56,800 m³/day) of hypersaline groundwater from the base of the Biscayne aquifer via a series of 10 extraction wells along the western edge of the CCS and Palm Drive. FPL (2018r) reported that these extractions had also removed approximately 27,600 lbs (12,520 kg) of ammonia from groundwater beneath the CCS as of October 2018. Further, no contaminants associated with the CCS, including ammonia, have been found in Biscayne Bay itself where sea turtles are more likely to be present. In summary, the very low likelihood of sea turtles to be exposed to elevated ammonia levels and the short duration of potential exposure is unlikely to result in measurable effects on sea turtles. Additionally, FPL's continued implementation of the mitigation plan described above would further reduce the contribution, if any, of the CCS to elevated ammonia levels in surrounding waters to which sea turtles could be exposed.

Toxicity data for smalltooth sawfish exposure to ammonia (or for taxonomically related species that would serve as a reasonable surrogate) are also unavailable. However, the NRC staff assumes that, as with sea turtles, the State water quality criteria are reasonably protective of smalltooth sawfish. Additionally, ureotelic species (species that excrete most of their waste nitrogen in the form of urea in the urine), such as the smalltooth sawfish, regulate the ion concentrations in their body fluids to maintain osmotic balance with their external environment, which reduces the influx of ammonia from the external environment (NMFS 2016a). Ureotelic species also convert ammonia to urea and native tri-methyl amine oxide, which counteracts its toxicity (NMFS 2016a). As such, smalltooth sawfish are expected to be less vulnerable to ambient ammonia than many other aquatic species. In a 2016 biological opinion on the EPA's approval of Florida water quality standards under Section 303(c) of the Clean Water Act, the NMFS (2016a) concluded that ammonia concentrations were not likely to adversely affect the survival or fitness of smalltooth sawfish individuals because responses to anticipated ammonia concentrations from the implementation of the revised standards would be insignificant based

on what is known about nitrogen metabolism and ion regulation for ureotelic elasmobranch species like the smalltooth sawfish. Further, smalltooth sawfish are unlikely to be present in the canals where elevated ammonia levels were measured. Even if smalltooth sawfish were to be present in the manmade canals adjacent to the CCS, exposure time would be limited because individuals are expected to only occur transiently and for short durations, if at all, in these areas. Based on this information, the NRC staff finds that smalltooth sawfish are unlikely to be measurably affected. Additionally, FPL's continued implementation of the mitigation plan described above would further reduce the CCS's contribution, if any, to elevated ammonia levels in surrounding waters to which smalltooth sawfish could be exposed. FPL's completion of the previously described fill and restoration projects will reduce access of smalltooth sawfish to these areas.

The NRC staff concludes that the potential for sea turtles or smalltooth sawfish to be exposed to elevated ammonia levels associated with the continued operation of Turkey Point and the CCS is unlikely based on the following.

- Available monitoring data suggest that the contribution of groundwater beneath the CCS to ammonia concentrations in adjacent surface waters, if any, is negligible.
- Sea turtles are unlikely to be present in the stagnant or dead-end canals where elevated levels of ammonia have been observed.
- Smalltooth sawfish are less vulnerable to ambient ammonia than many other aquatic species because of how they metabolize nitrogen. Smalltooth sawfish are also unlikely to be present in the canals where elevated levels of ammonia have been observed.
- FPL has completed fill and restoration of Turtle Point Canal and restoration of the Barge Canal Turning Basin. These projects have limited access to the previously stagnant regions of the canals and will continue to improve flow to the remaining portions of the canals.
- FPL will continue to implement mitigation to further reduce the contribution, if any, of the CCS to elevated ammonia levels in surrounding waters to which sea turtles or smalltooth sawfish could be exposed.

Any negligible ammonia exposure, if such exposure were to occur, would not result in effects that would be able to be meaningfully measured, detected, or evaluated. The NRC staff concludes that such effects would, therefore, be insignificant.

Potential Effects of Other Nonradiological Contaminants on Listed Species. The NRC staff did not identify any evidence that the CCS may be contributing to any other nonradiological contamination, such as nitrogen, phosphorus, or salinity, in any surface waters outside of the CCS beyond what the staff describes above relating to ammonia. Additionally, any potential future water quality effects on sea turtles and smalltooth sawfish would be limited because the NRC staff assumes that FPL will adhere to, and that the State and County will enforce, the various mitigation requirements in the 2016 FDEP Consent Order (FDEP 2016a) and 2015 DERM Consent Agreement (MDC 2015a) such that nonradiological contaminants associated with the CCS will not discernably affect the aquatic ecology of Biscayne Bay over the course of the proposed subsequent license renewal term. The NRC staff concludes that the potential for sea turtles or smalltooth sawfish to be exposed to nonradiological contaminants associated with the continued operation of Turkey Point and the CCS would not result in effects that would be able to be meaningfully measured, detected, or evaluated. The NRC staff concludes that such effects would, therefore, be insignificant.

Potential Effects of Radiological Contaminants on Listed Species. With respect to the potential impacts of radiological contaminants on listed species in the action area, the radionuclide of concern is tritium. Tritium is a radioactive isotope of hydrogen that has one proton and two neutrons. It occurs both naturally and as a by-product of nuclear reactor operation. In water, tritium binds with oxygen to form tritiated water (H₃O), which behaves in the environment identical to a normal water molecule (H₂O). Tritium is a relatively weak source of beta radiation; the beta particle itself does not have enough energy to penetrate human skin, but tritium molecules can enter humans and other organisms through inhalation or ingestion. Tritium has a half-life of 12.3 years. However, if ingested, the human body excretes half the ingested tritium within 10 days (NRC 2019h). For tritium in drinking water, the EPA (2002) has established a maximum contaminant level of 20,000 pCi/L, which is equivalent to 4 millirems per year (mrem/yr) or 2.7×10^{-6} rad/d. Because the EPA's drinking water standard is significantly lower than the DOE's previously described dose rate criterion of ≤ 1 rad/d for aquatic organisms, the NRC staff concludes that even the most sensitive aquatic receptors, including listed species, would not be affected by tritium concentrations below 20,000 pCi/L.¹

During operation, Turkey Point discharges liquid effluent containing tritium into the CCS. The site's NPDES permit (FDEP 2005) does not permit FPL to discharge to surface waters of the State. The FDEP (2018f) recently issued a draft renewed NPDES permit for Turkey Point. The draft permit, if issued, would continue to prohibit discharges to surface waters of the State. However, tritium may leave the CCS and enter nearby surface water bodies through one of two pathways: (1) as liquid through groundwater or (2) as gas through the air. Thus, for tritium associated with Turkey Point operation to enter Biscayne Bay, tritium molecules would either have to travel from the CCS as liquid water into the groundwater below the CCS (i.e., the Biscayne aquifer) and then through the aquifer's porous limestone bedrock and into the surface waters of Biscayne Bay, or tritium molecules would have to leave the CCS as water vapor and subsequently settle onto the bay's surface through rainfall or other forms of condensation, such as fog.

FPL monitors Biscayne Bay surface water at five stations (TPBBSW-3, 4, 5, 10, and 14) (as described in detail in Section 3.5.1.4, "Adjacent Surface Water Quality and Cooling Canal System Operation," of this SEIS). FPL collects surface water data, including tritium concentrations, from these stations on a quarterly or semi-annual basis. Observed tritium levels at these stations are extremely low and well below the EPA's 20,000 pCi/L standard. For instance, during the most recently available reporting period of June 1, 2017, through May 31, 2018, FPL (2018o) reported a maximum concentration of 18.5 pCi/L and an average concentration of 7.8 pCi/L at its Biscayne Bay monitoring stations. During the historical period of record (June 2010 through May 2017), FPL (2018o) reported a maximum concentration of 34.5 pCi/L and an average concentration of 11.7 pCi/L at its Biscayne Bay monitoring stations. Based on these values, an aquatic organism could potentially be exposed to a maximum concentration of 34.5 pCi/L, which is equivalent to 0.0069 mrem/yr or 1.9×10^{-8} rad/d. For the purposes of evaluating the potential effects of radiological contaminants on listed species, this value is so low as to be effectively zero. Accordingly, listed species in the action area would experience no effects from exposure to radiological contaminants resulting from continued operation of Turkey Point.

¹ In addition to the EPA's drinking water standard, the NRC regulates radiological releases, including tritium, through its regulations at 10 CFR Part 20 and Appendix I to 10 CFR Part 50.

Conclusion

In conclusion, potential impacts on federally listed species under the NMFS's jurisdiction associated with the proposed action could result from (1) interactions of sea turtles and smalltooth sawfish with barge vessels and (2) the potential for sea turtles and smalltooth sawfish to experience water quality impacts through the exchange of CCS water with other surface waters through a groundwater pathway. For the reasons set forth above, the NRC staff finds these potential impacts to be discountable or insignificant. Accordingly, the NRC staff concludes that the proposed subsequent license renewal of Turkey Point may affect, but is not likely to adversely affect, loggerhead, green, leatherback, hawksbill, and Kemp's ridley sea turtles and smalltooth sawfish.

Cumulative Effects

The ESA regulations at 50 CFR 402.12(f)(4) direct Federal agencies to consider cumulative effects as part of the proposed action effects analysis. Under the ESA, cumulative effects are defined as "those effects of future State or private activities, not involving Federal activities, that are reasonably certain to occur within the action area of the Federal action subject to consultation" (50 CFR 402.02, "Definitions"). Unlike the National Environmental Policy Act (NEPA) definition of cumulative impacts (see Section 4.16, "Cumulative Impacts"), cumulative effects under the ESA do not include past actions or other Federal actions requiring separate ESA Section 7 consultation. When formulating biological opinions under formal ESA Section 7 consultation, the FWS and the NMFS (1998) consider cumulative effects when determining the likelihood of jeopardy or adverse modification. Therefore, cumulative effects need only be considered under the ESA if listed species will be adversely affected by the proposed action and formal Section 7 consultation is necessary (FWS 2014b). Because the NRC staff concluded earlier in this section that the proposed subsequent license renewal is not likely to adversely affect sea turtles or smalltooth sawfish, consideration of cumulative effects for these species is not necessary. For those species under the FWS's jurisdiction, cumulative impacts are discussed, as appropriate, in the staff's biological assessment (NRC 2018n).

4.8.1.2 Essential Fish Habitat Protected Under the Magnuson–Stevens Act

Section 3.8, "Special Status Species and Habitat," describes seven federally managed species for which the South Atlantic Fishery Management Council and NMFS have designated Essential Fish Habitat (EFH) under the Magnuson–Stevens Fishery Conservation and Management Act of 1996, as amended (MSA), in Biscayne Bay: pink shrimp (*Farfantepenaeus duorarum*), white grunt (*Haemulon plumieri*), bluestriped grunt (*Haemulon sciurus*), mutton snapper (*Lutianus analis*), dog snapper (*Lutianus jocu*), gray snapper (*Lutjanus griseus*), and spiny lobster (*Panulirus argus*). In that section, the NRC staff concludes that while EFH occurs in Biscayne Bay, neither EFH nor the species themselves occur on the Turkey Point site.

The proposed Turkey Point subsequent license renewal would not result in any impacts to EFH. As described above in Section 4.8.1.1, "Federally Listed Species and Critical Habitats Protected Under the Endangered Species Act," the only potential activity that would affect aquatic resources outside of the Turkey Point site is vessel traffic associated with infrequent deliveries of large parts and equipment to the Turkey Point site and specifically associated with Units 3 and 4. However, such traffic would not impact any aquatic habitats (including prey) in any noticeable or measurable way and, thus, would also not affect EFH. The NRC staff also does not expect that federally managed species themselves or their prey would be directly affected by barge traffic because individuals could swim away to avoid vessels. Additionally,

several of the federally managed species or their prey are bottom-dwelling species that do not typically occur in the top of the water column where they might encounter vessels. Biscayne Bay water quality is not likely to be affected by continued Turkey Point operations in any way that would be discernable on the aquatic ecology of Biscayne Bay for the reasons set forth in Section 4.8.1.1. The NRC staff, therefore, concludes that the proposed action would have no adverse effects on EFH. Accordingly, the NRC staff also finds that EFH consultation for the proposed action is not required.

4.8.1.3 Marine Sanctuary Resources Protected Under the National Marine Sanctuaries Act

Under Section 304(d) of the National Marine Sanctuaries Act (NMSA), Federal agencies must consult with the National Oceanic and Atmospheric Administration's (NOAA's) Office of National Marine Sanctuaries if a Federal action is likely to destroy, cause the loss of, or injure any sanctuary resources. Within Southern Florida, Congress has designated the Florida Keys National Marine Sanctuary to include 2,900 nautical mi² (5,370 nautical km²) of waters surrounding the Florida Keys from south of Miami westward and encompassing the Dry Tortugas. This area includes Card Sound. Section 3.8.3, "Marine Sanctuary Resources Protected Under the National Marine Sanctuaries Act," of this SEIS describes the marine resources of the sanctuary and includes a figure showing the sanctuary's geographic boundaries.

The NRC staff has determined that the proposed Turkey Point subsequent license renewal would not affect the sanctuary resources of the Florida Keys National Marine Sanctuary for several reasons. First, currently available monitoring data do not indicate any discernable impact of the CCS on the ecology of surrounding marsh and mangrove areas, Biscayne Bay, Card Sound, or any other nearby surface waters to date. Second, FPL's continued implementation of its 2016 Consent Order with the Florida Department of Environmental Protection and 2015 Consent Agreement with the Miami-Dade County Department of Environmental Resources will ensure that any potential future impacts of the CCS will be mitigated such that constituents originating from the CCS will not discernably affect the ecology of nearby surface waters over the course of the proposed subsequent license renewal term.

Groundwater monitoring results indicate that water from the CCS has migrated via the groundwater pathway through the deeper interval of the Biscayne aquifer and to the east beneath Biscayne Bay and Card Sound. However, CCS-sourced constituents, which consist of elevated chloride, tritium, and possibly ammonia, have had no effect on surface water quality in Biscayne Bay and Card Sound. At no location outside the boundary of the Turkey Point site do tritium levels in groundwater approach the U.S. Environmental Protection Agency and State primary drinking water standard for tritium of 20,000 pCi/L (40 CFR 141.66). The NRC staff concludes that the proposed action is not likely to destroy, cause the loss of, or injure any sanctuary resources. Accordingly, the NRC staff also finds that consultation under the National Marine Sanctuaries Act for the proposed action is not required.

4.8.2 No-Action Alternative

Under the no-action alternative, the NRC would not issue subsequent renewed licenses, and Turkey Point would shut down on or before the expiration of the current renewed licenses. The ESA action area for the no-action alternative would most likely be the same or similar to the action area described in this section for the proposed subsequent license renewal. However, a

determination of effects would depend on the specific shutdown activities that would be included in the proposed action as well as the listed species and critical habitats present when the no-action alternative is implemented.

The CCS would continue to operate under the no-action alternative regardless of the proposed Turkey Point subsequent license renewal because it supports retired fossil fuel Units 1 and 2. FPL plans to continue to use water from the CCS to support the operation of these units in synchronous condenser mode over the course of the proposed subsequent license renewal period, as described in Section 3.1.3, "Cooling and Auxiliary Water Systems." Additionally, fossil fuel Unit 5 would remain in operation and would continue to discharge blowdown to the CCS. CCS conditions could change under the no-action alternative because less heat would be discharged to the system. This would potentially reduce evaporation resulting in less saline conditions that would be more favorable to ESA-listed species, such as the American crocodile. On the other hand, CCS flow would likely decrease because Turkey Point Units 3 and 4 would withdraw substantially reduced quantities of water during the shutdown period, and eventually Turkey Point 3 and 4 would cease to circulate water through the CCS entirely. This could lead to stagnant conditions, which could lower habitat quality and promote algae growth, both of which could affect ESA-listed species and habitats, such as the American crocodile and its critical habitat. Regardless, FPL would continue CCS restoration activities, as previously described in the discussion of the no-action alternative's impacts on water resources in Section 4.5.2 of this SEIS. The State of Florida requires these activities under FPL's Nutrient Management Plan, which is independent of subsequent license renewal. The CCS would likely continue to provide habitat for foraging and breeding, and restoration activities would benefit species that rely upon the CCS as a source of prey. For instance, CCS berms would continue to provide potential nesting habitat for American crocodiles, and the CCS canals would continue to serve as refuge and a source of prey for this species.

FPL currently implements a crocodile management plan to help improve breeding and nesting habitat and protect American crocodiles on the Turkey Point site. Many portions of this plan are voluntary and not required by any Federal, State, or local permit. During shutdown, FPL would decide whether to stop or continue implementing the crocodile management plan.

Shutdown of the plant with the currently existing cooling system would likely not affect the marine environments of Biscayne Bay, Card Sound, or the Atlantic Ocean. As such, there would likely be no effects on federally listed species or critical habitats under the NMFS's jurisdiction, on EFH, or on sanctuary resources of the Florida Keys National Marine Sanctuary. If necessary, any reinitiated consultation with the FWS pursuant to Section 7 of the ESA would determine effects on the American crocodile, its critical habitat, and other terrestrial and freshwater listed species based on circumstances that might exist at that time. However, a specific determination of effects and consultation requirements at such time would depend on the nature of shutdown and decommissioning activities, the action area associated with those activities, and the listed species, critical habitats, and EFH present when the no-action alternative is implemented.

4.8.3 Replacement Power Alternatives: Common Impacts

All of the replacement power alternatives would entail construction and operation of a new energy-generating facility on the existing Turkey Point site; certain of these alternatives would also entail offsite construction, in part, which is addressed for each of those alternatives below. The ESA action area, EFH, and marine sanctuary resources potentially affected by any new plant would be similar to the subsequent license renewal action area because the replacement

power generating alternatives would generally be sited on the existing site. However, specifically defining the action area would depend on exact plant siting, planned construction activities, temporary and permanent structure locations, and timeline of the alternative. Similarly, the listed species, critical habitats, EFH, and marine sanctuary resources potentially affected by a particular alternative would depend on the boundaries of that alternative's effects and the species and habitats protected at the time the alternative is implemented. For instance, if Turkey Point continues to operate until the end of the current renewed license terms (2032 for Unit 3 and 2033 for Unit 4) and the replacement power alternative is implemented at that time, the FWS and NMFS may have listed new species, delisted currently listed species whose populations may have recovered, or revised EFH designations. These listing and designation activities would change the potential for the various alternatives to impact special status species and habitats. Additionally, requirements for ESA Section 7 consultation with the FWS and NMFS, EFH consultation with the NMFS, and possible NMSA consultation with NOAA, would depend on whether Federal permits or authorizations are required in order to implement each particular alternative.

Sections 4.6.3 and 4.7.3 (both titled "Replacement Power Alternatives: Common Impacts") describe the types of impacts that terrestrial and aquatic resources would experience under each alternative. Impacts on special status species and habitats would likely be similar in type. However, the magnitude and significance of such impacts could be larger because special status species and habitats are rare and more sensitive to environmental stressors.

As described above under the no-action alternative, the CCS would continue to operate under the no-action alternative regardless of the proposed Turkey Point license renewal because it supports retired fossil fuel Units 1 and 2. FPL plans to continue to use water from the CCS to support the operation of these units in synchronous condenser mode over the course of the proposed subsequent license renewal period, as described in Section 3.1.3, "Cooling and Auxiliary Water Systems." Additionally, fossil fuel Unit 5 would remain in operation and would continue to discharge blowdown to the CCS. CCS conditions could change with implementation of one of the replacement power alternatives because less heat would be discharged to the system. This would potentially reduce evaporation resulting in less saline conditions that would be more favorable to ESA-listed species, such as the American crocodile. On the other hand, CCS flow would likely decrease because Turkey Point Units 3 and 4 would withdraw substantially reduced quantities of water during the shutdown period, and eventually Turkey Point Units 3 and 4 would cease to circulate water through the CCS entirely. This could lead to stagnant conditions, which could lower habitat quality and promote algae growth, both of which could affect ESA-listed species and habitats, such as the American crocodile and its critical habitat. Regardless, FPL would continue CCS restoration activities, as previously described in the discussion of the common impacts of replacement power alternatives on water resources in Section 4.5.3 of this SEIS. The State of Florida requires these activities under FPL's Nutrient Management Plan, which is independent of subsequent license renewal. The CCS would likely continue to provide habitat for foraging and breeding, and restoration activities would benefit species that rely upon the CCS as a source of prey. For instance, CCS berms would continue to provide potential nesting habitat for American crocodiles, and the CCS canals would continue to serve as refuge and a source of prey for this species.

FPL currently implements a crocodile management plan to help improve breeding and nesting habitat and protect American crocodiles on the Turkey Point site. Many portions of this plan are voluntary and not required by any Federal, State, or local permit. During shutdown, FPL would decide whether to stop or continue implementing the crocodile management plan.

4.8.3.1 *New Nuclear Alternative*

The NRC staff did not identify any impacts to special status species and habitats for the new nuclear alternative beyond those discussed in the impacts common to all replacement power alternatives. As described above, the CCS would continue to operate regardless of whether a replacement power alternative is implemented, and the impacts discussed previously that would be associated with continued operation of the CCS would apply to this alternative. Because the NRC would remain the licensing agency under this alternative, the ESA, MSA, and NMSA could require the NRC to consult with the FWS, NMFS, or NOAA, as applicable, prior to issuing a license for the construction and operation of the new plant in order to consider whether the plant would affect any federally listed species, adversely modify or destroy designated critical habitat, result in adverse effects on EFH, if present, or injure sanctuary resources of the Florida Keys National Marine Sanctuary. If the new power plant required a Clean Water Act, Section 404 permit, the USACE may be a cooperating agency for the ESA consultation. Ultimately, the magnitude and significance of adverse impacts on special status species and habitats would depend on the site location and layout, plant design, plant operations, and the special status species and habitats present in the area when the alternative is implemented.

4.8.3.2 *Natural Gas Combined-Cycle Alternative*

The NRC staff did not identify any impacts to special status species and habitats for the natural gas alternative beyond those discussed in the impacts common to all replacement power alternatives. Unlike Turkey Point subsequent license renewal or the licensing of a new nuclear alternative, the NRC does not license natural gas facilities; therefore, the NRC would not be responsible for initiating ESA Section 7 consultation, EFH consultation, or NMSA consultation if special status species or habitats might be adversely affected under this alternative. Other Federal agencies could be responsible for addressing impacts on special status species and habitats depending on the specific permits or licenses that the new plant would require. For instance, if the new power plant required a Clean Water Act, Section 404 permit, the ESA would require the USACE to consider impacts on federally listed species and EFH. If no Federal permits were required, the companies or entities implementing this alternative would be responsible for ensuring that their actions do not jeopardize the continued existence of listed species because the ESA Section 9 take prohibitions apply to both Federal and non-Federal entities. The MSA only requires EFH consultation for Federal actions. Similarly, NMSA consultation only applies to Federal agencies. Therefore, these consultations would be required if a Federal agency, such as the USACE, is involved in the permitting or authorization of this alternative and adverse effects are possible. As described above, the CCS would continue to operate regardless of whether a replacement power alternative is implemented, and the impacts discussed previously that would be associated with continued operation of the CCS would apply to this alternative. Ultimately, the magnitude and significance of adverse impacts on special status species and habitats would depend on the site location and layout, plant design, plant operations, and the special status species and habitats present in the area when the alternative is implemented.

4.8.3.3 *Combination Alternative (Natural Gas Combined-Cycle Alternative and Solar Photovoltaic Generation)*

The NRC staff did not identify any impacts to special status species and habitats for the combination alternative beyond those discussed in the impacts common to all replacement power alternatives and in the natural gas-only alternative. As described above, the CCS would continue to operate regardless of whether a replacement power alternative is implemented, and

the impacts discussed previously that would be associated with continued operation of the CCS would apply to this alternative. The magnitude and significance of adverse impacts on special status species and habitats resulting from this alternative would depend on the site location and layout, plant design, plant operations, and the special status species and habitats present in the area when the alternative is implemented.

4.8.3.4 Cooling Water System Alternative

The NRC staff did not identify any impacts to special status species and habitats for the cooling water system alternative beyond those discussed in the impacts common to all replacement power alternatives. As described above, the CCS would continue to operate regardless of whether cooling towers are constructed to support Turkey Point Units 3 and 4, and the impacts discussed previously that would be associated with continued operation of the CCS would apply to this alternative. To the extent that license amendments would be necessary to authorize cooling towers to dissipate excess heat during plant operation, the NRC would be the licensing agency under this alternative and the ESA, MSA, and/or NMSA would require the NRC to consult with the FWS, NMFS, or NOAA, as applicable, during the staff's review of that alternative. If the cooling water system alternative required a Clean Water Act, Section 404 permit, the USACE could be involved in these consultations. The consultations would determine whether the construction and operation of cooling towers would affect any federally listed species; adversely modify or destroy designated critical habitat; result in adverse effects on EFH, if present; or destroy, cause the loss of, or injure sanctuary resources of the Florida Keys National Marine Sanctuary. Because much of the Turkey Point site is designated as critical habitat for the American crocodile, land clearing and other construction activities could result in adverse impacts to this species and its critical habitat. The indigo snake, which also inhabits the site, could also experience adverse impacts from construction. Other federally listed species could also be affected. Ultimately, the magnitude and significance of adverse impacts on special status species and habitats would depend on the location and layout of the cooling towers, the design of the cooling towers, operational parameters, and the special status species and habitats present in the area when the alternative is implemented. As stated above, the NRC would consult with the FWS and NMFS, as applicable, during the staff's review of the license amendments associated with this alternative to determine the level of impact to ESA-listed species and habitats and to address any identified adverse effects.

4.9 Historic and Cultural Resources

This section describes the potential historic and cultural resources impacts of the proposed action (subsequent license renewal) and alternatives to the proposed action.

4.9.1 Proposed Action

Table 4-2 identifies one site-specific (Category 2) issue related to historic and cultural resources applicable to Turkey Point during the subsequent license renewal term. This issue is analyzed below.

4.9.1.1 Category 2 Issue Related to Historic and Cultural Resources: Historic and Cultural Resources

The National Historic Preservation Act of 1966, as amended (54 U.S.C. 300101 et seq.) (NHPA), requires Federal agencies to consider the effects of their undertakings on historic properties. Issuing a subsequent renewed license to a nuclear power plant is an undertaking

that could potentially affect historic properties. Historic properties are defined as resources included on, or eligible for inclusion on, the National Register of Historic Places (NRHP). The criteria for eligibility are listed in Title 36, "Parks, Forests, and Public Property," of the *Code of Federal Regulations* (36 CFR) Section 60.4, "Criteria for Evaluation," and include (a) association with significant events in history, (b) association with the lives of persons significant in the past, (c) embodiment of distinctive characteristics of a type, period, or method of construction, or (d) sites or places that have yielded, or are likely to yield, important information.

The historic preservation review process (NHPA Section 106) is outlined in regulations issued by the Advisory Council on Historic Preservation (ACHP) in 36 CFR Part 800, "Protection of Historic Properties." In accordance with NHPA provisions, the NRC establishes the undertaking (subsequent license renewal), identifies the appropriate State or Tribal historic preservation officer, and initiates consultation with the appropriate officer. The NRC is required to make a reasonable effort to identify historic properties included in, or eligible for inclusion in, the NRHP in the area of potential effect (APE). The APE for a subsequent license renewal action includes the power plant site, the transmission lines up to the first substation, and immediate environs that may be affected by the subsequent license renewal decision and land-disturbing activities associated with continued reactor operations during the subsequent license renewal term. In addition, the NRC is required to notify the State historic preservation officer if historic properties would not be affected by subsequent license renewal or if no historic properties are present. In Florida, State historic preservation officer responsibilities lie with the Florida Division of Historical Resources.

4.9.1.2 Consultation

In accordance with 36 CFR 800.8, "Coordination with the National Environmental Policy Act," on May 24, 2018, the NRC initiated consultation with the Advisory Council on Historic Preservation, the Florida State historic preservation officer, and the Miami-Dade County Office of Historic Preservation (NRC 2018j). Also, on May 24, 2018, the NRC initiated consultation with the following federally recognized tribes (NRC 2018j) (see Appendix C, "Consultation Correspondence"):

- Miccosukee Tribe of Indians of Florida
- Muscogee (Creek) Nation
- Poarch Band of Creek Indians
- Seminole Tribe of Florida
- Seminole Nation of Oklahoma

In these letters, the NRC provided information about the proposed action, provided its definition of the APE, and indicated that the NHPA review would be integrated with the NEPA process, in accordance with 36 CFR 800.8(c), "Use of the NEPA Process for Section 106 Purposes." The NRC invited participation in the identification and possible decisions concerning historic properties and also invited participation in the scoping process. The Seminole Tribe of Florida stated in correspondence to the NRC that they "have no comments regarding license renewal at this time" (STOF 2018). The Florida State Department, Division of Historic Resources stated in correspondence that since the proposed action will not involve ground disturbance it is "unlikely to affect historic properties" (DHR 2018). The Seminole Nation of Oklahoma requested consultation meetings with the NRC (SNO 2018). The NRC held a teleconference with the Seminole Nation of Oklahoma Tribal historic preservation officer on July 2, 2018 (NRC 2018k). Upon learning that the proposed action pertains to the license renewal of the existing Units 3 and 4 and that the plant uses a system of cooling canals rather than discharging into Biscayne

Bay, the Tribal historic preservation officer did not express concerns regarding the subsequent license renewal of Turkey Point (NRC 2018k). In addition, the Seminole Nation of Oklahoma Tribal historic preservation officer requested a list of flora present at the Turkey Point site; in response, the NRC staff provided a 2017 ecological monitoring survey of the Turkey Point site and vicinity to the Tribe on July 9, 2018 (NRC 2018k). FPL received similar responses from the Florida State historic preservation office, Seminole Nation of Oklahoma, and the Seminole Tribe of Florida regarding the proposed action (FPL 2018h).

Following issuance of the DSEIS, the NRC received comments from the Poarch Band of Creek Indians; the Poarch Band of Creek Indians concurred with the NRC's determination (PBCI 2019). In correspondence, the Florida State Department, Division of Historic Resources concurred that license renewal will not adversely affect known historic properties (DHR 2019).

4.9.1.3 Findings

As described in Section 3.9, "Historic and Cultural Resources," cultural resource surveys conducted within the 9,460-ac (3,828-ha) Turkey Point site did not identify archeological sites and concluded that the site has a low archeological potential. However, as discussed in Section 3.9, during the NRC staff's environmental site audit, NRC staff became aware of three wooden buildings that were part of a Boy Scouts of America camp and a cottage (known as the Ranger House/McGregor Smith Cottage) of potential historic significance on the Turkey Point site that are over 50 years old (FPL 2018h, NRC 2018c). The Boy Scouts structures and the Ranger House/McGregor Smith Cottage have not been evaluated for eligibility for listing in the NRHP. Given the age of the Ranger House/McGregor Smith Cottage (50 years old) and known association with McGregor Smith Cottage, the NRC believes that the cottage is potentially eligible for listing in the NRHP under Criterion b (association with the lives of persons significant in the past). McGregor Smith was known for his involvement with the Boy Scouts of America and environmental conservation; it is possible that onsite Boy Scouts structures were associated with McGregor Smith (FPL 2018m). Similarly, as a result of McGregor Smith's known involvement with the Boy Scouts, the Boy Scouts structures on the Turkey Point site may potentially be eligible for listing in the NRHP under Criterion b.

Within a 6-mi (9.7-km) radius of the site are two properties determined eligible for listing in the NRHP: K-9 cemetery (approximately 5.9 mi (9.5 km) from Turkey Point) and a canal bridge (approximately 3.6 mi (5.8 km) from Turkey Point). During the environmental site audit, the NRC staff observed that Turkey Point is not visible from these two sites due to tree buffers and distance (NRC 2018c).

FPL did not identify subsequent license renewal-related ground-disturbing activities (FPL 2018f; FPL 2018h). Plant operations and maintenance activities necessary to support subsequent license renewal would likely be limited to previously disturbed areas of the site (FPL 2018f). In the event that ground-disturbing activities are required as a result of plant operations and maintenance activities, FPL has administrative controls in place on how to handle unanticipated historical and cultural finds related to potential ground-disturbing activities. If historic and cultural resources are discovered within the project site, FPL will notify Florida's Division of Historical Resources and the FDEP, Southeast District (FPL 2018f). Additionally, FPL provides training sessions for staff that are involved in potential future ground-disturbing activities; the environmental training sessions are intended to familiarize FPL staff with common artifact types and actions to be taken if cultural resources are identified (FPL 2018h).

Based on (1) Tribal input, (2) no new ground disturbance, (3) FPL's administrative controls, and (4) State historic preservation officer input, the NRC staff concludes that subsequent license renewal for Turkey Point Units 3 and 4 would not adversely affect any known historic properties or historic and cultural resources.

4.9.2 No-Action Alternative

Under the no-action alternative, the NRC would not issue subsequent renewed licenses, and FPL would terminate reactor operations on or before the expiration of the current renewed licenses. As a result of facility shutdown, land-disturbing activities or dismantlement are not anticipated as these would be conducted during decommissioning. Therefore, facility shutdown would have no immediate effect on historic properties or historic and cultural resources.

4.9.3 Replacement Power Alternatives: Common Impacts

If construction and operation of replacement power alternatives require a Federal undertaking (e.g., license, permit), the Federal agency would need to make a reasonable effort to identify historic properties within the area of potential effects and consider the effects of their undertakings on historic properties, in accordance with Section 106 of the National Historic Preservation Act (NHPA) of 1966, as amended (54 U.S.C. 300101 et seq.). Historic and cultural resources identified would need to be recorded and evaluated for eligibility for listing on the NRHP. If historic properties are present and could be affected by the undertaking, adverse effects would be assessed, determined, and resolved in consultation with the State historic preservation officer and any Indian tribe that attaches religious and cultural significance to identified historic properties through the Section 106 process.

Construction

Impacts to historic and cultural resources from the construction of replacement power alternatives are primarily related to ground disturbance (land clearing, excavations, etc.). For the new nuclear alternative, natural gas combined-cycle alternative, and the natural gas combined-cycle portion and one installation of the solar photovoltaic portion of the combination alternative, this environmental review assumes that the new facilities would be built on the Turkey Point site. For the solar portion of the combination alternative, this environmental review assumes that three of the new facilities would occur at other sites in Miami-Dade County and/or Broward County. As discussed in Section 3.9.2, "Historic and Cultural Resources," of this SEIS, while a comprehensive cultural resource survey of the entire 9,460-ac (3,828-ha) Turkey Point site has not been conducted, cultural resource surveys that have been completed have concluded that the Turkey Point site has a low archeological potential. Land areas not previously surveyed (onsite and offsite) that are affected by the construction of power alternatives would need to be surveyed to identify and record historic and cultural resources.

Operation

The potential for impacts on historic and cultural resources from the operation of replacement power alternatives would be related to maintenance activities at the site as well as visual impacts that would vary with plant heights and associated exhaust stack or cooling towers. The replacement power alternatives located at the Turkey Point site would be in an industrialized area where tall structures already exist and visible plumes from the Turkey Point Unit 5 cooling towers occur.

4.9.3.1 *New Nuclear Alternative*

Impacts on historic and cultural resources from the construction and operation of a new nuclear alternative would include those common to all replacement power alternatives. The new nuclear alternative would require an estimated 360 ac (240 ha) of land on the Turkey Point site. Within a 6-mi (9.7-km) radius of the site are two offsite properties (at distances of 3.6 mi (5.8 km) and 5.9 mi (9.5 km) from the Turkey Point site) determined to be eligible for listing in the NRHP. The tallest structures would be the containment buildings at approximately 230 feet (70 m). A visible plume would occur from the draft cooling towers, particularly during winter months, which could have a median plume length of 820 feet (250 m) (NRC 2016a). Tall structures and cooling tower plumes that currently exist on the Turkey Point site are not visible from the two NRHP-eligible sites. Given the presence of tree buffers and distance, the NRC staff does not anticipate that the new structures and plumes as a result of the new nuclear alternative would be visible from these offsite NRHP-eligible properties. As discussed in Section 4.9.1.3 of this SEIS, there are historic structures on the Turkey Point site that are potentially eligible for listing on the NRHP. Construction of the new nuclear alternative on or near these structures, however, could be avoided. Depending on where the new nuclear alternative is located within the FPL site, construction and operation of this alternative could introduce additional containment buildings, stacks, and facility support structures and affect the viewshed of these historic structures. However, the Turkey Point site is an industrialized area restricted to the public where tall structures and plumes already exist. Therefore, construction and operation of the new nuclear alternative would be compatible with the current site and not out of character with the current setting.

Given that the Turkey Point site has a low archeological potential, that current site infrastructure use would be maximized, and that avoidance of significant historic resources would be possible, the NRC staff concludes that construction of the new nuclear alternative on the Turkey Point site would not adversely affect historic and cultural resources.

4.9.3.2 *Natural Gas Combined-Cycle Alternative*

Impacts on historic and cultural resources from the construction and operation of a new natural gas alternative would include those common to all replacement power alternatives. The natural gas facility would require an estimated 75 ac (30 ha) for the power block and support facilities and an additional 1,200 ac (490 ha) for a natural gas pipeline. Construction of the natural gas pipeline would use existing utility corridors to the extent possible. Within a 6-mi (9.7-km) radius of the site are two properties (approximately 3.6 mi (5.8 km) and 5.9 mi (9.5 km) from the Turkey Point site) determined to be eligible for listing in the NRHP. The tallest natural gas alternative structure would be the plant stacks at approximately 150-feet tall (46-m). The current Turkey Point containment structures are not visible from the two NRHP-eligible sites. Because the natural gas plant stacks would be shorter than the current Turkey Point containment structures, the NRC staff does not anticipate that the natural gas plant stacks would be visible from the NRHP-eligible sites. A visible plume would occur from the draft cooling towers, particularly during winter months, which could have a median plume length of 820 feet (250 m) (NRC 2016a). However, the NRC staff does not anticipate that the plume would be visible from these offsite NRHP-eligible sites given the presence of tree buffers and distance.

As discussed in Section 4.9.1.3 of this SEIS, there are historic structures on the Turkey Point site that are potentially eligible for listing in the NRHP. Construction of the natural gas alternative on or near these structures, however, could be avoided. Depending on where the

natural gas alternative is located within the FPL site, construction and operation of this alternative would introduce additional containment buildings, stacks, and facility support structures and affect the viewshed of these historic structures. However, the Turkey Point site is an industrialized area, restricted to the public, where tall structures and plumes already exist. Therefore, construction and operation of the natural gas alternative would be compatible with the current site and not out of character with the current setting.

Given that the Turkey Point site has a low archeological potential and that existing infrastructure use would be maximized, including the preferential use of previously disturbed land for the pipeline, the avoidance of significant historic resources would be possible. Therefore, the NRC staff concludes that construction and operation of the natural gas alternative on the Turkey Point site would not adversely affect historic and cultural resources.

4.9.3.3 *Combination Alternative*

Impacts on historic and cultural resources from the construction and operation of the natural gas components of the combination alternative would be the same as the natural gas-only alternative given that land requirement, location, and facility height structures would be the same. Therefore, the NRC staff concludes that construction and operation of the natural gas portion of the combination alternative on the Turkey Point site would not adversely affect historic and cultural resources. As stated in Section 2.2.2.3 of this SEIS, the NRC staff assumes that the solar portion that would be located on the Turkey Point site would maximize use of the existing infrastructure, would have a low visual profile, and would be located on a site that has a low archeological potential. Construction and operation of the solar alternative on or near historic and cultural resources could be avoided. Therefore, construction and operation of the solar component on the Turkey Point site would not adversely affect historic and cultural resources.

Impacts on historic and cultural resources from the construction and operation of the solar portion of the combination alternative would include those common to all replacement power alternatives. The solar portion of the combination alternative would require an estimated 470 ac (190 ha) for each of the four solar facilities. The impacts from the construction and operation of the solar component on historic and cultural resources would vary, depending on where solar facilities are constructed. The three offsite solar facilities would be installed in Miami-Dade and/or Broward Counties, but the exact locations are unknown. Depending on the site and historic and cultural resources present, construction and operation of the solar facilities could alter these resources within the area of potential effect. Areas with the greatest cultural sensitivity could be avoided or effectively managed. Therefore, for these three sites, the historic and cultural resource impact could range from no adverse effect to adverse effect.

4.9.4 *Cooling Water System Alternative*

If construction and operation of the cooling water system alternative were to require NRC licensing actions (e.g., a license amendment), the NRC would need to comply with Section 106 of NHPA consultation requirements. The Section 106 process would be initiated after submission of an application or request from FPL.

Land areas needed to support construction of the mechanical draft cooling towers would need to be surveyed for historic and archeological resources. Any resources found during these surveys would need to be evaluated for their eligibility for listing on the NRHP, and any adverse effects would need to be mitigated. Constructing the cooling towers on previously disturbed

land could reduce the potential impact to historic and archaeological resources. As discussed in Section 3.9.2 of this SEIS, while a comprehensive cultural resource survey of the entire 9,460-ac (3,828-ha) Turkey Point site has not been conducted, cultural resource surveys that have been completed have concluded that the Turkey Point site has a low archeological potential. Within a 6-mi (9.7-km) radius of the site there are two offsite properties (approximately 3.6 mi (5.8 km) and 5.9 mi (9.5 km) from the Turkey Point site) which were determined to be eligible for listing in the NRHP. The cooling towers would be approximately 70 feet (20 m) in height and plumes could be visible during the winter months with a median length of 820 feet (250 m) (NRC 2016a). However, the plume is not anticipated to be visible from these offsite NRHP-eligible sites given the presence of tree buffers and distance.

As discussed in Section 4.9.1.3 of this SEIS, there are historic structures on the Turkey Point site that are potentially eligible for listing in the NRHP. Construction of the cooling towers on or near these structures could be avoided. Depending on where the cooling towers are located within the FPL site, construction and operation of this alternative would introduce additional cooling towers and visible plumes and would affect the viewshed of these historic structures. However, the Turkey Point site is an industrialized area, restricted to the public, where tall structures and visible plumes already exist. Therefore, construction and operation of the cooling towers would be compatible with the current site and not out of character with the current setting.

The Turkey Point site has a low archeological potential and avoidance of construction and operations impacts of the cooling water system alternative to significant historic resources would be possible. The plume from the Turkey Point cooling towers is not anticipated to be visible from offsite historic properties within a 6-mi radius of Turkey Point. Therefore, the NRC staff concludes that construction and operation of the cooling water system alternative on the Turkey Point site would not adversely affect historic and cultural resources.

4.10 Socioeconomics

This section describes the potential socioeconomic impacts of the proposed action (subsequent license renewal) and alternatives to the proposed action.

4.10.1 Proposed Action

According to the GEIS (NRC 2013a), the impacts of license renewal on socioeconomic issues would be SMALL. The NRC staff identified no new or significant information for these issues. Socioeconomic effects of ongoing reactor operations at Turkey Point have become well established as regional socioeconomic conditions have adjusted to the presence of the nuclear power plant. Any changes in employment and tax revenue caused by subsequent license renewal and any associated refurbishment activities could have a direct and indirect impact on community services and housing demand, as well as traffic volumes in the communities around the nuclear power plant. FPL indicated in its environmental report that it has no plans to add non-outage workers during the subsequent license renewal term, does not anticipate changes in tax payments during the subsequent license renewal term, and will not conduct refurbishment activities. Consequently, people living in the vicinity of Turkey Point and in Miami-Dade County are not likely to experience any changes in socioeconomic conditions during the subsequent license renewal term beyond what is currently being experienced under the current renewed licenses.

As identified in Table 4-1 of this SEIS, the socioeconomic impacts of continued reactor operations during the subsequent license renewal term would be SMALL. Table 4-2 of this SEIS does not identify any site-specific (Category 2) socioeconomic issues for Turkey Point.

4.10.2 No-Action Alternative

4.10.2.1 Socioeconomics

Under the no-action alternative, the NRC would not issue subsequent renewed licenses and FPL would shut down Turkey Point on or before the expiration of the current renewed licenses. Termination of nuclear power plant operations would result in cessation of electrical power production and a loss of jobs, income, and tax revenues. Socioeconomic impacts from the termination of reactor operations would be concentrated in Miami-Dade County since the majority of Turkey Point Units 3 and 4 workers reside in this county. Employment and income from the buying and selling of goods and services needed to operate and maintain the nuclear power plant would also be reduced.

As jobs are eliminated, some, but not all, of the total 1,046 FPL workers (permanent and contractors) could begin to leave the region. If FPL workers and their families move out of the region, increased housing vacancies and decreased demand could cause housing prices to fall. However, the FPL workforce that resides in Miami-Dade County (approximately 85 percent of the total Turkey Point permanent workforce) represents only approximately 0.05 percent of Miami-Dade County's 2016 civilian labor force (see Section 3.10.2.1, "Regional Employment and Income"). The remaining FPL workers similarly comprise a very small percentage (less than 0.1 percent) of the civilian labor force in other nearby counties. Therefore, the migration of these workers out of those nearby counties would not have a noticeable socioeconomic impact in those counties.

The loss of tax revenue could result in the reduction or elimination of some public and educational services. However, as noted in Section 3.10.5, "Tax Revenues," FPL property tax payments to Miami-Dade County and Miami-Dade County Public School District as a result of Turkey Point Units 3 and 4 operations represent less than 1 percent of Miami-Dade County total revenues and Miami-Dade County Public School District total revenues. Because Turkey Point is located in a large metropolitan area, socioeconomic impacts from not subsequently renewing the Units 3 and 4 operating licenses and terminating reactor operations would be SMALL.

4.10.2.2 Transportation

Traffic volume as a result of commuting workers and truck deliveries on roads in the vicinity of Turkey Point Units 3 and 4 would be reduced after plant shutdown. The reduction in traffic would be associated with the loss of jobs. Similarly, truck deliveries to Turkey Point would be reduced. Therefore, traffic-related transportation impacts would be SMALL as a result of the shutdown of Turkey Point Units 3 and 4.

4.10.3 Replacement Power Alternatives: Common Impacts

The following provides a discussion of the common socioeconomic and transportation impacts during construction and operation of replacement power generating facilities.

4.10.3.1 Socioeconomics

Socioeconomic impacts are defined in terms of changes in the social and economic conditions of a region. For example, the creation of jobs and the purchase of goods and services during the construction and operation of a replacement power plant could affect regional employment, income, and tax revenue. For each alternative, two types of jobs would be created:

(1) construction jobs, which are transient, short in duration, and less likely to have a long-term socioeconomic impact, and (2) operations jobs, which have the greater potential for permanent, long-term socioeconomic impacts. The socioeconomic region of influence is Miami-Dade County for the new nuclear alternative and natural gas combined-cycle alternative. The socioeconomic region of influence for the combination alternative would be Miami-Dade and Broward counties.

Construction

The relative economic effect of an influx of workers on the local economy and tax revenue would vary and depend on the size of the workforce and construction completion time. The greatest impact would occur in the communities where the majority of construction workers would reside and spend their incomes. While some construction workers would be local, additional workers may be required from outside the immediate area depending on the local availability of appropriate trades and occupational groups. The region of influence could experience a short-term economic boom during construction from increased tax revenue, income generated by expenditures for goods and services, and the increased demand for temporary (rental) housing. After construction, the region of influence would likely experience a return to preconstruction economic conditions.

Operation

Prior to the commencement of startup and operations, local communities could see an influx of operations workers and their families resulting in an increased demand for permanent housing and public services. These communities would also experience the economic benefits from increased income and tax revenue generated by the purchase of goods and services needed to operate a new replacement power plant. Consequently, power plant operations would have a greater potential for effecting permanent, long-term socioeconomic impacts on the region.

4.10.3.2 Transportation

Transportation impacts are defined in terms of changes in level of service conditions on local roads in the region. Additional vehicles on local roadways during construction and operations could lead to traffic congestion, level of service impacts, and delays at intersections.

Construction

Transportation impacts during the construction of a replacement power plant would consist of commuting workers and truck deliveries of equipment and material to the construction site. Workers would arrive via site access roads, and the volume of traffic would increase during shift changes. In addition, trucks would transport equipment and material to the construction site, thus increasing the amount of traffic on local roads. The increase in traffic volumes could result in levels of service impacts and delays at intersections during certain hours of the day. In some instances, construction material could also be delivered by rail or barge.

Operation

Traffic-related transportation impacts would be greatly reduced after construction has been completed. Transportation impacts would include daily commuting by the operations workforce and deliveries of material, and the removal of commercial waste material by truck. Increased commuter traffic would occur during shift changes and deliveries of materials and equipment to the power plant.

4.10.4 New Nuclear Alternative

Socioeconomics

Construction of a new nuclear alternative would require a large workforce, approximately a peak at 3,900 workers. However, peak workforce construction jobs would represent approximately 0.3 percent of employment in Miami-Dade County. Tax revenue increases in the form of sales taxes and property taxes in the region would occur. However, because of the large tax revenue of Miami-Dade County (see Section 3.10.5), the impact on tax revenues during construction, while beneficial, would be relatively minimal. For instance, the NRC staff concluded that the taxes on construction expenses for Turkey Point Units 6 and 7 (estimated between \$12.8 and \$18.7 billion over a 12-year period) corresponded to approximately seven-tenths of 1 percent of Miami-Dade County sales and use tax revenues and 0.5 percent of the State of Florida's corporate income and excise tax revenues (NRC 2016a). As presented in Section 3.10.3.1, "Transient Population," and 3.10.4.1, "Housing," Miami-Dade County has available vacant rental units and housing to support a 3,900 peak construction workforce. Increases in property tax revenue are not anticipated during construction since property taxes due to the new nuclear units would not occur until after construction is completed (NRC 2016a). As a result of the construction workforce, service or retail-related jobs would be indirectly created (NRC 2016a). The NRC staff estimated that peak construction annual wage earnings of a workforce of 3,950 for Turkey Point Units 6 and 7 and indirect jobs would be less than eight-tenths of 1 percent of total annual wage earnings in Miami-Dade County (NRC 2016a). The construction of a new nuclear power plant would create a large number of jobs (directly and indirectly) and the socioeconomic impacts would be beneficial. The large workforce and jobs would be noticeable to the local communities in and near Homestead, FL. Therefore, the socioeconomic impacts from construction of a new nuclear alternative are SMALL to MODERATE.

Approximately 800 workers would be required during nuclear power plant operations, which would represent approximately 0.05 percent of the jobs in Miami-Dade County. Salary earnings of the workforce would be introduced into the Miami-Dade County economy, but they would not be noticeable. For instance, the NRC staff estimated that annual earnings of 806 operation workers for Turkey Point Units 6 and 7 would be a tenth of one percent of total wage earnings in Miami-Dade County (NRC 2016a). Tax revenues would increase as a result of operations of the new nuclear alternative. However, revenue generated by sales taxes and property taxes from operations of a new nuclear alternative would be minor. For instance, the NRC staff concluded that sales from operation of the proposed Turkey Point Units 6 and 7 would generate up to \$2 million in sales tax and \$50.4 million in property taxes. When compared to Miami-Dade County tax revenues (see Section 3.10.5, "Tax Revenues"), this is a small percentage. Furthermore, the number of operational and outage workers for a new nuclear alternative, property tax revenue, sales tax revenue, and the socioeconomic impacts would be similar to those currently experienced for Units 3 and 4. Therefore, the socioeconomic impacts from operating of a new nuclear power plant would be SMALL.

Transportation

During periods of peak construction activity, up to 3,900 workers would be commuting daily to the construction site. Workers commuting to the site and delivery vehicles would arrive via site access roads and the volume of traffic on nearby roads would increase substantially. The increase in vehicular traffic would peak during shift changes and during the peak building workforce use, resulting in temporary levels of service impacts and delays at intersections. In addition to the workforce, delivery vehicles transporting construction material would also use roads in the vicinity. A traffic study found that an additional 3,650 peak construction workforce and delivery vehicles for construction of Turkey Point Units 6 and 7 would not result in the exceedance capacity of local roads (along Palm Drive/SW 344th, SW 328th St, and SW 312th St) in the vicinity of the Turkey Point site; however, in order to maintain an adequate level of service for these roads, road improvements (additional turn lanes, roadway widening) would need to be implemented (Traf Tech 2009). Therefore, additional vehicles as a result of construction would noticeably alter traffic on roads in the vicinity Turkey Point, result in a loss of service for the nearby roads, and, without mitigation measures, would destabilize the transportation infrastructure. Therefore, the impact on transportation infrastructure in the immediate vicinity of the Turkey Point site during construction of a new nuclear power plant would be LARGE.

Approximately 800 workers would be commuting daily to the Turkey Point site during operations. Traffic on roadways would peak during shift changes and refueling outages, resulting in temporary levels of service impacts and delays at intersections. However, the operational and outage workforce would be similar to Turkey Point and the transportation impacts for a new nuclear alternative would be similar to what is currently being experienced as a result of operation for Units 3 and 4. Therefore, transportation impacts in the immediate vicinity of the Turkey Point site during nuclear power plant operations for the new nuclear alternative would be SMALL.

4.10.5 Natural Gas Combined-Cycle Alternative

Socioeconomics

Socioeconomic impacts would result from the approximately 1,200 construction workers and 150 workers to operate the natural gas alternative. Overall, the size of the workforce for both construction and operations would be smaller than the new nuclear alternative. The natural gas alternative would require 75 ac (30 ha) for the power block. While the natural gas alternative power block would require less land than Turkey Point, an additional 1,200 ac (490 ha) would be needed for right-of-way to connect with an existing natural gas supply line. This could result in additional property tax revenue. However, given Miami-Dade County's large funding source revenues (see Section 3.10.5 for a discussion of Miami-Dade County property tax revenues), additional property tax revenue from the natural gas alternative is not anticipated to be noticeable. The capital costs of a natural gas-fired power plant, the building and operations workforces, and the local expenditures on materials and equipment are lower at a natural-gas plant than those of a nuclear facility (EIA 2016d, EIA 2017f). Therefore, these impacts would be similar but of lesser magnitude than the new nuclear alternative. Therefore, the socioeconomic impacts from construction and operation of a natural gas alternative would be SMALL.

Transportation

Traffic-related impacts would result from the 1,200 construction workers and 150 workers during operation of the natural gas alternative, as well as delivery vehicles. The construction workforce

for a natural gas-fired power plant would be less than the construction and operational workforce (when considering refueling outage workers) for a new nuclear alternative. The NRC staff concludes that the transportation impacts in the immediate vicinity of the Turkey Point site from construction would be noticeable, but not destabilizing, and therefore MODERATE.

The operations workforce for the natural gas alternative would be substantially less than the operations workforce of a new nuclear alternative. While there would be some increase in traffic in the vicinity of the Turkey Point site for the natural-gas plant during operation, that increase would be less than the increase for the new nuclear alternative. Additionally, worker vehicles from operation of the natural gas alternative would be less than what is experienced from operation of Turkey Point. The NRC staff concludes that the transportation impacts in the immediate vicinity of the Turkey Point site from operation would be SMALL.

Therefore, the NRC staff concludes that, overall, the transportation impacts in the immediate vicinity of the Turkey Point site from constructing and operating the natural gas alternative would range from SMALL to MODERATE.

4.10.6 Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)

Socioeconomics

The workforce required to construct and operate the natural gas portion of the combination alternative and land requirements would be similar to the full-power natural gas-only alternative discussed in Section 4.10.5 since the natural gas unit under the combination alternative would be approximately 95 percent of that of the natural gas-only alternative. Therefore, the NRC staff concludes that the socioeconomic impacts from construction and operations of the natural gas portion of the combination alternative would be SMALL.

Installation of the solar portion of the combination alternative would require up to 200 construction workers. Miami-Dade County's regional employment, tax revenue, and housing is discussed in Chapter 3, "Affected Environment." Broward County has a civilian labor force of approximately 997,404 individuals and 143,898 vacant housing units (USCB 2016h). In 2017, Broward County's property tax revenue was \$0.929 billion, and its total operating revenue was \$4.704 billion (Broward County 2017). A construction workforce of 200 would not result in a noticeable or substantial increase in housing demand, jobs, or wages given Miami-Dade and Broward counties' available housing and labor force. Additionally, local expenditures for goods and expenditures for construction of the solar portion would not result in noticeable tax revenue given both Miami-Dade and Broward counties' large funding source revenues. Therefore, the socioeconomic impacts from constructing the solar portion would be SMALL.

A small number of workers would be needed to maintain and operate the solar systems (10 workers). This would not result in a noticeable or substantial increase in housing demand, jobs, or wages. Operation of solar systems would generate tax revenue from operation expenditures and the large amount of land required to support this alternative (total of 1,410 ac). However, Miami-Dade and Broward counties both have large funding source revenues. The additional tax revenue from operation of solar units is not anticipated to be noticeable given both counties' revenues. Therefore, the socioeconomic impacts from operation of the solar portion of the combination alternative would be SMALL.

Transportation

Traffic-related impacts for the natural gas portion of the combination alternative would result from worker and delivery vehicles. Since the workforce required to construct and operate the natural gas power plant component of the combination alternative would be approximately the same as the natural gas-only alternative discussed in Section 4.10.5, the NRC staff concludes that the overall transportation impacts in the immediate vicinity of the Turkey Point site from constructing and operating the natural gas portion of the combination alternative would be SMALL to MODERATE.

In addition to delivery vehicles, the solar component of the combination alternative would require an estimated 200 workers during construction and 10 workers during operation. The construction and operations workforce would not result in a substantial increase in traffic in the vicinity of the Turkey Point site. An additional 200 worker vehicles during construction at the two additional sites in Broward County could be noticeable depending on the exact location of the sites and access roads and result in level of service changes and therefore impacts could be SMALL to MODERATE. However, an additional 10 worker vehicles during operations is not anticipated to have noticeable changes in traffic; the transportation impacts from operation of the solar portion of the combination alternative would be SMALL. Therefore, the staff concludes that the overall transportation impacts from constructing and operating the solar component of the combination alternative would be SMALL to MODERATE.

4.10.7 Cooling Water System Alternative

4.10.7.1 Socioeconomics

Site preparation, necessary plant modifications, and cooling tower installation would result in short-term employment increases. The workforce necessary to construct a closed-cycle mechanical-draft cooling tower system at Turkey Point is unknown. Construction workforce estimates on the construction of cooling tower technologies have been prepared for other nuclear power plants. A mechanical-draft cooling tower system consisting of two cooling tower units at the Oyster Creek Nuclear Generating Station (single unit) was estimated to require 100 workers during non-peak construction months (NRC 2006b). Bechtel (2014) estimated that for a closed-cycle cooling alternative (consisting of two wet mechanical draft cooling towers per unit) at Diablo Canyon Power Plant, approximately 1,117 construction workers (585 workers per shift and 2 work shifts) would be needed. Based on these estimates, construction of cooling towers at Turkey Point could require approximately between 200 and 1,110 construction workers.

The majority of construction workers would relocate temporarily to Miami-Dade County, resulting in a short-term increase in the population and increased demand for temporary housing. However, given Miami-Dade County's population and available housing (see Sections 3.10.3, 3.10.3.1, and 3.10.4) an additional 1,110 construction workers would not result in a noticeable increase in population or shortages in temporary housing. Estimated cooling tower construction costs for Turkey Point Units 3 and 4 have varied and ranged from \$323.5 million to \$1.84 billion (High Bridge Associates undated). For purposes of estimating the tax benefits from constructing the cooling towers in this socioeconomic analysis, the NRC staff used the construction cost (\$12.8 billion to \$18.7 billion) of the new nuclear alternative discussed in Section 4.10.4 as a bounding analysis for the construction of the cooling water system alternative. As discussed in Section 4.10.4, increases in corporate income and excise taxes, sales taxes, and wages as a result of construction would be beneficial but relatively minor.

Furthermore, the construction workforce for the cooling water system alternative is one third of the new nuclear alternative construction workforce. Therefore, the socioeconomic impacts of constructing the cooling water system alternative would be SMALL.

Once the construction of the closed-cycle cooling towers and plant modifications has been completed, the size of the workforce at Turkey Point would return to normal. A small number of additional workers would likely be needed to maintain and monitor the cooling towers. At Oyster Creek Nuclear Generating Station (single unit), an additional 25 employees were estimated to be needed for operation of the closed-cycle cooling system (NRC 2006b). Therefore, 50 additional operations workers would be a reasonable estimate for the number of additional employees needed at Turkey Point Units 3 and 4. This would result in no noticeable increase in population or housing demand. Annual property taxes could increase with an increased assessed value of Turkey Point with the addition of the cooling water system alternative. However, additional revenue generated from operating the cooling water system alternative would not be noticeable. Therefore, the socioeconomic impacts of operating the cooling water system alternative would be SMALL.

4.10.7.2 Transportation

Transportation impacts associated with the construction and operation of the cooling water system alternative would consist of commuting workers and truck deliveries of construction materials to the Turkey Point site. Construction of the cooling water system alternative at Turkey Point could require up to 1,110 construction workers. The increase in vehicular traffic would peak during shift changes, resulting in temporary levels of service impacts and delays on local roads and at intersections. Up to 1,110 construction workers, in addition to the existing Turkey Point Units 3 and 4 workforce, commuting to the site would noticeably increase traffic on the roads. Therefore, transportation impacts in the immediate vicinity of the Turkey Point site during construction of the cooling towers could range from SMALL to MODERATE and would depend on the number of worker vehicles and truck deliveries. Once the construction of the cooling towers and plant modifications has been completed, the size of the workforce and truck deliveries would return to normal. A small number of additional workers may be needed to maintain and monitor the cooling towers. Operation of the closed-cycle cooling system would have little to no effect on transportation infrastructure and, therefore, transportation impacts would be SMALL.

Overall, transportation impacts in the immediate vicinity of the Turkey Point site from the construction and operation of the cooling water system alternative could range from SMALL to MODERATE.

4.11 Human Health

This section describes the potential human health impacts of the proposed action (subsequent license renewal) and alternatives to the proposed action.

4.11.1 Proposed Action

According to the GEIS (NRC 1996 and NRC 2013a), the generic issues related to human health as identified in Table 4-1 would have SMALL impacts resulting from license renewal. As discussed in Chapter 3, the NRC staff identified no new and significant information for these issues. Thus, as concluded in the GEIS, the impacts of those generic issues related to human health would be SMALL.

Table 4-2 identifies one uncategorized issue (chronic exposure to electromagnetic fields) and one site-specific (Category 2) issue (electric shock hazards) related to human health applicable to Turkey Point subsequent license renewal. These issues are analyzed below.

4.11.1.1 Uncategorized Issue Relating to Human Health: Chronic Effects of Electromagnetic Fields (EMFs)

The GEIS (NUREG-1437) (NRC 2013a) does not designate the chronic effects of 60-Hz electromagnetic fields (EMFs) from power lines as either a Category 1 or Category 2 issue. Until a scientific consensus is reached on the health implications of electromagnetic fields, the NRC will not include them as Category 1 or 2 issues.

The potential for chronic effects from these fields continues to be studied and is not known at this time. The National Institute of Environmental Health Sciences (NIEHS) directs related research through the DOE.

The report by the National Institute of Environmental Health Sciences, "NIEHS Report on Health Effects from Exposure to Power-Line Frequency Electric and Magnetic Fields" (NIEHS 1999), contains the following conclusion:

The NIEHS concludes that ELF-EMF [extremely low frequency-electromagnetic field] exposure cannot be recognized as entirely safe because of weak scientific evidence that exposure may pose a leukemia hazard. In our opinion, this finding is insufficient to warrant aggressive regulatory concern. However, because virtually everyone in the United States uses electricity and therefore is routinely exposed to ELF-EMF, passive regulatory action is warranted such as continued emphasis on educating both the public and the regulated community on means aimed at reducing exposures. The NIEHS does not believe that other cancers or non-cancer health outcomes provide sufficient evidence of a risk to currently warrant concern.

This statement was not sufficient to cause the NRC to change its position with respect to the chronic effects of electromagnetic fields. The NRC staff considers the GEIS finding of "UNCERTAIN" still appropriate and will continue to follow developments on this issue.

4.11.1.2 Category 2 Issue Related to Human Health: Electric Shock Hazards

Based on the GEIS (NUREG-1437) (NRC 2013a), the Commission found that electric shock resulting from direct access to energized conductors or from induced charges in metallic structures has not been identified to be a problem at most operating plants and generally is not expected to be a problem during the subsequent license renewal term. However, a site-specific review is required to determine the significance of the electric shock potential along the portions of the transmission lines that are within the scope of the Turkey Point subsequent license renewal review.

As discussed in Section 3.11.4, "Electromagnetic Fields," there are no offsite transmission lines that are in scope for this SEIS. Therefore, there are no potential impacts to members of the public.

As discussed in Section 3.11.5, "Other Hazards," Turkey Point maintains an occupational safety program for its workers in accordance with Occupational Safety & Health Administration

regulations, which includes protection from acute electric shock. Therefore, the NRC staff concludes that the potential impacts from acute electric shock during the subsequent license renewal term would be SMALL.

4.11.1.3 Environmental Consequences of Postulated Accidents

The GEIS (NUREG-1437) (NRC 2013a) evaluates the following two classes of postulated accidents as they relate to license renewal:

- Design-Basis Accidents: Postulated accidents that a nuclear facility must be designed and built to withstand without loss to the systems, structures, and components necessary to ensure public health and safety.
- Severe Accidents: Postulated accidents that are more severe than design-basis accidents because they could result in substantial damage to the reactor core, whether or not there are serious off-site consequences.

As shown in Table 4-1, the GEIS (NRC 2013a) addresses design-basis accidents as a Category 1 issue and concludes that the environmental impacts of design-basis accidents are of SMALL significance for all nuclear power plants.

As shown in Table 4-2, the GEIS designates severe accidents as a Category 2 issue requiring site-specific analysis. Based on information in the 2013 GEIS, the NRC determined in 10 CFR Part 51 that for all nuclear power plants, the probability-weighted consequences of severe accidents associated with license renewal are SMALL, with a caveat:

The probability-weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to groundwater, and societal and economic impacts from severe accidents are small for all plants. However, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives. (NRC 2013a)

As part of its initial license renewal application submitted in 2000, FPL's environmental report included an assessment of severe accident mitigation alternatives (SAMAs) for Turkey Point (FPL 2000). During its review of FPL's initial license renewal application, the NRC staff performed a site-specific analysis of Turkey Point SAMAs and documented its findings in a supplement to the GEIS (Supplement 5, "Regarding Turkey Point Nuclear Plant, Units 3 & 4," to NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants") (NRC 2002c). Because the staff has previously considered SAMAs for Turkey Point Units 3 and 4, FPL is not required to perform another SAMA analysis as part of its subsequent license renewal application (10 CFR 51.53(c)(3)(ii)(L)).

However, the NRC's regulations in 10 CFR Part 51, which implement Section 102(2) of the National Environmental Policy Act of 1969, as amended (NEPA), require that all applicants for license renewal submit an environmental report to the NRC and in that report identify any "new and significant information regarding the environmental impacts of license renewal of which the applicant is aware" (10 CFR 51.53(c)(3)(iv)). This includes new and significant information that could affect the environmental impacts related to postulated severe accidents or that could affect the results of a previous SAMA assessment. Accordingly, in its subsequent license renewal application environmental report, FPL evaluated areas of new and potentially significant information that could affect the environmental impact of postulated severe accidents during the

subsequent license renewal period. The NRC staff provides a discussion of new information pertaining to SAMAs in Appendix E, “Environmental Impacts of Postulated Accidents,” in this SEIS.

Based on the NRC staff’s review and evaluation of FPL’s analysis of new and potentially significant information regarding SAMAs and the staff’s independent analyses as documented in Appendix E, “Environmental Impacts of Postulated Accidents,” to this SEIS, the staff finds that there is no new and significant information for Turkey Point related to SAMAs.

4.11.2 No-Action Alternative

Under the no-action alternative, the NRC would not issue subsequent renewed licenses, and Turkey Point would shut down on or before the expiration of the current renewed licenses. Human health risks would be smaller following plant shutdown. The reactor units, which currently operate within regulatory limits, would emit less radioactive gaseous, liquid, and solid material to the environment. In addition, following shutdown, the variety of potential accidents at the plant (radiological or industrial) would be reduced to a limited set associated with shutdown events and fuel handling and storage. In Section 4.11.1, “Proposed Action,” the NRC staff concluded that the impacts of continued plant operation on human health would be SMALL, except for “Chronic effects of electromagnetic fields (EMFs),” for which the impacts are UNCERTAIN. In Section 4.11.1.3, “Environmental Consequences of Postulated Accidents,” the NRC staff concluded that the impacts of accidents during operation are SMALL. Therefore, as radioactive emissions to the environment decrease, and as the likelihood and types of accidents decrease following shutdown, the NRC staff concludes that the risk to human health following plant shutdown would be SMALL.

4.11.3 Replacement Power Alternatives: Common Impacts

Impacts on human health from construction of a replacement power station would be similar to impacts associated with the construction of any major industrial facility. Compliance with worker protection rules, the use of personal protective equipment, training, and placement of engineered barriers would limit those impacts on workers to acceptable levels.

The human health impacts from the operation of a power station include public risk from inhalation of gaseous emissions. Regulatory agencies, including the EPA and Florida State agencies, base air emission standards and requirements on human health impacts. These agencies also impose site-specific emission limits to protect human health.

4.11.4 New Nuclear Alternative

The construction impacts of the new nuclear alternative would include those identified in Section 4.11.3 above. Since the NRC staff expects that the licensee would limit access to active construction areas to only authorized individuals, the impacts on human health from the construction of the new nuclear alternative would be SMALL.

The human health effects from the operation of the new nuclear alternative would be similar to those of operating the existing Turkey Point Units 3 and 4. As presented in Section 4.11.1, impacts on human health from the operation of Turkey Point would be SMALL, except for “chronic effects of electromagnetic fields (EMFs),” for which the impacts are UNCERTAIN. Therefore, the NRC staff concludes that the impacts on human health from the operation of the new nuclear alternative would be SMALL.

4.11.5 Natural Gas Combined-Cycle Alternative

The construction impacts of the natural gas alternative would include those identified in Section 4.11.3, "Replacement Power Alternatives: Common Impacts," as common to the construction of all replacement power alternatives. Since the NRC staff expects that the builder will limit access to the active construction area to only authorized individuals, the impacts on human health from the construction of the natural gas alternative would be SMALL.

The human health effects from the operation of the natural gas alternative would include those identified in Section 4.11.3 as common to the operation of all replacement power alternatives. Health risk may be attributable to nitrogen oxide emissions that contribute to ozone formation (NRC 2013a). Given the regulatory oversight exercised by the EPA and State agencies, the NRC staff concludes that the human health impacts from the natural gas alternative would be SMALL.

4.11.6 Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)

Impacts on human health from construction of the combination natural gas and solar alternative would include those identified in Section 4.11.3 as common to the construction of all replacement power alternatives. Since the NRC staff expects that the builder will limit access to the active construction area to only authorized individuals, the impacts on human health from the construction of the combination natural gas and solar alternative would be SMALL.

Operational hazards at a natural gas facility are discussed in Section 4.11.5, "Natural Gas Combined-Cycle Alternative."

Solar photovoltaic panels are encased in heavy-duty glass or plastic. Due to this, there is little risk that the small amounts of hazardous semiconductor material that they contain will be released into the environment. In the event of a fire, hazardous particulate matter could be released to the atmosphere. Given the short duration of fires and the high melting points of the materials found in the solar photovoltaic panels, the impacts from inhalation are minimal. Also, the risk of fire at ground-mounted solar installations is minimal due to precautions taken during site preparation, such as the removal of fuels and the lack of burnable materials contained in the solar photovoltaic panels. Another potential risk associated with photovoltaic systems and fire is the potential for shock or electrocution from contact with a high voltage conductor. Proper procedures and clear marking of system components should be used to provide emergency responders with appropriate warnings to diminish the risk of shock or electrocution (OIPP 2010).

Photovoltaic solar panels do not produce electromagnetic fields at levels considered harmful to human health as established by the International Commission on Non-Ionizing Radiation Protection. These small electromagnetic fields diminish significantly with distance and are indistinguishable from normal background levels within several yards (OIPP 2010).

Therefore, given the expected compliance with worker and environmental protection rules and the use of personal protective equipment, training, and engineered barriers, the NRC staff concludes that the potential human health impacts for the combination natural gas and solar alternative would be SMALL.

4.11.7 Cooling Water System Alternative

The impacts of the cooling water system alternative would be similar to those identified in Section 4.11.3, "Replacement Power Alternatives: Common Impacts," as common to all alternatives. Limiting access to the active construction area to only authorized individuals is expected.

The human health effects from the operation of the cooling water system alternative would include microbiological organisms and exposure to any biocides added to the system to limit the growth of those microbiological organisms. The GEIS (NUREG-1437) evaluation of health effects from plants with cooling systems discusses the potential hazard to workers from microbiological organisms inhabiting the system whose presence might be enhanced by the thermal conditions found in the cooling system. The microbiological organisms of concern are freshwater organisms that are present at sites that use cooling ponds, lakes, or canals and that discharge to small rivers (NRC 2013a). These concerns would not apply to the cooling water system alternative at Turkey Point, which would be closed cycle, would use treated, reclaimed wastewater, and would not be accessible by members of the public. Also, the cooling system would contain cooling water treatment and conditioning chemical residuals (e.g., biocides, corrosion inhibitors) necessary for proper operation, maintenance, and microorganism control of the cooling towers and Turkey Point circulating water system. Incoming makeup water for the cooling water system alternative will be treated reclaimed wastewater that will be stored in an onsite reservoir. FPL has procedures onsite for the safe handling of any chemical usage for operations, and any chemical use for the cooling water alternative is expected to be added to these procedures. Also, the NRC staff assumes that any blowdown produced by the cooling towers would be disposed of by deep well injection into the Boulder Zone, which would be regulated under a Class I underground injection control permit issued by the FDEP (FAC 62-528).

In consideration of the information and assumptions presented above, the NRC staff concludes that the impacts on human health from the construction and operation of the cooling water system alternative would be SMALL.

4.12 Environmental Justice

In Section 3.12, "Environmental Justice," of this SEIS, the NRC staff explains the basis for its consideration of environmental justice impacts in an EIS and identifies environmental justice populations (i.e., minority and low-income populations) within a 50-mi (80-km) radius of Turkey Point. In this section, the staff describes the potential human health and environmental effects of the proposed action (subsequent license renewal) and alternatives to the proposed action on minority and low-income populations.

4.12.1 Proposed Action

The NRC addresses environmental justice matters for license renewal (including subsequent license renewal) by (1) identifying the location of minority and low-income populations that may be affected by the continued operation of the nuclear power plant during the subsequent license renewal term, (2) determining whether there would be any potential human health or environmental effects to these populations or to special pathway receptors (groups or individuals with unique consumption practices and interactions with the environment), and (3) determining whether any of the effects may be disproportionately high and adverse. Adverse health effects are measured in terms of the risk and rate of fatal or nonfatal adverse

impacts on human health. Disproportionately high and adverse human health effects occur when the risk or rate of exposure to an environmental hazard for a minority or low-income population is significant and exceeds the risk or exposure rate for the general population or for another appropriate comparison group. Disproportionately high environmental effects refer to impacts or risks of impacts on the natural or physical environment in a minority or low-income community that are significant and appreciably exceed the environmental impact on the larger community. Such effects may include biological, cultural, economic, or social impacts.

Figure 3-38 and Figure 3-39 show the location of predominantly minority and low-income population block groups residing within a 50-mi (80-km) radius of Turkey Point. This area of impact is consistent with the 50-mi (80-km) impact analysis for public and occupational health and safety. This chapter (Chapter 4) of the SEIS presents the assessment of environmental and human health impacts for each resource area. The analyses of impacts for environmental resource areas indicated that groundwater use conflicts would be SMALL to MODERATE because FPL's continued operation of its Upper Floridan aquifer production wells is likely to affect offsite well systems by increasing drawdown in the aquifer. However, as discussed in Section 4.5.1.2.2 of this SEIS, while projected drawdowns would noticeably affect the Upper Floridan aquifer, FPL's continued withdrawals would not be likely to destabilize the groundwater resource or impair the use by other users and well systems during the subsequent license renewal period. Therefore, these impacts would not be high and adverse. Additionally, the staff's analysis identified SMALL to MODERATE impacts for impingement and entrainment of aquatic organisms and thermal impacts on aquatic organisms in the CCS. As discussed in Section 4.7.1.1, the impacts are unlikely to create effects great enough to destabilize important attributes of the aquatic environment over the course of the subsequent license renewal term because the CCS aquatic community is composed of common species that exhibit no unique ecological value or niche and have no commercial or recreational value. The SMALL to MODERATE finding applies to only those aquatic resources occurring in the CCS, to which the public has no access. Impingement and entrainment and thermal effects do not apply to aquatic organisms inhabiting Biscayne Bay or other natural waterbodies because there are no surface water connections that allow flow between these waters and the CCS. Therefore, the impacts on aquatic resources would not be disproportionately high and adverse.

Potential impacts on minority and low-income populations (including migrant workers or Native Americans) would mostly consist of socioeconomic and radiological effects; however, radiation doses from continued operations during the subsequent license renewal term are expected to continue at current levels and would remain within regulatory limits. Section 4.11.1.3, "Environmental Consequences of Postulated Accidents," discusses the environmental impacts from severe accidents that might occur during the subsequent license renewal term. The Commission has determined that the probability-weighted consequences of severe accidents are SMALL. Therefore, these impacts would not be high and adverse.

Subsistence Consumption of Fish and Wildlife

As part of addressing environmental justice concerns associated with subsequent license renewal, the NRC staff assessed the potential radiological risk to special population groups (such as migrant workers or Native Americans) from exposure to radioactive material received through their unique consumption practices and interactions with the environment, including the subsistence consumption of fish, wildlife, and native vegetation; contact with surface waters, sediments, and local produce; absorption of contaminants in sediments through the skin; and inhalation of airborne radioactive material released from the plant during routine operation. The special pathway receptors analysis is an important part of the environmental justice analysis

because consumption patterns may reflect the traditional or cultural practices of minority and low-income populations in the area. The results of this analysis are presented here.

Section 4-4 of Executive Order 12898, "Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations" (59 FR 7629), directs Federal agencies, whenever practical and appropriate, to collect and analyze information about the consumption patterns of populations that rely principally on fish and wildlife for subsistence and to communicate the risks of these consumption patterns to the public. As part of the environmental review pertaining to the proposed new Turkey Point Units 6 and 7, the NRC staff concluded that subsistence activities are typically not conducted by minority or low-income populations in the vicinity of Turkey Point (NRC 2016a). As noted in Section 3.12 of this SEIS, according to the Census Bureau's 2010 Census data, the largest minority population residing within a 50-mi (80-km) radius of Turkey Point is Hispanic or Latino of any race (approximately 55 percent). In an effort to overcome potential language barriers and engage Hispanic or Latino populations at the scoping and draft SEIS public meetings for Turkey Point Units 3 and 4, the NRC staff provided paper copies of the presentation material in Spanish, and an NRC Spanish speaking representative was available at the public meetings to address questions from members of the public. Unique patterns of consumption of natural resources were not identified during the scoping process or in draft SEIS public meetings or comments. In this SEIS, the NRC staff considered whether there were any means for minority or low-income populations to be disproportionately affected by examining impacts on American Indians, Hispanics, migrant workers, and other traditional lifestyle special pathway receptors. The assessment of special pathways considered the levels of radiological and non-radiological contaminants in fish, sediments, water, milk, and food products on or near Turkey Point.

Radionuclides released to the atmosphere may deposit on soil and vegetation and may therefore eventually be incorporated into the human food chain. To assess the impact of Turkey Point operations to humans from the ingestion pathway, FPL collects and analyzes samples of air, water, sediment, fish, vegetation, and milk, if available, for radioactivity as part of its ongoing, comprehensive Radiological Environmental Monitoring Program.

To assess the impact of nuclear power plant operations on the environment, FPL collects samples annually from the environment and analyzes the samples for radioactivity. Two types of samples are collected. The first type, a control sample, is collected from areas that are beyond the influence of the nuclear power plant or any other nuclear facility. These control samples are used as reference data to determine normal background levels of radiation in the environment. The second type of samples, indicator samples, are collected near the nuclear power plant from areas where any radioactivity contribution from the nuclear power plant will be at its highest concentration. These indicator samples are then compared to the control samples to evaluate the contribution of nuclear power plant operations to radiation or radioactivity levels in the environment. An effect would be indicated if the radioactivity levels detected in an indicator sample were higher than the control sample or background levels.

FPL collected air samples and samples from the aquatic, and terrestrial environment near Turkey Point in 2017. The aquatic pathways sampled include surface water, shoreline sediment, and fish.

Aquatic monitoring results for 2017 were consistent with previous levels and, except for tritium in surface and groundwater, yielded no indication of nuclides attributable to Turkey Point operation. Tritium was reported in surface and groundwater samples. Tritium concentrations in water samples were below reporting limits as specified by Turkey Point's Offsite Dose

Calculation Manual (30,000 pCi/L) and EPA's public drinking water standard (20,000 pCi/L) (FPL 2013a, FPL 2018j, 40 CFR 141.66). Tritium occurs in underlying groundwater beneath the CCS as well as in adjacent areas beneath the Turkey Point plant complex. Because the canals comprising the CCS are not lined, CCS water containing tritium migrates into the groundwater of the underlying Biscayne aquifer. Sections 3.5.2.2 and 4.5.1.2 of this SEIS discuss groundwater tritium levels in the vicinity of the Turkey Point site and Turkey Point's Groundwater Protection Program in greater detail. As stated in Section 4.5.1.2, at no location outside the boundary of the Turkey Point site do tritium levels in groundwater approach the EPA and State primary drinking water standard for tritium (20,000 pCi/L), while the highest tritium levels in offsite monitoring wells near the site were at 15 percent of the standard.

Terrestrial monitoring results for 2017 of broad leaf vegetation were consistent with previous levels. Cesium-137 was detected in samples collected and it was below reporting limits as specified by Turkey Point's Offsite Dose Calculation Manual. Cesium-137 could be associated with fallout from past atmospheric nuclear weapons and reactor accidents (FPL 2018j). Milk samples were not available for testing.

Based on the radiological environmental monitoring data from Turkey Point, special pathway receptor populations in the region are not expected to experience disproportionately high and adverse human health impacts as a result of subsistence consumption of water, local food, fish, and wildlife.

4.12.2 No-Action Alternative

Under the no-action alternative, the NRC would not issue subsequent renewed licenses, and Turkey Point would shut down on or before the expiration of the current renewed licenses. Impacts on minority and low-income populations would include loss of jobs, reduction in tax revenue, and potentially a reduction in public services. A decrease in the availability of services could disproportionately affect minority and low-income populations that may have become dependent on these services. However, as discussed in Section 4.10.2, "No-Action Alternative," of this SEIS, because of the large population, labor force, and tax revenue of Miami-Dade County, the socioeconomic impacts from not issuing the subsequent renewed licenses and terminating reactor operations at Turkey Point would be SMALL. Therefore, under the no-action alternative, the effects to minority and low-income populations would not be disproportionately high and adverse.

4.12.3 Replacement Power Alternatives: Common Impacts

Construction

Potential impacts to minority and low-income populations from the construction of a new replacement power plant would mostly consist of environmental and socioeconomic effects (e.g., noise, air emissions, traffic, employment, and housing impacts). Figure 3-38 and Figure 3-39 show the location of predominantly minority and low-income population block groups residing within a 50-mi (80-km) radius of Turkey Point. Minority and low-income populations residing along site access roads could be affected by increased truck traffic and increased commuter vehicle traffic, especially during shift changes. However, a 2017 land-use survey within a 5-mi radius of Turkey Point identified few residents in the vicinity of the Turkey Point site; the nearest resident is approximately 1.9 mi (3.0 km) away from the site at the Homestead Bayfront Park complex; the nearest residential communities are in Homestead, approximately 6.0 mi (9.7 km) west of the site (FPL 2018k). During the environmental site audit,

the NRC staff confirmed that there are few residents along site access roads in the immediate vicinity of the Turkey Point site, in particular Palm Drive. Therefore, increased traffic along site access roads is not likely to affect minority and low-income populations.

Noise would result from construction equipment, site activities, and additional traffic. Migrant agricultural workers (see Section 3.10.3.2, "Migrant Farm Workers," of this SEIS) could be particularly vulnerable to noise impacts because of their outdoor presence. However, the nearest farm is approximately 4.5 mi (7.2 km) away from Turkey Point (FPL 2018j); and the NRC staff has determined that noise would be temporary and not significant, and that noise levels would be lessened by distance. Air emissions would result from increased vehicle traffic, construction equipment, and fugitive dust from construction activities. These emissions would be temporary and minor (see Section 4.3.3, "Replacement Power Alternatives: Common Impacts," of this SEIS). Increased demand for rental housing during construction could disproportionately affect low-income populations. However, there is a large housing stock available in Miami-Dade County (see Table 3-20 and Table 3-22).

Operation

Low-income populations living near the power plant that rely on subsistence consumption of fish and wildlife could be disproportionately affected by replacement power alternatives. Emissions during power plant operations could disproportionately affect nearby minority and low-income populations, depending on the type of replacement power. Noise, primarily associated with cooling towers and vehicle traffic, would be intermittent and not noticeable.

4.12.3.1 New Nuclear Alternative

Potential impacts to minority and low-income populations from the construction and operation of the new nuclear alternative on the Turkey Point site would be similar to the impacts discussed above in Section 4.12.3 as common to all replacement power alternatives. While transportation impacts on access roads in the immediate vicinity of Turkey Point during construction of a new nuclear alternative would be LARGE, there are few residents along site access roads in the immediate vicinity of the Turkey Point site and the nearest residential community is in Homestead, approximately 6.0 mi (9.7 km) from the site. Potential impacts from operation would mostly consist of radionuclide releases and effects during operations; however, radiation doses would be required to meet regulatory limits, similar to the current operation of Turkey Point.

Based on (1) the location of the new nuclear alternative, (2) the assumed plant design and characteristics, and (3) the human health and environmental effects findings, construction and operation of the new nuclear alternative would not likely have disproportionately high and adverse human health and environmental effects on minority and low-income populations.

4.12.3.2 Natural Gas Combined-Cycle Alternative

Potential impacts to minority and low-income populations from the construction and operation of the natural gas alternative on the Turkey Point site would be similar to the impacts discussed above in Section 4.12.3 as common to all replacement power alternatives. While transportation impacts on access roads in the immediate vicinity of Turkey Point during construction of a natural gas alternative would be MODERATE, there are few residents along site access roads in the vicinity of the Turkey Point site and the nearest residential community is in Homestead, approximately 6.0 mi (9.7 km) from the site. As noted in Section 3.12, "Environmental Justice,"

of this SEIS and in Figure 3-38 and Figure 3-39, the Turkey Point site is in a minority and low-income population block group where the minority population exceeds 78 percent. As discussed in Section 4.3.5, “Natural Gas Combined-Cycle,” of this SEIS, nitrogen oxide and greenhouse gas emissions from a natural gas combined-cycle plant would be significant. Therefore, there would be a high concentration of minorities in close proximity to the source of air emissions. However, as discussed in Section 4.3.5, “Natural Gas Combined-Cycle,” of this SEIS, emissions would be noticeable but not destabilizing. Therefore, these effects are not likely to be high and adverse and emissions from the natural gas alternative during power plant operation are not likely to disproportionately affect minority populations living in the vicinity of the new power plant.

Based on (1) the location of the natural gas alternative, (2) the assumed plant design and characteristics, and (3) the human health and environmental effects findings, construction and operation of the natural gas alternative would not likely have disproportionately high and adverse human health and environmental effects on minority and low-income populations.

4.12.3.3 Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic)

Potential impacts to minority and low-income populations from the construction and operation of the natural gas portion of the combination alternative on the Turkey Point site would be the same as those discussed for the natural gas alternative (see Section 4.12.3.2 of this SEIS). Therefore, the construction and operation of the natural gas portion would not likely have disproportionately high and adverse human health and environmental effects on minority and low-income populations.

Potential impacts to minority and low-income populations from the construction and operation of solar facilities would mostly consist of environmental and socioeconomic effects (e.g., noise, air emissions, traffic, employment, and housing impacts). Figure 3-38 and Figure 3-39 show the location of predominantly minority and low-income population block groups residing within a 50-mi (80-km) radius of Turkey Point. Three of the solar facilities would be built in Miami-Dade and/or Broward County. According to the 2010 U.S. Census, minorities comprised 56.5 percent of the total Broward County population (USCB 2010c). The 2012–2016 American Survey Community 5-Year Estimates shows that 14.4 percent of individuals in Broward County live below the poverty threshold (USCB 2018). As noted in Chapter 3, minorities comprised approximately 86 percent of the total Miami-Dade County population and 18.3 percent of individuals in Miami-Dade County live below the poverty threshold.

Noise and air emissions impacts from construction would be short term and primarily limited to onsite activities. Increased demand for rental housing during construction and operations could affect low-income populations. However, given the number of construction workers and housing availability in Miami-Dade and Broward Counties, the potential need for rental housing would not be significant. During operations, there would not be a noticeable housing demand given the small number of workers needed to maintain and operate the solar facilities. Minority and low-income populations residing along site access roads would be affected by increased commuter vehicle traffic during shift changes and truck traffic. Transportation impacts would be SMALL to MODERATE and would depend on the location of the solar facilities in Broward County. However, these effects would be temporary during certain hours of the day.

Based on this information and the analysis of human health and environmental impacts presented in this SEIS, it is not likely that the construction and operation of the solar facilities would have disproportionately high and adverse human health and environmental effects on

minority and low-income populations. However, this determination would depend on the location of the facilities in Miami-Dade County and/or Broward County. Therefore, the NRC staff cannot determine whether the solar portion of the combination alternative would result in disproportionately high and adverse human health and environmental effects on minority and low-income populations.

4.12.4 Cooling Water System Alternative

Potential impacts to minority and low-income populations from the construction and operation of the cooling water system alternative would mostly consist of environmental and socioeconomic effects (e.g., noise, air emissions, traffic, employment, and housing impacts). Figure 3-38 and Figure 3-39 show the location of predominantly minority and low-income population block groups residing within a 50-mi (80-km) radius of Turkey Point. As discussed in Section 4.10.7, “Cooling Water System Alternative,” of this SEIS, transportation impacts during construction would be SMALL to MODERATE on roads in the immediate vicinity of Turkey Point. Minority and low-income populations residing along site access roads could be affected by increased truck traffic and increased commuter vehicle traffic, especially during shift changes. However, the transportation impacts would be on access roads in the immediate vicinity of Turkey Point. A 2017 land-use survey within a 5-mi (8.0 km) radius of Turkey Point identified few residents in the vicinity of the Turkey Point site; the nearest resident was approximately 1.9 mi (3.0 km) away from the site and the nearest residential communities are in Homestead, approximately 6.0 mi (9.7 km) west of the site (FPL 2018k). During the environmental site audit, the NRC staff confirmed that there are few residents along site access roads in the immediate vicinity of the Turkey Point site, in particular Palm Drive.

Noise would result from construction equipment, site activities, and additional traffic. Migrant agricultural workers (see Section 3.10.3.2, “Migrant Farm Workers,” of this SEIS) could be particularly vulnerable to noise impacts because of their outdoor presence. However, the nearest farm is approximately 4.5 mi (7.2 km) away from Turkey Point (FPL 2018j); and the NRC staff has determined that noise would be temporary, not significant, and that noise levels would be lessened by distance. Air emissions would result from increased vehicle traffic, construction equipment, and fugitive dust from construction activities. However, these emissions would be temporary and minor (see Section 4.3.4, “New Nuclear Alternative,” of this SEIS).

Replacement power will be required during the construction outage as well as a result of efficiency losses or additional power needed to operate cooling tower pumps and fans once the cooling system is online. Replacement power could increase air quality impacts and human health effects in minority and low-income communities, depending on the location and characteristics of replacement power used to replace Turkey Point power. The effects would be short lived during the construction-related outages and would occur near the existing power plants and would result from incremental increases rather than new effects. As discussed in Section 4.12.4 of this SEIS, during operations, the cooling towers would emit particulate matter, however, these emissions would be minor.

Based on the analysis of human health and environmental impacts presented in this SEIS, the location of the alternative, and the assumed alternative design and characteristics, this alternative would not likely have disproportionately high and adverse human health and environmental effects on minority and low-income populations.

4.13 Waste Management

This section describes the potential waste management impacts of the proposed action (subsequent license renewal) and alternatives to the proposed action.

4.13.1 Proposed Action

According to the GEIS (NRC 1996, NRC 2013a), the generic issues related to waste management as identified in Table 4-1 would not be affected by continued operations associated with license renewal. As discussed in Chapter 3, the NRC staff identified no new and significant information for these issues. Thus, as concluded in the GEIS, the impacts of the generic issues related to waste management would be SMALL.

Table 4-2 does not identify any Turkey Point site-specific (Category 2) waste management issues resulting from issuing a subsequent renewed license for an additional 20 years of operations.

4.13.2 No-Action Alternative

Under the no-action alternative, the NRC would not issue subsequent renewed licenses, and Turkey Point would shut down on or before the expiration of the current renewed licenses and enter decommissioning. After plant shutdown and prior to entering the decommissioning phase, the plant would generate no additional spent nuclear fuel. In addition, following shutdown, the variety of potential accidents at the plant (radiological and industrial) would be reduced to a limited set associated with shutdown events and fuel handling and storage. Therefore, as radioactive emissions to the environment decrease, and the likelihood and variety of accidents decrease following shutdown and decommissioning, the NRC staff concludes that the impacts resulting from waste management from the implementation of the no-action alternative would be SMALL.

4.13.3 Replacement Power Alternatives: Common Impacts

Impacts from waste management common to all analyzed replacement power alternatives would be from construction-related debris generated during construction activities, and this waste would be recycled or disposed of in approved landfills.

4.13.4 New Nuclear Alternative

Impacts from the waste generated during the construction of a new nuclear unit would include those identified in Section 4.13.3, as common to all replacement power alternatives.

During normal plant operations, routine plant maintenance and cleaning activities would generate radioactive low-level waste, spent nuclear fuel, high-level waste, and nonradioactive waste. Sections 3.1.4 and 3.1.5 of this SEIS discuss radioactive and nonradioactive waste management at Turkey Point. Quantities of radioactive and nonradioactive waste generated by Turkey Point would be comparable to that generated by the new nuclear plant. As stated in the GEIS (NUREG-1437) (NRC 2013a), the NRC does not expect the generation and management of solid radioactive and nonradioactive waste during the subsequent license renewal term to result in significant environmental impacts. Based on this information, the waste impacts would be SMALL for the new nuclear alternative.

4.13.5 Natural Gas Combined-Cycle Alternative

Impacts from the waste generated during the construction of a natural gas power plant would include those identified in Section 4.13.3 of this SEIS as common to all replacement power alternatives.

Waste generation from natural gas technology would be minimal. The only significant waste generated at a natural gas combined-cycle power plant would be spent selective catalytic reduction catalyst (plants use selective catalytic reduction catalyst to control nitrogen oxide emissions).

The spent catalyst would be regenerated or disposed of offsite. Other than the spent selective catalytic reduction catalyst, waste generation at an operating natural gas fired plant would be limited largely to typical operations and maintenance nonhazardous waste (NRC 2013a). Overall, the NRC staff concludes that waste impacts from the natural gas alternative would be SMALL.

4.13.6 Combination Alternative (Natural Gas Combined-Cycle and Solar Photovoltaic Generation)

Impacts from the waste generated during the construction of the natural gas combined-cycle (NGCC) plant and solar photovoltaic (PV) alternative would include those identified in Section 4.13.3 of this SEIS as common to the construction of all replacement power alternatives. The combination alternative consists of a natural gas plant and solar PV facilities that provide generation equivalent to Turkey Point's 1,632 MWe with an annual generation of approximately 13,154,016 MWhs. The natural gas plant would be located at the Turkey Point site. Four solar PV facilities would be constructed. One solar PV facility would be located on FPL-owned land on or near the Turkey Point site, and the other three solar facilities would be located in Miami-Dade or Broward County.

During the construction of the natural gas plant and solar PV facilities, land clearing and other construction activities would generate waste that could be recycled, disposed of onsite, or shipped to an offsite waste disposal facility.

Waste generation from natural gas technology would be minimal. The only significant waste generated at a natural gas combined-cycle power plant would be spent selective catalytic reduction catalyst (plants use selective catalytic reduction catalyst to control nitrogen oxide emissions).

The spent catalyst would be regenerated or disposed of offsite. Other than the spent selective catalytic reduction catalyst, waste generation at an operating natural gas fired plant would be limited largely to typical operations and maintenance nonhazardous waste (NRC 2013a). Overall, the NRC staff concludes that waste impacts from the natural gas portion of the combination alternative would be SMALL.

Impacts on waste management from the construction and operation of the natural gas plant and pipeline component of the combination alternative would be similar to those associated with the natural gas alternative.

The construction of the solar PV facilities would create sanitary and industrial waste, although it would be of smaller quantity as compared to the natural gas plant. This waste could be

recycled, disposed of onsite, or shipped to an offsite waste disposal facility. All of the waste would be handled in accordance with appropriate FDEP regulations. Impacts on waste management resulting from the construction and operation of the solar PV facilities of the combination alternative would be minimal, and of a smaller quantity as compared to the natural gas plant. In sum, the waste management impacts resulting from the construction and operation of the PV facilities would be SMALL.

Overall, the NRC staff concludes that waste impacts for the natural gas and solar PV combination alternative would be SMALL.

4.13.7 Cooling Water System Alternative

Waste management impacts from the waste generated during the construction of the cooling water system alternative would include those identified in Section 4.13.3 as common to all replacement power alternatives.

During operation, some minor amounts of chemical wastes may result from efforts to maintain appropriate chemical quality of the recirculating cooling water, from the periodic maintenance (i.e., descaling) of the cooling towers, and from periodic removal of settled precipitates from the cooling water basins beneath each cooling tower. Operational solid wastes are expected to be temporarily stored on site or ultimately treated, recycled, or disposed in appropriately permitted offsite facilities. FPL would be expected to implement appropriate waste management practices to minimize volume and content of waste generated from the construction and operation of the cooling towers. Any cooling water treatment and conditioning chemical residuals (e.g., biocides, corrosion inhibitors) necessary for proper operation, maintenance, and microorganism control of the cooling towers and Turkey Point circulating water system would be disposed of and managed in accordance with FDEP requirements.

In consideration of the information and assumptions presented above, the NRC staff concludes that the impacts from waste management from the construction and operation of the cooling water system alternative would be SMALL.

4.14 Evaluation of New and Significant Information

As stated in Section 4.1, "Introduction," of this SEIS, for Category 1 (generic) issues, the NRC staff can rely on the analysis in the GEIS (NUREG-1437) (NRC 2013a) unless otherwise noted. Table 4-1 lists the Category 1 issues that apply to Turkey Point during the proposed subsequent license renewal period. The NRC staff identified and evaluated new and potentially significant information for two existing Category 1 issues (i.e., groundwater quality degradation (plants with cooling ponds in salt marshes) and cooling system impacts on terrestrial resources (plants with once-through cooling systems or cooling ponds)) and identified one new uncategorized issue (i.e., water quality impacts on adjacent water bodies (plants with cooling ponds in salt marshes)). The NRC staff determined that the information was both new and potentially significant for one of the issues, "Groundwater quality degradation (plants with cooling ponds in salt marshes)," as listed in Table 4-1 and as evaluated in Section 4.5.1.2, "Groundwater Resources," of this SEIS. For all other issues, the NRC staff did not identify any new and significant information during its review of FPL's environmental report, the site audits, or the scoping period that would change the conclusions presented in the GEIS.

New and significant information must be new based on a review of the GEIS (NRC 2013a) as codified in Table B-1 of Appendix B to Subpart A of 10 CFR Part 51. Such information must

also bear on the proposed action or its impacts, presenting a seriously different picture of the impacts from those envisioned in the GEIS (i.e., impacts of greater severity than the impacts considered in the GEIS, considering their intensity and context).

The NRC defines new and significant information in Regulatory Guide (RG) 4.2, Supplement 1, "Preparation of Environmental Reports for Nuclear Power Plant License Renewal Applications" (NRC 2013g), as (1) information that identifies a significant environmental impact issue that was not considered or addressed in the GEIS and, consequently, not codified in Table B-1, in Appendix B to Subpart A of 10 CFR Part 51, or (2) information not considered in the assessment of impacts evaluated in the GEIS leading to a seriously different picture of the environmental consequences of the action than previously considered, such as an environmental impact finding different from that codified in Table B-1. Further, a significant environmental issue includes, but is not limited to, any new activity or aspect associated with the nuclear power plant that can act upon the environment in a manner or an intensity and/or scope (context) not previously recognized.

In accordance with 10 CFR 51.53(c), "Operating license renewal stage," the applicant's environmental report must analyze the Category 2 (site-specific) issues in Table B-1 of Appendix B to Subpart A of 10 CFR Part 51. Additionally, the applicant's environmental report must discuss actions to mitigate any adverse impacts associated with the proposed action and environmental impacts of alternatives to the proposed action. In accordance with 10 CFR 51.53(c), the applicant's environmental report does not need to analyze any Category 1 issue unless there is new and significant information on a specific issue.

NUREG-1555, Supplement 1, Revision 1, "Standard Review Plans for Environmental Reviews for Nuclear Power Plants for Operating License Renewal" describes the NRC process for identifying new and significant information (NRC 2013b). The search for new information includes:

- review of an applicant's environmental report (FPL 2018f, FPL 2018n) and the process for discovering and evaluating the significance of new information
- review of public comments
- review of environmental quality standards and regulations
- coordination with Federal, State, and local environmental protection and resource agencies
- review of technical literature as documented through this SEIS

New information is evaluated for significance using the criteria set forth in the GEIS. For Category 1 issues for which new and significant information is identified, reconsideration of the conclusions for those issues is limited in scope to an assessment of the relevant new and significant information; the scope of the assessment does not include other facets of an issue that the new information does not affect.

The NRC staff reviewed the discussion of environmental impacts associated with operation during the subsequent license renewal term in the GEIS and has conducted its own independent review, including a public involvement process (e.g., public meetings and comments) to identify new and significant issues for the Turkey Point subsequent license renewal application environmental review.

4.15 Impacts Common to All Alternatives

This section describes the impacts that the NRC staff considers common to all alternatives discussed in this SEIS, including the proposed action and replacement power alternatives. The continued operation of a nuclear power plant and replacement fossil fuel power plants both involve mining, processing, and the consumption of fuel that result in comparative impacts (NRC 2013a). In addition, the following sections discuss the termination of operations and the decommissioning of both a nuclear power plant and replacement fossil fuel power plants and greenhouse gas emissions.

4.15.1 Fuel Cycle

This section describes the environmental impacts associated with the fuel cycles of both the proposed action and all replacement power alternatives. Most replacement power alternatives employ a set of steps in the use of their fuel sources, which can include extraction, transformation, transportation, and combustion. Emissions generally occur at each stage of the fuel cycle (NRC 2013a).

4.15.1.1 Uranium Fuel Cycle

The uranium fuel cycle includes uranium mining and milling, the production of uranium hexafluoride, isotopic enrichment, fuel fabrication, reprocessing of irradiated fuel, transportation of radioactive materials, and management of low-level wastes and high-level wastes related to uranium fuel cycle activities. The GEIS (NUREG-1437) describes in detail the generic potential impacts of the radiological and non-radiological environmental impacts of the uranium fuel cycle and transportation of nuclear fuel and wastes (NRC 1996, NRC 1999, NRC 2013a). The GEIS does not identify any site-specific (Category 2) uranium fuel cycle issues.

As stated in the GEIS (NRC 1996, NRC 2013a), the generic issues related to the uranium fuel cycle as identified in Table 4-1 would not be affected by continued operations associated with license renewal. As discussed in Chapter 3, the NRC staff identified no new and significant information for these issues. Thus, as concluded in the GEIS, the impacts of generic issues related to the uranium fuel cycle would be SMALL.

4.15.1.2 Replacement Power Plant Fuel Cycles

Fossil Fuel Energy Alternatives

Fuel cycle impacts for a fossil fuel-fired plant result from the initial extraction of fuel, cleaning and processing of fuel, transport of fuel to the facility, and management and ultimate disposal of solid wastes from fuel combustion. These impacts are discussed in more detail in Section 4.12.1.2 of the GEIS (NUREG-1437) (NRC 2013a) and can generally include the following:

- significant changes to land use and visual resources
- impacts to air quality, including release of criteria pollutants, fugitive dust, volatile organic compounds, and coalbed methane into the atmosphere
- noise impacts
- geology and soil impacts due to land disturbances and mining

- water resource impacts, including degradation of surface water and groundwater quality
- ecological impacts, including loss of habitat and wildlife disturbances
- historic and cultural resources impacts within the mine or pipeline footprint
- socioeconomic impacts from employment of both the mining workforce and service and support industries
- environmental justice impacts
- health impacts to workers from exposure to airborne dust and methane gases
- generation of industrial wastes

New Nuclear Energy Alternatives

Uranium fuel cycle impacts for a nuclear plant result from the initial extraction of fuel, transport of fuel to the facility, and management and ultimate disposal of spent fuel. The environmental impacts of the uranium fuel cycle are discussed in Section 4.15.1.1 of this SEIS.

Renewable Energy Alternatives

The fuel cycle for renewable energy facilities is difficult to define for different technologies because these natural resources exist regardless of any effort to harvest them for electricity production. Impacts from the presence or absence of these renewable energy technologies are often difficult to determine (NRC 2013a).

4.15.2 Terminating Power Plant Operations and Decommissioning

This section describes the environmental impacts associated with the termination of operations and the decommissioning of a nuclear power plant and replacement power alternatives. All operating power plants will terminate operations and be decommissioned at some point after the end of their operating life or after a decision is made to cease operations. For the proposed action at Turkey Point, subsequent license renewal would delay this eventuality for an additional 20 years beyond the current license period, which ends in 2032 (Unit 3) and 2033 (Unit 4).

4.15.2.1 Existing Nuclear Power Plant

Decommissioning would occur whether Turkey Point is shut down at the end of its current renewed license or at the end of the subsequent license renewal term. NUREG-0586, Supplement 1, "Final Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Regarding the Decommissioning of Nuclear Power Reactors" (the Decommissioning GEIS), evaluates the environmental impacts from the activities associated with the decommissioning of any reactor before or at the end of an initial or renewed license (NRC 2002a). Additionally, the License Renewal GEIS (NUREG-1437) (NRC 2013a) discusses the incremental environmental impacts associated with decommissioning activities resulting from continued plant operation during the renewal term. As noted in Table 4-1, there is one Category 1 issue applicable to Turkey Point decommissioning following the subsequent license renewal term. The License Renewal GEIS did not identify any site-specific (Category 2) decommissioning issues.

4.15.2.2 Replacement Power Plants

Fossil Fuel Energy Alternatives

The environmental impacts from the termination of power plant operations and decommissioning of a fossil fuel-fired plant are dependent on the facility's decommissioning plan. General elements and requirements for a fossil fuel plant decommissioning plan are discussed in Section 4.12.2.2 of the License Renewal GEIS (NUREG-1437) and can include the removal of structures to at least 3 feet (1 m) below grade; removal of all coal, combustion waste, and accumulated sludge; removal of intake and discharge structures; and the cleanup and remediation of incidental spills and leaks at the facility. The decommissioning plan outlines the actions necessary to restore the site to a condition equivalent in character and value to the site on which the facility was first constructed (NRC 2013a).

The environmental consequences of decommissioning are discussed in Section 4.12.2.2 of the License Renewal GEIS (NUREG-1437) and can generally include the following:

- short-term impacts on air quality and noise from the deconstruction of facility structures
- short-term impacts on land use and visual resources
- long-term reestablishment of vegetation and wildlife communities
- socioeconomic impacts due to decommissioning the workforce and the long-term loss of jobs
- elimination of health and safety impacts on operating personnel and the general public

New Nuclear Alternatives

Termination of operations and decommissioning impacts for a nuclear plant include all activities related to the safe removal of the facility from service and the reduction of residual radioactivity to a level that permits release of the property under restricted conditions or unrestricted use and termination of a license (NRC 2013a). The environmental impacts of the uranium fuel cycle are discussed in Section 4.15.1.1, "Uranium Fuel Cycle."

Renewable Alternatives

Termination of power plant operation and decommissioning for renewable energy facilities would be similar to the impacts discussed for fossil fuel-fired plants. Decommissioning would involve the removal of facility components and operational wastes and residues to restore the site to a condition equivalent in character and value to the site on which the facility was first constructed (NRC 2013a).

4.15.3 Greenhouse Gas Emissions and Climate Change

The following sections discuss greenhouse gas emissions and climate change impacts. Section 4.15.3.1 evaluates greenhouse gas emissions associated with operation of Turkey Point Units 3 and 4 and replacement power alternatives. Section 4.15.3.2 discusses the observed changes in climate and the potential future climate change during the subsequent license renewal term based on climate model simulations under future global greenhouse gas emission scenarios. The cumulative impacts of global greenhouse gas emissions on climate are discussed in Section 4.16.10, "Global Greenhouse Gas Emissions," in this SEIS. In Section 4.16, "Cumulative Impacts," of this SEIS, the NRC staff considers the potential

cumulative, or overlapping, impacts from climate change on environmental resources where there are incremental impacts of the proposed action (subsequent license renewal).

4.15.3.1 Greenhouse Gas Emissions from the Proposed Action and Alternatives

Gases found in the Earth's atmosphere that trap heat and play a role in the Earth's climate are collectively termed greenhouse gases. Greenhouse gases include carbon dioxide (CO₂); methane (CH₄); nitrous oxide (N₂O); water vapor (H₂O); and fluorinated gases, such as hydrofluorocarbons (HFCs), perfluorocarbons (PFCs), and sulfur hexafluoride (SF₆). The Earth's climate responds to changes in concentrations of greenhouse gases in the atmosphere because these gases affect the amount of energy absorbed and heat trapped by the atmosphere. Increasing greenhouse gas concentrations in the atmosphere generally increase the Earth's surface temperature. Atmospheric concentrations of carbon dioxide, methane, and nitrous oxide have significantly increased since 1750 (IPCC 2007, IPCC 2013). Carbon dioxide, methane, nitrous oxide, water vapor, and fluorinated gases (termed long-lived greenhouse gases) are well mixed throughout the Earth's atmosphere, and their impact on climate is long lasting as a result of their long atmospheric lifetime (EPA 2009b). Carbon dioxide is of primary concern for global climate change, due to its long atmospheric lifetime, and it is the primary gas emitted as a result of human activities. Climate change research indicates that the cause of the Earth's warming over the last 50 years is due to the buildup of greenhouse gases in the atmosphere resulting from human activities (IPCC 2013, USGCRP 2014, USGCRP 2017). The EPA has determined that greenhouse gases "may reasonably be anticipated both to endanger public health and to endanger public welfare" (74 FR 66496).

Proposed Action

Operation of Turkey Point emits greenhouse gases directly and indirectly. Turkey Point's direct greenhouse gas emissions result from stationary portable combustion sources (see Table 3-2) and stationary refrigeration appliances. Indirect greenhouse gas emissions originate from mobile combustion sources (e.g., employee vehicles, visitor vehicles, and delivery vehicles). Table 4-6 below presents quantified annual greenhouse gas emissions from sources at Turkey Point.

FPL does not maintain an inventory of greenhouse gas emissions resulting from visitor and delivery vehicles. Chlorofluorocarbon and hydrochlorofluorocarbon emissions from refrigerant sources can result from leakage, servicing, repair, or disposal of refrigerant sources. Chlorofluorocarbons and hydrochlorofluorocarbons are ozone-depleting substances that are regulated by the Clean Air Act under Title VI, "Stratospheric Ozone Protection." FPL maintains a program to manage stationary refrigeration appliances at Turkey Point to recycle, recapture, and reduce emissions of ozone-depleting substances (FPL 2018f). Estimating greenhouse gas emissions from refrigerant sources is complicated due to their ability to deplete ozone, which is also a greenhouse gas, making their global warming potentials difficult to quantify. Consequently, greenhouse gas emissions from refrigerant sources are commonly excluded from greenhouse gas inventories (EPA 2014d). Therefore, Table 4-6 does not account for potential greenhouse gas emissions from stationary refrigeration appliances or visitor and delivery vehicles at Turkey Point.

Table 4-6 Estimated Greenhouse Gas Emissions^(a) from Operation at Turkey Point, Units 3 and 4

Year	Turkey Point Combustion Sources ^(b) (tons/year)	Workforce Commuting ^(c) (tons/year)	Total (tons/year)
2012	570	3,400	3,970
2013	500	3,400	3,900
2014	620	3,400	4,020
2015	790	3,400	4,190
2016	540	3,400	3,940

Note: GHG emissions reported in metric tons and converted to short tons. All reported values are rounded. To convert tons per year to metric tons per year, multiply by 0.90718.

^(a) Expressed in carbon dioxide equivalents (CO₂eq), a metric used to compare the emissions of greenhouse gases (GHG) based on their global warming potential (GWP). The GWP is a measure used to compare how much heat a GHG traps in the atmosphere. The GWP is the total energy that a gas absorbs over a period of time compared to carbon dioxide. CO₂eq is obtained by multiplying the amount of the GHG by the associated GWP. For example, the GWP of methane is 21; therefore, 1 ton of methane is equivalent to 21 tons of carbon dioxide emissions.

^(b) Includes stationary and portable diesel and gasoline engines described in Table 3-2..

^(c) Emissions consider Turkey Point full-time employees and does not include additional contractor workers during refueling outages. Refueling outages occur on a staggered, 18-month schedule and last approximately 25–35 days per unit.

Source: Modified from FPL 2018f

No-Action Alternative

Under the no-action alternative, the NRC would not issue subsequent renewed licenses, and Turkey Point Units 3 and 4 would shut down on or before the expiration of the current renewed licenses. At some point, all nuclear plants will terminate operations and undergo decommissioning. The Decommissioning GEIS (NUREG–0586, NRC 2002a) considers the impacts from decommissioning. Therefore, the scope of impacts considered under the no-action alternative includes the immediate impacts resulting from activities at Turkey Point that would occur between plant shutdown and the beginning of decommissioning (i.e., activities and actions necessary to cease operation of Turkey Point). Turkey Point operations would terminate at or before the expiration of the current renewed licenses. When the plant stops operating, a reduction in greenhouse gas emissions from activities related to plant operation, such as the use of diesel generators and employee vehicles, would occur. The NRC staff anticipates that greenhouse gas emissions for the no-action alternative would be less than those presented in Table 4-6, which shows the estimated greenhouse gas emissions from operation of Turkey Point Units 3 and 4.

Since the no-action alternative would result in a loss of power generating capacity due to shutdown, the sections below discuss greenhouse gas emissions associated with replacement baseload power generation for each replacement power alternative analyzed.

New Nuclear Alternative

The license renewal GEIS (NUREG-1437) presents life-cycle greenhouse gas emissions associated with nuclear power generation. As presented in Tables 4.12-4 through 4.12-6 of the GEIS (NRC 2013a), life-cycle greenhouse gas emissions from nuclear power generation can range from 1 to 288 grams carbon equivalent per kilowatt-hour ($g C_{eq}/kWh$). Nuclear power plants do not burn fossil fuels to generate electricity. Sources of greenhouse gas emissions from the new nuclear alternative would include stationary combustion sources such as emergency diesel generators, boilers, and pumps similar to existing sources at Turkey Point (see Section 3.2.1 of this SEIS). The NRC staff estimates that greenhouse gas emissions from a new nuclear alternative would be similar to greenhouse gas emissions from Turkey Point.

Natural Gas Combined-Cycle Alternative

The GEIS (NRC 2013a) presents life-cycle greenhouse gas emissions associated with natural gas power generation. As presented in Table 4.12-5 of the GEIS, life-cycle greenhouse gas emissions from natural gas can range from 120 to 930 $g C_{eq}/kWh$. The NRC staff estimates that direct emissions from the operation of three, 500-MWe natural gas combined-cycle units would total 5.7 million tons (5.2 million MT) of carbon dioxide equivalents (CO_{2eq}) per year.

Combination Alternative

For the combination alternative, greenhouse gases would primarily be emitted from the natural gas component of this alternative. The NRC staff estimates that the operation of the natural gas-fired units would emit a total of 5.4 million tons (4.9 million MT) of CO_{2eq} per year.

Summary of Greenhouse Gas Emissions from the Proposed Action and Alternatives

Table 4-7 below presents the direct greenhouse gas emissions from facility operations under the proposed action of subsequent license renewal and alternatives to the proposed action. Greenhouse gas emissions from the proposed action (subsequent license renewal), the no-action alternative, and the new nuclear alternative would be the lowest. Greenhouse gas emissions from the natural gas and combination alternatives are several orders of magnitude greater than those from the continued operation of Turkey Point. Therefore, if Turkey Point's generating capacity were to be replaced by either of these two alternatives, there would be an increase in greenhouse gas emissions. Consequently, the continued operation of Turkey Point (the proposed action) results in greenhouse gas emissions avoidance as compared to the natural gas or combination alternative.

Table 4-7 Direct Greenhouse Gas Emissions from Facility Operations Under the Proposed Action and Alternatives

Technology/Alternative	CO _{2eq} ^(a) (tons/year)
Proposed Action (Turkey Point subsequent license renewal) ^(b)	604
No-Action Alternative ^(c)	<604
New Nuclear ^(d)	604
Natural Gas Combined-Cycle ^(e)	5.7 x 10 ⁶
Combination Alternative ^(f)	5.4 x 10 ⁶

- (a) Carbon dioxide equivalent (CO_{2eq}) is a metric used to compare the emissions of greenhouse gases (GHG) based on their global warming potential (GWP). The GWP is a measure used to compare how much heat a GHG traps in the atmosphere. The GWP is the total energy that a gas absorbs over a period of time compared to carbon dioxide. CO_{2eq} is obtained by multiplying the amount of the GHG by the associated GWP. For example, the GWP of methane is 21; therefore, 1 ton of methane emission is equivalent to 21 tons of carbon dioxide emissions.
- (b) Greenhouse gas emissions include only direct emissions from combustion sources averaged over the 5-year-period presented in Table 4-6 (Source: FPL 2018f).
- (c) Emissions resulting from activities at Turkey Point that would occur between plant shutdown and the beginning of decommissioning and assumed not to be greater than greenhouse gas emissions from operation of Turkey Point.
- (d) Emissions assumed to be similar to Turkey Point operation.
- (e) Emissions from direct combustion of natural gas. Greenhouse gas emissions estimated using emission factors developed by the DOE's National Energy Technology Laboratory (NETL 2012).
- (f) Emissions from the natural gas combined-cycle component of the combination alternative. Greenhouse gas emissions estimated using emission factors developed by DOE's National Renewable Energy Laboratory (NETL 2012).

4.15.3.2 Climate Change

Observed Trends in Climate Change Indicators

Climate change is the decades or longer change in climate measurements (e.g., temperature and precipitation) that has been observed on a global, national, and regional level (IPCC 2007, EPA 2016b, USGCRP 2014). Climate change can vary regionally, spatially, and seasonally, depending on local, regional, and global factors. Just as regional climate differs throughout the world, the impacts of climate change can vary among locations.

On a global level, from 1901 to 2015, average surface temperatures rose at a rate of 0.15 °F (0.08 °C) per decade, and total annual precipitation increased at an average rate of 0.08 inches (0.2 cm) per decade (EPA 2016b). The years 2017 and 2018 were the second and fourth warmest, respectively, on record globally; 2016 remains the warmest year on record. This finding is based on average global temperature data dating back to 1880. Analyses performed by both the National Aeronautics and Space Administration (NASA) and NOAA show that globally, the last 5 years have been the warmest in the modern record (NASA 2018, 2019). The observed global change in average surface temperature and precipitation has been accompanied by an increase in sea surface temperatures, a decrease in global glacier ice, an increase in sea level, and changes in extreme weather events. Such extreme events include an

increase in the frequency of heat waves, very heavy precipitation (defined as the heaviest 1 percent of all daily events), and recorded maximum daily high temperatures (IPCC 2007, EPA 2016b, USGCRP 2009, USGCRP 2014).

The U.S. Global Change Research Program (USGCRP) compiles the best available information and maintains the current state of knowledge regarding climate change trends and effects at the regional and national level. The USGCRP reports that, from 1901 to 2016, average surface temperature has increased by 1.8 °F (1.0 °C) across the contiguous United States. Since 1901, average annual precipitation has increased by 4 percent, comprised of increases in the Northeast, Midwest, and Great Plains and decreases across parts of the Southwest and Southeast (USGCRP 2017, 2018: Fig 2.5). On a seasonal basis, warming has been the greatest in winter. Since the 1980s, NOAA data show an increase in the length of the frost-free season, the period between the last occurrence of 32 °F (0 °C) in the spring and first occurrence of 32 °F (0 °C) in the fall, across the contiguous United States. Over the period 1991 through 2011, the average frost-free season was 10 days longer than between 1901 and 1960 (USGCRP 2014). Over the past two decades, the number of high temperature records observed in the United States far exceeds the number of low temperature records (USGCRP 2018).

Observed climate change-related indicators across the United States include increases in the frequency and intensity of heavy precipitation, earlier onset of spring snowmelt and runoff, rise of sea level in coastal areas, increase in occurrence of heat waves, and a decrease in occurrence of cold waves. Since the 1980s, the intensity, frequency, and duration of North Atlantic hurricanes has increased; however, there is no trend in landfall frequency along the U.S. eastern and Gulf coasts (USGCRP 2014).

Warming has generally been uneven across the Southeast region of the United States, where Turkey Point is located (USGCRP 2017, 2018). The Southeast region of the United States is one of the few areas of the world where there has not been an overall increase in daily maximum temperatures since 1900 (NOAA 2013a, USGCRP 2018). Across the Southeast, annual average temperatures have warmed by less than 0.5 °F (0.28 °C) (USGCRP 2014, 2017). The overall lack of warming in the Southeast has been termed “the warming hole” (NOAA 2013a, NOAA 2013b, USGCRP 2017). However, since the 1970s, average annual temperatures have steadily increased across the Southeast and have been accompanied by an increase in the number of hot days with maximum temperatures above 95 °F (35 °C) in the daytime and above 75 °F (23.9 °C) in the nighttime (NOAA 2013a, USGCRP 2009, USGCRP 2014, USGCRP 2018: Fig 19.1). The average annual number of hot days observed since the 1960s remains lower than the average number during the first half of the 20th century. In contrast, the number of warm nights above 75 °F (23.9 °C) has doubled on average in the Southeast region compared to the first half of the 20th century and have increased at most observing stations (USGCRP 2018: Fig 19.1). The eastern and far southern portions of the region have experienced a more definitive warming trend since 1901 (EPA 2016b, EPA 2016c, USGCRP 2018: Fig 2.4). South Florida has warmed by greater than 1.5 °F (0.83 °C) over the period 1986-2016 (relative to 1901-1960 for the contiguous United States) (EPA 2016c, USGCRP 2014: Fig 2.7, USGCRP 2018: Fig 2.4).

Average annual precipitation data for the Southeast does not exhibit an increasing or decreasing trend for the long-term period (1895–2011) (NOAA 2013b). Precipitation in the Southeast region varies considerably throughout the seasons and average precipitation has generally increased in the fall and decreased in the summer (NOAA 2013b, USGCRP 2009). Across parts of the Southeast region, including parts of Florida, decreases in annual average

precipitation of up to 10 percent have occurred over the period 1986–2015 (relative to 1901–1960 for the contiguous United States) (USGCRP 2018: Fig 2.5). Changes in the frequency and intensity of heavy precipitation events across the United States have been more definitive. Between 1958 and 2016, heavy precipitation (i.e., the amount of annual precipitation falling in the heaviest 1 percent of events) has increased by an average of 27 percent across the Southeast region (USGCRP 2018: Fig 2.6).

Specific to South Florida, the NRC staff used the NOAA Climate at a Glance tool to analyze temperature and precipitation trends for the period of 1895 to 2018 in the lower east coast region of Florida (NOAA 2018b). A trends analysis shows that average annual temperature has increased at a rate of 0.2 °F (0.11 °C) per decade while average annual precipitation has remained relatively flat with large year-to-year variations (NOAA 2018b). The number of extreme precipitation events (defined as precipitation greater than 4 inches, averaged over 5-year periods) since 1900 has been highly variable for Florida with no clear trend. In contrast, the threat of drought is persistent across the State, and Florida has experienced below average precipitation over the last decade (2005–2014) (Runkle et al. 2017).

Based on an analysis of tidal gauge data, global mean sea level has risen by approximately 8 to 9 inches (20 to 23 cm) since 1880, with about 3 inches (7.6 cm) of the rise having occurred since 1993. Since the early 1990s, tidal gauge and satellite altimeter data indicate an acceleration in the rate of sea level rise, which is now on the order of 1.2 inches (3 cm) per decade. With higher sea levels, the frequency of tidal flooding that causes minor impacts or “nuisance floods” has increased by a factor of 5 to 10 since the 1960s in several United States coastal cities. The rates of increase in such flooding are accelerating in more than 25 cities along the Atlantic and Gulf Coasts (USGCRP 2017).

Observed changes in sea level and their effects vary regionally and locally. In the United States, the Mid-Atlantic and parts of the Gulf coasts have experienced the greatest sea level rise, with some stations having experienced increases of more than 8 in. (20 cm) between 1960 and 2015 (EPA 2016b). Currently, the relative sea level rise trend at Miami, FL is 0.09 in. per year (0.24 cm per year), or about 9 in. (23 cm) per century. This is based on NOAA tidal gauge readings and includes local vertical land motion (e.g., subsidence and/or uplift) (NOAA 2018c).

Climate Change Projections

Future global greenhouse gas emission concentrations (emission scenarios) and climate models are commonly used to project possible climate change. Climate models indicate that over the next few decades, temperature increases will continue due to current greenhouse gas emission concentrations in the atmosphere (USGCRP 2014, 2018). Over the longer term, the magnitude of temperature increases and climate change effects will depend on both past and future global greenhouse gas emissions (IPCC 2007, IPCC 2013, USGCRP 2009, USGCRP 2014, USGCRP 2018). Climate model simulations often use greenhouse gas emission scenarios to represent possible future social, economic, technological, and demographic development that, in turn, drive future emissions. Consequently, the greenhouse gas emission scenarios, their supporting assumptions, and the projections of possible climate change effects entail substantial uncertainty.

The Intergovernmental Panel on Climate Change has generated various representative concentration pathway (RCP) scenarios commonly used by climate-modeling groups to project future climate conditions (IPCC 2000, IPCC 2013, USGCRP 2017, USGCRP 2018). For instance, the A2 scenario is representative of a high-emission scenario in which greenhouse

gas emissions continue to rise during the 21st century from 40 gigatons (GT) of carbon dioxide equivalents (CO_{2eq}) per year in 2000 to 140 GT of CO_{2eq} per year by 2100. The B1 scenario, on the other hand, is representative of a low-emission scenario in which emissions rise from 40 GT of CO_{2eq} per year in 2000 to 50 GT of CO_{2eq} per year midcentury before falling to 30 GT of CO_{2eq} per year by 2100 (IPCC 2000, USGCRP 2014).

The RCP scenarios are based on predicted changes in radiative forcing (a measure of the influence that a factor, such as greenhouse gas emissions, has in changing the global balance of incoming and outgoing energy) in the year 2100 relative to preindustrial conditions. The RCPs are numbered in accordance with the change in radiative forcing measured in watts per square meter (i.e., +2.6 (very low), +4.5 (lower), +6.0 (mid-high) and +8.5 (higher)) (USGCRP 2014, 2017, 2018). For example, RCP 8.5 reflects a continued increase in global emissions resulting in increased warming by 2100, while RCP 2.6 assumes immediate and rapid reductions in emissions resulting in less warming by 2100 (USGCRP 2014). Most recently, the USGCRP and the Intergovernmental Panel on Climate Change have used the RCPs and associated modelling results as the basis of its climate change assessments (IPCC 2013, USGCRP 2017, 2018).

The NRC staff considered the best available national climate change studies as part of its assessment of potential changes in climate-relevant indicators during the Turkey Point subsequent license renewal term (2032–2052 and 2033–2053 for Units 3 and 4, respectively). As input to the Third National Climate Assessment report (USGCRP 2014), NOAA analyzed future regional climate change scenarios based on climate model simulations using the high (A2) and low (B1) emission scenarios. NOAA's climate model simulations (for the period between 2041 and 2070 (2055 midpoint) relative to the reference period, 1971–1999) indicate the following. Annual mean temperature is projected to increase by 1.5–3.5 °F (0.83–1.9 °C) across the Southeast region under the low-emission modeled scenario, with much of the Florida peninsula falling in the lower end of the range. For the high-emission-modeled scenario, projected temperature increases fall within the range of 2.5–4.5 °F (1.4–2.5 °C), again with much of Florida experiencing warming on the low end of the range (NOAA 2013a: Fig 26). Increases in temperature during this time period are projected to occur for all seasons with the largest increase occurring in the summertime (June, July, and August) (NOAA 2013a: Fig 27).

Newer regional projections for annual mean temperature are available from The Fourth National Climate Assessment based on the RCP 4.5 and RCP 8.5 scenarios for the mid-century (2036-2065) as compared to the average for 1976-2005. The modeling predicts increases of 3.4–4.3 °F (1.9–2.4 °C) across the Southeast region by mid-century (USGCRP 2017: Tab 6.4). For much of the Florida peninsula, predicted annual temperature increases range from 2–4 °F (1.1–2.2 °C) under both scenarios (USGCRP 2017: Fig 6.7).

As for precipitation, the climate model simulations (for the time period 2041–2070, 2055 midpoint) suggest spatial differences in annual mean precipitation change across the Southeast with some areas experiencing an increase and others a decrease in precipitation. On a seasonal basis, climate models are not in agreement on the sign or direction (increase or decrease) of modeled precipitation changes. For Florida, a 0 to 3 percent decrease in annual mean precipitation is predicted under both a low- and high-emission-modeled scenario; however, the predicted changes in precipitation are not significant as the models indicate changes that are less than normal year-to-year variations (NOAA 2013a: Fig 37).

Heavy precipitation events across the Southeast including Southern Florida are expected to increase in both frequency and intensity. The USGCRP predicts continued increases in the

frequency and intensity of heavy or extreme precipitation events across the United States, including across the Southeast region (USGCRP 2014, USGCRP 2017, USGCRP 2018). For the Southeast region, models predict a 9 percent average increase in extreme precipitation (representing change in the 20-year return period amount for daily precipitation) under the lower RCP 4.5 scenario and up to 12 percent under the higher RCP 8.5 scenario by mid-century (USGCRP 2017: Fig 7.7).

With a warming climate, model simulations indicate that the total number of tropical storms will either remain steady or decrease worldwide. However, projections show that the frequency of the most intense storms will increase, and rainfall will be more intense with a given storm (USGCRP 2018). Climate models are not in agreement when projecting changes in Atlantic hurricane activity; nonetheless, models agree that under a warmer climate, hurricane-associated rainfall rates and wind speed will increase (EPA 2016b, USGCRP 2014, 2018).

In 2017, the USGCRP issued its Fourth National Climate Assessment report (USGCRP 2017), which includes updated sea level rise projections. The 2017 report updates NOAA's global sea level rise scenarios presented in the report, "Global Sea Level Rise Scenarios for the United States National Climate Assessment" (Parris et al. 2012) and which were previously used as the basis of the Southeast Florida Regional Climate Change Compact's 2015 sea level projections.

As for future sea levels, the USGCRP reports that, relative to the year 2000, global mean sea level is projected rise by 0.3 to 0.6 feet (0.09 to 0.18 m) by 2030 and 0.5 to 1.2 feet (0.15 to 0.37 m) by 2050 (USGCRP 2017). The USGCRP assigns very high confidence to the lower bounds of these projections and medium confidence to the upper bounds. For the first half of this century, future greenhouse gas emissions will have little effect as sea levels continue to rise, but emissions significantly affect levels beyond mid-century. Relative sea level rise on the East and Gulf Coasts of the United States is likely to be higher than the global average (USGCRP 2017, 2018).

Beyond the 2050 timeframe (and beyond the subsequent license renewal term for Turkey Point Units 3 and 4) and to the end of the century, sea levels are projected to continue to rise but the projections are subject to even greater uncertainty. In Appendix I, Section I.2 of the final EIS for the proposed Turkey Point Units 6 and 7 combined licenses (NUREG-2176, NRC 2016a), the NRC staff cited earlier sea level rise projections from the USGCRP (USGCRP 2014) of 1 to 4 feet (0.3 to 1.2 m) globally by the year 2100. NUREG-2176 also cited the "extreme high end" sea level rise estimate of 8.2 feet (2.5 m) by the year 2100 (NRC 2016a). In NUREG-2176, the NRC staff conjectured that should such a high rate of sea level rise occur, "much of South Florida would be uninhabitable and millions of people would likely be displaced." However, the NRC staff also observed that because sea level rise is likely to continue gradually, adaptation is possible (NRC 2016a). The latest consensus estimates from the USGCRP similarly indicate potential global sea level rise of 1 to 4.3 feet (0.3 to 1.3 m) by 2100. The USGCRP assigns low confidence to the upper bounds estimates for the year 2100 in part because future greenhouse gas emissions drive sea level rise projections for the second half of the century (USGCRP 2017, 2018). The USGCRP also indicates that sea level rise of 8 feet (2.4 m) or higher is physically possible, although the probability of that occurring has not been assessed by the USGCRP to date (USGCRP 2017, 2018). Nevertheless, it is apparent that future sea level rise is difficult to predict and is dependent on the amount of warming, ice melt from glaciers and ice sheets, and vertical land motion (e.g., local land subsidence or uplift) that may occur (USGCRP 2014, USGCRP 2017).

In 2015, the Southeast Florida Regional Climate Change Compact (SFRCCC or the Compact) published its update to the unified sea level rise projection. Its projections are intended for use by counties in the Southeast Florida compact to support planning with respect to potential vulnerabilities and the development of mitigation strategies to sea level rise (SFRCCC 2015).

The Compact produced sea level rise projections for three planning horizons (2030, 2060, and 2100). The projections for the medium term (i.e., 2060) most closely approximate the USGCRP's 2050 projections, which encompass the subsequent license renewal term for Turkey Point. Based on the Compact's estimates, relative to the year 1992, mean sea levels would rise 0.5 to 0.83 feet (0.15 to 0.25 m) by 2030 and 1.16 to 2.83 feet (0.35 to 0.86 m) by 2060. These estimates are referenced to the tidal gauge at Key West, FL. The Compact's projections (SFRCCC 2015), which are given in inches, have been converted to feet here for ease of comparison with those from the USGCRP (USGCRP 2017).

The NRC staff observes that in the short term (i.e., by the year 2030, or prior to the subsequent license renewal term), the Compact's regional estimates are not substantially different from the latest estimates produced by the USGCRP, although they diverge in the medium term (2050 to 2060). Specifically, the USGCRP projects sea level rise of 0.5 to 1.2 feet (0.15 to 0.37 m) by 2050, while the Compact projects a sea level rise of 1.16 to 2.83 feet (0.35 to 0.86 m) by 2060. The NRC staff observes that such divergence is not unexpected as uncertainty in the projections also increases with time. The Compact acknowledges as much, stating that, "sea level rise in the medium and long term has a significant range of variation as a result of uncertainty in future greenhouse gas emissions and their geophysical effects" (SFRCCC 2015).

The Compact's sea level rise estimates have some inherent differences as compared to the consensus-based estimates from the USGCRP. For example, the USGCRP's sea level rise estimates are relative to global mean sea level while the Compact's estimates are referenced to mean sea level at Key West, FL. The temporal baseline from which incremental sea level is measured also varies (year 2000 for USGCRP's current estimates versus 1992 for the Compact), a difference of 8 years over which time some sea level rise has inevitably already occurred. Accordingly, while they are useful for future planning, the various estimates are not directly comparable.

Based on the NRC staff's review, the staff considers the Compact's estimates to be conservative or bounding estimates (i.e., they reflect a higher sea level rise than would likely be observed based on the best available data from the USGCRP). As described in the Compact (SFRCCC 2015), sea level rise range estimates are based on the more conservative sea level rise projections or "curves" prepared by NOAA, the USACE, and the Intergovernmental Panel on Climate Change. Specifically, the Compact cites as the basis of its projections what is described as the "NOAA high curve," the "USACE high curve," and the median of the IPCC Fifth Assessment Report's (AR5) RCP 8.5 scenario, which is described in the report, "Climate Change 2013: The Physical Science Basis" (IPCC 2013). These scenarios in part define the upper bound (e.g., up to 2.83 feet (0.86 m) in sea level rise by 2060) of the Compact's projections.

The NOAA high curve adopted by the Compact is derived from the highest of four global sea level rise scenarios (i.e., highest, intermediate-high, intermediate-low, and lowest) presented in NOAA Technical Report OAR CPO-1 (Parris et al. 2012). As stated by Parris et al. (Parris et al. 2012), the highest scenario, in part, assumes "the maximum possible glacier and ice sheet loss." Similarly, with regard to the USACE high curve, USACE Technical Letter No. 1100-2-1 (DOA 2014) indicates that the USACE high curve exceeds the upper boundaries

for projected sea level rise from the Intergovernmental Panel on Climate Change for 2001, 2007, and 2013. The curve further accounts for the possibility of rapid ice loss from Antarctica and Greenland, and generally falls between the highest and intermediate high curves given in Parris (Parris et al. 2012). Finally, the Compact's adoption of RCP 8.5 represents another rather conservative assumption. As noted in the USGCRP report (USGCRP 2017), the RCP 8.5 scenario in part assumes that global carbon emissions continue to rise steadily due to continued fossil fuel combustion, whereas other scenarios reflect varying reductions in emissions.

Based on the studies referenced above, it is apparent that rising sea levels will continue to have measurable hydrologic effects on coastal communities, but those effects may vary in severity on a local and regional basis. As sea levels rise, the incidence of tidal flooding in coastal areas due to all coastal storms will increase, as will the depth and extent of such flooding (USGCRP 2017, 2018). Further, the USGCRP reports that there is medium confidence that the intensity of North Atlantic hurricanes will increase, thus increasing the chances of extreme flooding along the East and Gulf Coasts. However, as noted above, there is less confidence in the projected increase in frequency of intense storms including Atlantic hurricanes (USGCRP 2017, 2018). Modeling also suggests that predicted changes in the tracks of tropical cyclones may reduce hurricane landfalls along the Northeast and Mid-Atlantic coasts of the United States (USGCRP 2018).

Changes in climate have broader implications for public health, water resources, land use and development, and ecosystems. For instance, changes in precipitation patterns and increases in air temperature can affect water availability and quality, distribution of plant and animal species, land use patterns, and land cover, which can, in turn, affect terrestrial and aquatic habitats. In Section 4.16 of this SEIS, the NRC staff considers the potential cumulative, or overlapping, impacts from climate change on environmental resources that could also be impacted by the proposed action (subsequent license renewal).

The effects of climate change on Turkey Point Unit 3 and 4 structures, systems, and components are outside the scope of the NRC staff's license renewal environmental review. The environmental review documents the potential effects from continued nuclear power plant operation on the environment. Site-specific environmental conditions are considered when siting nuclear power plants. This includes the consideration of meteorological and hydrologic siting criteria as set forth in 10 CFR Part 100, "Reactor Site Criteria." Turkey Point was designed and constructed in accordance with 10 CFR Part 50, Appendix A, "General Design Criteria for Nuclear Power Plants." NRC regulations require that plant structures, systems, and components important to safety be designed to withstand the effects of natural phenomena, such as flooding, without loss of capability to perform safety functions. Further, nuclear power plants are required to operate within technical safety specifications in accordance with the NRC operating license, including coping with natural phenomena hazards. The NRC conducts safety reviews prior to allowing licensees to make operational changes due to changing environmental conditions. Additionally, the NRC evaluates nuclear power plant operating conditions and physical infrastructure to ensure ongoing safe operations under the plant's initial and renewed operating licenses, through the NRC's reactor oversight program. If new information about changing environmental conditions (such as rising sea levels that threaten safe operating conditions or challenge compliance with the plant's technical specifications) becomes available, the NRC will evaluate the new information to determine if any safety-related changes are needed at licensed nuclear power plants.

As part of the NRC's subsequent license renewal review for Turkey Point Units 3 and 4, a safety review was conducted. The NRC staff issued its initial safety evaluation report in May 2019 (NRC 2019I), and a final safety evaluation report in July 2019. While the NRC's safety review does not include a flood analysis of Turkey Point Units 3 and 4 or for the CCS in particular, it does document a requirement that FPL develop and implement an aging management program for the CCS as related to water-control structures, the failure of which could impact safety-related equipment. Aging management programs are implemented at the beginning of a new licensing period. FPL has stated in its license renewal application that the aging management program for the CCS will be commensurate with Regulatory Guide 1.12, "Criteria and Design Features for Inspection of Water-Control Structures Associated with Nuclear Power Plants" (NRC 2016e). The aging management program proposed by FPL specific to the CCS will include:

- 1) Visual inspections performed at least once every 5 years.
- 2) Special inspections will be performed following major events such as hurricanes.
- 3) Photographs will be used to document findings and trend degradation.
- 4) The inspections will be consistent with the 10 elements of NUREG-2191, Section XI.S7. "Inspection of Water-Control Structures Associated with Nuclear Power Plants" (NRC 2017c).
- 5) Parameters monitored for the CCS will be enhanced to include erosion and degradation.

In addition, as described above in Section 3.5.1.3, FPL's draft NPDES permit for the Turkey Point site issued by FDEP includes requirements for impoundment design, construction, operation, and maintenance. While the NRC aging management program is concerned with the safe operation of Units 3 and 4, the requirements of the NPDES permit address potential impacts on the environment from a structural failure of the CCS.

Based on the requirements of both the NRC's aging management program and the State-issued NPDES permit, the NRC staff has determined that the NRC's oversight process would monitor the structural integrity of the CCS over the duration of the subsequent license renewal term, and the FDEP's NPDES permit requirements will ensure that the CCS is monitored for any degradation that may lead to environmental impacts. FPL is required to report degradation of the CCS to State regulatory agencies to ensure that timely remedial actions can be taken.

As described above, ensuring continued safe operation of an operating nuclear power plant is a separate and distinct process from the NRC staff's subsequent license renewal environmental review that the staff conducts in accordance with the National Environmental Policy Act (NEPA). Nonetheless, as discussed below, the NRC staff considers the impacts of climate change in combination with the effects of subsequent license renewal, in assessing cumulative impacts on environmental resources in Section 4.16 of this SEIS.

4.16 Cumulative Impacts

Cumulative impacts may result when the environmental effects associated with the proposed action (e.g., subsequent license renewal) are added to the environmental effects from other past, present, and reasonably foreseeable future actions. Cumulative impacts can result from individually minor, but collectively significant, actions taking place over a period of time. An effect that may be inconsequential by itself could result in a greater environmental impact when combined with the effects of other actions. As explained in NUREG-1437, "Generic

Environmental Impact Statement for License Renewal of Nuclear Plants” (the GEIS) (NRC 2013a), the effects of the license renewal action combined with the effects of other actions could generate cumulative impacts on a given resource.

For the purposes of this analysis, past actions are those that occurred since the commencement of Turkey Point Units 3 and 4 reactor operations and prior to the submittal of the license renewal application. Older actions are considered as part of the affected environment in Chapter 3 of this SEIS. Present actions are those that are occurring during current power plant operations. Future actions are those that are reasonably foreseeable to occur through the end of power plant operation, including the period of extended operation. Therefore, the cumulative impacts analysis considers potential effects through the end of the current license term, as well as through the end of the 20-year subsequent license renewal term.

The cumulative impacts analysis accounts for both geographic (spatial) and time (temporal) considerations of past, present, and reasonably foreseeable future actions to determine whether other potential actions are likely to contribute to the total environmental impact. In addition, because cumulative impacts accrue to resources and focus on overlapping impacts with the proposed action, no cumulative impacts analysis was performed for resource areas where the proposed action is unlikely to have any incremental impacts on that resource. For example, because FPL is prohibited from discharging effluents into surface waters of the State and because impacts to surface water bodies via the groundwater pathway are projected to be SMALL during the subsequent license renewal period, subsequent license renewal is not expected to have a cumulative impact on surface water quality. Consequently, no cumulative impacts analysis was performed for the following resource areas: land use, noise, surface water, and geology and soils.

As noted in Section 4.15.3.2, “Climate Change,” of this SEIS, changes in climate could have broad implications for certain resource areas. Accordingly, a climate change impact discussion is provided for those resource areas that could be incrementally impacted by the proposed action (subsequent license renewal). It is also important to note that the potential effects of climate change would occur irrespective of the proposed action.

Information from FPL’s environmental report; responses to requests for additional information; information from other Federal, State, and local government agencies; scoping comments; and information gathered during the NRC staff’s visit to Turkey Point were used to identify past, present, and reasonably foreseeable future actions in the cumulative impacts analysis. To evaluate cumulative impacts resulting from the continued operation of Turkey Point Units 3 and 4, the incremental impacts of the proposed action, as described in Sections 4.2 to 4.13 of this SEIS, are combined with the impacts of other past, present, and reasonably foreseeable future actions regardless of which agency (Federal or non-Federal) or person undertakes such actions. In general, the effects of past actions have already been described in Chapter 3 of this SEIS, the affected environment, which serves as the environmental baseline for the cumulative impacts analysis.

Chapter 7.0 of the NRC staff’s EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a) provides a recent analysis of cumulative impacts at the Turkey Point site resulting from the construction and operation Turkey Point Units 6 and 7. Table 7-1 in NUREG-2176 identifies the past, present, and reasonably foreseeable future actions and other actions near the Turkey Point site, including Everglades restoration, and other energy, mining, and transportation projects considered in the analysis. All of this information is incorporated here by reference (NRC 2016a: pages 7-1 through 7-46).

The NRC staff identified as an additional future action, a plan that SDI Aggregate, LLC, a private project located at a quarry approximately 5.5 mi (9 km) west of Turkey Point, has to install a series of injection wells to mitigate the progression of saltwater intrusion westward. The SFWMD issued a consumptive use permit for this project in 2017 (SFWMD 2017a).

In addition, two potential future actions at the Turkey Point site were identified during the subsequent license renewal review: (1) the possible construction and operation of a Miami-Dade County wastewater treatment facility and (2) the possible expansion of the Turkey Point Units 3 and 4 independent spent fuel storage installation (ISFSI). FPL and Miami-Dade County have agreed to investigate the potential to create a tertiary wastewater treatment facility that could provide up to 60 million gallons (approximately 230 million liters) per day of reclaimed wastewater for use at the Turkey Point site. Possible uses for this treated wastewater would include makeup water for Turkey Point Unit 5 forced draft cooling towers and freshening water to assist in managing salinity in the cooling canal system (CCS). If constructed, this tertiary wastewater treatment facility could provide reclaimed water to the CCS during the subsequent license renewal period of extended operations. To date, FPL and Miami-Dade County have not yet committed to building this facility.

FPL may also need to expand the Turkey Point Units 3 and 4 ISFSI, which could require the construction of a new ISFSI pad to accommodate additional spent nuclear fuel generated during the subsequent license renewal term, if DOE does not begin to take ownership of the spent nuclear fuel in 2031 (FPL 2018g). Conversely, FPL may choose to utilize a higher density storage system to create additional storage capacity, thereby reducing the need to expand the ISFSI. As a result, FPL has not yet determined whether it would expand the ISFSI.

Regardless, if implemented, each of these actions would likely be completed prior to the commencement of the subsequent license renewal term. No other new and significant information was identified during the NRC staff's review of FPL's environmental report for Turkey Point Units 3 and 4 (FPL 2018f), the site audit, the scoping process, or the evaluation of other available information since the Turkey Point Units 6 and 7 COL EIS was issued (NUREG 2176) (NRC 2016a).

4.16.1 Air Quality

The region of influence (ROI) that the NRC staff considered in the cumulative air quality analysis is Miami-Dade County because air quality designations in Florida are made at the county level. FPL has not proposed any refurbishment-related activities during the subsequent license renewal period. As a result, the NRC staff expects that air emissions at Turkey Point during the subsequent license renewal period would be similar to those presented in Section 3.3.2, "Air Quality." Table 7-1 of the NRC staff's EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a), which is incorporated by reference in Section 4-16 of this SEIS, provides a list of present and reasonably foreseeable future projects that could contribute to cumulative impacts to air quality in Miami-Dade County. Current air emission sources operating in Miami-Dade County have not resulted in long-term National Ambient Air Quality Standards (NAAQS) violations given the designated unclassifiable/attainment status for all NAAQS in Miami-Dade County. Consequently, cumulative changes to air quality in Miami-Dade County would be the result of future projects and actions that change present-day emissions within the county.

The development and construction activities identified above in Section 4.16 and those identified in Table 7-1 of the EIS for the Turkey Point Units 6 and 7 combined licenses

(NUREG-2176) (NRC 2016a) can increase air emissions during their respective construction periods, but those air emissions would be temporary and localized. However, future operation of new commercial and industrial facilities and increases in vehicular traffic can result in overall long-term air emissions that contribute to cumulative air quality impacts. Any entity establishing new stationary sources of emissions in the region of influence would be required to apply for an air permit from the FDEP and would also be required to operate in accordance with applicable Federal, State, and local regulatory requirements.

Climate Change

Climate change can impact air quality as a result of changes in meteorological conditions. The formation, transport, dispersion, and deposition of air pollutants depend, in part, on weather conditions (IPCC 2007). Ozone has been found to be particularly sensitive to climate change (IPCC 2007; EPA 2009a). Ozone is formed, in part, as a result of the chemical reaction of nitrogen oxides and volatile organic compounds in the presence of heat and sunlight. Sunshine, high temperatures, and air stagnation are favorable meteorological conditions for higher levels of ozone (IPCC 2007, EPA 2009b). The emission of ozone precursors also depends on temperature, wind, and solar radiation (IPCC 2007). According to the EPA, both nitrogen oxide and biogenic volatile organic compound emissions are expected to be higher in a warmer climate (EPA 2009a). Although surface temperatures are expected to increase in the Southeast region of the United States (where Turkey Point is located), this may not necessarily result in an increase in ozone concentrations (Diem et al. 2017). For instance, during the fall in the Southeast, ozone concentrations correlate with humidity (Zhang and Wang 2016). Wu et al. (Wu et al. 2008) modeled changes in ozone levels in response to climate change and found negligible climate change-driven ozone concentrations for the Southeast region. Tao et al. (Tao et al. 2007) found differences in future changes in ozone for the Southeast with decreases in ozone concentrations under a low-emission-modelled scenario and increase under a high-emission-modelled scenario. Among modelled studies of climate-related ozone changes, model simulations for the Southeast region have the least consensus. Therefore, the potential cumulative impact to air quality ozone levels in the vicinity of Turkey Point due to climate change is unknown.

4.16.2 Water Resources

4.16.2.1 Groundwater Resources

The description of the affected environment in Section 3.5.2, “Groundwater Resources,” of this SEIS serves as the baseline for the NRC staff’s cumulative impacts assessment for groundwater resources. For groundwater, the geographic area of interest is comprised of the local and regional aquifer systems potentially affected by Turkey Point operations, the surficial (i.e., Biscayne) and Floridan aquifer systems. As such, this review focuses on those projects and activities that would withdraw water from, or discharge effluents to, the referenced aquifer systems.

Water Use Considerations

As part of the NRC staff’s analysis for proposed Units 6 and 7, Sections 7.2.1.2, “Groundwater-Use Impacts,” and Appendix G, Section G.3.2.3, “Summary of Review Team Focused Modeling,” of the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG–2176, NRC 2016a: 7-13–7-14, G-46–G-48) evaluate the cumulative impacts on groundwater use. The analysis considered preconstruction, construction, and operations of proposed Units 6 and 7 as

well as the other past, present, and reasonably foreseeable future actions that could affect groundwater uses, including some ongoing activities at the Turkey Point site and the potential continued operation of Turkey Point Units 3 and 4 through subsequent license renewal. In summary, the NRC staff concluded the following:

- The impacts from NRC-authorized construction from Units 6 and 7 and operations from Units 3, 4, 5, and 6 on groundwater use would be SMALL, and no further mitigation would be warranted beyond the State of Florida Siting Board's final conditions of certification (State of Florida Siting Board 2014).
- Limited operation of the four proposed radial collection wells at a withdrawal rate of 120 mgd (454,000 m³/day) on the Turkey Point peninsula would have minor impacts on Biscayne aquifer users, although continued development and increased groundwater use could lower groundwater levels in the aquifer and cause further inland movement of the saltwater interface.
- There would be an increase in hydraulic head beneath the CCS associated with the addition of groundwater to the CCS for freshening with operation of recovery wells. Operation of hypersaline plume recovery wells could locally decrease heads in the aquifer. Radial collection well operation for Units 6 and 7 would result in minor localized alterations in salinity distribution.

The NRC staff incorporates here by reference these findings from the EIS for the Turkey Point Units 6 and 7 combined licenses (NRC 2016a: 7-13–7-14, G46–G-48).

Section 4.5.1.2 of this SEIS, "Conflicts Analysis for the Upper Floridan Aquifer," separately describes and evaluates the potential impacts of FPL's withdrawals from the Upper Floridan aquifer. FPL is authorized to withdraw 14.06 mgd (53,200 m³/day) of groundwater from the upper production zones of the Upper Floridan aquifer for cooling water for Turkey Point Unit 5 and process water for Units 1, 2, 3, 4, and 5 (i.e., from three site production wells). FPL is authorized to withdraw an additional 14 mgd (53,000 m³/day) from the freshening well system (i.e., wells F-1, F-3, F-4, F-5, F-6). These withdrawals are authorized under the modified site certification and associated conditions of certification for the Turkey Point site (State of Florida Siting Board 2016, FDEP 2016b). FPL commissioned Tetra Tech, a consulting and engineering services firm, to prepare a technical evaluation and associated groundwater flow model (Tetra Tech 2014b) to evaluate the proposed freshening withdrawals from the Upper Floridan aquifer to support FPL's 2014 site certification modification for Turkey Point (FPL 2018n).

The technical evaluation and results indicate that operation of the freshening well system at the maximum rate of 14 mgd (53,000 m³/d) could result in maximum, offsite drawdowns of up to 2.26 feet (0.7 m) at the Miami-Dade Water and Sewer Department's (MDWSD's) South Miami Heights wellfield, located approximately 10.3 mi (16.6 km) north, northwest of the center point of FPL's freshening well system. Further, modeling shows that the incremental drawdown from freshening well system operations could account for 5 percent to as much as 19 percent of the total predicted cumulative drawdown from all permitted withdrawals from the Upper Florida aquifer at offsite locations. Specifically, the modeling projects incremental drawdown of up to 2.21 feet (0.67 m) at Sound Golf Club and Ocean Reef Club (about 9 mi (14 km) south of the FPL freshening wells); these drawdowns account for 19 percent of the total cumulative drawdown at these locations (Tetra Tech 2014b).

While the reported modeling results reflect conservative, bounding-case impacts, the results nonetheless indicate the potential for measurable cumulative impacts on groundwater within the

Upper Floridan aquifer. However, the NRC staff finds that the magnitude of FPL's withdrawals and projected cumulative drawdowns would be unlikely to preclude aquifer availability and cause groundwater use conflicts for other users based on the aquifer yields, total thickness, and regional extent, under current conditions. In addition, the State-issued modified site certification and associated conditions of certification for the Turkey Point site (State of Florida Siting Board 2016, FDEP 2016b) require FPL to mitigate harm to offsite groundwater users (either related to water quantity or quality) as well as to offsite water bodies, land uses, and other beneficial uses. As necessary, the SFWMD could require FPL to reduce withdrawals or undertake other mitigative actions during the subsequent license renewal term, as further described in Section 4.5.1.2 of this SEIS.

Implementation of the proposed project to treat up to 60 mgd (227,000 m³/day) of sanitary wastewater from Miami-Dade County for use by FPL at the Turkey Point site would likely have net, beneficial cumulative impacts on groundwater use. Using treated sanitary wastewater in the CCS would potentially reduce or eliminate the need to operate FPL's freshening well system, which conveys artesian groundwater from the Upper Floridan aquifer into the CCS for salinity management. Any reduction in groundwater withdrawals from the Upper Floridan aquifer would reduce regional aquifer drawdown.

Operation of the proposed freshwater injection system at the limestone quarries located approximately 5 mi (8 km) west of the CCS and Turkey Point property would be likely to have net, beneficial cumulative impacts on groundwater use and quality. As proposed and permitted by SFWMD, the project would entail the withdrawal of up to 5 mgd (19,000 m³/day) of fresh groundwater from a single well completed to a depth of 40 feet (12 m). This water would then be reinjected into the aquifer through a series of 14, 75-foot (23-m) deep injection wells that are aligned along the eastern edge of the quarry property. Rejection of the groundwater is intended to form an eastward hydraulic barrier to protect the quarry property from encroachment of the regional saltwater interface (SFWMD 2017b). The system is also expected to contribute to efforts to retract the regional saltwater interface to the east, working in conjunction with FPL's recovery well system, as evaluated in Section 4.5.1.2 of this SEIS. The modeling performed by the project applicant and reviewed by SFWMD staff, as documented in its staff report, indicates that operation of the system would have minimal offsite drawdown in the Biscayne aquifer (SFWMD 2017b).

The NRC staff assumes that the freshwater injection system at the limestone quarries would continue at least as long as operation of FPL's recovery well system, since it is intended to work alongside FPL's recovery well system. As stated in Section 4.5.1.2 of this SEIS, current modeling projections indicate that FPL's recovery well system will be successful in retracting the hypersaline plume back to within the boundaries of the CCS within 10 years of startup (i.e., by about 2028) while also retracting the saltwater interface back to the east from its current location. If these projections are realized, then it is possible that neither the freshwater injection system project nor FPL's recovery well system will be operating by the start of Turkey Point's subsequent license renewal term (i.e., 2032 for Unit 3 and 2033 for Unit 4). In that case, neither activity would contribute to cumulative impacts associated with the proposed action (subsequent license renewal). Nonetheless, it is possible that FPL's recovery well system might remain in operation for as long as necessary to achieve and maintain compliance with applicable provisions under the 2015 Consent Agreement with Miami-Dade County DERM (MDC 2015a) and the 2016 Consent Order (FDEP 2016a) with FDEP.

Water Quality Considerations

In Section 7.2.2.2, “Groundwater-Quality Impacts,” of the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG–2176, NRC 2016a), the NRC staff presented its evaluation of the potential cumulative impacts on groundwater quality. The analysis considered preconstruction, construction, and operations of proposed Units 6 and 7 as well as the other past, present, and reasonably foreseeable future actions that could affect groundwater quality, including some ongoing activities at the Turkey Point site and the potential continued operation of Turkey Point Units 3 and 4. In summary, the NRC staff concluded the following:

- The impacts from NRC-authorized construction and operations on groundwater quality would be SMALL, and no further mitigation would be warranted beyond the State of Florida Siting Board’s final conditions of certification (State of Florida Siting Board 2014).
- Ongoing and future actions being undertaken by Federal, State, and local government agencies to enhance freshwater recharge of the Biscayne aquifer would potentially have a positive impact on groundwater quality by reducing the potential for westward movement of the saltwater interface.
- The addition of brackish water from the Upper Floridan aquifer to the CCS would be likely to lower temperature, salinity, and concentration of other constituents in the CCS; this would result in lower salt concentrations in water seeping out of the CCS and into the Biscayne aquifer and thus reduce impacts on the Biscayne aquifer.
- Deep well injection of wastewater into the Boulder Zone proposed for Units 6 and 7 combined with wastewater injection operations at the Miami-Dade South District Wastewater Treatment Plant would be unlikely to contribute to cumulative effects on groundwater quality in the Boulder Zone or result in degradation of groundwater quality in the overlying Upper Floridan aquifer.
- Mining operations in the region to support construction of Turkey Point Units 6 and 7 could affect groundwater quality by increasing salinity in underlying groundwater, but regulation of mining operations would ensure that cumulative impacts would be minor.

The NRC staff incorporates here by reference all of the above findings (NRC 2016a: 7-13, 7-16–7-18).

As previously described, the operation of FPL’s recovery well system is projected to be successful in retracting the hypersaline plume back to within the boundaries of the CCS within 10 years of startup (i.e., by about 2028) while also retracting the saltwater interface back to the east from its current location. This would result in beneficial impacts on groundwater quality within the Biscayne aquifer to the west of the CCS and the Turkey Point site as well as in the portions of the aquifer beneath Biscayne Bay affected by CCS operations. The NRC staff finds that it is reasonable to expect that FPL’s freshening well system would continue to be operated during the subsequent license renewal term, and for as long as necessary to maintain compliance with the terms of the 2015 Consent Agreement with Miami-Dade County DERM (MDC 2015a) and the 2016 FDEP Consent Order (FDEP 2016a). The continuation of CCS freshening (salinity management) activities would ensure that the average annual salinity of the CCS is maintained at or below 34 PSU, to control the generation and migration of a hypersaline plume in groundwater. The NRC staff expects that continued operation of the freshening system, combined with proper operation and maintenance of the CCS, will result in no substantial contribution to cumulative impacts on groundwater quality during the subsequent license renewal period.

Climate Change and Related Considerations

The NRC staff considered the best available information regarding the potential impacts of climate change at a regional and local scale, including the U.S. Global Change Research Program's (USGCRP's) most recent compilations of the state of knowledge relative to global climate change effects (USGCRP 2014, USGCRP 2017). In Appendix I, Section I.3.2 of the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176, NRC 2016a), the NRC staff considered potential hydrologic changes related to climate change. Climate change can impact groundwater availability and quality as a result of changes in temperature and precipitation, as well as due to sea level rise.

As discussed in Section 4.15.3.2, "Climate Change," of this SEIS, average annual temperature across the lower east coast region of South Florida has increased at a rate of 0.2 °F (0.11 °C) per decade and is projected to continue to increase by up to 3.5 °F (1.9 °C) by 2050. Although annual precipitation data show no clear trend, climate model simulations indicate a slight decrease in annual mean precipitation by 2050. However, heavy precipitation events are expected to increase in both frequency and intensity. Changes in temperature and precipitation have important implications for near- or at-surface water table aquifers, such as the Biscayne aquifer of South Florida (see Section 3.5.2.1, "Hydrogeology and Aquifers," of this SEIS), which is locally recharged by precipitation and runoff and is the primary source of water supply for Miami-Dade County. An increase in average annual temperature without any increase in annual precipitation would likely increase evapotranspiration and reduce recharge to the Biscayne aquifer. Projected increases in heavy precipitation events could increase recharge during the timeframe when they occur. However, increases in heavy precipitation events and intensity without an annual increase in total precipitation would be unlikely to compensate for decreased recharge throughout the year.

The effects of climate change are projected to significantly increase water demand across most of the United States. Water demand across South Florida is projected to increase by more than 50 percent by 2060, relative to 2005, based on combined changes in population, socioeconomic conditions, and climate (NRC 2016a) (USGCRP 2014, Figure 3.11). For most of Florida, this increase in demand is forecast even without assuming climate change (USGCRP 2014, Figure 3.11). Regardless, climate change, mainly due to increases in temperature and evapotranspiration, would decrease water availability and further drive demand.

By about 2050, the USGCRP projects that global sea levels may rise by an additional 0.5 to 1.2 feet (0.15 to 0.37 m). This rise is likely to be higher along the East Coast of the United States (USGCRP 2017). Higher sea levels will increase the rate of saltwater intrusion (encroachment) into coastal freshwater supplies (USGCRP 2014). This is particularly true for the Biscayne aquifer, as referenced previously, but also for the confined, Upper Floridan aquifer, which is a designated underground source of drinking water across South Florida (see Sections 3.5.2.1 and 3.5.2.2 of this SEIS).

A rise in sea level would have the most direct impacts on the Biscayne aquifer. Currently, the saltwater interface is located about 4.7 mi (7.6 km) west of the Turkey Point site and the CCS at its closest point, as described in Sections 3.5.2.1 and 3.5.2.2 of this SEIS. As sea levels rise, saltwater from the east would move along the base of the Biscayne aquifer, pushing the saltwater interface farther to the west from its current location. Combined with sea level rise, decreases in recharge to the Biscayne aquifer would reduce the freshwater hydraulic head in the Biscayne aquifer, further increasing the potential for westerly migration of the saltwater interface across Miami-Dade County.

The potential for additional saltwater intrusion has significant implications for Miami-Dade County, other public water supply systems, and private and industrial users of the Biscayne and other affected aquifers. Increased salinity levels in groundwater supplies would increasingly require public and private groundwater users to invest in treatment technologies (e.g., desalination), to relocate supply wells and supporting infrastructure, to seek out and develop new water supply sources, or to pursue a combination of approaches to manage degraded groundwater quality.

In summary, increasing temperatures and steady or slightly decreasing average precipitation, combined with sea level rise, are expected to reduce groundwater recharge, degrade groundwater quality, and reduce water availability in southeastern Florida during the subsequent license renewal term. Therefore, climate change is expected to have adverse cumulative impacts on groundwater resources in the vicinity of Turkey Point.

4.16.3 Terrestrial Resources

The description of the affected environment in Section 3.6, “Terrestrial Resources,” of this SEIS serves as the baseline for the NRC staff’s cumulative impacts assessment for terrestrial resources. For terrestrial resources, the geographic area of interest is comprised of the Turkey Point site and offsite wetlands that could be impacted by FPL’s efforts to recover and extract the hypersaline water within and around the CCS as described in Section 3.6.1, “Vegetative Communities.”

In Section 7.3.1 of the EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176, NRC 2016a), the NRC staff described the cumulative impacts that terrestrial resources on and near the Turkey Point site may experience. In its assessment, the staff considered the historical context of the region, including prior drainage, development, and other modifications within South Florida and the concomitant loss in species diversity and habitat. Present and reasonably foreseeable future activities considered in the analysis included urban development, energy production, mining, manufacturing, transportation and infrastructure development, and other miscellaneous activities that could affect terrestrial and wetland resources. The NRC staff (NRC 2016a) also considered current efforts to restore or improve ecological habitat, including the Comprehensive Everglades Restoration Program and the Southern Glades Addition. In addition, the NRC staff’s cumulative impacts analysis (NRC 2016a) considered the overlapping impacts of construction and operation of proposed Turkey Point Units 6 and 7 with the impacts from continued operations at Units 3 and 4, such as any impacts to offsite wetlands from the removal of water from the L-31E Canal during periods of excess flow, for use in freshening the CCS. Appendix I, Section I.3.3 describes the potential overlapping impacts with climate change. The NRC staff incorporates here by reference the above cumulative impacts analyses from NUREG-2176 (NRC 2016a, Section 7.3.1, pages 7-19 to 7-23).

Since the NRC published the EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) (NRC 2016a), the NRC staff has determined that the possible construction and operation of a mine and a Miami-Dade County wastewater treatment facility, as well as the expansion of the Turkey Point Units 3 and 4 ISFSI, could result in additional overlapping impacts to wetlands and other important terrestrial resources. Construction could result in both the permanent and temporary loss of important terrestrial habitats, habitat fragmentation, and habitat degradation as a result of runoff, erosion, and sedimentation. Wildlife and birds would likely avoid the area during construction due to noise and other disturbances. Collisions with tall structures and vehicles could also result in mortality. However, the implementation of appropriate best management practices, revegetation following construction, and required

compensatory mitigation for unavoidable wetland impacts would minimize such impacts. Furthermore, locating these projects within previously disturbed areas would minimize any potential impacts to important terrestrial habitats. FPL (2018g) determined that if Turkey Point requires a new ISFSI, the preferable candidate site would be located on previously disturbed land within or adjacent to the Units 3 and 4 protected area.

4.16.4 Aquatic Resources

The description of the affected environment in Section 3.7, “Aquatic Resources,” in this SEIS serves as the baseline for the NRC staff’s cumulative impacts assessment for aquatic resources. For aquatic resources, the geographic area of interest is comprised of the CCS and other surface waters on the Turkey Point site (i.e., the hypersaline mudflats, remnant canals, channels, dwarf mangrove wetlands, and open water areas described in Section 3.7.3, “Aquatic Resources on the Turkey Point Site”) as well as Biscayne Bay. As such, this review focuses on those projects and activities that would affect the aquatic biota and habitats within this geographic area.

Many natural and human activities influence the characteristics of these aquatic environments and the condition of the aquatic resources found in them. In Section 4.7.1, “Proposed Action,” the NRC staff concludes that impingement, entrainment, and thermal effects associated with the proposed subsequent license renewal would result in SMALL to MODERATE effects on the aquatic resources of the CCS. These effects would not apply to aquatic resources within Biscayne Bay because there are no surface water connections that allow aquatic organisms inhabiting the Bay to interact with Turkey Point’s intake or discharge. All other potential impacts of subsequent license renewal on aquatic resources would be SMALL. In Section 7.3.2 of the EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176), the NRC (2016a) staff considered a number of past, present, and reasonably foreseeable future actions whose effects could overlap, resulting in cumulative impacts on the aquatic resources on the Turkey Point site and within Biscayne Bay. In its analysis, the NRC staff evaluated the following cumulative effects, which the staff hereby incorporates by reference.

- Historical context of the region, including prior drainage, development, and other modifications within South Florida (pages 7-24 to 7-25)
- Existing units on the Turkey Point site (i.e., Units 1, 2, 3, 4, and 5) (pages 7-25 to 7-26)
- Ecological restoration initiatives and management programs, including the Model Lands Basin and Southern Glades Addition; the Biscayne Bay Park Fishery Management Plan; the Comprehensive Everglades Restoration Program; and Florida Keys National Marine Sanctuary (pages 7-26 to 7-28)
- Population growth and coastal development (pages 7-28 to 7-29)
- Future construction and operation of Turkey Point Units 6 and 7 (Section 4.3.2; summarized on pages 4-97 to 4-98)

The NRC staff considers the following additional actions below: the past and current operations of the CCS, the possible construction and operation of several new industrial facilities, and climate change.

Past and Current Operations of the CCS

The CCS supports the operation of Turkey Point Units 3 and 4 as well as Turkey Point Units 1 and 2. Although Units 1 and 2 no longer generate electricity, their use of the CCS as a cooling water source has contributed to the changes in the CCS over time. Currently, Units 1 and 2 circulate a small amount of water from the CCS to support synchronous condenser mode. However, because Units 1 and 2 no longer produce steam, they do not discharge heated water to the CCS. Section 3.1.3.2, "Cooling Canal System," of this SEIS contains a detailed description of the CCS and its operation. Section 3.5.1.4 of this SEIS describes water quality in the CCS and adjacent surface waters as well as the State-required monitoring and mitigation that FPL has undertaken or is in the process of undertaking. As described in these sections, the CCS began experiencing a visible ecosystem shift beginning in 2010 and CCS water quality has deteriorated over the past decade. The average salinity of the CCS has increased, water quality and clarity have degraded, and average surface water temperatures have increased. Seagrass colonies died off, and the subsequent decomposition of dead organic matter released a significant volume of nutrients into the CCS. This facilitated algae blooms, which resulted in high turbidity and further degraded water quality. Whereas the CCS had previously been a seagrass-based ecological system, it now operates as an algal-based, phosphorus-limited system such that the algae life cycle primarily dictates the movement of nutrients in and out of the water column. As discussed in Section 4.7.1.2, "Thermal Impacts on Aquatic Organisms (Plants with Once-Through Cooling Systems or Cooling Ponds)," a number of species of fish, mollusks, crabs, and seagrasses have disappeared from the CCS in recent years. Thermal stress is one factor that has likely contributed to these disappearances (EAI 2017).

FPL is in the process of implementing a Nutrient Management Plan as a requirement of the FDEP Consent Order. The plan includes an initiative to re-establish seagrass meadows in the CCS. FPL (2016k) states in its Nutrient Management Plan that a healthy seagrass population growing over approximately 50 percent of the CCS surface water acreage would help balance and sequester the CCS's nutrient content. FPL's plan to re-establish seagrass is described in more detail in Section 3.7.3, "Aquatic Resources on the Turkey Point Site," of this SEIS. To date, FPL has identified no clear evidence that the CCS is having an ecological impact on Biscayne Bay or other adjacent surface waters (see Section 3.7.4, "Biscayne Bay and Card Sound Semiannual Monitoring," for more details) (E&E 2017).

Possible Construction and Operation of New Industrial Facilities

Since the NRC published its EIS for the Turkey Point Units 6 and 7 combined licenses in 2016 (NRC 2016a), the NRC staff has identified several new industrial facilities that may be constructed and operated in the vicinity of the Turkey Point site. These include a mine, a Miami-Dade County wastewater treatment facility, and the expansion of the Turkey Point ISFSI. Construction (or expansion) of these facilities could result in the temporary or permanent loss of wetlands and mangrove forests that function as important habitats for early life stages of fish and shellfish. Any permanent losses of aquatic habitats could create habitat fragmentation that would affect ecosystem function and connectivity. Habitat degradation associated with runoff, erosion, and sedimentation during construction could also occur. Additionally, direct mortality of aquatic organisms could result from dredging, wetland and mangrove filling, and other necessary in-water work. Barge traffic associated with delivery of construction supplies and plant components to the site would release pollutants into aquatic habitats and could result in collision-related mortality of larger aquatic organisms, especially turtles and marine mammals. Appropriate permits would mitigate some water quality and aquatic resource impacts by requiring implementation of best management practices or other mitigation during construction

and/or operation. The USACE or the FDEP would oversee applicable Clean Water Act permitting, including Section 404 permits for dredging and fill activities, Section 401 certification, and Section 402(p) NPDES general stormwater permitting. Once built, operation of these new facilities would likely have minimal to no discernable impacts on aquatic resources.

Climate Change

Section 4.15.3.2, "Climate Change," of this SEIS describes current climate change research and predictions across the contiguous United States as well as specific to the Southeast region of the United States and South Florida. The NRC staff also describes in that section the climate changes expected to occur over the course of the Turkey Point subsequent license renewal term, based on currently available climate model simulations. The primary climate changes that could affect aquatic resources during this timeframe include sea level rise of between 0.5 to 1.2 feet (0.15 to 0.37 m) by 2050 and increased storm frequency and intensity.

Sea level rise would likely alter the hydrological regime and flow and could result in saltwater intrusion, erosion, and inundation of coastal areas. This would affect the quality, quantity, and spatial distribution of wetlands and mangrove forests. Some of these habitats could become open water, which would reduce available nursery habitat for early life stages of many fish and shellfish. Loss of such habitats could affect the success of ongoing and planned restoration activities in the region. For example, in an analysis of the effects of climate-induced sea level rise on the success of the Biscayne Bay Coastal Wetlands Phase 1 Project, the USACE and the SFWMD estimated that by 2032, approximately 8 percent of the project's ecosystem benefits were likely to be at risk from sea level rise; and by 2062, the project's expected benefits would be diminished by 41 percent (USACE and SFWMD 2011).

Storm frequency and duration would also affect aquatic habitats and coastal wetlands and mangroves. If storm intensities and durations increase, these important habitats would be more likely to suffer damage, which could affect hydrological regimes, quality, quantity, and ecosystem function until those habitats recover. Also, with increased storm frequency, these habitats would not have as much time to recover between storms. This would affect the coasts' ability to serve as a nursery for fish and shellfish, and this could have cascading population effects over time for those species that are highly dependent upon wetlands and mangroves during early life stages.

Another potential climate change-induced stressor on the aquatic environment in the geographic area of interest is the likely use of additional shoreline infrastructure or armoring to protect cities, urban areas, roads, bridges, and agricultural lands from rising sea levels. For instance, in Miami-Dade County, 4,358 km² (2,708 mi²) of land are at elevations of 5 m (16.4 feet) or less, and 3,500 km² (2,174 mi²) of land are 2 m (6.6 feet) or lower (Cela et al. 2010). Shoreline protection efforts in these areas could contribute to habitat fragmentation or interfere with activities designed to restore historic hydrological flow and ecological connections. Dredging and other in-water work associated with shoreline protection infrastructure could result in erosion, sedimentation, and water-quality degradation, although implementation of best management practices and appropriate State and Federal water quality permits would mitigate such effects. Direct injury or mortality of aquatic organisms could also result from these activities. Associated barge traffic and construction equipment use would release pollutants into aquatic habitats and could result in collision-related injury or mortality of larger aquatic organisms, especially turtles and marine mammals. Coupled with continued population growth and urbanization, shoreline protection infrastructure that becomes a permanent part of the coastal landscape could dramatically influence the future of aquatic resources in South Florida.

4.16.5 Socioeconomics

This section addresses socioeconomic factors that have the potential to be directly or indirectly affected by changes in operations at Turkey Point in addition to the aggregate effects of other past, present, and reasonably foreseeable future actions. The region of influence (ROI) considered in this cumulative analysis is Miami-Dade County, where approximately 85 percent of FPL employees reside (see Table 3-14). This is where the economy, tax base, and infrastructure would most likely be affected because the majority of Turkey Point workers and their families reside, spend their incomes, and use their benefits within Miami-Dade County. As discussed in Section 4.10, "Socioeconomics," continued operation of Turkey Point during the subsequent license renewal period would result in SMALL socioeconomic impacts.

Past, present, and reasonably foreseeable future actions within the ROI could contribute to cumulative socioeconomic impacts. Relevant actions in this cumulative impact analysis include future planned activities at the Turkey Point site that are unrelated to the proposed action of subsequent license renewal, future urbanization, population increases, transportation infrastructure projects, and other reasonably foreseeable planned offsite activities. Future activities and planned projects in the ROI could bring additional workers and traffic, thus increasing the local population and causing increased traffic on local roads and increased demand for public services. For instance, the construction and operation of the proposed new Turkey Point Units 6 and 7 would have an impact on Miami-Dade County's economy including impacts from traffic in the immediate vicinity of the Turkey Point site (NRC 2016a). For instance, construction and operation of Turkey Point Units 6 and 7 would result in beneficial socioeconomic impacts including additional wages, tax revenue, and jobs. However, construction and operation of Turkey Point Units 6 and 7 would have adverse impacts on traffic as a result of additional worker and delivery vehicles. Transportation infrastructure projects throughout the region can have beneficial impacts on road quality and infrastructure. Miami-Dade County has experienced increased migration into the county as a result of the continuing effects of Hurricane Maria, which occurred in 2017 (BEBR 2018); increases in population (see Table 3-17) can increase the demand for public services.

Changes in climate conditions could impact certain industries such as tourism and recreation, which create jobs and bring significant revenue to regional economies. The U.S. Global Change Research Program reports that climate changes (increases in ambient temperatures and humidity) in the Southeast region of the United States by the year 2050 could create unfavorable summertime outdoor conditions for recreation and tourism (USGCRP 2014). The Everglades and Florida Keys are vulnerable to sea level rise and the effects of climate change impacts on the availability and quality of these resources can result in tourism and revenue loss (USGCRP 2014). Changes or fluctuations in sea levels, storm surges, erosion, and sedimentation could affect port operations and the economic activities that ports support. In 2016, Port Miami contributed approximately \$1.3 billion in State and local taxes, supported approximately 324,400 jobs (including direct, indirect, and induced jobs) as a result of cargo and cruise activity, and saw approximately 5.3 million passengers pass through its portals (Port Miami 2017). Additionally, most of the petroleum products consumed by Florida are delivered by barge to ports (USGCRP 2009). Rising sea levels and extreme weather events can damage roads and coastal infrastructure. Property values are also vulnerable to sea level rise; studies indicate that properties in lower elevations sell for less or gain in value more slowly than those located in higher elevations (Keenan et al. 2018, Bernstein et al. 2017). Therefore, climate changes in the ROI could result in adverse socioeconomic and transportation impacts.

4.16.6 Historic and Cultural Resources

As described in Section 4.9, “Historic and Cultural Resources,” of this SEIS, historic structures and properties within the area of potential effect are not likely to be adversely affected by subsequent license renewal-related activities since the site area has low historical, cultural and archeological potential, and no ground-disturbing activities or physical changes would occur at Turkey Point during the subsequent license renewal term beyond ongoing maintenance activities. As discussed in Section 4.9, FPL has administrative controls on how to handle unanticipated historical and cultural finds related to potential ground-disturbing activities. Additionally, FPL provides training sessions to Turkey Point staff to ensure that plant personnel consider cultural resources during planned maintenance activities.

As described in Section 3.9, “Historic and Cultural Resources,” of this SEIS, the geographic area considered in this analysis is the area of potential effect associated with the proposed undertaking (subsequent license renewal for Turkey Point Units 3 and 4). In the NRC staff’s EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176), Table 7-1 summarizes present and reasonably foreseeable future actions that could affect historic properties at the Turkey Point site. Direct impact would occur if historic and cultural resources in the area of potential effect were physically removed or disturbed. For instance, the potential expansion of the ISFSI, the construction of a wastewater treatment facility, and the expansion of roads (transportation projects) could have direct impacts on cultural resources through inadvertent discovery during ground-disturbing activities or result in new above-ground structures that affect the visual area of potential effect. However, reasonable onsite activities conducted on the Turkey Point site could avoid the areas where historic structures, such as the McGregor Smith Cottage, are located. As discussed in Section 4.9.1.3, “Findings,” based on cultural resource surveys, the Turkey Point site has a low archeological potential. Additionally, FPL has administrative controls in place on how to handle unanticipated historical and cultural finds related to potential ground-disturbing activities.

Changes or fluctuations in sea levels because of climate change could result in the disturbance or loss of terrestrial historic and cultural resources from flooding, increased erosion, or inundation of shorelines and surrounding areas. As discussed in Section 4.15.3.2, “Climate Change,” of this SEIS, sea level is projected to continue to rise. Because of water-level changes, historic and cultural resources could be lost before they could be documented or studied. Rising sea levels, loss of land, and changes in temperature can affect the availability and access to local plant and animal species, thereby impacting the tribal communities who have historically depended on them for food or medicine (USGCRP 2014).

4.16.7 Human Health

The NRC and EPA have established radiological dose limits to protect the public and workers from both acute and long-term exposure to radiation and radioactive materials. These dose limits are in 10 CFR Part 20, “Standards for Protection Against Radiation,” and 40 CFR Part 190, “Environmental Radiation Protection Standards for Nuclear Power Operations.” As discussed in Section 4.11, “Human Health,” of this SEIS, the impacts to human health from continued plant operations during the subsequent license renewal term are SMALL. For the purposes of this cumulative impacts analysis, the geographical area considered is the area within a 50-mi (80-km) radius of Turkey Point Units 3 and 4. There are no other nuclear power plants within this 50-mi (80-km) radius. However, that radius does overlap with the 50-mi (80-km) radius around proposed Turkey Point Units 6 and 7, which would be sited directly adjacent to Turkey Point Units 3 and 4. As discussed in Section 3.1.4.4, “Radioactive Waste

Storage,” of this SEIS, FPL stores spent nuclear fuel from Units 3 and 4 in a storage pool and in an onsite independent spent fuel storage installation (ISFSI). As a reasonably foreseeable future project, FPL has stated that if the DOE does not take ownership of onsite commercial spent nuclear fuel by 2031, FPL may need to expand the Turkey Point Units 3 and 4 ISFSI storage capability to account for the additional spent nuclear fuel generated during the subsequent license renewal term.

Another reasonably foreseeable future action with the potential to contribute to cumulative radiological impacts is the proposed construction and operation of two new nuclear units (Turkey Point Units 6 and 7) at the Turkey Point site. The operation of Turkey Point Units 6 and 7 would result in radiological releases and dose impacts to workers and the public, in addition to the impacts resulting from operation of Units 3 and 4. Also, spent fuel would accumulate onsite as a result of the operation of Units 6 and 7, in addition to the spent fuel produced by operation of Units 3 and 4. Sections 5.93, “Impacts on Members of the Public,” 5.94, “Occupational Doses to Workers,” and 6.1.6, “Radiological Wastes,” of the NRC staff’s EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG–2176) (NRC 2016a) describe those impacts in detail. The NRC staff incorporates those impact analyses from NUREG–2176 into this SEIS by reference.

EPA regulations in 40 CFR Part 190 limit the dose to members of the public from all sources in the nuclear fuel cycle, including nuclear power plants, fuel fabrication facilities, waste disposal facilities, and transportation of fuel and waste. As discussed in Section 3.1.4.5 in this SEIS, FPL has a radiological environmental monitoring program (REMP) that measures radiation and radioactive materials in the environment from Turkey Point Units 3 and 4, its ISFSI, and all other sources. The NRC staff reviewed the radiological environmental monitoring results for the 5-year period from 2014 through 2018 as part of this cumulative impacts assessment. The review of FPL’s data showed no indication of an adverse trend in radioactivity levels in the environment from either Turkey Point Units 3 and 4 or the ISFSI. The data showed that there was no measurable impact to the environment from operations at Turkey Point Units 3 and 4. Also, since the proposed Units 6 and 7 would operate under the same State and Federal regulatory standards as Units 3 and 4, there would be no significant impact on the environment from the operation of the proposed Turkey Point Units 6 and 7.

In summary, the NRC staff concludes that there is no significant cumulative effect on human health resulting from the proposed action of subsequent license renewal, in combination with cumulative impacts from other sources. The NRC staff bases this conclusion on its review of radiological environmental monitoring program data, radioactive effluent release data, worker dose data; the expectation that Turkey Point Units 3 and 4 would continue to comply with Federal radiation protection standards during the period of extended operation; and the continued regulation of any future development or actions in the vicinity of the Turkey Point site (including proposed Turkey Point Units 6 and 7) by the NRC and the State of Florida.

4.16.8 Environmental Justice

The environmental justice cumulative impact analysis evaluates the potential for disproportionately high and adverse human health and environmental effects on minority and low-income populations that could result from past, present, and reasonably foreseeable future actions, including the continued operational effects of Turkey Point Units 3 and 4 during the subsequent license renewal term. The geographic area of interest for this environmental justice cumulative impact analysis is the area within a 50-mi (80-km) radius of Turkey Point. As discussed in Section 4.12, “Environmental Justice,” of this SEIS, there would be no

disproportionately high and adverse impacts on minority and low-income populations from the continued operation of Turkey Point Units 3 and 4 during the subsequent license renewal term.

Contributory cumulative effects could come from the other reasonably foreseeable future planned activities at or near the Turkey Point site that are unrelated to the proposed action (subsequent license renewal), as well as from other reasonably foreseeable planned offsite activities. Potential impacts to minority and low-income populations from the construction and operation of proposed reactors Turkey Point Units 6 and 7 would mostly consist of certain localized environmental effects (such as noise, air emissions, traffic, and housing impacts). However, the NRC staff did not identify any disproportionately high and adverse impacts on minority and low-income populations that would occur as a result of the construction and operation of the proposed Turkey Point Units 6 and 7. Transportation projects can have disproportionately high and adverse impacts on minority and low-income populations if the projects bisect any minority or low-income neighborhoods, require the displacement of residences in those neighborhoods, or result in minority or low-income populations disproportionately bearing the effects of the project.

Changes in climate conditions could disproportionately affect minority and low-income populations. The U.S. Global Change Research Program (USGCRP 2009) states that “people living in poverty are especially at risk from a variety of climate-related health effects.” The greatest health burdens are likely to fall on the poor, especially those lacking adequate shelter and access to resources such as air conditioning (USGCRP 2014a). Climate change could affect the availability and access to local plant and animal species, thereby impacting the tribal communities that have historically depended on them for food or medicine (USGCRP 2014). In coastal regions, social and cultural disparities vary regionally and social factors (i.e., low-income, minority status, educational achievement) can limit the ability of some people to adapt to changing environmental conditions caused by climate change. This can result in the displacement of vulnerable minority and low-income populations and lead to social disruption. As discussed in Section 4.15.3 of this SEIS, climate change can result in decreases in water availability and water quality as a result of saltwater intrusion into coastal fresh groundwater supplies. This has significant implications for Miami-Dade County’s public water supply systems as well as for private and industrial users of groundwater aquifers. As discussed in Section 3.10.3, according to the 2010 Census (USCB 2010a), minorities (race and ethnicity combined) comprised approximately 85 percent of the total population in Miami-Dade County. Therefore, climate change effects on groundwater availability and quality would be disproportionately borne by the minority populations that Miami-Dade County water treatment plants serve.

4.16.9 Waste Management and Pollution Prevention

This section describes waste management impacts during the subsequent license renewal term when combined with the aggregate effects of other past, present, and reasonably foreseeable future actions. For the purpose of this cumulative impacts analysis, the NRC staff considered the area within a 50-mi (80-km) radius of Turkey Point. In Section 4.11, “Human Health,” the NRC staff concluded that the potential human health impacts from Turkey Point’s waste during the subsequent license renewal term would be SMALL.

As discussed in Sections 3.1.4 and 3.1.5 of this SEIS, FPL maintains waste management programs for radioactive and nonradioactive waste generated at Turkey Point Units 3 and 4 and is required to comply with Federal and State permits and other regulatory waste management requirements. The nuclear power plants and other facilities within a 50-mi (80-km) radius of Turkey Point Units 3 and 4 are also required to comply with appropriate NRC, EPA, and State

requirements for the management of radioactive and nonradioactive waste. Current waste management activities at Turkey Point Units 3 and 4 would likely remain unchanged during the subsequent license renewal term, and the NRC staff expects that FPL will continue to comply with Federal and State requirements for radioactive and nonradioactive waste.

Due to the comprehensive regulatory controls in place for management of radioactive waste, FPL's compliance with these regulations, and its use of licensed treatment and disposal facilities, the impacts of radioactive waste are expected to be SMALL during the subsequent license renewal term. There are no other operating nuclear power plants, fuel-cycle facilities, or radiological waste treatment and disposal facilities within a 50-mi (80-km) radius of Turkey Point. There are industrial, medical, and research facilities in the region that use radioactive materials. The NRC staff's EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176, Volume 1, Section 7.8) (NRC 2016a) analyzed the cumulative impacts of managing radioactive waste within a 50-mi (80-km) radius of Turkey Point and determined the cumulative impact to be SMALL. The NRC staff likewise expects that the cumulative impact of radioactive waste management, including the impacts from Turkey Point subsequent license renewal, will be SMALL, given the regulatory controls in place for radioactive waste treatment and disposal, FPL's established waste management practices, and its use of licensed treatment and disposal facilities.

Continued operation of Turkey Point would have a small impact on nonradioactive waste management facilities given FPL's program for waste management and the availability of treatment and disposal facilities. The NRC staff's EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176, Volume 1, Section 7.9) analyzed the cumulative impacts of nonradioactive waste from past, present, and future projects in the geographic area of interest of Miami-Dade County. The EIS concluded that the cumulative impacts from nonradioactive waste management would be SMALL. The NRC staff expects that FPL would continue its programs of waste management and will continue to comply with its permits and waste management regulations. Given that facilities within Miami-Dade County are also required to comply with appropriate EPA and state requirements for the management of hazardous and nonhazardous waste, and that state and local authorities would ensure that FPL continues to comply with regulations governing waste management, the cumulative impact of nonradioactive waste management would be small.

The additional 20 years of spent nuclear fuel generated during the subsequent license renewal term would be stored in the spent fuel pools until adequately cooled and then transferred to dry storage in an ISFSI. The Turkey Point onsite ISFSI is licensed under the general license provided to power reactor licensees under 10 CFR 72.210. The NRC oversight of onsite spent fuel storage ensures that the increased volume in onsite storage can be safely accommodated with little environmental effect. No new and significant information has been identified for this issue; therefore, no further analysis is required. The issue was also considered for Turkey Point's initial license renewal environmental review, and no new and significant information was found at that time (NRC 2002c).

In summary, the NRC staff concludes that there would be no significant cumulative effect from the generation of radioactive and nonradioactive waste during the period of extended operation authorized by the proposed action of subsequent license renewal. The NRC staff bases its conclusion on the continued compliance of FPL with Federal and State of Florida requirements for radioactive and nonradioactive waste management and on the expected regulatory compliance of other waste producers in the area.

4.16.10 Global Greenhouse Gas Emissions

The cumulative impact of a greenhouse gas emission source on climate is global. Greenhouse gas emissions are transported by wind and become well mixed in the atmosphere as a result of their long atmospheric residence time. Therefore, the extent and nature of climate change is not specific to where greenhouse gases are emitted. Due to the global significance of greenhouse gas emissions, a global climate change cumulative impacts analysis inherently considers the entire Earth's atmosphere and, therefore, emissions on a global scale (as opposed to simply those emissions on a county, State, or national scale). As discussed in Section 4.15.3.2, "Climate Change," of this SEIS, climate change and climate-related environmental changes have been observed on a global level, and climate models indicate that future climate change will depend on present and future global greenhouse gas emissions. Climate models indicate that short-term climate change (through the year 2030) is dependent on past greenhouse gas emissions. Therefore, short-term climate change is projected to occur with or without present and future greenhouse gas emissions from Turkey Point. Beyond the short term, climate models indicate that with continued increases in global greenhouse gas emission rates the Earth's average surface temperature will continue to increase and climate-related changes will persist.

In April 2018, EPA published its latest Greenhouse Gas Inventory report, "Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990–2016." As the official U.S. inventory of greenhouse gas emissions, this EPA report identifies and quantifies the primary anthropogenic sources (those human caused or produced) and sinks of greenhouse gases. The Greenhouse Gas Inventory is an essential tool for addressing climate change and for participating with the United Nations Framework Convention on Climate Change to compare the relative global contribution of different emission sources and greenhouse gases to climate change. In 2016, the United States emitted 6,511.3 million metric tons (MMT) of CO_{2eq}. From 1990 to 2016, emissions increased by 2.4 percent. However, from 2015 to 2016, emissions decreased by 1.9 percent. Across the United States, emissions attributable to electricity generation totaled 1,809.3 MMT of CO_{2eq} (EPA 2018c). The Energy Information Administration (EIA) reported that in 2015, Florida's electric power sector was responsible for 107.6 MMT of CO_{2eq} (EIA 2018e).

Facilities that emit 25,000 MT CO_{2eq} or more per year are required to annually report their greenhouse gas emissions to the EPA. These facilities are known as direct emitters, and the data are publicly available in EPA's facility-level information on greenhouse gases tool (FLIGHT). In 2016, FLIGHT-identified facilities in Florida emitted a total of 134 MMT of CO_{2eq}. Facilities in Miami-Dade County emitted a total of 4.95 MMT of CO_{2eq} (EPA 2018d).

Section 4.16, "Cumulative Impacts," of this SEIS references current and reasonably foreseeable future projects and actions that could contribute to greenhouse gas emissions. Permitting and licensing requirements and other mitigative measures can minimize the impacts of greenhouse gas emissions. For instance, in 2012, EPA issued a final Greenhouse Gas Tailoring Rule (77 FR 41051) to address greenhouse gas emissions from stationary sources under the Clean Air Act permitting requirements. The Greenhouse Gas Tailoring Rule establishes when an emission source will be subject to permitting requirements and control technology to reduce greenhouse gas emissions.

EPA's Greenhouse Gas Inventory illustrates the diversity of greenhouse gas sources, which include electricity generation (including fossil fuel combustion and incineration of waste), industrial processes, and agriculture. As presented in Section 4.15.3.1, "Greenhouse Gas Emissions and Climate Change," of this SEIS, annual direct greenhouse gas emissions from

combustion sources resulting from ancillary operations at Turkey Point range from 3,900 to 4,190 MT of CO_{2eq}. In comparing Turkey Point’s greenhouse gas emission to total U.S. greenhouse gas emissions, emissions from electricity production in Florida, or emissions on a county level, greenhouse gas emissions from Turkey Point are relatively minor. When compared to global emissions, greenhouse gas emissions associated with Turkey Point Units 3 and 4 operations are negligible (see Table 4-8 below). Furthermore, as presented in Table 4-7, “Direct Greenhouse Gas Emissions from Facility Operations Under the Proposed Action and Alternatives,” in Section 4.15.3.1, the natural gas and combination alternatives’ annual greenhouse gas emissions are higher by several orders of magnitude than those from the continued operation of Turkey Point Units 3 and 4. If Turkey Point’s generating capacity were to be replaced by other non-nuclear power generating alternatives evaluated in this SEIS, there would be an increase in greenhouse gas emissions. Consequently, the NRC staff concludes that the continued operation of Turkey Point through the subsequent license renewal period (the proposed action) would result in greenhouse gas emissions avoidance. In other words, when compared to alternative baseload replacement power generation sources considered in this SEIS, the continued operations of Turkey Point Units 3 and 4 would have a net, beneficial contribution to greenhouse gas emissions and climate change impacts during the subsequent license renewal term.

Table 4-8 Comparison of Greenhouse Gas Emission Inventories

Source	CO _{2eq} MMT/year
Global Emissions (2016) ^(a)	37,000
U.S. Emissions (2016) ^(b)	6,511
Florida (2016) ^(c)	134
Miami-Dade County, Florida (2016) ^(c)	4.95
Turkey Point ^(d)	4.2 x 10 ⁻³

^(a) Carbon dioxide emissions obtained from the Global Carbon Project (GCP 2018) and converted to carbon dioxide equivalents (CO_{2eq}).

^(b) Source: EPA 2018c.

^(c) Greenhouse gas emissions account only for direct emitters, those facilities that emit 25,000 MT or more a year (EPA 2018d).

^(d) Peak emissions over the last 5 years from FPL 2018f.

Source: GCP 2018, EPA 2018c, EPA 2018d, FPL 2018f

4.17 Resource Commitments Associated with the Proposed Action

This section describes the NRC staff’s consideration of potentially unavoidable adverse environmental impacts that could result from the implementation of the proposed action (subsequent license renewal) and alternatives to the proposed action, the relationship between short-term uses of the environment and the maintenance and enhancement of long-term productivity, and the irreversible and irretrievable commitments of resources.

4.17.1 Unavoidable Adverse Environmental Impacts

Unavoidable adverse environmental impacts are impacts that would occur after implementation of all workable mitigation measures. Carrying out any of the replacement energy alternatives

considered in this SEIS, including the proposed action of subsequent license renewal for Turkey Point Units 3 and 4, would result in some unavoidable adverse environmental impacts.

Minor unavoidable adverse impacts on air quality would occur due to emission and release of various chemical and radiological constituents from power plant operations. Non-radiological emissions resulting from power plant operations are expected to comply with EPA emissions standards, although the alternative of operating a fossil-fueled power plant in some areas may worsen existing attainment issues. Chemical and radiological emissions would not exceed the national emission standards for hazardous air pollutants.

During nuclear power plant operations, workers and members of the public would face unavoidable exposure to minor levels of radiation as well as to hazardous and toxic chemicals. Workers would be exposed to radiation and chemicals associated with routine plant operations and the handling of nuclear fuel and waste material. Workers would have higher levels of exposure than members of the public, but doses would be administratively controlled and would not exceed regulatory standards or administrative control limits. In comparison, the alternatives involving the construction and operation of a non-nuclear power generating facility would also result in unavoidable exposure to hazardous and toxic chemicals to workers and the public.

The generation of spent nuclear fuel and waste material—including low-level radioactive waste, hazardous waste, and nonhazardous waste—would be unavoidable. Non-nuclear power generating facilities would generate both hazardous and nonhazardous waste. For wastes generated during operations, power plant operators would collect, store, and ship these for suitable treatment, recycling, or disposal in accordance with applicable Federal and State regulations. Due to the costs of handling these materials, the NRC staff expects that power plant operators would optimize all waste management activities and operations in a way that generates the smallest possible amount of waste.

4.17.2 Relationship between Short-Term Use of the Environment and Long-Term Productivity

The operation of power generating facilities would result in short-term uses of the environment, as described in Chapter 4, “Environmental Consequences and Mitigating Actions,” of this SEIS. Short term is the period of time that continued power generating activities take place.

Power plant operations require short-term use of the environment and commitment of resources (e.g., land and energy), indefinitely or permanently. Certain short-term resource commitments are substantially greater under most energy alternatives, including subsequent license renewal, than under the no-action alternative because of the continued generation of electrical power and the continued use of generating sites and associated infrastructure. During operations, all energy alternatives entail similar relationships between local short-term uses of the environment and the maintenance and enhancement of long-term productivity.

Air emissions from nuclear power plant operations introduce small amounts of radiological and non-radiological emissions to the region around the plant site. Over time, these emissions would result in increased concentrations and exposure, but the NRC staff does not expect that these emissions would impact air quality or radiation exposure to the extent that they would impair public health and long-term productivity of the environment.

Continued employment, expenditures, and tax revenues generated during power plant operations directly benefit local, regional, and State economies over the short term. Local

governments investing project-generated tax revenues into infrastructure and other required services could enhance economic productivity over the long term.

The management and disposal of spent nuclear fuel, low-level radioactive waste, hazardous waste, and nonhazardous waste requires an increase in energy and consumes space at treatment, storage, or disposal facilities. Regardless of the location, the use of land to meet waste disposal needs would reduce the long-term productivity of the land.

Power plant facilities are committed to electricity production over the short term. After decommissioning these facilities and restoring the area, the land could be available for other future productive uses.

4.17.3 Irreversible and Irretrievable Commitment of Resources

Resource commitments are irreversible when primary or secondary impacts limit the future options for a resource. For example, the consumption or loss of nonrenewable resources are irreversible. An irretrievable commitment refers to the use or consumption of resources for a period of time (e.g., for the duration of the action under consideration) that are neither renewable nor recoverable for future use. Irreversible and irretrievable commitments of resources for electrical power generation include the commitment of land, water, energy, raw materials, and other natural and man-made resources required for power plant operations. In general, the commitments of capital, energy, labor, and material resources are also irreversible.

The implementation of any of the replacement energy alternatives considered in this SEIS would entail the irreversible and irretrievable commitments of energy, water, chemicals, and—in some cases—fossil fuels. These resources would be committed during the subsequent license renewal term and over the entire life cycle of the power plant, and they would be unrecoverable.

Energy expended would be in the form of fuel for equipment, vehicles, and power plant operations and electricity for equipment and facility operations. Electricity and fuel would be purchased from offsite commercial sources. Water would be obtained from existing water supply systems. These resources are readily available, and the NRC staff does not expect that the required amounts would deplete available supplies or exceed available system capacities.

5 CONCLUSION

This supplemental environmental impact statement (SEIS) contains the NRC staff's environmental review of Florida Power & Light Company's (FPL's) application for subsequent renewed operating licenses for Turkey Point Nuclear Generating Unit Nos. 3 and 4 (Turkey Point, or Turkey Point Units 3 and 4), as required by Title 10 of the *Code of Federal Regulations* (10 CFR) Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions." The regulations at 10 CFR Part 51 implement the National Environmental Policy Act of 1969, as amended (42 U.S.C. 4321 et seq.). This chapter briefly summarizes the environmental impacts of Turkey Point subsequent license renewal, lists and compares the environmental impacts of alternatives to subsequent license renewal, and presents the NRC staff's conclusions and recommendation.

5.1 Environmental Impacts of Subsequent License Renewal

After reviewing new and potentially significant information with respect to two generic (Category 1) environmental issues in this SEIS, the NRC staff concluded that issuing subsequent renewed licenses for Turkey Point would not have impacts beyond those discussed in the NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (NRC 2013a).

After reviewing the site-specific (Category 2) environmental issues and one new uncategorized issue in this SEIS, the NRC staff concluded that issuing subsequent renewed licenses for Turkey Point would have SMALL impacts for the Category 2 issues and the new uncategorized issue applicable to subsequent license renewal at Turkey Point, with two exceptions: (1) for groundwater resources, the impact would be SMALL to MODERATE, and (2) for aquatic resources, the impact would be SMALL to MODERATE. The NRC staff considered mitigation measures for each issue, as applicable. The NRC staff concluded that no additional mitigation measure is warranted.

5.2 Comparison of Alternatives

In Chapter 4, "Environmental Consequences and Mitigating Actions," of this SEIS, the NRC staff considered the following alternatives to issuing subsequent renewed licenses to Turkey Point:

- no-action alternative
- new nuclear alternative
- natural gas combined-cycle alternative
- combination alternative of natural gas combined-cycle and solar photovoltaic

The staff also evaluated a cooling water system alternative using mechanical draft cooling towers instead of the Cooling Canal System (CCS) for cooling the Turkey Point Units 3 and 4 reactors.

Based on the evaluation presented in this SEIS, the NRC staff concludes that the environmentally preferred alternative is the proposed action of subsequent license renewal for Turkey Point Units 3 and 4. As shown in Table 2-2, "Summary of Environmental Impacts of the Proposed Action and Alternatives," all reasonable power-generation alternatives have impacts in at least two resource areas that are greater than the impacts of subsequent license renewal, in addition to the environmental impacts inherent with new construction projects.

5.3 Recommendation

The NRC staff's recommendation is that the adverse environmental impacts of subsequent license renewal for Turkey Point are not so great that preserving the option of subsequent license renewal for energy-planning decisionmakers would be unreasonable. The NRC staff bases this recommendation on the following:

- the analysis and findings in NUREG–1437, “Generic Environmental Impact Statement for License Renewal of Nuclear Plants”
- the environmental report submitted by FPL
- the NRC staff's consultation with Federal, State, Tribal, and local government agencies
- the NRC staff's independent environmental review
- the NRC staff's consideration of public comments received during the scoping process and on the draft SEIS

6 REFERENCES

10 CFR Part 2. *Code of Federal Regulations*, Title 10, Energy, Part 2, “Agency Rules of Practice and Procedure.”

10 CFR Part 20. *Code of Federal Regulations*, Title 10, Energy, Part 20, “Standards for Protection against Radiation.”

10 CFR Part 50. *Code of Federal Regulations*, Title 10, Energy, Part 50, “Domestic Licensing of Production and Utilization Facilities.”

10 CFR Part 51. *Code of Federal Regulations*, Title 10, Energy, Part 51, “Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions.”

10 CFR Part 54. *Code of Federal Regulations*, Title 10, Energy, Part 54, “Requirements for Renewal of Operating Licenses for Nuclear Power Plants.”

10 CFR Part 100. *Code of Federal Regulations*, Title 10, Energy, Part 100, “Reactor Site Criteria.”

36 CFR Part 60. *Code of Federal Regulations*, Title 36, Parks, Forests, and Public Property, Part 60, “National Register of Historic Places.”

36 CFR Part 800. *Code of Federal Regulations*, Title 36, Parks, Forests, and Public Property, Part 800, “Protection of Historic Properties.”

40 CFR Part 50. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 50, “National Primary and Secondary Ambient Air Quality Standards.”

40 CFR Part 51. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 51, “Requirements for Preparation, Adoption, and Submittal of Implementation Plans.”

40 CFR Part 60. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 60, “Standards of Performance for New Stationary Sources.”

40 CFR Part 63. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 63, “National Emission Standards for Hazardous Air Pollutants for Source Categories.”

40 CFR Part 81. *Code of Federal Regulations*. Title 40, Protection of Environment, Part 81, “Designation of Areas for Air Quality Planning Purposes.”

40 CFR Part 110. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 110, “Discharge of Oil.”

40 CFR Part 112. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 112. “Oil Pollution Prevention.”

40 CFR Part 125. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 125, “Criteria and Standards for the National Pollutant Discharge Elimination System.”

40 CFR Part 131. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 131, “Water Quality Standards.”

40 CFR Part 141. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 141, “National Primary Drinking Water Regulations.”

40 CFR Part 143. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 143, “National Secondary Drinking Water Regulations.”

40 CFR Part 190. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 190, “Environmental Radiation Protection Standards for Nuclear Power Operations.”

50 CFR Part 17. *Code of Federal Regulations*, Title 50, Wildlife and Fisheries, Part 17, “Endangered and Threatened Wildlife and Plants.”

50 CFR Part 402. *Code of Federal Regulations*, Title 50, Wildlife and Fisheries, Part 402, “Interagency Cooperation – Endangered Species Act of 1973, as Amended.”

51 FR 19926. U.S. Fish and Wildlife Service and National Marine Fisheries Service. “Interagency cooperation—Endangered Species Act of 1973, as amended; final rule.” *Federal Register* 51(106):19926–19963. June 3, 1986.

53 FR 43950. U.S. Nuclear Regulatory Commission. “Memorandum of Understanding between the Nuclear Regulatory Commission and the Occupational Safety and Health Administration; Worker Protection at NRC-licensed Facilities.” *Federal Register* 53(210):43950–43952. October 31, 1988.

59 FR 7629. Executive Order No. 12898. “Federal actions to address environmental justice in minority populations and low-income populations.” *Federal Register* 59(32):7629–7634. February 11, 1994.

61 FR 28467. U.S. Nuclear Regulatory Commission. “Environmental review for renewal of nuclear power plant operating licenses.” *Federal Register* 61(109):28467–28481. June 5, 1996.

69 FR 52040. U.S. Nuclear Regulatory Commission. “Policy statement on the treatment of environmental justice matters in NRC regulatory and licensing actions.” *Federal Register* 69(163):52040–52048. August 24, 2004.

72 FR 71083. U.S. Nuclear Regulatory Commission. “Sally Shaw; Denial of Petition for Rulemaking.” *Federal Register* 72(240):71083–71086. December 14, 2007.

74 FR 13926. U.S. Nuclear Regulatory Commission. “Power reactor security requirements.” *Federal Register* 74(58):13926–13993. March 27, 2009.

74 FR 66496. U.S. Environmental Protection Agency. “Endangerment and cause or contribute findings for greenhouse gases under section 202(a) of the Clean Air Act.” *Federal Register* 74(239):66496–66546. December 15, 2009.

75 FR 9282. Fish and Wildlife Service, Interior. “General Provisions; Revised. List of Migratory Birds; final rule.” *Federal Register* 75(39):9282–9314. March 1, 2010.

77 FR 15916. National Marine Fisheries Service. “Fisheries of the Caribbean, Gulf of Mexico, and South Atlantic; Comprehensive annual catch limit amendment for the South Atlantic.” *Federal Register* 77(52):15916–15932. March 16, 2012.

77 FR 41051. U.S. Environmental Protection Agency. “Prevention of significant deterioration and Title V greenhouse gas tailoring rule step 3 and GHG plantwide applicability limits.” *Federal Register* 77(134):41051–41075. July 12, 2012.

78 FR 63796. U.S. Fish and Wildlife Service. “Endangered and Threatened Wildlife and Plants; Determination of Endangered Status for *Chromolaena frustrata* (Cape Sable Thoroughwort), *Consolea corallicola* (Florida Semaphore Cactus), and *Harrisia aboriginum* (Aboriginal Prickly-Apple); Final Rule.” *Federal Register* 78(206):63797–63821. October 24, 2013.

79 FR 44464. U.S. Nuclear Regulatory Commission. “Environmental assessment and final finding of no significant impact; issuance.” *Federal Register* 79(147):44464–44470. July 31, 2014.

80 FR 76324. U.S. Nuclear Regulatory Commission. “Atomic Safety and Licensing Board; in the Matter of Florida Power & Light Company (Turkey Point Nuclear Generating, Units 3 and 4).” *Federal Register* 80(235):76324–76325. December 8, 2015.

81 FR 32249. National Marine Fisheries Service. “Fisheries of the Caribbean, Gulf of Mexico, and South Atlantic; Snapper-grouper fishery off the southern Atlantic states; Amendment 35.” *Federal Register* 81(99):32249–32255. May 23, 2016.

82 FR 46691. U.S. Fish and Wildlife Service. “Endangered and Threatened Wildlife and Plants; Endangered Species Status for *Dalea carthagenensis* var. *floridana* (Florida Prairie-clover), and Threatened Species Status for *Sideroxylon reclinatum* ssp. *austrofloridense* (Everglades Bully), *Digitaria pauciflora* (Florida Pineland Crabgrass), and *Chamaesyce deltoidea* ssp. *pinetorum* (Pineland Sandmat); Final Rule.” *Federal Register* 82(193):46691–46715. October 6, 2017.

83 FR 19304. U.S. Nuclear Regulatory Commission. “License renewal application; opportunity to request a hearing and to petition for leave to intervene.” *Federal Register* 83(85):19304–19306. May 2, 2018.

83 FR 23726. U.S. Nuclear Regulatory Commission. “Intent to conduct scoping process and preparing environmental impact statement; public meeting and request for comment.” *Federal Register* 83(99):23726–23728. May 22, 2018.

Arnold T.M., Zimmerman R.C., Engelhardt K.A.M., Stevenson J.C. 2017. “Twenty-first century climate change and submerged aquatic vegetation in a temperate estuary: the case of Chesapeake Bay.” *Ecosystem Health and Sustainability*, 3(7):1353283. Available at <<https://doi.org/10.1080/20964129.2017.1353283>> (accessed July 24, 2018).

[Audubon] Audubon Florida. 2016. “Restoring Freshwater Flows to Biscayne Bay: Biscayne Bay Coastal Wetlands Phase 1.” April 2016. Available at <http://fl.audubon.org/sites/g/files/amh666/f/audubon_biscaynebaycoastalwetlands_bbcw_factsheet_august2016.pdf> (accessed July 9, 2018).

[Audubon] Audubon Society. 2019. “Important Bird Areas: Biscayne Bay, Florida.” Available at <<https://netapp.audubon.org/iba/Reports/104>> (accessed July 11, 2019).

Bald and Golden Eagle Protection Act of 1940, as amended. 16 U.S.C. Sections 668–668c.

Barlow P.M. 2003. “Ground Water in Freshwater-Saltwater Environments of the Atlantic Coast.” Denver, CO: U.S. Geological Survey Circular 1262. 121 p. 2003. Available at <<https://pubs.usgs.gov/circ/2003/circ1262/pdf/circ1262.pdf>> (accessed July 7, 2018).

[BBWW] Biscayne Bay Water Watch. 2019. Nutrients and Chlorophyll. Available at <<https://sfyl.ifas.ufl.edu/media/sfylifasufledu/miami-dade/documents/sea-grant/Chlorophyll-a.pdf>> (accessed July 23, 2019).

[BEBR] Bureau of Economic and Business Research. 2017. “Projections of Florida Population by County, 2020-2045, with Estimates for 2016.” Bureau of Economic and Business Research, 50(177). April 2017. Available at <<https://www.bebr.ufl.edu/population/population-data/projections-florida-population-county-2020–2045-estimates-2016>> (accessed April 30, 2018).

[BEBR] Bureau of Economic and Business Research. 2018. “Growth of the Puerto Rican Population in Florida and on the U.S. Mainland.” Available at: <<https://www.bebr.ufl.edu/population/website-article/growth-puerto-rican-population-florida-and-us-mainland>> (accessed September 12, 2018).

- [Bechtel] Bechtel Power Corporation. 2014. "Addendum to the Independent Third-Party Final Technologies Assessment for the Alternative Cooling Technologies or Modifications to the Existing Once-Through Cooling System for Diablo Canyon Power Plant Addressing the Installation of Saltwater Cooling Towers in the South Parking Lot." Report No. 25762-000-30H-G01G-00001. September 17, 2014. Available at <http://www.swrcb.ca.gov/water_issues/programs/ocean/cwa316/rcnfpp/docs/bpc091714_4.pdf> (accessed August 9, 2018).
- [BEIR] National Research Council. 2006. "Health Risks from Exposure to Low Levels of Ionizing Radiation, BEIR VII." Committee on the Biological Effects of Ionizing Radiation (BEIR). National Academies Press, Washington, D.C. DOI: 10.17226/11340.
- Bennett W.A., Beitinger T.L. 1997. "Temperature tolerance of the sheepshead minnow, *Cyprinodon variegatus*." *Copeia*, 1997(1):77-87.
- Bernstein A., Gustafson M., Lewis R. 2018. "Disaster on the Horizon: The Price Effect of Sea Level Rise." *Journal of Financial Economics*, Forthcoming. Available at SSRN: <https://ssrn.com/abstract=3073842> (accessed August 9, 2018).
- [BOEM] Bureau of Ocean Energy Management. undated. "Ocean Wave Energy." Available at <<https://www.boem.gov/Renewable-Energy-Program/Renewable-Energy-Guide/Ocean-Wave-Energy.aspx>> (accessed September 12, 2018).
- Broward County. 2017. "Fiscal Year 2017 Adopted Operating Budget." Available at: <<http://www.broward.org/Budget/Archives/Pages/FY2017AdoptedOperatingBudget.aspx>> (accessed August 6, 2018).
- Brown M., Cohen M., Bardi E., and Ingwersen W. 2006. "Species diversity in the Florida Everglades, USA: A systems approach to calculating biodiversity." *Aquatic Sciences*. 68(3):254-277. January 2006. Available at <https://www.researchgate.net/publication/226979308_Species_diversity_in_the_Florida_Everglades_USA_A_systems_approach_to_calculating_biodiversity> (accessed on August 28, 2018).
- Cela M., Hulse J., Titus J.G. 2010. "South Florida." Chapter 8 in *The Likelihood of Shore Protection along the Atlantic Coast of the United States. Volume 2: New England and the Southeast*. U.S. Environmental Protection Agency, Washington, D.C. ADAMS Accession No ML12269A197.
- [CEQ] Council on Environmental Quality. 1997. "Environmental Justice: Guidance under the National Environmental Policy Act." Washington, DC. December 10, 1997. Available at <<https://www.epa.gov/environmentaljustice/ceq-environmental-justice-guidance-under-national-environmental-policy-act>> (accessed July 8, 2018).
- Chervinski J. 1983. "Salinity tolerance of the mosquitofish, *Gambusia affinis*." *Journal of Fish Biology*, 22(1):9-11. DOI: 10.1111/j.1095-8649.1983.tb04720.x.
- Childers D., Iwaniec D., Rondeau D., Rubio G., Verdon E., and Madden C.J. 2006. "Responses of sawgrass and spikerush to variation in hydrologic drivers and salinity in Southern Everglades marshes." *Hydrobiologia*, 569(1):273-292. October 2006.
- Chin, D.A. 2016. "The Cooling-Canal System at the FPL Turkey Point Power Station." Final Report. May 2016. Available at <<http://www.miamidade.gov/mayor/library/memos-and-reports/2016/05/05.12.16-Final-Report-on-the-Cooling-Canal-Study-at-the-Florida-Power-and-Light-Turkey-Point-Power-Plant-Directive-151025.pdf>> (accessed August 21, 2018).
- Clean Air Act of 1970*. 42 U.S.C. 7401 et seq.
- Coastal Zone Management Act of 1972*. 16 U.S.C. 1451 et seq.

Conner A.M., Francfort J.E., Rinehart B.N. 1998. U.S. Hydropower Resource Assessment, Final Report. Idaho Falls, Idaho: Idaho National Engineering and Environmental Laboratory. DOE/ID 10430.2. December 1998. Available at <<https://www1.eere.energy.gov/wind/pdfs/doewater-10430.pdf>> (accessed September 14, 2018).

Costa T.M.M., Soares-Gomes A. 2015. "Secondary production of the fiddler crab *Uca rapax* from mangrove areas under anthropogenic eutrophication in the Western Atlantic, Brazil." *Marine Pollution Bulletin*, 101(2):533-538. DOI: 10.1016/j.marpolbul.2015.10.061.

CSX. 2018. CSX System Map. Available at <<https://www.csx.com/index.cfm/customers/maps/csx-system-map/>> (accessed June 11, 2018).

[DERM] Department of Regulatory and Economic Resources, Division of Environmental Resources Management. 2018. Letter from L. Hefty, Division Director, DERM, to M. Ma, Director Program Management Announcements and Editing Branch, NRC. Subject: "Environmental Impact Statement Scoping Comments Regarding Florida Power and Light's Subsequent License Renewal Application for Turkey Point Units 3 and 4, Docket Number NRC 2018-0101." June 21, 2018. ADAMS Accession No. ML18180A175.

[DHR] Florida Division of Historic Resources. 2018. Response to Request for Scoping Comments Concerning the Environmental Review of Turkey Point Nuclear Plant, Units 3 and 4 Subsequent License Renewal Application. ADAMS Accession No. ML18183A482.

[DHR 2019] Florida Division of Historic Resources 2019. Email from J. Aldridge to N. Martinez. Subject: Re: Draft Supplement Environmental Impact Statement for Subsequent License Renewal of Turkey Point Nuclear Generating Units Nos.3 and 4." May 22, 2019. ADAMS Accession No. ML19143A207.

Diem J.E., Stauber C.E., Rothernberg R. 2017. Heat in the southeastern United States: Characteristics, trends, and potential health impact. *PLOS ONE*, 12(5):e0177937. Available at <<http://journals.plos.org/plosone/article?id=10.1371/journal.pone.0177937#sec009>> (accessed September 21, 2018).

[DOA] Department of the Army. 2014. "Procedures to Evaluate Sea Level Change: Impacts, Responses, and Adaptation." Technical Letter No. 1100-2-1. Washington, DC: U.S. Army Corps of Engineers. June 30, 2014. Available at <http://www.publications.usace.army.mil/Portals/76/Publications/EngineerTechnicalLetters/ETL_1100-2-1.pdf> (accessed August 24, 2018).

[DOE] U.S. Department of Energy. 2010. "Kemper County Integrated Gasification Combined Cycle (IGCC) Project, Final Environmental Impact Statement." Washington, DC. DOE/EIS-0409, Volume 1. May 2010. Available at <https://www.energy.gov/sites/prod/files/nepapub/nepa_documents/RedDont/EIS-0409-FEIS-01-2010.pdf> (accessed September 13, 2018).

[DOE] U.S. Department of Energy. 2011. "2010 Solar Technologies Market Report." Washington, DC. November 2011. Available at <<https://www.nrel.gov/docs/fy12osti/51847.pdf>> (accessed July 2, 2018).

[DOE] U.S. Department of Energy. 2013a. "Geothermal Basics." Washington, DC. August 14, 2013. Available at <<https://www.energy.gov/eere/geothermal/geothermal-basics>> (accessed September 6, 2018).

[DOE] U.S. Department of Energy. 2013b. "Fuel Cell Basics." Washington, DC. August 14, 2013. Available at <<https://www.energy.gov/eere/fuelcells/fuel-cell-basics>> (accessed September 6, 2018).

[DOE] U.S. Department of Energy. 2018a. "2017 Offshore Wind Technologies Market Update." Washington, DC. September 2018. Available at <https://www.energy.gov/sites/prod/files/2018/09/f55/71709_V4.pdf> (accessed September 13, 2018).

[DOE] U.S. Department of Energy. 2018b. "Advanced Small Modular Reactors." Available at <<http://energy.gov/ne/nuclear-reactor-technologies/small-modular-nuclear-reactors>> (accessed September 13, 2018).

[DOE] U.S. Department of Energy. 2018c. "Marine and Hydrokinetic Resource Assessment and Characterization." Available at <<https://www.energy.gov/eere/water/marine-and-hydrokinetic-resource-assessment-and-characterization>> (accessed September 20, 2018).

[DOE] U.S. Department of Energy. 2018d. "WINDEXchange: U.S. Installed Wind Power Capacity – Q2 2018." Available at <<https://windexchange.energy.gov/maps-data/321>> (accessed September 13, 2018).

[DOE] U.S. Department of Energy. 2019. A Graded Approach for Evaluating Radiation Doses to Aquatic and Terrestrial Biota. DOE-STD-1153-2019. Washington, DC. February 2019. 169 p. Available at <<http://resrad.evs.anl.gov/docs/technicalStandard.pdf>> (accessed May 13, 2019).

[E&E] Ecology and Environment, Inc. 2017. "Turkey Point Plant Annual Monitoring Report. Prepared for Florida Power & Light Company." September 2017. 415 p. Available at <<http://prodenv.dep.state.fl.us/DepNexus/public/electronic-documents#>> (search facility/site ID: FL0001562, document date: 9/28/2017) (accessed June 13, 2018).

[EAI] Ecological Associates, Inc. 2017. "FPL Turkey Point Cooling Canal System Characterization Study. Prepared for Florida Power and Light Company." 55 p. ADAMS Accession No. ML18247A514. In: FPL 2018h, Attachment 5, Enclosure 5. ADAMS Accession No. ML18247A509.

[EB] Encyclopædia Britannica. 2018. "Seawater: Salinity Distribution." Available at <<https://www.britannica.com/science/seawater/Salinity-distribution>> (accessed July 10, 2018).

[EIA] U.S. Energy Information Administration. 2013a. "Annual Energy Outlook 2013 with Projections to 2040." DOE/EIA-0383 (2013). Washington, DC. April 2013. 244 p. Available at <[http://www.eia.gov/forecasts/aeo/pdf/0383\(2013\).pdf](http://www.eia.gov/forecasts/aeo/pdf/0383(2013).pdf)> (accessed June 29, 2018).

[EIA] U.S. Energy Information Administration. 2013b. "Updated Capital Cost Estimates for Utility Scale Electricity Generating Plants." Washington, DC. April 2013. 201 p. Available at <http://www.eia.gov/forecasts/capitalcost/pdf/updated_capcost.pdf> (accessed August 28, 2018).

[EIA] U.S. Energy Information Administration. 2015a. "Levelized Cost and Levelized Avoided Cost of New Generation Resources in the Annual Energy Outlook 2015." Washington, DC. June 2015. 12 p. Available at <https://www.eia.gov/outlooks/archive/aeo15/pdf/electricity_generation_2015.pdf> (accessed August 7, 2018).

[EIA] U.S. Energy Information Administration. 2015b. "Today in Energy—First offshore wind farm in the United States begins construction." August 14, 2015. Available at <<http://www.eia.gov/todayinenergy/detail.cfm?id=22512>> (accessed August 30, 2018).

[EIA] U.S. Energy Information Administration. 2015c. "Annual Energy Outlook 2015 with Projections to 2040." DOE/EIA-0383 (2015). Washington, DC. April 2015. 154 p. Available at <[http://www.eia.gov/forecasts/aeo/pdf/0383\(2015\).pdf](http://www.eia.gov/forecasts/aeo/pdf/0383(2015).pdf)> (accessed August 31, 2018).

[EIA] U.S. Energy Information Administration. 2016a. "Annual Energy Outlook 2016 with Projections to 2040." DOE/EIA-0383 (2016). Washington, DC. August 2016. 256 p. Available at <[http://www.eia.gov/outlooks/aeo/pdf/0383\(2016\).pdf](http://www.eia.gov/outlooks/aeo/pdf/0383(2016).pdf)> (accessed May 29, 2018).

[EIA] U.S. Energy Information Administration. 2016b. "Today in Energy—Southern states lead growth in biomass electricity generation." May 25, 2016. Available at <<https://www.eia.gov/todayinenergy/detail.php?id=26392>> (accessed June 26, 2018).

[EIA] U.S. Energy Information Administration. 2016c. "Today in Energy—California has nearly half of the nation's solar electricity generating capacity." February 5, 2016. Available at <<https://www.eia.gov/todayinenergy/detail.php?id=24852#>> (accessed September 20, 2018).

[EIA] U.S. Energy Information Administration. 2016d. "Capital Cost Estimated for Utility Scale Electricity Generating Plants." Washington, DC. November 2016. 141 p. Available at: <https://www.eia.gov/analysis/studies/powerplants/capitalcost/pdf/capcost_assumption.pdf> (accessed August 3, 2018).

[EIA] U.S. Energy Information Administration. 2017a. "Florida State Profile and Energy Estimates - Analysis." Washington, DC. Last updated: September 21, 2017. Available at <<https://www.eia.gov/state/analysis.php?sid=FL>> (accessed May 4, 2018).

[EIA] U.S. Energy Information Administration. 2017b. "Electric Power Annual 2016, Table 1.2. Summary Statistics for the United States, 2006–2016. Utility Scale Capacity: Solar Photovoltaic." Washington, DC. December 2017; Revised March 2018. 231 p. Available at <<https://www.eia.gov/electricity/annual/>> (accessed September 20, 2018).

[EIA] U.S. Energy Information Administration. 2017c. "Today in Energy—Utility-scale solar has grown rapidly over the past five years." May 4, 2017. Available at <<https://www.eia.gov/todayinenergy/detail.php?id=31072>> (accessed September 20, 2018).

[EIA] U.S. Energy Information Administration. 2017d. "Florida State Energy Profile—Florida Quick Facts." Last updated: September 21, 2017. Available at <<https://www.eia.gov/state/print.php?sid=FL>> (accessed August 28, 2018).

[EIA] U.S. Energy Information Administration. 2017e. "Geothermal Explained—State Rankings for Geothermal Electricity Generation, 2016." Last updated: May 18, 2017. Available at <https://www.eia.gov/energyexplained/index.cfm?page=geothermal_use> (accessed September 6, 2018).

[EIA] U.S. Energy Information Administration. 2017f. "Electric Power Annual 2017, Table 8.4. Average power plant operating expenses for major U.S. investor-owned electric utilities, 2007–2017." Washington, DC. October 2018. 239 p. Available at <<https://www.eia.gov/electricity/annual/>> (accessed August 3, 2018).

[EIA] U.S. Energy Information Administration. 2018a. "State Electricity Profiles—Florida—Table 4. Electric power industry capability by primary energy source, 1990 through 2016." January 25, 2018. Available at <<https://www.eia.gov/electricity/state/Florida/>> (accessed September 20, 2018).

[EIA] U.S. Energy Information Administration. 2018b. "State Electricity Profiles—Florida—Table 5. Electric power industry generation by primary energy source, 1990 through 2016." January 25, 2018. Available at <<https://www.eia.gov/electricity/state/Florida/>> (accessed September 20, 2018).

[EIA] U.S. Energy Information Administration. 2018c. "Today in Energy—Future U.S. electricity generation mix will depend largely on natural gas prices." February 7, 2018. Available at <<https://www.eia.gov/todayinenergy/detail.php?id=34852>> (accessed August 30, 2018).

[EIA] U.S. Energy Information Administration. 2018d. “Annual Energy Outlook 2018—Table: Electricity Supply, Disposition, Prices, and Emissions—Electricity Reference Case.” Available at <<https://www.eia.gov/outlooks/aeo/data/browser/#/?id=8-AEO2018®ion=0-0&cases=ref2018&start=2016&end=2050&f=A&linechart=~~ref2018-d121317a.44-8-AEO2018~ref2018-d121317a.42-8-AEO2018&ctype=linechart&sourcekey=0>> (accessed August 30, 2018).

[EIA] U.S. Energy Information Administration. 2018e. “Energy-Related Carbon Dioxide Emissions by State, 2000–2015.” Washington, DC. January 2018. 30 p. Available at <<https://www.eia.gov/environment/emissions/state/analysis/pdf/stateanalysis.pdf>> (accessed August 24, 2018).

Endangered Species Act of 1973, as amended. 16 U.S.C. 1531 et seq.

[Energy Daily] IHS The Energy Daily. 2016. “First U.S. Offshore Wind Farm Delivers Power to Grid.” *The Energy Daily*. Volume 44, Number 238. December 13, 2016. Available at <<http://www.theenergydaily.com>> (accessed September 13, 2018).

[Energy Daily] IHS The Energy Daily. 2017. “Southern Stops Work on Kemper’s Lignite Gasification Technology.” *The Energy Daily*. Volume 45, Number 124. June 29, 2017. Available at <<http://www.theenergydaily.com>> (accessed September 13, 2018).

[EPA] U.S. Environmental Protection Agency. 2002. “EPA Facts About Tritium.” Washington, DC. July 2002. 2 p. Available at <http://www.trainex.org/web_courses/tritium/reference_pages/tritium%20EPA.pdf> (accessed July 10, 2018).

[EPA] U.S. Environmental Protection Agency. 2006. “Voluntary Estuary Monitoring Manual, A Methods Manual.” Second Edition. EPA-842-B-06-003. Washington, DC. March 2006. 396 p. Available at <https://www.epa.gov/sites/production/files/2015-09/documents/2007_04_09_estuaries_monitoruments_manual.pdf> (accessed July 24, 2019).

[EPA] U.S. Environmental Protection Agency. 2009a. “Assessment of the Impacts of Global Change on Regional U.S. Air Quality: A Synthesis of Climate Change Impacts on Ground-Level Ozone.” EPA/600/R-07/094F. Washington, DC. April 2009. 131 p. Available at <<https://cfpub.epa.gov/ncea/risk/recordisplay.cfm?deid=203459>> (accessed September 21, 2018).

[EPA] U.S. Environmental Protection Agency. 2009b. “Endangerment and Cause or Contribute Findings for Greenhouse Gases under Section 202(a) of the Clean Air Act.” Last updated: July 11, 2017. Available at <<https://www.epa.gov/ghgemissions/endangerment-and-cause-or-contribute-findings-greenhouse-gases-under-section-202a-clean>> (accessed September 21, 2018).

[EPA] U.S. Environmental Protection Agency. 2014a. “Municipal Solid Waste: Energy Recovery from Waste.” Last updated: March 29, 2016. Available at <<https://archive.epa.gov/epawaste/nonhaz/municipal/web/html/index-11.html>> (accessed March 27, 2019).

[EPA] U.S. Environmental Protection Agency. 2014b. “Municipal Solid Waste: Basic Information about Energy Recovery from Waste.” Last updated: March 29, 2016. Available at <<https://archive.epa.gov/epawaste/nonhaz/municipal/web/html/basic.html>> (accessed March 27, 2019).

[EPA] U.S. Environmental Protection Agency. 2014c. "Numeric Nutrient Criteria for the State of Florida: Withdrawing the Federal Actions." EPA-820-F-14-006. September 2014. Available at <<https://www.epa.gov/sites/production/files/2015-07/documents/factsheet-withdrawl-2014.pdf>> (accessed July 3, 2018).

[EPA] U.S. Environmental Protection Agency. 2014d. "Greenhouse Gas Inventory Guidance: Direct Fugitive Emissions from Refrigeration, Air Conditioning, Fire Suppression, and Industrial Gases." Washington, DC. November 2014. 20 p. Available at <<https://www.epa.gov/sites/production/files/2015-07/documents/fugitiveemissions.pdf>> (accessed August 24, 2018).

[EPA] U.S. Environmental Protection Agency. 2015. "Mercury and Air Toxics Standards (MATS)." Last updated: February 13, 2018. Available at <<https://www.epa.gov/mats>> (accessed August 28, 2018).

[EPA] U.S. Environmental Protection Agency. 2016a. "Sole Source Aquifers in the Southeast." Last updated: February 2, 2016. Available at <<https://archive.epa.gov/pesticides/region4/water/groundwater/web/html/r4ssa.html#biscayne>> (accessed July 7, 2018).

[EPA] U.S. Environmental Protection Agency. 2016b. "Climate Change Indicators in the United States, 2016. Fourth Edition." EPA 430-R-16-004. Washington, DC. August 2016. 96 p. Available at <<https://www.epa.gov/climate-indicators>> (accessed August 24, 2018).

[EPA] U.S. Environmental Protection Agency. 2016c. "What Climate Change Means for Florida." EPA 430-F-16-011. Washington, DC. August 2016. 2 p. Available at <<https://www.epa.gov/sites/production/files/2016-08/documents/climate-change-fl.pdf>> (accessed August 24, 2018).

[EPA] U.S. Environmental Protection Agency. 2017. "Detailed Facility Report: FPL Turkey Point Nuclear Generating Station." EPA Enforcement and Compliance History Online. Available at <<https://echo.epa.gov/facilities/facility-search>> (search Facility ID Number 110000914832) (accessed April 12, 2017).

[EPA] U.S. Environmental Protection Agency. 2018a. "National Ambient Air Quality Standards Table." Last updated: December 20, 2016. Available at <<https://www.epa.gov/criteria-air-pollutants/naaqs-table>> (accessed September 14, 2018).

[EPA] U.S. Environmental Protection Agency. 2018b. "2014 National Emissions Inventory Report." Available at <<https://gispub.epa.gov/neireport/2014/>> (accessed September 16, 2018).

[EPA] U.S. Environmental Protection Agency. 2019. EJSCREEN: EPA Environmental Justice Screening and Mapping Tool. Available at <<https://ejscreen.epa.gov/mapper/>> (accessed March 1, 2019).

Erftemeijer P.L.A. 1994. "Differences in nutrient concentrations and resources between seagrass communities on carbonate and terrigenous sediments in South Sulawesi, Indonesia." *Bulletin of Marine Science* 54(2): 403-419.

Erftemeijer P.L.A., Middelburg J.J. 1993. "Sediment-nutrient interactions in tropical seagrass beds: a comparison between a terrigenous and a carbonate sedimentary environments in South Sulawesi (Indonesia)." *Marine Ecology Progress Series* 102(1):187-198.

[FAC] *Florida Administrative Code*, Chapter 40E-2, "Consumptive Use." Available at <<https://www.flrules.org/gateway/ChapterHome.asp?Chapter=40E-2>> (accessed August 1, 2018).

[FAC] *Florida Administrative Code*, Rule 62-296.320, “General Pollutant Emission Limiting Standards.” Available at <<https://www.flrules.org/gateway/RuleNo.asp?ID=62-296.320>> (accessed September 21, 2018).

[FAC] *Florida Administrative Code*, Rule 62-520.300, “Purpose and Intent for Ground Water.” Available at <<https://www.flrules.org/gateway/RuleNo.asp?ID=62-520.300>> (accessed July 17, 2018).

[FAC] *Florida Administrative Code*, Rule 62-520.410, “Classification of Ground Water, Usage, Reclassification.” Available at <<https://www.flrules.org/gateway/RuleNo.asp?ID=62-520.410>> (accessed July 17, 2018).

[FAC] *Florida Administrative Code*, Chapter 62-521, “Wellhead Protection.” Available at <<https://www.flrules.org/gateway/ChapterHome.asp?Chapter=62-521>> (accessed July 24, 2019).

[FAC] *Florida Administrative Code*, Chapter 62-528, “Underground Injection Control.” Available at <<https://www.flrules.org/gateway/ChapterHome.asp?Chapter=62-528>> (accessed December 7, 2018).

[FAC] *Florida Administrative Code*, Chapter 62-550, “Drinking Water Standards, Monitoring, and Reporting.” Available at <<https://www.flrules.org/gateway/ChapterHome.asp?Chapter=62-528>> (accessed July 24, 2019).

[FAC] *Florida Administrative Code*, Chapter 68A-27, “Rules Relating to Endangered or Threatened Species.” Available at <<https://www.flrules.org/gateway/ChapterHome.asp?Chapter=68A-27>> (accessed on September 11, 2018).

[FDACS] Florida Department of Agriculture and Consumer Services. 2017. “Office of Energy Annual Report.” Tallahassee, FL. 2017. 25 p. Available at <https://www.freshfromflorida.com/content/download/79009/2320944/2017_Office_of_Energy_Annual_Report.pdf> (accessed September 20, 2018).

[FDEP] Florida Department of Environmental Protection. 2005. “State of Florida: Industrial Wastewater Facility Permit, Permit Number FL0001562.” Issued May 6, 2005. Available at <<http://prodenv.dep.state.fl.us/DepNexus/public/electronic-documents#>> (search facility/site ID: FL0001562, document date: 5/16/2005) (accessed July 18, 2018).

[FDEP] Florida Department of Environmental Protection. 2013. “Underground Injection Control Class I Injection Well System, Construction and Testing Permit, Permit Number 293962-002-UC.” Issued July 29, 2013. Available at <<http://prodenv.dep.state.fl.us/DepNexus/public/electronic-documents>> (search facility/site ID: FL0001562, document date: 7/29/2013) (accessed July 7, 2018).

[FDEP] Florida Department of Environmental Protection. 2014. “Administrative Order in the Matter of Florida Power and Light Company, DEP State License No. PA03-45, OGC No. 14-0741.” December 23, 2014. ADAMS Accession No. ML15026A548.

[FDEP] Florida Department of Environmental Protection. 2016a. “Consent Order, OGC File Number 16-0241, between the State of Florida Department of Environmental Protection and Florida Power & Light Company regarding settlement of Matters at Issue [Westward Migration of Hypersaline Water from the Turkey Point Facility and Potential Releases to Deep Channels on the Eastern and Southern Side of the Facility].” June 20, 2016. ADAMS Accession No. ML16216A216.

[FDEP] Florida Department of Environmental Protection. 2016b. "Conditions of Certification, Florida Power & Light Company, Turkey Point Plant Units 3 and 4 Nuclear Power Plant Unit 5 Combined Cycle Plant, PA 03-45E." Last updated: March 29, 2016. Available at <<https://floridadep.gov/air/siting-coordination-office/content/turkey-point-power-plant>> (accessed July 7, 2018).

[FDEP] Florida Department of Environmental Protection. 2016c. Letter from F. Aschauer, Jr., to J. Leon, Registered Agent, Florida Power and Light Company. Subject: "Warning Letter #WL16-000151W13SED, Turkey Point Power Plant, Facility ID No.: FL0001562, Miami-Dade County." April 25, 2016. ADAMS Accession No. ML16216A215.

[FDEP] Florida Department of Environmental Protection. 2016d. "Notice of Violation and Orders for Corrective Action, OGC File No.: 16-0241, Florida Power and Light Company, Final Order." April 25, 2016. ADAMS Accession No. ML16216A214.

[FDEP] Florida Department of Environmental Protection. 2016e. Citation not used.

[FDEP] Florida Department of Environmental Protection. 2016f. Letter from J. Haberfeld, P.G., Environmental Administrator, Aquifer Protection Program, Division of Water Resource Management, to M. Raffenberg, Environmental Services Director, Florida Power & Light Company. Subject: "FPL Turkey Point Class I Injection Well Construction and Testing Permit - Authorization for Operational Testing." September 21, 2016. Available at <<http://prodenv.dep.state.fl.us/DepNexus/public/electronic-documents#>> (search Permit/Application Number 293962-002) (accessed July 7, 2018).

[FDEP] Florida Department of Environmental Protection. 2016g. Letter from J. Haberfeld, P.G., Environmental Administrator, Aquifer Protection Program, Division of Water Resource Management, to M. Raffenberg, Environmental Services Director, Florida Power & Light Company. Subject: Minor Modification to FDEP Permit 293962-002-UC to Allow the Inclusion of Biscayne Aquifer Groundwater Disposal Directed to the Injection Well. Permit Number 293962 003-UC/MM. May 25, 2016. Available at <<http://prodenv.dep.state.fl.us/DepNexus/public/electronic-documents#>> (search Permit/Application Number 293962-002) (accessed July 7, 2018).

[FDEP] Florida Department of Environmental Protection. 2016h. Final Order, DEP #16-0111, OGC Case No. 14-0741, DOAH Case No. 15-1746, DOAH Case No. 15-1747. April 21, 2016. Available at <<https://floridadep.gov/ogc/ogc/documents/14-0741>> (accessed July 7, 2018).

[FDEP] Florida Department of Environmental Protection. 2016i. Warning Letter #WL16 000151W13SED, Turkey Point Power Plant, Facility ID No.: FL0001562, Miami-Dade County. April 25, 2016. ADAMS Accession No. ML16216A215.

[FDEP] Florida Department of Environmental Protection. 2017a. Factsheet About Outstanding Florida Waters (OFW). November 2017. 4 p. Available at <https://floridadep.gov/sites/default/files/OFW%20factsheet_0.pdf> (accessed June 11, 2018).

[FDEP] Florida Department of Environmental Protection. 2017b. "Biscayne Bay Aquatic Preserves." Last updated: September 5, 2017. Available at <<https://floridadep.gov/fco/aquatic-preserve/locations/biscayne-bay-aquatic-preserves>> (accessed June 14, 2018).

[FDEP] Florida Department of Environmental Protection. 2018a. "NPDES Permits and Forms, Generic Permit for Stormwater Discharge from Large and Small Construction Activities." Last updated January 8, 2018. Available at <<https://floridadep.gov/water/stormwater/content/npdes-permits-and-forms>> (accessed July 7, 2018).

[FDEP] Florida Department of Environmental Protection. 2018b. Standards and Facts Drinking Water. Last updated April 11, 2018. Available at <<https://floridadep.gov/comm/press-office/documents/drinking-water-standards>> (accessed July 7, 2018).

[FDEP] Florida Department of Environmental Protection. 2018c. "Title V Air Operation Permit Renewal, Permit No. 0250003-028-AV." Issued April 26, 2018. Available at <<https://fldep.dep.state.fl.us/air/emission/apds/default.asp>> (search: permit number 0250003-028-AV) (accessed September 16, 2018).

[FDEP] Florida Department of Environmental Protection. 2018d. "Underground Injection Control Class I Injection Well System Operation Permit, Permit Number 0293962-004-UO/11." Issued July 12, 2018. Available at <<http://prodenv.dep.state.fl.us/DepNexus/public/electronic-documents>> (search permit/application number: 0293962-004-UO, document date: 7/12/2018) (accessed August 10, 2018).

[FDEP] Florida Department of Environmental Protection. 2018e. Florida Administrative Code 62-302.532 Estuary-Specific Numeric Interpretations of the Narrative Nutrient Criterion, OGC File No. 16-0241. 2018. Available at <<https://www.flrules.org/gateway/RuleNo.asp?title=SURFACE%20WATER%20QUALITY%20STANDARDS&ID=62-302.532>> (view Section 62-302.532, ID 17115861, effective 2/17/2016) (accessed July 3, 2018).

[FDEP] Florida Department of Environmental Protection. 2018f. Letter from B. Melnick, Deputy Director, Division of Water Resource Management, to B. Stamp, Florida Power & Light Company. Subject: Notice of draft National Pollutant Discharge Elimination System Permit Renewal for Permit No. FL0001562. December 27, 2018. 66 p. ADAMS Accession No. ML19095B424.

[FDEP] Florida Department of Environmental Protection. 2018g. "Title V Air Operation Permit Renewal, Permit No. 0250003-030-AV." Issued November 21, 2018. Available at <<https://fldep.dep.state.fl.us/air/emission/apds/default.asp>> (search: permit number 0250003-030-AV) (accessed June 14, 2019).

[FDOH] Florida Department of Health. 2018a. "Well Surveillance Mapping Site." Last updated August 9, 2016. Available at <<http://www.floridahealth.gov/environmental-health/drinking-water/well-surveillance-mapping-site.html>> (accessed July 7, 2018).

[FDOH] Florida Department of Health. 2018b. "Radioactive Materials." Last updated October 1, 2015. Available at <<http://www.floridahealth.gov/environmental-health/radiation-control/radmat/index.html>> (accessed December 31, 2018).

[FDOT] Florida Department of Transportation. 2007. "Strategic Aggregates Study: Sources, Constraints, and Economic Value of Limestone and Sand in Florida, Parts I and II." Lampl Herbert Consultants, Tallahassee, FL. March 12, 2007. 126 p. Available at <http://www.iti.northwestern.edu/publications/dowding/acm/Lampl_Herbert_Consultants-2007-Strategic_Aggregates_Study_Sources_Constraints_and_Economic_Value_of_Limestone_and_Sand_in_Florida.pdf> (accessed April 30, 2018).

[FDOT] Florida Department of Transportation. 2017. "Annual Average Daily Traffic Report." Available at <<https://tdaappsprod.dot.state.fl.us/fto>> (accessed May 11, 2018).

Federal Water Pollution Control Act (Clean Water Act or CWA) of 1972, as amended.
33 U.S.C. 1251 et seq.

[FEMA] U.S. Federal Emergency Management Agency. 2014. "Base Flood." Last updated: November 2014. Available at <<https://www.fema.gov/base-flood>> (accessed August 29, 2018).

[FEMA] U.S. Federal Emergency Management Agency. 2018a. "Earthquake Hazard Maps." Last updated: April 16, 2018. Available at <<https://www.fema.gov/earthquake-hazard-maps>> (accessed April 30, 2018).

[FEMA] U.S. Federal Emergency Management Agency. 2018b. "Definitions of FEMA Flood Zone Designations." August 2018. Available at <<https://snmapmod.snco.us/fmm/document/fema-flood-zone-definitions.pdf>> (accessed 29 August 2018).

Ferdie M., Fourqurean J.W. 2004. "Response of seagrass communities to fertilization along a gradient of relative availability of nitrogen and phosphorus in a carbonate environment." *Limnology and Oceanography* 49(6):2082-2094.

[FFWCC] Florida Fish and Wildlife Conservation Commission. Undated. "Miami Blue Butterfly." Available at <<https://myfwc.com/media/2278/miami-blue-butterfly.pdf>> (accessed August 28, 2018).

[FFWCC] Florida Fish and Wildlife Conservation Commission. 2016. Email: R. Zambrano, FFWCC to M. Aldecoa, FPL. Subject: Least Terns at Turkey Point. June 15, 2016. ADAMS Accession No. ML18247A526. In: FPL 2018h, Attachment 20, Enclosure 1. ADAMS Accession No. ML18247A507.

[FFWCC] Florida Fish and Wildlife Conservation Commission. 2018. Florida Shorebird Database. Available at <<https://public.myfwc.com/crossdoi/shorebirds/>> (accessed August 27, 2018).

[FHR] Florida House of Representatives. 2010. "Florida Education Finance Program," 2010–2011 Education Fact Sheets. Pp. 23–31. Available at <<http://basiceducationfundingcommission.pasenategop.com/wp-content/uploads/sites/68/2014/10/2010-11-Florida-Education-Finance-Program-FEFP.3.pdf>> (accessed May 1, 2018).

Fischer C., Schlupp I. 2009. "Differences in thermal tolerance in coexisting sexual and asexual mollies (Poecilia, Poeciliidae, Teleostei)." *Journal of Fish Biology* 74:1662–1668.

Fla. Stat. § 258.397. Available at <http://leg.state.fl.us/Statutes/index.cfm?App_mode=Display_Statute&Search_String=&URL=0200-0299/0258/Sections/0258.397.html> (accessed June 11, 2018).

[FKAA] Florida Keys Aqueduct Authority. 2016. Wellfield Protection, Florida Power and Light. Key West, FL. Available at <<https://fkaa.blob.core.windows.net/pressreleases/2016-03-01%20Wellfield%20Protection%20-%20Florida%20Power%20and%20Light.pdf>> (accessed July 24, 2019).

[FKAA] Florida Keys Aqueduct Authority. 2019a. "Resources, Where Does My Water Come From?, Drinking Water, Alternative Water Supply Plan." Available at <<http://www.fkaa.com/infoRepository.html>> (accessed July 24, 2019).

[FLDOE] Florida Department of Education. 2017. "2017–18 Funding for Florida School Districts." 2017. 43 p. Available at <<http://www.fldoe.org/core/fileparse.php/7507/urlt/Fefpdist.pdf>> (accessed May 1, 2018).

[FNAI] Florida Natural Areas Inventory. 2018. "Florida Natural Areas Inventory Tracking List, Miami–Dade County." Last updated: March 2018. Available at <<http://fnai.org/trackinglist.cfm>> (search: Miami–Dade County) (accessed August 15, 2018).

Foti R., et al. 2012. "Hydroperiod regime controls the organization of plant species in wetlands." *Proceedings of the National Academy of Sciences of the United States of America*. 109(48):19596–19600. Available at <<https://www.ncbi.nlm.nih.gov/pmc/articles/PMC3511740/>> (accessed August 27, 2018).

Fourqurean J.W., Powell G.V.N., Kenworthy W.J., Zieman J.C. 1995. "The effects of long-term manipulation of nutrient supply on competition between the seagrasses *Thalassia testudinum* and *Halodule wrightii* in Florida Bay." *Oikos* 72(3): 349-358.

Fourqurean J.W., Willsie A.W., Rose C.D., Rutten L.M. 2001. "Spatial and temporal pattern in seagrass community composition and productivity in south Florida." *Marine Biology* 138(2):341-354.

Fourqurean J.W., Zieman. 2002 J.C. "Nutrient content of the seagrass *Thalassia testudinum* reveals regional patterns of relative availability of nitrogen and phosphorus in the Florida Keys USA." *Biogeochemistry* 61:229-245.

[FPL] Florida Power & Light Company. 2000. "Applicant's Environmental Report - Operating License Renewal Stage, Turkey Point Units 3 & 4." September 8, 2000. ADAMS Accession No. ML003749667.

[FPL] Florida Power & Light Company. 2010. "Turkey Point Monitoring Plan, South Dade Water Issues Meeting." October 4, 2010. 17 p. Available at <https://www.sfwmd.gov/sites/default/files/documents/fpl_tp_monitor_plan_implementation_stat.us.pdf> (accessed July 6, 2018).

[FPL] Florida Power & Light Company. 2011a. "Turkey Point Plant Annual Monitoring Report Units 3 & 4 Uprate Project." Ecology and Environment, Inc. August 2011. Available at <[ftp://ftp.sfwmd.gov/pub/SMDWIC/turkey_point/annual_monitoring_report/2011/Disk1-Annual Monitoring Report 2011.zip](ftp://ftp.sfwmd.gov/pub/SMDWIC/turkey_point/annual_monitoring_report/2011/Disk1-Annual_Monitoring_Report_2011.zip)> (accessed July 6, 2018).

[FPL] Florida Power & Light Company. 2011b. "Turkey Point Units 6 & 7 Section 404(b)(1) Alternatives Analysis." October 2011. ADAMS Accession No. ML11319A035.

[FPL] Florida Power & Light Company. 2012a. "Turkey Point Plant - Comprehensive Pre-Uprate Monitoring Report, Units 3 & 4 Uprate Project." Ecology and Environment, Inc. 002998.FC11.01. 3841 p. October 31, 2012. ADAMS Accession No. ML15026A503.

[FPL] Florida Power & Light Company. 2012b. "Turkey Point Units 6 & 7 Federal Biological Assessment for Six Listed Species." November 2012. 255 p. ADAMS Accession No. ML123390437.

[FPL] Florida Power & Light Company. 2012c. FPL Turkey Point Combined Monitoring Site, 2012 Semi-Annual Report Data, Marsh and Mangrove. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2013a. "Offsite Dose Calculation Manual for Gaseous and Liquid Effluents from the Turkey Point Plant Units 3 and 4." Revision 20. December 19, 2013. ADAMS Accession No. ML14070A086.

[FPL] Florida Power & Light Company. 2013b. Florida Power and Light – Turkey Point Plant Units 3 and 4 – Annual Radioactive Effluent Release Report – January 2012 through December 2012." March 1, 2013. 281 p. ADAMS Accession No. ML13071A554.

[FPL] Florida Power & Light Company. 2013c. FPL Turkey Point Combined Monitoring Site, 2013 Data Delivery (Reporting Period: July 1 2012-May 31 2013), Ecological Data, Marsh-Mangrove. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2013d. FPL Turkey Point Combined Monitoring Site, 2013 Data Delivery (Reporting Period: July 1 2012-May 31 2013), Ecological Data, Biscayne Bay. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2014a. "Turkey Point Units 6 & 7 COL Application, Part 3—Environmental Report." Revision 6. December 8, 2014. 2,038 p. ADAMS Accession No. ML14342A011.

[FPL] Florida Power & Light Company. 2014b. "Turkey Point Plant Annual Post-Uprate Monitoring Report, Units 3 & 4 Uprate Project – August 2014." Ecology and Environment, Inc., Lancaster, New York. August 2014. 537 p. Available at<ftp://ftp.sfwmd.gov/pub/SMDWIC/turkey_point/2014_annual_post_uprate_report/1-report_sections.zip> (accessed July 7, 2018).

[FPL] Florida Power & Light Company. 2014c. "2013 Annual Radiological Environmental Operating Report, Turkey Point Plant – Units 3 & 4." 102 p. May 5, 2014. ADAMS Accession No. ML14139A082.

[FPL] Florida Power & Light Company. 2014d. "Turkey Point Plant, Units 3 and 4 – Annual Radioactive Effluent Release Report – January 2013 through December 2013." December 31, 2013. 67 p. ADAMS Accession No. ML14070A085.

[FPL] Florida Power & Light Company. 2014e. FPL Turkey Point Combined Monitoring Site, 2014 Data Delivery (Reporting Period: June 1 2013-November 30 2013), Ecological Data, Marsh-Mangrove. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2014f. FPL Turkey Point Combined Monitoring Site, 2014 Data Delivery (Reporting Period: June 1 2013-November 30 2013), Ecological Data, Biscayne Bay. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2015a. "Turkey Point Plant, Units 3 and 4 – Annual Radioactive Effluent Release Report – January 2014 through December 2014." February 25, 2015. 324 p. ADAMS Accession No. ML15072A014.

[FPL] Florida Power & Light Company. 2015b. "2014 Annual Radiological Environmental Operating Report, Turkey Point Plant, Units 3 & 4." 101 p. May 11, 2015. ADAMS Accession No. ML15147A515.

[FPL] Florida Power & Light Company. 2015c. FPL Turkey Point Combined Monitoring Site, 2015 Data Delivery (Reporting Period: June 1 2014-November 30 2014), Ecological Data, Marsh-Mangrove. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2015d. FPL Turkey Point Combined Monitoring Site, 2015 Data Delivery (Reporting Period: June 1 2014-November 30 2014), Ecological Data, Biscayne Bay. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2016a. "Turkey Point Plant Comprehensive Post-Uprate Monitoring Report, Units 3 & 4 Uprate Project." Prepared by Ecology and Environment, Inc., Lancaster, New York. March 31, 2016. 666 p. Available at <<http://prodenv.dep.state.fl.us/DepNexus/public/electronic-documents#>> (search facility/site ID: FL0001562, document date: 3/31/2016) (accessed July 7, 2018).

[FPL] Florida Power & Light Company. 2016b. "Turkey Point Plant Annual Monitoring Report – August 2016." Prepared by Ecology and Environment, Inc., Lancaster, New York. August 2016. Available at <<http://prodenv.dep.state.fl.us/DepNexus/public/electronic-documents#>> (search facility/site ID: FL0001562, document date: 8/1/2016) (accessed July 7, 2018).

[FPL] Florida Power & Light Company. 2016c. "Joint Application for Individual Environmental Resource Permit/Authorization to use State-Owned Submerged Lands/Federal Dredge and Fill Permit, Turtle Point and Barge Canal/Basin Water Quality Improvement Projects." August 2, 2016. ADAMS Accession No. ML18247A510. In: FPL 2018h, Attachment 5, Enclosure 1 ADAMS Accession No. ML18247A509.

[FPL] Florida Power & Light Company. 2016d. FPL Turkey Point Combined Monitoring Site, 2016 Data Delivery (Reporting Period: June 1 2015-November 30 2015), Ecological Data, Marsh-Mangrove. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2016e. "Consent Agreement 2016 Annual Report." November 10, 2016. Available at <<http://ecmrrer.miamidade.gov:8080/hpi/search>> (search Case Number: HWR-00945, Date: 11/11/2016) also available at <<https://www.fpl.com/landing/pdf/ca-annual-report.pdf>> (accessed July 9, 2018).

[FPL] Florida Power & Light Company. 2016f. "Florida Power & Light Company Turkey Point Power Plant Cooling Canal System (CCS) Freshening Effectiveness Report." Ecology and Environment, Inc. January 29, 2016. 70 p. Available at <<http://prodenv.dep.state.fl.us/DepNexus/public/searchPortal>> (search facility/site ID: FL0001562, document date: 1/29/2016) (accessed July 9, 2018).

[FPL] Florida Power & Light Company. 2016g. "Turkey Point Remnant Canal Site Assessment Plan." September 14, 2016. Available at <<http://ecmrrer.miamidade.gov:8080/hpi/search>> (search Case Number: CLI-2016-0428, Date: 9/15/2016) (accessed July 3, 2018).

[FPL] Florida Power & Light Company. 2016h. "Updated Final Safety Analysis Report, Turkey Point Units 3 & 4." Revised September 20, 2016. ADAMS Accession No. ML18117A085 (Section 11.1.2 is at ADAMS Accession No. ML18117A101).

[FPL] Florida Power & Light Company. 2016i. "Florida Power and Light, Turkey Point Plant Units 3 and 4 – Annual Radioactive Effluent Release Report – January 2015 through December 2015." February 26, 2016. 297 p. ADAMS Accession No. ML16109A044.

[FPL] Florida Power & Light Company. 2016j. "2015 Annual Radiological Environmental Operating Report – Turkey Point Plant, Units 3 & 4." May 12, 2016. 100 p. ADAMS Accession No. ML16144A790.

[FPL] Florida Power & Light Company. 2016k. "Turkey Point Cooling Canal System Nutrient Management Plan." September 16, 2016. 28 p. Available at <<http://www.psc.state.fl.us/library/filings/2017/09365-2017/Support/EXH%2061%2020170007%20-%20Staff's%203rd%20INT%20No.%2062%20-%20Attachment%20No.%202.pdf>> (accessed July 19, 2018).

[FPL] Florida Power & Light Company. 2016l. "Florida Power and Light, Turkey Point Plant, Units 3 and 4 – Annual Radioactive Effluent Release Report – January 2015 through December 2015." February 26, 2016. ADAMS Accession No. ML16109A044.

[FPL] Florida Power & Light Company. 2016m. FPL Turkey Point Combined Monitoring Site, 2016 Data Delivery (Reporting Period: June 1 2015-November 30 2015), Ecological Data, Biscayne Bay. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2017a. "Turkey Point Plant Annual Monitoring Report, September 2017." Prepared by Ecology and Environment, Inc., Lancaster, New York. September 2017. 414 p. Available at <<http://prodenv.dep.state.fl.us/DepNexus/public/electronic-documents#>> (search facility/site ID: FL0001562, document date: 9/28/2017) (accessed July 7, 2018).

[FPL] Florida Power & Light Company. 2017b. "2017 Annual Turkey Point Power Plant Remediation/Restoration Report." November 2017. Available at <<http://prodenv.dep.state.fl.us/DepNexus/public/searchPortal>> (search facility/site ID: FL0001562, document date: 11/1/2017) (accessed July 9, 2018).

[FPL] Florida Power & Light Company. 2017c. "Site Assessment Report – Ammonia in Surface Waters. Turkey Point Facility." March 17, 2017. 1709 p. Available at <<http://ecmrrer.miamidade.gov:8080/hpi/search>> (search Case Number: CLI-2016-0428, Date: 3/17/2017) (accessed July 5, 2018).

[FPL] Florida Power & Light Company. 2017d. "2016 Annual Radiological Environmental Operating Report – Turkey Point Plant, Units 3 & 4." May 11, 2017. 102 p. ADAMS Accession No. ML17131A341.

[FPL] Florida Power & Light Company. 2017e. "Florida Power and Light, Turkey Point Plant Units 3 and 4 – Annual Radioactive Effluent Release Report – January 2016 through December 2016." February 28, 2017. 297 p. ADAMS Accession No. ML17067A032.

[FPL] Florida Power & Light Company. 2017f. FPL Turkey Point Combined Monitoring Site, 2017 Data Delivery (Reporting Period: June 1 2016-November 30 2016), Ecological Data, Marsh-Mangrove. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2017g. FPL Turkey Point Combined Monitoring Site, 2017 Data Delivery (Reporting Period: June 1 2016-November 30 2016), Ecological Data, Biscayne Bay. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2017h. "Responses to MDC DERM July 7, 2017, Request for Supplemental Information in support of FPL's March 17, 2017 Site Assessment Report." 25 p. Available at <<http://ecmrrer.miamidade.gov:8080/hpi/search>> (search Case Number: CLI-2016-0428, Date: 11/13/2017) (accessed July 5, 2018).

[FPL] Florida Power & Light Company. 2018a. "Turkey Point Units 3 and 4 – Subsequent License Renewal Application. January 30, 2018. ADAMS Accession No. ML18037A812.

[FPL] Florida Power & Light Company. 2018b. "Turkey Point Units 3 and 4 Subsequent License Renewal Application – Supplement 1." February 9, 2018. ADAMS Accession No. ML18044A653.

[FPL] Florida Power & Light Company. 2018c. "Turkey Point Units 3 and 4 Subsequent License Renewal Application – Supplement 2." February 16, 2018. ADAMS Accession No. ML18053A123.

[FPL] Florida Power & Light Company. 2018d. "Turkey Point Units 3 and 4 Subsequent License Renewal Application – Supplement 3." March 1, 2018. ADAMS Accession No. ML18072A224.

[FPL] Florida Power & Light Company. 2018e. "Turkey Point Units 3 and 4 Subsequent License Renewal Application – Revision 1." April 10, 2018. ADAMS Accession No. ML18113A132.

[FPL] Florida Power & Light Company. 2018f. "Applicant's Environmental Report – Subsequent Operating License Renewal Stage – Turkey Point Nuclear Plant Units 3 and 4." January 2018. 762 p. ADAMS Accession No. ML18037A836.

[FPL] Florida Power & Light Company. 2018g. "Ten Year Power Plant Site Plan, 2018 – 2027." April 2018. 179 p. Available at <<https://www.fpl.com/company/pdf/10-year-site-plan.pdf>> (accessed May 18, 2018).

[FPL] Florida Power & Light Company. 2018h. Letter from W. Maher, Senior Licensing Director, Florida Power & Light Company, to NRC Document Control Desk. Subject: "Turkey Point Units 3 and 4 Subsequent License Renewal Application Environmental Report Requests for Additional Information (RAI) Responses." August 8, 2018. ADAMS Accession No. ML18247A509.

[FPL] Florida Power & Light Company. 2018i. Monthly Hypersaline Extraction Summary. In FPL 2018h, FPL Response to NRC RAI No. WR-3, L-2018-136 Attachment 44, Enclosure 1, p. 1 of 5. ADAMS Accession No. ML18247A563.

[FPL] Florida Power & Light Company. 2018j. "Florida Power and Light, Turkey Point Plant Units 3 and 4 – Annual Radioactive Effluent Release Report – January 2017 through December 2017." February 15, 2018. 300 p. ADAMS Accession No. ML18066A562.

[FPL] Florida Power & Light Company. 2018k. "2017 Annual Radiological Environmental Operating Report – Turkey Point Plant, Units 3 & 4." April 23, 2018. 96 p. ADAMS Accession No. ML18137A201.

[FPL] Florida Power & Light Company. 2018l. Supporting Monthly Volume [Groundwater Withdrawal] Tables. In: FPL 2018h, FPL Response to NRC RAI No. WR-2, L-2018-136 Attachment 43, Enclosure 20, 3 p. ADAMS Accession No. ML18247A559.

[FPL] Florida Power & Light Company. 2018m. Letter from W. Maher, Senior Licensing Director, Florida Power & Light Company, to NRC Document Control Desk. Subject: "Turkey Point Units 3 and 4 Subsequent License Renewal Application Environmental Review Requests for Additional Information (RAI) Set 3 Responses." October 5, 2018. 62 p. ADAMS Accession No. ML18283A882.

[FPL] Florida Power & Light Company. 2018n. Letter from W. Maher, Senior Licensing Director, FPL, to NRC Document Control Desk. Subject: "Turkey Point Units 3 and 4 Subsequent License Renewal Application, Appendix E Environmental Report Supplemental Information." April 10, 2018. 35 p. ADAMS Accession No. ML18102A521.

[FPL] Florida Power & Light Company. 2018o. "Turkey Point Plant Annual Monitoring Report, August 2018." Prepared by Ecology and Environment, Inc., Lancaster, New York. August 2018. 2,195 p. Available at <<http://prodenv.dep.state.fl.us/DepNexus/public/electronic-documents/PA03-45/facility!search>> (search document date 8-31-2018) (accessed June 7, 2019).

[FPL] Florida Power & Light Company. 2018p. "2018 Annual Turkey Point Power Plant Remediation/Restoration Report." December 2018. ADAMS Accession No. ML19095B494.

[FPL] Florida Power & Light Company. 2018q. "Recovery Well System Startup Report." October 5, 2018. 65 p. ADAMS Accession No. ML19095B382.

[FPL] Florida Power & Light Company. 2018r. Letter from M. Raffenberg, Sr. Director, Environmental Licensing and Permitting, Florida Power & Light Company to W. Mayorga, Chief, Environmental Monitoring and Restoration Division, Division of Environmental Resources Management. Subject: Miami Dade County July 10, 2018 Letter regarding the FPL Site Assessment Report (SAR) dated March 17, 2017 and the SAR Supplemental Information Submittal dated November 11, 2017. October 8, 2018. Available at <<http://ecmrer.miamidade.gov:8080/hpi/search>> (search Case Number: CLI-2016-0428, Date: 10/08/2018) (accessed July 16, 2019). ADAMS Accession No. ML19095B384.

[FPL] Florida Power & Light Company. 2018s. FPL Turkey Point Combined Monitoring Site, 2018 Data Delivery (Reporting Period: June 1 2017-November 30 2017), Ecological Data, Marsh-Mangrove. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2018t. FPL Turkey Point Combined Monitoring Site, 2018 Data Delivery (Reporting Period: June 1 2017-November 30 2017), Ecological Data, Biscayne Bay. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2019a. Letter from W. Maher, Senior Licensing Director, FPL, to NRC Document Control Desk. Subject: "Turkey Point Units 3 and 4 Subsequent License Renewal Application, Environmental Report Environmental Authorizations Updated Information." January 23, 2019. 9 p. ADAMS Accession No. ML19025A077.

[FPL] Florida Power & Light Company. 2019b. "Turkey Point Plant, Units 3 and 4 – Annual Radioactive Effluent Release Report – January 2018 through December 2018." February 27, 2019. 308 p. ADAMS Accession No. ML19070A111.

[FPL] Florida Power & Light Company. 2019c. "2018 Annual Radiological Environmental Operating Report – Turkey Point Plant, Units 3 & 4." May 2, 2019. 360 p. ADAMS Accession No. ML19136A190.

[FPL] Florida Power & Light Company. 2019d. Letter from W. Maher, Senior Licensing Director, FPL, to NRC. Subject: FPL Comments Regarding the NRC Biological Assessment. April 18, 2019. ADAMS Accession No. ML19112A023.

[FPL] Florida Power & Light Company. 2019e. Letter from W. Maher, Senior Licensing Director, FPL, to NRC. Subject: Florida Power & Light Company Comments Regarding the Turkey Point Nuclear Generating Unit Nos. 3 and 4 Subsequent License Renewal Draft Supplement 5. May 20, 2019. ADAMS Accession No. ML19112A023.

[FPL] Florida Power & Light Company. 2019f. FPL Turkey Point Combined Monitoring Site, 2019 Data Delivery (Reporting Period: June 1 2018-November 30 2018), Ecological Data, Marsh-Mangrove. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 22, 2019).

[FPL] Florida Power & Light Company. 2019g. FPL Turkey Point Combined Monitoring Site, Charting Tool, Analytical, Groundwater, Biscayne Bay, Terrestrial (Search and plot for selected wells and analytical parameters, for the period 4/1/2010-9/1/2018). FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 23, 2019).

[FPL] Florida Power & Light Company. 2019h. FPL Turkey Point Combined Monitoring Site, 2019 Data Delivery (Reporting Period: June 1 2018-November 30 2018), Ecological Data, Biscayne Bay. FPL Electronic Data Management System (EDMS) [online database]. Available at <<https://www.ptn-combined-monitoring.com>> (accessed July 23, 2019).

[FPL] Florida Power & Light Company. 2019i. "Turkey Point Recovery Well System (RWS) Third Quarter Status Report, Turkey Point Recovery Well System (RWS) Second Quarter Status Report." March 15, 2019. 8 p. ADAMS Accession No. ML19095B428.

[FPL] Florida Power and Light Company. 2019l. "Ten Year Power Plant Site Plan, 2019 – 2028." April 2019. 231 p. Available at <<https://www.fpl.com/company/pdf/10-year-site-plan.pdf>> (accessed July 19, 2019).

[FWS] U.S. Fish and Wildlife Service. 1999. "South Florida multi-species recovery plan." Available at <<https://www.fws.gov/verobeach/ListedSpeciesMSRP.html#jump4>> (accessed August 28, 2018).

[FWS] U.S. Fish and Wildlife Service. 2008. "Carter's mustard (*Warea carteri*) 5-Year Review: Summary and Evaluation." September 15, 2008. Available at <https://ecos.fws.gov/docs/five_year_review/doc1977.pdf> (accessed August 30, 2018).

[FWS] U.S. Fish and Wildlife Service. 2010. "U.S. Fish and Wildlife Service Species Assessment and Listing Priority Assignment Form: *Chromolaena frustrata* (Cape Sable Thoroughwort)." April 5, 2010. 20 p. ADAMS Accession No. ML14230A018.

[FWS] U.S. Fish and Wildlife Service. 2017. Letter from R. Hinzman, Field Supervisor South Florida Ecological Services Office, FWS, to A. Williamson, Project Manager, NRC. Subject: "Biological Opinion for Combined License for Turkey Point Nuclear Plant, Units 6 and 7." June 23, 2017. ADAMS Accession No. ML17177A673.

[FWS] U.S. Fish and Wildlife Service. 2018a. IPaC Resource List for the Turkey Point Subsequent License Renewal Project. September 11, 2018. 25 p. Accession No. ML18254A341.

[FWS] U.S. Fish and Wildlife Service. 2018b. Letter from South Florida Ecological Services Field Office, FWS. Subject: "Updated list of threatened and endangered species that may occur in your proposed project location, and/or may be affected by your proposed project." December 14, 2018. Accession No. ML18348A889.

[FWS] U.S. Fish and Wildlife Service. 2019a. Email from FWS to NRC, Summary of Conference Call and Updated Effect Determinations for Certain Federally Listed Species. February 25, 2019. ADAMS Accession No. ML19085A044.

[FWS] U.S. Fish and Wildlife Service. 2019b. Biological Opinion for Turkey Point Nuclear Plant Units 3 and 4 License Renewal, Miami-Dade County. Consultation Code: 04EF2000-2014-F-0177-R001. February 25, 2019. ADAMS Accession No. ML19221B583.

[FWS] U.S. Fish and Wildlife Service. 2019c. E-mail from J. Rivera, Supervisory Fish and Wildlife Biologist, FWS, to B. Grange, Conservation Biologist, NRC. Subject: Clarification of manatee critical habitat conclusion in Turkey Point biological opinion. August 16, 2019. ADAMS Accession No. ML19259A085.

[FWS and NMFS] U.S. Fish and Wildlife Service and National Marine Fisheries Service. 1998. "Endangered Species Consultation Handbook: Procedures for Conducting Consultation and Conference Activities Under Section 7 of the Endangered Species Act." March 1998. 315 p. Available at <http://www.fws.gov/endangered/esa-library/pdf/esa_section7_handbook.pdf> (accessed August 30, 2018).

[GCP] Global Carbon Project. 2018. "Global Carbon Atlas." Available at <<http://www.globalcarbonatlas.org/en/CO2-emissions>> (accessed August 24, 2018).

[GMCVB] The Greater Miami Convention and Visitors Bureau. 2018. Miami-Dade Monthly Hotel Inventory by Regions, May 2018. Available at <<https://www.miamiandbeaches.com/gmcvb-partners/tools-resources/research-statistics>> (accessed July 24, 2018).

[Golder] Golder Associates, Inc. 2008. "Cooling Canal System Modeling Report." January 13, 2008. 31 p. ADAMS Accession No. ML13072A713.

[Golder] Golder Associates, Inc. 2016. "Water Supply Alternatives Analysis, Florida Power and Light Company, Turkey Point." March 2016. 31 p. Available at <<http://ecmrrer.miamidade.gov:8080/hpi/search>> (search Case Number: HWR-00942, Date: 3/31/2016) (accessed August 23, 2018).

Harrington R.W. Jr., Harrington E.S. 1961. "Food selection among fishes invading a high subtropical salt marsh from onset of flooding through the progress of a mosquito brood." *Ecology* 42:646–666.

HDR Engineering, Inc. 2009. "Florida Power and Light, Turkey Point Exploratory Drilling and Aquifer Performance Test Program." West Palm Beach, FL. August 19, 2009. 351 p. ADAMS Accession No. ML110820053.

[High Bridge] High Bridge Associates. Undated. "Expert Report of Ron Seagraves for Southern Alliance for Clean Energy, et al., v. Florida Power & Light Co., Case No. 1:16-cv-23017 (S.D. Fla.)." ADAMS Accession No. ML18247A525. Hughes, J.D., Langevin, C.D., Brakefield-Goswami, L. 2010. "Effect of hypersaline cooling canals on aquifer salinization." *Hydrogeology Journal* 18:25–38.

[IEA] International Energy Agency. 2007. "Biomass for Power Generation and CHP." IEA Energy Technology Essentials ETE03. January 2007. 4 p. Available at <<https://www.iea.org/publications/freepublications/publication/essentials3.pdf>> (accessed August 14, 2018).

[IPCC] Intergovernmental Panel on Climate Change. 2000. *Special Report on Emissions Scenarios*. Nakicenovic N., Swart R. (eds.). Cambridge University Press, Cambridge, UK. 2000. 570 p. Available at <<https://www.ipcc.ch/report/emissions-scenarios/>> (accessed August 10, 2018).

[IPCC] Intergovernmental Panel on Climate Change. 2007. *Climate Change 2007: The Physical Science Basis. Contribution of Working Group I to the Fourth Assessment Report of the Intergovernmental Panel on Climate Change*. Solomon S., Qin D., et al (eds.). Cambridge University Press, Cambridge, UK. 2007. 996 p. Available at <<https://www.ipcc.ch/report/ar4/wg1/>> (accessed September 21, 2018).

[IPCC] Intergovernmental Panel on Climate Change. 2013. *Climate Change 2013: The Physical Science Basis. Contribution of Working Group I to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change*. Stocker T.F., Qin D., et al (eds.). Cambridge University Press, Cambridge, UK. 2013. 1535 p. Available at <<https://www.ipcc.ch/report/ar5/wg1/>> (accessed August 10, 2018).

Janus Research. 2009. "Cultural Resource Assessment Survey for the Turkey Point Units 6 & 7 Site, Associated Non-Linear Facilities, and Spoils Areas on Plant Property." 104 p. ADAMS Accession Nos. ML11109A019 and ML11109A017.

Jensen H.S., McGlathery K.J., Marino R., Howarth R.W. 1998. "Forms and availability of sediment phosphorus in carbonate sand of Bermuda seagrass beds." *Limnology and Oceanography* 43(5): 799-810.

Johnson W.E. 1974. "Morphological variation and local distribution of *Cyprinodon variegatus* in Florida." *Retrospective Theses and Dissertations*. University of Central Florida. 191 p. Available at <<https://stars.library.ucf.edu/rtd/109/>> (accessed December 15, 2018).

Kagan R.A., Viner T.C., Trail P.W., Espinoza E.O. 2014. Avian Mortality at Solar Energy Facilities in Southern California: A Preliminary Analysis. National Fish and Wildlife Forensics Laboratory. 28 p. Available at <<https://alternativeenergy.procon.org/sourcefiles/avian-mortality-solar-energy-ivanpah-apr-2014.pdf>> (accessed July 11, 2019).

Keenan J.M., Hill T., Gumber A. 2018. "Climate gentrification: from theory to empiricism in Miami-Dade County, Florida." *Environmental Research Letters* 13:5. Available at <<http://iopscience.iop.org/journal/1748-9326>> (accessed December 15, 2018).

Lapointe B.E., Matzie W.R. 1996. "Effects of stormwater nutrient discharges on eutrophication processes in nearshore waters of the Florida Keys." *Estuaries* 19(2): 422-435.

Lapointe B.E., O'Connell J.D., Garrett G.S. 1990. "Nutrient couplings between on-site sewage disposal systems, groundwaters, and nearshore surface waters of the Florida Keys." *Biogeochemistry* 10(3): 289-307.

Leavy T.R., Bonner T.H. 2009. "Relationships among swimming ability, current velocity association, and morphology of freshwater lotic fishes." *North American Journal of Fisheries Management* 29:72–83. DOI: 10.1577/M07-040.1.

[LBNL] Lawrence Berkeley National Laboratory. 2017. "U.S. Renewables Portfolio Standards 2017 Annual Status Report." July 2017. Available at <<http://eta-publications.lbl.gov/sites/default/files/2017-annual-rps-summary-report.pdf>> (accessed August 30, 2018).

Lirma D., Thyberg T., Santons R., Schopmeyer S., Drury C., Collado-Vides L., Bellmund S., Serafy J. 2014. "SAV communities of Western Biscayne Bay, Miami, Florida, USA: Human and natural drivers of seagrass and macroalgae abundance and distribution along a continuous shoreline." *Estuaries and Coasts*. 37:1243-1255.

Lugo A.E., Snedaker S. 1974. "The Ecology of Mangroves." *Annual Review of Ecology and Systematics*. 5:39-64.

Magnuson–Stevens Fishery Conservation and Management Act, as amended.
16 U.S.C. 1801 et seq.

[MASCWG] Multiagency Avian-Solar Collaborative Working Group. 2016. Multiagency Avian-Solar Science Coordination Plan. November 2016. 87 p. Available at <http://blmsolar.anl.gov/program/avian-solar/docs/Final_Avian-Solar_Science_Coordination_Plan.pdf> (accessed July 11, 2019).

Mayer F.L., Low J.B. 1970. "The effect of salinity on widgeongrass." *The Journal of Wildlife Management* 34(3):658–661. DOI: 10.2307/3798882.

Mayhew D.A., Jensen L.D., Hanson D.F., Muessig P.H. 2000. "A comparative review of entrainment survival studies at power plants in estuarine environments." *Environmental Science and Policy* 3:295–301. DOI: 10.1016/S1462-9011(00)00069-1.

McPherson B.F., Halley R. 1996. "The South Florida Environment—A Region Under Stress." U.S. Geological Survey Circular 1134. 67 p. ADAMS Accession No. ML12193A218.

McThenia A.W., Martin K.W., Reynolds J. 2017. "Rising tides and sinking brines: managing the threat of salt water intrusion." August 2017. *Florida Water Resources Journal*: 32-38. Available at <<https://fkaa.blob.core.windows.net/linkdocs/Managing%20the%20Threat%20of%20Salt%20Water%20Intrusion.pdf>> (accessed July 24, 2019).

[MDC] Miami-Dade County. 2006. "Miami-Dade County Wellfield Protection Areas." Map created September 23, 2006. Available at <<http://www.miamidade.gov/environment/wellfields.asp>> (accessed July 7, 2018).

[MDC] Miami-Dade County. 2012. Memorandum: Inspection of the Eastern Berm of the Cooling Canal System at the FPL Turkey Point Power Plant. August 11, 2012. Available at <[http://ecmrrer.miamidade.gov:8080/OpenContent/rest/content/content/MEMO.pdf?id=0902a134818d2f16&contentType\[\]=pdf,txt,.*/*true](http://ecmrrer.miamidade.gov:8080/OpenContent/rest/content/content/MEMO.pdf?id=0902a134818d2f16&contentType[]=pdf,txt,.*/*true)> (accessed July 7, 2018).

[MDC] Miami-Dade County. 2014. "20-year Water Supply Facilities Work Plan (2014–2033)." Available at <<http://www.miamidade.gov/water/library/20-year-water-supply-facilities-work-plan.pdf>> (accessed June 7, 2018).

[MDC] Miami-Dade County. 2015a. Consent Agreement Concerning Water Quality Impacts Associated with the Cooling Canal System at Turkey Point Power Plant. October 6, 2015. ADAMS Accession No. ML15286A366.

[MDC] Miami-Dade County. 2015b. "FY 2015–16 Business Plan, Adopted Budget, and Five-Year Financial Outlook." Available at <<http://www.miamidade.gov/budget/archives.asp>> (accessed May 9, 2018).

[MDC] Miami-Dade County. 2016a. Addendum 1 to the October 7, 2015 Consent Agreement between Miami-Dade County and Florida Power & Light Company. August 12, 2016. Available at <<http://ecmrrer.miamidade.gov:8080/hpi/search>> (search Case Number: HWR-00851, Date: 8/15/2016) (accessed July 3, 2018).

[MDC] Miami-Dade County. 2016b. FY 2016–17 Business Plan, Adopted Budget, and Five-Year Financial Outlook. Available at <<http://www.miamidade.gov/budget/current.asp>> (accessed May 9, 2018).

[MDC] Miami-Dade County. 2016c. 2016 Millage Tables. Available at <http://www.miamidade.gov/pa/millage_tables.asp> (accessed May 1, 2018).

[MDC] Miami-Dade County. 2016d. Memorandum from C.A. Gimenez to J. Monestime and Members of the Board of County Commissioners, dated March 7, 2016, regarding "Report on Recent Biscayne Bay Water Quality Observations Associated with Florida Power and Light Turkey Point Cooling Canal System Operations—Directive 152884." Miami, Florida. ADAMS Accession No. ML16167A518.

[MDC] Miami-Dade County. 2017a. "Comprehensive Development Master Plan Adopted Components." Available at <<http://www.miamidade.gov/planning/cdmp.asp>> (accessed July 2018).

[MDC] Miami-Dade County. 2017b. "Urban Expansion Area Task Force, Rockmining Considerations." November 17, 2017. 166 p. Available at <<https://www.miamidade.gov/planning/library/presentations/2017-11-17-ueatf-rockmining-considerations.pdf>> (accessed April 30, 2018).

[MDC] Miami-Dade County. 2017c. Memorandum from Jack Osterholt, Deputy Mayor/Director, Department of Environmental Resources Management, to Honorable Chairman Esteban L. Bovo, Jr. and Members, Board of County Commissioners, Subject: "Class IV Permit Application by Atlantic Civil. Inc to Impact 155.4 Acres of Wetlands for a Lake Excavation and to Restore and Enhance 343 Acres of Wetlands as Mitigation in Florida City, Florida." June 20, 2017. Available at <<http://www.miamidade.gov/govaction/legistarfiles/Matters/Y2017/171467.pdf>> (accessed April 30, 2018).

[MDC] Miami-Dade County. 2017d. Letter from C. Grossenbacher, Chief, Water Resources Coordination Division, to M. Raffenberg, Director, Environmental Licensing and Permitting, Florida Power & Light Company. Subject: "Site Assessment Report (SAR) dated March 17, 2017 and submitted pursuant to Paragraph 34.b. of Addendum 1 to the October 7, 2015 Consent Agreement for FPL's Turkey Point facility located at, near, or in the vicinity of 9700 SW 344 Street, Unincorporated Miami-Dade County, Florida (DERM IW-3, IW-16, IW5-6229, DWO-10, CLI-2014-0312, CLI-2016-0303, HWR-851)." July 7, 2017. Available at <<http://ecmrer.miamidade.gov:8080/hpi/search>> (search Case Number: HWR-00851, Date: 7/7/2017) (accessed July 5, 2018).

[MDC] Miami-Dade County. 2017e. Letter from W. Mayorga, Chief, Environmental Monitoring and Restoration Division, to M. Raffenberg, Director, Environmental Licensing and Permitting, Florida Power & Light Company. Subject: "Phase 1 Remedial Action Plan Submittal dated January 27, 2017 for the Florida Power and Light Facility and Cooling Canal System (DERM HWR-851, IW-3 & IW-16) located at, near or in the vicinity of 9760 SW 344th Street, Homestead, Miami-Dade County, Florida." May 15, 2017. Available at <<http://ecmrer.miamidade.gov:8080/hpi/search>> (search Case Number: HWR-00851, Date: 5/15/2017) (accessed July 7, 2018).

[MDC] Miami-Dade County. 2017f. 2017-2018 Business Plan, Adopted Budget, and Five-Year Financial Outlook. Available at <<http://www.miamidade.gov/budget/current.asp>> (accessed May 9, 2018).

[MDC] Miami-Dade County. 2018a. Letter from W. Mayorga, Chief, Environmental Monitoring and Restoration Division, to M. Raffenberg, Sr. Director, Environmental Licensing and Permitting, Florida Power & Light Company. Subject: "Site Assessment Report (SAR) dated March 17, 2017 and the SAR Supplemental Information dated November 11, 2017, submitted pursuant to Addendum 1 dated August 15, 2016 of the Consent Agreement between Florida Power & Light (FPL) and Miami-Dade County, Division of Environmental Resources Management for FPL's Turkey Point facility located at, near, or in the vicinity of 9700 SW 344 Street, Unincorporated Miami-Dade County, Florida (DERM IW-3, IW-16, IW5-6229, DWO-10, CLI-2014-0312, CLI-2016-0303, HWR-851)." July 10, 2018. Available at <<http://ecmrer.miamidade.gov:8080/hpi/search>> (search Case Number: CLI-2016-0428, Date: 7/10/2018) (accessed August 27, 2018).

[MDC] Miami-Dade County. 2018b. "Water Supply and Treatment." Page updated February 7, 2018. Available at <<http://www.miamidade.gov/water/water-supply-treatment.asp#0>> (accessed July 7, 2018).

[MDC] Miami-Dade County. 2018c. Environmental Considerations GIS Tool. Page updated 2018. Available at <<https://gisweb.miamidade.gov/EnvironmentalConsiderations/>> (toggle Wellfield Protection Areas layer in bottom panel on page) (accessed July 7, 2018).

[MDC] Miami-Dade County. 2018d. Letter from S. Cody, Historic Preservation Chief, Miami-Dade County, to N. Martinez, Division of Materials and License Renewal, U.S. Nuclear Regulatory Commission. Subject: “McGregor Smith Ranger House, Evaluation of Historic Significance.” ADAMS Accession No. ML18247A502.

[MDC] Miami-Dade County. 2019a. “Saltwater Intrusion.” Available at <<https://www8.miamidade.gov/global/water/conservation/saltwater-intrusion.page>> (accessed July 24, 2019).

[MDC] Miami-Dade County. 2019b. Report on the Findings of the County’s Study on the Decline of Seagrass and Hardbottom Habitat in Biscayne Bay – directive No. 171537. January 28, 2019. Available at <<http://www.miamidade.gov/govaction/legistarfiles/Matters/Y2019/190191.pdf>> (accessed July 23, 2019).

[MDC] Miami-Dade County. MDC 2019c. Code of Miami-Dade County Florida. Version May 16, 2019. Available at <https://library.municode.com/fl/miami-dade-county/codes/code_of_ordinances?nodeId=COMIDECOFL> (accessed July 26, 2019).

[MDCPS] Miami-Dade County Public Schools. 2017a. Statistical Highlights 2016–2017. April 2017. 6 p. Available at <<http://drs.dadeschools.net/StatisticalHighlights/SH1617.pdf>> (accessed May 7, 2018).

[MDCPS] Miami-Dade County Public Schools. 2017b. “Comprehensive Annual Financial Report for the Fiscal Year Ended June 30, 2017.” December 6, 2017. 201 p. Available at <http://financialaffairs.dadeschools.net/pdfs17/CAFR_17.pdf> (accessed May 1, 2018).

[MDCPS] Miami-Dade County Public Schools. 2018a. Statistical Highlights, 2017–2018. April 2018. 6 p. Available at <<http://drs.dadeschools.net/StatisticalHighlights/SH1718.pdf>> (accessed May 7, 2018).

Meffe G.K., Weeks S.C., Mulvey M., Kandl K.L. 1995. “Genetic differences in thermal tolerance of eastern mosquitofish (*Gambusia holbrooki*; Poeciliidae) from ambient and thermal ponds.” *Canadian Journal of Fishes and Aquatic Sciences* 52(12):2704–2711. DOI: 10.1139/f95-259.

Michaels T. 2010. “The 2010 ERC Directory of Waste-to-Energy Plants.” Washington, DC: Energy Recovery Council. November 2010. 32 p. Available at <http://www.seas.columbia.edu/earth/wtert/sofos/ERC_2010_Directory.pdf> (accessed September 11, 2018).

Michaels T. 2016. “Energy Recovery Council 2016 Directory of Waste-to-Energy Facilities.” Washington, DC: Energy Recovery Council. May 2016. 72 p. Available at <<http://energyrecoverycouncil.org/wp-content/uploads/2016/06/ERC-2016-directory.pdf>> (accessed September 11, 2018).

Migratory Bird Treaty Act of 1918, as amended. 16 U.S.C. 703 et seq.

Millette NC, C Kelbe, A Linhoss, S Ashby & L Visser. 2018. “Shift in baseline chlorophyll a following a three-year Synechococcus bloom in southeastern Florida.” *Bulletin of Marine Science* 94(1):3–19. 2018. Available at <<https://www.ingentaconnect.com/contentone/umrsmas/bullmar/2018/00000094/00000001/art00002?crawler=true&mimetype=application/pdf>> (accessed July 23, 2019).

[Morgan & Eklund] Morgan & Eklund, Inc. 2010. "Topographic and Bathymetric Survey, Turkey Point Cooling Canals, Miami-Dade County Florida, for Florida Power and Light June 2, 2010." Available at <<http://css-3-4-plan.com/>> (accessed July 18, 2018).

[NASA] National Aeronautics and Space Administration. 2018. "Long-Term Warming Trend Continued in 2017: NASA, NOAA." Release 18-003. January 18, 2018. Available at <<https://www.nasa.gov/press-release/long-term-warming-trend-continued-in-2017-nasa-noaa>> (accessed August 10, 2018).

[NASA] National Aeronautics and Space Administration. 2019. "2018 Fourth Warmest Year in Continued Warming Trend, According to NASA, NOAA." Release 19-002. February 6, 2019. Available at <<https://climate.nasa.gov/news/2841/2018-fourth-warmest-year-in-continued-warming-trend-according-to-nasa-noaa/>> (accessed April 29, 2019).

National Environmental Policy Act of 1969, as amended. 42 U.S.C. 4321 et seq.

[NCDC] National Climatic Data Center. 2017. "Local Climatological Data Annual Summary With Comparative Data, Miami, Florida (KMIA)." Available at <<https://www1.ncdc.noaa.gov/pub/orders/IPS/IPS-C03642BD-0801-4354-B0A8-62B1C266FEC2.pdf>> (accessed 16 September 2018).

[NCDC] National Climatic Data Center. 2018. "Storm Events Database" Database search: Florida, Miami-Dade County, 01/1950–12/2016. Available at <<https://www.ncdc.noaa.gov/stormevents/choosedates.jsp?statefips=12%2CFLORIDA>> (accessed 13 September 2018).

[NEI] Nuclear Energy Institute. 2005. "Severe Accident Mitigation Alternatives (SAMA) Analysis Guidance Document." NEI 05-01 [Rev A]. Washington, DC: NEI. November 2005. 79 p. ADAMS Accession No. ML060530203.

[NEI] Nuclear Energy Institute. 2007. "Industry Ground Water Protection Initiative—Final Guidance Document." NEI 07-07 [Final]. Washington, DC: NEI. August 2007. 27 p. ADAMS Accession No. ML072610036.

[NEI] Nuclear Energy Institute. 2017. "Model SLR New and Significant Assessment Approach for SAMA." NEI 17-04 [Rev 0]. Washington, DC: NEI. June 2017. 24 p. ADAMS Accession No. ML17181A470.

[NETL] National Energy Technology Laboratory. 2007. "Natural Gas Combined Cycle Plant." 4 p. Available at <https://wecanfigurethisout.org/ENERGY/Web_notes/Bigger%20Picture/Where%20do%20we%20go%20-%20Supporting%20-%20Files/Natural%20Gass%20Combined%20Cycle%20Plant%20-%20DOE.pdf> (accessed June 4, 2018).

[NETL 2012] National Energy Technology Laboratory. 2012. "Life Cycle Analysis: Natural Gas Combined Cycle (NGCC) Power Plant." DOE/NETL-403-110509. September 10, 2012. 148 pp. Available at <<https://www.netl.doe.gov/energy-analysis/search>> (accessed April 29, 2019).

[NETL] National Energy Technology Laboratory. 2013. "Cost and Performance Baseline for Fossil Energy Plants, Volume 1: Bituminous Coal and Natural Gas to Electricity." Revision 2a. DOE/NETL-2010/1397. September 2013. 626 p. Available at <<http://folk.ntnu.no/andersty/4.%20Klasse/TKP4170%20-%20Prosjektering%20Prosessanlegg/Report/Sources/Sigurd600pages.pdf>> (accessed September 13, 2018).

[NIEHS] National Institute of Environmental Health Sciences. 1999. NIEHS Report on Health Effects from Exposure to Power-Line Frequency Electric and Magnetic Fields.” Publication No. 99-4493. Research Triangle Park, NC: NIEHS. May 4, 1999. 80 p. Available at <https://www.niehs.nih.gov/health/assets/docs_p_z/report_powerline_electric_mg_predates_508.pdf> (accessed December 17, 2018).

National Historic Preservation Act of 1966, as amended. 54 U.S.C. 300101 et seq.

[NMFS] National Marine Fisheries Service. 2010. Letter from M. Croom, NMFS, to L. Bauer, NRC, regarding response to request for information regarding proposed construction and operation of Turkey Point Units 6 and 7. August 5, 2010. ADAMS Accession No. ML102250231.

[NMFS] National Marine Fisheries Service. 2016. Endangered Species Act Section 7 Biological Opinion for Approval of Florida Numeric Nutrient Criteria for Total Phosphorus, Total Nitrogen, and Chlorophyll-a, Dissolved Oxygen Criteria, and Turbidity Limits under section 303(c) of the Clean Water Act. PCTS No. FPR-2015-9234. August 2, 2016. 269 p. Available at <http://news.caloosahatchee.org/docs/BO_FL_NNC_DO_Turbidity_FPR-2015-9134.pdf> (accessed September 5, 2018).

[NMFS] National Marine Fisheries Service. 2017. Letter from R. Crabtree, NMFS, to J. Dixon-Herrity, NRC, and A. Dodd, Department of the Army, regarding concurrence with the NRC’s determination that the proposed construction and operation of two new units at the Turkey Point site is not likely to adversely affect federally listed species under the NMFS’s jurisdiction. April 26, 2017. ADAMS Accession No. ML17143A153.

[NMFS] National Marine Fisheries Service. 2019. Email from NMFS to NRC, requests for additional information related to Turkey Point Endangered Species Act Section 7 Consultation. May 3, 2019. ADAMS Accession No. ML19126A028.

National Marine Sanctuaries Act, as amended. 16 U.S.C. 1431 et seq.

[NOAA] National Oceanic Atmospheric Administration. 2007. “Florida Keys National Marine Sanctuary Revised Management Plan.” December 2007. 382 p. Available at <https://nmsfloridakeys.blob.core.windows.net/floridakeys-prod/media/archive/mgmtplans/2007_man_plan.pdf> (accessed August 9, 2019).

[NOAA] National Oceanic and Atmospheric Administration. 2013a. “Regional Climate Trends and Scenarios for the U.S. National Climate Assessment, Part 2. Climate of the Southeast U.S.” NOAA Technical Report NESDIS 142-2. Washington, DC: NOAA. January 2013. 103 p. Available at <<https://www.nesdis.noaa.gov/content/technical-reports>> (accessed September 16, 2018).

[NOAA] National Oceanic and Atmospheric Administration. 2013b. “Regional Climate Trends and Scenarios for the U.S. National Climate Assessment, Part 9. Climate of the Contiguous United States.” NOAA Technical Report NESDIS 142-9. Washington, DC: NOAA. January 2013. 85 p. Available at <<https://www.nesdis.noaa.gov/content/technical-reports>> (accessed August 10, 2018).

[NOAA] National Oceanic and Atmospheric Administration. 2018a. Soundings Map, Sands Key to Blackwater Sound. May 18, 2018. Available at <<http://www.charts.noaa.gov/InteractiveCatalog/nrnc.shtml>> (accessed May 24, 2018).

[NOAA] National Oceanic and Atmospheric Administration. 2018b. “NOAA National Centers for Environmental Information, Climate at a Glance: Divisional Time Series.” Parameters: average annual temperature and precipitation. Available at <<https://www.ncdc.noaa.gov/cag/divisional/time-series>> (accessed August 24, 2018).

[NOAA] National Oceanic and Atmospheric Administration. 2018c. "Sea Level Trends." Page updated August 8, 2018. Available at <<https://tidesandcurrents.noaa.gov/sltrends/>> (accessed August 24, 2018).

[NOAA] National Oceanic and Atmospheric Administration. 2019. "Florida Keys National Marine Sanctuary." Available at <https://nmsfloridakeys.blob.core.windows.net/floridakeys-prod/media/archive/fknms_map/sanctuaryzoneboundaries.pdf> (accessed August 9, 2019).

Nordlie F.G., Haney D.C., Walsh S.J. 1992. Comparisons of salinity tolerances and osmotic regulatory capabilities in populations of sailfin molly (*Poecilia latipinna*) from brackish and fresh waters. *Copeia* 1992(3):741–746. DOI: 10.2307/1446150.

[NPS] National Park Service. 2011. "Ecological Impacts on Biscayne Bay and Biscayne National Park from Proposed South Miami-Dade County Development, and Derivation of Numeric Nutrient Criteria for South Florida Estuaries and Coastal Waters, Final Report." Southeast Environmental Research Center of Florida International University. December 2011. 127 p. Available at <<http://serc.fiu.edu/wqmnetwork/BNP/Final%20Report%20BNP.pdf>> (accessed July 2, 2018).

[NPS] National Park Service. 2012. "Assessment of Natural Resource Conditions In and Adjacent to Biscayne National Park." Natural Resource Report NPS/BISC/NRR—2012/598. December 2012. 294 p. Available at <<http://npshistory.com/publications/bisc/nrr-2012-598.pdf>> (accessed May 24, 2018).

[NPS] National Park Service. 2015a. "Final General Management Plan / Environmental Impact Statement, Biscayne National Park, Miami-Dade County, FL." April 2015. 777 p. Available at <<https://parkplanning.nps.gov/document.cfm?parkID=353&projectID=11168&documentID=65801>> (accessed June 12, 2018).

[NPS] National Park Service. 2015b. "Acquisition of Florida Power & Light Company Land in the East Everglades Expansion Area, Final Environmental Impact Statement." November 2015. 502 p. ADAMS Accession No. ML16167A520.

[NPS] National Park Service. 2017a. "National Park Service Visitor Use Statistics." Available at: <<https://irma.nps.gov/Stats/>> (accessed June 7, 2018).

[NPS] National Park Service. 2017b. "Biscayne National Park, Florida: Bird List." Available at: <<https://www.nps.gov/bisc/learn/nature/bird-list.htm>> (accessed July 11, 2019).

[NPS] National Park Service. 2018a. Letter from S. Craighead, Acting Regional Director, NPS, to G. Wilson, Director of the Division of Materials and License Renewal, NRC, regarding Environmental Impact Statement scoping comments regarding Florida Power & Light's subsequent license renewal application for Turkey Point Units 3 and 4. June 22, 2018. ADAMS Accession No. ML18193B074.

[NPS] National Park Service. 2018b. "2017 National Park Visitor Spending Effects." Natural Resource Report NPS/NRSS/EQD/NRR—2018/1616. April 2018. 56 p. Available at <https://www.nps.gov/nature/customcf/NPS_Data_Visualization/docs/NPS_2017_Visitor_Spending_Effects.pdf> (accessed September 7, 2018).

[NPS] National Park Service. 2019a. Letter from R. Vogel, Regional Director, NPS, to B. Beasley, Chief, Environmental Review and NEPA Branch, NRC, providing comments on portions of the preliminary draft Supplemental Environmental Impact Statement regarding Florida Power & Light's subsequent license renewal application for Turkey Point Units 3 and 4. March 5, 2019. ADAMS Accession No. ML19072A162.

[NPS] National Park Service. 2019b. Letter from Vogel, Regional Director, NPS, to W. Burton, NRC, providing comments on the draft Supplemental Environmental Impact Statement for Turkey Point Units 3 and 4 subsequent license renewal. May 16, 2019. ADAMS Accession No. ML19143A166.

[NRC] U.S. Nuclear Regulatory Commission. 1972. "Final Environmental Statement related to operation of Turkey Point Plant, Florida Power and Light Company." July 1972. ADAMS Accession No. ML092030310.

[NRC] U.S. Nuclear Regulatory Commission. 1990. "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants." NUREG-1150, Volumes 1 and 2. December 31, 1990. ADAMS Accession No. ML040140729.

[NRC] U.S. Nuclear Regulatory Commission. 1995a. "Evaluation of Potential Severe Accidents During Low Power and Shutdown Operation at Grand Gulf, Unit 1." NUREG/CR-6143. July 1995.

[NRC] U.S. Nuclear Regulatory Commission. 1995b. "Evaluation of Potential Severe Accidents During Low Power and Shutdown Operations at Surry, Unit 1." NUREG/CR-6144. October 1995.

[NRC] U.S. Nuclear Regulatory Commission. 1996. "Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Final Report." NUREG-1437, Volumes 1 and 2. May 1996. ADAMS Accession Nos. ML040690705 and ML040690738.

[NRC] U.S. Nuclear Regulatory Commission. 1997. "Issuance for Public Comment of Proposed Rulemaking for Shutdown and Fuel Storage Pool Operation." SECY-97-168. Washington, D.C.: NRC. 125 p. July 30, 1997. Available at <<https://www.nrc.gov/reading-rm/doc-collections/commission/secys/1997/secy1997-168/1997-168scy.pdf>> (accessed December 28, 2018).

[NRC] U.S. Nuclear Regulatory Commission. 1999. "Generic Environmental Impact Statement License Renewal of Nuclear Plants, Main Report, Section 6.3—Transportation, Table 9.1, Summary of findings on NEPA issues for license renewal of nuclear power plants." NUREG-1437, Volume 1, Addendum 1. August 1999. 100 p. ADAMS Accession No. ML040690720.

[NRC] U.S. Nuclear Regulatory Commission. 2001. "Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants." NUREG-1738. Washington, D.C.: NRC. February 2001. ADAMS Accession No. ML010430066.

[NRC] U.S. Nuclear Regulatory Commission. 2002a. "Final Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of Nuclear Power Reactors." NUREG-0586, Volumes 1 and 2. November 30, 2002. 516 p. ADAMS Accession Nos. ML023470327, ML023500228, and ML023500295.

[NRC] U.S. Nuclear Regulatory Commission. 2002b. Letter from R. Auluck, NRC, to J. Stall, FPL. Subject: "Issuance of renewed facility operating Licenses Nos. DPR-31 and DPR-41 for Turkey Point Nuclear Generating Units Nos. 3 and 4." June 6, 2002. ADAMS Accession No. ML021550105.

[NRC] U.S. Nuclear Regulatory Commission. 2002c. "Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding Turkey Point Plant Units 3 and 4, Final Report." NUREG-1437, Supplement 5. January 2002. 669 p. ADAMS Accession Nos. ML020280119, ML020280202, and ML020280226.

[NRC] U.S. Nuclear Regulatory Commission. 2002d. Florida Power and Light Company, Docket No. 50-250, Turkey Point Nuclear Generating Unit No. 3, Renewed Facility Operating License No. DPR-31. Revised June 14, 2018. ADAMS Accession No. ML052790649.

[NRC] U.S. Nuclear Regulatory Commission. 2004. "Protecting Our Nation—Since 9-11-01." NUREG/BR-0314. Washington, DC: NRC. September 2004. ADAMS Accession No. ML042650352.

[NRC] U.S. Nuclear Regulatory Commission. 2005a. "Frequently Asked Questions on License Renewal of Nuclear Power Reactors." NUREG-1850. March 31, 2006. ADAMS Accession No. ML061110022.

[NRC] U.S. Nuclear Regulatory Commission. 2005b. "Staff Review of the National Academies Study of the Health Risks from Exposure to Low Levels of Ionizing Radiation (BEIR VII)." SECY-05-0202. Washington D.C.: NRC. October 29, 2005. ADAMS Accession No. ML052640532.

[NRC] U.S. Nuclear Regulatory Commission. 2006a. "Backgrounder: Tritium, Radiation Protection Limits, and Drinking Water Standards." February 2016. 7 p. ADAMS Accession No. ML062020079.

[NRC] U.S. Nuclear Regulatory Commission. 2006b. Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Regarding Oyster Creek Nuclear Generating Station-Final Report." NUREG-1437, Supplement 28. 360 p. ADAMS Accession No. ML070100234.

[NRC] U.S. Nuclear Regulatory Commission. 2012. Letter from J. Paige, NRC, to M. Nazar, FPL. Subject: "Turkey Point Units 3 and 4 – Issuance of Amendments Regarding Extended Power Uprate (TAC Nos. ME4907 and ME4908). June 15, 2012. ADAMS Accession No. ML11293A365.

[NRC] U.S. Nuclear Regulatory Commission. 2013a. "Generic Environmental Impact Statement for License Renewal of Nuclear Plants." Revision 1. NUREG-1437, Volumes 1, 2, and 3. June 2013. 1,535 p. ADAMS Accession Nos. ML13106A241, ML13106A242, and ML13106A244.

[NRC] U.S. Nuclear Regulatory Commission. 2013b. "Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal." Revision 1. NUREG-1555. June 2013. 325 p. ADAMS Accession No. ML13106A246.

[NRC] U.S. Nuclear Regulatory Commission. 2013c. "LIC-203, Revision 3, Procedural Guidance for Preparing Categorical Exclusions, Environmental Assessments, and Considering Environmental Issues." June 24, 2013. 72 p. ADAMS Accession No. ML12234A708.

[NRC] U.S. Nuclear Regulatory Commission. 2013d. Memorandum and Order in the Matter of Exelon Generation Company, LLC (Limerick Generating Station, Units 1 and 2). CLI-13-07. October 31, 2013. ADAMS Accession No. ML13304B417.

[NRC] U.S. Nuclear Regulatory Commission. 2013e. "Order Modifying Licenses with Regard to Reliable Hardened Containment Vents Capable of Operation Under Severe Accident Conditions." NRC Order Number EA-13-109. June 6, 2013. ADAMS Accession No. ML13130A067.

[NRC] U.S. Nuclear Regulatory Commission. 2013f. Memorandum of Understanding Between NRC and OSHA for NRC-Regulated Facilities. Final Report. October 2013. ADAMS Accession No. ML11354A432.

[NRC] U.S. Nuclear Regulatory Commission. 2013g. "Preparation of Environmental Reports for Nuclear Power Plant License Renewal Applications." Regulatory Guide 4.2, Supplement 1, Revision 1. June 2013. 48 p. ADAMS Accession No. ML13067A354.

[NRC] U.S. Nuclear Regulatory Commission. 2014a. "Probabilistic Seismic Hazard Analysis: Background Information." May 20, 2014. 6 p. ADAMS Accession No. ML14140A648.

[NRC] U.S. Nuclear Regulatory Commission. 2014b. Letter from A. Klett, NRC, to M. Nazar, NextEra Energy, Subject: "Turkey Point Nuclear Generating Unit Nos. 3 and 4 - Issuance of Amendments under Exigent Circumstances Regarding Ultimate Heat Sink and Component Cooling Water Technical Specifications (TAC Nos. MF4392 and MF4393)." April 8, 2014. ADAMS Accession No. ML14199A107.

[NRC] U.S. Nuclear Regulatory Commission. 2014c. "Generic Environmental Impact Statement for Continued Storage of Spent Nuclear Fuel." NUREG-2157, Volumes 1 and 2. September 2014. 1404 p. ADAMS Accession No. ML14198A440.

[NRC] U.S. Nuclear Regulatory Commission. 2014d. "Turkey Point Nuclear Generating Unit Nos 3 And 4- Issuance Of Amendments Under Exigent Circumstances Regarding Ultimate Heat Sink And Component Cooling Water Technical Specifications (TAC NOS. MF4392 and MF4393))." August 8, 2014. ADAMS Accession No. ML14199A107.

[NRC] U.S. Nuclear Regulatory Commission. 2015a. "Biological Assessment for the U.S. Fish and Wildlife Service, Prepared by the U.S. Nuclear Regulatory Commission and the U.S. Army Corps of Engineers for Florida Power and Light Company, Turkey Point Units 6 and 7 Nuclear Project, Combined License Application, Docket Nos. 052-040 and 052-041 and Permit Application No. SAJ-2009-02417." February 2015. 97 p. ADAMS Accession No. ML15028A372.

[NRC] U.S. Nuclear Regulatory Commission. 2015b. "Biological Assessment for the National Marine Fisheries Service, Turkey Point Nuclear Plant, Units 6 and 7 Combined License Application. February 2015. 85 p. ADAMS Accession No. ML15028A378.

[NRC] U.S. Nuclear Regulatory Commission. 2015c. "Essential Fish Habitat Assessment for the National Marine Fisheries Service, Turkey Point Nuclear Plant Units 6 and 7 Combined License Application." February 2015. 55 p. ADAMS Accession No. ML15028A395.

[NRC] U.S. Nuclear Regulatory Commission. 2015d. Letter from A. Klett, NRC, to M Nazar, NextEra Energy. Subject: "Turkey Point Nuclear Generating Unit Nos. 3 and 4 – Issuance of Amendments Regarding Transition to a Risk-Informed, Performance-Based Fire Protection Program in Accordance with Title 10 of the *Code of Federal Regulations* Section 50.48(c)." May 28, 2015. ADAMS Accession No. ML15061A237.

[NRC] U.S. Nuclear Regulatory Commission. 2016a. "Environmental Impact Statement for Combined Licenses (COLs) for Turkey Point Nuclear Plant Units 6 and 7, Final Report." October 2016. 2,092 p. ADAMS Accession No. ML16335A219.

[NRC] U.S. Nuclear Regulatory Commission. 2016b. "Staff Assessment by the Office of Nuclear Reactor Regulation Related to Seismic Hazard and Screening Report, Turkey Point Nuclear Generating, Unit Nos. 3 and 4." January 22, 2016. ADAMS Accession No. ML16013A472.

[NRC] U.S. Nuclear Regulatory Commission. 2016c. Letter from F. Vega, NRC, to M. Nazar, NextEra. Subject: "Turkey Point Nuclear Generating, Unit Nos. 3 and 4 – Staff Review of Mitigation Strategies Assessment Report of the Impact of the Reevaluated Seismic Hazard Developed in Response to the March 12, 2012, 50.54(f) Letter." June 16, 2016. ADAMS Accession No. ML16166A321.

[NRC] U.S. Nuclear Regulatory Commission. 2016d. Letter from M. Halter, NRC, to M. Nazar, NextEra. Subject: "Turkey Point Nuclear Generating, Units 3 and 4 – Safety Evaluation Regarding Implementation of Mitigating Strategies and Reliable Spent Fuel Pool Instrumentation Related to Orders EA-12-049 and EA-12-051." October 28, 2016. ADAMS Accession No. ML16279A455.

[NRC] U.S. Nuclear Regulatory Commission. 2016e. "Criteria and Design Features for Inspection of Water-Control Structures Associated with Nuclear Power Plants." Regulatory Guide 1.127, Revision 2. February 2016. ADAMS Accession No. ML15107A412.

[NRC] U.S. Nuclear Regulatory Commission. 2017a. "Design Certification Application–NuScale." Page updated October 24, 2017. Available at <<https://www.nrc.gov/reactors/new-reactors/design-cert/nuscale.html>> (accessed September 13, 2018).

[NRC] U.S. Nuclear Regulatory Commission. 2017b. Turkey Point Unit 3 and Unit 4, Docket Nos. 50-250 and 50-251, Flooding Focused Evaluation Summary. June 29, 2017. ADAMS Accession Number ML17212B180.

[NRC] U.S. Nuclear Regulatory Commission. 2017c. "Generic Aging Lessons Learned for Subsequent License Renewal (GALL-SLR) Report." NUREG–2191, Volumes 1 and 2. July 2017. ADAMS Accession Nos. ML17187A031 and ML17187A204.

[NRC] U.S. Nuclear Regulatory Commission. 2018a. Letter from G. Wilson, NRC, to M. Nazar, FPL. Subject: "Turkey Point Nuclear Generating Units Nos. 3 and 4 - Determination of Acceptability and Sufficiency for Docketing, Proposed Review Schedule, and Opportunity for a Hearing Regarding the Florida Power & Light Company's Application for Subsequent License Renewal." April 26, 2018. ADAMS Accession No. ML18003A050.

[NRC] U.S. Nuclear Regulatory Commission. 2018b. Not used.

[NRC] U.S. Nuclear Regulatory Commission. 2018c. Letter from L. James, NRC, to M. Nazar, FPL. Subject: "Summary of the Environmental Site Audit Related to the Review of the Subsequent License Renewal Application for Turkey Point Nuclear Generating Units Nos. 3 and 4." July 20, 2018. ADAMS Accession No. ML18178A229.

[NRC] U.S. Nuclear Regulatory Commission. 2018d. Letter from L. James, NRC, to M. Nazar, FPL. Subject: "Turkey Point Nuclear Generating Units 3 and 4 – Summary of the In-Office Regulatory Audit Regarding Severe Accident Mitigation Alternatives in the Subsequent License Renewal Application." August 31, 2018. ADAMS Accession No. ML18214A146.

[NRC] U.S. Nuclear Regulatory Commission. 2018e. "Issued Combined Licenses for Turkey Point, Units 6 and 7 Application." Page updated April 26, 2018. Available at <<https://www.nrc.gov/reactors/new-reactors/col/turkey-point.html>> (accessed September 6, 2018).

[NRC] U.S. Nuclear Regulatory Commission. 2018f. "Docket Nos. 52-040 and 52-041, Combined License Application for Turkey Point Units 6 and 7, Summary Record of Decision." April 12, 2018. 13 p. ADAMS Accession No. ML17333A164.

[NRC] U.S. Nuclear Regulatory Commission. 2018g. Teleconference Summary between M. Moser, Biologist, NRC and L. Nester, Biologist, FWS. Call held on September 6, 2018. ADAMS Accession No. ML18270A154.

[NRC] U.S. Nuclear Regulatory Commission. 2018h. Citation not used.

[NRC] U.S. Nuclear Regulatory Commission. 2018i. "Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 58, Regarding River Bend Station, Unit 1, Draft Report for Comment." NUREG-1437, Supplement 58. May 2018. 401 p. ADAMS Accession No. ML18143B736.

[NRC] U.S. Nuclear Regulatory Commission. 2018j. Letters from B. Beasley, NRC, to B. Cypress, Miccosukee Tribe of Indians of Florida; J. Floyd, Muscogee (Creek) Nation; A.S. Bryan, Poarch Band of Creek Indians; G. Chilcoat, Seminole Nation of Oklahoma; M.W. Osceola, Seminole Nation Tribe of Florida; S. Cody, Office of Historic Preservation; R. Nelson, Office of Federal Agency Programs; and T. Parsons, Florida Department of State. Subject: "Request for Scoping Comments Concerning the Environmental Review of Turkey Point Nuclear Plant, Units 3 and 4 Subsequent License Renewal Application." May 24, 2018. ADAMS Accession Nos. ML18114A381, ML18114A204, ML18114A202, and ML18114A206.

[NRC] U.S. Nuclear Regulatory Commission. 2018k. Memorandum from N. Martinez, NRC, to B. Beasley, NRC. Subject: "Summary of July 2, 2018, Teleconference Between the U.S. Nuclear Regulatory Commission and the Seminole Nation of Oklahoma Regarding the Turkey Point Nuclear Generating Units 3 and 4 Subsequent License Renewal Application." July 19, 2018. ADAMS Accession No. ML18190A179.

[NRC] U.S. Nuclear Regulatory Commission. 2018l. Memorandum from M. Moser, NRC, to B. Beasley, NRC. Subject: "Summary of June 18, 2018, Interagency Meeting Related to Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4." December 26, 2018. ADAMS Accession No. ML18360A445.

[NRC] U.S. Nuclear Regulatory Commission. 2018m. Letter from G. Wilson, NRC, to J. Hanson and N. Ranek, NEI. Subject: "Interim Endorsement of NEI 17-01, Industry Guideline for Implementing the Requirements of 10 CFR Part 54 for Subsequent License Renewal and NEI 17-04, Model SLR New and Significant Assessment Approach for SAMA." January 31, 2018. ADAMS Accession No. ML18029A368.

[NRC] U.S. Nuclear Regulatory Commission. 2018n. Biological Assessment for the Turkey Point Nuclear Generating Unit Nos. 3 and 4 Proposed Subsequent License Renewal. December 2018. ADAMS Accession No. ML18344A008.

[NRC] U.S. Nuclear Regulatory Commission. 2018o. Letter from NRC to FWS, Request for Formal Consultation under the Endangered Species Act Regarding the Proposed Subsequent License Renewal of Turkey Point Nuclear Generating Unit Nos. 3 and 4. December 19, 2018. ADAMS Accession No. ML18333A205.

[NRC] U.S. Nuclear Regulatory Commission. 2019a. "Supplemental Environmental Impact Statement Scoping Process, Summary Report, Turkey Point Nuclear Generating Unit Nos. 3 and 4, Miami-Dade County, Florida." January 2019. ADAMS Accession No. ML18342A014.

[NRC] U.S. Nuclear Regulatory Commission. 2019b. "Occupational Radiation Exposure at Commercial Nuclear Power Reactors and other Facilities 2017: Fiftieth Annual Report." NUREG-0713, Volume 39. March 2019. 241 p. ADAMS Accession No. ML19091A130.

[NRC] U.S. Nuclear Regulatory Commission. 2019c. Email from NRC to NMFS, Summary of Conference Call and Updated Effect Determinations for Certain Federally Listed Species. February 26, 2019. ADAMS Accession No. ML19085A045.

[NRC] U.S. Nuclear Regulatory Commission. 2019d. Email from NRC to NMFS, Request for Concurrence with NRC's NLAA Determination for Turkey Point Nuclear Generating, Units 3 and 4, License Renewal. April 1, 2019. ADAMS Accession No. ML19091A128.

[NRC] U.S. Nuclear Regulatory Commission. 2019e. Email from NRC to NMFS, NRC Issuance of Draft Environmental Impact Statement for Turkey Point 3 and 4 and Opportunity for Public Comment. April 1, 2019. ADAMS Accession No. ML19091A131.

[NRC] U.S. Nuclear Regulatory Commission. 2019f. Summary of April 30, 2019, Meeting with the National Marine Fisheries Service Regarding Endangered Species Act Section 7 Consultation for the Proposed License Renewal of Turkey Point Nuclear Generating Unit Nos. 3 and 4. May 7, 2019. ADAMS Accession No. ML19127A136.

[NRC] U.S. Nuclear Regulatory Commission. 2019g. Email from NRC to NMFS, NRC responses to NMFS requests for additional information for Turkey Point Endangered Species Act Section 7 Consultation. June 7, 2019. ADAMS Accession No. ML19158A503.

[NRC] U.S. Nuclear Regulatory Commission. 2019h. Background: Tritium, Radiation Protection Limits, and Drinking Water Standards. April 2019. 7 p. ADAMS Accession No. ML062020079.

[NRC] U.S. Nuclear Regulatory Commission. 2019i. Summary of April 4, 2019, Teleconference with the U.S. Fish and Wildlife Service Regarding Endangered Species Act Section 7 Consultation for Turkey Point Nuclear Generating, Units 3 and 4, Subsequent License Renewal. May 14, 2019. ADAMS Accession No. ML19134A096.

[NRC] U.S. Nuclear Regulatory Commission. 2019j. Email from NRC to FWS, Turkey Point Crocodile Injuries and Mortalities 2005-Present. May 14, 2019. ADAMS Accession No. ML19134A081.

[NRC] U.S. Nuclear Regulatory Commission. 2019k. Summary of May 24, 2019, Teleconference with the U.S. Fish and Wildlife Service Regarding Endangered Species Act Section 7 Consultation for Turkey Point Nuclear Generating, Units 3 and 4, Subsequent License Renewal. June 7, 2019. ADAMS Accession No. ML19158A023.

[NRC] U.S. Nuclear Regulatory Commission. 2019l. "Safety Evaluation Report with Open Items." May 2019. ADAMS Accession No. ML19078A012).

[NRC] U.S. Nuclear Regulatory Commission. 2019m. "Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 5, Second Renewal, Regarding Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4 Draft Report for Comment." NUREG-1437, Supplement 5, Second Renewal. March 2019. ADAMS Accession No. ML19078A330.

[NREL] National Renewable Energy Laboratory. 2013. "Land-Use Requirements for Solar Power Plants in the United States." Golden, Colorado: National Renewable Energy Laboratory. NREL/TP-6A20-56290. June 2013. 47 p. Available at <<http://www.nrel.gov/docs/fy13osti/56290.pdf>> (accessed August 30, 2018).

[NREL] National Renewable Energy Laboratory. 2014. "Concentrating Solar Power Projects in the United States." Available at <<https://solarpaces.nrel.gov/by-country/US>> (accessed June 4, 2018).

[NREL] National Renewable Energy Laboratory. 2017. "Global Horizontal Solar Resource of Florida." April 4, 2017. Available at <<http://www.nrel.gov/gis/solar.html>> (accessed September 12, 2018).

[NuScale] NuScale Power, LLC. 2018. "NuScale FAQs." Available at <<http://www.nuscalepower.com/about-us/faqs#p1a5>> (accessed September 13, 2018).

[OIPP] Office of Innovative Partnerships and Alternate Funding, Highway Division, Oregon Department of Transportation, State of Oregon. 2010. "Health and Safety Concerns of Photovoltaic Solar Panels." Salem, Oregon. Available at <https://www.ssti.us/wp/wp-content/uploads/2016/09/Health_and_Safety_Concerns_of_Photovoltaic_Solar_Panels_2010_OR.pdf> (accessed September 10, 2018).

Occupational Safety and Health Act of 1970, as amended. 29 U.S.C. 651 et seq.

[ORNL] Oak Ridge National Laboratory. 2012. "An Assessment of Energy Potential at Non-Powered Dams in the United States." Oak Ridge, TN: ORNL. April 2012. 44 p. Available at <http://www1.eere.energy.gov/water/pdfs/npd_report.pdf> (accessed September 14, 2018).

Parris A., et al. 2012. "Global Sea Level Rise Scenarios for the United States National Climate Assessment." NOAA Technical Report OAR CPO-1. Silver Spring, MD: Climate Program Office. December 6, 2012. 33 p. Available at <http://scenarios.globalchange.gov/sites/default/files/NOAA_SLR_r3_0.pdf> (accessed August 24, 2018).

[PBCI] Poarch Band of Creek Indians. 2019. Letter from L. Hailey to N. Martinez. Subject: Re: Environmental impact statement for subsequent licenser renewal of Turkey Point. April 22, 2019. ADAMS Accession No. ML19128A270.

[PEI] Power Engineering International. 2017. "South Korea fuel cell CHP plant comes online." March 21, 2017. Available at <<http://www.powerengineeringint.com/articles/2017/03/south-korea-fuel-cell-chp-plant-comes-online.html>> (accessed 28 August 2018).

[Port Miami] Port Miami. 2017. "2016 Local and Regional Economic Impacts of PortMiami: Executive Summary." Martin Associates. April 12, 2017. 4 p. Available at <<http://www.miamidade.gov/portmiami/library/reports/2016-economic-impact-executive-summary.pdf>> (accessed September 11, 2018).

Powell G.V.N., Kenworthy W.J., Fourqurean J.W. 1989. "Experimental evidence for nutrient limitation of seagrass growth in a tropical estuary with restricted circulation." *Bulletin of Marine Science* 44(1): 324-340.

Powell G.V.N., Fourqurean J.W., Kenworthy W.J., Zieman J.C. 1991. "Bird colonies cause seagrass enrichment in a subtropical estuary: observational and experimental evidence." *Estuarine, Coastal, and Shelf Science* 32(6): 567-579.

Prinos, S.T. 2017. "Map of the approximate inland extent of saltwater at the base of the Biscayne aquifer in the Model Land Area of Miami-Dade County, Florida, 2016." Lutz, FL: U.S. Geological Survey. Scientific Investigations Map 3380, 8 p. Pamphlet, 1 sheet. Available at <<https://pubs.er.usgs.gov/publication/sim3380>> (accessed July 7, 2018).

Prinos S.T., Wacker M.A., Cunningham K.J., Fitterman D.V. 2014. "Origins and Delineation of Saltwater Intrusion in the Biscayne Aquifer and Changes in the Distribution of Saltwater in Miami-Dade County, Florida." Reston, VA: U.S. Geological Survey. 2014. Scientific Investigations Report 2014-5025. 116 p. Available at <<http://dx.doi.org/10.3133/sir20145025>> (accessed July 7, 2018).

[RECOVER] Comprehensive Everglades Restoration Plan, 2014 System Status Report. August 2014. Available at <<https://evergladesecohealth.org/site/assets/files/1970/2014-system-status-report-1.pdf>> (accessed July 24, 2019).

[RECOVER] Restoration Coordination and Verification Program. 2019. 2019 Everglades System Status Report, Assessment period of 2012–2017. 2019. Available at <https://evergladesecohealth.org/site/assets/files/1969/2019_system_status_report-1.pdf> (accessed July 22, 2019).

Resource Conservation and Recovery Act of 1976, as amended, 42 U.S.C § 6901 et seq.

Robles, M.D., Armentano T., DiResta D., Lara M.R., Jones D.L. Butler, M.J. 2005. “Condition of the Natural Resources of Biscayne National Park.” A State of the Parks Technical Report, NatureServe. Arlington, Virginia. May 2005. Available at <http://www.marine.usf.edu/user/djones/pubs/Robles_etal_2005b.pdf> (accessed June 12, 2018).

Runkle, J., et al. 2017. “Florida State Climate Summary.” NOAA Technical Report NESDIS 149-FL. 5 p. Available at <<https://statesummaries.ncics.org/fl>> (accessed September 16, 2018).

Safe Drinking Water Act of 1974, as amended. 42 U.S.C § 300F et seq.

[SAFMC and NMFS] South Atlantic Fishery Management Council and National Marine Fisheries Service. 2016. “Users Guide to Essential Fish Habitat Designations by the South Atlantic Fisheries Management Council.” November 2016, Revised August 2017. 24 p. Available at <http://safmc.net/download/SAFMCFHUsersGuideFinalRevAug17_2.pdf> (accessed July 26, 2018).

[SFRCCC] Southeast Florida Regional Climate Change Compact, Sea Level Rise Work Group (Compact). 2015. “Unified Sea Level Rise Projection for Southeast Florida.” October 2015. 35 p. Available at <<http://www.southeastfloridaclimatecompact.org/wp-content/uploads/2015/10/2015-Compact-Unified-Sea-Level-Rise-Projection.pdf>> (accessed August 10, 2018).

[SFWMD] South Florida Water Management District. 2009. “FPL Turkey Point Power Plant, Groundwater, Surface Water, and Ecological Monitoring Plan.” October 14, 2009. ADAMS Accession No. ML12193A539.

[SFWMD] South Florida Water Management District. 2011a. “Water Quality Characterization of Southern Miami-Dade County and Nearby FPL Turkey Point Power Plant, Miami-Dade County, Florida.” Technical Publication WS-31. July 2011. 224 p. Available at <<https://www.sfwmd.gov/document/ws-31-water-quality-characterization-southern-miami-dade-county-and-nearby-fpl-turkey>> (accessed September 10, 2018).

[SFWMD] South Florida Water Management District. 2011b. Resolution No. 2011–927B. Available at <https://www.sfwmd.gov/sites/default/files/documents/fy12_trim_gb_resolution_okeechobee_basin.pdf> (accessed May 1, 2018).

[SFWMD] South Florida Water Management District. 2012. “Overview and Current Use of the Floridan Aquifer System in the Lower East Coast.” Public Workshop, Pompano Beach, Florida. April 18, 2012. 56 p. Available at <https://www.sfwmd.gov/sites/default/files/documents/fas_lec_041812_final_pjk.pdf> (accessed August 17, 2018).

[SFWMD] South Florida Water Management District. 2013. South Florida Water Management District Patrol Summary, Model Lands. October 18–31, 2013. West Palm Beach, FL. ADAMS Accession No. ML14328A521.

[SFWMD] South Florida Water Management District. 2015. "Applicant's Handbook for Water Use Permit Applications Within the South Florida Water Management District." Effective September 7, 2015. 115 p. Available at <<https://www.sfwmd.gov/doing-business-with-us/permits/water-use-permits>> (accessed July 7, 2018).

[SFWMD] South Florida Water Management District. 2017a. Water Use Individual Permit, Permit Number 13-0625-W, Florida Power and Light Turkey Point Groundwater Recovery Well System, and Water Use Staff Report. Issued February 27, 2017. Available at <<http://my.sfwmd.gov/ePermitting/PopulateLOVs.do?flag=1>> (search permit # 13-06251-W) (accessed August 1, 2018).

[SFWMD] South Florida Water Management District. 2017b. Water Use Individual Permit, Permit Number 13-06343-W, Atlantic Civil Inc. Freshwater Injection, and Water Use Staff Report. Date Issued May 9, 2017. Available at <<http://my.sfwmd.gov/ePermitting/PopulateLOVs.do?flag=1>> (search permit # 13-06343-W) (accessed August 24, 2018).

[SFWMD] South Florida Water Management District. 2019a. Pumpage Report for Water Use Permit, Permit # 13-00003-W [report dates: 4/18/2018, 7/23/2018, 10/25/2018, 1/21/2019]. Available at <<https://my.sfwmd.gov/ePermitting/PopulateLOVs.do?flag=1>> (search: FPL Turkey Point Nuclear Power, permit # 13-00003-W) (accessed July 19, 2019).

[SFWMD] South Florida Water Management District. 2019b. Pumpage Report for Water Use Permit, Permit # 13-06251-W [report dates: 7/26/2018, 10/25/2018, 1/25/2019]. Available at <<https://my.sfwmd.gov/ePermitting/PopulateLOVs.do?flag=1>> (search: FPL Turkey Point Groundwater Recovery Well System, permit # 13-06251-W) (accessed July 19, 2019).

[Smithsonian] Smithsonian Institution Marine Station at Fort Pierce. 2009. *Uca rapax*, Mudflat Fiddler Crab. Available at <https://naturalhistory2.si.edu/smsfp/irlspec/Uca_rapax.htm> (accessed September 13, 2018).

[SNO] The Seminole Nation of Oklahoma. 2018. Response to Request for Scoping Comments Concerning the Environmental Review of Turkey Point Nuclear Plant, Units 3 and 4 Subsequent License Renewal Application. June 12, 2018. ADAMS Accession No. ML18169A152.

Specziar A. 2004. "Life history pattern and feeding ecology of the introduced eastern mosquitofish, *Gambusia holbrooki*, in a thermal spa under temperature climate, of Lake Heviz, Hungary." *Hydrobiologia* 522:249–260. DOI: 10.1023/B:HYDR.0000029978.46013.d1.

Srean P., Almeida D., Rubio-Gracia F., Luo Y., Garcia-Berthou E. 2016. "Effects of size and sex on swimming performance and metabolism of invasive mosquitofish *Gambusia holbrooki*." *Ecology of Freshwater Fishes* 26(3):424–433. April 27, 2016. DOI: 10.1111/eff.12286.

State of Florida Siting Board. 2014. Final Order on Certification, In Re: Florida Power & Light Company Turkey Point Units 6 & 7 Power Plant Siting Application No. PA 03-45A3. OGC Case No. 09-3107, Division of Administrative Hearings Case No. 09-03575EPP. May 19, 2014. ADAMS Accession No. ML14345A291.

State of Florida Siting Board. 2016. Final Order, Florida Power and Light Company Turkey Point Power Plant Units 3 – 5 Modification to Conditions of Certification. OGC Case No. 14-0510, DOAH Case No. 15-1559EPP. April 1, 2016. Available at <<https://floridadep.gov/ogc/ogc/documents/14-0510>> (accessed July 7, 2018).

[STOF] Seminole Tribe of Florida. 2018. Response to Request for Scoping Comments Concerning the Environmental Review of Turkey Point Nuclear Plant, Units 3 and 4 Subsequent License Renewal Application. July 3, 2018. ADAMS Accession No. ML18184A462.

Strawn K., Dunn J.E. 1967. "Resistance of Texas salt- and freshwater-marsh fishes to heat death at various salinities." *Texas Journal of Science* 19:57–76.

Tomasko D.A., Lapointe B.E. 1991. "Productivity and biomass of *Thalassia testudinum* as related to water column nutrient availability and epiphyte levels: field observations and experimental studies." *Marine Ecology Progress Series* 75(1): 9-17.

Tao Z., et al. 2007. "Sensitivity of U.S. surface ozone to future emissions and climate changes." *Geophysical Research Letters*, 34(8):L08811. DOI: 10.1029/2007GL029455.

[Tetra Tech] Tetra Tech NUS, Inc. 2009. "Final Fish Surveys of the Turkey Point Property Associated with Units 6 & 7, June 23–24, 2009." July 2009. ADAMS Accession No. ML11168A043.

[Tetra Tech] Tetra Tech NUS Inc. 2014a. Technical Memorandum from P.F. Andersen and J.L. Ross, Tetra Tech, to R. Rahming, FPL, dated May 9, 2014, regarding "Evaluation of Required Floridan Water for Salinity Reduction in the Cooling Canal System." Pasadena, California. ADAMS Accession No. ML14279A555.

[Tetra Tech] Tetra Tech NUS Inc. 2014b. Technical Memorandum from P. F. Andersen and J. Ross, Tetra Tech, to R. Rahming, Florida Power & Light Company. Subject: "Evaluation of Drawdown in the Upper Floridan Aquifer Due to Proposed Salinity Reduction-based Withdrawals." November 13, 2014. In: In: FPL 2018n, SLRA Appendix E Section 4.5.3.4 Supplemental Information, L-2018-086, Attachment 1, Enclosure 1. ADAMS Accession No. ML18102A521.

[Tetra Tech] Tetra Tech NUS Inc. 2016. "A Groundwater Flow and Salt Transport Model of the Biscayne Aquifer." June 2016. 53 p. Attachment to email from W. Mayorga, Miami-Dade Regulatory and Economic Resources, to J. Truitt, FDEP. Subject: "FW: Supplemental Groundwater Model Documentation." June 13, 2016. Available at <<http://ecmrer.miamidade.gov:8080/hpi/search>> (search Case Number: HWR-00851, Date: 6/13/2016) (accessed August 1, 2018).

[Tetra Tech] Tetra Tech NUS Inc. 2018. "Variable Density Ground Water Flow and Salinity Transport Model Analysis, Attribution Analysis Results." June 19, 2018. 34 p. In: FPL 2018h, FPL Response to NRC RAI No. WR-12, L-2018-136 Attachment 53 Enclosure 1. ADAMS Accession No. ML18247A566.

Timmerman C.M., Chapman L.J. 2004. Behavioral and physiological compensation for chronic hypoxia in the sailfin molly (*Poecilia latipinna*). *Physiological and Biochemical Zoology* 77(4):601–610. DOI: 10.1086/421754.

[Tetra Tech] Tetra Tech Engineering, Inc. 2009. "Turkey Point Power Plant Peak Construction Analysis." June 2009. 82 p. ADAMS Accession No. ML16167A504.

[USCG] U.S. Coast Guard. 2018. National Response Center, 2018 Reports. Available at <<http://www.nrc.uscg.mil/>> (accessed July 20, 2018).

[UF] University of Florida. 2018a. "Handbook of Florida Water Regulation: State Groundwater Discharge Regulations." FE601. Available at <<http://edis.ifas.ufl.edu/pdffiles/FE/FE60100.pdf>> (accessed July 18, 2018).

[UF] University of Florida. 2018b. Sawgrass Marshes. Available at <<https://www.floridamuseum.ufl.edu/southflorida/habitats/freshwater-marshes/sawgrass-marshes/>> (accessed on August 27, 2018).

[USACE and SFWMD] U.S. Army Corps of Engineers and South Florida Water Management District. 2011. "Central and Southern Florida Project, Comprehensive Everglades Restoration Plan, Biscayne Bay Coastal Wetlands Phase 1 Final Integrated Project Implementation Report and Environmental Impact Statement, Volume 1 – Main Report." July 2011. 556 p. ADAMS Accession No. ML12270A058.

[USCB] U.S. Census Bureau. 1990. 1990 Census of Population, General Population Characteristics: Florida. Available at <<https://www.census.gov/programs-surveys/decennial-census/decade.1990.html>> (accessed August 8, 2018).

[USCB] U.S. Census Bureau. 1996. "Population of States and Counties of the United States: 1790 to 1990." Available at <<https://www.census.gov/population/www/censusdata/pop1790-1990.html>> (accessed May 4, 2018).

[USCB] U.S. Census Bureau. 2000a. "Census 2000: Summary File 2." Available at <<https://www.census.gov/census2000/sumfile2.html>> (accessed June 6, 2018).

[USCB] U.S. Census Bureau. 2000b. "Profile of General Demographic Characteristics: 2010 Florida." Available at <<http://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (August 8, 2018).

[USCB] U.S. Census Bureau. 2010a. Profile of General Population and Housing Characteristics: 2010, Miami-Dade County, Table DP-1. Available at <<https://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (accessed July 10, 2018).

[USCB] U.S. Census Bureau. 2010b. Profile of General Population and Housing Characteristics: 2010, Florida, Table DP-1. Available at <<https://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (accessed August 8, 2018).

[USCB] U.S. Census Bureau. 2010c. Profile of General Demographic Characteristics: 2010, Broward County. Table DP-1. Available at <<https://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (accessed August 24, 2018).

[USCB] U.S. Census Bureau. 2011. American FactFinder, 2011 American Community Survey 1-Year Estimates, Table DP03 – "Selected Economic Characteristics," for Miami-Dade County and State of Florida. Available at: <<https://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (accessed May 2, 2018).

[USCB] U.S. Census Bureau. 2016a. American FactFinder, 2016 American Community Survey 1-Year Estimates, Table DP03 – "Selected Economic Characteristics" for Miami-Dade County and State of Florida. Available at: <<https://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (accessed May 2, 2018).

[USCB] U.S. Census Bureau. 2016b. American FactFinder, 2016 American Community Survey 1-Year Estimates, Table DP5 – "Demographic and Housing Estimates" for Miami-Dade, Monroe, Broward, and Collier Counties. <<https://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (accessed May 4, 2018).

[USCB] U.S. Census Bureau. 2016c. American FactFinder, 2016 American Community Survey 1-Year Estimates, Table S1401 – “School Enrollment” for Miami-Dade County. Available at: <<https://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (accessed June 7, 2018).

[USCB] U.S. Census Bureau. 2016d. American FactFinder, 2016 American Community Survey 1-Year Estimates, Table B25002 – “Occupancy Status” for Miami-Dade, Monroe, Broward, and Collier Counties. Available at <<https://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (accessed May 4, 2018).

[USCB] U.S. Census Bureau. 2016e. American FactFinder, 2016 American Community Survey 1-Year Estimates,” Table DP4 – “Selected Housing Characteristics” for Miami-Dade County. Available at <<https://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (accessed May 4, 2018).

[USCB] U.S. Census Bureau. 2016f. American FactFinder, 2012-2016 American Community Survey 5-Year Estimates, Table DP3 – “Selected Economic Characteristics.” Available at: <<https://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (accessed July 12, 2018).

[USCB] U.S. Census Bureau. 2016g. Poverty Thresholds by Size of Family and Number of Related Children Under 18 Years. Available at <<https://www.census.gov/data/tables/time-series/demo/income-poverty/historical-poverty-thresholds.html>> (accessed July 9, 2018).

[USCB] U.S. Census Bureau. 2016h. American FactFinder, 2012-2016 American Community Survey 5-Year Estimates, Table DP4 – “Selected Housing Characteristics” and Table DP03 – “Selected Economic Characteristics” for Broward County. Available at <<https://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (accessed August 10, 2018).

[USCB] U.S. Census Bureau. 2018. American FactFinder, “2012-2016 American Community Survey 5-Year Estimates,” Table DP03 – Selected Economic Characteristics for Broward County. Available at: <<http://factfinder.census.gov/faces/nav/jsf/pages/searchresults.xhtml?refresh=t>> (accessed 24 August 2018).

[USGCRP] U.S. Global Change Research Program. 2009. “Global Climate Change Impacts in the United States.” New York, NY: NOAA National Climatic Data Center. June 2009. 196 p. Available at < <https://nca2009.globalchange.gov/> > (accessed August 10, 2018).

[USGCRP] U.S. Global Change Research Program. 2014. “Climate Change Impacts in the United States: The Third National Climate Assessment.” Washington, DC: Federal National Climate Assessment and Development Advisory Committee. May 2014. Revised October 2014. 841 p. DOI: 10.7930/J0Z31WJ2. Available at <<https://www.globalchange.gov/nca3-downloads-materials>> (accessed August 10, 2018).

[USGCRP] U.S. Global Change Research Program. 2017. “Climate Science Special Report: Fourth National Climate Assessment, Volume 1.” Washington, DC: USGCRP. 2017. 470 p. DOI: 10.7930/J0J964J6. Available at <https://science2017.globalchange.gov/downloads/CSSR2017_FullReport.pdf> (accessed August 10, 2018).

- USGCRP] U.S. Global Change Research Program. 2018. "Impacts, Risks, and Adaptation in the United States: Fourth National Climate Assessment, Volume II." Washington, DC: USGCRP. doi: 10.7930/NCA4.2018. 2018. 1,515 p. Available at <<https://nca2018.globalchange.gov/>> (accessed April 26, 2019).
- [USDA] U.S. Department of Agriculture. 2017. Custom Soil Resource Report for Turkey Point Power Plants. April 27, 2018. Available at <<http://websoilsurvey.nrcs.usda.gov/app/WebSoilSurvey.aspx>> (accessed April 27, 2018).
- [USDA] U.S. Department of Agriculture. 2019. 2017 Census of Agricultural. Available at <https://www.nass.usda.gov/Publications/AgCensus/2017/Full_Report/Volume_1,_Chapter_2_County_Level/Florida/> (accessed June 4, 2019).
- [USGS] U.S. Geological Survey. 2001. "Simulation of Ground-Water Discharge to Biscayne Bay, Southeastern Florida." Water-Resources Investigations Report 2000-4251. Available at <<https://pubs.er.usgs.gov/publication/wri004251>> (accessed May 25, 2018).
- [USGS] U.S. Geological Survey. 2008a. "Assessment of Moderate- and High-Temperature Geothermal Resources of the United States." Menlo Park, CA: USGS. Fact Sheet 2008-3082. 2008. 4 p. Available at <<http://pubs.usgs.gov/fs/2008/3082/pdf/fs2008-3082.pdf>> (accessed September 6, 2018).
- [USGS] U.S. Geological Survey. 2008b. "U.S. Geological Survey Science Support Strategy for Biscayne National Park and Surrounding Areas in Southeastern Florida." Open-File Report 2007-1288. 2008. 54 p. Available at <https://pubs.usgs.gov/of/2007/1288/pdf/ofr2007-1288_lowrez.pdf> (accessed May 25, 2018).
- [USGS] U.S. Geological Survey. 2012. "Evaluation of Effects of Changes in Canal Management and Precipitation Patterns on Salinity in Biscayne Bay, Florida, Using an Integrated Surface-Water/Groundwater Model." Scientific Investigations Report 2012-5099. 2012. 94 p. Available at <<https://pubs.er.usgs.gov/publication/sir20125099>> (accessed June 10, 2019).
- [USGS] U.S. Geological Survey. 2018a. "Data tables summarizing the source-specific estimated water withdrawals in Florida by category, county, and water management district, 2015." DOI: 10.5066/F7N29W5M. Available at <<https://www.sciencebase.gov/catalog/item/5a4cdec8e4b0d05ee8c4cabf>> (accessed August 1, 2018).
- [USGS] U.S. Geological Survey. 2018b. "South Florida Information Access: Mineral Resources." Page updated April 30, 2018. Available at <<https://sofia.usgs.gov/publications/reports/rali/mineral.html>> (accessed April 30, 2018).
- Vernberg F.J., Tashian R.E. 1959. Studies on the physiological variation between tropical and temperate zone fiddler crabs of the genus *Uca* I. Thermal death limits. *Ecology* 40(4):589-593. DOI: 10.2307/1929812.
- Wagner K.C., Gauntt R.O. 2006. "Mitigation of Spent Fuel Pool Loss-of-Coolant Inventory Accidents and Extension of Reference Plant Analyses to Other Spent Fuel Pools." Albuquerque, NM: Sandia National Laboratories. November 2006. 120 p. ADAMS Accession No. ML120970086.
- Zanders I.P., Rojas W.E. 1996. Osmotic and ionic regulation in the fiddler crab *Uca rapax* acclimated to dilute and hypersaline seawater. *Marine Biology* 125:315-320. DOI: 10.1007/BF00346312.

Wu S., et al. 2008. Effects of 2000–2050 global change on ozone air quality in the United States. *Journal of Geophysical Research* 113:D06302. DOI: 10.1029/2007JD008917.

Zhang Y., Wang Y. 2016. Climate-driven ground-level ozone extreme in the fall over the Southeast United States. *Proceedings of the National Academy of Sciences of the United States of America* 133(36):10025–10030. DOI: 10.1073/pnas.1602563113.

7 LIST OF PREPARERS

Members of the U.S. Nuclear Regulatory Commission’s (NRC’s) Office of Nuclear Reactor Regulation (NRR) prepared this supplemental environmental impact statement with assistance from other NRC organizations and support from Pacific Northwest National Laboratory.

Table 7-1 below identifies each contributor’s name, affiliation, and function or expertise.

Table 7-1 List of Preparers

Name	Education/Experience	Function or Expertise
NRC Staff (in alphabetical order)		
Benjamin Beasley	M.S. Nuclear Engineering; B.S. Chemical Engineering; 27 years of combined industry and Government experience including nuclear plant system analysis, risk analysis, and project management, with 13 years of management experience	Management Oversight
William “Butch” Burton	B.S. Nuclear Engineering; 39 years of industry and government experience including submarine and nuclear systems operations and testing	Project Management
Phyllis Clark	M.S. Nuclear Engineering; M.B.A, Business Administration; B.S. Physics; 35 years of industry and Government experience including nuclear power plant and production reactor operations, systems engineering, reactor engineering, fuels engineering, criticality, power plant emergency response	Radiological and Waste Management
Jerry Dozier	M.S. Reliability Engineering; M.B.A. Business Administration; B.S. Mechanical Engineering; 30 years of experience including operations, reliability engineering, technical reviews	Severe Accident Mitigation Alternative (SAMA)
David Drucker	M.S. Engineering Management; B.S. General Engineering; 37 years experience managing projects	Project Management
Kevin Folk	M.S. Environmental Biology; B.A. Geoenvironmental Studies; 29 years of experience in NEPA compliance; geologic, hydrologic, and water quality impacts analysis; utility infrastructure analysis, environmental regulatory compliance; and water supply and wastewater permitting	Groundwater; Greenhouse Gas Emissions and Climate Change
William Ford	M.S. Geology; 44 years of combined industry and Government experience working on groundwater, surface water, and geology projects	Geology; Surface Water
Briana Grange	M.Cert. National Environmental Policy Act; B.S. Conservation Biology; 14 years of	Aquatic Resources; Terrestrial Resources; Special Status

Name	Education/Experience	Function or Expertise
	experience in environmental impact analysis, Section 7 consultations, and Essential Fish Habitat consultations	Species and Habitats; Microbiological Hazards
Robert Hoffman	B.S. Environmental Resource Management; 33 years of experience in NEPA compliance, environmental impact assessment, alternatives identification and development, and energy facility siting	Alternatives; Meteorology and Air Quality
Lois James	M.S. Environmental Engineering; B.S. Nuclear Engineering; 27 years of combined industry and Government experience including power plant inspection, power plant incident response, and project management	Project Management
Nancy Martinez	B.S. Earth and Environmental Science; A.M. Earth and Planetary Science; 8 years of experience in environmental impact analysis	Historic and Cultural Resources; Socioeconomics; Environmental Justice
William Rautzen	M.S. Health Physics; B.S. Health Physics; B.S. Industrial Hygiene; 9 years of experience in environmental impact analysis	Human Health
Jeffrey Rikhoff	M.R.P. Regional Planning, M.S. Economic Development and Appropriate Technology; 38 years of combined industry and Government experience including 31 years of NEPA compliance, socioeconomics and environmental justice impact analyses, cultural resource impact assessments, consultations with American Indian tribes, and comprehensive land-use and development planning studies	Land Use, Noise, and Cumulative Impacts Introduction
Robert Schaaf	B.S. Mechanical Engineering; 31 years of government project management experience, including 15 years of experience in environmental project management	Project Management
Pacific Northwest National Laboratory Staff (in alphabetical order)		
Dave Anderson	M.S. Forest Economics; B.S. Forest Resources. 25 years of experience in environmental and economic modeling	Minority and low-income population mapping
Philip Meyer	Ph.D. Civil Engineering; B.A. Physics; 27 years relevant experience in subsurface hydrology and contaminant transport	Groundwater Resources
Terri Miley	M.S. Mathematics; B.S. Mathematics; 13 years relevant experience in NEPA comment-response and database development	Comment Response Support Lead
Rajiv Prasad	Ph.D. Civil and Environmental Engineering; M. Tech. Civil Engineering; B.S. Civil Engineering; 15 years relevant experience	Surface Water Resources

Name	Education/Experience	Function or Expertise
	in surface water use and quality characterization and assessment	
James Saulsbury	M.S. Planning; B.A. History; 31 years relevant experience in land use and socioeconomic impact assessment	Pacific Northwest National Laboratory Team Lead
Paul Thorne	M.S. Hydrology; B.S. Chemistry/Math; 34 years relevant experience in hydrogeology including analysis of groundwater flow and migration of contaminants in the subsurface	Groundwater Resources

8 LIST OF AGENCIES, ORGANIZATIONS, AND PERSONS TO WHOM COPIES OF THIS SEIS ARE SENT

Table 8-1 List of Agencies, Organizations, and Persons to Whom Copies of this SEIS Are Sent

Name and Title	Affiliation and Address
Aldridge, Jason, Supervisor of Federal and State Compliance and Review, and Deputy SHPO	Florida Department of State 500 South Bronough Street R.A. Gray Building Tallahassee, FL 32399-0250
Andreacchio, Tonya	Citizen
Altfater, Valerie	Citizen
Arditi-Rocha, Yoca	Citizen
Aronowitz, Karen	Citizen
Aurigemma, Kaye	Citizen
Ayres, Richard E.	Friends of the Earth 2923 Foxhall Road, NW. Washington, D.C. 20016 ayresr@ayreslawgroup.com
Backhouse, Paul Tribal Historic Preservation Officer	Seminole Tribe of Florida Ah-Ta-Thi-Ki Museum 30290 Josie Billie Hwy, PMB 1004 Clewiston, FL 33440
Baer, Robin	Citizen
Baez-Hernandez, Sonia	Citizen
Baloyra, Enrique	Citizen
Barczak, Sara Regional Advocacy Director	Southern Alliance for Clean Energy sara@cleanenergy.org
Bard, Brenda	Citizen
Barghahn, Serena	Citizen
Barstad, Cynthia	Citizen
Battelli, Tony	Citizen
Bauman, Laura	Citizen
Bausch, Joan	Citizen
Beauchamp, Kristin	Citizen
Beck, Clyde	Citizen
Beigel, Lynda	Citizen
Bender, Kae	Citizen
Besford, Stacey	Citizen
Black, Kerry	Citizen
Blackstone, Linore	Citizen
Blazier, Thomas	Citizen
Block, Emily	Citizen

Name and Title	Affiliation and Address
Bloom, Mary	Citizen
Bonasia, Joseph	Citizen
Brainard, Wendy	Citizen
Bratcher, Suzanne	Citizen
Brinkley, Brenda	Citizen
Bromfield, Chris	Citizen
Broms, Sharon	Citizen
Brown, Linda	Citizen
Brown, Steven	Citizen
Brusin, Eugene	Citizen
Bryan, Stephanie Tribal Chair	Poarch Band of Creek Indians 5811 Jack Springs Road Atmore, AL 36502
Buck, Julia	Citizen
Burke, Maureen	Citizen
Carter, Andrew	Miami Waterkeeper 2103 Coral Way, 2nd Floor Miami, FL 33145
Casalone, Virginia	Citizen
Case, Karen	Citizen
Cavros, George	Citizen
Champy, Cheryl	Citizen
Charles, David	Citizen
Chenoweth, Michael F. President	Friends of the Loxahatchee Refuge P.O. Box 6777 Delray Beach, FL 33482-6777
Chesnut, Joanna	Citizen
Chilcoat, Greg Principal Chief	Seminole Nation of Oklahoma P.O. Box 1498 Wewoka, OK 74884
Clancy, Bonnie	Citizen
Cochrane, Theodore	Citizen
Cody, Jeff	Citizen
Cody, Sarah Chief	Office of Historic Preservation Stephen P. Clark Center 111 NW 1st St. - 12th Floor Miami, FL 33128
Cook, Matthew	Citizen
Conley, Cristen	Citizen
Cosner, Zacharian	Citizen

Name and Title	Affiliation and Address
Cox, Kelly	Miami Waterkeeper 2103 Coral Way, 2nd Floor Miami, FL 33145 kelly@miamiwaterkeeper.org
Crupi, Kevin	Citizen
Culberson, Andrea	Citizen
Culberson, Ina	Citizen
Diane Curran	Southern Alliance for Clean Energy Harmon, Curran, Spielberg, & Eisenberg, L.L.P. 1725 DeSales Street N.W., Suite 500 Washington, D.C. 20036 240-393-9285 dcurran@harmoncurran.com
Cypress, Billy Chairman	Miccosukee Tribe of Indians of Florida Tamiami Station P.O. Box 440021 Miami, FL 33144
Davidson, Maggie	Citizen
Dayhoff, Fred Section 106 and NAGPRA Coordinator	Miccosukee Tribe of Indians of Florida HC61 SR Box 68 Old Loop Road Road Ochopee, FL 34141
Decker, Lesley	Citizen
Dehart, Jody Heriot	Citizen
deJong, Suki	Citizen
Dempsey, Kelley	Citizen
Denton, April	Citizen
Dick, Marianne	Citizen
Dickinson, Vicki	Citizen
Dickey, Michael	Citizen
Diersing, Nancy	nancy.diersing@noaa.gov
Drewelow, Beth	Citizen
Dunn, Leslene	Citizen
Echols, Darrell, Chief Science and Natural Resource Management	South East Region, National Park Service darrell_echols@nps.gov
Eikholt, Michele	Citizen
Elmo, Francesca	Citizen
Fahner, Bryan Energy & Environmental Protection Specialist	National Park Service, Southeast Region MIB Room 2642 Atlanta Federal Center 1924 Building 100 Alabama St., SW. Atlanta, GA 30303

Name and Title	Affiliation and Address
Fangman, Sarah	NOAA Florida Keys National Marine Sanctuary 33 East Quay Road Key West, FL 33040
Farber, Carol	Citizen
Fettus, Geoffrey H.	NRDC 1152 15th Street, NW, Suite 300 Washington, D.C. 20005 gfettus@nrdc.org
Figueroa, Stephanie	Citizen
Finell, Jeffrey	Citizen
Finver, Jody	Citizen
Fleener, Teresa	Citizen
Floyd, James Principal Chief	Muscogee (Creek) Nation Office of the Administration P.O. Box 580 Okmulgee, OK 74447
Foerste, Eleanor	Citizen
Ford, Patricia	Citizen
Foster, Delaina	Citizen
Franzone, Steve Licensing Manager	Florida Power & Light Co. Steve.Franzone@fpl.com
Frazzini, Vincent	Citizen
Free, Cherie	Citizen
Fried, Jonathan	Citizen
Friedman, Steve	Citizen
Fuentes, Ettienne	Citizen
Furtak, Sarah	sarah.furtak@noaa.gov
Gale, Michelle	Citizen
Gandarilla, Eric	Citizen
Gardiner, Hannah	Citizen
Gates, Christopher	Citizen
Gibaldi, Mike	Citizen
Gold, Sheryl	Citizen
Gomez, Albert	Citizen, albert@icassemblies.com
Gonzales, Erik	Citizen
Gonzalez, Kimberly	Citizen
Goodale, Margaret	Citizen
Goodro, Margaret, Superintendent Biscayne National Park	National Park Service margaret_goodro@nps.gov
Goppert, Donald	Citizen
Gorman, Emily	Citizen
Grace, Donna	Citizen

Name and Title	Affiliation and Address
Graffagnino, Mary Ann and Frank	Citizen
Grams, Yvonne	Citizen
Grantham, Tiffany	Citizen
Greene, J	Citizen
Greene, William	Citizen
Greenfield, Judy	Citizen
Grentzer, Kelsey	Citizen
Grossenbacher, Craig	Craig.Grossenbacher@miamidade.gov
Guest, David	Citizen
Gurtner, David	Citizen
Gutierrez, Mary	Citizen
Guy, Peter	Citizen
Haikey, Larry Tribal Historic Preservation Officer	Poarch Band of Creek Indians 5811 Jack Springs Road Atmore, AL 36502
Hall, Gilbert	Citizen
Hall, Michael	Citizen
Hamory, Ann	Citizen
Hangartner, Terry	Citizen
Harper, Cecelia Ann US EPA Comprehensive Everglades Restoration Plan Liaison	U.S. Environmental Protection Agency harper.cecelia@epa.gov
Harris, Susan	Citizen
Hartman, Richard	Citizen
Hefty, Lee Director	Department of Regulatory and Economic Resources Division of Environmental Resources Management (DERM) 701 NW 1st Court, 4th Floor, Miami, Florida 33136
Higgins, Jamie Project Manager	National Environmental Policy Act (NEPA) Program Office Resource Conservation Restoration Division Region 4, Environmental Protection Agency 61 Forsyth Street, NW Atlanta, GA 30303
Hildebrandt, Todd	Citizen
Hochkammer, Anna Council Member	Village of Pinecrest 12645 Pinecrest Pkwy Pinecrest, FL 33156
Hogan, Cynthia	Citizen
Hopf, James	Citizen
Hostler, Joyce	Citizen

Name and Title	Affiliation and Address
Howard, Derek	Assistant Monroe County Attorney Monroe County Attorney's Office 1111 12 th Street, Suite 408 Key West, FL 33040 Telephone: (305) 292-3470 Howard-Derek@monroecounty-fl.gov
Hummel, Lani	Citizen
Hunt, Melody Hydrologist	National Park Service melody_hunt@nps.gov
Ignetti, Gabriel	Citizen
Isham, Theodore Tribal Historic Preservation Officer	Seminole Nation of Oklahoma P.O. Box 1498 Wewoka, OK 74884
Jacobs, Kim	Citizen
Jahosky, Jackie	Citizen
James, Jason	Citizen
Janzen, Gayle	Citizen
Java, Theresa Free Press Staff	Florida Keys News TJAVA@Keysnews.com
Jimenez, Nathan	Citizen
Joannou Jr, Benjamin	Citizen
Johnson, Diane	Citizen
Kalman, Sherri	Citizen
Kalson, Vince Radiological Emergency Preparedness Administrator	Emergency Management Monroe County, Florida kalson-vince@monroecounty-fl.gov
Kapur, Aruni	Citizen
Karazsia, Jocelyn	jocelyn.karazsia@noaa.gov
Kick, Anna	Citizen
Kindred, Dorothy	Citizen
King, Christian	Citizen
King, Terry	Citizen
Kipnis, Dan	Citizen
Kirschbaum, Saran	Citizen
Kisor, Dave	Citizen
Knowles, Yvonne	Citizen
Kocol, John	Citizen
Kotzig, Allison	Citizen
Kuttner, Paula	Citizen
Lambert, Sandra	Citizen
Landry, Ju	Citizen
Laslie, Maude	Citizen

Name and Title	Affiliation and Address
Lennick, BrendaLee	Citizen
Levinson, David	Citizen
Levinson, Gilda	Citizen
Lewis, Nora	Citizen
Lighty, Ryan K. Esq.	Morgan, Lewis & Bockius LLP 1111 Pennsylvania Ave, N.W. Washington, D.C. 20004 ryan.lighty@morganlewis.com
Lion, Sue	Citizen
List, Gary	Citizen
Loerke, Alison	Citizen
Lopez, Jaclyn Florida Director	Center for Biological Diversity jlopez@biologicaldiversity.org
Lotz, Elizabeth	Citizen
Lowe-Zepeda, Corain Acting Tribal Historic Preservation Officer	Muscogee (Creek) Nation Cultural Preservation Office P.O. Box 580 Okmulgee, OK 74447
Lukowski, Stasa	Citizen
Luzum, Rosemary	Citizen
Macedo, Brenda	Citizen
Macraith, Bonnie	Citizen
Maher, William Senior Director, Licensing	Florida Power & Light Company William.Maher@fpl.com
Mahoney, Robert	Citizen
Makofske, William	Citizen
Manganello, Marilyn	Citizen
Marguardt, John	Citizen
Marin, Felipe	Citizen
Marin, Patricia	Citizen
Marquez, Orlando	Citizen
Martin, Drew	Citizen
Martinez, Jessica	Citizen
Masterson, Melanie	Citizen
Matthews, Ellyn	Citizen
Mazzuca, Rich	Citizen
Mcbride, Margaret	Citizen
McCluney, Ross	Citizen
McCormick, Jessica	Citizen
McCorry, Eileen	Citizen
McDonald, John	Citizen
McFall, Cynthia	Citizen

Name and Title	Affiliation and Address
McLaughlin, Caroline Associate Director	National Parks Conservation Association cmclaughlin@npca.org
Menchaca, Victoria L. Compliance Review Specialist	Seminole Tribe of Florida-THPO Compliance Review Section 30290 Josie Billie Hwy, PMB 1004 Clewiston, FL 33440
Mennel-Bell, Mari	Citizen
Messenger, Roger	Citizen
Metayer, Nancy	Citizen
Meyer, Roger	Citizen
Militscher, Christopher	U.S. Environmental Protection Agency
Miller, Jane	Citizen
Miller-Richardson, Gail	Citizen
Mills, Terri	Citizen
Milone, Patricia	Citizen
Monfredini, Janet	Citizen
Morra, Frank	Citizen
Morse, Stephanie Associate Public Counsel	Florida Office of Public Counsel morse.stephanie@leg.state.fl.us
Moses, Dorothy	Citizen
Mullray, Eileen	Citizen
Murphy, Sylvia	Citizen
Nazar, Mano President and Chief Nuclear Officer Nuclear Division	Florida Power & Light Company Mail Stop EX/JB 700 Universe Blvd Juno Beach, FL 33408
Nelson, Kent	Citizen
Neslon, Reid Director	Office of Federal Agency Programs Advisory Council on Historic Preservation 401 F Street NW, Suite 308 Washington, DC 20001-2637
Nester, Lindsay, FWS	Lindsay_Nester@fws.gov
Nicholson, Carol	Citizen
Nilon, Michael	Citizen
Nye, Janet	Citizen
O'Brien, Robert	Citizen
O'Keefe, Kevin	Citizen
Olivero, Carlos	Citizen
Olson, Brett	Citizen
O'Neill, Martin J. Esq.	Morgan, Lewis & Bockius LLP 1000 Louisiana St., Suite 4000 Houston, TX 77002 martin.o'neill@morganlewis.com

Name and Title	Affiliation and Address
Orthen, Rick	Florida Power & Light Company Richard.Orthen@fpl.com
Ortman, Nancy	Citizen
Osceola, Marcellus Chairman	Seminole Tribe of Florida 6300 Stirling Road Hollywood, FL 330241
Oswald, T	Citizen
Parker, Michael	Citizen
Parker, Sue	Citizen
Parra, Mana	Citizen
Penn, Jeremy	Citizen
Parsons, Timothy State Historic Preservation Officer	Florida Department of State 500 South Bronough Street R.A. Gray Building Tallahassee, FL 32399-0250
Pierce, Barbara	League of Women Voters
Pike, Robert	Citizen
Platero, Tracy	Citizen
Pritchard, Alvera	Citizen
Propen, Beverly	Citizen
Puca, Rob	Citizen
Quintero, Carolina	Citizen
Randall, Laura	Citizen
Rawal, Tatiana	Citizen
Raymond, Wendy	Citizen
Rees, Janet	Citizen
Reiser, Reba	Citizen
Remilien, Sandra	Citizen
Reynolds, Laura	lreynolds@conservationconceptsllc.org
Rippingille, Bonnie	Citizen
Riparetti-Stepien, Melissa	Citizen
Ritz, David President	Ocean Reef Community Association 24 Dockside Lane #505 Key Largo, FL 33037
Rivera, Jose, FWS	Jose_Rivera@fws.gov
Robinson Ford, Florence	Citizen
Robinson, Janet	Citizen
Roff, Rhonda	Citizen
Rose, Simon	Citizen
Rosenblum, Ron	Citizen

Name and Title	Affiliation and Address
Rotenberg, Edan	Miami Waterkeeper, Inc. Super Law Group, LLC 180 Maiden Lane, Suite 603 New York, New York 10038 edan@superlawgroup.com
Rumelt, Kenneth J	Environment & Natural Resources Law Clinic, Vermont Law School
Rushmer, Vera	Citizen
Rutkowski, Robert E.	e_rutkowski@att.net
Rybeck, Astrid	astrid_rybeck@nps.gov
Sagovac, Emily	Citizen
Salomon Miceli, Lynne	Citizen
Sanford, Ken	Citizen
Schafer, Alissa	Citizen
Schettini, Naomi	Citizen
Schievelbein, Tom	Citizen
Schoedinger, Steven, Chairman Ocean Reef Community	Ocean Reef Community Association 58 Anchor Drive, Unit B Key Largo, FL 33037
Schooley, Doreen	Citizen
Schuble, Sue	Citizen
Schulman, Stacie	Citizen
Schwartz, Matt	Citizen
Scotty, Vee	Citizen
Seamon, Jeffrey	Citizen
Seimer, Priscilla	Citizen
Sheridan, Michelle	Citizen
Shlackman, Mara	Citizen
Shoedinger, Steve	Citizen
Short, Mark	Citizen
Sieger, Brenda	Citizen
Silverstein, Rachel, Executive Director and Waterkeeper	Miami Waterkeeper 2103 Coral Way, 2nd Floor Miami, FL, 33145
Singleton, Martha	Citizen
Smith, Jennifer, K.	Jennifer.K.Smith@dep.state.fl.us
Songer, Mark E. Board President	Last Stand marksonger72@gmail.com
Sorkin, E	Citizen

Name and Title	Affiliation and Address
Spadafina, Lisa Chief	Natural Resources Division Department of Regulatory and Economic Resources Environmental Resources Management Overtown Transit Village 701 NW 1st Court 6th floor Miami, FL 33136 Lisa.Spadafina@miamidade.gov
Sramek, Jo-Ann	Citizen
Steele, Jody	Citizen
Stinson, Laura	Citizen
Stoddard, Philip	Citizen
Stone, Mike	Citizen
Storino, Michael	Citizen
Streit, Chris	Citizen
Sweeney, Pamela	Pamela.Sweeney@miamidade.gov
Talbot, Thomas	Citizen
Talbott, Diana	Citizen
Tamayo, Iggy	Citizen
Tamson, Edward Conservation Representative	Backcountry Fly Fishers P.O. Box 971 Naples, FL 34106
Teas, James	Citizen
Tejedor, Ignacio	Monroe County Board of County Commissioners 1100 Simonton Street Key West, FL 33040
Trudeau, Stephanie	Citizen
Tumolo, Marlies	Citizen
Van Walsen, Barbara	Citizen
Villablanca, Judith	Citizen
Vogel, Robert	National Park Service
Von Bargen, Donna	Citizen
Wald, Christina	Citizen
Waltz, Mike	Citizen
Wartman, Janet	Citizen
Waters, Lynn	Citizen
Webb, Ann	Citizen
Webster, Pamela	Citizen
Weiss, Allan	Citizen
Wesolowski, Pam	Citizen
Wheeler, Lynn	Citizen
White, Barry	Citizen

Name and Title	Affiliation and Address
White, Irene	Citizen
White, Susan	Citizen
Wieliczko, Julie	Citizen
Wilansky, Laura Sue	Citizen
Williams, Alek	Citizen
Williams, David	Citizen
Wingle, Dennis	Citizen
Worden, Susan	Citizen
Wright, Steven	Citizen
Wynn, Patricia	Citizen
Zapata, Monica	Citizen
Zavah, Barry	
Zimmerman, Katherine	Citizen
Zueleh, Kirk C. Executive Director	Florida Keys Aqueduct Authority 1100 Kennedy Drive Key West, FL 33040

9 INDEX

A

- accident..... 3-183, 4-5, 4-7, 4-108, 4-109, 4-113, 4-115, 4-119, 6-28, 6-31, 6-32, 6-33, 6-35, 6-44, 7-1, A-10, A-11, A-12, A-147, D-2, D-3, E-1, E-2, E-3, E-4, E-5, E-6, E-7, E-8, E-9, E-11, E-12, E-13, E-14, E-15, E-16, E-17, E-19, E-23
- Advisory Council on Historic Preservation (ACHP)xxiii, 8, 3-166, 4-94, 8-6, B-7, C-2, C-3, C-4
- aesthetic.....3-77, 3-165, 3-184, B-5, C-2
- algal..... 3-39, 3-40, 3-60, 3-137, 3-139, 4-147, A-54, A-125
- alternative..... iii, xxi, 2, 6, 7, 2-1, 2-3, 2-4, 2-5, 2-6, 2-7, 2-13, 2-15, 2-21, 2-22, 2-23, 2-24, 3-63, 3-64, 4-1, 4-2, 4-8, 4-10, 4-11, 4-12, 4-13, 4-15, 4-16, 4-17, 4-18, 4-19, 4-20, 4-21, 4-22, 4-23, 4-41, 4-44, 4-45, 4-46, 4-48, 4-54, 4-55, 4-56, 4-65, 4-66, 4-67, 4-69, 4-90, 4-91, 4-92, 4-93, 4-96, 4-97, 4-98, 4-99, 4-101, 4-107, 4-109, 4-110, 4-111, 4-112, 4-115, 4-116, 4-118, 4-119, 4-120, 4-121, 4-122, 4-123, 4-124, 4-125, 4-126, 4-129, 4-155, 4-156, 4-157, 4-158, 5-1, 6-15, 6-23, 6-28, 6-35, 7-2, A-10, A-11, A-12, A-13, A-14, A-15, A-16, A-17, A-19, A-20, A-21, A-23, A-24, A-35, A-40, A-44, A-46, A-50, A-57, A-58, A-62, A-63, A-65, A-66, A-81, A-83, A-90, A-91, A-92, A-93, A-101, A-112, A-118, A-121, A-122, A-130, A-137, A-138, A-139, A-141, A-143, A-144, A-147, B-3, C-2, D-2, D-3, E-4, E-15, E-16, E-18, E-19, E-23
- American crocodile xx, xxi, 2-25, 3-127, 3-129, 3-134, 3-156, 3-159, 3-161, 4-8, 4-51, 4-69, 4-70, 4-71, 4-74, 4-89, 4-90, 4-91, 4-93, A-21, A-24, A-25, A-26, A-60, A-64, A-65, A-66, A-67, A-68, A-140, B-8, C-1, C-2, C-3
- ammonia 3-55, 3-56, 3-66, 3-67, 3-68, 3-69, 3-70, 3-71, 3-72, 3-84, 3-88, 3-95, 3-97, 3-98, 3-99, 3-102, 3-122, 3-125, 3-126, 4-25, 4-40, 4-81, 4-82, 4-83, 4-84, 4-85, 4-88, A-24, A-25, A-26, A-37, A-51, A-57, A-75, A-85, A-88, A-90, A-103, A-104, A-105, A-108, A-112, A-125, A-126, A-127
- archaeological resources.....7, 3-165, 3-167, 3-168, 4-99, A-73

B

- biocide 3-182, 4-3, 4-48, 4-111, 4-121
- biological assessment.. 3-161, 3-162, 3-163, 4-69, 4-70, 4-75, 4-87, A-26, A-65, A-66, C-1, C-2, C-3
- biological opinionxxi, 2-25, 4-8, 4-70, 4-72, 4-75, 4-84, 4-86, 6-23, A-26, A-57, A-65, A-66, A-67, C-3, C-1
- biota..... 6-6, A-52
- Biscayne aquifer3-9, 3-11, 3-12, 3-13, 3-14, 3-34, 3-37, 3-46, 3-52, 3-59, 3-60, 3-61, 3-62, 3-63, 3-64, 3-70, 3-72, 3-73, 3-74, 3-75, 3-77, 3-78, 3-80, 3-81, 3-84, 3-87, 3-89, 3-90, 3-91, 3-92, 3-94, 3-95, 3-97, 3-98, 3-99, 3-101, 3-102, 3-105, 3-106, 3-111, 3-112, 3-114, 3-115, 3-116, 3-177, 4-24, 4-25, 4-26, 4-28, 4-29, 4-30, 4-31, 4-32, 4-33, 4-34, 4-37, 4-39, 4-40, 4-42, 4-43, 4-44, 4-47, 4-48, 4-50, 4-80, 4-81, 4-83, 4-86, 4-88, 4-114, 4-141, 4-142, 4-143, 4-144, 6-38, A-18, A-24, A-45, A-49, A-51, A-59, A-72, A-74, A-75, A-76, A-78, A-79, A-80, A-84, A-90, A-91, A-92, A-93, A-95, A-96, A-97, A-98, A-99, A-101, A-102, A-107, A-109, A-121, A-122, A-123, A-124, A-129, A-141, C-2
- Biscayne Bay9, 2-10, 3-1, 3-8, 3-9, 3-11, 3-12, 3-25, 3-26, 3-27, 3-34, 3-35, 3-36, 3-37, 3-38, 3-39, 3-40, 3-41, 3-43, 3-44, 3-45, 3-46, 3-54, 3-61, 3-62, 3-63, 3-64, 3-66, 3-67, 3-68, 3-69, 3-70, 3-71, 3-73, 3-74, 3-81, 3-84, 3-87, 3-89, 3-90, 3-91, 3-94, 3-97, 3-99, 3-100, 3-104, 3-105, 3-118, 3-124, 3-132, 3-133, 3-134, 3-142, 3-143, 3-145, 3-146, 3-149, 3-153, 3-154, 3-155, 3-161, 3-162, 3-163, 3-164, 4-8, 4-24, 4-25, 4-26, 4-28, 4-29, 4-30, 4-33, 4-34, 4-42, 4-43, 4-52, 4-57, 4-60, 4-64, 4-65, 4-77, 4-78, 4-79, 4-80, 4-81, 4-82, 4-83, 4-85, 4-86, 4-87, 4-88, 4-89, 4-94,

4-113, 4-143, 4-146, 4-147, 4-148, 6-3, 6-12, 6-16, 6-17, 6-18, 6-19, 6-21, 6-22, 6-24, 6-26, 6-27, 6-30, 6-42, 6-44, A-18, A-25, A-26, A-31, A-37, A-39, A-40, A-45, A-46, A-50, A-51, A-52, A-53, A-54, A-55, A-56, A-57, A-58, A-59, A-60, A-61, A-62, A-64, A-71, A-72, A-74, A-75, A-77, A-78, A-79, A-85, A-95, A-96, A-97, A-99, A-101, A-103, A-104, A-106, A-107, A-109, A-111, A-112, A-113, A-115, A-116, A-117, A-118, A-119, A-120, A-121, A-123, A-124, A-125, A-126, A-127, A-128, A-129, A-130, A-131, A-133, A-134, A-135, A-141, B-5, C-1, C-2

Biscayne National Park.....7, 9, 3-27, 3-31, 3-32, 3-38, 3-39, 3-131, 3-134, 3-164, 3-170, 3-174, 4-25, 6-30, 6-31, 6-39, 6-44, 8-3, A-32, A-38, A-50, A-53, A-54, A-57, A-58, A-64, A-83, A-85, A-88, A-97, A-98, A-99, A-106, A-125, A-127, A-130, A-133, A-134, A-135

C

Card Sound..... 3-1, 3-9, 3-34, 3-36, 3-37, 3-38, 3-39, 3-40, 3-41, 3-46, 3-54, 3-64, 3-66, 3-67, 3-68, 3-69, 3-70, 3-71, 3-72, 3-84, 3-97, 3-100, 3-105, 3-133, 3-134, 3-142, 3-143, 3-145, 3-153, 4-8, 4-24, 4-25, 4-57, 4-60, 4-64, 4-65, 4-81, 4-83, 4-88, 4-89, 4-147, A-18, A-25, A-26, A-39, A-40, A-42, A-46, A-51, A-52, A-55, A-56, A-57, A-58, A-59, A-94, A-95, A-99, A-106, A-107, A-113, A-115, A-116, A-117, A-120, A-123, A-125, A-126, A-127, A-128, B-5, C-2

chlorophyll..... 3-39, 3-40, 3-41, 3-57, 3-66, 6-28, A-79, A-125, A-126, A-127, A-128

chronic effect.....2-25, 4-107, 4-108, 4-110

Clean Air Act (CAA)xxiii, 3-28, 3-29, 4-18, 4-20, 4-127, 4-155, 6-2, 6-5, 6-9, B-3, B-4

climate change.....3-50, 4-19, 4-126, 4-130, 4-132, 4-136, 4-137, 4-138, 4-139, 4-144, 4-145, 4-147, 4-148, 4-149, 4-150, 4-152, 4-154, 4-155, 6-3, 6-41, A-21, A-24, A-26, A-27, A-28, A-29, A-30, A-31, A-32, A-33, A-34, A-35, A-36, A-38, A-40, A-41, A-42, A-43, A-44, A-47, A-48,

A-49, A-53, A-57, A-70, A-94, A-120, A-132, A-145, A-146, A-147

closed-cycle cooling.....2-8, 2-10, 2-11, 2-12, 2-13, 2-14, 3-4, 3-5, 3-9, 4-105, 4-106, A-21, A-42, A-74, A-102, A-121, A-124, A-137, A-138

Coastal Zone Management Act (CZMA).....xxiv, 3-26, 6-5, B-5, B-8

consumptive use..... 3-114, 4-138, A-60, B-9

cooling canal 3-1, 3-16, 3-47, 3-60, 3-62, 3-80, 3-168, 4-42, 4-49, 4-94, 6-23, A-17, A-19, A-20, A-22, A-24, A-31, A-37, A-42, A-50, A-53, A-65, A-70, A-83, A-95, A-96, A-97, A-99, A-101, A-110, A-112, A-114, A-115, A-119, A-129, A-131, B-8

cooling systemxix, xx, 7, 2-8, 3-13, 4-3, 4-4, 4-7, 4-27, 4-49, 4-50, 4-56, 4-61, 4-111, 4-121, A-56, A-140

cooling tower.....2-8, 2-10, 2-11, 2-12, 2-13, 2-14, 3-4, 3-8, 3-12, 3-47, 3-59, 4-1, 4-10, 4-11, 4-12, 4-13, 4-15, 4-16, 4-17, 4-18, 4-19, 4-20, 4-21, 4-40, 4-41, 4-43, 4-44, 4-45, 4-46, 4-47, 4-48, 4-54, 4-56, 4-66, 4-69, 4-92, 4-96, 4-97, 4-98, 4-99, 4-105, 4-106, 4-112, 4-116, 4-118, 4-121, 4-138, 5-1, A-17, A-18, A-19, A-20, A-21, A-22, A-23, A-24, A-42, A-47, A-62, A-91, A-101, A-110, A-118, A-130, A-131, A-134, A-136, A-137, A-138

core damage frequency (CDF).....E-5, E-7, E-9, E-10, E-16, E-18, E-21, E-23

Council on Environmental Quality (CEQ)xxiii, 4, 3-184, 3-185, 6-4, A-35, A-46, A-48, A-139, A-141, A-143

critical habitat2-25, 3-154, 4-8, 4-72, 4-88, 4-89, 4-90, A-66, B-6, C-1, C-2, C-1

cultural resource xx, 2-6, 2-25, 3-166, 3-168, 3-169, 4-7, 4-93, 4-95, 4-96, 4-97, 4-98, 4-99, 4-124, 4-150, A-70, A-73, B-1, B-7

D

decommissioningA-87

demography 2-7, 3-169, 3-172, 3-173, 4-132, 6-42, A-68

design-basis accident4-1, 4-108,
 A-12, E-1, E-2, E-3
 discharge..... 3-4, 3-5, 3-6, 3-8,
 3-12, 3-14, 3-15, 3-18, 3-22, 3-23, 3-34,
 3-37, 3-38, 3-40, 3-46, 3-51, 3-52, 3-54,
 3-59, 3-98, 3-100, 3-108, 3-111, 3-112,
 3-115, 3-134, 3-149, 3-182, 3-189, 4-24,
 4-27, 4-28, 4-30, 4-40, 4-41, 4-42, 4-52,
 4-53, 4-54, 4-61, 4-62, 4-64, 4-65, 4-67,
 4-78, 4-79, 4-81, 4-85, 4-88, 4-90, 6-24,
 A-25, A-37, A-38, A-51, A-74, A-79, A-81,
 A-85, A-92, A-106, A-110, A-116, A-120,
 A-121, A-124, A-125, A-132, B-1, B-9
 dose..... 3-15, 3-16, 3-17,
 3-18, 3-19, 3-182, 4-6, 4-80, 4-113,
 4-116, 4-156, B-2, E-10, E-20
 dredging 4-3, 4-4, 4-66, 4-78, 4-148, B-8

E

eastern indigo snake..... xx, xxi,
 2-25, 3-156, 3-161, 4-8, 4-70, 4-71, 4-74,
 4-93, A-67, A-68, C-1, C-2, C-3
 education.....3-165, 3-170,
 4-71, 4-100, 4-152, C-2
 effluent..... 3-14, 3-15, 3-16,
 3-17, 3-18, 3-19, 3-21, 3-22, 3-38, 3-58,
 3-105, 3-106, 3-181, 3-182, 3-189, 4-39,
 4-40, 4-45, 4-46, 4-47, 4-48, 4-64, 4-138,
 4-140, A-110, A-115, A-119, A-133
 electromagnetic field2-25, 3-180,
 4-7, 4-107, 4-108, 4-109, 4-110, 4-111
 endangered and threatened species..... 7,
 3-128, 3-129, 3-132, 3-134, 3-153, 3-154,
 3-159, 3-161, 4-33, 6-22, A-21, A-24,
 A-28, A-67, A-71, B-1, B-6, B-7, C-1
 Endangered Species Act (ESA) xxiv,
 7, 8, 2-6, 2-25, 3-134, 3-153, 3-154,
 3-155, 3-159, 3-161, 3-162, 4-51, 4-69,
 4-72, 4-75, 4-77, 4-78, 4-80, 4-86, 4-87,
 4-88, 4-89, 4-90, 4-91, 4-92, 4-93, 6-2,
 6-8, 6-23, 6-29, 6-36, 6-37, A-25, A-26,
 A-53, A-56, A-57, A-65, A-66, A-67, A-68,
 B-6, C-1, C-2, C-3, C-1
 entrainment xx, 2-23, 4-7,
 4-8, 4-56, 4-57, 4-58, 4-60, 4-61, 4-64,
 4-65, 4-67, 4-78, 4-113, 4-146, 6-25,
 A-120
 environmental justice (EJ)2-6, 3-184,
 3-185, 4-112, 4-113, 4-124, 4-152, 6-2,
 7-2, A-68

essential fish habitat (EFH)... xx, xxiv, 3-163,
 3-164, 4-7, 4-87, 4-89, 4-90, 4-91, 4-92,
 4-93, A-57, B-6, C-1
 eutrophication 4-4, 6-5, 6-24
 evaporative lossA-103, A-121

F

flooding..... 7, 2-18, 3-27, 3-34,
 3-38, 3-39, 3-46, 3-47, 3-49, 3-50, 3-119,
 3-133, 4-25, 4-81, 4-131, 4-135, 4-136,
 4-150, 6-14, 6-23, A-27, A-30, A-34, A-36,
 A-37, A-38, A-39, A-40, A-41, A-43, A-44,
 A-45, A-46, A-57, A-58, A-113, A-115,
 A-116, A-132, E-18, E-21
 Florida Department of Environmental
 Protection (FDEP) xxiv, 8,
 2-14, 3-26, 3-29, 3-30, 3-38, 3-39, 3-41,
 3-48, 3-49, 3-52, 3-53, 3-54, 3-55, 3-57,
 3-58, 3-61, 3-62, 3-63, 3-66, 3-67, 3-76,
 3-77, 3-78, 3-81, 3-82, 3-87, 3-98, 3-100,
 3-101, 3-102, 3-104, 3-105, 3-112, 3-113,
 3-114, 3-115, 3-118, 3-134, 3-139, 3-142,
 3-165, 3-189, 4-6, 4-16, 4-26, 4-28, 4-29,
 4-30, 4-31, 4-34, 4-35, 4-36, 4-39, 4-41,
 4-42, 4-43, 4-44, 4-45, 4-47, 4-48, 4-50,
 4-51, 4-52, 4-62, 4-63, 4-66, 4-81, 4-83,
 4-85, 4-88, 4-95, 4-112, 4-121, 4-136,
 4-137, 4-139, 4-141, 4-142, 4-143, 4-147,
 4-148, 6-11, 6-12, 6-13, 6-41, A-25, A-30,
 A-37, A-42, A-49, A-58, A-59, A-65, A-75,
 A-76, A-77, A-78, A-80, A-83, A-85, A-87,
 A-88, A-89, A-90, A-93, A-94, A-98,
 A-100, A-103, A-104, A-106, A-110,
 A-112, A-113, A-114, A-119, A-125,
 A-131, A-132, A-147, A-148, B-1, B-8,
 B-9, C-2
 Florida Power & Light Company..... iii,
 xvii, xix, 1, 2-2, 3-54, 3-169, 4-2, 5-1, 6-3,
 6-6, 6-11, 6-12, 6-13, 6-15, 6-16, 6-17,
 6-18, 6-19, 6-20, 6-21, 6-22, 6-25, 6-26,
 6-27, 6-31, 6-35, 6-40, 6-41, 8-5, 8-6, A-1,
 A-52, A-86, A-87, A-98, A-104, B-7, C-3,
 D-1, E-3
 Floridan aquiferxxviii, 3-8, 3-12,
 3-14, 3-47, 3-60, 3-62, 3-63, 3-64, 3-65,
 3-66, 3-72, 3-73, 3-75, 3-76, 3-77, 3-78,
 3-98, 3-101, 3-112, 3-113, 3-114, 3-115,
 3-116, 4-26, 4-32, 4-34, 4-35, 4-36, 4-37,
 4-40, 4-41, 4-43, 4-47, 4-113, 4-140,
 4-141, 4-142, 4-143, 4-144, A-47, A-48,

A-49, A-91, A-92, A-96, A-102, A-103,
A-107, A-112, A-118, A-128, A-129

G

Generic Environmental Impact Statement (GEIS)..... iii, xvii, xviii, xix, xxii, xxv, 3, 4, 5, 8, 2-2, 2-3, 2-4, 2-5, 2-6, 2-17, 2-26, 3-172, 3-183, 4-2, 4-3, 4-6, 4-7, 4-8, 4-9, 4-14, 4-21, 4-23, 4-24, 4-26, 4-27, 4-28, 4-30, 4-49, 4-50, 4-52, 4-54, 4-56, 4-57, 4-61, 4-78, 4-79, 4-80, 4-99, 4-107, 4-108, 4-109, 4-111, 4-119, 4-121, 4-122, 4-123, 4-124, 4-125, 4-128, 4-137, 5-1, 5-2, 6-32, 6-33, 6-34, 6-35, 6-37, A-1, A-12, A-35, A-56, A-58, A-74, A-82, A-86, A-87, A-120, A-124, A-126, A-132, D-4, D-5, E-1, E-2, E-3, E-4, E-5, E-6, E-7, E-8, E-9, E-10, E-11, E-12, E-13, E-14, E-15, E-16, E-17, E-18, E-21

green sea turtle2-25, 3-40, 3-66, 3-130, 3-136, 3-143, 3-162, 3-163, 4-8, 4-77, 4-78, 4-86, A-12, A-76, A-112, A-127, C-1

greenhouse gases 2-7, 2-11, 4-15, 4-16, 4-17, 4-18, 4-20, 4-116, 4-123, 4-126, 4-127, 4-128, 4-129, 4-132, 4-133, 4-134, 4-154, 4-155, 6-2, 6-9, A-31, A-38, A-41

groundwaterxix, xx, 7, 2-14, 2-22, 3-8, 3-10, 3-11, 3-12, 3-20, 3-21, 3-33, 3-34, 3-37, 3-38, 3-46, 3-50, 3-52, 3-53, 3-54, 3-55, 3-58, 3-59, 3-60, 3-61, 3-64, 3-67, 3-68, 3-69, 3-70, 3-71, 3-72, 3-74, 3-75, 3-76, 3-77, 3-78, 3-80, 3-81, 3-82, 3-84, 3-86, 3-87, 3-88, 3-90, 3-91, 3-92, 3-94, 3-95, 3-96, 3-97, 3-98, 3-99, 3-100, 3-101, 3-102, 3-104, 3-105, 3-106, 3-107, 3-108, 3-111, 3-112, 3-113, 3-114, 3-115, 3-116, 3-123, 3-126, 3-127, 3-142, 3-148, 3-150, 3-177, 3-181, 3-190, 4-2, 4-3, 4-6, 4-7, 4-23, 4-24, 4-25, 4-26, 4-27, 4-28, 4-29, 4-30, 4-31, 4-32, 4-33, 4-34, 4-35, 4-36, 4-37, 4-38, 4-39, 4-40, 4-41, 4-42, 4-43, 4-44, 4-45, 4-46, 4-47, 4-48, 4-49, 4-50, 4-51, 4-61, 4-80, 4-81, 4-82, 4-83, 4-84, 4-85, 4-86, 4-88, 4-109, 4-113, 4-114, 4-121, 4-124, 4-138, 4-140, 4-141, 4-142, 4-143, 4-144, 4-145, 4-153, 5-1, 6-9, 7-1, 7-3, A-18, A-21, A-22, A-23, A-25, A-26, A-42, A-47, A-48, A-49, A-50, A-51, A-52, A-54, A-55, A-56, A-59, A-74,

A-75, A-76, A-77, A-78, A-79, A-80, A-81, A-82, A-83, A-84, A-85, A-86, A-88, A-89, A-90, A-91, A-92, A-93, A-94, A-95, A-97, A-98, A-99, A-100, A-101, A-104, A-105, A-106, A-107, A-109, A-112, A-113, A-114, A-115, A-116, A-117, A-120, A-121, A-122, A-123, A-124, A-125, A-126, A-127, A-128, A-129, A-134, A-135, A-145, B-1, B-9, C-2, E-4

H

hawksbill sea turtle.....2-25, 3-155, 3-162, 3-163, 4-8, 4-77, 4-86, C-1

hazardous waste3-22, 3-182

heat shock..... 4-61

high-level waste 4-123

I

impingement.....2-23, 4-8, 4-56, 4-57, 4-58, 4-59, 4-60, 4-61, 4-64, 4-65, 4-67, 4-78, 4-113, 4-146, A-74

independent spent fuel storage installation (ISFSI).....xxv, 3-2, 3-20, 3-23, 4-78, 4-138, 4-139, 4-145, 4-147, 4-150, 4-151, 4-154, A-132, B-7

Indian tribe 8, 3-167, 3-184, 4-113, 7-2, A-69, B-7

interceptor ditch 3-10, 3-12, 3-59, 3-70, 3-71, 3-75, 3-80, 3-81, 4-49, 4-50, A-61, A-77, A-84, A-116, A-117

invasive species.....3-132, 3-153, 4-65, 4-67, 4-89, 4-91

L

L-31E Canal 3-12, 3-46, 3-50, 3-62, 3-64, 3-75, 3-81, 3-100, 3-104, 3-127, 4-33, 4-42, 4-145, A-36, A-60, A-90, A-116, D-5

leatherback sea turtle2-25, 3-155, 3-162, 3-163, 4-8, 4-77, 4-86, C-1

loggerhead sea turtle2-25, 3-155, 3-162, 4-8, 4-77, 4-86, C-1

low-level waste.....4-119, 4-123

M

Magnuson–Stevens Fishery Conservation and Management Act (MSA)..... xxvi, 7, 8,

2-6, 3-153, 3-163, 4-87, 4-91, 4-92, 4-93,
6-25, A-37, A-57, A-59, B-6, C-1, C-2
Miami-Dade County Division of
Environmental Resources Management
..... xxiv, 8, 3-69, 3-72,
3-81, 3-98, 3-99, 3-132, 4-6, 4-25, 4-30,
4-31, 4-34, 4-36, 4-41, 4-45, 4-48, 4-81,
4-82, 4-83, 4-85, 4-142, 4-143, 6-5, 6-19,
6-26, 6-27, 8-4, A-26, A-29, A-30, A-37,
A-42, A-52, A-83, A-84, A-86, A-88, A-89,
A-90, A-93, A-94, A-104, A-113, A-114,
A-116, A-126, A-139, B-10, B-11
mitigation.....xix, xxviii, 2, 4,
5, 6, 3-26, 3-65, 3-100, 3-104, 3-116,
3-132, 4-15, 4-25, 4-54, 4-55, 4-66, 4-82,
4-83, 4-84, 4-85, 4-103, 4-134, 4-140,
4-143, 4-146, 4-147, 4-148, 4-156, 5-1,
A-23, A-26, A-52, A-62, A-65, A-89, A-95,
A-102, A-114, A-130, A-131, A-137,
A-144, E-4, E-15, E-16, E-17, E-18, E-21
mixed waste 3-14
models..... 3-13, 3-16, 3-18,
3-37, 3-47, 3-64, 3-65, 3-80, 3-102,
3-105, 3-111, 4-26, 4-29, 4-30, 4-31,
4-33, 4-34, 4-35, 4-36, 4-37, 4-41, 4-126,
4-132, 4-133, 4-140, 4-141, 4-142, 4-144,
4-148, 4-154, 7-2, A-18, A-28, A-29, A-31,
A-32, A-37, A-38, A-40, A-41, A-46, A-47,
A-48, A-49, A-51, A-61, A-76, A-80, A-83,
A-84, A-85, A-87, A-89, A-90, A-91, A-92,
A-93, A-94, A-96, A-97, A-101, A-103,
A-121, A-144, E-5, E-6, E-7, E-17, E-19,
E-20, E-22

N

National Environmental Policy
Act (NEPA) xviii, xxvi, 1, 9,
2-1, 2-3, 2-13, 3-26, 3-167, 3-184, 4-6,
4-79, 4-86, 4-94, 4-109, 4-137, 5-1, 6-4,
6-28, 6-31, 6-32, 7-1, 7-2, 7-3, 8-4, A-1,
A-11, A-13, A-21, A-24, A-27, A-35, A-36,
A-41, A-42, A-43, A-46, A-47, A-48, A-49,
A-51, A-58, A-59, A-68, A-82, A-102,
A-120, A-131, A-137, A-138, A-139,
A-140, A-141, A-142, A-143, A-144, B-2,
B-3, C-1, C-2, E-3, E-4, E-6, E-15
National Marine Fisheries
Service (NMFS)..... xxvi, 7, 8,
2-25, 3-26, 3-154, 3-155, 3-161, 3-162,
3-163, 3-164, 4-8, 4-69, 4-77, 4-78, 4-79,

4-84, 4-86, 4-87, 4-89, 4-90, 4-91, 4-93,
6-2, 6-3, 6-23, 6-29, 6-34, 6-36, 6-37,
6-39, A-25, A-26, A-56, A-57, A-112,
A-131, B-6, C-1, C-2, C-1, D-3
National Marine Sanctuaries Act
(NMSA).....xxvii, 7, 8, 3-153,
3-165, 4-87, 4-88, 4-90, 4-91, 4-92, 4-93,
6-29, A-56, A-57, A-58, A-59, B-6, C-2
national park..... 3-30, A-21,
A-27, A-53, A-54, A-70, A-71, A-133,
A-134
National Pollutant Discharge Elimination
System (NPDES).....xxvii, 3-48,
3-49, 3-52, 3-53, 3-54, 3-182, 4-42, 4-43,
4-44, 4-47, 4-62, 4-66, 4-79, 4-85, 4-136,
4-137, 4-148, 6-1, 6-12, 6-13, A-30, A-39,
A-42, A-79, A-84, A-107, A-111, A-113,
A-114, A-119, A-121, A-147, A-148, B-1,
B-3, B-5, B-8
Native American tribes.....3-167, 4-96,
4-113, A-69
no-action alternative..... xxi, 2-1, 2-3,
2-4, 2-22, 2-23, 4-1, 4-9, 4-14, 4-22, 4-33,
4-40, 4-41, 4-44, 4-47, 4-53, 4-54, 4-64,
4-65, 4-67, 4-88, 4-89, 4-90, 4-96, 4-100,
4-109, 4-115, 4-119, 4-127, 4-128, 4-129,
4-157, 5-1, A-14, A-44, A-92, A-101,
A-130
nonattainment 3-29
nutrient 3-39, 3-40, 3-57,
3-58, 3-62, 3-64, 3-66, 3-67, 3-69, 3-70,
3-72, 3-81, 3-95, 3-96, 3-97, 3-99, 3-100,
3-102, 3-122, 3-123, 3-125, 3-137, 3-139,
3-142, 3-143, 3-144, 3-148, 3-149, 4-26,
4-82, 4-147, 6-10, 6-15, 6-24, 6-38, 6-41,
A-38, A-39, A-40, A-50, A-51, A-52, A-53,
A-55, A-56, A-79, A-95, A-96, A-105,
A-113, A-120, A-121, A-124, A-125,
A-126, A-127, A-129
nutrients 3-38, 3-39, 3-40,
3-41, 3-55, 3-57, 3-58, 3-62, 3-66, 3-69,
3-70, 3-71, 3-91, 3-95, 3-97, 3-119,
3-122, 3-125, 3-126, 3-137, 3-139, 3-143,
3-148, 4-25, 4-26, 4-40, 4-81, 4-83,
4-147, A-21, A-26, A-39, A-40, A-45,
A-50, A-51, A-52, A-53, A-56, A-96, A-99,
A-108, A-110, A-116, A-118, A-125,
A-126, A-127, A-134

O

once-through cooling xix, xx, 3-8,
4-3, 4-4, 4-7, 4-49, 4-50, 4-56, 4-61,
4-121, A-56

P

postulated accident.....4-1, 4-108,
A-11, E-1, E-3, E-7
power uprate 3-59, 3-81, 3-87,
3-90, 3-98, 3-118, 3-142, 3-169, 3-179,
4-28, 4-50, A-78, A-123, A-124, E-10,
E-22

R

radionuclide..... 3-21, 3-52, 3-105,
4-4, 4-38, 4-39, 4-79, 4-80, B-4, E-9
radon 3-20
reactor 1, 2-1, 2-9, 2-10,
2-14, 3-1, 3-4, 3-5, 3-23, 3-47, 3-101,
3-114, 3-162, 3-182, 4-152, 5-1, 6-6,
6-35, A-13, A-18, A-19, A-22, A-29, A-31,
A-32, A-35, A-40, A-42, A-63, A-99,
A-101, A-102, A-110, A-119, A-138,
A-140, A-141, A-144, B-2, E-5, E-11,
E-16, E-17, E-18, E-20
refurbishment..... 2-2, 2-3, 3-170,
4-8, 4-51, 4-99, 4-139
replacement power iii, xxi, 2-3,
2-4, 2-5, 2-6, 2-7, 2-10, 2-11, 2-12, 2-13,
2-15, 2-16, 2-21, 2-22, 2-23, 4-1, 4-10,
4-11, 4-12, 4-15, 4-16, 4-17, 4-18, 4-19,
4-20, 4-21, 4-22, 4-23, 4-41, 4-42, 4-44,
4-45, 4-46, 4-54, 4-55, 4-56, 4-65, 4-66,
4-67, 4-68, 4-69, 4-90, 4-91, 4-92, 4-96,
4-97, 4-98, 4-101, 4-102, 4-110, 4-111,
4-115, 4-116, 4-118, 4-119, 4-120, 4-121,
4-123, 4-124, 4-126, 4-128, 4-155, A-13,
A-14, A-15, A-16, A-17, A-23, A-44, A-58,
A-92, A-101, A-141
right-of-way 2-9, 2-11, 2-12,
4-4, 4-11, 4-12, 4-44, 4-55, 4-66, 4-103,
A-15
runoff 3-37, 3-38, 3-40,
3-46, 3-66, 3-71, 3-73, 3-74, 3-118,
3-149, 4-40, 4-44, 4-47, 4-52, 4-54, 4-66,
4-130, 4-144, 4-146, 4-148, A-37, A-40,
A-106, A-117, A-127, B-5

S

salinity gradient 3-139, 4-24
scoping iii, xvii, xviii, xix,
xxii, 2, 6, 3-25, 3-31, 3-168, 4-2, 4-9,
4-14, 4-26, 4-79, 4-94, 4-114, 4-122,
4-138, 4-139, 5-2, 6-3, 6-31, A-1, A-23,
A-69, A-137, A-139, C-3, D-1, E-3, E-8,
E-9, E-10, E-11, E-12, E-13
sea grass..... A-53, A-99
seismic 3-31, 3-32, E-8,
E-9, E-18, E-22
severe accident.....4-1, 4-108,
4-109, 4-113, A-12, A-147, E-1, E-3, E-4,
E-5, E-6, E-7, E-8, E-9, E-11, E-13, E-14,
E-15, E-16, E-17, E-21, E-23
severe accident mitigation alternatives
(SAMA) xvii, xix, xxii, xxviii,
2, 4-109, 6-28, 6-36, 7-1, A-10, A-11,
A-44, A-147, E-4, E-5, E-6, E-7, E-8, E-9,
E-10, E-11, E-12, E-13, E-14, E-15, E-16,
E-17, E-18, E-19, E-20, E-21, E-22, E-23
sewage 3-2, 3-14, 3-22,
3-38, 3-40, 3-51, 3-115, 6-24, A-18, A-20,
A-22, A-112, A-117, A-118, A-127
smalltooth sawfish..... 2-25, 3-134,
3-162, 3-163, 4-8, 4-77, 4-78, 4-80, 4-84,
4-85, 4-86, 4-87, A-25, A-26, C-1
solid waste 3-15, 3-19, 4-121, 4-123
spent fuel..... xix, 4, 2-26, 3-13,
3-17, 3-20, 3-23, 4-5, 4-38, 4-124, 4-151,
4-154, A-132, A-133, B-7, E-12, E-16
State Historic Preservation
Office (SHPO) 2-25, 3-167, 8-1, 8-6
stormwater 3-1, 3-48, 3-52,
3-80, 3-189, 4-40, 4-42, 4-43, 4-44, 4-47,
4-50, 4-52, 4-53, 4-66, 4-148, 6-12, 6-24,
A-38, B-5
surface water..... 7, 3-5, 3-9, 3-10,
3-12, 3-21, 3-33, 3-34, 3-35, 3-39, 3-46,
3-48, 3-51, 3-52, 3-53, 3-54, 3-55, 3-57,
3-64, 3-66, 3-67, 3-68, 3-69, 3-70, 3-71,
3-72, 3-74, 3-88, 3-99, 3-100, 3-101,
3-104, 3-105, 3-106, 3-111, 3-134, 3-135,
3-137, 3-139, 3-142, 3-143, 3-163, 3-165,
3-190, 4-3, 4-8, 4-23, 4-24, 4-25, 4-26,
4-33, 4-40, 4-41, 4-43, 4-45, 4-46, 4-52,
4-58, 4-60, 4-61, 4-64, 4-65, 4-78, 4-79,
4-80, 4-81, 4-82, 4-83, 4-84, 4-85, 4-86,
4-88, 4-113, 4-114, 4-124, 4-138, 4-144,
4-146, 4-147, 6-24, 7-1, 7-3, A-21, A-25,

A-37, A-38, A-39, A-40, A-46, A-50, A-51, A-53, A-55, A-56, A-59, A-60, A-74, A-75, A-79, A-85, A-88, A-90, A-91, A-94, A-95, A-97, A-98, A-99, A-100, A-103, A-104, A-105, A-108, A-112, A-113, A-114, A-115, A-116, A-117, A-118, A-120, A-121, A-122, A-123, A-124, A-125, A-126, A-127, A-129, A-134, A-135, A-145, A-147, B-1, B-9, C-1, C-2

T

taxes..... 3-178, 3-179, 3-180, 4-102, 4-103, 4-106, 4-150
transmission line 2-6, 2-9, 2-10, 2-11, 2-12, 2-17, 2-21, 3-8, 3-23, 3-131, 3-183, 4-3, 4-4, 4-6, 4-9, 4-10, 4-51, 4-53, 4-54, 4-94, 4-108, A-15, A-17, A-23, A-137
tritium..... 3-21, 3-55, 3-67, 3-69, 3-72, 3-77, 3-82, 3-84, 3-87, 3-88, 3-89, 3-90, 3-91, 3-92, 3-94, 3-95, 3-97, 3-105, 3-106, 3-107, 3-108, 3-109, 3-111, 3-126, 4-29, 4-30, 4-38, 4-39, 4-80, 4-85, 4-86, 4-88, 4-114, 6-8, A-37, A-39, A-51, A-56, A-59, A-94, A-95, A-104, A-108, A-112, A-116, A-117, A-121, A-126, A-133, C-2

U

U.S. Army Corps of Engineers xxviii, 4-66, 4-91, 4-92, 4-93, 4-135, 4-148, 6-42, A-27, A-28, A-29, A-30, A-92, A-112, B-5, B-8
U.S. Department of Energy (DOE) xxiv, 2-5, 2-9, 2-10, 2-13, 2-15, 2-16, 2-18, 2-19, 2-20, 2-21, 3-20, 4-17, 4-19, 4-80, 4-85, 4-107, 4-129, 4-139, 4-151, 6-5, 6-6, 6-7, 6-29
U.S. Environmental Protection Agency (EPA) xxiv, 8, 2-5, 2-19,

2-22, 3-15, 3-16, 3-17, 3-18, 3-21, 3-26, 3-28, 3-29, 3-30, 3-52, 3-55, 3-66, 3-78, 3-91, 3-106, 3-143, 3-172, 3-182, 3-189, 4-18, 4-19, 4-29, 4-38, 4-39, 4-79, 4-82, 4-84, 4-85, 4-86, 4-88, 4-110, 4-114, 4-126, 4-127, 4-130, 4-131, 4-133, 4-137, 4-140, 4-151, 4-153, 4-154, 4-155, 4-156, 6-2, 6-4, 6-8, 6-9, 6-10, 8-4, A-1, A-2, A-7, A-15, A-27, A-28, A-30, A-43, A-44, A-45, A-46, A-54, A-57, A-59, A-62, A-63, A-68, A-83, A-88, A-90, A-91, A-92, A-112, A-113, A-120, A-121, A-125, A-126, A-127, A-131, A-139, A-147, A-148, B-1, B-3, B-4, B-5, B-6, C-2, D-4, E-6
U.S. Fish and Wildlife Service (FWS)..... xxi, xxv, 7, 8, 9, 2-25, 3-26, 3-129, 3-130, 3-131, 3-154, 3-155, 3-156, 3-157, 3-158, 3-159, 3-160, 4-8, 4-55, 4-69, 4-70, 4-71, 4-72, 4-73, 4-75, 4-86, 4-89, 4-90, 4-91, 4-93, 6-2, 6-3, 6-22, 6-23, 6-34, 6-35, 6-36, 6-37, 8-6, 8-7, A-26, A-56, A-57, A-64, A-65, A-66, A-67, A-68, A-112, A-131, B-6, B-8, C-1, C-2, C-3, C-1, D-3
U.S. National Park Service (NPS) iii, xxvii, 2, 7, 8, 3-37, 3-38, 3-39, 3-66, 3-67, 3-70, 3-127, 3-131, 3-132, 3-171, 3-174, 6-30, 6-31, 8-2, 8-3, 8-4, A-10, A-36, A-51, A-53, A-60, A-62, A-63, A-64, A-65, A-66, A-72, A-94, A-95, A-106, A-112, A-124, A-125, A-127, A-130, A-135, A-136, D-2, D-4, D-5
uranium 4-5, 4-123, 4-124, 4-125

W

wastewater 3-21, 3-22, 3-52, 3-98, 3-112, 3-116, 4-36, 4-143, 6-11, A-97
water balance 3-13, A-121

APPENDIX A

COMMENTS RECEIVED ON THE TURKEY POINT NUCLEAR GENERATING UNITS 3 AND 4 ENVIRONMENTAL REVIEW

A.1 Comments Received During the Scoping Period

The scoping process for the environmental review of the Turkey Point Nuclear Generating Unit Nos. 3 and 4 (Turkey Point, or Turkey Point Units 3 and 4) subsequent license renewal began in May 2018, in accordance with the National Environmental Policy Act of 1969 (42 U.S.C. 4321 et seq.) (NEPA). On May 14, 2018, the U.S. Nuclear Regulatory Commission (NRC) issued a notice of intent to prepare an environmental impact statement and conduct an environmental scoping process for subsequent license renewal of Turkey Point; that notice was published in the *Federal Register* (FR) on May 14, 2018 (83 FR 23726). The scoping process included two public meetings held in Homestead, FL, on May 31, 2018. The NRC issued a press release and purchased newspaper advertisements to advertise the two public meetings. In addition to participation by the applicant, Florida Power & Light Company (FPL), and local officials, several members of the public attended the meetings. After the NRC staff presented prepared statements on the subsequent license renewal process, the staff opened the meetings for public comments. Attendees were provided the opportunity to make oral statements that were recorded and transcribed by a certified court reporter. A summary and transcripts of the scoping meetings are available in the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams.html>. The scoping meetings summary is available at ADAMS Accession No. ML18176A404. The transcripts of the meetings are available at ADAMS Accession No. ML18176A399 for the afternoon session and No. ML18176A401 for the evening session. In addition to comments received during the public meetings, comments were also received electronically and through the mail.

The NRC received numerous comments during the scoping process which identified many important issues that were addressed by the NRC staff in this draft supplemental environmental impact statement (SEIS) for Turkey Point's subsequent license renewal. The scoping summary report provides the NRC staff's responses to comments received as part of the Turkey Point environmental scoping process and is available at ADAMS Accession No. ML18342A014 (NRC 2019a).

A.2 Comments Received on the Draft SEIS

On March 31, 2019, the NRC issued the "Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4 (NUREG-1437, Supplement 5, Second Renewal), Draft Report for Comment," referred to as the draft SEIS, to Federal, Tribal, State, and local government agencies and interested members of the public. The Environmental Protection Agency (EPA) issued its Notice of Availability on April 5, 2019 (84 FR 13662). The public comment period continued for 45 days and ended on May 20, 2019. As part of the process to solicit public comments on the draft SEIS, the NRC did the following:

- placed copies of the draft SEIS at the following public libraries:
 - Homestead Branch Library in Homestead, FL
 - Naranja Branch Library in Homestead, FL

- South Dade Regional Library in Miami, FL
- Downtown Miami Branch in Miami, FL
- made a copy of the draft SEIS available in the NRC's Public Document Room in Rockville, Maryland;
- placed a copy of the draft SEIS on the NRC website at: <https://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1437/supplement5-slr/>
- provided a copy of the draft SEIS to any member of the public that requested one;
- sent copies of the draft SEIS to certain Federal, Tribal, State, and local government agencies;
- published a notice of availability of the draft SEIS in the *Federal Register* on April 4, 2019 (84 FR 13322);
- filed the draft SEIS with the EPA; and
- announced and held two public meetings at the City of Homestead City Hall, on May 1, 2019, to describe the preliminary results of the environmental review, answer any related questions, and take public comments.

Approximately 50 people attended the meetings, and 25 attendees provided oral and written comments. A certified court reporter recorded the oral comments and prepared written transcripts of the meeting. A meeting summary is available in the NRC's Agencywide Documents Access and Management System (ADAMS) (Accession No. ML19148A471).

In addition to the comments received at the public meetings, the NRC received almost 5,000 comments from letters, e-mails, and through regulations.gov, including almost 500 unique comments. To identify each individual comment, the NRC staff reviewed the transcripts of the public meetings, and each letter, e-mail, and regulations.gov submittal related to the draft SEIS, all of which are accessible in ADAMS. The NRC staff identified statements related to the proposed action and recorded the statements as comments.

Comments submitted during the comment period and their associated correspondence received a specific comment identification number consisting of the correspondence identification number and a number associated with the sequential order of the comment within the specific document. Table A-1 below lists individuals that provided comments during the comment period, including their affiliation (if available), the ADAMS Accession No. of their comment, their associated correspondence identification number, and the section of the Comment Response Report that contains the NRC staff's responses to their comments. Table A-2 is the Comment Response Report. It lists the comment categories, the commenters, their comments, and the staff's responses to their comments.

Many individuals submitted a generic campaign letter sponsored by the National Parks Conservation Association and were considered as Correspondence ID 0003. The list of individuals who submitted this letter can be found in ADAMS (Accession No. ML19246A710).

The Comment Response Report includes Sections A.2.1 through A.2.26 below.

Table A-1 Individuals Providing Comments During the Comment Period

Commenter	Affiliation (if stated)	Comment Source and Document ID	Correspondence ID	Comment Section
Aldrich, Johnnie		Email (ML19149A706)	0067	A.2.24
Altfater, Valerie		Email (ML19147A062)	0052	A.2.5
Aurigemma, Kaye		Email (ML19153A083)	0117	A.2.20
Ayres, Richard E.	Ayres Law Group LLP	reg.gov (ML19141A253)	0021	A.2.3, A.2.4, A.2.6, A.2.18, A.2.19
Baer, Robin		Email (ML19151A580)	0086	A.2.16
Bard, Brenda		Email (ML19153A305)	0146	A.2.20
Barghahn, Serena		Email (ML19146A107)	0040	A.2.20
Barstad, Cynthia		Email (ML19153A267)	0124	A.2.8
Battelli, Tony		Email (ML19149A648)	0065	A.2.4
Beauchamp, Kristin		Email (ML19146A331)	0047	A.2.16
Beigel, Lynda		Email (ML19151A756)	0088	A.2.20
Bender, Kae		Email (ML19150A740)	0075	A.2.4
Black, Kerry	South Dade Chamber of Commerce	Meeting Transcript (ML19141A157)	0001-2	A.2.16, A.2.21
Blackstone, Linore		Email (ML19152A224)	0099	A.2.6
Blazier, Thomas		Email (ML19147A098)	0054	A.2.26
Block, Emily		Email (ML19147A103)	0055	A.2.25, A.2.26
Bloom, Mary		Email (ML19147A010)	0032	A.2.3, A.2.4, A.2.11, A.2.12, A.2.13, A.2.16, A.2.18
Bloom, Mary		Email (ML19153A522)	0073	A.2.18
Bloom, Mary		Meeting Transcript (ML19141A157)	0001-9	A.2.4, A.2.8, A.2.11
Bratcher, Suzanne		Email (ML19152A266)	0100	A.2.4
Broms, Sharon		Email (ML19144A149)	0030	A.2.4
Brown, Linda		Email (ML19152A082)	0094	A.2.2, A.2.8
Brusin, Eugene		Email (ML19139A025)	0007	A.2.18

Commenter	Affiliation (if stated)	Comment Source and Document ID	Correspondence ID	Comment Section
Buck, Julia		Email (ML19151A145)	0082	A.2.4
Casalone, Virginia		Email (ML19153A613)	0131	A.2.16
Case, Karen		Email (ML19154A542)	0139	A.2.15
Champy, Cheryl		Email (ML19146A289)	0046	A.2.4, A.2.11
Charles, David		Email (ML19150A782)	0077	A.2.2
Chesnut, Joanna		Email (ML19147A036)	0050	A.2.12
Cochrane, Theodore		Email (ML19147A032)	0049	A.2.8
Cochrane, Theodore		reg.gov (ML19137A306)	0016	A.2.4, A.2.12
Cody, Jeff		Email (ML19153A257)	0123	A.2.6
Commenters, Multiple		Email (ML19137A176)	0003	A.2.4, A.2.11, A.2.18, A.2.20
Conley, Cristen		Email (ML19150A054)	0069	A.2.20
Cox, Kelly	Miami Waterkeeper	reg.gov (ML19141A253)	0021	A.2.3, A.2.4, A.2.6
Crupi, Kevin		Email (ML19145A201)	0143	A.2.4
Culberson, Ina		Email (ML19153A206)	0121	A.2.18
Dempsey, Kelley		Email (ML19151A763)	0089	A.2.8
Denton, April		Email (ML19153A440)	0152	A.2.20
Dick, Marianne		Email (ML19144A017)	0027	A.2.11
Dickinson, Vicki		Email (ML19152A498)	0106	A.2.12
Drewelow, Beth		Email (ML19146A047)	0037	A.2.16
Dunn, Leslene		Email (ML19154A200)	0140	A.2.26
Eikholt, Michele		Email (ML19151A021)	0078	A.2.4
Elmo, Francesca		Email (ML19142A016)	0014	A.2.4
Fangman, Sarah	Florida Keys National Marine Sanctuary	reg.gov (ML19141A054)	0018	A.2.3, A.2.4, A.2.6, A.2.18
Farber, Carol		Email (ML19153A319)	0147	A.2.11
Fettus, Geoffrey H.	Natural Resources Defense Council	reg.gov (ML19141A253)	0021	A.2.3, A.2.4, A.2.6

Commenter	Affiliation (if stated)	Comment Source and Document ID	Correspondence ID	Comment Section
Fleener, Teresa		Email (ML19147A124)	0056	A.2.4
Foerste, Eleanor		Email (ML19151A165)	0083	A.2.20
Ford, Patricia		Email (ML19145A177)	0142	A.2.6
Foster, Delaina		Email (ML19153A661)	0132	A.2.16
Friedman, Steve		Meeting Transcript (ML19141A157)	0001-11	A.2.6, A.2.12, A.2.18, A.2.20
Gomez, Albert		Meeting Transcript (ML19141A157)	0001-15	A.2.18
Gomez, Albert		reg.gov (ML19141A057)	0020	A.2.4, A.2.6, A.2.11, A.2.12, A.2.18, A.2.24
Goodale, Margaret		Email (ML19154A713)	0135	A.2.4
Goppert, Donald		Email (ML19152A384)	0103	A.2.8
Gould, Kyle		reg.gov (ML19129A088)	0006	A.2.18, A.2.25
Grace, Donna		Email (ML19153A455)	0153	A.2.6
Graffagnino, Mary Ann and Frank		Email (ML19152A071)	0093	A.2.20
Greene, J		Email (ML19139A080)	0010	A.2.4, A.2.20
Greene, William		Email (ML19154A628)	0137	A.2.4
Greenfield, Judy		Email (ML19153A057)	0115	A.2.20
Guest, David		Meeting Transcript (ML19141A139)	0002-4	A.2.12
Guest, David		Meeting Transcript (ML19141A157)	0001-17	A.2.3, A.2.11, A.2.12, A.2.20
Gurtner, David		Email (ML19143A444)	0026	A.2.4, A.2.22
Gutierrez, Vivian	League of Women Voters	Meeting Transcript (ML19141A139)	0002-2	A.2.2, A.2.6, A.2.11, A.2.24
Guy, Peter		Email (ML19146A141)	0042	A.2.8
Hall, Gilbert		Email (ML19154A714)	0134	A.2.20
Hamory, Ann		Email (ML19154A655)	0136	A.2.16
Hangartner, Terry		Email (ML19145A118)	0145	A.2.11
Harris, Susan		Email (ML19153A483)	0154	A.2.11
Hartman, Richard		Email (ML19139A072)	0009	A.2.8

Commenter	Affiliation (if stated)	Comment Source and Document ID	Correspondence ID	Comment Section
Hefty, Lee N.	Miami-Dade County Division of Environmental Resources Management	Email (ML19147A229)	0022	A.2.4, A.2.11, A.2.12, A.2.18
Hildebrandt, Todd		Email (ML19152A056)	0092	A.2.20
Hogan, Cynthia		Email (ML19153A387)	0149	A.2.20
Horton-Diaz, Daniel		Meeting Transcript (ML19141A157)	0001-1	A.2.3, A.2.8
Hostler, Joyce		Email (ML19153A593)	0129	A.2.12
Hummel, Lani		Email (ML19152A213)	0098	A.2.8
Janzen, Gayle		Email (ML19152A409)	0104	A.2.4, A.2.20
Jimenez, Nathan		Email (ML19149A658)	0066	A.2.2, A.2.26
Kalman, Sherri		Email (ML19153A520)	0125	A.2.20
Kick, Anna		Email (ML19153A116)	0118	A.2.15
Kindred, Dorothy		Email (ML19153A009)	0113	A.2.6
King, Christian		Email (ML19151A082)	0080	A.2.24
King, Terry		Email (ML19146A012)	0036	A.2.18
Kirschbaum, Saran		Email (ML19152A335)	0102	A.2.20
Kisor, Dave		Email (ML19153A222)	0122	A.2.4
Kuttner, Paula		Email (ML19146A005)	0035	A.2.22
Lambert, Sandra		Email (ML19151A630)	0087	A.2.20
Laslie, Maude		Email (ML19153A129)	0119	A.2.24
Lewis, Nora		Email (ML19147A079)	0053	A.2.20
Lion, Sue		Email (ML19145A301)	0034	A.2.4
List, Gary	Ocean Reef Community Association	Email (ML19155A205)	0024	A.2.4, A.2.11, A.2.12, A.2.22, A.2.25
Loerke, Alison		Email (ML19145A000)	0144	A.2.2, A.2.16, A.2.20
Lotz, Elizabeth		Email (ML19146A139)	0041	A.2.4
Lukowski, Stasa		Email (ML19144A119)	0029	A.2.8, A.2.22

Commenter	Affiliation (if stated)	Comment Source and Document ID	Correspondence ID	Comment Section
Luzum, Rosemary		Email (ML19152A582)	0109	A.2.4, A.2.11
Macraith, Bonnie		Email (ML19147A385)	0059	A.2.4
Maher, William	Florida Power and Light	reg.gov (ML19141A047)	0017	A.2.2, A.2.3, A.2.6, A.2.10, A.2.11, A.2.12, A.2.13, A.2.14, A.2.15, A.2.16, A.2.17, A.2.18
Makofske, William		Email (ML19149A527)	0064	A.2.24
Manganello, Marilyn		Email (ML19153A404)	0150	A.2.24
Matthews, Ellyn		Email (ML19144A020)	0028	A.2.4
Mazzuca, Rich		Email (ML19153A541)	0127	A.2.16
Mcbride, Margaret		Email (ML19152A658)	0112	A.2.4
McCorry, Eileen		Email (ML19151A093)	0081	A.2.16
McDonald, John		Email (ML19148A103)	0063	A.2.1
McFall, Cynthia		Email (ML19153A361)	0148	A.2.24
McLaughlin, Caroline	National Parks Conservation Association	Email (ML19147A145)	0023	A.2.4, A.2.6, A.2.11, A.2.18
McLaughlin, Caroline	National Parks Conservation Association	Meeting Transcript (ML19141A157)	0001-8	A.2.3, A.2.4, A.2.8, A.2.11, A.2.12
Meyer, Roger		Email (ML19147A013)	0048	A.2.12
Militscher, Christopher	U.S. Environmental Protection Agency	reg.gov (ML19157A200)	0031	A.2.2, A.2.4, A.2.6, A.2.7, A.2.11, A.2.12, A.2.13, A.2.18
Miller, Jane		Email (ML19153A555)	0128	A.2.2, A.2.23
Miller-Richardson, Gail		Email (ML19153A603)	0130	A.2.20
Mills, Terri		Email (ML19147A054)	0051	A.2.8
Monfredini, Janet		Email (ML19146A260)	0045	A.2.20

Commenter	Affiliation (if stated)	Comment Source and Document ID	Correspondence ID	Comment Section
Morra, Frank		Meeting Transcript (ML19141A157)	0001-6	A.2.11
Moses, Dorothy		Email (ML19135A652)	0004	A.2.4, A.2.6, A.2.11, A.2.20
Mullray, Eileen		Meeting Transcript (ML19141A157)	0001-5	A.2.3
Nilon, Michael		Email (ML19153A236)	0072	A.2.4, A.2.6
Nye, Janet		Email (ML19146A105)	0039	A.2.6
Ortman, Nancy		Email (ML19148A051)	0062	A.2.24
Parker, Sue		Email (ML19152A568)	0108	A.2.20
Pierce, Barbara	League of Women Voters	Meeting Transcript (ML19141A157)	0001-4	A.2.2, A.2.6, A.2.11, A.2.24
Platero, Tracy		Email (ML19152A102)	0095	A.2.19
Propen, Beverly		Email (ML19139A050)	0008	A.2.4, A.2.11
Puca, Rob		Email (ML19140A023)	0011	A.2.4, A.2.11
Raymond, Wendy		Email (ML19146A155)	0043	A.2.20
Rees, Janet		Email (ML19140A513)	0013	A.2.4
Reiser, Reba		Email (ML19146A228)	0044	A.2.8
Reynolds, Laura		reg.gov (ML19151A729)	0071	A.2.6, A.2.12
Reynolds, Laura	Florida Keys Fishing Guides Association	Meeting Transcript (ML19141A139)	0002-5	A.2.6, A.2.11, A.2.12
Reynolds, Laura	Florida Keys Fishing Guides Association	Meeting Transcript (ML19141A157)	0001-13	A.2.3, A.2.6, A.2.11, A.2.16
Riparetti-Stepien, Melissa		Email (ML19147A423)	0061	A.2.4
Rippingille, Bonnie		Meeting Transcript (ML19141A139)	0002-6	A.2.4, A.2.6, A.2.11, A.2.12, A.2.16, A.2.18, A.2.25, A.2.26
Rippingille, Bonnie		Meeting Transcript (ML19141A157)	0001-14	A.2.3, A.2.11, A.2.12, A.2.16, A.2.18, A.2.25

Commenter	Affiliation (if stated)	Comment Source and Document ID	Correspondence ID	Comment Section
Robinson Ford, Florence		Email (ML19138A039)	0015	A.2.24, A.2.26
Robinson, Janet		Email (ML19151A504)	0084	A.2.2
Rumelt, Kenneth J.	Environment & Natural Resources Law Clinic, Vermont Law School	reg.gov (ML19141A253)	0021	A.2.3, A.2.4, A.2.6
Rushmer, Vera		Email (ML19145A291)	0033	A.2.16
S, C		Email (ML19147A419)	0060	A.2.20
Salomon Miceli, Lynne		Email (ML19140A496)	0012	A.2.24
Sanford, Ken		Email (ML19151A031)	0079	A.2.6
Schettini, Naomi		reg.gov (ML19141A056)	0019	A.2.2
Schievelbein, Tom		Meeting Transcript (ML19141A157)	0001-3	A.2.3, A.2.11
Schoedinger, Steven		Meeting Transcript (ML19141A157)	0001-16	A.2.11, A.2.12
Schoemer, Richard		Email (ML19154A566)	0138	A.2.2
Schuble, Sue		Email (ML19153A431)	0151	A.2.6
Schulman, Stacie		Meeting Transcript (ML19141A157)	0001-10	A.2.4
Scotty, Vee		Email (ML19147A216)	0057	A.2.8
Seamon, Jeffrey		Email (ML19152A210)	0097	A.2.20
Seimer, Priscilla		Email (ML19150A020)	0068	A.2.4
Sheridan, Michelle		Email (ML19151A562)	0085	A.2.20
Shoedinger, Steve		Meeting Transcript (ML19141A139)	0002-1	A.2.3, A.2.11
Sieger, Brenda		Email (ML19152A596)	0110	A.2.11
Silverstein, Rachel	Miami Waterkeeper	Meeting Transcript (ML19141A157)	0001-7	A.2.4, A.2.11, A.2.15
Sramek, Jo-Ann		Email (ML19154A729)	0133	A.2.8
Steele, Jody		Meeting Transcript (ML19141A139)	0002-3	A.2.3
Streit, Chris		Meeting Transcript (ML19141A157)	0001-12	A.2.3
Talbot, Thomas		Email (ML19150A274)	0070	A.2.2, A.2.4

Commenter	Affiliation (if stated)	Comment Source and Document ID	Correspondence ID	Comment Section
Talbott, Diana		Email (ML19150A703)	0074	A.2.20
Van Walsen, Barbara		Email (ML19152A167)	0096	A.2.1
Villablanca, Judith		Email (ML19147A378)	0058	A.2.24
Vogel, Robert	National Park Service	reg.gov (ML19143A166)	0005	A.2.5, A.2.6, A.2.9, A.2.11, A.2.12, A.2.13, A.2.16
Von Bargen, Donna		Email (ML19151A918)	0090	A.2.20
Waltz, Mike		Email (ML19153A184)	0120	A.2.4
Wartman, Janet		Email (ML19142A472)	0025	A.2.6
Waters, Lynn		Email (ML19153A032)	0114	A.2.8
Webb, Ann		Email (ML19146A062)	0038	A.2.15
Webster, Pamela		Email (ML19153A082)	0116	A.2.4
Wesolowski, Pam		Email (ML19150A752)	0076	A.2.11, A.2.24
Wieliczko, Julie		Email (ML19152A532)	0107	A.2.2
Williams, David		Email (ML19151A521)	0141	A.2.1, A.2.4
Wingle, Dennis		Email (ML19152A427)	0105	A.2.2, A.2.16
Worden, Susan		Email (ML19152A275)	0101	A.2.20
Wright, Steven		Email (ML19151A937)	0091	A.2.24
Zavah, Barry		Email (ML19152A645)	0111	A.2.1
Zimmerman, Katherine		Email (ML19153A527)	0126	A.2.2

Table A-2 Comment Categories

A.2.1 Postulated Accidents and Severe Accident Mitigation Alternatives (SAMA)
A.2.2 Alternatives-Replacement Power and No Action
A.2.3 Alternatives-Technology and Mitigation
A.2.4 Climate Change
A.2.5 Cumulative Impacts
A.2.6 Ecological Resources
A.2.7 Environmental Justice
A.2.8 General Environmental Concerns
A.2.9 Geology and Soils
A.2.10 Historic and Cultural Resources

A.2.11 Groundwater Hydrology and Quality
A.2.12 Surface Water Hydrology and Quality
A.2.13 Land Use and Visual Resources
A.2.14 Nonradioactive Waste
A.2.15 Radioactive Waste
A.2.16 Socioeconomics
A.2.17 Editorial
A.2.18 License Renewal Process
A.2.19 NEPA Process
A.2.20 Opposition to License Renewal
A.2.21 Support of License Renewal
A.2.22 Outside Scope-Aging Management
A.2.23 Outside Scope-Energy Costs
A.2.24 Outside Scope-Safety Concerns
A.2.25 Outside Scope-Other Non-LR Actions
A.2.26 Outside Scope-Other Topics

A.2.1 Postulated Accidents and Severe Accident Mitigation Alternatives (SAMA)

Comment: The Gulf of Mexico and its bordering states have suffered a horrific blow with the Deep Water Horizon explosion and subsequent catastrophic oil spill. Florida did not escape unharmed which is why we do not need another man made disaster anywhere near Florida and its waterways. (0063-1 [Mcdonald, John])

Comment: We got lucky at Three Mile Island. Chernobyl will be unlivable for centuries. Fukushima was done in by a tidal wave that should have been accounted for but wasn't, and is taking years to clean up. (0141-2 [Williams, David])

Comment: You really need to check what has happened around the world when problems happen by damaged nuclear power plants and their surrounding land and water. (0096-1 [Van Walsen, Barbara])

Comment: I mean it sincerely ... but after 3 Mile Island, Chernobyl and more disasters that tend to make the papers, https://en.wikipedia.org/wiki/Lists_of_nuclear_disasters_and_radioactive_incidents why add more to the risk pool? Supporters say it is "cleaner". Maybe while 'on-line", but tell us again the risk vs. benefit analysis much like taking a prescription medicine or a risky surgery? (0111-1 [Zavah, Barry])

Response: *The NRC staff recognizes the concerns held by members of the public about the safety of nuclear power. The NRC is dedicated to ensuring the safety of nuclear power plants, in accordance with its statutory mandate under the Atomic Energy Act of 1954, as amended, through a rigorous licensing and reactor oversight program. In addition, the NRC staff evaluates the environmental impacts of nuclear reactor operation in accordance with the National Environmental Policy Act of 1969, as amended, including the preparation of environmental impact statements such as this SEIS. The staff assesses the potential environmental impacts of postulated accidents in Section 4.11.1 and Appendix E of the SEIS in accordance with Commission policy statements, the regulations of 10 CFR Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions," and the guidance in Sections 7.2 and 7.3 of NUREG-1555. In the staff's analysis, the term "accident" refers to any unintentional event outside the normal plant operational envelope that could result in either*

(a) an unplanned release of radioactive materials into the environment or (b) the potential for an unplanned release of radioactive materials into the environment. NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (NRC 1996, 2013a), evaluates in detail the following two classes of postulated accidents as they relate to license renewal:

- *Design-Basis Accidents: Postulated accidents that a nuclear facility must be designed and built to withstand without loss to the systems, structures, and components necessary to ensure public health and safety.*
- *Severe Accidents: Postulated accidents that are more severe than design-basis accidents because they could result in substantial damage to the reactor core, whether or not there are serious offsite consequences.*

Section 4.11.1 and Appendix E describe the evaluation of new and significant information as it relates to design-basis accidents, followed by an evaluation of new and significant information for severe accidents. These comments do not provide specific information related to the environmental effects of the proposed action. The NRC staff did not revise the SEIS based on these comments.

A.2.2 Alternatives-Replacement Power and No Action

Comment: FP&L clearly has the ability to implement sounder, safer, more sustainable methods to provide electricity to our community. On behalf of our community, the League of Women Voters urges the NRC to impel FP&L to implement one of these alternative methods going forward. (0001-4-5 [Pierce, Barbara])

Comment: Miami-Dade County community and customers request you to halt your cooling canal operations and provide electricity to us by any one of your alternative methods. (0002-2-5 [Gutierrez, Vivian])

Comment: I demand the attention to renewable sources of energy. We cannot pretend that the Nuclear Reactor will ever be safe in our times with increasing water levels. It's time we direct all of our efforts to a sustainable, cleaner method. The costs will be more in the end if we don't (for whoever is still living here and surviving). (0019-1 [Schettini, Naomi])

Comment: We all live on this planet and we only have one planet we have to be as the bible says good stewards of the earth. Do not give into greed or for the lust of power, greed and the lust for power leads to perdition. If we do not invest in a green infrastructure then the United States of America will fall behind in these technologies. Countries like China will gain market share in these areas of business. If we have sustainable green energy we will always eternally have sustainable green energy. This is a wise decision to switch to clean energy so we will always have energy. (0066-2 [Jimenez, Nathan])

Comment: We need to be switching to clean, renewable solar and wind energy, and cleaning up pollution caused by nuclear and fossil fuel plants across America. (0070-2 [Talbot, Thomas])

Comment: Up to this point I have been very impressed with FP&Ls commitment to clean power and the future of the planet. If what I read here is true, it gives me pause. I think it would be really awesome if FP&L made a decision to abandon the plans for an expanded nuclear facility and instead set the world on it's ear and decided to instead do a massive solar/natural

gas hybrid plant. That would set a precedent that would be extremely beneficial to both the planet and to FP&L. Make us proud to have FP&L as our power provider. (0077-1 [Charles, David])

Comment: FPL is making tons of money and they are getting into solar in a big way. I think they can close Turkey Point and not in 3 decades but in decade or sooner. Please don't let them off the hook. (0084-1 [Robinson, Janet])

Comment: I am personally opposed to nuclear power and believe that instead of extending the life of the Turkey Point nuclear power plant in Florida, this plant should be decommissioned altogether and allow a transition to solar power to occur as this form of energy is a much cleaner form of energy than nuclear power and will last as long as our sun will, which is expected to be at least five more billion years. (0105-2 [Wingle, Dennis])

Comment: We cannot afford to allow the plant to continue operating without making drastic changes. Florida is the Sunshine State; it's time we put the sun to good use. (0107-1 [Wieliczko, Julie])

Comment: We need clean energy to make this earth greener and cleaner. A better place to live for future generations! (0126-1 [Zimmerman, Katherine])

Comment: CLOSE IT... AND REPLACE WITH SOLAR AND WIND POWER PRODUCERS... (0138-1 [Schoemer, Richard])

Comment: Better yet, the plant should be closed down, and alternate renewable energy sources should be developed. With the amount of sun S Florida gets, solar power is a no brainer.... and wind power also could be accessed. The risk of damage to the local environment is much too great to take that risk. (0144-1 [Loerke, Alison])

Comment: I very much don't understand Florida Power & Light's plans to extend the operating life of the nuclear reactors at Turkey Point Nuclear Power Plant. So much of Florida is overdeveloped, or at risk of over development. (0128-1 [Miller, Jane])

Response: *The NRC does not promote any particular form of energy generation, including nuclear power. The purpose and need for NRC's proposed action is to determine the acceptability of providing an option to continue plant operations beyond the current license term to meet future system generating needs, as such needs may be determined by State, utility, system, and, where authorized, Federal (other than NRC) decisionmakers. Ultimately, those decisionmakers will decide whether to carry out the proposed action and continue operating the plant for an additional 20 years, if the NRC renews the license, or shut down the plant and choose an alternative power generation source. However, the NRC staff does examine energy alternatives as part of its environmental review responsibilities under NEPA, and compares the environmental impacts of those options with the environmental impacts of subsequent license renewal (SLR) for Turkey Point Units 3 and 4.*

In Section 2.2.2 of the SEIS, the NRC staff identified three possible replacement power alternatives to continued operation of Turkey Point Units 3 and 4: new nuclear generation; natural gas combined-cycle generation; and a combination of natural gas combined-cycle and solar power generation. In addition, the staff considered the environmental impacts of

the no-action alternative, in which the Turkey Point subsequent license renewal application would be denied, as well as the environmental impacts of an alternative cooling water system. In SEIS Chapter 4, the NRC staff assessed the impacts of these alternatives compared to continued operation of Turkey Point Units 3 and 4. None of these alternatives were found to be environmentally preferable to the proposed action of subsequent license renewal for Turkey Point Units 3 and 4.

In Section 2.3, the NRC staff considered, but eliminated from detailed evaluation, 13 alternative energy sources and energy-saving strategies: solar, wind, biomass, demand-side management, hydroelectric, geothermal, wave and ocean energy, municipal solid waste, petroleum, coal, fuel cells, purchased power, and delayed retirement of existing facilities. The staff eliminated these 13 alternatives because of technical reasons, resource availability limitations, or commercial or regulatory limitations, as explained in the SEIS.

These comments do not provide specific information related to the environmental effects of the proposed action. The NRC staff did not revise the SEIS based on these comments.

Comment: Section 2.2.2, Page 2-6. The DSEIS states: "If the NRC does not issue subsequent renewed licenses, procurement of replacement power for Turkey Point Units 3 and 4 may be necessary." The statement "may be necessary" is not accurate with respect to replacement power. Replacement power will be needed to meet the reserve margin requirements mandated by the Florida Public Service Commission. In addition, the replacement power will need to be sited in either Miami-Dade and/or Broward Counties to maintain the balance between load and generation in these two counties. FPL suggests that this section in general focus on this need to balance load and generation in these two counties for all alternatives considered. The need to maintain a balance between a balance between load and generation in these two counties has been discussed each year for more than a decade in FPL's Ten-Year Power Plan Site Plan (Site Plan) that is filed each year with the Florida Public Service Commission. This discussion appears on pages 61 and 62 in FPL's 2019 Site Plan. (0017-1-1 [Maher, William])

Comment: Section 2.2.2, Page 2-12. The DSEIS states "installed [solar] capacity with approximately 725 MW" and "FPL plans to add more than 2,000 MW of additional solar generation capacity during that timeframe." These statements are outdated. As of January 2019, FPL alone has 1,153 MW of PV installed and, as indicated in FPL's 2019 Ten Year Site Plan filing, FPL plans to have 8,053 MW of PV installed by the end of 2028. These statements should be revised accordingly. (0017-1-3 [Maher, William])

Response: *Section 2.2.2 of the SEIS has been revised as a result of these comments.*

Comment: Section 3.3.2, Page 3-27. The DSEIS references permit 0250003-028-AV as the fossil Title V permit. This is not the most recent permit information. This information should be replaced with permit 0250003-030-AV issued in November 2018. (0017-1-17 [Maher, William])

Response: *Section 3.3.2 in the SEIS has been revised as a result of this comment.*

Comment: Section 4.3.7.1, Page 4-19. The DSEIS states, "Replacement power would come from common types of existing technology within the region (natural gas, nuclear, and coal)". FPL doesn't operate any coal plants in Miami-Dade County. This statement should be revised by removing "and coal." (0017-4-4 [Maher, William])

Response: *The NRC staff disagrees that coal should not be considered due to the fact that Florida Power & Light (FPL) does not operate coal plants in Miami-Dade County. As described in Section 2.2.2, coal was the second-most common source of electrical generation in Florida in 2016. The NRC staff's analysis assumed that replacement power needed to support a hypothetical cooling water system alternative would likely come from common types of existing technology within the region, and accordingly included coal-fired generation as a possible technology. This was assumed regardless of whether this power might be generated by FPL or purchased from other power generators. Clarifying changes to Section 4.3.7.1 of the SEIS were made in response to this comment.*

Comment: Section 2.3.12, Page 2-20. The DSEIS states: "NRC staff concludes that purchased power does not provide a reasonable alternative to Turkey Point subsequent license renewal." The SEIS omits an additional reason for reaching the conclusion. This statement should be modified as follows: "Furthermore, because the replacement capacity would have to be delivered to the Southeast Florida region consisting of Miami-Dade and Broward counties, a purchased power alternative would require the construction of new transmission facilities to import the power from outside the region into these two counties" at the beginning of the sentence. (0017-1-12 [Maher, William])

Response: *Section 2.3.12 of the SEIS has been revised as a result of this comment.*

Comment: * Rationale for Constructing Facilities Onsite: On page 2-9 of the SD EIS, the NRC states, "For the new nuclear alternative, the replacement power facility would be located within the Turkey Point property, but outside the proposed footprint of the not-yet constructed Turkey Point Units 6 and 7. " Also, the NRC provides in sections 2.2.2.2 Natural Gas Combined-Cycle Alternative (page 2-1) and 2.2.2.3 Combination Alternative (Natural Gas Combined-Cycle and Solar) (page 2-11) that the natural gas combined cycle facility would be constructed on or adjacent to the Turkey Point footprint. However, the NRC does not provide an alternative to site the new build alternatives at other offsite locations. This requires the new onsite facilities to impact a footprint of 75 acres to 360 acres (depending on the alternative) (Table 2-1, page 2-7). Siting the build alternatives in another location might lessen environmental impacts, especially if they are located in an industrial area that does not impact valuable natural resources.

Recommendations: The EPA recommends the NRC provide the rationale for constructing the new alternative facilities onsite in the Final Supplemental Environmental Impact Statement (FSEIS). The EPA also recommends the NRC more robustly evaluate the potential for placing the build alternatives offsite. This evaluation should be factored into the alternatives analysis and environmental impact analysis in the FSEIS. (0031-4 [Militscher, Christopher])

Response: *Section 2.2.2 of the SEIS has been revised to provide the rationale for assessing the impacts of constructing and operating replacement power facilities onsite rather than offsite. When assessing the impacts of new alternative facilities in an environmental impact statement (EIS) for license renewal (as opposed to an environmental impact statement (EIS) for a combined operating license (COL) or an early site permit, the NRC staff evaluates onsite construction and operation to maximize use of the applicant's existing infrastructure. Further, for the Turkey Point site, the applicant identified onsite construction and operation as the most likely scenario for replacement power facilities.*

Comment: Section 2.2.2, 2.2.2.2, Page 2-7, 2-10, 2-11. The DSEIS states in Table 2-1: "construction of a new or upgraded pipeline" and a "right-of-way to connect with existing natural

gas supply lines north of the site." The DSEIS also states: "the natural gas alternative may also require up to 1,200 ac (490 ha) of land for right-of-way to connect with existing natural gas supply lines north of the site." The DSEIS indicates that a replacement plant may require infrastructure upgrades ("new or upgraded pipeline") to support a new facility and but did not identify the significance of changes required to provide additional gas supply. The sole existing pipeline from the north to the Turkey Point site is fully subscribed and cannot supply sufficient gas for the equivalent of 3x500 MW of new CC capacity. Replacement CC capacity sited at Turkey Point would require a new gas pipeline that would be totally separate from the existing gas pipeline. Whereas the existing pipeline comes down the eastern part of Miami-Dade County, the new pipeline would have to be sited down the extreme western portion of the county, then entering the Turkey Point site from the west. Similarly, on page 2-10, it should be noted that natural gas would flow through the existing pipeline system southward only to the Lake Okeechobee area. Then a new pipeline would be needed to bring sufficient gas to the Turkey Point site to power the equivalent of 3x500 MW gas units. This comment[s] would also apply to the gas plus solar alternative. This information was part of the record in FPL's filing for Florida Public Service Commission approval of the Dania Beach combined cycle unit, docket number 20170225-EI. (0017-1-2 [Maher, William])

Response: *The commenter suggests that the SEIS does not account for the acreage and routing requirements associated with new gas supply lines that would be needed to support natural gas replacement power alternatives. As described in Sections 2.2.2.2 and 2.2.2.3 of the SEIS, the NRC staff considered replacement power alternatives that include constructing and operating a hypothetical new natural gas combined-cycle plant. These proposed alternatives do, in fact, account for acreage and routing requirements that could be associated with these alternatives. The NRC staff estimated land requirements presented in the SEIS using parameters based, in part, on FPL's Environmental Report (ADAMS Accession No. ML18037A836) and further informed by FPL's response to the NRC request for additional information (ADAMS Accession No. ML18247A509). No change to the SEIS was made in response to this comment.*

Comment: Section 2.3.1, Page 2-14. The DSEIS states: "To be considered a viable alternative, a solar [or wind] alternative must replace the amount of energy that Turkey Point provides." This statement is incomplete because it provides only part of the requirement to be a viable alternative to Turkey Point. In addition, the stated "50%" value is unrealistic. This statement should be revised to add: "A viable alternative must also provide firm capacity at least FPL's Summer peak hour (4-to-5 p.m.) and Winter peak hour (7 to 8 a.m.). Solar alone cannot provide firm capacity on early Winter mornings. PV capacity factors in Florida are in the 25% to 30% range. Also, the alternative must be sited in Miami-Dade and/or Broward counties to maintain the required balance of load and generation in this Southeast Florida region." (0017-1-11 [Maher, William])

Response: *The NRC staff disagrees that the SEIS assumes an unrealistic solar power capacity factor and that additional language should be added to address peak-hour firming and facility siting needs. The purpose of Section 2.3 of the SEIS is to present a brief discussion of why the NRC staff eliminated certain replacement power alternatives from detailed study. The capacity factor range of 25 to 50 percent described in the SEIS (for solar photovoltaic power and concentrated solar power, respectively) is appropriate for broadly estimating potential installed capacity requirements that could be associated with a hypothetical solar power alternative. This estimate does not require the detailed consideration of specific design factors such as peak-hour firming capacity. In addition, the NRC evaluated a region of influence in the SEIS that includes Miami-Dade and Broward counties. Accordingly, all replacement power*

alternatives were assumed to be located on the Turkey Point site or elsewhere in Miami-Dade and/or Broward County, as described in Section 2.2.2. No change to the SEIS was made in response to this comment.

Comment: The DSEIS states "FPL has not identified opportunities within its existing fleet that would provide for the replacement of Turkey Point's net generation." The SEIS omits an additional explanation for the statement. This statement should be modified as follows: "Furthermore, because the replacement capacity needs to be in the Southeast Florida region consisting of Miami-Dade and Broward counties, any delayed retirement option would have to be associated with plans to retire units in those two counties. There are no generating units that are sited in those two counties that are projected to be candidates for retirement by the time Turkey Point Units 3 & 4 are facing the end of their current operating licenses." (0017-1-13 [Maher, William])

Response: *The NRC staff disagrees that the additional language should be added to the SEIS or that it was omitted. The purpose of Section 2.3 of the SEIS is to present a brief discussion of why the NRC staff eliminated certain replacement power alternatives from detailed study. The replacement power alternatives considered in the SEIS assumed that their location would be either in Miami-Dade or Broward County, as the commenter points out. Consistent with FPL's Environmental Report, the NRC staff did not assume that replacement power could be provided by the delayed retirement of any currently operating plants. The comment does not present new information and no change to the SEIS was made in response to this comment.*

Comment: Section 4.3.7.1, Page 4-18. The DSEIS states: "Replacement power may be needed during both construction and operation of a mechanical draft cooling tower system at Turkey Point. Following cooling tower construction, Turkey Point Units 3 and 4 would be offline for at least a short time during the switchover from use of the cooling canal system (CCS) to cooling towers." This statement accurately notes that replacement power would be needed during construction and operation, but appears to underemphasize the need during construction. With possible modifications to the discharge canal for UHS modifications, both units may have to be shut down for the pump station installation and other work. FPL has calculated that station off-line durations of up to 7 months could be required for construction and post-construction activities. Additionally, based upon system constraints, it is reasonable to expect that additional transmission would be required to make up for the capacity lost for the duration of the project at the southern extent of the FPL transmission system to compensate for the simultaneous outage of 1,600 MW in the state's largest load area. (0017-4-5 [Maher, William])

Response: *The commenter states that the SEIS does not fully capture the need for replacement power during construction of the alternative cooling tower system. The NRC staff has revised Section 4.3.7.1 of the SEIS to state that construction-related outages would occur and that replacement power would be needed to replace Turkey Point's generating capacity.*

A.2.3 Alternatives-Technology and Mitigation

Comment: It is clear that the cooling canals of Turkey Point are not a closed loop system, as was required back in the early '70's, and now we have 10 years of data to show it's impacting all of us. We ask that the NRC if you do decide to move forward with re-licensing this facility, a condition must be placed on that license. You must require the system to be a closed loop facility, as it was originally permitted to be, to protect our water supply and resiliency plans that are taxpayer funded, such as Everglades Restoration Projects underway in the area. (0001-1-2 [Horton-Diaz, Daniel])

Comment: And so I urge the NRC to look more fully at the cooling towers because that would, at least in my case, improve my trust in the operation of those plants. Without it, I think that the groundwater issue is going to continue to be an issue, and I don't believe that you can have discipline on one side, meaning the reactor, and not discipline on the balance of plant. So I urge the NRC to require the cooling towers when you issue the permit to extend the life of those reactors. (0001-3-2 [Schievelbein, Tom])

Comment: I concur with the speakers before me that are requesting that a closed loop system be installed. It's vitally important for our aquifer, for our drinking water, and for the marine life in Card Sound, where we spend a lot of time fishing and sailing, and for the future of our life in our community. (0001-5-1 [Mullray, Eileen])

Comment: I'm a resident of Key Largo and I'm also the Commodore of the Ocean Reef Yacht Club, of which I'm a local yachtsman and I represent 245 members and their respective spouses and significant others, so it's probably double that number or more. We think that the canal system should be eliminated and that we should move ahead with a closed system. (0001-12-1 [Streit, Chris])

Comment: So I ask you, how can you permit a new 20-year license extension without a closed loop system? So I'm sorry, I don't want to hear -- well, the NRC can't consider that. You have to consider it. It's the only thing to consider. And so if you're thinking about approving this, you have to consider the cooling system. (0001-13-4 [Reynolds, Laura])

Comment: As we know, FPL is filing for a 20 year extension to their nuclear plant, which would make them the oldest in this country and there's no history of operation so you don't have any experiential history to go by as to the safety of the operation of that plant. There's models, there's a committee that has done a risk analysis, but all of that is in the EIS, if you want to read it. ...So anyway, as you know, the plant was designed in the '60's. Our position is that it's antiquated antique plant and the industrial waste water site on the plant happens to be the cooling canal system. For those of you that don't know about the licensing, it's licensed as an industrial waste water plant. It's open. It's unlined. It's close to the Bay. It gets overrun by the waters of Biscayne Bay and the gunk inside gets washed out during violent storms, in particular the last one that we had which was Irma. So it does have a connection with the Bay as well as a hydrological connection through the limestone that encases the Biscayne aquifer, our sole source of drinking water. So with the Everglades to the west, outstanding Federal waters to the east, we have a problem. And you heard Ms. McLaughlin from the Park system. They are an agency that has to be consulted with regarding whether or not this permit should be granted and she's saying that we need the cooling canal system eliminated and the cooling towers, and we totally agree. The plant, which was designed in the '60s, hasn't worked for more than 30 years. And you've had other people in authority, other agencies speaking on that, the National Parks Conservation Association and the Biscayne Bay National Park. (0001-14-2 [Rippingille, Bonnie])

Comment: So with respect to WASD, which is Miami-Dade Water and Sewer, they're telling us, hey, I don't think that we're going to be able to do this deal. And this whole EIS is predicated -- is based upon the deal with Miami-Dade County. Because otherwise they're going to be continuing to use Floridan water to freshen this system. The deal with Dade County was a Godsend if it worked, because Dade County was going to take all that sewage water that it's pouring into the outfall -- outfalls now, way out in the ocean. They're under order to stop doing that, by I think it's 2020. Anyway, so they need a place for their sewage water. And it would be a

good system and it's worked in other nuclear facilities, but the problem here is, it's going to require very expensive RO treatment. So they're not sure they're going to do it. So this whole EIS, I keep reading Miami-Dade, waste water, will have water to freshen these canals, because they're saying that these extraction wells are going to continue now and into the renewal period. So that's what they're planning. They're planning that they're going to leave those extraction wells in and they're taking that dirty water and they're injecting it down into the Boulder Zone. I'm not going to address that. But the point is, there is no evidence that this is working or that it will work. And we have expert witnesses whose depositions and whose statements and affidavits have been filed with the NRC and they were filed last year when we came before them to talk to them about this, they were filed shortly thereafter. And they need to be taken into consideration because these are leading experts in hydrology, ecology, the leading expert on cooling towers is Bill Powers. His report is there. We have shown, I believe, that this system will not work and the need for cooling towers. (0001-14-7 [Rippingille, Bonnie])

Comment: What I want to say is if we are --support the three -- plant, the power generating plant alternatives that the EIs -- that the NRC has proposed in EIS. They all three use cooling towers. We also support the fact that the existing Units 3 and 4 could continue to operate moving forward to 2052 using cooling towers. Under no circumstance do we support the continued use of the open cooling canals to be used through 2052 and for having the license renewed in conjunction with their continued operation on any alternative, of the ones mentioned now or ones that we generated. (0001-16-1 [Schoedinger, Steven])

Comment: And so I think the EIS provides a definite guideline, I guess for FP&L with regard to the options of cooling towers and the use of reclaimed water with the cooling towers, because -- or Floridan water, if reclaimed water doesn't occur. Then in both instances you have those elements can be -- have come out as a blow down and can be injected into the Boulder Zone under the permit. So that has no impact, it doesn't require the existence of the canals and it doesn't go into the canals, you know, so you can use the reclaimed water. And I know it's planned to be used the reactor if the agreement with Miami-Dade is successful, then, you know, they're going to use that for the existing natural gas powered unit. And it was going to be used for nuclear reactors 6 and 7 which they have a permit for but they are not going to, I guess understand it, move forward. (0001-16-4 [Schoedinger, Steven])

Comment: You know, you can remove all this consternation about the environmental impact in the canals if the NRC considered just in its alternative analysis for the cooling water system, is just remove it as a viable alternative. It's not really reasonable and viable moving forward to 2052. And I think the data and the information that you could collect from the last couple of years will support that. You know the CCS is not a thermal efficient unit. I mean based on thermal efficiency, reliability for cool water back to the reactors and the adverse impact on the environment, it's definitely grossly inferior to the use of cooling towers, which will eliminate all that problem. And I think directly relates to the safety and the risk analysis for the operations of the nuclear plant. So I'd urge the NRC to remove the cooling canals from a viable alternative moving forward and I think that would have a large impact and I think you'd be well stead with the data that would support that. And if you don't feel like doing that, then at least in your analysis increase your ratings to environmental risk and safety by using the canals forward from moderate -- from low and moderate to high. Because it definitely, I think the data supports that. (0001-16-5 [Schoedinger, Steven])

Comment: And I think that what happens here is that you didn't put the direct discharge to the Bay on the list, the existing canal system should be off too. (0001-17-4 [Guest, David])

Comment: So, you know, you really don't have to deal with that [impact on Floridan Aquifer supply] and [with cooling towers] you're talking about 10,000 maybe gallons per day of blow down, which I think could get agglomerated and maybe disposed in a landfill or it could be put down to the Boulder Zone, which seems to be where all the other unwanted waste goes these days. But at any rate, it doesn't go to the Bay, it doesn't go to the well fields west. All that is eliminated. (0002-1-2 [Shoedinger, Steve])

Comment: And we are a supporter of use of reclaim water. We use reclaim water in our RO system that we use on the golf courses and the common areas. So I think the idea -- I hope it's very successful that Miami-Dade and Florida Power and Light will reach a deal to provide reclaim water. Now reclaim water going into the canals, you have to almost treat it to drinking water standards to be at non-degradation levels to not impact the Bay when it leaks out of the canals. So in that scenario, \$500 million plus on a tertiary plant, an RO plant, that Miami-Dade or FP&L would have to pay for to make this deal work. If you use cooling towers you can use sewage affluent that doesn't have to be treated to drinking water standards. It can be advance treated, they call it. It's done all over the U.S. and the world, and used in cooling towers and nuclear power plants, and it can be treated at a much less level. And of course treatment is exponentially, when you try to get finer and finer quality it goes up exponentially, and that price tag will be half, 250 to \$300 million dollars. So you got 250. There's a difference. And that alternative goes into cooling towers. And like I already said, it doesn't go into any canals, it doesn't hit the Bay, it doesn't go west. You know, the spent water goes down into the Boulder Zone. And the other idea on the reclaim water. Again, you don't have the problem with the canals. You're not losing 30 million gallons a day. Miami-Dade's going to treat 60 million gallons, which they want, to come over to use 30 million gallons in the process, and then 30 million to evaporate out of canals. And imagine 30 million gallons a day of almost drinking water being evaporated into the air, and you're talking 10, \$20 million a year to operate a system. I mean it's such a poor use of our water resources to just waste 30 million when you don't have to. So I think that was the point I wanted to make this morning. I think the 200 million in the savings, that if you built a plant, less costly. There's all this discussion about the cost of cooling towers. Well, Bill Powers' report has been looked at over and over, and I think the number of 400 million is a very accurate number of the capital costs for the cooling towers that would serve Turkey Point Reactors 3 and 4, which is one of the alternatives. And the 200 million that you would save in not having to build a drinking water plant and use just tertiary from Miami-Dade, could be applied by FP&L to fund that cost. So, I mean, you know, we went through the numbers and I know that the NRC people have looked at the cost effectiveness on a cost effective life cycle basis. There's no way the canals even come close. So I just want you guys, when you consider things, just the impact on the water resources, which is a factor you consider, and the impact on also the Bay. I think it's a two for one here if we go with cooling towers, which are really recommended in the alternatives. And I'm not advocating so much for cooling towers, I'm just against continued use of the canals for another 40 years, because I don't think that they're safe and the most cost effective way to use our water resources. (0002-1-3 [Shoedinger, Steve])

Comment: We have an alternative here, a good alternative that is safe. We are putting things in our water and in our drinking water and in the Bay, that are dangerous. They're having an effect already. Turkey Point is located in the worst place. Here we are in a very low level, facing rising sea waters, and then of course hurricanes. So we are in a danger situation. The cooling canals are not the solution. We have a much better solution. And I implore you to consider doing the right thing. (0002-3-1 [Steele, Jody])

Comment: FKNMS [Florida Keys National Marine Sanctuary] believes that the least damaging alternative to the sanctuary would be implementations of the cooling water system alternative. (0018-5 [Fangman, Sarah])

Comment: For decades, the operations of Turkey Point's antiquated cooling canal system (CCS) have contaminated the surrounding environment because of connectivity between the CCS and surrounding waters, threatening our national parks, sensitive natural areas, and the drinking water supply for millions. As outlined by the DSEIS, FPL has repeatedly violated various state and local water quality standards through the discharge of salinity and nutrients from the CCS into surrounding ground and surface waters. And yet, Nuclear Regulatory Commission (NRC) staff comes to a wholly unsupported conclusion that the environmental impacts of the subsequent license renewal and continued operation of the CCS will be mostly small. These conclusions are based on unsupported assumptions that FPL's efforts to remediate existing pollution and prevent future pollution will be successful. Until and unless there is concrete, scientific evidence to support such a conclusion, FPL should not be given a subsequent license renewal that allows the continued operation of the CCS. Rather, alternatives that involve the complete decommissioning of the CCS and a transition to other cooling technology, such as mechanical draft cooling towers, should be considered. (0023-1 [McLaughlin, Caroline])

Comment: While FP&L has said that they are addressing the leakages into the Aquifer and the Bay the past five plans and their current sixth plan have not addressed the real problem which is the flawed cooling canal design. As you probably know, Turkey Point is the only nuclear power plant in the world using canals instead of cooling towers. Yes, FP&L can point to the beneficial impacts of the canals for the American crocodile but, the ever- increasing human population of South Florida and the Keys is being negatively impacted as the quality of our water for drinking, recreation and Everglades restoration continues to be degraded. (0032-3 [Bloom, Mary])

Response: *These comments express a preference to discontinue use of the cooling canal system (CCS) and suggest that the NRC require FPL to implement an alternative closed-loop cooling water system for Turkey Point Units 3 and 4 that might be used to mitigate potential impacts associated with the continued use of the existing cooling canal system. The purpose of this analysis is for the NRC staff to compare an alternative closed-cycle cooling system approach with the proposed action to inform the NRC's licensing decision, decisions by other decisionmakers and the public, as applicable, under NEPA. However, the NRC has neither the statutory nor the regulatory authority to determine which system or technology should be used, or to decide other permitting issues, for which the State of Florida has been delegated regulatory authority. Further, the NRC does not have the regulatory authority to require that FPL implement an alternative closed-loop cooling water system as a license condition. To the extent that these comments raise specific concerns regarding environmental impacts of the cooling canal system as compared to a cooling tower alternative (e.g., climate change, hurricanes, groundwater, surface water, drinking water, aquatic resources, and endangered or threatened species), the SEIS addresses those issues. These comments provide no new information and no changes have been made to this SEIS as a result.*

Comment: Section 2.2.3, Page 2-13. In section 2.2.3, the DSEIS identifies a cooling water system alternative whose impacts will be assessed in Chapter 4. However, the DSEIS does not consider whether this alternative is a reasonable alternative. With respect to the reasonableness of this alternative, on August 8, 2018, FPL submitted an expert report in response to RAI AL-3 (the "High Bridge Report") that provided an analysis of the technical and economic challenges to the cooling tower alternative. Yet this report was apparently not considered in the DSEIS. As

a result, the analysis of the cooling water system alternative does not capture the full scope of a project to replace the cooling canal system with cooling towers. The DSEIS refers to the FEIS for the Turkey Point COL (NUREG-2176) but additional detail should be included in the EIS for the SLR to reflect the differences between a new facility and operating reactors, as there are differences in construction, location, and size between the cooling towers required for the two different projects. For instance, while a new plant design, like Units 6&7, would maximize the efficiency of the construction project, integrating cooling towers into already operating power plants necessarily would involve inefficiencies in the design due to the need to minimize disruption of plant activities and impacts on the existing facility design. This project will involve the construction of a large Reclaimed Water Treatment Facility and a 60+acre storage pond. These would need to be made to fit in the northern portions of the site because the southern area is covered by the existing Cooling Canal System, which would have to remain in operation while the cooling towers are being constructed and tested. In addition, the cooling tower modification for Turkey Point would require the addition of redundant circulating water pumps because the existing plants' circulating water pumps were not designed for the additional pressure drop required to accommodate cooling towers. Other less impactful design compromises would be necessary for this retrofit application that will increase the cost above what would be expected for a new build plant. These are addressed in the High Bridge Report. (0017-1-4 [Maher, William])

Comment: In addition to the tie-in to the MDWASD treatment plant, the waste water would need to be treated before it could be used by the Turkey Point nuclear units. The plants' main power steam turbine condensers would need to be protected against the residual chemicals in the reclaimed makeup water from municipal sewage. The extent of the facility required to address the residual chemicals in the water is quite substantial. This pre-treatment system would consist of nitrogen, phosphorus and disinfection of the reclaimed water. The treatment system would need to be sized for the 60 million gallons per day (MGD) flow rate, which would result in a water treatment system that would look more like a municipal water treatment facility. It would include chemical treatment, large full flow sand filters, settling ponds, and a range of other subsystems that all add to the costs and scope of the project. This was a significant part of the Turkey Point 6&7 project but appears to be missing from the impact sections of the DSEIS. (0017-1-5 [Maher, William])

Comment: Further, the Cooling Tower modification to the plants' discharge canal would require the construction of many earthen berms to direct flow into the cooling tower system and to prevent flow directly into the return canal to the inlet. Also, the canal would need to be deepened and widened to minimize silting resulting from the outflow from the cooling tower into the modified canal. (0017-1-6 [Maher, William])

Comment: Another major complexity of the addition of cooling towers to the Turkey Point nuclear plants is that the Ultimate Heat Sink for the safety related cooling of the nuclear reactors uses the existing Cooling Canal System. Substituting the cooling towers for the existing cooling system would eliminate the plants' Ultimate Heat Sink. This safety related system would need to be reestablished by modifications to the cooling water canals. Assuming that the canals would remain in place, this would involve the deepening and widening of the return canal to increase the water volume to meet the UHS requirements. If the cooling canals were fully eliminated (e.g., removed), then some other water volume would need to be identified. In addition, this new water volume needs to be in a lined reservoir to minimize salinization due to groundwater in-leakage. A new connection would need to be constructed between the plants' discharge canal and this new ultimate heat sink reservoir that does not short circuit the cooling towers. (0017-1-7 [Maher, William])

Comment: Lastly, the plant site is currently optimized for operations; not for construction. The addition of cooling towers, the Reclaimed Water Treatment Facility, the Makeup Storage Pond, the Pipeline tie-in to the MDWASD treatment facility, and all the civil work to expand and line the new Ultimate Heat Sink cooling water system represent a number of simultaneous large construction projects involving complicated interfaces:

- * The bulk of the Turkey Point site is dominated by the existing Canal Cooling System.
- * The barge unloading area is near retired unit 1 and unit 2, as well as operating unit 5. Additionally, the heavy haul road runs through this congested site area.
- * The site has no designated laydown area suitable for staging the required quantities of heavy equipment and material.
- * The overhead transmission lines from the operating power plants limit the height of packages and crane operations.
- * These proposed projects would require a great deal of excavation for foundations and footings, and the site is not uniformly capable of supporting these activities. Large quantities of engineered backfill may be required that will further occupy the limited shipping and receiving facilities necessary to receive components and bulk commodities to support the construction.
- * Buried utilities and abandoned construction services from previous projects, that may or may not be well documented, challenge and interfere with these civil construction projects. (0017-1-8 [Maher, William])

Comment: Section 2.2.3, Page 2-13. The DSEIS presents the cooling water system alternative as an alternative that would mitigate the potential impacts associated with continued use of the existing cooling canal system. This presentation is incomplete because it does not explain how the installation of cooling towers would achieve this end. First, the DSEIS concludes that the impacts of the CCS on groundwater quality would *be SMALL during the subsequent license renewal term as a result of ongoing remediation measures and State and county oversight, now in place at Turkey Point" and that "hypersalinity is projected to decrease substantially as a result of ongoing remediation efforts." DSEIS at 4-27. It is not clear then, what environmental impacts of the cooling canal system during the license renewal period would be mitigated by the cooling water system alternative. Moreover, even if there was an environmental impact from the cooling canal system during the period of extended operation, the DSEIS does not explain how or whether cooling towers would affect seepage of hypersaline water from the CCS. (0017-1-9 [Maher, William])

Comment: Section 2, Page 2-13. The DSEIS states, "the primary source of cooling water is assumed to be reclaimed wastewater." This statement is a valid assumption but incomplete because it does not provide a discussion of the reclaimed water supply that would be required. The statement should be revised by adding: "The reclaimed wastewater supply would be from the Miami Dade county wastewater treatment facility to the Turkey Point Site and would require construction of an approximately 10-mile-long pipeline and additional pumping stations." (0017-1-10 [Maher, William])

Response: *The NRC staff considered a hypothetical cooling water system alternative in response to comments received during the public scoping period suggesting the existing cooling canal system be replaced. The NRC staff's comparative analysis was limited to evaluating the general construction and operating impacts associated with this potential mitigation alternative and was performed at a level of detail commensurate with the evaluation of replacement power technology alternatives considered elsewhere in the SEIS. As described in Section 2.2.3 of the SEIS, the NRC staff's independent analysis draws upon the general mechanical draft cooling tower technology previously evaluated for Turkey Point Units 6 and 7 in NUREG-2176,*

“Environmental Impact Statement for Combined Licenses (COLs) for Turkey Point Nuclear Plant Units 6 and 7,” and reflects simplifying assumptions to enable the application of this technology to Turkey Point Units 3 and 4. Section 2.2.3 has been revised to acknowledge that additional engineering complexities and costs could be associated with detailed designs for retrofitting Turkey Point’s cooling water system in this manner.

Comment: The Draft SEIS fails to take this requisite hard look because, while it provides pieces of information about the effects of the Turkey Point subsequent relicensing and general facts about the environment, the Draft SEIS fails to (1) analyze the environmental benefits of replacing the cooling canal system with cooling towers and (2) account for the effects of climate change.

A. Cooling Towers

The Draft SEIS fails to analyze the environmental benefit of installing cooling towers as an alternative to the current cooling canal system. Its analysis focuses almost entirely on the environmental impacts of constructing and operating cooling towers. It presents essentially no comparison of the benefits to endangered species or the environment of replacing the cooling canal system with cooling towers.⁶ But replacing the cooling canals with cooling towers would mitigate serious environmental impacts on water sources and threatened and endangered species. Thus, the Draft SEIS completely ignores the point of considering cooling towers as an alternative, in effect treating the alternative of cooling towers as if it had no environmental benefits. The failure to address those benefits represents a failure to meet the NRC's obligations to consider reasonable alternatives under NEPA and its own regulations.

The Draft SEIS acknowledges, for example, that the existing cooling canal system is hydrologically connected to the Biscayne aquifer and surrounding waters and thus that it impacts surrounding water sources.⁷ It also considers some adverse impacts to protected species like the American crocodile.⁸ But the Draft SEIS fails to provide an analysis of how constructing cooling towers would eliminate the negative impacts on the American crocodile and other species by eliminating the ammonia now leaking from the cooling canal system.⁹

Thus, the Draft SEIS fails to take a hard look at the impacts of the cooling canal system because it does not provide any analysis of the beneficial effects operating cooling towers would have on listed species and the aquatic environment.

⁶ See, e.g., Draft SEIS at 4.5.7, 4.7.7, and 4.8.

⁷ See, e.g., *id.* at 4.5.1.1.

⁸ See U.S. Nuclear Regulatory Commission, Biological Assessment for the Turkey 10 Point Nuclear Generating Unit Nos. 3 and 4 Proposed Subsequent License Renewal (Dec. 11, 2018) (ADAMS Accession No. ML18344A008).

⁹ The Biological opinion does consider ammonia impacts on the manatee, but it does not explain why that is the only species considered. U.S. Nuclear Regulatory Commission, Biological Assessment for the Turkey Point Nuclear Generating Unit Nos. 3 and 4 Proposed Subsequent License Renewal, 59-61 (Dec. 11, 2018) (ML18344A008).

(0021-3 [Ayres, Richard E.] [Cox, Kelly] [Fettus, Geoffrey H.] [Rumelt, Kenneth J.]

Comment: Nowhere does the Draft SEIS provide an understanding of the benefits for the environment of operating cooling towers instead of the current cooling canal system. (0021-9 Ayres, Richard E.] [Cox, Kelly] [Fettus, Geoffrey H.] [Rumelt, Kenneth J.]

Response: *Under the cooling water system alternative, FPL would install cooling towers for Turkey Point Units 3 and 4 but would continue to operate the CCS because it supports retired*

fossil fuel Units 1 and 2, which use the CCS to support operation in synchronous mode, and Unit 5, which discharges blowdown to the CCS. These uses would continue over the course of the proposed subsequent license renewal term. Thus, the cooling water system alternative ultimately considers the impacts of retrofitting the cooling system of Turkey Point Units 3 and 4 to operate with cooling towers, but it does not contemplate replacing the CCS with cooling towers. The NRC staff explains this in several sections of the SEIS, including Sections 4.5.2.1, 4.6.2, 4.7.2, and 4.8.2. The NRC staff also added text to Section 2.2.3 of the SEIS, which introduces and describes the cooling water system alternative, to specifically explain that the CCS would continue to operate under this alternative and that the requirements of the October 7, 2015, Consent Agreement between FPL and Miami-Dade County and the June 20, 2016, Consent Order issued by the State of Florida, Department of Environmental Protection (FDEP), would continue to apply. The staff also added text in Sections 2.2.3 and 4.1, explaining where the benefits of the cooling water system alternative are described.

With respect to potential benefits of the cooling water system alternative on the American crocodile and other species, some potential benefits of ceasing to use the CCS to cool Turkey Point Units 3 and 4 were already addressed in Sections 4.6.2, 4.7.2, 4.7.7, and 4.8.2 of the SEIS. The staff also added text in Sections 4.6.3, 4.7.3, and 4.8.3 of the SEIS to further elaborate on the potential benefits of the cooling water system alternative on terrestrial resources, aquatic resources, and special status species and habitats.

The NRC staff describes the results of Biscayne Bay and Card Sound ecological monitoring in detail in Sections 3.6.2 and 3.7.4 of the SEIS. These sections discuss, in part, the effects of ammonia on the ecological environment, including the effects that the manatee, American crocodile, and other federally listed species would experience. To date, this monitoring has documented no ammonia in the Bay or Sound attributable to CCS operations nor any other discernable impacts on the ecology of Biscayne Bay.

Regarding the concerns expressed by the National Marine Fisheries Service (NMFS) and Miami-Dade County, the NRC staff conservatively undertook a species-specific evaluation of the potential impacts of ammonia originating from the CCS on federally listed aquatic species in Section 4.8.1.1 of the SEIS to support the NRC staff's Endangered Species Act (ESA) consultation with the NMFS. In that section, the NRC staff evaluates the potential impacts of elevated ammonia levels in several manmade canals adjacent to the CCS on smalltooth sawfish and sea turtles. Although hydrologically connected, these canals are not within the Bay itself.

As explained in Section 3.5.1.4 of the SEIS, Miami-Dade County found elevated concentrations of ammonia at certain sampling bottom locations within these canals where dissolved oxygen was less than 1.0 mg/L. Ammonia levels in the middle and upper portions of the water column were not elevated. The County found that the elevated ammonia at the sample points may be one contributing factor. For instance, several bottom samples within these canals exhibited total nitrogen concentrations that greatly exceeded total nitrogen concentrations measured in the CCS and in groundwater beneath the CCS during the same period. This suggests that sources external to the CCS are contributing nitrogen to the canals.

Because these regions of the canals are stagnant and exhibit low dissolved oxygen, decomposition of plant and animal material in these stagnant, anoxic areas creates extra nitrogen that is not able to disperse or be flushed out of the canals due to little or no mixing of the canals with other surface waters. This extra nitrogen may then contribute to ammonia formation, subsequent accumulation, and may ultimately play a significant role in the observed

ammonia in the bottom of the canals. FPL submitted a mitigation plan to the Miami-Dade County in October 2018. In the letter accompanying the plan (ADAMS Accession No. ML19095B384), FPL explained that the data upon which the Miami-Dade County Department of Environmental Resources Management (DERM) had relied upon in making its findings do not definitively delineate the contribution of groundwater underlying the CCS to ammonia levels in the surrounding waters. FPL stated that its data demonstrate that at most, groundwater underlying the CCS could have contributed 2 percent or less of the observed ammonia values in the samples taken from the canals. As such, FPL concluded that the contribution of groundwater beneath the CCS to ammonia concentrations in adjacent surface waters, if any, is negligible. Since then, FPL completed restoration and fill of the canals where elevated ammonia was observed.

The NRC staff concluded in its ESA analysis in Section 4.8.1.1 of the SEIS, that federally marine aquatic species under NMFS jurisdiction (i.e., sea turtles and smalltooth sawfish) are unlikely to be exposed to elevated ammonia associated with CCS operations in either Biscayne Bay, Card Sound, or the manmade canals described above. The NRC staff made similar conclusions in its biological assessment (ADAMS Accession No. ML18353A835; p. 59-62) (incorporated by reference in this SEIS) with respect to the West Indian manatee. The FWS also addressed the effects of ammonia and other CCS-sourced nutrients on the manatee on pp. 9-10 and 18-21, of its July 25, 2019, biological opinion (ADAMS Accession No. ML19221B583).

With respect to the American crocodile, CCS impacts on this species are addressed within the NRC staff and FWS's analyses of reduced nests and hatchling survival (pp. 32-34 of the biological assessment and pp. 29-31 of the biological opinion), crocodile health trends (pp. 34-37 of the biological assessment and pp. 31-34 of the biological opinion), impacts to wetland habitats (pp.37-38 of the biological assessment and pp. 35-36 of the biological opinion), and effects on critical habitat (pp. 39-42 of the biological assessment and pp. 38-40 of the biological opinion).

Finally, the full text of the commenter's climate change concerns, which are introduced at the beginning of this comment, was delineated as [Comment 0021-4]. Please see the staff's response to this comment under Section A.2.4, "Climate Change."

A.2.4 Climate Change

Comment: We have a lot of concerns about the operation of Turkey Point and the continued operation of Turkey Point into the future. We're going to be submitting extensive technical comments. But today I'm going to ask some questions of all of you that hopefully can help us address specifically regarding the sea level rise issue. So we were a bit concerned and confused why the analysis of sea level rise at the site was just incorporated by reference from the EIS for Units 6 and 7, which have different elevation levels, different cooling system, and it doesn't seem appropriate to apply that specifically to what we're dealing with here with running Units 3 and 4 with a cooling canal system. And largely the discussion of sea level rising in that EIS was somewhat limited to a footnote in that EIS as well. So we have a lot of concerns there. We are also wondering whether the sea level rise projections that you guys are you using are covering the entire life span of this plant, under the new time line running through decommissioning. (0001-7-1 [Silverstein, Rachel])

Comment: And we're also wondering why you didn't choose to rely on your sister Federal expert agencies sea level rise projections and instead you used those provided by FPL. So it seems like you should be using other Federal agencies sea level rise projections at a minimum, and then using the most conservative of those because of the risk with potential flooding at this site and the potential harm that could be done by flooding at the site as well. (0001-7-3 [Silverstein, Rachel])

Comment: And finally, I'd like to ask that you commit to uphold best available science standard through this NEPA review, particularly with respect to sea level rise caution using the best available projections. (0001-7-4 [Silverstein, Rachel])

Response: *These comments concern the sources of information that the NRC relied upon with respect to projections of sea level rise as presented in the SEIS, and the adequacy of the NRC staff's sea level rise projections. The cumulative impacts analysis contained in the EIS prepared for the Turkey Point Units 6 and 7 combined licenses is incorporated in this license renewal SEIS by reference (see Section 4.16 of the SEIS). The NRC staff describes observed sea level rise in this SEIS based on information provided by the U.S. Global Change Research Program (USGCRP), EPA, the National Oceanic and Atmospheric Administration (NOAA), and the U.S. Army Corps of Engineers (USACE), and the NRC staff's evaluation of projected sea level rise in the SEIS (Section 4.15.3.2) is based on information from the USGCRP's fourth national climate assessment published in 2017 and 2018 (USGCRP 2018, USGCRP 2018), which was updated for this final SEIS. The NRC staff considers the information relied upon in this final SEIS to be the best available information on projected sea level rise. The climate change projections currently available provide information to the year 2100, approximately 50 years after the end of the subsequent license renewal term, which would include a major part of the decommissioning timeline following the subsequent license renewal term for Turkey Point Units 3 and 4.*

These comments provide no new information and the SEIS was not revised as a result.

Comment: I didn't address climate change and that fact that it's bringing higher sea levels to Southeast Florida. And it's clear that sea level rise is accelerating faster than previously understood. And it's supposed to be substantially faster in Southeast Florida than any other place in the United States. And you can't ignore this in considering a permit for another 20 years. (0002-6-2 [Rippingille, Bonnie])

Comment: I number all our national parks as some of our greatest national treasures, to be preserved for future generations as well as now, and I believe we need to do everything in our power to protect them from human-caused disasters. Sea level rises are already occurring and are expected to increase as part of climate change. (0013-1 [Rees, Janet])

Comment: We are also VERY worried about the doom of sea level rise which is not "a if it happens problem" it is already happening in South Florida!!! We feel it all the time especially during rainy season and moon flood high tides! It is a regular occurrence anymore for our streets to be flooded for the waters to get precariously close to our homes! You politicians sit in your expensive homes, protected and secure that you are too removed from the everyday people and the real issues that exist due to climate change because you refuse to DO ANYTHING BECAUSE THAT WOULD MEAN LESS MONEY IN YOUR POCKET!!!! Make no mistake, we are all aware of the simple truth that YOU fail to acknowledge climate change and sea level rise because it would cost you financially! It's despicable that you see yourselves as

"working for the good of all people" because you clearly care nothing about us regular everyday people. You care about the top 1% only and keeping your deep pockets filled with our money! But in the end, even you will not be saved from the inevitable and your families will pay the price for your lack of ethics!! You have an opportunity to be at the forefront of addressing climate change and sea level rise and actually doing something about it. The choice is up to you. (0014-1 [Elmo, Francesca])

Comment: Miami-Dade County is currently within the SE FL Climate Change Regional Compact. Compliance with compact affects financial bond ratings. FPL is currently utilizing lower sea level rise models than what has been agreed to within the compact based on "conservatism". This is fundamentally at odds with the counties operating principals. (0020-11 [Gomez, Albert])

Response: *The commenters express concern about the adequacy of analyses related to climate change and sea level rise in the Turkey Point region. Section 4.15.3.2 of the SEIS (see "Climate Change Projections") summarizes the observed changes in sea level and presents future sea level rise projections. As stated in response to the comment above, the SEIS describes observed sea level rise based on information provided by USGCRP, EPA, NOAA, and USACE. The future projections for sea level rise are based on the latest scientific consensus estimates available from the USGCRP (USGCRP 2017, USGCRP 2018). In Section 4.15.3.2, the NRC staff specifically compares the USGCRP estimates with those from the 2015 Southeast Florida Regional Climate Change Compact. The SEIS also compares sea level rise projections for several time periods including 2030, 2050, and beyond to 2100, discusses the differences in projected sea level rise estimates, and the associated uncertainty in the projections. These comments provide no new information and the SEIS was not revised as a result.*

Comment: And now, as sea levels rise and the severity of hurricanes increases, Turkey Point poses a more serious threat to Biscayne and the surrounding area. So much is at stake: endangered species, mangrove forests, and the drinking water supply for millions of people. (0011-2 [Puca, Rob])

Comment: Thus, [re susceptibility to impacts from sea level rise, storm surge, and severe hurricanes] Turkey Point can be expected to pose even a more serious threat to the Biscayne area's mangrove forests, rare biota, and drinking water supply. (0016-2 [Cochrane, Theodore])

Response: *The NRC staff describes observed and projected changes in sea level rise and Atlantic hurricane activity in Section 4.15.3.2 of the SEIS. Impacts on terrestrial and aquatic environments from continued operations of Turkey Point Units 3 and 4 are described in Sections 4.6.1 and 4.7.1 of the SEIS. Impacts on water supply from continued operations of Units 3 and 4 are described in Section 4.5.1.2 of the SEIS. The potential cumulative or overlapping impacts from climate change on water supply, terrestrial resources, and aquatic resources are described in Section 4.16.2, 4.16.3, and 4.16.4 of the SEIS. These comments provide no new information and the SEIS was not revised as a result.*

Comment: Climate Change Projections - Miami-Dade County continues to have concerns regarding the long term viability of the Cooling Canal System (CCS) to meet its intended purpose as the ultimate heat sink for Units 3 and 4, in the context of further sea-level rise, and without the need for external sources of fresh or low salinity water sources in a basin already facing water shortages, saltwater intrusion and sea level rise. (i) Sea Level Rise. The DSEIS relies on sea level rise predictions from the U.S. Global Change Research Program's

(USGCRP) and provides sea level rise predictions of 0.3 to 0.6 feet (0.09 to 0.18 m) by 2030 and 0.5 to 1.2 feet (0.15 to 0.37 m) by 2050 (USGCRP 2017) and potential global sea level rise of 1 to 4.3 feet (0.3 to 1.3 m) by 2100. DERM submits that for long term planning purposes, e.g., subsequent license renewal, it is rational to utilize the USACE High predictions which represents a mid-level projection of 2 feet by 2060. All modeling and feasibility (floodplain analysis, storm surge) should develop future scenarios using elevated sea level boundaries. (0022-6 [Hefty, Lee N.]

Comment: DERM acknowledges the limitations with respect to the scope of the NRC's review under the license renewal process as it relates to the effect of climate change on the structures, systems and components of Turkey Point's Units 3 and 4 (page 4-110), and the NRC's responsibilities on an ongoing basis to ensure nuclear plants operate within the technical safety specifications provided in a safe provided by the pertinent regulations. Further, DERM acknowledges that sea level rise is anticipated to occur gradually over time and as such would potentially allow for adaptive responses with respect to the operations and infrastructure of Turkey Point's Units 3 and 4. However, the inevitability of sea level rise and the resulting inundation of the coastal area.,. surrounding Turkey Point and the impact on hydrological regimes in the area, is reasonably expected to result in further destabilization of the CCS operations resulting in reduced efficiency and effectiveness. If a license renewal is granted, DERM recommends that at a minimum the license renewal should require conditions that provide for a well-defined on-going evaluation of the facility. This should include conditions with built in criteria and decision points that trigger operational and infrastructural changes to ensure the facility, including the reactors and the cooling canal system will be able to continue to operate safely into the future, without unacceptable impacts to water resources surrounding the facility. (0022-7 [Hefty, Lee N.]

Response: *Miami-Dade County DERM expresses concerns regarding CCS operations under a changing climate scenario and requests that the NRC impose license conditions to ensure the reactor and the CCS operate safely and without unacceptable environmental impacts in the future. As documented in this SEIS, the purpose of the NRC's environmental review is to assess the potential effects on the environment from continued nuclear power plant operation following subsequent license renewal. While the SEIS does consider the effects of climate change in relation to the environmental resources potentially impacted by the continued operations of Turkey Point Units 3 and 4, the effects of climate change on Units 3 and 4 structures, systems, and components are considered as part of the NRC staff's ongoing reactor oversight program and license renewal safety review, and are outside the scope of the staff's license renewal environmental review.*

In accordance with Title 10 of the Code of Federal Regulations (10 CFR) Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants," of the NRC's regulations, the focus of the NRC staff's license renewal safety review, as documented in the safety evaluation report, is to verify that the applicant has identified aging effects that could impair the ability of structures and components within the scope of license renewal to perform their intended functions, and to demonstrate that these effects will be adequately managed during the proposed period of extended operation. Sections 3.5.1.1 and 4.15.3.2 of this SEIS describe FPL's proposed aging management program to ensure the continued integrity of the Turkey Point cooling canal system during the subsequent license renewal period of extended operation. Further, operating plants must deal with the effects of climate change (e.g., sea level rise) as required by the NRC's regulations in 10 CFR Part 50 and the requirements of their license, including technical specifications, to provide reasonable assurance that the activities authorized by the license can be conducted without endangering the health and safety of the

public, and to adequately manage the effects of aging so that structures, systems, and components that are important to safety will continue to perform their intended functions for the period of extended operation, as required in 10 CFR Part 54 and described in Section 4.15.3.2 of this SEIS. Furthermore, an operating nuclear power plant is subject to continuous NRC oversight under the Reactor Oversight Process where emerging safety and security issues are addressed. On an ongoing basis, this oversight assesses the adequacy of structures, systems, and components of a nuclear power plant, including their exposure to external hazards such as flooding. In the event that a license condition is needed to ensure public safety, it would be imposed by the NRC as part of its oversight of the operating reactor, outside the scope of license renewal.

Flood protection and the potential for flooding at Turkey Point is discussed as part of the NRC staff's description of the hydrologic environment, in Section 3.5.1.1, Surface Water Hydrology (see the subsection, "Potential for Flooding at the Turkey Point Site"). With respect to commenter concerns regarding the structural integrity of the CCS, the flooding discussion in Section 3.5.1.1 of this final SEIS has been expanded to include a discussion of the subsequent license renewal aging management program that would govern the Turkey Point CCS. The NRC staff has also revised that subsection to include a discussion of the operation and maintenance requirements that would apply to the CCS under the Florida Department of Environmental Protection's (FDEP's) draft National Pollutant Discharge Elimination System (NPDES) permit that was issued for continued operation of Turkey Point.

In addition to its comments regarding reactor safety, DERM requests that the future sea level rise projections discussed in the SEIS rely on the U.S. Army of Corps of Engineers (USACE) sea level rise prediction of 2 ft by 2060, rather than the sea level rise predictions from the U.S. Global Change Research Program (USGCRP). As noted by the commenter, the SEIS discusses future projections in sea level rise and uncertainty in projections. To inform the NRC's operating reactor licensing environmental review, the NRC uses consensus information from the USGCRP. The USGCRP integrates the best available information and current state of knowledge regarding climate change trends and effects and provides consensus-based estimates across 13 Federal member agencies. Nonetheless, as discussed above, sea level projections in Section 4.15.3.2 of the SEIS considered not only sea level rise estimates from USGCRP, but also information from the Southeast Florida Regional Climate Change Compact, EPA, NOAA, and USACE. Further, the SEIS specifically discusses the USACE high curve projections used by the Southeast Florida Regional Climate Change Compact in developing sea level rise projections. Section 4.15.3.2 of the SEIS also discusses the differences in sea level rise estimates from these sources, as well as uncertainties.

Comment: Closing one's eyes to climate change will not make it go away. It is imperative that measures are taken now to protect our environment and try and avoid the inevitable human suffering that will result. (0028-1 [Matthews, Ellyn])

Comment: Shut down Turkey Point! Just look at a map of the US and notice where the plant is located. Hurricanes are getting stronger and covering more area, and a storm surge could devastate the health and well being of FL residents if Turkey Point is allowed to continue operating. (0030-1 [Broms, Sharon])

Comment: Putting your head in the sand and pretending climate change doesn't exist is extremely dangerous for the citizens of FL. (0104-2 [Janzen, Gayle])

Comment: There is a certain point beyond which denying climate change is a criminal offense. Turkey Point is one of those points. (0112-1 [Mcbride, Margaret])

Comment: The great majority of the most qualified scientists in my field of atmospheric science believe human-caused greenhouse gas emissions and other activities are responsible for a dangerous climate change. The global warming associated with this climate change will cause rising sea levels and exacerbate the danger to Turkey Point. (0143-1 [Crupi, Kevin])

Response: *The commenters express concern about whether climate change and sea level rise have been considered. The NRC staff considered the effects of climate change and associated impacts on the environment in Chapter 4 of the SEIS. Section 4.15.3.1 of this SEIS presents the NRC staff's evaluation of the proposed action's (license renewal) contribution to greenhouse gas emissions. In addition, Section 4.15.3.2 of the SEIS discusses the observed changes in climate, including hurricanes, and potential future climate change during the subsequent license renewal term based on climate model simulations under future global greenhouse gas emission scenarios. In Section 4.16 of the SEIS, the NRC staff considers the potential cumulative, or overlapping, impacts from climate change on environmental resources where there are incremental impacts of the proposed action (subsequent license renewal). No changes were made to the SEIS in response to these comments.*

Comment: And again, someone has talked about sea level rise. It's true that if I understand reactors 3 and 4 are 20 feet above sea level. But one document I ran across said that the cooling canals themselves range from only 3.7 feet above sea level to 8.7 feet above sea level. I've always felt very strongly about this. I've been hearing about it for the 20 years that I've been down here. But just a month ago I had the opportunity, we flew over the cooling canals and I'd like to give you these photos. I'm hoping that all of you have either seen photos or if you've had the chance to fly over it and see the extent to all, almost 6,500 acres of this muddy, dead water, that not only the salt is seeping into our aquifer, but it's just literally, you can see how close -- there's a small strip of land that prevents this from entering Biscayne Bay. (0001-9-3 [Bloom, Mary])

Comment: Turkey Point's geographic location makes it particularly susceptible to sea level rise and storm surge impacts. Under even the most optimistic sea level rise projection by the U.S. Army Corps of Engineers, Turkey Point and parts of the cooling canals will be inundated by 2040. This is 13 years before the end of the reactor's operating life under the re-licensing for Units 3 and 4. The supplemental EIS unfortunately does not include any analysis on future sea level rise projections and does not discuss measures to account for the near certain impacts from sea level rise, impacts that we're going to see during the life of the plant operations. The analysis is inadequate at assessing the full scope of the environmental impacts associated with re-licensing Units 3 and 4. (0001-10-1 [Schulman, Stacie])

Comment: Additionally, Turkey Point's geographic location makes it particularly susceptible to sea level rise and storm surge impacts. Under even the most optimistic sea level rise projections, Turkey Point and parts of the cooling canals will be inundated by 2040, 13 years before the end of the reactors' operating life if this proposal is approved. (0003-3 [Commenters, Multiple])

Comment: As an environmentalist and wildlife advocate, I am very concerned about the operation of the nuclear power plant at Turkey Point. There should be concrete measures addressing the rise of sea levels (0008-1 [Propen, Beverly])

Comment: Our waters are at serious risk already from plastics and pollution. We, as a country, need to be forward thinking in regards to global warming and rising waters. A old nuclear plant that is already suffering leaks and contaminating the ocean has no place in our future, especially since it is located in within the projected rising waters area and will be flooded. (0010-1 [Greene, JJ])

Comment: Another concern about the canals is in relation to climate change both from rising sea levels as well as storm surges from stronger storms. While the reactors themselves are twenty feet above sea level the canals range from 3.7 to 8.6 feet above sea level which could result in a direct exchange between heavily polluted and hypersaline canal waters with the surrounding Bay and wetlands. (0032-4 [Bloom, Mary])

Comment: What disaster are you leaving for our children? This is ludicrous not to plan ahead. Sea levels are ALREADY rising so sticking your head in the sand will not prevent disaster. (0034-1 [Lion, Sue])

Comment: This outdated nuclear plant is in the wrong place at the wrong time, as rising sea levels and increased hurricane intensity create unacceptable risk to the surrounding population and environment. (0041-1 [Lotz, Elizabeth])

Comment: We have seen what has happened in other states with extreme weather events- such as coal ash and farm animal waste contaminating ponds, lakes, and other waterways. This is a real threat that needs serious planning to prevent disaster.. (0046-2 [Champy, Cheryl])

Comment: To clarify, I am not anti-nuclear energy. However, there are many places where it is not safe to located a nuclear powerplant. Rising sea level is a fact, most certainly felt and seen in Florida. (0056-1 [Fleener, Teresa])

Comment: Please support Biscayne National Park, do not allow Turkey Point to continue operating until pollution is cleaned up and a solid plan is in place to address threats from rising sea levels! (0059-1 [Macraith, Bonnie])

Comment: It is totally wrong to ignore these problems because of greed and a reluctance to accept the science on waters that will rise due to climate change. Leaving this nuclear plant in place would be a disaster for the future health of our planet. You must use your common sense and wisdom. (0061-1 [Riparetti-Stepien, Melissa])

Comment: [T]he risk for contaminated water, rising sea levels, increase in hurricanes (climate change), etc. affecting millions of Florida's residents and tourists. Without proper regulatory plans and assured oversight addressing the above concerns would be irresponsible both morally and ethically. For all Americans and the planet please take the lead in making the TP NPP a model of safety and stewardship. (0065-1 [Battelli, Tony])

Comment: To consider expanding Turkey Point without fully considering the reality of its aging reactors and structure as well as the FACTS of climate change is irresponsible and potentially devastating to the area and its human and non-human populations. The wise course of action is to thoroughly assess the power plant's structure and functioning with regard to its future and its vulnerability to rising seas. (0068-1 [Seimer, Priscilla])

Comment: Nuclear power plants need to be prepared for climate extremes, not just in Florida. (0070-1 [Talbot, Thomas])

Comment: The Turkey Point area will likely be inundated in the very near future, and the nuclear reactor needs to be decommissioned and removed far before the rise in sea levels threatens the stability and safety of the reactor. (0072-2 [Nilon, Michael])

Comment: Why on Earth would any right minded nuclear plant management NOT have a plan for sea level rise (and other climate chaos disasters)? Nuclear plant managers in particular must ensure their plants will not contaminate local waters (and land and air) and will NOT continue to pollute even when inundated from rising seas (or other climate-triggered disasters). (0075-1 [Bender, Kae])

Comment: we know weather is becoming more extreme- including hurricanes - and we know that sea levels will rise. Nuclear power is not the best choice but it is a justifiable choice -though only when we take common sense precautions in consideration of the changing conditions that we will experience over the next few decades. Have plans and responses in place before extending operations. (0078-1 [Eikholt, Michele])

Comment: Once again, the regulatory bodies of the United States are ignoring science, but in this case it even has a negative impact on the group that profits from Turkey Point. The waters will rise; make the contingency plan now. (0082-1 [Buck, Julia])

Comment: In this time of unprecedented climate change, it is imperative that we work together to do everything humanly possible to prevent disasters that will harm all life: both aquatic and human. Biscayne is a nonpartisan threat with the certainty of harming Republicans, Democrats, and Independents alike. Please do everything you can to prevent this tragedy waiting to happen. (0100-1 [Bratcher, Suzanne])

Comment: Despite the president's continued rejection of the concept of global warming, the sea levels WILL rise and impact all facilities along our shores. PLEASE take measures to protect our children. (0109-2 [Luzum, Rosemary])

Comment: I spent most of my adult life in Alaska and have watched temperatures rise and aspen forests begin to tilt due to melting permafrost. I've seen business interests trump environmental concerns with destructive results many times over. (0116-1 [Webster, Pamela])

Comment: I support continued responsible use of nuclear power. But running a plant that already is contaminating the local area and not actively responding to rising sea levels is foolish to the point of- in my opinion - criminal negligence. Look at Fukushima and learn. Or close. (0120-1 [Waltz, Mike])

Comment: By Cutler Ridge, the town that was wiped off the map by Cat 5 hurricane Andrew? With climate changing and spawning more Cat 5s all the time? That's about as sensible as building a nuke plant on the San Andreas Fault. Don't do it! (0122-1 [Kisor, Dave])

Comment: HAVING WORKED ON BECHTEL'S ESTIMATING TEAM FOR TURKEY POINT IN 1968, I AM PARTICULARLY AWARE THAT NO CONSIDERATION WAS THEN GIVEN TO THE POSSIBILITY IF SEA LEVEL RISE. (0135-1 [Goodale, Margaret])

Comment: We need to prepare for one of the consequences of Climate Warming, namely, rising sea levels and the threat to near-shore infrastructures. This one is a real hazard. (0137-1 [Greene, William])

Comment: America's coastal power plants need to start planning and building now for sea level rise. Some Florida cities already have seawater in the streets at high tide every day. Hurricanes are getting more frequent and severe. (0141-1 [Williams, David])

Response: *The commenters express a number of concerns relating to the effects and implications of climate change including sea level rise, storm surge, flooding, and related extreme weather events on Turkey Point Units 3 and 4 and related infrastructure.*

As discussed above, and as documented in this SEIS, the purpose of the NRC's environmental review is to assess the potential effects on the environment from continued nuclear power plant operation. While the SEIS does consider the potential effects of climate change on environmental resource conditions, the effects of climate change on the safety of Turkey Point Units 3 and 4 structures, systems, and components are outside the scope of the NRC staff's license renewal environmental review. Rather, an operating nuclear power plant is subject to continuous NRC oversight under the Reactor Oversight Process where emerging safety and security issues are addressed. On an ongoing basis, this oversight assesses the safety of structures, systems, and components of a nuclear power plant, including their exposure to hazards such as flooding, as further described in Section 4.15.3.2 of this SEIS. In the event a condition is needed to ensure public safety, it would be imposed by the NRC as part of its oversight of the operating license, outside the scope of license renewal. In addition, the potential need for an aging management program to ensure the continued safety of various structures and components is addressed as part of the NRC staff's subsequent license renewal safety review, outside the scope of its environmental review.

In this SEIS, flood protection and the potential for flooding at Turkey Point is discussed as part of the NRC staff's description of the hydrologic environment, in Section 3.5.1.1, "Surface Water Hydrology" (see "Potential for Flooding at the Turkey Point Site"). The NRC staff has revised and expanded that subsection to address commenter concerns about flooding, storm surge, and sea level rise.

Further, Section 4.15.3.2 of the SEIS discusses and considers sea level rise studies and projections developed by the U.S. Global Change Research Program (USGCRP) and the 2015 Southeast Florida Regional Climate Change Compact. Potential changes in hurricane frequency and intensity, flooding, and heavy precipitation are also described. The USGCRP integrates the best available information and current state of knowledge regarding climate change trends and effects and provides consensus-based estimates across 13 Federal member agencies. The climate change information presented in the SEIS is based on information from the USGCRP's fourth national climate assessment published in 2017 and updated in 2018, as reflected in the final SEIS. The SEIS also compares sea level rise projections for several time periods, including 2030, 2050, and beyond to 2100; discusses the differences in projected sea level rise estimates; and the associated uncertainty in the projections.

Comment: Finally, the Draft SEIS simply ignores the effects of climate change and related sea level rise on termination and decommissioning of Turkey Point Units 3 and 4. If the subsequent license renewal is granted, Units 3 and 4 will be permitted to remain open until the

early 2050s. Decommissioning can reasonably be expected to take 60 years to complete. This means that decommissioning activities will likely continue past 2100, when sea level rise at Turkey Point could rise between four to ten feet above current levels.³⁴ NEPA requires this scenario and the relevant environmental impacts be analyzed, including the cost of armoring the plant against sea level rise and the environmental impacts of decommissioning when the plant is a virtual island.

Thus, the Draft SEIS fails to take a hard look at the foreseeably affected environment and how those climate change-related effects can add to Turkey Point's impact on the environment. 34 Declaration of Dr. Robert Kopp (July 26, 2018) (ML18213A433). (0021-7 [Ayres, Richard E.] [Cox, Kelly] [Fettus, Geoffrey H.] [Rumelt, Kenneth J.]

Comment: Likewise, the Draft SEIS avoids any analysis of how climate disruption and resulting sea level rise would affect the environmental impact of operating Turkey Point for a total of 80 years, with a further 60 years of decommissioning, instead hiding behind the climate naïve analysis of 50 years ago. In light of the changes in climate that have already begun, and we know will worsen over this century, a searching look at the effects of extending the operations of these nuclear reactors for a total of 80 years is essential, especially when that nuclear power plant sits on the tip of Florida where climate change is projected to significantly alter and impact the environment. (0021-10 [Ayres, Richard E.] [Cox, Kelly] [Fettus, Geoffrey H.] [Rumelt, Kenneth J.]

Comment: Florida and many other States along the coast that have these older plants in expected sea level rise regions may have to consider the COST of closing and dismantling of the plants post inundation...A cost far more egregious than executing plans to prevent inundation.....

Eventually these plants will have to close.... Let US not let that happen with the site under water, polluting a vast area of a National Treasure and forcing the restrictions required to protect EVERYONE from the most probable outcome..... (0026-2 [Gurtner, David])

Response: *The NRC licensing process for nuclear power plants (including subsequent license renewal) includes a thorough review of the environmental impacts of the proposed action and alternatives in accordance with the Council on Environmental Quality (CEQ) and NRC regulations for implementing NEPA, as documented in the SEIS. Section 4.15.2 of the SEIS describes the generic environmental impacts associated with the termination of operations and the decommissioning of Turkey Point. Specifically, NUREG-0586, Supplement 1, "Final Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities: Regarding the Decommissioning of Nuclear Power Reactors" (the Decommissioning GEIS), evaluates the environmental impacts from the activities associated with the decommissioning of any reactor before or at the end of an initial or renewed license (NRC 2002). Additionally, the License Renewal GEIS (NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants") (NRC 2013a) discusses the incremental environmental impacts associated with decommissioning activities resulting from continued plant operation during the renewal term.*

In addition, Section 4.15.3.2 of the SEIS presents, in part, the NRC staff's evaluation of the potential effects of climate change on environmental resource conditions. Section 4.16 of the SEIS presents the NRC staff's evaluation of the potential changes in environmental impacts from continued operations of Turkey Point Units 3 and 4 that may occur as a result of the changes to the environment resulting from global climate change including sea level rise. The climate change information presented in the SEIS is based on information from the U.S. Global

Change Research Program's (USGCRP's) fourth national climate assessment published in 2017 and updated in 2018, as reflected in the final SEIS. The climate change projections currently available and presented in Section 4.15.3.2 of the SEIS provide information to the year 2100, which includes a major part of the decommissioning timeline following culmination of the subsequent license renewal term for Turkey Point Units 3 and 4. As stated in Section 4.15.3.2, "Climate Change Projections," of the SEIS, the latest consensus estimates from the USGCRP indicate potential global sea level rise of 1 to 4.3 ft (0.3 to 1.3 m) by 2100. As also referenced in Section 4.15.3.2 of this SEIS, on an ongoing basis and outside the scope of the NRC's license renewal environmental review process, operating plants must deal with the effects of climate change (e.g., sea level rise) through the requirements of their license, including technical specifications, to provide reasonable assurance that the activities authorized by the license can be conducted without endangering the health and safety of the public, and to adequately manage the effects of aging so that structures, systems, and components that are important to safety will continue to perform their intended functions for the period of extended operation. Appropriate requirements would continue to apply to the facility throughout the decommissioning period, to ensure the protection of public health and safety. No new information is provided by these comments and no revisions were made to the SEIS as a result.

Comment: Here in Key Largo, we are already experiencing sunny day flooding from sea level rise. Turkey Point and its cooling canal system will also, if they do not already, be dealing with the consequence of sea level rise. Over time, the canals will experience more and more flooding and this will lead to even more industrial wastewater escaping the canal system.
(0004-2 [Moses, Dorothy])

Comment: Deficient Analysis of Reasonably Foreseeable Activities Regarding Flooding

In Section 3.5.1.1 (page 3-37) of the DSEIS, the NRC states that the L-31E Canal includes a levee with a crest elevation of 7 ft. (2.1 m) MSL. However, it is not designed to prevent flooding from severe hurricanes with tidal flooding. Based on published storm-tide frequency studies, it is estimated that a 7 ft. (2.1 m) tide may occur once every 20 to 25 years near the Turkey Point site (FPL 2018f). The increased potential for future coastal flooding based on climate change projections is discussed in Section 4.15.3.2 (Climate Change) of this SEIS.

In Section 4.15.3.2 of the DSEIS, the NRC then describes various reasonably foreseeable forecasts whereby sea level rise would increase such that the L-31E Canal would no longer prevent flooding during large tides and especially during severe hurricanes with tidal flooding.

In Section 4.16 of the DSEIS, NRC evaluates the potential cumulative impacts of reasonably foreseeable activities. However, this analysis is deficient because it does not analyze any reasonably foreseeable flooding events, in which case water from the CCS would directly enter the sanctuary. FKNMS agrees with the analysis, "Modeled Storm Surge from Category 3 and Category 5 Hurricanes," provided by the National Park Service,⁶ a cooperating agency on the DSEIS. Therefore, FKNMS recommends that NRC analyze the environmental impacts of a reasonably foreseeable flooding event whereby the waters within the CCS enter the sanctuary.

⁶ Vogel, Robert A.; Regional Director, Southeast Regional Office, National Park Service, Atlanta, GA. Letter to Ben Beasley, Chief, Environmental Review and NEPA Branch, U.S. Nuclear Regulatory Commission, Rockville, MD. 5 March 2019.

(0018-3 [Fangman, Sarah])

Comment: The Draft SEIS also did not adequately address the reasonably foreseeable impacts on surface water resources of operating Units 3 & 4 for another 20 years in conjunction with foreseeable sea level rise. The NRC Staff claim there is no need to analyze cumulative impacts because the proposed action "is unlikely to have any incremental impacts" on surface water.²⁷ But the Draft SEIS points to no analysis of potential impacts on surface water; rather, it assumes that there will be no surface water impacts because FPL's permit prohibits discharges to the surface water and because of requirements imposed by FDEP and DERM to mitigate the hypersaline plume.²⁸ These regulatory requirements alone, however, will not prevent surface water discharges when the cooling canal system is overtopped by reasonably foreseeable flooding.

FPL's own studies demonstrate surface water discharges from the cooling canal system are foreseeable. Figure 4-37 below is a representative cross section of the Turkey Point plant.²⁹ Below that (Figure 4-35) is a bird's-eye view of the cross section. FPL's consultant prepared these figures in connection with an NRC-mandated "Flooding Hazard Reevaluation Report" following the Fukushima disaster [view figures in pdf available from NRC ADAMS, Accession No. ML19141A253]. The studies show, and NRC Staff confirm, that flood water levels could reach up to 19.1 ft NAVD88 30--well above the 16 ft NAVD88 height of the breakwater barrier east of the power block shown in Figure 4-37 that separates Biscayne Bay from the cooling canal.³¹ Notably, this modeling effort only accounted for sea level rise through the current license period.³² It did not account for additional projected sea level rise and other climate-related flood risks during the subsequent license renewal period.

While the NRC Staff evaluated flooding for safety purposes, it ignored the impacts of flooding on the environment. The impacts of overtopping the cooling canal system are significant. Pollutants in the cooling canals will inundate the Biscayne Bay and the surrounding environment with hyper saline water, tritium, sediment, ammonia, and other pollutants in the cooling canals.
27 Id. at 4-111.

28 Id.

29 ENERCON Services Inc. "Turkey Point Units 3 and 4 Flood Hazard Reevaluation Report," (Mar. 11, 2013) (ML13095A196, ML13095A197).

30 NAVD88 is the North American Vertical Datum of 1988, an elevation benchmark.

31 NRC, "Staff Assessment by the Office of Nuclear Reactor Regulation Related to Mitigation Strategies for Turkey Point Nuclear Generating, Unit Nos. 3 and 4 as a Result of the Reevaluated Flooding Hazard Near-Term Task Force Recommendation 2.1-Flooding," 5 (Jun. 27, 2017) (ML17143A034).

32 FP&L, Letter, *NEI 12-06, Revision 2, Appendix G, G.4.2, Mitigating Strategies Assessment (MSA) for FLEX Strategies report for the New Flood Hazard Information," 16 (Dec. 20, 2016) (ML17012A065). (0021-6 [Ayres, Richard E.] [Cox, Kelly] [Fettus, Geoffrey H.] [Rumelt, Kenneth J.]

Comment: Failure to Analyze Impacts of Sea Level Rise and Storm Surge

Turkey Point's geographic location makes it particularly susceptible to sea level rise and storm surge impacts. The plant is situated on a low-lying peninsula, bordered by Biscayne Bay to the east and the Everglades to the west. FPL's License Renewal Application's Environmental Report for Units 3 & 4 states that "[t]he ground elevation at the site is typically less than 1 foot above mean sea level."³² The Environmental Report also notes that "the normal tide range of Biscayne Bay is about 2 feet. Natural (undeveloped) areas are inundated during high tide and can remain under 1 to 3 inches of water at low tide. Tidal flooding is a much more significant surface hydrological feature of the area than is rainfall runoff."³³

South Florida is already experiencing sea level rise and is expected to experience an increase in sea level rise, flooding and severity of hurricanes in upcoming years. Over the last 100 years, sea level around Turkey Point has risen approximately 9-12 inches and according to projections by the U.S. Army Corps of Engineers and the National Oceanic and Atmospheric Administration, sea level could rise between 5 and 6.75 feet by 2100.³⁴ These estimates show that Turkey Point and parts of the CCS will be inundated by the year 2040, well within the subsequent relicensing period.³⁵ As sea levels rise, waters in Biscayne Bay will rise above CCS levels and may overtop the berms surrounding the CCS during storm events. This water could then travel either over the berms or through subsurface pathways back into Biscayne Bay. Moreover, serious storms could threaten the integrity of the berms themselves, raising the risk of a total failure of the berms. The addition of nutrient-rich water from the CCS into nutrient-limited Biscayne Bay has the potential to disrupt sensitive ecological systems that Biscayne National Park was established to protect. FPL greatly underestimates future sea level rise, and in the DSEIS, NRC staff fail to adequately analyze the potential environmental impacts associated with sea level rise and the continued operation of the CCS. By underestimating sea level rise, adjacent waters are at risk of nutrient loading and harmful algae blooms if the CCS were to freely flow into Biscayne Bay. (0023-14 [McLaughlin, Caroline])

Comment: While the DSEIS refers to a flood analysis completed by FPL for Units 3 & 4 through 2032,³⁶ that flood analysis does not account for sea level rise and storm surge projections during the subsequent relicensing period and thus is inadequate to account for all future environmental impacts. The DSEIS fails to acknowledge the effects of climate change and sea level rise on the operations of Units 3 & 4 under the license renewal. The DSEIS must include an in-depth analysis that addresses science-based projections for sea level rise and climate change throughout the life of the requested licensing period. Specifically, the plan should detail measures to prevent future violations of stormwater and wastewater discharges into adjacent waters, violations which are inevitable under the current plan. (0023-15 [McLaughlin, Caroline])

Response: *The commenters express concern pertaining to the environmental impacts from the potential flooding of the cooling canal system as a result of sea level rise. As documented in this SEIS, the purpose of the NRC's environmental review is to assess the potential effects from continued nuclear power plant operation on the environment. Section 4.15.3.2 of the SEIS discusses the observed changes in climate change indicators, including sea level rise, flooding, storms, and the potential future climate change effects during the subsequent license renewal term based on climate model simulations under future global greenhouse gas emission scenarios. In Section 4.16 of the SEIS, the NRC staff considers the potential cumulative, or overlapping, impacts from climate change on environmental resources where there are incremental impacts of the proposed action (subsequent license renewal). The impacts on surface water quality from the flooding of the cooling canal system is discussed below. While the SEIS does consider the potential effects of climate change on environmental resource conditions, the effects of climate change on Turkey Point Units 3 and 4 structures, systems, and components, as a safety consideration, are outside the scope of the NRC staff's license renewal environmental review. Rather, operating plants must deal with the effects of climate change (e.g., sea level rise) through the safety-related requirements of their license, including technical specifications, to provide reasonable assurance that the activities authorized by the license can be conducted without endangering the health and safety of the public, and to adequately manage the effects of aging so that structures, systems, and components that are important to safety will continue to perform their intended functions for the period of extended operation, as further described in Section 4.15.3.2 of this SEIS.*

Over the period of license renewal, overtopping of the CCS or a release of CCS waters into adjacent surface waters due to flood damage to the CCS could occur infrequently, but if it occurs it is likely to cause only small changes to the water quality in Biscayne Bay and Card Sound. Flooding and flood damage to the CCS is not likely to occur except in the event of a hurricane. A hurricane would dilute the impact of CCS releases and would likely cause greater impacts to the water quality of Biscayne Bay or Card Sound than any flooding caused by release of CCS waters.

Water levels within the CCS are below the top of the limestone bedrock. Perimeter berms surround the CCS and are built on top of the bedrock. The berms vary in height from 4 to 10 ft (1.2 to 3 m) and vary in width from 25 to 100 ft (7.6 m to 30.5 m), with an average width of 50 ft (15.2 m) (Section 3.1.3.2 “Cooling Canal System (CCS)”). These berms are intended to prevent surface water from entering the CCS; they are not intended to contain water within the CCS, since CCS water levels are below the top of the CCS channels (Section 3.5.1.1 under “Potential for Flooding at the Turkey Point Site”).

The State of Florida’s draft NPDES permit and the NRC’s aging management program will require the monitoring of CCS structural integrity over the duration of the subsequent license renewal term. Special inspections will be performed following major events, such as hurricanes. Therefore, any structural integrity hazards to the CCS would be known before they become critical hurricanes (Section 3.5.1.1 under “Potential for Flooding at the Turkey Point Site”). Both the NRC and the State of Florida could take appropriate regulatory actions to assure that the structural integrity of the CCS is maintained throughout the subsequent license renewal period. Therefore, except in the event of major hurricanes, flooding and overtopping of the CCS is unlikely during the subsequent license renewal period.

As described in the SEIS, if overtopping or flood damage to the CCS were to occur, it would be caused by tidal flooding during hurricanes (Section 3.5.1.1 under “Potential for Flooding at the Turkey Point Site”). Most of the Turkey Point site is constructed within the coastal flood zone, as designated by the Federal Emergency Management Agency (i.e., floods with a 1-percent chance of occurring in any single year). The highest measured flood may have occurred at the site in September 1965, during Hurricane Betsy. Debris marks from the flood tide were seen at an elevation of approximately 10 ft (3 m) MSL. In 1999, during Hurricane Andrew, earthen material in a plug that separated the CCS from Biscayne Bay and in a plug that separated the CCS from Card Sound failed. After the storm, the plugs were repaired and later reinforced (MDC 2012). The storm surge for Hurricane Andrew occurred 8 miles north of the site, where it was 15.4 ft above mean sea level.

At the levels that have been measured within the CCS, tritium is not a public health concern (Section 3.5.1.4, “Adjacent Surface Water Quality and Cooling Canal System Operation”). Therefore, near the site, in the event of a release, it would not have an impact on surface water quality or other resources.

During a major hurricane, total flooding of the CCS would contribute a large amount of sea water and fresh water to the area occupied by the CCS. This would dilute the concentration of salt in the water of the CCS, as well as the concentrations of nutrients and tritium. As a result, the mixing of CCS waters with seawater and rainwater during a hurricane would not have a significant impact on surface waters near the site. If FPL achieves its CCS salinity and nutrient management goals, the impacts of any release on the area near the CCS would be further reduced (Section 3.4.1.4 under “Salinity within the Cooling Canal System”).

In the event of a hurricane, the water in Biscayne Bay and Card Sound can receive large quantities of nutrients from regional surface water runoff and from disturbed bottom sediments in the bay and sound. The addition of nutrients as the result of hurricanes can have serious negative and sometimes long-term impacts on the bay and sound (Section 3.5.1.1 under "Relationship of Water Quality to Biologic Communities in Biscayne Bay and Card Sound"). The release of nutrients from these sources would likely be far greater than a hurricane-caused release of nutrients from the CCS.

The staff has previously assessed the potential effects of climate change and flooding of the CCS in the Environmental Impact Statement for Combined Licenses for Turkey Point Nuclear Plant Units 6 and 7, Volume 3 (Appendix I of NRC 2016a). The staff determined that while storm surge damage to the CCS and other onsite features would result in the release of sediment and nutrients to Biscayne Bay, such damage would not be localized to the Turkey Point site, and the contribution by the Turkey Point site to the release of sediment and nutrients into Biscayne Bay would likely be a small fraction of the total sediment and nutrient load that would enter via the local waterways. Thus, even in the event of a hurricane, the release of CCS waters into adjacent surface waters may have no more than a SMALL impact on surface water quality in the bay and sound.

As part of the hydrologic environment, flood protection and the potential for flooding at Turkey Point is discussed in Section 3.5.1.1, "Surface Water Hydrology," of the SEIS (see "Potential for Flooding at the Turkey Point Site"). Sections 3.5.1.1 and 4.15.3.2 of the SEIS have been revised and expanded to include a discussion regarding FPL's aging management program, the NRC's oversight process, and the monitoring of CCS for potential degradation.

Comment: [The Draft SEIS fails to take this requisite hard look because, while it provides pieces of information about the effects of the Turkey Point subsequent relicensing and general facts about the environment, the Draft SEIS fails to account for the effects of climate change.]

B. Climate Change

The Draft SEIS also fails to take a hard-look at the impact of continuing to operate Turkey Point during a period marked by increasing severity of climate change impacts. The Draft SEIS recites a few general facts about climate change - which it attempts to discount - but fails to analyze how those facts relate to the action of subsequently relicensing Turkey Point. Dismissing it as beyond the scope, the Draft SEIS does not consider the substantial environmental impacts of the continuing operations of the Turkey Point reactors in the steadily changing climate of the licensing period. Rather, the Draft SEIS's discussion of climate change is a mere litany of generic facts without any analysis of how they relate to proposed subsequent relicensing of Turkey Point.

In reviewing climate change impacts on all alternatives, the Draft SEIS presents observed historical climate trends in the last century in south Florida and discusses and compares results of climate modeling scenarios with respect to rising sea levels, increasing temperatures, and severity of extreme weather events.¹⁰ Throughout this litany of climate projections, the Draft SEIS attempts to cast doubt on the accuracy of the federal government's climate projections, inaccurately communicates the urgency with which these projections were reported, and dismisses the notion that new information about changing environmental conditions is available.¹¹ The most recent science, however, is clear and pointed.

For example, global mean sea level in the area around Turkey Point has risen over the past century and is projected to continue rising at an accelerated rate throughout this century and beyond. In every reasonably foreseeable climate change scenario, sea-level rise for south Florida, including around Turkey Point, will be faster than the average over the last century. Relative to the year 2000, there is at least a 90 percent probability that global mean sea level will rise by 0.3-0.6 feet by 2030 and 0.5-1.2 feet by 2050. By 2100, there is a 15 to 83 percent chance that average sea level will exceed 4 feet if today's rate of growth in emissions of greenhouse gases continues.¹² This sea-level rise will increase the frequency and degree of extreme flooding, which will exacerbate storm surges.¹³ Thus, climate reports emphasize "the need to consider revising flood study techniques and standards that are currently used to design and build coastal infrastructure."¹⁴

Despite these alarming findings, the Draft SEIS asserts that the NRC may relicense the plant relying on a fifty-year old understanding of climate perturbation.¹⁵ In a rapidly changing climate regime, the NRC cannot rely on "environmental conditions . . . considered when siting" Turkey Point fifty years ago that, as the Draft SEIS admits, no longer exist today, let alone during the proposed subsequent license renewal period ending in 2053. The NRC cannot meet its obligations under NEPA to take a "hard look" at the environmental consequences of its proposed further extension of the license using outdated assumptions of a stable climate made half a century ago, devoid of the most recent science.

10 Draft SEIS at 4.15.3.

11 Draft SEIS at 4-108 to 4-111.

12 Declaration of Dr. Robert Kopp (July 26, 2018) (ML18213A433) (referencing William V. Sweet et al., "Sea Level Rise," in CLIMATE SCIENCE SPECIAL REPORT: FOURTH NATIONAL CLIMATE ASSESSMENT, Vol. 1 333-363 (D.J. Wuebbles et al. eds., 2017)).

13 Id.

14 U.S. Global Change Research Program, CLIMATE SCIENCE SPECIAL REPORT: FOURTH NATIONAL CLIMATE ASSESSMENT (2018) (emphasis added).

15 Draft SEIS at 4-110 ("The effects of climate change on Turkey Point Unit 3 and 4 structures, systems, and components are outside the scope of the NRC staff's license renewal environmental review [because] Site-specific environmental conditions are considered when siting nuclear power plants."). (0021-4 [Ayres, Richard E.] [Cox, Kelly] [Fettus, Geoffrey H.] [Rumelt, Kenneth J.]

Comment: As we noted at the outset, rather than comply with well-established NEPA requirements of taking a "hard look" at the environmental impacts of a major federal action, the Draft SEIS provides some disjointed facts about climate change and sea level rise without relating them to the issue at hand--further extension of the operating license for Turkey Point--or analyzing how the facts recited affect the environmental impact of the plant. (0021-8 [Ayres, Richard E.] [Cox, Kelly] [Fettus, Geoffrey H.] [Rumelt, Kenneth J.]

Response: *The commenters express concerns that the SEIS did not take a "hard look" at climate change and did not consider the effect of climate change on environmental impacts of the proposed action. Contrary to the commenter's statements, the NRC staff considered the effects of climate change and associated impacts on the environment in Chapter 4 of the SEIS. Section 4.15.3.2 of the SEIS discusses the observed changes in climate change indicators, including sea level rise, flooding, storms, and the potential future climate change effects during the subsequent license renewal term based on climate model simulations under future global greenhouse gas emission scenarios. In Section 4.16 of the SEIS, the NRC staff*

considers the potential cumulative, or overlapping, impacts from climate change on environmental resources where there are incremental impacts of the proposed action (subsequent license renewal). As noted in Section 4.16 of the SEIS, changes in climate could have broad implications for certain resource areas and therefore the SEIS provides a climate change impact discussion for those resource areas that could be incrementally impacted by the proposed action, as presented in Sections 4.16.1 through 4.16.6, 4.16.8, and 4.16.10. No new information is provided by these comments and no revisions were made to the SEIS as a result.

Comment: What happens if this 6th fix fails and FPL devises a new plan for the 7th time which has all they have been required to do by the regulatory authorities for the last 35 years. Our aquifer and our drinking water supply as well as our bay continues at risk. The last time FPL had a live pollution permit was in 2005 and it was not extended because FPL have not provided a solution that works to date. Although the existing permit and the Clean Water Act prohibits discharging any "pollutants" directly and indirectly into a "water of the United States," the cooling canals have been leaking into the aquifer and the bay for decades, which is why FPL was cited by DERM and FDEP with violations several years ago. Why would the FDEP issue the new permit before FPL demonstrates that the current plan is successful? Under the Florida Administrative Code back sliding is not permitted where there have been violations by the holder of the NPDES permit so the issuance of a less restrictive permit under these circumstances violates FDEP's own rules and is subject to legal challenge. If the FPL proposed changes to this permit are approved without the cooling towers, it appears that the current polluted water leakage from the groundwater/ cooling canals into the aquifer, bay and Card Sound will continue.

The CCS at TPPP, which lies almost at sea level along the bay, is also at risk of being toppled during storm surges and hurricanes. Rising seas due to changing climate conditions also threaten the cooling canal system going forward. Serious safety concerns are presented by these issues.

For all of these reasons, we are asking that NRC require FPL to upgrade the TPPP by requiring one of the recognized new alternative options be installed, all of which include mechanical draft cooling towers, which have been recognized as the best available cooling technology for nuclear reactors for many years, and that FDEP require FPL to cease operations of the cooling canals because of the ongoing pollution to the bay and our sole source aquifer unless the remediation required in the Consent Decree is successful in the next four years. (0024-7 [List, Gary])

Response: *The NRC does not have the regulatory authority to require that FPL implement an alternative closed-loop cooling water system as a license condition. The SEIS evaluates an alternative cooling water system technology for Turkey Point Units 3 and 4 that might be used to mitigate potential impacts associated with the continued use of the existing cooling canal system. The purpose of this analysis is for the NRC staff to compare the impacts of an alternative closed-cycle cooling system with the proposed action's impacts, to inform the NRC's licensing decision, decisions by other decisionmakers, and the public, as applicable, under NEPA. However, the NRC has neither the statutory nor the regulatory authority to determine which system or technology should be used, or to decide other permitting issues, for which the State of Florida has been delegated regulatory authority under Section 402 of the Clean Water Act, National Pollutant Discharge Elimination System.*

As documented in this SEIS, the purpose of the NRC's environmental review is to assess the potential effects of subsequent license renewal of Turkey Point Units 3 and 4 on the environment. While the SEIS does consider the potential effects of climate change on environmental resource conditions, the effects of climate change on Turkey Point Units 3 and 4

structures, systems, and components, as a safety consideration, are outside the scope of the NRC staff's environmental review. Rather, operating plants must deal with the effects of climate change (e.g., sea level rise) through the requirements of their licenses, including technical specifications, to provide reasonable assurance that the activities authorized by the license can be conducted without endangering the health and safety of the public, and to adequately manage the effects of aging so that structures, systems, and components that are important to safety will continue to perform their intended functions for the period of extended operation, as further described in Section 4.15.3.2 of this SEIS. Furthermore, an operating nuclear power plant is subject to continuous NRC oversight under the Reactor Oversight Process where emerging safety and security issues are addressed. On an ongoing basis, this oversight assesses the adequacy of structures, systems, and components of a nuclear power plant, including their exposure to hazards such as flooding, as further described in Section 4.15.3.2 of this SEIS. In the event a condition is needed to ensure public safety, it would be imposed by the NRC as part of its oversight of the operating license, outside the scope of license renewal. In addition, the potential need for an aging management program to assure the continued safety of structures and components is addressed as part of the NRC staff's subsequent license renewal safety review, outside the scope of its environmental review.

This comment provides no new information and no changes have been made to this SEIS as a result.

Comment: Climate Resiliency: The EPA notes that the NRC has provided a discussion regarding climate change, adaptation and resiliency, current projections of climate change in Florida and the southeast (including acceleration of sea level rise, storm surge, decreased availability of fresh water and the resulting freshwater demands on aquifers, and increases in wind and rainfall due to extreme weather events). The analysis, however, did not discuss how these changes would potentially impact Nuclear Generating Units 3 and 4. On page 4-110, the analysis specifically indicated:

"The effects of climate change on Turkey Point Unit 3 and 4 structures, systems, and components are outside the scope of the NRC staff's license renewal environmental review. The environmental review documents the potential effects from continued nuclear power plant operation on the environment The NRC conducts safety reviews prior to allowing licensees to make operational changes due to changing environmental conditions. Additionally, the NRC evaluates nuclear power plant operating conditions and physical infrastructure to ensure ongoing safe operations under the plant's initial and renewed operating licenses, through the NRC's Reactor Oversight Program. If new information about changing environmental conditions (such as rising sea levels that threaten safe operating conditions or challenge compliance with the plant's technical specifications) becomes available, the NRC will evaluate the new information to determine if any safety-related changes are needed at licensed nuclear power plants. This is a separate and distinct process from the NRC staff's subsequent license renewal environmental review that it conducts in accordance with the National Environmental Policy Act (NEPA)."

The NRC has indicated that the scheduled public release of both the FSEIS and the Final Safety Evaluation Report (FSER) will be August 2019¹. It is important that the pertinent hurricane and storm resiliency information from the FSER be included in the FSEIS.

¹ Eric R. Oesterle, "Schedule Revision for the Review of the Turkey Point Nuclear Generating Unit Nos. 3 and 4 Subsequent license Renewal Application (EPID NOS. L-2018-LNE-00011L-2018-RNW-0002)", Nuclear Regulatory Commission, Washington D.C., May 3, 2019.

Recommendation: For NEPA disclosure, the EPA recommends the NRC evaluate potential impacts that climate change might have on the nuclear units and supporting facilities such as the CCS, transportation routes (roads, barge traffic) etc. The EPA also recommends the NRC provide any preliminary findings from the FSER within the FSEIS. The EPA recommends adding climate resiliency as an impact area for the comparison of the alternatives. (0031-17 [Militscher, Christopher])

Response: *As observed by the EPA, Section 4.15.3.2 of this SEIS includes the NRC staff's evaluation of observed trends in and effects of climate change on environmental resources as well as the potential implications of future changes in climate change indicators. However, the NRC staff has not provided an evaluation of the potential impacts of climate change on nuclear power plant operations because the purpose of the SEIS is to evaluate the potential environmental impacts of the proposed action (subsequent license renewal) and alternatives to the proposed action. Evaluation of potential climate change safety-related impacts, including the impacts of sea level rise, flooding, and storm surge on nuclear power plant operations and physical infrastructure are outside the scope of the NRC's license renewal environmental review. However, within the context of the environmental review, the NRC takes into consideration the effects of climate change in combination with impacts of continued plant operation in its cumulative impacts evaluation; in addition, external hazards, such as flooding, are considered as part of the NRC staff's evaluation of FPL's severe accident mitigation alternatives (SAMA) analysis, in which the staff conducted an evaluation of any new and significant information with respect to external hazards. This is referenced in Section 4.11.1.3 of this SEIS and further documented in Appendix E. Separately, however, the NRC addresses potential hazards such as from natural phenomena to safe operation of a nuclear power plant through its ongoing oversight of operating licenses, as noted by EPA in its comments and as referenced in Section 4.15.3.2 of this SEIS.*

The NRC's safety evaluation report (SER) for license renewal does not specifically evaluate topics such as hurricane and storm resiliency as these issues, along with other natural phenomena, are evaluated on an ongoing basis outside the scope of the NRC's license renewal safety and environmental reviews. In addition, as described in 10 CFR Part 54 of the NRC's regulations, the focus of the NRC staff's license renewal safety review as documented in the safety evaluation report is to verify that the license renewal applicant has identified aging effects that could impair the ability of structures and components within the scope of license renewal to perform their intended functions, and to demonstrate that these effects will be adequately managed during the proposed period of extended operation. The SER documents the staff's evaluation of the applicant's aging management programs for systems, structures, and components within the scope of license renewal, including its aging management program for the cooling canal system. The NRC staff disagrees, however, with the commenter's suggestion that "climate resiliency" be included as a factor in comparing alternatives, as no such comparison is possible without knowing the design and siting characteristics of the replacement power and cooling water system alternatives evaluated in this SEIS. As presented in Section 2.2 of this SEIS, the SEIS evaluates the environmental impacts of the proposed action (subsequent license renewal) and alternatives to license renewal, including the no-action alternative (not renewing the operating license) and the comparative impacts of replacement power alternatives.

No changes were made to the SEIS as a result of this comment.

Comment: Hurricane and Storm Impacts: As noted in the previous comment, the NRC intends to discuss information regarding hurricane and storm surge impacts in the FSER. On page 3-36, the SD EIS states, "Components vital to safety, with the exception of the intake cooling water (JCW) pumps, which are protected to 22.5 feet (6.9 m) MSL, are protected against flood tides and waves up to 22 feet (6.7 m) MSL on the east side of Turkey Point (FPL 20181). "As a part of the FSER for the Turkey Point Nuclear Units 6 and 7 Combined Operating License (COL)2, the NRC conducted various hurricane and storm impact evaluations for the proposed nuclear units and supporting facilities. The EPA notes that on page 2-138 of the FSER the NRC states:

"The applicant noted that the estimated PMSS [Probable Maximum Storm Surge Analysis] still-water level at Turkey Point Units 6 and 7, combined with coincidental wind-wave run-up, of approximately 24.8ft (7.6 m) NAVD 88 is lower than the design plant grade elevation of 26 ft (7.9 m) NAVD 88 for safety-related facilities. Therefore, the applicant concluded that the postulated PMH {Probable Maximum Hurricane} event does not affect the safety functions of the plant, and debris, waterborne projectiles, and sediment erosion and deposition are not of concern to the safety-related facilities.e" (0031-18 [Militscher, Christopher])

Comment: As written in the SDEIS, it would appear that "components vital to safety" could be compromised because vital facilities at the existing plant would have protection up to 22-22.5' while the PMSS from the FSER for proposed Nuclear Units 6 and 7 indicates a possible storm surge of up to 24.8'. The EPA acknowledges and defers to the NRC on matters of nuclear safety. However, there is a concern that the SDEIS does not adequately disclose storm surge impacts to the facility and potential damaging environmental impacts that could result from the facility being compromised during a hurricane or severe storm event.

The EPA has provided past technical comments on hurricane and storm analysis (Reference: Turkey Point Nuclear Units 6 and 7 COL's DEIS (July 17, 2015) and the FEIS (December 22, 2016). One particular issue that is applicable to this SD EIS is the lack of discussion and evaluation regarding potential damages that might be incurred to the nuclear units and supporting facilities (i.e., wave erosion and undercutting of the facility, damage due to debris impacts, etc.). In addition, the SDEIS did not factor in reasonably foreseeable future land use and population growth in considering the potential impacts of a catastrophic storm event and its environmental impacts on the facility and surrounding areas.

There is no distinct section within the SDEIS that describes potential damaging impacts that hurricane and storms could have on Nuclear Units 3 and 4 and supporting facilities. Additionally, there is no discussion regarding the adverse impacts on the surrounding environment or habitat associated with facility failures related to hurricane and storm events. An example is that there is no discussion regarding the potential impacts that a hurricane or storm could have on flooding the CCS. Presumably, heavy precipitation and/or storm surge could potentially impact the hypersalinity plume within the Biscayne aquifer or release harmful nutrients and contaminants to the surrounding environment which could adversely impact water quality and aquatic species.

Recommendations: The EPA recommends that a section in the FSEIS regarding hurricane and storm impacts be included and be considered a discrete "impact area" to be used in evaluating each alternative's impacts. The EPA recommends the NRC disclose potential 'reasonable and foreseeable' hurricane and storm impacts (heavy precipitation, storm surge, wave erosion/undercutting and debris impacts) to the nuclear units and supporting facilities. Additionally, the EPA recommends the NRC disclose impacts to the surrounding environment (i.e., ecosystems and water quality of Biscayne Bay, impacts to Biscayne Aquifer including the

hypersalinity plume, etc.) should the CCS be flooded during a hurricane or severe storm event. (0031-19 [Militscher, Christopher])

Response: *The NRC understands that the EPA is concerned about the impacts of storm surge on Turkey Point Units 3 and 4, citing the Probable Maximum Storm Surge (PMSS) estimate prepared for proposed Units 6 and 7. The effects of external hazards on Turkey Point Units 3 and 4 structures, systems, and components are outside the scope of the NRC staff's subsequent license renewal environmental review. This SEIS, which was prepared as part of the environmental review, provides a thorough assessment of the environmental impacts of the proposed action and alternatives in accordance with CEQ regulations and the NRC's regulations for implementing NEPA at 10 CFR Part 51. Operating plants must deal with the effects of external hazards (e.g., heavy precipitation, storm surge, flooding, and associated effects) through the requirements of their licenses, including technical specifications, to ensure that structures, systems, and components important to safety comply with applicable regulations and license requirements, as described in Sections 3.5.1.1 and 4.15.3.2 of this SEIS. As part of the NRC staff's description of Turkey Point's hydrologic environment, flood protection and the potential for flooding at Turkey Point are discussed in Section 3.5.1.1, "Surface Water Hydrology," of the SEIS (see "Potential for Flooding at the Turkey Point Site"). The NRC staff has revised and expanded this subsection to address commenter concerns about flooding, storm surge, and sea level rise. Also, as discussed in Sections 3.5.1.1 and 4.15.3.2, FPL has proposed an aging management program for the CCS berms, providing for the inspection and maintenance of the berms throughout the period of subsequent license renewal.*

An evaluation of impacts over the period of subsequent license renewal, from CCS flooding is discussed in response to the comment titled "Failure to Analyze Impacts of Sea Level Rise and Storm Surge." The evaluation concludes that over the period of subsequent license renewal, overtopping of the CCS or a release of CCS waters into adjacent surface waters due to flood damage to the CCS could occur infrequently. Flooding and flood damage to the CCS is not likely to occur except in the event of a hurricane. However, if it occurs it is likely to cause only small changes to the water quality in Biscayne Bay and Card Sound. A hurricane would dilute the impact of CCS releases and would likely cause greater impacts to the water quality of Biscayne Bay or Card Sound than any flooding caused by a release of CCS waters.

The difference between storm surge water surface elevations for Turkey Point Units 3 and 4 and proposed Units 6 and 7 is described in Section 3.5.1.1, "Surface Water Hydrology," ("Potential for Flooding at the Turkey Point Site"). The flood analysis for Units 3 and 4 contained a maximum storm surge projection of 19.1 ft (5.8 m). In a separate and independent analysis, the maximum storm surge projection for the design of proposed Units 6 and 7 at the Turkey Point site was 24.8 ft (7.6 m). In the analysis for Units 3 and 4, FPL used a detailed model that contained more realism than the less detailed deterministic model used by FPL for Units 6 and 7. To account for the less detailed evaluation, more conservative assumptions were incorporated into the analysis for the Units 6 and 7 model. For example, the assumptions in the model used for Units 6 and 7 included (1) a hypothetical hurricane with an intensity much greater than has ever been observed in the Atlantic Ocean and (2) an additional 20 percent added margin to the final computed storm surge water level. This resulted in a higher maximum storm surge projection in the Units 6 and 7 analysis.

As stated earlier, operating plants' structures, systems, and components are continually evaluated for external hazards under the NRC's Reactor Oversight Process where emerging safety and security issues are addressed. On an ongoing basis, this oversight assesses the

adequacy of structures, systems, and components of a nuclear power plant, including their exposure to hazards such as flooding. The NRC's reactor oversight program will continue in effect throughout the period of subsequent license renewal.

This comment provides no new information and no changes were made to this SEIS as a result.

Comment: In every instance, the Draft SEIS fails to adequately take into account foreseeable effects of climate change in analyzing the proposed action's environmental impacts. For example, in analyzing the cumulative impacts of climate change as related to the subsequent relicensing of Turkey Point, the Draft SEIS relies on a prior Environmental Impact Statement for the bulk of its cumulative impacts analysis for water resources.¹⁶ However, that Environmental Impact Statement evaluates a proposed cooling tower system rather than the cooling canal system and thus would have distinctly different impacts on water resources. Even after acknowledging that "Climate change can impact groundwater availability and quality as a result of changes in temperature and precipitation, as well as due to sea level rise,"¹⁷ the Draft SEIS fails to discuss how groundwater availability and quality will affect the environmental impact of the continued operation of Turkey Point Units 3 and 4. This is not the "hard look" and cumulative impact analysis NEPA requires.

Case in point is the Draft SEIS's analysis of FPL's "freshening" effort. FPL is required to lower the salinity of the cooling canal system by pumping low saline groundwater from subsurface aquifers to the cooling canal system. Several factors will affect this effort:

1. Groundwater salinity in the Upper Floridan aquifer. The more saline the extracted water, the less it can "freshen" the cooling canal system.¹⁸
2. Air temperature. Hotter air temperatures increase the rate of evaporation in the cooling canal system leading to higher salinity.
3. Water temperature. Hotter water temperatures increase evaporation in the cooling canal system leading to higher salinity.¹⁹
4. Precipitation. Less precipitation (i.e., freshwater recharge) will lead to higher levels of salinity.²⁰
5. Scarcity. FPL could be required to reduce its use of groundwater or take other measures if the "freshening" efforts harms offsite groundwater users.²¹

Climate change will negatively impact each of these factors. Sea level rise will lead to additional saltwater intrusion, which has "significant implications" for Miami-Dade County and others. "Increased salinity levels in groundwater supplies would increasingly require public and private groundwater users to invest in treatment technologies (e.g., desalination), to relocate supply wells and supporting infrastructure, to seek out and develop new water supply sources, or to pursue a combination of approaches to manage degraded groundwater quality." ²² Air temperatures will rise by 1.9-2.4 °C across the southeast by mid-century according to recent modeling.²³ Drought will become more frequent in the southeast due to extended periods without precipitation.²⁴ And water will become scarcer as demand increases. *Water demand across South Florida is projected to increase by more than 50 percent by 2060, relative to 2005, based on combined changes in population, socioeconomic conditions, and climate. For most of Florida, this increase in demand is forecast even without assuming climate change. Regardless, climate change, mainly due to increases in temperature and evapotranspiration, would decrease water availability and further drive demand."²⁵

The Draft SEIS fails to account for these changes in its evaluation of impacts on water resources or its cumulative impacts analysis. None of the models referenced in the Draft SEIS address these factors despite all indications showing FPL will need more fresh water to address rising salinity at the same time regional demand is increasing. That the Draft SEIS ignores these issues is particularly troubling given FPL's freshening efforts have not delivered the expected results and FPL is optimistic that freshening will work under "more favorable climatic conditions (e.g., less severe dry seasons) . . ."26

16 U.S. Nuclear Regulatory Commission, Environmental Impact Statement for 23 Combined Licenses (COLs) for Turkey Point Nuclear Plant Units 6 and 7, Final Report, I-5 (Oct. 24, 2016) (ML16335A219).

17 Draft SEIS at 4-117.

18 Tetra Tech, "Evaluation of Required Floridan Water for Salinity Reduction in the Cooling Canal System" 3 (May 9, 2014) (ML14279A555).

19 Draft SEIS at 3-46.

20 Draft SEIS at 3-46.

21 Id. at 4-32.

22 Id. at 4-118.

23 Id. at 4-107 to 4-108.

24 Carter, et. al, "Southeast" in FOURTH NATIONAL CLIMATE ASSESSMENT, VOL. II 775 (Reidmiller, D.R., et. al. eds., 2018).

25 Draft SEIS at 4-117.

26 Id. at 3-49. (0021-5 [Ayres, Richard E.] [Cox, Kelly] [Fettus, Geoffrey H.] [Rumelt, Kenneth J.]

Response:

The NRC staff has taken the required hard look at the potential cumulative impacts on water resources, including groundwater use and quality, under the proposed action (subsequent license renewal), and has further considered the possible effects of climate change based on the best available information. In accordance with the Council on Environmental Quality's regulations as well as the NRC's regulations for implementing NEPA, the NRC staff has incorporated by reference, where appropriate, throughout Section 4.16 of this SEIS, the NRC's prior cumulative impacts analysis for the Turkey Point site as contained in Chapter 7 and Appendix I of the final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176). That prior analysis specifically considered climate change. In preparing this SEIS, the NRC staff also considered other past, present, and reasonably foreseeable future actions including new information that has been identified since publication of the NRC's final EIS for the Turkey Point Units 6 and 7 combined licenses (NUREG-2176) and the draft SEIS for subsequent license renewal for Turkey Point Units 3 and 4. In Section 4.16.2.1 of this SEIS, the NRC staff has included a cumulative impacts analysis for groundwater resources.

The staff's cumulative impacts analysis for groundwater resources in Section 4.16.2.1 of the SEIS relies, in part, upon the incremental impacts of the proposed action, which were evaluated by the NRC staff in Section 4.5.1.2 of the SEIS with respect to groundwater quality degradation and water use conflicts. Specifically, Section 4.5.1.2 of the SEIS, as referenced by the commenter, considers the continued operation of Turkey Point Units 3 and 4 using the current CCS, including consideration of FPL's ongoing CCS freshening activities using groundwater withdrawn from the Upper Floridan aquifer as well as hypersaline plume remediation using FPL's recovery well system (RWS). The modeling analysis considered by the NRC staff assumed that FPL's freshening wells would operate at maximum permitted rates, combined with

other existing permitted withdrawals (using permitted rates) in the region. Section 4.5.1.2 has been revised in this SEIS based on the NRC staff's consideration of information that has become available since the draft SEIS was prepared. Section 4.16.2.1 also considers potential groundwater use conflicts arising from groundwater use by persons or entities other than Turkey Point.

The commenter further states that several factors, including future sea level rise and reduced water availability under a warming climate, may substantially affect FPL's ongoing CCS freshening efforts and that FPL's ongoing efforts have failed to deliver expected results. The NRC staff acknowledges these climate change considerations as reflected in Section 4.16.2.1 of the SEIS and as further described in Section 4.15.3.2. The staff's groundwater cumulative impacts analysis for the proposed subsequent license renewal considers observed trends in climate change indicators (e.g., temperature, precipitation, sea level rise) and projections in future conditions based on consensus data from the U.S. Global Change Research Program.

The NRC staff has projected potential cumulative impacts on groundwater resources for the 20-year subsequent license renewal term (beginning in 2032 and 2033 for Turkey Point Units 3 and 4, respectively) based on the best available information considering certain current and projected environmental conditions such as water availability. In the near term, CCS freshening activities are linked with FPL's ongoing hypersaline plume remediation efforts. As referenced in Section 4.16.2.1, FPL is required under the terms of the 2015 Consent Agreement with Miami-Dade County and the 2016 FDEP Consent Order to intercept, capture, and retract the hypersaline plume within 10 years of startup of the recovery well system (i.e., by about 2028 and prior to the start of the proposed subsequent license renewal term). As a result, the modeling study alluded to by the commenter and cited in Sections 4.5.1.2 and 4.16.2.1 of this SEIS (i.e., Tetra Tech 2014b) generally relied upon current hydrologic and water quality conditions as they exist in the Upper Floridan aquifer, rather than conditions that might exist after the mandated FDEP Consent Order compliance deadline.

The NRC staff acknowledges that there is substantial inherent uncertainty in groundwater modeling as well as in future hydrologic conditions given climate change. The NRC staff is unable to speculate on what additional measures, if any, the responsible regulatory agencies might require FPL to undertake if ongoing CCS freshening efforts and hypersaline plume recovery efforts are unsuccessful due to the effects of climate change, or other factors. While FPL's groundwater withdrawals, either from the Upper Floridan aquifer or from the Biscayne aquifer, could conceivably increase, the NRC staff has no basis for estimating any such increases based on unknown future conditions. Any such withdrawal increases would require additional review and approval from the responsible State agencies. Meanwhile, in contrast to the commenter's view, the staff notes that FPL's salinity management efforts to date using water from the Upper Floridan aquifer have been effective in reducing the annual average salinity of the CCS, as described in Sections 3.5.1.4 and 4.5.1.2 of this SEIS.

This comment provides no new information and no changes were made to this SEIS as a result.

A.2.5 Cumulative Impacts

Comment: It's vital to protect our natural resources for current and future generations. (0052-1 [Altfater, Valerie])

Response: *The NRC staff considers past, present, and reasonably foreseeable future actions in its process for assessing cumulative impacts. In its cumulative impacts analysis, the NRC staff follows the requirements of NEPA, the NRC's regulations, and the guidance provided in NUREG-1555, Supplement 1, Revision 1, the Environmental Standard Review Plan for Operating License Renewal (NRC 2013b). Chapter 3 of the SEIS describes the current environmental conditions at the Turkey Point site and in the surrounding region. Chapter 4 assesses the potential environmental impacts of subsequent license renewal of the Turkey Point Units 3 and 4 operating licenses and alternatives, including a discussion of cumulative impacts in Section 4.16. The FSEIS considers the impacts of subsequent license renewal upon a range of resource areas, consistent with the commenter's stated concern. The NRC staff did not revise the SEIS based on this comment.*

A.2.6 Ecological Resources

Comment: Turkey Point's cooling canal system has been leaking nutrient-rich hyper-saline water into surrounding waters for over 30 years, dumping 3 million pounds of salt per day into Biscayne Bay As a result, 80 percent of Biscayne Bay seagrass ... have been destroyed. (0001-4-2 [Pierce, Barbara])

Comment: I want you to imagine millions of people behind me, just the people that have spoken in this room this afternoon, represent the millions of people in this area. So I really want you to think long and hard on that as you sit through these meetings, after meetings after meetings and then go and analyze this data, really what we're impacting here. Even though this is my busiest time of year, I'm here because there is no doubt that there is a loss of seagrass and increased salinity that has occurred from the operation of this nuclear facility, which is impacting my livelihood. (0001-11-2 [Friedman, Steve])

Comment: So since a year, we have discovered new information and I think everybody's comments just about start to capture that. We have discovered dead zones of seagrass in the near shore area of Turkey Point, especially near the Arsenicker's. We put this information together in a poster that we just presented at the Greater Everglades Environmental Symposium. And I hung it in the back of the room and I've given you a copy of that. So the reason this is important is it shows definitive evidence that 30 percent of the time the cooling canal system is failing to protect surface waters of the United States. And that means that through groundwater it's seeping up into the seagrass, adding nutrients, salinity and creating a plume in Biscayne National Park and the Marine Sanctuary. Why is that important? Because you -- well, not you, but the permitted facility was supposed to be a closed loop system on all sides. To date there have not been definitive evidence to show you exactly what that's doing to the environment and I'm here to tell you that seagrass holds that information for a very long time. So you can actually take a seagrass blade, test it for nutrients, you can test pour water, and it tells you exactly what's happening there. So we've finally been able to put that information together since the Scoping Meeting after we discovered those dead zones, and now you can see from the image. In the bottom left hand corner, you can see the outline of the plume and how it's impacting two National protected entities, the Marine Sanctuary and the National Park. And why does this sort of change the eco system? Because as you add nutrients, the seagrass actually increases in density and eventually die. That's already happening now. (0001-13-1 [Reynolds, Laura])

Comment: I will also be submitting a fly over that I did to Turkey Point and the canals and the surrounding region. I am not a scientist per se. I did study geology in college and environmental science, but that doesn't make me a scientist. But it does give me a little bit of reference. And I

did note environmental decay. I also noticed and the video documents that, a scary plume that intermittently emerged in one of the seven sounds directly south from the cooling canals. It looked to me, based on my experience, like a high salt plume, actually extruding out and upward from a sand flat. It concerned me pretty significantly because there was no life in that sound. It was completely devoid of life and the perimeter ecology on the outskirts of that sound were also in decay. No seagrass to be found. It was completely devoid of life. That scares me because I have flown over that sound before and have seen life, so I've seen a pre and a post, and it concerns me, so I will be submitting that to record as well. I want to point to the modeling concern. Taken just FPL's model and a comment that was made earlier about agencies. You do have Federal agencies that are driving a certain model condition and a conservative model condition. In other words, other agencies can use a conservation track, an intermediary track based on the UN standards, or a more aggressive track based on the EU standards. And I wonder why we are not taking those into account. (0001-15-1 [Gomez, Albert])

Comment: Since Turkey Pont's cooling canal system has been leaking nutrient-rich hypersaline water into Biscayne Bay ... for over 30 years, 80 percent of Biscayne Bay's seagrass ... have been destroyed. (0002-2-2 [Gutierrez, Vivian])

Comment: For those of you who just got here, there is a poster in the back of the room with a handout, if you'd like to take one. And what that shows is the impact to Biscayne Bay. And I think it's pretty clear that we've been seeing a slow addition of salt and nutrients over 40-plus years of operations. And that shows how it's getting there and what the impact is. So I won't repeat that. (0002-5-1 [Reynolds, Laura])

Comment: There was nothing on the bottom when they were doing the dive. I saw the footage. The seagrass was gone. If you go out to the Arsnicker's the seagrass is gone. Somebody in Ocean Reef said to me, well, I went fishing in the Arsnicker's and it was clear, you know, really clear water. They must have done something about it. Rich, I said, it's clear because the seagrass is all gone, the bottom is bare so the water's very clear out there. (0002-6-8 [Rippingille, Bonnie])

Comment: FKNMS [Florida Keys National Marine Sanctuary] determined that the DSEIS contained an insufficient analysis of the potential effects to the sanctuary and sanctuary resources for the following reasons:

1. Deficient Analysis of the Potential Impacts from Ammonium, Tritium and Other Nutrients on sanctuary resources

As stated in Section 4.8.1.1 of the DSEIS, the waters of the CCS enter Biscayne Bay, including FKNMS waters of Card Sound, because "the porous nature of the limestone bedrock that forms the Biscayne aquifer results in some groundwater exchange between the CCS and the aquifer. This exchange of groundwater between the CCS and the Biscayne aquifer creates a pathway through which the CCS may influence Biscayne Bay." However, the DSEIS does not specifically consider how this interaction may affect the sanctuary. The DSEIS also does not acknowledge the potential for occasional breaching of the CCS during storm events, as demonstrated through National Weather Service modeling conducted by the National Park Service.¹ Monitoring data documents the hydrological connections between polluted CCS waters and ground and surface waters, including in canals in the immediate vicinity of the CCS. The S-20 Get Away Canal has been shown to have CCS plume waters with elevated ammonia and tritium.² These polluted plume waters presumably mix with waters from the wetlands to the east and may be discharged

into the sanctuary when the S-20 structure is opened for drainage purposes. Similarly, Card Sound Canal, which is tidally connected to the sanctuary, is also the receiver of CCS plume water.³

1 Vogel, Robert A.; Regional Director, Southeast Regional Office, National Park Service, Atlanta, GA. Letter to Ben Beasley, Chief, Environmental Review and NEPA Branch, U.S. Nuclear Regulatory Commission, Rockville, MD. 5 March 2019.

2 Mayorga, Wilbur; Environmental Monitoring and Restoration Division, Department of Regulatory and Economic Resources, Miami-Dade County, Miami, FL. "Re: Site Assessment Report (SAR) Dated March 17, 2017 and the SAR Supplemental Information Dated November 11, 2017." Received by Matthew J. Raffenberg, Sr. Director, Environmental Licensing and Permitting, Florida Power & Light Company, Juno Beach, FL. 10 July 2018.

3 Id.

4 Reynolds, L., J. Fourqurean, W. Nuttle. 2019. Future Impacts on Biscayne Bay of Extended Operation of Turkey Point Cooling Canals. Greater Everglades Ecosystem Restoration (GEER). <https://conference.ifas.ufl.edu/geer2019/posters/Reynolds-%20Future%20Impacts%20on%20Biscayne%20Bay.pdf>

In addition, Section 4.8.1.1 of the DSEIS states that in July 2018, the Miami-Dade County Division of Environmental Resources Management (DERM) found that several sampling locations at the Barge Basin, Turtle Point Canal, Card Sound Canal, S-20 Get Away Canal, and the Sea-Dade Canal exceeded the applicable Miami Dade County surface water standard for total ammonia concentrations (MDC 2018a)... [B]ecause the DERM believed that the CCS may be one source contributing to the elevated ammonia levels, it required FPL to take action to submit and implement a mitigation plan within 90 days of the date of the letter. The mitigation plan must address potential CCS nutrient impacts to groundwater and surface water resources beyond the boundaries of the CCS.

While the effects of higher than background levels of tritium on marine life are not yet fully understood, the influence of excess nutrients is well studied. Seagrass monitoring data show that phase shifts in these important marine communities adjacent to the CCS are occurring due to excess nutrients, specifically higher than normal phosphorus, a known component of CCS plume water.⁴ Changes in seagrass composition may in turn modify the species supported by such habitats, and excess nutrients over longer time periods can lead to complete collapse of seagrass habitat and associated organisms. Therefore, FKMNS suggests that NRC specifically examine the potential impacts from tritium, ammonium, and phosphorus on the sanctuary, including biota that use the sanctuary. (0018-1 [Fangman, Sarah])

Comment: Deficient Analysis of Seagrass Monitoring Data and Potential Impacts to Sanctuary Biota

In Section 3.7.4 of the DSEIS, NRC states that "FPL performs aquatic ecological sampling in three locations adjacent to the CCS within Biscayne Bay and Card Sound (BB1, BB2, and BB3) and one reference site in Barnes Sound (BB4), which lies directly south of Card Sound (see Figure 3-22)." The NRC then goes on to explain how FPL sampled seagrasses as part of the monitoring study. However, the conclusion for this monitoring data states on pages 3-102 to 3-104 that the major findings were as follows.

- . The marsh and mangrove areas are representative of the hydrologically modified or nutrient-limited communities found along the coastal fringe of south Florida.
- . Data collected during the reporting period continue to support the conclusion that the CCS

does not have an ecological impact on the surrounding areas, and there is no clear evidence of CCS water in the surrounding marsh or mangrove areas from a groundwater pathway. Rather, ecological changes observed during the reporting period are more seasonally and meteorologically driven.

These conclusions appear to describe potential impacts to marshes and mangroves. Elsewhere in the SEIS potential impacts to water quality within Biscayne Bay are described. However, no analysis in the SEIS evaluates the results of the seagrass monitoring program or the potential impacts to seagrasses and other biota (other than ESA-listed species) that occur within the sanctuary. Furthermore, as noted above, independent seagrass monitoring data show that phase shifts in these important marine communities adjacent to the CCS are occurring due to excess nutrients, specifically higher than normal phosphorus, a known component of CCS water.⁵

5 Id.

Seagrasses provide important nursery, foraging, and spawning grounds to sanctuary resources. Seagrasses are also integral to the life cycle of several species of fish that provide a foundation for the recreational and commercial fisheries that occur within the sanctuary. Therefore, FKNMS recommends that NRC analyze the potential impacts to sanctuary resources, including seagrasses, fish, and other biota. (0018-2 [Fangman, Sarah])

Comment: [With more time, the NRC and associated regulatory agencies can review new information on...] New dead zones just east of Turkey Point in Biscayne Bay National Park ...Scientific pier [peer] reviewed research on massive sea grass die offs with nutrient signatures related to Turkey Point just east of Turkey Point and the associated cooling canals (0020-3 [Gomez, Albert])

Comment: Terrestrial Resources - The surrounding mangroves, and wetland areas continue to be impacted by CCS operations. Figure 3-1 from the Continuous Survey Electromagnetic (CSEM) baseline report, a survey of subsurface salinity in the region, (Appendix G of the 2018 Annual Monitoring Report) shows there are high salinity zones which are indications of CCS upwelling in the mangrove wetlands within BNP. The mangroves in this area appear visibly stressed and the cause of this stress is currently under investigation. Surrounding wetlands have abnormal hydro-periods due in part to CCS operations. Water levels, CCS operations, and effects of sea level rise in the area may have an environmental impact over the course of proposed extension. The NPS recommends changing this impact rating from "Small" to "Moderate-Large." (0005-5 [Vogel, Robert])

Comment: The Proposed Action, involving the continued operation of Turkey Point nuclear Units 3&4 and the antiquated CCS through the 2050s, could result in numerous adverse environmental impacts to our national parks, protected areas, and the treasured natural resources they were designated to protect. Specifically, threatened wildlife and wetland habitat in Biscayne National Park could be harmed through impacts of the Proposed Action on ground and surface waters. The continued operation of the CCS also threatens the goals of CERP [Comprehensive Everglades Restoration Plan] through potential negative impacts to the benefits of BBCW [Biscayne Bay Coastal Wetlands project]. The primary objectives of BBCW are to rehydrate coastal wetlands located adjacent to Turkey Point, restore overland and subsurface water flows, and reduce salinity levels in coastal ground and surface waters. The continued deposition of salt and nutrients into natural areas, areas poised to benefit from the BBCW project, jeopardizes the investment of hundreds of millions of local, state, and federal

dollars to generate ecosystem benefits and increase the resiliency of the ecosystem to the impacts of climate change. (0023-3 [McLaughlin, Caroline])

Comment: Nutrient pollution emanating from the CCS is of particular concern because of the sensitivity of waters in Biscayne Bay and other surface water bodies to the addition of excess nutrients. Even in small quantities, an increase in nutrients, particularly phosphorus, can dramatically alter the delicate ecological balance in Biscayne Bay, with the potential to cause seagrass die-offs, algal blooms, and ecological disruption. As already described, there are significant hydrologic connections between the CCS, groundwater, and surface water bodies, raising the risk of the eutrophication of waters of Biscayne Bay and Biscayne National Park. (0023-9 [McLaughlin, Caroline])

Comment: Florida as a whole is in ecological trouble. We need to save Florida beginning here in Biscayne. The reefs are dying. The manatees and marine animals, as well as humans, don't need to be poisoned by nuclear contamination. (0025-1 [Wartman, Janet])

Comment: Our family has vacationed at Biscayne NP and were amazed by its marine diversity. I can't imagine this area being polluted. I also can't imagine allowing this plant to continue without making necessary steps to stop the pollution and account for rising seas. That doesn't sound responsible to me.....

Please consider the ecosystem when making plans for this plant.
(0039-1 [Nye, Janet])

Comment: Turkey Point's reactor and cooling mechanisms pose a threat to the ecosystems of South Florida. As state citizens, we need to take action to protect the quality of our water, since water is the basis of all life..... Our state boasts some of the most important well-preserved aquatic ecosystems in the United States, and it is our responsibility as citizens to protect them as long as we are able. (0072-1 [Nilon, Michael])

Comment: Everglades National Park, Biscayne National Park and Biscayne Bay Aquatic Preserve: As noted in previous comments, the EPA has raised concerns with respect to the Proposed Action's potential impacts to Everglades National Park, Biscayne National Park and Biscayne Bay Aquatic Preserve. The EPA also identified the potential impacts to CERP projects (i.e., potential drawdown of groundwater, ecosystem and water quality impacts should the CCS be flooded during a hurricane or severe storm event, potential continuation or worsening of the hypersalinity plume, etc.).

Recommendation: The EPA recommends the NRC consider a separate impact area (to be reflected in Table 2-2 of the FSEIS) for significant state and Federal resources to include Everglades National Park, Biscayne National Park and Biscayne Bay Aquatic Preserve and CERP projects which would better reflect the potential impacts to these valuable and high quality resources. (0031-21 [Militscher, Christopher])

Comment: It is totally unacceptable to continue an action that will be so devastating to a wonderful marine area. Are you going to continue this practice until you destroy this gem of an area and then go "oops, we made a drastic error"? Please pay attention to what we are saying!
(0113-1 [Kindred, Dorothy])

Comment: The viability of Biscayne bay as a national park and a habitat for marine life must not be threatened by dangerous power plants or the irresponsible activities of dangerous men.

The world needs protection and evidently it needs protection from the nuclear power plant known as Turkey Point. (0123-1 [Cody, Jeff])

Comment: As a diver I have dove in the Florida Keys many times and enjoyed all of the wonderful sea life and coral reefs there. So I feel a strong connection to those waters, and know we Must preserve them. (0142-1 [Ford, Patricia])

Comment: What a spectacular park, and most is underwater! Why would we let this masterpiece be compromised by an antiquated nuclear system? (0151-1 [Schuble, Sue])

Comment: It's more important to take care of sea life and stop water pollution than it is to continue to run the nuclear plant at Turkey Point and figure out how to do it under water. (0153-1 [Grace, Donna])

Comment: Fresh water is required for most species living on land. I consider it madness to place this resource in hazzard too provide profit to a limited few. (0079-1 [Sanford, Ken])

Comment: THE HUMAN SPECIES IS THE ONLY SPECIES THAT HAS AGENCY. ALL OTHER LIFE:THE WATERS, THE WILD CREATURES, THE AIR, THE TREES, LIFE, MUST ADAPT TO OUR ACTIONS. WHAT IS YOUR ETHIC? WHY ARE YOU NOT CONCERNED FOR THE LIFE THE POWER PLANT THREATENS? (0099-1 [Blackstone, Linore])

Response: *These comments concern the potential effects of continued operation of Turkey Point and the CCS on the ecological environment. Many of the comments specifically address impacts on seagrass in Biscayne Bay, Card Sound, and other nearby areas. Some of the comments concern the impacts of water quality on federally and State-managed natural resources, including Biscayne Bay National Park, the Comprehensive Everglades Restoration Plan (CERP), the Biscayne Bay Coastal Wetlands Project, and the Florida Keys National Marine Sanctuary. Other comments express general opposition to the proposed subsequent license renewal because of concern for the potential impacts of license renewal on the ecological environment.*

During its review, the NRC staff considered the impacts of the proposed action on the ecological environment, including those impacts that may be experienced by sensitive and important ecological resources within nearby federally and State-managed lands and waters, and whether CCS waters could impact the ecology of neighboring surface waters through groundwater exchange. Within the SEIS, the NRC staff describes terrestrial resources, aquatic resources, and special status species and habitats in Sections 3.6, 3.7, and 3.8, respectively. The NRC staff evaluates effects to these resources in Sections 4.6, 4.7, and 4.8, respectively. Within these sections of the SEIS, the NRC staff has incorporated additional information and several new subsections in response to these public comments and newly available monitoring data, among other information, as follows.

- *Section 3.6.2, "Marsh, Mangrove, and Tree Island Semiannual Monitoring," has been updated to reflect FPL data from the 2018 monitoring period. The NRC staff also generally expanded this section to describe methods and results of FPL's marsh and mangrove monitoring in more detail. Additionally, the staff updated certain figures and added new figures and graphs that depict sawgrass and mangrove monitoring results from Biscayne Bay and surrounding areas.*

- Section 3.7.4, “Biscayne Bay and Card Sound Semiannual Monitoring,” has been updated to reflect FPL data from the 2018 monitoring period. The NRC staff also generally expanded this section to describe methods and results of FPL’s aquatic monitoring in more detail. The staff added discussions of submerged aquatic vegetation monitoring results and seagrass leaf nutrient analysis results. The NRC staff also incorporated new figures and graphs to support this discussion.
- Section 3.8.3, “Marine Sanctuary Resources Protected Under the National Marine Sanctuaries Act,” is a new section in the SEIS. In this section, the staff describes sanctuary resources of the Florida Keys National Marine Sanctuary. The staff included a new figure within this section that depicts the geographic boundaries of the sanctuary.
- Section 4.6.1, “Proposed Action,” has been updated to reflect FPL marsh and mangrove monitoring data from the 2018 monitoring period. The staff also clarified language pertaining to its assessment of new information for the License Renewal GEIS Category 1 issue of “Cooling system impacts on terrestrial resources (plants with once-through cooling systems or cooling ponds.”
- Section 4.8.1.1, “Federally Listed Species and Critical Habitat Protected Under the Endangered Species Act,” has been updated to reflect the outcome of the NRC’s formal consultation with the FWS and the current status of the NRC’s informal consultation with the NMFS. The staff revised its effect determinations for several species under FWS jurisdiction in Table 4-4. The staff also significantly expanded its written assessment of potential water quality impacts on federally listed species under NMFS jurisdiction. The Kemp’s ridley sea turtle (*Lepidochelys kempii*) is now addressed in this section in addition to the four species of sea turtles included in the DSEIS.
- Section 4.8.1.3, “Marine Sanctuary Resources Protected Under the National Marine Sanctuaries Act,” is a new section in the FSEIS. In this section, the staff evaluates the impacts of the proposed action on sanctuary resources of the Florida Keys National Marine Sanctuary and makes a determination that consultation is not required.
- Appendix C.3, “National Marine Sanctuaries Act Consultation,” is a new section in the SEIS. In this section, the staff describes consultation requirements under the National Marine Sanctuaries Act that pertain to Federal action agencies and summarizes the staff’s determination that consultation is not required.

Ecological variations and fluctuations are typical in Southern Florida due to harsh physiological conditions, storm patterns, and other natural factors. For instance, during the 2018 reporting period, FPL observed some seasonally and meteorologically driven ecological changes. As described in Section 3.6.2 of the SEIS, one freshwater marsh plot (F1-1) experienced a complete die-off of sawgrass in connection with Hurricane Irma, which made landfall in September 2017. Mangrove plots, on the other hand, continued to exhibit stable structure and composition during the 2018 reporting period. As described in Section 3.7.4 of the SEIS, seagrass cover and composition monitoring and leaf nutrient analyses have yielded no clear trends and no evidence of ecological degradation. With respect to the commenters’ specific concerns regarding the impacts of the CCS on ecological resources, in the above-referenced sections of the SEIS, the NRC staff explains that current data indicate no discernable ecological impact on the areas surrounding the CCS and no clear evidence of CCS water in the surrounding marsh and mangrove areas or in Biscayne Bay from a groundwater

pathway. Ecological monitoring data collected during the 2018 reporting period continue to support this conclusion. Thus, available data do not support commenters' statements that the CCS is contributing salt, tritium, and nutrients to Biscayne Bay, Card Sound, or other neighboring surface waters; that nearby marshes are being adversely affected; or that seagrass beds are exhibiting die-off attributable to CCS operation.

With respect to flooding, the NRC's evaluation of such impacts is discussed in response to Comment 0023-15. The staff's evaluation concludes that over the period of subsequent license renewal, flooding and flood damage to the CCS is not likely to occur except in the event of a hurricane. Such an event would only cause insignificant changes to Biscayne Bay and Card Sound water quality.

With respect to sea level rise, climate change, and other potential cumulative impacts, the NRC staff addresses these impacts in Sections 4.15.3, 4.16.3, and 4.16.4 of the SEIS.

With respect to potential impacts on sanctuary resources of the Florida Keys National Marine Sanctuary, the NRC staff documents its determination that the proposed action is not likely to destroy, cause the loss of, or injure any sanctuary resources in Section 4.8.1.3 of the SEIS. For more information on this topic, see the NRC's response to Comment 0018-4 and 0018-7.

Comment: The EPA recommends that the NRC consult with the Florida Fish and Wildlife Conservation Commission (FWC), U.S. Fish and Wildlife Service (USFWS), and National Oceanic and Atmospheric Administration's National Marine Fisheries Service (NMFS) to evaluate each alternative's impacts to terrestrial and aquatic species and also consider the current consent agreement regarding ammonia releases to Biscayne Bay. Additionally, the EPA recommends the NRC conduct a quantitative evaluation of each alternatives' impacts to terrestrial and aquatic resources. For a more comprehensive evaluation of impacts, the EPA also recommends the NRC develop additional impact area categories to reflect a holistic approach to assessing each alternatives' environmental impacts. These impact areas could be climate resiliency (to include sea level rise, droughts and hurricane/storm impacts), and state and Federal resources including Everglades National Park, Biscayne National Park, Biscayne Bay Aquatic Preserve and CERP. (0031-9 [Militscher, Christopher])

Response: As part of its environmental review, the NRC staff has consulted with both the FWS and NMFS under Section 7 of the Endangered Species Act. On July 25, 2019, the FWS issued a biological opinion (ADAMS Accession No. ML19221B583), which concluded consultation between the NRC and FWS. The NRC's Endangered Species Act Section 7 consultation with the NMFS is currently ongoing. Appendix C of the SEIS describes the NRC staff's consultations with these agencies, and the staff has updated this appendix to reflect the current status of each consultation. The NRC staff will conclude its consultation with the NMFS and report the results of this consultation in the Record of Decision prior to making a license renewal decision. The NRC staff also considered whether Essential Fish Habitat (EFH) consultation with the NMFS under the Magnuson–Stevens Act or Section 304(d) consultation with the National Oceanic and Atmospheric Administration under the National Marine Sanctuaries Act is required for the proposed Turkey Point subsequent license renewal. The staff determined that these consultations are not required because the proposed action would not result in any impacts to EFH and the proposed action is not likely to destroy, cause the loss of, or injure any sanctuary resources of the Florida Keys National Marine Sanctuary. In correspondence dated April 1, 2019, the NRC (ADAMS Accession No. ML19091A131) notified the NMFS of its EFH findings and the NRC's determination that EFH consultation is not required for the proposed action. The NMFS provided no specific response concerning EFH. The NRC considers its

obligations related to EFH consultation under the provisions of the Magnuson–Stevens Act to be fulfilled with respect to the proposed Turkey Point license renewal. This information is summarized in Appendix C of the SEIS. The NRC staff added information to the SEIS to address consultation under the National Marine Sanctuaries Act in Sections 1.8, 3.8.3, 4.8.1.3, and Appendix C.3. For more information on National Marine Sanctuaries Act consultation, see the NRC’s response to Comment 0018-4 and 0018-7.

With respect to the Florida Fish and Wildlife Conservation Commission, the NRC has no statutory requirement to consult with this agency; however, the staff used information from this agency’s online databases to obtain shorebird and State-listed species information presented in Sections 3.6.2 and 3.6.3 of the SEIS. With respect to the Consent Agreement, the NRC has no authority over water quality issues. The Consent Agreement is between FPL and Miami-Dade County. However, the NRC staff describes the Consent Agreement in detail and considers the Consent Agreement, as well as the 2016 FDEP Consent Order, among other factors, in its resource-specific analyses in Chapter 4 of the SEIS.

With respect to the NRC’s approach for addressing impacts to terrestrial and aquatic resources, NRC regulations in 10 CFR Part 51 implement NEPA and provide the framework for the NRC’s environmental review. In Table B-1 in Appendix B to Subpart A of 10 CFR Part 51, the NRC identifies 78 issues to be evaluated for license renewal of nuclear plants during the environmental review process. Of these issues, 23 apply to terrestrial resources, aquatic resources, or special status species and habitats. In the GEIS, the NRC staff determined that 17 of these 23 issues are generic (Category 1) and that the impact of license renewal on those resource areas would be SMALL. Absent “new and significant information” that the NRC staff may obtain during its site-specific environmental review, Category 1 issues are not reevaluated in the SEIS; new information is considered, however, and its significance is evaluated. The remaining six ecological issues are site-specific and are specifically analyzed with respect to subsequent license renewal of Turkey Point Units 3 and 4 in Chapter 4 of the SEIS. Because the NRC’s NEPA process for license renewal is established by regulation and tiers from the GEIS, the NRC staff did not revise the impact area categories, as suggested by the commenter. However, the topics recommended by the commenter are addressed in the SEIS, except for the commenter’s suggestion that “climate resiliency” be included as a factor in comparing alternatives, as no such comparison is possible without knowing the design and siting characteristics of the replacement power and cooling water system alternatives. State and Federal natural resources, including Everglades National Park, Biscayne National Park, Biscayne Bay Aquatic Preserve, and the Comprehensive Everglades Restoration Program are described in Sections 3.6 and 3.7 of the SEIS. Additionally, the staff’s impact conclusions for terrestrial and aquatic resources in Chapter 4 of the SEIS are inclusive of these State and Federal natural resources.

Comment: FKNMS, established in 1990 to protect nationally significant aquatic and marine resources, includes Card Sound – a body of water that borders the southeastern edge of Turkey Point’s Cooling Canal System (CCS). The sanctuary is managed and protected by NOAA under authority of the National Marine Sanctuaries Act (NMSA, 16 USC §§ 1431 et seq.), Florida Keys National Marine Sanctuary and Protection Act (Pub. Law 101-605), and associated regulations (15 CFR part 922, subpart P). Under Section 304(d) of the NMSA, a Federal agency must consult with NOAA’s Office of National Marine Sanctuaries if the Federal agency action, including licensing or permitting, is likely to destroy, cause the loss of, or injure any sanctuary resource. Please see <https://sanctuaries.noaa.gov/management/consultations/> for additional information regarding the 304(d) consultation process. (0018-7 [Fangman, Sarah])

Comment: For the reasons stated above, and given the engineered features of the existing CCS and reasonably foreseeable likelihood that sea level rise will lead to flooding events of the low-lying CCS, FKNMS [Florida Keys National Marine Sanctuary] believes that analysis of impacts to sanctuary resources in the DSEIS is insufficient and should be further evaluated. NOAA would then review any such revised analysis to determine if consultation under Section 304(d) of the National Marine Sanctuaries Act (16 USC § 1434(d)) is required. (0018-4 [Fangman, Sarah])

Response: *Section 304(d) of the National Marine Sanctuaries Act (NMSA) contains consultation requirements relevant to Federal agency actions that may affect marine sanctuary resources. Under the NMSA, Federal agencies must consult with the National Oceanic and Atmospheric Administration's (NOAA's) Office of National Marine Sanctuaries if a Federal action is likely to destroy, cause the loss of, or injure any sanctuary resources. Within Southern Florida, NOAA has designated the Florida Keys National Marine Sanctuary to include 2,900 square nautical miles of waters surrounding the Florida Keys, from south of Miami westward and encompassing the Dry Tortugas. This area includes Card Sound. Sections 1.11, 3.7.2, 3.7.5, 3.8.3, 4.8.1.3, 4.8.2, 4.8.3, and 4.16.4 of the SEIS discuss the Florida Keys National Marine Sanctuary.*

The NRC staff considered whether the NRC must consult with NOAA under Section 304(d) of the NMSA with respect to the proposed Turkey Point subsequent license renewal. The staff determined that consultation is not required because the proposed action is not likely to destroy, cause the loss of, or injure any sanctuary resources. The staff made this determination for several reasons. First, currently available monitoring data do not indicate any discernable impact of the Turkey Point CCS on the ecology of Biscayne Bay, Card Sound, or any other nearby surface waters to date. Second, FPL's continued implementation of the 2016 FDEP Consent Order and FPL's 2015 Consent Agreement with Miami-Dade County will ensure that any potential future impacts of the CCS will be mitigated such that constituents originating from the CCS will not discernably affect the ecology of nearby surface waters over the course of the proposed subsequent license renewal term. Additionally, during preparation of the FSEIS, the NRC staff reviewed FPL's 2018 surface water, groundwater, and ecological monitoring results. Data from 2018 continue to support the conclusion that the CCS does not have a discernable ecological impact on surrounding areas and that there is no clear evidence of CCS water in the surrounding marsh and mangrove areas, in Biscayne Bay, in Card Sound, or in other nearby surface waters via a groundwater pathway. The staff has incorporated the 2018 monitoring data and results into Sections 3.5, 3.6, 3.7, 3.8, 4.5, 4.6, 4.7, and 4.8 of the FSEIS.

Groundwater monitoring results indicate that water from the Turkey Point CCS has migrated via the groundwater pathway through the deeper interval of the Biscayne aquifer and to the east beneath Biscayne Bay and Card Sound. CCS-sourced constituents include elevated chloride and tritium. However, these constituents have had no effect on overlying surface water quality. At no location outside the boundary of the Turkey Point site do tritium levels in groundwater approach the U.S. Environmental Protection Agency and State primary drinking water standards for tritium of 20,000 pCi/L. Sections 3.5.2 and 4.5.1.2 of the SEIS discuss groundwater quality and monitoring in detail.

Although the Florida Keys National Marine Sanctuary's comments do not change the NRC staff's NEPA conclusions or the staff's determination that NMSA consultation for the proposed action is not required, the staff added a more detailed discussion of the Florida Keys National Marine Sanctuary in Section 3.8.3 of the FSEIS, and the staff added a new section

(Section 4.8.1.3) in Chapter 4 of the FSEIS that describes why the NRC staff concluded that no consultation under the National Marine Sanctuaries Act is required for the proposed action. A new section in Appendix C of the FSEIS describes consultation requirements and summarizes the NRC's findings with respect to consultation. See also the staff's responses to Comments 0018-1 through 0018-6 for more information on the potential effects of continued operation of Turkey Point and the CCS on the ecological environment, including those impacts that may be experienced by sensitive and important ecological resources, such as sanctuary resources of the Florida Keys National Marine Sanctuary.

Comment: Section 3.7.2 -NPS suggests adding information to this section that identifies the southern part of Biscayne Bay hosting its own family group of bottlenose dolphin (*Tursiops truncatus*). (0005-14 [Vogel, Robert])

Response: In Section 3.7.5 of SEIS, the NRC staff incorporates by reference several sections of the NRC's 2016 EIS for the Turkey Point Units 6 and 7 COLs pertaining to the aquatic environment. The COL EIS describes bottlenose dolphins on pages 2-129, 2-134, 2-136, Table 2-27, and 4-86 through 4-87. Page 2-136 of the COL EIS specifically describes the Biscayne Bay population. The NRC staff did not revise the SEIS based on this comment.

Comment: But what I do want to talk about is the conflict with Everglades restoration. So for those of you who might not be familiar, there are 68 projects around South Florida. There's 2 in the vicinity of the cooling canal system. Now, this is a State and Federal funded project, all 68 of them. And Dade County, for example, their drinking water is predicated on full implementation of CERP. So their consumptive use permit for use of water is predicated on that success. And I wanted to leave this for the record. I only have one copy. But the report card for 2012 through 2017 of Everglades restoration shows that the only poor condition throughout the entire system is in the southern coastal systems, and it gets the lowest rating. And the things that it's rated for are crocodiles, crashing the nesting, salinity, and the prey fish community. All of those things have been affected by the cooling canal system. (0002-5-2 [Reynolds, Laura])

Response: With respect to water use conflicts between the Comprehensive Everglades Restoration Project (CERP) and the Turkey Point site, in the past, FPL has obtained permits to pump excess freshwater from State canals, such as the L-31E Canal that lies west of the Turkey Point site, to support freshening of the CCS. However, as explained in Section 3.5.1.4 of the SEIS, FPL's current plans to manage CCS water quality do not include the use of freshwater from State canals. In the future, should FPL need to use freshwater from State canals, FPL would need to seek permission to do so from State and county governments. Through the permitting process, the relevant permitting agencies would address any potential surface water use conflicts to ensure that FPL's freshwater consumption does not adversely affect the surrounding ecological environment. For these reasons, surface water consumption associated with the proposed Turkey Point license renewal would not conflict with Everglades restoration.

The NRC staff reviewed the document referenced by the commenter entitled "2012-2017 Everglades Report Card" issued by RECOVER (REstoration COordination and VERification) and available online at: http://ian.umces.edu/pdfs/ian_report_card_610.pdf. The report rates the Southern Coastal System, which encompasses Biscayne Bay, Florida Bay, and the Southwest Coast, as poor to fair. The report states that increased salinity throughout the region has resulted from a combination of a continued inconsistent delivery of freshwater combined with periods of drought in 2014 and 2015, hurricanes, and sea level rise. Negative

impacts to American crocodiles, gulf pipefish, and submerged aquatic vegetation (including seagrass) in Biscayne Bay and Florida Bay are specifically attributed to the drought. Neither the operation of Turkey Point nor the CCS are mentioned in the report.

The comment did not provide new information, and the NRC staff did not revise the SEIS as a result of this comment.

Comment: One of the things that we're lacking for Everglades restoration success is clean, fresh water. We don't have enough of it. And the southern coastal system, like I said, gets the poorest rating out of the entire system, and that includes Lake Okeechobee, which only gets one little red mark. If you look at this whole thing there's not much red on the rest of the system, just Biscayne Bay. So I would argue that the operations of the cooling canal system are in direct conflict with a federally funded project. Two of them, at least, if not more. In addition, you have the C-111 project, which is basically just to the west. Now, the way that the system operates there's -- I don't remember exactly how many acres it is. But the model land region, which is just west of the cooling canal system, is a series of wetlands. Now recently Dade County in fact documented salinity levels increasing in the surface of those model lands from contamination from the L-31-E traced back to the cooling canal system. Now after Irma those weirs were opened up to flush water out and that salinity level dropped again. But the canal system actually was contaminated, and so was the surface wetlands to the west. So I think continued operations will continue to contaminate those wetlands, and many of them have been purchased for restoration purposes. In addition, the water levels in that area are kept at 1.8. Now that happens to be the trigger to operate the interceptor ditch pumps. The interceptor ditch pumps actually can pump water into the cooling canal system at about 3 million gallons a day on average. That water would otherwise be available for restoration, would maybe go into Taylor Slough or south into other parts of the system. Instead, it's being pumped into the cooling canal system to keep it fresher. So in my opinion, a direct conflict with water, water quality, water quantity, and the storage. So if you were able to meet the trigger identified in the Yellow Book for C-111, you would go up to 2.4 to 2.9 feet, holding that water level higher and in fact improving restoration benefits in the area. By keeping it low and staying at that trigger you're losing all of those benefits. And so what I would argue is that you must consider the cumulative effects of what this does to Everglades restoration. (0002-5-5 [Reynolds, Laura])

Response: *The comment primarily concerns the potential for the Turkey Point subsequent license renewal to affect the quantity or quality of freshwater available to offsite wetlands. With respect to the quantity of freshwater available to wetlands and other natural habitats, as explained in Section 3.5.1.4 of the SEIS, FPL's current plans to manage CCS water quality do not include the use of freshwater from State canals that feed neighboring and other offsite wetlands. In the future, should FPL need to use freshwater from State canals, FPL would need to seek permission to do so from State and county governments. Through the permitting process, the relevant permitting agencies would address any potential water use conflicts to ensure that FPL's freshwater consumption does not adversely affect the surrounding ecological environment. For these reasons, water consumption associated with the proposed Turkey Point license renewal would not conflict with the needs of offsite wetlands.*

With respect to water quality, the NRC staff evaluates the potential impacts of subsequent license renewal on wetlands in Sections 3.6.2, "Marsh, Mangrove, and Tree Island Semiannual Monitoring," and 4.6.1, "Proposed Action," of the SEIS. During its review, the NRC staff reviewed the most recently available results of FPL's vegetation monitoring at 32 plots of freshwater wetland and mangrove habitat adjacent to the CCS. The NRC staff found that

landscape-scale environmental factors, such as the length of the hydroperiod or overall water depth, have a greater effect on changes in live biomass and sawgrass height than proximity to the CCS. Based on this and other information, the NRC staff concluded in Section 4.6.1 of the SEIS that operation of the CCS does not have a noticeable impact on wetlands or any other important attribute of the terrestrial resources on or near Turkey Point and that impacts on these resource areas would be SMALL during the subsequent license renewal term. In the FSEIS, the NRC staff updated and expanded its discussions of marsh and mangrove monitoring results in Sections 3.6.2 and 4.6.1 to reflect newly available monitoring data and general public interest on this topic.

The comment does not provide new information with respect to this issue. The NRC staff did not revise the SEIS as a result of this comment.

Comment: Now, I remember talking on the record at the 6 and 7 NRC hearing, saying the same thing; that this is in direct conflict with Everglades restoration. And so, please, consider that. It doesn't seem to have enough weight in your EIS draft, so you need to take another look at really what those conflicts are. And I ask you to go back to the Yellow Book, look at the benefits and see the report on why the coastal systems next to Turkey Point, because there's two projects there, are failing. And I would argue that it's because this system is in direct conflict with it and you wouldn't see any of these benefits. It masks everything. (0002-5-6 [Reynolds, Laura])

Response: *Two Comprehensive Everglades Restoration Plan (CERP) projects are located near the Turkey Point site: Biscayne Bay Coastal Wetlands Project and the C-111 Spreader Canal Project. Both projects are ongoing with estimated completion in 2022. According to the Seventh Biennial Review of the CERP, published by the National Academies of Science, Engineering, and Medicine (NASEM) and available at <https://www.nap.edu/catalog/25198/progress-toward-restoring-the-everglades-the-seventh-biennial-review-2018>, monitoring of the Biscayne Bay Coastal Wetlands Project indicates some positive wetland vegetation responses to freshwater inputs but no change in nearshore salinity. However, many project components have yet to be constructed or implemented, and monitoring data have not been sufficiently analyzed to fully assess ecological responses. The C-111 Spreader Canal Project is intended to restore the volume, distribution, and timing of flow into Taylor Slough and to improve salinity regimes in eastern Florida Bay. As such, most of the ecological monitoring associated with this project has focused on Florida Bay. The NASEM's biennial review did not associate the ecological responses or impacts of these or other CERP projects with the operation of Turkey Point or the CCS. The "Yellow Book" referenced by the commenter is the CERP conceptual plan, which outlines the major components of the CERP. The document is titled, "Central and Southern Florida Project Comprehensive Review Study, Final Integrated Feasibility Report and Programmatic Environmental Impact Statement." It was issued by the U.S. Army Corps of Engineers and South Florida Water Management District (SFWMD) in 1999 and, thus, does not provide any new information relevant to the staff's review. The NRC staff did not revise the SEIS based on this comment.*

Comment: The EPA recommends the NRC describe the Cooling Water System in terms of numeric acreage and consider this footprint when determining terrestrial and aquatic impacts. Furthermore, the relatively small footprint of the cooling towers should be considered in comparison with the known adverse environmental impacts of the CCS. The EPA recommends the Cooling Water System Alternative and other build alternatives be evaluated further to include a data-driven noise assessment study rather than relying on ratings of "small to large".

The temporary nature of the construction of the build alternatives should be considered in the noise impact assessment. (0031-7 [Militscher, Christopher])

Comment: Noise Sections 4.3.3.2, 4.3.4.2, 4.3.5.2, 4.3.6.2 -Construction noise could impact nesting activity at the nearby least tern colony. NPS recommends consideration of mitigation measures that include limiting construction in the vicinity of the colony to non-breeding season months. (0005-16 [Vogel, Robert])

Response: *In Section 2.2.3, "Cooling Water System Alternative," of the SEIS, the NRC staff explains that in formulating the cooling water system alternative, the staff drew upon FPL's 2009 application to the NRC to build and operate two new nuclear reactors on the Turkey Point site (i.e., Turkey Point Units 6 and 7). The cooling water system alternative for Turkey Point Units 3 and 4 would have the general design, construction, and operating characteristics as the cooling water system associated with Turkey Points Units 6 and 7. Where numeric data were available and supported by reference sources (e.g., land acreage, water consumption), these data were provided and considered as part of the staff's impact analyses in Chapter 4 of the SEIS for the various environmental resource areas.*

With respect to noise, the NRC staff addresses the potential impacts of noise associated with the proposed subsequent license renewal in Section 4.3.1.2, "Noise," of the SEIS. The impacts of noise associated with alternatives are addressed in Sections 4.3.3.2, 4.3.4.2, 4.3.5.2, and 4.3.6.2 of the SEIS. In response to the U.S. Environmental Protection Agency's comment, the NRC staff revised Section 4.3.3.2 of the SEIS to identify the temporary nature of construction activities. The staff addresses the potential impacts of noise on wildlife in Section 4.6.1 of the SEIS (for the proposed action) and Section 4.6.3 of the SEIS (for alternatives to the proposed action). Notably, these sections consider the impacts of construction noise on wildlife. With specific respect to the National Park Service's concern related to least terns, the NRC staff added the following text to Section 4.6.3 of the SEIS: "Limiting construction in areas near known bird nests, rookeries, or colonies (e.g., CCS berms on which least terns are known to nest) to the non-breeding season would limit behavioral avoidance and other potential impacts to locally breeding bird populations."

Comment: Combination Alternative (Natural Gas Combined-Cycle and Solar) Section 2.2.2.3 - If FPL creates solar power generation facilities, impacts to birds would be a concern as bird deaths from solar arrays in other areas reach thousands per year. BNP is in the Atlantic migratory bird flyway, and has a designated as an Important Bird Area due to its significant population of protected species and its migratory stopover habitats (<https://www.audubon.org/important-birdareas/biscayne-bay>). If this alternative is selected, impacts to birds at Turkey Point would affect populations of these species well outside the project area. Therefore, it is critically important that any potential solar facilities follow recommendations for reducing avian mortality, such as "clearing vegetation around solar towers to make the area less attractive to birds, retrofitting panels and mirrors with designs that help birds realize the solar arrays are not water, suspending operations at key migration times, and preventing birds and bats from roosting and perching at the facilities." (<https://www.scientificamerican.com/article/solar-farms-threaten-birds/>) Best management practices may reduce but likely will not eliminate this impact. Therefore, NPS recommends that the SEIS evaluation of environmental impacts from the proposed solar facility include specific ratings on avian mortality, particularly in this important habitat. (0005-9 [Vogel, Robert])

Response: *The NRC staff revised Section 4.6.6 of the FSEIS, which addresses the impacts of solar power generation on terrestrial resources as part of the combination alternative (natural gas combined-cycle and solar photovoltaic generation). The newly added text addresses the potential for birds and their insect prey to become injured or die in interactions with utility-scale solar arrays.*

Comment: The SEIS states in this section (bottom of page 3-89) that FPL conducted bird surveys on May 23, 2016. This is late in the year and would not accurately capture the presence of spring migrant species or nesting species. We recommend FPL conduct early-morning avian surveys in late April and early May and include this information in the SEIS. (0005-11 [Vogel, Robert])

Response: *FPL conducted the May 2016 avian survey referenced by the commenter in connection with the Turtle Point remnant canal and Barge-Turning Basin water quality improvement project. This project is separate from the proposed license renewal and has since been completed. In Section 3.6.3, "Wildlife," of the SEIS, the NRC staff describe the results of the May 2016 avian survey, among other ecological surveys, to support its discussion of the wildlife that are present on and near the Turkey Point site. FPL did not conduct any avian surveys specific to the proposed license renewal because none were required. The NRC staff did not revise the SEIS based on this comment.*

Comment: Table 3-7 -NPS suggests changing the name of "screen owl" to its correct name of Eastern screech owl and adding Northern mockingbird, blue jay, Northern cardinal, mangrove cuckoo, yellow-billed cuckoo, black-bellied plover, red knot (a federally listed species), whimbrel, Western sandpiper, least sandpiper, laughing gull, ring-billed gull, great black-backed gull, lesser black-backed gull, downy woodpecker, and the full suite of eastern warblers (black-and-white, American redstart, black-throated blue, etc.) to the list of migratory birds likely to occur at Turkey Point. (0005-12 [Vogel, Robert])

Response: *The NRC staff developed the table, "Migratory Birds Protected under the Migratory Bird Treaty Act That Are Most Likely to Occur at Turkey Point," from information provided by the FWS through its online Information Planning and Consultation System tool and from survey data and incidental observation records from FPL. While the staff recognizes that many additional species of birds may occur on the Turkey Point site, the intent of the table was to focus the reader on the most common or most frequently observed migratory bird species in the area. While the NRC staff did not add additional species to the table in response to the comment, the staff added text to Section 3.6.3.2 acknowledging the bird species that the National Park Service identifies in its comment. The added text describes which of these species FPL has reported from avifauna surveys of the Turkey Point site. The staff also corrected the grammatical error in the table's listing of the Eastern screech owl that the commenter noted. Finally, the staff renumbered the table in the FSEIS to account for the staff's addition of new tables in preceding sections.*

Comment: Important Habitats, Section. 3.6.3.3 -Please change the name from "Biscayne Bay National Park" to "Biscayne National Park." Additionally, the NPS recommends adding information regarding BNP's significance as being designated as an Important Bird Area (<https://www.audubon.org/important-bird-areas/biscayne-bay>). (0005-13 [Vogel, Robert])

Response: *The NRC staff revised all instances of “Biscayne Bay National Park” in the SEIS to “Biscayne National Park.” The NRC staff added a discussion of the Biscayne Bay Important Bird Area to Section 3.6.4.3, “Important Habitats,” of the SEIS.*

Comment: Table 2-2, Page 2-23. DSEIS table note (a) states that SLR is "likely to adversely affect the American crocodile," based on its findings in the Biological Assessment (BA). The BA conclusion is based on the impacts to crocodiles from hypersaline waters alone in the CCS. As explained in FPL's April 18, 2019 comments on BA pages 32, 34 and 35 (ADAMS Accession No. ML19112A023), FPL has implemented a program to reduce salinity in the CCS to bring it to 34 PSU prior to the SLR period. Regardless, the USFWS has concluded that hypersalinity alone doesn't adversely affect the crocodiles. The DSEIS should be fully informed by FPL's comments on the NRC BA and revised accordingly. Similarly, the DSEIS should also be fully informed by the additional information provided by FPL in FPL Letter L-2019-031 dated April 3, 2019 (ADAMS Accession No. ML19095B380 - Enclosure 5). (0017-1-14 [Maher, William])

Comment: I have heard that even the endangered american crocodiles have experienced negative side effects from the canals when they overheat. (0004-4 [Moses, Dorothy])

Comment: Wildlife Section 3.6.2 -Alternatives that affect listed species also indirectly impact wildlife in the adjacent BNP. For example, American crocodiles that hatch inside FPL-owned property often spend juvenile years inside NPS boundaries, contributing to the ecosystem there. Similarly, Least Terns that nest on FPL property are observed foraging in park waters. Efforts to reduce wildlife mortality (such as keeping temperatures low enough in the cooling canals to sustain American crocodiles) will help sustain park wildlife. Minimizing boat (including barge) traffic and any nearby construction activity during Least Tern nesting season would reduce disturbances to this colony, one of the largest ground-nesting colonies in eastern Florida. (0005-10 [Vogel, Robert])

Response: *The NRC staff addressed the potential effects of Turkey Point subsequent license renewal on the American crocodile in the staff's 2018 biological assessment (ADAMS Accession No. ML18353A835), which the staff incorporated into the SEIS by reference. Section 5.1.2, “Impacts to the American Crocodile and Designated Critical Habitat,” of the biological assessment addresses the potential impacts on crocodiles in connection with CCS water quality and temperature. In that section, the NRC staff acknowledged that the current conditions within the CCS are having an adverse impact on the American crocodile. The staff recognizes that FPL is taking actions to improve the conditions in the CCS in accordance with the terms of the 2016 FDEP Consent Order and FPL's Consent Agreement with the Miami-Dade County Department of Environmental Resources Management. The NRC staff describes FPL's actions and mitigation strategies in the biological assessment and in many sections of the SEIS, and the staff's biological assessment acknowledges that water quality-related impacts to crocodiles are likely to decrease as CCS water improves. The NRC staff's overall finding was that subsequent license renewal is likely to adversely affect the American crocodile based on several factors, including but not limited to CCS water quality. Under the Endangered Species Act, such a conclusion is appropriate when effects are not wholly insignificant or discountable. Insignificant effects relate to the size of the impact and should never reach the scale where take occurs. Based on best judgement, a person would not be able to meaningfully measure, detect, or evaluate insignificant effects. Discountable effects are those that are extremely unlikely to occur. In all cases where incidental take is anticipated to occur as a result of the proposed action, an “is likely to adversely affect” determination should be made. At Turkey Point, crocodiles are occasionally killed in collisions with vehicles associated with Turkey Point operations. In 2006, the FWS issued a biological opinion authorizing such take. In the*

NRC's 2018 biological assessment, the NRC staff determined that vehicle collisions will continue to be a potential source of incidental take during the proposed license renewal term. This fact alone causes the potential effect of license renewal on the American crocodile to the level of "is likely to adversely affect."

Concerning the FWS's conclusions with respect to the American crocodile, the FWS's statement regarding hypersalinity that FPL references in its comment was made in connection with continued operation of Turkey Point during the initial license renewal term, which is a previous Federal action. The full quotation is: "Based on the success of crocodile reproduction documented in the cooling canal system over the last 30 years, the FWS does not believe that the hypersalinity of the cooling canal waters has adversely affected crocodiles or will adversely affect crocodiles in the future" (see ADAMS Accession No. ML061430174, p.11). This statement, which was made in 2006, does not account for more recently available water quality information or crocodile population data; it is, therefore, not appropriate to apply this statement to the current Federal action of subsequent license renewal without significant caveats regarding changes in CCS water quality and the result of crocodile monitoring on the Turkey Point site.

As part of its environmental review of FPL's subsequent license renewal application, the NRC staff consulted with the FWS under Section 7 of the Endangered Species Act regarding the American crocodile and its critical habitat, among other federally listed species and critical habitats. In a July 25, 2019, biological opinion (ADAMS Accession No. ML19221B583), the FWS concluded that the continued operation of Turkey Point Units 3 and 4 through the duration of the proposed subsequent license renewal period "...is not likely to jeopardize the continued existence of the crocodile...and it will not adversely modify the critical habitat of the crocodile." The NRC staff has updated Section 4.8.1.1, "Federally Listed Species and Critical Habitat Protected Under the Endangered Species Act," and Appendix C.1, "Endangered Species Act Section 7 Consultation," to reflect the outcome of the NRC's consultation with the FWS.

With respect to FPL's comments on the NRC staff's biological assessment, the NRC staff acknowledges the information provided by FPL in its April 3, 2019, letter to the NRC (ADAMS Accession No. ML19112A023). The NRC staff provided the FWS with a copy of this letter, and the two agencies discussed FPL's comments during communications pursuant to their recently concluded Endangered Species Act Section 7 consultation. The FWS considered FPL's comments on the biological assessment in formulating its biological opinion. The NRC staff did not revise the SEIS based on this comment.

With respect to the National Park Service's comment concerning alternatives, the NRC staff recognizes that potential impacts that federally listed species, such as the American crocodile and least tern, might experience also have the potential to directly or indirectly affect other wildlife. The NRC staff addresses impacts to federally listed species in Section 4.8.1.1, "Federally Listed Species and Critical Habitats Protected Under the Endangered Species Act," of the SEIS. The staff addresses impacts to wildlife and other terrestrial resources in Section 4.6.1, "Proposed Action," of the SEIS. With respect to construction impacts on federally listed species and other wildlife, the proposed subsequent license renewal would not involve any new construction, so no construction impacts would result. The staff describes the impacts on wildlife that would be associated with the construction of alternatives in Section 4.6.3, "Replacement Power Alternatives: Common Impacts."

With respect to barge traffic, subsequent license renewal would necessitate infrequent deliveries of large parts and equipment to the Turkey Point site, associated with plant operation

for another 20 years. FPL estimates that up to five barges in a single year at intervals of 4 to 5 years would travel to and from the site during the proposed subsequent license renewal term. The NRC staff evaluated the potential impacts of barge traffic on federally listed species in Section 4.8.1.1 of the SEIS and in Section 6.2.2.3, "West Indian Manatee," of the biological assessment. In Section 6.2.2.3 of the biological assessment, the NRC staff determined that the infrequency of vessel traffic and the ability of individuals to move away from vessels to avoid contact make injury or death extremely unlikely to occur. Barge traffic in association with either the proposed action or alternatives would not disrupt least tern nesting activity because this species nests on berms within the CCS, and the CCS would not be used by barges.

As described above, the FWS issued a biological opinion following Endangered Species Act Section 7 consultation with the NRC. The opinion includes one Reasonable and Prudent Measure and five Terms and Conditions to minimize or avoid adverse effects to the American crocodile and eastern indigo snake. Implementation of these measures may also directly or indirectly benefit other wildlife, as suggested by the commenter. The NRC staff did not revise the SEIS based on this comment.

Comment: Section 3.6.1, Page 3-89. The DSEIS states: "In 2017, the Southwest Florida Water Management District (SWFMD) issued Permit No. 13-06251-W allowing FPL to recover and extract the hypersaline water within and around the CCS (SFWMD 2017a)." This statement misidentifies the Southwest Florida Water Management District (SWFMD) with the South Florida Water Management District (SFWMD). The subject water use permit was issued by the SFWMD, not the SWFWMD as stated. This statement should be revised to replace 'SWFMD' with 'SFWMD.' (0017-2-9 [Maher, William])

Response: The NRC staff revised the referenced text to state: "In 2017, the South Florida Water Management District (SFWMD) issued Permit No. 13-06251-W allowing FPL to recover and extract the hypersaline water within and around the CCS (SFWMD 2017a)." In addition, the staff corrected all other incorrect references to "SWFMD" to "SFWMD."

Comment: Section 3.6.1, Page 3-89. The DSEIS states: "In conclusion, the SWFMD determined that while the authorized withdrawal would impact wetlands, the impacts to onsite and offsite wetlands would be minimal (SFWMD 2017a)." This statement does not accurately reflect the agency or its finding. This statement should be revised to: "In conclusion, the SFWMD determined that the potential for harm to occur to wetlands as a result of the authorized withdrawal of the recommended allocation is considered minimal (SFWMD 2017a)." (0017-2-10 [Maher, William])

Response: The NRC staff revised the referenced text to state: "In issuing its water use permit, the SFWMD (2017a) determined that the risk of adverse effects to wetlands as a result of the authorized withdrawal of the recommended allocation would be minimal."

Comment: Section 3.6.3.1, Page 3-90. The DSEIS states, "This chapter of the FAC gives the FFWCC the authority to list species as State- threatened or endangered." The state of Florida no longer has a "state-endangered" listing category (ref. Chapter 68A-27.001 Definitions). This statement should be revised to remove "endangered" from the listing category. (0017-3-14 [Maher, William])

Response: The Florida Administrative Code recognizes several categories of special status species within the State of Florida. These include State-designated endangered species, which

are species determined to be threatened by the Florida Fish and Wildlife Conservation Commission, and Florida endangered and threatened species, which include federally listed endangered and threatened species and State-designated threatened species. The NRC staff updated Section 3.6.4.1, "State-Listed Species," of the SEIS to clarify these categories. The NRC staff also added text recognizing that Chapter 5B-40 of the Florida Administrative Code authorizes the Florida Department of Agriculture and Consumer Services to list plants as endangered, threatened, and commercially exploited.

Comment: Section 3.6.3.1, Page 3-91. The DSEIS states, "...the American crocodile, which is State- and federally listed as threatened*." American crocodiles are federally threatened; therefore, they do not have a separate state designation. This statement should be revised by removing the 'State-' listing reference. (0017-3-15 [Maher, William])

Response: The Florida Fish and Wildlife Conservation Commission lists the American crocodile as endangered at the State level, and the FWS lists the species as threatened under the Endangered Species Act. Therefore, the NRC staff revised the text in Section 3.6.4.1, "State-Listed Species," of the SEIS to state: "...American crocodile, which is State-listed as endangered and federally listed as threatened."

Comment: Section 3.6.4, Page 3-94. The DSEIS states, "The Argentine black-and-white tegu (*Tupanimbis merianae*) has also been observed at Turkey Point (NRC 2016a)." This statement is incomplete because the Burmese python has also been observed onsite (and removed when possible). This statement should be revised to reflect the Burmese python observation. (0017-3-16 [Maher, William])

Response: The NRC staff revised Section 3.6.5, "Invasive and Non-Native Species," to acknowledge the occurrence of the Burmese python on the Turkey Point site.

Comment: Section 3.8.1.1, Page 3-107. The DSEIS states the Indigo snake occurrence pattern is "...regularly observed onsite." "Regularly" is an incorrect description since there have only been five to ten sightings over a few years. This statement should be revised to replace "regularly" with "occasionally." (0017-3-17 [Maher, William])

Response: The NRC staff revised Table 3-11 in Section 3.8.1.2, "Federally Listed Species and Critical Habitats under U.S. Fish and Wildlife Service's Jurisdiction," of the SEIS to indicate that the eastern indigo snake is only occasionally observed onsite.

A.2.7 Environmental Justice

Comment: Environmental Justice (EJ): Pursuant to Executive Order 12898, the SDEIS includes demographic and impact information related to minority and low-income populations. Turkey Point Nuclear Unit Nos. 3 and 4 are located within an area containing substantive minority and low-income populations within a 50-mile radius of the proposed project. Thresholds and census data are used to compare race and income data at the block group level to the reference population. The SDEIS identifies minority populations using the meaningfully greater analysis (i.e., 78% or greater) and low-income populations are identified using the % of individual living below the Federal poverty threshold (18% or greater). The SDEIS evaluates the potential for disproportionately high and adverse health and environmental impacts and concludes that there are no disproportionately high and adverse environmental or health impacts on low-income and minority populations due to the proposed project license renewal.

Recommendations: The SDEIS identifies minority populations using the meaningfully greater analysis. Typically, minority populations are identified using the meaningfully greater analysis along with the 50% percent analysis. At the 50% percent or greater threshold, the project area includes a substantive minority population that should be meaningfully engaged throughout the NEPA process to help identify potential benefits and burdens associated with licensing permitting decisions. The EPA recommends the NRC include the 50% percent or greater and analysis in the EJ evaluation in the FSEIS. Additionally, the EPA recommends the EJ section include information about the public outreach efforts to minority and low-income populations and participation (i.e., receiving community input) of these communities in the proposed project (i.e., scoping, planning, impact assessment, etc). Because there is a high Hispanic population as well as migrant populations within the vicinity of the project, the EPA recommends the FSEIS discuss outcomes of efforts to engage these populations and describe efforts made to address issues related to limited English proficiency. The EPA also recommends that Native American tribes and populations that may utilize area resources as part of their cultural practice or for subsistence should also be coordinated with and efforts to engage them should also be discussed. (0031-20 [Militscher, Christopher])

Response: *The commenter recommends that the NRC staff include the Fifty-Percent Analysis in combination with the Meaningfully Greater Analysis in identifying minority populations as part of the Environmental Justice evaluation in the SEIS. The NRC staff conducted its Environmental Justice review in accordance with guidance contained in the Commission's Policy Statement on the Treatment of Environmental Justice Matters in NRC Regulatory and Licensing Actions (69 FR 52040) and Appendix D to LIC-203 (ADAMS Accession No. ML12234A708). The NRC staff is aware that the identification of minority populations can be conducted in various ways, including the No-Threshold analysis, Fifty Percent analysis, the Meaningfully Greater analysis, or both the Fifty Percent analysis and the Meaningfully Greater analysis in concert. However, in accordance with NRC's policy statement and guidance, minority and low-income populations are identified when the minority and/or low-income population of an impacted areas exceeds 50 percent or the minority and/or low-income population is meaningfully greater than the minority and/or low-income population percentage than the minority and/or low-income population within a 50-mi (80-km) radius of the nuclear power site.*

The NRC staff determined that the Meaningfully Greater analysis is appropriate to identify minority populations as a result of the substantial aggregate minority population within the geographic area (50 mi (80 km)). The Meaningfully Greater analysis allows for the Environmental Justice analysis to focus on the potential effects occurring where the concentration of minority populations is the greatest when compared to the geographic area (50-mi (80-km)) radius). If the Fifty-Percent threshold were to be applied to identify minority populations, the analysis would result in approximately 81 percent of the census block groups (1,743 out of 2,152) within a 50-mi (80-km) radius of Turkey Point as minority population block groups. Given that 78 percent of the population within a 50-mi (80-km) radius of Turkey Point are minority individuals, the 50 percent threshold would not distinguish the location of higher concentrations of minority populations when compared to the aggregate minority individuals residing within a 50-mi (80-km) radius of Turkey Point. Additionally, the Fifty-Percent analysis would not change how the NRC staff considered Environmental Justice matters in the SEIS as this would confirm a majority minority population (already noted in the SEIS). In applying the Meaningfully Greater analysis, the SEIS documents the extent to which minority populations reside within a 50-mi (80-km) radius of Turkey Point (discussed in Section 3.12 of the SEIS) and did not preclude Environmental Justice matters from being considered in greater detail as these

are addressed in Section 4.12 of the SEIS. No changes were made to the SEIS in response to this comment.

For the scoping and issuance of the draft SEIS public meetings, paper copies of the presentation material was available in Spanish (ADAMS Accession Nos. ML18150A255 and ML19116A258) and an NRC Spanish-speaking representative was available at the meetings to address questions from members of the public. Consistent with 36 CFR 800.8(c), the NRC staff consulted with potentially affected Indian tribes as part of the "National Historic Preservation Act of 1966, as Amended" (NHPA) Section 106 process. Consultation under Section 106 of NHPA is presented in Section 4.9.1.2 of the SEIS. As part of consultation, subsistence activities conducted by Indian tribes were not identified. Section 4.12.1 of the SEIS was revised to include the NRC's outreach efforts to minority populations.

A.2.8 General Environmental Concerns

Comment: We [Florida's 26th Congressional District, which includes Homestead and the Florida Keys] are following this issue very closely. As you can see it's very important to people in this District, and we are concerned that it presents a risk, not only to our water supply and therefore our resiliency, but also to the health and beauty of our natural resources and the local economy that depends on them. Our National Parks and the Marine Sanctuary are treasures we need to protect for future generations. (0001-1-1 [Horton-Diaz, Daniel])

Comment: Yes, it is in fact a truth that the crocodiles have benefitted from those cooling canals. But the ever increasing human population in the Keys and South Miami-Dade and all of Miami also have to be taken into account, what's happening; our drinking water, our recreation, the environment. (0001-9-2 [Bloom, Mary])

Comment: I realize that nuclear power can play a big part in reducing carbon emissions that threaten our planet. However, we must ensure that this is truly "clean" energy, and is not damaging the environment where the plant is located. (0009-1 [Hartman, Richard])

Comment: NPCA and its members care deeply about the health of our national parks, protecting water and biodiversity, and conserving cultural resources. Unfortunately, many park waterways are in jeopardy from threats beyond park boundaries, such as incompatible development, pollution, demands for water use, and climate change. These are among the many threats that are of great concern to NPCA and its members posed by the continued operations of the CCS at Turkey Point and their impacts on the surrounding environment, including our national parks. (0023-2 [McLaughlin, Caroline])

Comment: While safety is always a top priority, I ask that the safety of the surrounding wildlife, marine life, and drinking water should be taken into account. Please keep the surrounding ecosystem in mind as the plant looks to continue to operate. (0029-2 [Lukowski, Stasa])

Comment: While I support nuclear as part of our power generation mix, Turkey Point may present some important concerns that absolutely have to be addressed (0042-1 [Guy, Peter])

Comment: As a concerned citizen and someone who cares deeply about protecting the environment for myself, for my family and for the innocent wildlife that live and travel through National Parks like Biscayne, I am asking that we are proactive as a country to make sure that

any Nuclear facility is safe and not causing harm to our environment, the wildlife and the people who live near them. (0044-1 [Reiser, Reba])

Comment: Thus, Turkey Point can be expected to pose even a more serious threat to Biscayne and the surrounding area, including mangrove forests, rare biota, and the drinking water supply for millions of people. (0049-1 [Cochrane, Theodore])

Comment: Please pay attention and do the right thing. The right thing may not be popular to that big Power conglomerate but it's important for the Park and for the Planet! (0051-1 [Mills, Terri])

Comment: I am first a supporter of preserving what keeps our country great, AMERICA THE BEAUTIFUL. Decisions should not be made in light of short term greed of profit, but in light of life, love and preservation. Need examples? Look at other overindustrialized countries whose land is poisoned, uninhabitable, and reeks of death. (0057-1 [Scotty, Vee])

Comment: My husband and I have visited Biscayne Bay and kayaked and swam there many times. It would be a huge loss if the area is rendered useless for flora and fauna due to nuclear contamination, not to mention the issue of the overarching need we all have for clean drinking water. Please use common sense and logic here!! (0089-1 [Dempsey, Kelley])

Comment: We are killing ourselves with our complacency. It is time to start taking care of our planet - or we won't have one for our grandchildren! (0094-1 [Brown, Linda])

Comment: I grew up on the water and spent many happy hours boating around Turkey Point. It was a pristine environment for wildlife. That was many years ago. Now, we need to take steps to protect this area for our children and grandchildren. (0098-1 [Hummel, Lani])

Comment: Please give mercy, compassion, kindness, respect, justice and very strong protection for the vulnerable environment, precious wildlife and residents of South Florida. Please help to prevent their suffering, abuse, contamination and destruction. (0103-1 [Goppert, Donald])

Comment: Preserving spectacular natural areas that belong to all people should be one of our main goals, always. Pollution is obviously wrong. There are no reasonable arguments FOR pollution. (0114-1 [Waters, Lynn])

Comment: I am a south Florida resident and highly value a clean and safe Biscayne Bay, one of the most important natural areas in our state -for endangered species, marine life, migrating birds and those that depend on mangrove habitat, as well as people who rely on this area for drinking water. (0124-1 [Barstad, Cynthia])

Comment: We have no time to waste because this is an emergency situation and if we don't act aggressively to stop the progression of pollution we are going to find that in a few short years, the earth will not be inhabitable. (0133-1 [Sramek, Jo-Ann])

Response: *These comments express general concerns on topics including water supply and quality, impacts on national parks, economic impacts, and ecological impacts on habitats and species. The NRC staff considered the topics identified in these comments, among other*

matters, in the SEIS. The affected environment at Turkey Point Units 3 and 4 is described in Chapter 3 of the SEIS and the environmental consequences of subsequent license renewal for Turkey Point Units 3 and 4 are addressed in Chapter 4. No new information is provided by these comments and no changes were made to the SEIS as a result of these comments.

A.2.9 Geology and Soils

Comment: Geologic Environment - The descriptions of geologic setting are incomplete. The geologic environment has a direct connection to the operation of the Cooling Canal System (CCS) and the ongoing surface and ground water remediation activities currently occurring on the site. The Draft SEIS does not include a description of the transmissivity of limestone or the importance of the Biscayne aquifer in the water needs of the region. The Biscayne aquifer is considered one of the most transmissive aquifers in the world and provides a direct connection for the flow of water between the CCS and Biscayne Bay through multiple pathways. Geologists have identified three types of voids occurring in Biscayne aquifer: matrix porosity, touching-vug porosity, and conduit porosity. Water flow porosity occurs primarily through the touching-vug porosity and larger conduits (Wacker et a. 2014.) Solution cavities found in the Biscayne aquifer include vertical pipes, which are approximately a foot in diameter, and larger caves (Cunniham and Lee. 2009). Several caves have been identified recently in Biscayne Bay near the Turkey Point site and are being investigated for a direct connection between Biscayne Bay and the CCS. The NPS recommends changing the impact rating for the geologic setting from "Small" to "Moderate-Large" based on the aforementioned connectivity between the CCS and Biscayne Bay. (0005-1 [Vogel, Robert])

Response:

As described in Section 3.5.2.1 of the SEIS, the hydrogeologic characteristics of the Biscayne aquifer, including the porosity, transmissivity, and hydraulic conductivity, are described in Section 2.3.1.2 of NUREG-2176, which is incorporated by reference in the SEIS. The incorporated text includes a description of the secondary porosity features and acknowledges the resulting high horizontal permeabilities of the aquifer. In addition, Section 3.5.2.3 of this SEIS describes water use in the region and acknowledges that nearly all of the potable water supplied to southern Miami-Dade County comes from the Biscayne aquifer. The relationships between the CCS and surrounding water bodies and the potential impacts on water quality from CCS operations are the focus of Sections 3.5 and 4.5 of the SEIS.

As referenced in Section 4.4.1 and Table 4-1 of the SEIS, the scope of the Category 1 (generic) issue "geology and soils" is limited to the staff's evaluation of the impacts of the proposed action (subsequent license renewal) on site geologic and soil resources. However, the NRC staff has separately considered the hydrogeologic properties of the Turkey Point site including the high permeability of the Biscayne aquifer as part of its impact assessments contained in Section 4.5.1.2 of the SEIS, which has been updated in this SEIS based on the staff's consideration of the latest available information.

No new information is provided by this comment and no changes were made to the SEIS as a result.

A.2.10 Historic and Cultural Resources

Comment: Section 4.9.1.3, Page 4-72. The DSEIS states, "Given the age of the Ranger House/McGregor Smith Cottage (50 years old) and the known association with McGregor Smith Cottage, the NRC believes that the cottage is potentially eligible for listing on the NRHP under Criterion b (association with the lives of person significant in the past)." 36CFR60.4, Criterion B and its supporting guidelines (National Register Bulletin 15, page 14) states that this criterion is restricted to those properties that illustrate (rather than commemorate) a person's important achievements. FPL has no evidence that former FPL President Smith had any significant influence over the design, construction or use of this building, nor did he live in it, use it as an office, or spend significant amounts of time in this structure. The structure's association with McGregor Smith is apparently solely that the building was named after him. This statement should be revised to reflect that the association between McGregor Smith and this cottage is remote, at best. FPL recommends that the NRHP eligibility recommendation for this building be stated as *undetermined" until such time as it has been formally evaluated. (0017-4-13 [Maher, William])

Comment: Section 4.9.1.3, Page 4-72. The DSEIS states, "Similarly, as a result of McGregor Smith's known involvement with the Boy Scouts, the Boy Scout structures on the Turkey Point site may potentially be eligible for listing in the NRHP under Criterion b." 36CFR60.4, Criterion B and its supporting guidelines (National Register Bulletin 15, page 14) states that this criterion is restricted to those properties that illustrate (rather than commemorate) a person's important achievements. FPL has no evidence that former FPL President Smith had any significant influence over the design, construction or use of the Boy Scout Camp, nor did he spend significant amounts of time in this location. This statement should be revised to reflect that although it is well-known that McGregor Smith had close ties to both the Boy Scouts and Girl Scouts, the eligibility of the three Boy Scout Camp buildings is remote, at best. FPL recommends that the NRHP eligibility recommendation for the Boy Scout Camp buildings be stated as *undetermined" until such time as they have been formally evaluated. (0017-4-14 [Maher, William])

Response: *Based on recommendations made by the Miami Dade County Historic Preservation Chief in 2012 and 2018 (ADAMS Accession No. ML18247A502), research findings conducted by Coastal Archeology and History Research, Inc. (documented in "A Cultural Content of the McGregor Smith Cottage," ADAMS Accession No. ML18283A882), and the NRC staff's research, the NRC staff believes that there is enough information to conclude that all four structures are potentially NRHP-eligible under Criterion B. The McGregor Smith Cottage and the Boy Scout structures are associated with McGregor Smith, who was an important figure in the history of FPL and in the local Boy Scouts of America community during the time the four structures were constructed. Furthermore, the SEIS clearly states that the Boy Scout structures and the Ranger House/McGregor Smith Cottage have not been evaluated for eligibility for listing in the NRHP in Sections 3.9.2 and 4.9.1.3 of the SEIS. The SEIS was not revised based on these comments.*

Comment: Section 3.9.2, Page 3-115. The DSEIS states, "Construction of Turkey Point likely disturbed any historic and archaeological resource that may have been located within its footprint." This is entirely conjecture. Archaeological investigations have been on-going in Florida since at least 1874 and have been particularly focused in the southeast Florida region during the period following World War II. No sites had been recorded in the vicinity of Turkey Point prior to its construction. This statement should be removed or reworded to indicate that it is "possible" that unrecorded archaeological sites were disturbed. (0017-3-18 [Maher, William])

Response: *The statement in the SEIS was not intended to state that historic and archaeological resources were present within the Turkey Point footprint prior to the construction of Turkey Point Units 3 and 4, as it is unknown if historic and archaeological resources were present prior to construction because cultural resources surveys had not been conducted. The NRC staff revised the subject statement in Section 3.9.2 to clearly state that it is unknown whether historic or cultural resources were disturbed previously.*

A.2.11 Groundwater Hydrology and Quality

Comment: Section 3.5, Page 3-31,3-32. The DSEIS states: "At the Turkey Point site, surface water (including the area's freshwater canals, wetlands, and the adjoining Biscayne Bay) and groundwater are closely connected. This close relationship is attributable to the very high permeability of the underlying Biscayne aquifer, which permits water to move relatively freely between the surface and subsurface and vice versa. As a result, the CCS is hydraulically connected to surface waters including Biscayne Bay via the groundwater pathway." This statement does not distinguish hydraulic characteristics and dynamics of fluid flow. Consequently, there is insufficient information to establish that CCS water is moving into Biscayne Bay or adjacent surface water bodies, that waters from the adjacent water bodies are flowing into the CCS, or whether surface waters from the CCS and surrounding water bodies are not interacting at all. The last sentence should be revised to: "Surface waters in the CCS are hydraulically connected to groundwater within the Biscayne aquifer. Surface waters outside the Plant are also hydraulically connected to the Biscayne aquifer. Flow between surface waters and groundwaters are governed by a variety of factors include stage/hydraulic head gradients, hydraulic conductivity of sedimentation, hydraulic conductivities of aquifer materials, porosity, and fluid density gradients. Transport of surface water sediments and/or dissolved chemical constituents are further complicated by factors such as impingement, diffusion, dispersion, chemical reactions with matrix materials, biologic attenuation, decay/chemical breakdown, temperature/ fluid density gradients etc. All of these factors need to be considered in order to establish, and the degree to which, surface and groundwaters interact." (0017-1-18 [Maher, William])

Comment: Failure to Accurately Characterize Connectivity Between CCS and Surrounding Environment

In the DSEIS, NRC staff fail to present a consistent, accurate characterization of the connectivity between the CCS and surrounding ground and surface water and thus fail to adequately analyze the significance and impacts of these interactions. DSEIS language regarding how the CCS connects to the surrounding environment is contradictory and NRC staff somehow refer to the CCS as a closed system while simultaneously recognizing the contribution of water from the CCS into the surrounding environment because of hydrologic connectivity. NRC staff write that, "at Turkey Point, water from the cooling water loop is discharged into a closed body of water called the cooling canal system."¹¹ Indeed, NRC staff incorrectly state that "the CCS does not connect to any other surface water bodies,"¹² and that, in order to comply with a 1971 consent decree that required FPL to discharge cooling water from plant operations into a closed-cycle cooling canal system, "FPL designed and constructed the CCS and ensured that it had no surface water connection to any outside water body."¹³

And yet, NRC staff go on to explicitly recognize the connectivity between the CCS and outside water bodies: "Water in the CCS is in direct contact with the Biscayne Aquifer and with earthen plugs located in the perimeter of the CCS."¹⁴ This connectivity results in water leaving the CCS

via the Biscayne Aquifer, with more water moving from the CCS into the aquifer than water moving from the aquifer into the CCS.¹⁵ Indeed, *the CCS affects the hydrology and groundwater quality of the Biscayne aquifer. The CCS is unlined and hydraulically connected to the upper Biscayne aquifer because permeable aquifer strata permit the movement of water between the aquifer and the CCS."¹⁶

11 United States Nuclear Regulatory Commission, Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 5, Second Renewal Regarding Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4, Draft Report for Comment, NUREG-1437 Supplement 5 Second Renewal, March 2019, pg. 3-4, emphasis added.

12 Ibid., 3-5

13 Ibid., 3-8, 3-9

14 Ibid., 3-11

15 Ibid., 3-11

16 Ibid., 3-55 (0023-6 [McLaughlin, Caroline])

Response: *The SEIS, including Sections 3.1.1, 3.1.3, and 3.5, was revised to clarify the description of hydrologic connections between surface water bodies and groundwater. In particular, references to the cooling canal system as a closed body of water were revised for clarity, and text was further revised to clearly specify that the connection between the CCS and surrounding surface water bodies is via the Biscayne aquifer groundwater pathway, with no direct connection between the CCS and other surface water bodies. A detailed description of the staff's evaluation of water resources at the site and the surrounding area is contained in Section 3.5 of the SEIS.*

Comment: Section 3.5, Page 3-64. The DSEIS states, "Well locations TPGW-10S/D, TPGW-11S/D, TPGW-13S/D, and TPGW-14S/D are offshore in Biscayne Bay." This statement is inaccurate because TPGW-13 is not located off-shore, but located at the center of the CCS as stated in the previous sentence. This statement should be revised to remove "TPGW-13S/D". (0017-2-1 [Maher, William])

Response: *The sentence in Section 3.5.2.2 of the SEIS was revised to delete the erroneous reference to TPGW-13S/D, and to be consistent with the figures in the SEIS.*

Comment: Section 3.5, Page 3-68. The DSEIS states, "While all wells had detectable ammonia, the concentrations were variable, ranging from a low of 0.17 mg/L at MW-3 adjacent to the intake canal and Biscayne Bay to a high of 4.6 mg/L at the South MW, as compared to the surface water quality standard of 0.5 mg/L." This statement is inaccurate because this is a GW sample and its concentration should be compared to the MDC GW standard. Additionally, there is no State groundwater criterion for ammonia. The statement should be revised to: *While all wells had detectable ammonia, the concentrations were variable, ranging from a low of 0.17 mg/L at MW-3 adjacent to the intake canal and Biscayne Bay to a high of 4.6 mg/L at the South MW, as compared to the Miami-Dade County groundwater standard of 0.5 mg/L." (0017-2-2 [Maher, William])

Response: *The sentence in Section 3.5.2.2 of the SEIS was revised to clarify that the comparison is to the water quality standard for Miami-Dade County.*

Comment: Section 3.5, Page 3-82. The DSEIS states: "Each well is equipped with a 2,500-gpm (9,460 L/min) capacity pump (FDEP 2016b)." This statement is inaccurate because the

wells do not have pumps as they produce water by natural artesian flow. This statement should be removed. (0017-2-7 [Maher, William])

Response: *The sentence in Section 3.5.2.3 of the SEIS was revised to state the authorized maximum flow of 2,500 gpm for each well.*

Comment: Section 3.5, Page 3-85. The DSEIS Figure 3-16 defines the Unit 5 production wells as "Saline Wells" and the CCS freshening wells as "Floridan-Wells." The legend is confusing as both the Floridan freshening wells and the Unit 5 "PW" wells are producing brackish water from the Upper Floridan Aquifer (UFA). The legend should be revised to identify "F" wells (green triangles) as "UFA freshening Wells and "PW" wells (yellow circles) as "Unit 5 UFA Wells". (0017-2-8 [Maher, William])

Response: *In preparing the SEIS, the NRC staff endeavored to be consistent with the well system descriptions and illustrations and to make maximum use of the illustrations provided in relevant documents, including FPL's Environmental Report and Turkey Point Remediation/Restoration Reports. The legend in the referenced figure was revised to differentiate between the site production and freshening wells, and Section 3.5.2 of the SEIS was revised to improve the clarity and consistency of the well designations.*

Comment: Section 3.5, Page 3-72. DSEIS Figure 3-14 depicts the location of RWS-3. This location depiction is incorrect. RWS-3 is located in the NW corner of the CCS. This Figure should be revised to depict the correct location for RWS-3 as identified in the Recovery Well System Startup Report provided in Enclosure 1 to FPL letter L-2019-031 dated April 3, 2019 (ADAMS Accession Nos. ML19095B380 and ML19095B382). (0017-2-5 [Maher, William])

Response: *The referenced figure in Section 3.5.2.2 of the SEIS was revised to replace the graphic (Figure 2.2-1) from FPL's 2017 Annual Remediation/Restoration Report with the graphic (Figure 2.1-1) from FPL's Recovery Well System Startup Report, depicting the correct location of recovery well RWS-3.*

Comment: Section 3.5, Page 3-73. The DSEIS states: "FPL's modeling analysis indicates that operating the CCS with salinity in excess of 35 PSU is the single largest contributor to changes (movement) in the location of the saltwater interface, as measured by the areal extent of the saltwater interface." This statement is incomplete because, although the CCS was the single largest contributing factor, the other factors combined contributed more to the changes in the location of the saltwater interface, than the CCS alone. This statement should be revised to: "Although the CCS was the single largest contributing factor, the other factors combined contributed more to the changes in the location of the saltwater interface, than the CCS alone." (0017-2-6 [Maher, William])

Response: *The statement in Section 3.5.2.2, subsection "Regulatory Developments with Respect to Cooling Canal System Operations and Groundwater Quality," of the SEIS describing the results of FPL's modeling to evaluate the relative contributions of factors affecting the movement of the saltwater interface in the Biscayne aquifer is correct as stated. However, the discussion has been expanded to provide additional context for clarity purposes.*

Comment: Section 3.5.2.2, Page 3-59. The DSEIS states: "FDEP has classified groundwater west of the Turkey Point site (i.e., to the west of the site boundary and CCS) as Class G-II, which means potable water use, with TDS levels of less than 10,000 mg/L (FPL 2018f)." This

statement is inaccurate because it incorrectly suggests that the Biscayne aquifer is supposed to be G-II potable throughout its entire thickness west of the Plant Site. Prior to construction of the CCS, saltwater had already intruded into the Biscayne Aquifer for several miles inland. Near the coast, the aquifer was saline for the full depth of the aquifer (FPL 2018f). Moreover, the FDEP does not specifically list or map GW classifications in aquifers in Florida, rather the classifications are determined by rule criteria (See chapter 62-520.410, F.A.C.). This statement should be revised to: "Groundwater in the fresher upper portion of the Biscayne aquifer west of the Turkey Point site (i.e., to the west of the site boundary and CCS) is classified as Class G-II, which means potable water use, with TDS levels of less than 10,000 mg/L and G-III for those lower portions of the aquifer with TDS levels of 10,000 mg/L or greater which has been intruded with saline groundwater from Biscayne Bay since the 1950s (FPL 2018f)." (0017-3-5 [Maher, William])

Response: *The statement cited by the commenter in Section 3.5.2.2 was revised and expanded to clarify that surficial groundwater west of the Turkey Point site has been classified by FDEP as G-II, consistent with FPL's Environmental Report and as defined by the Florida Department of Environmental Protection.*

Comment: Section 3.5.2.2, Page 3-62. The DSEIS states: "For groundwater monitoring, FPL's contractor performs quarterly field sampling from 14 well clusters, comprising 42 wells in total." This statement is inaccurate because it isn't consistent with Figure 3-12. This statement should be revised to: "... from 14 clusters and 5 historic wells used for salinity and temperature profiling, comprising 47 wells in total." (0017-3-6 [Maher, William])

Response: *Section 3.5.2.2 of the SEIS was revised to acknowledge that the five historical wells shown in the referenced figure, which has been renumbered in this SEIS, have been monitored since the 1970s to assess the impact of interceptor ditch operation on Biscayne Aquifer water quality, as described in FPL's August 2018 Turkey Point Plant Annual Monitoring Report.*

Comment: Section 3.5.2.2, Page 3-63. In Table 3-4, Table footnote: "M" incompletely characterizes the condition as 'missing data' thus allowing for an improper noncompliance inference. The footnote should be modified to reflect the following basis for the 'missing data' condition: "missing data (parameter not required to be monitored)." (0017-3-7 [Maher, William])

Response: *The table footnote cited by the commenter in Section 3.5.2.2 of the SEIS was revised for clarity as suggested.*

Comment: Section 3.5.2.2, Page 3-64. The DSEIS states: "Wells TPGW-1 through TPGW-7 are situated at various distances to the north and west of the CCS. Well cluster TPGW-7S/D can also be considered a sentinel well as it is the monitoring location nearest to the Miami-Dade County's Newton Wellfield that supplies potable water to municipal customers." The statement is misleading as it implies TPGW-7S/D is the last monitoring well between the SWI and the wellfield. There are multiple monitoring wells between the TPGW-7 site and the Newton Wellfield including wells monitored by FPL (including TPGW-20; one of 19 additional wells added to the original EPU monitoring well network shown on Figure 3-12), the USGS and MDC. The sentence implies saline GW could advance into the wellfield without advanced notification since TPGW-7D has become saline. In addition, FPL has monitoring well clusters west of TPGW-7 (TPGW-8 and 9 as shown on Figure 3-12). This statement should be modified to

replace "TPGW-7" with "TPGW-9" and either remove the second sentence or replace with: "Additional monitoring wells that track the orientation of the saltwater interface (not shown on Figure 3-12) occur between the Newton Wellfield and the current location of the saltwater interface line." (0017-3-8 [Maher, William])

Response: *The sentence cited by the commenter was revised for clarity and consistency with the 2009 Monitoring Plan (SFWMD 2009), and a description of additional groundwater monitoring required by the Miami-Dade County Consent Agreement and by the FDEP Consent Order was added to Section 3.5.2.2 of the SEIS.*

Comment: Section 3.5.2.2, Page 3-64. The DSEIS states: "Additionally, data from March 2011 are included to provide an historical baseline, representing the pre-extended power uprate monitoring period for Turkey Point." This statement creates the impression that in 2011, the saltwater interface was stable and could be used as a baseline condition upon which to assess the effects of the uprate on SWI movement. This is not supported by USGS studies that show the freshwater/saltwater interface is and has been moving inland throughout coastal Palm Beach, Broward and Miami Dade counties for decades due to numerous factors independent of Turkey Point. This statement should be revised to: "Additionally, data from March 2011 and 2017 are included to provide comparative water chemistry at selected monitor sites over a six year period." (0017-3-9 [Maher, William])

Response: *The discussion cited by the commenter in Section 3.5.2.2 of the SEIS that discusses comparative groundwater monitoring results from the FPL uprate monitoring program along with the supporting data table were revised to clarify that the groundwater quality data presented is used to compare recent data with data from the pre-uprate monitoring period. In addition, the section was updated to include the most recent, published data from FPL's August 2018 Turkey Point Annual Monitoring Report (FPL 2018o) and other sources.*

Comment: Section 3.5.2.2, Page 3-64. The DSEIS states: "The current monitoring data (Table 3-5) also establish that TDS concentrations in Class G-II designated groundwater immediately to the west of the CCS boundary exceed the G-II standard (TDS of less than 10,000 mg/L)." The sentence makes statements regarding classifications of groundwater under current conditions in relation to presumed groundwater classification earlier in the history of the CCS without consideration of groundwater quality in the area west of the CCS prior to the Construction and operation of the CCS. Determinations whether state water quality criterion are exceeded are made by FDEP with full consideration of State groundwater quality rules. The presumption that G-II groundwater occurred immediately west of the CCS is not supported by historic data collected during the construction of the CCS in 1972 and 1973. For example, TPGW-1,2 and 4 are west of the CCS boundary in portions of the aquifer that exceeded 10,000 mg/L TDS threshold in 1972 before the CCS was operational. This statement should be revised to: "Prior to the construction of the CCS, non-potable groundwater with TDS levels exceeding 10,000 mg/L occurred in the lower portions of the Biscayne aquifer several miles west of the L-31E canal and the Plant Site. Shallow portions of the aquifer contained fresher groundwater the thickness of which increased with distance from the coast. Over the years since the CCS was constructed and operated, the salinities along the base of the aquifer increased and the thickness of the upper freshwater portion of the aquifer thinned. As discussed, there are multiple causes for these changes including the westward migration of hypersaline groundwater from beneath the CCS." (0017-3-10 [Maher, William])

Response: *The paragraph in Section 3.5.2.2 of the SEIS was revised to clarify the staff's evaluation of the monitoring data, references to the FDEP groundwater classifications, and conclusions about the influence of the CCS on groundwater quality.*

Comment: Section 3.5.2.2, Page 3-69. The DSEIS states: "On April 25, 2016, the FDEP issued a warning letter (FDEP 2016c) expressing concern that CCS water was reaching Biscayne Bay." This paragraph is incomplete with regard to the resolution of the FDEP issue raised in the Warning Letter, consequently inadvertently creating a potential impression that operations of the CCS resulted in exceedances of surface water quality standards in Biscayne Bay. This statement should be revised to: "...expressing concern that CCS water was reaching Biscayne Bay and requested FPL provide facts that would assist the Department in determining whether any violations had occurred. On May 16, 2016, FPL submitted nutrient monitoring data to the Department from certain surface water monitoring stations in deep channels adjacent to the CCS for total nitrogen, total phosphorous, TKN, and chlorophyll a. The Department reviewed the information and determined that no exceedances of surface water quality standards were detected in Biscayne Bay monitoring. The Department concluded the Consent Order is intended to minimize the potential for future exceedances of surface water standards (FDEP, 2016a)." [See paragraph 17 of the FDEP CO]. (0017-3-11 [Maher, William])

Response: *The statement in Section 3.5.2.2 of the SEIS is part of the description of the regulatory developments for the site and is correct as written with no implication for effects of CCS operations on Biscayne Bay water quality, which are discussed elsewhere in the SEIS. However, the text has been revised for clarity with a cross-reference added to Section 3.5.1.4 of the SEIS where nutrient monitoring is discussed in detail.*

Comment: Section 3.5.2.2, Page 3-70. The DSEIS states: "Between September 2016 and May 2018, the testing and recovery well systems have extracted and disposed of approximately 8,285 million gallons (31.4 million m³) of hypersaline groundwater, with the removal of 1.92 million tons (1.74 million metric tons) of salt from the Biscayne aquifer (FPL 2018h, 2018i)." The values stated are preliminary values that were finalized and changed during the data validation process (the validated values were reported to the regulatory agencies). This statement should be revised to include the following validated removal quantities: 7.63 billion gallons of hypersaline groundwater removed with an associated salt removal mass of 1.87 million tons. (0017-3-12 [Maher, William])

Response: *Section 3.5.2.2 of the SEIS was revised to reflect the recovery well system performance reported in FPL's 2017 and 2018 Annual Remediation/Restoration Reports (FPL 2017b, FPL 2018p).*

Comment: Section 3.5.2.2, Page 3-70. The DSEIS states, "FPL has constructed five wells to date (i.e., wells F-1, F-2, F-3, F-4, and F-5)." This statement contains incorrect well identifiers. This statement should be revised to: "FPL has constructed wells F-1, F-3, F-4, F-5 and F-6." (0017-3-13 [Maher, William])

Response: *Sections 3.5.2.2 and 4.5.1.2 of the SEIS were revised to remove the erroneous references to well F-2.*

Comment: Section 4.5.1.1, Page 4-23. The DSEIS states: "The program implemented by FPL to extract hypersaline groundwater from the Biscayne aquifer (on the west side of the CCS) is not designed to remove the hypersaline groundwater beneath Biscayne Bay (on the east side of

the CCS)." The statement creates the impression that removal of hypersaline groundwater from the G-III groundwater under Biscayne Bay is an un-met requirement of FPL. The CCS is authorized to discharge to G-III groundwater by NPDES Permit (FL0001562).

Groundwater beneath Biscayne Bay is and has been G-III non potable. CCS discharges to G-III groundwater beneath Biscayne Bay comply with state groundwater discharge rules and accordingly, FPL has not been required to extract hypersaline groundwater from beneath the Bay. This statement should be revised to: "...to extract hypersaline groundwater from the Biscayne aquifer (on the west side of the CCS) is not required or designed to remove the hypersaline groundwater beneath Biscayne Bay (on the east side of the CCS)." (0017-4-6 [Maher, William])

Response: *Section 4.5.1.1 of the SEIS was revised; the sentence indicating that the recovery well system was not designed to extract hypersaline water to the east of the CCS was not essential to the paragraph and was deleted.*

Comment: Section 4.5.1.2, Page 4-25. The DSEIS states: "The hypersaline plume emanating from the CCS has migrated along the base of the Biscayne aquifer to the west into groundwater designated by the State as Class G-II, potable water use (defined as having total dissolved solids (TDS) levels of less than 10,000 mg/L)." This statement is not supported by data and conflicts with the finding in the FDEP CO. Paragraph 14 of the FDEP CO states: "On April 25, 2016, the Department issued a Notice of Violation (OGC File No.: 16-0241) ("NOV") to FPL stating that the CCS is the major contributing cause to the continuing westward movement of the saline water interface, and that the discharge of hypersaline water contributes to saltwater intrusion. In the NOV, the Department found that saltwater intrusion into the area west of the CCS is impairing the reasonable and beneficial use of adjacent G-II groundwater in that area." There was no finding, nor is FPL aware, of instances where hypersaline water emanating from the CCS has migrated into G-II groundwater as stated in the DSEIS. In fact, controlled-source electromagnetic (CSEM) surveying of the hypersaline groundwater identifies the western edge of the hypersaline as being 1 mile or more east of the area where G-II groundwater is being impacted by saltwater intrusion.

The statement should be revised to reflect FDEP findings that the CCS is a major contributing cause of SWI in the area but hypersaline groundwater from the CCS has not been found to be migrating into G-II groundwater. This is also supported by the SWI modeling that identified the CCS hypersaline water as the single largest contributing factor but the combined impact of the remaining seven SWI factors exceeded the influence of the CCS. See also the DSEIS sentence 36 - 39 on page 4-26. (0017-4-8 [Maher, William])

Response: *Sections 3.5.2.2 and 4.5.1.2 of the SEIS were revised to delete inaccurate references indicating or implying that hypersaline water from the CCS has moved westward into groundwaters designated as Class G-II by the State of Florida.*

Comment: Section 4.5.1.2, Page 4-27. The DSEIS states, "Consistent with FPL's statements in its Environmental Report (FPL 2018f), the modeling results for the constructed well system predict retraction of the westward plume to the edge of the CCS by about 5 years and complete retraction within 10 years, with minor aquifer drawdown impacts." This statement is not accurate as retraction to the edge of the CCS will not be complete in 5 years. This statement should be revised to: "Groundwater models of the RWS indicate the westward migration of the hypersaline plume will be stopped in three years of operation, with retraction of the hypersaline plume north

and west of the CCS beginning in 5 years. Retraction of the plume back to the FPL site boundary is projected in 10 years." (0017-4-9 [Maher, William])

Response: Section 4.5.1.2 of the SEIS was revised to clarify the statements regarding the results of groundwater modeling of the recovery well system operation reviewed by the NRC staff as well as statements attributed to FPL as contained in the Environmental Report (FPL 2018f).

Comment: Section 4.5, Page 4-35. The DSEIS states, "Sanitary wastewater discharges to the Boulder Zone via Turkey Point's injection well and septic systems" Turkey Point does not discharge sanitary wastewater into the Boulder Zone. This statement should be revised to: "Sanitary wastewater that is discharged at the site is discharged via a Class V injection well to the Biscayne Aquifer..." (0017-4-10 [Maher, William])

Response: Section 4.5.2.2 of the SEIS was revised to correct the description of the sanitary wastewater discharges consistent with the discussion in Section 3.5.1.3 of the SEIS.

Comment: I saw that it was moderate to small impact. I happen to believe on the groundwater that it's more than small. I think it's at least moderate or more. (0001-3-1 [Schievelbein, Tom])

Comment: Section 4.5.1.2, Page 4-31. In section 4.5.1.2, the DSEIS analyzes potential new Information on a Category 1 Issue, Groundwater Quality Degradation (Plants with Cooling Ponds in Salt Marshes). On page 4-27, the DSEIS concludes that "this information is both new and significant." Based on this information, the NRC concludes that "the site-specific impacts for this issue at the Turkey Point site are MODERATE for current operations, but will be SMALL during the subsequent license renewal term as a result of ongoing remediation measures and State and county oversight, now in place at Turkey Point." Similarly, the DSEIS in section 4.14 (p 4-98) states "The NRC staff determined that the information was both new and significant for one of the issues, 'Groundwater quality degradation (plants with cooling ponds in salt marshes),' as listed in Table 4-1 and as evaluated in Section 4.5.1.2, 'Groundwater Resources,' of this SEIS."

This conclusion, that the information is significant due to its relevance for consideration of current operational impacts, is a misapplication of NRC rules and guidance. 10 CFR 51.75(d) states that a draft EIS is intended to analyze the environmental effects of the proposed action and "need not discuss other issues not related to the environmental effects of the proposed action and associated alternatives." Under section 1.1 of the DSEIS, the proposed action is for the NRC to determine whether to issue a renewed license allowing an operation for an additional twenty years. NUREG 1555, Supplement 1, Revision 1 makes clear that new and significant information must bear on impacts of license renewal (*The NRC staff must identify any new information on the environmental impacts of license renewal.) While the information identified by the NRC in section 4.5.1.2 is certainly "significant" from a public interest and regulatory standpoint, it is not significant as that term is defined by the NRC for this purpose. The NRC concluded that this information does not paint a seriously different picture of the environmental consequence of the proposed during the proposed action. Therefore, this information cannot be considered "significant" for the purpose of reviewing the continued applicability of a Category 1 issue.

It appears that the NRC agrees with this conclusion because it has not followed the process

established by the Commission for instances where information bearing on the proposed license renewal period is deemed new and significant. As explained by the First Circuit Court of Appeals and by the Commission in its 1996 rulemaking, where the Staff identifies new and significant information bearing on a Category 1 issue, it must notify the Commission and seek a waiver of the rule addressing Category 1 issues.

Massachusetts v. NRC, 522 F.3d 115, 120-21 (1st. Cir. 2008); 61 Fed. Reg. 28467 at 28470.

Because the staff has neither identified new information that has significant bearing on the period of renewed operation nor sought a waiver of 10 CFR 51.71(d), the NRC could add clarity and regulatory consistency by stating that it has not identified new information that has a significant bearing on the proposed period of extended operations. (0017-4-11 [Maher, William])

Response: *The NRC staff has appropriately considered and evaluated new information in the SEIS consistent with the NRC's "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," NUREG-1437 (NRC 1996, 2013a) and NUREG-1555, Supplement 1, Revision 1, "Standard Review Plans for Environmental Reviews for Nuclear Power Plants" (NRC 2013b).*

Where appropriate, consistent with the cited NRC staff guidance, the staff has performed a plant-specific analysis of new information in the SEIS to determine whether the information is both new and significant, including for the issue, "Groundwater Quality Degradation ('Plants with Cooling Ponds in Salt Marshes')."

As referenced in Section 1.4 of this SEIS and as further described under Sections 1.5 and 1.8 of the GEIS (NRC 2013a), no additional site-specific analysis is required by the NRC staff for a Category 1 (generic) NEPA issue in the SEIS unless new and significant information is identified that would change the conclusions in the GEIS. In the SEIS, the NRC staff is required to address any new and significant information on the environmental impacts of license renewal involving Category 1 and Category 2 issues.

The NRC provides a more detailed definition of new and significant information in Regulatory Guide (RG) 4.2, Supplement 1, Revision 1 (NRC 2013g). New and significant information is (1) information that identifies a significant environmental impact issue that was not considered or addressed in the GEIS and, consequently, not codified in Table B-1, in Appendix B to Subpart A of 10 CFR Part 51, or (2) information that was not considered in the assessment of impacts evaluated in the GEIS leading to a seriously different picture of the environmental consequences of the action than previously considered, such as an environmental impact finding different from that codified in Table B-1. Further, a significant environmental issue includes, but is not limited to, any new activity or aspect associated with the nuclear power plant that can act upon the environment in a manner or an intensity and/or scope (context) not previously recognized.

With respect to new information concerning a Category 1 issue, the NRC staff must evaluate the significance of any changes in the affected environment or in nuclear power plant operations that have occurred since the initial license renewal term as a basis for predicting the potential environmental impacts of continued operations during the subsequent license renewal term. With regard to the cited issue, as described in Section 4.5.1.2 of the SEIS ("New Information, Category 1 Issue, Groundwater Quality Degradation" ("Plants with Cooling Ponds in Salt Marshes")), the staff's findings regarding the significance of the new information and the associated impacts determination of MODERATE for the current license renewal term are

based on the fact that current and ongoing operations have noticeably degraded groundwater quality in the vicinity of the Turkey Point site and contributed to migration of the saltwater interface. Without mitigative actions, continued operations of the CCS will likely result in additional degradation of groundwater quality. In its analysis, which has been revised for clarity in this final SEIS and based on the latest available information including data on CCS freshening and recovery well operations, the NRC staff acknowledges that groundwater remediation activities are now ongoing and have had, and are likely to continue to have, beneficial effects on groundwater quality. Accordingly, the staff's final SEIS projection that the impacts would be "SMALL" during the subsequent license renewal period is based upon the continuance of FPL's ongoing mitigative actions (CCS freshening and plume recovery) and regulatory oversight by the FDEP and the Miami-Dade County DERM, to reduce the effects of past and ongoing operations on groundwater quality and to achieve the remediation standards prescribed by the State and Miami-Dade County. Because the predicted success of the mitigative actions is based on groundwater modeling and regulatory oversight of the responsible State and local agencies, the staff acknowledges as part of its assessment that there is uncertainty as to the level of projected impacts of the proposed action.

Comment: For decades the antiquated cooling canal system at Turkey Point has been releasing contaminated hyper-saline water into the underlying aquifer. And that's been moving west towards the well fields that supply drinking water for millions and east into Biscayne National Park. This is nothing new, right? So FP&L is currently now working with Miami-Dade County and Florida's Department of Environmental Protection to clean up the pollution and prevent it from recurring in the future. However these remediation efforts have just begun and there's no hard evidence or data at this point in time that conclusively shows that these efforts will be successful. Now FP&L is looking to extend the operating license of its two nuclear units, Units 3 and 4 and by design to continue to operate the cooling canal system. The Environmental Impact Statement that analyzes the impacts of this re-licensing is fundamentally flawed in its conclusions and in the alternatives it considers. The analysis concludes that FP&L should receive a license renewal, which of course assumes that the cooling canal system will continue to operate, because the environmental impacts will be mostly small or occasionally moderate. However, if these conclusions are based on the assumption that FP&L will be successful in meeting the terms of its agreement with Miami-Dade County and with the State of Florida and that pollution from the canals will cease and be cleaned up. It treats this assumption as though it's a foregone conclusion even though it's based only on models provided by FP&L. The remediation efforts that are set to take place over a 10 year time frame only began last year. (0001-8-1 [McLaughlin, Caroline])

Comment: At this time there is no hard data or evidence that conclusively indicates that FP&L will be successful in cleaning up that pollution. Under a different scenario, what happens if their remediation efforts don't work and the cooling canals continue to pollute the surrounding environment? What would the environmental impacts of that scenario look like? We don't know because an assessment of that scenario is not included in this Environmental Impact Statement. NPCA as an organization strongly hopes that the remediation efforts will in fact be successful. However, until there is strong data or science to back up that assumption, it's absolutely premature for NRC to be issuing the recommendation on whether or not to re-license these units. (0001-8-2 [McLaughlin, Caroline])

Comment: And specific to ongoing framework development that I mentioned earlier on groundwater in situ and sent to the management of Yellow Cake and different things like that, that would be related here. And I noticed, that based on chronology and statements that are in the abstract, you know, the EPA has wavered on communicating details specific to impact,

inputting how to build out that framework. And that's concerning. Because that overlays to basically politic. And if we're building frameworks, they have extend beyond politic or a four year presidential cycle. It has to extend to something that well last over the life of the permit and the guidance. And I see a conflict there with regards to clearly stating that the EPA would give guidance, and then backtracking back and letting the NRC to its own devices, not that you're not more than capable with your environmental staff, but you have an agency for that and I'm wondering why the resource is not being mandated, if not utilized. The same thing, why aren't the resources of modeling being utilized like the agencies that are provided by the acts, that's detailed in acts. (0001-15-2 [Gomez, Albert])

Comment: But I will mention that prior to the current fix, which is proposed under the consent decree, there's been no less than four previous attempts to operate these canals within the NPDES permit and deal with the leakage and the environmental impacts that it's causing to the water resources. And this has been over the last 20, 25, 30 years and they've all failed. And in this current consent decree is an attempt, again, to implement a fifth fix and if it doesn't work, then after that, FP&L has a chance to try it again, I guess. (0001-16-3 [Schoedinger, Steven])

Comment: And it's a relief to see this impact statement that doesn't have the direct discharge into the Bay, because that's not acceptable, and you don't think it's acceptable and you shouldn't. But what is not being said here is that these canals are not water from elsewhere. They just dug a hole, a channel into the aquifer. This is the Biscayne aquifer. And what you're doing is you're pumping Biscayne aquifer water around in a big circle. And why that's so weird to be doing, is because the geologic formation here is basically stone swiss cheese. What you have is you have a swimming pool that's about 90 feet deep and it covers many square miles. So the idea here is that you've got water in a channel on the top of a swimming pool that you're moving around for cooling and you're adding contaminants to it. Does it come as any surprise that when you boil the water off, essentially making it evaporate, the salt plume starts going down to the bottom of the aquifer and spreads all through the swimming pool. Of course it did. There were concerns raised at the time, they didn't think that it was really gonna work. And it didn't. So what they did was they came up with a scheme to have an interceptor canal, almost 18 feet deep, 20 percent down to the bottom of the aquifer and 60 feet wide. They were going to pump it out into the groundwater canals to keep the plume from moving. And it didn't work. Five years later it was very clear it didn't work at all, so they -- the Florida Power and Light took the bull by the horns. They renamed the interceptor canal to the interceptor ditch to downplay its failure. And then they produced a series over 35 years, 35 years, a series of models and plans to pump the polluted water around inside the aquifer and stop the contamination from moving. 35 years later the water is still moving at 15 inches per day westward into drinking water aquifers, into drinking water sources. (0001-17-2 [Guest, David])

Comment: we talked about the many times that FP&L has tried to fix the cooling canal situation with respect to the hyper saline plume, and how every single time it's been unsuccessful. In this case there's no evidence that it's working and that the EIS is premised -- if you read the EIS, that many of the statements that they make and findings they make, are based upon this system working. And you heard from Carolyn McLaughlin who said there was no indication that it was working. In fact, we had a statement by several of the speakers that the plume was moving and there was a new report out on wells that were in the western part and that the plume is moving. (0002-6-1 [Rippingille, Bonnie])

Comment: FPL operates within Miami-Dade County and has currently entered into a clean up agreement with DERM over the increasing and advancing radioactive high salinity pollution

plume. This clean up agreement has not been fulfilled or validated, in fact varying scientific institutions have reviewed FPL's pollution plume clean up methodology and have concluded that it will fail to clean up the pollution plume, therefore advancing more pollution through continued operation of Turkey Point Reactor 3 & 4 will place FPL in breach of the clean up agreement. Re-licensing Turkey Point ahead of the clean up would usurp DERMs authority to regulate and protect our clean drinking water supply. (0020-7 [Gomez, Albert])

Comment: Also, the NRC is currently adjusting the environmental review frame work for ground water standards. The NRC should not relicense while relevant frameworks are in flux. (0020-10 [Gomez, Albert])

Comment: For years, the CCS has been contributing to the steady growth of a hypersaline plume, marching west in the Biscayne Aquifer towards our wellfields and east underneath Biscayne National Park. In 2015, after Miami-Dade County issued FPL a notice of violation pertaining to the County groundwater quality standards, FPL entered into a Consent Agreement with the County to abate hypersaline water discharges and remediate the hypersaline plume to the west and north of Turkey Point. In 2016, Miami-Dade County executed an addendum to the Consent Agreement due to apparent violations of County water quality standards related to ammonia exceedances in surface water. As stated above, ammonia exceedances in surface water quality standards attributable to the CCS were detected in 2018, after the execution of the amended Consent Agreement.

In 2016, FPL and FDEP executed a Consent Order related to discharges from the CCS that impaired the beneficial use of Class G-II groundwater adjacent to the CCS, the exceedance of surface water quality standards in Biscayne Bay, and the impact of the hypersaline plume on the saltwater interface. One of the requirements of the Consent Order is for FPL to maintain the average salinity in the CCS at or below 34 PSU. Modeling from 2014 showed that by adding about 14 million gallons per day (mgd) of Upper Floridan Aquifer water with a salinity of 2 PSU to the CCS, it should only take a year to reduce salinities in the CCS to 35 PSU.²³ However, in 2016 and 2017, when FPL added approximately 12.8 mgd of Upper Floridan Aquifer water to the CCS, the average salinity was nowhere near 35 PSU. Rather, it was around 65 PSU.²⁴ While FPL has additional time to comply with Consent Order requirements regarding salinity, this example illustrates the uncertainty inherent in modeling exercises.

Uncertain Outcome of Remediation Efforts

In order to meet remediation objectives of both the Consent Agreement and Consent Order, FPL has constructed recovery wells to extract the hypersaline plume from the Biscayne Aquifer, pumping contaminated water into the Boulder Zone. According to remediation objectives, FPL has 10 years to retract the hypersaline plume to the boundaries of Turkey Point. FPL is required to conduct a series of Continuous Surface Electromagnetic Mapping (CSEM) surveys designed to illustrate the extent and boundaries of the hypersaline plume. The recovery well system went online in 2018 and has been operational for only one year. The only CSEM data currently available shows baseline data from which the future efficacy of remediation efforts will be measured. At this point there is no concrete data to support the claim that remediation efforts will be successful, or that they will be successful in the 10-year time frame stipulated in the Consent Agreement and Consent Order.

It is important to note the consequences laid out in both the Consent Order and Consent Agreement if FPL is unsuccessful at meeting remediation requirements. If FPL is unsuccessful at meeting the terms of these agreements, they only need to come up with additional remediation plans and strategies to be implemented under an indeterminate timeline. Regarding

CCS salinity requirements laid out by the Consent Order with FDEP:

If FPL fails to reach an annual average salinity of at or below 34 PSU by the end of the fourth year of freshening activities, within 30 days of failing to reach the required threshold, FPL shall submit a plan to the Department detailing additional measures, and a timeframe, that FPL will implement to achieve the threshold. Subsequent to attaining the threshold in the manner set forth above, if FPL fails more than once in a 3 year period to maintain an average annual salinity of at or below 34 PSU, FPL shall submit, within 60 days of reporting the average annual salinity, a plan containing additional measures that FPL shall implement to achieve the threshold salinity level.²⁵

FPL is also required by the Consent Order to implement remediation efforts that will halt the westward migration of the hypersaline plume within three years and reduce the westward extent of the plume to Turkey Point boundaries within 10 years:

iv. To ensure overall remediation objectives are attained in a timely manner, if the second CSEM survey indicates that the net westward migration of the hypersaline plume is not being halted, then, within 180 days of the second CSEM survey, FPL shall develop and submit for approval to the Department a plan with specific actions to achieve the objectives of the remediation project. If the third CSEM survey still indicates the net westward migration of the hypersaline plume has not halted, FPL shall implement the approved additional measures within 30 days after submittal of the third CSEM report to the Department.

v. At the conclusion of the fifth year of operation of the remediation project, FPL shall evaluate and report to the Department, within 60 days, the effectiveness of the system in retracting the hypersaline plume to the L-31E canal within 10 years. If this report shows the remediation project will not retract the hypersaline plume to the L-31E canal within 10 years due to adverse environmental impacts of remedial measures or other technical issues, FPL shall provide an alternate plan for Department review and approval. FPL shall begin implementing the alternate plan within 30 days of receipt of notice that the alternate plan has been approved.²⁶

23 Ibid.[United States Nuclear Regulatory Commission, Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 5, Second Renewal Regarding Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4, Draft Report for Comment, NUREG-1437 Supplement 5 Second Renewal, March 2019, pg. 3-4, emphasis added.], p. 3-49.

24 Ibid., p. 3-49.

25 Florida Department of Environmental Protection, Consent Order with Florida Power & Light Company, OGC File No:16-0241, June 20, 2016, p. 8, 20.a, emphasis added.

26 Ibid., p. 10, 20.c.iv. emphasis added.

(0023-10 [McLaughlin, Caroline])

Comment: Similarly, FPL's Consent Agreement with Miami-Dade County requires the implementation of a Biscayne Aquifer Recovery Well System (RWS) to intercept, capture, contain, and retract the hypersaline plume. After five years, the effectiveness of the RWS will be evaluated:

If the analysis indicates that the RWS is not anticipated to achieve the goal to intercept, capture, contain, and ultimately retract the hypersaline groundwater plume, FPL shall make recommendations for modifications to the project components and/or designs to ensure the

ability of the system to achieve the objectives of the Consent Agreement. The evaluation and any proposed revisions shall be submitted to DERM for review and approval.²⁷

The Consent Agreement stipulates that the effectiveness of the RWS will also be evaluated after 10 years:

If monitoring demonstrates that the activities are not achieving the objectives of this Consent Agreement, FPL shall revise the project components and/or designs to ensure the ability of the system to achieve the objectives of this Consent Agreement. The proposed revisions shall be submitted to DERM for review and approval.²⁸

Thus, if remediation efforts as stipulated by the Consent Agreement and Consent Order prove to be ineffective and fail to meet the regulatory requirements laid out in the documents, the only real consequence is that new remediation plans will be devised and implemented over an even longer timeframe. There are no concrete requirements laid out that would guarantee a cessation of continued pollution by the CCS, such as, for instance, a requirement to decommission the CCS. Rather, the only consequence would be unspecified continued remediation efforts over an unspecified timeframe with uncertain results. It is possible that the westward migration of the hypersaline plume and surface and groundwater quality violations could continue indefinitely, and certainly through the subsequent relicensure period. *Unfounded Conclusions Regarding Impacts of Proposed Action on Groundwater Resources*

In the DSEIS, NRC staff concludes that groundwater quality impacts, "are MODERATE for current operations, but will be SMALL during the subsequent license renewal term as a result of ongoing remediation measures and State and county oversight, now in place at Turkey Point."²⁹ As described above, FPL has a history of violating water quality standards and some of the models predicting the impacts of remediation efforts have already shown to be unsound. FPL has always been responsible for operating Turkey Point under all applicable federal, state, and local laws. That they are currently under State and county oversight does not change their history of noncompliance with applicable regulations. Moreover, models are inherently uncertain. NRC staff acknowledges that, "groundwater models are approximations of natural systems and are dependent on a number of input variables based on assumptions regarding present and future environmental conditions. Thus, they entail substantial uncertainty."³⁰

Despite the uncertainty inherent in modeling, FPL's history of violating water quality standards, and the absence of any concrete evidence or data indicating that remediation efforts will be successful, NRC staff somehow comes to the following conclusion:

As a result of FPL's operation of its recovery well system and continued regulatory oversight and enforcement of the terms of the consent order and consent agreement by the FDEP and DERM, the impacts on groundwater quality from operations during the subsequent license renewal term would be SMALL.³¹

²⁷ Miami-Dade County Department of Regulatory and Economic Resources, Consent Agreement with Florida Power & Light Company, October 7, 2015, p. 6, 17.b.iii, emphasis added.

²⁸ *Ibid.*, p. 6, 17.b.iv, emphasis added.²⁹ United States Nuclear Regulatory Commission, Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 5, Second Renewal Regarding Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4, Draft Report for Comment, NUREG-1437 Supplement 5 Second Renewal, March 2019, p. 4-27.

30 Ibid., p. 4-27.

31 Ibid., p. 4-27.32 Applicant's Environmental Report: Operating License Renewal Stage Turkey Point Units 3 & 4 Florida Power & Light Company; Docket Nos. 50-250 and 50-251 Revision 1, Page 2.2-1. (0023-11 [McLaughlin, Caroline])

Comment: As cited extensively above, the Consent Order and Consent Agreement do not guarantee that remediation efforts will be effective. If they are not effective, the only result would be the development of additional remediation techniques, the success of which also cannot be guaranteed. The conclusion that environmental impacts of the Proposed Action on groundwater resources would be SMALL is an unfounded, unsupported, and inaccurate conclusion. It is a very real possibility that remediation efforts will be unsuccessful, and the CCS will continue to discharge pollution into surrounding ground and surface waters, including those of Biscayne National Park. In the DSEIS, NRC staff must include any kind of assessment of the environmental impacts of the Proposed Action if remediation efforts are unsuccessful. (0023-12 [McLaughlin, Caroline])

Comment: I would like to know when the current contamination of the aquifer will be corrected. (0027-1 [Dick, Marianne])

Comment: License Renewal Term: As outlined in the comments below, the EPA identified numerous issues from the review of the SD EIS regarding many aspects of the Proposed Action or relicensing renewal. Most significant of these issues is the hypersalinity plume in the aquifer related to the Canal Cooling System (CCS). The EPA notes that the Florida Department of Environmental Protection (FDEP) and the Miami-Dade County Department of Environmental Resources Management (DERM) have entered into various consent agreements with Florida Power and Light (FPL) regarding issues related to the CCS. The EPA supports the FDEP and DERM's efforts to work with FPL to remediate the adverse impacts of the hypersalinity plume in the aquifer and the ammonia releases to surface waters. The EPA notes that these consent agreements have outlined various corrective actions to address the issues related to the CCS. However, these corrective measures have only recently been implemented.

Recommendations: Given the many unknowns related to the CCS corrective measures effectiveness and the timing and length of the license renewal, the EPA recommends the NRC consider a reopening term and/or condition in the license should the corrective measures in the FDEP and DERM consent agreements not be met. As part of this reopening term and/or condition, we recommend that the NRC and the licensee re-evaluate the alternative corrective measures to include the Cooling Water System Alternative. The EPA recommends the NRC, in consultation with FPL, FDEP and DERM, take an adaptive management approach to ensure the facility's compliance with the applicable consent agreements. The EPA further recommends that the NRC coordinate closely with FDEP and DERM to ensure that the FDEP and DERM are sufficiently satisfied with the progress of the CCS corrective measures before the license renewal begins in 2032. (0031-2 [Militscher, Christopher])

Response: *As described throughout Sections 3.5.1.4 and 3.5.2.2 of the SEIS, which have been revised in this SEIS based on the latest available information, including from annual surface water, groundwater, and ecological monitoring surveys, the staff has considered the development of regulatory actions addressing cooling canal system (CCS) operational effects on groundwater quality and the adjacent surface waters. The staff considered the results achieved to date, the regulatory authority exercised by State and County regulatory agencies, and the likely effectiveness of the mitigative actions undertaken by FPL under the Miami-Dade*

County Consent Agreement and the Florida Department of Environmental Protection Consent Order to remediate the hypersaline plume and reduce the impact of CCS operation on groundwater quality and surface water quality via the groundwater pathway.

In the NRC staff's impacts analysis presented in Section 4.5.1.2 of the SEIS, the staff determined that impacts on groundwater quality are MODERATE for the current license renewal term based on the fact that current and ongoing operations have noticeably degraded groundwater quality in the vicinity of the Turkey Point site and contributed to migration of the saltwater interface. Without mitigative actions, continued operation of the CCS is likely to result in continued degradation of groundwater quality. In its analysis, however, the NRC staff further acknowledges that groundwater remediation activities are now ongoing and have had and are likely to continue to have beneficial effects on groundwater quality.

The staff's impacts projection that the impacts would be "SMALL" during the subsequent license renewal period is based upon the continuance of FPL's ongoing mitigative actions (freshening and plume recovery) to reduce the effects of past and ongoing operations on groundwater quality. Because the predicted success of the mitigative actions is based on groundwater modeling and regulatory oversight of the responsible State and local agencies, the staff acknowledges as part of its assessment that there is uncertainty in the projected impacts under the proposed action. The staff determined in Section 4.5.1.2 of the SEIS that, while there is uncertainty in timing and the ultimate effectiveness of the mitigative actions, the success of FPL's mitigation efforts is subject to regulatory oversight by county and state agencies and is continually evaluated through a comprehensive water quality monitoring program. Section 3.5.2.2 of this SEIS has been revised to reflect the latest published groundwater monitoring data for the Turkey Point site, including the results from the 2018 continuous surface electromagnetic survey designed to track changes in the hypersaline plume, as well as the latest published data on CCS freshening and recovery well operation effectiveness. The NRC staff has considered and acknowledged this new information in its impact assessment as presented in revised Section 4.5.1.2 of the SEIS (see "New Information, Category 1 Issue, Groundwater Quality Degradation" ("Plants with Cooling Ponds in Salt Marshes")) while acknowledging that uncertainty remains. If FPL's monitoring results show that water quality improvements are not being made because corrective actions are not as effective as projected, FPL must develop and submit alternative remediation plans to the regulatory agencies. Because the regulatory oversight is anticipated to remain in place and the regulatory agencies retain the authority to require FPL to continue its current freshening activities, the NRC staff concluded that the proposed action would have SMALL impacts on water resources during the period of subsequent license renewal, despite the existence of uncertainty as referenced above.

With respect to commenter concerns that the NRC should include a reopening clause and/or condition in the renewed reactor operating licenses, if issued, for Turkey Point Units 3 and 4 in the event that FPL is unable to achieve the mandated groundwater remediation objectives, the staff notes that the NRC does not have regulatory authority to require FPL to comply with consent agreements or consent orders issued by the State of Florida's Department of Environmental Protection or the Miami-Dade County DERM, and therefore cannot make compliance with orders issued by other agencies a condition of the NRC license. Miami-Dade County and the Florida Department of Environmental Protection have the authority and responsibility for enforcing applicable provisions of their environmental regulations and the referenced consent order and consent agreement. Issuance of a renewed license, however, does not foreclose or restrict the ability of other regulatory authorities to take such actions as

they deem necessary to ensure compliance with the orders, consent agreements, or other regulatory requirements under their jurisdiction.

Comment: I have to agree with the representative from the League of Women Voters, and m[M]y other concern has to do with housing. This part of the County is where the greatest growth in housing is occurring in Miami-Dade County, and that's largely driven by the cost of housing everywhere else in the County. And as a consequence you're going to have more people that are going to be relying on electricity and also on water. And it's very important, it's critical that we get this right. I mean we have a plume that is growing about a foot a day, and this has been going on for 30 years, and we need to make sure this is taken care of. And frankly, I think that FP&L should assume the cost in cleaning this up, because they've got the money to do it. (0001-6-1 [Morra, Frank])

Comment: [The EPA has identified the following issues related to the environmental impact and alternatives analysis as discussed in Chapter 4 of the SDEIS....]

*Minimization of CCS Impacts: Descriptions of the CCS environmental impacts are not provided in a cohesive manner in the SD EIS. An explanation for the characterization approach is found in a table footnote on page 199 of the document (Table 4-1, footnote b, pg 4-4,5):

"(b) The NRC staff recognizes that the current impacts on this issue are greater than SMALL (i.e., the impacts are MODERATE). However, as discussed in Section 4.5.1.2 of this chapter, in response to a 2015 consent agreement with the Miami-Dade County Department of Environmental Resource Management (DERM) (MDC 2015a) and a 2016 consent order from the Florida Department of Environmental Protection (FDEP) (FDEP 2016e), FPL has implemented a recovery well system to halt and retract the hypersaline plume and to abate and remediate the effects of the hypersaline plume from the cooling canal system. These efforts are expected to remediate the hypersaline plume prior to the commencement of the subsequent license renewal term. In addition, FPL's actions to remediate the plume are subject to continued regulatory oversight by the DERM and the FDEP. Therefore, the NRC staff expects that groundwater quality degradation impacts resulting from subsequent license renewal will be SMALL."

The EPA is concerned that the Proposed Action is placed in the "small" impact category. The EPA supports the FDEP and DERM's efforts to work with FPL to remediate the adverse impacts of the hypersalinity plume and ammonia releases. However, there is much unknown regarding the hypersalinity plume and ammonia releases and it is uncertain that these measures will provide the long-term results as modeled. Additionally, the water withdrawal impacts to drinking water sources and the Comprehensive Everglades Restoration Plan projects (CERP) (See comment below) when determining the impact category should be considered.

Recommendation: The EPA recommends the NRC reevaluate the impacts to groundwater by including impacts associated with water withdrawals and evaluating the impacts of the CCS in the existing condition. The EPA recommends the NRC reconsider placing groundwater and surface waters in the "Moderate to Large" impact category. (0031-5 [Militscher, Christopher])

Response: *The NRC staff evaluated the potential groundwater use conflicts resulting from groundwater extraction for the recovery well system (RWS) and the cooling canal system (CCS) salinity reduction in Section 4.5.1.2 (see "Groundwater Use Conflicts (Plants That Withdraw More Than 100 Gallons per Minute)") of this SEIS. Impacts on the Biscayne aquifer, including on drinking water sources, were determined to be SMALL. RWS groundwater withdrawals*

associated with hypersaline plume recovery and other FPL withdrawals from the saline portion of the aquifer would be unlikely to interact with any offsite wells withdrawing water from the inland portions of the Biscayne aquifer. Offsite reductions in groundwater elevations due to RWS pumping were also evaluated by the staff on the basis of groundwater modeling by FPL and the South Florida Water Management District (SFWMD) and were determined to have minimal potential to impact wetlands to the west of the L-31E Canal. This modeling (Tetra Tech 2016) included the pumping effects of known municipal, industrial, and agricultural wells pumping at their maximum permitted withdrawal rates. The NRC staff considers the modeling assumption that wells would operate at their maximum permitted rates to be conservative and acceptable, considering potential regional population growth and associated water demands during the projected remediation timeframe.

Groundwater withdrawal impacts on the Upper Floridan aquifer were determined to be MODERATE during the subsequent license renewal term. The modeling analysis considered by the NRC staff (Tetra Tech 2014b) assumed that FPL's freshening wells withdrawing from the Upper Floridan aquifer would operate at maximum permitted rates, combined with other existing permitted withdrawals in the region withdrawing at permitted rates. As for the Biscayne aquifer, the NRC staff also considers the modeling assumption to be conservative and acceptable, considering potential regional population growth and associated water demands.

The NRC staff's response to comments specific to the likely effectiveness of the mitigative actions undertaken by FPL to remediate the hypersaline plume and reduce the impact of CCS operation on groundwater quality and surface water quality is provided in its response to Comment no. 0031-2.

Comment: Groundwater: Regarding groundwater, the SDEIS provides the following: 3.1.3.2, (pg 3-11). States: "FPL estimates that the inflow of groundwater from the Biscayne aquifer into the CCS is about twice the volume of outflow of water from the CCS into the Biscayne aquifer (FPL 2018f).e"

The EPA is concerned that discussing inflows/outflows apart from concentration can create a potential misunderstanding. To a lay person, a positive inflow/outflow volume ratio may appear to be a 'positive' indicator. However, when considering that dissolved solids are retained apart from volume, this ratio can be problematic. Volume exchange is a factor that must be considered in the system characterization, but it is the total mass and concentrations of dissolved constituents that determine the water quality impacts. The analysis in the SDEIS is lacking these refined distinctions. (0031-12 [Miliischer, Christopher])

Response: The comment refers to a subsection in Section 3.1.3.2 of the SEIS that describes the operation of the cooling canal system (CCS) in terms of water flows into and out of the CCS. A comprehensive discussion of the water and salt budgets of the CCS, the water quality of the CCS, the transport of dissolved constituents from the CCS to adjacent water bodies, and the management of salinity in the CCS is included in Section 3.5.1.4 of the SEIS. This comment provides no new information, and no changes were made to the SEIS in response to this comment.

Comment: The two alternatives, especially as it relates to the cooling water systems that are being looked at, which are either cooling towers or to continue with the canals, the open canals that are there. Presently the source of the water for the canals is out of the Floridan, which is brackish water, which contributes somewhere between a million and a half pounds of salt per day into those canals, which is, you know, part of the problem that we're identifying today. Over

decades that's generated part of the problem we're dealing with at this point in the admissions to the Bay. If you look at the Floridan going into cooling towers, then you don't deal with the impacts of salt into a body of water that might leach into surrounding resources. It is truly a closed-loop system, and it would, at that point, be used to cool and you'd use much less, because in order to use the canals, out of the Floridan, you have to generate 30 million gallons a day more than you really need for the process to allow for the evaporation that takes place daily over 6,000 acres of these 3-foot deep, 20 and 50-foot wide canals. And that's a horrendous use, a horrible use of water resources for South Florida. We are growing more and more reliant on the Floridan for our drinking water. For example, FKA, a third of the capacity at that plant is an RO plant that takes water from the Floridan in order to serve the Florida Keys. And I think at this point that is a serious resource. We have a drought in North Florida where the Floridan takes its water, you know, then the water levels in the Floridan could drop down to levels which would impact the operation of a lot of water supply, irrigation systems that are being used, and maybe in some case drinking water systems. (0002-1-1 [Shoedinger, Steve])

Comment: Conflict Analysis: On page 4-30, Conflicts Analysis for the Upper Floridan Aquifer section, the SDEIS discusses the groundwater impacts for the Proposed Action related to FPL's freshening well system and states, "For offsite, non-FPL wells, the model projects a maximum drawdown of 2.26 feet (0.7 m) at the MD WSD's South Miami Heights wellfield, located approximately 10.3 mi (16.6 km) north, northwest of the center point of FPL's freshening well system." The EPA notes that there appears to be no evaluation in this conflict analysis that considers possible impacts to the U.S. Army Corps of Engineers (USACE) or South Florida Water Management District's (SFWMD) CERP projects. Also, there appears to be no water use conflict analysis for the other alternatives (no action, new nuclear, natural gas combined-cycle, combination alternative or cooling water system), which does not adequately portray how the other alternatives would potentially impact groundwater and drinking water resources.

Recommendation: The EPA recommends the NRC conduct a groundwater use conflict analysis for the FSEIS (as described for the Proposed Action, pages 4-28-4-35) and comparatively evaluate each alternative's impacts related to water withdrawals. Furthermore, the EPA recommends the NRC consider the water withdrawal impacts to include impacts to CERP when determining the Proposed Action's groundwater impacts. (0031-10 [Militscher, Christopher])

Response: *Section 3.5.2.1 of the SEIS describes that the Biscayne aquifer is separated from the Upper Floridan aquifer by the Intermediate Confining Unit, which serves as an effective aquiclude for the Floridan aquifer system. Due to the low permeability of the confining unit, extraction of water from the Upper Floridan aquifer is not expected to affect uses of Biscayne aquifer water, including for projects related to the Comprehensive Everglades Restoration Plan (CERP). As a result, the scope of the NRC staff's groundwater use conflicts analysis in Section 4.5.1.2 (see "Groundwater Use Conflicts (Plants That Withdraw More Than 100 Gallons per Minute)") of the SEIS with respect to FPL freshening operations for the CCS was restricted to users extracting water from the Upper Floridan aquifer. However, the NRC staff's conflicts analysis for the Biscayne aquifer is separately presented in Section 4.5.1.2, which considers the effects of FPL's recovery well system. This analysis considers and quantifies projected impacts on groundwater elevations, offsite sawgrass marsh wetlands, and on existing users of the Biscayne aquifer.*

With respect to alternatives, as described in Sections 4.5.2.2 and 4.5.7.2 of the SEIS for the no-action and the cooling water system alternatives, respectively, the staff expects that groundwater demands for CCS freshening would decrease over time commensurate with the

reduction in thermal discharge to the CCS from Turkey Point Units 3 and 4, so that potential water use conflicts would also be reduced for these alternatives, compared to the proposed action. Because thermal discharges to the CCS would also be reduced for the replacement power alternatives, potential water use conflicts would also be reduced for these alternatives. Sections 4.5.2.2, 4.5.3.2, and 4.5.7.2 were revised where appropriate to provide a discussion of these and related considerations.

Comment: Groundwater Resources. The DSEIS concludes that the impact of the selected alternative, subsequent license renewal, on Groundwater Resources, specifically groundwater quality degradation, would be SMALL. The NRC in a footnote to Table 4-1 indicates that the impacts "are greater than SMALL (i.e., the impacts are MODERATE)" but further indicates that the groundwater quality degradation will be ameliorated by FPL's implementation of the recovery well system "to halt and retract the hypersaline plume and to abate and remediate the effects of the hypersaline plume" and through FDEP and DERM's continued regulatory oversight and enforcement. a) While DERM will continue its regulatory oversight of FPL's remediation of the hypersaline plume, including any required modification and adaptive management on FPL's part, it should be noted that the groundwater model that formed the basis of the predictions regarding the performance of the recovery well system found that "eastward retreat of the hypersaline interface is not achieved in the deepest portion of the aquifer via this remedial alternative" (see Application of Parameter Estimation Techniques to Simulation of Remedial Alternatives at the FPL Turkey Point Cooling Canal System dated July 2016 and submitted by FPL).

b) The groundwater model was calibrated based on a 10-year sea level rise projection and as such the effectiveness of the recovery well system with respect to the capture and containment of the hypersaline plume (as required in the Miami-Dade County Consent Agreement) based on sea level rise projection beyond 2025 was not evaluated. Given the concerns with the documented groundwater impacts of the Cooling Canal System on water resources in the area, the potential limitations and uncertainty associated with complete remediation of the hypersaline plume, and the challenges and uncertainty over FPL's ability to successfully manage the Cooling Canal System water quality into the future, DERM recommends that NRC staff reconsider its characterization of Groundwater Degradation Impacts as SMALL. (0022-1 [Hefty, Lee N.]

Response: *As indicated in footnote (b) in Table 4-1 of Section 4.1 of the SEIS, the current MODERATE impacts finding for the issue, "Groundwater quality degradation (plants with cooling ponds in salt marshes)," reflects the staff's impacts assessment with respect to the current affected environment for groundwater quality in the vicinity of the Turkey Point site. However, the NRC staff also predicts the environmental impacts of the agency's proposed action (subsequent license renewal) including the continued operation of Turkey Point Units 3 and 4 beyond the expiration of their current licenses; as discussed in Section 4.5.1.2, those impacts are expected to be SMALL. This second license renewal term would not begin until 2032 and 2033 for Units 3 and 4, respectively.*

In support of the staff's impacts analysis for the proposed action (subsequent license renewal) on groundwater quality presented in Section 4.5.1.2, "Groundwater Resources" (see "New Information, Category 1 Issue, Groundwater Quality Degradation (Plants with Cooling Ponds in Salt Marshes)", of the SEIS, the NRC staff reviewed the information provided by FPL (Tetra Tech 2016) describing groundwater modeling of the recovery well system performance as well as a report prepared by the South Florida Water Management District (SFWMD 2017a).

As noted in the modeling report (Tetra Tech 2016), the model results were compared to results of a continuous surface electromagnetic (CSEM) survey conducted to evaluate the extent of the hypersaline groundwater plume west of the cooling canal system (CCS). As stated in Section 3.5.2.2 of the SEIS, the Miami-Dade County Consent Agreement and the Florida Department of Environmental Protection Consent Order specify the use of CSEM survey results to evaluate the location, volume, and movement of the hypersaline plume. The original CSEM survey discussed in the modeling report indicated that the greatest westward extent of the hypersaline plume is not along the base of the Biscayne aquifer, but in a high-flow zone of the aquifer at a higher elevation. This result has been confirmed by the baseline CSEM survey conducted in March/April 2018. As noted in the model report (Tetra Tech 2016), the groundwater model overestimates the westward extent of the hypersaline plume at the base of the Biscayne aquifer. Based on the NRC staff's review of Tetra Tech (2016), the staff has determined that modeling choices were the likely explanation for this overestimate.

Section 3.5.2.2, subsection "Baseline Groundwater Quality and Changes Attributable to Turkey Point Operations," of this SEIS has been revised to describe the depth dependence of the hypersaline plume based on the CSEM survey results. In addition, Section 3.5.2.2 has been revised to reflect the latest published groundwater monitoring data for the Turkey Point site as well as the latest published data on CCS freshening and recovery well operations effectiveness. The NRC staff has considered and acknowledges this new information in its impact assessment as presented in revised Section 4.5.1.2.

As part of its review, the NRC staff reviewed the FPL modelers' calibration process and assumptions, including those with respect to water levels, as documented in the modeling report for the 10-year simulation periods (2016 through 2025). The NRC staff acknowledges the commenter's statement that the modeling commissioned by FPL does not evaluate the effectiveness of the recovery well system beyond 2025. Nevertheless, FPL is required under the terms of the 2015 Consent Agreement with Miami-Dade County and the 2016 FDEP Consent Order to intercept, capture, and retract the hypersaline plume within 10 years of startup of the recovery well system (i.e., by about 2028 and prior to the start of the proposed subsequent license renewal term). The NRC staff further acknowledges that there is inherent uncertainty in groundwater modeling as well as in future hydrologic conditions given climate change. The staff's evaluation (which has been revised in this final SEIS based on the latest available information, including data on CCS freshening and recovery well operations), acknowledges that ongoing groundwater remediation activities have had and are likely to continue to have beneficial effects on groundwater quality. Accordingly, the staff's final SEIS projection that the impacts would be "SMALL" during the subsequent license renewal period is based upon the continuance of FPL's ongoing mitigative actions (CCS freshening and plume recovery) and regulatory oversight by the FDEP and the Miami-Dade County DERM, to achieve the remediation goals prescribed by the State and County.

Comment: Groundwater Resources - FPL, through guidance by the Florida Department of Environmental Protection (FDEP), uses the presence of tritium to trace water movement from the CCS into surrounding areas. As tritium in natural conditions is expected to be lower than 20 pCi L⁻¹, concentrations in sampled waters indicate higher levels that are attributable to the CCS. Groundwater sampled in a series of wells within the CCS and Card Sound show that concentrations are exceptionally higher than the background level (Figure 1). These extremely elevated levels of tritium are a clear indicator of CCS water infiltration into the bay and ultimately a signal of the adverse impacts the bay is experiencing as a result of operations of the CCS. This is further evident in the elevated groundwater samples concentrations for Total Nitrogen (TN) in Figure 2 and Total Phosphorus (TP) in Figure 3. [view figures in pdf available in NRC

ADAMS at ML19143A166] The Draft SEIS states that new technology established in May 2018 will limit CCS waters to the boundary of the CCS and prevent intrusion into the bay in five to 10 years and as such Groundwater impacts were identified as "small to moderate." Assumptions about the effectiveness of these remediation efforts to make predictions about future conditions introduce uncertainty. Instead, this technology should be tested and the assertion that the hypersaline plume will recede back to the boundary of the CCS should be assessed in the identified five-years. With the high levels of tritium already persisting in Card Sound groundwaters, the NPS recommends changing the impact rating for surface water to "Moderate-Large." (0005-4 [Vogel, Robert])

Response: *Section 3.5.2.2 of the SEIS describes the current water quality in the Biscayne aquifer, including an increasing vertical trend in tritium activity with depth. Section 3.5.2.2 of this SEIS has been revised to reflect the latest published groundwater monitoring data for the Turkey Point site, the results from the 2018 continuous surface electromagnetic survey designed to track changes in the hypersaline plume, as well as the latest published data on cooling canal system (CCS) freshening and recovery well operations effectiveness. The SEIS describes how the higher density of the hypersaline water from the CCS is expected to preferentially move in the lower intervals of the Biscayne aquifer. The NRC staff concluded that the available tritium data indicate CCS operations have influenced aquifer water quality beneath Biscayne Bay, at least in the deep interval of the aquifer. Section 3.5.1.4 of the SEIS describes surface water quality and notes that tritium measured in adjacent surface water bodies has been very low as compared to the deeper intervals of the Biscayne aquifer both onshore adjacent to the CCS and offshore beneath Biscayne Bay and Card Sound.*

As described in Section 4.5.1.2 (see "New Information, Category 1 Issue, Groundwater Quality Degradation (Plants with Cooling Ponds in Salt Marshes)") of the SEIS, the staff evaluated the impacts on groundwater quality from the past and current operation of the CCS and determined that they are currently MODERATE. However, as part of its impact analysis, the staff also projects the potential impacts of the proposed action (subsequent license renewal), including the continued operation of Turkey Point Units 3 and 4, for the 20-year period following 2032 and 2033. As discussed in Section 4.5.1.2 of this SEIS, the NRC staff determined that the impacts on groundwater quality for the proposed action would be SMALL. The NRC staff acknowledges the NPS's concerns regarding the uncertainty in making predictions about the effectiveness of remediation technologies currently being used by FPL, which have been reflected in Section 4.5.1.2 of this final SEIS. However, as discussed in Section 4.5.1.2, which has been updated based on the latest published information presented in Section 3.5.2.2, the staff's impact conclusion is based on consideration of the existing groundwater resource conditions, the current efforts to mitigate the effects of the CCS, and the existing regulatory oversight by State and County agencies. The staff's impacts projection during the subsequent license renewal period is based upon the continuance of FPL's ongoing mitigative actions (freshening and plume recovery) and continued oversight by State and County regulatory agencies (with the authority to impose alternate methodologies, if necessary), to reduce the effects of past and ongoing operations on groundwater quality. The staff determined that, while there is substantial uncertainty in timing and the ultimate effectiveness of the mitigative actions, the mitigation is subject to regulatory oversight by County and State agencies and is continually evaluated through a comprehensive water quality monitoring program.

Comment: [Turkey Point's cooling canal system has been leaking nutrient-rich hyper-saline water into surrounding waters for over 30 years, dumping 3 million pounds of salt per day] into

.... Biscayne aquifer. As a result.... 50 percent of Biscayne aquifer have been destroyed. To repeat, Biscayne aquifer is Miami-Dade's only source of drinking water. FP&L Turkey Point has now applied for a permit renewal that will add another 30 years to their right to pollute the waters of South Florida. It is estimated that if FP&L Turkey Point continues operation of its cooling canals our drinking water supply would be unusable with 5 to 20 years. (0001-4-3 [Pierce, Barbara])

Comment: It's very clear that to the west -- and by the way, I've just looked at the well data to the west. There is Florida Keys Aquaduct Authority that has several wells that track the movement of this plume. I just looked them up. The well that they put in recently, last year, Well 14 has shown that within a year, the plume has moved beyond that well. They just put it in and they put it in a location where the plume was not there. And if you know anything about science, you know that ionic concentrations of high concentration move to a lower concentration. So this plume will not stop moving. 15 million gallons a day of extraction wells is not going to stop it. That's a fact. It just can't. It will go until the [salt] in concentration settles out. And where is that? The Everglades. It's going to keep moving west. Now one of the solutions in the remediation plan is to add a whole bunch of fresh water to the cooling canal system. If you do that, you increase the driving head of the cooling canal system and what will happen is more of the time it will seep out everywhere around us, flushing the pollution everywhere around us. (0001-13-3 [Reynolds, Laura])

Comment: And so the nutrients that were left behind formed a toxic hypersaline plume as well as fueled the growth of algae and all of that is going west and going east. West through the aquifer, our sole source of drinking water and down through the limestone and into the Bay, when it's not washing over due to storms or tidal surges.

Anyway FPL is using water that should instead be used for critical Everglades restoration. Our Floridan supply of water in that Floridan aquifer, it's brackish water, it's not unlimited. It's fueled and recharged by water, rainfall from Northern Florida and Georgia. If it doesn't rain, it doesn't get refueled. So it's not unlimited.

The Biscayne aquifer, for your information, has already been allocated to agencies, Governmental agencies, different users, commercial users. It's not being allocated anymore. So the Floridan is the backup to that and the Floridan has to go through an RO process. And one of our speakers today from the North Utility District will talk to you about that. He's an expert in that system. (0001-14-4 [Rippingille, Bonnie])

Comment: Anyway, as Laura Reynolds said, the pumping of all this massive amount of water, into the cooling canals, has caused a surge. And as she said, I got the same information and actually I got it from her, the wells west now are showing that the plume is moving, which is shocking because we were told that they didn't have any evidence that it was not moving. I'm not saying they were misrepresenting, because the evidence just came in. But the point is, the plume is moving and this system as Ms. McLaughlin told you, is not working and no one expects it to work. This is FPL modeling, this is FPL stalling because they don't want to tie into their profits and have to put these cooling canals (sic) in. They know that they're appropriate. Trust me, they know. And they don't want to do it. And in this process that's going on, over 35 years, starting in 1982, FPL has tried no less than five fixes on this plume situation and this seepage and leakage. And none of them have worked. Now they're into the sixth fix and it's an experimental line of 10 extraction wells along the western side of the five mile link to the canal system, trying to pull back and stop the polluted hyper-saline water after it leaks into the aquifer. They're not pulling it out of the cooling canals, they're pulling it out of the aquifer after it has been permitted over 30 years to leak into the aquifer. Also, they've been permitted to draw all

this water from the L-31, the brackish water in the Floridan, and I've already told you that's not an unlimited supply. (0001-14-6 [Rippingille, Bonnie])

Comment: [Turkey Point's cooling canal system has been leaking nutrient-rich hyper-saline water into Biscayne ...] aquifer for over 30 years... and 50 percent of Biscayne aquifer have been destroyed. For over 30 years FP&L has been quietly dumping 3 million pounds of salt per day into Biscayne Bay and aquifer. Biscayne aquifer is Miami-Dade's only source of drinking water. FP&L has now applied for a permit renewal which will add another 30 years to their permit to pollute, taking them to the year 2050. It is estimated that if FP&L Turkey Point continues operation of their cooling canals, our drinking water supply will be unusable within 5 to 20 years. (0002-2-3 [Gutierrez, Vivian])

Comment: These canals are in the aquifer, they're in the Biscayne aquifer. So what you put in there goes into the groundwater. And you hear all these stories we've heard today; people referring to these things as a closed-loop system. It's not. These are canals in the aquifer. And as you heard earlier you have about 3 million pounds a day of salt going through into the aquifer. Even FPL, which is known to stretch the truth pretty thin, even they acknowledge 660,000 pounds of salt goes into the aquifer every day from operating this system. It's not closed loop. It's aquifer contamination and it's moving at 15 inches a day. We've had five previous plants [plans] based on FPL modeling that would stop the salt plume. All five failed completely. It's been moving at 15 inches a day for 35 years. And the new plant, number 6 model, has what is absolutely necessary for them in it, which is a promise that if this plan fails, like the previous five did, that they'll produce another one. That's the obligation is to just keep on doing experiments. And with the level of contamination we have now, I think the time for experimentation has ended, and indeed ended long ago. (0002-4-1 [Guest, David])

Comment: So the future water supply to continue operating this plant is very important to think about. And I would argue that generally using nuclear power is a bad choice because of its water demands for South Florida. (0002-5-4 [Reynolds, Laura])

Comment: The cooling canals are only about two feet above sea level and it's dramatically reducing the amount of available fresh water in the Biscayne aquifer because of salt water intrusion. And that's a real problem for this community in South Florida because we are growing. We are growing and we're going to be continuing to grow, by the looks of it. I know all of you experienced the traffic coming here, and know what it's like to try to even get to work in Miami-Dade County. (0002-6-3 [Rippingille, Bonnie])

Comment: Contaminated water from Turkey Point's antiquated cooling canal system has been seeping into the groundwater and polluting surface waters connected to Biscayne and the aquifer that supplies drinking water for millions. (0003-2 [Commenters, Multiple])

Comment: I live in Key Largo, FL in Monroe County which is down wind and down stream from FPL's Turkey Point Nuclear Power Plant. I am quite concerned and worried about their application to renew and extend their operating license on their aging power plant. I am aware of the hypersaline plume that extends from Turkey Point's antiquated and dysfunctional cooling canal system. This plume is the single most damaging source of groundwater pollution threatening Monroe County's drinking water supply. The plume also intrudes into Biscayne National Park and threatens the health of the wildlife and habitat that the park is meant to protect.. (0004-1 [Moses, Dorothy])

Comment: Failure of Turkey Point's Industrial Wastewater Facility Cooling Canal System

Turkey Point is unique among nuclear plants in the United States in that it uses a system of unlined cooling canals to cool water from plant operations. The CCS, in place for more than 40 years, consists of approximately 5,900 acres of former wetlands along the coast of Biscayne Bay and Biscayne National Park. It is used to cool water from nuclear power Units 3 & 4 and to dispose of wastewater from the operations of natural gas Unit 5. When the system was constructed under a 1971 consent decree, the CCS was intended to be a closed loop system. However, due to South Florida's porous limestone geology, the CCS is hydrologically connected to the underlying Biscayne Aquifer and to surrounding surface waters.⁶

Over the years, water in the CCS has become hypersaline, increasing in density and sinking into the underlying Biscayne Aquifer, ultimately creating an underground hypersaline plume. The plume is spreading out into the Biscayne Aquifer "at an average rate of migration to the west estimated between 525 (northern part) and 660 (southern part) feet per year,"⁷ towards several wellfields that supply drinking water to the residents of the Florida Keys and southern Miami-Dade County. The plume is also moving east, under the waters of Biscayne Bay and Biscayne National Park.

⁶ Hefty, Lee, Miami-Dade Department of Environmental Resources Management, Letter to Phil Coram, Florida

Department of Environmental Protection, November 26, 2014.

⁷ Florida Department of Environmental Protection Administrative Order in Re: Florida Power & Light Company, Turkey Point Power Plant, DEP State License No. PA03-45, OGC No. 14-0741, December 23, 2014. (0023-4 [McLaughlin, Caroline])

Comment: We can't afford to have more groundwater polluted. (0046-1 [Champy, Cheryl])

Comment: Turkey Point is a danger South Florida now and plans need to be made soonest to alleviate ground water contamination[.] (0076-1 [Wesolowski, Pam])

Comment: I am concerned that our ground water be protected for our future generations. (0109-1 [Luzum, Rosemary])

Comment: As a frequent visitor to the area, I have grave concerns about this ongoing contamination of groundwater. Please solve this issue before extending the life of this facility. (0145-1 [Hangartner, Terry])

Response: *The impacts to groundwater and surface water resources are described extensively in this SEIS. For example, Section 3.1.3.2 of this SEIS describes the design and function of the cooling canal system (CCS) at Turkey Point. Groundwater resources are described in Section 3.5.2 of the SEIS, including the hydrologic connection between the CCS and the Biscayne aquifer, the current location and rate of movement of the saltwater interface in the groundwater, the effects of the CCS on groundwater quality, regulatory actions to restore groundwater quality, and FPL's groundwater use for CCS freshening and other uses at the Turkey Point site. Portions of Section 3.5.2 have been revised to provide additional information in response to specific comments on the draft SEIS. Specifically, Section 3.5.2.2 has been revised to reflect the latest published groundwater monitoring data for the Turkey Point site, the results from the 2018 continuous surface electromagnetic survey designed to track changes in the hypersaline plume, as well as the latest published data on CCS freshening and recovery well operations effectiveness. Section 4.5.1.2 of the SEIS describes the NRC staff's evaluation*

of the impacts of the proposed action on groundwater quality and potential groundwater use conflicts. Sections 4.5.1, 4.6.1, and 4.7.1 discuss, respectively, impacts to water resources adjoining the Turkey Point site, as well as terrestrial and aquatic resources, including resources within Biscayne National Park.

These comments provide no new information, and no changes have been made to this SEIS as a result.

Comment: The League [of Women Voters of Miami-Dade County], together with other community leaders, has been following FPL's persistent attempts to renew its Turkey Point cooling canals permit for more than via now. We're deeply concerned by the environmental and economic impact these cooling canals are having on Biscayne Bay and on Biscayne aquifer, Miami-Dade's only source of drinking water. Even more concerning is FP&L's apparent lack of concern for the health and welfare of the community and its own customers. (0001-4-1 [Pierce, Barbara])

Comment: I'd like to say that although FP&L claims it's addressing the leakage, the past five and the current sixth plan that they're using has not addressed the source of the problem and that's the flawed cooling canal design. (0001-9-4 [Bloom, Mary])

Comment: But when looking at these cooling canals, and the degradation of the Bay and the aquifer, we have to remember that so many people in Monroe County, which includes all of the Florida Keys, are going to be terribly impacted if the cooling canals continue to operate. So please, we need to revisit your statement on that. (0001-9-5 [Bloom, Mary])

Comment: We at the League, together with other community leaders from the County, have been following FPL's persistent attempts to renew their Turkey Point cooling canals permit for over two years now. We are deeply concerned of the environmental and economic impact these cooling canals are having on Biscayne Bay and our fresh water drinking supply, Biscayne aquifer. Even more concerning perhaps is FP&L's lack of concern for the health and welfare of our community and our customers, which grant them access to a very profitable business and location. (0002-2-1 [Gutierrez, Vivian])

Comment: [As an environmentalist and wildlife advocate, I am very concerned about the operation of of the nuclear power plant at Turkey Point. There should be concrete measures addressing . . .] the contamination that seeps from Turkey Point. (0008-2 [Propen, Beverly])

Comment: For years, contaminated water from Turkey Point Nuclear Power Plant's antiquated cooling system has been seeping into the groundwater, polluting surface waters connected to Biscayne National Park and the aquifer that supplies drinking water for nearby communities. (0011-1 [Puca, Rob])

Comment: The TP plant was designed in the 60s with a unique cooling system of approximately 10 square miles of open, unlined cooling canals which use water to cool the reactors. The TPP site and cooling canal system are adjacent to the surficial Biscayne Aquifer, our designated sole source drinking water aquifer and situated between the Everglades National Park, the designated Outstanding Federal Waters of the US, the Biscayne National Park and Card Sound. The open cooling canal system (CCS) was an experiment and is an antiquated system that has not worked as designed for approximately 30 years. The unlined cooling canals are licensed by the State of Florida as an industrial wastewater site. The hyper saline plume

created by the FPL operation of the cooling canal system was caused by the 40 mgd of evaporation of water from the open canals which left millions of gallons of heavier salt behind in the bottom of the canals. The hot polluted hyper saline water (3 times saltier than seawater) in the cooling canals has caused the sea grass to die in the canals, which leaving a polluted mix of nutrients and decaying organic matter in the CCS that has interfered with the ability of the water to cool the reactors during periods of intense heat. Now, the system cannot be operated safely without the infusion of 30 million gallons of brackish water daily from our secondary aquifer, the Floridan, to freshen and dilute the salt concentration in the CCS. The CCS water is still hypersaline although the level of salinity has been reduced. Over the course of approximately 35 years, starting in about 1982; FPL has tried five times to resolve the issues caused by the cooling canals, but none of these proposed solutions have worked. At the present time, FPL is attempting a 6th fix which is a line of 10 extraction wells, along the western side of the 5 mile length of the canal system, to attempt to pull back the polluted hyper saline water after it leaks into the aquifer and to stop and pull back the hyper saline plume which extends out more than 4 miles in all directions from the cooling canals. The hypersaline plume is still moving towards Monroe County water well field to the West of the TPPP. Now into the second year of operation , there is no evidence that the hyper saline plume has been stopped. Recently, FKAA scientist Kirk Martin provided us with monitoring well reports demonstrating that the hyper saline plume is still moving westward. (0024-3 [List, Gary])

Comment: Nobody, animal or human, should have to worry about the safety of their drinking water! (0110-1 [Sieger, Brenda])

Comment: Logic dictates that protection of human health and the water supply for hundreds of thousands of people must be the priority concern. (0147-1 [Farber, Carol])

Comment: As a National Park lover and also one who appreciates clean drinking water, it's important to me that we protect our parks and our waters. (0154-1 [Harris, Susan])

Response: *These comments express concerns regarding the effects of the cooling canal system on water supply and water quality, similar to several comments addressed above. The NRC staff considered the issues identified in these comments, among other matters, in this SEIS. Section 3.5 of the SEIS describes the water resources of the Turkey Point site including the current water quality of the CCS and surrounding surface- and groundwater-bodies. As described in Sections 3.5.1.4 and 3.5.2.2 of the SEIS, the staff considered the development of regulatory actions addressing CCS operational effects on groundwater quality and the adjacent surface waters. The staff also considered the likely effectiveness of the mitigative actions undertaken by FPL under the Miami-Dade County Consent Agreement and the Florida Department of Environmental Protection Consent Order to remediate the hypersaline plume and reduce the impact of CCS operation on water quality. The staff evaluated the potential water resources-related impacts of renewing the Turkey Point Units 3 and 4 operating licenses in Section 4.5. In preparing this final SEIS, the NRC staff reviewed information that became available after publication of the draft SEIS, including ongoing water quality monitoring data, additional environmental studies, and evolving regulatory actions to include information on FPL's progress in achieving the objectives related to the aforementioned State and County regulatory requirements. In addition, the staff incorporated recent information in the final SEIS, as appropriate.*

These comments provide no new information, and no changes have been made to this SEIS as a result.

Comment: [With more time, the NRC and associated regulatory agencies can review new information on] New fresh water well contaminations that occurred since the SEIS was completed (0020-2 [Gomez, Albert])

Comment: [With more time, the NRC and associated regulatory agencies can review new information on...] Documented illegal salt dumping south of Turkey Point which has created contaminated ground water, more dead zones and is in violation of environmental regulations (0020-4 [Gomez, Albert])

Response: *In preparing this final SEIS, the NRC staff reviewed information that became available after publication of the draft SEIS, including ongoing water quality monitoring data, additional environmental modeling studies, and evolving regulatory actions. In addition, the staff incorporated recent information in revisions to the SEIS, as appropriate. For example, Section 3.5.2.2 of the SEIS has been revised to reflect the latest published groundwater monitoring data for the Turkey Point site, the results from the 2018 continuous surface electromagnetic survey designed to track changes in the hypersaline plume, and the latest published data on CCS freshening and recovery well operations effectiveness. New reference documents are listed in Chapter 6 of this SEIS. No new information is provided by these comments, and no specific changes have been made to the SEIS as a result.*

Comment: Section 4.5.2.2, Page 4-35. In the DSEIS Section 4.5.2.2 and 4.5.7.2 discussions of the water resource impacts of the No-Action and Cooling Water System alternatives, the DSEIS acknowledges that the CCS would remain in place, albeit with reduced thermal input and a corresponding reduced demand for freshening water additions from the UFA. FPL notes that with these alternatives, the hypersaline plume would also remain and still require operation of the Recovery Well System and disposal through deep well injection in accordance with the Consent Order and Consent Agreement. (0017-4-12 [Maher, William])

Response: *Sections 4.5.2.2, 4.5.3.2, and 4.5.7.2 of the SEIS that describe the impacts to groundwater resources under the no-action alternative, replacement power alternatives, and cooling water system alternative, respectively, have been revised for clarity to include the addition of a discussion of freshening water additions and recovery well and deep well system injection operational considerations.*

Comment: We currently have 197 members who not only fish in the Bay waters surrounding Turkey Point but also reside in Monroe County and are dependent on the Biscayne Aquifer as our primary source of drinking water. We are concerned about the license renewal for Turkey Point as regards the continued use of the cooling canals as the system to cool the nuclear reactors rather than requiring FP&L to build cooling towers which are recognized by the nuclear industry as the best technology for cooling said reactors. The canals lie above the Biscayne Aquifer and have been leaking pollution into the Aquifer and the waters of Biscayne Bay National park for decades. (0032-1 [Bloom, Mary])

Response: *Section 3.5.2.2 of the SEIS describes the current water quality in the Biscayne aquifer, and Section 3.5.2.3 describes current groundwater use for operation of Turkey Point and other users in Miami-Dade County. Sections 4.5.1 and 4.7.1 of this SEIS evaluate the impacts of the proposed action (subsequent license renewal of Turkey Point Units 3 and 4) on water resources and aquatic resources, respectively. Further, as described in Section 4.5.1.2 of the SEIS, which has been revised in consideration of the latest available information, the staff*

evaluated the impacts on groundwater quality from the past and current operation of the CCS and determined that they are currently MODERATE. However, the staff also evaluated groundwater quality impacts during the proposed subsequent license renewal period and concluded that these would be SMALL. The staff's impact conclusion was based on consideration of the existing groundwater resource conditions, the current efforts to remediate impacts to groundwater, and the existing regulatory oversight by State and County agencies.

With regard to FPL's continued uses of the CCS under the proposed action (subsequent license renewal), this SEIS evaluates an alternative closed-cycle cooling water system that could mitigate potential impacts associated with the continued use of the existing CCS. The purpose of this analysis is for the NRC staff to compare the closed-cycle cooling alternative with the proposed action to inform NRC's licensing decision, as well as to inform other decisionmaking authorities and the public, in accordance with NEPA.

The NRC's statutory mission is to protect public health and safety from the effects of radiation from nuclear reactors, materials, and waste facilities. A discussion of these responsibilities beginning with the Atomic Energy Act of 1954 can be found on the NRC Web site at <http://www.nrc.gov/about-nrc/history.html>. The NRC does not have the authority to require its licensees to utilize a particular type of cooling system, nor can the NRC ensure a licensee's compliance with other regulatory authorities' requirements under the Federal Clean Water Act or with applicable State water quality standards. Accordingly, the NRC does not have the regulatory authority to require that FPL implement an alternative closed-loop cooling water system as a condition of subsequent license renewal.

These limitations on the NRC's authority do not foreclose or restrict the ability of other regulatory authorities to take such actions as they deem necessary to ensure compliance with orders, consent agreements, or other regulatory requirements under their Clean Water Act or other lawful statutory jurisdiction.

No changes were made to the SEIS in response to this comment.

A.2.12 Surface Water Hydrology and Quality

Comment: Section 3.5, Page 3-45. The DSEIS states, "According to its environmental report for subsequent license renewal, FPL's current plans to lower CCS temperatures do not include the use of freshwater from State canals (FPL 2018f). In the future, should FPL need to use freshwater from State canals, FPL would need to seek permission to do so from State and county governments. FPL states that future plans to reduce CCS temperatures include adding brackish water from the Upper Floridan aquifer, reducing algae in the CCS, continuing to remove sediment within the CCS, and, only in extraordinary circumstances, pumping saltwater from the Biscayne aquifer into the CCS (FPL 2018f)." This statement is incomplete because the mitigation activities described are primarily to address salinity in the CCS, not temperature. However, there may be some secondary benefit of temperature reduction that is not reflected in this section. This statement should be revised to: "FPL states that future plans to improve water quality include adding brackish water from the Upper Floridan aquifer, reducing algae in the CCS, continuing to remove sediment within the CCS, and, only in extraordinary circumstances, pumping saltwater from the Biscayne aquifer into the CCS (FPL 2018f)." (0017-1-19 [Maher, William])

Comment: Section 3.5, Page 3-47. The DSEIS states, "To help reduce the water temperatures within the CCS, on June 27, 2014, the State of Florida granted FPL permission to add saltwater from the Biscayne aquifer and brackish water from the Upper Floridan aquifer to the CCS (NRC 2016a)." This statement is inaccurate because temperature reduction was not the primary objective of the water additions authorized by the State of Florida on June 27, 2014. The supplemental water supplies were used to improve water conditions in the CCS, primarily to lower CCS salinity and temperature. While decreasing salinity levels within the CCS was the primary objective, a secondary benefit may have provided some heat reduction to the CCS. This statement should be revised to: "To help improve water conditions within the CCS, on June 27, 2014, the State of Florida granted FPL permission to ...". (0017-1-20 [Maher, William])

Response: Section 3.5.1.4 of the SEIS has been revised, in part, as a result of these comments, to clarify the primary purpose of adding lower-salinity water to the CCS.

Comment: Section 3.5, Page 3-49. The DSEIS states, "In 2014, Tetra Tech used numerical models to estimate the volume of Upper Floridan aquifer water that would be required to reduce CCS water salinity to seawater range. The modeling exercise produced an estimate that with the addition of 14 mgd (53,000 m³/day) of Upper Floridan aquifer water that had a salinity of 2 PSU it would require less than a year to reduce salinities in the CCS to 35 PSU (Tetra Tech 2014a). However, while FPL then added an average of 12.8 mgd (48,500 m³/day) of Upper Floridan aquifer brackish water to the CCS from the beginning of November 2016 to the end of May 2017, salinities in the CCS did not go down to 35 PSU (FPL 2017a). Rather, at the end of May 2017, average salinity concentrations in the CCS were 64.9 PSU (FPL 2017b)." This statement is ambiguous because it raises questions regarding the volume of Upper Floridan water needed to achieve the targeted annual average salinity of 34 PSU in the CCS. The modeling efforts that are discussed in the Tetra Tech 2014a memo were based on 22 months of data, one year of which had above normal rainfall. As a result of continued monitoring, the model has been updated and further refined using a longer data record that incorporates a more representative range of hydrologic and salinity conditions. The refined model identified a longer period of time would be needed to reduce the average annual CCS salinity in the event of extended dry period or drought. Information from this expanded model was considered by the FDEP in requiring FPL to achieve the average annual salinity of 34 psu in the CCS within four years of initiating freshening activities as described in the Consent Order. The 2017 and 2018 annual monitoring reports both described drier than normal conditions with January through May 2017 being the 6th driest dry season over the previous 49 years and January through March 2018 being the driest in 10 years. If wetter than normal conditions (similar to those that occurred in 2012) persisted, 14 MGD of Floridan aquifer water would achieve the target. However, based on the updated modeling that reflects normal to extended dry conditions, the time needed to achieve the target salinity is longer and even that longer modeled period would be predicated on wetter conditions than the dry conditions experienced in 2017 and early 2018. This statement should be clarified by adding: "Additional data collected since 2014 have been used to update the model with a wider range of hydrologic conditions and associated CCS salinity responses. The updated modeling indicates a wider range of evaporative conditions exist, particularly during the dry seasons, which exceed 14 mgd and suggest that when such drier conditions occur, more freshening water or longer timeframes will be needed to offset the drought related evaporative losses from the CCS." (0017-1-21 [Maher, William])

Response: Section 3.5.1.4, "Application of Numerical Modeling to CCS Salinity Mitigation," of the SEIS has been revised, in part, as a result of this comment, to clarify that if drier conditions

were to prevail, more freshening water or longer timeframes may be needed to mitigate elevated CCS salinities.

Comment: Section 3.5, Page 3-50. The DSEIS states, "Sampling data by Miami-Dade County and FPL in the late fall and winter months of 2015-2016 revealed levels of ammonia concentration that exceeded the County's water quality standard for ammonia (0.5 mg/L) at two surface water quality monitoring stations near the CCS in Biscayne Bay (MDC 2016a)." This statement is inaccurate because the monitoring stations referred to in this section are not located in Biscayne Bay. They are located in remnant deep-cut man-made canals adjacent to Biscayne Bay. Following an evaluation of those data and data collected in Biscayne Bay conducted by the FDEP, the FDEP determined that no exceedances of State or federal surface water quality standards were detected in Biscayne Bay monitoring (FDEP, 2016e). Miami-Dade County has established its own standard for ammonia as nitrogen under municipal code (Chapter 24, Article III, Division 3, Section 24- 44.(2)(f)(v) MDC Municipal Code). The rule identifies the basis of the promulgated ammonia numeric standard as respiratory. This statement should be revised to: "Sampling data by Miami-Dade County and FPL in the late fall and winter months of 2015-2016 revealed levels of ammonia concentration that exceeded the County's water quality standard for ammonia (0.5 mg/L) at two surface water quality monitoring stations near the CCS in bottom samples collected in remnant deep (>20 feet deep) man-made canals adjacent to Biscayne Bay (MDC 2016a). FDEP evaluated those data and additional water chemistry data collected in Biscayne Bay and determined no exceedances of State or Federal surface water quality standards were detected in Biscayne Bay monitoring (FDEP, 2016e)." (0017-1-22 [Maher, William])

Response: Section 3.5.1.4 of the SEIS has been revised, in part, as a result of this comment, to clarify the location of the surface water quality monitoring stations and FDEP's determination regarding the exceedance of water quality standards during the 2015-2016 monitoring period.

Comment: Section 3.5, Page 3-68. The DSEIS states: "In July 2017, Miami-Dade County requested that FPL collect additional data in support of the ammonia site assessment report (FPL 2017b). In November 2017, FPL responded to the County's request by submitting supplemental information." This statement is incomplete because it does not include the significant findings from FPL's November 2017 supplemental information submittal (FPL letter dated November 13, 2017 - Florida Power & Light Company Site Assessment Report Supplemental Information Submittal: DERM File Number HWR 851; available on the FPL SLR online reference portal by May 31, 2019). That submittal documents data and research demonstrating the CCS has little potential for contribution to the ammonia levels in deep canals and identifies sources and process by which ammonia occurs at the monitoring sites. This statement should be revised to include the following information (taken from FPL's November 2017 response): "The FPL response evaluated tritium results from the ten sites identified in the County's April 20, 2017 email combined with data provided from six sites analyzed by MDC DERM to assess the strength of relationship between tritium levels and ammonia measured in surface and groundwater sites. Tritium data were also used to estimate percentage contributions of Cooling Canal System (CCS) waters at the MDC specified surface and groundwater sites to evaluate the degree to which organic nitrogen in and beneath the CCS could account for the ammonia values measured at each site. Ammonia data collected from background porewater monitoring sites located outside the influence of CCS waters from freshwater marsh and coastal brackish water mangrove wetlands was also presented. These data document elevated ammonia levels consistently above County standards that forms from organic nitrogen released from plant debris and organic soils. Additional data and reports were

also provided regarding numerous other monitoring stations within the Biscayne Bay coastal area that have documented similar ephemeral excursions of ammonia greater than 0.5 mg/L to those recorded in stagnant deadend canals outside of the Turkey Point facility. FPL concluded these data and analyses support the original conclusions in the Site Assessment Report that the source of the ammonia in the area of Turkey Point is attributable to the degradation of plant and animal material and to natural and anthropogenic phenomenon related to non-CCS factors affecting Biscayne Bay. The elevated ammonia levels in surface waters surrounding the Plant are of limited vertical, spatial and temporal extent. The results obtained from the sampling program at Turkey Point are consistent with data collected throughout Biscayne Bay in other studies along coastal Miami-Dade and Monroe counties. Elevated ammonia values in excess of County surface water standards are not the result of point or non-point source contamination attributable to the Turkey Point Power Plant site and CCS. Rather, the occurrence of elevated ammonia is the result of the conversion of organic nitrogen sourced from organic wetland soils, decomposition of wetland and aquatic plant material, atmospheric nitrogen fixation and natural microbial processes in anoxic, stagnate surface and groundwater environments." (0017-2-3 [Maher, William])

Comment: Section 3.5, Pages 3-68 and 3-69. The DSEIS states: "The County's letter directs FPL to undertake a number of additional actions, including development of a revised sampling plan for ammonia in surface water and groundwater and measures to reduce nutrient impacts from the CCS on surface waters and groundwater (MDC 2018a). Surface water sampling results from the ammonia site assessment report are discussed in Section 3.5.1.4, "Adjacent Surface Water Quality and Cooling Canal System Operation," of this SEIS." This statement is incomplete because it does not address FPL's October 8, 2018 response, (a copy of which FPL provided to the NRC in Enclosure 2 to FPL letter L-2019-031 dated April 3, 2019 (ADAMS Accession Nos. ML 19095B380 and ML19095B384). This statement should be revised to: "On October 8, 2018, FPL responded to the MDC July 18, 2018. In their response, FPL noted that groundwater data collected since 2010 from stations surrounding the CCS show, groundwater ammonia concentrations were consistently below MDC Chapter 24-44 Clean-up Target Levels (CTLs) (Section 24-44.(2)(f)(v) of the Code of Miami-Dade County) and as such, provide an acceptable level of protection for human health, public safety and environmental resources and are below the point at which a site rehabilitation action is determined to be accomplished (Section 24-44.(2)(a) of the Code of Miami-Dade County). Further, the average ammonia levels within the CCS canals are well below Chapter 24-42(4) surface water standards of 0.5 ppm (Enclosure 2 to FPL letter L- 2019-031 dated April 3, 2019 (ADAMS Accession Nos. ML 19095B380 and ML19095B384). Measured ammonia concentrations in several of the deep samples greatly exceeded the total nitrogen concentrations in the CCS and in groundwater beneath the CCS demonstrating that there are sources of nitrogen other than the CCS causing exceedances of county ammonia standards in the bottom of the deep canals. As identified in FPL's Site Assessment Report (SAR), ammonia concentrations that exceeded applicable MDC surface water standards in five deep man-made drainage canals adjacent to the CCS were located in bottom samples where dissolved oxygen levels were less than 1.0 mg/L. Ammonia levels in the middle and upper portions of the water column were compliant with county ammonia standards with the exception of middle samples in the Turtle Point Canal where the dissolved oxygen levels were also less than 1.0 mg/L. There are no state numeric ammonia standards for Class III marine waters. Using Tritium and salinity mixing analyses, the SAR analysis demonstrated that for those bottom canal samples that exceeded the Miami-Dade limit for ammonia, the maximum contribution attributable to the CCS was 8% with an average of 2.85%. The SAR also established that the estimated CCS contribution to surface water site with ammonia levels below the county standard ranged from 0.4 to 16%. These evaluations were conservative as the potential for CCS ammonia contributions to the deep man-made canals were made using the

concentrations of total nitrogen in the CCS (to address the theory that total nitrogen in CCS waters was being converted to ammonia in groundwater and then being transported to the adjacent canals) which were much higher than the ammonia concentrations in the CCS. Thus, if there is any contribution to ammonia concentrations in adjacent surface water from groundwater beneath the CCS, it is de minimis. FPL also outlined the numerous successful actions taken to reduce nutrient levels in the CCS and the additional actions underway that address nutrient contributions from the Turkey Point facility." (0017-2-4 [Maher, William])

Response: *The discussion in the cited portion of the SEIS relates to groundwater quality, specifically ammonia and not surface water quality, which is discussed separately in Section 3.5.1.4 of the SEIS. Ammonia levels in the CCS and vicinity are correctly described in that section. Further, in Section 3.5.1.4 under "Ammonia and Nutrients within Biscayne Bay and Card Sound," the NRC staff observed that ammonia values are consistent with the anoxic conditions that exist at the bottom of remnant canals and the accumulation of organic matter falling into the remnant canals from surrounding areas of the bay. The comments provide no new information, and the SEIS text was not changed in response to these comments.*

Comment: Section 3.5.1.1, Page 3-34. The DSEIS states: "The canals generally discharge the most freshwater into the bay and sound during wet times of the year and the least during dry periods. As a result, salinity concentrations throughout the year in the bay and sound are more variable in time and space than prior to the construction of drainage canals (NRC 2016a)." This statement is incomplete. In addition to canal discharges to the bay, USGS studies have shown a reduction in groundwater stages as a result of drainage have affected Bay salinities as a result of reduced fresh groundwater seepage into near shore coastal waters (see "Evaluation of Effects of Changes in Canal Management and Precipitation Patterns on Salinity in Biscayne Bay, Florida", Using an Integrated Surface-Water/Groundwater Model", Scientific Investigations Report 2012-5099). This is a significant factor in the water quality in the Bay and Sound. This statement should be revised by adding: "In addition, canal management practices lower area groundwater table elevations which have reduced fresh groundwater seepage into Biscayne Bay and Card Sound further affecting coastal salinity." (0017-2-11 [Maher, William])

Response: *Section 3.5.1.1 has been revised, in part, as a result of this comment, to indicate that groundwater table elevations may be affected by the presence of the drainage canals that intercept surface runoff and therefore prevent infiltration of that runoff to the groundwater table. However, the strong conclusion suggested by the comment is not found in the cited USGS Scientific Investigations Report 2012-5099.*

Comment: Section 3.5.1.1, Page 3-34. The DSEIS states: "The Turkey Point site occupies an area of former sheet flow that discharged into the bay. However, development of the site's location blocks sheet flow from reaching Biscayne Bay (NRC 2016a)." This statement is inaccurate because sheet flow into Biscayne Bay and Card Sound had been intercepted by the construction of the L-31E canal/levee in the early 1960's prior to the construction of the CCS. This statement should be revised to: "The Turkey Point site and L-31E canal/levee occupies an area of former sheet flow that discharged into the bay. Development of the L-31E canal/levee and the TP site has blocked historic sheet flow from reaching Biscayne Bay and Card Sound. However, FPL installed a series of 40 culverts through the L-31E levee in 2009 that re-established sheet flow into Card Sound." (0017-2-12 [Maher, William])

Response: Section 3.5.1.1 has been revised, in part, as a result of this comment, to describe the effects of the Central and Southern Florida Flood Control Project (L-31E canal/levee) on historical sheet flow near the Turkey Point site.

Comment: Section 3.5.1.1, Page 3-35. The DSEIS states: "The Florida legislature has designated Biscayne Bay and Card Sound, including Biscayne National Park, as Outstanding Florida Waters. This affords these waters the highest water quality protections in the State (NRC 2016a; Robles, et al 2005; NPS 2012). The FDEP cannot issue permits for direct discharges to Outstanding Florida Waters that would lower ambient (existing) water quality and may not issue permits for indirect discharges that would significantly degrade a nearby waterbody designated as an Outstanding Florida Water (FDEP 2017a)." As a completeness clarification, the following language should be added to the above paragraph: "However, the CCS was authorized and constructed prior to the OFW designation was enacted and Florida water quality rules provide exceptions for existing facilities that were permitted prior to the effective date of the Outstanding Florida Water designation (chapter 62-4.242(2)(a) F.A.C.). The effective date of the OFW rule was 3/1/1979 and Card Sound, Biscayne Bay National Park were added to the rule in 12/1/1982 and 5/14/1986 respectively (chapter 62-302.700 F.A.C.). The first NPDES permit for Turkey Point including the CCS was effective on September 23, 1973." (0017-2-13 [Maher, William])

Response: Section 3.5.1.1 of the SEIS has been revised, in part, as a result of this comment, to clarify Florida water quality rules that apply to the CCS.

Comment: Section 3.5.1.4, Page 3-46. The DSEIS states: "Most of the salt in the CCS comes from the groundwater of the Biscayne aquifer which is saltwater. As groundwater from the Biscayne aquifer moves into the CCS, the salt it contains also moves into the CCS. The Biscayne aquifer obtains its salt from Biscayne Bay, and is hydrologically connected to both the Biscayne Bay and the CCS (FPL 2018f, Tetra Tech 2014, FPL 2016a)." The statement is incomplete as it doesn't explain how the saltwater in the Biscayne aquifer becomes hypersaline in the CCS. The salt levels in the CCS are concentrated as a result of limited rainfall and evapotranspiration. This statement should be revised to: "As groundwater from the Biscayne aquifer moves into the CCS, the salt it contains also moves into the CCS and becomes concentrated as a result of evaporation. FPL's addition of fresher groundwater from the Floridan aquifer offsets the freshwater lost to evaporation is the underpinning of the strategy to lower CCS salinities to mirror the salinities in the Bay." Also, the second sentence regarding the hydrologic connection between Biscayne Bay and the CCS is more complex than this sentence conveys and a more detailed discussion of the hydraulic relationship between the CCS and the Bay is previously covered in Section 3.5.3, page 3-31 and 3-32 (refer to Comment Item 13). (0017-2-14 [Maher, William])

Response: Section 3.5.1.4 of the SEIS has been revised, in part, as a result of this comment, to indicate that salt in the CCS is concentrated as a result of evaporation.

Comment: Section 3.5.1.4, Page 3-41. The DSEIS states: "In response to orders from the State of Florida and Miami-Dade County, FPL conducts an extensive water quality monitoring program that includes the CCS, Biscayne Bay, Card Sound, marshland, mangrove areas, and canals adjacent to the CCS. A major objective of this program is to evaluate the effects, if any, of CCS operation on the surrounding environment." This statement is inaccurate because the extensive monitoring conducted by FPL is in response to conditions X and XI of the State of Florida PPSA License PA 03-45E and the 5th Supplemental Agreement with the SFWMD not

the Department of Environmental Protection Consent Order or the Miami-Dade County Consent Agreement. This statement should be revised to: *Pursuant to conditions of the State of Florida PPSA License PA 03-45E, FPL conducts an extensive" (0017-2-15 [Maher, William])

Response: *Section 3.5.1.4 of the SEIS has been revised, in part, as a result of this comment, to indicate that pursuant to conditions of the State of Florida PPSA License PA 03-45E, and in accordance with the FPL Turkey Point Power Plant, Groundwater, Surface Water, and Ecological Monitoring Plan, FPL conducts an extensive water quality monitoring program that includes the CCS, Biscayne Bay, Card Sound, marshland, mangrove areas, and canals adjacent to the CCS.*

Comment: Section 3.5.1.4, Page 3-41. The DSEIS states: "This water quality monitoring program monitors surface water bodies for numerous water quality parameters, including ammonia and other nutrients and salinity." This statement is inaccurate because it under represents the depth of analytical data used to assess surface water quality. FPL analyzes surface water samples for 29 parameters, including physical parameters including salinity, anions, cations, tritium, ammonia and other nutrients. The statement should be revised to: "...surface water bodies for twenty nine water quality parameters including physical parameters such as salinity, temperature and specific conductance, anions, cations, tritium, ammonia and other nutrients." (0017-2-16 [Maher, William])

Response: *The cited statement is accurate in that it mentions numerous water quality parameters monitored by FPL and focuses on the parameters that have been of particular interest to the public and State of Florida regulatory agencies. This comment provides no new information, and the SEIS text was not changed in response to this comment.*

Comment: 3.5.1.4, Page 3-42. The DSEIS states: "Between June 2010 and May 2016, ammonia concentrations within the CCS ranged from below detectable levels to 0.3 mg/L and averaged 0.04 mg/L (FPL 2017c)." Ammonia data values could not be verified in the cited reference. Suggest the sentence be replaced with the following sentence: "Average ammonia levels within the CCS canals are well below Chapter 24-42(4) surface water standards of 0.5 ppm." (Enclosure 2 to FPL letter L-2019-031 dated April 3, 2019 (ADAMS Accession Nos. ML 19095B380 and ML19095B384). (0017-2-17 [Maher, William])

Response: *Section 3.5.1.4 of the SEIS has been revised, in part, as a result of this comment, to correct the reference cited in the DSEIS.*

Comment: Section 3.5.1.4, Page 3-46. The DSEIS states: "The salinities of seawater are around 34-35 practical salinity units (PSU), while the salinity of water in the CCS is presently around 60 PSU, or almost twice the salinity of seawater (EB 2018, FPL 2018f)." This statement is inaccurate because the 60 PSU value does not represent recent conditions. The average annual CCS salinity in 2017-2018 was 51 PSU. This statement should be revised to: "...while the salinity of water in the CCS in 2015-2017 was around 60 PSU, most recent annual average salinity for the CCS was 51 PSU (2017 - 2018)." (0017-2-18 [Maher, William])

Response: *Section 3.5.1.4 of the SEIS has been revised, in part, as a result of this comment, to update the CCS salinity values to those reported most recently in the FPL Turkey Point Plant Remediation/Restoration Report, December 2018.*

Comment: Section 3.5.1.4, Page 3-48. The DSEIS states: "The County recommended that FPL revisit this alternative for further evaluation as a potential long-term solution (MDC 2016a). The current status of this proposal is unclear." This statement is outdated. This statement should be revised to: "At the time of this report, FPL and MDC were evaluating a potential cooperative reclaimed water use project for Turkey Point." (0017-2-19 [Maher, William])

Response: *Section 3.5.1.4 of the SEIS has been revised, in part, as a result of this comment, to clarify the current status of plans to use reclaimed water from Miami-Dade County.*

Comment: Section 3.5.1.4, Page 3-51. The DSEIS states: "In response to the modified consent agreement between FPL and Miami Dade County, FPL submitted a corrective action plan to Miami-Dade County on September 14, 2016." This statement is inaccurate because the wrong plan is identified. This statement should be revised to: "...submitted a Site Assessment Plan to Miami-Dade County on September 14, 2016 (FPL, 2016g)." (0017-3-1 [Maher, William])

Response: *Section 3.5.1.4 of the SEIS has been revised, in part, as a result of this comment, to report the submission of a Site Assessment Plan by FPL to Miami-Dade County.*

Comment: Section 3.5.1.4, Page 3-51. The DSEIS states: "As of July 5, 2018, FPL was in the process of obtaining the final permits for these restoration projects (FPL 2018f)." This statement is inaccurate because it does not reflect the current status of these projects. This statement should be revised to: "The Turtle Point Canal restoration was completed in April 2019 and restoration of the Barge Turning Basin began in May 2019 is scheduled to be completed by September 2019." (0017-3-2 [Maher, William])

Comment: Section 3.5.1.4, Page 3-52. The DSEIS states: "Restoration activities at Turtle Point will backfill one-third of the remnant canal up to a depth of 0.33 ft (0.1 m) below MSL (for future Mangrove Planting)." This statement is inaccurate because it does not reflect the current status of these projects. This statement should be revised to: "Restoration activities at Turtle Point Canal included backfilling one-third of the remnant canal up to a depth of 0.33 ft. (0.1 m) below MSL and the planting of approximately 1,700 mangroves was completed in April 2019." (0017-3-3 [Maher, William])

Response: *Section 3.5.1.4 of the SEIS has been revised, in part, as a result of these comments, to update the status of the Turtle Point Canal and Barge Turning Basin restoration projects.*

Comment: Section 3.5.1.4, Page 3-56. The DSEIS states: "The rate and direction of this water movement depend on the head differences between the CCS and the Biscayne aquifer (FPL 2018f, NRC 2016a)." This statement does not include additional factors that affect rate of water movement. Suggest the statement be expanded to: "...head differences between the CCS and the Biscayne aquifer, hydraulic conductivity of the canal sediments, and fluid density differences between fluids in the CCS and Biscayne aquifer (FPL 2018f, NRC 2016a)." (0017-3-4 [Maher, William])

Response: *Section 3.5.1.4 of the SEIS has been revised, in part, as a result of this comment, to clarify factors affecting movement of water between the CCS and the Biscayne aquifer.*

Comment: Section 4.5.1.1, Page 4-23. The DSEIS states: "Hypersaline groundwater flow from the CCS beneath Biscayne Bay would, however, continue to move eastward and downgradient

along the base of the Biscayne aquifer." This forecast statement is not supported by the actions and regulatory requirements in place today. With the CCS salinity reduced to 34 psu (equaling Biscayne Bay's salinity), and the RWS wells extracting hypersaline water, the source of hypersaline water to drive the continued easterly movement along the base of the aquifer will be gone long before the expiration of the current site license. This statement should be revised to: "Hypersaline groundwater flow from the CCS beneath Biscayne Bay would, however, diminish over time after the CCS salinities are reduced and maintained at levels equal to the Bay (34 PSU) and the hypersaline groundwater beneath and west of the CCS is removed by the RWS extraction wells." (0017-4-7 [Maher, William])

Response: *While freshening of the CCS to 34 PSU may prevent additional hypersaline water infiltrating to the bottom of the Biscayne aquifer and the recovery well system may extract parts of the hypersaline plume beneath the CCS, the NRC staff believes the hypersaline plume will continue to move eastward and downgradient. This comment provides no new information, and the SEIS text was not changed in response to this comment.*

Comment: Section 4.13.7, Page 4-97. The DSEIS states, "During operation, some minor amounts of chemical wastes may result from efforts to maintain appropriate chemical quality of the recirculating cooling water, from the periodic maintenance (i.e., descaling) of the cooling towers, and from periodic removal of settled precipitates from the cooling water basins beneath each cooling tower." This statement is incomplete because it does not consider information from NUREG-2176, Vol. 1 Environmental Impact Statement for Combined Licenses (COLs) for Turkey Point Nuclear Plant Units 6 and 7, Section 3.4.2.3, which discuss the Injection Wells for cooling towers blowdown. Units 3 and 4 would need a method for disposal of liquid radioactive waste, in accordance with Part 20 methods, like Units 6&7 if the CCS is removed from service. Currently, Units 3 and 4 discharge liquid radioactive waste to the CCS, but it is diluted to meet Part 20 requirements. If the plant no longer discharges circulating water to the CCS, it would need to identify an alternative method for discharge of radioactive waste. This scenario was analyzed in detail in the Safety Evaluation and FEIS for the Units 6&7 COL project. This statement should be revised accordingly. (0017-4-17 [Maher, William])

Response: *A discussion of disposal of liquid radioactive waste for the cooling water system alternative is included in Section 4.5.7.2. As stated in Section 4.5.7.2, operation of mechanical-draft cooling towers for condenser cooling would produce cooling tower blowdown that may contain water treatment and conditioning chemical residuals necessary for proper operation of the cooling towers. Additionally, Turkey Point Units 3 and 4 operations would continue to produce various process water effluents, including liquid radwaste effluents. The NRC staff assumed that these effluents would be disposed of by deep well injection into the Boulder Zone, which would be regulated under a Class I underground injection control permit issued by the FDEP (FAC 62-528). This comment provides no new information, and the SEIS text was not changed in response to this comment.*

Comment: I hope that people will find it incredibly alarming as far as I understand it, that this is the only nuclear facility in the world that has a cooling canal system. Is that right? Can anybody else? Is that wrong? That's incredibly alarming. So the fact that we are even considering issuing a permit to continue this, is absolutely ludicrous and I hope that you think long and hard on it. So this is a known fact, that commonly important species are diminished to disappear over time as salinity increases. We also know that nutrients are so high in the plume that it is also changing the near shore environment of Turkey Point which is in a National Park and a National

Marine Sanctuary.
(0001-11-3 [Friedman, Steve])

Comment: So there was a situation where the water in the cooling canals has heated up during periods of intense heat, specifically in the summer. Algae is covering the canals and acting as a thermal blanket. Those canals cool the reactors. If they're not cooling the reactors then the reactors would have to be shut down. So this is why Laura Reynolds referred to the use of massive amounts of Floridan water to freshen or cool and desalinize these cooling canals. To date, because FPL speaks regularly at our association in Ocean Reef -- today, Mr. Sole admitted that he still doesn't have those canals down to the proper salinity, which is supposed to be the salinity of the Bay. And they're not there yet and they've been as high as three times saltier than sea water. And that's why everything died. Everything in the cooling canal system died. (0001-14-3 [Rippingille, Bonnie])

Response: *Operations of the CCS are described in Section 3.1.3.2 of the SEIS and the interactions between the CCS and adjacent surface and ground waters are described in Section 3.5. Terrestrial and aquatic resources, including special status species and their habitats are described in Sections 3.6 through 3.8. The impacts from continued CCS operations on water resources, terrestrial resources, aquatic resources, and special status species and related habitats are described in Chapter 4 of the SEIS, Sections 4.5.1, 4.6.1, 4.7.1, and 4.8.1. These comments provide no new information, and the SEIS text was not changed in response to these comments.*

Comment: Anyway, so they're using this water that really was designed for the CERP, which is the Comprehensive Everglades Restoration Plan project, such as the Biscayne Bay Coastal Wetlands, which are very close to the plant. And they're using that water and that's in direct conflict with the CERP. FPL must be required to use readily available treated municipal waste water for the nuclear plant. Well, they had a plan for that and they entered into -- in 2018 FPL visited us and told us, well, we're working on this waste water facility that we're going to do with Miami-Dade County. Well, guess what, folks. They don't have an agreement yet as to how the water needs to be cleaned and to what level it needs to be cleaned. Miami-Dade is saying it has to be to non-degradation standards, and that is because the water is going into the Bay and outstanding Federal waters. That's why it has to be clean, almost to drinking water standards and that costs a lot of money and somebody else is going to address that after me. (0001-14-5 [Rippingille, Bonnie])

Response: *The SEIS recognizes that FPL and Miami-Dade County are evaluating a potential cooperative reclaimed wastewater use project to provide freshening water to the CCS. The discussion of alternative water sources to reduce CCS salinities is described in Section 3.5.1.4 of this SEIS. This comment provides no new information, and the SEIS text was not changed in response to this comment.*

Comment: I've looked at lot of data, I've reviewed the EIS. I've looked at a lot of data that's submitted since the Scoping Meeting. And I would mention in looking at the EIS, I would encourage the committee -- there's a lot of data that was generated in late 2016, 2017 and 2018 that I don't find referenced in the EIS. I see a lot of references to 2014, '15 and '16. And there are a lot of organizations that really have been energized in the last three years and done a lot a data collecting, a lot of expert testimony brought to bear that I think clearly shows the environmental impact of this antiquated component of the nuclear power plant open canals. I think the data, actually in my opinion, clearly shows that FP&L has failed to, over the decades,

to operate and maintain this shallow open cooling canal system properly, either due to gross negligence, in my opinion, or incompetence and in compliance, therefore it isn't. It's violated -- had violations to its NPDES permit that expired about five years ago. And it's been administratively continued. I would, I guess for those who say it wouldn't be gross negligence or incompetence, it's not the case with FP&L, then the only other plausible reason that I can come up with is that the CCS is a failed design that cannot be operated and maintained to meet its NPDES permits. It was originally designed to include the sea water to sea water exchange. It was never a closed loop or closed system. I think there is a preponderance of data that indicates that it, you know, twice a day, I mean you get a high and low tide. There is a sea water exchange between the canals and the Bay. And so it clearly, whatever is in the canals twice a day exits into the Bay and vice versa. So it clearly, you know, the water quality in canals is impacting the Bay I'm going let others and the evidence that's been put forth support that. (0001-16-2 [Schoedinger, Steven])

Response: *Section 3.5 has been updated in part in response to this comment by incorporating 2018 groundwater and surface water data. Operations of the CCS are described in Section 3.1.3.2 of the SEIS and the interactions between the CCS and adjacent surface and ground waters are described in Section 3.5. In preparing the SEIS, the NRC staff used data available from FPL in its annual monitoring reports and remediation/restoration reports, including those from years 2016, 2017, and 2018. The SEIS also used data and information collected and reported by State of Florida regulatory agencies including FDEP, MDC, and SFWMD; Federal agencies including FWS, EPA, NMFS, NOAA, NPS, USACE, USCG, USGCRP, and USGS; and scientific studies published in open literature.*

Comment: On the other side, it's leaking into Biscayne Bay like it always did. And so now we're on plan number 6 and it's more pumping, it's another experimental scheme. You can know it's an experiment because the remedy if it fails is another plan. Plan number 7 is what's required if it fails. It's an acknowledgment that this system does not and cannot work. And so now we have the craziest solution in the world now, which is that now we're going to put treated sewage in it, adding treated sewage to aquifer to solve this problem. This is absolutely crazy. It had a design flaw from the very beginning. Nothing has ever been done to make it fixed, to fix it. You've got now a sewage scheme to make it even worse. (0001-17-3 [Guest, David])

Response: *Operations of the CCS are described in Section 3.1.3.2 of the SEIS and the interactions between the CCS and adjacent surface and ground waters are described in Section 3.5. The impacts from continued CCS operations on water resources are described in Section 4.5.1. FPL evaluated the potential use of reclaimed wastewater for freshening of the CCS (Section 3.5.1.4 under "Study of Alternatives to Reduce CCS Salinities"). As reported in that section, FPL decided not to use reclaimed waste water but to use water from the Floridan aquifer. This comment provides no new information, and the SEIS text was not changed in response to this comment.*

Comment: Samples of bay water at various depths and sites around the power plant show elevated levels of salt, ammonia, phosphorous, and tritium. (0016-1 [Cochrane, Theodore])

Comment: I have video showcasing the ultra green, high turbidity cooling canals. The video was taken after the FPL fresh water recharge events within the cooling canals. The poor condition of the water quality showcases that the water recharge methodology is not a permanent solution. Furthermore, the recharging simply pushes down the hyper saline plume

via ionization transfer and pressure into our water supply further contaminating our ground water and advancing the radioactive hypersaline pollution plume. (0020-8 [Gomez, Albert])

Response: *Section 3.5.1.4 of the SEIS describes the water quality in the CCS. Section 3.5.2.2 of the SEIS describes groundwater quality. Impacts to surface water and groundwater quality associated with continued operations of Turkey Point Units 3 and 4 under the proposed action are described in Sections 4.5.1.1 and 4.5.1.2 of the SEIS. This comment provides no new information, and the SEIS text was not changed in response to these comments.*

Comment: [With more time, the NRC and associated regulatory agencies can review new information on...] Negatively cascading water quality within the cooling canals
....Radioactive high salinity pollution plumes continuing to advance and seep from cooling canals into our water supply in violation of several federal, state and county regulations with no validated clean up methodology to recapture the increasing polluted water
...Ongoing and concurrent consent decrees between the EPA, FL DEP, DERM and Miami-Dade county within Miami-Dade County mandating the county improve water quality, which is below standard and behind the stated schedule for clean up and nutrient reduction. Turkey Point is negatively impacting water quality and nutrient load through the ongoing operation of Turkey Point Reactor 3 & 4 and associated polluting cooling canals, and in so will further delay adherence to the consent decree and associated guidelines (0020-5 [Gomez, Albert])

Response: *Impacts to surface water and groundwater quality associated with continued operations of Turkey Point under the proposed action are described in Sections 4.5.1.1 and 4.5.1.2 of the SEIS. The NRC staff's review of new information is described, in part, in Section 4.14 of the SEIS. Various agreements and orders involving State and County regulatory agencies and FPL are described in Chapters 3 and 4. This comment provides no new information, and the SEIS text was not changed in response to this comment.*

Comment: Surface Water Resources. The DSEIS evaluated the significance of new information relating to impacts from the CCS on adjacent surface water bodies and provided that, "Water that likely originated from the CCS has sporadically been detected in two canals adjacent to the CCS", but concluded that the water quality in these two canals have not been degraded sufficiently to prevent these canals from achieving their intended purpose (i.e., transporting fresh water, draining the land and flood control) (page 4-23). However, the two canals being discussed were not specifically identified. The DSEIS should identify the canals that were evaluated. (0022-2 [Hefty, Lee N.]

Response: *Section 4.5.1.1 of the SEIS has been revised, in part, as a result of this comment, to identify the two canals as the Card Sound remnant canal and the S-20 canal that are shown in Figure 3-4.*

Comment: DERM and WASD are requiring the cleaning of the reclaimed water to non degradation standards to avoid further impairment of the bay. This water quality standard and the 40 mgd a day that evaporates yearly from the canals make this an extremely costly process. FDEP has recognized southern Biscayne Bay is already impaired on their official list of impaired water bodies, which is why DERM is requiring the non-degradation standard. Because of the cost of cleaning the wastewater to nondegradation standards, there has been no agreement to date reached between FPL and WASD for the RO reclaimed water plant. We believe that approval of the proposed permit and the application for license renewal would be premature

until the RO reclaimed water plant issues are resolved between Miami Dade County/DERM and FPL. (0024-5 [List, Gary])

Comment: FPL is also seeking a new NPDES permit from the Florida Department of Environmental Protection which will allow FPL to continue discharging polluted hyper saline water from the (CCS) into the Biscayne Aquifer, our primary source of drinking water, and into the bay through the groundwater and porous limestone under the aquifer. FPL is not allowed to discharge into the navigable waters of the United States either directly or indirectly under its current FDEP pollution permit and FPL has been discharging for 35 years in violation of this permit. We understand that they will be required to have this permit as a condition of granting the SLRA and have asked that it be deferred or not issued until the extent of the damage caused by the operation of the CCS to the bay is assessed. (0024-6 [List, Gary])

Comment: I implore the NRC to extend their date for final EIS a few months if necessary to consider the content of the final issued new NPDES permit, if one is issued, for FPL TPP. I don't know whether you realize, but that permit has not even been a live permit for practically ten years because of all the problems that FDEP recognized with FPL's compliance with the terms of their existing permit. So that's a very important issue. And the records, and I'm happy to supply them to your group, of their non-compliance and what was done about it in administrative hearings and other proceedings, resulted finally in DERM and FTP citing them for violations. And they're still in violation and they're going to continue in violation. And the NPDES permit conveniently appears to make those violations not a violation with respect to the Bay and the coverage under the NPDES permit. And I suggest to you that they know it's not going to work, and that's why they're going for this new permit. And this new permit was submitted during the final months of the Scott administration. And we didn't find out about it -- the environmental groups didn't find out about it until 15 days before the meeting, the public meeting on it. And there was an extension granted, and that meeting is going to take place next week, and we hope that everybody will come back so that we can talk about this again, because they are not in compliance with their permit. They know it, DERM knows it, FDEP knows it. And why would you give an NRC permit for another 20 years to FPL when they're in violation of their permit? And when they're in violation of the DERM and FDEP consent order and consent decree, why would you reward them like this? Because all you're going to do is incentivize them to continue to delay, delay, delay in doing something about those cooling canals. (0002-6-5 [Rippingille, Bonnie])

Response: *The commenters propose that the NRC delay its subsequent license renewal decision to await the FDEP's issuance of a renewed National Pollutant Discharge Elimination System (NPDES) permit for Turkey Point Units 3 and 4. The NRC's consideration of the Turkey Point subsequent license renewal application considers issues that are subject to NRC regulatory authority; environmental issues associated with issuance of a renewed NPDES permit are not within the NRC's regulatory authority to resolve. While the NRC coordinates with other regulatory authorities, the NRC cannot address issues that are not under its jurisdiction. The NRC does not have the authority to ensure compliance with other regulatory authorities' requirements under the Clean Water Act, and cannot make compliance with permits, agreements, and orders issued by other agencies a condition of the NRC license. Issuance of a renewed license, however, does not foreclose or restrict the ability of other regulatory authorities to take such actions as they deem necessary to ensure compliance with orders, consent agreements, or other regulatory requirements under their Clean Water Act or other lawful statutory jurisdiction.*

These comments provide no new information, and no changes have been made to this SEIS as a result.

Comment: The DSEIS does not evaluate potential cumulative impacts for surface water, based on the conclusion that "Since FPL is prohibited from discharging effluent into surface waters of the State, and the FDEP and DERM has imposed requirements for mitigation of the hypersaline plume originating from the CCS, subsequent license renewal is not expected to have a cumulative impact on surface water quality in combination with rising sea levels." The premise of this conclusion is flawed since the groundwater recovery well system is not designed for nor was it intended to address surface water impacts resulting from the CCS operations. (0022-5 [Hefty, Lee N.])

Response: *The Miami-Dade County DERM expresses concern that no cumulative impacts analysis is contained in the SEIS for surface water. As defined in Section 4.16 of the SEIS, cumulative impacts may result when the environmental effects associated with the proposed action (subsequent license renewal) are added to the environmental effects from other past, present, and reasonably foreseeable future actions. The NRC staff did not perform a cumulative impacts analysis specifically for surface water because the staff determined that the continued operation of Turkey Point Units 3 and 4 would have no incremental impacts on surface water. In this regard, Turkey Point Units 3 and 4 do not directly consume or discharge effluents to surface water bodies. The staff recognized, in Sections 3.5.1.4 and 4.5.1.1 of the SEIS, that CCS operations have resulted in minor impacts via the groundwater pathway to surface water quality in surface water bodies adjacent to the CCS. The staff determined, however, that impacts to surface water bodies via the groundwater pathway during the subsequent license renewal term would be SMALL, based on the staff's analysis presented in Section 4.5.1.1 (see "New Issue, Water Quality Impacts on Adjacent Water Bodies (Plants with Cooling Ponds in Salt Marshes").*

An evaluation of impacts over the period of subsequent license renewal from CCS flooding is discussed in response to the comment titled "Failure to Analyze Impacts of Sea Level Rise and Storm Surge" (Comment numbers 0023-14 and 0023-15). Except in the event of a hurricane, flooding and flood damage to the CCS is not likely to occur. The NRC staff's evaluation concludes that over the period of subsequent license renewal, overtopping of the CCS or a release of CCS waters into adjacent surface waters due to flooding could occur infrequently. However, if it does occur, it is likely to cause only SMALL changes to the water quality in Biscayne Bay and Card Sound.

Section 4.16 of the SEIS was revised to clarify the staff's basis for not preparing a cumulative impacts analysis for surface water resources.

Comment: And we were taken out, and I was present, and we did sample four separate what we call cave or upwelling exits, and we took about two dozen samples. And the photos show that the phosphorous was 1,000 percent greater than average geometric mean. And the nitrogen was 300 percent greater than average geometric mean. And the chlorophyll was 100 percent greater than average geometric mean. We were less than a quarter mile from the FPL plant and the cooling canals. And the well that we were close to was TPGW-14-D, less than one quarter mile east of the southeast corner of the CCS, the cooling canal system. (0002-6-4 [Rippingille, Bonnie])

Comment: I have the charts that show what we found there out in that Bay, and I'm going to file them with you. I believe there's also video footage of the dive. I just collected the samples

that came in and charted them on the chart. I wasn't diving. But we have video footage of it. So I implore you to look at their non-compliance over the last 30, 35 years and ask you to delay granting this license until they show that they can comply with the rules, the most important thing is your duty to comply with the rules. Because you're in an area where -- outstanding federal water, the Everglades, from which we get our water supply, on each side of this plant. (0002-6-6 [Rippingille, Bonnie])

Response: *The data referred to in these comments, the methodology used to collect the data, and a description of any associated quality control were not provided to the NRC staff. Accordingly, the data referred to by the commenter are not considered in this SEIS. Rather, the NRC staff relied on data in FPL's submittals and data available at the Turkey Point Combined Monitoring Site (<https://www.ptn-combined-monitoring.com/Home>), which is the repository for monitoring data required to be collected and reported by cognizant regulatory authorities under various agreements and orders. Since the publication of the draft SEIS, the NRC staff also reviewed the monitoring data included in FPL's 2018 Annual Monitoring Report and in additional reports. The additional review did not result in alteration of the staff's conclusions in the SEIS. However, various sections of the SEIS, particularly Sections 3.5.1 and 3.5.2, have been updated as necessary to reflect the staff's review of the latest available monitoring data for surface water, groundwater, and ecology resources. This newly reviewed information is cited throughout the SEIS and is listed in Chapter 6 of the SEIS.*

Comment: Regardless, DERM finds that the DSEIS does not appear to have evaluated water quality impacts to the L-31E canal. Surface water data from that portion of the L-31E which runs parallel to and west of the CCS and the interceptor ditch indicate tritium concentrations (TPSWC-1,2,3 and TPL31E-INTS) that are inconsistent with and higher than tritium concentration in Biscayne Bay (TPBBSW-3, 4 and 5), and in the northern (TPL31E-INTN) reaches of the L-31E and station TPSWC-6 in the Card Sound Road Canal suggest surface water impacts that are persistent rather than sporadic as described by the NRC. (0022-3 [Hefty, Lee N.]

Comment: Additionally, available data indicates that salinity levels in the L-31E (see attached) [view attached figure in pdf, available from NRC ADAMS, accession no. ML19147A229], which has historically been a fresh water canal, are increasing. Given the importance of this canal to the fresh water wetland resources in the Model Lands west of Turkey Point and the coastal wetlands to the south, degradation of the water quality in this canal will result in impaired functionality which becomes more critical with the sea level rise projections. DERM recommends the Draft DSEIS be amended to include further evaluation of the impacts to the L-31E canal. (0022-4 [Hefty, Lee N.]

Response: *In these comments, the Miami-Dade County DERM expresses concern that the SEIS does not adequately characterize and assess water quality impacts to the L-31E canal (primarily tritium and salinity levels), which could then affect nearby wetlands and surface waters.*

In the vicinity of the Turkey Point site, the L-31E canal generally is located to the west of the CCS and runs northeast to southwest. West of the Turkey Point site, the L-31 canal is a dead-end canal and is generally filled with stagnant water. The northern end of the canal dead ends against SW 344th Street, while the southern end of the canal dead ends against Card Sound Road. A section of the L-31E canal, located west of approximately the (north-south) midpoint of the CCS, contains a partial plug of sediment that restricts any southward flow of

water from the northern-most section of the canal. The east side of the L-31E canal contains a levee. This levee is designed to provide flood protection to properties further west (see Section 3.5.1.1, "Surface Water Hydrology, Potential for Flooding at the Turkey Point Site").

Historically, in the L-31E canal, the water quality ranges from fresh to brackish. Increases in specific conductance (an indirect measure of salinity) have historically been observed during the latter part of the dry season. Salinity concentrations near the surface of waters in the L-31E canal are consistently lower than concentrations from the bottom of the canal. This is expected as more saline water is denser than less saline water. Salinity concentrations in the canal drop in response to heavy rain events or when the water is released from the L-31E canal (FPL 2018o).

During wet periods, the levee on the east side of the canal prevents surface water in the low-lying areas west of the levee from moving eastward; at these time, excess water is discharged from the L-31E Canal into Card Sound via the S-20 Canal or into wetlands southeast of the weirs. As this discharge takes place during wet periods, salinities and nutrients should be greatly diluted in water discharged from the L-31 canal, by surface runoff flowing southward toward the weirs. Section 3.5.1.4 of the SEIS has been updated to summarize new water quality information obtained from FPL (2018o).

At Turkey Point, the highest tritium concentrations have been detected closest to the CCS and have been found to diminish with distance from the CCS. When compared to the L-31E canal, the tritium concentrations in the relatively large water bodies of Biscayne Bay and Card Sound are quite low. As explained in Section 3.5.1.4 of the SEIS, there are two possible pathways for tritium to leave the CCS and move to another surface water body: (1) through the groundwater pathway or (2) through air via steam or water vapor). The tritium concentrations in samples collected from the L-31E canal appear to be heavily influenced by the atmospheric pathway. For example, over the June 1, 2017 through May 31, 2018 monitoring period, tritium concentrations in evaporation pans (i.e., from precipitation) located near the L-31E canal and monitor well TPGW-31 were often more than 100 to 200 pCi/L. Tritium values in samples from L-31E canal water contained similar concentrations (FPL 2018o).

During the annual monitoring period from June 1, 2017 through May 31, 2018, water in the L-31E canal had significant increases in salinity. The salinity increases occurred during and after an extended dry period and were observed in most of the marsh sites in response to dry conditions during the drought and in response to the storm surge during Hurricane Irma. Increases in soil porewater salinities were also detected at all ecological transects, including one located approximately 4 mi (6.5 km) southwest of the CCS (FPL 2018o, NRC staff review of data available in FPL's Electronic Data Management System (EDMS; <https://www.ptn-combined-monitoring.com>)).

The increases in salinity levels are not believed to have been caused by a failure of the interceptor ditch. This is because (a) surface water levels have consistently indicated that groundwater flow was eastward from the L-31E canals towards the interceptor ditch and towards the CCS; (b) the L-31E canal water tritium values are within the ranges observed from atmospheric deposition; (c) L-31E canal water tritium values did not respond commensurately and consistently with changes in the canal water's salinity; and (d) tritium concentrations at all terrestrial soil porewater sites were within historical ranges (FPL 2018o). Rather, the increases in salinity in the marsh lands, soils, and the L-31E canal are believed to have been caused by the evaporation of water from the marsh lands, soils, and the stagnant water in the L-31E canal

during dry periods. This was followed in some areas by increased salinity caused by storm surges (FPL 2018o).

The SEIS has been updated to summarize the new information obtained from FPL (2018o) and from the NRC staff's review of data available in FPL's Electronic Data Management System (EDMS; <https://www.ptn-combined-monitoring.com>).

Comment: Now the new scheme is even more exotic than the previous ones. Now what we're going to take is treated sewage water and put it into these aquifer canals. There is no honest debate about where there's a direct connect between these aquifer canals and Biscayne Bay. It's established in nine different ways. Nobody's seriously contested it. If you read your EIS, FPL minimizes it, certainly minimizes it, but doesn't deny it. No honest person could even think about denying that. And so what you're talking about doing is putting sewage water into the canals, which goes straight into Biscayne Bay. And what's happening in Florida? There's one big issue that's happening in the Florida environment, and that is the algae crisis. There is an algae crisis on East and West Coast. There's one in the great St. John's River, the biggest river in Florida, that's developing, as we speak. There's emergency measures by the Corps of Engineers, by Governor DeSantis, by the legislatures.

There's hundreds of millions of dollars of fixes to try to stop the algae crisis as it is now. But then you want to talk about adding sewage water into Biscayne Bay, which is teetering on the edge of collapsing like the rest of them have. It's crazy. It's absolutely crazy to be putting sewage water into a place where it's going to go straight into the Bay and risk a broadening toxic algae crisis. It just makes no sense at all. And you guys don't have -- as an alternative, you don't have the straight sea water exchange into Biscayne Bay, like it was long ago. And it's a good reason it's not there. It's because the carnage that it does to the Bay if you do that. Well, that's the standard that you should be operating on. Carnage to the Bay is not a viable alternative. And the sewage plant is just that, it's not a viable alternative, it should be taken off the table. (0002-4-2 [Guest, David])

Comment: So not only do you have the salt loading that David Guest talked about, which is in direct conflict with the goals of Biscayne Bay coastal wetlands. The goal stated in the Yellow Book for that project is to bring the near shore environment back to mesohaline conditions. Which essentially means, bring it back to an estuary because it's been getting too salty. And the operations of the plant. Basically all it does is evaporate fresh water and leave behind salt and any contaminants that are in that water. And it does that very well, just like a radiator. And we know that whatever water is being pulled in through the water budget, that gets concentrated over time. That could be a little bit of fertilizer from a farm, it could be the salt from Biscayne Bay, it could be something from rainfall. And it could also be whatever input you have. So I think it's a good point that Steve Schoedinger made, that if you put in recycled sewage water, you're adding to the problem. Not only EPOCs, but also additional nutrients. (0002-5-3 [Reynolds, Laura])

Response: Sections 3.5.1.4 and 4.5.1 of the SEIS consider the impacts of CCS operation, including the deposition of phosphorus, other nutrients, and salinity on wetlands and surface waters. The NRC staff notes, however, as explained in the SEIS and defined in Section 2.1, that the NRC's proposed action (subsequent license renewal) includes the continued operation of Turkey Point Units 3 and 4 for an additional 20 years. This involves operating Turkey Point Units 3 and 4 and supporting facilities in their current configuration, including the continued use of the cooling canal system (CCS). As described in Section 3.5.1.4 of the SEIS (see "Salinity Management Plan") the use of reclaimed sanitary wastewater in the CCS is not part of the

proposed action. As reported in Section 3.5.1.4 (under “Study of Alternatives to Reduce CCS Salinities”), FPL did evaluate the potential use of reclaimed wastewater for freshening of the CCS. However, FPL decided not to use reclaimed waste water, but to use water from the Floridan aquifer.

Under the proposed action, the staff assumes that water for CCS freshening would continue to be withdrawn from the Upper Floridan aquifer. However, in the SEIS, the NRC staff evaluates two alternatives that would use reclaimed sanitary wastewater. These alternatives are the New Nuclear Alternative and the Cooling Water System Alternative as described in Sections 2.2.2.1 and 2.2.3 of this SEIS and evaluated in Chapter 4 of the SEIS. In both of these alternatives, reclaimed wastewater would be used as makeup water for cooling towers. The blowdown (discharge) from the cooling towers would be disposed of by deep well injection more than 3,000-ft (914-m) deep into the Boulder Zone beneath the Turkey Point site. The comments provide no new information, and no changes were made to the SEIS in response to these comments.

Comment: As the salinity of the canals has increased so has the temperature of the water in them. According to an article in the Miami Herald from 2016 overheating in the canals has caused FP&L to shut down reactors at least twice in the past few years. (0032-5 [Bloom, Mary])

Response: Overheating in the canals has not caused FP&L to shut down the Turkey Point Units 3 and 4 reactors. However as described in Section 3.5.1.4 (under “Temperatures within the Cooling Canal System”), prior to August 2014, the NRC had set the ultimate heat sink limit at 100 °F (37.8 °C). In early July 2014, the water temperature in the cooling canals began to approach the limit of 100 °F (37.8 °C); FPL then requested an increase in the temperature limit. In response, the NRC staff performed a safety and environmental analysis, and then established the current heat sink temperature limit of 104 °F (40 °C) (NRC 2014b). This comment provides no new information and no changes were made to the SEIS as a result.

Comment: Nuclear power can be good in not polluting the air, but harmful to the natural world through pollution due to wastewater. It is important to stop this from happening. (0048-1 [Meyer, Roger])

Comment: I grew up sailing on Biscayne Bay and even in the 60's you could walk across the bay at low tide if you knew where to go. My sister-in-law's father worked for FP & L and was concerned then about the water temperature increase. This is not anew problem but one that has new urgency with the rising sea levels. Have we learned nothing in 50 years? (0050-1 [Chesnut, Joanna])

Comment: This area MUST be secured and the water treated and made safe. This can and DOES affect the Wildlife.....People and those in the surrounding areas. (0106-1 [Dickinson, Vicki])

Comment: We cannot continue to destroy our environment especially our waters and expect to survive! (0129-1 [Hostler, Joyce])

Response: The commenters appear to express general concerns about water quality including nuclear reactor effluents and operation of the Turkey Point CCS. The facility's effluents are controlled by NRC requirements (see Section 3.1.4.1, “Radioactive Liquid Waste Management”), the technical specifications, and the facility's NPDES permit. Operations of the CCS are subject to a State-issued NPDES permit (currently in the renewal process) that

contains specific requirements for impoundment design, construction, operation, maintenance, and reporting. As stated in the Notice of Draft Permit, the FDEP, based on FPL's application and supplemental information, has determined that FPL has provided reasonable assurance that the wastewater treatment and effluent disposal facility (the CCS) complies with the applicable provisions of Florida Statutes and Florida Administrative Code and that the proposed project (the continued CCS operations) would not adversely impact water quality as long as all of the conditions in the permit are complied with.

These comments provide no new information and no changes were made to the SEIS as a result.

Comment:

However, these measures do little to mitigate the discharge of water into Biscayne Bay. Monitoring results indicate that adding water to lower salinity has had the effect of increasing discharge toward Biscayne Bay. Discharge to the bay occurs intermittently in response to changes in plant operations, heavy rainfall, and fluctuations in bay water levels, the last two being also affected by climate change and accelerated sea level rise.

[View pdf to see attachment w/color figures entitled "Future Impacts on Biscayne Bay of Extended Operation of Turkey Point Cooling Canals" by Laura Reynolds, James Fourqurean, and William Nuttle, available from NRC ADAMS, Accession No. ML19151A729]

(0071-2 [Reynolds, Laura])

Response: *The operation of CCS and its connection to and effect on surface and groundwater resources are described in Sections 3.1.3, "Cooling and Auxiliary Water Systems," 3.5.1, "Surface Water," and 3.5.2, "Groundwater Resources." A discussion has been added to Section 3.7.4 of this SEIS regarding seagrass leaf nutrient monitoring in Biscayne Bay and Card Sound. This monitoring is conducted by FPL contractors to evaluate the effects, if any, of CCS operation on the surrounding environment.*

Comment: Executive Summary: In Table ES-I (page xviii), the NRC summarizes site-specific environmental impact characterizations related to the Turkey Point license renewal. The "Groundwater Resources" and "Aquatic Resources" categories include reference to volume withdrawal, radionuclide releases, organism entrainment, and thermal impacts, but omits "Water Resources" category, which addresses the hypersalinity plume and nutrient impacts that result from the CCS discharges. As previously discussed, the EPA is concerned that these impacts are not adequately discussed and would be better categorized as 'Moderate to Large' impacts for water resources. The EPA is also concerned that the omission of the most important environmental impact of the license renewal (especially in the Executive Summary) is problematic and does not adequately describe environmental impacts to readers seeking an overview of the SD EIS.

Recommendation: The EPA recommends the NRC provide an entry in Table ES-I in the FSEIS and briefly describes the water resource impacts from the CCS. (0031-16 [Militscher, Christopher])

Response: *The category, "Water Resources," has not been omitted from Table ES-1 in the Executive Summary of the SEIS. Rather, the NRC separates water resources-related NEPA issues into the categories of "surface water" or "groundwater." The NRC's Category 1 (generic)*

issues for the analysis of environmental impacts associated with license renewal of nuclear power plants reflect the generic impacts codified in the NRC's regulations in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B. Table ES-1 in this SEIS only summarizes the NRC staff's impacts determinations for applicable Category 2 (site-specific) issues for the proposed action (subsequent license renewal) for Turkey Point Units 3 and 4, in accordance with 10 CFR 51.53(c)(3), 51.71, and 51.95(c). Table ES-1 is similar to, but not as detailed as, Table 4-2 in Section 4.1 of the "Environmental Consequences and Mitigating Actions" chapter of the SEIS. Impact levels (SMALL, MODERATE, and LARGE) for each resource area are established in accordance with the definitions in Section 1.4 of the SEIS, consistent with the NRC's definition of those levels in the GEIS for license renewal.

Separately, in Table 4-1 of Section 4.1, the NRC lists the Category 1 (generic) NEPA issues that the NRC staff found to be applicable to Turkey Point. However, Category 1 issues are not included in the Executive Summary, and there are no Category 2 surface water resources issues applicable to Turkey Point Units 3 and 4. Regardless, the tables are intended to reflect the staff's final impact determination for each resource-specific issue, rather than to provide a synopsis of the myriad aspects of each resource that the staff considered as part of its impacts analysis. The NRC staff's detailed impacts analyses for the listed Category 2 issues are presented in Sections 4.2 through 4.16 of the SEIS, as applicable. Similarly, a synopsis of the NRC staff's generic analyses for Category 1 issues, and a description of the consideration of new and potentially significant information related to those issues, are also presented in Chapter 4.

This comment provides no new information, and no changes have been made to this SEIS as a result.

Comment: National Pollution Discharge Elimination System (NPDES): On page 3-1 (line 41) of the SDEIS states, "This network of canals forms a closed, recirculating source of water ... "This discussion should clarify that cooling canal system is a closed-cycle cooling system -but not a closed hydrologic system. This is because the current NPDES permit allows for seepages from the canals to groundwater. Surface water sampling data from Biscayne Bay detected the presence of tritium, which indicates that the canals may be hydraulically connected to surface waters. Additionally, data indicate there is a westward migration of the hypersaline groundwater plume from the canal. The SD EIS does not address the structural integrity of the CCS to retain releases of nutrient-rich wastewater in the canal to waters of the United States nor does it discuss the impact of these releases on surface water quality and aquatic life in Biscayne Bay. Recommendations: The EPA recommends that a water balance calculation for the site that shows all the potential sources of water supplying the site, and discharges and other releases from the site under normal operating conditions be included in the FSEIS. This balance should include seepages from the canal system and changes in evaporative losses. The EPA also recommends the NRC address the structural integrity of the CCS to retain nutrient-rich wastewater and associated impacts to surface water quality and aquatic life in Biscayne Bay. (0031-11 [Militscher, Christopher])

Response: A 1971 consent decree by the Federal District Court for the Southern District of Florida required FPL to discharge all cooling water from Turkey Point facilities into a closed-cycle cooling canal system, as referenced in Section 3.1.3.2 of the SEIS. Section 3.1.3.2 also notes that the CCS does not have a direct surface water connection to any outside surface water body. Further, Sections 3.1.3.2, 3.5.1.3, and 3.5.1.4 state that water is exchanged between the CCS and the Biscayne aquifer. Section 3.5.1.3 of this SEIS, which has been revised in this final SEIS, contains a description of the current and the draft NPDES permit

issued by the State of Florida, including a description of the permit's requirements related to CCS impoundment design, construction, operation, and maintenance. A discussion of FPL's aging management program for the CCS has also been added to Section 3.5.1.3 of this final SEIS.

Section 3.1.3.2, "Cooling Canal System Operation," describes the components of the water budget. In light of this comment, Section 3.1.3.2 has been updated to include a typical water budget schematic for the CCS, which shows components of the CCS water budget based on modeling predictions during the June 2015 through May 2017 period.

Comment: 3.5.1.4, (pg 3-48). States: "The study considered technical, environmental, economic, and social criteria. Relative to the ranking criteria, it ranked Alternative Five as the best overall and the most balanced alternative. It also identified that Alternatives One and Seven should be maintained as short-term backup water options to be used when appropriate and as needed during extreme conditions. It further determined that Alternatives Two, Four, Six, and Eight did not provide a significant advantage and should not be evaluated further unless conditions change."

Stating that direct treatment of CCS water to remove salinity (Option 6) "did not provide significant advantage and should not be evaluated further" seems to negate the environmental impact of contamination migration in the groundwater without providing supportive data or information. The underlining problem is salt concentration in the CCS. The language above states that economics was considered in these characterizations. However, the SDEIS does not define what is considered too expensive or detail any significant advantage. Also, if cost is the major factor in characterizing an option, then this should be stated with supporting estimates and data. (0031-14 [Militscher, Christopher])

Response: *The commenter is concerned that Section 3.5.1.4 of the SEIS does not define or discuss the factors considered in determining viable alternatives to offset CCS water deficits. The discussion quoted and provided in Section 3.5.1.4 summarizes FPL's evaluation of alternative sources of water conducted to reduce CCS salinities in response to the 2017 Consent Agreement between Miami-Dade County and FPL.*

The purpose of this discussion in the SEIS is to provide a summary of an alternative study that was developed by FPL and reviewed by Miami-Dade County. The study was reviewed by Miami-Dade County approximately 2 years prior to the NRC's receipt of the Turkey Point subsequent license renewal application. The NRC did not have a role in evaluating or approving that study, nor does the NRC have the regulatory authority to approve it. As discussed in the SEIS, Miami-Dade County reviewed the evaluation and made a recommendation as to which alternative could provide a long-term, sustainable source of water to offset CCS water deficits. The process and factors that were considered by Miami-Dade County in providing a recommendation on the alternative to offset CCS water deficits are reflected in its report (MDC 2016a). The comments provide no new information, and no change to the SEIS was made in response to this comment.

Comment: 3.1.3.2, (pg 3-11, 12). States: "Sediments can build up in the channels of the CCS. These sediments can obstruct the lateral flow of water through the CCS and can also lower the rate of water movement into the CCS from the Biscayne aquifer. Therefore, CCS maintenance activities include the removal of accumulated sediments as required to maintain adequate water flow in the CCS (FPL 2018j).e"

Accumulated sediments do obstruct the rate of lateral flow across the CCS boundary but would also obstruct vertical flow if not removed. In actuality, CCS isolation is being sacrificed for the sake of maintaining volumetric capacity. Removal of low permeability sediments to maintain depth in the canals can be a 'net negative' from an environmental perspective. (0031-13 [Militscher, Christopher])

Response: *As stated in Section 3.1.3.2, "Cooling Canal System Operation," of the SEIS, sediment build-up in the CCS canals can obstruct the lateral flow of water through the CCS and can also lower the rate of water movement into the CCS from the Biscayne aquifer. As described in Section 3.5.1.4, "Temperatures within the Cooling Canal System" and "Thermal Efficiency Plan for the Cooling Canal System," maintaining adequate water flow through the CCS is essential for safe and efficient operation of the CCS. FPL is required to monitor surface water, groundwater, and porewater quality in and around the CCS and to report them to State regulatory agencies so that they can take timely actions under their respective jurisdictions. This comment provides no new information and no changes were made to the SEIS as a result.*

Comment: Surface Water Resources - The information presented is incomplete and inaccurate. The CCS connection to surface water including the surrounding wetlands and Biscayne Bay is not recognized in the document. The document incorrectly states in multiple locations that there is no connection of the CCS to surface waters, which has been described in the previous comment. The description of the CCS and its operation is also incomplete and inaccurate. In Section 3.1.3.2 of the SEIS, the water budget and CCS operations are not described, which is relevant to both the consumption of surrounding surface waters and the impact of water quality of the surrounding surface waters. Several connections to Biscayne Bay have been documented, including in a State consent order. (0005-2 [Vogel, Robert])

Comment: Cooling and Auxiliary Water Systems -An accurate and thorough water budget is necessary to identify all sources and losses of water to understand the full impact of the operations of the CCS. Section 3.1.3.2 of the SEIS describes the operation of the CCS as "closed," which is inaccurate as described previously. The salt within the system comes from the ocean and is a clear indication of water flowing into the CCS from Biscayne Bay while the salt plume beneath the system in the Biscayne Aquifer is an indicator of the free flow of water out of the system into the surrounding environment. Using the term "closed" when these two connections are clearly known is a mischaracterization of the system misrepresentation of the conclusions of the SEIS. The presence of a water budget within the Final SEIS would greatly clarify this situation and provide a sound basis for determining impacts. A brief history of the operations of the CCS and some of the difficulties that have been observed should be included in the SEIS. For example, in the application for the first license extension, which included power uprate of Units 3 and 4, FPL incorrectly predicted that there would be no impact on the operation of the CCS. This prediction was incorrect and while there is some argument over the specific cause, the immediate result was higher than expected temperature and salinity in the CCS. A variance on temperature was necessary to remain in operation and, to this day, we understand that the CCS remains reliant on additions of water in order to reduce salinity, control temperature, and continue to operate. (0005-7 [Vogel, Robert])

Response: *The SEIS describes the hydrologic connection between Biscayne Bay and Card Sound in Section 3.5, "Water Resources." In this section, it is pointed out that "the CCS is hydraulically connected to surface waters including Biscayne Bay via the groundwater*

pathway.” These factors have been considered as part of the NRC staff’s characterization of surface water and groundwater resources as presented in Sections 3.5.1 and 3.5.2, as well as in the staff’s impact analyses for water resources presented in Section 4.5, “Water Resources.”

Section 3.5.1.4 (“Adjacent Surface Water Quality and Cooling Canal System Operation”) describes recent studies to evaluate potential effects of CCS operations via the movement of groundwater from the CCS to adjacent surface water bodies. In Section 3.5.1.2 (“Surface Water Consumption”) it is pointed out that “surface water resources are not consumed by Turkey Point operations. All water consumed by Turkey Point is derived from groundwater resources.” The SEIS points out that the groundwater underlying and surrounding the CCS is salt water. The section titled “Salinity within the Cooling Canal System” states that “most of the salt in the CCS comes from the groundwater of the Biscayne aquifer which is saltwater. As groundwater from the Biscayne aquifer moves into the CCS, the salt it contains also moves into the CCS... [T]he Biscayne aquifer obtains its salt from Biscayne Bay, and is hydraulically connected to both the Biscayne Bay and the CCS.”

The history of the CCS during the period of the power uprates of Turkey Point Units 3 and 4 is described in Section 3.5.1.4 under “Temperatures within the Cooling Canal System.” As pointed out in this section, “Historically, Turkey Points Units 1, 2, 3, and 4 all contributed heat to the CCS. Units 1 and 2 are now retired and no longer contribute heat to the CCS. Even under current operations (i.e., after the NRC approved extended power uprates for Units 3 and 4 on June 15, 2012 ...the heat that Units 3 and 4 discharge to the CCS is less than the amount of heat Turkey Point had discharged to the CCS when Units 1, 2, 3, and 4 were all in operation.”

Because of changing climatic conditions, the water budget for the Turkey Point site is always in a state of flux. A figure has been added to Section 3.1.3.2 to characterize a typical water budget for the Turkey Point site.

Comment: NRC staff explain the close connection between ground and surface water:

At the Turkey Point site, surface water (including the area’s freshwater canals, wetlands, and the adjoining Biscayne Bay) and groundwater are closely connected. This close relationship is attributable to the very high permeability of the underlying Biscayne aquifer, which permits water to move relatively freely between the surface and subsurface and vice versa. As a result, the CCS is hydraulically connected to surface waters including Biscayne Bay via the groundwater pathway.¹⁷

Despite the NRC’s identification of the close connection between groundwater and surface water and the hydraulic connection of the CCS to surface waters via a groundwater pathway, NRC staff also assert that the CCS “does not connect to any other surface water bodies.”¹⁸ The characterization made by NRC of the CCS as a closed loop system that does not connect to surrounding surface bodies is inaccurate and directly contradicted by information contained within the same document.

¹⁷ Ibid.[United States Nuclear Regulatory Commission, Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 5, Second Renewal Regarding Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4, Draft Report for Comment, NUREG-1437 Supplement 5 Second Renewal, March 2019, pg. 3-4, emphasis added.], 3-31, 3-32

¹⁸ Ibid., 3-38

(0023-7 [McLaughlin, Caroline])

Response: As referenced in Section 3.1.3.2 of this SEIS, a 1971 consent decree by the Federal District Court for the Southern District of Florida required FPL to discharge all cooling water from Turkey Point facilities into a closed-cycle cooling canal system. Section 3.1.3.2 states that the CCS does not have a direct surface water connection to any outside surface water body. Further, Sections 3.1.3.2, 3.5.1.3, and 3.5.1.4 state that water is exchanged between the CCS and the Biscayne aquifer. Section 3.1.3.1 was updated, in part, as a result of this comment to state that the CCS does not directly connect to any other surface water bodies.

Comment: The water quality impact to Biscayne Bay surface waters is not adequately addressed because the state of the nutrient condition in the Turkey Point area of Biscayne Bay is not presented. The numeric nutrient criteria for Biscayne Bay is not referenced or discussed in relation to the operation of the CCS, and the water use required by the CCS in daily operations from sources of the surrounding wetlands and Biscayne Bay is not adequately described. The NPS recommends providing additional detail and analysis regarding the status and condition of surface water and recommends changing the impact rating for surface water from "Small" to "Moderate-Large." (0005-3 [Vogel, Robert])

Comment: Water Quality Impacts Biscayne Bay-The numeric nutrient criteria, established by the Florida Department of Environmental Protection, does not appear to be taken into account when scoring the impacts to surface water resources in Biscayne Bay in the EIS. Review of these nutrient criteria over the past few years shows that Total Nitrogen (TN) and Chlorophyll-a (Chia) have exceeded these criteria. Calendar year 2017 is a prime example of these conditions. Monitoring for the Turkey Point Cooling Canal System (CCS), shows that TN concentrations in the surrounding canals were greater than the TN numeric criterion (0.33 mg L⁻¹) by as much as three times (Figures 4 and 5) [view figures in pdf available in NRC ADAMS at ML19143A166]. Similarly, sample locations established as transects from the east side of the CCS within Card Sound, all show TN concentrations that exceed the criterion with the highest values found in the locations closest to the CCS (Figure 4). Transects established from the east boundary of the CCS into Card Sound also show that Chi-a concentrations exceed the criterion (Figures 6 and 7). Given these elevated bay conditions appear to be linked via groundwater transport (see comments in the groundwater section) to the CCS, the rating established in Table 2-2 appears to underestimate the existing impacts of the CCS on Card Sound and the score, based on existing data, should be elevated to "Large." (0005-8 [Vogel, Robert])

Comment: Moreover, monitoring data indicate that water from the CCS is also hydrologically connected to the waters of Biscayne Bay, with CCS water moving through or under berms.⁸ Pollutants from the CCS, including elevated levels of ammonia, phosphorus, TKN, total nitrogen, and chlorophyll a, have been detected in the waters of Biscayne Bay.⁹ The addition of excess nutrients, such as ammonia and phosphorus, into the nutrient-limited waters of Biscayne Bay and Biscayne National Park has the potential to stimulate algal growth,¹⁰ which could ultimately lead to seagrass die-offs, toxic algal blooms, and severe ecosystem disruption, thus presenting a serious ecological concern.

⁸ Cox, William L., U.S. Department of Interior National Park Service, Letter to James D. Giattina, U.S. Environmental

Protection Agency; Jonathan P. Steverson, Florida Department of Environmental Protection; and Jack Osterholt, Miami-Dade County, May 13, 2016.

⁹ Miami-Dade County Report on Biscayne Bay Water Quality Observations associated with the Turkey Point Cooling

Canal System operations, March 7, 2016 Memorandum from Mayor Carlos A. Gimenez to

Miami-Dade County Board of County Commissioners Chair Jean Monestime and members. 10 Cox, William, US DOI NPS letter to EPA, DEP, MDC, May 13, 2016. (0023-5 [McLaughlin, Caroline])

Comment: Repeated Violations of Water Quality Standards

The connectivity between the CCS and surrounding waterways combined with persistent water quality issues involving hypersalinity and nutrification has resulted in the repeated violation of water quality standards by FPL over the years. Prior to 2010, seagrasses in the CCS served to remove nutrients that were added to the system. However, instances of high salinity and temperature in the canals led to a massive seagrass die-off and subsequent algal blooms in the CCS, significantly degrading water quality.¹⁹ Today, waters in the CCS are known to contain nutrient pollutants, including phosphorus, nitrogen, ammonia, and chlorophyll-a, which have subsequently been discharged into surrounding waterways. Indeed, ammonia exceedances have been repeatedly recorded in nearby waterways and attributed to contributions from the CCS. On April 25, 2016, the Florida Department of Environmental Protection (FDEP) issued a warning letter to FPL notifying them that monitoring data indicated that levels of ammonia exceeded ammonia water quality standards.²⁰ On July 10, 2018, Miami-Dade County Division of Environmental Resource Management (DERM) issued a letter indicating that total ammonia concentrations in the Barge Basin, Turtle Point, Card Sound remnant canal, S-20 canal, and the Sea-Dade remnant canal were in exceedance of County surface water quality standards.²¹ Through an analysis of temperature and tritium data, the County concluded that the CCS is a contributing source of ammonia to the areas.²²

¹⁹ Ibid.[United States Nuclear Regulatory Commission, Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 5, Second Renewal Regarding Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4, Draft Report for Comment, NUREG-1437 Supplement 5 Second Renewal, March 2019, pg. 3-4, emphasis added.], p. 3-44.

²⁰ Ibid., p. 3-50.

²¹ Ibid., p. 3-52, 3-53.

²² Ibid., p. 3-52, 3-53. (0023-8 [McLaughlin, Caroline])

Comment: 3.5.1.4, (pg 3-51). States: "The study and its conclusions are contained in an assessment published on March 17, 2017(FPL 2017c). The report concluded that the elevated ammonia values are attributable to the degradation of plant and animal material under anoxic (low oxygen) conditions in areas with little or no mixing with other surface waters. The occurrence of ammonia appears to be limited to the locations of deep stagnant anoxic water bodies. "

of Ammonia may result from degradation of organics in an anoxic environment, but the occurrence an anoxic environment in Bay waters (typically oxygenated) may be indicative of a nutrient source. Samples only collected from surface water (as opposed to sampling from bottom sediments or groundwater) could yield different results.

Recommendations: The EPA recommends the NRC critically evaluate statements taken from references describe the complexity and reflect that evaluation within the FSEIS. The EPA recommends that the FSEIS of pertinent systems in enough detail to provide readers of this document

with understandings without referencing separate documents. Additionally, the EPA recommends the NRC provide comprehensive system component range, property, and interaction descriptions in a concise, localized manner in the FSEIS. (0031-15 [Militscher, Christopher])

Response: The SEIS has been updated with respect to data on salinity and nutrients, including ammonia, phosphorus, nitrogen and chlorophyll-a, in the CCS and nearby surface waters. The local and regional hydrology including Biscayne Bay and Card Sound is described in Section 3.5.1.1, “Surface Water Hydrology.” In addition to the descriptions within the SEIS, several detailed descriptions were incorporated into the SEIS by reference from the final environmental impact statement (FEIS) for the Turkey Point Units 6 and 7 combined licenses (NRC 2016a). For example, the following information from the FEIS for Units 6 and 7 was incorporated by reference:

1. A description of the South Florida Hydrologic System and how it has changed over time from FEIS Section 2.3.1.1 on pages 2-25 to 2-30, including Figures 2-8, 2-9, 2-10, and 2-11.
2. The regional surface water system west of Biscayne Bay and how it has changed over time from FEIS Section 2.3.1.1 on Pages 2-31 and 2-32, including Figure 2-12.
3. A description of the hydrology and hydrodynamics of Biscayne Bay from FEIS Section 2.3.1.1 on pages 2-33 through 2-38, including Figures 2-14, and 2-15, and Table 2-8.

The SEIS points out that the Florida legislature has designated Biscayne Bay and Card Sound, including Biscayne National Park, as Outstanding Florida Waters. This affords these waters the highest water quality protection. The SEIS also points out that “...pollution from human activities also impacts the water quality of Biscayne Bay. Sections of the shoreline of Biscayne Bay are highly developed. The southern end of Biscayne Bay and Card Sound is less urbanized than the northern section of Biscayne Bay. Pollutants can potentially enter Biscayne Bay from multiple sources, including boats, canals, quarrying operations, landfills, military operations, a sewage-treatment plant, urban and agricultural runoff, and submarine groundwater springs (USGS 2008b).”

Section 3.5.1.4 (“Adjacent Surface Water Quality and Cooling Canal System Operation”) of this SEIS describes recent studies to evaluate potential effects of CCS operations via the movement of groundwater from the CCS to adjacent surface water bodies. This section also includes a description of monitoring data and mitigative actions for ammonia and nutrients within Biscayne Bay and Card Sound. The text points out that “If the concentration of nutrients in either Biscayne Bay or Card Sound get too high, they can negatively impact the ecological environment. Excess nutrients can cause algae blooms (thick green algae mats that can be toxic), deplete oxygen in the water, and reduce water clarity.”

The State of Florida (with the approval of the EPA) has established numeric nutrient criteria for Biscayne Bay and Card Sound. Section 3.5.1.4 (“Ammonia and Nutrients within Biscayne Bay and Card Sound”) of the SEIS also states, “The numeric nutrient criteria include criteria for phosphorus, chlorophyll, and total nitrogen, of which ammonia is a contributor.” Furthermore, the SEIS states, “Biscayne Bay waters are generally low in plant nutrients. This means the aquatic ecosystems respond very rapidly to small nutrient enrichment, especially to increases of phosphorous. The concentrations of ammonia from runoff tends to be higher in urban runoff than in wetland or agricultural runoff. The Biscayne Bay watershed has a diverse agricultural, urban, and wetland land use. This results in lateral differences in bay water nutrient concentrations.” The text also points out that “in general, ammonia concentrations are higher in

the northern portion of Biscayne Bay, which is most urbanized, while the lowest values are next to the Turkey Point site in Biscayne Bay and in Card Sound.”

Commenting on the draft SEIS, the National Park Service produced isopleth maps of total nitrogen and chlorophyll-a concentrations for surface water bodies including the CCS, Card Sound, Biscayne Bay, and local canals. The maps indicate that they represent 2017 data. The isopleth maps unrealistically treated the separate surface water bodies like they were one contiguous surface water body. However, the main point of these maps was to illustrate that in Biscayne Bay and Card Sound, chlorophyll-a and total nitrogen concentrations increased from east to west as the CCS was approached. The chlorophyll-a isopleth map was based only on data from Biscayne Bay and Card Sound. The NRC staff and its contractors evaluated the 2016, 2017, and 2018 data available in FPL’s Electronic Data Management System (EDMS; <https://www.ptn-combined-monitoring.com>) and in annual monitoring reports covering the same time period (FPL 2018o, FPL 2017a, FPL 2016b). However, the staff was unable to match the chlorophyll-a values in the map either from specific sampling events or yearly averaged values.

Looking at specific sampling events and yearly averages, the NRC staff and its contractors did not find a consistent trend in the data from 2016, 2017, and 2018 that were in FPL’s Electronic Data Management System (EDMS; <https://www.ptn-combined-monitoring.com>). The NRC staff observed that moving away from the CCS, chlorophyll-a concentrations could either decrease or increase. Within Biscayne Bay, sometimes concentrations increased or decreased moving either east or west from the center of the bay, with no apparent relation to the CCS.

The isopleth map of total nitrogen used values for the CCS, Biscayne Bay, Card Sound, and local canals. The NRC staff and its contractors were able to match the values in the map for total nitrogen values used to represent Biscayne Bay and Card Sound. The match for these values came from a single sampling event on September 12, 2016. As with the chlorophyll-a data, the NRC staff and its contractors could not find a consistent trend in the data from 2016, 2017, and 2018 in FPL’s Electronic Data Management System (EDMS; <https://www.ptn-combined-monitoring.com>).

To better characterize the water quality conditions in Biscayne Bay and Card Sound and its relationship to biologic communities, Section 3.5.1.4 of this SEIS was updated, in part, in response to these comments.

Comment: The renewal of the FPL TPPP NRC license according to the NRC environmental impact statement (EIS) is also premised on the agreement with Miami Dade WASD to build a RO reclaimed water plant for the purpose of providing FPL with the massive amounts of water required to operate the cooling canal system safely and effectively. In the interim, FPL has been permitted by the SFWMD to withdraw this water from the L31 canal and the brackish water of the Floridan, of which supply is limited because it is recharged by rainfall and artesian wells from Northern Florida and Georgia. This use of the Floridan in large quantities for this purpose adversely affects taxpayer funded Everglades Restoration projects in the area by diverting our limited water supply to the cooling canal system. If FPL is allowed to continue to use the cooling canal system, the reclaimed RO water produced by the plant will continue to leak from the canals and into the aquifer and bay. (0024-4 [List, Gary])

Response: *The NRC’s proposed action (subsequent license renewal) for Turkey Point Units 3 and 4 and its continued operation for an additional 20 years is not premised on the agreement between FPL and Miami-Dade County for use of reclaimed sanitary wastewater for CCS salinity*

reduction. Under the proposed action, the staff assumes that water for CCS freshening would continue to be withdrawn from the Upper Floridan aquifer, as described in Section 3.5.1.4 of the SEIS (see "Salinity Management Plan"). In addition, Section 3.5.2.3 of the SEIS describes the operation and quantifies the withdrawals of FPL's Upper Floridan aquifer freshening wells and Section 4.5.1.2, "Groundwater Use Conflicts" (see "Groundwater Use Conflicts (Plants That Withdraw More Than 100 Gallons per Minute)," presents an evaluation of the water use conflicts associated with the continued use of groundwater for CCS freshening and other uses under the proposed action, along with a discussion of groundwater use conflicts with other users.

This comment provides no new information and no changes were made to the SEIS as a result.

Comment: Currently, FPL is under orders from regulators to correct problems stemming from the canals that cool the water used to run the steam turbines. Among these, the cooling canals discharge nutrient-rich, hypersaline water into Biscayne Bay and the Biscayne aquifer. The Interceptor Ditch has failed its intended function to prevent contamination of the aquifer, and its continued operation comes at the cost of extracting around 3 mgd of freshwater from the wetlands in the Model Lands area. What are the consequences for the health of the bay and success of the C-111 and Biscayne Bay Coastal Wetlands Restoration projects if the cooling canals operate for another 30 years?

Results from an expanded monitoring program, initiated in 2009, reveal how the cooling canals interact with Biscayne Bay and the regional groundwater system through an active exchange of water between the canals and the aquifer. The cooling canals were constructed in the 1970s to prevent damaging discharge of heated water directly into the bay from the Turkey Point power plants. Until about 2009 it was widely assumed that the canals had little impact on the bay and adjacent wetlands. However, by 2012, investigations demonstrated the canals were the source of a plume of hypersaline groundwater extending several miles west, and nutrient-rich water from the canals was found in the bay.

Water in the canals is hypersaline as a consequence of high rates of evaporation. Evaporation is one of the primary mechanisms that cools the heated water as it circulates through the canals from the point of discharge on the west side of the power plants, returning to the water intake on the east side of the plant. For the first 40 years of operation, an inflow of saline water from Biscayne Bay made up the difference between losses from evaporation and water added by rainfall, pumping from the Interceptor Ditch and other minor sources. As a result, salt accumulated in the canals. Since 2010, the salinity of water in the canals has averaged around 60 psu. Seepage out of the canals provides a steady supply of hypersaline water to feed the growth of the groundwater plume.

In 2016, FPL initiated actions to remediate the discharge of hypersaline water into the aquifer. In particular, fresher water is being added to the canals from the Upper Floridan aquifer to decrease the average salinity to 34 psu. And, water is being withdrawn from the groundwater plume through a series of recovery wells and pumped into a deep injection well. These actions address the factors involved in the formation and westward migration of the saline groundwater plume.)

[View pdf to see attachment w/color figures entitled "Future Impacts on Biscayne Bay of Extended Operation of Turkey Point Cooling Canals" by Laura Reynolds, James Fourqurean, and William Nuttle, available from NRC ADAMS, Accession No. ML19151A729] (0071-1 [Reynolds, Laura])

Response: *The SEIS provides a thorough evaluation of the impacts of CCS operation on groundwater resources, surface water resources, and other resources, including CCS impacts on nearby surface waters through a groundwater pathway. The operation of CCS and its connection to and effects on surface and groundwater resources are described in Sections 3.1.3, "Cooling and Auxiliary Water Systems," 3.5.1, "Surface Water," and 3.5.2, "Groundwater Resources." The NRC staff did not revise the SEIS based on this comment.*

A.2.13 Land Use and Visual Resources

Comment: The proximity of the Turkey Point Plant location to BNP, BNP Visitor Center and Headquarters, and Homestead Bayfront Park is missing from Section 3.1.1 entitled, External Appearance and Setting (SEIS, Page 3-1) and only briefly mentioned in passing in last paragraph of Section 3.2. BNP supports nearly 500,000 visitors annually who enjoy the park for various recreational activities such as sightseeing, snorkeling, boating and fishing. The BNP Visitor Center, as well as Homestead Community Bayfront Park, have clear views of the FPL facility including Units 3 and 4. Page 3-25 of the Draft SEIS should provide additional information regarding the proximity of Turkey Point to BNP, the benefits of BNP to the local economy and communities, and a description of the visual impact of seeing the FPL facility from the water within BNP. The NPS recommends changing the impact rating for this topic from "Small" to "Moderate." (0005-6 [Vogel, Robert])

Comment: It is recommended that all alternatives be given the same impact category assessment for visual resources because the skyline is already impacted with the existing facility. (0031-8 [Militscher, Christopher])

Response: *As explained in Section 4.2.1 of the SEIS, nuclear power plant operations at Turkey Point Units 3 and 4 have not changed appreciably with time, and no change in land use and visual impacts are expected during the subsequent license renewal term. Therefore, people living in the vicinity of Turkey Point and visitors to the Biscayne National Park, Biscayne Bay, Homestead Bayfront Park, and the Dante Fascell Visitor Center would not experience any visual changes in the appearance of Turkey Point Units 3 and 4 during the subsequent license renewal term beyond what is currently being experienced. Section 3.2.2 points out that Turkey Point power units can be clearly seen from Biscayne National Park, including much of Biscayne Bay. Denial of the requested licensing action would not diminish the visual impacts, as the structures would remain in place for some time, before eventually being dismantled, as discussed in Section 4.2.2.2 (no-action alternative/visual resources). The comments did not introduce any new information that has not already been considered in the analysis. No changes were made to the SEIS as a result of these comments.*

Comment: Section 4.2.7.1, Page 4-11. The DSEIS states, "land use impacts associated with the construction and operation of the mechanical draft cooling towers for the cooling water system alternative would be SMALL." The DSEIS should recognize that, with much of the Turkey Point site occupied by the existing generation facilities, the cooling canal system, and wetlands, the footprint for cooling towers should be expected to impact wetlands and require permits and mitigation. The proposed location of the cooling towers and new Waste Water Treatment Facility would likely require wetland mitigation due to the need to establish a large construction site area that would be required for material and equipment laydown and staging in conjunction with the footprints of the new Cooling Towers, Waste Water Treatment Facility, Make-Up Water Pond (which is calculated at 60 Acres), and new pumping station. This statement should be revised to indicate that the land use impacts for this alternative would likely be larger than described in the DSEIS. (0017-4-3 [Maher, William])

Response: As explained in Sections 4.2.3.1 and 4.2.7.1 of the SEIS, construction would require the permanent commitment of FPL land at Turkey Point zoned for industrial use. Because only previously disturbed industrial portions of the Turkey Point site would be used to accommodate the cooling towers, land use impacts would be SMALL. Operation of the mechanical draft cooling towers would have no additional land use impacts beyond the use of the industrial zoned land.

Section 4.6 of the SEIS, "Terrestrial Resources," discusses the impacts to wetlands at the Turkey Point site and states "given the prevalence of wetlands within the Turkey Point site, it is unlikely that FPL would be able to avoid permanently filling or disturbing wetlands" when siting new facilities. As further explained in Section 4.6.7, impacts to terrestrial resources from the construction and operation of a cooling tower water system would be MODERATE due to noticeable impacts from the permanent disturbance, fragmentation, and degradation of important terrestrial habitat. Section 4.16.3 describes the cumulative effects on wetlands from past, present, and reasonably foreseeable actions at the Turkey Point site including the cooling towers, potential waste water treatment facility, and other related infrastructure. No changes were made to the SEIS as a result of these comments.

Comment: I have been aware of the problems caused by the cooling canals at Turkey Point but had not actually seen the canals. About a month ago I had the opportunity to fly over the Bay and see them from the air. I was shocked to see what 6,000 acres of open, unlined canals actually look like and how close they are to the open waters of Biscayne Bay. (My photos are included with this document as attachments.) [original pdf and attachments available from NRC ADAMS, Accession No. ML19147A010] (0032-2 [Bloom, Mary])

Response: This comment does not provide specific information related to the environmental effects of the proposed action (subsequent license renewal). No changes were made to the SEIS as a result of this comment.

Comment: Section 3.2.1.2, Page 3-24. The DSEIS states, "The U.S. Army Corps of Engineers, the U.S. Environmental Protection Agency (EPA), the Natural Resources Conservation Service, the U.S. Fish and Wildlife Service (FWS), and the National Marine Fisheries Service (NMFS) provide guidance on the use of the mitigation bank to satisfy mitigation requirements of specific laws and provisions, including Section 404 of the Federal Water Pollution Control Act (also known as the Clean Water Act [CWA]) permit program, the wetland conservation provisions of the Food Security Act, the National Environmental Policy Act (NEPA), and several other statutory provisions. The FDEP, the South Florida Water Management District (SFWMD), and Miami Dade County guide the mitigation bank program within Florida pursuant to the Florida Mitigation Banking Rule and other State authorities." This statement is not entirely correct. The US EPA, Natural Resources Conservation Service, the FWS and the NMFS do not provide guidance on the use of the mitigation bank; rather they participated in the review of the mitigation bank permit application and subsequent Mitigation Banking Instrument issued by the US Army Corps of Engineers. The FDEP has regulatory authority over the mitigation bank program within Florida pursuant to the Florida Mitigation Banking Rule. Neither the SFWMD nor Miami-Dade County have any regulatory authority over the FPL Everglades Mitigation Bank. This statement should be revised to: "... and the National Marine Fisheries Service (NMFS) participate in the review of the mitigation bank permit applications and subsequent Mitigation Banking Instruments issued by the US Army Corps of Engineers to ensure consistency with

specific laws and provisions including ...". "The FDEP guides the mitigation bank program within Florida pursuant to the Florida Mitigation Banking Rule." (0017-1-16 [Maher, William])

Response: *The NRC staff revised Section 3.2.1.2, "Coastal Zone," of the SEIS to state: "... and the National Marine Fisheries Service (NMFS) review and comment on mitigation bank permit applications and subsequent Mitigation Banking Instruments issued by the U.S. Army Corps of Engineers to ensure consistency with specific laws and provisions, including ...". The staff also revised a related statement on the same page to: "The FDEP permits mitigation banks for utility companies within Florida pursuant to the Florida Mitigation Banking Rule."*

A.2.14 Nonradioactive Waste

Comment: Section 3.13.2, Page 3-136. The DSEIS states, "there have been no reportable spills since the ER was submitted." This quotation from FPL's August 2018 WM-2 RAI response is incomplete. FPL's complete statement was, "There have been no reportable spills triggering the FAC 62-780.110 notification requirement since the ER was submitted." This statement should be replaced by FPL's complete statement. (0017-4-1 [Maher, William])

Comment: Section 3.13.2, Page 3-135. The DSEIS states, "From 2012 through 2016, FPL reported no oil discharges" This reporting period is not current. This statement should be revised to "From 2012 through 2018, FPL reported no oil discharges...." (0017-4-2 [Maher, William])

Response: *Section 3.13.2 of the SEIS has been revised based on these comments.*

A.2.15 Radioactive Waste

Comment: We're also a bit confused whether the storage of waste on site is being considering with respect to sea level rise and potential flooding risk. I know that the storage of waste is considered at all plants, however in this particular place there's an extra vulnerability with the flooding risk and sea level rise. (0001-7-2 [Silverstein, Rachel])

Comment: The long-range effects of nuclear power plant disasters (Japan, Pennsylvania, etc.) are yet to be seen. A little closer to the present is the continuing cavalier dismissal of the problem of storing nuclear waste. BUT with climate change affecting sea levels, we have a current and increasing likelihood of a disaster at nuclear plants. These plants need to be dismantled and cleaned up before they are flooded. I know you think Price-Anderson is going to protect your stockholders, but I am sure they would rather be known as those who brought about the end of this pollution and prevented this pending catastrophe. (0038-1 [Webb, Ann])

Comment: We continue to have no place to store spent fuel rods and until that time we should discontinue all nuclear power. (0118-1 [Kick, Anna])

Comment: Nuclear waste is still toxic for more than 10,000 years. Without proper containment it is a threat to all life. It is not a substance to ignore. (0139-1 [Case, Karen])

Response: *Onsite storage of spent nuclear fuel was determined in the License Renewal GEIS to be a Category 1 issue. As stated in Section 3.1.4.4 of the SEIS, FPL stores its spent fuel onsite in an independent spent fuel storage installation (ISFSI). In accordance with the requirements of 10 CFR Parts 50 and 72, spent fuel stored in the ISFSI must be protected*

against external hazards, including flooding, so as to provide reasonable assurance that the activities authorized under the license can be conducted without endangering public health and safety. The design, construction, and operation of the ISFSI must take potential external hazards, such as flooding, into consideration. A discussion of flooding hazards at the site is provided in Section 3.5.1.1 (under "Potential for Flooding at the Turkey Point Site") of this SEIS. The NRC staff determined that there is no new and significant information regarding radioactive waste impacts related to the storage of spent fuel from renewing the Turkey Point Units 3 and 4 licenses. The comments provide no new information, and no changes were made to the SEIS as a result of these comments.

Comment: Section 3.13.1, Page 3-133. The DSEIS states, "Radioactive materials in liquid and gaseous effluents are reduced prior to being released into the environment...." For nearly all materials released, this is a true statement. However, tritium is a special case in that it is impractical to reduce its pre-release concentration by conventional means. This statement should be revised to insert 'Nearly all' or 'Most' before 'Radioactive.' (0017-3-20 [Maher, William])

Response: Section 3.13.1 of the SEIS has been revised based on this comment.

Comment: Section 4.13.2, Page 4-95. The DSEIS states, "...the plant would generate less spent nuclear fuel...." This statement is inaccurate because the plant would not be operating and thus no new spent fuel would be produced. This statement should be revised to: "... after plant shutdown and prior to entering the decommissioning phase, the plant would generate no additional spent nuclear fuel." (0017-4-16 [Maher, William])

Response: Section 4.13.2 of the SEIS has been revised based on this comment.

A.2.16 Socioeconomics

Comment: We [Bonefish Bonnies] are a 20 year old women's fishing club at Ocean Reef in North Key Largo. We are 197 members strong. All of us are dedicated to the joys of angling and sharing that joy with more and more women and in conserving what we have and what we're in the process of losing. I wanted to say, I've been hearing a lot about Miami-Dade County and specifically the economics of what FPL is doing for Miami-Dade County. (0001-9-1 [Bloom, Mary])

Comment: Our national parks provide glimpses of nature to people of all ages who might not otherwise be able to access the unspoiled outdoors. (0033-1 [Rushmer, Vera])

Comment: I have visited Biscayne National Park and the Everglades several times. These parks are among my favorites. Please don't fail to address the problems with Turkey Point so that more generations can enjoy these precious resources. (0037-1 [Drewelow, Beth])

Comment: This flagged my attention! Our family visits national parks as often as we can. We have learned much in a short time, how many national parks are being put at risk due to development and poor management. These parks are our nation's legacy to future generations. We must do what is necessary to responsibly salvage them. (0047-1 [Beauchamp, Kristin])

Comment: National Parks belong to the nation and must be protected for all of us and for future generations. (0081-1 [Mccorry, Eileen])

Comment: I would love to visit Biscayne National Park, but I'll have second thoughts if this power plant is extended. (0086-1 [Baer, Robin])

Comment: I would just to say that our national parks, including Biscayne Bay, are far too valuable to allow them to be subjected to the threats of water pollution such as in the case of Biscayne Bay National Park off Florida's coast. (0105-1 [Wingle, Dennis])

Comment: Biscayne National Park is one of North America's iconic natural areas and unique to the United States. The National Park is a place of solitude and unique biota and it is appreciated by visitors from all over the World. The protected park adds a special place to our national heritage in addition to bringing in tourism revenue to the area. (0127-1 [Mazzuca, Rich])

Comment: My family has vacationed at Biscayne National Park. Act to ensure this fragile natural national treasure that is owned by the citizens of this country continues to exist protected and undamaged. (0131-1 [Casalone, Virginia])

Comment: We have personally enjoyed Biscayne and the Everglades, and want to see them protected for my future grandkids to see too. (0132-1 [Foster, Delaina])

Comment: I spend 3 months each winter enjoying the warmer climate and the beautiful parks and nature preserves in South Florida. To see this area damaged unnecessarily by poor management at the Turkey Point plant would be a travesty. (0136-1 [Hamory, Ann])

Response: *The commenters express general concerns regarding the impacts to Biscayne Bay, including impacts to recreational use of Biscayne National Park and the Everglades, as a result of continued operations from Turkey Point Units 3 and 4. As discussed in Section 3.10.2.1 of the SEIS, the NRC acknowledges that Biscayne Bay and National Parks in the vicinity of Turkey Point attract visitors that support economic activity in the region. As discussed in Section 4.7 of the SEIS, aquatic organisms in Biscayne Bay and other nearby water bodies are not subject to thermal impacts associated with Turkey Point and do not interact with the Turkey Point intake structure because there are no surface water connections that allow flow between the Bay waters and the CCS; similarly, as discussed in Section 4.5.1.1, the staff has determined that direct impacts to surface water resources would be SMALL. Additionally, Section 4.5.1.1 of the SEIS concludes that the impacts on adjacent surface water bodies via the groundwater pathway from the CCS during the subsequent license renewal term would be SMALL.*

The comments provide no new information, and no changes were made to the final SEIS as a result of these comments.

Comment: And one last thing I want to say in response to the person from the Chamber of Commerce. If you read the EIS, you will see that the cooling tower solution has nothing to do with eliminating jobs in this County. Nothing. And I ask you to read it. Not only that, but it creates 1,200 new jobs, although they're temporary because it's going to take them a couple of years to build the cooling towers, but it has nothing to do with jobs. The jobs will continue. And so I don't want you to be misinformed. (0001-14-9 [Rippingille, Bonnie])

Response: *The commenter references the construction workforce discussed under the "Cooling Water System Alternative" in Section 4.10.7.1 of the SEIS. This comment presents no new information and no change to the SEIS resulted from this comment.*

Comment: [And why does this sort of change the eco system? Because as you add nutrients, the seagrass actually increases in density and eventually die.] That's already happening now. And so what that does, is it will diminish how the fish and wildlife are able to survive. Why is that important? Because all of the fishing guides that are here and all of the people that depend on the resources of Biscayne National Park and the Marine Sanctuary, are impacted. That has an economic value that your Environmental Impact Statement had not captured at all. This is not a low risk, it's not a moderate risk, this is a high risk. And in fact, you cannot continue to operate this system without causing a great impact. And that's just to the east. And the reason I'm focusing on the east is because there's less information there. (0001-13-2 [Reynolds, Laura])

Comment: And we have a lot to lose in Florida. There are millions of people that come here as tourists. Millions. And they spend money and they support business activity in the area. And I want to continue to go and do fish fries. I don't want to have the Bay pickled, and that's what's happening because everything's dying. (0002-6-7 [Rippingille, Bonnie])

Comment: Please, don't forget the impact on the economies of the Miami-Dade and Monroe Counties if the canals are allowed to continue to pollute the source of our drinking water as well as the fisheries of Biscayne Bay and the creeks that connect the Bay to the ocean. Thousands of people depend on these waters for their livelihoods. Fishing and tourism are the lifeblood of the Keys. (0032-6 [Bloom, Mary])

Comment: It will impact the tourist industry among many others, further exacerbating the negative impact on S Florida. (0144-2 [Loerke, Alison])

Response: *The commenters express concerns that the ecological impacts to Biscayne Bay and drinking water as a result of continued operation of Turkey Point Units 3 and 4 will have a negative economic impact. As discussed in Section 3.10.2.1 of the SEIS, the NRC acknowledges that National Parks in the vicinity of the Turkey Point site support jobs and wages and attract visitors that support economic activity in the region. Furthermore, Section 3.10.4.3 of the SEIS discusses the public water supply system in Miami-Dade County. Ecological impacts on aquatic ecosystems are discussed in Section 4.7 of the SEIS. As discussed in the SEIS, aquatic organisms are not subject to thermal impacts associated with Turkey Point and do not interact with the Turkey Point intake structure because there are no surface water connections that allow flow between Biscayne Bay and the CCS; similarly, as discussed in Section 4.5.1.1, the staff has determined that direct impacts to surface water resources would be SMALL. Additionally, Section 4.5.1.1 of the SEIS concludes that the impacts on adjacent surface water bodies via the groundwater pathway from the CCS during the subsequent license renewal term would be SMALL. Section 4.8.1.1 of the SEIS has been updated to discuss that to date, FPL's monitoring data indicate no discernible ecological impact on the areas surrounding the CCS and no clear evidence of CCS water in the surrounding marsh and mangrove areas or in Biscayne Bay from a groundwater pathway. Furthermore, Section 4.5.1.2 of the SEIS concludes that the impacts to groundwater quality from operations during the subsequent license renewal term would be SMALL as a result of ongoing remediation measures and State and County oversight now in place. Therefore, subsequent license renewal of Turkey Point Units 3 and 4 is not expected to have adverse economic impacts on Biscayne Bay, Biscayne National Park, or surrounding areas.*

The comments provide no new information, and no changes were made to the SEIS as a result of these comments.

Comment: Section 3.10.3 -NPS suggests adding information that identifies the closest residential area to Turkey Point as the Convoy Point housing at BNP headquarters. (0005-15 [Vogel, Robert])

Comment: Section 3.10.5, Page 3-125. The DSEIS states 'Turkey Point property tax payment for 2012 - 2017 are presented in Table 3-23.' It should be noted that the tax payments in Table 3.23 are attributed to Turkey Point nuclear units 3 and 4 alone, and exclude the other units at the Turkey Point site during those tax years. This statement should be revised by inserting 'Units 3 and 4' after 'Point.' (0017-3-19 [Maher, William])

Response: *The NPS recommends that Section 3.10.3 of the SEIS identify the nearest resident from the Turkey Point site in Section 3.10.3 and that the title of Table 3-24 (the correct table number is Table 3-24, rather than Table 3-23 as mentioned by the commenter) of the SEIS be revised. The NRC agrees with the recommendations. The nearest resident has been included in Section 3.10.3 of the SEIS; however, a 2017 land-use survey within a 5-mi (8-km) radius of the Turkey Point site (ADAMS Accession No. ML18137A201) indicated that the nearest resident is at the Homestead Bayfront Park complex, which is approximately 1,000 ft closer to Turkey Point than the Convoy Point resident noted by the commenter. The title of Table 3-24 has been revised to clarify that the tax payments presented in the Table 3-24 are attributed specifically to Units 3 and 4.*

Comment: Operations at Turkey Point are estimated to generate nearly \$1.7 billion of total economic output annually with \$740 million at this outfit right here in Miami-Dade County. It's clear that FPL has already invested extensively to this facility. We in Homestead experience the phenomenon known as the refueling outage every so often. During these projects, the plant equipment is upgraded and more than 1,000 additional employees are hired at the site, benefitting surrounding local businesses. FPL continues the process of renewing the operating license for Units 3 and 4, through 2052 and 2053, as part of an application with the U.S. Nuclear Commission -- Regulatory Commission. If granted, this extension would support billions of dollars in savings to -- for FPL customers by avoiding the need for other more expensive power generation. It would also be a major asset to the South Miami-Dade economy in the way of tax benefits as well as secure, high paying jobs. It would also mean local businesses can count on continued support from FPL and its employees as a vital part of an economic stability in our community. (0001-2-2 [Black, Kerry])

Response: *This comment identifies beneficial economic impacts as a result of Turkey Point Units 3 and 4 operations. Section 4.10.1 of the SEIS discusses the socioeconomic impacts from continued operations of Turkey Point Units 3 and 4. The comment does not provide new information. There was no change to the SEIS as a result of this comment.*

Comment: Section 4.10.7.1, Page 4-83. The DSEIS states: "Therefore, the socioeconomic impacts of constructing the cooling water system alternative would be SMALL." The DSEIS section should be revised to consider the capital costs of constructing the Cooling Towers, the Waste Water Treatment Facility, Make-Up water Pond and related support facilities that has been estimated at well over \$1B. This cost would also be relevant for the consideration of the reasonableness of this alternative. This is discussed in detail in the High Bridge Report. (Attachment 19 Enclosure 1 to FPL Letter L-2018-136 dated August 8, 2018; ADAMS Accession No. ML18247A509). (0017-4-15 [Maher, William])

Response: *The commenter recommends that Section 4.10.7 of the SEIS should be revised to consider the capital costs of constructing the cooling water system alternative estimated in a High Bridge Associates report (ADAMS Accession No. ML18247A525) and to reconsider the SMALL impact level concluded. The High Bridge Associates report estimates that the capital cost to construct cooling towers would be approximately \$1.87 billion over a 7- to 9-year period. The socioeconomic impacts discussion of the cooling water system alternative presented in Section 4.10.7 used the new nuclear alternative as a bounding analysis (Section 4.10.4 of the SEIS) for the increase in revenue sales tax and corporate income and excise tax that would result from construction costs. As presented in Section 4.10.4 of the SEIS, the new nuclear alternative concluded that the increase in tax revenue from construction costs would be beneficial, but relatively minimal; total plant construction costs were estimated to be between \$12.8 billion and \$18.7 billion over a 12-year period for the new nuclear alternative, a cost substantially greater than what is estimated in the High Bridge Associates report. Therefore, given that the cooling water system alternative used the new nuclear alternative construction costs and the increase in tax revenue as a bounding analysis and that the construction workforce of the cooling water system alternative would be one third of the new nuclear alternative construction workforce, a SMALL socioeconomic impact is concluded. In response to this comment, the significant impact level in Section 4.10.7 of the SEIS was not revised. However, Sections 4.10.4 and 4.10.7 were revised to clarify that the analysis presented considered a construction cost estimated to be between \$12.8 billion and \$18.7 billion over a 12-year period.*

The commenter further requests that the construction capital cost (\$1.87 billion over a 7- to 9-year period) estimated in the High Bridge Associates report for a cooling water system alternative should be considered in determining the reasonableness of this alternative. The SEIS evaluates an alternative closed-cycle cooling water system that could mitigate potential impacts associated with the continued use of the existing cooling canal system. The purpose of this analysis is for the NRC staff to compare the closed-cycle cooling alternative with the proposed action to inform NRC's licensing decision as applicable under NEPA. Furthermore, the NRC staff examined this alternative in response to numerous scoping comments requesting that the SEIS evaluate alternatives to the existing CCS at Turkey Point Units 3 and 4. The NRC has neither the statutory nor the regulatory authority to determine which system or technology should be used. The NRC staff has evaluated cooling system alternatives in a limited number of other license renewal environmental impact statements (e.g., Seabrook Station, Oyster Creek Nuclear Generating Station SEISs) in response to comments and to compare a cooling system alternative with the proposed action to inform the licensing decision. In accordance with 10 CFR 51.95(c)(2), the SEIS does not need to consider the costs of alternatives to the proposed action except insofar as such costs are either essential for a determination regarding the inclusion of the alternative in the range of alternatives considered or relevant to mitigation. Section 4.10.7.1 of the SEIS was revised to incorporate information regarding the cost of constructing cooling towers for subsequent license renewal of Turkey Point Units 3 and 4. While the cost of constructing cooling towers for Turkey Point Units 3 and 4 would be considerable, the socioeconomic impacts of such construction in Miami-Dade County would be SMALL, as discussed in Section 4.10.7.1 of the SEIS.

A.2.17 Editorial

Comment: Section 3.1.1, Page 3-1. In several places, the DSEIS gives the false impression that five units remain on site. To be clear, the DSEIS should be revised to indicate that Units 1 and 2 have been significantly decommissioned, but the generators remain on site to help

stabilize and optimize grid performance. See also pages 2-9, line 10; 3-20, line 5; page 3-27, line 13; and page 3-81, line 11. (0017-1-15 [Maher, William])

Response: *The characterization of the status of Turkey Point Units 1 and 2, referred to as retired fossil-fueled units has been updated to clarify that Turkey Point Units 1 and 2 have been repurposed to support transmission reliability.*

A.2.18 License Renewal Process

Comment: Several commenters expressed concern with the public comment opportunities and the openness of the public participation process.

Comments: (0001-11-1 [Friedman, Steve], 0007-1 [Brusin, Eugene], 0036-1 [King, Terry])

Response: *The NRC agrees that public participation and a thorough analysis of the potential environmental impacts of the agency's proposed action (subsequent license renewal) and alternatives to the proposed action are critical to the NRC's decisionmaking process. The NRC staff performed its environmental review and developed the draft SEIS in accordance with NEPA and the NRC's requirements in 10 CFR Part 51. The results of public involvement in the Turkey Point Units 3 and 4 environmental review are captured in this Appendix. These comments provide no new information, and no changes have been made to this SEIS as a result.*

Comment: A number of commenters expressed concern with issues such as requiring the licensee to use an alternative cooling system design, coordination with local agencies on permitting at the Turkey Point site, working with other Federal agencies regarding the review of the license renewal application, and requiring the licensee to remediate for water quality in the area of the site.

Comments: (0001-14-1 [Rippingille, Bonnie], 0001-15-3 [Gomez, Albert], 0003-4 [Commenters, multiple], 0018-6 [Fangman, Sarah], 0023-13 [McLaughlin, Caroline], 0032-7 [Bloom, Mary], 0073-1 [Bloom, Mary])

Response: *The NRC's statutory mission is to protect public health and safety from the effects of radiation from nuclear reactors, materials, and waste facilities. A discussion of these responsibilities beginning with the Atomic Energy Act of 1954 can be found on the NRC Web site at <http://www.nrc.gov/about-nrc/history.html>. The NRC does not have the regulatory authority to require that FPL implement an alternative closed-loop cooling water system as a condition of subsequent license renewal. The SEIS evaluates an alternative cooling water system that might be used to mitigate the potential impacts associated with the continued use of the existing cooling canal system. SEIS Chapter 4 assesses the environmental impacts of a cooling water system alternative to the existing cooling canal system (i.e., constructing and operating two new mechanical draft cooling towers). The purpose of this analysis is for the NRC staff to compare an alternative closed-cycle cooling system approach with the proposed action to inform the NRC's licensing decision, decisions by other decisionmakers and the public, as applicable, under NEPA.*

The NRC has neither the statutory nor the regulatory authority to determine which cooling water system or technology should be used, or to decide other permitting issues, for which the State of Florida has been delegated regulatory authority under the Clean Water Act. Issuance of a renewed license does not foreclose or restrict the ability of other regulatory authorities to take such actions as they deem necessary to ensure compliance with regulations, orders, consent

agreements, or other regulatory requirements under their Clean Water Act or other lawful statutory jurisdiction. No new information was provided by these comments, and the NRC staff did not revise the SEIS in response to these comments.

Comment: One commenter questions whether the environmental review is being conducted using NEPA standards.

Comment: (0006-1 [Gould, Kyle])

Response: *The NRC licensing process for nuclear power plants (including subsequent license renewal) includes both an environmental review under NEPA and a separate safety review. The SEIS, which was prepared as part of the NRC staff's environmental review, conducted in accordance with NEPA, provides a thorough assessment of the environmental impacts of the proposed action and alternatives in accordance with CEQ regulations and the NRC's regulations for implementing NEPA at 10 CFR Part 51. Chapter 2 of the SEIS describes the proposed action and alternatives. Chapter 3 of the SEIS describes the affected environment. Chapter 4 describes and assesses the potential direct, indirect, and cumulative environmental impacts of the proposed action and alternatives. This comment does not provide specific information related to the environmental effects of the proposed action. The NRC staff did not revise the SEIS based on this comment.*

Comment: One commenter suggests that the review allow time for additional data to be considered and asks that DERM and related agencies weigh in on the NRC's licensing decision.

Comments: (0020-1 [Gomez, Albert], 0020-9 [Gomez, Albert])

Response: *As discussed in Section 1.3 of this SEIS, FPL submitted its subsequent license renewal application (SLRA) on January 30, 2018. On May 2, 2018, the NRC staff published a Federal Register notice of acceptability for the SLRA and opportunity for hearing. On May 22, 2018, the NRC published another notice in the Federal Register informing members of the public of the staff's intent to conduct an environmental scoping process for the DSEIS, thereby beginning a 30-day scoping comment period.*

During the scoping period, the NRC staff held two public scoping meetings on May 31, 2018, near the Turkey Point site in Homestead, Florida. In January 2019, the NRC issued its "Supplemental Environmental Impact Statement Scoping Process Summary Report, Turkey Point Nuclear Generating Unit Nos. 3 and 4, Miami-Dade County, Florida," which includes the comments received during the scoping process and the NRC staff's responses to those comments.

Upon completion of its review of FPL's Environmental Report and related documents and scoping comments, the NRC staff published the DSEIS on March 28, 2019. The NRC provided a 45-day comment period on the DSEIS (April 5 to May 20, 2019), including two public meetings in Homestead, Florida, on May 1, 2019. To the extent practicable, the NRC staff considered all comments received on the DSEIS beyond the scheduled 45-day comment period.

The NRC staff's responses to all substantive comments received from the public and from regulatory and resource management agencies on the draft SEIS are contained in Section A.2 of this Appendix. These include the staff's responses to comments from EPA and from the Miami-Dade County Department of Environmental Resources Management. The NRC staff

has invited pertinent regulatory agencies to participate in its environmental review process. The commenter did not specify or identify the additional data that exist and should be considered in the SEIS. The SEIS was not revised based on these comments.

Comment: Commenters express general environmental and safety concerns related to subsequent license renewal and continued operation at Turkey Point Unit Nos. 3 and 4, as well concerns about the timing of the NRC staff's environmental review and the desire that the NRC ensure FPL's compliance with environmental requirements.

Comment: (0002-6-9 [Rippingille, Bonnie], 0121-1 [Culberson, Ina])

Response: *With respect to the timing of license renewal applications, Section 54.17(c) of 10 CFR Part 54 allows licensees to submit license renewal applications up to 20 years before the expiration of the licenses currently in effect. The Commission established this earliest date for submission of license renewal applications after soliciting and considering public comments (56 FR 64943). In the 1991 statements of consideration for 10 CFR 54.17(c), the Commission rejected the suggestion that 20 years of operational and regulatory experience with a particular plant was an insufficient period in which to accumulate information on plant performance. Further, the Commission rejected suggestions that a 5-year or even a 15-year time limit for filing renewal applications would be adequate. The Commission stated that, in establishing the earliest date for license renewal applications, it considered the time necessary for utilities to plan for replacement of retired nuclear plants. The Commission found that the lead time for building new electric generation facilities is 10-14 years depending on the technology. When the license renewal rule was revised in 1995, the Commission again solicited comments on the earliest date for filing license renewal applications. After considering the comments, the Commission concluded that there was no new information warranting a change in the earliest date for license renewal applications, either to make it earlier or later (60 FR 22461).*

With respect to the NRC's regulatory authority, the NRC's statutory mission is to protect public health and safety from the effects of radiation from nuclear reactors, materials, and waste facilities. A discussion of these responsibilities beginning with the Atomic Energy Act of 1954 can be found on the NRC Web site at <http://www.nrc.gov/about-nrc/history.html>. The NRC does not have the authority to ensure a licensee's compliance with other regulatory authorities' requirements under the Clean Water Act or with applicable State water quality standards. This limitation on the part of the NRC's authority does not foreclose or restrict the ability of other regulatory authorities to take such actions as they deem necessary to ensure compliance with regulations, orders, consent agreements, or other regulatory requirements under their Clean Water Act or other lawful statutory jurisdiction. This comment does not provide specific information related to the environmental effects of the proposed action. The NRC staff did not revise the SEIS based on this comment.

Comment: The commenter requests that a full hearing be held on alternative cooling systems and issues related to the American crocodile.

Comment: (0001-14-10 [Rippingille, Bonnie])

Response: *The NRC's hearing process, governed by 10 CFR Part 2, is an adjudicatory process that is separate and distinct from the NRC's license renewal environmental review that is conducted in accordance with NEPA and the NRC's regulations for implementing NEPA. An Atomic Safety and Licensing Board (ASLB) has been appointed to rule upon petitions for leave*

to intervene and hearing requests concerning the proposed action, and to preside over any hearings that may be held in the proceeding. Contentions have been filed before the ASLB, which raise a number of issues, including the effects of continued CCS operation on the American crocodile and its critical seagrass habitat. The NRC's hearing process remains ongoing. This comment provides no new information, and no changes have been made to this SEIS as a result.

Comment: The commenter is concerned that the SEIS does not adequately characterize the impacts associated with the CCS, alternative cooling water system, or replacement power alternatives, recommends that SEIS be more data-driven, and specifically provides two examples pertaining to Aquatic Resources and Noise impacts where the analysis can be improved.

Comment: (0031-6 [Militscher, Christopher])

Response: *The NRC staff performed its environmental review and developed the draft SEIS in accordance with NEPA and NRC's requirements in 10 CFR Part 51. The SEIS evaluates the potential environmental impacts of the proposed action (subsequent license renewal) and designates the environmental impacts from the proposed action as SMALL, MODERATE, or LARGE. The NRC established the three levels of significance using the Council on Environmental Quality terminology for "significantly" (40 CFR 1508.27). CEQ's regulations implementing NEPA (40 CFR 1500-1508) require that EISs be concise, clear, to the point, and supported by evidence that agencies have made the necessary environmental analyses. The NRC staff uses SMALL, MODERATE, and LARGE to communicate the results of its environmental impact analyses in a concise manner. In compliance with CEQ regulations, the SEIS identifies the methodologies used in the environmental analyses, and explicitly references sources relied upon for conclusions. For some analyses, a separate appendix is included that contains additional detailed calculations and numerical data.*

Chapter 4 of the SEIS evaluates the environmental consequences and impacts associated with continued operations of Turkey Point Units 3 and 4, including the impacts associated with the CCS. Chapter 2 of the SEIS describes the NRC staff's process for developing a range of reasonable alternatives to the proposed action and the replacement power alternatives that the staff selected for detailed analysis, including supporting assumptions and data. The NRC staff's analysis of the alternative cooling water system draws upon an application that FPL submitted to the NRC in 2009, to build and operate two new onsite nuclear reactors (Turkey Point Units 6 and 7). The Units 3 and 4 alternative cooling water system would have the general design, construction, and operating characteristics as the cooling water system associated with Turkey Points Units 6 and 7. Where numeric data were available and supported by reference sources (e.g., land acreage, water consumption), they were provided and considered as part of impact analyses for the alternatives considered. When quantifiable information was not available, in accordance with 10 CFR 51.71(d), the analysis was discussed in qualitative terms. Chapter 4 of the SEIS describes and assesses the potential direct, indirect, and cumulative environmental impacts of the replacement power alternatives and alternative cooling water system.

Specifically, the commenter states that the SEIS did not evaluate the impacts of the proposed action on species living in the Biscayne aquifer. The NRC did not consider the impacts of the proposed action on species living in the Biscayne aquifer because there are no known species living in the Biscayne aquifer. The staff addressed the impacts of the proposed action on aquatic and terrestrial resources, including species inhabiting Biscayne Bay, in Sections 4.6.1, 4.7.1, and 4.8.1 of the SEIS. No change was made to the SEIS in response to this comment.

Further, the commenter states that the SEIS could be improved in that it does not discuss the temporary nature of noise impacts from construction of the replacement power alternatives, and does not consider the baseline conditions for the visual resource impact analysis for the alternatives. Common construction-related noise impacts for replacement power facilities and the cooling water system alternative are discussed in Section 4.3.3.2. The discussion in Section 4.3.3.2 of the SEIS has been revised to identify the temporary nature of construction activities in response to this comment. Section 4.2.3.2 of the SEIS indicates that the visual impact analysis focuses on the degree of contrast between the replacement power plant and the surrounding landscape and the visibility of the alternative.

Comment: The commenter identifies that they submitted a request for a hearing and petition to intervene regarding the Turkey Point Unit Nos. 3 and 4 subsequent license renewal application and raises concerns that while the DSEIS comment period provides a means for comments to be provided, as it does not provide an adjudicatory pathway, they are less meaningful.

Comment: (0021-1 [Ayres, Richard E.]

Response: *As discussed in Section 1.3 of the SEIS, FPL submitted its subsequent license renewal application (SLRA) on January 30, 2018. On May 2, 2018, the NRC staff published a Federal Register notice of acceptability for the SLRA and opportunity for hearing. Consistent with NRC regulations, the Federal Register notice informed members of the public that any person whose interest may be affected by the proceeding may request a hearing or petition for leave to intervene with respect to the proposed license renewal action in accordance with 10 CFR 2.309. The commenter filed a request for hearing and petition for leave to intervene on behalf of certain organizations, and his contentions are under consideration by the ASLB, in accordance with NRC adjudicatory procedures.*

Requests for hearing and petitions for leave to intervene are part of an adjudicatory process that is separate from the NRC's license renewal environmental review process. The NRC staff conducted an environmental review of the Turkey Point Units 3 and 4 subsequent license renewal application, and issued a draft SEIS in accordance with NEPA and NRC's requirements in 10 CFR Part 51. As part of the environmental review process, the public was invited to comment on the draft SEIS. The commenter submitted comments on the draft SEIS as part of that process. After considering all public comments and resolving the comments received, the NRC staff is issuing this final SEIS, which incorporates appropriate responses to comments and changes to the SEIS. The NRC staff has conducted a thorough analysis of the public comments received, in accordance with the requirements of NEPA and NRC regulations that implement NEPA. The results of the public's involvement in the Turkey Point Units 3 and 4 environmental review are captured here, in Appendix A of the SEIS. As stated above, this process is in addition to and separate from the adjudicatory process afforded to the petitioner and others under 10 CFR Part 2. This comment provides no new information, and no changes have been made to the SEIS.

Comment: The commenter requests that technical comments and recommendations be addressed in the Final Supplement Environmental Impact Statement.

Comment: (0031-1 [Militscher, Christopher])

Response: *The commenter requests that technical comments and recommendations be addressed in the final SEIS. The NRC acknowledges the comment and agrees that a thorough analysis of public comments and input are critical to the NRC's environmental review process. The NRC staff's responses to comments received from the public and from regulatory agencies on the draft SEIS are contained in Section A.2 of this Appendix. The staff has carefully considered and responded to comments provided on the draft SEIS and the final SEIS incorporates appropriate comments and recommendations.*

This comment provides no new information, and no changes have been made to the SEIS.

Comment: The commenter recommends that NRC provide a quantitative approach including data and analysis which better define the levels of impact described in Chapter 4.

Comment: (0031-3 [Militscher, Christopher])

Response: *The NRC staff uses the SMALL, MODERATE, and LARGE significance levels to communicate the results of its assessment of the environmental impacts of the proposed action and alternatives. The structure for these significance levels is based on Council on Environmental Quality (CEQ) terminology for "significantly" (see 40 CFR 1508.27). Since the significance and severity of an impact can vary with the setting of the proposed action, both "context" and "intensity," as defined in CEQ regulations 40 CFR 1508.27, were considered. Context is the geographic, biophysical, and social context in which the effects will occur. In the case of license renewal, the context is the environment surrounding the nuclear power plant. Intensity refers to the severity of the impact in whatever context it occurs. Based on this, the NRC established its three levels of significance for potential impacts. The definitions of the three significance levels are presented in the footnotes to Table B-1 of 10 CFR Part 51, in Appendix B to Subpart A, and which are provided Section 1.4 of this SEIS.*

CEQ's regulations implementing NEPA (40 CFR 1500-1508) require that EISs be concise, clear, to the point, and supported by evidence that agencies have made the necessary environmental analyses. The NRC staff uses SMALL, MODERATE, and LARGE to communicate the results of its environmental impact analyses in a concise manner. The staff's impacts analyses presented in Chapter 4 of the SEIS are contained in the paragraphs preceding the significance determinations of SMALL, MODERATE, or LARGE, as appropriate. In compliance with CEQ regulations, the SEIS identifies the methodologies used in the environmental analyses, and explicitly references sources relied upon for conclusions. For some analyses, a separate appendix is included that contains additional detailed calculations and numerical data. This comment provides no new information, and no change was made to the SEIS.

Comment: The commenter notes that the greater negative impacts for the cooling water system alternative are associated with construction when compared to the impacts from operation. Given shorter construction period relative to operation of the cooling water system alternative, the commenter recommends that the overall significance impact level presented in the SEIS for the cooling water system alternative be that only for operation.

Comment: (0022-8 [Hefty, Lee N.]

Response: *The NRC acknowledges that the cooling water system alternative will require construction and modifications to the facility and site, while continued operations with the existing CCS does not require such construction and modifications. However, to determine the*

environmental impacts associated with an alternative cooling system alternative, the NRC staff considers the impact from construction as part of the overall impacts, since operation of the cooling water system alternative would not proceed without construction. Furthermore, while the construction activities would be temporary and short-term, the severity of the impact, while short-lived, may be significant and therefore should be considered to inform NRC's licensing decision, as well as other decisionmaking authorities and the public, as applicable under NEPA. The cooling water system alternative analysis considered the environmental consequences of both constructing and operating a new system in accordance with the NRC's environmental standard review plan (NUREG-1555, Supplement 1, Revision 1), which provides guidance in conducting environmental reviews for the renewal of nuclear power plant operating licenses.

This comment provides no new information, and no changes have been made to the SEIS.

A.2.19 NEPA Process

Comment: The commenter addresses the legal standards required under NEPA to take a "hard look" at the significant environmental impacts associated with a major federal action.

Comment: (0021-2 [Ayres, Richard E.]

Response: *The NRC staff recognizes that NEPA calls for a hard look at the significant environmental impacts associated with a major Federal action. The NRC licensing process for nuclear power plants (including subsequent license renewal) includes a thorough review of the environmental impacts of the proposed action and reasonable alternatives thereto, in accordance with NEPA and the NRC's regulations implementing NEPA at 10 CFR Part 51. Chapter 2 of this SEIS describes the proposed action and alternatives. Chapter 3 describes the affected environment. Chapter 4 describes and assesses the potential direct, indirect, and cumulative environmental impacts of the proposed action and alternatives. Chapter 4 also describes mitigation measures. This SEIS documents the NRC staff's analyses of the impacts of the proposed action and alternatives, based on an extensive review including literature searches, field work, modeling, and independent staff consideration of all pertinent information. This comment does not provide specific information related to the environmental effects of the proposed action. The NRC staff did not revise the SEIS based on this comment.*

Comment: The commenter expresses concern with environmental cleanup at the Turkey Point site and questions the regulatory authority of the NRC.

Comment: (0095-1 [Platero, Tracy])

Response: *The NRC's statutory mission is to protect public health and safety from the effects of radiation from nuclear reactors, materials, and waste facilities. A discussion of these responsibilities beginning with the Atomic Energy Act of 1954 can be found on the NRC Web site at <http://www.nrc.gov/about-nrc/history.html>. The proposed licensing action (subsequent license renewal of Turkey Point Units 3 and 4) does not include plans for ultimate cleanup of the site. Once a license terminates, the licensee must begin decommissioning the facility. In accordance with 10 CFR 50.82, all nuclear power reactor licensees are required to submit decommissioning plans for approval by the NRC, which the NRC evaluates separately from the license renewal process. In addition, pursuant to 10 CFR 50.82(a)(9), all nuclear power*

licensees must submit a license termination plan for NRC approval, which must include plans for site remediation.

The NRC's regulations governing radiological protection were promulgated to protect workers and members of the public from the harmful health effects (i.e., cancer and other biological impacts) of radiation. In addition, other regulations establish requirements for the design, construction, and operation of nuclear facilities. Compliance with these regulatory requirements provides reasonable assurance that public health and safety will be adequately protected. The NRC does not have the authority to ensure a licensee's compliance with other regulatory authorities' requirements under the Clean Water Act or with applicable State water quality standards. This limitation on the scope of the NRC's authority does not foreclose or restrict the ability of other regulatory authorities to take such actions as they deem necessary to ensure compliance with regulations, orders, consent agreements, or other regulatory requirements under their Clean Water Act or other lawful statutory jurisdiction.

This comment does not provide specific information related to the environmental effects of the proposed action. The NRC staff did not revise the SEIS based on this comment.

A.2.20 Opposition to License Renewal

Comment: Many commenters express opposition to extending the licenses of Unit Nos. 3 and 4 at the Turkey Point site.

Comments: (0001-11-4 [Friedman, Steve], 0003-1 [[Commenters, multiple], 0010-2 [Greene, J.], 0045-1 [Monfredini, Janet], 0060-1 [S.C.], 0074-1 [Talbot, Diana], 0092-1 [Hildebrandt, Todd], 0097-1 [Seamon, Jeffrey], 0101-1 [Worden, Susan], 0102-1 [Kirschbaum, Sarah], 0117-1 [Aurigemma, Kaye], 0125-1 [Kalman, Sherri], 0130-1 [Miller-Richardson, Gail], 0144-3 [Loerke, Alison], 0149-1 [Hogan, Cynthia])

Response: *The NRC staff acknowledges the commenters' expression of their views. These comments do not provide any specific information related to the environmental effects of the proposed action. No changes were made to the SEIS as a result of these comments.*

Comment: The commenters identify general concerns about water quality impacts from current operation of Turkey Point Unit Nos. 3 and 4 and opposition to continued operation of the plant.

Comments: (0004-3 [Moses, Dorothy], 0004-5 [Moses Dorothy], 0040-1 [Barghahn, Serena], 0043-1 [Raymond, Wendy], 0053-1 [Lewis, Nora], 0069-1 [Conley, Cristen], 0083-1 [Foerste, Eleanor], 0087-1 [Lambert, Sandra], 0104-1 [Jantzen, Gayle], 0108-1 [Parker, Sue], 0152-1 [Denton, April])

Response: *The existing surface water and groundwater resources at the Turkey Point site are described in Section 3.5. Impacts to water resources from continued operation of Units 3 and 4 are described in Section 4.5. These comments did not provide any new information, and no changes were made to the SEIS as a result of these comments.*

Comment: The commenters identify general concerns about the ecology surrounding the Turkey Point Unit Nos. 3 and 4.

Comments: (0001-17-1 [Guest, David], 0085-1 [Sheridan, Michelle], 0088-1 [Beigel, Lynda], 0115-1 [Greenfield, Judy])

Response: Ecological impacts of continued operation are described in Sections 4.6, 4.7, and 4.8. These comments do not provide any specific information related to the environmental effects of the proposed action. No changes were made to the SEIS as a result of these comments.

Comment: The commenters express opposition to the renewal of the licenses for Turkey Point Unit Nos. 3 and 4 due to concerns about global climate change and rising sea levels.
Comments: (0090-1 [Von Barga, Donna], 0093-1 [Graffagnino, Mary Ann and Frank], 0134-1 [Hall, Gilbert], 0146-1 [Bard, Brenda])

Response: The NRC staff's analysis of changes in the environment related to climate change are presented in Section 4.15.3.2 and Section 4.16 of the SEIS. These sections present the NRC staff's evaluation of the potential changes in impacts that may occur as a result of the changes to the environment resulting from global climate change including sea level rise. The changes that were considered include potential changes in temperature, rainfall, and occurrence of severe weather events. The effects of sea level rise were also considered in this analysis. These comments did not provide any specific information, and no changes were made to the SEIS in response to these comments.

A.2.21 Support of License Renewal

Comment: The commenter expresses support for FPL and for Turkey Point Unit Nos. 3 and 4.

Comment: (0001-2-1 [Black, Kerry])

Response: This comment is general in nature and provides no specific information. No changes were made to the SEIS as a result of this comment.

A.2.22 Outside Scope-Aging Management

Comment: Several commenters expressed concern about aging components at Turkey Point or the ability to effectively manage aging during the period of extended operation.

Comments: (0024-1 [List, Gary], 0024-2 [List, Gary], 0026-1 [Gurtner, David], 0029-1 [Lukowski Stasa], 0035-1 [Kuttner, Paula])

Response: The NRC staff conducts both an environmental review and a safety review of each license renewal application. The staff's safety review is conducted in accordance with 10 CFR Part 54, and the results of the staff's evaluation are documented in a safety evaluation report issued separately from this SEIS. Operational safety issues related to the management of aging structures, systems, and components are outside the scope of the environmental review conducted under 10 CFR Part 51. In order to be granted renewed licenses, FPL must demonstrate that aging effects will be adequately managed such that the intended functions of the systems, structures, and components within the scope of license renewal will be maintained consistent with the current licensing basis for the period of extended operation. Pursuant to 10 CFR Part 54, the NRC staff conducted a review of the licensee's aging management programs within the scope of license renewal. The results of this review are documented in a safety evaluation report separate from this SEIS. The NRC staff did not revise the SEIS based on these comments.

A.2.23 Outside Scope-Energy Costs

Comment: The commenter suggests that there is not an economic need to continue operating Turkey Point Units 3 and 4 to generate power.

Comment: (0128-2 [Miller, Jane])

Response: *The purpose and need for NRC's proposed action is to provide an option to continue plant operations beyond the current licensing term to meet future system generating needs, as such needs may be determined by State, utility, system, and, where authorized, Federal (other than NRC) decisionmakers. The NRC does not make decisions or recommendations regarding the need for power at nuclear power plants. The regulatory authority over licensee economics (including the need for power) falls within the jurisdiction of the States and, to some extent, within the jurisdiction of the Federal Energy Regulatory Commission. No changes were made to the SEIS as a result of this comment.*

A.2.24 Outside Scope-Safety Concerns

Comment: Several commenters expressed concern about the safety impacts of external events and natural hazards, primarily sea level rise, storm surge, and hurricanes, on Turkey Point Unit Nos. 3 and 4.

Comments: (0001-4-4 [Pierce, Barbara], 0002-2-4 [Gutierrez, Vivian], 0012-1 [Salomon, Lynne], 0015-1 [Robinson Ford, Florence], 0020-6 [Gomez, Albert], 0058-1 [Villablanca, Judith], 0062-1 [Ortman, Nancy], 0064-1 [Makofske, William], 0067-1 [Aldrich, Johnnie], 0076-2 [Wesolowski, Pam], 0080-1 [King, Christian], 0091-1 [Wright, Steven], 0119-1 [Laslie, Maude], 0148-1 [McFall, Cynthia], 0150-1 [Manganello, Marilyn])

Response: *The NRC staff conducts both an environmental review and a safety review of each license renewal application. The staff's safety review is conducted in accordance with 10 CFR Part 54, and the results of the staff's evaluation are documented in a safety evaluation report issued separately from this SEIS. In addition, the NRC addresses potential hazards to safe operation of a nuclear power plant, including external hazards, through its ongoing oversight of operating licenses. Such oversight will continue during the term of any renewed license.*

The NRC staff's review of the subsequent license renewal application takes into consideration external hazards, such as hurricanes, storm surge, and rising sea levels, in two ways. First, the risks from external hazards were considered as part of the NRC staff's review of FPL's Severe Accident Mitigation Alternatives (SAMA) analysis, which FPL performed for the initial license renewal of Turkey Point Units 3 and 4. For subsequent license renewal, the NRC staff considered new and potentially significant information related to SAMAs in Appendix E of the SEIS. SAMAs are potential ways to reduce the risk or potential impacts of highly unlikely, but potentially severe accidents. As stated in Appendix E of the SEIS, the NRC staff's review concluded that there is no new and significant information regarding any potentially cost-beneficial SAMA that would substantially reduce the risks of a severe accident at Turkey Point.

Comments related to the impacts of continued plant operation on the surrounding environment, such as potential environmental releases from the CCS, are within the scope of the environmental review (e.g., surface water hydrology and climate change) and are evaluated in

Chapters 3 and 4 of the SEIS. No changes were made to the SEIS as a result of these comments.

A.2.25 Outside Scope-Other Non-License Renewal Actions

Comment: Several commenters addressed the NPDES permit to be issued by FDEP as delegated by the EPA.

Comments: (0001-14-8 [Rippingille, Bonnie], 0006-2 [Gould, Kyle], 0024-8 [List, Gary])

Response: *The NRC has regulatory authority over civilian uses of nuclear materials. The NRC does not license or regulate alternative sources of energy and cannot require licensees to employ any energy source. The NPDES permit is issued by FDEP as delegated by the EPA. The NRC does not review or approve NPDES permits. However, the NRC considered the NPDES permit requirements in the evaluation of the environmental impacts of license renewal. These comments did not provide any new information, and no change was made to the SEIS as a result of these comments.*

A.2.26 Outside Scope-Other Topics

Comment: The commenters address topics such as the use of fossil fuels for non-energy uses, mistrust of the NRC to oversee licensing, business practices of FPL, and a general lack of trust in humans to preserve the environment.

Comments: (0002-6-10 [Rippingille, Bonnie], 0055-1 [Block, Emily], 0066-1 [Jimenez, Nathan], 0140-1 [Dunn, Leslene])

Response: *These topics are outside the scope of the NRC staff's environmental review and do not provide specific information related to the environmental effects of the proposed action. The NRC staff did not revise the SEIS based on these comments.*

Comment: The commenter expresses concern about reactor design and safety.

Comment: (0054-1 [Blazier, Thomas])

Response: *This comment is outside the scope of the environmental review. Reactor design and safety issues are addressed in the NRC's safety review, which is conducted separately from the environmental review. The comment did not provide any new information, and the NRC staff did not revise the SEIS based on this comment.*

APPENDIX B

APPLICABLE LAWS, REGULATIONS, AND OTHER REQUIREMENTS

A number of Federal laws and regulations affect environmental protection, health, safety, compliance, and consultation at every NRC-licensed nuclear power plant. Some of these laws and regulations require permits from or consultations with other Federal agencies or State, Tribal, or local governments. Certain Federal environmental requirements have been delegated to State authorities for enforcement and implementation. Furthermore, States have also enacted their own laws to protect public health and safety and the environment. It is the NRC's policy to make sure nuclear power plants are operated in a manner that provides adequate protection of public health and safety and protection of the environment through compliance with applicable Federal and State laws, regulations, and other requirements.

The Atomic Energy Act of 1954, as amended (42 U.S.C. 2011 et seq.) (AEA), authorizes the NRC to enter into an agreement with any State that allows the State to assume regulatory authority for certain activities (see 42 U.S.C. 2021). Florida has been an NRC Agreement State since 1964, and the Bureau of Radiation Control within the Florida Department of Health has regulatory responsibility over the radioactive materials program as it is carried out under the AEA Section 274b Agreement between the NRC and the State of Florida (FDOH 2018b).

In addition to carrying out some Federal programs, State legislatures develop their own laws. State statutes can supplement, as well as implement, Federal laws for protection of air, surface water, and groundwater. State legislation may address solid waste management programs, locally rare or endangered species, and historic and cultural resources.

The U.S. Environmental Protection Agency (EPA) has the primary responsibility to administer the Federal Water Pollution Control Act (33 U.S.C. 1251 et seq., herein referred to as the Clean Water Act (CWA)). The National Pollutant Discharge Elimination System (NPDES) program addresses water pollution by regulating the discharge of potential pollutants to waters of the United States. EPA allows for primary enforcement and administration through State agencies, as long as the State program is at least as stringent as the Federal program.

The EPA has delegated the authority to issue NPDES permits to the State of Florida. The Florida Department of Environmental Protection (FDEP) provides oversight for public water supplies, issues permits to regulate the discharge of industrial and municipal wastewaters—including discharges to groundwater—and monitors State water resources for water quality. The FDEP issues NPDES permits to regulate and control water pollutants.

B.1 Federal and State Requirements

Turkey Point Nuclear Generating Unit Nos. 3 and 4 (Turkey Point, or Turkey Point Units 3 and 4) is subject to various Federal and State requirements. Table B-1 lists the principal Federal and State regulations and laws that are used or mentioned in this supplemental environmental impact statement (SEIS) for Turkey Point.

Table B-1 Federal and State Requirements

Law/regulation	Requirements
Current operating license and subsequent license renewal	
Atomic Energy Act, 42 U.S.C. 2011 et seq.	The Atomic Energy Act of 1954, as amended (AEA), and the Energy Reorganization Act of 1974, as amended (42 U.S.C. 5801 et seq.), give the NRC the licensing and regulatory authority for commercial nuclear energy use. They allow the NRC to establish dose and concentration limits for protection of workers and the public for activities under NRC jurisdiction. The NRC implements its responsibilities under the AEA through regulations set forth in Title 10, "Energy," of the <i>Code of Federal Regulations</i> (10 CFR).
10 CFR Part 2	Regulations in 10 CFR Part 2, "Agency Rules of Practice and Procedure," govern the conduct of all proceedings (other than export and import licensing proceedings) for: (a) granting, suspending, revoking, amending, or taking other action with respect to any license, construction permit, or application to transfer a license, (b) issuing orders and demands for information to persons subject to the Commission's jurisdiction, including licensees and persons not licensed by the Commission, (c) imposing civil penalties under AEA Section 234, (d) rulemaking under the AEA and the Administrative Procedure Act, and (e) standard design approvals under 10 CFR Part 52.
10 CFR Part 20	Regulations in 10 CFR Part 20, "Standards for Protection Against Radiation," establish standards for protection against ionizing radiation resulting from activities conducted under licenses issued by the NRC. These regulations are issued under the AEA and the Energy Reorganization Act of 1974, as amended. The purpose of these regulations is to control the receipt, possession, use, transfer, and disposal of licensed material by any licensee in such a manner that the total dose to an individual (including doses resulting from licensed and unlicensed radioactive material and from radiation sources other than background radiation) does not exceed the standards for protection against radiation prescribed in 10 CFR Part 20.
10 CFR Part 50	Regulations in 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities," provide for the licensing of production and utilization facilities, including power reactors.
10 CFR Part 51	Regulations in 10 CFR Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions," implement Section 102(2) of the National Environmental Policy Act of 1969, as amended (NEPA).
10 CFR Part 54	Regulations in 10 CFR Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants," govern the issuance of renewed operating licenses and renewed combined licenses for nuclear power plants licensed pursuant to Sections 103 or 104b of the AEA, as amended, and Title II of the Energy Reorganization Act of 1974. The regulations focus on managing adverse effects of aging and are intended to ensure that important systems, structures, and components will continue to perform their intended functions during the period of extended operation.
10 CFR Part 100	Regulations in 10 CFR Part 100, "Reactor Site Criteria," establish approval requirements for proposed sites for stationary power and testing reactors.

Law/regulation	Requirements
National Environmental Policy Act of 1969, as amended, 42 U.S.C. 4321 et seq. (NEPA)	NEPA requires Federal agencies to integrate environmental values into their decisionmaking process by considering the environmental impacts of proposed Federal actions and reasonable alternatives to those actions. NEPA establishes policy and sets goals (in Section 101) and provides means for carrying out the policy and goals (in Section 102). NEPA Section 102(2) contains action-forcing provisions to ensure that Federal agencies follow the letter and spirit of the act. For major Federal actions significantly affecting the quality of the human environment, Section 102(2)(C) of the act requires Federal agencies to prepare a detailed statement that includes the environmental impacts of the proposed action and other specified information.
40 CFR Part 50	Regulations in 40 CFR Part 50, "National Primary and Secondary Ambient Air Quality Standards," establish the following: (1) national primary ambient air quality standards that define levels of air quality which the EPA judges are necessary to protect the public health and (2) national secondary ambient air quality standards that define levels of air quality which the EPA judges necessary to protect the public welfare from any known or anticipated adverse effects of a pollutant.
40 CFR Part 51	Regulations in 40 CFR Part 51, "Requirements for Preparation, Adoption, and Submittal of Implementation Plans," include § 51.308, "Regional haze program requirements" (referred to as the Regional Haze Rule), which establishes requirements for implementation plans, plan revisions, and periodic progress reviews to address regional haze.
40 CFR Part 60	Regulations in 40 CFR Part 60, "Standards of Performance for New Stationary Sources," contain emissions guidelines and standards of performance for new stationary sources.
40 CFR Part 63	Regulations in 40 CFR Part 63, "National Emission Standards for Hazardous Air Pollutants for Source Categories," contain national emission standards for hazardous air pollutants (NESHAP) established pursuant to Section 112 of the Clean Air Act, that regulate specific categories of stationary sources that emit (or have the potential to emit) one or more hazardous air pollutants listed in this part.
40 CFR Part 81	Regulations in 40 CFR Part 81, "Designation of Areas for Air Quality Planning Purposes," designate Air Quality Control Regions (Subpart B), list the standards attainment status by state areas (Subpart C), and identify Mandatory Class I Federal Areas Where Visibility is an Important Value (Subpart D).
40 CFR Part 110	Regulations in 40 CFR Part 110, "Discharge of Oil," establish regulations applicable to the discharge of oil prohibited by Section 311(b)(3) of the CWA.
40 CFR Part 112	Regulations in 40 CFR Part 112, "Oil Pollution Prevention," establish procedures, methods, equipment, and other requirements to prevent the discharge of oil from non-transportation-related onshore and offshore facilities into or upon the navigable waters of the United States or adjoining shorelines.
40 CFR Part 125	Regulations in 40 CFR Part 125, "Criteria and Standards for the National Pollutant Discharge Elimination System," establish criteria and standards for the imposition of technology-based treatment requirements in permits under Section 301(b) of the CWA, including the application of EPA-promulgated effluent limitations and case-by-case determinations of effluent limitations under Section 402(a)(1) of the CWA.
40 CFR Part 131	Regulations in 40 CFR Part 131, "Water Quality Standards," contain requirements and procedures for developing, reviewing, revising, and approving water quality standards by the States as authorized by Section 303(c) of the CWA.

Law/regulation	Requirements
40 CFR Part 141	Regulations in 40 CFR Part 141, "National Primary Drinking Water Regulations," establish primary drinking water regulations pursuant to Section 1412 of the Public Health Service Act, as amended by the Safe Drinking Water Act.
40 CFR Part 143	Regulations in 40 CFR Part 143, "National Secondary Drinking Water Regulations," establish National Secondary Drinking Water Regulations pursuant to Section 1412 of the Safe Drinking Water Act.
40 CFR Part 190	Regulations in 40 CFR Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operations," establish limits for radiation dose equivalent to the public and the total quantity of radioactive materials entering the environment from the entire uranium fuel cycle.

Air quality protection

Clean Air Act, 42 U.S.C. 7401 et seq.	<p>The Clean Air Act (CAA) is intended to "protect and enhance the quality of the Nation's air resources so as to promote the public health and welfare and the productive capacity of its population." The CAA establishes regulations to ensure maintenance of air quality standards and authorizes individual States to manage permits.</p> <p>Section 109 of the CAA directs the U.S. Environmental Protection Agency (EPA) to set National Ambient Air Quality Standards (NAAQS) for criteria pollutants. The EPA has identified and set NAAQS for the following criteria pollutants: particulate matter, sulfur dioxide, carbon monoxide, ozone, nitrogen dioxide, and lead. Section 111 of the CAA requires the establishment of national performance standards for new or modified stationary sources of atmospheric pollutants. Section 161 of the CAA requires that specific emission increases must be evaluated before permit approval to prevent significant deterioration of air quality. Section 112 requires specific standards for release of hazardous air pollutants (including radionuclides). These standards are implemented through plans developed by each State and approved by the EPA. The CAA requires sources to meet standards and obtain permits to satisfy those standards.</p> <p>Nuclear power plants may be required to comply with the CAA Title V, Sections 501–507, for sources subject to new source performance standards or sources subject to National Emission Standards for Hazardous Air Pollutants. EPA regulates the emissions of air pollutants using 40 CFR Parts 50 to 99.</p>
---	--

Law/regulation	Requirements
Water resources protection	
Clean Water Act, 33 U.S.C. 1251 et seq., and the National Pollutant Discharge Elimination System (NPDES) (40 CFR Part 122)	<p>The Clean Water Act (CWA) was enacted to “restore and maintain the chemical, physical, and biological integrity of the Nation’s waters.” As authorized by the CWA, the National Pollutant Discharge Elimination System (NPDES) permit program controls water pollution by regulating point sources that discharge pollutants into waters of the United States.</p> <p>The NPDES program requires all facilities that discharge pollutants from any point source into waters of the United States to obtain an NPDES permit. A nuclear power plant may also participate in the NPDES General Permit for Industrial Stormwater due to stormwater runoff from industrial or commercial facilities to waters of the United States. EPA is authorized under the CWA to directly implement the NPDES program; however, EPA has authorized many States to implement all or parts of the national program. Section 401 of the CWA requires applicants for federal permits or licenses for a facility that may discharge into navigable waters to provide a certification from the State that the permitted discharge would comply with all limitations necessary to meet established State water quality standards, treatment standards, or schedule of compliance.</p> <p>The U.S. Army Corps of Engineers (USACE) is the lead agency for enforcement of CWA wetland requirements (33 CFR Part 320, “General Regulatory Policies”). Under Section 401 of the CWA, the EPA or a delegated State agency has the authority to review and approve, condition, or deny all permits or licenses that might result in a discharge to waters of the State, including wetlands.</p>
Coastal Zone Management Act of 1972, as amended, 16 U.S.C. 1451 et seq.	Congress enacted the Coastal Zone Management Act (CZMA) in 1972 to address the increasing pressures of over-development upon the Nation’s coastal resources. The National Oceanic and Atmospheric Administration administers the Act. The CZMA encourages States to preserve, protect, develop, and, where possible, restore or enhance valuable natural coastal resources such as wetlands, floodplains, estuaries, beaches, dunes, barrier islands, and coral reefs, as well as the fish and wildlife using those habitats. Participation by States is voluntary. To encourage States to participate, the CZMA makes Federal financial assistance available to any coastal State or territory, including those on the Great Lakes, as long as the State or territory is willing to develop and implement a comprehensive coastal management program.
FAC 62-296	Florida Administrative Code Rule 62-296, “Stationary Sources—Emission Standards,” establishes emission limiting standards and compliance requirements for stationary sources of air pollutant emissions.
FAC 62-520	Florida Administrative Code Rule 62-520, “Ground Water Classes, Standards, and Exemptions,” establishes water quality standards to protect designated beneficial uses of all ground waters of the State of Florida.
FAC 62-528	Florida Administrative Code Rule 62-528, “Underground Injection Control,” establishes provisions to protect the quality of the State’s underground sources of drinking water and to prevent degradation of the quality of other aquifers adjacent to the injection zone that may be used for other purposes.
Fla. Stat. § 258.397	Florida Statute Section 258.397, “Biscayne Bay Aquatic Preserve,” designates Biscayne Bay in Miami-Dade and Monroe Counties (including Card Sound) as an aquatic preserve under the provisions of Florida Statutes Title XVIII, “Public Lands and Property,” to be preserved in an essentially natural condition so that its biological and aesthetic values may endure for the enjoyment of future generations.

Law/regulation	Requirements
Wild and Scenic Rivers Act, 16 U.S.C. 1271 et seq.	The Wild and Scenic Rivers Act created the National Wild and Scenic Rivers System, which was established to protect the environmental values of free-flowing streams from degradation by impacting activities, including water resources projects.
Waste management and pollution prevention	
Resource Conservation and Recovery Act, 42 U.S.C. 6901 et seq.	The Resource Conservation and Recovery Act (RCRA) requires the EPA to define and identify hazardous waste; requires the EPA to establish standards for its transportation, treatment, storage, and disposal; and requires permits for persons engaged in hazardous waste activities. Section 3006, "Authorized State Hazardous Waste Programs" (42 U.S.C. 6926), allows States to establish and administer these permit programs with EPA approval. EPA regulations implementing the RCRA are found in 40 CFR Parts 260 through 282. Regulations imposed on a generator or on a treatment, storage, and/or disposal facility vary according to the type and quantity of material or waste generated, treated, stored, or disposed. The method of treatment, storage, or disposal also impacts the extent and complexity of the requirements.
Pollution Prevention Act, 42 U.S.C. 13101 et seq.	The Pollution Prevention Act establishes a national policy for waste management and pollution control that focuses first on source reduction, then on environmental issues, safe recycling, treatment, and disposal.
Protected species and habitats	
Endangered Species Act, 16 U.S.C. 1531 et seq.	The Endangered Species Act (ESA) was enacted to prevent the further decline of endangered and threatened species and to restore those species and their critical habitats. Section 7, "Interagency Cooperation," of the Act requires Federal agencies to consult with the U.S. Fish and Wildlife Service (FWS) or the National Marine Fisheries Service (NMFS) on Federal actions that may affect listed species or designated critical habitats.
50 CFR Part 17	Regulations in 50 CFR Part 17, "Endangered and Threatened Wildlife and Plants," implement the ESA.
50 CFR Part 402	Regulations in 50 CFR Part 402, "Interagency Cooperation - Endangered Species Act of 1973, as Amended," interpret and implement Sections 7(a)-(d) of the ESA regarding endangered or threatened species of fish, wildlife, or plants ("listed species") and habitats of such species that have been designated as critical ("critical habitat").
Magnuson–Stevens Fishery Conservation and Management Act, 16 U.S.C. 1801–1884	The Magnuson–Stevens Fishery Conservation and Management Act, as amended, governs marine fisheries management in U.S. Federal waters. This Act created eight regional fishery management councils and includes measures to rebuild overfished fisheries, protect essential fish habitat, and reduce bycatch. Under Section 305 of this Act, Federal agencies are required to consult with the National Marine Fisheries Service for any Federal actions that may adversely affect essential fish habitat.
National Marine Sanctuaries Act, 16 U.S.C. 1431 et seq.	The National Marine Sanctuaries Act of 1966, as amended, protects nationally significant aquatic and marine resources. Under the Act, Congress may delegate areas as marine sanctuaries, and the National Oceanic and Atmospheric Administration administers and manages such sanctuaries, often in cooperation with the State. Under Section 304(d) of this Act, Federal agencies are required to consult with the National Oceanic and Atmospheric Administration for any Federal action that is likely to destroy, cause the loss of, or injure any sanctuary resources.

Law/regulation	Requirements
FAC 68A-27	Florida Administrative Code Rule 68A-27, "Rules Relating to Endangered or Threatened Species," establishes provisions to conserve or improve the status of endangered and threatened species in Florida.
Historic preservation and cultural resources	
National Historic Preservation Act, 16 U.S.C. 470 et seq.	The National Historic Preservation Act was enacted to create a national historic preservation program, including the National Register of Historic Places and the Advisory Council on Historic Preservation (ACHP). Section 106 of this Act requires Federal agencies to take into account the effects of their undertakings on historic properties. The ACHP regulations implementing Section 106 of the Act are found in 36 CFR Part 800, "Protection of Historic Properties."
36 CFR Part 60	Regulations in 36 CFR Part 60, "National Register of Historic Places," establish procedural requirements for listing properties on the National Register of Historic Places.
36 CFR Part 800	Regulations in 36 CFR Part 800, "Protection of Historic Properties," establish provisions for public involvement in the National Historic Preservation Act Section 106 consultation process, including involvement from Indian tribes and other interested members of the public, as applicable.

B.2 Operating Permits and Other Requirements

Table B-2 lists the permits and licenses issued by Federal, State, and local authorities for activities at Turkey Point, as identified in Chapter 9 of Florida Power & Light Company's environmental report submitted as part of its subsequent license renewal application.

Table B-2 Federal, State, and Local Permits and Other Requirements

Permit	Responsible Agency	Number	Expiration Date	Authorized Activity
Federal Authorizations				
Authorization to export waste	Southeast Compact Commission	None	Updated annually	Export of LLRW outside the region
General license for storage of spent fuel at power reactor sites	NRC	General permit	N/A	Storage of power reactor spent fuel and other associated radioactive materials in an ISFSI
Licensing of nuclear power plant	NRC	DPR-31	7/19/2032	Operation of Unit 3
Licensing of nuclear power plant	NRC	DPR-41	4/10/2033	Operation of Unit 4
Consent decree	U.S. District Court	70-328-CA	N/A	IWW Construction, Operation, and Maintenance
Registration	U.S. Department of Transportation	060911 551 091T	None	Hazardous materials shipments

Permit	Responsible Agency	Number	Expiration Date	Authorized Activity
Section 401/404 permit; Submerged lands permit	U.S. Army Corps of Engineers (USACE) & Florida Department of Environmental Protection (FDEP)	SAJ-2016-02462 (USACE); 13-0127512-013 (FDEP)	5/7/2023 (USACE); 9/20/2021 (FDEP)	Discharge of dredge and fill materials into waters of the U.S. (Turtle Point and Barge Terminal) and use of state-owned submerged lands
NPDES permit - Industrial Waste Water facility (IWW) (cooling canals)	FDEP	FL0001562	May 2010 (administratively continued thereafter); draft permit issued 12/27/2018	Operation of IWW (cooling canals)
Hazardous waste generator number	USACE & FDEP	FLR000192922	N/A	Small Quantity Hazardous Waste Generator
Endangered species permit to take American crocodile during monitoring	U.S. Fish and Wildlife Service (FWS)	TE092945-2	4/20/2018 (renewal in progress)	Provides authorization to take (capture, examine, weigh, sex, collect tissue samples, mark, radio-tag, radio-track, relocate, release) threatened American crocodile individuals during population monitoring
Effects of operation on the threatened American crocodile	USFWS	41420-2006-FA-0478; 41420-2006-F-0125	N/A	Plan to minimize the potential adverse effects of ongoing operations of PTN to the American crocodile
Migratory bird special purpose utility permit	USFWS	MB697722-0	3/31/2021	Authorizes utilities to collect, transport and temporarily possess migratory birds found dead on utility property, structures, and ROWs for avian mortality monitoring or disposal purposes
State of Florida Authorizations				
Power plant site certification	FDEP Siting Board	PA 03-45E	Final conditions of certification issued 3/29/2016	Certification of Turkey Point site, initiated by PTN uprate. Provides for CZMA certification confirmation and CWA 401 certification

Permit	Responsible Agency	Number	Expiration Date	Authorized Activity
Power plant site certification	South Florida Water Management District (SFWMD)	N/A	N/A	Implementation of new monitoring plan that includes groundwater, surface water, and ecological monitoring in and around the Turkey Point CCS
Operation of Recovery Well System consumptive use permit	SFWMD	13-06251-W	2/27/2029	Use of Recovery Well System to extract hypersaline plume
Certification of state water quality standards	FDEP	PA 03-45E	Final conditions of certification issued 3/29/2016	Discharges during license renewal term
Operation of Class V, Group 3 domestic wastewater injection (gravity flow) well	FDEP	0355186-001-UO/5W	Issued 1/25/2023	Operation of IW-1
Operation of domestic wastewater treatment facility	FDEP	FLA013612-005-DW3P	9/27/2020	Operation of PTN wastewater treatment facility
Annual storage tank registration	FDEP	Facility ID: 8622249 Placard No.: 110600	Annual renewal	Operation of above-ground storage tanks
Annual storage tank registration	FDEP	Facility ID: 8622251 Placard No.: 110599	Annual renewal	Operation of above-ground storage tanks
Title V operations permit	FDEP	025003-028-AV	4/26/2023	Operation of facilities that generate air emissions
Underground injection control permit, injection well and monitoring well	FDEP	29392-004-UO/1I	7/12/2023	Disposal of extracted hypersaline water
Operation of freshening wells	FDEP	PA 03-45E	Final conditions of certification issued 3/29/2016	Withdrawal of groundwater for freshening of the IWW
Migratory bird nest removal	Florida Fish and Wildlife Conservation Commission (FFWCC)	LSNR-11-00026D	12/31/2020	Authorization to remove and replace inactive nests of migratory birds
Scientific collection permit	FFWCC	LSSC-11-00021B	12/31/2019	Scientific collection for avian species
Special purpose permit	FFWCC	SPGS-14-35	4/10/2019	Capture, hold and relocate American alligators

Permit	Responsible Agency	Number	Expiration Date	Authorized Activity
Burn permit	Florida Department of Agriculture and Consumer Service	1373498	No expiration	Authorization for open fires
Other States' Authorizations				
Revision of existing general site access permit	Utah Department of Environmental Quality Division of Radiation Control	None	Annual authorization	Transport of radioactive materials into the State of Utah
Revision of existing Tennessee radioactive waste license for delivery	Tennessee Department of Environment and Conservation Division of Radiological Health	None	Annual authorization	Transport of radioactive waste into the State of Tennessee
Local Authorizations				
Stratospheric ozone protection annual operations permit	Miami-Dade County, Department of Environmental Resources Management (MDC DERM)	APCF-001747-2018/2019	June 30, 2019 Annual renewal	Use of refrigerants R-134A, R-22, R 410A, R-502 for Robinair Recovery Units, Models 25200, 25200B and 34700Z.
Industrial waste annual operations permit	MDC DERM	IW-000003-2018/2019	May 31, 2019 Annual renewal	Oil and water separators and hazardous waste storage and used oil containment areas
Domestic wastewater annual operating permit	MDC DERM	DWO-000010-2018/2019	April 14, 2019 Annual renewal	Stabilization treatment facility
IW5 permit (or waiver)	MDC DERM	IW-000016-2018/2019	May 31, 2019 Annual renewal	Water treatment units, oil drum and compressed gasses storage, and vehicle refueling station
Research permit on MDC DERM environmentally endangered lands	MDC DERM	2011	Under agency review	Authorization to conduct ecological monitoring on county-owned environmentally endangered lands

Permit	Responsible Agency	Number	Expiration Date	Authorized Activity
Operation of pollution control facility permit	MDC DERM	IW5-006229-2018/2019	April 30, 2019	Operation of fleet vehicle maintenance facility that generates waste oil, coolant, and used batteries with a solvent wash tank and served by septic tank

Source: FPL 2019a

APPENDIX C CONSULTATION CORRESPONDENCE

C.1 Endangered Species Act Section 7 Consultation

As a Federal agency, the U.S. Nuclear Regulatory Commission (NRC) must comply with the Endangered Species Act of 1973, as amended (16 United States Code (U.S.C.) Section 1531 et seq.) (ESA), as part of any action authorized, funded, or carried out by the agency. In this case, the proposed agency action is whether to issue subsequent renewed licenses for the continued operation of Turkey Point Nuclear Generating Unit Nos. 3 and 4 (Turkey Point, or Turkey Point Units 3 and 4), which would authorize operation for an additional 20 years beyond the end of the current renewed license terms. Under Section 7, “Interagency Cooperation,” of the ESA, the NRC must consult with the U.S. Fish and Wildlife Service (FWS) and the National Marine Fisheries Service (NMFS) (referred to jointly as “the Services” and individually as “Service”), as appropriate, to ensure that the proposed agency action is not likely to jeopardize the continued existence of any endangered or threatened species or result in the destruction or adverse modification of designated critical habitat.

C.1.1 Federal Agency Obligations under Section 7 of the Endangered Species Act

The ESA and the regulations that implement Section 7 of the ESA (Title 50, “Wildlife and Fisheries,” of the *Code of Federal Regulations* (50 CFR) Part 402, “Interagency Cooperation—Endangered Species Act of 1973, as Amended”) describe the consultation process that Federal agencies must follow in support of agency actions. As part of this process, the Federal agency shall either request that the Services (1) provide a list of any listed or proposed species or designated or proposed critical habitats that may be present in the action area or (2) request that the Services concur with a list of species and critical habitats that the Federal agency has created (50 CFR 402.12(c), “Request for Information”). If any such species or critical habitats may be present, the Federal agency prepares a biological assessment to evaluate the potential effects of the action on the species or critical habitat and to determine whether the species or critical habitat are likely to be adversely affected by the action (50 CFR 402.12(a), “Purpose”; 16 U.S.C. 1536(c)). Biological assessments are required for any agency action that is a “major construction activity” (50 CFR 402.12(b), “Preparation Requirement”), which is defined as a construction project or other undertaking having construction-type impacts that is a major Federal action significantly affecting the quality of the human environment under the National Environmental Policy Act of 1969, as amended (42 U.S.C. 4321 et seq.) (NEPA) (51 FR 19926). Federal agencies may fulfill their obligations to consult with the Services under ESA Section 7 and to prepare a biological assessment, if required, in conjunction with the interagency cooperation procedures required by other statutes, including NEPA (50 CFR 402.06(a)). In such cases, the Federal agency should include the results of the ESA Section 7 consultation in the NEPA document (50 CFR 402.06(b)).

C.1.2 Biological Assessment

Subsequent license renewal does not require the preparation of a biological assessment because it is not a major construction activity. However, the NRC staff prepared a biological assessment (NRC 2018n) to evaluate the potential impacts of Turkey Point subsequent license renewal on the American crocodile (*Crocodylus acutus*), eastern indigo snake (*Drymarchon corais couperi*), and other species under the FWS’s jurisdiction as well as designated critical habitat for the American crocodile and the West Indian manatee (*Trichechus manatus*). The

staff included a summary of the results of the biological assessment in Section 4.8.1.1, “Federally Listed Species and Critical Habitats Protected Under the Endangered Species Act,” of this supplemental environmental impact statement (SEIS). Additionally, this SEIS includes an evaluation of the potential impacts to federally listed species and critical habitats under the NMFS’s jurisdiction to support the NRC’s ESA effect determinations for listed species and critical habitats that may occur in the action area. The staff did not prepare a separate biological assessment for species under the NMFS’s jurisdiction due to the limited number of listed species and the minimal potential effects on these species. Section 4.8.1.1 of this SEIS contains the NRC staff’s assessment of impacts to NMFS-listed species.

The NRC staff structured its evaluations of the impacts to both FWS- and NMFS-listed species in accordance with the Services’ suggested biological assessment contents described at 50 CFR 402.12(f), “Contents.” Within Section 3.8, “Special Status Species and Habitats,” of this SEIS and Sections 4.0 through 6.0 of the biological assessment, the NRC staff describes the action area as well as the federally listed and proposed species and designated and proposed critical habitats potentially present in the action area. These sections include information pursuant to 50 CFR 402.12(f)(1), (2), and (3). Section 4.8, “Special Status Species and Habitats,” of this SEIS and Sections 4.0 through 7.0 of the biological assessment provide an assessment of the potential effects of the proposed Turkey Point subsequent license renewal on the species and critical habitats present. These sections also contain the NRC’s ESA effect determinations, which are consistent with the conclusions described in Section 3.5 of the *Endangered Species Consultation Handbook* (FWS and NMFS 1998). Finally, Section 4.8 of this SEIS and Section 8.0 of the biological assessment address cumulative effects and alternatives to the proposed action pursuant to 50 CFR 402.12(f)(4) and (5).

C.1.3 Chronology of Endangered Species Act Section 7 Consultation

Endangered Species Act Section 7 Consultation with the U.S. Fish and Wildlife Service

During its review of the Turkey Point subsequent license renewal application, the NRC staff considered whether any federally listed, proposed, or candidate species or proposed or designated critical habitats may be present in the action area (as defined at 50 CFR 402.02, “Definitions”) for the proposed action. With respect to species under the FWS’s jurisdiction, the FWS identified 46 federally listed species, as well as designated critical habitat for two of those species, that have the potential to occur in the vicinity of the action area in a letter to the NRC dated December 14, 2018 (FWS 2018b). In Section 3.8 of this SEIS and Enclosure 1 of the biological assessment (NRC 2018n), the NRC staff concludes that 25 species would not occur in the action area because those species are extirpated from Miami-Dade County, are not known to occur within Miami-Dade County, or no suitable habitat occurs within the action area. In addition, two species are listed because of similarity of appearance to other listed species, and therefore, are not subject to ESA Section 7 consultation. The FWS and the NMFS have joint jurisdiction for four of the species; the proposed action would have no effect on the portions of the life cycle that are under the FWS’s jurisdiction for these species (NRC 2018g). The NRC staff evaluates the impacts to the remaining 15 species and designated critical habitat for two of those species in Sections 4.0 and 5.0 of the biological assessment. Section 4.8 of this SEIS contains a summary of the staff’s findings, in which the staff modified some of the findings in its biological assessment in consultation with the FWS. The staff concludes that the proposed subsequent license renewal may affect, but is not likely to adversely affect, four species and that the proposed subsequent license renewal is likely to adversely affect the American crocodile and the eastern indigo snake. The staff also concludes that the proposed subsequent license renewal is not likely to adversely modify designated critical habitat for the West Indian

manatee but may adversely modify designated critical habitat for the American crocodile. The NRC staff determined that the proposed license renewal would have no effect on the remaining listed species. No other listed, proposed, or candidate species or proposed or designated critical habitats under FWS jurisdiction occur in the action area.

Following completion of its biological assessment, the NRC staff (2018o) submitted its assessment to the FWS for review on December 19, 2018. In the accompanying letter, the NRC staff requested to initiate formal consultation under 50 CFR 402.14 for the American crocodile and eastern indigo snake, and the staff requested the FWS's concurrence with the NRC staff's "may affect, but is not likely to adversely affect" determinations for other federally listed species in accordance with 50 CFR 402.12(j).

On February 25, 2019, the NRC staff and the FWS (2019a) held a teleconference to discuss the NRC staff's effect determinations for certain federally listed species. On February 26, 2019, the NRC staff (2019c) revised its impact determinations from "may affect, but is not likely to adversely affect" to "no effect" for the following species: Florida bonneted bat (*Eumops floridanus*), piping plover (*Charadrius melodus*), Everglades snail kite (*Rostrhamus sociabilis*), Kirtland's warbler (*Setophaga kirtlandi*), Blodgett's silverbush (*Argythamnia blodgettii*), Cape Sable thoroughwort (*Chromolaena frustrata*), Florida semaphore cactus (*Consolea corallicola*), sand flax (*Linum arenicola*), and Florida bristle fern (*Trichomanes punctatum* ssp. *floridanum*).

On April 4, 2019, the NRC staff (2019i) and the FWS held a teleconference to discuss the status of the consultation. On April 18, 2019, Florida Power & Light Company (FPL) submitted comments on the NRC staff's biological assessment (FPL 2019d). On May 14, 2019, the NRC staff (2019j) provided the FWS with corrected and updated information concerning crocodile injuries and mortalities at the Turkey Point site. On May 24, 2019, the NRC staff (2019k) and the FWS held a teleconference to discuss the discovery of a dead eastern indigo snake on the Turkey Point site.

Consultation between the NRC staff and the FWS continued until the FWS (2019b) issued a new biological opinion for Turkey Point on July 25, 2019. The FWS (2019b) concluded in the biological opinion that the continued operation of Turkey Point through the duration of the proposed subsequent license renewal period (i.e., through July 19, 2052, for Unit 3 and through April 10, 2053, for Unit 4) is not likely to jeopardize the continued existence of the American crocodile or eastern indigo snake and will not adversely modify the critical habitat of the American crocodile. The biological opinion includes an Incidental Take Statement that applies to the American crocodile and eastern indigo snake during continued operation of Turkey Point. Section 4.8.1.1, "Federally Listed Species and Critical Habitats Protected Under the Endangered Species Act," of the SEIS describes the Incidental Take Statement, as well as the Reasonable and Prudent Measures and Terms and Conditions that implement it. The biological opinion's Terms and Conditions are nondiscretionary and must be undertaken by the NRC so that they become binding conditions of the renewed licenses, if granted, for the exemption in Section 7(o)(2) of the ESA to apply. In the biological opinion, the FWS also concurred with the NRC staff's "may affect, but is not likely to adversely affect" determinations for the Florida panther (*Puma concolor coryi*), West Indian manatee (*Trichechus manatus*), red knot (*Caladris rufa*), and wood stork (*Mycteria americana*). Finally, the FWS concurred in the biological opinion with the staff's "no adverse modification" determination for designated critical habitat of the West Indian manatee, as clarified in an email dated August 16, 2019 (FWS 2019c). Table 4-4, "Effect Determinations for Federally Listed Species Under U.S. Fish and Wildlife Service Jurisdiction" in this SEIS lists the NRC effect determinations and FWS conclusions for each of the federally listed species and designated critical habitats.

The FWS's issuance of the July 25, 2019, biological opinion concluded ESA Section 7 consultation for the proposed Turkey Point subsequent license renewal. Accordingly, the NRC has fulfilled its obligations under Section 7(a)(2) of the ESA with respect to the proposed Turkey Point license renewal for federally listed species and critical habitats under the jurisdiction of the FWS.

Endangered Species Act Section 7 Consultation with the National Marine Fisheries Service

During its review of the Turkey Point subsequent license renewal application, the NRC staff considered whether any federally listed, proposed, or candidate species or proposed or designated critical habitats may be present in the action area (as defined at 50 CFR 402.02, "Definitions") for the proposed action. With respect to species under the NMFS's jurisdiction, the NMFS identified federally listed species that have the potential to occur in the vicinity of the Turkey Point site in a letter to the NRC dated April 26, 2017 (NMFS 2017). The species are loggerhead sea turtle (*Caretta caretta*), green sea turtle (*Chelonia mydas*), leatherback sea turtle (*Dermochelys coriacea*), hawksbill sea turtle (*Eretmochelys imbricata*), Kemp's ridley sea turtle (*Lepidochelys kempii*) and smalltooth sawfish (*Pristis pectinata*). The NRC staff evaluated the potential impacts to these species in Section 3.8 and Section 4.8 of this SEIS. The staff concludes that the proposed subsequent license renewal may affect, but is not likely to adversely affect these species. No other NMFS listed, proposed, or candidate species or proposed or designated critical habitats occur in the action area.

On April 1, 2019, the NRC staff (2019d) submitted a copy of the draft SEIS to the NMFS for review accompanied by a request for the NMFS to concur with the staff's ESA effect determinations in accordance with 40 CFR 402.12(j). On April 30, 2019, the NRC staff (2019f) and NMFS staff met to discuss the consultation. On May 3, 2019, the NMFS (2019) requested additional information from the NRC staff to support its review of the proposed action, and on June 6, 2019, the NRC staff (2019g) responded to these requests. Consultation between the NRC staff and the NMFS continues at this time. The results of this consultation will be reported in the NRC's Record of Decision for the proposed Turkey Point subsequent license renewal.

C.2 Essential Fish Habitat Consultation

The Magnuson–Stevens Fishery Conservation and Management Act, as amended (16 U.S.C. 1801–1884), requires Federal agencies to consult with the NMFS with respect to any action authorized, funded, or undertaken, or proposed to be authorized, funded, or undertaken that may adversely affect any Essential Fish Habitat identified under the Act.

In Sections 3.8 and 4.8 of this SEIS, the NRC staff concludes that although the NMFS has designated Essential Fish Habitat (EFH) for a number of federally managed species within Biscayne Bay, neither EFH nor the species themselves occur in the CCS or on the Turkey Point site because there are no surface water connections between the CCS and any natural waterbodies, and that the proposed Turkey Point subsequent license renewal would not result in any impacts to EFH. Accordingly, the NRC is not required under the Act to consult with the NMFS for the proposed action. In correspondence dated April 1, 2019, the NRC staff (2019e) notified the NMFS of its EFH findings and the NRC staff's determination that EFH consultation is not required for the proposed action. The NMFS provided no specific response concerning EFH. The NRC staff therefore considers the NRC's obligations related to EFH consultation under the provisions of the Magnuson–Stevens Act to be fulfilled with respect to the proposed Turkey Point subsequent license renewal.

C.3 National Marine Sanctuaries Act Consultation

he National Marine Sanctuaries Act of 1966, as amended (16 U.S.C. 1431 et seq.) authorizes the Secretary of Commerce to designate and protect areas of the marine environment with special national significance due to their conservation, recreational, ecological, historical, scientific, cultural, archeological, educational or aesthetic qualities as national marine sanctuaries. Under Section 304(d) of the Act, Federal agencies must consult with the National Oceanic and Atmospheric Administration's (NOAA) Office of National Marine Sanctuaries if a Federal action is likely to destroy, cause the loss of, or injure any sanctuary resources.

In Sections 3.8 and 4.8 of the SEIS, the NRC staff concludes that although Congress has designated the Florida Keys National Marine Sanctuary, which includes waters surrounding the Florida Keys from south of Miami westward and encompassing the Dry Tortugas, the proposed Turkey Point subsequent license renewal would not affect the sanctuary resources of this national marine sanctuary for several reasons. First, currently available monitoring data do not indicate any discernable impact of Turkey Point Units 3 and 4 or the CCS on the ecology of surrounding marsh and mangrove areas, Biscayne Bay, Card Sound, or any other nearby surface waters to date. Second, FPL's continued implementation of its 2016 Consent Order with the Florida Department of Environmental Protection and 2015 Consent Agreement with the Miami-Dade County Department of Environmental Resources will ensure that any potential future impacts of the CCS will be mitigated such that constituents originating from the CCS will not discernably affect the ecology of nearby surface waters over the course of the proposed subsequent license renewal term. Groundwater monitoring results do indicate that water from the CCS has migrated via the groundwater pathway through the deeper interval of the Biscayne aquifer and to the east beneath Biscayne Bay and Card Sound. However, CCS-sourced constituents, which consist of elevated chloride and tritium, have had no effect on surface water quality in Biscayne Bay and Card Sound. At no location outside the boundary of the Turkey Point site do tritium levels in groundwater approach the U.S. Environmental Protection Agency and State primary drinking water standard for tritium of 20,000 pCi/L (40 CFR 141.66). Accordingly, the NRC is not required to consult under the National Marine Sanctuaries Act for the proposed action because the proposed action is not likely to destroy, cause the loss of, or injure any sanctuary resources. The NRC staff therefore considers the NRC's obligations related to consultation under Section 304(d) of the National Marine Sanctuaries Act to be fulfilled with respect to the proposed Turkey Point subsequent license renewal.

C.4 National Historic Preservation Act Section 106 Consultation

The National Historic Preservation Act of 1966, as amended (16 U.S.C. 470 et seq.) (NHPA), requires Federal agencies to take into account the effects of their undertakings on historic properties and consult with applicable State and Federal agencies, Tribal groups, individuals, and organizations with a demonstrated interest in the undertaking before taking action. Historic properties are defined as resources that are eligible for listing on the National Register of Historic Places (NRHP). The historic preservation review process (Section 106 of the NHPA) is outlined in regulations issued by the Advisory Council on Historic Preservation (ACHP) in 36 CFR Part 800, "Protection of Historic Properties." In accordance with 36 CFR 800.8(c), "Use of the NEPA Process for Section 106 Purposes," the NRC has elected to use the NEPA process to comply with its obligations under Section 106 of the NHPA.

Table C-1 lists the chronology of consultation and consultation documents related to the NRC's NHPA Section 106 review of the Turkey Point subsequent license renewal. The NRC staff is

required to consult with the noted agencies and organizations in accordance with the statute and regulations listed in the previous paragraph.

Table C-1 National Historic Preservation Act Correspondence

Date	Sender and Recipient	Description	ADAMS Accession No. ^(a)
May 24, 2018	B. Beasley (NRC) to B. Cypress, Miccosukee Tribe of Indians of Florida	Request for scoping comments/notification of Section 106 review	ML18114A381
May 24, 2018	B. Beasley (NRC) to J. Floyd, Muscogee (Creek) Nation	Request for scoping comments/notification of Section 106 review	ML18114A381
May 24, 2018	B. Beasley (NRC) to S.A. Bryan, Poarch Band of Creek Indians	Request for scoping comments/notification of Section 106 review	ML18114A381
May 24, 2018	B. Beasley (NRC) to G. Chilcoat, Seminole Nation of Oklahoma	Request for scoping comments/notification of Section 106 review	ML18114A381
May 24, 2018	B. Beasley (NRC) to M.W. Osceola, Seminole Tribe of Florida	Request for scoping comments/notification of Section 106 review	ML18114A381
May 24, 2018	B. Beasley (NRC) to T. Parsons, Florida Department of State, Division of Historical Resources	Request for scoping comments/notification of Section 106 review	ML18114A206
May 24, 2018	B. Beasley (NRC) to S. Cody, Miami-Dade County Office of Historic Preservation	Request for scoping comments/notification of Section 106 review	ML18114A204
May 24, 2018	B. Beasley (NRC) to R. Nelson, Advisory Council on Historic Preservation	Request for scoping comments/notification of Section 106 review	ML18114A202
June 12, 2018	T. Isham, Seminole Nation of Oklahoma to N. Martinez (NRC)	Request for Section 106 consultation meetings	ML18169A152
June 26, 2018	T.A. Parsons, Florida Department of State to M. Ma (NRC)	Response to request for scoping comments/notification of Section 106 review	ML18183A482
July 3, 2018	V. Menchaca, Seminole Tribe of Florida to J. Borges Roman (NRC)	Response to request for scoping comments/notification of Section 106 review	ML18184A462
July 19, 2018	N. Martinez (NRC) to B. Beasley (NRC)	Summary of teleconference between the NRC and the Seminole Nation of Oklahoma	ML18190A179
April 3, 2019	K. Erwin (NRC) to B. Cypress, Miccosukee Tribe of Indians of Florida	Notice of availability of the draft for comment of the supplemental environmental impact	ML19066A303

Date	Sender and Recipient	Description	ADAMS Accession No. ^(a)
		statement for subsequent license renewal	
April 3, 2019	K. Erwin (NRC) to J. Floyd, Muscogee (Creek) Nation	Notice of availability of the draft for comment of the supplemental environmental impact statement for subsequent license renewal	ML19066A303
April 3, 2019	K. Erwin (NRC) to S.A. Bryan, Poarch Band of Creek Indians	Notice of availability of the draft for comment of the supplemental environmental impact statement for subsequent license renewal	ML19066A303
April 3, 2019	K. Erwin (NRC) to G. Chilcoat, Seminole Nation of Oklahoma	Notice of availability of the draft for comment of the supplemental environmental impact statement for subsequent license renewal	ML19066A303
April 3, 2019	K. Erwin (NRC) to M.W. Osceola, Seminole Tribe of Florida	Notice of availability of the draft for comment of the supplemental environmental impact statement for subsequent license renewal	ML19066A303
April 3, 2019	K. Erwin (NRC) to T. Parsons, Florida Department of State, Division of Historical Resources	Notice of availability of the draft for comment of the supplemental environmental impact statement for subsequent license renewal	ML19066A302
April 3, 2019	K. Erwin (NRC) to S. Cody, Miami-Dade County Office of Historic Preservation	Notice of availability of the draft for comment of the supplemental environmental impact statement for subsequent license renewal	ML19066A300
April 3, 2019	K. Erwin (NRC) to R. Nelson, Advisory Council on Historic Preservation	Notice of availability of the draft for comment of the supplemental environmental impact statement for subsequent license renewal	ML19066A301
April 22, 2019	C. Lowe-Zepeda (Muscogee Nation) to N. Martinez (NRC)	Defer to other tribes contacted	ML19119A185
April 22, 2019	L. Haikey (Poarch Band of Creek Indians) to N. Martinez (NRC)	Concur with the determination of no effect	ML19128A270

Date	Sender and Recipient	Description	ADAMS Accession No. ^(a)
May 15, 2019	L. Haikey (Poarch Band of Creek Indians) to K. Erwin (NRC)	Concur with the determination of no effect	ML19168A194
May 22, 2019	J. Aldridge (Florida Department of State, Division of Historical Resources) to N. Martinez (NRC)	Concur license renewal will not adversely affect any known historic properties	ML19143A207

^(a) Access these documents through the NRC's Agencywide Documents Access and Management System (ADAMS) at <http://adams.nrc.gov/wba/>.

APPENDIX D

CHRONOLOGY OF ENVIRONMENTAL REVIEW CORRESPONDENCE

This appendix contains a chronological listing of correspondence between the U.S. Nuclear Regulatory Commission (NRC) and external parties as part of the agency’s environmental review of the Turkey Point Nuclear Generating Unit Nos. 3 & 4 (Turkey Point, or Turkey Point Units 3 and 4) subsequent license renewal application. This appendix does not include consultation correspondence or comments received during the scoping process. For a list and discussion of consultation correspondence, see Appendix C, “Consultation Correspondence,” of this supplemental environmental impact statement (SEIS). For scoping comments, see Appendix A, “Comments Received on the Turkey Point Nuclear Generating Units 3 and 4 Environmental Review,” of this SEIS and the NRC’s scoping summary report (NRC 2019). All documents are available electronically from the NRC’s Public Electronic Reading Room found at: <http://www.nrc.gov/reading-rm.html>. From this site, the public can gain access to ADAMS, which provides text and image files of the NRC’s public documents. The ADAMS accession number for each document is included in the following table.

D.1 Environmental Review Correspondence

Table D-1 lists the environmental review correspondence, by date, beginning with the request by Florida Power & Light Company (FPL) for subsequent license renewal of the operating licenses for Turkey Point Units 3 and 4.

Table D-1 Environmental Review Correspondence

Date	Correspondence Description	ADAMS Accession No.
January 30, 2018	Turkey Point Units 3 and 4—Submittal of Subsequent License Renewal Application	ML18037A812
February 9, 2018	Turkey Point Units 3 and 4 License Renewal Application—Supplement 1	ML18044A653
February 16, 2018	Turkey Point, Units 3 and 4, Subsequent License Renewal Application—Supplement 2	ML18053A123
March 1, 2018	Turkey Point Units 3 and 4, Subsequent License Renewal Application—Supplement 3	ML18072A224
March 22, 2018	Press Release 18-009: NRC Makes Available First Subsequent License Renewal Application from Turkey Point Nuclear Power Plant	ML18085A035
April 10, 2018	Turkey Point, Units 3 and 4, Subsequent License Renewal Application Appendix E Environmental Report Supplemental Information	ML18102A521
April 10, 2018	Turkey Point Units 3 and 4—Transmittal of Subsequent License Renewal Application, Revision 1	ML18113A132
April 12, 2018	Turkey Point Nuclear Generating Units 3 and 4—Status of Subsequent License Renewal Application (EPID No. L-2018-RNW-0002)	ML18074A252
April 13, 2018	Receipt and Availability of the Subsequent License Renewal Application for the Turkey Point Nuclear Generating Units 3 and 4	ML17338A141

Date	Correspondence Description	ADAMS Accession No.
April 25, 2018	Turkey Point Nuclear Generating Units 3 and 4, Subsequent License Renewal Application Online Reference Portal (EPID No. L-2018-RNW-002)	ML17360A054
April 26, 2018	Determination of Acceptability and Sufficiency for Docketing, Proposed Review Schedule, and Opportunity for a Hearing Regarding the Application from FPL for Subsequent Renewal of the Turkey Point Units 3 and 4 (CAC Nos. MF9747 and MF9747)	ML18003A050
May 3, 2018	Press Release 18-014: NRC Accepts Application for Subsequent License Renewal of Turkey Point Reactors	ML18124A078
May 14, 2018	Notice of Intent to Prepare an Environmental Impact Statement and Conduct Scoping Process for Turkey Point Nuclear Plant Units 3 and 4	ML18109A516
May 22, 2018	Press Release 18-019: Corrected—NRC To Hold Meeting on Environmental Review for Turkey Point Subsequent License Renewal	ML18145A064
May 25, 2018	05/31/2018 Public Scoping Meeting for the Environmental Review of the Subsequent License Renewal Application for Turkey Point Units 3 and 4	ML18145A201
June 13, 2018	License Renewal Environmental Site Audit Regarding the Turkey Point Nuclear Generating Units 3 and 4 Subsequent License Renewal Application (EPID No. L-2018-LNE-0001).	ML18158A335
June 22, 2018	Letter from the National Park Service (S. Craighead), to the NRC pertaining to the Turkey Point, Units 3 and 4 Subsequent License Renewal	ML18193B074
July 3, 2018	Turkey Point Nuclear Generating Units 3 and 4—In-Office Regulatory Audit Plan Regarding Severe Accident Mitigation Alternatives in the Subsequent License Renewal Application Review (EPID No. L-2018-LNE-0001)	ML18178A152
July 9, 2018	Requests for Additional Information for the Environmental review of the Turkey Point Subsequent License Renewal Application (EPID No. L-2018-LNE-0001)	ML18190A499
July 17, 2018	Requests for Additional Information for the Environmental Review of the Turkey Point Subsequent License Renewal Application—Set 2 (EPID No. L-2018-LNE-0001)	ML18198A274
July 20, 2018	Summary of the Site Environmental Audit Related to the Review of the Subsequent License Renewal Application for Turkey Point Nuclear Generating Units 3 and 4 (EPID No. L-2018-LNE-0001)	ML18178A229
July 20, 2018	National Park Service Cooperating Agency Request for Subsequent License Renewal of Turkey Point Nuclear Generating Units 3 and 4 (EPID No. L-2018-LNE-0001)	ML18197A294
July 23, 2018	05/31/2018 Summary of Public Scoping Meeting for the Environmental Review of the Subsequent License Renewal Application for Turkey Point Units 3 and 4 (EPID No. L-2018-LNE-0001)	ML18176A403

Date	Correspondence Description	ADAMS Accession No.
August 8, 2018	Turkey Point Units 3 and 4 Subsequent License Renewal Application Environmental Report Requests for Additional Information (RAI) Responses	ML18247A507
August 17, 2018	Notice of Public Meeting—Turkey Point Subsequent License Renewal Application Review—Discussion of Responses to Two Environmental Requests for Additional Information—HC-7 and WR-2	ML18229A111
August 31, 2018	Turkey Point Nuclear Generating Units 3 and 4—Summary of the In-Office Regulatory Audit Regarding Severe Accident Mitigation Alternatives in the Subsequent License Renewal Application (EPID No. L-2018-LNE-0001)	ML18214A146
September 17, 2018	Requests for Additional Information for the Turkey Point Subsequent License Renewal Application—Environmental Set 3 (EPID No. L-2018-LNE-0001)	ML18248A158
September 18, 2018	08/28/2018 Summary of Meeting to Discuss Turkey Point Subsequent License Renewal Application Review - Discussion of Responses to Two Environmental Requests for Additional Information - HC-7 and WR-2 (EPID No. L-2018-LNE-0001)	ML18247A301
September 27, 2018	Teleconference Summary with NRC and FWS Re: Species under Joint NMFS and FWS Jurisdiction for Turkey Point Subsequent License Renewal	ML18270A154
October 5, 2018	Turkey Point, Units 3 and 4, Responses to Requests for Additional Information for Subsequent License Renewal Application Environmental Review	ML18283A882
November 11, 2018	11/13/2018 Telecon Between NRC and FPL to Discuss Items Associated with the Safety Review of the Turkey Point Subsequent License Renewal Application	ML18315A003
November 28, 2018	Turkey Point, Units 3 and 4, Supplemental Response to Request for Additional Information (RAI) Set 1, Subsequent License Renewal Application Environmental Review	ML18334A101
December 19, 2018	Letter to FWS transmitting Biological Assessment for the Turkey Point Units 3 and 4 Proposed Subsequent License Renewal	ML18344A008
December 26, 2018	06/18/18 Summary of Interagency Meeting Related to Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4	ML18360A445
January 2019	Environmental Scoping Summary Report Associated with the Staff's Review of the Turkey Point Nuclear Generating Units 3 and 4 Subsequent License Renewal Application (EPID No. L-2018-LNE-0001)	ML18342A014
March 5, 2019	Letter from National Parks Service to NRC providing comments on preliminary drafts of parts of Chapter 3 and Chapter 4 of Turkey Point Subsequent License Renewal Draft SEIS	ML19072A162

Date	Correspondence Description	ADAMS Accession No.
March 31, 2019	NUREG-1437, Supplement 5, Second Renewal, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants - Supplement 5, Second Renewal – Regarding Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4"	ML19078A330
April 1, 2019	Notice of Availability of the Draft Supplement 5, Second Renewal, to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding Turkey Point Nuclear Generating Unit Nos. 3 and 4	ML19007A022
April 1, 2019	Letter to Florida Power and Light: Notice of Availability of the Draft Supplement 5, Second Renewal, to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding Turkey Point Nuclear Generating Unit Nos. 3 and 4	ML19007A017
April 1, 2019	Turkey Point Units 3 and 4 Subsequent License Renewal Application -First Annual Update	ML19093A060
April 3, 2019	Letter from Florida Power and Light – Environmental Report Additional Information	ML19095B380
April 4, 2019	Press Release 19-018: NRC Seeks Public Comment on Draft Environmental Impact Statement for Turkey Point Subsequent License Renewal	ML19094A629
May 2, 2019	Letter from Florida Power and Light – Submittal of 2018 Annual Radiological Environmental Operating Report	ML19136A190
May 3, 2019	Schedule Revision for the Review of the Turkey Point Nuclear Generating Unit Nos. 3 and 4 Subsequent License Renewal Application	ML19123A220
May 9, 2019	Schedule Correction for the Review of the Turkey Point Nuclear Generating Unit Nos. 3 and 4 Subsequent License Renewal Application	ML19127A070
May 16, 2019	Letter from National Park Service – Comments on the Draft Supplemental Environmental Impact Statement	ML19143A166
May 20, 2019	Letter from the Environmental Protection Agency – Comments on the Supplemental Draft Environmental Impact Statement for the License Renewal of Turkey Point Nuclear Generating Units 3 and 4	ML19157A200
May 20, 2019	Letter from Florida Power and Light – Comments Regarding the Turkey Point Nuclear Generating Unit Nos. 3 and 4 Subsequent License Renewal Draft Supplement 5 Generic Environmental Impact Statement	ML19141A047
May 20, 2019	Letter from the U.S. Department of Commerce, National Oceanic and Atmospheric Administration, National Ocean Service, Florida Keys National Marine Sanctuary – Comments on Draft Supplemental Environmental Impact Statement for Turkey Point Nuclear Generating Unit Nos. 3 and 4 Subsequent License Renewal	ML19141A054

Date	Correspondence Description	ADAMS Accession No.
May 22, 2019	Summary of 5/1/19 Public Meetings To Receive Comments on the Turkey Point Units 3 and 4 Draft Supplemental Environmental Impact Statement for Florida Power and Light's Subsequent License Renewal Application	ML19148A471
July 15, 2019	Summary of Teleconference Between Nuclear Regulatory Commission and Florida Power & Light To Discuss the Current Status and Use of the L-31E Canal at Turkey Point Nuclear Generating Units 3 and 4	ML19197A171
July 22, 2019	Observations Regarding NPS and NOAA Comments on the Turkey Point Nuclear Generating Unit Nos. 3 and 4 Subsequent License Renewal Draft Supplement 5 Generic Environmental Impact Statement	ML19205A068

APPENDIX E

ENVIRONMENTAL IMPACTS OF POSTULATED ACCIDENTS

This section describes the environmental impacts from postulated accidents that may occur at Turkey Point Nuclear Generating Unit Nos. 3 and 4 (Turkey Point, or Turkey Point Units 3 and 4) during the subsequent license period. The term “accident” refers to any unintentional event outside the normal plant operational envelope that could result in either (a) an unplanned release of radioactive materials into the environment or (b) the potential for an unplanned release of radioactive materials into the environment. NUREG–1437, “Generic Environmental Impact Statement for License Renewal of Nuclear Plants” (GEIS) (NRC 1996, 2013a), evaluates in detail the following two classes of postulated accidents as they relate to license renewal:

- **Design-Basis Accidents:** Postulated accidents that a nuclear facility must be designed and built to withstand without loss to the systems, structures, and components necessary to ensure public health and safety.
- **Severe Accidents:** Postulated accidents that are more severe than design-basis accidents because they could result in substantial damage to the reactor core, whether or not there are serious off-site consequences.

This section first describes the evaluation of new and significant information as it relates to design-basis accidents, followed by an evaluation of new and significant information for severe accidents.

E.1 Background

Although this supplemental environmental impact statement documents the NRC staff’s review of a subsequent license renewal application, it is helpful to keep in mind that long before any license renewal actions, an operating reactor has already completed the NRC licensing process for the original 40-year operating license. To receive a license to operate a new nuclear power reactor, an applicant must submit to the NRC an operating license application that includes, among many other requirements, a safety analysis report. The applicant’s safety analysis report presents the design criteria and design information for the proposed reactor and includes comprehensive data on the proposed site. The applicant’s safety analysis report also describes various design-basis accidents and the safety features designed to prevent or mitigate their impacts. The NRC staff reviews the operating license application to determine if the plant’s design—including designs for preventing or mitigating accidents—meet the NRC’s regulations and requirements.

E.1.1 Design-Basis Accidents

Design-basis accidents are postulated accidents that a nuclear facility must be designed and built to withstand without loss to the systems, structures, and components necessary to ensure public health and safety. Planning for design-basis accidents ensures that the proposed plant can withstand normal transients (rapid changes in the reactor coolant system temperature or pressure, or rapid changes in reactor power), as well as a broad spectrum of postulated accidents without undue hazard to the health and safety of the public. Many of these design-basis accidents may occur, but are unlikely to occur even once during the life of the plant; nevertheless, carefully evaluating each design-basis accident is crucial to establishing the design basis for the preventive and mitigative safety systems of the proposed nuclear power

plant. Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50, “Domestic Licensing of Production and Utilization Facilities,” and 10 CFR Part 100, “Reactor Site Criteria,” describe the NRC’s acceptance criteria for design-basis accidents.

Before the NRC will issue an operating license for a new nuclear power plant, the applicant must demonstrate the ability of its proposed reactor to withstand all design-basis accidents. The applicant and the NRC staff evaluate the environmental impacts of design-basis accidents for the hypothetical maximum-exposed individual. The results of these evaluations of design-basis accidents are found in the reactor’s original licensing documents such as the applicant’s final safety analysis report, the NRC staff’s safety evaluation report, and the final environmental statement (FES). Once the NRC issues the operating license for the new reactor, the licensee is required to maintain the acceptable design and performance criteria (which includes withstanding design-basis accidents) throughout the operating life of the nuclear power plant, including any license renewal periods of extended operation. The consequences for these events are evaluated for the hypothetical maximum exposed individual; as such, changes in the plant environment will not affect these evaluations.

Pursuant to 10 CFR 54.29(a), license renewal applicants are required to manage the effects of aging and perform any required time-limited aging analyses (as further described in the regulation), such that there is reasonable assurance that the activities authorized by the renewed license will continue to be conducted in accordance with the plant’s current licensing basis (CLB) and any changes made to the plant’s CLB in order to comply with section 54.29 are in accordance with the Atomic Energy Act and the Commission’s regulations. In other words, because of the requirements that the existing design-basis and aging management programs be in effect for license renewal, the environmental impacts of design-basis accidents as calculated for the original operating license application should not differ significantly from the environmental impacts of design-basis accidents at any other time during plant operations, including during the initial license renewal and subsequent renewal periods. Accordingly, the design of the nuclear power plant, relative to design-basis accidents during the period of extended operation, is considered to remain acceptable.

E.1.2 Design-Basis Accidents and License Renewal

The early identification and resolution of the design-basis accidents (prior to subsequent license renewal) makes them a part of the current licensing basis (CLB) of the plant. The NRC requires licensees to maintain the CLB of the plant under the current operating license, as well as during any license renewal period. Therefore, under the provisions of 10 CFR 54.30, “Matters not Subject to a Renewal Review,” design-basis accidents are not subject to review under license renewal.

As stated in Section 5.3.2 of the 1996 GEIS, the environmental impact from design-basis accidents was assessed in the individual plant-specific EISs at the time of the initial license application review. Since the licensee is required to maintain the plant within acceptable design and performance criteria, including during any license renewal term, these environmental impacts are not expected to change significantly. Therefore, additional assessment of the environmental impacts from design-basis accidents is not necessary (NRC 2013a).

The GEIS concludes that the environmental impacts of design-basis accidents are of SMALL significance for all nuclear power plants, because the plants were designed to successfully withstand these accidents. For the purposes of initial or subsequent license renewal, the NRC designates design-basis accidents as a Category 1 generic issue—applicable to all nuclear

power plants (see 10 CFR Part 51, Subpart A, Appendix B, Table B-1, “Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants”). During the license renewal review process, the NRC staff adopts the applicable Category 1 issue conclusions from the GEIS (unless there exists new and significant information about the issue). Hence, the NRC staff need not address most Category 1 issues (like design-basis accidents) in the site-specific supplemental environmental impact statement for license renewal, in the absence of new and significant information pertinent to those issues.

In its environmental report for the Turkey Point subsequent license renewal application, Florida Power & Light Company (FPL) did not identify any new and significant information related to design-basis accidents at Turkey Point (FPL 2018f). The NRC staff also did not identify any new and significant information related to design-basis accidents during its independent review of FPL’s environmental report, through the scoping process, or in its evaluation of other available information. Therefore, the NRC staff concludes that there are no environmental impacts related to design-basis accidents at Turkey Point during the subsequent license renewal period beyond those already discussed generically for all nuclear power plants in the GEIS.

E.1.3 Severe Accidents

Severe accidents are postulated accidents that are more severe than design-basis accidents because severe accidents can result in substantial damage to the reactor core, whether or not there are serious offsite consequences. Severe accidents can entail multiple failures of equipment or function. The likelihood of a severe accident occurring is generally even lower than the likelihood of a design-basis accident occurring.

E.1.4 Severe Accidents and License Renewal

Chapter 5 of the 1996 GEIS (NUREG-1437) conservatively predicts the environmental impacts of postulated severe accidents that may occur during the period of extended operations at nuclear power plants. In the 2013 GEIS, the staff updated the NRC’s 1996 plant-by-plant severe accident environmental impact assessments (NRC 2013a, Appendix E). In the GEIS, the impacts of severe accidents that were considered include:

- dose and health effects of accidents
- economic impacts of accidents
- effect of uncertainties on the results

The NRC staff calculated these estimated impacts by studying the risk analysis of severe accidents as reported in the environmental impact statements (EISs) and/or final environmental statements that the NRC staff had prepared for each of the plants in support of their original reactor operating licenses. When the NRC staff prepared the 1996 GEIS, 28 nuclear power plant sites (44 units) had EISs or FESs that contained a severe accident analysis. Not all original operating reactor licenses contain a severe accident analysis since the NRC has not always required such analyses. The 1996 GEIS assessed the impacts of severe accidents during the license renewal period, using the results of existing analyses and site-specific information to conservatively predict the environmental impacts of severe accidents for all plants during the renewal period. With few exceptions, the severe accident analyses evaluated in the 1996 GEIS were limited to consideration of reactor accidents caused by internal events. The 1996 GEIS addressed the impacts from external events qualitatively.

For its severe accident environmental impact analysis for each plant, the 1996 GEIS used very conservative 95th percentile upper confidence bound estimates for environmental impact whenever available. This approach provides conservatism to cover uncertainties, as described in Section 5.3.3.2.2 of the 1996 GEIS. The 1996 GEIS concluded that the probability-weighted impacts of severe accidents as related to license renewal are small compared to other risks to which the populations surrounding nuclear power plants are routinely exposed. The NRC's understanding of severe accident risk has continued to evolve since it issued the 1996 GEIS. The updated 2013 GEIS assesses more recent information and developments in severe accident analyses and how they might affect the conclusions in Chapter 5 of the 1996 GEIS. The 2013 GEIS also provides comparative data where appropriate. Based on information in the 2013 GEIS, the NRC staff determined that for all nuclear power plants, the probability-weighted consequences of severe accidents are SMALL. However, the GEIS determined that alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives, as a Category 2 issue. See Table B-1, "Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants," of Appendix B to Subpart A of 10 CFR Part 51, which states:

The probability-weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to groundwater, and societal and economic impacts from severe accidents are SMALL for all plants. However, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives.

An analysis of severe accident mitigation alternatives was performed for Turkey Point at the time of initial license renewal. The staff documented its review in NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," Supplement 5, Regarding Turkey Point Nuclear Plant, Units 3 & 4. Any new and significant information that might alter the conclusions of that analysis was considered for subsequent license renewal, as discussed below.

E.2 Severe Accident Mitigation Alternatives

In a SAMA analysis, the NRC requires license renewal applicants to consider the environmental impacts of severe accidents, their probability of occurrence, and potential means available to mitigate those accidents. As quoted above, 10 CFR Part 51, Table B-1 states "alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives." This NRC requirement to consider alternatives to mitigate severe accidents can be fulfilled by a severe accident mitigation alternatives (SAMA) analysis. The purpose of the SAMA analysis is to identify design alternatives, procedural modifications, or training activities that may further reduce the risks of severe accidents at nuclear power plants and that are also potentially cost beneficial to implement. The SAMA analysis includes the identification and evaluation of SAMAs that may reduce the radiological risk from a severe accident by preventing substantial core damage (i.e., preventing a severe accident) or by limiting releases from containment in the event that substantial core damage occurs (i.e., mitigating the impacts of a severe accident) (NRC 2013b). The regulations at 10 CFR 51.53(c)(3)(ii)(L) state that each license renewal applicant must submit an environmental report that considers alternatives to mitigate severe accidents, "If the staff has not previously considered severe accident mitigation alternatives for the applicant's plant in an environmental impact statement or related supplement or in an environmental assessment."

E.2.1 Turkey Point Initial License Renewal Application and SAMA Analysis in 2000

As part of its initial license renewal application submitted in 2000, FPL's environmental report included an analysis of SAMAs for Turkey Point Units 3 and 4 (FPL 2000). FPL based this SAMA analysis on (1) the Turkey Point probabilistic safety assessment (PSA) for total accident frequency, core damage frequency (CDF), and containment large early release frequency (LERF), and (2) a supplemental analysis of offsite consequences and economic impacts for risk determination. The Turkey Point PSA included a Level 1 analysis to determine the CDF from internally initiated events and a Level 2 analysis to determine containment performance during severe accidents. The offsite consequences and economic impacts analyses used the MELCOR Accident Consequence Code System 2 (MACCS2) code, Version 1.2, to determine the offsite risk impacts on the surrounding environment and the public. Inputs for the latter analysis included plant/site-specific values for core radionuclide inventory, source term and release fractions, meteorological data, projected population distribution (based on 1990 census data, projected out to 2025), emergency response evacuation modeling, and economic data. To help identify and evaluate potential SAMAs, FPL considered insights and recommendations from SAMA analyses for other plants, potential plant improvements discussed in NRC and industry documents, and documented insights provided by Turkey Point staff.

In its 2000 environmental report, FPL considered 167 SAMAs. FPL then performed a qualitative screening of those SAMAs, eliminating SAMAs that were not applicable to Turkey Point or had already been implemented at Turkey Point (or the design met the intent of the SAMA). Based on this qualitative screening, 91 SAMAs were eliminated, leaving 76 subject to the final screening and evaluation process. Of the 91 SAMAs eliminated, 64 were eliminated because they had already been implemented at Turkey Point (or the design met the intent of the SAMA), while 27 SAMAs were eliminated because they were not applicable to Turkey Point. The 76 remaining SAMAs were listed in Table F.2-2 of Appendix F of the 2000 ER (FPL 2000). The final screening process involved identifying and eliminating those SAMAs whose cost exceeded twice their benefit. Ultimately, FPL concluded that there were no potentially cost-beneficial SAMAs associated with the initial Turkey Point license renewal (FPL 2000).

As part of the NRC staff's review of the initial Turkey Point license renewal application, the staff reviewed FPL's analysis of SAMAs for Turkey Point Units 3 and 4 and documented this review in its SEIS, which the NRC published in January 2002 as Supplement 5, "Regarding Turkey Point Nuclear Plant, Units 3 & 4," to NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (NRC 2002c). Chapter 5 of Supplement 5 to NUREG-1437 contains the NRC staff's evaluation of the potential environmental impacts of plant accidents and examines each SAMA (individually and, in some cases, in combination) to determine the SAMA's individual risk reduction potential. The NRC staff then compared this potential risk reduction against the cost of implementing the SAMA to quantify the SAMA's cost-benefit value.

In Section 5.2 of its 2002 SEIS for the initial Turkey Point license renewal (NUREG-1437, Supplement 5), the NRC staff found that FPL used a systematic and comprehensive process for identifying potential plant improvements for Turkey Point Units 3 and 4, and that its bases for calculating the risk reductions afforded by these plant improvements were reasonable and generally conservative. Further, the NRC staff found that FPL's estimates of the costs of implementing each SAMA were reasonable and consistent with estimates developed for other operating reactors. In addition, the NRC staff concluded that FPL's cost-benefit comparisons were performed appropriately. The NRC staff concluded that FPL's SAMA methods and implementation of those methods were sound, and it agreed with FPL's conclusion that none of

the candidate SAMAs were potentially cost beneficial based on conservative treatment of costs and benefits. The staff found FPL's conclusion consistent with the low residual level of risk indicated in the Turkey Point probabilistic safety assessment, and was also consistent with the fact that Turkey Point had already implemented many plant improvements identified during two risk analysis processes: (1) the individual plant examination or IPE (a risk analysis that considers the unique aspects of a particular nuclear power plant, identifying the specific vulnerabilities to severe accident of that plant) and (2) the individual plant examination for external events or IPEEE (a risk analysis that considers external events such as earthquakes, internal fires, and high winds) (NRC 2002c).

E.2.2 Turkey Point 2018 Subsequent License Renewal Application and New and Significant Information as it Relates to the Probability-Weighted Consequences of Severe Accidents

As mentioned above, a license renewal application must include an environmental report that describes SAMAs if the NRC staff has not previously evaluated SAMAs for that plant in an environmental impact statement (EIS), in a related supplement to an EIS, or in an environmental assessment. As also discussed above, the NRC staff performed a site-specific analysis of Turkey Point SAMAs in a supplement to an EIS (Supplement 5, "Regarding Turkey Point Nuclear Plant, Units 3 & 4," to NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants") (NRC 2002c). Therefore, in accordance with 10 CFR 51.53(c)(3)(ii)(L) and Table B-1 of Appendix B to Subpart A of 10 CFR Part 51, FPL is not required to provide another SAMA analysis in its environmental report for the Turkey Point subsequent license renewal application.

The NRC's regulations in 10 CFR Part 51, which implement Section 102(2) of the National Environmental Policy Act (NEPA), require that all applicants for license renewal submit an environmental report to the NRC, in which they identify any "new and significant information regarding the environmental impacts of license renewal of which the applicant is aware" (10 CFR 51.53(c)(3)(iv)). This includes new and significant information that could affect the environmental impacts related to postulated severe accidents or that could affect the results of a previous SAMA analysis. Accordingly, in its subsequent license renewal application environmental report, FPL evaluates areas of new and significant information that could affect the environmental impact of postulated severe accidents during the subsequent license renewal period of extended operation, and possible new and significant information as it relates to SAMAs.

In FPL's assessment of new and significant information related to SAMAs in its SLR application, FPL utilized guidance that was recently issued by the Nuclear Energy Institute (NEI), which the NRC staff has endorsed. As discussed in Section E-5 below, NEI developed a model approach for license renewal applicants to use in assessing the significance of new information of which the applicant is aware, that relates to a prior SAMA analysis that was performed in support of the issuance of an initial license, renewed license, or combined license (COL). This effort led to the publication of NEI 17-04, "Model SLR New and Significant Assessment Approach for SAMA, Rev. 0," on June 29, 2017 (NEI 2017). NEI 17-04 provides a tiered approach that entails a 3-stage screening process for the evaluation of new information. In this screening process, new information is deemed to be "potentially significant" to the extent that it results in the identification in Stage 1 (involving the use of PRA risk insights and/or risk model quantifications) of an unimplemented SAMA that reduces the maximum benefit by 50 percent or more. If a SAMA is found to result in a 50 percent reduction in maximum benefit in Stage 1, a Stage 2 assessment would then be performed (involving an updated averted cost-risk estimate for

implementing that SAMA). A Stage 3 assessment (involving a cost-benefit analysis) would be required only for “potentially significant” SAMAs, i.e., those that are shown by the Stage 2 assessment to reduce the maximum benefit by 50 percent or more. Finally, if the Stage 3 assessment shows that a “potentially significant” SAMA is “potentially cost-beneficial,” thus indicating the existence of “new and significant” information, then the applicant must supplement the previous SAMA analysis. The NRC endorsed NEI 17-04 for use by license renewal applicants on January 31, 2018 (NRC 2018m). FPL’s assessment of new and significant information related to its SAMA cost-benefit analysis is discussed in Section E.5 of this Appendix.

Below, the NRC staff summarizes FPL’s description of possible areas of new and significant information and assesses FPL’s conclusions.

E.3 Evaluation of New Information Concerning Severe Accident Consequences for Turkey Point as it relates to the GEIS and the 2002 Turkey Point SEIS.

The 2013 GEIS considers developments in plant operation and accident analysis that could have changed the assumptions made in the 1996 GEIS concerning severe accident consequences. The 2013 GEIS confirmed the determination in the 1996 GEIS that the probability-weighted consequences of severe accidents are small for all plants. In the 2013 GEIS, Appendix E provides the NRC staff’s evaluation of the environmental impacts of postulated accidents. Table E-19, “Summary of Conclusions,” shows the developments that the NRC staff considered as well as the staff’s conclusions. Consideration of the listed items was the basis for the NRC staff’s overall determination in the 2013 GEIS that the probability-weighted consequences of severe accidents remain small for all plants.

For subsequent license renewal for Turkey Point, the staff confirmed that there is no new and significant information that would change the 2013 GEIS or the 2002 Turkey Point SEIS conclusions on the consequences of severe accidents. The NRC staff evaluated FPL’s information related to the 2013 GEIS, Table E-19, “Summary of Conclusions,” during the onsite Turkey Point audit and by reviewing docketed information (NRC 2018c). The results of that review follow.

E.3.1 New Internal Events Information (Section E.3.1 of the 2013 GEIS)

After FPL submitted the Turkey Point initial license renewal application environmental report in 2000 and the NRC issued its corresponding SAMA review in its 2002 SEIS, there have been many improvements to Turkey Point’s risk profile. The Turkey Point internal events core damage frequency in the initial license renewal SAMA was approximately 1.6×10^{-5} /year. The current Turkey Point internal events probabilistic risk assessment (PRA) model of record has a core damage frequency of approximately 7.0×10^{-7} /year. This change represents a 96-percent reduction or a factor-of-23 reduction in core damage frequency for each unit. This substantial improvement in CDF makes any proposed new SAMA or previously evaluated SAMA less likely to be cost beneficial.

In the 2013 GEIS, the NRC staff reviewed the updated boiling-water reactor (BWR) and pressurized-water reactor (PWR) internal event core damage frequencies (CDFs). The CDF is an expression of the likelihood that, given the way a reactor is designed and operated, an accident could cause the fuel in the reactor to be damaged. The 2013 GEIS addresses new information on the risk and environmental impacts of severe accidents caused by internal events which had emerged following issuance of the 1996 GEIS and included consideration of

Turkey Point's plant-specific PRA analysis. The new information addressed in the 2013 GEIS indicates that PWR and BWR CDFs evaluated for the 2013 GEIS are generally comparable to or less than the CDFs that formed the basis of the 1996 GEIS (NRC 2013a).

Therefore, the NRC staff concludes that the offsite consequences of severe accidents initiated by internal events during the subsequent license renewal term would not exceed the impacts predicted in the 2013 GEIS. For these issues, the GEIS predicted that the impacts would be SMALL for all nuclear plants. The NRC staff identified no new and significant information regarding internal events during its review of FPL's environmental report, during the SAMA audit, through the scoping process, or through the evaluation of other available information. Thus, the NRC staff agrees with FPL's conclusion that no new and significant information exists for Turkey Point concerning offsite consequences of severe accidents initiated by internal events that would alter the conclusions reached in the 2013 GEIS or Turkey Point's previous SAMA analysis.

E.3.2 External Events (Section E.3.2 of the 2013 GEIS)

Section E.3.2.3 of the 2013 GEIS concludes that the CDFs from severe accidents initiated by external events, as quantified in NUREG-1150, "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants," (NRC 1990) and other sources, are comparable to CDFs from accidents initiated by internal events but lower than the CDFs that formed the basis for the 1996 GEIS. In the 2013 GEIS, the environmental impacts from externally initiated events are generally significantly lower—one or more orders of magnitude lower—than the environmental impacts from external events determined in the 1996 GEIS.

The 1996 GEIS concluded that severe accidents initiated by external events (such as earthquakes, floods, or fires) could have potentially high consequences but also found that the risks from these external events are adequately addressed through a consideration of severe accidents initiated by internal events (such as a loss of cooling water). Therefore, the 1996 GEIS concluded that an applicant for license renewal need only analyze the environmental impacts from an internal event to characterize the environmental impacts from either internal or external events.

External Events: Seismic

In 2014, FPL performed a bounding seismic evaluation for Turkey Point using appropriate seismic hazard curves and a plant-level fragility curve. This bounding seismic evaluation demonstrated that the seismic risk at Turkey Point is not significant. By letter dated January 22, 2016 (NRC 2016b), the NRC staff documented its review of FPL's Turkey Point reevaluated seismic hazard, also referred to as the mitigating strategies seismic hazard information. The staff confirmed FPL's conclusion that the Turkey Point reevaluated seismic hazard is bounded by the current design basis at all frequencies above 1 Hertz (Hz). In addition, in the staff's letter of June 16, 2016, the staff concluded that the FPL-determined ground motion response spectrum adequately characterizes the reevaluated seismic hazard for the Turkey Point site (NRC 2016b). For more detail, see the NRC staff's June 16, 2016 letter, "Turkey Point Nuclear Generating, Unit Nos. 3 And 4—Staff Review of Mitigation Strategies Assessment Report of the Impact of the Reevaluated Seismic Hazard Developed in Response to the March 12, 2012, [10 CFR] 50.54(F) Letter (CAC Nos. MF7886 and MF7887)" (NRC 2016c). Thus, the NRC staff agrees with FPL's statement in its 2018 environmental report for Turkey Point subsequent license renewal, that Turkey Point does not require an updated seismic probabilistic risk assessment for subsequent license renewal.

External Events: Fire

By letter dated May 28, 2015, the NRC approved amendments modifying the Turkey Point Units 3 and 4 operating licenses and technical specifications to incorporate a new fire protection licensing basis in accordance with 10 CFR 50.48(c), "Fire Protection." The amendments authorized the transition of Turkey Point's fire protection program to a risk-informed and performance-based program based on the 2001 edition of National Fire Protection Association Standard 805, "Performance-Based Standard for Fire Protection for Light Water Reactor Electric Generating Plants" (NRC 2015d]. FPL used the Fire PRA for consideration of the reduction in benefit for the fire-related SAMAs in the Turkey Point subsequent license renewal application environmental report.

In conclusion, there was a greater-than-a-factor-of-20 decrease in the Turkey Point internal events CDF and seismic risk for Turkey Point was determined to be insignificant. Therefore, the offsite consequences of severe accidents initiated by external events during the subsequent license renewal term would not exceed the impacts predicted in the GEIS. For these issues, the GEIS predicts that the impacts would be SMALL for all nuclear plants. The NRC staff identified no new and significant information regarding external events during its review of FPL's environmental report, through the SAMA audit, during the scoping process, or through the evaluation of other available information. Thus, the NRC staff agrees with FPL's conclusion that no new and significant information exists for Turkey Point concerning offsite consequences of severe accidents initiated by external events that would alter the conclusions reached in the 2013 GEIS or Turkey Point's previous SAMA analysis.

E.3.3 New Source Term Information (Section E.3.3 of the 2013 GEIS)

The source term refers to the magnitude and mix of the radionuclides released from the fuel (expressed as fractions of the fission product inventory in the fuel), as well as their physical and chemical form, and the timing of their release following an accident. The 2013 GEIS concludes that, in most cases, more recent estimates give significantly lower release frequencies and release fractions than was assumed in the 1996 GEIS. Thus, the environmental impacts of radioactive materials released during severe accidents, used as the basis for the 1996 GEIS (i.e., the frequency-weighted release consequences), are higher than the environmental impacts that would be estimated today using more recent source term information. The staff also notes that results from the NRC's State-of-the-Art Reactor Consequence Analysis (SOARCA) project (which represents a significant ongoing effort to re-quantify realistic severe accident source terms) confirm that source term timing and magnitude values calculated in the SOARCA reports are significantly lower than source term values quantified in previous studies. The NRC staff expects to incorporate the information gleaned from the SOARCA project in future revisions of the GEIS.

For the reasons described above, current source term timing and magnitude at Turkey Point is likely to be significantly lower than had been quantified in previous studies and the initial license renewal Turkey Point SAMA analysis in 2000. Therefore, the offsite consequences of severe accidents initiated with the new source term during the subsequent license renewal term would not exceed the impacts predicted in the GEIS. For these issues, the GEIS predicts that the impacts would be SMALL for all nuclear plants. The NRC staff identified no new and significant information regarding internal events during its review of FPL's environmental report, through the SAMA audit, during the scoping process, or through the evaluation of other available information. Thus, the NRC staff agrees with FPL's conclusion that no new and significant

information exists for Turkey Point concerning offsite consequences of severe accidents initiated by internal events that would alter the conclusions reached in the 2013 GEIS or Turkey Point's previous SAMA analysis.

E.3.4 Power Uprate Information (Section E.3.4 of the 2013 GEIS)

Operating at a higher reactor power level results in a larger fission product radionuclide inventory in the core than if the reactor were operating at a lower power level. In the event of an accident, the larger radionuclide inventory in the core would result in a larger source term. If the accident is severe, this larger source term could result in higher doses to offsite populations.

Large early release frequency (LERF) represents the frequency of sequences that result in early fatalities. The impact of a power uprate on early fatalities can be measured by considering the impact of the uprate on the LERF calculated value. To this end, Table E-14 of the 2013 GEIS presents the change in LERF calculated by each licensee that has been granted a power uprate of greater than 10 percent. As can be seen, the increase in LERF ranges from a minimal impact to an increase of about 30 percent (with a mean of 10.5 percent). The 2013 GEIS, Section E.3.4.3, "Conclusion," determines that power uprates will result in a small to (in some cases) moderate increase in the environmental impacts from a postulated accident. However, taken in combination with the other information presented in the GEIS, the increases would be bounded by the 95 percent upper confidence bound values in Table 5.10 and Table 5.11 of the 1996 GEIS.

In 2012, the NRC approved a 15 percent power uprate for Turkey Point, which included a 13 percent increase in core thermal power and a 1.7 percent measurement uncertainty recapture, from 2,300 megawatts thermal (MWt) to 2644 MWt. Before the extended power uprate, FPL calculated the Turkey Point Unit 4 internal events LERF to be 1.3×10^{-8} /year. After the extended power uprate, FPL conservatively projected the Unit 4 LERF to be 1.8×10^{-8} /year. This is a change of 4.3×10^{-9} /year, or an increase in LERF of about 32 percent. The NRC staff's safety evaluation for this extended power uprate at Turkey Point states that this increase in LERF falls within the acceptance guidelines for being "very small" (i.e., less than 1×10^{-7} per reactor year), set forth in Regulatory Guide (RG) 1.174, "An Approach for Using Probabilistic Risk Assessment In Risk Informed Decisions on Plant Specific Changes to the Licensing Basis," and therefore does not raise any concerns of adequate protection (NRC 2012). Accordingly, even though the change in LERF is slightly greater than 30 percent (upper percentage increase in LERF determined in the updated 2013 GEIS), the staff finds this change to be a very small impact due to the very small change in LERF as defined in RG 1.174.

In sum, the staff finds the conclusions of the 2013 GEIS on this topic appropriate for the Turkey Point subsequent license renewal application, considering that there was a "very small" (less than 1×10^{-7} per reactor year) change in LERF, the increases would be bounded by the 95 percent upper confidence bound values in Table 5.10 and Table 5.11 of the 1996 GEIS and Turkey Point had a greater-than-a-factor-of-20 decrease in the internal events CDF from the original SAMA to the subsequent license renewal application (which lowers the LERF). Therefore, the offsite consequences from the power uprate would not exceed the impacts predicted in the GEIS. For these issues, the GEIS predicted that the impacts would be SMALL to MODERATE for all nuclear plants. The NRC staff has identified no new and significant information regarding power uprates during its review of FPL's environmental report, through the SAMA audit, during the scoping process, or through the evaluation of other available information. Thus, the NRC staff agrees with FPL's conclusion that no new and significant

information exists for Turkey Point concerning offsite consequences due to power uprates that would alter the conclusions reached in the 2013 GEIS or Turkey Point's previous SAMA analysis.

E.3.5 Higher Fuel Burnup Information (Section E.3.5 of the 2013 GEIS)

According to the 2013 GEIS, increased peak fuel burnup from 42 to 75 gigawatt days per metric ton uranium (GWd/MTU) for PWRs, and 60 to 75 GWd/MTU for BWRs, results in small to moderate increases (up to 38 percent) in environmental impacts in the event of a severe accident. However, taken in combination with the other information presented in the 2013 GEIS, the increases would be bounded by the 95 percent upper confidence bound values in Table 5.10 and Table 5.11 of the 1996 GEIS.

FPL's environmental report, Section 2.2.1, "Reactor and Containment Systems," states that both Units 3 and 4 are licensed for fuel that is slightly enriched uranium dioxide (i.e., fuel that is up to 5 percent by weight uranium-235). FPL operates the reactors at an equilibrium core maximum fuel discharge burnup rate of 62 GWd/MTU (NRC 2018e). Therefore, the updated estimates of offsite consequences remained within the bounds of the 1996 GEIS evaluation (NRC 2013a).

Therefore, the offsite consequences from higher fuel burnup would not exceed the impacts predicted in the 2013 GEIS. For these issues, the GEIS predicted that the impacts would be SMALL for all nuclear plants. The NRC staff identified no new and significant information regarding higher fuel burnup during its review of FPL's environmental report, SAMA audit, the scoping process, or the evaluation of other available information. Thus, the staff agrees with FPL's conclusion that no new and significant information exists for Turkey Point concerning offsite consequences due to higher fuel burnup that would alter the conclusions reached in the 2013 GEIS or Turkey Point's previous SAMA analysis.

E.3.6 Low Power and Reactor Shutdown Event Information (Section E.3.6 of the 2013 GEIS)

The 2013 GEIS concludes that the environmental impacts from accidents at low-power and shutdown conditions are generally comparable to those from accidents at full power, based on a comparison of the values in NUREG/CR-6143, "Evaluation of Potential Severe Accidents During Low Power and Shutdown Operations at Grand Gulf, Unit 1," (NRC 1995a) and NUREG/CR-6144, "Evaluation of Potential Severe Accidents During Low Power and Shutdown Operations at Surry, Unit 1," (NRC 1995b), with the values in NUREG-1150, "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants" (NRC 1990). The 1996 GEIS estimates of the environmental impact of severe accidents bound the potential impacts from accidents at low power and shutdown, with margin. There are no plant configurations in low power and shutdown conditions that would distinguish Turkey Point from the evaluated plants such that the assumptions in the 2013 and 1996 GEISs would not apply.

Finally, as discussed in SECY-97-168, "Issuance for Public Comment of Proposed Rulemaking Package for Shutdown and Fuel Storage Pool Operation" (NRC 1997), industry initiatives taken during the early 1990s have also contributed to the improved safety of low-power and shutdown operations for all plants. Therefore, the offsite consequences of severe accidents, considering low-power and reactor shutdown events, would not exceed the impacts predicted in the 1996 or 2013 GEIS. For these issues, the GEIS predicts that the impacts would be SMALL for all nuclear plants. The NRC staff identified no new and significant information regarding low-power and reactor shutdown events during its review of FPL's environmental report, through the NRC

staff's SAMA audit, during the scoping process, or through the evaluation of other available information. Thus, the staff agrees with FPL's conclusion that no new and significant information exists for Turkey Point concerning low-power and reactor shutdown events that would alter the conclusions reached in the 2013 GEIS or Turkey Point's previous SAMA analysis.

E.3.7 Spent Fuel Pool Accident Information (Section E.3.7 of the 2013 GEIS)

The 2013 GEIS concludes that the environmental impacts from accidents involving spent fuel pools (as quantified in NUREG-1738, "Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants" (NRC 2001)), can be comparable to those from reactor accidents at full power (as estimated in NUREG-1150 (NRC 1990)). Subsequent analyses performed, and mitigative measures employed since 2001, have further lowered the risk of this class of accidents. In addition, even the conservative estimates from NUREG-1738 are much lower than the impacts from full power reactor accidents estimated in the 1996 GEIS. Therefore, the environmental impacts stated in the 1996 GEIS bound the impact from spent fuel pool accidents for all plants. For these issues, the GEIS predicts that the impacts would be SMALL for all nuclear plants. There are no spent fuel configurations that would distinguish Turkey Point from the evaluated plants such that the assumptions in the 2013 and 1996 GEISs would not apply. The NRC staff identified no new and significant information regarding spent fuel pool accidents during its review of FPL's environmental report, the SAMA audit, the scoping process, or the evaluation of other available information. Thus, the NRC staff agrees with FPL's conclusion that no new and significant information exists for Turkey Point concerning spent fuel pool accidents that would alter the conclusions reached in the 2013 GEIS or Turkey Point's previous SAMA analysis.

E.3.8 Use of Biological Effects of Ionizing Radiation (BEIR)-VII Risk Coefficients (Section E.3.8 of the 2013 GEIS)

In 2005, the NRC staff completed a review of the National Academy of Sciences report, "Health Risks from Exposure to Low Levels of Ionizing Radiation: Biological Effects of Ionizing Radiation (BEIR) VII, Phase 2" (BEIR VII 2005). The staff documented its findings in SECY-05-0202, "Staff Review of the National Academies Study of the Health Risks from Exposure to Low Levels of Ionizing Radiation (BEIR VII)" (NRC 2005a). The SECY paper states that the NRC staff agrees with the BEIR VII report's major conclusion—namely, the current scientific evidence is consistent with the hypothesis that there is a linear, no-threshold, dose response relationship between exposure to ionizing radiation and the development of cancer in humans. The BEIR VII conclusion is consistent with the hypothesis on radiation exposure and human cancer that the NRC uses to develop its standards of radiological protection. Therefore, the NRC staff has determined that the conclusions of the BEIR VII report do not warrant any change in the NRC's radiation protection standards and regulations, which are adequately protective of public health and safety and will continue to apply during Turkey Point's subsequent license renewal term. This general topic is discussed further in the NRC's 2007 denial of Petition for Rulemaking (PRM)-51-11, which found no need to modify the 1996 GEIS in light of the BEIR VII report. For these issues, the GEIS predicts that the impacts of using the BEIR VII Risk Coefficients would be SMALL for all nuclear plants.

The NRC staff has identified no new and significant information regarding the risk coefficient used in the BEIR VII report during its review of FPL's environmental report, the SAMA audit, the scoping process, or the evaluation of other available information. Thus, the staff concludes that

no new and significant information exists for Turkey Point concerning the biological effects of ionizing radiation that would alter the conclusions reached in the 2013 GEIS or Turkey Point's previous SAMA analysis.

E.3.9 Uncertainties (Section E.3.9 of the 2013 GEIS)

Section 5.3.3 in the 1996 GEIS provides a discussion of the uncertainties associated with the analysis in the GEIS and in the individual plant EISs used to estimate the environmental impacts of severe accidents. The 1996 GEIS used 95th percentile upper confidence bound estimates whenever available for its estimates of the environmental impacts of severe accidents. This approach provides conservatism to cover uncertainties, as described in Section 5.3.3.2.2 of the 1996 GEIS. Many of these same uncertainties also apply to the analysis used in the 2013 GEIS update. As discussed in Sections E.3.1 through E.3.8 of the 2013 GEIS, the GEIS update used more recent information to supplement the estimate of environmental impacts contained in the 1996 GEIS. In effect, the assessments contained in Sections E.3.1 through E.3.8 of the 2013 GEIS provided additional information and insights into certain areas of uncertainty associated with the 1996 GEIS. However, as provided in the 2013 GEIS, the impact and magnitude of uncertainties, as estimated in the 1996 GEIS, bound the uncertainties introduced by the new information and considerations addressed in the 2013 GEIS. Accordingly, in the 2013 GEIS, the staff concluded that the reduction in environmental impacts resulting from the use of new information (since the 1996 GEIS analysis) outweighs any increases in impact resulting from the new information. As a result, the findings in the 1996 GEIS remain valid. The NRC staff has identified no new and significant information regarding uncertainties during its review of FPL's environmental report, the SAMA audit, the scoping process, or the evaluation of other available information. Accordingly, the NRC staff concludes that no new and significant information exists for Turkey Point concerning uncertainties that would alter the conclusions reached in the 2013 GEIS or Turkey Point's previous SAMA analysis.

Section E.3.9.2 of Appendix E to the 2013 GEIS discusses the impact of population increases on offsite dose and economic consequences. The 2013 GEIS, in section E.3.9.2, states the following:

The 1996 GEIS estimated impacts at the mid-year of each plant's license renewal period (i.e., 2030 to 2050). To adjust the impacts estimated in the NUREGs and NUREG/CRs to the mid-year of the assessed plant's license renewal period, the information (i.e., exposure indexes [EIs]) in the 1996 GEIS can be used. The EIs adjust a plant's airborne and economic impacts from the year 2000 to its mid-year license renewal period based on population increases. These adjustments result in anywhere from a 5 to a 30 percent increase in impacts, depending upon the plant being assessed. Given the range of uncertainty in these types of analyses, a 5 to 30 percent change is not considered significant. Therefore, the effect of increased population around the plant does not generally result in significant increases in impacts.

Table 3.11-2 of Turkey Point's ER provides population information for the "County Populations Totally or Partially Included within a 50-Mile Radius of Turkey Point." As Table 3.11-2 shows, FPL estimates that in 2053 (i.e., at the end of the license renewal period for unit 4) the population within the 50-mile radius will be 6,890,445. Assuming a uniform increase in population, the mid-year population (2043) is projected to be 6,366,881 persons (37 percent higher than the U.S. Census Bureau data for the four counties in 2010). FPL's estimated population increase is slightly above the 30 percent range determined by the NRC in the 2013 GEIS to be not significant. However, as discussed in section E.3.3 of the 2013 GEIS and this

SEIS, more recent estimates give significantly lower release frequencies and release fractions for the source term than was assumed in the 1996 GEIS. Specifically, the 2013 GEIS states that “a comparison of population dose from newer assessments illustrates a reduction in impact by a factor of 5 to 100 when compared to older assessments, and an additional factor of 2 to 4 due to the conservatism built into the 1996 GEIS values.” Thus, the effect of this reduction in total dose from a radiological release following a severe accident far exceeds the effect of a population increase. The staff concludes that the effect of increased population around the plant does not result in significant increases in impacts. Thus, the staff concludes that no new and significant information exists for Turkey Point concerning population increase that would alter the conclusions reached in the 2013 GEIS or Turkey Point’s previous SAMA analysis.

E.3.10 Summary/Conclusion (Section E.5 of the 2013 GEIS)

The 2013 GEIS categorizes “sources of new information” by their potential effect on the best-estimate environmental impacts associated with postulated severe accidents. These effects can (1) decrease the environmental impact associated with severe accidents, (2) not affect the environmental impact associated with severe accidents, or (3) increase the environmental impact associated with severe accidents.

Areas of new and significant information that can result in the first effect (decrease the environmental impacts associated with severe accidents) at Turkey Point include:

- New internal events information (significant decrease)
- New source term information (significant decrease)

Areas of new and significant information that can result in the second effect (no effect on the environmental impact associated with severe accidents) or the third effect (increase the environmental impact associated with severe accidents) include:

- Use of BEIR VII risk coefficients
- Consideration of external events (comparable to internal event impacts)
- Spent fuel pool accidents (could be comparable to full-power event impacts)
- Higher fuel burnup (small to moderate increases)
- Low power and reactor shutdown events (could be comparable to full-power event impacts)
- Population Increase

The 2013 GEIS states, “Given the difficulty in conducting a rigorous aggregation of these results with the differences in the information sources utilized, a fairly simple approach is taken. The GEIS estimated the net increase from the first five areas listed above would be (in a simplistic sense) approximately an increase by a factor of 4.7. At the same time, however, for Turkey Point, the reduction in risk due to newer internal event information is a decrease in risk by a factor of 23. The net effect of an increase by a factor of 4.7 and a decrease by a factor of 23 would be overall lower estimated impact (as compared to the 1996 GEIS assessment) by a factor of 18.3. Thus, the staff finds that there is no new and significant information related to the severe accidents at Turkey Point that would alter the conclusions reached in the 2013 GEIS or Turkey Point’s previous SAMA analysis.

Other areas of new information relating to Turkey Point severe accident risk, severe accident environmental impact assessment, and cost-beneficial SAMAs are described below. These areas of new information demonstrate additional conservatism in the evaluations in the GEIS and FPL's ER, because they result in further reductions in the impact of a severe accident.

E.4 Other New Information Related to NRC Efforts to Reduce Severe Accident Risk Following Publication of the 1996 GEIS

The Commission has considered numerous ways to mitigate severe accidents, in addition to requiring a SAMA analysis at the time of initial license renewal, and has adopted various regulatory requirements for mitigating severe accident risks at reactor sites. In 1996, when it promulgated Table B-1 in Appendix B to Subpart A of 10 CFR Part 51, the Commission explained in a *Federal Register* notice:

The Commission has considered containment improvements for all plants pursuant to its Containment Performance Improvement (CPI) program...and the Commission has additional ongoing regulatory programs whereby licensees search for individual plant vulnerabilities to severe accidents and consider cost beneficial improvements (Final rule, Environmental review for renewal of nuclear power plant operating licenses, 61 FR 28467 (June 5, 1996)).

These "additional ongoing regulatory programs" that the Commission mentioned include the IPE (individual plant examination) and the IPEEE (individual plant examination of external events) program, which consider "potential improvements to reduce the frequency or consequences of severe accidents on a plant-specific basis and essentially constitute a broad search for severe accident mitigation alternatives." Further, the Commission observed that the IPEs "resulted in a number of plant procedural or programmatic improvements and some plant modifications that will further reduce the risk of severe accidents." Based on these and other considerations, the Commission stated its belief that it is "unlikely that any site-specific consideration of SAMAs for license renewal will identify major plant design changes or modifications that will prove to be cost-beneficial for reducing severe accident frequency or consequences" (61 FR 28481). The Commission noted that it may review and possibly reclassify the issue of severe accident mitigation as a Category 1 issue upon the conclusion of its IPE/IPEEE program, but deemed it appropriate to consider severe accident mitigation alternatives for plants for which had not done so previously, pending further rulemaking on this issue (61 FR 28481).

The Commission reaffirmed its SAMA-related conclusions in Table B-1 of Appendix B to Subpart A of 10 CFR Part 51 and 10 CFR 51.53(c)(3)(ii)(L), in *Exelon Generation Co., LLC* (Limerick Generating Station, Units 1 and 2), CLI-13-07, (Oct. 31, 2013) (ADAMS Accession No. ML13304B417). In addition, the Commission observed that it had promulgated those regulations because it had "determined that one SAMA analysis would uncover most cost beneficial measures to mitigate both the risk and the effects of severe accidents, thus satisfying our obligations under NEPA" (NRC 2013d).

The NRC has continued to address severe accident-related issues since the agency published the GEIS in 1996. Combined NRC and licensee efforts have reduced risks from accidents beyond those that were considered in the 1996 GEIS. The 2013 GEIS describes many of those efforts (NRC 2013a). In some cases, such as the NRC's response to the accident at Fukushima, these activities are still ongoing. In the remainder of Section E.4 of this SEIS, the

NRC staff describes efforts to reduce severe accident risk (CDF and LERF) following publication of the GEIS in 1996. Each of these initiatives applies to all reactors, including Turkey Point Units 3 and 4. Section E.4.1 describes requirements adopted following the terrorist attacks in September 2001, to address the loss of large areas of a plant caused by fire or explosions. Section E.4.2 describes the SOARCA project, which indicates that source term timing and magnitude values may be significantly lower than source term values quantified in previous studies using other analysis methods. Section E.4.3 describes measures adopted following the Fukushima earthquake and tsunami events of 2013. Section E.4.4 discusses efforts that have been made to utilize plant operating experience to improve plant performance and design features. These are areas of new information that reinforce the conclusion that the probability-weighted consequences of a severe accident are SMALL for all plants, as stated in the 2013 GEIS, and further reduce the likelihood of finding a cost-beneficial SAMA that would substantially reduce the severe accident risk at Turkey Point.

E.4.1 10 CFR 50.54(hh)(2) Requirements Regarding Loss of Large Areas of the Plant Caused by Fire or Explosions

As discussed on page E-7 of the 2013 GEIS, following the terrorist attacks of September 11, 2001, the NRC conducted a comprehensive review of the agency's security program and made further enhancements to security at a wide range of NRC-regulated facilities. These enhancements included significant reinforcement of the defense capabilities for nuclear facilities, better control of sensitive information, enhancements in emergency preparedness, and implementation of mitigating strategies to deal with postulated events potentially causing loss of large areas of the plant due to explosions or fires, including those that an aircraft impact might create. For example, the Commission issued Order EA-02-026, "Interim Compensatory Measures (ICM) Order." The ICM Order provided interim safeguards and security compensatory measure, and ultimately led to the promulgation of a new regulation in 10 CFR 50.54(hh). This regulation requires commercial power reactor licensees to prepare for a loss of large areas of the facility due to large fires and explosions from any cause, including beyond-design-basis aircraft impacts. In accordance with 10 CFR 50.54(hh)(2), licensees must adopt mitigation guidance and strategies to maintain or restore core cooling, containment, and spent fuel pool cooling capabilities under circumstances associated with the loss of large areas of the plant due to explosion or fire.

NRC requirements pertaining to plant security are subject to NRC oversight on an ongoing basis under a plant's current operating license, and are beyond the scope of license renewal. As discussed in Section 5.3.3.1 of the 1996 GEIS, the NRC addresses security-related events using deterministic criteria in 10 CFR Part 73, "Physical Protection of Plants and Materials," rather than by risk assessments or SAMAs. However, the implementation of measures that reduce the risk of severe accidents, including measures adopted to comply with 10 CFR 50.54(hh), also have a beneficial impact on the level of risk evaluated in a SAMA analysis, the purpose of which is to identify potentially cost-beneficial design alternatives, procedural modifications, or training activities that may further reduce the risks of severe accidents. Inasmuch as FPL has updated Turkey Point's guidelines, strategies, and procedures to meet the requirements of 10 CFR 50.54(hh), those efforts have contributed to mitigation of the risk of a beyond design basis event. Accordingly, actions taken by FPL to comply with those regulatory requirements have further contributed to the reduction of risk at Turkey Point.

In sum, the new information regarding actions taken by FPL to prepare for potential loss of large areas of the plant due to fire or explosions has further contributed to the reduction of severe

accident risk at Turkey Point. Thus, this information does not alter the conclusions reached in the 2013 GEIS regarding the consequences of a severe accident or Turkey Point's previous SAMA analysis.

E.4.2 SOARCA

The 2013 GEIS notes that a significant NRC effort is ongoing to re-quantify realistic severe accident source terms under the State-of-the-Art Reactor Consequence Analysis (SOARCA) project. Preliminary results indicate that source term timing and magnitude values quantified using SOARCA may be significantly lower than source term values quantified in previous studies using other analysis methods (NRC 2008). The NRC staff plans to incorporate this new information regarding source term timing and magnitude using SOARCA in future revisions of the GEIS.

The NRC has completed a SOARCA study for Surry Nuclear Power Station. The Surry Nuclear Power Station is a Westinghouse 3-loop PWR similar to Turkey Point. The Surry SOARCA summary concludes that with SOARCA, the NRC has achieved its objective of developing a body of knowledge regarding detailed, integrated, state-of-the-art modeling of the more important severe accident scenarios for Surry. SOARCA analyses indicate that successful implementation of existing mitigation measures can prevent reactor core damage or delay or reduce offsite releases of radioactive material. All SOARCA scenarios, even when unmitigated, progress more slowly and release much less radioactive material than the potential releases cited in the 1982 Siting Study (NUREG/CR-2239, "Technical Guidance for Siting Criteria Development"). As a result, the calculated risks of public health consequences of severe accidents modeled in SOARCA are very small.

This new information regarding the SOARCA project's findings has further contributed to the reduction of the calculated severe accident risk at Turkey Point, as compared to the 1996 GEIS and the Turkey Point SAMA evaluation for the initial license renewal application in 2000. Thus, the NRC staff finds there is no new and significant information related to Turkey Point SAMAs that would alter the conclusions reached in the 2013 GEIS or Turkey Point's previous SAMA analysis.

E.4.3 Fukushima-Related Activities

As discussed in Section E.2.1 of the 2013 GEIS, on March 11, 2011, a massive earthquake off the east coast of the main island of Honshu, Japan, produced a tsunami that struck the coastal town of Okuma in Fukushima Prefecture. This event damaged the six-unit Fukushima Dai-ichi nuclear power plant, causing the failure of safety systems needed to maintain cooling water flow to the reactors. Because of the loss of cooling, the fuel overheated, and there was a partial meltdown of fuel in three of the reactors. Damage to the systems and structures containing reactor fuel resulted in the release of radioactive material to the surrounding environment (NRC 2013a).

As further discussed in Section E.2.1 of the 2013 GEIS, in response to the earthquake, tsunami, and resulting reactor accidents at Fukushima Dai-ichi (hereafter referred to as the Fukushima events), the Commission directed the NRC staff to convene an agency task force of senior leaders and experts to conduct a methodical and systematic review of NRC regulatory requirements, programs, and processes (and their implementation) relevant to the Fukushima event. After thorough evaluation, the NRC required significant enhancements to U.S. commercial nuclear power plants. The enhancements included: adding capabilities to maintain

key plant safety functions following a large-scale natural disaster; updating evaluations on the potential impact from seismic and flooding events; adding new equipment to better handle potential reactor core damage events; and strengthening emergency preparedness capabilities. Further information regarding this matter is presented in the 2013 GEIS and the NRC's Web site Fukushima-related actions at <https://www.nrc.gov/reactors/operating/ops-experience/post-fukushima-safety-enhancements.html>.

In sum, the Commission has imposed additional safety requirements on operating reactors following the Fukushima accident (as described in the preceding paragraphs). The new regulatory requirements contribute to the mitigation of the risk of a severe accident. Therefore, the NRC staff concludes there is no new and significant information related to the Fukushima events that would alter the conclusions reached in the 2013 GEIS or Turkey Point's previous SAMA analysis.

E.4.4 Operating Experience

Section E.2 of the 2013 GEIS mentions the considerable operating experience that supports the safety of U.S. nuclear power plants. As with the use of any technology, greater user experience generally leads to improved performance and, if applicable, improved safety. This additional experience has contributed to improved plant performance (e.g., as measured by trends in plant-specific performance indicators), a reduction in adverse operating events, and lessons learned that improve the safety of all the operating nuclear power plants. The items above contribute to improved safety as do those safety improvements not related to license renewal such as generic safety issues (e.g., Generic Safety Issue 191, "Assessment of Debris Accumulation on PWR Sump Pump Performance"). Thus, the performance and safety record of nuclear power plants operating in the United States, including Turkey Point, continue to improve. This is also confirmed by analysis which indicates that, in many cases, improved plant performance and design features have resulted in reductions in initiating event frequency, CDF, and containment failure frequency (NRC 2013a).

Conclusion

As discussed above, the NRC and the nuclear industry have addressed and continue to address numerous severe accident-related issues since the publication of the 1996 GEIS and the 2000 Turkey Point SAMA analysis. These actions reinforce the conclusion that the probability-weighted consequences of a severe accident are SMALL for all plants, as stated in the 2013 GEIS, and further reduce the likelihood of finding a cost-beneficial SAMA that would substantially reduce the severe accident risk at Turkey Point.

E.5 Florida Power & Light's Evaluation of New and Significant Information Pertaining to SAMAs, Using NEI 17-04, "Model SLR New and Significant Assessment Approach for SAMA"

In its evaluation of the significance of new information, the NRC staff considers that new information is significant if it provides a seriously different picture of the impacts of the Federal action under consideration. Thus, for mitigation alternatives such as SAMAs, new information is significant if it indicates that a mitigation alternative would substantially reduce an impact of the Federal action on the environment. Consequently, with respect to SAMAs, new information may be significant if it indicates a given potentially cost-beneficial SAMA would substantially reduce the impacts of a severe accident or the probability or consequences (risk) of a severe accident occurring.

As discussed in Section E.2.2 above, FPL stated in its environmental report submitted as part of its subsequent license renewal application, that it used the methodology in NEI 17-04, “Model SLR New and Significant Assessment Approach for SAMA,” dated June 29, 2017 (NEI 2017) to evaluate new and significant information as it relates to the Turkey Point subsequent license renewal SAMAs. By letter dated January 31, 2018, the staff reviewed NEI 17-04 and found it acceptable for interim use, pending formal NRC endorsement of NEI 17-04 by incorporation in Regulatory Guide 4.2, Supplement 1, “Preparation of Environmental Reports for Nuclear Power Plant License Renewal Applications,” (NRC 2018m). In general, as discussed above, the NEI 17-04 methodology (NEI 2017) does not consider a potential SAMA to be significant unless it reduces by at least 50 percent the maximum benefit as defined in Section 4.5, “Total Cost of Severe Accident Risk/Maximum Benefit,” of NEI 05-01, Revision A, “Severe Accident Mitigation Alternatives (SAMA) Analysis Guidance Document.”

NEI 17-04, “Model SLR New and Significant Assessment Approach for SAMA,” describes a three-stage process for determining whether there is any “new and significant” information relevant to a previous SAMA analysis.

- **Stage 1:** The subsequent license renewal applicant uses PRA risk insights and/or risk model quantifications to estimate the percent reduction in the maximum benefit associated with (1) all unimplemented “Phase 2” SAMAs for the analyzed plant and (2) those SAMAs identified as potentially cost beneficial for other U.S. nuclear power plants and which are applicable to the analyzed plant. If one or more of those SAMAs are shown to reduce the maximum benefit by 50 percent or more, then the applicant must complete Stage 2. (Applicants that are able to demonstrate through the Stage 1 screening process that there is no potentially significant new information are not required to perform the Stage 2 or Stage 3 assessments).
- **Stage 2:** The subsequent license renewal applicant develops updated averted cost-risk estimates for implementing those SAMAs. If the Stage 2 assessment confirms that one or more SAMAs reduce the maximum benefit by 50 percent or more, then the applicant must complete Stage 3.
- **Stage 3:** The subsequent license renewal applicant performs a cost-benefit analysis for the “potentially significant” SAMAs identified in Stage 2.

The following sections describe FPL’s application of the NEI 17-04 methodology to Turkey Point SAMAs. FPL determined that none of the SAMAs evaluated in Stage 1 reduced the maximum benefit by 50 percent or more. As a result, FPL concluded it is not required to perform the Stage 2 or Stage 3 evaluations for any SAMAs.

E.5.1 Data Collection

NEI 17-04 Section 3.1, “Data Collection,” explains that the initial step of the assessment process is to identify the “new information” relevant to the SAMA analysis and to collect and develop those elements of information that will be used to support the assessment. The guidance document states that each applicant should collect, develop, and document the information elements corresponding to the stage or stages of the SAMA analysis performed for the site. For Turkey Point subsequent license renewal, the NRC staff reviewed the onsite information during an audit at NRC headquarters and determined that FPL had considered the appropriate information (NRC 2018d).

E.5.2 Stage 1 Assessment

Section 4.15.3, “Methodology for Evaluation of New and Significant SAMAs,” of FPL’s environmental report describes the process it used for identifying any potentially new and significant SAMAs from the 2000 SAMA analysis (FPL 2018f). In Stage 1 of the process, FPL used PRA risk insights and/or risk model quantifications to estimate the percent reduction in the maximum benefit associated with the following two types of SAMAs:

- 1) all unimplemented “Phase 2” SAMAs for Turkey Point
- 2) those SAMAs identified as potentially cost beneficial for other U.S. nuclear power plants and which are applicable to Turkey Point (FPL 2018f)

As discussed below, as a result of FPL’s qualitative and quantitative Stage 1 screening, all potential SAMAs were found to reduce the maximum benefit by less than 50 percent, and they were therefore screened out from further evaluation. Therefore, Stage 2 of the NEI methodology was not entered, and an update of the Turkey Point Level 3 PRA was not needed.

E.5.3 Florida Power & Light’s Evaluation of Unimplemented “Phase 2” SAMAs for Turkey Point

In 2000, FPL submitted an application for initial operating license renewal (FPL 2000), which the NRC approved in 2002. As part of that initial license renewal process, FPL performed a detailed evaluation of potential SAMAs, identifying 167 potential SAMAs. FPL then qualitatively screened out 93 of these potential SAMAs from further evaluation (for example, by screening out SAMAs that are only applicable to boiling water reactors), leaving 76 potential SAMAs. For these 76 SAMAs, FPL performed a detailed cost-benefit analysis (FPL 2000). The cost benefit analysis included development of a Level 3 probabilistic risk assessment (PRA) for Turkey Point Unit 3, which FPL used to calculate conditional offsite population doses and offsite economic consequences for each of the PRA source term categories (STCs). FPL developed the analysis for Turkey Point Unit 3, but it was applicable to the license renewal for both units (FPL 2000). By calculating the reduction in source term category frequencies for each potential SAMA, the present value dollar benefit of each SAMA was determined using the guidance of NUREG/BR-0184, “Regulatory Analysis Technical Evaluation Handbook,” (FPL 2000). FPL then compared the benefit to a cost estimate for each to complete the cost-benefit comparison. The conclusion reached by FPL in the SAMA analysis in its 2000 environmental report and by the NRC staff in its 2002 SEIS was that none of the analyzed Turkey Point SAMAs were potentially cost-beneficial.

As part of its subsequent license renewal application, FPL examined the Turkey Point probabilistic risk assessment again, for insights. The purpose was to determine if there was any new and significant information regarding the SAMA analyses that were performed to support issuance of the initial renewed operating licenses for Turkey Point. FPL re-evaluated the 76 SAMAs that were considered in connection with initial license renewal, using the NEI 17-04 process. Based on the Phase 1 qualitative and quantitative screening results, FPL found that all plant-specific and industry SAMAs were demonstrated to not be new and significant. Therefore, FPL concluded that there is no new and significant information that would alter the conclusions of Turkey Point’s SAMA analysis for initial license renewal.

E.5.4 Florida Power & Light Evaluation of SAMAs Identified as Potentially Cost Beneficial at Other U.S. Nuclear Power Plants and Which Are Applicable to Turkey Point

The 2013 GEIS (NRC 2013a) considered the plant-specific supplemental EISs that document potential environmental impacts and mitigation measures for severe accidents relevant to license renewal for each plant. Some of these plant-specific supplements had identified potentially cost-beneficial SAMAs. FPL reviewed the SEISs of plants with a similar design to Turkey Point (large, dry PWR containment), to identify potentially cost-beneficial SAMAs. FPL qualitatively screened from further evaluation any SAMAs that were not applicable to Turkey Point, SAMAs that were already implemented at Turkey Point, and SAMAs that had excessive implementation costs. In this regard, FPL screened out SAMAs from further consideration if the initial license renewal review found that they reduced the Turkey Point maximum benefit by greater than 50 percent but were found not to be cost effective due to their high estimated costs of implementation. FPL grouped the remaining SAMAs based on similarities in mitigation equipment or risk reduction benefits. FPL then evaluated all the remaining SAMAs for the impact they would have assuming those SAMAs were implemented at Turkey Point.

Section 4.15.4.2 of FPL's subsequent license renewal environmental report provides the Turkey Point Stage 1 screening evaluation, using the methodology in NEI 17-04 "Model SLR New and Significant Assessment Approach for SAMA." FPL evaluated 76 Turkey Point-specific SAMAs and 263 potentially cost-beneficial SAMAs identified at similarly designed nuclear power plants (industry SAMAs). The SAMAs were related to both internal and external events. Qualitative screening resulted in elimination from further analysis of all external event SAMAs in the Turkey Point subsequent license renewal application, based on application of the screening criteria in section 3.2.1 of NEI 17-04. Qualitative screening of internal event SAMAs, along with binning of similar SAMAs, reduced the total number of SAMAs requiring further evaluation to 13. FPL binned the SAMAs in a manner that allowed bounding cases that completely addressed a plant risk contributor to be defined to estimate the maximum possible benefits for any of the grouped SAMAs. For example, all intersystem loss-of-coolant accident (ISLOCA)-related SAMAs could be represented by a single case in which all ISLOCA events are set to zero (i.e., the risk of an ISLOCA event was assumed to be completely eliminated by SAMA implementation). The NRC staff finds that this bounding approach provides a conservative analysis.

Table 4.15-1 of FPL's environmental report lists the 13 SAMAs identified by FPL as requiring a quantitative screening analysis, including the industry internal events SAMAs and the Turkey Point-specific SAMAs. FPL then performed quantitative screening using the full internal events Turkey Point Level 2 probabilistic risk assessment and the CDF/LERF portions of the fire and flood probabilistic risk assessments. Specifically, FPL quantitatively screened SAMAs if the bounding Turkey Point-specific case yielded a reduction of less than 50 percent in the frequency of each source term category group. As stated in Section 4.15.4.1 of the environmental report, the criterion for quantitative screening from further evaluation in the Stage 1 evaluation was that the SAMA does not reduce any source term category group frequency by at least 50 percent; if a SAMA was found to reduce at least one source term category group frequency by at least 50 percent, the SAMA would be evaluated in a Stage 2 assessment (as described in section E.5). In accordance with this approach, FPL performed the qualitative and quantitative Stage 1 screening, and determined that all potential SAMAs were screened out from further evaluation.

Since none of the SAMAs were found to reduce the maximum benefit by at least 50 percent, FPL determined that the SAMAs are not "potentially significant" and a Stage 2 assessment is not needed. Therefore, FPL concluded it was not required to proceed to a Stage 2 assessment

for any SAMAs. As stated in NEI 17-04, “if a plant is able to demonstrate that none of the SAMAs evaluated in the Stage 1 assessment are potentially significant, then the Stage 2 inputs, such as the projected population within a 50-mile radius of the plant, should be listed as “new information”, but no work to estimate the actual 50-mile population is required.” Accordingly, consistent with NEI 17-04, there was no need for FPL to conduct a quantitative assessment of the effect of an increase in population numbers relative to the population considered in its initial license renewal SAMA analysis

The NRC staff reviewed Turkey Point’s onsite information and its SAMA identification and screening process, during an in-office audit at NRC headquarters (NRC 2018d). The staff found that FPL had used a methodical and reasonable approach to identify any SAMAs that might reduce the maximum benefit by at least 50 percent and therefore be considered to be potentially significant. Therefore, the NRC staff finds that FPL properly concluded, in accordance with the NEI 17-04 guidance, that a Stage 2 assessment was not needed.

E.5.5 Other New information

As discussed in FPL’s subsequent license renewal application environmental report and in NEI 17-04, there are some inputs to the SAMA analysis that are expected to change or to potentially change for all plants. These inputs include the following:

- Updated Level 3 PRA model consequence results, which may be impacted by multiple inputs, including, but not limited to, the following:
 - population, as projected within a 50-mile (80-km) radius of the plant
 - value of farm and nonfarm wealth
 - core inventory (e.g., due to power uprate)
 - evacuation timing and speed
 - Level 3 PRA methodology updates
 - cost-benefit methodology updates

In addition, other changes that could be considered to be new information may be dependent on plant activities or site-specific changes. These types of changes (listed in NEI 17-04) include the following:

- Identification of a new hazard (e.g., a fault that was not previously analyzed in the seismic analysis)
 - Updated plant risk model (e.g., a fire probabilistic risk assessment that replaces the individual plant examination of external events (IPEEE) analysis).
- Impacts of plant changes that are included in the plant risk models will be reflected in the model results and do not need to be assessed separately.
- Non-modeled modifications to the plant
 - Modifications determined to have no risk impact need not be included (e.g., replacement of the condenser vacuum pumps), unless they impact a specific input to SAMA (e.g., new low-pressure turbine in the power conversion system that results in a greater net electrical output)

Offsite consequence codes used in SAMA analyses consider plant-specific inputs as provided above. A detailed SAMA analysis would be able to analyze numerous plant-specific variables and the sensitivity of a SAMA analysis to these variables. However, inasmuch as a thorough

SAMA analysis was previously performed for Turkey Point's initial license renewal, a new SAMA analysis is not required by 51.53(c)(3)(ii)(L) and 10 CFR Part 51, Table B-1. Rather, as explained above, the licensee is required to consider new and significant information, i.e., new information that provides a seriously different picture of the consequences of the Federal action under consideration. With respect to SAMAs, new information may be significant if it indicated a SAMA would substantially reduce the probability or consequences of a severe accident.

The NEI methodology in NEI 17-04 uses "maximum benefit" to determine if SAMA-related information is new and significant. Maximum benefit (MB) is defined in Section 4.5 of NEI 05-01, Revision A, "Severe Accident Mitigation Alternatives (SAMA) Analysis Guidance Document," (NEI 2005), as the benefit a SAMA could achieve if it eliminated all risk. The total off-site dose and total economic impact are the baseline risk measures from which the maximum benefit is calculated. The NEI methodology in NEI 17-04 considers a SAMA to be potentially significant if it reduces the maximum benefit by at least 50 percent. The NRC staff finds the criterion of exceeding a 50-percent reduction in MB to be a reasonable significance threshold, because it correlates with the significance determination used in the ASME/ANS PRA standard, NUMARC 93-01, and NEI 00-04, all of which have been endorsed by the staff. It is also a reasonable quantification of the qualitative criterion for significance, which states that "new information is significant if it presents a seriously different picture of the impacts of the Federal action under consideration." Furthermore, it is consistent with the criterion that was accepted by the NRC staff in the Limerick Generating Station license renewal final SEIS.

In evaluating the guidance in NEI 17-04, the NRC staff found the 50-percent reduction approach described in NEI 17-04 to be reasonable because, with respect to SAMAs, the staff concluded that new information may be significant if it indicates a potentially cost-beneficial SAMA could substantially reduce the probability or consequences (risk) of a severe accident occurring. The implication of this statement is that "significance" is not solely related to whether a SAMA is cost beneficial (which may be affected by economic factors, increases in population, etc.), but depends also on a SAMA's potential to significantly reduce risk to the public.

E.5.6 Conclusion

As described above, FPL evaluated a total of 339 SAMAs for Turkey Point subsequent license renewal and did not find any SAMAs that would reduce the maximum benefit by 50 percent or more, and that further analysis was not required based on the guidance in NEI 17-04. The NRC staff reviewed FPL's evaluation and concludes that the methods used, and the results obtained, were reasonable. Based on Turkey Point's Phase 1 qualitative and quantitative screening results, FPL demonstrated that none of the plant-specific and industry SAMAs that it considered constitute new and significant information in that none changed the conclusion of Turkey Point's previous SAMA analysis. Further, the NRC staff has not identified any other new and significant information that would alter the conclusions reached in the previous SAMA analysis for Turkey Point. Therefore, the NRC staff finds no new and significant information that would alter the conclusions of the SAMA analysis performed for Turkey Point's initial license renewal.

The NRC staff reviewed FPL's new and significant information analysis for severe accidents and SAMAs at Turkey Point during the subsequent license renewal period and finds the analysis and the methods used to be reasonable. Given the low residual risk at Turkey Point, the substantial decrease in CDF at Turkey Point since the previous SAMA analysis, and the fact that no potentially cost-beneficial SAMAs were identified during the Turkey Point's initial license renewal review, the staff considers it unlikely that FPL would have found any potentially cost-beneficial SAMAs for subsequent license renewal. Further, FPL's implementation of actions to

satisfy the NRC's orders and regulatory requirements regarding beyond-design-basis events after the 9/11 and Fukushima events, as well as the conservative assumptions used in earlier severe accident studies and SAMA analyses, also made it unlikely that FPL would have found any potentially significant cost-beneficial SAMAs during its subsequent license renewal review. For all of the reasons stated above, the NRC staff concludes that the conclusions reached by FPL in its subsequent license renewal environmental report regarding SAMAs are reasonable and that there is no new and significant information regarding any potentially cost-beneficial SAMA that would substantially reduce the risks of a severe accident at Turkey Point.

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

NUREG-1437
Supplement 5, Second
Renewal

2. TITLE AND SUBTITLE

Generic Environmental Impact Statement for License Renewal of Nuclear
Plants Supplement 5, Second Renewal, Regarding Subsequent License
Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4
Final Report

3. DATE REPORT PUBLISHED

MONTH	YEAR
October	2019

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

See Chapter 7, "List of Preparers," of the report.

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Division of Materials and License Renewal
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above", if contractor, provide NRC Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address.)

Same as 8 above.

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

The U.S. Nuclear Regulatory Commission (NRC) staff prepared this supplemental environmental impact statement (SEIS) as part of its environmental review of Florida Power & Light Company's subsequent license renewal application, to renew the operating licenses for Turkey Point Nuclear Generating Unit Nos. 3 and 4 (Turkey Point) for an additional 20 years. This SEIS includes the NRC staff's evaluation of the environmental impacts of the subsequent license renewal as well as alternatives to subsequent license renewal. Alternatives to subsequent license renewal considered in this SEIS include: (1) a new nuclear power plant, (2) a new natural gas combined cycle power plant, and (3) the combination of a new natural gas combined cycle power plant and new solar photovoltaic power generation. In addition to replacement power alternatives, this SEIS evaluates an alternative cooling water system to mitigate potential impacts associated with the continued use of the existing cooling canal system. The NRC staff's recommendation is that the adverse environmental impacts of subsequent license renewal for Turkey Point are not so great that preserving the option of subsequent license renewal for energy planning decisionmakers would be unreasonable.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

Turkey Point Nuclear Generating Unit Nos. 3 and 4; Turkey Point; Supplement to the Generic Environmental Impact Statement; Subsequent License Renewal; DSEIS; GEIS; National Environmental Policy Act; NEPA

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, DC 20555-0001
OFFICIAL BUSINESS



@NRCgov

**NUREG-1437
Supplement 5, Second
Renewal, Final**

**Generic Environmental Impact Statement for License Renewal of Nuclear Plants
Supplement 5, Second Renewal, Regarding Subsequent License Renewal for
Turkey Point Nuclear Generating Unit Nos. 3 and 4**

October 2019