

REGULATORY COMMITMENT UPDATE

The following table identifies those actions previously identified as regulatory commitments by Ameren Missouri in Reference 1. Please direct questions regarding these commitments to Bruce Huhmann at (573) 694-6741.

Regulatory Commitments and Completion Schedule			
Modification	Committed Completion Date	Commitment Tracking Number	Status
Install Anchorage to the Alternate Emergency Power Supply transformer (XPB05).	December 31, 2020	50431	Complete
Provide a minimum of 1-inch clearance around two fire sprinkler heads located on the 1974' elevation of the control building at grid C4 & CC, and grid C2 & CB.	December 31, 2020	50432	Complete