

Knowledge and Abilities Catalog for Nuclear Power Plant Operators: Boiling Water Reactors

Final Report

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at the NRC's Library at www.nrc.gov/reading-rm.html. Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and Title 10, "Energy," in the *Code of Federal Regulations* may also be purchased from one of these two sources:

1. The Superintendent of Documents

U.S. Government Publishing Office
Washington, DC 20402-0001
Internet: www.bookstore.gpo.gov
Telephone: (202) 512-1800
Fax: (202) 512-2104

2. The National Technical Information Service

5301 Shawnee Road
Alexandria, VA 22312-0002
Internet: www.ntis.gov
1-800-553-6847 or, locally, (703) 605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: **U.S. Nuclear Regulatory Commission**
Office of Administration
Multimedia, Graphics, and Storage &
Distribution Branch
Washington, DC 20555-0001
E-mail: distribution.resource@nrc.gov
Facsimile: (301) 415-2289

Some publications in the NUREG series that are posted at the NRC's Web site address www.nrc.gov/reading-rm/doc-collections/nuregs are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library

Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute

11 West 42nd Street
New York, NY 10036-8002
Internet: www.ansi.org
(212) 642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and the Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of the NRC's regulations (NUREG-0750).

DISCLAIMER: This report was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product, or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.

Knowledge and Abilities Catalog for Nuclear Power Plant Operators: Boiling Water Reactors

Final Report

Manuscript Completed: April 2020
Date Published: September 2020

Prepared by:
B. Tindell and S. Cushing

Office of Nuclear Reactor Regulation

ABSTRACT

This catalog lists important reactor operator and senior reactor operator knowledge and abilities. Examiners and licensees use the BWR catalog along with NUREG-1021, "Operator Licensing Examination Standards for Power Reactors," to develop examinations that sample the topics listed under Title 10 of the *Code of Federal Regulations* (10 CFR) Part 55, "Operators' Licenses." The BWR catalog is organized into six major sections: Organization of the Catalog, Generic Knowledge and Abilities, Plant Systems, Emergency and Abnormal Plant Evolutions, Components, and Theory.

Revision 3 includes the following changes: (1) the clarification of numerous K/A statements and elimination of duplicate K/As, (2) the addition of the circulating water and service water systems, (3) a re-rating of importance ratings for plant systems and emergency and abnormal plant evolutions, and (4) the reduction to a single importance rating for K/As that only relate to one license level.

This NUREG is a rule as defined in the Congressional Review Act (5 U.S.C. 801-808). However, the Office of Management and Budget has not found it to be a major rule as defined in the Congressional Review Act.

PAPERWORK REDUCTION ACT STATEMENT

This NUREG contains information collection requirements that are subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). These information collections were approved by the Office of Management and Budget (OMB), approval number 3150-0018.

PUBLIC PROTECTION NOTIFICATION

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.

CONTENTS

ABSTRACT.....	iii
SUMMARY OF SIGNIFICANT CHANGES.....	xi
1 ORGANIZATION OF THE CATALOG.....	1-1
1.1 Introduction.....	1-1
1.2 10 CFR Part 55.....	1-1
1.3 Reactor Operator Written Examination.....	1-1
1.4 Senior Reactor Operator Written Examination.....	1-1
1.5 Reactor Operator and Senior Reactor Operator Operating Test Items.....	1-1
1.6 Senior Operators Limited to Fuel Handling.....	1-1
1.7 Organization of the BWR Catalog.....	1-1
1.8 Generic Knowledge and Abilities.....	1-2
1.9 Plant Systems.....	1-3
1.10 Emergency and Abnormal Plant Evolutions.....	1-7
1.11 Components.....	1-9
1.12 Theory.....	1-9
1.13 Importance Ratings.....	1-10
1.14 Rules of Use.....	1-11
1.15 General Guidance.....	1-11
1.16 Acronyms and Terms.....	1-12
2 GENERIC KNOWLEDGE AND ABILITIES.....	2-1
2.0 Generic Knowledge and Abilities.....	2-1
2.1 Conduct of Operations.....	2-1
2.2 Equipment Control.....	2-5
2.3 Radiation Control.....	2-9
2.4 Emergency Procedures/Plan.....	2-10
3 PLANT SYSTEMS.....	3.1-1
3.1 Safety Function 1: Reactivity Control.....	3.1-1
CRDH Control Rod Drive Hydraulic System.....	3.1-3
CRDM Control Rod and Drive Mechanism.....	3.1-7
RMCS Reactor Manual Control System.....	3.1-10
RFCS Recirculation Flow Control System.....	3.1-13
RS Recirculation System.....	3.1-17
RCIS Rod Control and Information System.....	3.1-23
SLCS Standby Liquid Control System.....	3.1-27

3.2	Safety Function 2: Reactor Coolant System Inventory Control.....	3.2-1
HPCI	High-Pressure Coolant Injection System.....	3.2-3
HPCS	High-Pressure Core Spray System.....	3.2-8
LPCS	Low-Pressure Core Spray System.....	3.2-12
CDS	Condensate System.....	3.2-16
RCIC	Reactor Core Isolation Cooling System.....	3.2-21
FWS	Feedwater System.....	3.2-26
RWCU	Reactor Water Cleanup System.....	3.2-30
RWLCS	Reactor Water Level Control System.....	3.2-34
RHR/LPCI	RHR/LPCI: Injection Mode.....	3.2-38
3.3	Safety Function 3: Reactor Pressure Control.....	3.3-1
ADS	Automatic Depressurization System.....	3.3.3
MRSS	Main and Reheat Steam System.....	3.3-6
RTPRS	Reactor/Turbine Pressure Regulating System.....	3.3-11
SRV	Safety Relief Valves.....	3.3-18
3.4	Safety Function 4: Heat Removal from the Reactor Core.....	3.4-1
HPCI	High-Pressure Coolant Injection System.....	3.4-3
HPCS	High-Pressure Core Spray System.....	3.4-8
IC	Isolation (Emergency) Condenser.....	3.4-12
LPCS	Low-Pressure Core Spray System.....	3.4-16
MRSS	Main and Reheat Steam System.....	3.4-20
MTGEN	Main Turbine Generator and Auxiliary Systems.....	3.4-25
RCIC	Reactor Core Isolation Cooling System.....	3.4-29
RS	Recirculation System.....	3.4-34
RHR/LPCI	RHR/LPCI: Injection Mode.....	3.4-40
SDC	Shutdown Cooling System (RHR Shutdown Cooling Mode).....	3.4-45
RVI	Reactor Vessel and Internals.....	3.4-49
SWS	Service Water System.....	3.4-53
3.5	Safety Function 5: Containment Integrity.....	3.5-1
PCS	Primary Containment System and Auxiliaries.....	3.5-3
PCIS	Primary Containment Isolation System/Nuclear Steam Supply Shutoff.....	3.5-9
RHR SPC	RHR/LPCI: Torus/Suppression Pool Cooling Mode.....	3.5-14
RHR CSS	RHR/LPCI: Containment Spray System Mode.....	3.5-18
RHR SPS	RHR/LPCI: Torus/Suppression Pool Spray Mode.....	3.5-23
SC	Secondary Containment.....	3.5-27

3.6	Safety Function 6: Electrical.....	3.6-1
AC	AC Electrical Distribution.....	3.6-3
DC	DC Electrical Distribution.....	3.6-6
EGE	Emergency Generators (Diesel/Jet).....	3.6-9
UPS	Uninterruptable Power Supply (AC/DC).....	3.6-13
3.7	Safety Function 7: Instrumentation.....	3.7-1
PRMS	Average Power Range Monitor/Local Power Range Monitor System.....	3.7-3
IRM	Intermediate Range Monitor System.....	3.7-7
NBI	Nuclear Boiler Instrumentation.....	3.7-10
RMS	Radiation Monitoring System.....	3.7-15
RPS	Reactor Protection System.....	3.7-19
RBMS	Rod Block Monitor System.....	3.7-23
RCIS	Rod Control and Information System.....	3.7-26
RPIS	Rod Position Information System.....	3.7-30
RSCS	Rod Sequence Control System.....	3.7-33
RWMS	Rod Worth Minimizer System.....	3.7-36
SRMS	Source Range Monitor System.....	3.7-39
TIP	Traversing In-Core Probe.....	3.7-42
3.8	Safety Function 8: Plant Service Systems.....	3.8-1
FPS	Fire Protection System.....	3.8-3
FH	Fuel Handling.....	3.8-7
IA	Instrument Air System.....	3.8-11
CCW	Component Cooling Water System.....	3.8-15
CWS	Circulating Water System.....	3.8-19
3.9	Safety Function 9: Radioactivity Release.....	3.9-1
MSIVLC	Main Steam Isolation Valve Leakage Control System.....	3.9-3
OG	Offgas System.....	3.9-7
PVS	Plant Ventilation Systems.....	3.9-11
RMS	Radiation Monitoring System.....	3.9-14
RW	Radwaste System.....	3.9-18
CRV	Control Room Ventilation.....	3.9-21
FPCCU	Fuel Pool Cooling and Cleanup.....	3.9-24
SGTS	Standby Gas Treatment System.....	3.9-28
4	EMERGENCY AND ABNORMAL PLANT EVOLUTIONS.....	4.1-1
4.1	Generic Emergency Plant Evolutions.....	4.1-1
EPE 1	High Drywell Pressure.....	4.1-3
EPE 2	High Reactor Pressure.....	4.1-6

EPE 3	Suppression Pool High Water Temperature.....	4.1-8
EPE 4	High Containment Temperature (Mark III Containment Only).....	4.1-10
EPE 5	High Drywell Temperature (Mark I and II Only).....	4.1-12
EPE 6	High Suppression Pool Water Level.....	4.1-14
EPE 7	Low Suppression Pool Water Level.....	4.1-16
EPE 8	Reactor Low Water Level.....	4.1-18
EPE 9	High Secondary Containment Area Temperature.....	4.1-20
EPE 10	High Secondary Containment Area Radiation Levels.....	4.1-22
EPE 11	Secondary Containment Ventilation High Radiation.....	4.1-24
EPE 12	Secondary Containment High Differential Pressure.....	4.1-26
EPE 13	Secondary Containment High Sump/Area Water Level.....	4.1-27
EPE 14	SCRAM Condition Present and Reactor Power Above APRM Downscale or Unknown.....	4.1-29
EPE 15	High Offsite Radioactivity Release Rate.....	4.1-32
EPE 16	High Containment Hydrogen Concentration.....	4.1-34
4.2	Generic Abnormal Plant Evolutions.....	4.2-1
APE 1	Partial or Complete Loss of Forced Core Flow Circulation.....	4.2-3
APE 2	Loss of Main Condenser Vacuum.....	4.2-5
APE 3	Partial or Complete Loss of AC Power.....	4.2-7
APE 4	Partial or Complete Loss of DC Power.....	4.2-9
APE 5	Main Turbine Generator Trip.....	4.2-11
APE 6	SCRAM.....	4.2-13
APE 7	High Reactor Pressure.....	4.2-15
APE 8	High Reactor Water Level.....	4.2-17
APE 9	Low Reactor Water Level.....	4.2-19
APE 10	High Drywell Pressure.....	4.2-21
APE 11	High Containment Temperature (Mark III Containment Only).....	4.2-23
APE 12	High Drywell Temperature.....	4.2-24
APE 13	High Suppression Pool Water Temperature.....	4.2-25
APE 14	Inadvertent Reactivity Addition.....	4.2-26
APE 15	Incomplete SCRAM.....	4.2-28
APE 16	Control Room Abandonment.....	4.2-29
APE 17	High Offsite Radioactive Release Rate.....	4.2-31
APE 18	Partial or Complete Loss of Component Cooling Water.....	4.2-33
APE 19	Partial or Complete Loss of Instrument Air.....	4.2-35
APE 20	Inadvertent Containment Isolation.....	4.2-37
APE 21	Loss of Shutdown Cooling.....	4.2-39
APE 22	Loss of Control Rod Drive Pumps.....	4.2-41
APE 23	Refueling Accidents.....	4.2-43
APE 24	Plant Fire on Site.....	4.2-45
APE 25	Generator Voltage and Electric Grid Disturbances.....	4.2-47

5 COMPONENTS..... 5-1

Valves.....	5-3
Sensors and Detectors.....	5-4
Controllers and Positioners.....	5-6
Pumps.....	5-7

	Motors and Generators.....	5-9
	Heat Exchangers and Condensers.....	5-10
	Demineralizers and Ion Exchangers.....	5-11
	Breakers, Relays, and Disconnects.....	5-12
6	THEORY.....	6.1-1
6.1	Reactor Theory.....	6.1-1
	Neutrons.....	6.1-3
	Neutron Life Cycle.....	6.1-4
	Reactor Kinetics and Neutron Sources.....	6.1-5
	Reactivity Coefficients.....	6.1-6
	Control Rods.....	6.1-7
	Fission Product Poisons.....	6.1-8
	Fuel Depletion and Burnable Poisons.....	6.1-9
	Reactor Operational Physics.....	6.1-10
6.2	Thermodynamics Theory.....	6.2-1
	Thermodynamic Units and Properties.....	6.2-3
	Basic Energy Concepts.....	6.2-4
	Steam.....	6.2-5
	Thermodynamic Processes.....	6.2-6
	Thermodynamic Cycles.....	6.2-7
	Fluid Statics and Dynamics.....	6.2-8
	Heat Transfer.....	6.2-10
	Thermal Hydraulics.....	6.2-11
	Core Thermal Limits.....	6.2-13
	Brittle Fracture and Vessel Thermal Stress.....	6.2-15

SUMMARY OF SIGNIFICANT CHANGES

Revision 3 to NUREG-1123 includes the following changes:

1. Linked each K/A to the areas and evolutions identified in 10 CFR 55.41, "Written Examination: Operators"; 10 CFR 55.43, "Written Examination: Senior Operators"; and 10 CFR 55.45, "Operating Tests."
2. Revised K/A stem statements for clarity and consistency with other catalogs.
3. Identified K/A statements that apply to specific plant designs as applicable to that design within the actual statement.
4. Identified K/A statements that apply to only the senior operator position as "SRO Only." Identified K/A statements that are likely to require reference material as "reference potential."
5. Reduced to a single IR for K/As that only relate to one license level (RO or SRO). Retained both RO and SRO IRs for K/As that relate to both license levels, such as generic, A2, and fuel handling system K/As.
6. Deleted K/A statements in the plant systems sections that were redundant to the K/As contained in Section 5, "Components."
7. Reviewed and deleted "definition" K/As where appropriate.
8. Standardized common systems between the pressurized water reactor and boiling water reactor catalogs.
9. Re-rated IRs for plant systems and emergency and abnormal plant evolutions.
10. Removed K/As that are part of general employee training (basic tasks that a general nuclear worker is already evaluated on with some periodicity).
11. Added K/A statements for the circulating water and service water systems.
12. Eliminated the overlap in the A3 and A4 statements and redundancy in the K3 statements related to the specific system.
13. Removed the lists of tasks provided for each system because the lists are no longer used and are retained in previous revisions.

1 ORGANIZATION OF THE CATALOG

1.1 Introduction

NUREG-1123, Revision 3, "Knowledge and Abilities Catalog for Nuclear Power Plant Operators: Boiling Water Reactors [BWR]" (also known as the BWR catalog) provides the basis for development of content-valid written and operating licensing examinations for reactor operators (ROs) and senior reactor operators (SROs). The BWR catalog is designed to ensure equitable and consistent examinations.

1.2 10 CFR Part 55

The catalog is used in conjunction with NUREG-1021, "Operator Licensing Examination Standards for Power Reactors." NUREG-1021 provides policy and guidance and establishes the procedures and practices for examining licensees and applicants for RO and SRO licenses pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) Part 55, "Operators' Licenses." All knowledge and abilities (K/As) in this catalog are directly linked by item number to 10 CFR Part 55.

1.3 Reactor Operator Written Examination

NUREG-1021 presents the guidance for preparation of the RO written examination, while 10 CFR 55.41(b) presents the specific items for RO written examinations.

1.4 Senior Reactor Operator Written Examination

NUREG-1021 presents the guidance for preparation of the SRO written examination. In addition to the RO items specified in 10 CFR 55.41(b), 10 CFR 55.43(b) lists additional items for SRO written examinations.

1.5 Reactor Operator and Senior Reactor Operator Operating Test Items

The U.S. Nuclear Regulatory Commission (NRC) provides the items for operating tests for ROs and SROs in 10 CFR 55.45(a). NUREG-1021 presents the guidance for the preparation of operating tests. The operating test should include a representative selection of K/As derived from those items listed in 10 CFR 55.45(a).

1.6 Senior Operators Limited to Fuel Handling

NUREG-1021 provides the specifications for examinations for senior operators limited to fuel handling (LSRO). The LSRO examination process includes both a written examination and an operating test. These examinations and tests include, but are not limited to, items associated with 10 CFR 55.43(b), items 5 through 7, and 10 CFR 55.45(a), items 5 and 6.

1.7 Organization of the BWR Catalog

The BWR catalog is organized into six major sections. K/As are grouped according to the major section to which they pertain. The following shows this organization schematically:

1 ORGANIZATION OF THE CATALOG

2 GENERIC KNOWLEDGE AND ABILITIES

Conduct of Operations K/As
Equipment Control K/As
Radiation Control K/As
Emergency Procedures/Plan K/As

3 PLANT SYSTEMS

Knowledge Categories (K1–K6)
Ability Categories (A1–A4)

4 EMERGENCY AND ABNORMAL PLANT EVOLUTIONS

Knowledge Categories (E/A K1–E/A K3)
Ability Categories (E/A A1–E/A A2)

5 COMPONENTS

Component Knowledge Categories

6 THEORY

Reactor Theory Knowledge Categories
Thermodynamics Knowledge Categories

1.8 Generic Knowledge and Abilities

Generic K/As are generally administrative K/As with broad application across systems and operations. They are listed in Section 2 of the catalog. The following are the four categories of generic K/As:

- 2.1 Conduct of Operations K/As
- 2.2 Equipment Control K/As
- 2.3 Radiation Control K/As
- 2.4 Emergency Procedures/Plan K/As

The generic K/As for “Conduct of Operations” are used to evaluate the applicant’s knowledge of the daily operation of the facility. Examples of the types of information evaluated under this category include shift turnover, operator responsibilities, and procedure usage.

The generic K/As for “Equipment Control” are used to evaluate the administrative requirements associated with the management and control of plant systems and equipment. Examples of the types of information evaluated under this category include maintenance and temporary modifications of systems.

The generic K/As for “Radiation Control” are used to evaluate the applicant’s knowledge and ability with respect to radiation hazards and protection (personnel and public). Examples of the types of information evaluated under this category include knowledge of significant radiation hazards and radiation work permits.

The generic K/As for “Emergency Procedures/Plan” are used to evaluate the applicant’s general knowledge of emergency operations. The emergency procedures K/As are designed to evaluate knowledge of the use of emergency procedures. The emergency plan K/As may be used to evaluate the applicant’s knowledge of the plan, including, as appropriate, the RO’s or SRO’s responsibility to decide whether the plan should be executed and the duties assigned under the plan.

1.9 Plant Systems

Plant Systems Organization by Safety Function

The following nine major safety functions must be maintained to ensure safe BWR nuclear power plant operation:

1. Reactivity Control
2. Reactor Water Inventory Control
3. Reactor Pressure Control
4. Heat Removal from the Reactor Core
5. Containment Integrity
6. Electrical
7. Instrumentation
8. Plant Service Systems
9. Radioactivity Release

The NRC has included plant systems in the BWR catalog based on their relationship and importance to safety functions. Table 1 lists these plant systems, arranged by safety function, and each plant system has a six-digit code number. Some plant systems contribute to more than one safety function. Section 3 of the BWR catalog delineates K/As for the plant systems.

Table 1: Plant Systems by Safety Functions

Safety Function 1: Reactivity Control

201001	Control Rod Drive Hydraulic System
201003	Control Rod and Drive Mechanism
201002	Reactor Manual Control System
202002	Recirculation Flow Control System
202001	Recirculation System
201005	Rod Control and Information System
211000	Standby Liquid Control System

Safety Function 2: Reactor Water Inventory Control

206000	High-Pressure Coolant Injection System
209002	High-Pressure Core Spray System
209001	Low-Pressure Core Spray System
256000	Condensate System
217000	Reactor Core Isolation Cooling System
259001	Feedwater System
204000	Reactor Water Cleanup System
259002	Reactor Water Level Control System
203000	RHR/LPCI: Injection Mode

Safety Function 3: Reactor Pressure Control

218000	Automatic Depressurization System
239001	Main and Reheat Steam System
241000	Reactor/Turbine Pressure Regulating System
239002	Safety Relief Valves

Safety Function 4: Heat Removal from the Reactor Core

206000	High-Pressure Coolant Injection System
209002	High-Pressure Core Spray System
207000	Isolation (Emergency) Condenser
209001	Low-Pressure Core Spray System
239001	Main and Reheat Steam System
245000	Main Turbine Generator and Auxiliary Systems
217000	Reactor Core Isolation Cooling System
202001	Recirculation System
203000	RHR/LPCI: Injection Mode
205000	Shutdown Cooling System (RHR Shutdown Cooling Mode)
290002	Reactor Vessel and Internals
510000	Service Water System

Safety Function 5: Containment Integrity

223001	Primary Containment System and Auxiliaries
223002	Primary Containment Isolation System/Nuclear Steam Supply Shutoff
219000	RHR/LPCI: Torus/Suppression Pool Cooling Mode
226001	RHR/LPCI: Containment Spray System Mode
230000	RHR/LPCI: Torus/Suppression Pool Spray Mode
290001	Secondary Containment

Safety Function 6: Electrical

262001	AC Electrical Distribution
263000	DC Electrical Distribution
264000	Emergency Generators (Diesel/Jet)
262002	Uninterruptable Power Supply (AC/DC)

Safety Function 7: Instrumentation

215005	Average Power Range Monitor/Local Power Range Monitor
215003	Intermediate Range Monitor System
216000	Nuclear Boiler Instrumentation
272000	Radiation Monitoring System
212000	Reactor Protection System
215002	Rod Block Monitor System
201005	Rod Control and Information System
214000	Rod Position Information System
201004	Rod Sequence Control System
201006	Rod Worth Minimizer System
215004	Source Range Monitor System
215001	Traversing In-Core Probe

Safety Function 8: Plant Service Systems

286000	Fire Protection System
234000	Fuel Handling
300000	Instrument Air System
400000	Component Cooling Water System
510001	Circulating Water System

Safety Function 9: Radioactivity Release

239003	Main Steam Isolation Valve Leakage Control System
271000	Offgas System
288000	Plant Ventilation Systems
272000	Radiation Monitoring System
268000	Radwaste System
290003	Control Room Ventilation
233000	Fuel Pool Cooling and Cleanup
261000	Standby Gas Treatment System

Knowledge and Ability Stem Statements for Plant Systems

The information delineated within each plant system is organized into six different types of knowledge and four different types of ability. If no K/A statements follow a stem statement, then there is no applicable K/A.

Each stem statement includes the applicable item numbers from 10 CFR 55.41, "Written Examination: Operators"; 10 CFR 55.43, "Written Examination: Senior Operators"; and 10 CFR 55.45, "Operating Tests." In most cases, the K/As associated with the stem statements can be used for both the written examination and the operating test. Table 2 provides the stem statements and their bases.

Table 2: Knowledge and Ability Stem Statements for Plant Systems

K1. Knowledge of the physical connections and/or cause and effect relationships between the (SYSTEM) and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)

Basis—K1 contains the systems that have a connection to (SYSTEM). The selected systems listed have either a plant protection/logic relationship or physical piping relationship to the (SYSTEM). Cause and effect relationships from system interactions may be tested in K1, as appropriate. K2 addresses electrical systems, and K4 addresses controls and interlocks.

K2. Knowledge of electrical power supplies to the following: (CFR: 41.7)

Basis—K2 lists the power supplies to system components for which knowledge of power supplies is testable due to their importance for safe plant operation or are operationally significant.

K3. Knowledge of the effect that a loss or malfunction of the (SYSTEM) will have on the following systems or system parameters: (CFR: 41.7 / 45.4)

Basis—K3 lists the systems included in K1 that will be affected by a loss of (SYSTEM).

K4. Knowledge of (SYSTEM) design features and/or interlocks that provide for the following: (CFR: 41.7)

Basis—K4 contains the plant protection/control design features and interlocks.

K5. Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the (SYSTEM): (CFR: 41.5 / 45.3)

Basis—K5 contains theoretical concepts related to the operation of the (SYSTEM) and resulting operational implications.

K6. Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the (SYSTEM): (CFR: 41.7 / 45.7)

Basis—K6 includes conditions or malfunctions which will have an effect on the (SYSTEM) if the K6 listed system or component is not operating according to design. K6 also contains (SYSTEM) components whose failure can affect the operation of the (SYSTEM).

A1. Ability to predict and/or monitor changes in parameters associated with operation of the (SYSTEM) including: (CFR: 41.5 / 45.5)

Basis—A1 includes parameters monitored to verify proper operation of the (SYSTEM) or indications that the (SYSTEM) is outside normal operating bands.

- A2. Ability to (a) predict the impacts of the following on the (SYSTEM) and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations: (CFR: 41.5 / 45.6)

Basis—A2 is the ability to predict and mitigate the consequences of selected items from K6.

- A3. Ability to monitor automatic operation of the (SYSTEM) including: (CFR: 41.7 / 45.7)

Basis—A3 includes the automatic features of the (SYSTEM) identified in K4 that can be monitored from the control room.

- A4. Ability to manually operate and/or monitor the (SYSTEM) in the control room: (CFR: 41.7 / 45.5 to 45.8)

Basis—A4 includes the features of the (SYSTEM) that can be manually performed in the control room or manually performed locally that are important to plant safety and monitored in the control room. This also includes automatic features listed in A3 that can be performed manually. A4 includes system monitoring associated with the listed manual actions. A4 for the fuel handling system includes manual operation of refueling equipment from the equipment location.

1.10 Emergency and Abnormal Plant Evolutions

Section 4 of the BWR catalog contains emergency plant evolutions (EPEs) and abnormal plant evolutions (APEs). An EPE is any condition, event, or symptom that leads to entry into the plant-specific EOPs. An APE is any degraded condition, event, or symptom that does not directly lead to an EOP entry condition but, nonetheless, adversely affects a safety function. The NRC developed the list of EPEs and APEs to include those integrative situations crossing several plant systems and/or safety functions. EPEs and APEs consist of conditions, events, symptoms, system operations, and the operators' mitigating actions, collectively known as an evolution. Thus, EPEs and APEs are not limited to the contents of a particular procedure.

Table 3 lists the EPEs and the APEs covered by this catalog.

Table 3: Emergency and Abnormal Plant Evolutions

EPEs	
295024	High Drywell Pressure
295025	High Reactor Pressure
295026	Suppression Pool High Water Temperature
295027	High Containment Temperature (Mark III Containment Only)
295028	High Drywell Temperature (Mark I and II Only)
295029	High Suppression Pool Water Level
295030	Low Suppression Pool Water Level
295031	Reactor Low Water Level
295032	High Secondary Containment Area Temperature
295033	High Secondary Containment Area Radiation Levels
295034	Secondary Containment Ventilation High Radiation

295035	Secondary Containment High Differential Pressure
295036	Secondary Containment High Sump/Area Water Level
295037	SCRAM Condition Present and Reactor Power Above APRM Downscale or Unknown
295038	High Offsite Radioactivity Release Rate
500000	High Containment Hydrogen Concentration

APEs

295001	Partial or Complete Loss of Forced Core Flow Circulation
295002	Loss of Main Condenser Vacuum
295003	Partial or Complete Loss of AC Power
295004	Partial or Complete Loss of DC Power
295005	Main Turbine Generator Trip
295006	SCRAM
295007	High Reactor Pressure
295008	High Reactor Water Level
295009	Low Reactor Water Level
295010	High Drywell Pressure
295011	High Containment Temperature (Mark III Containment Only)
295012	High Drywell Temperature
295013	High Suppression Pool Water Temperature
295014	Inadvertent Reactivity Addition
295015	Incomplete SCRAM—DELETED
295016	Control Room Abandonment
295017	High Offsite Radioactivity Release Rate
295018	Partial or Complete Loss of Component Cooling Water
295019	Partial or Complete Loss of Instrument Air
295020	Inadvertent Containment Isolation
295021	Loss of Shutdown Cooling
295022	Loss of Control Rod Drive Pumps
295023	Refueling Accidents
600000	Plant Fire on Site
700000	Generator Voltage and Electric Grid Disturbances

Knowledge and Ability Stem Statements for Emergency and Abnormal Plant Evolutions

The information delineated within each EPE or APE is organized into three types of knowledge and two types of ability. If no K/A statements follow a stem statement, then there is no applicable K/A.

Each stem statement includes the applicable item numbers from 10 CFR 55.41, 10 CFR 55.43, and 10 CFR.55.45. In most cases, the K/As associated with the stem statements can be used for both the written and the operating examinations. See Table 4.

Table 4: Knowledge and Ability Stem Statements for EPEs and APEs

- E/AK1 Knowledge of the operational implications and/or cause and effect relationships of the following concepts as they apply to the (EVOLUTION): (CFR: 41.5 / 41.7 / 45.7 / 45.8)
- Basis—Tests the knowledge of operationally-based concepts applicable to the (EVOLUTION). These items can come from the procedure bases, operating experience, procedure notes, procedure cautions, integrated system response, or other documents that describe operational implications and/or cause and effect for the (EVOLUTION).
- E/AK2 Knowledge of the relationship between the (EVOLUTION) and the following systems or components: (CFR: 41.8 / 41.10 / 45.3)
- Basis—Tests for knowledge of how the (EVOLUTION) affects the listed systems.
- E/AK3 Knowledge of the reasons for the following responses or actions as they apply to (EVOLUTION): (CFR: 41.5 / 41.10 / 45.6 / 45.13)
- Basis—Tests for knowledge of the reasons for the listed responses and/or actions during the (EVOLUTION).
- E/AA1 Ability to operate or monitor the following as they apply to (EVOLUTION): (CFR: 41.5 / 41.7 / 45.5 to 45.8)
- Basis—Tests the ability to operate or monitor the listed systems and/or components during all phases of the (EVOLUTION).
- E/AA2 Ability to determine or interpret the following as they apply to (EVOLUTION): (CFR: 41.10 / 43.5 / 45.13)
- Basis—Tests the ability to monitor the listed conditions and/or parameters and interpret their importance to the (EVOLUTION) or the (EVOLUTION) response.

1.11 Components

Basic components such as valves and pumps are found in many systems. NUREG-1021 lists eight categories of components. The component knowledge statements are more detailed than those provided in the system listing, yet at the same time, they are generic to the component types. Each of the eight categories of components has a unique six-digit code number and 10 CFR 55.41(b) item number for which additional knowledge statements are necessary. Section 5 of the BWR catalog delineates the components, listed in Table 5.

Table 5: Components

291001	Valves (CFR: 41.3)
291002	Sensors and Detectors (CFR: 41.7)
291003	Controllers and Positioners (CFR: 41.7)
291004	Pumps (CFR: 41.3)
291005	Motors and Generators (CFR: 41.7)
291006	Heat Exchangers and Condensers (CFR: 41.4)
291007	Demineralizers and Ion Exchangers (CFR: 41.3)
291008	Breakers, Relays, and Disconnects (CFR: 41.7)

1.12 Theory

NUREG-1021 lists theory items. Section 6 of the BWR catalog delineates the general fundamental knowledge that underlies safe performance on the job. These theory topics represent general fundamental concepts related to plant operation. Each theory topic has a unique six-digit code number, and the applicable 10 CFR 55.41(b) item number is provided.

Reactor Theory (CFR: 41.1)

292001	Neutrons
292002	Neutron Life Cycle
292003	Reactor Kinetics and Neutron Sources
292004	Reactivity Coefficients
292005	Control Rods
292006	Fission Product Poisons
292007	Fuel Depletion and Burnable Poisons
292008	Reactor Operational Physics

Thermodynamics Theory (CFR: 41.14)

293001	Thermodynamic Units and Properties
293002	Basic Energy Concepts
293003	Steam
293004	Thermodynamic Processes
293005	Thermodynamic Cycles
293006	Fluid Statics and Dynamics
293007	Heat Transfer
293008	Thermal Hydraulics
293009	Core Thermal Limits
293010	Brittle Fracture and Vessel Thermal Stress

1.13 Importance Ratings

In this context, importance considers the direct and indirect effects of the K/A on safe plant operation in a manner that ensures personnel and public health and safety. Importance ratings (IRs) of the K/As are next to each K/A in the catalog. These ratings reflect average ratings of individual NRC and utility panel members. Table 6 presents the rating scale.

Table 6: RO and SRO Importance Ratings

Rating	Importance for Safe Operation
5	Essential
4	Very important
3	Fairly important
2	Of limited importance
1	Insignificant importance

Therefore, a rating of below 2.5 represents a statement of limited or insignificant importance for the safe operation of a plant. Such statements are generally considered as inappropriate content for NRC licensing examinations, and they will be considered for deletion in a future revision to this catalog. (See below for qualifications of IRs related to variability of the ratings and plant-specific data.)

1.14 Rules of Use

To ensure consistency in applying this catalog, the following terms are interpreted as shown:

- “Parameters” include any characteristic of a system or component that is measured.
- “Actuation” includes actuation logic, signals, blocks, bypasses, permissives, interlocks, and resets.

1.15 General Guidance

This catalog uses the following strategies and principles:

- The use of setpoints is minimized. Values included are specific to titles or procedures. If a plant-specific value is different than that in the catalog, the intent of the K/A remains valid.
- When referencing a system or component, the associated indications, controls, and alarms that support the system function are applicable.
- The catalog minimizes K/A statement overlap in multiple sections. K/As are assigned to the most appropriate section.
- All IRs are in a single-column format except for generic, A2, and fuel handling system K/As.
- Subsystems, where applicable, are listed before each associated system.

1.16 Acronyms and Terms

AC	alternating current
ADS	automatic depressurization system
APE	abnormal plant evolution
APLHGR	average planar linear heat generation rate
APRM	average power range monitor
ARI	alternate rod insertion
ATWS	anticipated transient without SCRAM
ATWS/RPT	anticipated transient without SCRAM recirculation pump trip
BWR	boiling water reactor
CCW	component cooling water
CDS	condensate system
CFR	<i>Code of Federal Regulations</i>
CPR	critical power ratio
CRD	control rod drive
CRDH	control rod drive hydraulic
CRDM	control rod and drive mechanism
CRIDS	control room integrated display computer system
CRV	control room ventilation
CRW	control rod worth
CSS	containment spray system mode
CWS	circulating water system
DC	direct current
ECCS	emergency core cooling system
EGE	emergency generators
EHC	electrohydraulic control system
EOP	emergency operating procedure
EPE	emergency plant evolution
ERIS	emergency response information system
FCV	flow control valve
FH	fuel handling
FLPD	fraction of limiting power density
FRVS	filtration, recirculation ventilation system
FW	feedwater
FWCI	feedwater coolant injection
FWRV	feedwater regulating valve
FWS	feedwater system
FPCCU	fuel pool cooling and cleanup
FPS	fire protection system
GDS	graphical display system
HCU	hydraulic control unit
HPCI	high-pressure coolant injection
HPCS	high-pressure core spray
HVAC	heating, ventilation, and air conditioning

IA	instrument air
IC	isolation (emergency) condenser
IR	importance rating
IRM	intermediate range monitor
K/A	knowledge and ability
LHGR	linear heat generation rate
LOCA	loss of coolant accident
LPRM	local power range monitor
LPCI	low-pressure coolant injection
LPCS	low-pressure core spray
LSRO	senior reactor operator limited to fuel handling
LVDT	linear variable differential transformer
MAPLHGR	maximum average planar linear heat generation rate
MCPR	minimum critical power ratio
MFLPD	maximum fraction of limiting power density
MG	motor generator
MRSS	main and reheat steam system
MSIV	main steam isolation valve
MSIVLC	main steam isolation valve leakage control
MSR	moisture separator reheater
MTGEN	main turbine generator and auxiliary systems
NBI	nuclear boiler instrumentation
NPSH	net positive suction head
NSSSS	nuclear steam supply shutoff system
OG	offgas
OMB	Office of Management and Budget
OPRM	oscillation power range monitor
PCIOMR	preconditioning interim operating management recommendations
PCIS	primary containment isolation system
PCS	primary containment system and auxiliaries
POAH	point of adding heat
PRMS	power range monitoring system (includes APRM, LPRM and OPRM)
PVS	plant ventilation system
RACS	rod action control system
RBMS	rod block monitor system
RCIC	reactor core isolation cooling
RCIS	rod control and information system
RCS	reactor coolant system
RFCS	recirculation flow control system
RFP	reactor feedwater pump
RHR	residual heat removal
RMCS	reactor manual control system
RMS	radiation monitoring system
RO	reactor operator
RPIS	rod position information system

RPS	reactor protection system
RPT	recirculation pump trip
RPV	reactor pressure vessel
RS	recirculation system
RSCS	rod sequence control system
RTD	resistance temperature detector
RTPRS	reactor/turbine pressure regulating system
RVI	reactor vessel and internals
RW	radwaste
RWCU	reactor water cleanup
RWLCS	reactor water level control system
RWMS	rod worth minimizer system
SC	secondary containment
SDV	scram discharge volume
SDC	shutdown cooling
SGTS	standby gas treatment system
SLCS	standby liquid control system
SJAE	steam jet air ejector
SPC	torus/suppression pool cooling mode
SPDS	safety parameter display system
SPS	suppression pool spray mode
SRMS	source range monitor system
SRO	senior reactor operator
SRV	safety relief valve
SWS	service water system
T/C	thermocouple
TDRFP	Turbine-driven reactor feedwater pump
TIP	traversing in-core probe
T-s	temperature vs. specific entropy
UPS	uninterruptible power supply
VAR	volt-ampere reactive
VFD	variable frequency drive

2 GENERIC KNOWLEDGE AND ABILITIES

2.0 Generic Knowledge and Abilities

- 2.0.1 Technical Requirements Manual—For the purpose of this catalog, K/As that reference Technical Specifications may include the Technical Requirements Manual, where applicable.
- 2.0.2 K/A clarifying examples—K/As that include the words “such as” list suggested topical areas as examples and are not intended to be all inclusive.

2.1 Conduct of Operations

2.1.1 Knowledge of conduct of operations requirements

(CFR: 41.10 / 43.10 / 45.13)

IMPORTANCE RO 3.8 SRO 4.2

2.1.2 Knowledge of operator responsibilities during any mode of plant operation

(CFR: 41.10 / 43.1 / 45.13)

IMPORTANCE RO 4.1 SRO 4.4

2.1.3 Knowledge of shift or short-term relief turnover practices

(CFR: 41.10 / 45.13)

IMPORTANCE RO 3.7 SRO 3.9

2.1.4 Knowledge of individual licensed operator responsibilities related to shift staffing, such as medical requirements, “no-solo” operation, maintenance of active license status, 10 CFR Part 55

(CFR: 41.10 / 43.2)

IMPORTANCE RO 3.3 SRO 3.8

2.1.5 Ability to use procedures related to shift staffing, such as minimum crew complement or overtime limitations (reference potential)

(CFR: 41.10 / 43.5 / 45.12)

IMPORTANCE RO 2.9 SRO 3.9

2.1.6 Ability to manage the control room crew during plant transients (SRO Only)

(CFR: 43.5 / 45.12 / 45.13)

IMPORTANCE RO N/A SRO 4.8

2.1.7 Ability to evaluate plant performance and make operational judgments based on operating characteristics, reactor behavior, and instrument interpretation

(CFR: 41.5 / 43.5 / 45.12 / 45.13)

IMPORTANCE RO 4.4 SRO 4.7

2.1.8 Ability to coordinate personnel activities outside the control room

(CFR: 41.10 / 43.1 / 45.5 / 45.12 / 45.13)

IMPORTANCE RO 3.4 SRO 4.1

2.1.9 Ability to direct licensed personnel activities inside the control room (SRO Only)

(CFR: 43.1 / 45.5 / 45.12 / 45.13)

IMPORTANCE RO N/A SRO 4.5

2.1.10 Moved to 2.2.38

2.1.11 Moved to 2.2.39

2.1.12 Moved to 2.2.40

2.1.13 DELETED

2.1.14 Knowledge of criteria or conditions that require plantwide announcements, such as pump starts, reactor trips, and mode changes

(CFR: 41.10 / 43.5 / 45.12)

IMPORTANCE RO 3.1 SRO 3.1

2.1.15 Knowledge of administrative requirements for temporary management direction, such as standing orders, night orders, or operations memoranda

(CFR: 41.10 / 45.12)

IMPORTANCE RO 2.7 SRO 3.4

2.1.16 DELETED

2.1.17 Ability to make accurate, clear, and concise verbal reports

(CFR: 41.10 / 45.12 / 45.13)

IMPORTANCE RO 3.9 SRO 4.0

2.1.18 Ability to make accurate, clear, and concise logs, records, status boards, and reports

(CFR: 41.10 / 45.12 / 45.13)

IMPORTANCE RO 3.6 SRO 3.8

2.1.19 Ability to use available indications to evaluate system or component status

(CFR: 41.10 / 45.12)

IMPORTANCE RO 3.9 SRO 3.8

2.1.20 Ability to interpret and execute procedure steps

(CFR: 41.10 / 43.5 / 45.12)

IMPORTANCE RO 4.6 SRO 4.6

2.1.21 Ability to verify that a copy of a controlled procedure is the proper revision

(CFR: 41.10 / 45.10 / 45.13)

IMPORTANCE RO 3.5 SRO 3.6

2.1.22 Revised and moved to 2.2.35

2.1.23 Ability to perform general or normal operating procedures during any plant condition

(CFR: 41.10 / 43.5 / 45.2 / 45.6)

IMPORTANCE RO 4.3 SRO 4.4

2.1.24 Moved to 2.2.41

2.1.25 Ability to interpret reference materials, such as graphs, curves, and tables (reference potential)

(CFR: 41.10 / 43.5 / 45.12)

IMPORTANCE RO 3.9 SRO 4.2

2.1.26 DELETED

2.1.27 Knowledge of system purpose and/or function

(CFR: 41.7)

IMPORTANCE RO 3.9 SRO 4.0

2.1.28 Knowledge of the purpose and function of major system components and controls

(CFR: 41.7)

IMPORTANCE RO 4.1 SRO 4.1

2.1.29 Knowledge of how to conduct system lineups, such as valves, breakers, or switches

(CFR: 41.10 / 45.1 / 45.12)

IMPORTANCE RO 4.1 SRO 4.0

2.1.30 Ability to locate and operate components, including local controls

(CFR: 41.7 / 45.7)

IMPORTANCE RO 4.4 SRO 4.0

2.1.31 Ability to locate control room switches, controls, and indications, and to determine that they correctly reflect the desired plant lineup

(CFR: 41.10 / 45.12)

IMPORTANCE RO 4.6 SRO 4.3

2.1.32 Ability to explain and apply system precautions, limitations, notes, or cautions

(CFR: 41.10 / 43.2 / 45.12)

IMPORTANCE RO 3.8 SRO 4.0

2.1.33 Moved to 2.2.42

2.1.34 Knowledge of RCS or balance of plant chemistry controls, including parameters measured and reasons for the control

(CFR: 41.10 / 43.5 / 45.12)

IMPORTANCE RO 2.7 SRO 3.5

2.1.35 Knowledge of the fuel handling responsibilities of SROs (SRO Only)

(CFR: 43.7)

IMPORTANCE RO N/A SRO 3.9

2.1.36 Knowledge of procedures and limitations involved in core alterations

(CFR: 41.10 / 43.6 / 45.7)

IMPORTANCE RO 3.0 SRO 4.1

- 2.1.37 Knowledge of procedures, guidelines, or limitations associated with reactivity management**
(CFR: 41.1 / 41.5 / 41.10 / 43.6 / 45.6)
IMPORTANCE RO 4.3 SRO 4.6
- 2.1.38 Knowledge of the station's requirements for verbal communications when implementing procedures**
(CFR: 41.10 / 45.13)
IMPORTANCE RO 3.7 SRO 3.8
- 2.1.39 Knowledge of conservative decision-making practices**
(CFR: 41.10 / 43.5 / 45.12)
IMPORTANCE RO 3.6 SRO 4.3
- 2.1.40 Knowledge of refueling administrative requirements**
(CFR: 41.10 / 43.5 / 43.6 / 45.13)
IMPORTANCE RO 2.8 SRO 3.9
- 2.1.41 Knowledge of the refueling process**
(CFR: 41.2 / 41.10 / 43.6 / 45.13)
IMPORTANCE RO 2.8 SRO 3.7
- 2.1.42 Knowledge of new and spent fuel movement procedures (SRO Only)**
(CFR: 43.7 / 45.13)
IMPORTANCE RO N/A SRO 3.4
- 2.1.43 Ability to use an online power distribution monitoring system and/or procedures to determine the effects on reactivity of plant changes, such as RCS temperature, secondary plant, or fuel depletion**
(CFR: 41.10 / 43.6 / 45.6)
IMPORTANCE RO 4.1 SRO 4.3
- 2.1.44 Knowledge of RO duties in the control room during fuel handling, such as responding to alarms from the fuel handling area, communication with fuel handling personnel, operating systems from the control room in support of fueling operations, or supporting instrumentation**
(CFR: 41.10 / 43.7 / 45.12)
IMPORTANCE RO 3.9 SRO N/A
- 2.1.45 Ability to identify and interpret diverse indications to validate the response of another indication**
(CFR: 41.7 / 43.5 / 45.4)
IMPORTANCE RO 4.3 SRO 4.3
- 2.1.46 Ability to use integrated control systems to operate plant systems or components**
(CFR: 41.10 / 45.12 / 45.13)
IMPORTANCE RO 4.0 SRO 3.3
- 2.1.47 Ability to direct nonlicensed personnel activities inside the control room**
(CFR: 41.10 / 43.5 / 45.5 / 45.12 / 45.13)
IMPORTANCE RO 3.2 SRO 3.2

2.2 Equipment Control

2.2.1 Ability to perform pre-startup procedures for the facility, including operating those controls associated with plant equipment that could affect reactivity

(CFR: 41.5 / 41.10 / 43.5 / 43.6 / 45.1)

IMPORTANCE RO 4.5 SRO 4.4

2.2.2 Ability to manipulate the console controls as required to operate the facility between shutdown and designated power levels

(CFR: 41.6 / 41.7 / 45.2)

IMPORTANCE RO 4.6 SRO 4.1

2.2.3 (Multi-unit license) Knowledge of the design, procedural, or operational differences between units

(CFR: 41.5 / 41.6 / 41.7 / 41.10 / 45.12)

IMPORTANCE RO 3.8 SRO 3.9

2.2.4 (Multi-unit license) Ability to explain the variations in control room layouts, systems, instrumentation, or procedural actions between units at a facility

(CFR: 41.6 / 41.7 / 41.10 / 45.1 / 45.13)

IMPORTANCE RO 3.6 SRO 3.6

2.2.5 Knowledge of the process for making design or operating changes to the facility, such as 10 CFR 50.59, "Changes, Tests and Experiments," screening and evaluation processes, administrative processes for temporary modifications, disabling annunciators, or installation of temporary equipment

(CFR: 41.10 / 43.3 / 45.13)

IMPORTANCE RO 2.2 SRO 3.2

2.2.6 Knowledge of the process for making changes to procedures

(CFR: 41.10 / 43.3 / 45.13)

IMPORTANCE RO 3.0 SRO 3.6

2.2.7 Knowledge of the process for conducting infrequently performed tests or evolutions

(CFR: 41.10 / 43.3 / 45.13)

IMPORTANCE RO 2.9 SRO 3.6

2.2.8 DELETED

2.2.9 DELETED

2.2.10 DELETED

2.2.11 DELETED

2.2.12 Knowledge of surveillance procedures

(CFR: 41.10 / 43.2 / 45.13)

IMPORTANCE RO 3.7 SRO 4.1

2.2.13 Knowledge of tagging and clearance procedures

(CFR: 41.10 / 43.1 / 45.13)

IMPORTANCE RO 4.1 SRO 4.3

2.2.14 Knowledge of the process for controlling equipment configuration or status
(CFR: 41.10 / 43.3 / 45.13)
IMPORTANCE RO 3.9 SRO 4.3

2.2.15 Ability to determine the expected plant configuration using design and configuration control documentation, such as drawings, lineups or, tagouts (reference potential)
(CFR: 41.10 / 43.3 / 45.13)
IMPORTANCE RO 3.9 SRO 4.3

2.2.16 DELETED

2.2.17 Knowledge of the process for managing maintenance activities during power operations, such as risk assessments, work prioritization, and coordination with the transmission system operator
(CFR: 41.10 / 43.5 / 45.13)
IMPORTANCE RO 2.6 SRO 3.8

2.2.18 Knowledge of the process for managing maintenance activities during shutdown operations, such as risk assessments and work prioritization
(CFR: 41.10 / 43.5 / 45.13)
IMPORTANCE RO 2.6 SRO 3.9

2.2.19 Knowledge of maintenance work order requirements
(CFR: 41.10 / 43.5 / 45.13)
IMPORTANCE RO 2.3 SRO 3.4

2.2.20 Knowledge of the process for managing troubleshooting activities
(CFR: 41.10 / 43.5 / 45.13)
IMPORTANCE RO 2.6 SRO 3.8

2.2.21 Knowledge of pre- and post-maintenance operability requirements
(CFR: 41.10 / 43.2)
IMPORTANCE RO 2.9 SRO 4.1

2.2.22 Knowledge of limiting conditions for operation and safety limits
(CFR: 41.5 / 43.2 / 45.2)
IMPORTANCE RO 4.0 SRO 4.7

2.2.23 Ability to track technical specification limiting conditions for operation
(CFR: 41.10 / 43.2 / 45.13)
IMPORTANCE RO 3.1 SRO 4.6

2.2.24 Moved to 2.2.36

2.2.25 Knowledge of the bases in technical specifications for limiting conditions for operation and safety limits (SRO Only)
(CFR: 43.2)
IMPORTANCE RO N/A SRO 4.2

2.2.26 Moved to 2.1.40

- 2.2.27 Moved to 2.1.41**
- 2.2.28 Moved to 2.1.42**
- 2.2.29 Moved to 2.1.35**
- 2.2.30 Moved to 2.1.44**
- 2.2.31 Moved to 2.1.36**
- 2.2.32 DELETED**
- 2.2.33 DELETED**
- 2.2.34 Revised and moved to 2.1.43**

- 2.2.35 Ability to determine technical specification mode of operation**
 (CFR: 41.7 / 41.10 / 43.2 / 45.13)
 IMPORTANCE RO 3.6 SRO 4.5

- 2.2.36 Ability to analyze the effect of maintenance activities, such as degraded power sources, on the status of limiting conditions for operation**
 (CFR: 41.10 / 43.2 / 45.13)
 IMPORTANCE RO 3.1 SRO 4.2

- 2.2.37 Ability to determine operability or availability of safety-related equipment (SRO Only)**
 (CFR: 43.2 / 43.5 / 45.12)
 IMPORTANCE RO N/A SRO 4.6

- 2.2.38 Knowledge of conditions and limitations in the facility license**
 (CFR: 41.7 / 41.10 / 43.1 / 45.13)
 IMPORTANCE RO 3.6 SRO 4.5

- 2.2.39 Knowledge of less than or equal to 1 hour technical specification action statements (This K/A does not include action statements of 1 hour or less that follow the expiration of a completion time for a technical specification condition for which an action statement has already been entered.)**
 (CFR: 41.7 / 41.10 / 43.2 / 45.13)
 IMPORTANCE RO 3.9 SRO 4.5

- 2.2.40 Ability to apply technical specifications with action statements of less than or equal to 1 hour**
 (CFR: 41.10 / 43.2 / 43.5 / 45.3)
 IMPORTANCE RO 3.4 SRO 4.7

- 2.2.41 Ability to obtain and interpret station electrical and mechanical drawings (reference potential)**
 (CFR: 41.10 / 45.12 / 45.13)
 IMPORTANCE RO 3.5 SRO 3.9

- 2.2.42 Ability to recognize system parameters that are entry-level conditions for technical specifications**
 (CFR: 41.7 / 41.10 / 43.2 / 43.3 / 45.3)
 IMPORTANCE RO 3.9 SRO 4.6

2.2.43 Knowledge of the process used to track inoperable alarms

(CFR: 41.10 / 43.5 / 45.13)

IMPORTANCE RO 3.0 SRO 3.3

2.2.44 Ability to interpret control room indications to verify the status and operation of a system and understand how operator actions and directives affect plant and system conditions

(CFR: 41.5 / 43.5 / 45.12)

IMPORTANCE RO 4.2 SRO 4.4

2.2.45 Ability to determine or interpret technical specifications with action statements of greater than 1 hour (SRO Only)

(CFR: 43.2 / 43.5 / 45.3)

IMPORTANCE RO N/A SRO 4.7

2.3 Radiation Control

2.3.1 DELETED

2.3.2 DELETED

2.3.3 DELETED

2.3.4 DELETED

2.3.5 Ability to use radiation monitoring systems, such as fixed radiation monitors and alarms or personnel monitoring equipment

(CFR: 41.11 / 41.12 / 43.4 / 45.9)

IMPORTANCE RO 2.9 SRO 2.9

2.3.6 Ability to approve liquid or gaseous release permits

(CFR: 41.13 / 43.4 / 45.10)

IMPORTANCE RO 2.0 SRO 3.8

2.3.7 DELETED

2.3.8 DELETED

2.3.9 DELETED

2.3.10 DELETED

2.3.11 Ability to control radiation releases

(CFR: 41.11 / 43.4 / 45.10)

IMPORTANCE RO 3.8 SRO 4.3

2.3.12 Knowledge of radiological safety principles and procedures pertaining to licensed operator duties, such as response to radiation monitor alarms, containment entry requirements, fuel handling responsibilities, access to locked high-radiation areas, or alignment of filters

(CFR: 41.12 / 43.4 / 45.9 / 45.10)

IMPORTANCE RO 3.2 SRO 3.7

2.3.13 DELETED

2.3.14 Knowledge of radiation or contamination hazards that may arise during normal, abnormal, or emergency conditions or activities, such as analysis and interpretation of radiation and activity readings as they pertain to administrative, normal, abnormal, and emergency procedures, or analysis and interpretation of coolant activity, including comparison to emergency plan or regulatory limits (SRO Only)

(CFR: 43.4 / 45.10)

IMPORTANCE RO N/A SRO 3.8

2.3.15 DELETED

2.4 Emergency Procedures/Plan

2.4.1 DELETED

2.4.2 Knowledge of system setpoints, interlocks and automatic actions associated with emergency and abnormal operating procedure entry conditions

(CFR: 41.7 / 45.7 / 45.8)

IMPORTANCE RO 4.5 SRO 4.6

2.4.3 Ability to identify post-accident instrumentation

(CFR: 41.6 / 45.4)

IMPORTANCE RO 3.7 SRO 3.9

2.4.4 Ability to recognize abnormal indications for system operating parameters that are entry-level conditions for emergency and abnormal operating procedures

(CFR: 41.10 / 43.2 / 45.6)

IMPORTANCE RO 4.5 SRO 4.7

2.4.5 Knowledge of the organization of the operating procedures network for normal, abnormal, and emergency evolutions

(CFR: 41.10 / 43.5 / 45.13)

IMPORTANCE RO 3.7 SRO 4.3

2.4.6 Knowledge of emergency and abnormal operating procedures major action categories

(CFR: 41.10 / 43.5 / 45.13)

IMPORTANCE RO 3.7 SRO 4.7

2.4.7 DELETED

2.4.8 DELETED

2.4.9 DELETED

2.4.10 DELETED

2.4.11 DELETED

2.4.12 Knowledge of operating crew responsibilities during emergency and abnormal operations

(CFR: 41.10 / 45.12)

IMPORTANCE RO 4.0 SRO 4.3

2.4.13 DELETED

2.4.14 Knowledge of general guidelines for emergency and abnormal operating procedures usage

(CFR: 41.10 / 43.1 / 45.13)

IMPORTANCE RO 3.8 SRO 4.5

2.4.15 Revised and moved to 2.1.38

- 2.4.16 Knowledge of emergency and abnormal operating procedures implementation hierarchy and coordination with other support procedures or guidelines such as, operating procedures, abnormal operating procedures, or severe accident management guidelines**
(CFR: 41.10 / 43.5 / 45.13)
IMPORTANCE RO 3.5 SRO 4.4
- 2.4.17 Knowledge of emergency and abnormal operating procedures terms and definitions**
(CFR: 41.10 / 45.13)
IMPORTANCE RO 3.9 SRO 4.3
- 2.4.18 Knowledge of the specific bases for emergency and abnormal operating procedures**
(CFR: 41.10 / 43.1 / 45.13)
IMPORTANCE RO 3.3 SRO 4.0
- 2.4.19 Knowledge of emergency and abnormal operating procedures layout, symbols, and icons**
(CFR: 41.10 / 45.13)
IMPORTANCE RO 3.4 SRO 4.1
- 2.4.20 Knowledge of the operational implications of emergency and abnormal operating procedures warnings, cautions, and notes**
(CFR: 41.10 / 43.5 / 45.13)
IMPORTANCE RO 3.8 SRO 4.3
- 2.4.21 Knowledge of the parameters and logic used to assess the status of emergency operating procedures critical safety functions or shutdown critical safety functions**
(CFR: 41.7 / 43.5 / 45.12)
IMPORTANCE RO 4.0 SRO 4.6
- 2.4.22 Knowledge of the bases for prioritizing safety functions during abnormal/emergency operations**
(CFR: 41.7 / 41.10 / 43.5 / 45.12)
IMPORTANCE RO 3.6 SRO 4.4
- 2.4.23 Knowledge of the bases for prioritizing emergency operating procedures implementation**
(CFR: 41.10 / 43.5 / 45.13)
IMPORTANCE RO 3.4 SRO 4.4
- 2.4.24 DELETED**
- 2.4.25 Knowledge of fire protection procedures**
(CFR: 41.10 / 43.5 / 45.13)
IMPORTANCE RO 3.3 SRO 3.7

2.4.26 Knowledge of facility protection requirements, including fire brigade and portable firefighting equipment usage

(CFR: 41.10 / 43.5 / 45.12)

IMPORTANCE RO 3.1 SRO 3.6

2.4.27 DELETED

2.4.28 Knowledge of procedures relating to a security event (ensure that the test item includes no safeguards information)

(CFR: 41.10 / 43.5 / 45.13)

IMPORTANCE RO 3.2 SRO 4.1

2.4.29 Knowledge of the emergency plan implementing procedures

(CFR: 41.10 / 43.5 / 45.11)

IMPORTANCE RO 3.1 SRO 4.4

2.4.30 Knowledge of events related to system operation/status that must be reported to internal organizations or external agencies, such as the State, the NRC, or the transmission system operator

(CFR: 41.10 / 43.5 / 45.11)

IMPORTANCE RO 2.7 SRO 4.1

2.4.31 Knowledge of annunciator alarms, indications, or response procedures

(CFR: 41.10 / 45.3)

IMPORTANCE RO 4.2 SRO 4.1

2.4.32 Knowledge of operator response to loss of annunciators

(CFR: 41.10 / 43.5 / 45.13)

IMPORTANCE RO 3.6 SRO 4.0

2.4.33 Moved to 2.2.43

2.4.34 Knowledge of RO responsibilities outside the main control room during an emergency

(CFR: 41.10 / 43.5 / 45.13)

IMPORTANCE RO 4.2 SRO N/A

2.4.35 Knowledge of nonlicensed operator responsibilities during an emergency

(CFR: 41.10 / 43.1/ 43.5 / 45.13)

IMPORTANCE RO 3.8 SRO 4.0

2.4.36 DELETED

2.4.37 Knowledge of the lines of authority during implementation of the emergency plan implementing procedures

(CFR: 41.10 / 45.13)

IMPORTANCE RO 3.0 SRO 4.1

- 2.4.38 Ability to take actions required by the facility emergency plan implementing procedures, including supporting or acting as emergency coordinator**
(CFR: 41.10 / 43.5 / 45.11)
IMPORTANCE RO 2.4 SRO 4.4
- 2.4.39 Knowledge of RO responsibilities in emergency plan implementing procedures**
(CFR: 41.10 / 45.11)
IMPORTANCE RO 3.9 SRO N/A
- 2.4.40 Knowledge of SRO responsibilities in emergency plan implementing procedures (SRO Only)**
(CFR: 43.5 / 45.11)
IMPORTANCE RO N/A SRO 4.5
- 2.4.41 Knowledge of the emergency action level thresholds and classifications (SRO Only)**
(CFR: 43.5 / 45.11)
IMPORTANCE RO N/A SRO 4.6
- 2.4.42 Knowledge of emergency response facilities**
(CFR: 41.10 / 45.11)
IMPORTANCE RO 2.6 SRO 3.8
- 2.4.43 Knowledge of emergency communications systems and techniques**
(CFR: 41.10 / 43.5 / 45.13)
IMPORTANCE RO 3.2 SRO 3.8
- 2.4.44 Knowledge of emergency plan implementing procedures protective action recommendations (SRO Only)**
(CFR: 41.10 / 41.12 / 43.5 / 45.11)
IMPORTANCE RO N/A SRO 4.4
- 2.4.45 Ability to prioritize and interpret the significance of each annunciator or alarm**
(CFR: 41.10 / 43.5 / 45.3 / 45.12)
IMPORTANCE RO 4.1 SRO 4.3
- 2.4.46 Ability to verify that the alarms are consistent with the plant conditions**
(CFR: 41.10 / 43.5 / 45.3 / 45.12)
IMPORTANCE RO 4.2 SRO 4.2
- 2.4.47 Ability to diagnose and recognize trends in an accurate and timely manner using the appropriate control room reference material (reference potential)**
(CFR: 41.10 / 43.5 / 45.12)
IMPORTANCE RO 4.2 SRO 4.2
- 2.4.48 Revised and moved to 2.2.44**
- 2.4.49 Ability to perform without reference to procedures those actions that require immediate operation of system components and controls**
(CFR: 41.10 / 43.2 / 45.6)
IMPORTANCE RO 4.6 SRO 4.4

2.4.50 Ability to verify system alarm setpoints and operate controls identified in the alarm response procedure

(CFR: 41.10 / 43.5 / 45.3)

IMPORTANCE RO 4.2 SRO 4.0

2.4.51 Knowledge of emergency operating procedure exit conditions (e.g., emergency condition no longer exists or severe accident guideline entry is required)

(CFR: 41.10 / 43.5 / 45.13)

IMPORTANCE RO 3.0 SRO 4.0

2.4.52 Knowledge of the lines of authority during implementation of the emergency plan, emergency plan implementing procedures, emergency operating procedures, or severe accident guidelines

(CFR: 41.10 / 45.13)

IMPORTANCE RO 3.0 SRO 4.0

3 PLANT SYSTEMS

3.1	Safety Function 1: Reactivity Control	Page
201001	Control Rod Drive Hydraulic System.....	3.1-3
201003	Control Rod and Drive Mechanism.....	3.1-7
201002	Reactor Manual Control System.....	3.1-10
202002	Recirculation Flow Control System.....	3.1-13
202001	Recirculation System.....	3.1-17
201005	Rod Control and Information System.....	3.1-23
211000	Standby Liquid Control System.....	3.1-27

System: 201001 SF1 CRDH Control Rod Drive Hydraulic System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Control Rod Drive Hydraulic System and the following systems: (CFR: 41.1-3 to 41.5-8 / 45.1-6 / 45.8)	
K1.01	Condensate system	3.1
K1.02	Condensate storage tanks	3.2
K1.03	Recirculation pumps seal purge	3.3
K1.04	Head spray (BWR 2)	2.6
K1.05	CRD return to the vessel	3.2
K1.06	Component cooling water systems	3.0
K1.07	Reactor protection system	4.3
K1.08	Reactor manual control system	4.2
K1.09	IA	3.6
K1.10	Control rod drive mechanisms	3.8
K1.11	Reactor water cleanup pumps	2.7
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Pumps	3.5
K2.02	SCRAM valve solenoids	4.2
K2.03	Backup SCRAM valve solenoids	4.1
K2.04	SCRAM discharge volume vent and drain valve solenoids	3.8
K2.05	Alternate rod insertion valve solenoids	3.9
K2.06	Motor-operated valves	2.9
K2.07	Breaker control	3.0
K3	Knowledge of the effect that a loss or malfunction of the Control Rod Drive Hydraulic System will have on the following systems or system parameters: (CFR: 41.5-7 / 45.10 / 45.1-3 / 45.5-6 / 45.8 / 45.12)	
K3.01	Recirculation pumps	3.2
K3.02	Reactor water level	3.2
K3.03	Control rod drive mechanisms	3.7
K3.04	Head spray (BWR 2)	2.5
K3.05	Reactor water cleanup pumps	2.5

System: 201001 SF1 CRDH Control Rod Drive Hydraulic System

K4 Knowledge of Control Rod Drive Hydraulic System design features and/or interlocks that provide for the following:

(CFR: 41.2-3 / 41.6-7 / 41.10 / 45.1-6 / 41.12)

K4.01	Protection against pump runout during SCRAM conditions (location of the CRD system flow element and a restricting orifice in the accumulator charging water line)	3.1
K4.02	Stable system flow when moving control rods using stabilizing valves	3.3
K4.03	Control rod drive mechanism cooling water flow	3.3
K4.04	Scramming control rods with inoperative SCRAM solenoid valves (backup SCRAM valves)	4.0
K4.05	Control rod SCRAM	4.4
K4.06	Isolation of the SCRAM discharge volumes during SCRAM conditions	4.1
K4.07	Testing SCRAM discharge volume isolation valves	2.9
K4.08	Controlling control rod drive header pressure	3.6
K4.09	Controlling control rod drive cooling header pressure	3.3
K4.10	Control of rod movement with HCU directional control valves	3.8
K4.11	Protection against filling the SDV during non-SCRAM conditions	3.7
K4.12	Controlling CRD system flow	3.5
K4.13	Motor cooling	2.7
K4.14	Alternate control rod insertion	4.3

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Control Rod Drive Hydraulic System:

(CFR: 41.5-7 / 41.10 / 45.1-6 / 45.12-13)

K5.01	Pump operation	3.2
K5.02	Flow indication	3.3
K5.03	Pressure indication	3.3
K5.04	DELETED	
K5.05	DELETED	
K5.06	Differential pressure indication	3.4
K5.07	Air-operated control valves	3.1
K5.08	Solenoid-operated valves	3.3
K5.09	System venting	2.7

System: 201001 SF1 CRDH Control Rod Drive Hydraulic System

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Control Rod Drive Hydraulic System:

(CFR: 41.6-7 / 41.10 / 45.1-6 / 45.8 / 45.12-13)

K6.01	Condensate system	2.9
K6.02	Condensate storage tanks	3.0
K6.03	IA	3.6
K6.04	RPS	4.2
K6.05	AC power	3.9
K6.06	Component cooling water systems	3.1
K6.07	Reactor manual control system	3.9
K6.08	SDV instrumentation	3.7

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Control Rod Drive Hydraulic System including:

(CFR: 41.1-2 / 41.5-7 / 41.10 / 45.1-6 / 45.12)

A1.01	CRD drive water header pressure	3.7
A1.02	CRD cooling water header pressure	3.3
A1.03	CRD system flow	3.5
A1.04	Head spray flow (BWR 2)	2.6
A1.05	SDV isolation valve position	3.6
A1.06	HCU pressure or level	3.6
A1.07	Reactor water level	3.4
A1.08	Pump amps	2.8
A1.09	CRD drive water flow	3.3
A1.10	CRD cooling water flow	3.2
A1.11	System lights and alarms	3.5

A2 Ability to (a) predict the impacts of the following on the Control Rod Drive Hydraulic System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.2 / 41.5-7 / 41.10 / 45.1-6 / 41.12-13)

		RO	SRO
A2.01	Pumps trips	4.4	3.9
A2.02	Valve closures due to malfunction(s)	3.8	3.5
A2.03	Power supply failures	4.0	3.5
A2.04	SCRAM conditions	4.7	4.2
A2.05	Discharge strainer(s) becoming plugged	3.5	3.1

System: 201001 SF1 CRDH Control Rod Drive Hydraulic System

A2.06	Suction strainer(s) becoming plugged	3.7	3.1
A2.07	Flow control valve failure	4.0	3.6
A2.08	Inadequate system flow	3.8	3.4
A2.09	Loss of applicable plant air systems	3.9	3.5
A2.10	Low HCU accumulator pressure or high-level	3.7	3.7
A2.11	Valve openings due to malfunction(s)	3.4	3.1
A2.12	High cooling water flow	3.5	3.1
A2.13	Low cooling water flow	3.5	3.1
A2.14	Low drive header pressure	3.9	3.4
A2.15	Pressure control valve failure	4.0	3.5

A3 Ability to monitor automatic operation of the Control Rod Drive Hydraulic System including:

(CFR: 41.1-2 / 41.5-7 / 41.9 / 45.1-6 / 45.8 / 45.12-13)

A3.01	Valve operation	3.3
A3.02	Pump start	3.2
A3.03	System pressure	3.5
A3.04	System flow	3.4
A3.05	Reactor water level	3.4
A3.06	Reactor power	3.6
A3.07	HCU accumulator pressure or level	3.4
A3.08	Drive water flow	3.3
A3.09	Cooling water flow	3.2
A3.10	System lights and alarms	3.4
A3.11	SDV level	3.7

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.5-7 / 41.9 / 41.10 / 45.1-6 / 45.8 / 45.12-13)

A4.01	CRD pumps	3.7
A4.02	CRD pump discharge valve	2.9
A4.03	CRD system flow control valve	3.6
A4.04	Drive water header pressure control valve	3.6
A4.05	Cooling water header pressure control valve	3.3
A4.06	SDV isolation valve test switch	2.8
A4.07	Stabilizing valve selector switch	2.5

System: 201003 SF1 CRDM Control Rod and Drive Mechanism

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Control Rod and Drive Mechanism and the following systems: (CFR: 41.1 to 41.10 / 45.1 to 45.8)	
K1.01	Control rod drive hydraulic system	3.9
K1.02	DELETED	
K1.03	RPIS (BWR 2, 3, 4, 5)	3.8
K1.04	Reactor vessel and internals	3.3
K1.05	DELETED	
K1.06	RCIS (BWR 6)	3.9
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7) None	
K3	Knowledge of the effect that a loss or malfunction of the Control Rod and Drive Mechanism will have on the following systems or system parameters: (CFR: 41.1-2 / 41.7 / 41.10 / 45.1-6 / 4)	
K3.01	Reactor power	4.1
K3.02	DELETED	
K3.03	DELETED	
K3.04	Rod position and indicating system (BWR 2, 3, 4, 5)	3.8
K3.05	RCIS (BWR 6)	3.8
K4	Knowledge of Control Rod and Drive Mechanism design features and/or interlocks that provide for the following: (CFR: 41.1-7 / 41.10 / 45.1-6)	
K4.01	Limiting control rod velocity in the event of a rod drop	3.6
K4.02	DELETED	
K4.03	Slowing the drive mechanism near the end of its travel following a SCRAM	2.9
K4.04	Scramming of the control rod with accumulator or RPV pressure	4.0
K4.05	Rod position indication	3.7
K4.06	Uncoupling/coupling of the control rod from the drive mechanism	3.3
K4.07	Maintaining the control rod at a given position	3.7

System: 201003 SF1 CRDM Control Rod and Drive Mechanism

K4.08	CRD mechanism temperature	3.1
K4.09	Movement of a control rod	4.0
K5	Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Control Rod and Drive Mechanism: (CFR: 41.1-6 / 45.1-6)	
K5.01	Hydraulics	3.6
K5.02	DELETED	
K5.03	DELETED	
K5.04	DELETED	
K5.05	DELETED	
K5.06	DELETED	
K5.07	DELETED	
K5.08	How control rods affect shutdown margin	3.4
K6	Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Control Rod and Drive Mechanism: (CFR: 41.1-6 / 45.1-6)	
K6.01	Control rod drive hydraulic system	3.8
K6.02	Reactor pressure	3.5
K6.03	Reactor manual control system (BWR 2, 3, 4, 5)	3.7
K6.04	RCIS (BWR 6)	3.7
A1	Ability to predict and/or monitor changes in parameters associated with operation of the Control Rod and Drive Mechanism including: (CFR: 41.1-6 / 45.1-6)	
A1.01	DELETED	
A1.02	DELETED	
A1.03	DELETED	
A1.04	CRD mechanism temperature	3.0

System: 201003 SF1 CRDM Control Rod and Drive Mechanism

A2	Ability to (a) predict the impacts of the following on the Control Rod and Drive Mechanism and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations: (CFR: 41.1-6 / 45.1-6)	RO	SRO
A2.01	Stuck rod	4.0	4.0
A2.02	Uncoupled rod	4.4	4.1
A2.03	Drifting rod	4.7	4.2
A2.04	Single control rod SCRAM	4.2	3.8
A2.05	Reactor SCRAM	4.5	4.3
A2.06	Abnormal CRD cooling water flow	3.5	3.2
A2.07	Abnormal CRD drive water flow	3.6	3.3
A2.08	Low HCU accumulator pressure or high-level	3.8	3.4
A2.09	Low reactor pressure	4.0	3.4
A2.10	Excessive SCRAM time	3.7	3.7
A3	Ability to monitor automatic operation of the Control Rod and Drive Mechanism including: (CFR: 41.1-6 / 45.1-6)		
A3.01	DELETED		
A4	Ability to manually operate and/or monitor in the control room: (CFR: 41.1-7 / 45.1-8)		
A4.01	CRD mechanism temperature		3.0
A4.02	DELETED		

System: 201002 SF1 RMCS Reactor Manual Control System (BWR 2, 3, 4, 5)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Reactor Manual Control System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Control rod drive hydraulic system	3.9
K1.02	Control rod and drive mechanism	3.6
K1.03	Fuel handling systems	3.2
K1.04	Rod block monitor	3.8
K1.05	Rod worth minimizer	3.7
K1.06	Rod sequence control system	3.1
K1.07	Plant process computer/parameter display systems	2.9
K1.08	DELETED	
K1.09	RPIS	3.7
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	DELETED	
K2.02	DELETED	
K2.03	RMCS	3.0
K3	Knowledge of the effect that a loss or malfunction of the Reactor Manual Control System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Control rod drive hydraulic system	3.6
K3.02	Rod block monitor	3.2
K3.03	Automatic rod block	3.4
K3.04	Rod worth minimizer	3.2
K3.05	Fuel handling systems	2.9
K3.06	Rod deselect block (BWR 2)	3.0
K4	Knowledge of Reactor Manual Control System design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Detection of sequence timer malfunction	3.1
K4.02	Control rod blocks	3.8
K4.03	Detection of drifting control rods	3.9
K4.04	“Single notch” rod withdrawal and insertion	3.7
K4.05	“Notch override” rod withdrawal	3.6

System:	201002 SF1 RMCS Reactor Manual Control System (BWR 2, 3, 4, 5)		
K4.06	“Emergency In” rod insertion		3.7
K4.07	Timing of rod insert and withdrawal cycles (rod movement sequence timer)		3.2
K4.08	“Continuous In” rod insertion		3.7
K5	Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Reactor Manual Control System: (CFR: 41.5 / 45.3)		
K5.01	Control rod blocks		3.9
K5.02	Refueling equipment interlocks		3.3
K6	Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Reactor Manual Control System: (CFR: 41.7 / 45.7)		
K6.01	Loss of power to RMCS		3.3
K6.02	Rod block monitor		3.4
K6.03	Rod worth minimizer		3.4
K6.04	RPIS		3.5
A1	Ability to predict and/or monitor changes in parameters associated with operation of the Reactor Manual Control System, including: (CFR: 41.5 / 45.5)		
A1.01	CRD drive water flow		3.5
A1.02	Control rod position		4.0
A1.03	DELETED		
A1.04	Reactor power		4.1
A1.05	DELETED		
A1.06	Lights and alarms		3.3
A2	Ability to (a) predict the impacts of the following on the Reactor Manual Control System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations: (CFR: 41.5 / 43.5 / 45.6)		
		RO	SRO
A2.01	Rod movement sequence timer malfunctions	4.0	3.2
A2.02	Rod drift	4.4	4.0
A2.03	Select block	3.1	3.2

System:	201002 SF1 RMCS Reactor Manual Control System (BWR 2, 3, 4, 5)		
A2.04	Control rod block	3.5	3.5
A3	Ability to monitor automatic operation of the Reactor Manual Control System including: (CFR: 41.7 / 45.7)		
A3.01	Control rod block actuation		3.6
A3.02	DELETED		
A3.03	DELETED		
A3.04	Rod movement sequence timer		3.1
A4	Ability to manually operate and/or monitor in the control room: (CFR: 41.7 / 45.5 to 45.8)		
A4.01	Rod movement control switch		4.1
A4.02	Emergency in/notch override switch		4.1
A4.03	Rod drift test switch		2.7
A4.04	Timer malfunction test switch		2.5
A4.05	Rod select matrix		3.8
A4.06	Rod select matrix power switch		3.3

System: 202002 SF1 RFCS Recirculation Flow Control System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Recirculation Flow Control System and the following systems:	
K1.01	Recirculation system	4.2
K1.02	DELETED	
K1.03	DELETED	
K1.04	Reactor/turbine pressure regulating system	3.5
K1.05	DELETED	
K1.06	DELETED	
K1.07	DELETED	
K1.08	Reactor feedwater system	3.7
K1.09	Reactor water level control system	3.8
K1.10	DELETED	
K1.11	Average power range monitor/local power range monitor system	4.1
K1.12	DELETED	
K1.13	Primary containment isolation system/nuclear steam supply shutoff	3.2
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Recirculation flow control system	3.2
K2.02	Hydraulic power unit	2.8
K2.03	AC electrical distribution system	3.6
K2.04	DC electrical distribution system	3.3
K3	Knowledge of the effect that a loss or malfunction of the Recirculation Flow Control System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Core flow	4.4
K3.02	Reactor power	4.6
K3.03	Reactor water level	4.1
K3.04	Reactor/turbine pressure regulation system	3.6
K3.05	Recirculation pump speed	3.8
K3.06	Recirculation flow control valve position	3.9
K3.07	APRM/LPRM	4.1

System: 202002 SF1 RFCS Recirculation Flow Control System

**K4 Knowledge of Recirculation Flow Control System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Scoop tube brake	3.5
K4.02	Recirculation pump speed control	3.8
K4.03	Signal failure detection	3.3
K4.04	DELETED	
K4.05	Limiting recirculation pump speed/loop flow mismatch	3.9
K4.06	Recirculation pump adequate NPSH	3.5
K4.07	Minimum and maximum pump speed setpoints	3.2
K4.08	Recirculation loop flow control	3.8
K4.09	Minimum and maximum flow control valve position (BWR 5, 6)	3.7
K4.10	Flow control valve speed (BWR 5, 6)	3.4
K4.11	Adjustable speed drives/variable frequency drives	3.5
K4.12	Flow control valve runback	4.1

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Recirculation Flow Control System:
(CFR: 41.5 / 45.3)**

K5.01	Fluid coupling (BWR 2, 3, 4)	3.3
K5.02	Feedback signals	3.3
K5.03	Error signals	3.1
K5.04	Rod pattern	3.2
K5.05	Reactor power	4.3
K5.06	Reactor core flow	4.2
K5.07	Feedwater flow	3.6
K5.08	Reactor water level	3.7

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Recirculation Flow Control System:
(CFR: 41.7 / 45.7)**

K6.01	AC electrical distribution system	3.7
K6.02	DC electrical distribution system	3.4
K6.03	Recirculation system	3.8
K6.04	Feedwater flow inputs (BWR 3, 4, 5, 6)	3.6

System: 202002 SF1 RFCS Recirculation Flow Control System

K6.05	Reactor water level	3.6
K6.06	Reactor/turbine pressure regulating system	3.2
K6.07	APRM signal input	3.6
K6.08	Primary containment/drywell pressure	3.0
K6.09	Flow control valves	3.7
K6.10	MG sets/variable frequency drives/adjustable speed drives	3.7
K6.11	Flow controller failure	3.9

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Recirculation Flow Control System, including: (CFR: 41.5 / 45.5)

A1.01	Recirculation pump speed	3.9
A1.02	MG set drive motor amps	3.1
A1.03	MG set generator current, power, voltage	2.9
A1.04	Reactor water level	3.7
A1.05	Reactor power	4.4
A1.06	Reactor core flow	4.2
A1.07	Recirculation loop flow	4.1
A1.08	Recirculation FCV position (BWR 5, 6)	3.8
A1.09	Lights and alarms	3.6
A1.10	Recirculation pump speed	3.7
A1.11	Recirculation system flow	3.9
A1.12	Core flow	4.0

A2 Ability to (a) predict the impacts of the following on the Recirculation Flow Control System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations: (CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Recirculation pump trip	4.4	4.3
A2.02	Loss of AC electrical power	4.0	3.6
A2.03	Loss of DC electrical power	3.6	3.3
A2.04	Recirculation pump speed/loop flow mismatch	3.8	3.8
A2.05	Scoop tube lockup (BWR 2, 3, 4)	3.3	3.7
A2.06	Low reactor water level	4.0	3.6
A2.07	Loss of feedwater signal inputs	3.5	3.4
A2.08	FCV lockup (BWR 5, 6)	4.0	3.7

System: 202002 SF1 RFCS Recirculation Flow Control System

A2.09	Recirculation flow instrumentation	3.8	3.3
A2.10	High primary containment/drywell pressure	4.0	3.1
A2.11	Reactor/turbine pressure regulating system	3.6	3.1
A2.12	APRM/LPRM	3.8	3.4
A2.13	Loss of loop flow signal	3.8	3.5

A3 Ability to monitor automatic operation of the Recirculation Flow Control System, including:
(CFR: 41.7 / 45.7)

A3.01	DELETED		
A3.02	DELETED		
A3.03	DELETED		
A3.04	System lockups/lockouts		3.9
A3.05	System runbacks		4.3

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	MG sets		3.5
A4.02	Hydraulic power unit (BWR 5, 6)		3.4
A4.03	DELETED		
A4.04	DELETED		
A4.05	DELETED		
A4.06	DELETED		
A4.07	DELETED		
A4.08	DELETED		
A4.09	DELETED		
A4.10	Flow control valve		4.0
A4.11	System lockups/lockouts		3.8

System: 202001 SF1 RS Recirculation System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Recirculation System and the following systems: (CFR: 41.2 to 41.8 / 45.7 to 45.8)	
K1.01	DELETED	
K1.02	DELETED	
K1.03	DELETED	
K1.04	Reactor/turbine pressure regulating system	3.4
K1.05	DELETED	
K1.06	DELETED	
K1.07	Component cooling water systems	3.2
K1.08	DELETED	
K1.09	DELETED	
K1.10	Control rod drive system	3.0
K1.11	Drywell equipment/floor drain sump system	2.8
K1.12	DELETED	
K1.13	DELETED	
K1.14	Rod block monitor system	3.0
K1.15	Nuclear boiler instrumentation	3.3
K1.16	Residual heat removal/low-pressure coolant injection	3.5
K1.17	DELETED	
K1.18	Shutdown cooling system (RHR shutdown cooling mode)	3.5
K1.19	Reactor feedwater system	3.1
K1.20	Instrument air system	2.6
K1.21	Reactor water cleanup system	2.8
K1.22	DELETED	
K1.23	APRM/LPRM	3.5
K1.24	Isolation condenser	3.1
K1.25	Reactor water sampling system	2.6
K1.26	Recirculation flow control system	3.9
K1.27	Reactor protection system	3.7
K1.28	DELETED	
K1.29	Redundant reactivity control system (BWR 4, 5, 6)	3.8
K1.30	Reactor vessel internals	3.3
K1.31	Primary containment isolation system	3.3
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Recirculation pumps	3.5

System: 202001 SF1 RS Recirculation System

K2.02	MG sets	3.5
K2.03	Recirculation system valves	3.3
K2.04	DELETED	
K2.05	DELETED	
K2.06	VFDs	3.8
K2.07	VFD cooling water pumps	3.4

**K3 Knowledge of the effect that a loss or malfunction of the Recirculation System will have on the following systems or system parameters:
(CFR: 41.5 to 41.7 / 45.4)**

K3.01	Core flow	4.2
K3.02	DELETED	
K3.03	Reactor power	4.4
K3.04	Reactor water level	4.0
K3.05	DELETED	
K3.06	Residual heat removal/low-pressure coolant injection logic	3.3
K3.07	Vessel bottom head drain temperature	3.2
K3.08	Shutdown cooling system (RHR shutdown cooling mode)	3.5
K3.09	Reactor water cleanup system	2.9
K3.10	APRM/LPRM	3.5
K3.11	Component cooling water systems	2.6
K3.12	Isolation condenser	3.1
K3.13	Reactor water sampling system	2.5
K3.14	Primary containment integrity	2.9
K3.15	Reactor moderator temperature	3.3
K3.16	Reactor pressure	3.5
K3.17	Drywell equipment/floor drain sump system	2.7

**K4 Knowledge of Recirculation System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	2/3 core coverage	4.3
K4.02	Adequate recirculation pump NPSH	3.8
K4.03	Recirculation pump motor cooling	3.3
K4.04	Controlled seal flow	3.3
K4.05	Seal cooling	3.3
K4.06	Automatic voltage/frequency regulation	3.0
K4.07	Motor generator set trips	3.3
K4.08	Oil pump automatic starts	2.8

System: 202001 SF1 RS Recirculation System

K4.09	Pump minimum flow limit	3.2
K4.10	Pump start permissives	3.4
K4.11	Limitation of recirculation pumps flow mismatch	3.8
K4.12	Minimization of reactor vessel bottom head temperature gradients	3.6
K4.13	End-of-cycle recirculation pump trip	3.6
K4.14	ATWS/RPT	4.0
K4.15	Slow-speed pump start	3.2
K4.16	Recirculation pump downshift/runback	3.8
K4.17	Fast-speed pump start	3.3
K4.18	Automatic MG set start sequencing	3.3
K4.19	VFD trips	3.7
K4.20	VFD start sequencing	3.4

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Recirculation System:
(CFR: 41.5 / 45.3)**

K5.01	Indications of pump cavitation	3.5
K5.02	Jet pump operation (BWR 3, 4, 5, 6)	3.7
K5.03	Pump/motor cooling	3.3
K5.04	DELETED	
K5.05	End-of-cycle recirculation pump trip	3.5
K5.06	ATWS RPT	3.8
K5.07	Natural circulation	3.6
K5.08	DELETED	
K5.09	Hydraulically operated valves	2.8
K5.10	Motor generator set operation	3.0
K5.11	Core flow	3.8
K5.12	Reactor power	4.1
K5.13	Reactor moderator temperature	3.4
K5.14	Reactor water level	3.8
K5.15	VFD operation	3.7

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Recirculation System:
(CFR: 41.7 / 45.7)**

K6.01	Jet pumps	4.0
K6.02	Component cooling water systems	3.3
K6.03	AC electrical distribution system	3.5
K6.04	DC electrical distribution system	3.1

System: 202001 SF1 RS Recirculation System

K6.05	Control rod drive system	2.9
K6.06	Recirculation system motor-generator sets	3.2
K6.07	Feedwater flow	3.1
K6.08	Reactor water cleanup system	2.8
K6.09	Reactor water level	3.7
K6.10	Recirculation flow control system	3.8
K6.11	Reactor protection system	3.4
K6.12	APRMs	3.2
K6.13	Redundant reactivity control system	3.4
K6.14	Variable frequency drives	3.7

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Recirculation System, including:
(CFR: 41.5 / 45.5)**

A1.01	Recirculation pump flow	3.1
A1.02	Jet pump flow	3.9
A1.03	Core flow	4.1
A1.04	Reactor water level	3.9
A1.05	Reactor power	4.4
A1.06	Recirculation pump motor amps	3.0
A1.07	Recirculation pump speed	3.2
A1.08	Recirculation FCV position (BWR 5, 6)	3.8
A1.09	Recirculation pump seal pressures	3.5
A1.10	Recirculation seal purge flows	2.9
A1.11	Vessel bottom head drain temperature	3.2
A1.12	Recirculation pump differential pressure	2.9
A1.13	Recirculation loop temperatures	3.4
A1.14	Recirculation drive motor temperature	3.0
A1.15	Recirculation MG set temperatures	2.8
A1.16	Recirculation MG drive motor amps	2.6
A1.17	Recirculation MG set generator current, power, and voltage	2.6
A1.18	Lights and alarms	3.4
A1.19	VFD temperature	3.3
A1.20	VFD cooling water temperature	3.3
A1.21	VFD current, power, and voltage	3.1

System: 202001 SF1 RS Recirculation System

A2 Ability to (a) predict the impacts of the following on the Recirculation System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Jet pump failure	3.9	4.1
A2.02	Recirculation system leak	4.1	4.0
A2.03	Single recirculation pump trip	4.1	4.2
A2.04	Multiple recirculation pump trip	4.5	4.3
A2.05	Inadvertent recirculation flow increase (reference potential)	4.3	4.2
A2.06	Inadvertent recirculation flow decrease	3.8	4.0
A2.07	Recirculation pump speed mismatch	3.5	3.2
A2.08	Recirculation flow mismatch	3.8	3.7
A2.09	DELETED		
A2.10	Recirculation pump seal failure (reference potential)	3.9	3.9
A2.11	Low reactor water level	4.0	3.8
A2.12	Loss of reactor feedwater	3.9	3.6
A2.13	Carryunder	3.4	2.7
A2.14	High reactor pressure (ATWS circuitry initiation)	3.9	3.8
A2.15	End-of-cycle trip circuitry	3.8	3.6
A2.16	Loss of seal purge flow (CRD)	3.4	3.1
A2.17	Loss of seal cooling water	3.8	3.3
A2.18	Loss of motor cooling	3.6	3.1
A2.19	Loss of AC power	3.9	3.4
A2.20	Loss of DC power	3.3	3.1
A2.21	Recirculation loop temperature out of specification	3.8	3.2
A2.22	Loss of component cooling water	3.8	3.2
A2.23	Valve closures due to malfunction(s)	3.6	3.3
A2.24	Valve opening due to malfunction(s)	3.4	3.3
A2.25	Recirculation flow control valve lockup	3.8	3.6
A2.26	Incomplete start sequence	3.0	2.9
A2.27	Failure of RPS end-of-cycle recirculation pump trip circuitry (BWR 5, 6)	3.3	3.5
A2.28	Failure of redundant reactivity control system (BWR 4, 5, 6)	3.5	3.6
A2.29	VFD cell bypass	3.5	3.6
A2.30	VFD cooling system failure	3.5	3.4

A3 Ability to monitor automatic operation of the Recirculation System, including:

(CFR: 41.7 / 45.7)

A3.01	Valve operation		3.6
-------	-----------------	--	-----

System: 202001 SF1 RS Recirculation System

A3.02	Pump/MG set start sequence	3.4
A3.03	DELETED	
A3.04	DELETED	
A3.05	DELETED	
A3.06	Flow control valve position (BWR 5, 6)	3.9
A3.07	Pump trips	4.0
A3.08	Pump downshift (BWR 5, 6)	3.8
A3.09	MG set trip	3.5
A3.10	VFD start sequence	3.4
A3.11	VFD trip	3.9

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Recirculation pumps	4.0
A4.02	System valves	3.8
A4.03	Reactor power	4.4
A4.04	System flow	4.1
A4.05	DELETED	
A4.06	Oil pumps	3.0
A4.07	Vent fans	2.8
A4.08	Motor-generator sets	3.1
A4.09	DELETED	
A4.10	Seal flow	3.1
A4.11	Seal pressures	3.6
A4.12	Core flow	4.1
A4.13	Core differential pressure	3.8
A4.14	Variable frequency drives	3.9
A4.15	VFD cooling water pumps	3.4

System: 201005 SF1 RCIS Rod Control and Information System (BWR 6)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Rod Control and Information System and the following systems: (CFR: 41.2 to 41.7 / 45.8)	
K1.01	APRM/LPRM system	3.9
K1.02	Reactor/turbine pressure regulating system	3.5
K1.03	Control rod drive hydraulic system	3.7
K1.04	DELETED	
K1.05	DELETED	
K1.06	DELETED	
K1.07	DELETED	
K1.08	Intermediate range monitor system	3.6
K1.09	Source range monitor system	3.6
K1.10	Control rod and drive mechanism system	3.6
K1.11	Recirculation flow control system	3.2
K1.12	Fuel handling system	3.0
K2	Knowledge of electrical power supplies to the following: (CFR: 41.6 / 41.7)	
K2.01	RCIS	3.3
K3	Knowledge of the effect that a loss or malfunction of the Rod Control and Information System will have on the following systems or system parameters: (CFR: 41.6 and 41.7 / 45.4–45.6)	
K3.01	Control rod drive hydraulic system	3.4
K3.02	DELETED	
K3.03	DELETED	
K3.04	Flux shaping	3.1
K3.05	Control rod drive mechanism system	3.1
K3.06	Fuel handling system	3.0
K3.07	Reactor protection system	3.4
K4	Knowledge of Rod Control and Information System design features and/or interlocks that provide for the following: (CFR: 41.5–41.7)	
K4.01	Limiting the effects of a control rod accident	3.9
K4.02	Bank position withdrawal sequence	3.7

System: 201005 SF1 RCIS Rod Control and Information System (BWR 6)

K4.03	Rod withdrawal block signals	4.0
K4.04	Rod insertion block signals	3.9
K4.05	Rod withdrawal limiter	3.8
K4.06	DELETED	
K4.07	RPIS	3.9
K4.08	RACS	3.5
K4.09	Rod gang drive	3.5
K4.10	Rod interface system	3.6
K4.11	Rod pattern controller	3.8
K4.12	Rod withdrawal limiter	3.8
K4.13	Temperature monitoring	2.7

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Rod Control and Information System:
(CFR: 41.5–41.7 / 45.3 / 45.5)

K5.01	DELETED	
K5.02	DELETED	
K5.03	Rod groups	3.3
K5.04	Rod sequences	3.7
K5.05	DELETED	
K5.06	Target rod pattern	3.3
K5.07	Low-power alarm point	3.3
K5.08	Transition zone	3.2
K5.09	High-power setpoints	3.7
K5.10	DELETED	
K5.11	Control rod motion	3.8
K5.12	RACS channel agreement and multiplexing	3.4
K5.13	Position indication	3.8
K5.14	Low-power setpoint	3.6
K5.15	Changes in reactor power	4.2

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Rod Control and Information System:
(CFR: 41.7 / 45.7)

K6.01	First stage shell pressure or opening of a bypass valve(s)	3.8
K6.02	Rod position signal	3.7
K6.03	AC electrical distribution system	3.3
K6.04	Intermediate range monitor system	3.7

System: 201005 SF1 RCIS Rod Control and Information System (BWR 6)

K6.05	Source range monitor system	3.7
K6.06	APRM/LPRM system	3.7
K6.07	Fuel handling system	3.1
K6.08	Gang misalignment	2.7

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Rod Control and Information System, including:
(CFR: 41.5 / 45.5)

A1.01	First stage shell pressure/turbine load	3.5
A1.02	Reactor power	4.1
A1.03	Lights and alarms	3.6

A2 Ability to (a) predict the impacts of the following on the Rod Control and Information System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6 / 45.8)

		RO	SRO
A2.01	High flux (SRMS, IRM, APRM)	4.3	4.0
A2.02	Position indication probe failure	3.3	3.9
A2.03	Insert block	3.4	3.7
A2.04	Withdraw block	3.7	3.8
A2.05	Insert required	3.4	3.4
A2.06	Insert inhibit	3.3	3.7
A2.07	Withdraw inhibit	3.3	3.7
A2.08	LPRM upscale/downscale	3.3	3.5
A2.09	Test display blinking	2.7	2.9
A2.10	Data fault	2.9	3.4
A2.11	DELETED		
A2.12	DELETED		
A2.13	Rod drift	4.4	4.2
A2.14	AC electrical distribution system malfunction	3.4	3.4
A2.15	Fuel handling system malfunction	3.1	3.3
A2.16	Gang misalignment	2.7	2.8

A3 Ability to monitor automatic operation of the Rod Control and Information System, including:
(CFR: 41.7 / 45.7)

A3.01	Operator control module lights	3.6
A3.02	Rod display module lights	3.7
A3.03	Verification of proper functioning/operability	3.9

System: 201005 SF1 RCIS Rod Control and Information System (BWR 6)

A3.04 DELETED

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Operator control module (lights and push buttons)	3.8
A4.02	Rod display module (lights and push buttons)	3.7
A4.03	Back panel indicating lights	3.3
A4.04	Bypassing rod position in RACS	3.7
A4.05	Bypassing a rod drive in rod gang drive system	3.6

System: 211000 SF1 SLCS Standby Liquid Control System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Standby Liquid Control System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Leak detection system	2.6
K1.02	Nuclear boiler instrumentation	3.0
K1.03	Plant air systems	2.5
K1.04	Demineralized water/condensate storage system	2.4
K1.05	RWCU system	3.8
K1.06	Reactor vessel internals	3.3
K1.07	Reactor recirculation system	2.9
K1.08	CRD system	2.7
K1.09	Core spray system	3.0
K1.10	HPCI	2.4
K1.11	Redundant reactivity control system	3.6
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	SLCS pumps	3.6
K2.02	Squib valves	3.5
K2.03	Heater power	2.5
K3	Knowledge of the effect that a loss or malfunction of the Standby Liquid Control System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor power	4.0
K3.02	Leak detection system	2.4
K3.03	Core plate differential pressure	3.0
K3.04	Jet pump differential pressure (BWR 3, 4, 5, 6)	2.8
K3.05	CRD drive and cooling water differential pressure	2.4
K4	Knowledge of Standby Liquid Control System design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Zero leakage to the reactor (squib valves)	3.3
K4.02	Component and system testing	3.0
K4.03	Keeping sodium pentaborate in solution	3.6

System: 211000 SF1 SLCS Standby Liquid Control System

K4.04	Indication of a fault in squib valves firing circuits	3.7
K4.05	Dispersal of boron upon injection into the vessel	3.3
K4.06	DELETED	
K4.07	RWCU isolation	4.0
K4.08	SLCS initiation	4.1
K4.09	Dampening of positive displacement pump discharge oscillations	2.7
K4.10	Overpressure protection	2.9
K4.11	Automatic system initiation	3.8
K4.12	SLCS pump trips	3.3
K4.13	Tank heater operation	2.8

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Standby Liquid Control System:
(CFR: 41.5 / 45.3)**

K5.01	Effects of the moderator temperature coefficient of reactivity on boron	3.0
K5.02	DELETED	
K5.03	Shutdown margin	3.7
K5.04	Squib valve operation	3.7
K5.05	Accumulator operation	2.8
K5.06	DELETED	
K5.07	DELETED	
K5.08	SLCS pressure/relief valve operation	2.9

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Standby Liquid Control System:
(CFR: 41.7 / 45.7)**

K6.01	Plant air systems	2.5
K6.02	Demineralized water system	2.3
K6.03	AC power	3.7
K6.04	Core spray system	2.8
K6.05	HPCI	2.2
K6.06	Redundant reactivity control system	3.6

**A1 Ability to predict or monitor changes in parameters associated with operation of the Standby Liquid Control System, including:
(CFR: 41.5 / 45.5)**

A1.01	Tank level	3.8
-------	------------	-----

System: 211000 SF1 SLCS Standby Liquid Control System

A1.02	Explosive squib valves status	4.0
A1.03	Pump discharge pressure	3.9
A1.04	Valve position	3.5
A1.05	Pump amps	2.9
A1.06	SLCS pump/system flow	3.7
A1.07	Reactor power	4.2
A1.08	RWCU system lineup	3.9
A1.09	SLCS lineup	3.8
A1.10	Lights and alarms	3.6

A2 Ability to (a) predict the impacts of the following on the Standby Liquid Control System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Pump trip	4.2	3.8
A2.02	Failure of squib valves to open	4.1	4.0
A2.03	AC power failures	3.9	3.7
A2.04	Inadequate SLCS system flow	3.9	3.8
A2.05	Loss of SLCS tank heaters	3.1	3.0
A2.06	Abnormal valve position	3.7	3.4
A2.07	DELETED		
A2.08	DELETED		
A2.09	Automatic or manual initiation failure	4.4	4.1

A3 Ability to monitor automatic operation of the Standby Liquid Control System, including:

(CFR: 41.7 / 45.7)

A3.01	DELETED		
A3.02	DELETED		
A3.03	DELETED		
A3.04	DELETED		
A3.05	DELETED		
A3.06	RWCU system isolation	4.1	
A3.07	DELETED		
A3.08	System initiation	4.1	
A3.09	Pump trip	3.8	

System: 211000 SF1 SLCS Standby Liquid Control System

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

A4.01	DELETED	
A4.02	SLCS control switch	4.1
A4.03	DELETED	
A4.04	DELETED	
A4.05	DELETED	
A4.06	RWCU system isolation	4.0
A4.07	DELETED	
A4.08	System initiation	4.3

3.2	Safety Function 2: Reactor Water Inventory Control	Page
206000	High-Pressure Coolant Injection System.....	3.2-3
209002	High-pressure Core Spray System.....	3.2-8
209001	Low-Pressure Core Spray System.....	3.2-12
256000	Condensate System.....	3.2-16
217000	Reactor Core Isolation Cooling System.....	3.2-21
259001	Feedwater System.....	3.2-26
204000	Reactor Water Cleanup System.....	3.2-30
259002	Reactor Water Level Control System.....	3.2-34
203000	Residual Heat Removal/Low-Pressure Coolant Injection: Injection Mode	3.2-38

System: 206000 SF2 HPCI High-Pressure Coolant Injection System (BWR 2, 3, 4)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the High-Pressure Coolant Injection System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Reactor vessel and internals	3.5
K1.02	DELETED	
K1.03	DELETED	
K1.04	Feedwater system	3.7
K1.05	Condensate system	3.0
K1.06	Primary containment	3.5
K1.07	DELETED	
K1.08	DELETED	
K1.09	DELETED	
K1.10	DELETED	
K1.11	DELETED	
K1.12	Nuclear boiler instrumentation	3.6
K1.13	DELETED	
K1.14	SGTS	2.7
K1.15	Instrument air system	2.6
K1.16	DELETED	
K1.17	Reactor protection system	2.8
K1.18	Main steam system	3.4
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Motor-operated valves	3.7
K2.02	Pumps	3.2
K2.03	Initiation/isolation logic	4.1
K2.04	Turbine control circuits	3.3
K3	Knowledge of the effect that a loss or malfunction of the High-Pressure Coolant Injection System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor water level	4.3
K3.02	Reactor pressure	3.8

System: 206000 SF2 HPCI High-Pressure Coolant Injection System (BWR 2, 3, 4)

K3.03	Suppression pool level	3.4
K3.04	Reactor power	3.6
K3.05	Secondary containment parameters	3.1

**K4 Knowledge of High-Pressure Coolant Injection System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Turbine trips	3.8
K4.02	System isolations	4.2
K4.03	Resetting turbine trips	3.8
K4.04	Resetting system isolations	3.9
K4.05	Preventing water hammer in turbine exhaust line (vacuum breakers)	3.4
K4.06	Preventing water hammer in pump discharge line (keep fill)	3.3
K4.07	Automatic system initiation	4.4
K4.08	Manual system initiation	4.3
K4.09	Automatic flow control	3.9
K4.10	DELETED	
K4.11	Turbine speed control	3.7
K4.12	Condensation of shaft sealing steam	2.5
K4.13	Turbine and pump lubrication	3.2
K4.14	Control oil to turbine speed controls	3.1
K4.15	Low-speed turning of the turbine rotor	2.5
K4.16	DELETED	
K4.17	DELETED	
K4.18	Pump minimum flow	3.2
K4.19	Automatic transfer of HPCI pump suction	3.7
K4.20	Testable check valve operation	2.3

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the High-Pressure Coolant Injection System:
(CFR: 41.5 / 45.3)**

K5.01	Turbine operation	3.5
K5.02	Turbine shaft sealing	2.6
K5.03	Flow control	3.7
K5.04	Indications of pump cavitation	3.2
K5.05	Turbine speed control	3.5
K5.06	Turbine speed measurement	2.7
K5.07	DELETED	

System: 206000 SF2 HPCI High-Pressure Coolant Injection System (BWR 2, 3, 4)

K5.08	DELETED	
K5.09	DELETED	
K5.10	Reactor pressure control	3.9

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the High-Pressure Coolant Injection System:
(CFR: 41.7 / 45.7)

K6.01	Instrument air system	2.6
K6.02	DC electrical distribution system	3.9
K6.03	AC electrical distribution system	3.3
K6.04	Condensate storage tank low level	3.7
K6.05	Suppression pool level	3.7
K6.06	SGTS	3.0
K6.07	Keep fill system	3.0
K6.08	Low reactor pressure	3.4
K6.09	DELETED	
K6.10	HPCI initiation/isolation logic	4.3
K6.11	Nuclear boiler instrumentation	3.6
K6.12	Reactor water level	4.0
K6.13	High suppression pool temperature	3.6
K6.14	Feedwater system	3.3
K6.15	Low-pressure core spray system	2.5
K6.16	High turbine exhaust pressure	3.6
K6.17	High steam flow	3.7
K6.18	Area high temperature	3.9
K6.19	High drywell pressure	4.0
K6.20	Auxiliary oil pump	3.8
K6.21	Component cooling water	3.0

A1 Ability to predict and/or monitor changes in parameters associated with operation of the High-Pressure Coolant Injection System, including:
(CFR: 41.5 / 45.5)

A1.01	Reactor water level	4.3
A1.02	Reactor pressure	4.1
A1.03	Condensate storage tank level	3.5
A1.04	Suppression pool level	3.6
A1.05	Suppression pool temperature	3.8
A1.06	System flow	3.9

System: 206000 SF2 HPCI High-Pressure Coolant Injection System (BWR 2, 3, 4)

A1.07	System discharge pressure	3.8
A1.08	DELETED	
A1.09	Turbine speed	3.5
A1.10	Lights and alarms	3.6
A1.11	Secondary containment parameters	3.1
A1.12	Turbine bearing temperature	3.0

**A2 Ability to (a) predict the impacts of the following on the High-Pressure Coolant Injection System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	Turbine trips	4.3	4.1
A2.02	DELETED		
A2.03	Abnormal valve positions	4.0	3.7
A2.04	AC electrical distribution system failures	4.0	3.5
A2.05	DC electrical distribution system failures	4.3	3.9
A2.06	Inadequate system flow	4.3	3.6
A2.07	High/low suppression pool level	4.2	3.6
A2.08	High suppression pool temperature	4.3	3.6
A2.09	Low condensate storage tank level	3.8	3.5
A2.10	System isolation	4.7	4.0
A2.11	High/low reactor water level	4.3	4.1
A2.12	Loss of room cooling	3.3	2.8
A2.13	Loss of instrument air system	3.2	2.5
A2.14	Flow controller failure	4.3	3.6
A2.15	Loss of control oil pressure	4.3	3.7
A2.16	High drywell pressure	4.5	3.8
A2.17	Inadvertent initiation	4.3	3.9

**A3 Ability to monitor automatic operation of the High-Pressure Coolant Injection System, including:
(CFR: 41.7 / 45.7)**

A3.01	DELETED	
A3.02	DELETED	
A3.03	System initiation	4.4
A3.04	DELETED	
A3.05	DELETED	
A3.06	DELETED	
A3.07	DELETED	
A3.08	DELETED	
A3.09	System isolation	4.3
A3.10	Pump suction transfer	3.6
A3.11	Barometric condenser level control	2.5

System: 206000 SF2 HPCI High-Pressure Coolant Injection System (BWR 2, 3, 4)

A3.12 Turbine reset 3.8

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Turbine speed control	4.2
A4.02	Flow controller	4.3
A4.03	DELETED	
A4.04	Valves	3.8
A4.05	DELETED	
A4.06	DELETED	
A4.07	DELETED	
A4.08	DELETED	
A4.09	DELETED	
A4.10	Pumps	3.7
A4.11	Turning gear	2.4
A4.12	Turbine trip	4.1
A4.13	Initiation reset	4.0
A4.14	DELETED	
A4.15	Isolation reset	4.0

System: 209002 SF2 HPCS High-Pressure Core Spray System (BWR 5, 6)

K/A NO. KNOWLEDGE IMPORTANCE

K1 Knowledge of the physical connections and/or cause and effect relationships between the High-Pressure Core Spray System and the following systems:
(CFR: 41.2 to 41.9 / 45.7 to 45.8)

K1.01	Condensate system	3.2
K1.02	Primary containment	3.6
K1.03	DELETED	
K1.04	Emergency generators	4.0
K1.05	Standby liquid control system	3.3
K1.06	Suppression pool cleanup system	2.8
K1.07	Plant ventilation systems (HPCS room coolers)	3.1
K1.08	Component cooling water systems	3.1
K1.09	Leak detection	3.2
K1.10	DELETED	
K1.11	DELETED	
K1.12	Reactor vessel and internals	3.7
K1.13	Instrument nitrogen	2.1
K1.14	Instrument air system	2.4
K1.15	Safety-related service water	3.6

K2 Knowledge of electrical power supplies to the following:
(CFR: 41.7)

K2.01	Pumps	4.2
K2.02	Valves	3.9
K2.03	Initiation logic	4.2

K3 Knowledge of the effect that a loss or malfunction of the High-Pressure Core Spray System will have on the following systems or system parameters:
(CFR: 41.7 / 45.4)

K3.01	Reactor water level	4.3
K3.02	Standby liquid control system	3.0
K3.03	DELETED	
K3.04	Suppression pool level	3.3
K3.05	Reactor power	3.6
K3.06	Reactor pressure	3.7
K3.07	Secondary containment parameters	2.9
K3.08	Condensate storage tank level	3.2
K3.09	Override of drywell pressure interlock	3.6

System: 209002 SF2 HPCS High-Pressure Core Spray System (BWR 5, 6)

**K4 Knowledge of High-Pressure Core Spray System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Prevention of water hammer (keep fill)	3.5
K4.02	Prevention of overfilling reactor vessel	4.0
K4.03	Prevention of pump overheating	3.2
K4.04	Testable check valve operation	2.4
K4.05	DELETED	
K4.06	DELETED	
K4.07	Override of reactor water level interlock	4.0
K4.08	Automatic system initiation	4.4
K4.09	Manual system initiation	4.2
K4.10	Uniform core spray coverage	3.1
K4.11	Prevention of piping overpressurization	3.2
K4.12	Automatic transfer of HPCS pump suction	3.8

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the High-Pressure Core Spray System:
(CFR: 41.5 / 45.3)**

K5.01	Indications of pump cavitation	3.5
K5.02	DELETED	
K5.03	DELETED	
K5.04	Adequate core cooling	4.5

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the High-Pressure Core Spray System:
(CFR: 41.7 / 45.7)**

K6.01	Loss of AC electrical distribution	4.2
K6.02	Abnormal condensate storage tank water level	3.6
K6.03	Component cooling water systems	3.1
K6.04	Suppression pool suction strainer	3.4
K6.05	Abnormal suppression pool water level	3.7
K6.06	Keep fill system	3.3
K6.07	Plant ventilation systems (HPCS room coolers)	3.3
K6.08	Loss of DC electrical distribution	3.8
K6.09	Abnormal reactor water level	4.2

System: 209002 SF2 HPCS High-Pressure Core Spray System (BWR 5, 6)

K6.10	High drywell pressure	4.1
K6.11	High suppression pool temperature	3.5

A1 Ability to predict and/or monitor changes in parameters associated with operation of the High-Pressure Core Spray System, including:
(CFR: 41.5 / 45.5)

A1.01	System flow	4.0
A1.02	System pressure	3.9
A1.03	Reactor water level	4.3
A1.04	Reactor pressure	3.9
A1.05	Suppression pool level	3.6
A1.06	DELETED	
A1.07	Diesel loading	3.8
A1.08	System lineup	3.9
A1.09	Condensate storage tank level	3.6
A1.10	Lights and alarms	3.7
A1.11	Suppression pool temperature	3.3
A1.12	Reactor power	3.8

A2 Ability to (a) predict the impacts of the following on the High-Pressure Core Spray System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Automatic system initiation	4.5	4.4
A2.02	Pump trips	4.1	3.9
A2.03	Abnormal valve positions	4.1	3.9
A2.04	Loss of AC electrical distribution	4.1	4.0
A2.05	Loss of DC electrical distribution	4.0	3.9
A2.06	Core spray line break	4.0	3.6
A2.07	Pump seal failure	3.5	3.3
A2.08	Inadequate system flow	4.0	3.8
A2.09	Loss of plant ventilation (HPCS room cooler)	3.1	3.3
A2.10	DELETED		
A2.11	Low suppression pool level	3.8	3.5
A2.12	High suppression pool level	3.4	3.2
A2.13	Low condensate storage tank level	3.4	3.7
A2.14	High suppression pool temperature	3.4	3.4
A2.15	Clogged suppression pool suction strainers	3.8	3.4
A2.16	Emergency diesel generator failure	4.3	3.9
A2.17	Initiation logic failure	4.5	4.2

System: 209002 SF2 HPCS High-Pressure Core Spray System (BWR 5, 6)

A2.18	Keep fill system failure	3.6	3.3
A2.19	Abnormal reactor water level	4.1	3.9
A2.20	High drywell pressure	4.3	3.9
A2.21	Inadvertent initiation	4.0	3.4

**A3 Ability to monitor automatic operation of the High-Pressure Core Spray System, including:
(CFR: 41.7 / 45.7)**

A3.01	Valve operation	4.2	
A3.02	Pump start	4.1	
A3.03	DELETED		
A3.04	DELETED		
A3.05	DELETED		
A3.06	DELETED		
A3.07	Emergency diesel generator operation	4.1	
A3.08	Pump trip	4.0	

**A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)**

A4.01	HPCS pump	4.3	
A4.02	Suction valves	4.0	
A4.03	Injection valve	4.3	
A4.04	Minimum flow valve	3.8	
A4.05	Manual initiation controls	4.3	
A4.06	Testable check valve	2.4	
A4.07	Keep fill pump	3.2	
A4.08	DELETED		
A4.09	DELETED		
A4.10	DELETED		
A4.11	DELETED		
A4.12	DELETED		
A4.13	DELETED		
A4.14	Test return valve	3.3	
A4.15	Initiation reset	3.9	
A4.16	Emergency diesel generator operation	4.3	

System: 209001 SF2 LPCS Low-Pressure Core Spray System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Low-Pressure Core Spray System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	DELETED	
K1.02	Primary containment	3.7
K1.03	DELETED	
K1.04	Condensate system	2.6
K1.05	Automatic depressurization system	4.2
K1.06	Instrument air system	2.4
K1.07	DELETED	
K1.08	DELETED	
K1.09	Nuclear boiler instrumentation	3.6
K1.10	Emergency generators	4.2
K1.11	Drywell coolers	2.4
K1.12	ECCS room coolers	3.1
K1.13	Leak detection	3.2
K1.14	Reactor vessel and internals	3.7
K1.15	Residual heat removal system	3.3
K1.16	High-pressure coolant injection system	3.0
K1.17	Standby liquid control	2.7
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Pumps	4.2
K2.02	Valves	3.8
K2.03	Initiation logic	4.1
K3	Knowledge of the effect that a loss or malfunction of the Low-Pressure Core Spray System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor water level	4.3
K3.02	ADS logic	4.1
K3.03	Emergency generators	3.6
K3.04	DELETED	
K3.05	Drywell cooling	2.8

System: 209001 SF2 LPCS Low-Pressure Core Spray System

**K4 Knowledge of Low-Pressure Core Spray System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Prevention of overpressurization of core spray piping	3.5
K4.02	Prevents water hammer	3.4
K4.03	Motor cooling	2.9
K4.04	Line break detection	3.4
K4.05	Pump minimum flow	3.4
K4.06	Adequate pump net positive suction head	3.4
K4.07	DELETED	
K4.08	Automatic system initiation	4.5
K4.09	Load sequencing	4.0
K4.10	DELETED	
K4.11	Override injection	3.9

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Low-Pressure Core Spray System:
(CFR: 41.5 / 45.3)**

K5.01	DELETED	
K5.02	Abnormal differential pressure indication (leak detection)	3.4
K5.03	Testable check valve operation	2.5
K5.04	Heat removal (transfer) mechanisms	3.2
K5.05	DELETED	
K5.06	DELETED	
K5.07	Adequate core cooling	4.5

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Low-Pressure Core Spray System:
(CFR: 41.7 / 45.7)**

K6.01	Loss of AC electrical distribution system	4.2
K6.02	Loss of emergency generators	4.2
K6.03	Torus/suppression pool water level	3.7
K6.04	Loss of DC electrical distribution system	3.9
K6.05	ECCS room cooler(s)	3.4
K6.06	Pump motor cooler(s)	2.9
K6.07	Pump seal cooler(s)	2.9
K6.08	Keep fill system	3.4

System: 209001 SF2 LPCS Low-Pressure Core Spray System

K6.09	DELETED	
K6.10	ECCS room integrity	3.1
K6.11	ADS	4.1
K6.12	Suppression pool suction strainer	3.4
K6.13	High drywell pressure	4.3
K6.14	Low reactor water level	4.3
K6.15	Condensate storage tank low level	2.8

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Low-Pressure Core Spray System, including:
(CFR: 41.5 / 45.5)**

A1.01	Core spray flow	4.1
A1.02	Core spray pressure	3.9
A1.03	Reactor water level	4.4
A1.04	Reactor pressure	4.1
A1.05	Torus/suppression pool water level	3.6
A1.06	DELETED	
A1.07	Emergency generator loading	3.9
A1.08	System lineup	4.0
A1.09	Lights and alarms	3.7
A1.10	Suppression pool temperature	3.3

**A2 Ability to (a) predict the impacts of the following on the Low-Pressure Core Spray System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	Pump trips	4.1	3.9
A2.02	Valve closures due to malfunction(s)	3.9	3.8
A2.03	AC failures	4.0	4.0
A2.04	DC failures	3.7	4.0
A2.05	Core spray line break	4.0	3.5
A2.06	Inadequate system flow	4.3	3.7
A2.07	Loss of room cooling	3.3	3.2
A2.08	Valve openings due to malfunction(s)	3.9	3.5
A2.09	Low suppression pool level	3.8	3.5
A2.10	High suppression pool temperature	3.5	3.3
A2.11	Loss of fire protection	2.3	2.0
A2.12	Inadvertent system initiation	4.4	4.3

System: 209001 SF2 LPCS Low-Pressure Core Spray System

A3 Ability to monitor automatic operation of the Low-Pressure Core Spray System, including:
(CFR: 41.7 / 45.7)

A3.01	Valve operation	4.2
A3.02	Pump start	4.3
A3.03	DELETED	
A3.04	DELETED	
A3.05	DELETED	
A3.06	DELETED	

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Core spray pump	4.3
A4.02	Valves	4.2
A4.03	DELETED	
A4.04	DELETED	
A4.05	Manual initiation controls	4.2
A4.06	DELETED	
A4.07	Keep fill pump	3.0
A4.08	DELETED	
A4.09	DELETED	
A4.10	DELETED	
A4.11	DELETED	
A4.12	DELETED	
A4.13	DELETED	
A4.14	DELETED	
A4.15	Initiation reset	3.6

System: 256000 SF2 CDS Condensate System

Sub Systems: Condensate Polishing Condensate Transfer Condenser Air Removal

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Condensate System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Main turbine	2.9
K1.02	Reactor feedwater system	3.9
K1.03	HPCI	3.4
K1.04	RCIC	3.1
K1.05	CRD hydraulics system	3.3
K1.06	Extraction steam system	2.9
K1.07	SJAE condenser system	3.0
K1.08	Gland seal steam system	2.9
K1.09	Offgas condenser	2.9
K1.10	Exhaust hood spray system	2.8
K1.11	Instrument air system	3.0
K1.12	DELETED	
K1.13	Reactor water level control system	3.9
K1.14	RHR (LPCI)	2.6
K1.15	HPCI	2.9
K1.16	RWCU	2.2
K1.17	ECCS keep fill system	2.8
K1.18	Circulating water system	2.6
K1.19	Component cooling water systems	2.7
K1.20	Demineralized water storage and makeup system	2.5
K1.21	Steam seal evaporator	2.5
K1.22	Offgas system	2.8
K1.23	Auxiliary steam system	2.1
K1.24	Radwaste system	2.2
K1.25	Main steam system	2.7
K1.26	Condensate demineralizer system	3.3
K1.27	Condensate filter system	3.1
K1.28	Heater drains and vent system	3.0
K1.29	Hydrogen water chemistry system	2.8
K1.30	Oxygen injection system	2.7
K1.31	Noble metal injection system	2.2
K1.32	Zinc injection system	2.2

System: 256000 SF2 CDS Condensate System

**K2 Knowledge of electrical power supplies to the following:
(CFR: 41.7)**

K2.01	System pumps	3.4
K2.02	Motor-operated valves	2.7

**K3 Knowledge of the effect that a loss or malfunction of the Condensate System will have on the following systems or system parameters:
(CFR: 41.7 / 45.4)**

K3.01	Main turbine/main generator	3.2
K3.02	CRD hydraulics system	3.1
K3.03	Extraction steam system	2.8
K3.04	Reactor feedwater system	4.1
K3.05	HPCI	2.9
K3.06	RCIC	2.8
K3.07	DELETED	
K3.08	SJAE system	3.0
K3.09	Offgas system	2.8
K3.10	Gland seal steam system	2.8
K3.11	Reactor water level	4.2
K3.12	HPCI	2.9
K3.13	Main steam system	2.8
K3.14	Exhaust hood spray system	2.5
K3.15	ECCS keep fill system	2.9
K3.16	Condensate demineralizer system	3.0
K3.17	Condensate filter system	2.8
K3.18	Heater drains and vent system	2.6
K3.19	Hydrogen water chemistry system	2.6
K3.20	Oxygen injection system	2.5

**K4 Knowledge of Condensate System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Condensate or booster pump automatic start	3.5
K4.02	CRD pump suction	3.3
K4.03	Condensate or booster pump protection	3.1
K4.04	Maintaining water quality	3.0
K4.05	Maintaining 100-percent system flow if a feedwater string isolates	3.3
K4.06	Control of extraction steam	2.8
K4.07	Cascading heater drains	3.0

System: 256000 SF2 CDS Condensate System

K4.08	Dedicated ECCS water supply	3.1
K4.09	Initial main condenser vacuum	2.9
K4.10	Noncondensable gas removal	2.8
K4.11	Isolation of SJAEs	2.8
K4.12	Bypassing of condensate filters or demineralizers	3.0

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Condensate System:
(CFR: 41.5 / 45.3)

K5.01	DELETED	
K5.02	Water conductivity	3.0
K5.03	Heat exchanger level operation	2.9
K5.04	DELETED	
K5.05	De-aeration of condensate	2.4
K5.06	DELETED	
K5.07	Reactor water level	3.9
K5.08	DELETED	
K5.09	DELETED	
K5.10	Air ejection operation	2.8

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Condensate System:
(CFR: 41.7 / 45.7)

K6.01	Instrument air systems	3.5
K6.02	Circulating water system	2.9
K6.03	Extraction steam system	3.0
K6.04	AC electrical distribution	3.5
K6.05	Component cooling water systems	2.9
K6.06	Reactor feedwater system	3.7
K6.07	Demineralized water storage and makeup system	2.5
K6.08	Main turbine	2.8
K6.09	Offgas system	2.6
K6.10	Main steam system	2.7
K6.11	Condensate demineralizer system	3.3
K6.12	Condensate filter system	3.2
K6.13	Heater drains and vent system	2.8

System: 256000 SF2 CDS Condensate System

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Condensate System, including:
(CFR: 41.5 / 45.5)

A1.01	System flow	3.6
A1.02	Pump amps	2.9
A1.03	System pressure	3.4
A1.04	Hotwell level	3.5
A1.05	Condensate storage tank level	3.0
A1.06	Reactor water level	4.0
A1.07	System lineup	3.3
A1.08	System water quality	2.8
A1.09	Feedwater temperature	3.5
A1.10	Condenser vacuum	3.5
A1.11	Lights and alarms	3.4

A2 Ability to (a) predict the impacts of the following on the Condensate System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Pump trips	4.2	3.9
A2.02	Valve closures due to malfunction(s)	3.9	3.6
A2.03	Valve openings due to malfunction(s)	3.8	3.4
A2.04	AC power failures	3.9	3.7
A2.05	Inadequate system flow	3.9	3.7
A2.06	Low hotwell level	3.9	3.4
A2.07	High hotwell level	3.0	3.0
A2.08	High feedwater heater level	3.6	3.3
A2.09	Low feedwater heater level	3.6	3.2
A2.10	Main turbine trip	3.7	2.9
A2.11	Loss of circulating water system	3.6	3.1
A2.12	Loss of component cooling water systems	3.3	2.9
A2.13	Loss of instrument air system	3.8	3.3
A2.14	Low condensate storage tank level	3.3	3.0
A2.15	Abnormal water quality	3.0	2.8
A2.16	High demineralizer differential pressure	3.2	3.0
A2.17	Feedwater heater string trip	3.6	3.5
A2.18	Loss of SJAE	3.6	3.1
A2.19	Condensate filter high differential pressure	3.1	2.9

System: 256000 SF2 CDS Condensate System

A3 Ability to monitor automatic operation of the Condensate System, including:
(CFR: 41.7 / 45.7)

A3.01	DELETED	
A3.02	Pump starts	3.4
A3.03	System pressure	3.4
A3.04	System flow	3.5
A3.05	DELETED	
A3.06	Hotwell level	3.3
A3.07	Feedwater heater level	3.3
A3.08	DELETED	
A3.09	Feedwater heater drain tank level	3.0
A3.10	Pump trips	3.7
A3.11	Condensate filter/demineralizer automatic bypass	3.0

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Condensate/condensate booster pumps	3.8
A4.02	System motor-operated valves	3.3
A4.03	Hotwell level controls	3.3
A4.04	Minimum flow valves	3.4
A4.05	System flow	3.6
A4.06	System pressure	3.5
A4.07	DELETED	
A4.08	Reactor water level	4.2
A4.09	DELETED	
A4.10	DELETED	
A4.11	Condensate storage tank level	3.1
A4.12	Feedwater heater level	3.2
A4.13	DELETED	
A4.14	Feedwater heater drain tank level	3.1
A4.15	Air ejectors	3.0

System: 217000 SF2 RCIC Reactor Core Isolation Cooling System

K/A NO. KNOWLEDGE IMPORTANCE

K1 Knowledge of the physical connections and/or cause and effect relationships between the Reactor Core Isolation Cooling System and the following systems:
(CFR: 41.2 to 41.9 / 45.7 to 45.8)

K1.01	Condensate system	3.1
K1.02	Nuclear boiler Instrumentation	3.7
K1.03	Suppression pool	3.8
K1.04	DELETED	
K1.05	Residual heat removal system	2.8
K1.06	Instrument air systems	2.5
K1.07	Leak detection	3.3
K1.08	DELETED	
K1.09	Reactor vessel and internals	3.3
K1.10	Main steam system	3.6
K1.11	Radwaste system	1.8
K1.12	Remote shutdown system	3.5
K1.13	Component cooling water	2.8
K1.14	Primary containment isolation system	3.9
K1.15	Feedwater system	3.2

K2 Knowledge of electrical power supplies to the following:
(CFR: 41.7)

K2.01	Motor-operated valves	3.3
K2.02	Initiation/isolation logic	3.7
K2.03	RCIC flow controller	3.5
K2.04	Gland seal compressor (vacuum pump)	2.6
K2.05	Water leg pump	2.6

K3 Knowledge of the effect that a loss or malfunction of the Reactor Core Isolation Cooling System will have on the following systems or system parameters:
(CFR: 41.7 / 45.4)

K3.01	Reactor water level	4.2
K3.02	Reactor vessel pressure	3.9
K3.03	DELETED	
K3.04	DELETED	
K3.05	Suppression pool level	3.3
K3.06	Condensate storage tank level	3.2
K3.07	Secondary containment parameters	3.4

System: 217000 SF2 RCIC Reactor Core Isolation Cooling System

**K4 Knowledge of Reactor Core Isolation Cooling System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Prevent water hammer	3.4
K4.02	Prevent overfilling reactor vessel	3.8
K4.03	Prevents pump overheating	3.2
K4.04	Turbine trips	3.9
K4.05	DELETED	
K4.06	Manual system initiation	4.0
K4.07	Automatic transfer of RCIC pump suction	3.6
K4.08	Automatic system initiation	4.1
K4.09	Initiation reset	3.7
K4.10	System isolation	4.1
K4.11	Resetting system isolations	3.8
K4.12	Automatic flow control	3.7
K4.13	Turbine speed control	3.6
K4.14	Control oil to turbine speed controls	3.3
K4.15	Testable check valve operation	2.2
K4.16	Turbine shaft sealing	2.4
K4.17	Bypass trips and isolation logic	3.7
K4.18	Remote operation	3.7

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Reactor Core Isolation Cooling System:
(CFR: 41.5 / 45.3)**

K5.01	DELETED	
K5.02	Flow control	3.8
K5.03	DELETED	
K5.04	DELETED	
K5.05	DELETED	
K5.06	Turbine operation	3.5
K5.07	Reactor pressure control	3.7
K5.08	Decay heat removal	3.8
K5.09	Adequate core cooling	4.2
K5.10	Reactor level control	4.2

System: 217000 SF2 RCIC Reactor Core Isolation Cooling System

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Reactor Core Isolation Cooling System:

(CFR: 41.7 / 45.7)

K6.01	Electrical power	3.8
K6.02	Instrument air systems	2.6
K6.03	Suppression pool level	3.5
K6.04	Condensate storage tank low level	3.5
K6.05	Low reactor pressure	3.7
K6.06	Keep fill system	3.1
K6.07	Nuclear boiler instrumentation	3.6
K6.08	Reactor water level	4.1
K6.09	High suppression pool temperature	3.5
K6.10	High turbine exhaust pressure	3.7
K6.11	High steam flow	3.9
K6.12	High area temperature	4.0
K6.13	Low pump suction pressure	3.7
K6.14	Turbine control failure	3.7
K6.15	Lube oil pump	3.3
K6.16	Minimum flow valve	3.3
K6.17	Flow controller failure	3.9

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Reactor Core Isolation Cooling System, including:

(CFR: 41.5 / 45.5)

A1.01	RCIC flow	4.1
A1.02	RCIC pressure	3.9
A1.03	Reactor water level	4.3
A1.04	Reactor pressure	4.1
A1.05	RCIC turbine speed	3.7
A1.06	Condensate storage tank level	3.2
A1.07	Suppression pool level	3.4
A1.08	Suppression pool temperature	3.5
A1.09	Lights and alarms	3.6

System: 217000 SF2 RCIC Reactor Core Isolation Cooling System

A2 Ability to (a) predict the impacts of the following on the Reactor Core Isolation Cooling System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Inadvertent system initiation signal	4.3	4.2
A2.02	Turbine trips	4.2	4.0
A2.03	Valve closures due to malfunction(s)	3.8	3.7
A2.04	AC power loss	3.5	3.4
A2.05	DC power loss	4.1	3.9
A2.06	Loss of instrument air systems	2.9	2.5
A2.07	Loss of lube oil	3.6	3.3
A2.08	Loss of lube oil cooling	3.6	3.2
A2.09	Loss of vacuum pump	3.0	2.7
A2.10	Turbine control system failures	3.6	3.7
A2.11	Inadequate system flow	4.0	3.7
A2.12	Valve openings due to malfunction(s)	3.3	3.6
A2.13	Loss of room cooling	3.2	3.1
A2.14	Rupture disc failure: exhaust-diaphragm	3.9	3.6
A2.15	Steam line break	4.0	4.0
A2.16	Low condensate storage tank level	3.5	3.3
A2.17	Abnormal suppression pool level	3.7	3.4
A2.18	DELETED		
A2.19	High suppression pool temperature	3.7	3.5

A3 Ability to monitor automatic operation of the Reactor Core Isolation Cooling System, including:
(CFR: 41.7 / 45.7)

A3.01	Valve operation	3.9	
A3.02	Turbine startup	4.0	
A3.03	DELETED		
A3.04	DELETED		
A3.05	DELETED		
A3.06	DELETED		
A3.07	Trips and isolations	4.2	
A3.08	Automatic flow control	4.0	

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	DELETED		
A4.02	Turbine trip throttle valve reset	4.0	

System: 217000 SF2 RCIC Reactor Core Isolation Cooling System

A4.03	System valves	3.8
A4.04	DELETED	
A4.05	DELETED	
A4.06	DELETED	
A4.07	DELETED	
A4.08	DELETED	
A4.09	DELETED	
A4.10	DELETED	
A4.11	DELETED	
A4.12	Turbine speed control	3.9
A4.13	Manual initiation	4.1
A4.14	Resetting isolations	3.9

System: 259001 SF2 FWS Feedwater System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Feedwater System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Reactor vessel and internals	3.7
K1.02	HPCI	3.6
K1.03	RWCU system	3.3
K1.04	Extraction steam system	3.0
K1.05	Condensate system	3.5
K1.06	Instrument air systems	3.3
K1.07	DELETED	
K1.08	Reactor water level control system	4.1
K1.09	DELETED	
K1.10	Component cooling water systems	3.0
K1.11	RFP lube oil system	3.1
K1.12	RFP turbine seal steam system: TDRFPs-only	2.8
K1.13	Main turbine generator	2.9
K1.14	RCIC system	3.5
K1.15	RHR system	2.9
K1.16	Recirculation system	3.1
K1.17	Heater drains system	2.8
K1.18	Fire protection system (emergency cooling)	2.5
K1.19	Redundant reactivity control system	3.3
K1.20	Main steam system: TDRFPs-only	3.3
K1.21	DELETED	
K1.22	Feedwater control system	3.8
K1.23	Hydrogen water chemistry system	2.9
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Reactor feedwater pump(s): motor-driven-only	3.8
K2.02	System motor-operated valves	2.9
K2.03	RFP auxiliary oil pumps	2.8
K3	Knowledge of the effect that a loss or malfunction of the Feedwater System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor water level	4.5
K3.02	Reactor water level control system	4.2

System: 259001 SF2 FWS Feedwater System

K3.03	HPCI	3.7
K3.04	RWCU	2.8
K3.05	Recirculation pump NPSH	3.3
K3.06	Core inlet subcooling	3.3
K3.07	Condensate system	3.2
K3.08	RCIC	3.4
K3.09	Extraction steam system	2.7
K3.10	HPCI	3.1
K3.11	RHR	3.0
K3.12	Reactor power	4.0
K3.13	Digital feedwater control system	4.0

**K4 Knowledge of Feedwater System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Automatic start of the RFPs	3.9
K4.02	Feedwater heating	3.3
K4.03	RFP minimum flow	3.3
K4.04	Dispersal of feedwater in the reactor vessel	3.0
K4.05	RFP protection	3.2
K4.06	RFP lubrication	3.0
K4.07	RFP motor cooling: motor-driven-only	3.0
K4.08	RFP turbine seals: TDRFPs-only	2.7
K4.09	System isolation from the reactor vessel (check valves, double valve isolation inside/outside containment)	3.2
K4.10	Feedwater pump runbacks	3.5
K4.11	Recirculation runbacks	3.7
K4.12	RFP start permissives	3.1
K4.13	Reactor water level control	4.0
K4.14	Digital feedwater control system	3.9

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Feedwater System:
(CFR: 41.5 / 45.3)**

K5.01	DELETED	
K5.02	DELETED	
K5.03	Turbine operation: TDRFPs-only	3.5
K5.04	Reactor water level	4.2
K5.05	Thermal power calculation	3.5
K5.06	Rod worth minimizer	2.7
K5.07	Reactor recirculation system	3.3

System: 259001 SF2 FWS Feedwater System

K5.08 Feedwater heaters, including heater drain pumps 3.0

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Feedwater System:
(CFR: 41.7 / 45.7)**

K6.01 Instrument air system 3.5
 K6.02 Condensate system 3.5
 K6.03 AC electrical power 3.4
 K6.04 Extraction steam 2.9
 K6.05 Component cooling water systems 2.9
 K6.06 DELETED
 K6.07 Reactor water level control system 4.0
 K6.08 Reactor feedwater pump motor ventilation: motor-driven only 2.9
 K6.09 Reactor feedwater pump lube oil system 3.1
 K6.10 RFP turbine seal system: TDRFPs only 2.8
 K6.11 Main steam: TDRFPs only 3.0
 K6.12 DC electrical power 2.9
 K6.13 Redundant reactivity control 3.1
 K6.14 Feedwater heaters 3.1
 K6.15 Digital feedwater control system 3.8

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Feedwater System, including:
(CFR: 41.5 / 45.5)**

A1.01 Feedwater flow/pressure 3.9
 A1.02 Feedwater inlet temperature 3.4
 A1.03 RFP motor amps: motor-driven only 3.0
 A1.04 RFP turbine speed: turbine-driven only 3.3
 A1.05 RFP turbine control valve position: turbine-driven only 2.8
 A1.06 Feedwater heater level 2.9
 A1.07 Reactor water level 4.3
 A1.08 Feedwater control valve position 3.6

**A2 Ability to (a) predict the impacts of the following on the Feedwater System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	RFP trip	4.3	4.1

System: 259001 SF2 FWS Feedwater System

A2.02	Feedwater heater isolation	3.4	3.4
A2.03	Loss of condensate system pump(s)	3.9	3.9
A2.04	Loss of extraction steam	3.4	3.5
A2.05	Loss of Instrument air system	3.6	3.3
A2.06	Loss of AC electrical distribution	3.5	3.4
A2.07	Reactor water level control system malfunctions	4.1	4.1
A2.08	Loss of DC electrical distribution	3.3	2.9
A2.09	TDRFP steam inlet pressure flow	3.0	2.6
A2.10	Digital feedwater control malfunctions	3.8	3.7
A2.11	Component cooling water malfunctions	3.1	2.9
A2.12	Heater drain pump trip	3.0	3.0

A3 Ability to monitor automatic operation of the Feedwater System, including:
(CFR: 41.7 / 45.7)

A3.01	RFP automatic start	3.7
A3.02	DELETED	
A3.03	System flow	3.8
A3.04	Reactor water level	4.3
A3.05	DELETED	
A3.06	DELETED	
A3.07	FWRV position	3.8
A3.08	Turbine speed: TDRFPs-only	3.4
A3.09	Lights and alarms	3.6
A3.10	Pump trips	3.9
A3.11	Reactor feedwater pump runbacks	4.0

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	System flow	3.9
A4.02	Manually start/control an RFP	4.0
A4.03	Feedwater heater/drain controls	3.3
A4.04	System valves	3.4
A4.05	Reactor water level	4.2
A4.06	Feedwater inlet temperature	3.4
A4.07	Pump discharge pressure	3.5
A4.08	FWRV position	3.8

System: 204000 SF2 RWCU Reactor Water Cleanup System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Reactor Water Cleanup System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Reactor vessel and internals	3.3
K1.02	Recirculation system	3.3
K1.03	Feedwater system	3.2
K1.04	Component cooling water system	3.2
K1.05	Instrument air systems	2.8
K1.06	Condensate system	2.4
K1.07	Radwaste	2.5
K1.08	SLCS	3.6
K1.09	DELETED	
K1.10	DELETED	
K1.11	PCIS/NSSSS	3.8
K1.12	DELETED	
K1.13	RHR system	2.6
K1.14	DELETED	
K1.15	DELETED	
K1.16	Control rod drive hydraulic system	2.4
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Pumps	2.9
K2.02	Motor-operated valves	3.0
K3	Knowledge of the effect that a loss or malfunction of the Reactor Water Cleanup System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor water quality	3.5
K3.02	Reactor water level	3.2
K3.03	Component cooling water systems	2.7
K3.04	Heat balance	3.5
K3.05	Area temperature	3.0
K3.06	Area radiation levels	3.0
K3.07	Drywell temperature	2.7
K3.08	Drywell pressure	2.7

System: 204000 SF2 RWCU Reactor Water Cleanup System

**K4 Knowledge of Reactor Water Cleanup System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Pump protection	2.9
K4.02	Piping overpressurization protection	2.9
K4.03	Overtemperature protection for system components	3.0
K4.04	System isolation	3.9
K4.05	DELETED	
K4.06	Maximize plant efficiency (use of regenerative heat exchanger)	2.8
K4.07	Draining of reactor water	3.5
K4.08	DELETED	
K4.09	Leak detection	3.4
K4.10	Decay heat removal	2.9

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Reactor Water Cleanup System:
(CFR: 41.5 / 45.3)**

K5.01	DELETED	
K5.02	DELETED	
K5.03	DELETED	
K5.04	DELETED	
K5.05	DELETED	
K5.06	DELETED	
K5.07	Conductivity monitoring	3.2
K5.08	System temperatures	3.0
K5.09	System flow	3.1

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Reactor Water Cleanup System:
(CFR: 41.7 / 45.7)**

K6.01	Component cooling water systems	3.3
K6.02	Main condenser	2.6
K6.03	Radwaste	2.4
K6.04	Instrument air systems	2.9
K6.05	DELETED	
K6.06	Feedwater system	2.7
K6.07	SLCS logic	3.7
K6.08	PCIS/NSSSS	3.8

System: 204000 SF2 RWCU Reactor Water Cleanup System

K6.09 Control rod drive hydraulic system 2.5

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Reactor Water Cleanup System, including:
(CFR: 41.5 / 45.5)**

A1.01	Reactor water level	3.4
A1.02	Component cooling water temperature	3.0
A1.03	Reactor water temperature	3.0
A1.04	System flow	3.2
A1.05	System pressure	2.9
A1.06	System temperature	3.0
A1.07	RWCU drain flow	3.1
A1.08	Main condenser hotwell level	2.4
A1.09	Reactor water conductivity	3.3
A1.10	Lights and alarms	3.0

**A2 Ability to (a) predict the impacts of the following on the Reactor Water Cleanup System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	Loss of component cooling water	3.4	3.2
A2.02	Pressure control valve failure	3.2	3.0
A2.03	Flow control valve failure	3.2	3.0
A2.04	Pump trips	3.2	3.1
A2.05	Abnormal valve position	3.2	3.0
A2.06	Loss of AC electrical distribution	3.1	3.1
A2.07	Loss of instrument air systems	2.9	2.9
A2.08	RWCU pump seal failure	3.2	3.0
A2.09	Loss of room coolers	2.8	2.3
A2.10	DELETED		
A2.11	Abnormal system flow	3.2	3.1
A2.12	DELETED		
A2.13	System isolation	3.5	3.9
A2.14	System high temperature	3.3	3.4
A2.15	Cleanup demineralizer high differential pressure	2.8	2.9
A2.16	Abnormal reactor water chemistry	3.2	3.3

System: 204000 SF2 RWCU Reactor Water Cleanup System

A3 Ability to monitor automatic operation of the Reactor Water Cleanup System, including:
(CFR: 41.7 / 45.7)

A3.01	System pressure control for low pressure piping	2.9
A3.02	DELETED	
A3.03	System isolations	4.0
A3.04	System interlocks and trips	3.8
A3.05	DELETED	
A3.06	DELETED	
A3.07	System flow	3.2

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	System pumps	3.3
A4.02	Valve controllers	3.3
A4.03	DELETED	
A4.04	Heat exchanger temperature	3.1
A4.05	DELETED	
A4.06	DELETED	
A4.07	DELETED	
A4.08	DELETED	
A4.09	DELETED	
A4.10	Motor-operated valves	3.3

System: 259002 SF2 RWLCS Reactor Water Level Control System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Reactor Water Level Control System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	RPS	3.9
K1.02	Main and reheat steam system	2.9
K1.03	Reactor water level	4.2
K1.04	Reactor feedwater flow	3.9
K1.05	Feedwater system	3.9
K1.06	DELETED	
K1.07	Rod worth minimizer	2.8
K1.08	DELETED	
K1.09	DELETED	
K1.10	Emergency generator(s): FWCI	2.9
K1.11	DELETED	
K1.12	DELETED	
K1.13	DELETED	
K1.14	DELETED	
K1.15	DELETED	
K1.16	ECCS	3.5
K1.17	RWCU	3.0
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Reactor water level control system	3.3
K2.02	Feedwater coolant injection (FWCI) initiation logic	3.4
K2.03	Feedwater controllers	3.1
K3	Knowledge of the effect that a loss or malfunction of the Reactor Water Level Control System will have on the following systems or system parameters: (CFR: 41.7 / 45.4 to 45.8)	
K3.01	Reactor water level	4.3
K3.02	Feedwater system	4.0
K3.03	Rod worth minimizer	2.7
K3.04	Recirculation system	3.3
K3.05	Recirculation flow control system	3.3
K3.06	Main turbine generator and auxiliaries	2.9

System: 259002 SF2 RWLCS Reactor Water Level Control System

K3.07	DELETED	
K3.08	Main and reheat steam system	2.7
K3.09	Condensate system	3.0

**K4 Knowledge of Reactor Water Level Control System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	DELETED	
K4.02	Bypassing of the RWMS	3.0
K4.03	Reactor feedwater pump runout protection	3.2
K4.04	Reactor water level setpoint setdown after a reactor SCRAM	3.5
K4.05	P sat/T sat (compensation)	2.7
K4.06	Control signal failure	3.2
K4.07	TDRFP 20-percent power interlock	3.0
K4.08	TDRFP speed control	3.2
K4.09	Single-element control (reactor water level provides the only input)	3.5
K4.10	Three-element control (main steam flow, reactor feedwater flow, and reactor water level provide input)	3.6
K4.11	Differential pressure control	2.7
K4.12	Manual and automatic control of the system	3.9
K4.13	FWRV lockup	3.7
K4.14	Selection of various instruments to provide reactor water level input	3.8
K4.15	Automatic initiation of the feedwater system upon receipt of an ECCS initiation signal: FWCI	3.8
K4.16	Dedication of feedwater string(s) to ECCS: FWCI	3.4
K4.17	Simultaneous manual and automatic operation of the system (i.e., 1 RFP in automatic, 1 RFP in manual)	3.5
K4.18	Reactor level control at low power	3.8

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Reactor Water Level Control System:
(CFR: 41.5 / 45.3)**

K5.01	DELETED	
K5.02	Controller operation	3.8
K5.03	Water level measurement	3.7
K5.04	Moisture carryover/carryunder	3.1
K5.05	DELETED	
K5.06	Pump runout	3.2
K5.07	Turbine speed control mechanisms: TDRFP	3.3

SYSTEM: 259002 SF2 RWLCS Reactor Water Level Control System

K5.08 DELETED
K5.09 DELETED

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Reactor Water Level Control System:
(CFR: 41.7 / 45.7)

K6.01	Instrument air systems	3.3
K6.02	AC power	3.3
K6.03	Main steam flow input	3.7
K6.04	Reactor feedwater flow input	3.7
K6.05	Reactor water level input	3.8
K6.06	Reactor pressure/temperature input (for water level input compensation)	2.9
K6.07	High drywell pressure	2.9
K6.08	Loss of differential pressure across startup level control bypass valve	2.7

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Reactor Water Level Control System, including:
(CFR: 41.5 / 45.5)

A1.01	Reactor water level	4.3
A1.02	Reactor feedwater flow	4.0
A1.03	Reactor power	4.0
A1.04	Reactor water level control controller indications	3.9
A1.05	FWRV/startup level control position	3.6
A1.06	Feedwater string(s) selected for FWCI	3.5
A1.07	TDRFP speed	3.3
A1.08	Main steam flow	3.6
A1.09	Lights and alarms	3.5

A2 Ability to (a) predict the impacts of the following on the Reactor Water Level Control System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Loss of any number of main steam flow inputs	3.8	3.5
A2.02	Loss of any number of reactor feedwater flow inputs	3.8	3.6
A2.03	Loss of reactor water level input	3.8	3.9
A2.04	RFP runout condition	3.4	3.0
A2.05	Loss of applicable plant air systems	3.3	3.2
A2.06	Loss of controller signal output	3.6	3.3
A2.07	Loss of comparator bias signal	3.0	2.7
A2.08	Receipt of an ECCS initiation signal: FWCI	4.0	3.7
A2.09	FWCI system failure alarm	3.3	3.6

SYSTEM: 259002 SF2 RWLCS Reactor Water Level Control System

A3 Ability to monitor automatic features of the Reactor Water Level Control System, including:
(CFR: 41.7 / 45.7)

A3.01	Runout flow control	3.1
A3.02	DELETED	
A3.03	DELETED	
A3.04	DELETED	
A3.05	DELETED	
A3.06	Reactor water level setpoint setdown following a reactor SCRAM	3.6
A3.07	FWRV lockup	3.5
A3.08	FWCI system initiation	3.7
A3.09	Transfer of system from flow control to level control mode: FWCI	3.6
A3.10	TDRFP lockup	3.1
A3.11	Automatic selection of feedflow/steam flow/level channel input	3.2
A3.12	Transfer from three-element to one-element control	3.4

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	All individual component controllers	3.9
A4.02	DELETED	
A4.03	All individual component controllers when transferring from manual to automatic modes	3.9
A4.04	FWRV lockup reset controls	3.7
A4.05	Runout flow control reset controls	3.4
A4.06	Differential pressure/single/three element control selector switch	3.4
A4.07	All individual component controllers when transferring from automatic to manual mode	3.8
A4.08	Manually initiate FWCI	3.5
A4.09	TDRFP lockout reset	3.2
A4.10	Setpoint setdown reset controls	3.1
A4.11	High-level lockout reset controls	3.4
A4.12	Instrument bypass switches	3.0

SYSTEM: 203000 SF2 RHR/LPCI: Injection Mode

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the RHR/LPCI: Injection Mode and the following systems: (CFR: 41.2 to 41.9 / 43.5 / 45.7 to 45.8)	
K1.01	Condensate system	2.3
K1.02	Primary containment	3.5
K1.03	DELETED	
K1.04	DELETED	
K1.05	Recirculation system (BWR 3, 4)	3.7
K1.06	ADS	4.1
K1.07	DELETED	
K1.08	DELETED	
K1.09	Emergency generators	4.0
K1.10	Plant ventilation systems	2.5
K1.11	Nuclear boiler instrumentation	3.7
K1.12	Instrument air system	2.4
K1.13	DELETED	
K1.14	Shutdown cooling system	3.6
K1.15	Reactor building drain system	2.0
K1.16	Component cooling water systems	2.7
K1.17	DELETED	
K1.18	Reactor vessel	3.8
K1.19	Low-pressure core spray system	3.5
K1.20	Service water	3.1
K1.21	Remote shutdown system	3.4
K1.22	Spent fuel pool cooling	2.9
K1.23	Primary containment isolation system	3.6
K1.24	Leak detection system	3.0
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Pumps	4.1
K2.02	Valves	3.7
K2.03	Initiation logic	3.7
K3	Knowledge of the effect that a loss or malfunction of the RHR/LPCI: Injection Mode will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor water level	4.2

System: 203000 SF2 RHR/LPCI: Injection Mode

K3.02	Suppression pool level	3.4
K3.03	Automatic depressurization logic	4.0
K3.04	Adequate core cooling	4.3
K3.05	Drywell pressure	3.3
K3.06	Reactor pressure	3.5
K3.07	Primary containment	3.5

**K4 Knowledge of RHR/LPCI: Injection Mode design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Automatic system initiation/injection	4.4
K4.02	DELETED	
K4.03	Pump minimum flow protection	3.2
K4.04	Pump seal cooler	2.7
K4.05	Prevention of water hammer (keep fill)	3.4
K4.06	No-suction path pump trip	3.5
K4.07	Emergency generator load sequencing	3.8
K4.08	Pump operability testing	3.0
K4.09	Surveillance for all operable components	2.9
K4.10	Dedicated injection system during automatic system initiation (injection valve interlocks)	3.7
K4.11	Loop selection logic	3.4
K4.12	System redundancy	3.5
K4.13	Prevention of leakage to the environment through LPCI/RHR heat exchanger	3.0
K4.14	Operation from remote shutdown panel	3.6
K4.15	Pump runout protection	3.0
K4.16	Manual system initiation	4.1
K4.17	Testable check valve operation	2.6

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the RHR/LPCI: Injection Mode:
(CFR: 41.5 / 45.3)**

K5.01	DELETED	
K5.02	Core cooling methods	4.2
K5.03	Vortex limits	3.3
K5.04	NPSH limits	3.4

System: 203000 SF2 RHR/LPCI: Injection Mode

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the RHR/LPCI: Injection Mode:
(CFR: 41.7 / 45.7)**

K6.01	AC electrical power	3.9
K6.02	DC electrical power	3.8
K6.03	Emergency generator	4.0
K6.04	Keep fill	3.2
K6.05	Condensate system	2.3
K6.06	Suppression pool water level	3.4
K6.07	Plant air systems	2.4
K6.08	ECCS room cooling	3.1
K6.09	Nuclear boiler instrumentation	3.5
K6.10	Component cooling water systems	2.8
K6.11	ADS	4.1
K6.12	ECCS room integrity	3.0
K6.13	High suppression pool temperature	3.5
K6.14	High drywell pressure	3.7
K6.15	Low reactor water level	4.0
K6.16	Service water system	3.0
K6.17	Suppression pool suction strainer clogging	3.4

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the RHR/LPCI: Injection Mode, including:
(CFR: 41.5 / 45.5)**

A1.01	Reactor water level	4.4
A1.02	Reactor pressure	4.0
A1.03	System flow	4.0
A1.04	System pressure	3.8
A1.05	Suppression pool level	3.6
A1.06	Condensate storage tank level	2.5
A1.07	Motor amps	2.7
A1.08	Emergency generator loading	3.7
A1.09	Component cooling water systems	2.8
A1.10	Lights and alarms	3.5
A1.11	Suppression pool temperature	3.5

System: 203000 SF2 RHR/LPCI: Injection Mode

**A2 Ability to (a) predict the impacts of the following on the RHR/LPCI: Injection Mode and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	Inadequate net positive suction head	3.9	3.6
A2.02	Pump trips	4.0	3.9
A2.03	Valve closures due to malfunction(s)	3.7	3.8
A2.04	AC failures	3.9	3.8
A2.05	DC failures	3.6	3.7
A2.06	Emergency generator failure	3.9	3.9
A2.07	Pump seal failure	3.1	2.9
A2.08	Inadequate room cooling	2.9	3.0
A2.09	Inadequate system flow	3.6	3.5
A2.10	Nuclear boiler instrument failure	3.4	3.5
A2.11	Motor-operated valve failures	3.7	3.6
A2.12	Pump runout	3.7	3.1
A2.13	Valve openings due to malfunction(s)	3.6	3.3
A2.14	Initiation logic failure	3.9	4.0
A2.15	Loop selection logic failure	4.3	3.9
A2.16	Loss of coolant accident	4.4	4.4
A2.17	Keep fill system failure	3.6	3.1
A2.18	High suppression pool temperature	3.6	3.4
A2.19	Low suppression pool level	3.7	3.5
A2.20	Surveillance acceptance criteria not being met	3.0	3.3

**A3 Ability to monitor automatic operation of the RHR/LPCI: Injection Mode, including:
(CFR: 41.7 / 45.7)**

A3.01	Valve operation		4.0
A3.02	Pump start		4.1
A3.03	DELETED		
A3.04	DELETED		
A3.05	DELETED		
A3.06	DELETED		
A3.07	Loop selection		4.1
A3.08	System initiation sequence		4.0
A3.09	DELETED		

System: 203000 SF2 RHR/LPCI: Injection Mode

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Pumps	4.2
A4.02	System valves	4.2
A4.03	Keep fill system	3.1
A4.04	DELETED	
A4.05	Manual initiation controls	4.3
A4.06	System reset following automatic initiation	3.6
A4.07	DELETED	
A4.08	DELETED	
A4.09	DELETED	
A4.10	DELETED	
A4.11	DELETED	
A4.12	DELETED	
A4.13	DELETED	
A4.14	Testable check valves	2.6
A4.15	Room coolers	2.9

3.3	Safety Function 3: Reactor Pressure Control	Page
218000	Automatic Depressurization System.....	3.3-3
239001	Main and Reheat Steam System.....	3.3-6
241000	Reactor/Turbine Pressure Regulating System.....	3.3-11
239002	Safety Relief Valves.....	3.3-18

System: 218000 SF3 ADS Automatic Depressurization System		
K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Automatic Depressurization System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	RHR/LPCI system	4.3
K1.02	LPCS system	4.2
K1.03	Nuclear boiler instrumentation	3.9
K1.04	DELETED	
K1.05	DELETED	
K1.06	Safety/relief valves	4.3
K1.07	Reactor vessel and internals	3.2
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	ADS logic	4.0
K3	Knowledge of the effect that a loss or malfunction of the Automatic Depressurization System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor water level	4.1
K3.02	Reactor pressure	4.3
K4	Knowledge of Automatic Depressurization System design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Prevention of an inadvertent initiation of ADS logic	4.0
K4.02	Allow manual initiation of ADS logic	4.1
K4.03	ADS logic control	4.2
K4.04	Ensure adequate pneumatic supply to ADS valves	3.8
K4.05	Inhibiting automatic initiation of ADS logic	4.2
K5	Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Automatic Depressurization System: (CFR: 41.5 / 45.3)	
K5.01	ADS logic operation	4.3

System: 218000 SF3 ADS Automatic Depressurization System

K5.02	Primary containment/drywell pressure	3.7
K5.03	Reactor pressure	4.1
K5.04	Suppression pool temperature	3.8
K5.05	Suppression pool level	3.7
K5.06	Reactor water level	4.0

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Automatic Depressurization System:
(CFR: 41.7 / 45.7)

K6.01	RHR/LPCI pump running permissive	4.2
K6.02	Low-pressure core spray pump running permissive	4.2
K6.03	Reactor water level instrumentation	4.1
K6.04	Pneumatic supply to ADS valves	3.7
K6.05	AC power	3.5
K6.06	DC power	4.0
K6.07	Primary containment/drywell pressure instrumentation	3.7

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Automatic Depressurization System, including:
(CFR: 41.5 / 45.5)

A1.01	DELETED	
A1.02	ADS valve position indications	4.0
A1.03	ADS valve pneumatic supply pressure	3.5
A1.04	Reactor pressure	4.2
A1.05	Reactor water level	4.0
A1.06	Suppression pool temperature	3.7
A1.07	Suppression pool level	3.4
A1.08	Primary containment/drywell pressure	3.7
A1.09	Lights and alarms	3.8

A2 Ability to (a) predict the impacts of the following on the Automatic Depressurization System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Steam line break	3.6	3.2
A2.02	Loss of coolant accident	4.2	4.1

System: 218000 SF3 ADS Automatic Depressurization System

A2.03	Loss of pneumatic supply to ADS valves	3.9	3.8
A2.04	ADS failure to initiate	4.4	4.2
A2.05	Loss of electrical power to ADS	4.2	4.0
A2.06	ADS initiation signals present	4.5	4.3

A3 Ability to monitor automatic operation of the Automatic Depressurization System, including:
(CFR: 41.7 / 45.7)

A3.01	ADS valves		4.1
A3.02	DELETED		
A3.03	DELETED		
A3.04	DELETED		
A3.05	DELETED		
A3.06	DELETED		
A3.07	DELETED		
A3.08	DELETED		
A3.09	DELETED		
A3.10	ADS logic		4.1

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	ADS valves		4.5
A4.02	ADS logic initiation		4.2
A4.03	ADS logic reset		3.9
A4.04	ADS inhibit		4.4
A4.05	ADS timer reset		4.0
A4.06	DELETED		
A4.07	DELETED		
A4.08	DELETED		
A4.09	DELETED		
A4.10	DELETED		
A4.11	DELETED		
A4.12	DELETED		

System: 239001 SF3 MRSS Main and Reheat Steam System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Main and Reheat Steam System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Reactor vessel and internals	3.5
K1.02	Plant process computer/parameter display systems	2.6
K1.03	Main turbine generator and auxiliary systems	3.6
K1.04	DELETED	
K1.05	DELETED	
K1.06	Reactor/turbine pressure regulating system	4.0
K1.07	Offgas system	3.2
K1.08	DELETED	
K1.09	DELETED	
K1.10	Extraction steam system	3.2
K1.11	DELETED	
K1.12	Instrument air systems	3.0
K1.13	Main steam isolation valve leakage control system	3.0
K1.14	DELETED	
K1.15	DELETED	
K1.16	Radiation monitoring system	3.0
K1.17	Primary containment system and auxiliaries	3.2
K1.18	High-pressure coolant injection system	3.3
K1.19	Reactor core isolation cooling system	3.4
K1.20	Residual heat removal system	2.7
K1.21	Isolation condenser system	3.6
K1.22	Feedwater system	3.3
K1.23	Reactor water level control system	3.7
K1.24	DELETED	
K1.25	DELETED	
K1.26	Safety relief valves	4.0
K1.27	Reactor protection system	4.1
K1.28	PCIS/NSSSS	3.9
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Main steam isolation valve solenoids	3.6
K2.02	Main steam line shutoff valves	3.3

System: 239001 SF3 MRSS Main and Reheat Steam System

**K3 Knowledge of the effect that a loss or malfunction of the Main and Reheat Steam System will have on the following systems or system parameters:
(CFR: 41.7 / 45.4)**

K3.01	Main turbine generator and auxiliary systems	3.5
K3.02	Condenser vacuum	3.5
K3.03	Feedwater system	3.5
K3.04	Offgas system	3.1
K3.05	DELETED	
K3.06	Reactor/turbine pressure regulating system	3.7
K3.07	Primary containment system and auxiliaries	3.2
K3.08	DELETED	
K3.09	DELETED	
K3.10	High-pressure coolant injection system	3.3
K3.11	Reactor core isolation cooling system	3.5
K3.12	Isolation condenser	3.7
K3.13	DELETED	
K3.14	Residual heat removal system	2.7
K3.15	Reactor water level	3.7
K3.16	Safety relief valves	3.9
K3.17	Reactor vessel and internals	3.2

**K4 Knowledge of Main and Reheat Steam System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Steam line isolation	4.3
K4.02	Automatic isolation and opening of drain valves	3.3
K4.03	Ensures that steam released from a steam line break will not bypass suppression pool (BWR 6)	3.7
K4.04	Limits steam flow during a steam line rupture	3.5
K4.05	Steam flow measurement	3.4
K4.06	Allows for removal or prevents escape of radioactive steam from systems that have leaky MSIVs	3.1
K4.07	Overpressure control	4.1
K4.08	Removal of noncondensable gases from reactor head area	2.6
K4.09	Equalization of pressure across the MSIVs before opening	3.2
K4.10	Moisture removal from steam lines before admitting steam	3.0
K4.11	Positive sealing of the MSIVs when shut down	2.9
K4.12	MSIV testing	3.0

System: 239001 SF3 MRSS Main and Reheat Steam System

K4.13 Backup pneumatic source for MSIV closure 3.1

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Main and Reheat Steam System:
(CFR: 41.5 / 45.3)**

K5.01 DELETED
K5.02 DELETED
K5.03 DELETED
K5.04 Steam blanketing of the moisture separator reheater 2.0
K5.05 DELETED
K5.06 Inadvertent MSIV operation 3.5
K5.07 DELETED
K5.08 DELETED
K5.09 Decay heat removal 3.5
K5.10 Steam bypass capability 3.8
K5.11 Noncondensable gases in the reactor head area 2.5
K5.12 MSR heatup limitations 2.9

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Main and Reheat Steam System:
(CFR: 41.7 / 45.7)**

K6.01 Electrical power 3.3
K6.02 Plant pneumatic systems 3.4
K6.03 Safety relief valves 3.9
K6.04 DELETED
K6.05 Steam line leak 4.0
K6.06 MSIV isolation signal 4.3
K6.07 MSIV leakage control 2.9
K6.08 Main condenser vacuum 3.5
K6.09 PCIS/NSSSS 3.9
K6.10 DELETED
K6.11 Moisture separator/reheaters 2.9
K6.12 Main turbine trip 3.6
K6.13 Reactor/turbine pressure regulating system 3.8

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Main and Reheat Steam System, including:
(CFR: 41.5 / 45.5)**

A1.01 Main steam pressure 3.8

System: 239001 SF3 MRSS Main and Reheat Steam System

A1.02	Main steam temperature	2.6
A1.03	Reheat steam pressure	2.7
A1.04	Reheater temperature	2.4
A1.05	Main steam line radiation	3.3
A1.06	Offgas process radiation	3.3
A1.07	Reactor water level	4.0
A1.08	Reactor pressure	4.2
A1.09	Main steam flow	3.7
A1.10	Reactor power	4.1
A1.11	Lights and alarms	3.3

A2 Ability to (a) predict the impacts of the following on the Main and Reheat Steam System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Malfunction of reactor turbine pressure regulating system	4.3	4.0
A2.02	Steam demand malfunction and its effect on reactor pressure and power	4.2	4.0
A2.03	MSIV closure	4.3	3.9
A2.04	Main steam line low pressure	4.2	3.7
A2.05	Main steam line high radiation	3.6	3.6
A2.06	Turbine trip without bypass valves	4.4	4.0
A2.07	Main steam area high temperature	3.9	3.8
A2.08	Low condenser vacuum	4.0	3.6
A2.09	DELETED		
A2.10	Closure of one or more MSIVs at power	4.2	3.7
A2.11	Steam line break	4.3	4.1
A2.12	PCIS/NSSSS actuation	3.9	4.2
A2.13	High reactor water level	4.1	3.6
A2.14	DELETED		

A3 Ability to monitor automatic operation of the Main and Reheat Steam System, including:

(CFR: 41.7 / 45.7)

A3.01	Isolation of main steam system	4.2
A3.02	Opening and closing of drain valves as turbine load changes	2.6
A3.03	Moisture separator reheat steam supply	2.8
A3.04	Isolation of moisture separator reheater	3.0
A3.05	MSR drain tank level control	2.9

System: 239001 SF3 MRSS Main and Reheat Steam System

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

A4.01	MSIVs	4.4
A4.02	Main steam line drain valves	3.4
A4.03	DELETED	
A4.04	DELETED	
A4.05	DELETED	
A4.06	DELETED	
A4.07	DELETED	
A4.08	DELETED	
A4.09	DELETED	
A4.10	DELETED	
A4.11	DELETED	
A4.12	MSR steam admission valves	2.8

System: 241000 SF3 RTPRS Reactor/Turbine Pressure Regulating System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Reactor/Turbine Pressure Regulating System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	DELETED	
K1.02	DELETED	
K1.03	DELETED	
K1.04	DELETED	
K1.05	DELETED	
K1.06	DELETED	
K1.07	DELETED	
K1.08	DELETED	
K1.09	DELETED	
K1.10	DELETED	
K1.11	RPS	4.1
K1.12	DELETED	
K1.13	DELETED	
K1.14	DELETED	
K1.15	DELETED	
K1.16	Component cooling water systems	2.6
K1.17	DELETED	
K1.18	DELETED	
K1.19	DELETED	
K1.20	DELETED	
K1.21	DELETED	
K1.22	DELETED	
K1.23	Recirculation flow control system	3.2
K1.24	Main turbine generator and auxiliary systems	3.3
K1.25	DELETED	
K1.26	DELETED	
K1.27	DELETED	
K1.28	DELETED	
K1.29	DELETED	
K1.30	DELETED	
K1.31	DELETED	
K1.32	DELETED	
K1.33	DELETED	
K1.34	DELETED	
K1.35	DELETED	
K1.36	DELETED	

System: 241000 SF3 RTPRS Reactor/Turbine Pressure Regulating System

K1.37	DELETED	
K1.38	PCIS/NSSSS	3.4
K1.39	Main and reheat steam system	3.3
K1.40	Nuclear boiler instrumentation system	3.3
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Pumps	2.9
K2.02	Controls	2.9
K3	Knowledge of the effect that a loss or malfunction of the Reactor/Turbine Pressure Regulating System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor power	4.5
K3.02	Reactor pressure	4.5
K3.03	Reactor water level	3.9
K3.04	Reactor steam flow	3.9
K3.05	Main turbine steam flow	3.8
K3.06	DELETED	
K3.07	DELETED	
K3.08	DELETED	
K3.09	DELETED	
K3.10	DELETED	
K3.11	RPS	4.1
K3.12	DELETED	
K3.13	DELETED	
K3.14	Component cooling water systems	2.3
K3.15	DELETED	
K3.16	DELETED	
K3.17	Turbine acceleration	2.9
K3.18	Turbine speed	3.0
K3.19	Turbine inlet pressure	3.2
K3.20	DELETED	
K3.21	Recirculation flow control system	3.1
K3.22	Main turbine generator and auxiliary systems	3.1
K3.23	DELETED	
K3.24	Reactor heatup rate	3.8
K3.25	Reactor cooldown rate	3.9
K3.26	DELETED	

System: 241000 SF3 RTPRS Reactor/Turbine Pressure Regulating System

K3.27	DELETED	
K3.28	DELETED	
K3.29	PCIS/NSSSS	3.5
K3.30	DELETED	
K3.31	Main and reheat steam system	3.2

**K4 Knowledge of Reactor/Turbine Pressure Regulating System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Reactor pressure control	4.3
K4.02	Turbine inlet pressure control	3.5
K4.03	Turbine speed control	3.2
K4.04	Turbine acceleration control	3.1
K4.05	Reactor SCRAM	4.4
K4.06	Turbine trip	4.2
K4.07	Generator runback	3.9
K4.08	Feedwater heater isolation	3.2
K4.09	Turbine chest warming	2.8
K4.10	Turbine shell warming	2.8
K4.11	Load following	2.5
K4.12	Recirculation flow control	3.1
K4.13	Turbine trip testing	2.9
K4.14	DELETED	
K4.15	Automatic pump start	3.0
K4.16	Reactor cooldown	3.7
K4.17	DELETED	
K4.18	Turbine protection	3.6
K4.19	Main turbine bypass valve control	4.0

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Reactor/Turbine Pressure Regulating System:
(CFR: 41.5 / 45.3)**

K5.01	Accumulator operation	2.6
K5.02	DELETED	
K5.03	Reactor power vs. reactor pressure	4.2
K5.04	Turbine inlet pressure vs. reactor pressure	3.6
K5.05	Turbine inlet pressure vs. turbine load	3.3
K5.06	Turbine speed measurement	2.6
K5.07	DELETED	

System: 241000 SF3 RTPRS Reactor/Turbine Pressure Regulating System

K5.08 Valve position control 3.3

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Reactor/Turbine Pressure Regulating System:
(CFR: 41.7 / 45.7)

K6.01	AC electrical power	3.4
K6.02	DC electrical power	3.2
K6.03	Component cooling water systems	2.6
K6.04	Recirculation flow control system	3.1
K6.05	Condenser vacuum	3.5
K6.06	Reactor pressure	4.0
K6.07	Turbine inlet pressure	3.3
K6.08	Reactor power	4.0
K6.09	Main turbine steam flow	3.4
K6.10	Bypass valves	4.0
K6.11	Main stop valves	3.7
K6.12	Control/governor valves	3.7
K6.13	Combined intermediate valves	3.3
K6.14	Bearing oil	3.0
K6.15	Turbine speed signal	3.0
K6.16	Stator water cooling system	3.2
K6.17	Main turbine prime mover governor	2.8
K6.18	Low pressure stop and control valves	3.0
K6.19	DELETED	
K6.20	Main turbine generator and auxiliary systems	3.0
K6.21	Front standard trip system	3.4
K6.22	Turbine chest warming	2.7
K6.23	Turbine shell warming	2.7
K6.24	Turbine trip	3.9
K6.25	Reactor startup	3.8

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Reactor/Turbine Pressure Regulating System, including:
(CFR: 41.5 / 45.5)

A1.01	Reactor pressure	4.4
A1.02	Reactor power	4.4
A1.03	Reactor water level	3.8
A1.04	Main turbine inlet pressure	3.3

System: 241000 SF3 RTPRS Reactor/Turbine Pressure Regulating System

A1.05	Reactor steam flow	3.7
A1.06	Main turbine steam flow	3.5
A1.07	Main turbine bypass valve position	4.0
A1.08	Control/governor valve position	3.4
A1.09	Main stop valve position	3.4
A1.10	Combined intermediate valve position	3.2
A1.11	Hydraulic oil pressure	3.2
A1.12	Reactor/turbine pressure regulating system load set/reference	3.5
A1.13	Main turbine speed	3.0
A1.14	Pressure setpoint/pressure demand	3.7
A1.15	Maximum combined flow limit	3.3
A1.16	Load limit set	3.4
A1.17	Hydraulic oil pump current	2.1
A1.18	Hydraulic reservoir oil level	2.5
A1.19	Hydraulic reservoir oil temperature	2.4
A1.20	Servo valve position	2.5
A1.21	Main condenser vacuum	3.7
A1.22	Reactor cooldown	3.8
A1.23	Main turbine vibration	3.4
A1.24	Main turbine eccentricity	2.6
A1.25	Main turbine expansion	2.6
A1.26	Governor valve limit	2.6
A1.27	Lights and alarms	3.3
A1.28	Main generator output	3.4
A1.29	MSR cross-around pressure	2.7

A2 Ability to (a) predict the impacts of the following on the Reactor/Turbine Pressure Regulating System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Loss of turbine inlet pressure signal	3.3	3.4
A2.02	High reactor pressure	4.4	4.1
A2.03	Abnormal main turbine bypass valve position	4.0	3.9
A2.04	Abnormal control/governor valve position	3.8	3.7
A2.05	Abnormal main stop valve position	3.9	3.5
A2.06	Low hydraulic oil pressure	3.7	3.3
A2.07	Loss of condenser vacuum	4.3	3.8
A2.08	Main turbine overspeed	4.0	3.5
A2.09	Loss of generator load	4.2	3.6
A2.10	Loss of stator water cooling	4.0	3.6

System: 241000 SF3 RTPRS Reactor/Turbine Pressure Regulating System

A2.11	Loss of AC electrical power	3.5	3.3
A2.12	Loss of DC electrical power	3.6	3.2
A2.13	Loss of component cooling water systems	3.1	2.7
A2.14	Loss of main turbine prime mover governor	3.1	2.7
A2.15	Loss of main turbine speed feedback	2.8	2.8
A2.16	Loss of steam pressure signal	3.7	3.3
A2.17	Turbine trip	4.3	4.0
A2.18	Generator trip	4.3	4.0
A2.19	Reactor SCRAM	4.4	4.2
A2.20	Abnormal reservoir oil level	3.4	2.8
A2.21	Hydraulic pump trip	3.4	3.2
A2.22	Turbine high vibration	3.8	3.4
A2.23	Turbine high eccentricity	2.8	2.7
A2.24	Turbine high differential expansion	2.8	2.5
A2.25	DELETED		

**A3 Ability to monitor automatic operation of the Reactor/Turbine Pressure Regulating System, including:
(CFR: 41.7 / 45.7)**

A3.01	Turbine speed control	3.2	
A3.02	Turbine acceleration control	3.0	
A3.03	Turbine inlet pressure control	3.2	
A3.04	Hydraulic pump start	3.0	
A3.05	Low hydraulic pressure turbine trip	3.4	
A3.06	Low hydraulic pressure reactor SCRAM	3.7	
A3.07	Hydraulic reservoir oil temperature control	2.6	
A3.08	Main turbine bypass valve operation	4.0	
A3.09	Control/governor valve operation	3.7	
A3.10	Main stop valve operation	3.4	
A3.11	Combined intermediate valve operation	3.3	
A3.12	DELETED		
A3.13	Feedwater heater isolation	3.3	
A3.14	DELETED		
A3.15	Recirculation pump trip	3.6	
A3.16	DELETED		
A3.17	Turbine runback	4.0	
A3.18	Turbine startup	3.5	
A3.19	Shell/chest warming	3.0	
A3.20	Reactor cooldown	3.8	

System: 241000 SF3 RTPRS Reactor/Turbine Pressure Regulating System

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	DELETED	
A4.02	DELETED	
A4.03	DELETED	
A4.04	DELETED	
A4.05	DELETED	
A4.06	Bypass valves	4.2
A4.07	Main stop valves	3.6
A4.08	Control/governor valves	3.6
A4.09	Combined intermediate valves	3.4
A4.10	Hydraulic pumps	3.3
A4.11	Turbine speed	3.3
A4.12	Turbine acceleration	3.0
A4.13	DELETED	
A4.14	Turbine trip	4.1
A4.15	Generator load	3.7
A4.16	DELETED	
A4.17	Turbine chest warming	2.9
A4.18	Turbine shell warming	2.9
A4.19	Turbine panel controls	3.4
A4.20	Turbine trip testing	3.2

System: 239002 SF3 SRV Safety Relief Valves

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Safety Relief Valves and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Reactor vessel and internals	3.6
K1.02	Plant process computer/parameter display systems	3.0
K1.03	Nuclear boiler instrument system	3.6
K1.04	Main steam system	3.8
K1.05	Instrument air systems	3.1
K1.06	Drywell instrument air/drywell pneumatics	3.6
K1.07	Suppression pool	4.1
K1.08	Automatic depressurization system	4.5
K1.09	DELETED	
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	SRV solenoids	3.7
K3	Knowledge of the effect that a loss or malfunction of the Safety Relief Valves will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor pressure control	4.3
K3.02	Reactor overpressurization	4.4
K3.03	DELETED	
K3.04	Automatic depressurization system	4.5
K3.05	Suppression pool	3.9
K4	Knowledge of Safety Relief Valves design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Ensures that only one or two safety/relief valves reopen following the initial portion of a reactor isolation event (low-low set logic)	3.7
K4.02	Minimizes containment fatigue duty cycles resulting from relief valve cycling during decay-heat-dominant period late in an isolation transient (low-low set logic)	3.3
K4.03	Prevents siphoning of water into SRV discharge piping and limits loads on subsequent actuation of SRVs	3.5
K4.04	Ensures even distribution of heat load to suppression pool and adequate steam condensing	3.5

System: 239002 SF3 SRV Safety Relief Valves

K4.05	Allows for SRV operation from more than one location	3.7
K4.06	Detection of valve leakage	3.5
K4.07	Minimum steam pressure required to keep SRV open or to open SRV	3.6
K4.08	Opening of the SRV from either an electrical or mechanical signal	3.9
K4.09	Manual opening of the SRV	4.0
K4.10	Methods for determining position of SRV	4.1

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Safety Relief Valves:
(CFR: 41.5 / 45.3)

K5.01	Relief function of SRV operation	4.0
K5.02	Safety function of SRV operation	4.0
K5.03	Acoustical monitoring	3.2
K5.04	Tailpipe temperature monitoring	3.6
K5.05	Discharge line quencher operation	3.2
K5.06	Vacuum breaker operation	3.3
K5.07	Rapid depressurization of the reactor	4.2

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Safety Relief Valves:
(CFR: 41.7 / 45.5 to 45.8)

K6.01	Nuclear boiler instrument system (pressure indication)	3.8
K6.02	Pneumatics supply	3.8
K6.03	AC power	3.2
K6.04	DC power	3.9
K6.05	Discharge line vacuum breaker	3.4

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Safety Relief Valves, including:
(CFR: 41.5 / 45.5)

A1.01	Tailpipe temperature	3.8
A1.02	Acoustical monitor noise	3.2
A1.03	Pneumatic supply	3.5
A1.04	Reactor pressure	4.3
A1.05	Reactor water level	4.2
A1.06	Reactor power	4.1
A1.07	Turbine load	3.4

System: 239002 SF3 SRV Safety Relief Valves

A1.08	Suppression pool water temperature	4.0
A1.09	Indicated vs. actual steam flow	3.5
A1.10	Drywell pressure	3.6
A1.11	Lights and alarms	3.7

A2 Ability to (a) predict the impacts of the following on the Safety Relief Valves and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Stuck-open vacuum breakers	3.7	3.6
A2.02	Leaking SRV	3.7	3.6
A2.03	Stuck-open SRV	4.6	4.4
A2.04	ADS actuation	4.6	4.5
A2.05	Low reactor pressure	3.9	3.5
A2.06	Reactor high pressure	4.6	4.2

A3 Ability to monitor automatic operation of the Safety Relief Valves, including:

(CFR: 41.7 / 45.7)

A3.01	SRV operation after ADS actuation	4.1
A3.02	SRV operation on high reactor pressure	4.2
A3.03	DELETED	
A3.04	DELETED	
A3.05	DELETED	
A3.06	DELETED	
A3.07	DELETED	
A3.08	DELETED	
A3.09	Low-low set logic	3.8

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

A4.01	SRVs	4.4
A4.02	DELETED	
A4.03	DELETED	
A4.04	Suppression pool temperature	4.2
A4.05	Reactor pressure	4.4
A4.06	DELETED	
A4.07	DELETED	
A4.08	DELETED	

3.4	Safety Function 4: Heat Removal from the Reactor Core	Page
206000	High-Pressure Coolant Injection System.....	3.4-3
209002	High-Pressure Core Spray System.....	3.4-8
207000	Isolation (Emergency) Condenser.....	3.4-12
209001	Low-Pressure Core Spray System.....	3.4-16
239001	Main and Reheat Steam System.....	3.4-20
245000	Main Turbine Generator and Auxiliary Systems.....	3.4-25
217000	Reactor Core Isolation Cooling System.....	3.4-29
202001	Recirculation System.....	3.4-34
203000	Residual Heat Removal/Low-Pressure Coolant Injection: Injection Mode.....	3.4-40
205000	Shutdown Cooling System (RHR Shutdown Cooling Mode).....	3.4-45
290002	Reactor Vessel and Internals.....	3.4-49
510000	Service Water System.....	3.4-53

System: 206000 SF4 HPCI High-Pressure Coolant Injection System (BWR 2, 3, 4)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the High-Pressure Coolant Injection System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Reactor vessel and internals	3.5
K1.02	DELETED	
K1.03	DELETED	
K1.04	Feedwater system	3.7
K1.05	Condensate system	3.0
K1.06	Primary containment	3.5
K1.07	DELETED	
K1.08	DELETED	
K1.09	DELETED	
K1.10	DELETED	
K1.11	DELETED	
K1.12	Nuclear boiler instrumentation	3.6
K1.13	DELETED	
K1.14	SGTS	2.7
K1.15	Instrument air system	2.6
K1.16	DELETED	
K1.17	Reactor protection system	2.8
K1.18	Main steam system	3.4
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Motor-operated valves	3.7
K2.02	Pumps	3.2
K2.03	Initiation/isolation logic	4.1
K2.04	Turbine control circuits	3.3
K3	Knowledge of the effect that a loss or malfunction of the High-Pressure Coolant Injection System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor water level	4.3
K3.02	Reactor pressure	3.8
K3.03	Suppression pool level	3.4

System: 206000 SF4 HPCI High-Pressure Coolant Injection System (BWR 2, 3, 4)

K3.04	Reactor power	3.6
K3.05	Secondary containment parameters	3.1

**K4 Knowledge of High-Pressure Coolant Injection System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Turbine trips	3.8
K4.02	System isolations	4.2
K4.03	Resetting turbine trips	3.8
K4.04	Resetting system isolations	3.9
K4.05	Preventing water hammer in turbine exhaust line (vacuum breakers)	3.4
K4.06	Preventing water hammer in pump discharge line (keep fill)	3.3
K4.07	Automatic system initiation	4.4
K4.08	Manual system initiation	4.3
K4.09	Automatic flow control	3.9
K4.10	DELETED	
K4.11	Turbine speed control	3.7
K4.12	Condensation of shaft sealing steam	2.5
K4.13	Turbine and pump lubrication	3.2
K4.14	Control oil to turbine speed controls	3.1
K4.15	Low-speed turning of the turbine rotor	2.5
K4.16	DELETED	
K4.17	DELETED	
K4.18	Pump minimum flow	3.2
K4.19	Automatic transfer of HPCI pump suction	3.7
K4.20	Testable check valve operation	2.3

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the High-Pressure Coolant Injection System:
(CFR: 41.5 / 45.3)**

K5.01	Turbine operation	3.5
K5.02	Turbine shaft sealing	2.6
K5.03	Flow control	3.7
K5.04	Indications of pump cavitation	3.2
K5.05	Turbine speed control	3.5
K5.06	Turbine speed measurement	2.7
K5.07	DELETED	

System: 206000 SF4 HPCI High-Pressure Coolant Injection System (BWR 2, 3, 4)

K5.08	DELETED	
K5.09	DELETED	
K5.10	Reactor pressure control	3.9

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the High-Pressure Coolant Injection System:
(CFR: 41.7 / 45.7)

K6.01	Instrument air system	2.6
K6.02	DC electrical distribution system	3.9
K6.03	AC electrical distribution system	3.3
K6.04	Condensate storage tank low level	3.7
K6.05	Suppression pool level	3.7
K6.06	SGTS	3.0
K6.07	Keep fill system	3.0
K6.08	Low reactor pressure	3.4
K6.09	DELETED	
K6.10	HPCI initiation/isolation logic	4.3
K6.11	Nuclear boiler instrumentation	3.6
K6.12	Reactor water level	4.0
K6.13	High suppression pool temperature	3.6
K6.14	Feedwater system	3.3
K6.15	Low-pressure core spray system	2.5
K6.16	High turbine exhaust pressure	3.6
K6.17	High steam flow	3.7
K6.18	Area high temperature	3.9
K6.19	High drywell pressure	4.0
K6.20	Auxiliary oil pump	3.8
K6.21	Component cooling water	3.0

A1 Ability to predict and/or monitor changes in parameters associated with operation of the High-Pressure Coolant Injection System, including:
(CFR: 41.5 / 45.5)

A1.01	Reactor water level	4.3
A1.02	Reactor pressure	4.1
A1.03	Condensate storage tank level	3.5
A1.04	Suppression pool level	3.6
A1.05	Suppression pool temperature	3.8
A1.06	System flow	3.9

System: 206000 SF4 HPCI High-Pressure Coolant Injection System (BWR 2, 3, 4)

A1.07	System discharge pressure	3.8
A1.08	DELETED	
A1.09	Turbine speed	3.5
A1.10	Lights and alarms	3.6
A1.11	Secondary containment parameters	3.1
A1.12	Turbine bearing temperature	3.0

A2 Ability to (a) predict the impacts of the following on the High-Pressure Coolant Injection System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Turbine trips	4.3	4.1
A2.02	DELETED		
A2.03	Abnormal valve positions	4.0	3.7
A2.04	AC electrical distribution system failures	4.0	3.5
A2.05	DC electrical distribution system failures	4.3	3.9
A2.06	Inadequate system flow	4.3	3.6
A2.07	High/low suppression pool level	4.2	3.6
A2.08	High suppression pool temperature	4.3	3.6
A2.09	Low condensate storage tank level	3.8	3.5
A2.10	System isolation	4.7	4.0
A2.11	High/low reactor water level	4.3	4.1
A2.12	Loss of room cooling	3.3	2.8
A2.13	Loss of instrument air system	3.2	2.5
A2.14	Flow controller failure	4.3	3.6
A2.15	Loss of control oil pressure	4.3	3.7
A2.16	High drywell pressure	4.5	3.8
A2.17	Inadvertent initiation	4.3	3.9

A3 Ability to monitor automatic operation of the High-Pressure Coolant Injection System, including:
(CFR: 41.7 / 45.7)

A3.01	DELETED		
A3.02	DELETED		
A3.03	System initiation	4.4	
A3.04	DELETED		
A3.05	DELETED		
A3.06	DELETED		
A3.07	DELETED		
A3.08	DELETED		

System: 206000 SF4 HPCI High-Pressure Coolant Injection System (BWR 2, 3, 4)

A3.09	System isolation	4.3
A3.10	Pump suction transfer	3.6
A3.11	Barometric condenser level control	2.5
A3.12	Turbine reset	3.8

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Turbine speed control	4.2
A4.02	Flow controller	4.3
A4.03	DELETED	
A4.04	Valves	3.8
A4.05	DELETED	
A4.06	DELETED	
A4.07	DELETED	
A4.08	DELETED	
A4.09	DELETED	
A4.10	Pumps	3.7
A4.11	Turning gear	2.4
A4.12	Turbine trip	4.1
A4.13	Initiation reset	4.0
A4.14	DELETED	
A4.15	Isolation reset	4.0

System: 209002 SF4 HPCS High-Pressure Core Spray System (BWR 5, 6)

K/A NO. KNOWLEDGE IMPORTANCE

K1 Knowledge of the physical connections and/or cause and effect relationships between the High-Pressure Core Spray System and the following systems:
(CFR: 41.2 to 41.9 / 45.7 to 45.8)

K1.01	Condensate system	3.2
K1.02	Primary containment	3.6
K1.03	DELETED	
K1.04	Emergency generators	4.0
K1.05	Standby liquid control system	3.3
K1.06	Suppression pool cleanup system	2.8
K1.07	Plant ventilation systems (HPCS room coolers)	3.1
K1.08	Component cooling water systems	3.1
K1.09	Leak detection	3.2
K1.10	DELETED	
K1.11	DELETED	
K1.12	Reactor vessel and internals	3.7
K1.13	Instrument nitrogen	2.1
K1.14	Instrument air system	2.4
K1.15	Safety-related service water	3.6

K2 Knowledge of electrical power supplies to the following:
(CFR: 41.7)

K2.01	Pumps	4.2
K2.02	Valves	3.9
K2.03	Initiation logic	4.2

K3 Knowledge of the effect that a loss or malfunction of the High-Pressure Core Spray System will have on the following systems or system parameters:
(CFR: 41.7 / 45.4)

K3.01	Reactor water level	4.3
K3.02	Standby liquid control system	3.0
K3.03	DELETED	
K3.04	Suppression pool level	3.3
K3.05	Reactor power	3.6
K3.06	Reactor pressure	3.7
K3.07	Secondary containment parameters	2.9
K3.08	Condensate storage tank level	3.2
K3.09	Override of drywell pressure interlock	3.6

System: 209002 SF4 HPCS High-Pressure Core Spray System (BWR 5, 6)

**K4 Knowledge of High-Pressure Core Spray System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Prevention of water hammer (keep fill)	3.5
K4.02	Prevention of overfilling reactor vessel	4.0
K4.03	Prevention of pump overheating	3.2
K4.04	Testable check valve operation	2.4
K4.05	DELETED	
K4.06	DELETED	
K4.07	Override of reactor water level interlock	4.0
K4.08	Automatic system initiation	4.4
K4.09	Manual system initiation	4.2
K4.10	Uniform core spray coverage	3.1
K4.11	Prevention of piping overpressurization	3.2
K4.12	Automatic transfer of HPCS pump suction	3.8

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the High-Pressure Core Spray System:
(CFR: 41.5 / 45.3)**

K5.01	Indications of pump cavitation	3.5
K5.02	DELETED	
K5.03	DELETED	
K5.04	Adequate core cooling	4.5

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the High-Pressure Core Spray System:
(CFR: 41.7 / 45.7)**

K6.01	Loss of AC electrical distribution	4.2
K6.02	Abnormal condensate storage tank water level	3.6
K6.03	Component cooling water systems	3.1
K6.04	Suppression pool suction strainer	3.4
K6.05	Abnormal suppression pool water level	3.7
K6.06	Keep fill system	3.3
K6.07	Plant ventilation systems (HPCS room coolers)	3.3
K6.08	Loss of DC electrical distribution	3.8
K6.09	Abnormal reactor water level	4.2
K6.10	High drywell pressure	4.1

System: 209002 SF4 HPCS High-Pressure Core Spray System (BWR 5, 6)

K6.11 High suppression pool temperature 3.5

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the High-Pressure Core Spray System, including:
(CFR: 41.5 / 45.5)**

A1.01	System flow	4.0
A1.02	System pressure	3.9
A1.03	Reactor water level	4.3
A1.04	Reactor pressure	3.9
A1.05	Suppression pool level	3.6
A1.06	DELETED	
A1.07	Diesel loading	3.8
A1.08	System lineup	3.9
A1.09	Condensate storage tank level	3.6
A1.10	Lights and alarms	3.7
A1.11	Suppression pool temperature	3.3
A1.12	Reactor power	3.8

**A2 Ability to (a) predict the impacts of the following on the High-Pressure Core Spray System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	Automatic system initiation	4.5	4.4
A2.02	Pump trips	4.1	3.9
A2.03	Abnormal valve positions	4.1	3.9
A2.04	Loss of AC electrical distribution	4.1	4.0
A2.05	Loss of DC electrical distribution	4.0	3.9
A2.06	Core spray line break	4.0	3.6
A2.07	Pump seal failure	3.5	3.3
A2.08	Inadequate system flow	4.0	3.8
A2.09	Loss of plant ventilation (HPCS room coolers)	3.1	3.3
A2.10	DELETED		
A2.11	Low suppression pool level	3.8	3.5
A2.12	High suppression pool level	3.4	3.2
A2.13	Low condensate storage tank level	3.4	3.7
A2.14	High suppression pool temperature	3.4	3.4
A2.15	Clogged suppression pool suction strainers	3.8	3.4
A2.16	Emergency diesel generator failure	4.3	3.9
A2.17	Initiation logic failure	4.5	4.2
A2.18	Keep fill system failure	3.6	3.3

System: 209002 SF4 HPCS High-Pressure Core Spray System (BWR 5, 6)

A2.19	Abnormal reactor water level	4.1	3.9
A2.20	High drywell pressure	4.3	3.9
A2.21	Inadvertent initiation	4.0	3.4

**A3 Ability to monitor automatic operation of the High-Pressure Core Spray System, including:
(CFR: 41.7 / 45.7)**

A3.01	Valve operation	4.2	
A3.02	Pump start	4.1	
A3.03	DELETED		
A3.04	DELETED		
A3.05	DELETED		
A3.06	DELETED		
A3.07	Emergency diesel generator operation	4.1	
A3.08	Pump trip	4.0	

**A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)**

A4.01	HPCS pump	4.3	
A4.02	Suction valves	4.0	
A4.03	Injection valve	4.3	
A4.04	Minimum flow valve	3.8	
A4.05	Manual initiation controls	4.3	
A4.06	Testable check valve	2.4	
A4.07	Keep fill pump	3.2	
A4.08	DELETED		
A4.09	DELETED		
A4.10	DELETED		
A4.11	DELETED		
A4.12	DELETED		
A4.13	DELETED		
A4.14	Test return valve	3.3	
A4.15	Initiation reset	3.9	
A4.16	Emergency diesel generator operation	4.3	

System: 207000 SF4 IC Isolation (Emergency) Condenser (BWR 2, 3)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Isolation (Emergency) Condenser and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Reactor vessel and internals	3.8
K1.02	DELETED	
K1.03	DELETED	
K1.04	Condensate system	2.8
K1.05	Demineralized water system	3.2
K1.06	Fire protection system	3.3
K1.07	DELETED	
K1.08	Recirculation system	3.7
K1.09	Main steam system	3.5
K1.10	Instrument air system	3.2
K1.11	PCIS/NSSSS	3.7
K1.12	Reactor protection system	3.5
K1.13	Low-pressure core spray system	2.7
K1.14	Shutdown cooling system	2.6
K1.15	Primary containment system and auxiliaries	3.2
K1.16	Service water system	2.5
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Motor-operated valves	3.5
K2.02	Initiation logic	3.7
K3	Knowledge of the effect that a loss or malfunction of the Isolation (Emergency) Condenser will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor pressure	3.8
K3.02	Reactor water level	3.6
K3.03	Reactor vessel and internals	3.0
K3.04	Recirculation system	3.2

System: 207000 SF4 IC Isolation (Emergency) Condenser (BWR 2, 3)

**K4 Knowledge of Isolation (Emergency) Condenser design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	System isolation	4.1
K4.02	Automatic initiation	4.3
K4.03	Filling of the system	3.3
K4.04	DELETED	
K4.05	Leak detection	3.3
K4.06	Throttling of system flow	3.2
K4.07	Manual operation of the system	3.5
K4.08	DELETED	

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Isolation (Emergency) Condenser:
(CFR: 41.5 / 45.3)**

K5.01	DELETED	
K5.02	DELETED	
K5.03	Assist core cooling	3.7
K5.04	DELETED	
K5.05	DELETED	
K5.06	DELETED	
K5.07	DELETED	
K5.08	DELETED	
K5.09	Cooldown rate	3.8
K5.10	System venting	3.2
K5.11	Incomplete steam condensation	2.8

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Isolation (Emergency) Condenser:
(CFR: 41.7 / 45.7)**

K6.01	Demineralized water system	3.2
K6.02	Fire protection system	3.0
K6.03	Condensate system	2.8
K6.04	Instrument air system	3.3
K6.05	PCIS/NSSSS	3.8
K6.06	Recirculation system	3.3
K6.07	AC electrical distribution	3.5

System: 207000 SF4 IC Isolation (Emergency) Condenser (BWR 2, 3)

K6.08	DC electrical distribution	3.7
K6.09	Reactor protection system	3.3
K6.10	Low-pressure core spray	2.7
K6.11	Shutdown cooling system	2.8
K6.12	Service water system	2.7
K6.13	Main steam system	3.2

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Isolation (Emergency) Condenser, including:
(CFR: 41.5 / 45.5)

A1.01	Isolation condenser level	3.8
A1.02	Shell side water temperature	3.4
A1.03	Steam flow	3.2
A1.04	Condensate flow	3.3
A1.05	Reactor pressure	4.0
A1.06	Reactor water level	3.5
A1.07	Vent radiation level	3.9
A1.08	Cooldown rate	3.8
A1.09	DELETED	
A1.10	Primary side temperature	3.4
A1.11	Lights and alarms	3.7
A1.12	Steam line pressure	3.5

A2 Ability to (a) predict the impacts of the following on the Isolation (Emergency) Condenser and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Tube bundle leak	4.0	4.1
A2.02	Vent high radiation	4.0	4.1
A2.03	System isolation	4.0	3.9
A2.04	Abnormal system flow	3.3	3.6
A2.05	Insufficient shell side makeup	3.7	3.9
A2.06	Valve malfunctions	3.7	3.7
A2.07	DELETED		
A2.08	Inadvertent system initiation	4.0	4.2

System: 207000 SF4 IC Isolation (Emergency) Condenser (BWR 2, 3)

A3 Ability to monitor automatic operation of the Isolation (Emergency) Condenser, including:
(CFR: 41.7 / 45.7)

A3.01	Isolation condenser level control	3.9
A3.02	DELETED	
A3.03	DELETED	
A3.04	DELETED	
A3.05	System initiation	4.3
A3.06	DELETED	
A3.07	DELETED	
A3.08	DELETED	
A3.09	System isolation	4.2

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Isolation condenser level control	4.0
A4.02	DELETED	
A4.03	DELETED	
A4.04	DELETED	
A4.05	DELETED	
A4.06	DELETED	
A4.07	System initiation	4.2
A4.08	System isolation	4.1

System: 209001 SF4 LPCS Low-Pressure Core Spray System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Low-Pressure Core Spray System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	DELETED	
K1.02	Primary containment	3.7
K1.03	DELETED	
K1.04	Condensate system	2.6
K1.05	Automatic depressurization system	4.2
K1.06	Instrument air systems	2.4
K1.07	DELETED	
K1.08	DELETED	
K1.09	Nuclear boiler instrumentation	3.6
K1.10	Emergency generators	4.2
K1.11	Drywell coolers	2.4
K1.12	ECCS room coolers	3.1
K1.13	Leak detection	3.2
K1.14	Reactor vessel and internals	3.7
K1.15	Residual heat removal system	3.3
K1.16	High-pressure coolant injection system	3.0
K1.17	Standby liquid control	2.7
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Pumps	4.2
K2.02	Valves	3.8
K2.03	Initiation logic	4.1
K3	Knowledge of the effect that a loss or malfunction of the Low-Pressure Core Spray System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor water level	4.3
K3.02	ADS logic	4.1
K3.03	Emergency generators	3.6
K3.04	DELETED	
K3.05	Drywell cooling	2.8

System: 209001 SF4 LPCS Low-Pressure Core Spray System

**K4 Knowledge of Low-Pressure Core Spray System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Prevention of overpressurization of core spray piping	3.5
K4.02	Prevention of water hammer	3.4
K4.03	Motor cooling	2.9
K4.04	Line break detection	3.4
K4.05	Pump minimum flow	3.4
K4.06	Adequate pump net positive suction head	3.4
K4.07	DELETED	
K4.08	Automatic system initiation	4.5
K4.09	Load sequencing	4.0
K4.10	DELETED	
K4.11	Override injection	3.9

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Low-Pressure Core Spray System:
(CFR: 41.5 / 45.3)**

K5.01	DELETED	
K5.02	Abnormal differential pressure indication (leak detection)	3.4
K5.03	Testable check valve operation	2.5
K5.04	Heat removal (transfer) mechanisms	3.2
K5.05	DELETED	
K5.06	DELETED	
K5.07	Adequate core cooling	4.5

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Low-Pressure Core Spray System:
(CFR: 41.7 / 45.7)**

K6.01	Loss of AC electrical distribution system	4.2
K6.02	Loss of emergency generators	4.2
K6.03	Torus/suppression pool water level	3.7
K6.04	Loss of DC electrical distribution system	3.9
K6.05	ECCS room cooler(s)	3.4
K6.06	Pump motor cooler(s)	2.9
K6.07	Pump seal cooler(s)	2.9
K6.08	Keep fill system	3.4

System: 209001 SF4 LPCS Low-Pressure Core Spray System

K6.09	DELETED	
K6.10	ECCS room integrity	3.1
K6.11	ADS	4.1
K6.12	Suppression pool suction strainer	3.4
K6.13	High drywell pressure	4.3
K6.14	Low reactor water level	4.3
K6.15	Condensate storage tank low level	2.8

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Low-Pressure Core Spray System, including:
(CFR: 41.5 / 45.5)

A1.01	Core spray flow	4.1
A1.02	Core spray pressure	3.9
A1.03	Reactor water level	4.4
A1.04	Reactor pressure	4.1
A1.05	Torus/suppression pool water level	3.6
A1.06	DELETED	
A1.07	Emergency generator loading	3.9
A1.08	System lineup	4.0
A1.09	Lights and alarms	3.7
A1.10	Suppression pool temperature	3.3

A2 Ability to (a) predict the impacts of the following on the Low-Pressure Core Spray System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Pump trips	4.1	3.9
A2.02	Valve closures due to malfunction(s)	3.9	3.8
A2.03	AC failures	4.0	4.0
A2.04	DC failures	3.7	4.0
A2.05	Core spray line break	4.0	3.5
A2.06	Inadequate system flow	4.3	3.7
A2.07	Loss of room cooling	3.3	3.2
A2.08	Valve openings due to malfunction(s)	3.9	3.5
A2.09	Low suppression pool level	3.8	3.5
A2.10	High suppression pool temperature	3.5	3.3
A2.11	Loss of fire protection	2.3	2.0
A2.12	Inadvertent system initiation	4.4	4.3

System: 209001 SF4 LPCS Low-Pressure Core Spray System

A3 Ability to monitor automatic operation of the Low-Pressure Core Spray System, including:
(CFR: 41.7 / 45.7)

A3.01	Valve operation	4.2
A3.02	Pump start	4.3
A3.03	DELETED	
A3.04	DELETED	
A3.05	DELETED	
A3.06	DELETED	

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Core spray pump	4.3
A4.02	Valves	4.2
A4.03	DELETED	
A4.04	DELETED	
A4.05	Manual initiation controls	4.2
A4.06	DELETED	
A4.07	Keep fill pump	3.0
A4.08	DELETED	
A4.09	DELETED	
A4.10	DELETED	
A4.11	DELETED	
A4.12	DELETED	
A4.13	DELETED	
A4.14	DELETED	
A4.15	Initiation reset	3.6

System: 239001 SF4 MRSS Main and Reheat Steam System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Main and Reheat Steam System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Reactor vessel and internals	3.5
K1.02	Plant process computer/parameter display systems	2.6
K1.03	Main turbine generator and auxiliary systems	3.6
K1.04	DELETED	
K1.05	DELETED	
K1.06	Reactor/turbine pressure regulating system	4.0
K1.07	Offgas system	3.2
K1.08	DELETED	
K1.09	DELETED	
K1.10	Extraction steam system	3.2
K1.11	DELETED	
K1.12	Instrument air systems	3.0
K1.13	Main steam isolation valve leakage control system	3.0
K1.14	DELETED	
K1.15	DELETED	
K1.16	Radiation monitoring system	3.0
K1.17	Primary containment system and auxiliaries	3.2
K1.18	High-pressure coolant injection system	3.3
K1.19	Reactor core isolation cooling system	3.4
K1.20	Residual heat removal system	2.7
K1.21	Isolation condenser system	3.6
K1.22	Feedwater system	3.3
K1.23	Reactor water level control system	3.7
K1.24	DELETED	
K1.25	DELETED	
K1.26	Safety relief valves	4.0
K1.27	Reactor protection system	4.1
K1.28	PCIS/NSSSS	3.9
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Main steam isolation valve solenoids	3.6
K2.02	Main steam line shutoff valves	3.3

System: 239001 SF4 MRSS Main and Reheat Steam System

**K3 Knowledge of the effect that a loss or malfunction of the Main and Reheat Steam System will have on the following systems or system parameters:
(CFR: 41.7 / 45.4)**

K3.01	Main turbine generator and auxiliary systems	3.5
K3.02	Condenser vacuum	3.5
K3.03	Feedwater system	3.5
K3.04	Offgas system	3.1
K3.05	DELETED	
K3.06	Reactor/turbine pressure regulating system	3.7
K3.07	Primary containment system and auxiliaries	3.2
K3.08	DELETED	
K3.09	DELETED	
K3.10	High-pressure coolant injection system	3.3
K3.11	Reactor core isolation cooling system	3.5
K3.12	Isolation condenser	3.7
K3.13	DELETED	
K3.14	Residual heat removal system	2.7
K3.15	Reactor water level	3.7
K3.16	Safety relief valves	3.9
K3.17	Reactor vessel and internals	3.2

**K4 Knowledge of Main and Reheat Steam System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Steam line isolation	4.3
K4.02	Automatic isolation and opening of drain valves	3.3
K4.03	Ensures that steam released from a steam line break will not bypass suppression pool (BWR 6)	3.7
K4.04	Limits steam flow during a steam line rupture	3.5
K4.05	Steam flow measurement	3.4
K4.06	Allows for removal or prevents escape of radioactive steam from systems that have leaky MSIVs	3.1
K4.07	Overpressure control	4.1
K4.08	Removal of noncondensable gases from reactor head area	2.6
K4.09	Equalization of pressure across the MSIVs before opening	3.2
K4.10	Moisture removal from steam lines before admitting steam	3.0
K4.11	Positive sealing of the MSIVs when shutdown	2.9
K4.12	MSIV testing	3.0

System: 239001 SF4 MRSS Main and Reheat Steam System

K4.13 Backup pneumatic source for MSIV closure 3.1

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Main and Reheat Steam System:
(CFR: 41.5 / 45.3)**

K5.01 DELETED
K5.02 DELETED
K5.03 DELETED
K5.04 Steam blanketing of the moisture separator reheater 2.0
K5.05 DELETED
K5.06 Inadvertent MSIV operation 3.5
K5.07 DELETED
K5.08 DELETED
K5.09 Decay heat removal 3.5
K5.10 Steam bypass capability 3.8
K5.11 Noncondensable gases in the reactor head area 2.5
K5.12 MSR heatup limitations 2.9

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Main and Reheat Steam System:
(CFR: 41.7 / 45.7)**

K6.01 Electrical power 3.3
K6.02 Plant pneumatic systems 3.4
K6.03 Safety relief valves 3.9
K6.04 DELETED
K6.05 Steam line leak 4.0
K6.06 MSIV isolation signal 4.3
K6.07 MSIV leakage control 2.9
K6.08 Main condenser vacuum 3.5
K6.09 PCIS/NSSSS 3.9
K6.10 DELETED
K6.11 Moisture separator/reheaters 2.9
K6.12 Main turbine trip 3.6
K6.13 Reactor/turbine pressure regulating system 3.8

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Main and Reheat Steam System, including:
(CFR: 41.5 / 45.5)**

A1.01 Main steam pressure 3.8

System: 239001 SF4 MRSS Main and Reheat Steam System

A1.02	Main steam temperature	2.6
A1.03	Reheat steam pressure	2.7
A1.04	Reheater temperature	2.4
A1.05	Main steam line radiation	3.3
A1.06	Offgas process radiation	3.3
A1.07	Reactor water level	4.0
A1.08	Reactor pressure	4.2
A1.09	Main steam flow	3.7
A1.10	Reactor power	4.1
A1.11	Lights and alarms	3.3

A2 Ability to (a) predict the impacts of the following on the Main and Reheat Steam System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Malfunction of reactor turbine pressure regulating system	4.3	4.0
A2.02	Steam demand malfunction and its effect on reactor pressure and power	4.2	4.0
A2.03	MSIV closure	4.3	3.9
A2.04	Main steam line low pressure	4.2	3.7
A2.05	Main steam line high radiation	3.6	3.6
A2.06	Turbine trip without bypass valves	4.4	4.0
A2.07	Main steam area high temperature	3.9	3.8
A2.08	Low condenser vacuum	4.0	3.6
A2.09	DELETED		
A2.10	Closure of one or more MSIVs at power	4.2	3.7
A2.11	Steam line break	4.3	4.1
A2.12	PCIS/NSSSS actuation	3.9	4.2
A2.13	High reactor water level	4.1	3.6
A2.14	DELETED		

A3 Ability to monitor automatic operation of the Main and Reheat Steam System, including:

(CFR: 41.7 / 45.7)

A3.01	Isolation of main steam system	4.2
A3.02	Opening and closing of drain valves as turbine load changes	2.6
A3.03	Moisture separator reheat steam supply	2.8
A3.04	Isolation of moisture separator reheater	3.0
A3.05	MSR drain tank level control	2.9

System: 239001 SF4 MRSS Main and Reheat Steam System

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

A4.01	MSIVs	4.4
A4.02	Main steam line drain valves	3.4
A4.03	DELETED	
A4.04	DELETED	
A4.05	DELETED	
A4.06	DELETED	
A4.07	DELETED	
A4.08	DELETED	
A4.09	DELETED	
A4.10	DELETED	
A4.11	DELETED	
A4.12	MSR steam admission valves	2.8

System: 245000 SF4 MTGEN Main Turbine Generator and Auxiliary Systems

K/A NO. KNOWLEDGE IMPORTANCE

K1 Knowledge of the physical connections and/or cause and effect relationships between the Main Turbine Generator and Auxiliary Systems and the following systems:
(CFR: 41.2 to 41.9 / 45.7 to 45.8)

K1.01	AC electrical distribution	3.6
K1.02	Condensate system	2.9
K1.03	Main and reheat steam system	3.1
K1.04	Reactor protection system	3.8
K1.05	DELETED	
K1.06	Component cooling water systems	3.0
K1.07	Instrument air systems	2.6
K1.08	Reactor/turbine pressure regulating system	3.7
K1.09	DELETED	
K1.10	Feedwater system	2.9
K1.11	Hydrogen seal oil system	3.3
K1.12	Stator water cooling system	3.4
K1.13	Bus duct cooling system	3.2
K1.14	EHC system	3.6
K1.15	Core monitor system	2.5
K1.16	Lube oil system	3.1

K2 Knowledge of electrical power supplies to the following:
(CFR: 41.7)

K2.01	Stator water cooling pumps	2.9
K2.02	Lube oil pumps	2.9
K2.03	Amplidyne/exciter	2.6
K2.04	Hydrogen seal oil pumps	2.9
K2.05	DELETED	
K2.06	DELETED	

K3 Knowledge of the effect that a loss or malfunction of the Main Turbine Generator and Auxiliary Systems will have on the following systems or system parameters:
(CFR: 41.7 / 45.4)

K3.01	AC electrical distribution	3.7
K3.02	Reactor pressure	4.0
K3.03	Reactor power	4.0
K3.04	Feedwater system	3.2

System: 245000 SF4 MTGEN Main Turbine Generator and Auxiliary Systems

K3.05	DELETED	
K3.06	DELETED	
K3.07	Reactor protection system	3.9
K3.08	Reactor/turbine pressure regulating system	3.7
K3.09	RCIS	3.1
K3.10	Rod worth minimizer	2.3

**K4 Knowledge of Main Turbine Generator and Auxiliary Systems design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Bearing lubrication	2.9
K4.02	Generator cooling	3.1
K4.03	Limit hydrogen leakage	2.9
K4.04	DELETED	
K4.05	Turbine protection	3.5
K4.06	Generator protection	3.5
K4.07	Generator voltage regulation	3.1
K4.08	Moisture removal from turbine steam	2.7
K4.09	Turbine control	3.5
K4.10	DELETED	
K4.11	Limit steam leakage	2.8

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Main Turbine Generator and Auxiliary Systems:
(CFR: 41.5 / 45.3)**

K5.01	DELETED	
K5.02	Turbine operation and limitations	3.5
K5.03	Hydraulically operated valve operation	2.9
K5.04	Turbine speed control	3.2
K5.05	DELETED	
K5.06	Turbine shaft sealing	2.8
K5.07	Generator operations and limitations (reference potential)	3.1
K5.08	Generator cooling	3.1

System: 245000 SF4 MTGEN Main Turbine Generator and Auxiliary Systems

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Main Turbine Generator and Auxiliary Systems:
(CFR: 41.7 / 45.7)**

K6.01	Gland seal	3.1
K6.02	Reactor/turbine pressure regulating system	3.8
K6.03	Hydrogen seal oil	3.1
K6.04	Hydrogen cooling	3.1
K6.05	Stator water cooling	3.1
K6.06	Electrical distribution	3.3
K6.07	DELETED	
K6.08	Main and reheat steam	3.1
K6.09	Voltage regulator	3.2
K6.10	Lube oil system	3.1
K6.11	Reactor SCRAM	3.8

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Main Turbine Generator and Auxiliary Systems, including:
(CFR: 41.5 / 45.5)**

A1.01	Generator megawatts	3.5
A1.02	Turbine speed	3.1
A1.03	Turbine valve position	3.2
A1.04	Steam flow	3.3
A1.05	Reactor pressure	3.8
A1.06	Condenser vacuum	3.5
A1.07	First stage turbine pressure	3.3
A1.08	DELETED	
A1.09	Lights and alarms	3.2
A1.10	Hydrogen gas temperature	2.7
A1.11	Turbine lube oil pressure	2.9
A1.12	Hydrogen seal oil pressure	2.9

**A2 Ability to (a) predict the impacts of the following on the Main Turbine Generator and Auxiliary Systems and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	Turbine trip	4.2	3.9
A2.02	Loss of lube oil	3.8	3.5

System: 245000 SF4 MTGEN Main Turbine Generator and Auxiliary Systems

A2.03	Degraded/ loss of condenser vacuum	4.1	3.7
A2.04	Reactor SCRAM	4.4	3.9
A2.05	Generator trip	4.3	3.9
A2.06	DELETED		
A2.07	Loss of reactor/turbine regulating control system	4.1	4.0
A2.08	DELETED		
A2.09	Turbine vibration	3.7	3.5

A3 Ability to monitor automatic operation of the Main Turbine Generator and Auxiliary Systems, including:
(CFR: 41.7 / 45.7)

A3.01	Turbine trip		3.9
A3.02	Turbine roll to rated speed		3.1
A3.03	DELETED		
A3.04	DELETED		
A3.05	Control valve operation		3.2
A3.06	DELETED		
A3.07	DELETED		
A3.08	Hydrogen gas pressure control		2.9
A3.09	DELETED		
A3.10	Voltage regulator		3.1
A3.11	DELETED		
A3.12	Automatic turbine control		3.3

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Turbine lube oil pumps		2.9
A4.02	Generator controls		3.5
A4.03	Stator water cooling pumps		3.2
A4.04	Hydrogen seal oil pumps		3.2
A4.05	DELETED		
A4.06	Turbine speed		3.2
A4.07	Turbine valve position		3.3
A4.08	DELETED		
A4.09	DELETED		
A4.10	Hydrogen gas pressure control		2.9
A4.11	DELETED		
A4.12	Voltage regulator		3.3
A4.13	DELETED		
A4.14	DELETED		

System: 217000 SF4 RCIC Reactor Core Isolation Cooling System

K/A NO.	KNOWLEDGE	IMPORTANCE
----------------	------------------	-------------------

K1	Knowledge of the physical connections and/or cause and effect relationships between the Reactor Core Isolation Cooling System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
-----------	---	--

K1.01	Condensate system	3.1
K1.02	Nuclear boiler Instrumentation	3.7
K1.03	Suppression pool	3.8
K1.04	DELETED	
K1.05	Residual heat removal system	2.8
K1.06	Instrument air system	2.5
K1.07	Leak detection	3.3
K1.08	DELETED	
K1.09	Reactor vessel and internals	3.3
K1.10	Main steam system	3.6
K1.11	Radwaste system	1.8
K1.12	Remote shutdown system	3.5
K1.13	Component cooling water	2.8
K1.14	Primary containment isolation system	3.9
K1.15	Feedwater system	3.2

K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
-----------	--	--

K2.01	Motor-operated valves	3.3
K2.02	Initiation/isolation logic	3.7
K2.03	RCIC flow controller	3.5
K2.04	Gland seal compressor (vacuum pump)	2.6
K2.05	Water leg pump	2.6

K3	Knowledge of the effect that a loss or malfunction of the Reactor Core Isolation Cooling System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
-----------	---	--

K3.01	Reactor water level	4.2
K3.02	Reactor vessel pressure	3.9
K3.03	DELETED	
K3.04	DELETED	
K3.05	Suppression pool level	3.3
K3.06	Condensate storage tank level	3.2
K3.07	Secondary containment parameters	3.4

System: 217000 SF4 RCIC Reactor Core Isolation Cooling System

**K4 Knowledge of Reactor Core Isolation Cooling System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Prevent water hammer	3.4
K4.02	Prevent overfilling reactor vessel	3.8
K4.03	Prevents pump overheating	3.2
K4.04	Turbine trips	3.9
K4.05	DELETED	
K4.06	Manual system initiation	4.0
K4.07	Automatic transfer of RCIC pump suction	3.6
K4.08	Automatic system initiation	4.1
K4.09	Initiation reset	3.7
K4.10	System isolation	4.1
K4.11	Resetting system isolations	3.8
K4.12	Automatic flow control	3.7
K4.13	Turbine speed control	3.6
K4.14	Control oil to turbine speed controls	3.3
K4.15	Testable check valve operation	2.2
K4.16	Turbine shaft sealing	2.4
K4.17	Bypass trips and isolation logic	3.7
K4.18	Remote operation	3.7

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Reactor Core Isolation Cooling System:
(CFR: 41.5 / 45.3)**

K5.01	DELETED	
K5.02	Flow control	3.8
K5.03	DELETED	
K5.04	DELETED	
K5.05	DELETED	
K5.06	Turbine operation	3.5
K5.07	Reactor pressure control	3.7
K5.08	Decay heat removal	3.8
K5.09	Adequate core cooling	4.2
K5.10	Reactor level control	4.2

System: 217000 SF4 RCIC Reactor Core Isolation Cooling System

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Reactor Core Isolation Cooling System:

(CFR: 41.7 / 45.7)

K6.01	Electrical power	3.8
K6.02	Instrument air systems	2.6
K6.03	Suppression pool level	3.5
K6.04	Condensate storage tank low level	3.5
K6.05	Low reactor pressure	3.7
K6.06	Keep fill system	3.1
K6.07	Nuclear boiler instrumentation	3.6
K6.08	Reactor water level	4.1
K6.09	High suppression pool temperature	3.5
K6.10	High turbine exhaust pressure	3.7
K6.11	High steam flow	3.9
K6.12	High area temperature	4.0
K6.13	Low pump suction pressure	3.7
K6.14	Turbine control failure	3.7
K6.15	Lube oil pump	3.3
K6.16	Minimum flow valve	3.3
K6.17	Flow controller failure	3.9

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Reactor Core Isolation Cooling System, including:

(CFR: 41.5 / 45.5)

A1.01	RCIC flow	4.1
A1.02	RCIC pressure	3.9
A1.03	Reactor water level	4.3
A1.04	Reactor pressure	4.1
A1.05	RCIC turbine speed	3.7
A1.06	Condensate storage tank level	3.2
A1.07	Suppression pool level	3.4
A1.08	Suppression pool temperature	3.5
A1.09	Lights and alarms	3.6

System: 217000 SF4 RCIC Reactor Core Isolation Cooling System

A2 Ability to (a) predict the impacts of the following on the Reactor Core Isolation Cooling System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Inadvertent system initiation	4.3	4.2
A2.02	Turbine trips	4.2	4.0
A2.03	Valve closures due to malfunction(s)	3.8	3.7
A2.04	AC power loss	3.5	3.4
A2.05	DC power loss	4.1	3.9
A2.06	Loss of instrument air systems	2.9	2.5
A2.07	Loss of lube oil	3.6	3.3
A2.08	Loss of lube oil cooling	3.6	3.2
A2.09	Loss of vacuum pump	3.0	2.7
A2.10	Turbine control system failures	3.6	3.7
A2.11	Inadequate system flow	4.0	3.7
A2.12	Valve openings due to malfunction(s)	3.3	3.6
A2.13	Loss of room cooling	3.2	3.1
A2.14	Rupture disc failure: exhaust-diaphragm	3.9	3.6
A2.15	Steam line break	4.0	4.0
A2.16	Low condensate storage tank level	3.5	3.3
A2.17	Abnormal suppression pool level	3.7	3.4
A2.18	DELETED		
A2.19	High suppression pool temperature	3.7	3.5

A3 Ability to monitor automatic operation of the Reactor Core Isolation Cooling System, including:
(CFR: 41.7 / 45.7)

A3.01	Valve operation		3.9
A3.02	Turbine startup		4.0
A3.03	DELETED		
A3.04	DELETED		
A3.05	DELETED		
A3.06	DELETED		
A3.07	Trips and isolations		4.2
A3.08	Automatic flow control		4.0

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	DELETED		
A4.02	Turbine trip throttle valve reset		4.0

System: 217000 SF4 RCIC Reactor Core Isolation Cooling System

A4.03	System valves	3.8
A4.04	DELETED	
A4.05	DELETED	
A4.06	DELETED	
A4.07	DELETED	
A4.08	DELETED	
A4.09	DELETED	
A4.10	DELETED	
A4.11	DELETED	
A4.12	Turbine speed control	3.9
A4.13	Manual initiation	4.1
A4.14	Resetting isolations	3.9

System: 202001 SF4 RS Recirculation System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Recirculation System and the following systems: (CFR: 41.2 to 41.8 / 45.7 to 45.8)	
K1.01	DELETED	
K1.02	DELETED	
K1.03	DELETED	
K1.04	Reactor/turbine pressure regulating system	3.4
K1.05	DELETED	
K1.06	DELETED	
K1.07	CCW system	3.2
K1.08	DELETED	
K1.09	DELETED	
K1.10	Control rod drive system	3.0
K1.11	Drywell equipment/floor drain sump system	2.8
K1.12	DELETED	
K1.13	DELETED	
K1.14	Rod block monitor system	3.0
K1.15	Nuclear boiler instrumentation	3.3
K1.16	Residual heat removal/low-pressure coolant injection	3.5
K1.17	DELETED	
K1.18	Shutdown cooling system (RHR shutdown cooling mode)	3.5
K1.19	Reactor feedwater system	3.1
K1.20	Instrument air system	2.6
K1.21	Reactor water cleanup system	2.8
K1.22	DELETED	
K1.23	APRM/LPRM	3.5
K1.24	Isolation condenser	3.1
K1.25	Reactor water sampling system	2.6
K1.26	Recirculation flow control system	3.9
K1.27	Reactor protection system	3.7
K1.28	DELETED	
K1.29	Redundant reactivity control system (BWR 4, 5, 6)	3.8
K1.30	Reactor vessel internals	3.3
K1.31	Primary containment isolation system	3.3
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Recirculation pumps	3.5

System: 202001 SF4 RS Recirculation System

K2.02	MG sets	3.5
K2.03	Recirculation system valves	3.3
K2.04	DELETED	
K2.05	DELETED	
K2.06	VFDs	3.8
K2.07	VFD cooling water pumps	3.4

**K3 Knowledge of the effect that a loss or malfunction of the Recirculation System will have on the following systems or system parameters:
(CFR: 41.5 to 41.7 / 45.4)**

K3.01	Core flow	4.2
K3.02	DELETED	
K3.03	Reactor power	4.4
K3.04	Reactor water level	4.0
K3.05	DELETED	
K3.06	Residual heat removal/low-pressure coolant injection logic	3.3
K3.07	Vessel bottom head drain temperature	3.2
K3.08	Shutdown cooling system (RHR shutdown cooling mode)	3.5
K3.09	Reactor water cleanup system	2.9
K3.10	APRM/LPRM	3.5
K3.11	CCW system	2.6
K3.12	Isolation condenser	3.1
K3.13	Reactor water sampling system	2.5
K3.14	Primary containment integrity	2.9
K3.15	Reactor moderator temperature	3.3
K3.16	Reactor pressure	3.5
K3.17	Drywell equipment/floor drain sump system	2.7

**K4 Knowledge of Recirculation System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	2/3 core coverage	4.3
K4.02	Adequate recirculation pump NPSH	3.8
K4.03	Recirculation pump motor cooling	3.3
K4.04	Controlled seal flow	3.3
K4.05	Seal cooling	3.3
K4.06	Automatic voltage/frequency regulation	3.0
K4.07	Motor generator set trips	3.3
K4.08	Oil pump automatic starts	2.8

System: 202001 SF4 RS Recirculation System

K4.09	Pump minimum flow limit	3.2
K4.10	Pump start permissives	3.4
K4.11	Limitation of recirculation pumps flow mismatch	3.8
K4.12	Minimization of reactor vessel bottom head temperature gradients	3.6
K4.13	End-of-cycle recirculation pump trip	3.6
K4.14	ATWS/RPT	4.0
K4.15	Slow-speed pump start	3.2
K4.16	Recirculation pump downshift/runback	3.8
K4.17	Fast-speed pump start	3.3
K4.18	Automatic MG set start sequencing	3.3
K4.19	VFD trips	3.7
K4.20	VFD start sequencing	3.4

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Recirculation System:
(CFR: 41.5 / 45.3)**

K5.01	Indications of pump cavitation	3.5
K5.02	Jet pump operation (BWR 3, 4, 5, 6)	3.7
K5.03	Pump/motor cooling	3.3
K5.04	DELETED	
K5.05	End-of-cycle recirculation pump trip	3.5
K5.06	ATWS RPT	3.8
K5.07	Natural circulation	3.6
K5.08	DELETED	
K5.09	Hydraulically operated valves	2.8
K5.10	Motor generator set operation	3.0
K5.11	Core flow	3.8
K5.12	Reactor power	4.1
K5.13	Reactor moderator temperature	3.4
K5.14	Reactor water level	3.8
K5.15	VFD operation	3.7

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Recirculation System:
(CFR: 41.7 / 45.7)**

K6.01	Jet pumps	4.0
K6.02	Component cooling water systems	3.3
K6.03	AC electrical distribution system	3.5
K6.04	DC electrical distribution system	3.1

System: 202001 SF4 RS Recirculation System

K6.05	Control rod drive system	2.9
K6.06	Recirculation system motor-generator sets	3.2
K6.07	Feedwater flow	3.1
K6.08	Reactor water cleanup system	2.8
K6.09	Reactor water level	3.7
K6.10	Recirculation flow control system	3.8
K6.11	Reactor protection system	3.4
K6.12	APRMs	3.2
K6.13	Redundant reactivity control system	3.4
K6.14	Variable frequency drives	3.7

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Recirculation System, including:
(CFR: 41.5 / 45.5)**

A1.01	Recirculation pump flow	3.1
A1.02	Jet pump flow	3.9
A1.03	Core flow	4.1
A1.04	Reactor water level	3.9
A1.05	Reactor power	4.4
A1.06	Recirculation pump motor amps	3.0
A1.07	Recirculation pump speed	3.2
A1.08	Recirculation FCV position (BWR 5, 6)	3.8
A1.09	Recirculation pump seal pressures	3.5
A1.10	Recirculation seal purge flows	2.9
A1.11	Vessel bottom head drain temperature	3.2
A1.12	Recirculation pump differential pressure	2.9
A1.13	Recirculation loop temperatures	3.4
A1.14	Recirculation drive motor temperature	3.0
A1.15	Recirculation MG set temperatures	2.8
A1.16	Recirculation MG drive motor amps	2.6
A1.17	Recirculation MG set generator current, power, and voltage	2.6
A1.18	Lights and alarms	3.4
A1.19	VFD temperature	3.3
A1.20	VFD cooling water temperature	3.3
A1.21	VFD current, power, and voltage	3.1

System: 202001 SF4 RS Recirculation System

A2 Ability to (a) predict the impacts of the following on the Recirculation System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Jet pump failure	3.9	4.1
A2.02	Recirculation system leak	4.1	4.0
A2.03	Single recirculation pump trip	4.1	4.2
A2.04	Multiple recirculation pump trip	4.5	4.3
A2.05	Inadvertent recirculation flow increase (reference potential)	4.3	4.2
A2.06	Inadvertent recirculation flow decrease	3.8	4.0
A2.07	Recirculation pump speed mismatch	3.5	3.2
A2.08	Recirculation flow mismatch	3.8	3.7
A2.09	DELETED		
A2.10	Recirculation pump seal failure (reference potential)	3.9	3.9
A2.11	Low reactor water level	4.0	3.8
A2.12	Loss of reactor feedwater	3.9	3.6
A2.13	Carryunder	3.4	2.7
A2.14	High reactor pressure (ATWS circuitry initiation)	3.9	3.8
A2.15	End-of-cycle trip circuitry	3.8	3.6
A2.16	Loss of seal purge flow (CRD)	3.4	3.1
A2.17	Loss of seal cooling water	3.8	3.3
A2.18	Loss of motor cooling	3.6	3.1
A2.19	Loss of AC power	3.9	3.4
A2.20	Loss of DC power	3.3	3.1
A2.21	Recirculation loop temperature out of specification	3.8	3.2
A2.22	Loss of component cooling water	3.8	3.2
A2.23	Valve closures due to malfunction(s)	3.6	3.3
A2.24	Valve opening due to malfunction(s)	3.4	3.3
A2.25	Recirculation flow control valve lockup	3.8	3.6
A2.26	Incomplete start sequence	3.0	2.9
A2.27	Failure of RPS end-of-cycle recirculation pump trip circuitry (BWR 5, 6)	3.3	3.5
A2.28	Failure of redundant reactivity control system (BWR 4, 5, 6)	3.5	3.6
A2.29	VFD cell bypass	3.5	3.6
A2.30	VFD cooling system failure	3.5	3.4

System: 202001 SF4 RS Recirculation System

A3 Ability to monitor automatic operation of the Recirculation System, including:
(CFR: 41.7 / 45.7)

A3.01	Valve operation	3.6
A3.02	Pump/MG set start sequence	3.4
A3.03	DELETED	
A3.04	DELETED	
A3.05	DELETED	
A3.06	Flow control valve position (BWR 5, 6)	3.9
A3.07	Pump trips	4.0
A3.08	Pump downshift (BWR 5, 6)	3.8
A3.09	MG set trip	3.5
A3.10	VFD start sequence	3.4
A3.11	VFD trip	3.9

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Recirculation pumps	4.0
A4.02	System valves	3.8
A4.03	Reactor power	4.4
A4.04	System flow	4.1
A4.05	DELETED	
A4.06	Oil pumps	3.0
A4.07	Vent fans	2.8
A4.08	Motor-generator sets	3.1
A4.09	DELETED	
A4.10	Seal flow	3.1
A4.11	Seal pressures	3.6
A4.12	Core flow	4.1
A4.13	Core differential pressure	3.8
A4.14	Variable frequency drives	3.9
A4.15	VFD cooling water pumps	3.4

System: 203000 SF4 RHR/LPCI: Injection Mode

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the RHR/LPCI: Injection Mode and the following systems: (CFR: 41.2 to 41.9 / 43.5 / 45.7 to 45.8)	
K1.01	Condensate system	2.3
K1.02	Primary containment	3.5
K1.03	DELETED	
K1.04	DELETED	
K1.05	Recirculation system (BWR 3, 4)	3.7
K1.06	ADS	4.1
K1.07	DELETED	
K1.08	DELETED	
K1.09	Emergency generators	4.0
K1.10	Plant ventilation systems	2.5
K1.11	Nuclear boiler instrumentation	3.7
K1.12	Instrument air system	2.4
K1.13	DELETED	
K1.14	Shutdown cooling system	3.6
K1.15	Reactor building drain system	2.0
K1.16	Component cooling water systems	2.7
K1.17	DELETED	
K1.18	Reactor vessel	3.8
K1.19	Low-pressure core spray system	3.5
K1.20	Service water	3.1
K1.21	Remote shutdown system	3.4
K1.22	Spent fuel pool cooling	2.9
K1.23	Primary containment isolation system	3.6
K1.24	Leak detection system	3.0
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Pumps	4.1
K2.02	Valves	3.7
K2.03	Initiation logic	3.7

System: 203000 SF4 RHR/LPCI: Injection Mode

K3 Knowledge of the effect that a loss or malfunction of the RHR/LPCI: Injection Mode will have on the following systems or system parameters:
(CFR: 41.7 / 45.4)

K3.01	Reactor water level	4.2
K3.02	Suppression pool level	3.4
K3.03	Automatic depressurization logic	4.0
K3.04	Adequate core cooling	4.3
K3.05	Drywell pressure	3.3
K3.06	Reactor pressure	3.5
K3.07	Primary containment	3.5

K4 Knowledge of RHR/LPCI: Injection Mode design features and/or interlocks that provide for the following:
(CFR: 41.7)

K4.01	Automatic system initiation/injection	4.4
K4.02	DELETED	
K4.03	Pump minimum flow protection	3.2
K4.04	Pump seal cooler	2.7
K4.05	Prevention of water hammer (keep fill)	3.4
K4.06	No-suction path pump trip	3.5
K4.07	Emergency generator load sequencing	3.8
K4.08	Pump operability testing	3.0
K4.09	Surveillance for all operable components	2.9
K4.10	Dedicated injection system during automatic system initiation (injection valve interlocks)	3.7
K4.11	Loop selection logic	3.4
K4.12	System redundancy	3.5
K4.13	Prevention of leakage to the environment through LPCI/RHR heat exchanger	3.0
K4.14	Operation from remote shutdown panel	3.6
K4.15	Pump runout protection	3.0
K4.16	Manual system initiation	4.1
K4.17	Testable check valve operation	2.6

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the RHR/LPCI: Injection Mode:
(CFR: 41.5 / 45.3)

K5.01	DELETED	
K5.02	Core cooling methods	4.2

System: 203000 SF4 RHR/LPCI: Injection Mode

K5.03	Vortex limits	3.3
K5.04	NPSH limits	3.4

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the RHR/LPCI: Injection Mode:
(CFR: 41.7 / 45.7)**

K6.01	AC electrical power	3.9
K6.02	DC electrical power	3.8
K6.03	Emergency generator	4.0
K6.04	Keep fill	3.2
K6.05	Condensate system	2.3
K6.06	Suppression pool water level	3.4
K6.07	Plant air systems	2.4
K6.08	ECCS room cooling	3.1
K6.09	Nuclear boiler instrumentation	3.5
K6.10	Component cooling water systems	2.8
K6.11	ADS	4.1
K6.12	ECCS room integrity	3.0
K6.13	High suppression pool temperature	3.5
K6.14	High drywell pressure	3.7
K6.15	Low reactor water level	4.0
K6.16	Service water system	3.0
K6.17	Suppression pool suction strainer clogging	3.4

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the RHR/LPCI: Injection Mode, including:
(CFR: 41.5 / 45.5)**

A1.01	Reactor water level	4.4
A1.02	Reactor pressure	4.0
A1.03	System flow	4.0
A1.04	System pressure	3.8
A1.05	Suppression pool level	3.6
A1.06	Condensate storage tank level	2.5
A1.07	Motor amps	2.7
A1.08	Emergency generator loading	3.7
A1.09	Component cooling water systems	2.8
A1.10	Lights and alarms	3.5
A1.11	Suppression pool temperature	3.5

System: 203000 SF4 RHR/LPCI: Injection Mode

A2 Ability to (a) predict the impacts of the following on the RHR/LPCI: Injection Mode and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Inadequate net positive suction head	3.9	3.6
A2.02	Pump trips	4.0	3.9
A2.03	Valve closures due to malfunction(s)	3.7	3.8
A2.04	AC failures	3.9	3.8
A2.05	DC failures	3.6	3.7
A2.06	Emergency generator failure	3.9	3.9
A2.07	Pump seal failure	3.1	2.9
A2.08	Inadequate room cooling	2.9	3.0
A2.09	Inadequate system flow	3.6	3.5
A2.10	Nuclear boiler instrument failure	3.4	3.5
A2.11	Motor-operated valve failures	3.7	3.6
A2.12	Pump runout	3.7	3.1
A2.13	Valve openings due to malfunction(s)	3.6	3.3
A2.14	Initiation logic failure	3.9	4.0
A2.15	Loop selection logic failure	4.3	3.9
A2.16	Loss of coolant accident	4.4	4.4
A2.17	Keep fill system failure	3.6	3.1
A2.18	High suppression pool temperature	3.6	3.4
A2.19	Low suppression pool level	3.7	3.5
A2.20	Surveillance acceptance criteria not being met	3.0	3.3

A3 Ability to monitor automatic operation of the RHR/LPCI: Injection Mode, including:
(CFR: 41.7 / 45.7)

A3.01	Valve operation		4.0
A3.02	Pump start		4.1
A3.03	DELETED		
A3.04	DELETED		
A3.05	DELETED		
A3.06	DELETED		
A3.07	Loop selection		4.1
A3.08	System initiation sequence		4.0
A3.09	DELETED		

System: 203000 SF4 RHR/LPCI: Injection Mode

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Pumps	4.2
A4.02	System valves	4.2
A4.03	Keep fill system	3.1
A4.04	DELETED	
A4.05	Manual initiation controls	4.3
A4.06	System reset following automatic initiation	3.6
A4.07	DELETED	
A4.08	DELETED	
A4.09	DELETED	
A4.10	DELETED	
A4.11	DELETED	
A4.12	DELETED	
A4.13	DELETED	
A4.14	Testable check valves	2.6
A4.15	Room coolers	2.9

System: 205000 SF4 SDC Shutdown Cooling System (RHR Shutdown Cooling Mode)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Shutdown Cooling System (RHR Shutdown Cooling Mode) and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	DELETED	
K1.02	DELETED	
K1.03	DELETED	
K1.04	Fuel pool cooling and cleanup system	3.2
K1.05	Component cooling water systems	3.1
K1.06	DELETED	
K1.07	DELETED	
K1.08	RHR/LPCI	3.7
K1.09	DELETED	
K1.10	RWCU	2.8
K1.11	Plant pneumatic systems	2.5
K1.12	Isolation condenser	2.3
K1.13	Radwaste system	2.3
K1.14	DELETED	
K1.15	Service water	3.2
K1.16	PCIS/NSSSS	3.7
K1.17	Recirculation system	3.5
K1.18	Feedwater system (BWR 6)	3.2
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Pump motors	3.6
K2.02	Motor-operated valves	3.3
K3	Knowledge of the effect that a loss or malfunction of the Shutdown Cooling System (RHR Shutdown Cooling Mode) will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor pressure	3.7
K3.02	Reactor water level	3.7
K3.03	Temperatures	4.2
K3.04	DELETED	
K3.05	Fuel pool cooling and cleanup	3.0

System: 205000 SF4 SDC Shutdown Cooling System (RHR Shutdown Cooling Mode)

K4 Knowledge of Shutdown Cooling System (RHR Shutdown Cooling Mode) design features and/or interlocks that provide for the following:
(CFR: 41.7)

K4.01	High temperature isolation /protection	3.6
K4.02	High pressure isolation	3.9
K4.03	Low reactor water level	3.9
K4.04	Adequate pump NPSH	3.3
K4.05	Cooldown rate	3.9
K4.06	DELETED	
K4.07	SDC minimum flow	3.5
K4.08	Prevent inadvertent vessel draining	4.1

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Shutdown Cooling System (RHR Shutdown Cooling Mode):
(CFR: 41.5 / 45.3)

K5.01	DELETED	
K5.02	Valve operation	3.5
K5.03	Decay heat removal	3.9
K5.04	System venting	2.9

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Shutdown Cooling System (RHR Shutdown Cooling Mode):
(CFR: 41.7 / 45.7)

K6.01	AC electrical distribution	3.7
K6.02	DC electrical distribution	3.5
K6.03	Recirculation system	3.4
K6.04	Abnormal reactor water level	3.7
K6.05	Component cooling water systems	3.2
K6.06	DELETED	
K6.07	Plant pneumatic systems	2.5
K6.08	Service water	3.3
K6.09	Reactor water cleanup	2.8
K6.10	Fuel pool cooling and cleanup	3.0

System: 205000 SF4 SDC Shutdown Cooling System (RHR Shutdown Cooling Mode)

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Shutdown Cooling System (RHR Shutdown Cooling Mode), including:
(CFR: 41.5 / 45.5)

A1.01	Heat exchanger cooling flow	3.6
A1.02	SDC/RHR pump flow	3.7
A1.03	DELETED	
A1.04	SDC/RHR pump suction pressure	3.0
A1.05	Reactor water level	3.9
A1.06	Temperatures	3.9
A1.07	DELETED	
A1.08	Heat exchanger temperatures	3.6
A1.09	SDC/RHR pump/system discharge pressure	3.3
A1.10	Throttle valve position	3.2
A1.11	Lights and alarms	3.4

A2 Ability to (a) predict the impacts of the following on the Shutdown Cooling System (RHR Shutdown Cooling Mode) and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6)

		RO	SRO
A2.01	Recirculation loop high temperature	3.6	3.3
A2.02	Low shutdown cooling suction pressure	3.5	3.4
A2.03	Loss of AC power	3.9	3.8
A2.04	Loss of DC power	3.6	3.6
A2.05	System isolation	4.0	4.0
A2.06	Pump trips	4.0	3.8
A2.07	DELETED		
A2.08	Loss of heat exchanger cooling	4.0	3.8
A2.09	Reactor low water level	4.1	3.9
A2.10	Abnormal valve position	3.6	3.4
A2.11	DELETED		
A2.12	Inadequate system flow	3.6	3.6

A3 Ability to monitor automatic operation of the Shutdown Cooling System (RHR Shutdown Cooling Mode), including:
(CFR: 41.7 / 45.7)

A3.01	Valve operation	3.7
A3.02	Pump operation	3.7

System: 205000 SF4 SDC Shutdown Cooling System (RHR Shutdown Cooling Mode)

A3.03 DELETED

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	SDC/RHR pumps	3.9
A4.02	SDC/RHR valves	3.9
A4.03	DELETED	
A4.04	DELETED	
A4.05	DELETED	
A4.06	Reactor water level	4.0
A4.07	DELETED	
A4.08	DELETED	
A4.09	DELETED	
A4.10	DELETED	
A4.11	Heat exchanger cooling flow	3.6
A4.12	Recirculation loop temperatures	3.7

System: 290002 SF4 RVI Reactor Vessel and Internals

K/A NO.	KNOWLEDGE	IMPORTANCE
----------------	------------------	-------------------

K1	Knowledge of the physical connections and/or cause and effect relationships between the Reactor Vessel and Internals and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
-----------	---	--

K1.01	Main steam system	3.8
K1.02	Recirculation system	4.1
K1.03	Reactor feedwater system	3.8
K1.04	High-pressure coolant injection system (BWR 3, 4)	3.6
K1.05	Residual heat removal system	3.9
K1.06	High-pressure core spray system (BWR 5, 6)	4.0
K1.07	Isolation condenser system (BWR 2, 3)	4.0
K1.08	Reactor core isolation cooling system (BWR 4, 5, 6)	3.8
K1.09	Low-pressure coolant injection system	3.9
K1.10	Control rod drive hydraulic system	3.8
K1.11	Control rod drive mechanism system	3.7
K1.12	Standby liquid control system	3.9
K1.13	Safety relief valve system	3.9
K1.14	Reactor water cleanup system	3.5
K1.15	Nuclear boiler instrumentation system	4.0
K1.16	Low-pressure core spray system	3.9
K1.17	Automatic depressurization system	3.9
K1.18	DELETED	
K1.19	Traversing in-core probe system	3.0
K1.20	DELETED	
K1.21	Leak detection system	3.4
K1.22	Average power range monitor/local power range monitor system	3.5
K1.23	Intermediate range monitor system	3.5
K1.24	Source range monitor system	3.5

K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
-----------	---	--

None

K3	Knowledge of the effect that a loss or malfunction of the Reactor Vessel and Internals will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
-----------	---	--

K3.01	Reactor water level	4.2
K3.02	Reactor pressure	4.0

System: 290002 SF4 RVI Reactor Vessel and Internals

K3.03	Reactor power	4.1
K3.04	DELETED	
K3.05	DELETED	
K3.06	DELETED	
K3.07	Nuclear boiler instrumentation	3.9
K3.08	Leak detection system	3.4
K3.09	Main steam system	3.6
K3.10	Recirculation system	4.0
K3.11	Reactor feedwater system	3.5
K3.12	High-pressure coolant injection system (BWR 3, 4)	3.4
K3.13	High-pressure core spray system (BWR 5, 6)	3.7
K3.14	Low-pressure coolant injection system	3.8
K3.15	Low-pressure core spray system	3.9
K3.16	Residual heat removal system	3.8
K3.17	Reactor core isolation cooling system (BWR 4, 5, 6)	3.6
K3.18	Control rod drive hydraulic system	3.5
K3.19	Control rod drive mechanism system	3.5
K3.20	SRV system	3.6
K3.21	Standby liquid control system	3.7
K3.22	Average power range monitor/local power range monitor system	3.3
K3.23	Intermediate range monitor system	3.3
K3.24	Source range monitor system	3.3

**K4 Knowledge of Reactor Vessel and Internals design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	2/3 core coverage following a design-basis LOCA (BWR 3, 4, 5, 6)	4.6
K4.02	Flow paths within the reactor vessel	3.9
K4.03	DELETED	
K4.04	Moisture removal from steam	3.3
K4.05	DELETED	
K4.06	Loose parts monitoring	2.3

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Reactor Vessel and Internals:
(CFR: 41.5 / 45.3)**

K5.01	Thermal limits	4.0
K5.02	DELETED	
K5.03	DELETED	

System: 290002 SF4 RVI Reactor Vessel and Internals

K5.04	DELETED	
K5.05	DELETED	
K5.06	DELETED	
K5.07	Safety limits	4.5
K5.08	Natural circulation	3.9
K5.09	Plant radiation levels	3.2
K5.10	Offsite radiation levels	3.2

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Reactor Vessel and Internals: (CFR: 41.7 / 45.7)

K6.01	DELETED	
K6.02	DELETED	
K6.03	Recirculation system	3.9
K6.04	Reactor feedwater system	3.5
K6.05	Standby liquid control system	3.5
K6.06	SRVs	3.9
K6.07	Reactor water cleanup system	3.3
K6.08	Nuclear boiler instrumentation	3.7
K6.09	Low-pressure core spray system	3.7
K6.10	High-pressure coolant injection system (BWR 3, 4)	3.5
K6.11	Residual heat removal system	3.7
K6.12	Isolation condenser system (BWR 2, 3)	3.6
K6.13	Reactor core isolation cooling system (BWR 4, 5, 6)	3.5
K6.14	Low-pressure coolant injection system	3.6
K6.15	Automatic depressurization system	3.8
K6.16	DELETED	
K6.17	DELETED	
K6.18	DELETED	
K6.19	High-pressure core spray system (BWR 5, 6)	3.7
K6.20	Main steam system	3.5

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Reactor Vessel and Internals, including: (CFR: 41.5 / 45.5)

None

System: 290002 SF4 RVI Reactor Vessel and Internals

A2 Ability to (a) predict the impacts of the following on the Reactor Vessel and Internals and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	LOCA	4.6	4.5
A2.02	DELETED		
A2.03	Control rod drop accident	4.4	3.8
A2.04	Excessive heatup/cool-down rate	4.4	4.1
A2.05	Exceeding thermal limits	4.4	4.1
A2.06	Exceeding safety limits	4.6	4.5

A3 Ability to monitor automatic operation of the Reactor Vessel and Internals, including:

(CFR: 41.7 / 45.7)

None

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

None

System: 510000 SF4 SWS Service Water System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Service Water System and the following systems: (CFR: 41.4 to 41.8 / 45.7 to 45.8)	
K1.01	Component cooling water system	3.7
K1.02	Main turbine generator and auxiliary systems	3.3
K1.03	Circulating water system	2.7
K1.04	Emergency generators (diesel/jet)	3.4
K1.05	High-pressure coolant injection system	3.0
K1.06	High-pressure core spray system	2.8
K1.07	Residual heat removal/low-pressure coolant injection	3.5
K1.08	Primary containment system and auxiliaries	3.0
K1.09	Fire protection system	2.9
K1.10	Radiation monitoring system	2.7
K1.11	Fuel pool cooling and cleanup system	3.3
K1.12	Radwaste system	2.4
K1.13	Feedwater system	2.7
K1.14	Condensate system	2.6
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Service water system pumps (Class 1E)	3.7
K2.02	Service water system valves (Class 1E)	3.4
K3	Knowledge of the effect that a loss or malfunction of the Service Water System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Component cooling water system	3.8
K3.02	Main turbine generator and auxiliary systems	3.4
K3.03	Circulating water system	2.5
K3.04	Emergency generators (diesel/jet)	3.6
K3.05	High-pressure coolant injection system	3.1
K3.06	High-pressure core spray system	2.8
K3.07	Residual heat removal/low-pressure coolant injection	3.7
K3.08	Primary containment system and auxiliaries	3.1
K3.09	Fire protection system	2.7
K3.10	Radiation monitoring system	2.5
K3.11	Fuel pool cooling and cleanup system	3.4
K3.12	Radwaste system	2.3

System: 510000 SF4 SWS Service Water System

K3.13	Feedwater system	2.7
K3.14	Condensate system	2.7
K3.15	Service water system pressure	3.7
K3.16	Service water system temperature	3.6
K3.17	Service water system flows	3.5

**K4 Knowledge of Service Water System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Automatic pump starts	3.6
K4.02	Automatic valve alignments	3.5
K4.03	Cooling tower makeup water	2.9
K4.04	Low/high temperature operation	3.3
K4.05	Alternate intake pathway	2.9
K4.06	Alternate discharge pathway	2.9
K4.07	Discharge strainer backwashing	2.8
K4.08	Alternate cooling water supply to FPCCU heat exchangers	3.1
K4.09	Trash and debris removal	3.0

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Service Water System:
(CFR: 41.4, 41.7 / 45.5)**

K5.01	Intake/traveling screen high differential pressure/ differential level	3.3
K5.02	Radiation alarm response	3.0
K5.03	Flood prevention	3.1
K5.04	Pipe rupture	3.3

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Service Water System:
(CFR: 41.7 / 45.7)**

K6.01	Pump trip	3.8
K6.02	Temperature control valve malfunction	3.5
K6.03	Entry/discharge path blockage	3.4
K6.04	Leakage to/from contaminated system	3.4
K6.05	Intake/traveling screen high differential pressure/ differential level	3.2
K6.06	Discharge strainers clogging	3.2
K6.07	Loss of AC electrical distribution	3.6
K6.08	Loss of coolant accident	3.7

System: 510000 SF4 SWS Service Water System

K6.09 Loss of ultimate heat sink 3.9

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Service Water System, including:
(CFR: 41.5 / 45.5)**

A1.01	Ultimate heat sink temperature	3.5
A1.02	Temperature control valve position	3.3
A1.03	Service water pressures	3.6
A1.04	Service water temperatures	3.5
A1.05	Service water flow	3.3
A1.06	CCW heat exchanger outlet temperature	3.4
A1.07	Lights and alarms	3.3
A1.08	Intake screen differential pressure/level	3.1
A1.09	Strainer differential pressure	3.0

**A2 Ability to (a) predict the impacts of the following on the Service Water System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 41.1 / 43.5 / 45.3 / 45.6 / 45.13)**

		RO	SRO
A2.01	Pump/motor failure	3.6	3.7
A2.02	Abnormal valve positions	3.6	3.5
A2.03	Intake/discharge blockage	3.6	3.5
A2.04	Pipe leakage/rupture	3.6	3.5
A2.05	Intake/traveling screen failure	3.4	3.2
A2.06	Discharge strainer failure	3.3	3.2
A2.07	Abnormal intake water temperature	3.3	3.6
A2.08	Abnormal intake water level	3.7	3.6

**A3 Ability to monitor automatic operation of the Service Water System, including:
(CFR: 41.7 / 45.5)**

A3.01	Pump starts	3.5
A3.02	Valve alignment	3.3
A3.03	Traveling screen operation	2.8
A3.04	Strainer operation	2.8

System: 510000 SF4 SWS Service Water System

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Pump operations	3.7
A4.02	Valve operations	3.6

3.5	Safety Function 5: Containment Integrity	Page
223001	Primary Containment System and Auxiliaries.....	3.5-3
223002	Primary Containment Isolation System /Nuclear Steam Supply Shutoff.....	3.5-9
219000	RHR/LPCI: Torus/Suppression Pool Cooling Mode.....	3.5-14
226001	RHR/LPCI: Containment Spray System Mode.....	3.5-18
230000	RHR/LPCI: Torus/Suppression Pool Spray Mode.....	3.5-23
290001	Secondary Containment.....	3.5-27

System: 223001 SF5 PCS Primary Containment System and Auxiliaries

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Primary Containment System and Auxiliaries and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	PCIS	4.3
K1.02	DELETED	
K1.03	Containment/drywell atmosphere control system	3.7
K1.04	Drywell floor and equipment floor drain system	3.4
K1.05	Suppression pool makeup system: Mark III	3.4
K1.06	RHR/LPCI	3.9
K1.07	Suppression pool cleanup system	2.9
K1.08	SRVs	3.8
K1.09	Standby gas treatment system or filtration, recirculation and ventilation system	3.8
K1.10	Plant pneumatic systems	3.1
K1.11	Post-accident sampling system	2.8
K1.12	LPCS	3.9
K1.13	HPCS	3.8
K1.14	RCIC	3.8
K1.15	HPCI	3.9
K1.16	Containment and drywell atmosphere monitoring system	3.5
K1.17	Plant ventilation	3.2
K1.18	Drywell differential pressure compressors	3.4
K1.19	Containment hardened venting	3.9
K1.20	Containment atmosphere dilution	3.5
K1.21	Penetration cooling system	2.8
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Atmosphere containment/ atmospheric dilution compressors	2.8
K2.02	Drywell compressors	3.1
K2.03	Pumpback compressors	2.9
K2.04	Combustible gas mixing compressors (Mark III)	3.2
K2.05	Hydrogen recombiners	2.9
K2.06	Hydrogen igniters	3.3
K2.07	Containment atmosphere monitoring system	3.1
K2.08	Containment cooling air handling units	3.0
K2.09	Containment/drywell cooling fans	3.2

System: 223001 SF5 PCS Primary Containment System and Auxiliaries

K2.10	Containment/drywell chillers	3.1
K2.11	Suppression pool cleanup pump	2.5
K2.12	Containment hardened vent isolation valves	3.5

K3 Knowledge of the effect that a loss or malfunction of the Primary Containment System and Auxiliaries will have on the following systems or system parameters:
(CFR: 41.7 / 45.4)

K3.01	Secondary containment	3.8
K3.02	Containment/drywell temperature	3.8
K3.03	Containment/drywell pressure	3.8
K3.04	Containment/drywell hydrogen gas concentration	3.5
K3.05	Containment/drywell oxygen gas concentration	3.4
K3.06	Differential pressure between secondary and primary containment	3.5
K3.07	Differential pressure between suppression pool and drywell/containment	3.6
K3.08	Pneumatically operated valves internal to containment/drywell	3.4
K3.09	Nuclear boiler instrumentation	3.6
K3.10	Containment/drywell moisture content	2.7
K3.11	LPCS	3.8
K3.12	HPCS	3.9
K3.13	RCIC	3.8
K3.14	HPCI	3.7
K3.15	Containment hardened vent	3.7
K3.16	Suppression pool level	3.7
K3.17	Suppression pool temperature	3.6

K4 Knowledge of Primary Containment System and Auxiliaries design features and/or interlocks that provide for the following:
(CFR: 41.7)

K4.01	Absorption of energy released during a LOCA	4.2
K4.02	Contains fission products after a LOCA	4.0
K4.03	Containment/drywell isolation	4.0
K4.04	Limiting hydrogen concentration	3.8
K4.05	Maintains proper suppression pool to drywell differential pressure	3.7
K4.06	Maintains proper containment/secondary containment to drywell differential pressure	3.7
K4.07	Prevents localized heating of suppression pool (SRV steam quenchers)	3.6

System: 223001 SF5 PCS Primary Containment System and Auxiliaries

K4.08	Overpressure protection—containment hardened vent	3.8
K4.09	Containment integrity	4.1
K4.10	Penetration cooling	2.7
K4.11	Maintain minimum suppression pool level (automatic suppression pool makeup) (Mark III)	3.7

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Primary Containment System and Auxiliaries:

(CFR: 41.5 / 45.3)

K5.01	Vacuum breaker/relief operation	3.8
K5.02	Guard pipe operation (Mark III)	2.8
K5.03	Downcomer operation	3.6
K5.04	Horizontal vent operation (Mark III)	3.4
K5.05	Hydrogen recombiner operation	3.4
K5.06	Hydrogen igniter operation	3.6
K5.07	Suppression pool cleanup	2.3
K5.08	Pressure	3.9
K5.09	Hydrogen production mechanisms	3.6
K5.10	Hydrogen combustibility versus hydrogen concentration and oxygen concentration	3.4
K5.11	Temperature	3.8
K5.12	Hydrogen concentration	3.8
K5.13	Oxygen concentration	3.6
K5.14	Differential pressure	3.7
K5.15	Moisture content	2.5
K5.16	Containment spray operation	4.1
K5.17	Suppression pool level	3.9

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Primary Containment System and Auxiliaries:

(CFR: 41.7 / 45.7)

K6.01	Drywell cooling	3.8
K6.02	Containment cooling (Mark III)	3.8
K6.03	Suppression pool makeup	3.4
K6.04	Combustible gas mixing	3.4
K6.05	Hydrogen recombiner	3.3
K6.06	Backup hydrogen purge	3.2

System: 223001 SF5 PCS Primary Containment System and Auxiliaries

K6.07	Hydrogen igniter system	3.5
K6.08	Containment atmospheric control	3.4
K6.09	Drywell vacuum relief system	3.8
K6.10	Containment vacuum relief system (Mark III)	3.6
K6.11	AC electrical distribution	3.5
K6.12	DC electrical distribution	3.5
K6.13	Applicable plant pneumatic systems	3.2
K6.14	RHR/LPCI	3.7
K6.15	Containment hardened vent	4.0
K6.16	Standby gas treatment system or filtration, recirculation and ventilation system	3.7

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Primary Containment System and Auxiliaries, including: (CFR: 41.5 / 45.5)

A1.01	Drywell temperature	4.1
A1.02	Drywell pressure	4.2
A1.03	Containment pressure	4.1
A1.04	Containment temperature	4.0
A1.05	Hydrogen concentration	3.7
A1.06	Oxygen concentration	3.5
A1.07	Drywell/suppression chamber differential pressure (drywell to containment building)	3.7
A1.08	Suppression pool level	4.0
A1.09	Suppression pool temperature	4.0
A1.10	RCS leakage	3.8
A1.11	Reactor building to suppression chamber differential pressure	3.5
A1.12	Moisture concentration	2.4
A1.13	System indicating light and alarms	3.6
A1.14	Containment/drywell differential pressure (Mark III)	3.8

System: 223001 SF5 PCS Primary Containment System and Auxiliaries

A2 Ability to (a) predict the impacts of the following on the Primary Containment System and Auxiliaries and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6)

		RO	SRO
A2.01	Loss of coolant accident	4.4	4.5
A2.02	Steam bypass of suppression pool	4.1	4.1
A2.03	Safety/relief valve leaking or stuck-open	4.3	4.0
A2.04	High containment/drywell hydrogen concentration	3.8	3.8
A2.05	High containment/drywell oxygen concentration	3.6	3.6
A2.06	High containment pressure (Mark III)	4.0	4.1
A2.07	High drywell pressure	4.4	4.3
A2.08	Compressor trips (loss of air)	3.7	2.9
A2.09	Vacuum breaker malfunction	3.9	3.7
A2.10	High drywell temperature	4.0	3.8
A2.11	Abnormal suppression pool level	3.9	3.7
A2.12	Abnormal suppression pool temperature	4.0	3.8
A2.13	High containment temperature (Mark III)	4.0	3.9
A2.14	Low containment to annulus pressure (Mark III)	3.5	3.4
A2.15	Steam line break	4.0	4.0
A2.16	Opening of head vent to drywell equipment sump with pressure in the reactor vessel	3.9	3.5

A3 Ability to monitor automatic operation of the Primary Containment System and Auxiliaries, including:
(CFR: 41.7 / 45.7)

A3.01	Suppression pool level makeup system: Mark III		3.5
A3.02	Vacuum breaker/relief valve operation		3.9
A3.03	DELETED		
A3.04	Containment/drywell response during LOCA		4.2
A3.05	DELETED		
A3.06	Drywell/suppression chamber differential pressure (Mark I, II)		3.9
A3.07	DELETED		

System: 223001 SF5 PCS Primary Containment System and Auxiliaries

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

A4.01	Containment relief valves (Mark III)	4.2
A4.02	Air containment atmosphere dilution compressors	3.2
A4.03	Air dilution valves to drywell and suppression pool	3.1
A4.04	DELETED	
A4.05	DELETED	
A4.06	DELETED	
A4.07	DELETED	
A4.08	DELETED	
A4.09	SPDS/CRIDS/ERIS/GDS	3.5
A4.10	Drywell nitrogen makeup (Mark I, II)	3.5
A4.11	Drywell pneumatics	3.5
A4.12	Drywell coolers/chillers	3.5
A4.13	Hydrogen recombiners	3.3
A4.14	Hydrogen igniters	3.5
A4.15	Suppression pool makeup systems	3.5
A4.16	Suppression pool cleanup system	2.5
A4.17	Hardened containment vent	3.8
A4.18	Containment spray system (Mark III)	4.2

System: 223002 SF5 PCIS Primary Containment Isolation System/Nuclear Steam Supply Shutoff

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Primary Containment Isolation System/Nuclear Steam Supply Shutoff and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Main steam system	4.2
K1.02	Reactor water cleanup	3.8
K1.03	Plant ventilation	3.5
K1.04	HPCI	4.2
K1.05	Isolation condenser	4.1
K1.06	Recirculation system	3.1
K1.07	RCIC	4.1
K1.08	Shutdown cooling system/RHR	3.9
K1.09	Reactor vessel head spray	3.0
K1.10	Containment ventilation	3.4
K1.11	Containment atmosphere sampling	3.1
K1.12	SGTS	3.8
K1.13	Traversing in-core probe system	3.1
K1.14	Containment/drywell floor and equipment drain system	3.5
K1.15	HPCI	3.8
K1.16	DELETED	
K1.17	Plant process computer/parameter display systems	2.9
K1.18	Reactor building drainage system	2.8
K1.19	Component cooling water systems	3.1
K1.20	AC electrical distribution	3.3
K1.21	Circulating water	2.0
K1.22	Containment nitrogen inerting system	3.2
K1.23	Condenser circulating water makeup	1.8
K1.24	Leak detection system	3.1
K1.25	RPS	3.8
K1.26	DC electrical distribution	3.2
K1.27	Plant pneumatic systems	3.3
K1.28	Process radiation monitoring	3.3
K1.29	Nuclear boiler instrumentation	3.5
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Logic power supplies	3.6

System: 223002 SF5 PCIS Primary Containment Isolation System/Nuclear Steam Supply Shutoff

K3 Knowledge of the effect that a loss or malfunction of the Primary Containment Isolation System/Nuclear Steam Supply Shutoff will have on the following systems or system parameters:
(CFR: 41.7 / 45.4)

K3.01	Reactor water level	3.9
K3.02	Fuel cladding temperature	3.7
K3.03	Offsite radioactive release rates	4.1
K3.04	Reactor building radiation level	3.8
K3.05	Containment/drywell floor and equipment drain system	3.4
K3.06	Turbine building radiation	3.4
K3.07	Reactor pressure	4.0
K3.08	Reactor vessel temperature	3.5
K3.09	Main steam system	4.0
K3.10	Reactor water cleanup	3.8
K3.11	Plant ventilation	3.4
K3.12	High-pressure coolant injection	3.9
K3.13	Isolation condenser	4.0
K3.14	Recirculation system	3.1
K3.15	Reactor core isolation cooling	4.0
K3.16	Shutdown cooling system/RHR	3.8
K3.17	Reactor vessel head spray	3.1
K3.18	Containment ventilation	3.3
K3.19	Containment atmosphere sampling	3.0
K3.20	SGTS	3.8
K3.21	Traversing in-core probe system	3.0
K3.22	DELETED	
K3.23	High-pressure core spray	3.6
K3.24	Reactor building drainage system	2.7
K3.25	Component cooling water systems	2.9
K3.26	AC electrical distribution	3.0
K3.27	Circulating water	2.0
K3.28	Containment nitrogen inerting system	3.3
K3.29	Condenser circulating water makeup	1.8
K3.30	Leak detection system	3.1
K3.31	RPS	3.6
K3.32	DC electrical distribution	3.0
K3.33	Plant pneumatic systems	3.3
K3.34	Process radiation monitoring	3.1
K3.35	Nuclear boiler instrumentation	3.4

System: 223002 SF5 PCIS Primary Containment Isolation System/Nuclear Steam Supply Shutoff

**K4 Knowledge of Primary Containment Isolation System/Nuclear Steam Supply Shutoff design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Redundancy	3.8
K4.02	Testability	3.2
K4.03	Manual initiation capability	3.9
K4.04	Automatic bypassing of selected isolations during specified plant conditions	3.8
K4.05	Single failures will not impair the function ability of the system	3.6
K4.06	Once initiated, system reset requires deliberate operator action	3.8
K4.07	Physical separation of system components (to prevent localized environmental factors, electrical faults, and physical events from impairing system response)	3.3
K4.08	Manual defeating of selected isolations during specified emergency conditions	4.0

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Primary Containment Isolation System/Nuclear Steam Supply Shutoff:
(CFR: 41.5 / 45.3)**

K5.01	Primary containment integrity	4.1
K5.02	Secondary containment integrity	3.9

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Primary Containment Isolation System/Nuclear Steam Supply Shutoff:
(CFR: 41.7 / 45.7)**

K6.01	AC electrical distribution	3.8
K6.02	DC electrical distribution	3.7
K6.03	Process radiation monitoring system	3.5
K6.04	Nuclear boiler instrumentation	3.7
K6.05	Containment instrumentation	3.6
K6.06	Various process instrumentation	3.2
K6.07	DELETED	
K6.08	Reactor protection system	3.7
K6.09	Plant pneumatic systems	3.2
K6.10	Leak detection system	3.1

System: 223002 SF5 PCIS Primary Containment Isolation System/Nuclear Steam Supply Shutoff

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Primary Containment Isolation System/Nuclear Steam Supply Shutoff, including:
(CFR: 41.5 / 45.5)**

A1.01	System indicating lights and alarms	4.0
A1.02	DELETED	
A1.03	Plant process computer/parameter display systems	3.3
A1.04	Individual system relay status	3.0
A1.05	Containment/drywell pressure	4.0
A1.06	Suppression chamber pressure	3.8
A1.07	Reactor water level	4.2
A1.08	Reactor pressure	4.2
A1.09	Secondary containment temperature	3.6
A1.10	Secondary containment pressure	3.6
A1.11	Containment floor drain/equipment drain sump levels	3.1
A1.12	Condenser vacuum	3.1

**A2 Ability to (a) predict the impacts of the following on the Primary Containment Isolation System/Nuclear Steam Supply Shutoff and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6)**

		RO	SRO
A2.01	AC electrical distribution failures	3.8	3.8
A2.02	DC electrical distribution failures	3.8	3.6
A2.03	System logic failures	3.9	4.0
A2.04	Process radiation monitoring system failures	3.4	3.3
A2.05	Nuclear boiler instrumentation failures	3.8	3.8
A2.06	Containment instrumentation failures	3.8	3.6
A2.07	Various process instrumentation failures	3.6	3.1
A2.08	DELETED		
A2.09	Inadvertent system initiation	4.0	4.1
A2.10	Loss of coolant accidents	4.0	4.3
A2.11	Standby liquid initiation	4.0	3.7
A2.12	Plant pneumatic system failures	3.6	3.1
A2.13	Leak detection system failures	3.3	3.1
A2.14	Reactor protection system failures	4.0	4.0

System: 223002 SF5 PCIS Primary Containment Isolation System/Nuclear Steam Supply Shutoff

A3 Ability to monitor automatic operation of the Primary Containment Isolation System/Nuclear Steam Supply Shutoff, including:
(CFR: 41.7 / 45.7)

A3.01	System indicating lights and alarms	4.0
A3.02	Valve closures	4.3
A3.03	DELETED	
A3.04	Verification of relay operation	3.2
A3.05	Group isolations	4.2

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	System valve operations	4.2
A4.02	Initiation of the system	4.3
A4.03	Reset of system isolations	4.0
A4.04	System indicating lights and alarms	3.8
A4.05	DELETED	
A4.06	Confirmation of initiation to completion	4.2
A4.07	Reset of system initiations	3.8
A4.08	Group isolations	4.2

System: 219000 SF5 RHR SPC RHR/LPCI: Torus/Suppression Pool Cooling Mode

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the RHR/LPCI: Torus/Suppression Pool Cooling Mode and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Primary containment	4.1
K1.02	Condensate system	2.4
K1.03	DELETED	
K1.04	DELETED	
K1.05	DELETED	
K1.06	Keep fill system	3.1
K1.07	DELETED	
K1.08	DELETED	
K1.09	Nuclear boiler instrumentation	3.3
K1.10	Reactor building drain system	2.2
K1.11	Component cooling water systems	2.8
K1.12	LPCI/RHR system	3.9
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Valves	3.6
K2.02	Pumps	3.9
K2.03	Valve control logic	3.6
K3	Knowledge of the effect that a loss or malfunction of the RHR/LPCI: Torus/Suppression Pool Cooling Mode will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Suppression pool temperature control	4.2
K3.02	Suppression chamber temperature	3.8
K3.03	Primary containment	3.9
K4	Knowledge of RHR/LPCI: Torus/Suppression Pool Cooling Mode design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	DELETED	

System: 219000 SF5 RHR SPC RHR/LPCI: Torus/Suppression Pool Cooling Mode

K4.02	DELETED	
K4.03	Diverting flow from the RPV to the containment during accident conditions	4.1
K4.04	DELETED	
K4.05	DELETED	
K4.06	DELETED	
K4.07	DELETED	
K4.08	Adequate pump net positive suction head	3.5
K4.09	Heat exchanger cooling	3.5
K4.10	DELETED	

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the RHR/LPCI: Torus/Suppression Pool Cooling Mode:
(CFR: 41.5 / 45.3)

K5.01	DELETED	
K5.02	NPSH/vortex	3.4
K5.03	DELETED	
K5.04	Heat exchanger operation	3.4
K5.05	LOCA signal	4.1
K5.06	System lineup	3.9

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the RHR/LPCI: Torus/Suppression Pool Cooling Mode:
(CFR: 41.7 / 45.7)

K6.01	AC electrical distribution system	3.8
K6.02	DC electrical distribution system	3.5
K6.03	Emergency diesel generator	4.0
K6.04	Keep fill system	3.3
K6.05	Condensate system	2.3
K6.06	Suppression pool	3.6
K6.07	DELETED	
K6.08	ECCS room cooling	3.3
K6.09	Nuclear boiler instrumentation	3.4
K6.10	CCW system	3.0

System: 219000 SF5 RHR SPC RHR/LPCI: Torus/Suppression Pool Cooling Mode

A1	Ability to predict and/or monitor changes in parameters associated with operation of the RHR/LPCI: Torus/Suppression Pool Cooling Mode, including: (CFR: 41.5 / 45.5)		
A1.01	Suppression pool temperature	4.2	
A1.02	System flow	4.1	
A1.03	System pressure	3.7	
A1.04	Suppression pool level	3.8	
A1.05	Condensate storage tank level	2.7	
A1.06	Motor amps	3.1	
A1.07	Emergency generator loading	4.0	
A1.08	DELETED		
A1.09	Suppression chamber air temperature	3.3	
A1.10	Containment air temperature: Mark III	3.5	
A1.11	System lights and alarms	3.7	
A1.12	Heat exchanger cooling flow	3.6	
A2	Ability to (a) predict the impacts of the following on the RHR/LPCI: Torus/Suppression Pool Cooling Mode and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations: (CFR: 41.5 / 43.5 / 45.6)	RO	SRO
A2.01	Inadequate net positive suction head/vortex limits	3.9	3.7
A2.02	Pump trips	4.0	3.8
A2.03	Valve malfunction	3.7	3.7
A2.04	DELETED		
A2.05	AC electrical failures	3.7	3.8
A2.06	DC electrical failures	3.3	3.5
A2.07	Emergency generator failure	3.9	3.9
A2.08	Pump seal failure	3.1	2.9
A2.09	Inadequate room cooling	3.3	3.0
A2.10	Nuclear boiler instrument failures	3.4	3.4
A2.11	Motor-operated valve failures	3.7	3.7
A2.12	Valve logic failure	3.6	3.9
A2.13	High suppression pool temperature	3.9	3.9
A2.14	Loss of coolant accident	3.9	4.2
A2.15	Loss of, or inadequate, heat exchanger cooling flow	3.9	3.7
A2.16	High suppression pool level	3.7	3.3
A2.17	Low suppression pool level	3.7	3.6

System: 219000 SF5 RHR SPC RHR/LPCI: Torus/Suppression Pool Cooling Mode

A3	Ability to monitor automatic operation of the RHR/LPCI: Torus/Suppression Pool Cooling Mode, including: (CFR: 41.7 / 45.7)	
A3.01	Valve operation	3.9
A4	Ability to manually operate and/or monitor in the control room : (CFR: 41.7 / 45.5 to 45.8)	
A4.01	Pumps	4.2
A4.02	Valve lineup	4.2
A4.03	Keep fill system	3.3
A4.04	Minimum flow valves	3.5
A4.05	Heat exchanger cooling flow	3.7
A4.06	Valve logic reset following automatic initiation of LPCI/RHR in injection mode	3.8
A4.07	DELETED	
A4.08	DELETED	
A4.09	DELETED	
A4.10	DELETED	
A4.11	DELETED	
A4.12	DELETED	
A4.13	DELETED	
A4.14	Overrides for suppression pool cooling valve logic	4.0

System: 226001 SF5 RHR CSS RHR/LPCI: Containment Spray System Mode

K/A NO.	KNOWLEDGE	IMPORTANCE
----------------	------------------	-------------------

K1	Knowledge of the physical connections and/or cause and effect relationships between the RHR/LPCI: Containment Spray System Mode and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
-----------	---	--

K1.01	Primary containment	4.2
K1.02	DELETED	
K1.03	DELETED	
K1.04	DELETED	
K1.05	Keep fill system	3.2
K1.06	Condensate system	2.4
K1.07	DELETED	
K1.08	Nuclear boiler instrumentation	3.5
K1.09	DELETED	
K1.10	DELETED	
K1.11	Component cooling water systems	3.0
K1.12	DELETED	
K1.13	Containment instrumentation	3.4
K1.14	LPCI/RHR system	4.0

K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
-----------	--	--

K2.01	Valves	3.5
K2.02	Pumps	4.0
K2.03	Valve control logic	3.7

K3	Knowledge of the effect that a loss or malfunction of the RHR/LPCI: Containment Spray System Mode will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
-----------	---	--

K3.01	Containment/drywell/suppression chamber pressure	4.3
K3.02	Containment/drywell/suppression chamber temperature	4.1
K3.03	Containment/drywell/suppression chamber components, continued operation with elevated pressure or temperature or level	3.7

System: 226001 SF5 RHR CSS RHR/LPCI: Containment Spray System Mode

**K4 Knowledge of RHR/LPCI: Containment Spray System Mode design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	DELETED	
K4.02	DELETED	
K4.03	Reduction in vessel injection flow during accident conditions	3.8
K4.04	DELETED	
K4.05	Pump minimum flow protection	3.2
K4.06	Pump motor cooling	2.8
K4.07	Prevention of water hammer	3.2
K4.08	Adequate pump net positive suction head	3.4
K4.09	Automatic containment spray initiation (BWR 6)	4.2
K4.10	DELETED	
K4.11	Prevention of leakage to the environment through system heat exchanger	3.2
K4.12	Prevention of inadvertent containment spray activation	3.2

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the RHR/LPCI: Containment Spray System Mode:
(CFR: 41.5 / 45.3)**

K5.01	DELETED	
K5.02	DELETED	
K5.03	DELETED	
K5.04	DELETED	
K5.05	DELETED	
K5.06	Vacuum breaker operation	3.6
K5.07	Pressure suppression pressure	4.3
K5.08	Containment spray initiation pressure limit	4.3

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the RHR/LPCI: Containment Spray System Mode:
(CFR: 41.7 / 45.7)**

K6.01	AC electrical distribution system	4.0
K6.02	DC electrical distribution system	3.5
K6.03	DELETED	
K6.04	Keep fill system	3.2
K6.05	Suppression pool (temperature level and pressure)	3.6

System: 226001 SF5 RHR CSS RHR/LPCI: Containment Spray System Mode

K6.06	Condensate transfer	2.5
K6.07	ECCS room cooling	2.9
K6.08	Nuclear boiler instrumentation	3.4
K6.09	Reactor building to suppression chamber vacuum breakers	3.5
K6.10	Suppression chamber to drywell vacuum breakers (Mark I, II)	3.6
K6.11	Component cooling water systems	2.8
K6.12	Containment integrity	3.8
K6.13	Suction flow path	3.5
K6.14	Containment vacuum breakers (Mark III)	3.9

A1 Ability to predict and/or monitor changes in parameters associated with operation of the RHR/LPCI: Containment Spray System Mode, including:
(CFR: 41.5 / 45.5)

A1.01	Containment/drywell pressure	4.5
A1.02	Containment/drywell temperature	4.1
A1.03	Suppression chamber pressure (Mark I, II)	4.4
A1.04	Suppression pool temperature (Mark I, II)	3.9
A1.05	DELETED	
A1.06	System flow	3.8
A1.07	System pressure	3.6
A1.08	Suppression pool level	3.5
A1.09	DELETED	
A1.10	Emergency generator loading	3.7
A1.11	Heat exchanger cooling flow	3.4
A1.12	Lights and alarms	3.6
A1.13	Pump discharge pressure	3.4

A2 Ability to (a) predict the impacts of the following on the RHR/LPCI: Containment Spray System Mode and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Inadequate net positive suction head	4.0	3.6
A2.02	Pump(s) trips	4.0	3.8
A2.03	Valve closures due to malfunction(s)	3.8	3.8
A2.04	Valve openings due to malfunction(s)	3.8	3.8
A2.05	AC electrical failures	3.8	3.8
A2.06	DC electrical failures	3.3	3.6

System: 226001 SF5 RHR CSS RHR/LPCI: Containment Spray System Mode

A2.07	DELETED		
A2.08	Pump seal failure	3.3	2.7
A2.09	Inadequate room cooling	3.0	2.9
A2.10	Nuclear boiler instrument failures	3.7	3.4
A2.11	Motor-operated valve failures	3.7	3.8
A2.12	DELETED		
A2.13	Valve logic failure	3.8	3.8
A2.14	High suppression pool level	3.8	3.3
A2.15	High containment/drywell pressure	4.0	3.9
A2.16	Loss of or inadequate heat exchanger cooling flow	3.5	3.5
A2.17	High containment/drywell temperature	3.7	3.7
A2.18	Low (or negative) containment/drywell pressure during system operation	4.0	3.8
A2.19	Low (or negative) suppression chamber pressure during system operation (Mark I, II)	4.0	3.8
A2.20	Loss of coolant accident	3.8	4.2
A2.21	Loss of containment/drywell cooling system(s)	3.3	3.5

A3 Ability to monitor automatic operation of the RHR/LPCI: Containment Spray System Mode, including:
(CFR: 41.7 / 45.7)

A3.01	Valve operation		3.8
A3.02	DELETED		
A3.03	DELETED		
A3.04	DELETED		
A3.05	DELETED		
A3.06	DELETED		
A3.07	Pump start		3.9

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Pumps		4.2
A4.02	Valves		4.1
A4.03	DELETED		
A4.04	Keep fill system		3.2
A4.05	DELETED		
A4.06	DELETED		
A4.07	Valve logic reset/bypass/override		3.8
A4.08	DELETED		
A4.09	DELETED		
A4.10	DELETED		
A4.11	DELETED		
A4.12	DELETED		

System: 226001 SF5 RHR CSS RHR/LPCI: Containment Spray System Mode

A4.13	DELETED	
A4.14	DELETED	
A4.15	DELETED	
A4.16	Suppression pool spray valve logic override	3.9
A4.17	Manual initiation controls (BWR 6)	4.2
A4.18	Automatic system initiation reset (BWR 6)	4.1
A4.19	DELETED	
A4.20	DELETED	

System: 230000 SF5 RHR SPS RHR/LPCI: Torus/Suppression Pool Spray Mode

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the RHR/LPCI: Torus/Suppression Pool Spray Mode and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Primary containment	3.9
K1.02	Condensate system	2.3
K1.03	DELETED	
K1.04	DELETED	
K1.05	DELETED	
K1.06	Keep fill system	3.0
K1.07	DELETED	
K1.08	Nuclear boiler instrumentation	3.2
K1.09	Reactor building drain system	2.3
K1.10	Component cooling water systems	2.6
K1.11	LPCI/RHR system	4.0
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Valves	3.6
K2.02	Pumps	3.8
K2.03	Control logic	3.7
K3	Knowledge of the effect that a loss or malfunction of the RHR/LPCI: Torus/Suppression Pool Spray Mode will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Suppression chamber pressure	4.0
K3.02	Suppression pool temperature	3.6
K3.03	Drywell pressure	3.7
K3.04	Suppression chamber air temperature	3.5
K3.05	Primary containment	3.7
K3.06	Primary containment pressure	3.7

System: 230000 SF5 RHR SPS RHR/LPCI: Torus/Suppression Pool Spray Mode

**K4 Knowledge of RHR/LPCI: Torus/Suppression Pool Spray Mode design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	DELETED	
K4.02	DELETED	
K4.03	Diverting flow from the RPV to the containment during accident conditions	3.9
K4.04	Prevention of piping overpressurization	3.2
K4.05	Pump minimum flow protection	3.2
K4.06	Pump motor cooling	2.7
K4.07	Prevention of water hammer	3.2
K4.08	Adequate pump net positive suction head	3.4
K4.09	DELETED	
K4.10	Prevention of leakage to the environment through system heat exchanger	3.2

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the RHR/LPCI: Torus/Suppression Pool Spray Mode:
(CFR: 41.5 / 45.3)**

K5.01	DELETED	
K5.02	Pump cavitation/vortex	3.3
K5.03	DELETED	
K5.04	DELETED	
K5.05	DELETED	
K5.06	Heat exchanger operation	3.2
K5.07	Vacuum breaker operation	3.4
K5.08	System lineup	3.5

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the RHR/LPCI: Torus/Suppression Pool Spray Mode:
(CFR: 41.7 / 45.7)**

K6.01	AC electrical distribution	3.8
K6.02	DC electrical distribution	3.5
K6.03	Emergency diesel generator	3.8
K6.04	Keep fill system	3.1
K6.05	Suppression pool	3.5
K6.06	Condensate system	2.3

System: 230000 SF5 RHR SPS RHR/LPCI: Torus/Suppression Pool Spray Mode

K6.07	ECCS room cooling	3.0
K6.08	Nuclear boiler instrumentation	3.3
K6.09	Reactor building to suppression pool vacuum breakers	3.7
K6.10	Component cooling water systems	2.9
K6.11	High drywell pressure	3.8
K6.12	Low suppression pool level	3.7
K6.13	High reactor pressure	3.3

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the RHR/LPCI: Torus/Suppression Pool Spray Mode, including:
(CFR: 41.5 / 45.5)**

A1.01	Suppression chamber pressure	4.0
A1.02	Suppression pool temperature	3.6
A1.03	Drywell pressure	3.9
A1.04	System flow	3.6
A1.05	System pressure	3.6
A1.06	Suppression pool level	3.6
A1.07	Condensate storage tank level	2.7
A1.08	DELETED	
A1.09	Emergency generator loading	3.5
A1.10	DELETED	
A1.11	Suppression chamber air temperature	3.2
A1.12	Lights and alarms	3.6
A1.13	Heat exchanger cooling flow	3.4

**A2 Ability to (a) predict the impacts of the following on the RHR/LPCI: Torus/Suppression Pool Spray Mode and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	Inadequate net positive suction/vortex limits	3.4	3.8
A2.02	Pump trips	3.6	3.9
A2.03	Valve closures due to malfunction(s)	3.6	3.7
A2.04	Valve openings due to malfunction(s)	3.6	3.6
A2.05	AC electrical failures	3.7	3.8
A2.06	DC electrical failures	3.6	3.5
A2.07	Emergency generator failure	3.7	3.7
A2.08	Pump seal failure	2.7	2.9
A2.09	Inadequate room cooling	2.9	2.9
A2.10	Nuclear boiler instrument failures	3.6	3.3

System: 230000 SF5 RHR SPS RHR/LPCI: Torus/Suppression Pool Spray Mode

A2.11	Motor-operated valve failures	3.6	3.6
A2.12	Valve logic failure	3.4	3.7
A2.13	High suppression pool level	3.6	3.3
A2.14	Low (or negative) suppression pool pressure during system operation	3.0	3.6
A2.15	Loss of coolant accident	3.7	4.0
A2.16	Loss of, or inadequate, heat exchanger cooling flow	3.3	3.4

**A3 Ability to monitor automatic operation of the RHR/LPCI: Torus/Suppression Pool Spray Mode, including:
(CFR: 41.7 / 45.7)**

A3.01	Valve operation		3.8
-------	-----------------	--	-----

**A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)**

A4.01	Pumps		4.2
A4.02	Valve lineup		4.1
A4.03	Keep fill system		3.2
A4.04	Minimum flow valves		3.3
A4.05	Heat exchanger cooling flow		3.4
A4.06	Valve logic reset following automatic initiation of LPCI/RHR in injection mode		3.6
A4.07	DELETED		
A4.08	DELETED		
A4.09	DELETED		
A4.10	DELETED		
A4.11	DELETED		
A4.12	DELETED		
A4.13	DELETED		
A4.14	DELETED		
A4.15	DELETED		
A4.16	Override for suppression pool spray valve logic		4.0

System: 290001 SF5 SC Secondary Containment

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Secondary Containment and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Reactor building ventilation	3.9
K1.02	Primary containment system	3.7
K1.03	Fuel handling building ventilation	3.5
K1.04	SGTS/FRVS	4.0
K1.05	Auxiliary building ventilation (BWR 6)	3.9
K1.06	DELETED	
K1.07	Turbine building ventilation (steam tunnel)	3.2
K1.08	Offgas system	2.8
K1.09	Plant pneumatic systems	3.2
K1.10	Auxiliary boiler system (BWR 2, 3, 4)	2.6
K1.11	Process radiation monitoring system	3.7
K1.12	Area radiation monitoring	3.4
K1.13	Radwaste systems	2.5
K1.14	Fire protection system	2.9
K1.15	Nuclear boiler instrumentation	3.4
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Airlock door interlock	2.7
K2.02	HVAC isolation dampers	2.8
K3	Knowledge of the effect that a loss or malfunction of the Secondary Containment will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Offsite radioactive release rates	4.1
K3.02	Secondary containment pressure	3.7
K3.03	Plant ventilation systems	3.4
K3.04	Primary containment system (BWR 6)	3.5
K3.05	Offgas system flow	2.7
K3.06	Secondary containment temperature	3.2

System: 290001 SF5 SC Secondary Containment

**K4 Knowledge of Secondary Containment design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Personnel access without breaching secondary containment	3.4
K4.02	Protection against overpressurization	3.3
K4.03	Fluid leakage collection	2.9
K4.04	Auxiliary building isolation (BWR 6)	3.5

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Secondary Containment:
(CFR: 41.5 / 45.3)**

K5.01	Vacuum breaker operation (BWR 4)	3.6
K5.02	Flow measurement (BWR 3)	2.9
K5.03	Building delta pressure control	3.5
K5.04	Secondary containment integrity	3.9

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Secondary Containment:
(CFR: 41.7 / 45.7)**

K6.01	Reactor building ventilation	3.8
K6.02	Radwaste building ventilation	2.2
K6.03	SGTS/FRVS	4.0
K6.04	Primary containment system	3.6
K6.05	Auxiliary building ventilation (BWR 6)	3.5
K6.06	DELETED	
K6.07	DELETED	
K6.08	Plant pneumatic systems	3.1
K6.09	AC electrical distribution	3.3
K6.10	Radwaste systems	2.2

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Secondary Containment, including:
(CFR: 41.5 / 45.5)**

A1.01	DELETED	
A1.02	High area temperature (BWR 6)	3.8
A1.03	Reactor building differential pressure	3.9
A1.04	Reactor building area temperature	3.6

System: 290001 SF5 SC Secondary Containment

A1.05	Auxiliary building differential pressure (BWR 6)	3.6
A1.06	Auxiliary building area temperatures (BWR 6)	3.7
A1.07	Fuel building differential pressure	3.3
A1.08	Fuel building area temperature	3.3
A1.09	Radwaste building differential pressure	2.1
A1.10	Radwaste building area temperature	2.0
A1.11	System indicating lights and alarms	3.5
A1.12	Offsite release rates	4.0

A2 Ability to (a) predict the impacts of the following on the Secondary Containment and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Personnel airlock failure	3.8	3.3
A2.02	Excessive outleakage	3.6	3.6
A2.03	High area radiation	3.9	3.8
A2.04	High airborne radiation	3.9	3.7
A2.05	High area temperature	4.0	3.7
A2.06	Auxiliary building isolation (BWR 6)	3.7	3.4
A2.07	Inadvertent fire suppression system initiation	2.8	2.7
A2.08	Loss of secondary containment integrity	4.0	3.9

A3 Ability to monitor automatic operation of the Secondary Containment, including:

(CFR: 41.7 / 45.7)

A3.01	Secondary containment isolation	4.1
A3.02	Normal building differential pressure	3.7
A3.03	Plant ventilation systems	3.3

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

A4.01	Reactor building differential pressure	3.9
A4.02	DELETED	
A4.03	DELETED	
A4.04	DELETED	
A4.05	DELETED	
A4.06	DELETED	
A4.07	DELETED	
A4.08	DELETED	

System: 290001 SF5 SC Secondary Containment

A4.09	DELETED	
A4.10	System lineups	3.7
A4.11	System reset	3.5
A4.12	Surveillance testing	2.9
A4.13	Secondary containment ventilation systems	3.6

3.6	Safety Function 6: Electrical	Page
262001	AC Electrical Distribution.....	3.6-3
263000	DC Electrical Distribution.....	3.6-6
264000	Emergency Generators (Diesel/Jet).....	3.6-9
262002	Uninterruptable Power Supply (AC/DC).....	3.6-13

System: 262001 SF6 AC AC Electrical Distribution

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the AC Electrical Distribution and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Emergency generators	4.7
K1.02	DC electrical distribution	4.1
K1.03	Offsite power system	4.4
K1.04	Uninterruptible power supply (switchyard UPS)	3.5
K1.05	Main turbine generator and auxiliaries system	3.5
K1.06	DELETED	
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	DELETED	
K2.02	AC breaker control power	3.7
K2.03	Major motor control centers/buses (480 volts and higher)	3.8
K3	Knowledge of the effect that a loss or malfunction of the AC Electrical Distribution will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Operationally significant AC loads	4.1
K3.02	Emergency generators	4.6
K3.03	DC electrical distribution	3.9
K3.04	Uninterruptible power supply system	3.7
K3.05	Qualified offsite power sources	4.1
K3.06	DELETED	
K4	Knowledge of AC Electrical Distribution design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Lockouts	3.5
K4.02	Circuit breaker automatic trips	3.5
K4.03	Automatic bus transfer	3.8
K4.04	Protective relaying	3.5
K4.05	Paralleling of AC sources	3.8
K4.06	Redundant power sources to vital buses	4.1
K4.07	Breaker closure permissives	3.6

System:	262001 SF6 AC AC Electrical Distribution		
K4.08	Alternate breaker control methods		3.2
K4.09	Divisional separation		3.6
K5	Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the AC Electrical Distribution: (CFR: 41.5 / 45.3)		
K5.01	Paralleling AC sources		3.9
K5.02	Breaker control power		3.5
K6	Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the AC Electrical Distribution: (CFR: 41.7 / 45.7)		
K6.01	DC power		3.8
K6.02	Offsite power		4.2
K6.03	Generator trip		3.9
K6.04	Emergency generators		4.5
K6.05	Breaker malfunctions		3.6
A1	Ability to predict and/or monitor changes in parameters associated with operation of the AC Electrical Distribution, including: (CFR: 41.5 / 45.5)		
A1.01	DELETED		
A1.02	DELETED		
A1.03	Bus voltage		3.6
A1.04	Load currents		3.2
A1.05	DELETED		
A1.06	Lights and alarms		3.4
A1.07	System frequency		3.2
A1.08	System power		3.3
A2	Ability to (a) predict the impacts of the following on the AC Electrical Distribution and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations: (CFR: 41.5 / 43.5 / 45.6)		
		RO	SRO
A2.01	Turbine/generator trip	4.0	3.8
A2.02	Loss of coolant accident	4.3	4.2

System: 262001 SF6 AC Electrical Distribution

A2.03	Loss of/degraded offsite power	4.5	4.3
A2.04	DELETED		
A2.05	Bus grounds /faults	3.8	3.6
A2.06	Loss of a plant bus	4.0	3.8
A2.07	DELETED		
A2.08	DELETED		
A2.09	Exceeding voltage limitations	3.8	3.4
A2.10	Exceeding current limitations	3.7	3.4
A2.11	Degraded bus voltages	3.9	3.9
A2.12	Station blackout	4.6	4.5

**A3 Ability to monitor automatic operation of the AC Electrical Distribution, including:
(CFR: 41.7 / 45.7)**

A3.01	Breaker tripping	3.6	
A3.02	Bus transfer	3.7	
A3.03	Load shedding	3.8	
A3.04	Load sequencing	3.8	
A3.05	Synchronization of AC sources	3.7	
A3.06	Tap changers	2.9	

**A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)**

A4.01	Breakers and disconnects	3.7	
A4.02	DELETED		
A4.03	Local operation of breakers	3.0	
A4.04	Synchronizing of AC sources	3.9	
A4.05	DELETED		
A4.06	Instrumentation switches	3.2	
A4.07	Tap changers	2.8	

System: 263000 SF6 DC Electrical Distribution

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the DC Electrical Distribution and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	AC electrical distribution	4.0
K1.02	DELETED	
K1.03	Plant ventilation systems	2.8
K1.04	DELETED	
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Operationally significant DC loads	4.0
K2.02	DELETED	
K2.03	Battery chargers	3.5
K2.04	Inverters	3.4
K3	Knowledge of the effect that a loss or malfunction of the DC Electrical Distribution will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	DELETED	
K3.02	Operationally significant systems using DC control power	4.2
K3.03	Systems with DC components (e.g., valves, motors, solenoids, instruments)	3.8
K4	Knowledge of DC Electrical Distribution design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Manual/automatic transfers	3.5
K4.02	Breaker interlocks, permissives, bypasses, and cross ties	3.5
K4.03	Ground detection	2.9
K4.04	Battery charging methods	2.9
K4.05	Coping time	3.6
K4.06	Divisional separation	3.6

System: 263000 SF6 DC DC Electrical Distribution

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the DC Electrical Distribution:
(CFR: 41.5 / 45.3)**

K5.01	Hydrogen generation	3.1
K5.02	Battery charger and battery	3.4
K5.03	Battery ventilation	2.9
K5.04	Ground detection	2.9

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the DC Electrical Distribution:
(CFR: 41.7 / 45.7)**

K6.01	AC electrical distribution	3.8
K6.02	Battery ventilation	2.9
K6.03	Grounds	3.0
K6.04	Station blackout	4.3
K6.05	Degraded voltage	3.6
K6.06	Breaker malfunctions	3.4

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the DC Electrical Distribution, including:
(CFR: 41.5 / 45.5)**

A1.01	Battery charging/discharging rate	3.3
A1.02	Lights and alarms	3.3
A1.03	Voltage	3.5

**A2 Ability to (a) predict the impacts of the following on the DC Electrical Distribution and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	Grounds/faults	3.5	3.2
A2.02	Loss of ventilation during charging	2.9	3.0
A2.03	Abnormal battery parameters	3.4	3.2
A2.04	Station blackout	4.5	4.2

System: 263000 SF6 DC DC Electrical Distribution

**A3 Ability to monitor automatic operation of the DC Electrical Distribution, including:
(CFR: 41.7 / 45.7)**

A3.01	DELETED	
A3.02	Breaker trips	3.5
A3.03	Transfers	3.3

**A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)**

A4.01	Operationally significant breakers and control power fuses	3.7
A4.02	DELETED	
A4.03	DELETED	
A4.04	Ground detection circuit	2.8
A4.05	Meters, dials, recorders, alarms, and indicating lights	3.3
A4.06	Transfers	3.2

System: 264000 SF6 EGE Emergency Generators (Diesel/Jet)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Emergency Generators and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	AC electrical distribution	4.5
K1.02	DELETED	
K1.03	Fire protection system	3.0
K1.04	Component cooling water system	3.4
K1.05	DELETED	
K1.06	DELETED	
K1.07	Emergency core cooling systems	4.4
K1.08	Plant ventilation systems	3.0
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Starting air compressor	2.8
K2.02	Fuel oil pumps	2.9
K2.03	Turning gear (jet engine)	2.6
K2.04	Ignition system (jet engine)	2.7
K2.05	Lube oil pumps	2.9
K2.06	Battery charger	3.0
K2.07	DC components	3.2
K2.08	Cooling water pumps	3.3
K2.09	Room ventilation fans	2.8
K3	Knowledge of the effect that a loss or malfunction of the Emergency Generators will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	DELETED	
K3.02	AC electrical distribution	4.4
K3.03	Operationally significant loads	4.3
K3.04	Bus frequency/voltage	3.9

**System: 264000 SF6 EGE Emergency Generators
(Diesel/Jet)**

**K4 Knowledge of Emergency Generators
design features and/or interlocks that
provide for the following:
(CFR: 41.7)**

K4.01	Generator trips	4.0
K4.02	DELETED	
K4.03	Generator droop control	3.4
K4.04	Field flashing	3.2
K4.05	Load shedding and sequencing	4.1
K4.06	Governor control	3.6
K4.07	Local operation and control	3.5
K4.08	Automatic startup	4.2
K4.09	Standby readiness	3.8
K4.10	Automatic start logic	4.2

**K5 Knowledge of the operational implications
or cause and effect relationships of the
following concepts as they apply to the
Emergency Generators:
(CFR: 41.5 / 45.3)**

K5.01	Parallel vs. isochronous operation	3.6
K5.02	DELETED	
K5.03	DELETED	
K5.04	DELETED	
K5.05	DELETED	
K5.06	Load sequencing	3.9
K5.07	DELETED	
K5.08	Generator load limits	4.1
K5.09	Fuel consumption rate	2.8

**K6 Knowledge of the effect of the following
plant conditions, system malfunctions, or
component malfunctions on the Emergency
Generators:
(CFR: 41.7 / 45.7)**

K6.01	Starting air components	3.8
K6.02	Fuel oil components	3.6
K6.03	Lube oil components	3.6
K6.04	Turning gear	2.2
K6.05	Ignition system	3.0
K6.06	Battery charger	3.2

**System: 264000 SF6 EGE Emergency Generators
(Diesel/Jet)**

K6.07	Cooling water system	3.7
K6.08	AC electrical distribution system	4.0
K6.09	DC electrical distribution system	4.0
K6.10	Jacket water components	3.3
K6.11	Turbo/super charger	3.2
K6.12	Room ventilation	3.1

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Emergency Generators, including:
(CFR: 41.5 / 45.5)**

A1.01	DELETED	
A1.02	Fuel consumption rate	2.7
A1.03	Operating voltages, currents, and temperatures	3.6
A1.04	DELETED	
A1.05	DELETED	
A1.06	Emergency generator room temperature	2.8
A1.07	Gas generator temperature	3.0
A1.08	Gas generator speed	3.0
A1.09	Generator load	3.9
A1.10	Lights and alarms	3.5

**A2 Ability to (a) predict the impacts of the following on the Emergency Generators and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	DELETED		
A2.02	DELETED		
A2.03	DELETED		
A2.04	DELETED		
A2.05	DELETED		
A2.06	DELETED		
A2.07	Loss of offsite power	4.7	4.6
A2.08	Initiation of emergency generator room fire protection system	3.1	3.5
A2.09	Loss of safety bus	4.7	4.3
A2.10	LOCA	4.7	4.4
A2.11	Failure of emergency generator to start/load	4.6	4.3
A2.12	Loss of DC electrical distribution	3.5	4.0

System:	264000 SF6 EGE Emergency Generators (Diesel/Jet)		
A2.13	Loss of starting air	3.8	3.9
A3	Ability to monitor automatic operation of the Emergency Generators, including: (CFR: 41.7 / 45.7)		
A3.01	Starting/loading	4.2	
A3.02	DELETED		
A3.03	DELETED		
A3.04	Frequency and voltage control	4.0	
A3.05	Load shedding and sequencing	3.9	
A3.06	Cooling water system operation	3.6	
A3.07	Room ventilation system	3.1	
A4	Ability to manually operate and/or monitor in the control room: (CFR: 41.7 / 45.5 to 45.8)		
A4.01	Voltage/frequency	4.1	
A4.02	Synchroscope	3.9	
A4.03	Transfer of emergency control between manual and automatic	3.6	
A4.04	Starting, loading, unloading, and stopping of emergency generator	4.1	
A4.05	DELETED		
A4.06	Droop setting	3.3	
A4.07	Transfer of control to local/remote panels	3.4	

System: 262002 SF6 UPS Uninterruptable Power Supply (AC/DC)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Uninterruptable Power Supply (AC/DC) and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Reactor water level control system	3.5
K1.02	Feedwater system	3.4
K1.03	RPIS	3.5
K1.04	Reactor manual control system	3.4
K1.05	Reactor/turbine pressure regulating system	3.3
K1.06	Plant process computer/parameter display systems	2.8
K1.07	Rod worth minimizer system	3.0
K1.08	Primary containment isolation system/nuclear steam supply shutoff	3.3
K1.09	Primary containment system and auxiliaries	3.1
K1.10	Fire protection system	2.6
K1.11	DELETED	
K1.12	Main turbine generator and auxiliary systems	2.8
K1.13	Recirculation flow control system	3.3
K1.14	Radiation monitoring system	2.9
K1.15	DELETED	
K1.16	Main and reheat steam system	2.5
K1.17	RPS	3.5
K1.18	DELETED	
K1.19	APRM/LPRM/OPRM system	3.4
K1.20	DELETED	
K1.21	RCIS (BWR 6)	3.6
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Static switch/inverter	3.3
K2.02	Motor generator	3.3
K3	Knowledge of the effect that a loss or malfunction of the Uninterruptable Power Supply (AC/DC) will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor water level control system	3.5
K3.02	Recirculation flow control system	3.3

System: 262002 SF6 UPS Uninterruptable Power Supply (AC/DC)

K3.03	Feedwater system	3.4
K3.04	Fire protection system	2.5
K3.05	Rod worth minimizer system	2.8
K3.06	RPIS	3.4
K3.07	Reactor manual control system	3.4
K3.08	Plant process computer/parameter display systems	2.8
K3.09	Primary containment system and auxiliaries	3.0
K3.10	Primary containment isolation system/nuclear steam supply shutoff	3.3
K3.11	Main and reheat steam system	2.6
K3.12	DELETED	
K3.13	Reactor pressure	3.1
K3.14	Reactor power	3.3
K3.15	Main turbine generator and auxiliary systems	2.9
K3.16	DELETED	
K3.17	DELETED	
K3.18	RCIS (BWR 6)	3.8
K3.19	Reactor/turbine pressure regulating system	3.2
K3.20	Radiation monitoring system	2.7
K3.21	APRM/LPRM/OPRM system	3.3
K3.22	RPS	3.3

**K4 Knowledge of Uninterruptable Power Supply (AC/DC) design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Transfer of power supplies	3.5
-------	----------------------------	-----

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Uninterruptable Power Supply (AC/DC):
(CFR: 41.5 / 45.3)**

K5.01	Static switch/inverter operation	3.3
K5.02	Motor generator operation	3.1
K5.03	DELETED	
K5.04	DELETED	

System: 262002 SF6 UPS Uninterruptable Power Supply (AC/DC)

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Uninterruptable Power Supply (AC/DC):
(CFR: 41.7 / 45.7)

K6.01	AC electrical distribution	3.4
K6.02	DC electrical distribution	3.4
K6.03	Static switch/inverter	3.4
K6.04	Motor generator	3.2

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Uninterruptable Power Supply (AC/DC), including:
(CFR: 41.5 / 45.5)

A1.01	Inverter outputs	3.1
A1.02	Motor generator outputs	3.1
A1.03	Lights and alarms	3.1

A2 Ability to (a) predict the impacts of the following on the Uninterruptable Power Supply (AC/DC) and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Abnormal voltage	3.2	3.2
A2.02	DELETED		
A2.03	Frequency malfunctions in the system	3.0	2.9
A2.04	DELETED		
A2.05	Loss of UPS	3.8	3.9

A3 Ability to monitor automatic operation of the Uninterruptable Power Supply (AC/DC), including:
(CFR: 41.7 / 45.7)

A3.01	Transfer of power sources	3.4
-------	---------------------------	-----

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Transfer of power sources	3.1
-------	---------------------------	-----

3.7	Safety Function 7: Instrumentation	Page
215005	Average Power Range Monitor/Local Power Range Monitor System.....	3.7-3
215003	Intermediate Range Monitor System.....	3.7-7
216000	Nuclear Boiler Instrumentation.....	3.7-10
272000	Radiation Monitoring System.....	3.7-15
212000	Reactor Protection System.....	3.7-19
215002	Rod Block Monitor System.....	3.7-23
201005	Rod Control and Information System.....	3.7-26
214000	Rod Position Information System.....	3.7-30
201004	Rod Sequence Control System.....	3.7-33
201006	Rod Worth Minimizer System.....	3.7-36
215004	Source Range Monitor System.....	3.7-39
215001	Traversing In-Core Probe.....	3.7-42

System: 215005 SF7 Average Power Range Monitor/Local Power Range Monitor System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Average Power Range Monitor/Local Power Range Monitor System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	RPS	4.4
K1.02	IRM system	3.7
K1.03	RBMS	3.9
K1.04	DELETED	
K1.05	DELETED	
K1.06	Plant process computer/parameter display systems	3.1
K1.07	DELETED	
K1.08	DELETED	
K1.09	Reactor recirculation system (BWR 5, 6)	3.6
K1.10	RMCS (BWR 2, 3, 4, 5)	3.5
K1.11	RCIS (BWR 6)	3.8
K1.12	DELETED	
K1.13	TIP	3.1
K1.14	Reactor vessel and internals	3.0
K1.15	Redundant reactivity control system	3.5
K1.16	DELETED	
K1.17	Recirculation flow control system	3.5
K1.18	OPRM	3.9
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	LPRM channels	3.2
K2.02	APRM channels	3.7
K2.03	OPRM channels	3.6
K3	Knowledge of the effect that a loss or malfunction of the Average Power Range Monitor/Local Power Range Monitor System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	RPS	4.2
K3.02	Reactor recirculation system (BWR 5, 6)	3.6
K3.03	RMCS (BWR 2, 3, 4, 5)	3.4

System: 215005 SF7 Average Power Range Monitor/Local Power Range Monitor System

K3.04	RCIS (BWR 6)	3.8
K3.05	Reactor power indication	4.0
K3.06	IRM system	3.2
K3.07	Rod block monitor system	3.7
K3.08	Plant process computer parameter display systems	3.0
K3.09	Recirculation flow control system	3.3
K3.10	OPRM	3.7

**K4 Knowledge of Average Power Range Monitor/Local Power Range Monitor System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Rod withdrawal blocks	3.9
K4.02	Reactor SCRAM signals	4.4
K4.03	DELETED	
K4.04	LPRM detector replacement	2.5
K4.05	Alarm seal-in	2.9
K4.06	Effects of detector aging on LPRM/APRM readings	2.9
K4.07	Flow-biased trip setpoints	3.9
K4.08	Sampling of overall core power in each APRM	3.5
K4.09	Core thermal calculations	3.6
K4.10	Bypassing an LPRM, APRM, or OPRM channel	3.7

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Average Power Range Monitor/Local Power Range Monitor System:
(CFR: 41.5 / 45.3)**

K5.01	LPRM detector operation	3.5
K5.02	Effects of voids on LPRM indication	3.1
K5.03	Control rod symmetrical patterns	3.5
K5.04	LPRM detector location and core symmetry	3.3
K5.05	Core flow effects on APRM trip setpoints	3.8
K5.06	LPRM/OPRM/APRM channel assignments	3.2
K5.07	APRM operation	3.7
K5.08	OPRM operation	3.6

System: 215005 SF7 Average Power Range Monitor/Local Power Range Monitor System

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Average Power Range Monitor/Local Power Range Monitor System:
(CFR: 41.7 / 45.7)

K6.01	RPS	3.9
K6.02	TIP	2.9
K6.03	Detectors	3.3
K6.04	Trip units	3.6
K6.05	IRMs	3.1
K6.06	Recorder	2.6
K6.07	Flow converter/comparator network	3.5
K6.08	Uninterruptable power supply (AC/DC)	3.5
K6.09	Thermal-hydraulic instability	3.9

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Average Power Range Monitor/Local Power Range Monitor System, including:
(CFR: 41.5 / 45.5)

A1.01	Reactor power indication	4.3
A1.02	RPS status	4.2
A1.03	Control rod block status	3.9
A1.04	SCRAM and rod block trip setpoints	4.0
A1.05	Lights and alarms	3.8
A1.06	Recirculation flow control valve position (BWR 5, 6)	3.6
A1.07	APRM (gain adjustment factor)	3.7
A1.08	LPRM, APRM, or OPRM channel bypass status	3.7

A2 Ability to (a) predict the impacts of the following on the Average Power Range Monitor/Local Power Range Monitor System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Power supply degradation	3.3	3.1
A2.02	Upscale or downscale trips	4.1	3.9
A2.03	Inoperable trip	4.1	3.9
A2.04	SCRAM trip signals	4.4	4.3
A2.05	Loss of recirculation flow signal	4.0	3.9
A2.06	Recirculation flow channels upscale	3.8	3.8

System: 215005 SF7 Average Power Range Monitor/Local Power Range Monitor System

A2.07	Recirculation flow channels flow mismatch	3.8	3.5
A2.08	Faulty or erratic operation of detectors/systems	3.5	3.4
A2.09	DELETED		
A2.10	Changes in void concentration	3.3	2.9
A2.11	Recirculation vortex event	3.3	2.7
A2.12	Operation of the OPRM-enabled region of the power to flow map	4.0	3.9
A2.13	Thermal-hydraulic instability	4.0	4.0

A3 Ability to monitor automatic operation of the Average Power Range Monitor/Local Power Range Monitor System system, including:
(CFR: 41.7 / 45.7)

A3.01	Four rod display	3.6	
A3.02	DELETED		
A3.03	Meters and recorders	3.6	
A3.04	DELETED		
A3.05	Flow converter/comparator signals	3.2	
A3.06	Maximum disagreement between flow comparator channels	3.2	
A3.07	DELETED		
A3.08	DELETED		

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	IRM/APRM recorder	3.7	
A4.02	DELETED		
A4.03	APRM back panel switches, meters, and indicating lights	3.6	
A4.04	LPRM back panel switches, meters, and indicating lights	3.4	
A4.05	Trip bypasses	3.7	
A4.06	DELETED		
A4.07	OPRM back panel switches, and indicating lights	3.6	

System: 215003 SF7 IRM Intermediate Range Monitor System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Intermediate Range Monitor System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	RPS	4.3
K1.02	Reactor manual control system (BWR 2, 3, 4, 5)	3.9
K1.03	RCIS (BWR 6)	4.0
K1.04	Plant process computer/parameter display systems	3.0
K1.05	Display control system	3.2
K1.06	APRM system	3.7
K1.07	Reactor vessel and internals	3.0
K1.08	SRMS	3.3
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	IRM channels/detectors	3.4
K3	Knowledge of the effect that a loss or malfunction of the Intermediate Range Monitor System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	RPS	4.2
K3.02	Reactor manual control	3.8
K3.03	RCIS (BWR 6)	3.9
K3.04	Reactor power indication	4.0
K3.05	APRM system	3.4
K4	Knowledge of Intermediate Range Monitor System design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Rod withdrawal blocks	4.0
K4.02	Reactor SCRAM signals	4.2
K4.03	Gamma compensation	2.6
K4.04	Ranging IRMs	3.8
K4.05	Changing detector position	3.6
K4.06	Alarm seal-in	2.9
K4.07	Bypassing an IRM channel	3.6
K4.08	SRMS-IRM overlap	3.5

System: 215003 SF7 IRM Intermediate Range Monitor System

K4.09	IRM-APRM overlap	3.6
K4.10	Automatically bypassing IRM rod block signals	3.6
K4.11	Automatically bypassing IRM SCRAM signals	3.6
K4.12	IRM inoperable	3.7

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Intermediate Range Monitor System:
(CFR: 41.5 / 45.3)

K5.01	Detector operation	3.0
K5.02	Gamma discrimination	2.6
K5.03	Changing detector position	3.3
K5.04	Reactor power indication response to rod position changes	3.8
K5.05	Downscale	3.7
K5.06	Inoperable	3.7
K5.07	High or upscale	3.8

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Intermediate Range Monitor System:
(CFR: 41.7 / 45.7)

K6.01	Reactor protection system (power supply)	3.7
K6.02	24/48 volt DC power	3.6
K6.03	Detector drive motor	2.9
K6.04	Detectors	3.2
K6.05	Trip units	3.4
K6.06	DELETED	
K6.07	Recorder	2.9
K6.08	Changing mode switch position	3.8

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Intermediate Range Monitor System, including:
(CFR: 41.5 / 45.5)

A1.01	Detector position	3.2
A1.02	Reactor power	4.1
A1.03	Reactor SCRAM signals	4.0
A1.04	Control rod block status	3.9
A1.05	SCRAM and rod block trip setpoints	3.9

System: 215003 SF7 IRM Intermediate Range Monitor System

A1.06	Lights and alarms		3.6
A1.07	Range		3.7
A1.08	IRM back panel switches		3.1
A2	Ability to (a) predict the impacts of the following on the Intermediate Range Monitor System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations: (CFR: 41.5 / 43.5 / 45.6)	RO	SRO
A2.01	Power supply degradation	3.1	3.0
A2.02	IRM inoperable condition	3.9	3.7
A2.03	Stuck detector	3.3	3.0
A2.04	Upscale or downscale trips	4.0	3.8
A2.05	Faulty or erratic operation of detectors/system	3.6	3.2
A2.06	Faulty range switch	3.4	3.2
A2.07	Failed recorder	3.0	2.8
A2.08	Improper overlap	3.8	3.5
A3	Ability to monitor automatic operation of the Intermediate Range Monitor System, including: (CFR: 41.7 / 45.7)		
A3.01	Meters and recorders		3.6
A3.02	DELETED		
A3.03	SCRAM signals		4.1
A3.04	Control rod block signals		3.9
A4	Ability to manually operate and/or monitor in the control room: (CFR: 41.7 / 45.5 to 45.8)		
A4.01	IRM recorder indication		3.6
A4.02	DELETED		
A4.03	IRM range switches		3.9
A4.04	IRM back panel switches, meters, and indicating lights		3.2
A4.05	Trip bypasses		3.5
A4.06	Detector drives		3.4
A4.07	DELETED		

System: 216000 SF7 NBI Nuclear Boiler Instrumentation

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Nuclear Boiler Instrumentation and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	RPS	4.1
K1.02	PCIS/NSSSS	4.1
K1.03	RCIC	4.0
K1.04	HPCS	4.0
K1.05	RHR system	4.0
K1.06	LPCS system	4.0
K1.07	ADS	4.1
K1.08	SRVs	3.7
K1.09	DELETED	
K1.10	Recirculation flow control system	3.5
K1.11	MSIV leakage control system	2.9
K1.12	Reactor water level control system	4.0
K1.13	Feedwater system	3.6
K1.14	High-pressure coolant injection system	4.1
K1.15	Isolation (emergency) condenser	4.2
K1.16	Main turbine generator and auxiliary systems	3.1
K1.17	Emergency generators (BWR 2)	3.7
K1.18	Analog trip system	3.6
K1.19	ATWS-alternate rod insertion (ARI) system	3.9
K1.20	Plant process computer/parameter display systems	3.1
K1.21	DELETED	
K1.22	Reactor vessel and internals	3.1
K1.23	Recirculation system	3.4
K1.24	RWCU	3.4
K1.25	Primary containment system and auxiliaries	3.4
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Analog trip system	3.6
K3	Knowledge of the effect that a loss or malfunction of the Nuclear Boiler Instrumentation will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	RPS	4.1

System: 216000 SF7 NBI Nuclear Boiler Instrumentation

K3.02	PCIS/NSSSS	4.1
K3.03	RCIC	4.0
K3.04	HPCI	4.1
K3.05	RHR system	4.0
K3.06	LPCS	4.0
K3.07	ADS	4.0
K3.08	SRVs	3.8
K3.09	Redundant reactivity control	3.6
K3.10	Recirculation flow control system	3.4
K3.11	MSIV leakage control system	2.9
K3.12	Reactor water level control system	3.9
K3.13	Feedwater system	3.5
K3.14	HPCI	4.1
K3.15	Isolation (emergency) condenser	4.1
K3.16	Main turbine generator and auxiliary systems	3.1
K3.17	Emergency generators (BWR 2)	3.6
K3.18	Analog trip system	3.7
K3.19	ATWS-alternate rod insertion (ARI) system	3.8
K3.20	Plant process computer/parameter display systems	3.0
K3.21	DELETED	
K3.22	Reactor vessel and internals	3.1
K3.23	Vessel temperature	3.0
K3.24	Vessel level	3.7
K3.25	Vessel pressure	3.6
K3.26	Core flow	3.5
K3.27	Core differential pressure	3.3
K3.28	DELETED	
K3.29	Jet pump flow	3.3
K3.30	Recirculation system	3.4
K3.31	Remote shutdown system	3.2

**K4 Knowledge of Nuclear Boiler Instrumentation design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Reading of nuclear boiler parameters outside the control room	3.3
K4.02	Physical separation of sensors	3.2
K4.03	DELETED	
K4.04	Inputs to the RPS	4.0
K4.05	Initiation of the ECCS	4.1
K4.06	Initiation of the PCIS/NSSSS	4.1

System: 216000 SF7 NBI Nuclear Boiler Instrumentation

K4.07	Recirculation pump protection	3.5
K4.09	Protection against filling the main steam lines from the feed system	3.3
K4.10	Automatic recirculation pump speed control	3.2
K4.11	Inputs to the redundant reactivity control system/alternate rod insertion	3.4
K4.12	Reactor vessel overpressure protection	3.6
K4.13	Overpressure protection for various low-pressure systems	3.3
K4.14	Temperature compensation for reactor water level indication	3.1
K4.15	Level/pressure channel ranges	3.3
K4.16	RPV level instrumentation design calibration conditions	3.3

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Nuclear Boiler Instrumentation:
(CFR: 41.5 / 45.3)

K5.01	Vessel level measurement	3.9
K5.02	Vessel pressure measurement	3.8
K5.03	Vessel temperature measurement	3.3
K5.04	Vessel differential pressure measurement	3.0
K5.05	DELETED	
K5.06	Rapid vessel depressurization effects on vessel level indications	4.0
K5.07	Elevated containment temperature effects on level indication	3.8
K5.08	Steam flow effect on reactor water level	3.5
K5.09	Recirculation flow effects on level indications	3.4
K5.10	Indicated level versus actual vessel level during vessel heatups or cooldowns	3.5
K5.11	Indicated vessel temperature response during rapid heatups or cooldowns	3.4
K5.12	Effects on level indication due to rapid changes in void fraction	3.5
K5.13	Reference leg flashing	3.8
K5.14	Density compensation	3.2
K5.15	DELETED	
K5.16	DELETED	

System: 216000 SF7 NBI Nuclear Boiler Instrumentation

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Nuclear Boiler Instrumentation:
(CFR: 41.7 / 45.7)

K6.01	AC electrical distribution	3.4
K6.02	DC electrical distribution	3.4
K6.03	RPV temperature/pressure changes	3.5
K6.04	Transmitters	3.3
K6.05	Instrument channels	3.3
K6.06	Reference leg or condensing pot	3.5
K6.07	Loss of a recirculation pump	3.1

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Nuclear Boiler Instrumentation, including:
(CFR: 41.5 / 45.5)

A1.01	DELETED	
A1.02	Removing or returning a sensor (transmitter) to service	3.1
A1.03	Surveillance testing	3.0
A1.04	System venting	3.0
A1.05	Lights and alarms	3.3
A1.06	RPV pressure	3.8
A1.07	RPV level	3.8
A1.08	RPV temperature	3.4

A2 Ability to (a) predict the impacts of the following on the Nuclear Boiler Instrumentation and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Detector malfunctions	3.7	3.5
A2.02	DELETED		
A2.03	DELETED		
A2.04	DELETED		
A2.05	DELETED		
A2.06	Loss of power supply	3.3	3.4
A2.07	DELETED		
A2.08	Elevated containment temperature	3.4	3.4
A2.09	Jet pump malfunction	3.8	3.3
A2.10	DELETED		

System: 216000 SF7 NBI Nuclear Boiler Instrumentation

A2.11	DELETED		
A2.12	DELETED		
A2.13	DELETED		
A2.14	Partial or complete loss of recirculation flow	3.6	3.3
A3	Ability to monitor automatic operation of the Nuclear Boiler Instrumentation, including: (CFR: 41.7 / 45.7)		
A3.01	DELETED		
A4	Ability to manually operate and/or monitor in the control room: (CFR: 41.7 / 45.5 to 45.8)		
A4.01	DELETED		
A4.02	Channel select controls		3.2
A4.03	Plant process computer/parameter display systems		3.0
A4.04	Analog trip units		3.3

System: 272000 SF7 RMS Radiation Monitoring System

K/A NO. KNOWLEDGE IMPORTANCE

K1 Knowledge of the physical connections and/or cause and effect relationships between the Radiation Monitoring System and the following systems:
(CFR: 41.2 to 41.9 / 45.7 to 45.8)

K1.01	Main steam system	3.6
K1.02	Offgas system (augmented offgas)	3.7
K1.03	Stack gas	3.7
K1.04	Component cooling water system	3.0
K1.05	Radwaste system	2.9
K1.06	Reactor building ventilation system	3.6
K1.07	Isolation condenser	3.3
K1.08	DELETED	
K1.09	Primary containment isolation system	3.9
K1.10	Fuel handling systems	3.4
K1.11	DELETED	
K1.12	DELETED	
K1.13	DELETED	
K1.14	DELETED	
K1.15	DELETED	
K1.16	Plant process computer/parameter display systems	3.0
K1.17	DELETED	
K1.18	Primary/secondary containment	3.6
K1.19	DELETED	
K1.20	DELETED	
K1.21	DELETED	
K1.22	DELETED	
K1.23	Continuous air monitoring/ post-accident air monitoring systems	3.3
K1.24	Plant ventilation system	3.4
K1.25	Standby gas treatment	3.8
K1.26	Safety-related service water system	3.2

K2 Knowledge of electrical power supplies to the following:
(CFR: 41.7)

K2.01	DELETED	
K2.02	DELETED	
K2.03	DELETED	
K2.04	Process radiation monitoring system	2.8
K2.05	DELETED	

System: 272000 SF7 RMS Radiation Monitoring System

K2.06	Area radiation monitors	2.6
K2.07	DELETED	
K2.08	Continuous air monitoring/post-accident air monitoring systems	2.7

K3 Knowledge of the effect that a loss or malfunction of the Radiation Monitoring System will have on the following systems or system parameters:
(CFR: 41.5 / 45.3)

K3.01	Liquid effluent release monitoring	3.4
K3.02	Gaseous effluent release monitoring	3.6
K3.03	Area radiation monitoring	3.1
K3.04	Main steam system	3.2
K3.05	Offgas system	3.6
K3.06	Plant ventilations systems	3.3
K3.07	DELETED	
K3.08	DELETED	
K3.09	DELETED	
K3.10	DELETED	
K3.11	Standby gas treatment system	3.6
K3.12	Safety-related service water system	3.0
K3.13	Continuous air monitoring/post-accident air monitoring systems	2.9

K4 Knowledge of Radiation Monitoring System design features and/or interlocks that provide for the following:
(CFR: 41.7)

K4.01	DELETED	
K4.02	System isolations/initiations	4.1
K4.03	Fail-safe tripping of process radiation monitoring logic during conditions of instrument failure	3.5
K4.04	Process radiation monitoring surveillance testing	2.7

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Radiation Monitoring System:
(CFR: 41.7 / 45.4)

K5.01	Effect of hydrogen injection operation on process radiation indications	3.3
K5.02	Trends in radiation levels	3.3

System: 272000 SF7 RMS Radiation Monitoring System

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Radiation Monitoring System:
(CFR: 41.7 / 45.7)**

K6.01	DELETED	
K6.02	DC power	3.0
K6.03	AC power	3.1
K6.04	Plant process computer/parameter display systems	2.7
K6.05	DELETED	
K6.06	Continuous air monitoring/post-accident radiation monitoring system	2.9

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Radiation Monitoring System, including:
(CFR: 41.5 / 45.5)**

A1.01	Lights and alarms	3.4
A1.02	DELETED	
A1.03	Radiations levels	3.7
A1.04	Sample flows	2.8

**A2 Ability to (a) predict the impacts of the following on the Radiation Monitoring System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6)**

		RO	SRO
A2.01	Fuel element failure	4.1	4.2
A2.02	DELETED		
A2.03	AC electrical failure	3.1	3.3
A2.04	DC electrical failure	2.9	3.2
A2.05	Loss of dilution steam	2.9	2.8
A2.06	Downscale trips	3.0	3.1
A2.07	Hydrogen injection operation	3.4	3.0
A2.08	Offgas system failure	3.5	3.4
A2.09	Low fuel pool level	3.7	3.6
A2.10	Loss of coolant accident	4.2	4.0
A2.11	Leakage or breaks from contaminated systems to atmosphere or to other process systems	3.9	3.7
A2.12	Refuel floor handling accidents/operations	3.9	4.0
A2.13	Low reactor water level during refueling operations	3.9	3.7
A2.14	Loss of, or inadequate, shielding	3.4	3.5
A2.15	DELETED		

System: 272000 SF7 RMS Radiation Monitoring System

A2.16	Instrument malfunctions	2.9	3.0
A2.17	Plant ventilation systems abnormal radiation levels	3.4	3.3

**A3 Ability to monitor automatic operation of the Radiation Monitoring System, including:
(CFR: 41.7 / 45.7)**

A3.01	Main steam radiation alarms	3.5	
A3.02	DELETED		
A3.03	DELETED		
A3.04	DELETED		
A3.05	DELETED		
A3.06	DELETED		
A3.07	DELETED		
A3.08	DELETED		
A3.09	Containment isolation	4.1	
A3.10	DELETED		
A3.11	DELETED		
A3.12	Process radiation monitor isolations	3.6	

**A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)**

A4.01	Radiation monitoring system recorders	3.3	
A4.02	Meter indications	3.2	
A4.03	DELETED		
A4.04	Plant process computer/parameter display systems	3.2	
A4.05	Process radiation monitor	3.3	
A4.06	Process radiation monitor logic	2.9	

System: 212000 SF7 RPS Reactor Protection System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Reactor Protection System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Nuclear instrumentation	4.3
K1.02	Nuclear boiler instrumentation	4.1
K1.03	DELETED	
K1.04	DELETED	
K1.05	Process radiation monitoring system	3.2
K1.06	Control rod drive hydraulic system	3.9
K1.07	DELETED	
K1.08	DELETED	
K1.09	Plant process computer/parameter display systems	2.8
K1.10	Main turbine generator and auxiliary systems	3.5
K1.11	Condensate system	2.4
K1.12	Reactor/turbine pressure regulating system	3.5
K1.13	Primary containment and auxiliaries	3.6
K1.14	Main steam system	3.6
K1.15	DELETED	
K1.16	RCIS (BWR 6)	3.4
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	RPS motor-generator sets	3.8
K2.02	RPS logic	4.1
K2.03	RPS alternate power supplies	3.9
K3	Knowledge of the effect that a loss or malfunction of the Reactor Protection System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Process radiation monitoring	3.1
K3.02	PCIS/NSSSS	3.9
K3.03	Nuclear instrumentation	3.7
K3.04	DELETED	
K3.05	DELETED	
K3.06	SCRAM air header solenoid-operated valves	4.1
K3.07	Reactor power	4.1
K3.08	DELETED	
K3.09	DELETED	

System: 212000 SF7 RPS Reactor Protection System

K3.10 DELETED
K3.11 DELETED
K3.12 DELETED

**K4 Knowledge of Reactor Protection System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01 DELETED
K4.02 DELETED
K4.03 Transferring RPS power supplies 3.7
K4.04 DELETED
K4.05 DELETED
K4.06 DELETED
K4.07 Manual SCRAM 4.2
K4.08 SCRAM reset time delay 3.3
K4.09 DELETED
K4.10 Individual rod testing 3.2
K4.11 DELETED
K4.12 Bypassing SCRAM signals 3.8
K4.13 Underfrequency, overvoltage, and undervoltage protection 3.5

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Reactor Protection System:
(CFR: 41.5 / 45.3)**

K5.01 DELETED
K5.02 Logic channel arrangements 4.1

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Reactor Protection System:
(CFR: 41.7 / 45.7)**

K6.01 AC electrical distribution 3.9
K6.02 Nuclear instrumentation 4.0
K6.03 Nuclear boiler instrumentation 3.9
K6.04 DC electrical distribution 3.4
K6.05 DELETED
K6.06 Process radiation monitoring system 3.0
K6.07 Control rod drive hydraulic system 3.3
K6.08 Main turbine generator and auxiliaries systems 3.3

System: 212000 SF7 RPS Reactor Protection System

K6.09	Condensate system	2.5
K6.10	Reactor/turbine pressure regulating system	3.5
K6.11	Primary containment and auxiliaries	3.5
K6.12	Main steam system	3.5

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Reactor Protection System, including:
(CFR: 41.5 / 45.5)

A1.01	DELETED	
A1.02	DELETED	
A1.03	DELETED	
A1.04	RPS bus status	3.7
A1.05	DELETED	
A1.06	DELETED	
A1.07	DELETED	
A1.08	Valve position	3.6
A1.09	DELETED	
A1.10	DELETED	
A1.11	Lights and alarms	3.7

A2 Ability to (a) predict the impacts of the following on the Reactor Protection System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6)

		RO	SRO
A2.01	RPS motor-generator set failure	3.9	3.9
A2.02	RPS bus power supply failure	4.0	3.9
A2.03	DELETED		
A2.04	Nuclear instrument system failure	4.0	4.0
A2.05	Nuclear boiler instrument system failure	3.9	3.9
A2.06	High reactor power	4.2	4.3
A2.07	High reactor pressure	4.3	4.4
A2.08	Low reactor level	4.3	4.4
A2.09	High containment/drywell pressure	4.3	4.3
A2.10	Reactor/turbine pressure regulating system low hydraulic pressure	4.1	4.0
A2.11	Main steamline isolation valve closure	4.1	4.1
A2.12	Main turbine stop/control valve closure	4.1	4.1
A2.13	Low condenser vacuum	4.1	3.9
A2.14	High SCRAM discharge instrument volume water level	4.2	4.1
A2.15	Load rejection	3.9	3.8

System: 212000 SF7 RPS Reactor Protection System

A2.16	Mode switch malfunction or misposition	4.0	4.1
A2.17	Main steamline high radiation	3.1	3.0
A2.18	SCRAM air header low pressure	3.9	3.9
A2.19	Partial RPS actuation	4.2	3.9
A2.20	Full RPS actuation	4.3	4.1
A2.21	DELETED		

**A3 Ability to monitor automatic operation of the Reactor Protection System, including:
(CFR: 41.7 / 45.7)**

A3.01	DELETED		
A3.02	DELETED		
A3.03	DELETED		
A3.04	DELETED		
A3.05	DELETED		
A3.06	DELETED		
A3.07	DELETED		
A3.08	DELETED		
A3.09	System actuation	4.3	
A3.10	Bypassing SCRAM signals	3.8	

**A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)**

A4.01	System actuation	4.3	
A4.02	DELETED		
A4.03	DELETED		
A4.04	Bypass SCRAM signals	3.7	
A4.05	DELETED		
A4.06	DELETED		
A4.07	DELETED		
A4.08	DELETED		
A4.09	DELETED		
A4.10	DELETED		
A4.11	DELETED		
A4.12	DELETED		
A4.13	Individual control rod SCRAM testing	3.2	
A4.14	System reset	3.8	
A4.15	DELETED		
A4.16	DELETED		
A4.17	DELETED		
A4.18	Transferring RPS power supplies	3.6	

System: 215002 SF7 RBMS Rod Block Monitor System (BWR 3, 4, 5)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Rod Block Monitor System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	APRM	3.8
K1.02	LPRM	3.7
K1.03	Reactor manual control system	3.7
K1.04	Reactor recirculation system	3.4
K1.05	DELETED	
K1.06	DELETED	
K1.07	DELETED	
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	RBMS channels	3.1
K2.02	DELETED	
K2.03	DELETED	
K3	Knowledge of the effect that a loss or malfunction of the Rod Block Monitor System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor manual control system	3.9
K3.02	DELETED	
K4	Knowledge of Rod Block Monitor System design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Rod withdrawal blocks	3.9
K4.02	Allows manual or automatic setup of rod block setpoints during power ascension	3.4
K4.03	Initiation point (30-percent)	3.3
K4.04	Automatic setdown of rod block setpoints during power reduction	3.2
K4.05	Automatic and manual bypass of an RBMS channel	3.3
K4.06	Transfer to alternate APRM when referenced APRM is bypassed	3.4

System: 215002 SF7 RBMS Rod Block Monitor System (BWR 3, 4, 5)

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Rod Block Monitor System:
(CFR: 41.5 / 45.3)

K5.01	Trip reference selection	2.8
K5.02	Null sequence control	2.8
K5.03	Control rod selection	3.3

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Rod Block Monitor System:
(CFR: 41.7 / 45.7)

K6.01	RBMS power supply	3.0
K6.02	DELETED	
K6.03	DELETED	
K6.04	APRM reference channel	3.3
K6.05	LPRM detectors	3.2
K6.06	Reactor recirculation system	3.2

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Rod Block Monitor System, including:
(CFR: 41.5 / 45.5)

A1.01	Trip reference	3.0
A1.02	Reactor power	3.5
A1.03	Control rod block status	3.7
A1.04	Lights and alarms	3.2
A1.05	Meters and recorders	3.2

A2 Ability to (a) predict the impacts of the following on the Rod Block Monitor System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Withdrawal of control rod in high power region of core	3.8	3.6
A2.02	Loss or reduction in reactor recirculation system flow (flow comparator)	3.5	3.5
A2.03	Loss of associated reference APRM channel	3.3	3.4
A2.04	Loss of electrical power	2.8	3.2
A2.05	RBMS upscale, downscale, or inoperable	4.0	3.5
A2.06	Loss of associated LPRM detector(s)	3.5	3.2

System: 215002 SF7 RBMS Rod Block Monitor System (BWR 3, 4, 5)

A3 Ability to monitor automatic operation of the Rod Block Monitor System, including:

(CFR: 41.7 / 45.7)

A3.01	DELETED	
A3.02	DELETED	
A3.03	DELETED	
A3.04	DELETED	
A3.05	DELETED	
A3.06	Transfer to alternate APRM when referenced is APRM bypassed	2.8
A3.07	RBMS initiation (30-percent)	3.2
A3.08	Rod withdrawal blocks	3.7
A3.09	Setup of rod block setpoints during power ascension	3.1
A3.10	Setdown of rod block setpoints during power reduction	3.1
A3.11	RBMS channel bypass	3.2

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

A4.01	IRM/RBMS recorder/switch	3.0
A4.02	RBMS back panel switches, meters, and indicating lights	2.9
A4.03	Trip/channel bypasses	3.2
A4.04	"Push to Check" pushbutton	2.8
A4.05	"Setup" pushbutton	2.8
A4.06	DELETED	

System: 201005 SF7 RCIS Rod Control and Information System (BWR 6)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Rod Control and Information System and the following systems: (CFR: 41.2 to 41.7 / 45.8)	
K1.01	APRM/LPRM system	3.9
K1.02	Reactor/turbine pressure regulating system	3.5
K1.03	Control rod drive hydraulic system	3.7
K1.04	DELETED	
K1.05	DELETED	
K1.06	DELETED	
K1.07	DELETED	
K1.08	Intermediate range monitor system	3.6
K1.09	Source range monitor system	3.6
K1.10	Control rod and drive mechanism system	3.6
K1.11	Recirculation flow control system	3.2
K1.12	Fuel handling system	3.0
K2	Knowledge of electrical power supplies to the following: (CFR: 41.6 / 41.7)	
K2.01	RCIS	3.3
K3	Knowledge of the effect that a loss or malfunction of the Rod Control and Information System will have on the following systems or system parameters: (CFR: 41.6 and 41.7 / 45.4–45.6)	
K3.01	Control rod drive hydraulic system	3.4
K3.02	DELETED	
K3.03	DELETED	
K3.04	Flux shaping	3.1
K3.05	Control rod drive mechanism system	3.1
K3.06	Fuel handling system	3.0
K3.07	Reactor protection system	3.4
K4	Knowledge of Rod Control and Information System design features and/or interlocks that provide for the following: (CFR: 41.5–41.7)	
K4.01	Limiting the effects of a control rod accident	3.9
K4.02	Bank position withdrawal sequence	3.7

System: 201005 SF7 RCIS Rod Control and Information System (BWR 6)

K4.03	Rod withdrawal block signals	4.0
K4.04	Rod insertion block signals	3.9
K4.05	Rod withdrawal limiter	3.8
K4.06	DELETED	
K4.07	RPIS	3.9
K4.08	RACS	3.5
K4.09	Rod gang drive	3.5
K4.10	Rod interface system	3.6
K4.11	Rod pattern controller	3.8
K4.12	Rod withdrawal limiter	3.8
K4.13	Temperature monitoring	2.7

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Rod Control and Information System:
(CFR: 41.5–41.7 / 45.3 / 45.5)

K5.01	DELETED	
K5.02	DELETED	
K5.03	Rod groups	3.3
K5.04	Rod sequences	3.7
K5.05	DELETED	
K5.06	Target rod pattern	3.3
K5.07	Low-power alarm point	3.3
K5.08	Transition zone	3.2
K5.09	High-power setpoints	3.7
K5.10	DELETED	
K5.11	Control rod motion	3.8
K5.12	RACS channel agreement and multiplexing	3.4
K5.13	Position indication	3.8
K5.14	Low-power setpoint	3.6
K5.15	Changes in reactor power	4.2

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Rod Control and Information System:
(CFR: 41.7 / 45.7)

K6.01	First stage shell pressure or opening of a bypass valve(s)	3.8
K6.02	Rod position signal	3.7
K6.03	AC electrical distribution system	3.3
K6.04	Intermediate range monitor system	3.7

System: 201005 SF7 RCIS Rod Control and Information System (BWR 6)

K6.05	Source range monitor system	3.7
K6.06	APRM/LPRM system	3.7
K6.07	Fuel handling system	3.1
K6.08	Gang misalignment	2.7

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Rod Control and Information System, including:
(CFR: 41.5 / 45.5)

A1.01	First stage shell pressure/turbine load	3.5
A1.02	Reactor power	4.1
A1.03	Lights and alarms	3.6

A2 Ability to (a) predict the impacts of the following on the Rod Control and Information System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6 / 45.8)

		RO	SRO
A2.01	High flux (SRM, IRM, APRM)	4.3	4.0
A2.02	Position indication probe failure	3.3	3.9
A2.03	Insert block	3.4	3.7
A2.04	Withdraw block	3.7	3.8
A2.05	Insert required	3.4	3.4
A2.06	Insert inhibit	3.3	3.7
A2.07	Withdraw inhibit	3.3	3.7
A2.08	LPRM upscale/downscale	3.3	3.5
A2.09	Test display blinking	2.7	2.9
A2.10	Data fault	2.9	3.4
A2.11	DELETED		
A2.12	DELETED		
A2.13	Rod drift	4.4	4.2
A2.14	AC electrical distribution system malfunction	3.4	3.4
A2.15	Fuel handling system malfunction	3.1	3.3
A2.16	Gang misalignment	2.7	2.8

A3 Ability to monitor automatic operation of the Rod Control and Information System, including:
(CFR: 41.7 / 45.7)

A3.01	Operator control module lights	3.6
A3.02	Rod display module lights	3.7
A3.03	Verification of proper functioning/operability	3.9
A3.04	DELETED	

System: 201005 SF7 RCIS Rod Control and Information System (BWR 6)

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

A4.01	Operator control module (lights and push buttons)	3.8
A4.02	Rod display module (lights and push buttons)	3.7
A4.03	Back panel indicating lights	3.3
A4.04	Bypassing rod position in RACS	3.7
A4.05	Bypassing a rod drive in rod gang drive system	3.6

System: 214000 SF7 RPIS Rod Position Information System (BWR 2, 3, 4, 5)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Rod Position Information System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Rod worth minimizer	3.6
K1.02	Rod sequence control system	3.4
K1.03	Control rod drive mechanism	3.3
K1.04	Reactor manual control system	3.7
K1.05	DELETED	
K1.06	DELETED	
K1.07	Plant process computer/parameter display systems	3.1
K1.08	DELETED	
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	RPIS	3.0
K3	Knowledge of the effect that a loss or malfunction of the Rod Position Information System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Rod worth minimizer	3.4
K3.02	Rod sequence control system	3.2
K3.03	Reactor manual control system	3.6
K3.04	DELETED	
K3.05	Plant process computer/parameter display systems	2.9
K3.06	DELETED	
K4	Knowledge of Rod Position Information System design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Reed switch locations	3.2
K4.02	DELETED	
K4.03	Control rod position indication	3.6
K4.04	Detection of a drifting control rod	3.9
K4.05	Detection of an uncoupled control rod	4.0

System: 214000 SF7 RPIS Rod Position Information System (BWR 2, 3, 4, 5)

K5

Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Rod Position Information System:
(CFR: 41.5 / 45.3)

K5.01 Rod position indication failures 3.5

K6

Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Rod Position Information System:
(CFR: 41.7 / 45.7)

K6.01 RPIS power supply 3.2
K6.02 DELETED

A1

Ability to predict and/or monitor changes in parameters associated with operation of the Rod Position Information System, including:
(CFR: 41.5 / 45.5)

A1.01 Control rod position 3.8
A1.02 Lights and alarms 3.6

A2

Ability to (a) predict the impacts of the following on the Rod Position Information System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Failed reed switches	3.3	3.3
A2.02	DELETED		
A2.03	DELETED		
A2.04	Power supply loss	3.3	3.3

A3

Ability to monitor automatic operation of the Rod Position Information System, including:
(CFR: 41.7 / 45.7)

A3.01 DELETED
A3.02 DELETED
A3.03 DELETED
A3.04 DELETED

System: 214000 SF7 RPIS Rod Position Information System (BWR 2, 3, 4, 5)

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01 DELETED

A4.02 DELETED

A4.03 DELETED

System: 201004 SF7 RSCS Rod Sequence Control System (BWR 4, 5)

K/A NO. KNOWLEDGE IMPORTANCE

K1 Knowledge of the physical connections and/or cause and effect relationships between the Rod Sequence Control System and the following systems:
(CFR: 41.2 to 41.9 / 45.7 to 45.8)

K1.01	Reactor manual control system	3.5
K1.02	Main turbine generator and auxiliary systems	2.3
K1.03	RPIS	3.4
K1.04	DELETED	

K2 Knowledge of electrical power supplies to the following:
(CFR: 41.7)

K2.01	RSCS logic power	2.7
-------	------------------	-----

K3 Knowledge of the effect that a loss or malfunction of the Rod Sequence Control System will have on the following systems or system parameters:
(CFR: 41.7 / 45.4)

K3.01	Reactor manual control system	3.5
-------	-------------------------------	-----

K4 Knowledge of Rod Sequence Control System design features and/or interlocks that provide for the following:
(CFR: 41.7)

K4.01	Select blocks	3.4
K4.02	Insert rod blocks	3.4
K4.03	Withdraw rod blocks	3.4
K4.04	RSCS bypass as reactor power increases	3.1
K4.05	Rod movement, direction, and selection information	3.3
K4.06	Group notch control	3.1
K4.07	Minimizing rod worth	3.2
K4.08	Sequence control	3.3

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Rod Sequence Control System:
(CFR: 41.5 / 45.3)

K5.01	Limiting the impacts of a control rod drop accident	3.5
-------	---	-----

System: 201004 SF7 RSCS Rod Sequence Control System (BWR 4, 5)

K5.02	Sequences and groups	3.1	
K5.03	Group notch control limits and rod density	3.1	

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Rod Sequence Control System:
(CFR: 41.7 / 45.7)**

K6.01	Rod position information	3.5	
K6.02	Rod direction information	3.3	
K6.03	Rod movement information	3.4	
K6.04	Turbine generator (1 st stage shell pressure)	2.9	

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Rod Sequence Control System, including:
(CFR: 41.5 / 45.5)**

A1.01	DELETED		
A1.02	Select blocks	3.2	
A1.03	Insert blocks	3.4	
A1.04	Withdraw blocks	3.5	
A1.05	Lights and alarms	3.2	
A1.06	Rod select switch light	3.1	
A1.07	Rod select bottom lamp dimmer logic	2.9	
A1.08	Back panel indicators	2.4	

**A2 Ability to (a) predict the impacts of the following on the Rod Sequence Control System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	Loss of rod position information	3.6	3.6
A2.02	Stuck control rod	2.8	3.7
A2.03	Turbine trip	2.3	2.7

**A3 Ability to monitor automatic operation of the Rod Sequence Control System, including:
(CFR: 41.7 / 45.7)**

A3.01	DELETED		
A3.02	DELETED		
A3.03	DELETED		
A3.04	DELETED		
A3.05	DELETED		

System: 201004 SF7 RSCS Rod Sequence Control System (BWR 4, 5)

A3.06	Select blocks	3.3
A3.07	Control rod blocks	3.4
A3.08	System bypass	3.1

**A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)**

A4.01	System bypass switches	3.3
A4.02	RSCS console switches and indicators	3.3
A4.03	RSCS back panel switches and indicators	2.7

System: 201006 SF7 RWMS Rod Worth Minimizer System (BWR 2, 3, 4, 5)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Rod Worth Minimizer System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Reactor manual control system	3.7
K1.02	RPIS	3.7
K1.03	Reactor water level control (feed flow/steam flow)	3.2
K1.04	DELETED	
K1.05	DELETED	
K1.06	DELETED	
K1.07	Process computer	2.9
K1.08	DELETED	
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Rod worth minimizer	2.8
K3	Knowledge of the effect that a loss or malfunction of the Rod Worth Minimizer System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Reactor manual control system	3.7
K3.02	Rod pattern limit	3.6
K4	Knowledge of Rod Worth Minimizer System design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Insert blocks/errors	3.7
K4.02	Withdraw blocks/errors	3.8
K4.03	Select blocks/errors	3.5
K4.04	System bypass	3.4
K4.05	Substitute rod position data	3.3
K4.06	Correction of out-of-sequence rod positions	3.5
K4.07	Display of out-of-position control rods without rod blocks (transition zone)	3.3
K4.08	System testing	2.8
K4.09	System initialization	2.8

System: 201006 SF7 RWMS Rod Worth Minimizer System (BWR 2, 3, 4, 5)

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Rod Worth Minimizer System:
(CFR: 41.5 / 45.3)**

K5.01	Limiting the impacts of a control rod drop accident	3.7
K5.02	Low-power set point	3.5
K5.03	Low-power alarm point	3.2
K5.04	Transition zone	3.1
K5.05	High-power set point	3.2
K5.06	Rod groups and steps	3.3
K5.07	Latch groups	3.2
K5.08	Rod pattern limits	3.3
K5.09	Select error	3.2
K5.10	Withdraw error	3.3
K5.11	Insert error	3.3
K5.12	Withdraw block	3.5
K5.13	Insert block	3.5
K5.14	Alternate withdraw and insert limits	3.2

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Rod Worth Minimizer System:
(CFR: 41.7 / 45.7)**

K6.01	RWMS power supply	3.0
K6.02	Reactor water level control input	3.0
K6.03	Rod position information	3.4
K6.04	Process computer	2.8
K6.05	DELETED	

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Rod Worth Minimizer System, including:
(CFR: 41.5 / 45.5)**

A1.01	Rod position	3.7
A1.02	DELETED	
A1.03	Latched group	3.3
A1.04	Rod withdrawal blocks	3.6
A1.05	Rod insert blocks	3.6
A1.06	Rod withdrawal errors	3.4
A1.07	Rod insert errors	3.3
A1.08	Rod select errors	3.2

System: 201006 SF7 RWMS Rod Worth Minimizer System (BWR 2, 3, 4, 5)

A1.09 Lights and alarms 3.3

A2 Ability to (a) predict the impacts of the following on the Rod Worth Minimizer System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.5 / 43.5 / 45.6)

RO SRO

A2.01	Power supply loss	3.3	3.0
A2.02	DELETED		
A2.03	Rod drift	3.9	3.6
A2.04	Stuck rod	3.6	3.4
A2.05	Out-of-sequence rod movement	3.9	3.7
A2.06	Loss of reactor water level control input (steam flow/feed flow)	3.3	3.0
A2.07	RWMS hardware/software failure	3.1	2.9
A2.08	Loss of rod position information	3.7	3.3
A2.09	Loss of process computer	3.3	3.0

A3 Ability to monitor automatic operation of the Rod Worth Minimizer System, including:

(CFR: 41.7 / 45.7)

A3.01	DELETED		
A3.02	DELETED		
A3.03	DELETED		
A3.04	Control rod movement blocks	3.8	
A3.05	Latching operation	3.3	
A3.06	System bypass	3.3	

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

A4.01	System bypass switch	3.4	
A4.02	Pushbutton indicating switches	3.2	
A4.03	DELETED		
A4.04	DELETED		
A4.05	DELETED		
A4.06	DELETED		
A4.07	Touch screen display	3.2	

System: 215004 SF7 SRMS Source Range Monitor System		
K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Source Range Monitor System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	RPS	3.5
K1.02	RMCS (BWR 2, 3, 4, 5)	3.5
K1.03	RCIS (BWR 6)	3.8
K1.04	DELETED	
K1.05	DELETED	
K1.06	Reactor vessel and internals	3.1
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	SRMS channels/detectors	3.3
K2.02	Detector drive modules	2.7
K2.03	Detector drive module control	2.6
K3	Knowledge of the effect that a loss or malfunction of the Source Range Monitor System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	RPS	3.5
K3.02	RMCS (BWR 2, 3, 4, 5)	3.5
K3.03	RCIS (BWR 6)	3.9
K3.04	Reactor power indication	4.0
K4	Knowledge of Source Range Monitor System design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Rod withdrawal blocks	3.9
K4.02	Reactor SCRAM signals	3.6
K4.03	Gamma compensation	2.7
K4.04	Changing detector position	3.4
K4.05	Alarm seal-in	2.7
K4.06	IRM/SRMS interlock	3.4
K4.07	SRMS channel bypass	3.4
K4.08	SRMS detector longevity	2.3

System: 215004 SF7 SRMS Source Range Monitor System

K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Source Range Monitor System:
(CFR: 41.5 / 45.3)

K5.01	Detector operation	2.8
K5.02	DELETED	
K5.03	Changing detector position	3.2
K5.04	SRMS/IRM overlap	3.5

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Source Range Monitor System:
(CFR: 41.7 / 45.7)

K6.01	RPS	3.3
K6.02	24/48 volt DC power	3.4
K6.03	Detector drive motor	2.9
K6.04	Detectors	3.2
K6.05	Trip units	3.3
K6.06	DELETED	
K6.07	Reactor vessel and internals	2.6

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Source Range Monitor System, including:
(CFR: 41.5 / 45.5)

A1.01	Detector position	3.3
A1.02	Reactor power	4.0
A1.03	RPS status	3.3
A1.04	Control rod block status	3.6
A1.05	SCRAM, rod block, and period alarm and trip setpoints	3.7
A1.06	Lights and alarms	3.4
A1.07	SRMS count rate and period	4.0

A2 Ability to (a) predict the impacts of the following on the Source Range Monitor System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Degraded power supply	3.1	2.8
A2.02	SRMS inoperable condition	3.4	3.7
A2.03	Stuck detector	3.1	3.2

System: 215004 SF7 SRMS Source Range Monitor System

A2.04	Upscale and downscale trips	4.0	3.7
A2.05	Faulty or erratic operation of detectors/system	3.7	3.4
A2.06	DELETED		

**A3 Ability to monitor automatic operation of the Source Range Monitor System, including:
(CFR: 41.7 / 45.7)**

A3.01	DELETED		
A3.02	DELETED		
A3.03	RPS status	3.5	
A3.04	Control rod block status	3.7	

**A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)**

A4.01	SRMS count rate and period	4.1	
A4.02	SRMS recorder	3.4	
A4.03	DELETED		
A4.04	SRMS drive control switches	3.5	
A4.05	SRMS back panel switches, meters, and indicating lights	3.0	
A4.06	DELETED		
A4.07	DELETED		
A4.08	SRMS channel bypass	3.4	

System: 215001 SF7 TIP Traversing In-Core Probe

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Traversing In-Core Probe and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Local power range monitoring system	3.3
K1.02	Plant process computer/parameter display systems	2.9
K1.03	Nitrogen system (BWR 2, 3, 4, 5)	2.5
K1.04	Instrument air system	2.4
K1.05	Primary containment isolation system (BWR 2, 3, 4, 5)	3.7
K1.06	DELETED	
K1.07	DELETED	
K1.08	Reactor vessel and internals	3.2
K1.09	Primary containment and auxiliaries	2.9
K1.10	Radiation monitoring system	2.7
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Shear valves (BWR 2, 3, 4, 5)	3.1
K2.02	Ball valves (BWR 2, 3, 4, 5)	3.0
K3	Knowledge of the effect that a loss or malfunction of the Traversing In-Core Probe will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Local power range monitoring system	3.1
K4	Knowledge of Traversing In-Core Probe design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Primary containment isolation (BWR 2, 3, 4, 5)	3.7
K4.02	Corrosion prevention (air/nitrogen purge)	2.3
K4.03	Radiation shielding	2.9
K5	Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Traversing In-Core Probe: (CFR: 41.5 / 45.3)	
K5.01	Flux detection	3.2

System: 215001 SF7 TIP Traversing In-Core Probe

K5.02 Area radiation monitor indications 2.8

K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Traversing In-Core Probe:
(CFR: 41.7 / 45.7)

K6.01 DC electrical distribution 2.7
 K6.02 AC electrical distribution 2.7
 K6.03 Plant process computer/parameter display systems 2.7
 K6.04 Primary containment isolation system (BWR 2, 3, 4, 5) 3.7
 K6.05 Instrument air system 2.4
 K6.06 Nitrogen system (BWR 2, 3, 4, 5) 2.5
 K6.07 Reactor water level (BWR 2, 3, 4, 5) 2.9
 K6.08 Containment/drywell pressure (BWR 2, 3, 4, 5) 3.0

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Traversing In-Core Probe, including:
(CFR: 41.5 / 45.5)

A1.01 Area radiation levels 3.1
 A1.02 Detector position 3.2
 A1.03 Valve status (BWR 2, 3, 4, 5) 3.3
 A1.04 Drive speed 2.5
 A1.05 Detector output 2.7
 A1.06 DELETED
 A1.07 Lights and alarms 2.8

A2 Ability to (a) predict the impacts of the following on the Traversing In-Core Probe and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6)

		RO	SRO
A2.01	Low reactor water level (BWR 2, 3, 4, 5)	3.3	3.2
A2.02	High primary containment/drywell pressure (BWR 2, 3, 4, 5)	3.5	3.3
A2.03	Drive mechanism failure	2.9	2.7
A2.04	Loss of AC electrical distribution	2.8	2.6
A2.05	Loss of DC electrical distribution	2.7	2.7
A2.06	Abnormal valve position (BWR 2, 3, 4, 5)	3.5	3.1
A2.07	Failure to retract during accident conditions (BWR 2, 3, 4, 5)	3.8	3.5
A2.08	Failure to retract to shield (BWR 2, 3, 4, 5)	3.7	3.3

System: 215001 SF7 TIP Traversing In-Core Probe

A3 Ability to monitor automatic operation of the Traversing In-Core Probe, including:
(CFR: 41.7 / 45.7)

A3.01	DELETED	
A3.02	DELETED	
A3.03	Valve operation (BWR 2, 3, 4, 5)	3.3
A3.04	DELETED	
A3.05	DELETED	
A3.06	TIP detector insertion into the reactor core	2.9
A3.07	TIP detector withdrawal from the reactor core	2.9
A3.08	TIP detector retract during accident conditions (BWR 2, 3, 4, 5)	3.7

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	DELETED	
A4.02	DELETED	
A4.03	Isolation valves (BWR 2, 3, 4, 5)	3.6
A4.04	DELETED	
A4.05	DELETED	
A4.06	Drive mechanism operation	2.7

3.8	Safety Function 8: Plant Service Systems	Page
286000	Fire Protection System.....	3.8-3
234000	Fuel Handling.....	3.8-7
300000	Instrument Air System.....	3.8-11
400000	Component Cooling Water System.....	3.8-15
510001	Circulating Water System.....	3.8-19

System: 286000 SF8 FPS Fire Protection System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Fire Protection System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	CCW	2.4
K1.02	Isolation condenser	3.3
K1.03	DELETED	
K1.04	DC electrical distribution	2.8
K1.05	Main generator hydrogen system	2.9
K1.06	Auxiliary boiler steam system	1.8
K1.07	AC electrical distribution system	2.9
K1.08	Intake canals	2.5
K1.09	DELETED	
K1.10	Main generator/exciter systems	2.7
K1.11	Screen wash system	2.1
K1.12	Emergency core cooling system	3.1
K1.13	Plant ventilation systems	2.4
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	DELETED	
K2.02	Fire pumps	3.2
K2.03	DELETED	
K3	Knowledge of the effect that a loss or malfunction of the Fire Protection System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	DELETED	
K3.02	Personnel protection	3.3
K3.03	Plant protection	3.6
K3.04	Component cooling water systems	2.4
K3.05	Isolation condenser system	3.3
K3.06	Main generator hydrogen system	2.8
K3.07	Main generator/exciter systems	2.7
K3.08	Auxiliary boiler steam system	1.7
K3.09	AC electrical distribution systems	2.8
K3.10	DC electrical distribution systems	2.7
K3.11	Plant ventilation systems	2.4

System: 286000 SF8 FPS Fire Protection System

K3.12	Screen wash system	1.9
K3.13	Emergency core cooling systems	3.0

**K4 Knowledge of Fire Protection System design features and/or interlocks that provide for the following:
(CFR:41.5 / 41.7 / 45.3 to 45.8)**

K4.01	Adequate water supply system	3.4
K4.02	Automatic system initiation	3.5
K4.03	Maintaining of fire header pressure	3.1
K4.04	Personnel safety during halon/carbon dioxide system actuation	3.7
K4.05	Maintaining fire protection capability during loss of offsite power	3.5
K4.06	Fire suppression	3.4
K4.07	DELETED	
K4.08	Containment isolation	2.5
K4.09	Fire detection and alarm	3.4
K4.10	Spent fuel pool makeup and spray	3.5
K4.11	Alternate injection to the RPV or primary containment	3.8

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Fire Protection System:
(CFR: 41.5 / 45.3)**

K5.01	Effect of carbon dioxide on fires	3.1
K5.02	Effect of halon on fires	3.0
K5.03	Effect of water spray on electrical components	3.4
K5.04	Valve operation	2.9
K5.05	Diesel operations	3.3
K5.06	Heat detection	3.1
K5.07	Smoke detection	3.1
K5.08	Gas refrigeration	2.3
K5.09	Reactor water level	3.0
K5.10	Equipment/rooms protected by FPS	3.1

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Fire Protection System:
(CFR: 41.7 / 45.7)**

K6.01	AC electrical distribution	3.2
K6.02	DC electrical distribution	3.0
K6.03	Component cooling water system	2.1

System: 286000 SF8 FPS Fire Protection System

K6.04	Diesel fuel transfer system	2.4
K6.05	Screen wash system	1.9
K6.06	Motor-driven fire pump	3.4
K6.07	Diesel-driven fire pump	3.4

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Fire Protection System, including:
(CFR: 41.5 / 45.5)

A1.01	System pressure	3.4
A1.02	System flow	3.1
A1.03	Fire doors	3.1
A1.04	Fire dampers	3.1
A1.05	System lineups	3.1
A1.06	Fire water tank pressure	2.5

A2 Ability to (a) predict the impacts of the following on the Fire Protection System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6)

		RO	SRO
A2.01	System logic failure	2.8	3.1
A2.02	DC electrical distribution failure	2.6	2.8
A2.03	AC electrical distribution failure	2.8	3.0
A2.04	CCW failure	2.0	2.0
A2.05	Fire protection pump trips	3.4	3.2
A2.06	Low fire main pressure	3.3	3.3
A2.07	Inadvertent system initiation	3.2	2.9
A2.08	Failure to actuate when required	3.7	3.3
A2.09	Valve closures due to malfunction(s)	2.9	2.9
A2.10	Valve openings due to malfunction(s)	2.9	2.9
A2.11	DELETED		
A2.12	Low diesel fuel supply	3.1	3.0

A3 Ability to monitor automatic operation of the Fire Protection System, including:
(CFR: 41.7 / 45.7)

A3.01	Fire water pump start	3.4
A3.02	Fire system keep fill	2.8
A3.03	Actuation of fire detectors	3.3
A3.04	System initiation	3.5
A3.05	Fire doors	2.8
A3.06	Fire dampers	2.8

System: 286000 SF8 FPS Fire Protection System

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

A4.01	System alarms and indicating lights	3.3
A4.02	CCW	2.1
A4.03	DELETED	
A4.04	Fire main pressure	3.0
A4.05	Motor-driven fire pump start	3.2
A4.06	Diesel-driven fire pump start	3.4

System: 234000 SF8 FH Fuel Handling

K/A NO.	KNOWLEDGE	IMPORTANCE	
K1	Knowledge of the physical connections and/or cause and effect relationships between the Fuel Handling System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	RO	SRO
K1.01	Fuel	3.0	3.7
K1.02	DELETED		
K1.03	DELETED		
K1.04	Reactor manual control system	3.4	3.5
K1.05	Reactor vessel components	3.1	3.2
K1.06	RCIS (BWR 6)	3.6	3.7
K1.07	Fuel transfer tube system (Mark III)	3.0	3.0
K1.08	DELETED		
K1.09	Fuel pool ventilation	3.2	2.8
K1.10	Containment ventilation	3.0	2.8
K1.11	Primary containment system and auxiliaries	2.9	2.8
K1.12	Fuel pool cooling and cleanup system	3.1	3.3
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)		
K2.01	Fuel handling equipment power	2.3	2.5
K3	Knowledge of the effect that a loss or malfunction of the Fuel Handling System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)		
K3.01	Reactor manual control system	2.8	3.4
K3.02	RCIS	3.0	3.0
K3.03	Fuel handling operations	3.0	3.4
K3.04	Core modifications/alterations	3.3	3.4
K3.05	Fuel pool level	3.0	3.1
K3.06	Fuel pool cooling and cleanup system	2.6	2.9
K4	Knowledge of Fuel Handling System design features and/or interlocks that provide for the following: (CFR: 41.7)		
K4.01	Prevention of core alterations during control rod movements	3.6	3.8
K4.02	Prevention of control rod movement during core alterations	3.6	3.8

System:	234000 SF8 FH Fuel Handling	RO	SRO
K4.03	Protection against inadvertently lifting radioactive components out of the water	3.7	3.7
K4.04	Movement of the spent fuel cask only over designated areas	3.3	2.8
K4.05	Movement of fuel via fuel transfer tube (Mark III)	3.0	2.9
K4.06	Protection from dropping a fuel assembly	3.6	3.5
K4.07	Hoist overload or underload protection	3.1	3.1
K4.08	Preventing draining of water from the inclined fuel transfer system	3.3	3.1
K4.09	Determining refueling machine position, speed, or direction	2.7	2.8
K4.10	Maintaining minimum water level in the spent fuel pool	3.9	3.6
K5	Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Fuel Handling System: (CFR: 41.5 / 45.3)		
K5.01	Crane/hoist operation	2.4	2.7
K5.02	FH equipment interlocks	3.6	3.7
K5.03	Minimum cavity/pool level as a shield against radiation	3.4	3.7
K5.04	Spent fuel pool design	2.9	3.0
K5.05	Fuel orientation	3.1	3.4
K5.06	Fuel	3.0	3.2
K5.07	Spent fuel cask	2.7	2.6
K5.08	Fuel pools configuration (Mark III)	2.3	2.8
K5.09	Refuel floor ventilation	3.3	2.9
K5.10	Nuclear instrument system response to core offload/reload	3.3	3.5
K5.11	Area radiation monitors response to fuel handling event	3.6	3.6
K5.12	Containment closure requirements	3.6	3.3
K5.13	Loss of spent fuel pool or reactor cavity level	4.0	3.8
K6	Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Fuel Handling System: (CFR: 41.7 / 45.7)		
K6.01	Electrical power	2.9	2.8
K6.02	Reactor manual control system	3.0	3.4
K6.03	RCIS	3.5	3.0
K6.04	Refueling platform air	2.7	2.9
K6.05	Upper fuel pool water inventory (Mark III)	3.7	3.4
K6.06	Fuel transfer tube interlocks (Mark III)	3.3	3.1

System:	234000 SF8 FH Fuel Handling	RO	SRO
K6.07	Fuel pool ventilation	3.3	2.7
K6.08	Fuel pool cooling and cleanup system	3.1	3.1
K6.09	Bridge, trolley, or hoist encoder failure	2.4	2.6
K6.10	Mechanically bound fuel assembly	3.0	3.1
A1	Ability to predict and/or monitor changes in parameters associated with operation of the Fuel Handling System, including: (CFR: 41.5 / 45.5)		
A1.01	Spent fuel pool level	3.7	3.3
A1.02	Refuel floor radiation levels/airborne levels	3.7	3.4
A1.03	Core reactivity level	3.7	3.6
A1.04	Upper fuel pool water level	3.5	3.2
A1.05	Refueling machine position, speed, or direction	2.1	2.8
A2	Ability to (a) predict the impacts of the following on the Fuel Handling System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations: (CFR: 41.5 / 45.6)		
A2.01	Interlock failure	3.1	3.4
A2.02	Loss of refueling platform air	2.7	2.9
A2.03	Loss of electrical power	2.7	2.9
A2.04	Reactor manual control system malfunction	3.3	3.4
A2.05	RCIS malfunction	3.3	3.0
A2.06	Abnormal upper fuel pool water inventory (Mark III)	3.7	3.4
A2.07	Fuel transfer tube interlocks malfunction (Mark III)	2.7	3.3
A2.08	Fuel pool ventilation malfunction	3.2	2.9
A2.09	Fuel pool cooling and cleanup system malfunction	3.3	3.0
A2.10	Bridge, trolley, or hoist encoder failure	2.3	2.7
A2.11	Mechanically bound fuel assembly	2.7	3.1
A3	Ability to monitor automatic operation of the Fuel Handling System, including: (CFR: 41.7 / 45.7)		
A3.01	Crane/refuel bridge movement	2.4	3.1
A3.02	Interlock operation	3.1	3.4

System: 234000 SF8 FH Fuel Handling		RO	SRO
A4	Ability to manually operate and/or monitor at the equipment location/control room: (CFR: 41.7 / 45.5 to 45.8)		
A4.01	Neutron monitoring system	3.7	3.7
A4.02	Control rod drive system	3.9	3.5
A4.03	Mode switch	3.7	3.5

System: 300000 SF8 IA Instrument Air System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Instrument Air System and the following systems: (CFR: 41.4 to 41.5, 41.7 to 41.9 / 45.6 and 45.8)	
K1.01	DELETED	
K1.02	Service air system	3.5
K1.03	Drywell pneumatic system	3.1
K1.04	Component cooling water system	3.2
K1.05	DELETED	
K1.06	Plant ventilation systems	3.0
K1.07	Circulating water system	2.1
K1.08	Condensate system	3.2
K1.09	Condenser air removal system	2.8
K1.10	Containment airlock system	2.1
K1.11	Control rod drive hydraulic system	3.5
K1.12	Extraction steam system	3.0
K1.13	Feedwater system	3.4
K1.14	Fire protection system	2.2
K1.15	Fuel handling system	2.3
K1.16	Fuel pool cooling cleanup system	2.9
K1.17	Generator hydrogen system	2.2
K1.18	Heater drain system	3.1
K1.19	Liquid radwaste system	2.4
K1.20	Main steam system	3.6
K1.21	Main turbine lube oil system	2.3
K1.22	Neutron monitoring system	1.8
K1.23	Offgas system	3.0
K1.24	Post-accident monitoring system	2.4
K1.25	Reactor recirculation sample system	2.4
K1.26	Reactor water cleanup system	3.2
K1.27	Service water system	2.7
K1.28	Standby gas treatment system	3.0
K1.29	Suppression pool cleanup system	2.4
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Instrument air compressor	3.3
K2.02	Emergency air compressor	3.3

System: 300000 SF8 IA Instrument Air System

**K3 Knowledge of the effect that a loss or malfunction of the Instrument Air System will have on the following systems or system parameters:
(CFR: 41.7 / 45.6)**

K3.01	Drywell pneumatic system	3.1
K3.02	DELETED	
K3.03	DELETED	
K3.04	Plant ventilation systems	3.0
K3.05	Circulating water system	2.0
K3.06	Component cooling water system	3.0
K3.07	Condensate system	3.2
K3.08	Condenser air removal system	2.9
K3.09	Containment airlock system	2.1
K3.10	Control rod drive hydraulic system	3.6
K3.11	Extraction steam system	3.0
K3.12	Feedwater system	3.5
K3.13	Fire protection system	2.3
K3.14	Fuel handling system	2.3
K3.15	Fuel pool cooling cleanup system	2.9
K3.16	Generator hydrogen system	2.2
K3.17	Heater drain system	3.1
K3.18	Liquid radwaste system	2.2
K3.19	Main steam system	3.6
K3.20	Main turbine lube oil system	2.2
K3.21	Neutron monitoring system	1.8
K3.22	Offgas system	3.1
K3.23	Post-accident monitoring system	2.2
K3.24	Reactor recirculation sample system	2.3
K3.25	Reactor water cleanup system	3.2
K3.26	Service water system	2.7
K3.27	Standby gas treatment system	3.1
K3.28	Suppression pool cleanup system	2.3

**K4 Knowledge of Instrument Air System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Modes of control	3.1
K4.02	Crossover to other pneumatic systems	3.3
K4.03	Compressor automatic starts/trips	3.2
K4.04	Containment isolation	3.5
K4.05	Maintaining dry air	3.1

System: 300000 SF8 IA Instrument Air System

K4.06 Maintaining normal instrument air pressure 3.4

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Instrument Air System:
(CFR: 41.5 / 45.3)**

K5.01 DELETED
K5.02 DELETED
K5.03 DELETED
K5.04 DELETED
K5.05 DELETED
K5.06 DELETED
K5.07 DELETED
K5.08 DELETED
K5.09 DELETED
K5.10 DELETED
K5.11 DELETED
K5.12 DELETED
K5.13 Low instrument air pressure 3.9
K5.14 Air leaks 3.3
K5.15 High moisture content in instrument air 3.1

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Instrument Air System:
(CFR: 41.8 / 45.7)**

K6.01 Air compressors 3.7
K6.02 DELETED
K6.03 DELETED
K6.04 DELETED
K6.05 Air dryers 3.3
K6.06 DELETED
K6.07 DELETED
K6.08 DELETED
K6.09 DELETED
K6.10 Heat exchangers and condensers 3.1
K6.11 DELETED
K6.12 DELETED
K6.13 Service air cross-connect valve 3.4
K6.14 Component cooling water system 3.1
K6.15 Low instrument air pressure 3.6
K6.16 Backwashing condensate filter/demins 2.6

System: 300000 SF8 IA Instrument Air System

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Instrument Air System, including:
(CFR: 41.5 / 45.5)

A1.01	Instrument air supply pressure	3.7
A1.02	Lights and alarms	3.4
A1.03	Service air pressure	3.1

A2 Ability to (a) predict the impacts of the following on the Instrument Air System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6)

		RO	SRO
A2.01	Air dryer and filter malfunctions	3.8	3.3
A2.02	Component cooling water system malfunction	3.4	3.2
A2.03	Low instrument air pressure	3.9	3.8

A3 Ability to monitor automatic operation of the Instrument Air System, including:
(CFR: 41.8 / 45.7)

A3.01	DELETED	
A3.02	DELETED	
A3.03	Compressor automatic starts/trips	3.5
A3.04	Automatic isolation	3.4

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.8 / 45.5 to 45.8)

A4.01	DELETED	
A4.02	Instrument air compressors	3.5
A4.03	Manual isolations	3.2

System: 400000 SF8 CCW Component Cooling Water System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Component Cooling Water System and the following systems: (CFR: 41.4 to 41.5 / 41.7 to 41.9 / 45.6 to 45.8)	
K1.01	Service water system	3.8
K1.02	Loads cooled by CCW	3.8
K1.03	Radiation monitoring systems	3.1
K1.04	DELETED	
K1.05	Plant ventilation	2.3
K1.06	Instrument air system	3.0
K1.07	Control rod drive hydraulic system	3.2
K1.08	Recirculation system	3.7
K1.09	Recirculation flow control system	2.8
K1.10	Residual heat removal system	3.7
K1.11	Low-pressure core spray system	3.1
K1.12	Reactor core isolation cooling system (BWR 4, 5, 6)	3.1
K1.13	Reactor water cleanup system	3.6
K1.14	Fuel pool cooling and cleanup system	3.8
K1.15	Turbine generator and auxiliary systems	3.2
K1.16	High-pressure coolant injection system (BWR 3, 4)	3.3
K1.17	High-pressure core spray system (BWR 5, 6)	3.2
K1.18	Reactor condensate system	3.1
K1.19	Reactor feedwater system	3.1
K1.20	Reactor/turbine pressure regulating system	2.8
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	CCW pumps	3.4
K2.02	CCW valves	2.8
K3	Knowledge of the effect that a loss or malfunction of the Component Cooling Water System will have on the following systems or system parameters: (CFR: 41.7 / 45.6)	
K3.01	Loads cooled by CCW	3.9
K3.02	Plant ventilation systems	2.4
K3.03	Instrument air system	3.3
K3.04	Service water system	2.9
K3.05	Control rod drive hydraulic system	3.4

System: 400000 SF8 CCW Component Cooling Water System

K3.06	Recirculation system	3.8
K3.07	Recirculation flow control system	2.7
K3.08	Residual heat removal system	3.7
K3.09	Low-pressure core spray system	3.1
K3.10	Reactor core isolation cooling system (BWR 4, 5, 6)	3.1
K3.11	Reactor water cleanup system	3.5
K3.12	Fuel pool cooling and cleanup system	3.7
K3.13	Turbine generator and auxiliary systems	3.1
K3.14	Radiation monitoring systems	2.3
K3.15	High-pressure coolant injection system (BWR 3, 4)	3.0
K3.16	High-pressure core spray system (BWR 5, 6)	3.1
K3.17	Reactor condensate system	3.1
K3.18	Reactor feedwater system	3.1
K3.19	Reactor/turbine pressure regulating system	2.8

**K4 Knowledge of Component Cooling Water System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Automatic start of standby pump	3.4
K4.02	Containment isolation	3.6
K4.03	Spent fuel pool cooling	3.6
K4.04	Pump trip on low surge tank level	3.1
K4.05	Surge tank level control	2.9
K4.06	System protection due to reactor coolant system in-leakage	3.2
K4.07	System response to LOCA signal	3.8
K4.08	System response to LOOP signal	3.8
K4.09	Operation from the remote shutdown panel	3.3

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Component Cooling Water System:
(CFR: 41.5 / 45.3)**

K5.01	Chemistry control	2.4
K5.02	Determine source(s) of RCS leakage into CCW	3.1

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Component Cooling Water System:
(CFR: 41.7 / 45.7)**

System: 400000 SF8 CCW Component Cooling Water System

K6.01	DELETED	
K6.02	DELETED	
K6.03	DELETED	
K6.04	DELETED	
K6.05	DELETED	
K6.06	DELETED	
K6.07	DELETED	
K6.08	Service water system	3.7
K6.09	Radiation monitoring systems	2.4
K6.10	Control rod drive hydraulic system	2.8
K6.11	Recirculation system	2.9
K6.12	Reactor water cleanup system	3.1
K6.13	Fuel pool cooling and cleanup system	3.3
K6.14	AC electrical distribution system	3.5

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Component Cooling Water System, including:
(CFR: 41.5 / 45.5)**

A1.01	CCW flow rate	3.0
A1.02	CCW temperature	3.4
A1.03	CCW pressure	3.0
A1.04	Surge tank level	3.0

**A2 Ability to (a) predict the impacts of the following on the Component Cooling Water System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	Loss of CCW pump	4.1	3.9
A2.02	High/low surge tank level	3.6	3.2
A2.03	High/low CCW temperature	3.8	3.5
A2.04	Radiation monitoring system alarm	3.0	2.7
A2.05	Loss of service water system	4.1	3.8
A2.06	Component cooling water system heat exchanger tube leak	3.3	3.1
A2.07	Loss of cooling to residual heat removal system heat exchangers	3.9	3.8
A2.08	Residual heat removal system heat exchanger tube leak	3.5	3.3
A2.09	Loss of cooling to spent fuel pool cooling system heat exchanger	4.2	3.8
A2.10	Spent fuel pool cooling system heat exchanger tube leak	3.6	3.2

System: 400000 SF8 CCW Component Cooling Water System

A2.11	Loss of cooling to reactor recirculation pump	4.2	3.7
A2.12	Loss of cooling to reactor recirculation pump variable frequency drive	3.0	3.5
A2.13	Loss of instrument air system	4.0	3.3
A2.14	Loss of AC electrical distribution system	3.9	3.7
A2.15	Loss of cooling to turbine lube oil system	3.4	2.9
A2.16	Loss of cooling to alternate decay heat removal system	3.7	3.3
A2.17	Loss of cooling to ECCS pump rooms	3.5	3.4

**A3 Ability to monitor automatic operations of the Component Cooling Water System, including:
(CFR: 41.7 / 45.7)**

A3.01	DELETED		
A3.02	Containment isolation	3.6	
A3.03	Spent fuel pool cooling	3.8	
A3.04	Pump trip	3.8	
A3.05	System response due to a LOCA signal	3.8	
A3.06	System response due to a LOOP signal	3.7	
A3.07	System realignments	3.3	

**A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)**

A4.01	CCW indications and control	3.8	
-------	-----------------------------	-----	--

System: 510001 SF8 CWS Circulating Water System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Circulating Water System and the following systems: (CFR: 41.4 to 41.8 / 45.7 to 45.8)	
K1.01	Condensate system	3.3
K1.02	Feedwater system	2.9
K1.03	Service water system	2.8
K1.04	Main turbine generator and auxiliary systems	3.1
K1.05	Recirculation flow control system	2.2
K1.06	Reactor/turbine pressure regulating system	2.7
K1.07	Fire protection system	2.2
K1.08	Radwaste system	2.1
K1.09	Radiation monitoring system	2.5
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	System pumps	3.1
K2.02	System valves	2.6
K2.03	Cooling tower fans	2.5
K3	Knowledge of the effect that a loss or malfunction of the Circulating Water System will have on the following systems or system parameters: (CFR: 41.7 / 45.4)	
K3.01	Main turbine generator and auxiliary systems	3.5
K3.02	Fire protection system	2.2
K3.03	Reactor/turbine pressure regulating system	2.9
K3.04	Condensate system	3.1
K3.05	Circulating water system temperature	3.1
K3.06	Recirculation flow control system	2.2
K3.07	Service water system	2.3
K3.08	Feedwater system	2.8
K3.09	Condenser vacuum	4.0
K3.10	Circulating water system pressure	3.1
K3.11	Circulating water system flow	3.3

System: 510001 SF8 CWS Circulating Water System

**K4 Knowledge of Circulating Water System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Automatic valve alignments	2.9
K4.02	Cooling tower cold weather operations	2.8
K4.03	Cooling tower blowdown	2.6
K4.04	Turbine load reduction	3.2
K4.05	Reactor power reduction	3.3
K4.06	Condenser mechanical cleaning	2.1
K4.07	Cooling tower basin level control	2.7

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Circulating Water System:
(CFR: 41.4, 41.7 / 45.5)**

K5.01	Pump suction low level	3.0
K5.02	Flood detection/prevention	3.2
K5.03	Pipe rupture	3.3

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Circulating Water System:
(CFR: 41.7 / 45.7)**

K6.01	Pump trip	3.5
K6.02	Cooling tower level control valve malfunction	2.9
K6.03	Cooling tower ice formation	2.7
K6.04	Valve malfunctions	3.0

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Circulating Water System, including:
(CFR: 41.5 / 45.5)**

A1.01	Weather changes	3.0
A1.02	Circulating water flow	2.9
A1.03	Circulating water pressures	2.6
A1.04	Circulating water temperatures	3.1
A1.05	Lights and alarms	3.1
A1.06	Condenser vacuum	3.9

System: 510001 SF8 CWS Circulating Water System

A2 Ability to (a) predict the impacts of the following on the Circulating Water System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.5, 41.1 / 43.5 / 45.3, 45.6, 45.13)

RO

SRO

A2.01	Pump/Motor failure	3.5	3.3
A2.02	Abnormal valve positions	3.0	3.0
A2.03	Cooling tower ice formation	2.3	2.9
A2.04	System leakage/rupture	3.2	3.5

A3 Ability to monitor automatic operation of the Circulating Water System, including:

(CFR: 41.7 / 45.5)

A3.01	Pump starts/stops	3.0
A3.02	Valve alignment	2.9

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

A4.01	Circulating water pumps	3.3
A4.02	Circulating water valves	3.1
A4.03	Cooling tower basin level	2.8
A4.04	Cooling tower fans	2.4

3.9	Safety Function 9: Radioactivity Release	Page
239003	Main Steam Isolation Valve Leakage Control System.....	3.9-3
271000	Offgas System.....	3.9-7
288000	Plant Ventilation Systems.....	3.9-11
272000	Radiation Monitoring System.....	3.9-14
268000	Radwaste System.....	3.9-18
290003	Control Room Ventilation.....	3.9-21
233000	Fuel Pool Cooling and Cleanup.....	3.9-24
261000	Standby Gas Treatment System.....	3.9-28

System: 239003 SF9 MSIVLC Main Steam Isolation Valve Leakage Control System (BWR 4, 5, 6)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Main Steam Isolation Valve Leakage Control System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Main steam system	3.4
K1.02	Standby gas treatment system	2.7
K1.03	DELETED	
K1.04	AC electrical distribution system	2.8
K1.05	DELETED	
K1.06	Radwaste system	2.0
K1.07	DELETED	
K1.08	Nuclear boiler instrumentation system	2.8
K1.09	Condensate system	2.5
K1.10	Radiation monitoring system	2.9
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Motor-operated valves	2.7
K2.02	Leakage control system blowers	2.1
K2.03	Leakage control system heaters	2.1
K3	Knowledge of the effect that a loss or malfunction of the Main Steam Isolation Valve Leakage Control System will have on the following systems or system parameters: (CFR: 41.5 / 45.3)	
K3.01	Radiation monitoring system	3.0
K4	Knowledge of Main Steam Isolation Valve Leakage Control System design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Performance of its safety function following a loss of offsite power	3.2
K4.02	Performance of intended safety function following any single active component failure	3.0
K4.03	Prevention of inadvertent system operation	2.4

System: 239003 SF9 MSIVLC Main Steam Isolation Valve Leakage Control System (BWR 4, 5, 6)

K4.04	DELETED	
K4.05	Assurance that any MSIV leakage will pass through the system and into standby gas treatment before release to the atmosphere	2.8
K4.06	Depressurization of main steam piping before routing leakage through system	2.8
K4.07	Reduction of MSIV leakage temperature	2.6
K4.08	Prevention of collected condensate in system bleed lines	2.5
K4.09	Dilution of MSIV leakage	2.5

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Main Steam Isolation Valve Leakage Control System:
(CFR: 41.7 / 45.4)**

K5.01	Radiation release	3.2
K5.02	System lineup	3.0

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Main Steam Isolation Valve Leakage Control System:
(CFR: 41.7 / 45.7)**

K6.01	AC electrical distribution system	2.8
K6.02	Standby gas treatment system	2.9
K6.03	Nuclear boiler instrumentation	2.6
K6.04	Main steam system	2.8
K6.05	Radwaste system	2.0
K6.06	Inboard MSIV leakage	2.8
K6.07	Outboard MSIV leakage	2.9
K6.08	Low dilution air flow (inboard or outboard)	2.4
K6.09	Outboard system logic failure	2.7
K6.10	Inboard system logic failure	2.7
K6.11	Blower failure	2.6
K6.12	Heater failure	2.4
K6.13	Motor-operated valve failure(s)	2.8
K6.14	Outboard main steamline high pressure	2.8
K6.15	High reactor pressure	2.7
K6.16	MSIV failure to close	2.9
K6.17	Main steam line pressure instrumentation	2.7

System: 239003 SF9 MSIVLC Main Steam Isolation Valve Leakage Control System (BWR 4, 5, 6)

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Main Steam Isolation Valve Leakage Control System, including:
(CFR: 41.5 / 45.5)**

A1.01	Main steam line pressure	2.8
A1.02	Heater operation	2.4
A1.03	Dilution air flow	2.8
A1.04	Status indicating lights and alarms	2.7
A1.05	DELETED	
A1.06	MSIV leakage flow leakage	2.9
A1.07	Reactor building temperature	2.3

**A2 Ability to (a) predict the impacts of the following on the Main Steam Isolation Valve Leakage Control System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6)**

		RO	SRO
A2.01	Inboard MSIV leakage	3.0	2.8
A2.02	Outboard MSIV leakage	3.0	2.8
A2.03	Low dilution air flow (inboard or outboard)	2.5	2.4
A2.04	Outboard system logic failure	2.5	2.7
A2.05	Inboard system logic failure	2.5	2.7
A2.06	Blower failure	2.5	2.6
A2.07	Heater failure	2.0	2.6
A2.08	Motor-operated valve failure(s)	3.0	2.7
A2.09	Outboard main steamline high pressure	3.0	2.5
A2.10	AC electrical distribution power failures	2.7	2.6
A2.11	High reactor pressure	3.0	2.5
A2.12	MSIV failure to close	3.0	2.5
A2.13	Standby gas treatment system malfunction	2.5	2.6
A2.14	Nuclear boiler instrumentation system malfunction	2.3	2.6
A2.15	Radwaste system malfunction	1.5	2.1
A2.16	Main steam system malfunction	3.0	2.6

**A3 Ability to monitor automatic operation of the Main Steam Isolation Valve Leakage Control System, including:
(CFR: 41.7 / 45.7)**

A3.01	System logic initiation	3.1
A3.02	Main steamline pressures	2.5
A3.03	Dilution air flows	2.6

**System: 239003 SF9 MSIVLC Main Steam Isolation Valve Leakage Control System
(BWR 4, 5, 6)**

A3.04	MSIV leakage flows	2.7
A3.05	Heater operation	2.4
A3.06	DELETED	
A3.07	System lineups	2.6
A3.08	Blower operation	2.6
A3.09	Reactor building temperature	2.4

**A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)**

A4.01	Manually initiate system operation	3.2
A4.02	DELETED	
A4.03	Main steamline pressures	2.8
A4.04	Dilution air flows	2.7
A4.05	MSIV leakage flows	2.7
A4.06	Heater operation	2.4
A4.07	DELETED	
A4.08	System lineups	2.6
A4.09	System reset	2.6

System: 271000 SF9 OG Offgas System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Offgas System and the following systems: (CFR: 41.4 to 41.5 / 41.7 / 41.13 / 45.6 to 45.8)	
K1.01	Condenser air removal system	3.4
K1.02	Process radiation monitoring system	3.3
K1.03	DELETED	
K1.04	Reactor condensate system	3.0
K1.05	Radwaste system	3.1
K1.06	Main steam system	2.9
K1.07	Instrument air system	2.8
K1.08	DELETED	
K1.09	Component cooling water systems	2.5
K1.10	DELETED	
K1.11	DELETED	
K1.12	DELETED	
K1.13	DELETED	
K1.14	DELETED	
K1.15	Hydrogen water chemistry system	2.7
K1.16	Plant ventilation systems	2.3
K1.17	Fire protection system	2.3
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	DELETED	
K3	Knowledge of the effect that a loss or malfunction of the Offgas System will have on the following systems or system parameters: (CFR: 41.5 / 45.3)	
K3.01	Condenser vacuum	4.0
K3.02	Offsite release rate	3.7
K3.03	Condenser air removal	3.6
K3.04	Hydrogen concentration	3.1
K3.05	Hydrogen water chemistry system	2.8
K3.06	Radiation monitoring system	3.2
K3.07	Offgas flow	3.6

System: 271000 SF9 OG Offgas System

**K4 Knowledge of Offgas System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Dilution of hydrogen gas concentration	3.1
K4.02	Prevention of water entering the recombiner catalyst	2.8
K4.03	Sufficient oxygen providing for complete hydrogen recombination	2.9
K4.04	Prevention of hydrogen explosions or fires	3.5
K4.05	DELETED	
K4.06	Decay of fission product gases	3.2
K4.07	Maximizing charcoal bed efficiency	2.7
K4.08	Automatic system isolation	3.7
K4.09	Filtration of radioactive particulate	3.2
K4.10	Prevention of water intrusion into charcoal beds	3.0
K4.11	Elevated release point	3.3

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Offgas System:
(CFR: 41.5 / 41.7 / 45.4)**

K5.01	DELETED	
K5.02	Heat removal mechanisms	2.6
K5.03	Heat addition mechanisms	2.6
K5.04	Hydrogen concentration	3.3
K5.05	Oxygen concentration	3.0
K5.06	DELETED	
K5.07	Radioactive decay	3.1
K5.08	Charcoal adsorption of fission product gases	3.0
K5.09	Hydrogen and oxygen recombination	3.1
K5.10	DELETED	
K5.11	Reducing relative humidity for carbon bed filters	2.7
K5.12	Condenser vacuum	3.5
K5.13	Offsite release rate	3.6

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Offgas System:
(CFR: 41.5 / 41.7 / 45.7)**

K6.01	Instrument air system	3.0
K6.02	Radiation monitoring system	3.2
K6.03	Component cooling water systems	2.7

System: 271000 SF9 OG Offgas System

K6.04	DELETED	
K6.05	DELETED	
K6.06	DELETED	
K6.07	DELETED	
K6.08	Condenser air removal system	3.2
K6.09	Fuel cladding integrity	3.2
K6.10	Condensate system	2.9
K6.11	Condenser vacuum	3.5
K6.12	Glycol subsystem	2.5
K6.13	DELETED	
K6.14	Plant ventilation systems	2.2
K6.15	Main steam system	2.8
K6.16	Hydrogen water chemistry system	2.7

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Offgas System, including:
(CFR: 41.5 / 45.3 / 45.5)**

A1.01	Condenser vacuum	3.7
A1.02	Offsite release rate	3.7
A1.03	Preheater discharge temperature	2.5
A1.04	Recombiner catalyst temperature	2.7
A1.05	Cooler condenser discharge temperature	2.4
A1.06	Filter differential pressure	2.4
A1.07	Charcoal bed humidity	2.6
A1.08	System flow	3.2
A1.09	Charcoal bed temperature	2.7
A1.10	Charcoal vault temperature	2.4
A1.11	Offgas condenser temperatures	2.6
A1.12	Process radiation monitoring indications	3.3
A1.13	Hydrogen gas concentration	3.2
A1.14	Oxygen gas concentration	2.8
A1.15	Steam supply pressures	2.7
A1.16	Lights and alarms	3.0

**A2 Ability to (a) predict the impacts of the following on the Offgas System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6 / 43.5 / 45.8)**

		RO	SRO
A2.01	Low condenser vacuum	4.1	3.3

System: 271000 SF9 OG Offgas System

A2.02	Low dilution steam flow	3.4	2.9
A2.03	Main steam line high radiation	3.8	3.3
A2.04	Offgas system high radiation	3.8	3.4
A2.05	High charcoal bed humidity	2.9	2.6
A2.06	Offgas system holdup volume explosion/ fire	3.9	3.3
A2.07	Low oxygen injection flow	2.9	2.5
A2.08	DELETED		
A2.09	Abnormal valve positions	3.5	2.8
A2.10	Offgas system high flow	3.6	3.2
A2.11	Offgas system low flow	3.5	3.0
A2.12	Recombiner high temperature	3.1	2.8
A2.13	Recombiner low temperature	3.2	2.7
A2.14	Offgas filter high differential pressure	3.0	2.5
A2.15	Air intrusion	3.5	2.8
A2.16	Loss of offgas system loop seals	3.5	3.2
A2.17	Unplanned reactor power changes	3.2	3.0

A3 Ability to monitor automatic operation of the Offgas System, including:
(CFR: 41.7 / 45.7)

A3.01	System isolations	3.8	
A3.02	System flow control	3.1	
A3.03	System temperature control	2.8	
A3.04	DELETED		
A3.05	DELETED		
A3.06	System differential pressure control	2.6	
A3.07	DELETED		
A3.08	Fire suppression	2.7	

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Reset system isolations	3.4	
A4.02	System flows	3.3	
A4.03	System temperatures	2.9	
A4.04	DELETED		
A4.05	DELETED		
A4.06	DELETED		
A4.07	System differential pressures	2.7	
A4.08	DELETED		
A4.09	Offgas system controls/components	3.0	

System: 288000 SF9 PVS Plant Ventilation Systems

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Plant Ventilation Systems and the following systems: (CFR: 41.4 to 41.5 / 45.7 to 45.8)	
K1.01	AC electrical distribution system	3.0
K1.02	Secondary containment system	3.5
K1.03	Standby gas treatment system	3.6
K1.04	Component cooling water system	2.6
K1.05	Process radiation monitoring system	3.2
K1.06	Instrument air system	3.0
K1.07	Heating, ventilation, and air conditioning system cooling water systems	2.6
K1.08	Heating, ventilation, and air conditioning system heating water system	2.6
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Primary containment supply and exhaust fans	3.0
K2.02	Auxiliary building supply and exhaust fans (turbine building/radwaste building)	2.6
K3	Knowledge of the effect that a loss or malfunction of the Plant Ventilation Systems will have on the following systems or system parameters: (CFR: 41.5 / 45.3)	
K3.01	Secondary containment temperature	3.5
K3.02	Primary containment temperature	3.4
K3.03	Auxiliary building temperature	2.8
K3.04	Secondary containment pressure	3.6
K3.05	Primary containment pressure	3.4
K3.06	Auxiliary building pressure	2.7
K3.07	Turbine building temperature	2.6
K3.08	Turbine building differential pressure	2.6
K3.09	Secondary containment system	3.4
K3.10	Standby gas treatment system	3.5
K3.11	Process radiation monitoring system	3.1

System:	288000 SF9 PVS Plant Ventilation Systems	
K4	Knowledge of Plant Ventilation Systems design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	DELETED	
K4.02	Secondary containment isolation	3.8
K4.03	Automatic starting and stopping of fans	3.1
K4.04	Smoke removal	2.7
K5	Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Plant Ventilation Systems: (CFR: 41.7 / 45.4)	
K5.01	Airborne contamination control	3.2
K5.02	Differential pressure control	3.3
K5.03	Temperature control	2.9
K6	Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Plant Ventilation Systems: (CFR: 41.7 / 45.7)	
K6.01	AC electrical distribution system	3.1
K6.02	Component cooling water system	2.8
K6.03	Instrument air system	3.0
K6.04	Standby gas treatment system	3.5
K6.05	Heating, ventilation, and air conditioning system cooling water systems	2.6
K6.06	Heating, ventilation, and air conditioning system heating water system	2.7
K6.07	Process radiation monitoring system	3.1
A1	Ability to predict and/or monitor changes in parameters associated with operation of the Plant Ventilation Systems, including: (CFR: 41.5 / 45.5)	
A1.01	Filter differential pressure	2.4
A1.02	Fan differential pressure	2.4
A1.03	Area temperatures	3.1
A1.04	Secondary containment differential pressure	3.4

System: 288000 SF9 PVS Plant Ventilation Systems

A2	Ability to (a) predict the impacts of the following on the Plant Ventilation Systems and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations: (CFR: 41.5 / 45.6)	RO	SRO
A2.01	High drywell pressure	3.5	3.6
A2.02	Low reactor water level	3.3	3.2
A2.03	Loss of coolant accident	3.4	3.6
A2.04	High radiation	3.6	3.7
A2.05	Extreme outside weather conditions	3.0	2.9
A2.06	Secondary containment differential pressure malfunction	3.5	3.4
A2.07	Loss of AC electrical distribution system	3.1	3.1
A2.08	Loss of component cooling water system	2.7	2.7
A2.09	Loss of instrument air system	3.1	3.0
A2.10	Loss of standby gas treatment system	3.2	3.7
A3	Ability to monitor automatic operation of the Plant Ventilation Systems, including: (CFR: 41.7 / 45.7)		
A3.01	Isolation/initiation signals		3.7
A3.02	Differential pressure control		3.3
A4	Ability to manually operate and/or monitor in the control room: (CFR: 41.4 / 41.7 / 45.5 to 45.8)		
A4.01	Fans		3.2
A4.02	Area temperature		3.3
A4.03	Dampers		3.0
A4.04	Building differential pressure		3.3

System: 272000 SF9 RMS Radiation Monitoring System

K/A NO. KNOWLEDGE IMPORTANCE

K1 Knowledge of the physical connections and/or cause and effect relationships between the Radiation Monitoring System and the following systems:
(CFR: 41.2 to 41.9 / 45.7 to 45.8)

K1.01	Main steam system	3.6
K1.02	Offgas system (augmented offgas)	3.7
K1.03	Stack gas	3.7
K1.04	Component cooling water system	3.0
K1.05	Radwaste system	2.9
K1.06	Reactor building ventilation system	3.6
K1.07	Isolation condenser	3.3
K1.08	DELETED	
K1.09	Primary containment isolation system	3.9
K1.10	Fuel handling systems	3.4
K1.11	DELETED	
K1.12	DELETED	
K1.13	DELETED	
K1.14	DELETED	
K1.15	DELETED	
K1.16	Plant process computer/parameter display systems	3.0
K1.17	DELETED	
K1.18	Primary/secondary containment	3.6
K1.19	DELETED	
K1.20	DELETED	
K1.21	DELETED	
K1.22	DELETED	
K1.23	Continuous air monitoring/ post-accident air monitoring systems	3.3
K1.24	Plant ventilation system	3.4
K1.25	Standby gas treatment	3.8
K1.26	Safety-related service water system	3.2

K2 Knowledge of electrical power supplies to the following:
(CFR: 41.7)

K2.01	DELETED	
K2.02	DELETED	
K2.03	DELETED	
K2.04	Process radiation monitoring system	2.8
K2.05	DELETED	

System: 272000 SF9 RMS Radiation Monitoring System

K2.06	Area radiation monitors	2.6
K2.07	DELETED	
K2.08	Continuous air monitoring/post-accident air monitoring systems	2.7

**K3 Knowledge of the effect that a loss or malfunction of the Radiation Monitoring System will have on the following systems or system parameters:
(CFR: 41.5 / 45.3)**

K3.01	Liquid effluent release monitoring	3.4
K3.02	Gaseous effluent release monitoring	3.6
K3.03	Area radiation monitoring	3.1
K3.04	Main steam system	3.2
K3.05	Offgas system	3.6
K3.06	Plant ventilations systems	3.3
K3.07	DELETED	
K3.08	DELETED	
K3.09	DELETED	
K3.10	DELETED	
K3.11	Standby gas treatment system	3.6
K3.12	Safety-related service water system	3.0
K3.13	Continuous air monitoring/post-accident air monitoring systems	2.9

**K4 Knowledge of Radiation Monitoring System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	DELETED	
K4.02	System isolations/initiations	4.1
K4.03	Fail-safe tripping of process radiation monitoring logic during conditions of instrument failure	3.5
K4.04	Process radiation monitoring surveillance testing	2.7

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Radiation Monitoring System:
(CFR: 41.7 / 45.4)**

K5.01	Effect of hydrogen injection operation on process radiation indications	3.3
K5.02	Radiation level trends	3.3

System: 272000 SF9 RMS Radiation Monitoring System

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Radiation Monitoring System:
(CFR: 41.7 / 45.7)**

K6.01	DELETED	
K6.02	DC power	3.0
K6.03	AC power	3.1
K6.04	Plant process computer/parameter display systems	2.7
K6.05	DELETED	
K6.06	Continuous air monitoring/ post-accident radiation monitoring system	2.9

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Radiation Monitoring System, including:
(CFR: 41.5 / 45.5)**

A1.01	Lights and alarms	3.4
A1.02	DELETED	
A1.03	Radiations levels	3.7
A1.04	Sample flows	2.8

**A2 Ability to (a) predict the impacts of the following on the Radiation Monitoring System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 45.6)**

		RO	SRO
A2.01	Fuel element failure	4.1	4.2
A2.02	DELETED		
A2.03	AC electrical failure	3.1	3.3
A2.04	DC electrical failure	2.9	3.2
A2.05	Loss of dilution steam	2.9	2.8
A2.06	Downscale trips	3.0	3.1
A2.07	Hydrogen injection malfunction	3.4	3.0
A2.08	Offgas system failure	3.5	3.4
A2.09	Low fuel pool level	3.7	3.6
A2.10	Loss of coolant accident	4.2	4.0
A2.11	Leakage or breaks from contaminated systems to atmosphere or to other process systems	3.9	3.7
A2.12	Refuel floor handling accidents/operations	3.9	4.0
A2.13	Low reactor water level during refueling operations	3.9	3.7
A2.14	Loss of, or inadequate, shielding	3.4	3.5
A2.15	DELETED		
A2.16	Instrument malfunctions	2.9	3.0

System: 272000 SF9 RMS Radiation Monitoring System

A2.17 Plant ventilation systems abnormal radiation levels 3.4 3.3

A3 Ability to monitor automatic operation of the Radiation Monitoring System, including:
(CFR: 41.7 / 45.7)

A3.01 Main steam radiation alarms 3.5

A3.02 DELETED

A3.03 DELETED

A3.04 DELETED

A3.05 DELETED

A3.06 DELETED

A3.07 DELETED

A3.08 DELETED

A3.09 Containment isolation 4.1

A3.10 DELETED

A3.11 DELETED

A3.12 Process radiation monitor isolations 3.6

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01 Radiation monitoring system recorders 3.3

A4.02 Meter indications 3.2

A4.03 DELETED

A4.04 Plant process computer/parameter display systems 3.2

A4.05 Process radiation monitor 3.3

A4.06 Process radiation monitor logic 2.9

System: 268000 SF9 RW Radwaste System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Radwaste System and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Condensate system	2.6
K1.02	Plant pneumatic systems	2.4
K1.03	DELETED	
K1.04	DELETED	
K1.05	DELETED	
K1.06	DELETED	
K1.07	RWCU system	2.9
K1.08	Fuel pool	2.9
K1.09	DELETED	
K1.10	Auxiliary steam	1.9
K1.11	Component cooling water system	2.1
K1.12	DELETED	
K1.13	DELETED	
K1.14	DELETED	
K1.15	Condenser air removal/offgas system	2.2
K1.16	Circulating water system	1.8
K1.17	Secondary containment	2.6
K1.18	Primary containment	2.5
K1.19	Plant ventilation systems	2.3
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Radiological release isolation valves	2.7
K3	Knowledge of the effect that a loss or malfunction of the Radwaste System will have on the following systems or system parameters: (CFR: 41.5 / 45.3)	
K3.01	RWCU system	2.6
K3.02	Condensate system	2.3
K3.03	DELETED	
K3.04	Primary containment drain sumps	3.0
K3.05	Fuel pools	2.6
K3.06	Secondary containment drain sumps	2.8

System:	268000 SF9 RW Radwaste System		
K4	Knowledge of Radwaste System design features and/or interlocks that provide for the following: (CFR: 41.7)		
K4.01	Automatic isolation of radiological release isolation valves	3.0	
K5	Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Radwaste System: (CFR: 41.5 / 45.3)		
K5.01	DELETED		
K5.02	DELETED		
K5.03	Dilution flow for releases	2.9	
K6	Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Radwaste System: (CFR: 41.7)		
K6.01	Component cooling water system	2.1	
K6.02	Plant pneumatic systems	2.4	
K6.03	Plant ventilation systems	2.4	
K6.04	Circulating water	1.9	
A1	Ability to predict and/or monitor changes in parameters associated with operation of the Radwaste System, including: (CFR: 41.5 / 45.5)		
A1.01	Area radiation level	3.0	
A1.02	Offsite release (liquid/gaseous release)	3.2	
A1.03	Lights and alarms	2.6	
A2	Ability to (a) predict the impacts of the following on the Radwaste System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations: (CFR: 41.5 / 43.5 / 45.6)		
		RO	SRO
A2.01	System rupture	2.8	3.1
A2.02	DELETED		
A2.03	Loss of evaporator steam supply	2.1	2.2
A2.04	Radiological release isolation valve failure	3.1	3.2
A2.05	Abnormal primary containment sump pump run time	3.4	3.3

System: 268000 SF9 RW Radwaste System

A3 Ability to monitor automatic operation of the Radwaste System, including:
(CFR: 41.7 / 45.7)

A3.01	Radiological release isolation valves	3.2
A3.02	Primary/secondary containment sump pump operation	3.1

A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)

A4.01	Sump integrators	3.2
A4.02	Primary containment sump pumps	3.1

System: 290003 SF9 CRV Control Room Ventilation

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Control Room Ventilation and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	Radiation monitoring system	3.5
K1.02	DELETED	
K1.03	DELETED	
K1.04	Nuclear steam supply system (NSSSS/PCIS)	2.8
K1.05	Component cooling water system	2.7
K1.06	Plant pneumatic system	2.6
K1.07	Fire protection system	2.7
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Fans	3.0
K2.02	Chiller units	3.1
K2.03	DELETED	
K2.04	Control room HVAC logic	3.1
K3	Knowledge of the effect that a loss or malfunction of the Control Room Ventilation will have on the following systems or system parameters: (CFR: 41.7 / 45.6)	
K3.01	DELETED	
K3.02	DELETED	
K3.03	Control room temperature	3.4
K3.04	Control room pressure	3.4
K3.05	Control room humidity	2.7
K3.06	Control room radioactivity	3.5
K4	Knowledge of Control Room Ventilation design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	System initiation/reconfiguration	3.8
K4.02	Control room temperature/humidity control	2.9
K4.03	Differential pressure control	3.1
K4.04	Chlorine ammonia detection	3.3

System: 290003 SF9 CRV Control Room Ventilation

K4.05	Remote air intake	2.9
K4.06	Fire protection	2.7

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Control Room Ventilation:
(CFR: 41.5 / 45.3)**

K5.01	Control of airborne contamination (e.g., radiological, toxic gas, smoke)	3.6
K5.02	DELETED	
K5.03	DELETED	
K5.04	Control room habitability	3.7

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Control Room Ventilation:
(CFR: 41.7 / 45.7)**

K6.01	AC electrical distribution	3.4
K6.02	Component cooling water system	2.9
K6.03	Plant pneumatic system	2.7
K6.04	Fire protection system	2.7
K6.05	Radiation monitoring system	3.4
K6.06	Nuclear steam supply system (NSSSS/PCIS)	3.0

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Control Room Ventilation, including:
(CFR: 41.5 / 45.5)**

A1.01	Filter differential pressure	2.5
A1.02	Fan differential pressure	2.3
A1.03	Control room temperature	3.0
A1.04	Control room pressure	3.0
A1.05	Airborne radioactivity levels	3.4
A1.06	Control room humidity	2.3
A1.07	Lights and alarms	3.3
A1.08	Toxic gas	3.2

System: 290003 SF9 CRV Control Room Ventilation

A2 Ability to (a) predict the impacts of the following on the Control Room Ventilation and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:

(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Automatic initiation/reconfiguration	3.3	3.8
A2.02	Extreme environmental conditions (fire, toxic gas, smoke, radiation, etc.)	3.5	3.7
A2.03	Initiation/reconfiguration failure	3.5	3.8
A2.04	Initiation/failure of fire protection system	3.0	3.0
A2.05	Loss of chillers	3.2	3.1
A2.06	Breaches of control room envelope	3.2	3.7

A3 Ability to monitor automatic operation of the Control Room Ventilation, including:

(CFR: 41.7 / 45.7)

A3.01	Initiation/reconfiguration	3.7
A3.02	Initiation/failure of fire protection system	3.0
A3.03	Plant process computer/parameter display systems	2.4

A4 Ability to manually operate and/or monitor in the control room:

(CFR: 41.7 / 45.5 to 45.8)

A4.01	Initiate/reset system	3.8
A4.02	Fans	3.3
A4.03	Dampers	3.0
A4.04	DELETED	
A4.05	Heaters	2.5
A4.06	Chillers	3.0

System: 233000 SF9 FPCCU Fuel Pool Cooling and Cleanup

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Fuel Pool Cooling and Cleanup and the following systems: (CFR: 41.2 to 41.9 / 45.7 to 45.8)	
K1.01	DELETED	
K1.02	Residual heat removal system	3.3
K1.03	DELETED	
K1.04	Process sampling system	2.3
K1.05	Instrument air system	2.8
K1.06	DELETED	
K1.07	Condensate system	2.6
K1.08	DELETED	
K1.09	Component cooling water systems	3.2
K1.10	DELETED	
K1.11	DELETED	
K1.12	Radwaste systems	2.6
K1.13	Torus/suppression pool cleanup system	2.5
K1.14	Plant ventilation systems	2.7
K1.15	DELETED	
K1.16	Safety-related service water	3.2
K1.17	Backup fuel pool systems	3.3
K1.18	Alternate decay heat removal system	3.3
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Fuel pool cooling pumps	3.1
K2.02	DELETED	
K3	Knowledge of the effect that a loss or malfunction of the Fuel Pool Cooling and Cleanup will have on the following systems or system parameters: (CFR: 41.7 / 45.6)	
K3.01	Fuel pool temperature	3.9
K3.02	Fuel pool water level	3.6
K3.03	Fuel pool water clarity	2.9
K3.04	Fuel pool water chemistry	2.7
K3.05	Fuel pool water fission product concentration	2.8
K3.06	Area radiation levels	3.4

System:	233000 SF9 FPCCU Fuel Pool Cooling and Cleanup	
K3.07	Suppression pool chemistry	2.1
K3.08	DELETED	
K4	Knowledge of Fuel Pool Cooling and Cleanup design features and/or interlocks that provide for the following: (CFR: 41.7)	
K4.01	Redundancy	3.1
K4.02	Pool clarity	2.7
K4.03	Maintaining adequate pool temperature	3.6
K4.04	DELETED	
K4.05	Maintaining fuel pool cooling pump NPSH	3.2
K4.06	Maintaining adequate pool level	3.7
K4.07	Supplemental heat removal capability	3.4
K4.08	Pool cooling during loss of coolant accident (BWR 6)	3.6
K4.09	Maintaining filter/demineralizer precoat during low flow conditions	2.6
K4.10	Fuel pool leak detection	3.0
K5	Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Fuel Pool Cooling and Cleanup: (CFR: 41.5 / 45.3)	
K5.01	Heat removal mechanisms	3.3
K5.02	DELETED	
K5.03	Spent fuel decay heat generation	3.3
K5.04	DELETED	
K5.05	DELETED	
K5.06	Maximum heat load	3.3
K5.07	DELETED	
K5.08	Interconnections with storage pools/pits	3.2
K5.09	Refueling operations	3.4
K5.10	Abnormal fuel pool temperatures	3.5
K6	Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Fuel Pool Cooling and Clean- Up: (CFR: 41.7 / 45.7)	
K6.01	AC electrical power	3.3
K6.02	DELETED	
K6.03	Residual heat removal system	2.8
K6.04	DELETED	

System: 233000 SF9 FPCCU Fuel Pool Cooling and Cleanup

K6.05	Condensate system	2.5
K6.06	DELETED	
K6.07	Component cooling water systems	3.2
K6.08	Instrument air system	2.9
K6.09	Radwaste systems	2.3
K6.10	Reactor cavity seal failure	3.1
K6.11	NSSSS/PCIS	2.9
K6.12	Alternate decay heat removal system	3.3
K6.13	Pump trip	3.5

**A1 Ability to predict and/or monitor changes in parameters associated with operation of the Fuel Pool Cooling and Cleanup, including:
(CFR: 41.5 / 45.5)**

A1.01	Fuel pool surge tank level	3.6
A1.02	Fuel pool level	3.6
A1.03	Fuel pool temperature	3.8
A1.04	DELETED	
A1.05	DELETED	
A1.06	System flow	3.2
A1.07	DELETED	
A1.08	Fuel pool chemistry	2.4
A1.09	Fuel pool clarity	2.5
A1.10	Fuel pool activity levels	2.4
A1.11	DELETED	
A1.12	Lights and alarms	3.3
A1.13	Closed cooling water temperature	3.1

**A2 Ability to (a) predict the impacts of the following on the Fuel Pool Cooling and Cleanup and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)**

		RO	SRO
A2.01	Abnormal fuel pool level	3.8	3.8
A2.02	DELETED		
A2.03	Abnormal surge tank level	3.6	3.5
A2.04	Pump trip	3.6	3.5
A2.05	Abnormal valve position	3.2	3.0
A2.06	DELETED		
A2.07	Abnormal fuel pool temperature	3.7	3.6
A2.08	Closed cooling water failure	3.3	3.4
A2.09	AC electrical power failures	3.4	3.3

System: 233000 SF9 FPCCU Fuel Pool Cooling and Cleanup

A2.10	Refueling bellows seal high flow	3.4	2.9
A2.11	Fuel pool gate seal high flow	3.3	3.0
A2.12	Abnormal filter/demineralizer differential pressure	2.9	2.7
A2.13	DELETED		
A2.14	Low system flow	3.1	2.8
A2.15	DELETED		
A2.16	Loss of coolant accident signal	3.4	3.3
A2.17	Fuel transfer tube drain tank high/low level (BWR 6)	3.0	3.0
A2.18	Low pool clarity	2.7	2.4
A2.19	Inadequate system/pool chemistry	2.6	2.3

**A3 Ability to monitor automatic operation of the Fuel Pool Cooling and Cleanup, including:
(CFR: 41.7 / 45.7)**

A3.01	Valve operation		2.9
A3.02	Pump trip(s)		3.3
A3.03	DELETED		

**A4 Ability to manually operate and/or monitor in the control room:
(CFR: 41.7 / 45.5 to 45.8)**

A4.01	DELETED		
A4.02	Fuel pool cooling system valves		2.8
A4.03	DELETED		
A4.04	DELETED		
A4.05	DELETED		
A4.06	DELETED		
A4.07	DELETED		
A4.08	DELETED		
A4.09	Fuel pool cooling system pumps		3.1
A4.10	DELETED		
A4.11	DELETED		

System: 261000 SF9 SGTS Standby Gas Treatment System

K/A NO.	KNOWLEDGE	IMPORTANCE
K1	Knowledge of the physical connections and/or cause and effect relationships between the Standby Gas Treatment System and the following systems: (CFR: 41.4 to 41.9 / 45.7 to 45.8)	
K1.01	Plant ventilation systems	3.5
K1.02	Primary containment system and auxiliaries	3.7
K1.03	DELETED	
K1.04	Radiation monitoring system	3.6
K1.05	Radwaste system	2.1
K1.06	High-pressure coolant injection system	2.8
K1.07	DELETED	
K1.08	DELETED	
K1.09	Primary containment isolation system/nuclear steam supply shutoff system	3.6
K1.10	Instrument air system	3.0
K1.11	DELETED	
K1.12	DELETED	
K1.13	Fire protection system	2.7
K2	Knowledge of electrical power supplies to the following: (CFR: 41.7)	
K2.01	Standby gas treatment system fans	3.5
K2.02	Standby gas treatment system motor-operated valves/dampers	3.1
K2.03	Standby gas treatment system initiation logic	3.5
K2.04	Standby gas treatment system heaters	2.9
K3	Knowledge of the effect that a loss or malfunction of the Standby Gas Treatment System will have on the following systems or system parameters: (CFR: 41.7 / 45.6)	
K3.01	Secondary containment differential pressure	3.9
K3.02	Offsite release rate	4.0
K3.03	Primary containment pressure (Mark I and II)	3.7
K3.04	High-pressure coolant injection system (BWR 3, 4)	2.8
K3.05	Secondary containment radiation/ contamination levels	3.5
K3.06	Primary containment oxygen content (Mark I and II)	3.0

System: 261000 SF9 SGTS Standby Gas Treatment System

**K4 Knowledge of Standby Gas Treatment System design features and/or interlocks that provide for the following:
(CFR: 41.7)**

K4.01	Automatic system initiation	4.0
K4.02	Charcoal bed decay heat removal	3.0
K4.03	Moisture removal	3.0
K4.04	Radioactive particulate filtration	3.4
K4.05	Fission product gas removal	3.3
K4.06	Charcoal bed retention	2.9
K4.07	Elevated release stack	3.4
K4.08	Fire suppression	2.7

**K5 Knowledge of the operational implications or cause and effect relationships of the following concepts as they apply to the Standby Gas Treatment System:
(CFR: 41.5 / 45.3)**

K5.01	Heat removal mechanisms	3.0
K5.02	DELETED	
K5.03	Primary containment pressure changes	3.3
K5.04	Secondary containment pressure changes	3.4
K5.05	Fuel handling building pressure changes	3.0

**K6 Knowledge of the effect of the following plant conditions, system malfunctions, or component malfunctions on the Standby Gas Treatment System:
(CFR: 41.7 / 45.7)**

K6.01	AC electrical distribution	3.5
K6.02	DC electrical distribution	3.2
K6.03	DELETED	
K6.04	Radiation monitoring system	3.4
K6.05	Reactor protection system	3.1
K6.06	Instrument air system	2.8
K6.07	DELETED	
K6.08	Reactor vessel level	3.4
K6.09	Primary containment high pressure	3.4
K6.10	Primary containment isolation system/nuclear steam supply shutoff system	3.4

System: 261000 SF9 SGTS Standby Gas Treatment System

A1 Ability to predict and/or monitor changes in parameters associated with operation of the Standby Gas Treatment System, including:
(CFR: 41.5 / 45.5)

A1.01	System flow	3.5
A1.02	Primary containment pressure	3.5
A1.03	Offsite radioactive release limits	3.7
A1.04	Secondary containment differential pressure	3.7
A1.05	Primary containment oxygen level (Mark I and II)	3.0
A1.06	Drywell and suppression chamber differential pressure (Mark I)	3.2
A1.07	SGTS train temperature	3.0

A2 Ability to (a) predict the impacts of the following on the Standby Gas Treatment System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operations:
(CFR: 41.5 / 43.5 / 45.6)

		RO	SRO
A2.01	Low system flow	3.4	3.5
A2.02	High system flow	3.0	3.2
A2.03	High train temperature	2.9	3.3
A2.04	High train moisture content	2.9	2.9
A2.05	Fan trips	3.6	3.8
A2.06	Valve/damper closures	3.6	3.6
A2.07	AC electrical distribution failure	3.3	3.5
A2.08	DELETED		
A2.09	Instrument air system malfunction	3.2	2.7
A2.10	Low reactor water level	3.4	3.4
A2.11	High containment pressure	3.6	3.2
A2.12	High fuel pool ventilation radiation	3.4	3.3
A2.13	High secondary containment ventilation exhaust radiation	3.7	3.6
A2.14	High system pressure	3.1	3.0
A2.15	High area radiation by refuel bridge	3.3	3.2

A3 Ability to monitor automatic operation of the Standby Gas Treatment System, including:
(CFR: 41.7 / 45.7)

A3.01	System flow	3.6
A3.02	Fan start	3.8

System: 261000 SF9 SGTS Standby Gas Treatment System

A3.03	Valve/damper operation	3.7
A3.04	System temperature	3.1
A4	Ability to manually operate and/or monitor in the control room: (CFR: 41.7 / 45.5 to 45.8)	
A4.01	Offsite radioactive release limits	3.9
A4.02	DELETED	
A4.03	Fan	3.7
A4.04	Primary containment pressure	3.6
A4.05	Drywell to suppression chamber/torus differential pressure (Mark I and II)	3.5
A4.06	Reactor building differential pressure	3.6
A4.07	System flow	3.6
A4.08	System temperature	3.1
A4.09	SGTS valves/dampers	3.6

4 EMERGENCY AND ABNORMAL PLANT EVOLUTIONS

4.1	Generic Emergency Plant Evolutions (EPEs)	Page
295024	High Drywell Pressure.....	4.1-3
295025	High Reactor Pressure.....	4.1-6
295026	Suppression Pool High Water Temperature.....	4.1-8
295027	High Containment Temperature (Mark III Containment Only).....	4.1-10
295028	High Drywell Temperature (Mark I and II Only).....	4.1-12
295029	High Suppression Pool Water Level.....	4.1-14
295030	Low Suppression Pool Water Level.....	4.1-16
295031	Reactor Low Water Level.....	4.1-18
295032	High Secondary Containment Area Temperature.....	4.1-20
295033	High Secondary Containment Area Radiation Levels.....	4.1-22
295034	Secondary Containment Ventilation High Radiation.....	4.1-24
295035	Secondary Containment High Differential Pressure.....	4.1-26
295036	Secondary Containment High Sump/Area Water Level.....	4.1-27
295037	SCRAM Condition Present and Reactor Power Above APRM Downscale or Unknown.....	4.1-29
295038	High Offsite Radioactivity Release Rate.....	4.1-32
500000	High Containment Hydrogen Concentration.....	4.1-34

EPE: 295024 High Drywell Pressure

K/A NO. KNOWLEDGE IMPORTANCE

EK1 Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Drywell Pressure:
(CFR: 41.8 to 41.10)

EK1.01 Drywell integrity 4.3
EK1.02 Containment building integrity (Mark III) 4.0

EK2 Knowledge of the relationship between High Drywell Pressure and the following systems or components:
(CFR: 41.7 / 45.8)

EK2.01 HPCI (FWCI) 4.2
EK2.02 HPCS 4.3
EK2.03 LPCS 4.4
EK2.04 RHR/LPCI 4.4
EK2.05 RPS 4.4
EK2.06 Emergency generators 4.2
EK2.07 PCIS/NSSSS 4.4
EK2.08 ADS 4.2
EK2.09 Suppression pool makeup 3.1
EK2.10 AC electrical distribution 3.3
EK2.11 Drywell spray (RHR) (Mark I, II) 4.2
EK2.12 Suppression pool cooling 3.7
EK2.13 Suppression pool spray 3.9
EK2.14 Containment (Mark III) 4.1
EK2.15 Containment spray (Mark III) 4.2
EK2.16 Plant process computer/parameter display systems 3.1
EK2.17 Secondary containment/auxiliary building isolation 3.7
EK2.18 Plant ventilation systems 3.2
EK2.19 Feedwater and condensate 2.8
EK2.20 DC electrical distribution 2.9
EK2.21 RCIC 3.3
EK2.22 Standby gas treatment system 3.9
EK2.23 Hardened vent system (Mark I) 4.1
EK2.24 Safety/relief valves 3.6

EK3 Knowledge of the reasons for the following responses or actions as they apply to High Drywell Pressure:
(CFR: 41.5 / 45.6)

EK3.01 Drywell spray (Mark I, II) 4.4

EPE: 295024 High Drywell Pressure

EK3.02	Suppression pool spray	4.1
EK3.03	Containment venting (Mark III)	4.2
EK3.04	Emergency depressurization	4.2
EK3.05	Drywell flooding	3.7
EK3.06	Reactor SCRAM	4.3
EK3.07	Drywell venting	4.2
EK3.08	Containment spray	4.3
EK3.09	Secondary containment/auxiliary building isolation	3.6

EA1 Ability to operate and/or monitor the following as they apply to High Drywell Pressure:
(CFR: 41.7 / 45.6)

EA1.01	HPCI (FWCI)	4.1
EA1.02	HPCS	4.2
EA1.03	LPCS	4.2
EA1.04	RHR/LPCI	4.2
EA1.05	RPS	4.2
EA1.06	Emergency generators	4.1
EA1.07	PCIS/NSSSS	4.2
EA1.08	ADS	4.1
EA1.09	Suppression pool makeup	3.1
EA1.10	AC electrical distribution	3.4
EA1.11	Drywell spray (Mark I, II)	4.4
EA1.12	Suppression pool spray (Mark I, II)	4.2
EA1.13	Suppression pool cooling	3.8
EA1.14	Drywell ventilation system	3.4
EA1.15	Containment/drywell atmospheric monitoring	3.5
EA1.16	Containment/drywell vacuum breakers	3.8
EA1.17	Containment spray	4.3
EA1.18	Containment ventilation system (Mark III)	3.5
EA1.19	Containment atmosphere control	3.2
EA1.20	Standby gas treatment/FRVS	3.8
EA1.21	Recirculation system (LPCI loop select logic)	3.6
EA1.22	DC electrical distribution	3.1
EA1.23	RCIC	3.5
EA1.24	Drywell cooling	3.6

EA2 Ability to determine and/or interpret the following as they apply to High Drywell Pressure:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
EA2.01	Drywell pressure	4.4	4.4
EA2.02	Drywell temperature	4.4	4.3
EA2.03	Suppression pool level	4.1	4.0

EPE: 295024 High Drywell Pressure

EA2.04	Suppression chamber pressure	4.3	4.3
EA2.05	Suppression chamber air-space temperature	3.3	3.4
EA2.06	Suppression pool temperature	4.1	4.0
EA2.07	Containment radiation levels (Mark III)	3.4	3.6
EA2.08	Drywell radiation levels	3.5	3.6
EA2.09	Containment pressure (Mark III)	3.9	4.2
EA2.10	Containment temperature (Mark III)	3.9	4.0
EA2.11	Drywell integrity	4.2	4.4
EA2.12	Safety/relief valves	3.9	3.7

EPE: 295025 High Reactor Pressure

K/A NO.	KNOWLEDGE	IMPORTANCE
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Reactor Pressure: (CFR: 41.8 to 41.10)	
EK1.01	DELETED	
EK1.02	DELETED	
EK1.03	Safety/relief valve tailpipe temperature/pressure relationships	4.1
EK1.04	Decay heat	3.8
EK1.05	Exceeding safety limits	4.6
EK1.06	Pressure effects on reactor water level	3.8
EK1.07	Pressure control strategies	4.2
EK2	Knowledge of the relationship between High Reactor Pressure and the following systems or components: (CFR: 41.7 / 45.8)	
EK2.01	RPS	4.2
EK2.02	Isolation condenser	4.0
EK2.03	RFCS	3.9
EK2.04	ARI/RPT/ATWS	4.1
EK2.05	Safety/relief valves	4.4
EK2.06	HPCI	3.5
EK2.07	RCIC	3.6
EK2.08	Reactor/turbine pressure regulating system	3.7
EK2.09	DELETED	
EK2.10	Plant process computer/parameter display systems	2.9
EK2.11	DELETED	
EK2.12	Main and reheat steam system	3.1
EK2.13	Reactor water cleanup system	2.8
EK3	Knowledge of the reasons for the following responses or actions as they apply to High Reactor Pressure: (CFR: 41.5 / 45.6)	
EK3.01	Safety/relief valve operation	4.3
EK3.02	ARI/RPT/ATWS	4.2
EK3.03	HPCI operation	3.5
EK3.04	Isolation condenser initiation	4.0
EK3.05	RCIC operation	3.5
EK3.06	DELETED	

EPE:	295025 High Reactor Pressure		
EK3.07	RFCS initiation		3.8
EK3.08	Reactor/turbine pressure regulating system operation		3.6
EK3.09	Low-low set initiation		3.9
EK3.10	Reactor SCRAM		4.3
EA1	Ability to operate and/or monitor the following as they apply to High Reactor Pressure: (CFR: 41.7 / 45.6)		
EA1.01	Main and reheat steam		3.1
EA1.02	Reactor/turbine pressure regulating system		3.7
EA1.03	Safety/relief valves		4.4
EA1.04	HPCI		3.6
EA1.05	RCIC		3.6
EA1.06	Isolation condenser		4.1
EA1.07	ARI/RPT/ATWS		4.0
EA1.08	RFCS		3.9
EA1.09	RPS		4.2
EA1.10	Reactor water cleanup system		2.8
EA2	Ability to determine and/or interpret the following as they apply to High Reactor Pressure: (CFR: 41.10 / 43.5 / 45.13)	RO	SRO
EA2.01	Reactor pressure	4.7	4.3
EA2.02	Reactor power	4.4	4.2
EA2.03	Suppression pool temperature	4.0	3.5
EA2.04	Suppression pool level	4.0	3.4
EA2.05	DELETED		
EA2.06	Reactor water level	4.2	3.7

EPE: 295026 Suppression Pool High Water Temperature		
K/A NO.	KNOWLEDGE	IMPORTANCE
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Suppression Pool High Water Temperature: (CFR: 41.8 to 41.10)	
EK1.01	Pump NPSH	3.6
EK1.02	Heat capacity	4.1
EK1.03	Primary containment integrity	3.8
EK1.04	Suppression pool level	3.5
EK1.05	Suppression pool cooling	3.8
EK2	Knowledge of the relationship between Suppression Pool High Water Temperature and the following systems or components: (CFR: 41.7 / 45.8)	
EK2.01	RHR/LPCI	3.8
EK2.02	DELETED	
EK2.03	DELETED	
EK2.04	Plant process computer/parameter display systems	2.9
EK2.05	DELETED	
EK2.06	DELETED	
EK2.07	HPCI	3.8
EK2.08	RCIC	3.8
EK2.09	HPCS	3.6
EK2.10	LPCS	3.7
EK2.11	Safety/relief valves	3.9
EK2.12	Suppression pool makeup	2.8
EK3	Knowledge of the reasons for the following responses or actions as they apply to Suppression Pool High Water Temperature: (CFR: 41.5 / 45.6)	
EK3.01	Emergency/normal depressurization	4.3
EK3.02	Suppression pool cooling	3.8
EK3.03	Suppression pool spray	3.4
EK3.04	SLCS injection	3.6
EK3.05	Reactor SCRAM	3.9

EPE: 295026 Suppression Pool High Water Temperature

**EA1 Ability to operate and/or monitor the following as they apply to Suppression Pool High Water Temperature:
(CFR: 41.7 / 45.6)**

EA1.01	DELETED	
EA1.02	DELETED	
EA1.03	Suppression pool temperature monitoring system	3.8
EA1.04	HPCI	3.7
EA1.05	RCIC	3.9
EA1.06	RHR/LPCI	4.0
EA1.07	HPCS	3.6
EA1.08	LPCS	3.8
EA1.09	Safety/relief valves	4.1

**EA2 Ability to determine and/or interpret the following as they apply to Suppression Pool High Water Temperature:
(CFR: 41.10 / 43.5 / 45.13)**

		RO	SRO
EA2.01	Suppression pool water temperature	4.1	4.0
EA2.02	Suppression pool level	3.6	3.9
EA2.03	Reactor pressure	3.5	3.7

EPE: 295027 High Containment Temperature (Mark III Containment Only)		
K/A NO.	KNOWLEDGE	IMPORTANCE
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Containment Temperature: (CFR: 41.8 to 41.10)	
EK1.01	Equipment environmental qualifications	3.2
EK1.02	Reactor water level measurement	4.1
EK1.03	Primary containment integrity	4.0
EK2	Knowledge of the relationship between High Containment Temperature and the following systems or components: (CFR: 41.7 / 45.8)	
EK2.01	RHR/LPCI: containment spray system mode	4.0
EK2.02	Components internal to the containment	3.3
EK2.03	Containment ventilation/cooling	3.4
EK2.04	Plant process computer/parameter display systems.	2.9
EK2.05	Safety relief valves	3.4
EK2.06	Reactor/turbine pressure regulating system	2.7
EK2.07	Hydrogen recombiners	3.1
EK3	Knowledge of the reasons for the following responses or actions as they apply to High Containment Temperature: (CFR: 41.5 / 45.6)	
EK3.01	Anticipated/emergency depressurization	4.0
EK3.02	Containment spray	4.2
EK3.03	Reactor SCRAM	3.9
EK3.04	Hydrogen recombiners	3.2
EA1	Ability to operate and/or monitor the following as they apply to High Containment Temperature: (CFR: 41.7 / 45.6)	
EA1.01	RHR/LPCI containment spray system mode	4.2
EA1.02	Containment ventilation/cooling	3.7
EA1.03	Safety relief valves	3.7
EA1.04	Reactor/turbine pressure regulating system	3.0
EA1.05	Hydrogen recombiners	3.1

EPE: 295027 High Containment Temperature (Mark III Containment Only)

EA2 Ability to determine and/or interpret the following as they apply to High Containment Temperature:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
EA2.01	Containment temperature	4.5	4.1
EA2.02	Containment pressure	4.5	4.1
EA2.03	Reactor pressure	4.1	3.6
EA2.04	DELETED		
EA2.05	Reactor water level	4.5	4.0

EPE: 295028 High Drywell Temperature (Mark I and II Only)

K/A NO.	KNOWLEDGE	IMPORTANCE
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Drywell Temperature: (CFR: 41.8 to 41.10)	
EK1.01	Reactor water level measurement	3.8
EK1.02	Equipment environmental qualification	3.1
EK1.03	Primary containment integrity	3.6
EK1.04	Emergency depressurization	4.0
EK1.05	High drywell pressure	3.8
EK2	Knowledge of the relationship between High Drywell Temperature and the following systems or components: (CFR: 41.7 / 45.8)	
EK2.01	RHR/LPCI: containment spray system mode	3.9
EK2.02	Components internal to the drywell	3.2
EK2.03	DELETED	
EK2.04	Drywell ventilation	3.4
EK2.05	Plant process computer/parameter display systems	2.8
EK2.06	Safety relief valves	3.5
EK3	Knowledge of the reasons for the following responses or actions as they apply to High Drywell Temperature: (CFR: 41.5 / 45.6)	
EK3.01	Emergency depressurization	4.1
EK3.02	RPV flooding	3.7
EK3.03	Drywell spray	3.8
EK3.04	Increased drywell cooling	3.6
EK3.05	Reactor SCRAM	3.7
EK3.06	DELETED	
EA1	Ability to operate and/or monitor the following as they apply to High Drywell Temperature: (CFR: 41.7 / 45.6)	
EA1.01	Drywell spray	4.0
EA1.02	Drywell ventilation system	3.6
EA1.03	Drywell cooling system	3.7
EA1.04	DELETED	
EA1.05	Safety relief valves	3.8

EPE: 295028 High Drywell Temperature (Mark I and II Only)

EA2 Ability to determine and/or interpret the following as they apply to High Drywell Temperature:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
EA2.01	Drywell temperature	4.0	4.2
EA2.02	Reactor pressure	3.6	3.7
EA2.03	Reactor water level	3.6	4.0
EA2.04	Drywell pressure	3.9	4.0
EA2.05	Torus/suppression chamber pressure	3.7	3.7
EA2.06	Torus/suppression chamber air space temperature	3.0	3.5

EPE: 295029 High Suppression Pool Water Level

K/A NO.	KNOWLEDGE	IMPORTANCE
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Suppression Pool Water Level: (CFR: 41.8 to 41.10)	
EK1.01	Containment integrity	3.8
EK1.02	Venting the suppression pool (Mark I containment)	4.0
EK2	Knowledge of the relationship between High Suppression Pool Water Level and the following systems or components: (CFR: 41.7 / 45.8)	
EK2.01	RHR/LPCI	3.1
EK2.02	HPCI	3.7
EK2.03	HPCS	3.3
EK2.04	Suppression pool cleanup system	2.7
EK2.05	Containment/drywell vacuum breakers	3.6
EK2.06	SRVs and discharge piping	3.7
EK2.07	Drywell/containment water level	3.6
EK2.08	Drywell/suppression chamber ventilation	3.5
EK2.09	RCIC	3.4
EK2.10	Radwaste	2.3
EK3	Knowledge of the reasons for the following responses or actions as they apply to High Suppression Pool Water Level: (CFR: 41.5 / 45.6)	
EK3.01	Emergency depressurization	4.1
EK3.02	Lowering suppression pool water level	3.7
EK3.03	Reactor SCRAM	3.5
EA1	Ability to operate and/or monitor the following as they apply to High Suppression Pool Water Level: (CFR: 41.7 / 45.6)	
EA1.01	HPCI	3.5
EA1.02	HPCS	3.4
EA1.03	RHR/LPCI	3.3
EA1.04	RCIC	3.5
EA1.05	Suppression pool level	3.7

EPE: 295029 High Suppression Pool Water Level

EA2 Ability to determine and/or interpret the following as they apply to High Suppression Pool Water Level:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
EA2.01	Suppression pool water level	4.0	4.0
EA2.02	Reactor pressure	3.5	3.3
EA2.03	Drywell/containment water level	3.8	3.6
EA2.04	Drywell/containment pressure	3.8	3.7

EPE: 295030 Low Suppression Pool Water Level		
K/A NO.	KNOWLEDGE	IMPORTANCE
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Low Suppression Pool Water Level: (CFR: 41.8 to 41.10)	
EK1.01	Steam condensation	3.9
EK1.02	Pump NPSH	3.9
EK1.03	Heat capacity	4.0
EK1.04	Downcomer/horizontal vent submergence	3.9
EK1.05	SRV discharge submergence	4.0
EK2	Knowledge of the relationship between Low Suppression Pool Water Level and the following systems or components: (CFR: 41.7 / 45.8)	
EK2.01	HPCI	4.0
EK2.02	RCIC	3.7
EK2.03	LPCS	3.8
EK2.04	RHR/LPCI	3.8
EK2.05	HPCS	3.8
EK2.06	Suppression pool makeup system(s)	3.5
EK2.07	DELETED	
EK2.08	Systems required to depressurize the reactor	3.9
EK2.09	DELETED	
EK2.10	Systems required to shut down the reactor	3.4
EK3	Knowledge of the reasons for the following responses or actions as they apply to Low Suppression Pool Water Level: (CFR: 41.5 / 45.6)	
EK3.01	Anticipated/emergency depressurization	4.0
EK3.02	HPCI shutdown	4.0
EK3.03	DELETED	
EK3.04	DELETED	
EK3.05	Suppression pool makeup system(s) operation	3.6
EK3.06	Reactor shutdown/SCRAM	4.0
EK3.07	NPSH/vortex limits	3.8

EPE: 295030 Low Suppression Pool Water Level

**EA1 Ability to operate and/or monitor the following as they apply to Low Suppression Pool Water Level:
(CFR: 41.7 / 45.6)**

EA1.01	ECCSs	4.0
EA1.02	RCIC	3.8
EA1.03	DELETED	
EA1.04	Suppression pool makeup system(s)	3.5
EA1.05	DELETED	
EA1.06	DELETED	
EA1.07	Plant process computer/parameter display systems	2.9
EA1.08	Systems required to shut down the reactor	3.4

**EA2 Ability to determine and/or interpret the following as they apply to Low Suppression Pool Water Level:
(CFR: 41.10 / 43.5 / 45.13)**

		RO	SRO
EA2.01	Suppression pool level	4.1	4.1
EA2.02	Suppression pool temperature	4.1	3.8
EA2.03	Reactor pressure	4.1	3.7
EA2.04	Drywell/suppression chamber differential pressure (Mark I, II)	4.2	3.5
EA2.05	ECCS/RCIC pump flow	4.1	3.4
EA2.06	Suppression chamber pressure	4.1	3.5

EPE: 295031 Reactor Low Water Level

K/A NO.	KNOWLEDGE	IMPORTANCE
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Reactor Low Water Level: (CFR: 41.8 to 41.10)	
EK1.01	Adequate core cooling	4.7
EK1.02	DELETED	
EK1.03	DELETED	
EK2	Knowledge of the relationship between Reactor Low Water Level and the following systems or components: (CFR: 41.7 / 45.8)	
EK2.01	Nuclear boiler instrumentation	4.2
EK2.02	DELETED	
EK2.03	Low-pressure core spray	4.3
EK2.04	Reactor core isolation cooling	4.2
EK2.05	RHR/LPCI	4.3
EK2.06	High-pressure coolant injection (HPCI)	4.1
EK2.07	High-pressure core spray	4.5
EK2.08	Automatic depressurization system	4.3
EK2.09	Recirculation system	3.5
EK2.10	Redundant reactivity control	3.8
EK2.11	Reactor protection system	4.3
EK2.12	PCIS/NSSSS	4.3
EK2.13	ARI/RPT/ATWS	4.1
EK2.14	Emergency generators	4.1
EK2.15	AC electrical distribution	3.6
EK2.16	Reactor water level control system	4.1
EK2.17	Feedwater system	3.9
EK2.18	Condensate system	3.5
EK2.19	Isolation condenser	3.6
EK2.20	Control rod drive hydraulic system	3.4
EK2.21	Alternate injection systems	3.8
EK2.22	Shutdown cooling system (RHR shutdown cooling mode)	3.6
EK2.23	Plant process computer/parameter display systems	2.9

EPE: 295031 Reactor Low Water Level

EK3 Knowledge of the reasons for the following responses or actions as they apply to Reactor Low Water Level:
(CFR: 41.5 / 45.6)

EK3.01	Automatic depressurization system actuation	4.3
EK3.02	Core submergence	4.7
EK3.03	Spray cooling	4.4
EK3.04	Steam cooling	4.3
EK3.05	Emergency depressurization	4.4

EA1 Ability to operate and/or monitor the following as they apply to Reactor Low Water Level:
(CFR: 41.7 / 45.6)

EA1.01	Low-pressure coolant injection (RHR)	4.3
EA1.02	High-pressure coolant injection	4.2
EA1.03	Low-pressure core spray	4.3
EA1.04	High-pressure core spray	4.3
EA1.05	Reactor core isolation cooling system	4.1
EA1.06	Automatic depressurization system	4.3
EA1.07	Safety/relief valves	4.1
EA1.08	Alternate injection systems	3.9
EA1.09	Isolation condenser	3.8
EA1.10	Control rod drive hydraulic system	3.6
EA1.11	Condensate system	3.6
EA1.12	Feedwater system	3.8
EA1.13	Reactor water level control system	4.1
EA1.14	PCIS/NSSSS	4.1

EA2 Ability to determine and/or interpret the following as they apply to Reactor Low Water Level:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
EA2.01	Reactor water level	4.7	4.6
EA2.02	DELETED		
EA2.03	Reactor pressure	4.2	4.0
EA2.04	Adequate core cooling	4.9	4.7

EPE: 295032 High Secondary Containment Area Temperature

K/A NO.	KNOWLEDGE	IMPORTANCE
----------------	------------------	-------------------

EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Secondary Containment Area Temperature: (CFR: 41.8 to 41.10)	
------------	---	--

EK1.01	DELETED	
EK1.02	Radiation releases	3.5
EK1.03	Secondary containment leakage detection	3.7
EK1.04	Impact of operating environment on components	3.1

EK2	Knowledge of the relationship between High Secondary Containment Area Temperature and the following systems or components: (CFR: 41.7 / 45.8)	
------------	---	--

EK2.01	Area/room coolers	3.5
EK2.02	Secondary containment ventilation	3.5
EK2.03	Fire protection system	2.8
EK2.04	PCIS/NSSSS	3.6
EK2.05	Temperature sensitive instrumentation	3.2
EK2.06	Area temperature monitoring system	3.4
EK2.07	Leak detection system	3.6
EK2.08	Systems required for safe shut-down	3.6

EK3	Knowledge of the reasons for the following responses or actions as they apply to High Secondary Containment Area Temperature: (CFR: 41.5 / 45.6)	
------------	--	--

EK3.01	RPV emergency/normal depressurization	4.0
EK3.02	Reactor SCRAM	4.0
EK3.03	Isolating affected systems	4.0

EA1	Ability to operate and/or monitor the following as they apply to High Secondary Containment Area Temperature: (CFR: 41.7 / 45.6)	
------------	--	--

EA1.01	Area temperature monitoring system	3.9
EA1.02	Leak detection system	3.8
EA1.03	Secondary containment ventilation	3.6
EA1.04	Fire protection system	2.9
EA1.05	Isolate damaged portions of affected systems	3.7
EA1.06	PCIS/NSSSS	3.7

EPE: 295032 High Secondary Containment Area Temperature

EA1.07 Fire protection system 2.9

EA2 Ability to determine and/or interpret the following as they apply to High Secondary Containment Area Temperature:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
EA2.01	Area temperature	3.9	4.0
EA2.02	Equipment operability	3.2	3.5
EA2.03	Cause of high area temperature	3.7	3.6

EPE: 295033 High Secondary Containment Area Radiation Levels

K/A NO.	KNOWLEDGE	IMPORTANCE
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Secondary Containment Area Radiation Levels: (CFR: 41.8 to 41.10)	
EK1.01	DELETED	
EK1.02	DELETED	
EK1.03	Radiation releases	4.1
EK1.04	Maximum normal operating radiation limit	3.9
EK1.05	Maximum safe operating radiation limit	4.1
EK2	Knowledge of the relationship between High Secondary Containment Area Radiation Levels and the following systems or components: (CFR: 41.7 / 45.8)	
EK2.01	Area radiation monitoring system	3.7
EK2.02	Process radiation monitoring system	3.5
EK2.03	Secondary containment ventilation	3.6
EK2.04	SGTS/FRVS	4.0
EK2.05	Primary system discharging into secondary containment	4.2
EK2.06	Systems required to suppress a fire	3.5
EK2.07	Systems required for adequate core cooling	4.2
EK2.08	Systems required to shut down the reactor	4.1
EK2.09	Systems required to protect the containment	4.1
EK2.10	Systems required to depressurize the reactor	4.1
EK3	Knowledge of the reasons for the following responses or actions as they apply to High Secondary Containment Area Radiation Levels: (CFR: 41.5 / 45.6)	
EK3.01	Anticipated/emergency depressurization	4.1
EK3.02	Reactor shutdown/SCRAM	4.1
EK3.03	Isolating affected systems	4.2
EK3.04	DELETED	
EK3.05	DELETED	
EK3.06	Operating ventilation systems	3.6

EPE: 295033 High Secondary Containment Area Radiation Levels

EA1 Ability to operate and/or monitor the following as they apply to High Secondary Containment Area Radiation Levels:
(CFR: 41.7 / 45.6)

EA1.01	Area radiation monitoring system	3.8
EA1.02	Process radiation monitoring system	3.6
EA1.03	Secondary containment ventilation	3.6
EA1.04	SGTS/FRVS	4.0
EA1.05	DELETED	
EA1.06	DELETED	
EA1.07	DELETED	
EA1.08	DELETED	
EA1.09	Systems required to depressurize the reactor	4.2
EA1.10	Primary system discharging into secondary containment	4.3
EA1.11	Systems required to suppress a fire	3.5
EA1.12	Systems required for adequate core cooling	4.2
EA1.13	Systems required to shut down the reactor	4.1
EA1.14	Systems required to protect the containment	4.1

EA2 Ability to determine and/or interpret the following as they apply to High Secondary Containment Area Radiation Levels:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
EA2.01	Area radiation levels	4.1	4.1
EA2.02	DELETED		
EA2.03	Source of high area radiation	4.0	3.8
EA2.04	Emergency plan	3.6	4.3

EPE: 295034 Secondary Containment Ventilation High Radiation

K/A NO.	KNOWLEDGE	IMPORTANCE
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Secondary Containment Ventilation High Radiation: (CFR: 41.8 to 41.10)	
EK1.01	DELETED	
EK1.02	Radiation releases	3.9
EK2	Knowledge of the relationship between Secondary Containment Ventilation High Radiation and the following systems or components: (CFR: 41.7 / 45.8)	
EK2.01	Process radiation monitoring system	3.7
EK2.02	Area radiation monitoring system	3.3
EK2.03	SGTS/FRVS	4.0
EK2.04	Secondary containment ventilation	3.8
EK2.05	DELETED	
EK2.06	PCIS/NSSSS	3.7
EK3	Knowledge of the reasons for the following responses or actions as they apply to Secondary Containment Ventilation High Radiation: (CFR: 41.5 / 45.6)	
EK3.01	Isolating secondary containment ventilation	4.1
EK3.02	Starting SGTS/FRVS	4.0
EK3.03	Personnel evacuation	3.8
EK3.04	Secondary containment ventilation operation	3.6
EK3.05	Manual SCRAM	3.5
EA1	Ability to operate and/or monitor the following as they apply to Secondary Containment Ventilation High Radiation: (CFR: 41.7 / 45.6)	
EA1.01	Area radiation monitoring system	3.5
EA1.02	Process radiation monitoring system	3.7
EA1.03	Secondary containment ventilation	3.8
EA1.04	SGTS/FRVS	4.0
EA1.05	DELETED	

EPE: 295034 Secondary Containment Ventilation High Radiation

EA2 Ability to determine and/or interpret the following as they apply to Secondary Containment Ventilation High Radiation:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
EA2.01	Ventilation radiation levels	3.9	4.0
EA2.02	Source of high radiation levels	3.6	3.6

EPE: 295035 Secondary Containment High Differential Pressure

K/A NO.	KNOWLEDGE	IMPORTANCE	
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Secondary Containment High Differential Pressure: (CFR: 41.8 to 41.10)		
EK1.01	Secondary containment integrity	3.9	
EK1.02	Radiation release	3.8	
EK2	Knowledge of the relationship between Secondary Containment High Differential Pressure and the following systems or components: (CFR: 41.7 / 45.8)		
EK2.01	Secondary containment ventilation	3.8	
EK2.02	SGTS/FRVS	3.9	
EK2.03	DELETED		
EK2.04	Blow-out panels	3.5	
EK3	Knowledge of the reasons for the following responses or actions as they apply to Secondary Containment High Differential Pressure: (CFR: 41.5 / 45.6)		
EK3.01	Blow-out panel operation	3.3	
EK3.02	Secondary containment ventilation alignment	3.7	
EA1	Ability to operate and/or monitor the following as they apply to Secondary Containment High Differential Pressure: (CFR: 41.7 / 45.6)		
EA1.01	Secondary containment ventilation	3.7	
EA1.02	SGTS/FRVS	3.8	
EA1.03	Blowout panels	3.0	
EA2	Ability to determine and/or interpret the following as they apply to Secondary Containment High Differential Pressure: (CFR: 41.8 to 41.10)	RO	SRO
EA2.01	Secondary containment pressure	4.0	3.9
EA2.02	Radiation release rate	4.1	3.9
EA2.03	Lights and alarms	3.7	3.3

EPE: 295036 Secondary Containment High Sump/Area Water Level

K/A NO.	KNOWLEDGE	IMPORTANCE
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Secondary Containment High Sump/Area Water Level: (CFR: 41.8 to 41.10)	
EK1.01	Radiation releases	3.2
EK1.02	Electrical ground/circuit malfunction	2.7
EK1.03	Maximum normal operating limit	3.9
EK1.04	Maximum safe operating limit	4.1
EK1.05	Identification of a primary system discharging to secondary containment	4.2
EK2	Knowledge of the relationship between Secondary Containment High Sump/Area Water Level and the following systems or components: (CFR: 41.7 / 45.8)	
EK2.01	Equipment and floor drain sumps and pumps	3.4
EK2.02	DELETED	
EK2.03	Radwaste system	2.9
EK2.04	Area/room/sump level indicators	3.5
EK3	Knowledge of the reasons for the following responses or actions as they apply to Secondary Containment High Sump/Area Water Level: (CFR: 41.5 / 41.10 / 45.6)	
EK3.01	Emergency depressurization	4.0
EK3.02	Reactor SCRAM	3.8
EK3.03	Isolating affected systems	3.9
EK3.04	Pumping secondary containment sumps	3.2
EK3.05	Allowance for continued operation of a system discharging into an area	3.6
EK3.06	Normal reactor shutdown	3.3
EA1	Ability to operate and/or monitor the following as they apply to Secondary Containment High Sump/Area Water Level: (CFR: 41.7 / 45.6 / 45.8)	
EA1.01	Equipment and floor drain sumps and pumps	3.2
EA1.02	Affected systems so as to isolate damaged portions	3.6
EA1.03	Radwaste system	2.7
EA1.04	DELETED	
EA1.05	Systems for emergency depressurization	3.9

EPE: 295036 Secondary Containment High Sump/Area Water Level

EA2 Ability to determine and/or interpret the following as they apply to Secondary Containment High Sump/Area Water Level:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
EA2.01	Operability of components within the affected area	3.3	3.7
EA2.02	Water level in the affected area	3.5	3.8
EA2.03	Cause of the high water level	3.6	3.6

**EPE: 295037 SCRAM Condition Present and Reactor Power Above APRM
Downscale or Unknown**

K/A NO.	KNOWLEDGE	IMPORTANCE
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to SCRAM Condition Present and Reactor Power Above APRM Downscale or Unknown: (CFR: 41.8 to 41.10)	
EK1.01	Reactor pressure effects on reactor power	4.3
EK1.02	Reactor water level effects on reactor power	4.3
EK1.03	Boron effects on reactor power	4.1
EK1.04	Hot shutdown boron weight	3.7
EK1.05	Cold shutdown boron weight	3.7
EK1.06	Cooldown effects on reactor power	4.1
EK1.07	Shutdown conditions	4.1
EK2	Knowledge of the relationship between SCRAM Condition Present and Reactor Power Above APRM Downscale or Unknown and the following systems or components: (CFR: 41.7 41.8 / 45.8)	
EK2.01	RPS	4.3
EK2.02	Redundant reactivity control system	4.0
EK2.03	DELETED	
EK2.04	Standby liquid control system	4.2
EK2.05	CRD hydraulic system	3.9
EK2.06	CRD mechanisms	3.2
EK2.07	APRM/Local power range monitor system	3.9
EK2.08	Plant process computer/parameter display systems	3.2
EK2.09	DELETED	
EK2.10	DELETED	
EK2.11	RMCS (BWR 2, 3, 4, 5)	3.9
EK2.12	RCIS (BWR 6)	3.7
EK2.13	Systems used for alternate boron injection	3.6
EK2.14	RPIS (BWR 2, 3, 4, 5)	4.0
EK2.15	Recirculation system	3.7
EK2.16	Recirculation flow control system	3.8
EK2.17	Reactor water level control system	4.1
EK2.18	Reactor feedwater system	3.8
EK2.19	High-pressure coolant injection	3.7
EK2.20	High-pressure core spray	3.8
EK2.21	Low-pressure core spray	3.8
EK2.22	RHR/LPCI system	3.8

**EPE: 295037 SCRAM Condition Present and Reactor Power Above APRM
Downscale or Unknown**

EK2.23	SRVs	3.9
EK2.24	Reactor/turbine pressure regulating system	3.9
EK2.25	Rod worth minimizer	3.0

**EK3 Knowledge of the reasons for the following responses or actions as they apply to SCRAM Condition Present and Reactor Power Above APRM Downscale or Unknown:
(CFR: 41.5 / 41.7 / 45.6)**

EK3.01	Recirculation pump trip/runback	3.9
EK3.02	Boron injection	4.2
EK3.03	Reactor water level control strategies	4.3
EK3.04	DELETED	
EK3.05	DELETED	
EK3.06	Maintaining heat sinks external to the containment	4.1
EK3.07	Alternate control rod insertion methods	4.2
EK3.08	Initiation of ATWS circuitry	4.1
EK3.09	Bypassing rod insertion blocks	3.8

**EA1 Ability to operate and/or monitor the following as they apply to SCRAM Condition Present and Reactor Power Above APRM Downscale or Unknown:
(CFR: 41.7 / 45.5 to 45.8)**

EA1.01	Reactor protection system	4.2
EA1.02	Redundant reactivity control system	4.0
EA1.03	DELETED	
EA1.04	Standby liquid control system	4.2
EA1.05	CRD hydraulics systems	3.9
EA1.06	APRM/LPRM system	3.9
EA1.07	RMCS (BWR 2, 3, 4, 5)	4.0
EA1.08	RCIS (BWR 6)	3.8
EA1.09	Plant process computer/parameter display systems	3.3
EA1.10	Systems used for alternate boron injection	3.7
EA1.11	DELETED	
EA1.12	Recirculation system	3.7
EA1.13	Recirculation flow control system	3.8
EA1.14	Reactor feedwater system	3.9
EA1.15	SRVs	3.9
EA1.16	Reactor/turbine pressure regulating system	3.7
EA1.17	Rod worth minimizer	3.5

**EPE: 295037 SCRAM Condition Present and Reactor Power Above APRM
Downscale or Unknown**

EA1.18 RPIS 3.8

**EA2 Ability to determine and/or interpret the following as
they apply to SCRAM Condition Present and Reactor
Power Above APRM Downscale or Unknown:
(CFR: 41.10 / 43.5 / 45.13)**

		RO	SRO
EA2.01	Reactor power	4.3	4.7
EA2.02	Reactor water level	4.3	4.4
EA2.03	Standby liquid control system tank level	3.8	4.1
EA2.04	Suppression pool temperature	3.8	4.4
EA2.05	Control rod position	4.2	4.5
EA2.06	Reactor pressure	4.2	4.3
EA2.07	Containment conditions/isolations	3.7	4.1
EA2.08	SCRAM discharge volume level	3.6	4.0
EA2.09	SCRAM air header pressure	3.5	4.0

EPE: 295038 High Offsite Radioactivity Release Rate

K/A NO. KNOWLEDGE IMPORTANCE

EK1 Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Offsite Radioactivity Release Rate:
(CFR: 41.8 to 41.10)

EK1.01	DELETED	
EK1.02	DELETED	
EK1.03	DELETED	
EK1.04	Elevated vs. ground level release	3.8
EK1.05	Exceeding limits for gaseous/liquid releases	4.1
EK1.06	Filtered vs. nonfiltered release	3.8

EK2 Knowledge of the relationship between High Offsite Radioactivity Release Rate and the following systems or components:
(CFR: 41.7 / 45.8)

EK2.01	Radwaste system	3.3
EK2.02	Offgas system	3.8
EK2.03	Plant ventilation systems	3.8
EK2.04	DELETED	
EK2.05	DELETED	
EK2.06	Process radiation monitoring system	3.8
EK2.07	Control room heating, ventilation and air conditioning	3.5
EK2.08	Plant process computer/parameter display systems	3.2
EK2.09	Post-accident sample system	3.0
EK2.10	Condenser air removal system	3.2
EK2.11	MSIV leakage control	3.0
EK2.12	Feedwater leakage control	2.9
EK2.13	SGTS/FRVS	4.0
EK2.14	Main and reheat steam system	2.7
EK2.15	Primary containment system and auxiliaries	3.7

EK3 Knowledge of the reasons for the following responses or actions as they apply to High Offsite Radioactivity Release Rate:
(CFR: 41.5 / 45.6)

EK3.01	DELETED	
EK3.02	System isolations	4.1
EK3.03	Control room ventilation system isolation	3.8
EK3.04	Emergency depressurization	4.1
EK3.05	Reactor shutdown/SCRAM	4.1

EPE: 295038 High Offsite Radioactivity Release Rate

EK3.06 Elevated vs. ground level release 3.6

EA1 Ability to operate and/or monitor the following as they apply to High Offsite Radioactivity Release Rate:
(CFR: 41.7 / 45.6)

EA1.01	DELETED	
EA1.02	Meteorological instrumentation	3.7
EA1.03	Process radiation monitoring system	3.8
EA1.04	Plant process computer/parameter display systems	3.4
EA1.05	Post-accident sample system	3.0
EA1.06	Plant ventilation systems	3.6
EA1.07	Control room heating, ventilation, and air conditioning	3.7
EA1.08	MSIV leakage control	3.1
EA1.09	Feedwater leakage control	2.9
EA1.10	SGTS/FRVS	3.9
EA1.11	Main and reheat steam system	2.9
EA1.12	Primary containment system and auxiliaries	3.8
EA1.13	Radwaste system	3.0
EA1.14	Offgas system	3.6
EA1.15	Condenser air removal system	3.3

EA2 Ability to determine and/or interpret the following as they apply to High Offsite Radioactivity Release Rate:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
EA2.01	DELETED		
EA2.02	Total number of curies released or release rate/duration	3.2	3.6
EA2.03	Radiation levels	3.4	4.0
EA2.04	Source of offsite release	3.8	3.9
EA2.05	Emergency plan implementation	3.6	4.5
EA2.06	Meteorological data	3.7	3.8

EPE: 500000 High Containment Hydrogen Concentration

K/A NO.	KNOWLEDGE	IMPORTANCE
EK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Containment Hydrogen Concentration: (CFR: 41.8 to 41.10)	
EK1.01	Containment integrity	4.0
EK1.02	Hydrogen generation	3.7
EK1.03	Hydrogen ignition/deflagration	3.8
EK1.04	Drywell nitrogen purge	3.8
EK1.05	Venting	3.9
EK2	Knowledge of the relationship between High Containment Hydrogen Concentration and the following systems or components: (CFR: 41.7 / 45.8)	
EK2.01	Containment hydrogen monitors	3.8
EK2.02	Containment oxygen monitors	3.8
EK2.03	Containment atmosphere control system	3.5
EK2.04	Drywell recirculating fan	2.9
EK2.05	Hydrogen and oxygen recombiners	3.5
EK2.06	Wetwell spray	3.3
EK2.07	Drywell vent	3.7
EK2.08	Wetwell vent	3.7
EK2.09	Drywell nitrogen purge	3.6
EK2.10	Drywell hydrogen mixing compressors (BWR 6)	3.6
EK2.11	Hydrogen igniters (BWR 6)	3.7
EK3	Knowledge of the reasons for the following responses or actions as they apply to High Containment Hydrogen Concentration: (CFR: 41.5 / 45.6)	
EK3.01	Initiation of containment atmosphere control	3.5
EK3.02	Operation of drywell recirculating fans	3.0
EK3.03	Operation of hydrogen and oxygen recombiners	3.4
EK3.04	Emergency depressurization	3.9
EK3.05	Operation of wetwell (suppression pool) sprays	3.5
EK3.06	Operation of wetwell vent	3.7
EK3.07	Operation of drywell vent	3.7

EPE:	500000 High Containment Hydrogen Concentration		
EK3.08	Operation of drywell nitrogen purge system	3.6	
EK3.09	Operation of drywell hydrogen mixing compressors (BWR 6)	3.5	
EK3.10	Operation of the hydrogen igniters (BWR 6)	3.6	
EK3.11	Operation of the containment/drywell hydrogen monitors	3.8	
EK3.12	Initiation of containment venting	3.8	
EA1	Ability to operate and/or monitor the following as they apply to High Containment Hydrogen Concentration: (CFR: 41.7/45.6)		
EA1.01	Primary containment hydrogen instrumentation	3.7	
EA1.02	Primary containment oxygen instrumentation	3.6	
EA1.03	Containment atmosphere controls	3.4	
EA1.04	Drywell recirculating fans	3.2	
EA1.05	Wetwell sprays	3.5	
EA1.06	Drywell sprays	3.6	
EA1.07	Nitrogen purge	3.5	
EA1.08	Drywell vent	3.8	
EA2	Ability to determine and/or interpret the following as they apply to High Containment Hydrogen Concentration: (CFR 41.10 / 43.5 / 45.13)		
		RO	SRO
EA2.01	Hydrogen monitoring availability	3.4	3.8
EA2.02	Oxygen monitoring availability	3.1	3.8
EA2.03	Hydrogen concentration limits for drywell	3.3	3.8
EA2.04	Hydrogen concentration limits for wetwell	3.2	3.9
EA2.05	Hydrogen concentration limits for containment	3.4	3.9

4.2	Generic Abnormal Plant Evolutions	Page
295001	Partial or Complete Loss of Forced Core Flow Circulation.....	4.2-3
295002	Loss of Main Condenser Vacuum.....	4.2-5
295003	Partial or Complete Loss of AC Power.....	4.2-7
295004	Partial or Complete Loss of DC Power.....	4.2-9
295005	Main Turbine Generator Trip.....	4.2-11
295006	SCRAM.....	4.2-13
295007	High Reactor Pressure.....	4.2-15
295008	High Reactor Water Level.....	4.2-17
295009	Low Reactor Water Level.....	4.2-19
295010	High Drywell Pressure.....	4.2-21
295011	High Containment Temperature (Mark III Containment Only).....	4.2-23
295012	High Drywell Temperature.....	4.2-24
295013	High Suppression Pool Water Temperature.....	4.2-25
295014	Inadvertent Reactivity Addition.....	4.2-26
295015	Incomplete SCRAM—DELETED.....	4.2-28
295016	Control Room Abandonment.....	4.2-29
295017	High Offsite Radioactive Release Rate.....	4.2-31
295018	Partial or Complete Loss of Component Cooling Water.....	4.2-33
295019	Partial or Complete Loss of Instrument Air.....	4.2-35
295020	Inadvertent Containment Isolation.....	4.2-37
295021	Loss of Shutdown Cooling.....	4.2-39
295022	Loss of Control Rod Drive Pumps.....	4.2-41
295023	Refueling Accidents.....	4.2-43
600000	Plant Fire on Site.....	4.2-45
700000	Generator Voltage and Electric Grid Disturbances.....	4.2-47

APE: 295001 Partial or Complete Loss of Forced Core Flow Circulation

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Partial or Complete Loss of Forced Core Flow Circulation: (CFR: 41.8 to 41.10)	
AK1.01	Natural circulation	3.7
AK1.02	Power/flow distribution	3.7
AK1.03	Thermal limits	4.1
AK1.04	Thermal-hydraulic instabilities	4.3
AK2	Knowledge of the relationship between Partial or Complete Loss of Forced Core Flow Circulation and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	Recirculation system	4.1
AK2.02	Nuclear boiler instrumentation	3.6
AK2.03	Reactor water level control system	3.4
AK2.04	Reactor/turbine pressure regulating system	3.0
AK2.05	DELETED	
AK2.06	DELETED	
AK2.07	DELETED	
AK2.08	DELETED	
AK2.09	Reactor water cleanup system	2.8
AK2.10	Power range monitoring system	3.6
AK2.11	Reactor manual control system (BWR 2, 3, 4, 5)	3.1
AK2.12	Recirculation flow control system	3.5
AK2.13	RCIS (BWR 6)	3.2
AK2.14	Plant process computer/parameter display systems	2.9
AK3	Knowledge of the reasons for the following responses or actions as they apply to Partial or Complete Loss of Forced Core Flow Circulation: (CFR: 41.5 / 45.6)	
AK3.01	Reactor water level response	3.7
AK3.02	Reactor power response	4.0
AK3.03	Idle loop/reverse flow	3.8
AK3.04	Reactor SCRAM	4.1
AK3.05	Reduced loop operating requirements	3.7
AK3.06	Core flow response	3.7

APE: 295001 Partial or Complete Loss of Forced Core Flow Circulation

AK3.07	Recirculation pump discharge/suction valve manipulation	3.3
AK3.08	Thermal stratification	3.7

AA1 Ability to operate and/or monitor the following as they apply to Partial or Complete Loss of Forced Core Flow Circulation:
(CFR: 41.7 / 45.6)

AA1.01	Recirculation system	4.0
AA1.02	RPS	3.8
AA1.03	Reactor manual control system (BWR 2, 3, 4, 5)	3.4
AA1.04	RCIS (BWR 6)	3.4
AA1.05	Recirculation flow control system	3.7
AA1.06	Power range monitoring system	3.6
AA1.07	Nuclear boiler instrumentation system	3.4
AA1.08	DELETED	
AA1.09	Reactor water level control system	3.6
AA1.10	Reactor/turbine pressure regulating system	2.9
AA1.11	Reactor water cleanup system	2.8

AA2 Ability to determine and/or interpret the following as they apply to Partial or Complete Loss of Forced Core Flow Circulation:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Power/flow map	4.4	4.3
AA2.02	Neutron monitoring	4.0	4.0
AA2.03	Core flow	4.2	4.0
AA2.04	Individual jet pump flows	3.4	3.4
AA2.05	Jet pump operability	3.3	3.5
AA2.06	DELETED		
AA2.07	Reactor power	4.1	4.0
AA2.08	Reactor water level	4.1	3.6
AA2.09	Reactor pressure	3.8	3.4
AA2.10	Recirculation system/RPV differential temperatures	3.6	3.7
AA2.11	Individual loop flow(s)	3.6	3.6
AA2.12	Thermal-hydraulic instabilities	4.2	4.2
AA2.13	Thermal limits	4.1	3.9

APE: 295002 Loss of Main Condenser Vacuum

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Loss of Main Condenser Vacuum: (CFR: 41.8 to 41.10)	
AK1.01	DELETED	
AK1.02	DELETED	
AK1.03	Loss of heat sink	4.1
AK1.04	Offgas flow changes	3.4
AK2	Knowledge of the relationship between Loss of Main Condenser Vacuum and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	RPS	3.8
AK2.02	Main turbine generator and auxiliaries	3.7
AK2.03	PCIS/NSSSS	3.5
AK2.04	Reactor/turbine pressure regulating system	3.6
AK2.05	Feedwater system	3.1
AK2.06	Condensate system	3.2
AK2.07	Offgas system	3.6
AK2.08	Circulating water system	3.5
AK2.09	DELETED	
AK2.10	Recirculation flow control system	2.7
AK2.11	DELETED	
AK2.12	Reactor manual control system (BWR 2, 3, 4, 5)	2.7
AK2.13	RCIS (BWR 6)	2.8
AK2.14	Condenser air removal system	3.6
AK3	Knowledge of the reasons for the following responses or actions as they apply to Loss of Main Condenser Vacuum: (CFR: 41.5 / 45.6)	
AK3.01	Reactor SCRAM	3.9
AK3.02	Turbine trip	4.1
AK3.03	Reactor feedwater pump turbine trip	3.7
AK3.04	Bypass valve closure	4.0
AK3.05	Main steam isolation valve closure	3.8

APE: 295002 Loss of Main Condenser Vacuum

AK3.06	DELETED	
AK3.07	DELETED	
AK3.08	Recirculation flow control system runbacks	3.5
AK3.09	Reactor power reduction	3.7
AK3.10	Steam jet air ejector operation	3.4
AK3.11	Bypass augmented offgas system	3.1

**AA1 Ability to operate and/or monitor the following as they apply to Loss of Main Condenser Vacuum:
(CFR: 41.7 / 45.6)**

AA1.01	Condensate system	2.9
AA1.02	Offgas system	3.5
AA1.03	RPS	3.7
AA1.04	PCIS/NSSSS	3.6
AA1.05	Main turbine generator and auxiliaries system	3.4
AA1.06	Reactor/turbine pressure regulating system	3.6
AA1.07	Circulating water system	3.4
AA1.08	Recirculation flow control system	3.2
AA1.09	Reactor manual control system (BWR 2, 3, 4, 5)	3.2
AA1.10	Feedwater system	3.2
AA1.11	RCIS (BWR 6)	3.0
AA1.12	Condenser air removal system	3.5

**AA2 Ability to determine and/or interpret the following as they apply to Loss of Main Condenser Vacuum:
(CFR: 41.10 / 43.5 / 45.13)**

		RO	SRO
AA2.01	Condenser vacuum	4.3	4.2
AA2.02	Reactor power	4.1	3.7
AA2.03	Generator output	3.6	3.3
AA2.04	Offgas system flow	3.9	3.6
AA2.05	Condensate temperature	3.4	2.8
AA2.06	Condensate flow	3.3	2.7
AA2.07	Turbine limitations	3.7	3.4

APE: 295003 Partial or Complete Loss of AC Power

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Partial or Complete Loss of AC Power: (CFR: 41.8 to 41.10)	
AK1.01	Battery capacity	3.8
AK1.02	Load shedding	3.8
AK1.03	DELETED	
AK1.04	DELETED	
AK1.05	DELETED	
AK1.06	Station blackout	4.3
AK1.07	Load sequencing	3.8
AK1.08	Emergency diesel generator load limits	4.0
AK2	Knowledge of the relationship between Partial or Complete Loss of AC Power and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	Station batteries	4.0
AK2.02	Emergency generators	4.3
AK2.03	AC electrical distribution system	3.9
AK2.04	AC electrical loads	3.8
AK2.05	Decay heat removal systems	4.2
AK2.06	DC electrical loads	3.8
AK2.07	DC electrical distribution system	3.7
AK3	Knowledge of the reasons for the following responses or actions as they apply to Partial or Complete Loss of AC Power: (CFR: 41.5 / 45.6)	
AK3.01	Manual and automatic bus transfer	3.7
AK3.02	DELETED	
AK3.03	Load shedding	3.8
AK3.04	DELETED	
AK3.05	DELETED	
AK3.06	Containment isolation	3.5
AK3.07	DELETED	
AK3.08	Reactor cooldown	3.8

APE: 295003 Partial or Complete Loss of AC Power

AA1 Ability to operate and/or monitor the following as they apply to Partial or Complete Loss of AC Power:
(CFR: 41.7 / 45.6)

AA1.01	AC electrical distribution system	4.0
AA1.02	Emergency generators	4.5
AA1.03	Decay heat removal systems	4.2
AA1.04	DC electrical distribution system	3.8
AA1.05	Station batteries	3.8
AA1.06	AC electrical loads	3.8
AA1.07	DC electrical loads	3.8
AA1.08	Station blackout instrumentation	4.3

AA2 Ability to determine and/or interpret the following as they apply to Partial or Complete Loss of AC Power:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Partial or complete loss of AC power	4.0	4.1
AA2.02	Reactor power, pressure, and level	4.4	4.3
AA2.03	Battery status	3.9	3.9
AA2.04	System lineups	3.6	3.6
AA2.05	DELETED		

APE: 295004 Partial or Complete Loss of DC Power

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Partial or Complete Loss of DC Power: (CFR: 41.8 to 41.10)	
AK1.01	DELETED	
AK1.02	Redundant DC power supplies	3.8
AK1.03	DELETED	
AK1.04	Battery capacity	3.9
AK1.05	Loss of breaker protection	3.7
AK1.06	Prevention of inadvertent system(s) actuation upon restoration of DC power	3.7
AK2	Knowledge of the relationship between Partial or Complete Loss of DC Power and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	Battery charger	3.8
AK2.02	Batteries	4.1
AK2.03	DC electrical loads	3.8
AK2.04	AC electrical distribution system	3.7
AK3	Knowledge of the reasons for the following responses or actions as they apply to Partial or Complete Loss of DC Power: (CFR: 41.5 / 45.6)	
AK3.01	Load shedding	3.9
AK3.02	Ground isolation/fault determination	3.3
AK3.03	DELETED	
AA1	Ability to operate and/or monitor the following as they apply to Partial or Complete Loss of DC Power: (CFR: 41.7 / 45.6)	
AA1.01	DC electrical distribution	3.8
AA1.02	Systems necessary to ensure safe plant shutdown	4.3
AA1.03	AC electrical distribution	3.5
AA1.04	DC electrical loads	3.7

APE: 295004 Partial or Complete Loss of DC Power

AA2 Ability to determine and/or interpret the following as they apply to Partial or Complete Loss of DC Power:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Partial or complete loss of DC power	4.0	4.1
AA2.02	DELETED		
AA2.03	Battery parameters	3.8	3.7
AA2.04	System lineups	3.2	3.5

APE: 295005 Main Turbine Generator Trip

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Main Turbine Generator Trip: (CFR: 41.8 to 41.10)	
AK1.01	Reactor pressure control	4.3
AK1.02	Core thermal limits	3.8
AK1.03	Reactor level control	3.8
AK2	Knowledge of the relationship between Main Turbine Generator Trip and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	RPS	4.1
AK2.02	DELETED	
AK2.03	Recirculation system	3.5
AK2.04	Main turbine generator and auxiliaries	3.1
AK2.05	Main and reheat steam system	2.9
AK2.06	DELETED	
AK2.07	Reactor/turbine pressure regulating system	3.9
AK2.08	AC electrical distribution	3.4
AK2.09	Feedwater (BWR 2)	3.4
AK2.10	Reactor water level control system	3.4
AK2.11	Recirculation flow control system	3.0
AK2.12	Reactor manual control system (BWR 2, 3, 4, 5)	2.9
AK2.13	RCIS (BWR 6)	3.4
AK2.14	RCIC (BWR 6)	3.6
AK3	Knowledge of the reasons for the following responses or actions as they apply to Main Turbine Generator Trip: (CFR: 41.5 / 45.6)	
AK3.01	Reactor SCRAM	4.1
AK3.02	Recirculation pump downshift/trip	3.5
AK3.03	Feedwater temperature decrease	3.2
AK3.04	Main generator trip	3.2
AK3.05	Extraction steam/moisture separator isolations	2.8
AK3.06	Realignment of electrical distribution	3.6
AK3.07	Turbine bypass valve operation	3.9
AK3.08	DELETED	

APE: 295005 Main Turbine Generator Trip

AA1 Ability to operate and/or monitor the following as they apply to Main Turbine Generator Trip:
(CFR: 41.7 / 45.6)

AA1.01	Recirculation system	3.3
AA1.02	RPS	3.9
AA1.03	Reactor manual control system	3.0
AA1.04	Main turbine generator and auxiliaries	2.9
AA1.05	Reactor/turbine pressure regulating system	3.9
AA1.06	Condenser vacuum breaker(s)	2.7
AA1.07	AC electrical distribution	3.4
AA1.08	RCIS (BWR 6)	3.0
AA1.09	Reactor water level control system	3.7
AA1.10	Recirculation flow control system	3.0
AA1.11	RCIC (BWR 6)	3.5

AA2 Ability to determine and/or interpret the following as they apply to Main Turbine Generator Trip:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	DELETED		
AA2.02	DELETED		
AA2.03	Turbine valve position	4.4	3.6
AA2.04	Reactor pressure	4.5	4.3
AA2.05	Reactor power	4.4	4.1
AA2.06	Feedwater temperature	3.5	2.9
AA2.07	Reactor water level	4.4	3.9
AA2.08	Electrical distribution status	3.9	3.6
AA2.09	Turbine limitations	2.9	3.0

APE: 295006 SCRAM

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to SCRAM: (CFR: 41.8 to 41.10)	
AK1.01	Decay heat generation and removal	4.0
AK1.02	Shutdown margin	3.6
AK1.03	Reactivity control	3.9
AK1.04	Pressure control	4.1
AK2	Knowledge of the relationship between SCRAM and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	RPS	4.5
AK2.02	Reactor water level control system	4.1
AK2.03	CRD hydraulic system	3.9
AK2.04	Turbine trip logic	3.7
AK2.05	CRD mechanism	3.4
AK2.06	DELETED	
AK2.07	DELETED	
AK3	Knowledge of the reasons for the following responses or actions as they apply to SCRAM: (CFR: 41.5 / 45.6)	
AK3.01	Reactor water level response	4.0
AK3.02	Reactor power response	4.2
AK3.03	Reactor pressure response	4.0
AK3.04	Reactor water level setpoint setdown	3.7
AK3.05	Direct turbine generator trip	3.7
AK3.06	Recirculation pump speed reduction	3.7
AA1	Ability to operate and/or monitor the following as they apply to SCRAM: (CFR: 41.7 / 45.6)	
AA1.01	RPS	4.3
AA1.02	Reactor water level control system	4.2
AA1.03	Reactor/turbine pressure regulating system	4.2
AA1.04	Recirculation system	3.8
AA1.05	Neutron monitoring system	3.9

APE: 295006 SCRAM

AA1.06	CRD hydraulic system	3.7
AA1.07	Control rod position	4.2

AA2 Ability to determine and/or interpret the following as they apply to SCRAM:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Reactor power	4.3	4.4
AA2.02	Control rod position	4.4	4.5
AA2.03	Reactor water level	4.3	4.1
AA2.04	Reactor pressure	4.3	4.1
AA2.05	Whether a reactor SCRAM has occurred	4.6	4.5
AA2.06	Cause of reactor SCRAM	3.6	3.7

APE: 295007 High Reactor Pressure

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Reactor Pressure: (CFR: 41.5 / 41.10)	
AK1.01	Pump shutoff head	3.6
AK1.02	Decay heat generation	3.1
AK1.03	Pressure effects on reactor power	4.1
AK1.04	Turbine load	3.3
AK2	Knowledge of the relationship between High Reactor Pressure and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	Reactor/turbine pressure regulating system	4.0
AK2.02	DELETED	
AK2.03	DELETED	
AK2.04	DELETED	
AK2.05	Shutdown cooling system (RHR shutdown cooling mode)	3.7
AK2.06	DELETED	
AK2.07	RPS	4.4
AK3	Knowledge of the reasons for the following responses or actions as they apply to High Reactor Pressure: (CFR: 41.5 / 45.6)	
AK3.01	DELETED	
AK3.02	DELETED	
AK3.03	DELETED	
AK3.04	DELETED	
AK3.05	DELETED	
AK3.06	Reactor/turbine pressure regulating system operation	4.0
AK3.07	Shutdown cooling system (RHR shutdown cooling mode) operation	3.6
AK3.08	Reducing reactor power	3.9
AA1	Ability to operate and/or monitor the following as they apply to High Reactor Pressure: (CFR: 41.7 / 45.6)	
AA1.01	DELETED	
AA1.02	DELETED	
AA1.03	DELETED	

APE: 295007 High Reactor Pressure

AA1.04	DELETED		
AA1.05	Reactor/turbine pressure regulating system		3.9
AA1.06	Shutdown cooling system (RHR shutdown cooling mode)		3.6
AA1.07	Reactor manual control system		3.4
AA1.08	Recirculation flow control system		3.5
AA1.09	RCIS (BWR 6)		3.0

AA2 Ability to determine and/or interpret the following as they apply to High Reactor Pressure:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Reactor pressure	4.6	4.2
AA2.02	Reactor power	4.5	4.3
AA2.03	DELETED		
AA2.04	Bypass valve capacity	4.2	4.0

APE: 295008 High Reactor Water Level

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Reactor Water Level: (CFR: 41.8 to 41.10)	
AK1.01	Moisture carryover	3.3
AK1.02	Component erosion/damage	3.1
AK1.03	Feed flow/steam flow mismatch	3.6
AK1.04	Containment integrity	3.1
AK2	Knowledge of the relationship between High Reactor Water Level and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	RPS	3.9
AK2.02	Reactor feedwater system	4.0
AK2.03	Reactor water level control	4.2
AK2.04	PCIS/NSSSS	3.6
AK2.05	HPCI	4.1
AK2.06	RCIC	4.0
AK2.07	HPCS	3.7
AK2.08	Main turbine	3.8
AK2.09	Reactor water cleanup system (ability to drain)	3.3
AK2.10	RHR (ability to drain)	3.3
AK2.11	Main steam	3.5
AK3	Knowledge of the reasons for the following responses or actions as they apply to High Reactor Water Level: (CFR: 41.5 / 45.6)	
AK3.01	Main turbine trip	4.0
AK3.02	Reactor SCRAM	4.0
AK3.03	PCIS/NSSSS initiation	3.5
AK3.04	Reactor feedwater pump trip	3.8
AK3.05	HPCI turbine trip	4.0
AK3.06	RCIC turbine trip	3.8
AK3.07	HPCS isolation	3.5
AK3.08	RCIC steam supply valve closure	3.5
AK3.09	HPCS injection valve closure	3.5

APE: 295008 High Reactor Water Level

AA1 Ability to operate and/or monitor the following as they apply to High Reactor Water Level:
(CFR: 41.7 / 45.6)

AA1.01	Reactor water level control	4.4
AA1.02	Reactor water cleanup (ability to drain)	3.4
AA1.03	Main steam system	3.5
AA1.04	HPCI	4.0
AA1.05	RCIC	3.9
AA1.06	HPCS	3.8
AA1.07	Main turbine	3.6
AA1.08	Feedwater system	4.1
AA1.09	RHR (ability to drain)	3.3

AA2 Ability to determine and/or interpret the following as they apply to High Reactor Water Level:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Reactor water level	4.4	4.4
AA2.02	Steam flow/feedflow mismatch	3.9	4.0
AA2.03	Reactor water cleanup blowdown flow	3.4	3.2
AA2.04	Heatup rate	3.3	3.3
AA2.05	Swell	3.8	3.5

APE: 295009 Low Reactor Water Level

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Low Reactor Water Level: (CFR: 41.8 to 41.10)	
AK1.01	Steam carryunder	2.9
AK1.02	Recirculation pump net positive suction head	3.4
AK1.03	Jet pump net positive suction head	3.2
AK1.04	Jet pump efficiency	2.8
AK1.05	Natural circulation	3.5
AK2	Knowledge of the relationship between Low Reactor Water Level and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	DELETED	
AK2.02	Reactor water level control	4.1
AK2.03	Recirculation system	3.5
AK2.04	Recirculation flow control system	3.5
AK2.05	PCIS/NSSSS	4.1
AK2.06	RPS	4.3
AK2.07	Feedwater system	3.8
AK2.08	CRD system	2.9
AK3	Knowledge of the reasons for the following responses or actions as they apply to Low Reactor Water Level: (CFR: 41.5 / 45.6)	
AK3.01	Recirculation runback	3.7
AK3.02	DELETED	
AK3.03	Reactor SCRAM	4.2
AA1	Ability to operate and/or monitor the following as they apply to Low Reactor Water Level: (CFR: 41.7 / 45.6)	
AA1.01	Feedwater system	4.0
AA1.02	Reactor water level control	4.2
AA1.03	Recirculation flow control system	3.5
AA1.04	Reactor water cleanup	3.0
AA1.05	PCIS/NSSSS	3.9
AA1.06	CRD system	3.1
AA1.07	RPS	4.1

APE: 295009 Low Reactor Water Level

AA2 Ability to determine and/or interpret the following as they apply to Low Reactor Water Level:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Reactor water level	4.1	4.5
AA2.02	Steam flow/feed flow mismatch	3.9	3.8
AA2.03	Reactor water cleanup blowdown rate	3.0	2.9

APE: 295010 High Drywell Pressure		
K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Drywell Pressure: (CFR: 41.8 to 41.10)	
AK1.01	DELETED	
AK1.02	DELETED	
AK1.03	Drywell temperature increase	3.8
AK2	Knowledge of the relationship between High Drywell Pressure and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	DELETED	
AK2.02	DELETED	
AK2.03	DELETED	
AK2.04	DELETED	
AK2.05	DELETED	
AK2.06	Primary containment and auxiliaries	3.8
AK2.07	Component cooling water	3.5
AK2.08	Plant ventilation systems	3.2
AK3	Knowledge of the reasons for the following responses or actions as they apply to High Drywell Pressure: (CFR: 41.5 / 45.6)	
AK3.01	Drywell venting	4.1
AK3.02	Increased drywell cooling	3.5
AK3.03	Radiation level monitoring	3.4
AK3.04	Leak investigation	3.6
AK3.05	Temperature monitoring	3.6
AK3.06	Termination of drywell inerting	3.2
AA1	Ability to operate and/or monitor the following as they apply to High Drywell Pressure: (CFR: 41.7 / 45.6)	
AA1.01	Primary containment and auxiliaries	3.7
AA1.02	DELETED	
AA1.03	DELETED	
AA1.04	Drywell sampling system	3.0
AA1.05	DELETED	
AA1.06	Leakage detection systems	3.4

APE: 295010 High Drywell Pressure

AA1.07	DELETED	
AA1.08	Component cooling water	3.3
AA1.09	Plant ventilation systems	3.1
AA1.10	Suppression pool level	3.5
AA1.11	Drywell/suppression chamber differential pressure (Mark I, II)	3.6
AA1.12	Drywell/containment differential pressure (Mark III)	3.6

AA2 Ability to determine and/or interpret the following as they apply to High Drywell Pressure:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Leak rates	3.4	3.7
AA2.02	Drywell pressure	4.0	4.3
AA2.03	Drywell radiation levels	3.4	3.6
AA2.04	Drywell humidity	2.7	2.7
AA2.05	Drywell air cooler drain flow	2.7	2.9
AA2.06	Drywell temperature	3.8	3.7
AA2.07	Drywell/containment or suppression chamber differential pressure	3.7	3.7

APE: 295011 High Containment Temperature (Mark III Containment Only)

K/A NO.	KNOWLEDGE	IMPORTANCE	
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Containment Temperature: (CFR: 41.8 to 41.10)		
AK1.01	Containment pressure	4.1	
AK2	Knowledge of the relationship between High Containment Temperature and the following systems or components: (CFR: 41.7 / 45.8)		
AK2.01	Containment ventilation/cooling	3.8	
AK3	Knowledge of the reasons for the following responses or actions as they apply to High Containment Temperature: (CFR: 41.5 / 45.6)		
AK3.01	Increased containment cooling	3.6	
AA1	Ability to operate and/or monitor the following as they apply to High Containment Temperature: (CFR: 41.7 / 45.6)		
AA1.01	Containment ventilation/cooling system	3.7	
AA2	Ability to determine and/or interpret the following as they apply to High Containment Temperature: (CFR: 41.10 / 43.5 / 45.13)	RO	SRO
AA2.01	Containment temperature	4.0	4.0
AA2.02	Containment pressure	3.8	4.3
AA2.03	Containment humidity	2.2	2.7
AA2.04	System/component operating limitations	3.2	3.6

APE: 295012 High Drywell Temperature

K/A NO.	KNOWLEDGE	IMPORTANCE	
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Drywell Temperature: (CFR: 41.8 to 41.10)		
AK1.01	Drywell pressure	4.0	
AK1.02	DELETED		
AK2	Knowledge of the relationship between High Drywell Temperature and the following systems or components: (CFR: 41.7 / 45.8)		
AK2.01	Drywell ventilation	3.7	
AK2.02	Drywell cooling	3.9	
AK3	Knowledge of the reasons for the following responses or actions as they apply to High Drywell Temperature: (CFR: 41.5 / 45.6)		
AK3.01	Increased drywell cooling	3.8	
AK3.02	Venting	3.9	
AA1	Ability to operate and/or monitor the following as they apply to High Drywell Temperature: (CFR: 41.7 / 45.6)		
AA1.01	Drywell ventilation system	3.7	
AA1.02	Drywell cooling system	3.9	
AA1.03	Drywell pressure	4.2	
AA2	Ability to determine and/or interpret the following as they apply to High Drywell Temperature: (CFR: 41.10 / 43.5 / 45.13)	RO	SRO
AA2.01	Drywell temperature	4.4	4.2
AA2.02	Drywell pressure	4.3	4.3
AA2.03	Drywell humidity	2.8	2.7
AA2.04	System/component operating limitations	3.8	3.6

APE: 295013 High Suppression Pool Water Temperature			
K/A NO.	KNOWLEDGE	IMPORTANCE	
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Suppression Pool Water Temperature: (CFR: 41.8 to 41.10)		
AK1.01	DELETED		
AK1.02	DELETED		
AK1.03	Localized heating	3.2	
AK1.04	DELETED		
AK1.05	Containment integrity	4.1	
AK1.06	Surveillance testing	3.4	
AK2	Knowledge of the relationship between High Suppression Pool Water Temperature and the following systems or components: (CFR: 41.7 / 45.8)		
AK2.01	Suppression pool cooling	3.9	
AK2.02	Safety/relief valve operation	4.2	
AK2.03	RCIC/HPCI operation	4.0	
AK3	Knowledge of the reasons for the following responses or actions as they apply to High Suppression Pool Water Temperature: (CFR: 41.5 / 45.6)		
AK3.01	Suppression pool cooling operation	4.1	
AK3.02	Limiting heat additions	3.9	
AA1	Ability to operate and/or monitor the following as they apply to High Suppression Pool Water Temperature: (CFR: 41.7 / 45.6)		
AA1.01	Suppression pool cooling	4.3	
AA1.02	Systems that add heat to the suppression pool	4.1	
AA1.03	Suppression pool temperature monitoring system	4.0	
AA2	Ability to determine and/or interpret the following as they apply to High Suppression Pool Water Temperature: (CFR: 41.10 / 43.5 / 45.13)	RO	SRO
AA2.01	Suppression pool temperature	4.3	4.2
AA2.02	Localized heating/stratification	3.5	3.1
AA2.03	Open/leaking Safety relief valve	4.2	3.9

APE: 295014 Inadvertent Reactivity Addition

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Inadvertent Reactivity Addition: (CFR: 41.8 to 41.10)	
AK1.01	DELETED	
AK1.02	Reactivity anomaly	3.8
AK1.03	Shutdown margin	3.8
AK1.04	Preconditioning interim operating management recommendations (PCIOMR)	3.1
AK1.05	Fuel thermal limits	4.1
AK1.06	Reactivity changes	4.3
AK1.07	Void concentration	3.7
AK1.08	Moderator temperature	3.7
AK1.09	Reactor power	4.4
AK1.10	Safety limits	4.3
AK1.11	Thermal-hydraulic instability	4.0
AK2	Knowledge of the relationship between Inadvertent Reactivity Addition and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	RPS	4.1
AK2.02	DELETED	
AK2.03	DELETED	
AK2.04	DELETED	
AK2.05	Neutron monitoring system/OPRMs	4.2
AK2.06	DELETED	
AK2.07	DELETED	
AK2.08	RMCS	3.8
AK2.09	RCIS (BWR 6)	3.6
AK2.10	DELETED	
AK2.11	Recirculation flow control	3.9
AK2.12	HPCI	3.6
AK2.13	RCIC	3.3
AK2.14	HPCS	3.3

APE: 295014 Inadvertent Reactivity Addition

**AK3 Knowledge of the reasons for the following responses or actions as they apply to Inadvertent Reactivity Addition:
(CFR: 41.5 / 45.6)**

AK3.01	Reactor SCRAM	4.3
AK3.02	Control rod blocks	4.0
AK3.03	Changing recirculation flow	4.1
AK3.04	Changing control rod positions	4.0

**AA1 Ability to operate and/or monitor the following as they apply to Inadvertent Reactivity Addition:
(CFR: 41.7 / 45.6)**

AA1.01	RPS	4.1
AA1.02	Recirculation flow control system	4.2
AA1.03	RMCS	4.0
AA1.04	RCIS (BWR 6)	4.1
AA1.05	Neutron monitoring system/OPRMs	4.1
AA1.06	Reactor/turbine pressure regulating system	3.7
AA1.07	DELETED	
AA1.08	HPCI	3.7
AA1.09	RCIC	3.5
AA1.10	HPCS	3.5
AA1.11	Feedwater system	3.9

**AA2 Ability to determine and/or interpret the following as they apply to Inadvertent Reactivity Addition:
(CFR: 41.10 / 43.5 / 45.13)**

		RO	SRO
AA2.01	Reactor power	4.7	4.5
AA2.02	Reactor period	4.5	4.1
AA2.03	Cause of reactivity addition	4.1	4.2
AA2.04	Violation of fuel thermal limits	4.5	4.3
AA2.05	Violation of safety limits	4.8	4.4
AA2.06	Cold water injection	4.2	4.1

APE: 295015 Incomplete SCRAM

K/A NO. KNOWLEDGE

IMPORTANCE

DELETED—K/As moved to EPE 295037, “SCRAM Condition Present and Reactor Power Above APRM Downscale or Unknown”

APE: 295016 Control Room Abandonment

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Control Room Abandonment: (CFR: 41.8 to 41.10)	
	None	
AK2	Knowledge of the relationship between Control Room Abandonment and the following systems or components : (CFR: 41.7 / 45.8)	
AK2.01	Remote shutdown panel	4.4
AK2.02	Local control stations	3.9
AK2.03	DELETED	
AK2.04	AC electrical distribution	3.5
AK2.05	DC electrical distribution	3.5
AK2.06	Safety/relief valves	3.8
AK2.07	RCIC	4.1
AK2.08	Isolation condensers	3.9
AK2.09	RHR/LPCI: torus/suppression pool cooling mode	3.7
AK2.10	Shutdown cooling system (RHR shutdown cooling mode)	3.7
AK2.11	Main and reheat steam system	2.7
AK2.12	Emergency generators	3.9
AK2.13	RPS	3.4
AK2.14	Cooling water systems	3.4
AK2.15	Main turbine and auxiliaries	2.6
AK3	Knowledge of the reasons for the following responses or actions as they apply to Control Room Abandonment: (CFR: 41.5 / 45.6)	
AK3.01	Reactor SCRAM	4.0
AK3.02	Turbine trip	3.6
AK3.03	Disabling/transferring control room controls	4.0
AK3.04	Abandonment criteria	4.1
AA1	Ability to operate and/or monitor the following as they apply to Control Room Abandonment: (CFR: 41.7 / 45.6)	
AA1.01	RPS	3.8
AA1.02	DELETED	

APE: 295016 Control Room Abandonment

AA1.03	DELETED	
AA1.04	AC electrical distribution	3.6
AA1.05	DC electrical distribution	3.5
AA1.06	DELETED	
AA1.07	Control room/local control transfer mechanisms	4.0
AA1.08	DELETED	
AA1.09	Isolation condensers	4.0
AA1.10	Safety/relief valves	3.9
AA1.11	RCIC	4.2
AA1.12	RHR/LPCI: torus/suppression pool cooling mode	3.8
AA1.13	Shutdown cooling system (RHR shutdown cooling mode)	3.7
AA1.14	Main and reheat steam system	2.7
AA1.15	Emergency generators	3.8
AA1.16	Cooling water systems	3.3
AA1.17	Main turbine and auxiliaries	2.6

AA2 Ability to determine and/or interpret the following as they apply to Control Room Abandonment:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Reactor power	4.3	3.7
AA2.02	Reactor water level	4.5	4.2
AA2.03	Reactor pressure	4.5	4.2
AA2.04	Suppression pool temperature	4.0	3.8
AA2.05	Drywell pressure	3.9	3.6
AA2.06	Cooldown rate	3.9	3.7
AA2.07	Suppression chamber pressure	3.7	3.4
AA2.08	Successful transfer	4.3	3.9

APE: 295017 High Offsite Radioactive Release Rate

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to High Offsite Radioactive Release Rate: (CFR: 41.8 to 41.10)	
AK1.01	DELETED	
AK1.02	DELETED	
AK1.03	DELETED	
AK1.04	Elevated vs. ground level release	3.7
AK1.05	Exceeding limits for gaseous/liquid releases	4.0
AK1.06	Filtered vs. nonfiltered release	3.6
AK2	Knowledge of the relationship between High Offsite Radioactive Release Rate and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	DELETED	
AK2.02	Radwaste system	3.0
AK2.03	Off-gas system	3.7
AK2.04	Plant ventilation systems	3.6
AK2.05	DELETED	
AK2.06	DELETED	
AK2.07	Control room heating, ventilation and air conditioning	3.3
AK2.08	Plant process computer/parameter display systems	3.1
AK2.09	Condenser air removal system	3.3
AK2.10	Process radiation monitoring system	3.7
AK2.11	DELETED	
AK2.12	SGTS/FRVS	3.8
AK2.13	RPS	3.4
AK2.14	PCIS/NSSSS	3.7
AK2.15	Fuel pool cooling and cleanup system	3.1
AK3	Knowledge of the reasons for the following responses or actions as they apply to High Offsite Radioactive Release Rate: (CFR: 41.5 / 45.6)	
AK3.01	System isolations	4.0
AK3.02	Plant ventilation	3.6
AK3.03	DELETED	
AK3.04	Power reduction	3.7

APE: 295017 High Offsite Radioactive Release Rate

AK3.05 CRV system operation 3.5

AA1 Ability to operate and/or monitor the following as they apply to High Offsite Radioactive Release Rate: (CFR: 41.7 / 45.6)

AA1.01 Radwaste 2.8
 AA1.02 Off-gas system 3.6
 AA1.03 Plant ventilation systems 3.5
 AA1.04 DELETED
 AA1.05 Plant process computer/parameter display systems 3.0
 AA1.06 Condenser air removal system 3.3
 AA1.07 Process radiation monitoring system 3.7
 AA1.08 DELETED
 AA1.09 SGTS/FRVS 3.9
 AA1.10 RPS 3.5
 AA1.11 PCIS/NSSSS 3.7
 AA1.12 DELETED
 AA1.13 Control room heating, ventilation and air conditioning 3.4
 AA1.14 Fuel pool cooling and cleanup system 3.0

AA2 Ability to determine and/or interpret the following as they apply to High Offsite Radioactive Release Rate: (CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Offsite release rate	3.8	4.2
AA2.02	Total number of curies released or release rate/duration	3.4	3.3
AA2.03	Radiation levels	3.7	3.9
AA2.04	Source of offsite release	3.9	4.0
AA2.05	Meteorological data	3.8	3.9
AA2.06	Emergency plan implementation	3.4	4.3

APE: 295018 Partial or Complete Loss of Component Cooling Water

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Partial or Complete Loss of Component Cooling Water: (CFR: 41.8 to 41.10)	
AK1.01	DELETED	
AK2	Knowledge of the relationship between Partial or Complete Loss of Component Cooling Water and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	DELETED	
AK2.02	Plant operations	3.9
AK2.03	Reactor water cleanup system	3.5
AK2.04	Reactor recirculation system	3.7
AK2.05	RHR/LPCI	3.3
AK2.06	Fuel pool cooling and cleanup system	3.8
AK3	Knowledge of the reasons for the following responses or actions as they apply to Partial or Complete Loss of Component Cooling Water: (CFR: 41.5 / 45.6)	
AK3.01	Isolation of non-essential heat loads	3.4
AK3.02	Reactor power reduction	3.6
AK3.03	Securing individual components (preventing equipment damage)	3.3
AK3.04	Starting the standby pump	3.5
AK3.05	Placing the standby heat exchanger in service	3.4
AK3.06	Increasing cooling water flow to heat exchangers	3.3
AK3.07	Cross-connecting with backup systems	3.1
AA1	Ability to operate and/or monitor the following as they apply to Partial or Complete Loss of Component Cooling Water: (CFR: 41.7 / 45.6)	
AA1.01	Backup systems	3.3
AA1.02	DELETED	
AA1.03	Affected systems so as to isolate damaged portions	3.3
AA1.04	Reactor water cleanup system	3.4
AA1.05	Reactor recirculation system	3.6
AA1.06	RHR/LPCI	3.2

APE: 295018 Partial or Complete Loss of Component Cooling Water

AA1.07	Fuel pool cooling and cleanup system	3.6
AA1.08	Plant operations	3.6

AA2 Ability to determine and/or interpret the following as they apply to Partial or Complete Loss of Component Cooling Water:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Component temperatures	3.7	3.5
AA2.02	Cooling water temperature	3.7	3.5
AA2.03	Partial or complete loss	3.7	3.5
AA2.04	System flow	3.4	3.2
AA2.05	System pressure	3.7	3.2
AA2.06	Surge tank level	3.6	3.0

APE: 295019 Partial or Complete Loss of Instrument Air

K/A NO. KNOWLEDGE IMPORTANCE

AK1 Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Partial or Complete Loss of Instrument Air:
(CFR: 41.8 to 41.10)

None

AK2 Knowledge of the relationship between Partial or Complete Loss of Instrument Air and the following systems or components:
(CFR: 41.7 / 45.8)

AK2.01	CRD hydraulics	4.0
AK2.02	Component cooling water	3.2
AK2.03	Feedwater system	3.7
AK2.04	Reactor water cleanup system	3.2
AK2.05	Main and reheat steam system	3.3
AK2.06	Offgas system	3.2
AK2.07	Condensate system	3.3
AK2.08	Plant ventilation	3.0
AK2.09	Primary containment and auxiliaries	3.4
AK2.10	Fuel pool cooling and cleanup system	3.2
AK2.11	Radwaste	2.5
AK2.12	SGTS/FRVS	3.1
AK2.13	Isolation condenser	3.1
AK2.14	Plant air systems	3.5
AK2.15	Standby liquid control system	2.8
AK2.16	Reactor core isolation cooling	3.0
AK2.17	High-pressure coolant injection	2.8
AK2.18	Safety/relief valves	3.7
AK2.19	RHR/LPCI	2.6
AK2.20	Control room ventilation	3.1
AK2.21	Recirculation system	2.6
AK2.22	Circulating water	2.2
AK2.23	Service water	2.7
AK2.24	Shutdown cooling system	2.6

AK3 Knowledge of the reasons for the following responses or actions as they apply to Partial or Complete Loss of Instrument Air:
(CFR: 41.5 / 45.6)

AK3.01 Alignment of backup air systems 3.6

APE: 295019 Partial or Complete Loss of Instrument Air

AK3.02	Standby air compressor operation	3.7
AK3.03	Service air isolations	3.3
AK3.04	Dryer/filter realignment	3.0
AK3.05	Leak isolation	3.3

AA1 Ability to operate and/or monitor the following as they apply to Partial or Complete Loss of Instrument Air:
(CFR: 41.7 / 45.6)

AA1.01	Backup air supply	3.4
AA1.02	System valves	3.2
AA1.03	Air compressors	3.5
AA1.04	DELETED	

AA2 Ability to determine and/or interpret the following as they apply to Partial or Complete Loss of Instrument Air:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Instrument air pressure	4.1	3.9
AA2.02	DELETED		

APE: 295020 Inadvertent Containment Isolation

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Inadvertent Containment Isolation: (CFR: 41.8 to 41.10)	
AK1.01	Loss of normal heat sink	4.1
AK1.02	Power/reactivity control	3.9
AK1.03	Water chemistry	2.8
AK1.04	Bottom head thermal stratification	3.3
AK1.05	Loss of drywell/containment cooling	3.5
AK1.06	Loss of reactor building HVAC	3.3
AK2	Knowledge of the relationship between Inadvertent Containment Isolation and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	Main and reheat steam system	3.9
AK2.02	Sampling system	2.7
AK2.03	Drywell or containment ventilation	3.5
AK2.04	RWCU system	3.6
AK2.05	Isolation condenser	3.5
AK2.06	HPCI	3.6
AK2.07	RCIC	3.8
AK2.08	Traversing in-core probes	2.7
AK2.09	RHR/shutdown cooling	4.0
AK2.10	Drywell equipment/floor drain sumps	3.1
AK2.11	SGTS/FRVS	3.5
AK2.12	Instrument air/nitrogen	3.1
AK2.13	Containment atmosphere control system	3.0
AK3	Knowledge of the reasons for the following responses or actions as they apply to Inadvertent Containment Isolation: (CFR: 41.5 / 45.6)	
AK3.01	RPS actuation	3.9
AK3.02	Drywell/containment pressure response	3.9
AK3.03	Drywell/containment temperature response	3.9
AK3.04	Reactor pressure response	3.9
AK3.05	Reactor water level response	3.9
AK3.06	DELETED	
AK3.07	DELETED	
AK3.08	Suppression chamber pressure response	3.5

APE: 295020 Inadvertent Containment Isolation

AA1 Ability to operate and/or monitor the following as they apply to Inadvertent Containment Isolation:
(CFR: 41.7 / 45.6)

AA1.01	PCIS/NSSSS	3.9
AA1.02	Drywell ventilation/cooling system	3.5
AA1.03	Containment ventilation system	3.5
AA1.04	SGTS/FRVS	3.6
AA1.05	RPS	3.8
AA1.06	Secondary containment temperature/pressure	3.5
AA1.07	Reactor pressure	3.8
AA1.08	Reactor water level	3.8

AA2 Ability to determine and/or interpret the following as they apply to Inadvertent Containment Isolation:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Drywell/containment pressure	3.9	3.7
AA2.02	Drywell/containment temperature	3.9	3.7
AA2.03	Reactor power	3.9	3.8
AA2.04	Reactor pressure	4.0	3.8
AA2.05	Reactor water level	4.0	3.8
AA2.06	Cause of isolation	3.4	3.7
AA2.07	Condenser vacuum	3.4	3.2
AA2.08	High-energy line break	3.6	3.6
AA2.09	Area/delta temperatures	3.3	3.5
AA2.10	Reactor building radiation	3.6	3.5
AA2.11	RPS status	3.8	3.9

APE: 295021 Loss of Shutdown Cooling

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Loss of Shutdown Cooling: (CFR: 41.8 to 41.10)	
AK1.01	Decay heat	4.4
AK1.02	Thermal stratification	3.9
AK1.03	Adequate core cooling	4.4
AK1.04	Natural circulation	3.9
AK2	Knowledge of the relationship between Loss of Shutdown Cooling and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	DELETED	
AK2.02	Reactor water cleanup	3.2
AK2.03	RHR/shutdown cooling	4.2
AK2.04	Component cooling water systems	3.4
AK2.05	Fuel pool cooling and cleanup system	3.4
AK2.06	DELETED	
AK2.07	Reactor recirculation	3.5
AK2.08	Alternate decay heat removal systems	3.9
AK3	Knowledge of the reasons for the following responses or actions as they apply to Loss of Shutdown Cooling: (CFR: 41.5 / 45.6)	
AK3.01	Raising reactor water level	4.0
AK3.02	Feeding and bleeding reactor vessel	3.7
AK3.03	Increasing drywell cooling	2.9
AK3.04	Maximizing reactor water cleanup flow	3.5
AK3.05	Establishing alternate heat removal flow paths	4.0
AK3.06	Installing fuel pool gates	3.0
AA1	Ability to operate and/or monitor the following as they apply to Loss of Shutdown Cooling: (CFR: 41.7 / 45.6)	
AA1.01	Reactor water cleanup system	3.4
AA1.02	RHR/shutdown cooling	4.3
AA1.03	Component cooling water systems	3.4
AA1.04	Alternate decay heat removal systems	3.9
AA1.05	Reactor recirculation	3.6

APE: 295021 Loss of Shutdown Cooling

AA1.06 DELETED
AA1.07 Fuel pool cooling and cleanup 3.4

AA2 Ability to determine and/or interpret the following as they apply to Loss of Shutdown Cooling:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Containment/drywell temperature	3.6	2.8
AA2.02	RHR/shutdown cooling system flow	4.1	3.9
AA2.03	Reactor water level	4.4	4.0
AA2.04	Reactor water temperature	4.6	4.3
AA2.05	Reactor vessel metal temperature	3.9	3.7
AA2.06	Reactor pressure	4.2	3.8
AA2.07	Reactor recirculation flow	3.8	3.2

APE: 295022 Loss of Control Rod Drive Pumps

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Loss of Control Rod Drive Pumps: (CFR: 41.8 to 41.10)	
AK1.01	Reactor pressure vs. rod insertion capability	3.9
AK1.02	Reactivity control	3.9
AK2	Knowledge of the relationship between Loss of Control Rod Drive Pumps and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	Recirculation system	3.1
AK2.02	CRD mechanism	3.6
AK2.03	Accumulator	3.8
AK2.04	DELETED	
AK2.05	Reactor water cleanup	2.6
AK2.06	Shared components with other units	2.6
AK2.07	DELETED	
AK2.08	Condensate system	2.6
AK2.09	NBI	3.1
AK3	Knowledge of the reasons for the following responses or actions as they apply to Loss of Control Rod Drive Pumps: (CFR: 41.5 / 45.6)	
AK3.01	Reactor SCRAM	4.0
AK3.02	Restoring CRDM cooling/drive water flow	3.6
AK3.03	Swapping/bypassing filter	3.0
AK3.04	Closing flow control valve	3.1
AA1	Ability to operate and/or monitor the following as they apply to Loss of Control Rod Drive Pumps: (CFR: 41.7 / 45.6)	
AA1.01	CRD hydraulic system	3.7
AA1.02	RPS	3.4
AA1.03	Recirculation system	3.0
AA1.04	Reactor water cleanup system	2.7
AA1.05	NBI	3.4

APE: 295022 Loss of Control Rod Drive Pumps

AA2 Ability to determine and/or interpret the following as they apply to Loss of Control Rod Drive Pumps:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Accumulator pressure	4.0	3.7
AA2.02	CRD hydraulic system status	4.0	3.7
AA2.03	CRD mechanism temperatures	3.2	3.1
AA2.04	Reactor water level	3.7	3.0
AA2.05	Reactor pressure	3.7	3.2

APE: 295023 Refueling Accidents

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Refueling Accidents: (CFR: 41.8 to 41.10)	
AK1.01	Radiation exposure hazards	3.9
AK1.02	Shutdown margin	3.5
AK1.03	Inadvertent criticality	3.8
AK1.04	Fuel positioning	3.4
AK2	Knowledge of the relationship between Refueling Accidents and the following systems or components: (CFR: 41.7 / 45.8)	
AK2.01	Fuel handling equipment	3.5
AK2.02	Fuel pool cooling and cleanup system	3.4
AK2.03	Radiation monitoring system	3.7
AK2.04	RMCS/RCIS	3.2
AK2.05	Secondary containment ventilation	3.7
AK2.06	Containment ventilation (Mark III)	3.5
AK2.07	SGTS/FRVS	3.8
AK2.08	Fuel handling building ventilation (Mark III)	3.4
AK2.09	Incline fuel/horizontal fuel transfer system (Mark III)	3.2
AK2.10	Nuclear instrumentation	3.5
AK2.11	Alternate fuel pool makeup systems	3.5
AK3	Knowledge of the reasons for the following responses or actions as they apply to Refueling Accidents: (CFR: 41.5 / 45.6)	
AK3.01	Personnel evacuation	4.0
AK3.02	Refueling interlocks	3.7
AK3.03	Ventilation isolation	3.7
AK3.04	Non-coincident SCRAM function	2.8
AK3.05	DELETED	
AA1	Ability to operate and/or monitor the following as they apply to Refueling Accidents: (CFR: 41.7 / 45.6)	
AA1.01	Secondary containment ventilation	3.8
AA1.02	Fuel pool cooling and cleanup system	3.4

APE: 295023 Refueling Accidents

AA1.03	Fuel handling equipment	3.1
AA1.04	Radiation monitoring equipment	3.6
AA1.05	Fuel transfer system	2.7
AA1.06	Nuclear instrumentation	3.6
AA1.07	SGTS/FRVS	4.0
AA1.08	Containment building ventilation (Mark III)	3.5
AA1.09	Fuel handling building ventilation (Mark III)	3.4
AA1.10	Alternate fuel pool makeup systems	3.5

AA2 Ability to determine and/or interpret the following as they apply to Refueling Accidents:
(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	Radiation levels	4.1	3.9
AA2.02	Fuel pool level	4.6	3.8
AA2.03	Airborne contamination levels	3.9	3.2
AA2.04	Occurrence of fuel handling accident	4.0	3.6
AA2.05	Emergency plan implementation	4.1	4.4

APE: 600000 Plant Fire on Site

K/A NO. KNOWLEDGE IMPORTANCE

**AK1 Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Plant Fire on Site:
(CFR 41.8 / 41.10 / 45.3)**

AK1.01 DELETED

AK1.02 Firefighting methods for each type of fire 3.4

AK1.03 DELETED

**AK2 Knowledge of the relationship between Plant Fire on Site and the following systems or components:
(CFR 41.7 / 45.7)**

AK2.01 DELETED

AK2.02 DELETED

AK2.03 DELETED

AK2.04 DELETED

AK2.05 Fire alarm panels 3.4

AK2.06 Fire pumps 3.8

AK2.07 Electrical distribution system 3.3

AK2.08 Portable fire suppression systems 3.0

AK2.09 Installed fire suppression systems 3.5

AK2.10 Plant ventilation systems 3.2

AK2.11 Gas treatment system 3.0

**AK3 Knowledge of the reasons for the following responses or actions as they apply to Plant Fire on Site:
(CFR 41.5,41.10 / 45.6 / 45.13)**

AK3.01 DELETED

AK3.02 Steps called out in the site fire protection plant, fire protection system manual, and fire zone manual 3.3

AK3.03 DELETED

AK3.04 Actions contained in the fire response procedures for a plant fire on site 3.6

**AA1 Ability to operate and/or monitor the following as they apply to Plant Fire on Site:
(CFR 41.7 / 45.5 / 45.6)**

AA1.01 Respirator air pack 3.5

AA1.02 Fire detectors/heat detectors 3.1

AA1.03 DELETED

APE: 600000 Plant Fire on Site

AA1.04	DELETED		
AA1.05	Plant and control room ventilation systems		3.3
AA1.06	Fire alarm		3.5
AA1.07	Fire alarm reset panel		3.2
AA1.08	Firefighting equipment used on each class of fire		3.3
AA1.09	Plant fire zone panel (including detector location)		3.3

AA2 Ability to determine and/or interpret the following as they apply to Plant Fire on Site:

(CFR: 41.10 / 43.5 / 45.13)

		RO	SRO
AA2.01	DELETED		
AA2.02	DELETED		
AA2.03	Fire alarm	3.8	3.7
AA2.04	The fire's extent of potential operational damage to plant equipment	3.9	3.6
AA2.05	Ventilation alignment necessary to secure affected area	3.2	3.2
AA2.06	Need for pressurizing control room (recirculating mode)	3.4	3.3
AA2.07	Whether malfunction(s) are due to common-mode electrical failures	3.1	3.0
AA2.08	DELETED		
AA2.09	DELETED		
AA2.10	Time limit of long-term-breathing air system for control room	3.4	3.0
AA2.11	Time limit for use of respirators	3.9	3.1
AA2.12	Location of vital equipment within fire zone	3.3	3.5
AA2.13	Need for emergency plant shutdown	3.8	3.8
AA2.14	DELETED		
AA2.15	Requirements for establishing a fire watch (SRO Only)	N/A	3.3
AA2.16	Vital equipment and control systems to be maintained and operated during a fire	3.3	3.4
AA2.17	DELETED		
AA2.18	Assessment of control room habitability (SRO Only)	N/A	3.6

APE: 700000 Generator Voltage and Electric Grid Disturbances

K/A NO.	KNOWLEDGE	IMPORTANCE
AK1	Knowledge of the operational implications and/or cause and effect relationships of the following as they apply to Generator Voltage and Electric Grid Disturbances: (CFR: 41.4, 41.5, 41.7, 41.10 / 45.8)	
AK1.01	DELETED	
AK1.02	Over-excitation	3.1
AK1.03	Under-excitation	3.2
AK1.04	Frequency changes	3.2
AK1.05	Voltage disturbance	3.5
AK2	Knowledge of the relationship between Generator Voltage and Electric Grid Disturbances and the following systems or components: (CFR: 41.4, 41.5, 41.7, 41.10 / 45.8)	
AK2.01	Motors	3.0
AK2.02	Breakers, relays	3.2
AK2.03	DELETED	
AK2.04	DELETED	
AK2.05	DELETED	
AK2.06	DELETED	
AK2.07	Reactor/turbine pressure regulating system	3.3
AK2.08	Main turbine generator and auxiliary systems	3.1
AK2.09	AC electrical distribution system	3.5
AK2.10	Emergency generators (diesel/jet)	3.9
AK3	Knowledge of the reasons for the following responses or actions as they apply to Generator Voltage and Electric Grid Disturbances: (CFR: 41.4 / 41.5 / 41.7 / 41.10 / 45.8)	
AK3.01	Reactor and turbine trip criteria	3.8
AK3.02	Actions contained in abnormal operating procedure for voltage and grid disturbances	3.8
AA1	Ability to operate and/or monitor the following as they apply to Generator Voltage and Electric Grid Disturbances: (CFR: 41.5 / 41.10 / 45.5 / 45.7 / 45.8)	
AA1.01	DELETED	
AA1.02	Turbine/generator controls	3.4
AA1.03	DELETED	

APE: 700000 Generator Voltage and Electric Grid Disturbances

AA1.04	Reactor controls	3.6
AA1.05	DELETED	
AA1.06	AC electrical distribution system	3.5
AA1.07	Emergency generators (diesel/jet)	3.8

AA2 Ability to determine and/or interpret the following as they apply to Generator Voltage and Electric Grid Disturbances:

(CFR: 41.5 and 43.5 / 45.5 / 45.7 / 45.8)

		RO	SRO
AA2.01	Operating point on the generator capability curve	3.4	3.2
AA2.02	Generator voltage limitations	3.7	3.3
AA2.03	Generator current limitations	3.7	3.3
AA2.04	DELETED		
AA2.05	Operational status of offsite circuit	3.3	3.7
AA2.06	Generator frequency limitations	3.2	3.0
AA2.07	Operations status of safety-related (vital) buses	4.1	4.0
AA2.08	DELETED		
AA2.09	Operational status of emergency diesel generators	4.2	4.2
AA2.10	Generator overheating and the required actions	3.7	3.5
AA2.11	Grid frequency and voltage	3.5	3.5

5	COMPONENTS	Page
291001	Valves (CFR: 41.3).....	5-3
291002	Sensors and Detectors (CFR: 41.7).....	5-4
291003	Controllers and Positioners (CFR: 41.7).....	5-6
291004	Pumps (CFR: 41.3).....	5-7
291005	Motors and Generators (CFR: 41.7).....	5-9
291006	Heat Exchangers and Condensers (CFR: 41.4).....	5-10
291007	Demineralizers and Ion Exchangers (CFR: 41.3).....	5-11
291008	Breakers, Relays, and Disconnects (CFR: 41.7).....	5-12

Component: 291001 Valves

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	The function and operation of safety valves	3.5
K1.02	The function and operation of relief valves	3.6
K1.03	The relationship of valve position to flow rate and back pressure	2.8
K1.04	The failed-valve positions for different operators (open, closed, and as-is positions; spring-loaded valves; hydraulically/pneumatically controlled valves; electric motor-driven valves)	2.8
K1.05	The significance of stem position (valve status) for gate valves	2.9
K1.06	Equipment protection/safety concerns in the use of gate valves (protect valves seals, open slowly)	2.7
K1.07	DELETED	
K1.08	Emergency/manual operation of motor-operated valves with motor inoperable	3.5
K1.09	The stroke test for a valve, including the use of a stopwatch	2.7
K1.10	Principles of operation and purpose of check valves	3.1
K1.11	Operation of valves and verification of position	3.2
K1.12	Reason for using a globe valve versus a gate valve for throttling	2.8

Component: 291002 Sensors and Detectors

K/A NO.	KNOWLEDGE	IMPORTANCE
	<u>Flow</u>	
K1.01	Operational characteristics of venturis and orifices	2.5
K1.02	Temperature/density compensation requirements	2.5
K1.03	Effects of gas or steam on liquid flow rate indications (erroneous reading)	2.6
K1.04	Modes of failure	3.1
K1.05	Operation of a flow D/P cell-type flow detector	3.1
	<u>Level</u>	
K1.06	Temperature/pressure compensation requirements	2.9
K1.07	Theory and operation of level detectors	3.2
K1.08	Effects of operating environment (pressure, temperature, or radiation)	2.9
K1.09	Modes of failure	3.3
	<u>Pressure</u>	
K1.10	Theory and operation of pressure detectors (bourdon tubes, diaphragms, bellows, forced balance, variable capacitance, and D/P cell)	2.5
K1.11	Effects of operating environment (pressure, temperature, or radiation)	2.5
K1.12	DELETED	
K1.13	Modes of failure	3.1
	<u>Temperature</u>	
K1.14	Theory and operation of T/C, RTD, thermostats, thermometers (expanding fluid)	2.4
K1.15	Failure modes and indications of T/C, RTD or, thermometers	2.8
	<u>Position Detectors</u>	
K1.16	Failure modes of reed switches, LVDTs, limit switches, and potentiometers	2.7
K1.17	Applications of reed switches, magnets, LVDTs, potentiometers, and limit switches	2.4
	<u>Electrical</u>	
K1.18	Theory and operation of voltmeters, ammeters, frequency, and ground detectors	2.4
	<u>Nuclear Instrumentation</u>	
K1.19	Theory and operation of fission chambers, and ion chambers	3.1
K1.20	Neutron monitoring indication units	3.2

Component: 291002 Sensors and Detectors

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.21	Effects of voltage changes on neutron detector performance	2.9
K1.22	Failure modes of fission chambers, ion chambers, and proportional counters	3.1
	<u>Radiation Detection</u>	
K1.23	Theory and operation of ion chambers, Geiger-Mueller tubes, and scintillation detectors	2.9
K1.24	Use of portable and personal radiation monitoring instruments	3.2
K1.25	Effects of core voiding on neutron detection	3.5

Component: 291003 Controllers and Positioners

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Function and operation of flow controller in manual and automatic modes	3.7
K1.02	Function and operation of a speed controller	3.6
K1.03	Operation of valve controllers in manual and automatic modes, including seal-in features	3.4
K1.04	Function and operation of pressure and temperature controllers, including pressure and temperature control valves	3.3
K1.05	Function and characteristics of valve positioners	2.8
K1.06	Function and characteristics of governors and other mechanical controllers	2.6
K1.07	Safety precautions with respect to the operation of controllers and positioners	2.8
K1.08	Theory of operation of the following types of controllers: electronic, electrical, and pneumatic	2.2
K1.09	Effects on operation of controllers due to proportional, integral (reset), and derivative (rate), as well as their combinations	2.2
K1.10	Function and characteristics of air-operated valves, including failure modes	2.8
K1.11	Cautions for placing a valve controller in manual mode	2.9

Component: 291004 Pumps

K/A NO.	KNOWLEDGE	IMPORTANCE
	<u>Centrifugal</u>	
K1.01	Identification, symptoms, and consequences of cavitation	3.2
K1.02	Reasons for venting a centrifugal pump	2.8
K1.03	Consequences of air/steam binding	2.9
K1.04	Consequences of operating a pump dead headed or for extended times without adequate recirculation	3.1
K1.05	Discuss relationships among head, flow, and power, as related to pump speed	2.9
K1.06	Need for net positive suction head (NPSH); effects of loss of suction	3.3
K1.07	Starting current and operating current interpretation	2.8
K1.08	Purpose of starting a pump with discharge valve closed	2.8
K1.09	Pressure and flow relationship of pumps in parallel	2.4
K1.10	Pressure and flow relationship of pumps in series	2.4
K1.11	Definition of pump shutoff head	2.5
K1.12	“Runout” of a centrifugal pump (definition, indications, causes, effects, and corrective measures)	2.8
K1.13	Theory of operation of a centrifugal pump	2.7
K1.14	Relationship between flow from a pump and suction heads	2.5
K1.15	DELETED	
K1.16	Given the characteristic curve for a typical centrifugal pump, explain the reason for its shape	2.3
K1.17	Using a centrifugal pump characteristic curve and a system characteristic curve, illustrate how the system operating point changes due to system changes	2.5
K1.18	Describe how a centrifugal pump characteristic curve will change with pump speed	2.3
K1.19	Safety procedure and precautions associated with centrifugal pumps	2.9
	<u>Positive Displacement</u>	
K1.20	Discuss relationship among head, flow, speed, and power	2.7
K1.21	Net positive suction head (NSPH) requirements for a positive displacement pump	2.6
K1.22	Consequences of operating a positive displacement pump against a closed flow path	3.3
K1.23	Functions and characteristics of positive displacement pumps	2.6
K1.24	Reason for starting a positive displacement pump with the discharge valve open; need to clear the flow path	3.1
K1.25	Safety procedures and precautions associated with positive displacement pumps	3.1

Component: 291004 Pumps

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.26	Theory of operation of positive displacement pumps	2.0
K1.27	Discuss the characteristic curve for a typical positive displacement pump and explain the reason for its shape	2.1
	<u>Jet Pumps</u>	
K1.28	Describe the principles of operation of a jet pump	1.8

Component: 291005 Motors and Generators

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Indication of a locked rotor	2.6
K1.02	Potential consequences of overheating motor insulation or motor bearings	2.7
K1.03	Causes of excessive current in motors and generators, such as low voltage, overloading, and mechanical binding	2.7
K1.04	Relationship between pump motor current (ammeter reading) and the following: pump fluid flow, head, speed, and stator temperature	2.7
K1.05	Explain the difference between starting current and operating (running) current in a motor	2.7
K1.06	Reason for limiting the number of motor starts in a given time period	3.1
K1.07	Electrical units: volts, amps, VARs, watts and hertz	2.6
K1.08	Consequences of overexcited/underexcited	2.6
K1.09	Interrelations of the following: VARs, watts, amps, volts, power factor	2.6
K1.10	Load sharing with parallel generators	2.4
K1.11	Motor and generator protective devices	2.4

Component: 291006 Heat Exchangers and Condensers (CFR: 41.4)

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Startup/shutdown of a heat exchanger	2.7
K1.02	Proper filling of a shell-and-tube heat exchanger	2.6
K1.03	Basic heat transfer in a heat exchanger	2.6
K1.04	Effects of heat exchanger flow rates that are too high or too low and methods of proper flow adjustment	2.8
K1.05	Flow paths for the heat exchanger (counterflow and U-types)	2.3
K1.06	Components of a heat exchanger (e.g., shells, tubes, plates)	2.3
K1.07	Control of heat exchanger temperatures	2.8
K1.08	Relationship between flow rates and temperatures	3.0
K1.09	Definition of thermal shock	2.8
K1.10	Principle of operation of condensers	2.8
K1.11	Relationship between condenser vacuum and backpressure	2.8
K1.12	DELETED	
K1.13	DELETED	
K1.14	DELETED	
K1.15	Effects of heat exchanger tube fouling	2.8
K1.16	Effects of scaling on heat exchanger operation	2.6
K1.17	Consequences of heat exchanger tube failure	2.8
K1.18	Reasons for noncondensable gas removal	2.9

Component: 291007 Demineralizers and Ion Exchangers

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Effect of excessive differential pressure on demineralizer performance	2.7
K1.02	Reason for sampling inlet and outlet of demineralizer	2.6
K1.03	Effects of channeling in a demineralizer	2.9
K1.04	Purpose of a demineralizer	2.9
K1.05	DELETED	
K1.06	Reason for demineralizer temperature and flow limits	2.7
K1.07	Principles of demineralizer operation	2.5
K1.08	Demineralizer D/P to determine condition of demineralizer resin bed	2.6
K1.09	Effects of demineralizer operation on water conductivity	2.7
K1.10	Reasons for bypassing demineralizers	2.7
K1.11	Reasons for using mixed-bed demineralizers to process primary water	2.3
K1.12	Plant evolutions that can cause crud bursts and the effect on demineralizers	2.8

Component: 291008 Breakers, Relays, and Disconnects

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Purpose for racking out breakers (deenergize components and associated control and indication circuits)	3.6
K1.02	Local indication that breaker is open, closed or tripped	3.5
K1.03	Meaning and/or the loss of power supply circuit breaker indicator lights and capability to remotely open and close	3.4
K1.04	Operation of various push buttons, switches, and handles and the resulting action on breakers	3.3
K1.05	Function of thermal overload protection device	3.1
K1.06	Interpreting one-line diagram of control circuitry	3.6
K1.07	Safety procedures and precautions associated with breakers, including motor control center bus breakers, high, medium, and low voltage breakers, relays and disconnects	3.7
K1.08	Effects of closing breakers with current out of phase, different frequencies, high voltage differential, low current, or too much load	3.5
K1.09	Effect of racking out breakers on control and indicating circuits and removal of control power on breaker operation	3.5
K1.10	Function, control, and precautions associated with disconnects	3.4
K1.11	Control room indication of a breaker status	3.3
K1.12	Trip indicators for circuit breakers and protective relays	2.9

6**THEORY**

6.1	Reactor Theory (CFR: 41.1)	Page
292001	Neutrons.....	6.1-3
292002	Neutron Life Cycle.....	6.1-4
292003	Reactor Kinetics and Neutron Sources.....	6.1-5
292004	Reactivity Coefficients.....	6.1-6
292005	Control Rods.....	6.1-7
292006	Fission Product Poisons.....	6.1-8
292007	Fuel Depletion and Burnable Poisons.....	6.1-9
292008	Reactor Operational Physics.....	6.1-10

6.1 Reactor Theory: 292001 Neutrons

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Define fast, intermediate, and slow neutrons	2.1
K1.02	Define prompt and delayed neutrons	3.1
K1.03	Define thermal neutrons	2.7
K1.04	Describe neutron moderation	3.2
K1.05	Identify characteristics of good moderators	2.6
K1.06	Define neutron lifetime	1.9
K1.07	Define neutron generation time	1.9
K1.08	Describe fast flux, thermal flux, and flux distribution	2.4
K1.09	Describe sources of neutrons	2.4

6.1 Reactor Theory: 292002 Neutron Life Cycle

K/A NO.	KNOWLEDGE	IMPORTANCE
	<u>Describe the neutron life cycle using the following terms:</u>	
K1.01	--fast fission factor	1.9
K1.02	--fast non-leakage probability factor	1.9
K1.03	--resonance escape probability factor	2.1
K1.04	--thermal non-leakage probability factor	2.0
K1.05	--thermal utilization factor	2.0
K1.06	--reproduction factor	1.9
K1.07	DELETED	
K1.08	Define effective multiplication factor (K-effective) and discuss its relationship to the state of a reactor (critical, subcritical, and supercritical)	2.8
K1.09	Define K-excess (excess reactivity)	2.6
K1.10	Define shutdown margin	3.5
K1.11	Define reactivity	3.3
K1.12	State the relationship between reactivity and effective multiplication factor	2.5
K1.13	Calculate shutdown margin using procedures and given plant parameters	2.4
K1.14	Evaluate change in shutdown margin due to changes in plant parameters	2.9

6.1 Reactor Theory: 292003 Reactor Kinetics and Neutron Sources

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Explain the concept of subcritical multiplication	3.0
K1.02	Given the simplified formula for subcritical multiplication, perform calculations involving steady-state count rate and source count state count rate	2.3
K1.03	Describe the production of delayed neutrons	2.4
K1.04	Define delayed neutron fraction and effective delayed neutron fraction; state the reasons for variation	2.5
K1.05	Define reactor period	3.7
K1.06	Explain the effect of delayed neutrons on reactor period	3.7
K1.07	Explain prompt critical, prompt jump, and prompt drop	3.3
K1.08	Given the power equation, solve problems for power changes and period	2.8
K1.09	Define doubling time and calculate it using the power equation	2.6
K1.10	Explain the necessity for installed neutron sources in a reactor core	2.4
K1.11	Explain why installed sources are not needed after one cycle of core operation	2.4

6.1 Reactor Theory: 292004 Reactivity Coefficients

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Define the moderator temperature coefficient of reactivity	3.2
K1.02	Describe the effect on the magnitude of the temperature coefficient of reactivity from changes in moderator temperature and core age	2.6
K1.03	Explain resonance absorption	2.7
K1.04	Explain Doppler broadening and self-shielding	2.7
K1.05	Define the fuel temperature (Doppler) coefficient of reactivity	2.9

Describe the effect on the magnitude of the Doppler coefficient of reactivity for changes in the following:

K1.06	--Moderator temperature	2.2
K1.07	--Core void fraction	2.2
K1.08	--Fuel temperature	2.4
K1.09	--Core age	2.1
K1.10	Define the void coefficient of reactivity	3.2

Describe the effect on the magnitude of void coefficient from changes in the following:

K1.11	--Core void fraction	2.6
K1.12	--Fuel temperature	2.3
K1.13	--Core age	2.2
K1.14	Compare the relative magnitudes of the temperature, Doppler, and void coefficients of reactivity	3.3
K1.15	Explain the differences between reactivity coefficients and reactivity defects	2.7
K1.16	Explain and describe the effect of power defect and Doppler defect on reactivity	2.9

6.1 Reactor Theory: 292005 Control Rods

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Relate notch and rod position	3.3
K1.02	Name the material used for thermal neutron absorption in control rods	2.6
K1.03	Describe nuclear properties of active neutron absorber material in the control rod	1.9
K1.04	Predict direction of change in reactor power for a change in control rod position	3.5
K1.05	Define rod density	2.6
K1.06	Define reactor SCRAM/trip	3.8
K1.07	Define control rod worth, differential CRW, and integral control rod worth	2.6
K1.08	Explain the shape of curves for differential and integral CRW versus rod position	2.3
K1.09	Explain direction of change in the magnitude of CRW for a change in moderator temperature, void fraction, control rod density, and xenon	2.6
K1.10	State the purpose of flux shaping	3.3
K1.11	Define deep rods and shallow rods	2.5
K1.12	Describe effects of deep and shallow control rods on axial and radial flux distribution	2.9

6.1 Reactor Theory: 292006 Fission Product Poisons

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Define fission product poison	2.8
K1.02	State the characteristics of xenon-135 as a fission product poison	3.1
K1.03	Describe the production of xenon-135	2.9
K1.04	Describe the removal of xenon-135	2.9

Describe the following processes and state their effect on reactor operations:

K1.05	--Equilibrium xenon	2.9
K1.06	--Transient xenon	2.7
K1.07	--Xenon following a SCRAM	3.2
K1.08	Describe the effects that xenon concentration has on flux shape and control rod patterns	3.2

Plot the curve and explain the reasoning for the reactivity insertion by Xenon-135 versus time for the following:

K1.09	--Initial reactor startup and ascension to rated power	2.5
K1.10	--Reactor startup with xenon-135 already present in the core	2.9
K1.11	--Power changes from steady-state power to another	2.7
K1.12	--Reactor SCRAM	2.8
K1.13	--Reactor shutdown	2.6
K1.14	Explain the process and reasons for the reactor operator to compensate for the time dependent behavior of xenon-135 concentration in the reactor	3.2
K1.15	State the characteristics of samarium-149 as a fission product poison	2.1
K1.16	Describe the production of samarium-149	1.9
K1.17	Describe the removal of samarium-149	1.9
K1.18	Define equilibrium samarium	1.8

Plot the curve and explain the reasoning for the reactivity insertion by Samarium-149 versus time for the following:

K1.19	--Initial reactor startup and ascension to rated power	1.8
K1.20	--Reactor shutdown	1.7
K1.21	Describe effects of power changes on samarium concentration	1.8
K1.22	Compare effects of samarium-149 on reactor operation with those of xenon-135	2.4

6.1 Reactor Theory: 292007 Fuel Depletion and Burnable Poisons

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Define burnable poison and state its use in the reactor	3.1
K1.02	Describe and explain distribution of burnable poisons in the core	2.0
K1.03	Given a curve of K-effective versus core age, state the reasons for maximum, minimum, and inflection points	2.7

6.1 Reactor Theory: 292008 Reactor Operational Physics

K/A NO.	KNOWLEDGE	IMPORTANCE
<u>Startup and Approach to Criticality</u>		
K1.01	List parameters that should be monitored and controlled during the approach to criticality	3.9
K1.02	List reactivity control mechanisms that exist for plant conditions during the approach to criticality	3.8
K1.03	Describe count rate and instrument response that should be observed for rod withdrawal during the approach to criticality	4.1
K1.04	Relate the concept of subcritical multiplication to predicted count rate and startup rate/period response for control rod withdrawal during the approach to criticality	3.4
K1.05	Explain characteristics to be observed when the reactor is very close to criticality	4.3
<u>Criticality</u>		
K1.06	List parameters that should be monitored and controlled upon reaching initial criticality	4.2
K1.07	Define criticality as related to a reactor startup	3.9
K1.08	Describe reactor power and startup rate/period response once criticality is reached	4.1
<u>Intermediate Range Operation</u>		
K1.09	List parameters that should be monitored and controlled during the intermediate phase of startup (from criticality to the point of adding heat (POAH))	3.9
K1.10	Explain procedures for adjusting reactor period during the intermediate phase of startup	3.6
K1.11	Discuss the concept of the point of adding heat (POAH) and its impact on reactor power	3.8
K1.12	Describe reactor power and period response prior to reaching the POAH	3.7
K1.13	Explain characteristics to look for when the POAH is reached	3.9
<u>Heatup Operation</u>		
K1.14	Describe three parameters to be monitored and controlled during heatup	3.5
K1.15	Describe reactor power and startup rate/period response after reaching the POAH	3.7
K1.16	Explain procedures for establishing and controlling heatup rate	3.7
<u>Power Operation</u>		
K1.17	Describe three parameters to be monitored and controlled during power operation	3.6
K1.18	Describe the means by which reactor power will be increased to rated power	3.8

6.1 Reactor Theory: 292008 Reactor Operational Physics

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.19	Explain transient and steady-state effects of a control rod withdrawal on reactor power and void fraction content	3.2
K1.20	Explain transient and steady-state effects of an increase in core flow on reactor power and void fraction	3.4
K1.21	Explain the relationship between steam production rate and reactor power given specific conditions	3.0
K1.22	Explain the effect that opening steam bypass valves, during power operation, will have on reactor power	3.6
K1.23	Explain the necessity for rod pattern exchanges	3.1
K1.24	Describe the parameters to be monitored and controlled during rod pattern exchanges	3.2
<u>Reactor Response on a SCRAM</u>		
K1.25	Explain the shape of a curve of reactor power versus time after a SCRAM	2.9
<u>Normal Reactor Shutdown</u>		
K1.26	Explain reactor power response to a decrease in core flow	3.7
K1.27	Explain reactor power response to a control rod insertion	3.5
K1.28	Explain the necessity for inserting control rods in a predetermined sequence during normal shutdown	3.7
K1.29	Define decay heat	3.6
K1.30	Explain the relationship between decay heat generation and (a) power level history, (b) power production, and (c) time since reaction shut down	3.5

6.2	Thermodynamics Theory (CFR: 41.14)	
293001	Thermodynamic Units and Properties.....	6.2-3
293002	Basic Energy Concepts.....	6.2-4
293003	Steam.....	6.2-5
293004	Thermodynamic Processes.....	6.2-6
293005	Thermodynamic Cycles.....	6.2-7
293006	Fluid Statics and Dynamics.....	6.2-8
293007	Heat Transfer.....	6.2-10
293008	Thermal-Hydraulics.....	6.2-11
293009	Core Thermal Limits.....	6.2-13
293010	Brittle Fracture and Vessel Thermal Stress.....	6.2-15

6.2 Thermodynamics Theory: 293001 Thermodynamic Units and Properties

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Convert between absolute and relative pressure and vacuum scales	2.3
K1.02	Recognize the difference between absolute and relative (Kelvin) temperature scales	2.1
K1.03	DELETED	
K1.04	Explain relationships between work, power, and energy	1.9

6.2 Thermodynamics Theory: 293002 Basic Energy Concepts

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Define energy and work	1.7
K1.02	Explain the law of conservation of energy	1.9
K1.03	Explain the difference between state and phase of a working substance	1.7
K1.04	Explain the application of enthalpy in the monitoring of plant processes	2.4
K1.05	Identify the relationship between heat flow during a process and a temperature entropy diagram representation of the process	2.2
K1.06	Define specific heat	2.1
K1.07	Apply specific heat in solving heat transfer problems	1.6
K1.08	Define enthalpy	2.4

6.2 Thermodynamics Theory: 293003 Steam

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Describe effects of pressure and temperature on density or specific volume of a liquid and gas	2.4
K1.02	Distinguish between liquids, vapors, gases, and fluids	2.3
<u>Define the following terms:</u>		
K1.03	Latent heat of vaporization	2.4
K1.04	Vaporization line	2.1
K1.05	Critical point	1.8
K1.06	Vapor dome	2.0
K1.07	Saturated liquid	2.8
K1.08	Wet vapor	1.9
K1.09	Saturated vapor	2.6
K1.10	Vapor pressure	1.9
K1.11	Moisture content	2.3
K1.12	Quality	2.6
K1.13	Superheated vapor	2.4
K1.14	Supersaturated vapor	1.8
K1.15	Subcooled and compressed liquids	2.4
K1.16	Subcooling	2.8
K1.17	DELETED	
<u>Identify the following terms on a T-s diagram:</u>		
K1.18	--Critical point	1.7
K1.19	--Saturated liquid line	2.2
K1.20	--Saturated vapor line	2.3
K1.21	--Solid, liquid, gas, vapor, and fluid regions	2.2
K1.22	Explain the usefulness of steam tables to the control room operator	3.2
K1.23	Use saturated and superheated steam tables	3.1

6.2 Thermodynamics Theory: 293004 Thermodynamic Processes

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Explain the relationship between real and ideal processes	1.7
K1.02	Explain the shape of the T-s diagram process line for a typical boiler	1.9
<u>Nozzles</u>		
K1.03	Describe the functions of nozzles in flow restrictors	2.2
K1.04	Describe the functions of nozzles in air ejectors	2.6
K1.05	DELETED	
<u>Turbines</u>		
K1.06	Explain the function of nozzles, fixed blading, and moving blading in the turbine	2.1
K1.07	Explain the reason turbines are multistaged	2.2
K1.08	Define turbine efficiency	2.1
K1.09	Explain the difference between real and ideal turbine efficiency	1.8
<u>Pumps</u>		
K1.10	Define pump efficiency	1.9
K1.11	Explain the difference between ideal and real pumping processes	1.8
<u>Condensers</u>		
K1.12	Describe the process of condensate depression (subcooling) and its effect on plant operation	3.1
K1.13	Explain vacuum formation in condenser processes	2.6
K1.14	Explain the condensing process	2.7
<u>Throttling and the throttling process</u>		
K1.15	Define throttling	2.3
K1.16	Explain the reduction of process pressure from throttling	2.3
K1.17	Determine the exit conditions for a throttling process based on the use of steam or water	2.8

6.2 Thermodynamics Theory: 293005 Thermodynamic Cycles

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Define thermodynamic cycle	1.8
K1.02	Define thermodynamic cycle efficiency in terms of net work produced and energy applied	1.7
K1.03	Describe the steam quality/moisture effects on turbine integrity and efficiency	2.7
K1.04	DELETED	
K1.05	State the advantages of moisture separators/reheaters and feedwater heaters for a typical steam cycle	2.8
K1.06	Describe how changes in system parameters affect thermodynamic efficiency	2.6

6.2 Thermodynamics Theory: 293006 Fluid Statics and Dynamics

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Distinguish between fluids and other substances	1.8
K1.02	Distinguish between static pressure, dynamic pressure, and total pressure	2.2
K1.03	Define head loss	2.5
K1.04	Discuss operational considerations of viscosity as related to head loss	1.9
K1.05	Explain operational implications of fluid/water hammer	3.3
K1.06	Discuss methods of prevention of fluid/water hammer	3.2
<u>Pumps and Pump Characteristics</u>		
K1.07	State the purpose of a pump	2.6
K1.08	Discuss pump head	2.6
K1.09	Discuss relationship between pump speed, head, flow, and power without using formulas or calculations	2.6
K1.10	Define cavitation	2.9
K1.11	Define net positive suction head (NPSH)	2.8
K1.12	Define pump shutoff head, pump runout, and axial thrust	2.5
K1.13	Explain the importance of proper system venting for pump operations	2.9
K1.14	Explain the results of putting centrifugal pumps in parallel or series combinations	2.7
K1.15	Given the characteristic curve for a typical centrifugal pump, explain the reason for its shape	2.3
K1.16	Using a centrifugal pump characteristic curve and a system characteristic curve, illustrate how the system operating point changes due to system changes	2.4
K1.17	Describe how a centrifugal pump characteristic curve will change with pump speed	2.3
K1.18	Explain how operating a centrifugal pump at shutoff head may cause overheating of the pump and describe methods used to avoid overheating	2.7
K1.19	Discuss the characteristic curve for a typical positive displacement pump and explain the reason for its shape	2.1
K1.20	Describe the problems that will occur in emergency core cooling systems if the pumps are operated at lower than design flow for extended periods of time	2.9
<u>Define or explain the following terms and concepts:</u>		
K1.21	Mass flow rate	2.4
K1.22	Two-phase flow	2.6
K1.23	Pressure spike	2.3
K1.24	Gas binding	2.3
K1.25	Recirculation ratio	2.3
K1.26	Pipe whip	2.2

6.2 Thermodynamics Theory: 293006 Fluid Statics and Dynamics

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.27	Explain why flow measurements must be corrected for density changes	2.4
K1.28	Explain the relationship between pressure head and velocity head in a fluid system	2.0
K1.29	Discuss the velocity profiles for laminar flow and turbulent flow	1.8
K1.30	Describe the methods of controlling system flow rates	2.7

6.2 Thermodynamics Theory: 293007 Heat Transfer

K/A NO.	KNOWLEDGE	IMPORTANCE
<u>Heat Transfer</u>		
K1.01	Describe three mechanisms of heat transfer	3.2
K1.02	Describe thermal conductivity	2.6
K1.03	Explain the manner in which fluid films affects heat transfer	2.8
<u>Heat Exchangers</u>		
K1.04	Discuss parallel-flow heat exchangers	2.2
K1.05	Discuss counter-flow heat exchangers	2.2
K1.06	Discuss the factors that affect heat transfer rate in a heat exchanger	2.8
K1.07	Describe how the presence of gases or steam can affect heat transfer and fluid flow in heat exchangers	2.9
<u>Condenser Applications of Heat Transfer</u>		
K1.08	List functions of the main condenser in a power plant	3.1
K1.09	Discuss operational implications of condensate depression	2.7
<u>Core Thermal Power</u>		
K1.10	Define core thermal power	2.9
K1.11	Explain methods of calculating core thermal power	3.1
K1.12	Define percent reactor power	2.7
K1.13	Calculate core thermal power using a simplified heat balance	2.9

6.2 Thermodynamics Theory: 293008 Thermal-Hydraulics

K/A NO.	KNOWLEDGE	IMPORTANCE
<u>Boiling Heat Transfer</u>		
K1.01	Distinguish between boiling processes and other heat transfer mechanisms	2.8
K1.02	Describe surface or cavity nucleation	2.3
K1.03	List factors affecting bubble formation in a cavity	2.1
K1.04	Describe means by which boiling improves convection heat transfer	2.7
K1.05	Describe microconvection	1.5
<u>Pool Boiling Curve (Temperature vs. heat flux)</u>		
K1.06	Define a natural convection heat transfer	2.6
K1.07	Define nucleate boiling, subcooled nucleate boiling, and bulk boiling	3.0
K1.08	Describe departure from nucleate boiling	3.1
K1.09	Describe onset of transition boiling	3.2
K1.10	Describe critical heat flux	3.0
K1.11	Describe transition (partial film) boiling	2.8
K1.12	Describe stable film boiling	2.8
K1.13	Describe burnout and burnout heat flux	2.3
<u>Two Phase Flow</u>		
K1.14	Classify slug flow region along a fuel channel, experiencing two-phase flow	2.1
K1.15	Describe annular flow region along a hypothetical fuel channel, experiencing two-phase flow	2.3
K1.16	Describe dryout region or mist flow region along a hypothetical fuel channel, experiencing two-phase flow	2.3
K1.17	Describe onset of transition boiling point along a hypothetical fuel channel, experiencing two phase flow	2.8
K1.18	Describe effects of flowrate and phase change on the heat transfer coefficient	2.4
<u>Core Inlet Subcooling</u>		
K1.19	Define core inlet subcooling	2.8
K1.20	Define carryunder	2.6
<u>Void and Void Fraction</u>		
K1.21	Define void fraction	3.0
K1.22	Explain the term void as applied to core operations	3.0
K1.23	Define quality	2.7
K1.24	Draw the temperature profile from the centerline of a fuel pellet to the centerline of the channel	2.5
<u>Recirculation System</u>		
K1.25	Explain the reason for forced core recirculation	3.2

6.2 Thermodynamics Theory: 293008 Thermal-Hydraulics

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.26	Explain the jet pump operating principle	3.1
K1.27	Explain the necessity of determining core coolant flow	3.0
K1.28	Describe the factors affecting single- and two-phase flow resistance	2.5
<u>Core Orificing</u>		
K1.29	Describe the effects of increasing bundle power on bundle flow resistance	3.0
K1.30	Compare the flow resistance through high-powered bundles to that of low-powered bundles	2.7
K1.31	Explain the necessity of core orificing	3.0
K1.32	Describe core bypass flow	2.6
K1.33	Explain the need for adequate core bypass flow	2.6
<u>Natural Circulation</u>		
K1.34	Explain the causes of natural circulation in BWRs	3.1
K1.35	Describe problems that thermal stratification can cause	3.3
K1.36	Describe means by which the operator can determine if natural circulation flow exists	3.3
K1.37	Describe means by which the operator can enhance natural circulation	3.4
<u>Sketch the axial temperature and enthalpy profiles for a typical reactor coolant channel and describe how they are affected by the following:</u>		
K1.38	--Onset of nucleate boiling	2.1
K1.39	--Axial core flux	1.9
K1.40	--Inlet temperature	1.9
K1.41	--Heat generation rate	2.0
K1.42	--Flow rate in the channel	1.9
K1.43	Sketch the temperature profile in the axial and radial directions for a typical fuel rod and explain the reason for its shape.	2.2

6.2 Thermodynamics Theory: 293009 Core Thermal Limits

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	Explain radial peaking factor	2.5
K1.02	Explain axial peaking factor	2.6
K1.03	Explain local peaking factor	2.5
K1.04	Explain total peaking factor	2.6
K1.05	State the reason thermal limits are necessary	3.5
<u>LHGR</u>		
K1.06	Define LHGR	3.8
K1.07	Explain the basis of the limiting condition of LHGR	3.6
K1.08	Describe the mode of fuel failure for LHGR	3.4
K1.09	Define FLPD and MFLPD	3.7
<u>MAPLHGR</u>		
K1.10	Define APLHGR	3.7
K1.11	Explain the basis of the limiting condition for APLGHR	3.6
K1.12	Describe the mode of fuel failure for APLHGR	3.5
K1.13	Define MAPLHGR	3.6
K1.14	Explain the mechanisms most limiting for each region of the MAPLHGR limit curves	2.7
K1.15	Describe conditions under which radiative heat transfer becomes the significant method of heat transfer within a fuel bundle	3.1
K1.16	Discuss how changes in the heat generation rate and thermal conductivity of the fuel rod affect fuel centerline temperature	2.8
<u>M CPR</u>		
K1.17	Define critical power	3.7
K1.18	Define CPR	3.7
K1.19	Explain the basis of the limiting condition for CPR	3.6
K1.20	Describe the mode of fuel failure for CPR	3.6
K1.21	Define MCPR	3.6
K1.22	Describe the effects of subcooling on critical power	3.3
K1.23	Describe the effects of mass flow on critical power	3.2
K1.24	Describe the effects of pressure on critical power	3.2
K1.25	Describe the effects of local power distribution on critical power	3.2
K1.26	Describe the effects of axial power distribution on critical power	3.1
K1.27	Explain the purpose of the flow biasing correlation factor, (K), as it relates to MCPR limits	3.3
K1.28	Define fraction of limiting critical power ratio	3.5

6.2 Thermodynamics Theory: 293009 Core Thermal Limits

K/A NO.	KNOWLEDGE	IMPORTANCE
<u>Thermal Time Constant</u>		
K1.29	Define fuel thermal time constant	2.7
K1.30	Relate thermal time constant to transient operating condition	2.7
<u>Pellet-Clad Interaction</u>		
K1.31	Describe pellet-clad interaction	3.4
K1.32	List the causes of pellet-clad interaction	3.3
K1.33	Describe the purpose of the pellet to clad gap	2.8
K1.34	Identify the possible effects of fuel densification	2.6
K1.35	Describe the effects of iodine and cadmium on pellet-clad interaction	2.6
<u>Preconditioning Interim Operating Management Recommendations (PCIOMR)</u>		
K1.36	Explain the purpose for PCIOMR	3.4
K1.37	Identify how the PCIOMR rules minimize the adverse effects of pellet-clad interaction	3.3
K1.38	State the items measured for each of the three core thermal limits	3.1
<u>For the following plant operating or accident conditions, identify which of the three core thermal limits are most limiting:</u>		
K1.39	Full power operation	3.2
K1.40	Loss of reactor coolant	3.3
K1.41	Increase in core flow	3.3
K1.42	Increase in reactor pressure	3.3
K1.43	Cold water addition	3.4

6.2 Thermodynamics Theory: 293010 Brittle Fracture and Vessel Thermal Stress

K/A NO.	KNOWLEDGE	IMPORTANCE
K1.01	State the brittle fracture mode of failure	2.8
K1.02	State the definition of nil-ductility transition temperature	2.7
K1.03	Define reference temperature	2.5
K1.04	State how the possibility of brittle fracture is minimized by operating limitations	3.2
K1.05	State the effect of fast neutron irradiation on reactor vessel metals	2.8
K1.06	State the operational concerns of uncontrolled cooldown	4.1

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

NUREG-1123, Rev. 3

2. TITLE AND SUBTITLE

Knowledge and Abilities Catalog for Nuclear Power Plant Operators: Boiling Water Reactors

3. DATE REPORT PUBLISHED

MONTH

YEAR

September

2020

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

B. Tindell and S. Cushing

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Division of Reactor Oversight
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above", if contractor, provide NRC Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address.)

Same as above

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

NUREG-1123, "Knowledge and Abilities Catalog for Nuclear Power Plant Operators: Boiling Water Reactors," provides the basis for the development of content-valid licensing examinations for reactor operators and senior reactor operators. The examinations developed using the Boiling Water Reactor Catalog along with NUREG-1021, "Operator Licensing Examination Standards for Power Reactors" will sample the topics listed under Title 10 of the Code of Federal Regulations (10 CFR) Part 55, "Operators' Licenses."

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

operator licensing
examinations
reactor operator
senior reactor operator
training
task analysis
boiling water reactors

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)


unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, DC 20555-0001
OFFICIAL BUSINESS



@NRCgov

**NUREG-1123, Rev. 3
Final**

**Knowledge and Abilities Catalog for Nuclear Power Plant Operators:
Boiling Water Reactors**

September 2020