

Confirmatory Thermal- Hydraulic Analysis to Support Specific Success Criteria in the Standardized Plant Analysis Risk Models- Duane Arnold

Appendices D to E

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at the NRC's Public Electronic Reading Room at <http://www.nrc.gov/readi ng-rm.html>. Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and Title 10, "Energy," in the *Code of Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents

U.S. Government Publishing Office
Washington, DC 20402-0001
Internet: <http://bookstore.gpo.gov>
Telephone: 1-866-512-1800
Fax: (202) 512-2104

2. The National Technical Information Service

5301 Shawnee Road
Alexandria, VA 22161-0002
<http://www.ntis.gov>
1-800-553-6847 or, locally, (703) 605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

U.S. Nuclear Regulatory Commission

Office of Administration
Multimedia, Graphics and Storage & Distribution Branch
Washington, DC 20555-0001
E-mail: distribution.resource@nrc.gov
Facsimile: (301) 415-2289

Some publications in the NUREG series that are posted at the NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library

Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute

11 West 42nd Street
New York, NY 10036-8002
<http://www.ansi.org>
(212) 642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

DISCLAIMER: This report was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product, or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.

Confirmatory Thermal- Hydraulic Analysis to Support Specific Success Criteria in the Standardized Plant Analysis Risk Models- Duane Arnold

Appendices D to E

Manuscript Completed: May 2019
Date Published: October 2020

Prepared by:
S. Campbell,¹ S. Dennis,¹ D. Helton,¹ L. Kozak,¹ J. Pires,¹ F. Sock,¹ M.
Khatib-Rahbar,² A. Krall²
R. Buell³

U.S. Nuclear Regulatory Commission¹

Energy Research, Inc.²
P.O. Box 2034
Rockville, MD 20847

Idaho National Laboratory³
P.O. Box 1625
Idaho Falls, ID 83415

Office of Nuclear Regulatory Research

ABSTRACT

This report extends the work documented in NUREG-2187, “Confirmatory Thermal-Hydraulic Analysis to Support Specific Success Criteria in the Standardized Plant Analysis Risk Models—Byron Unit 1,” issued January 2016, to the Duane Arnold Energy Center. Its purpose is to produce an additional set of best estimate thermal-hydraulic calculations that can confirm or enhance specific success criteria for system performance and operator timing found in the agency’s probabilistic risk assessment tools. Along with enhancing the technical basis for the agency’s independent standardized plant analysis risk (SPAR) models, these calculations are expected to be a useful reference to model end users for specific regulatory applications.

This report first describes major assumptions used in this study. It then discusses the major plant characteristics for the Duane Arnold Energy Center, in addition to the MELCOR model used to represent the plant. Finally, the report presents the results of MELCOR calculations for selected initiators and compares these results to SPAR success criteria, the licensee’s success criteria, or other generic studies.

The study results provide additional timing information for several probabilistic risk assessment sequences, confirm many of the existing SPAR modeling assumptions, and give a technical basis for a few specific SPAR modeling changes, including the following potential changes:

- Degraded high-pressure injection and relief valve Criteria (non-anticipated transient without scram): A single control rod drive pump injecting at the postscram increased injection rate is sufficient for reactor pressure vessel (RPV) water inventory makeup. Additionally, two control rod drive pumps injecting at the postscram injection rate provide enough makeup to the RPV to facilitate a cooldown of the RPV to cold shutdown conditions. This increased injection is currently not queried in the SPAR models but could be added.
- Mitigating strategies usage: If diverse and flexible coping strategies (FLEX) are not available, success of long-term cooling for these scenarios is only possible with both anticipatory venting and condensate storage tank (CST) availability. Currently, CST availability is not queried in the SPAR models. This could be added for scenarios for which no alternate injection is available. For loss-of-offsite-power scenarios, FLEX injection led to success in all scenarios that gave FLEX credit. Given the ability of FLEX to prevent core damage, this confirms that the SPAR models should have FLEX equipment added.
- Emergency core cooling system injection following containment failure or venting: Depending upon the size of containment failure, wetwell and drywell pressure will fall, potentially to the point of allowing high-pressure injection restart following its loss. This action could be added to the SPAR models.
- Safe and stable end-state considerations: If the CST is unavailable, the long-term availability of high-pressure injection is questionable at best. CST should be queried when high-pressure injection systems are the source of long-term makeup. Additionally, increased postscram control rod drive hydraulic system injection is adequate for makeup. This increased injection is a candidate for inclusion in the SPAR model. Depressurizing when reaching the heat capacity limit curve is important, since the rate of

seal leakage, as well as the rate of injection, is pressure dependent. This depressurization is a candidate for consideration in the SPAR models.

FOREWORD

The U.S. Nuclear Regulatory Commission (NRC) uses its standardized plant analysis risk (SPAR) models to support many risk-informed initiatives. A number of processes ensure the fidelity and realism of these models, including cross-comparison with industry models, review and use by a wide range of technical experts, and confirmatory analysis. This report—prepared by the staff of the Office of Nuclear Regulatory Research, in consultation with the staff of the Office of Nuclear Reactor Regulation; experts from Energy Research, Inc. and Idaho National Laboratory; and the agency’s senior reactor analysts—represents a major confirmatory analysis activity.

Probabilistic risk assessment (PRA) models for nuclear power plants rely on underlying modeling assumptions known as success criteria and sequence timing assumptions. These criteria and assumptions determine what combination of system and component availabilities will lead to postulated core damage, as well as the timeframes during which components must operate or operators must take particular actions. This report investigates certain thermal-hydraulic aspects of a particular SPAR model (which is generally representative of other models within the same class of plant design), with the goal of further strengthening the technical basis for decisionmaking that relies on the SPAR models. This report augments the existing collection of contemporary Level 1 PRA success criteria analyses and, as such, supports (1) maintaining and enhancing the SPAR models that the NRC develops, (2) supporting the NRC’s risk analysts when addressing specific issues in the accident sequence precursor program and the significance determination process, and (3) informing other ongoing and planned initiatives. This analysis employs the MELCOR computer code and uses a plant model developed for this project.

The analyses summarized in this report provide the basis for confirming or changing success criteria in the SPAR model for the Duane Arnold Energy Center. Based on further evaluation, these results could apply to similar plants, while future analyses could apply to other design classes, as occurred in the past (see NUREG-2187, “Confirmatory Thermal-Hydraulic Analysis to Support Specific Success Criteria in the Standardized Plant Analysis Risk Models—Byron Unit 1,” issued January 2016). The staff expects to continue its focus on confirming success criteria and other aspects of PRA modeling using its state-of-the-art tools (e.g., the MELCOR computer code) as it develops and improves its risk tools.

TABLE OF CONTENTS

ABSTRACT	iii
FOREWORD	v
LIST OF FIGURES	ix
LIST OF TABLES	xi
ACKNOWLEDGMENTS	xiii
ABBREVIATIONS AND ACRONYMS	xv
1 BACKGROUND	1-1
1.1 Confirmatory Success Criteria Project	1-1
1.2 Hazard, Mode, and Radiological Source Scope	1-2
1.3 Issues To Be Investigated	1-2
1.4 Plant Selection	1-3
2 MAJOR ASSUMPTIONS AND PEER REVIEW DESCRIPTION	2-1
2.1 Major Assumptions.....	2-1
2.2 Description of the DAEC MELCOR Model.....	2-3
2.3 Shakedown and Benchmarking of the DAEC MELCOR Model	2-7
2.3.1 Steady State.....	2-7
2.3.2 Comparison to Select Licensing-Basis Analysis	2-8
2.3.3 Application of the Baseline Small Loss-of-Coolant-Accident Sequence.....	2-8
2.3.4 Application of the Baseline FLEX Sequence	2-11
2.3.5 Application of a Baseline Station Blackout Sequence	2-18
2.3.6 Updated Shakedown Based upon Latest Deck Revision.....	2-24
3 SUCCESS CRITERIA FOR SITUATIONS WITH DEGRADED HIGH-PRESSURE INJECTION AND RELIEF VALVE CRITERIA FOR NON-ANTICIPATED TRANSIENT WITHOUT SCRAM	3-1
3.1 Issue Description	3-1
3.2 Transient Sequence	3-3
3.2.1 Calculation Matrix Development	3-3
3.2.2 MELCOR Simulation Results.....	3-7
3.3 Small Loss-of-Coolant Accident Sequence	3-11
3.3.1 Calculation Matrix Development	3-11
3.3.2 MELCOR Simulation Results	3-13
3.4 Conclusions Drawn from MELCOR Results	3-16
4 MITIGATING STRATEGIES (FLEX) USAGE IN LOSS-OF-ALTERNATING-CURRENT-POWER SCENARIOS	4-1
4.1 Issue Description.....	4-1
4.1.1 DAEC Post-Fukushima Actions Related to Mitigating Strategies.....	4-2
4.1.2 The Scenario Assumed for Mitigating Strategies Formulation	4-2
4.1.3 DAEC Plant Modifications To Comply with the Post-Fukushima Orders.....	4-4

4.2	Station Blackout Sequence	4-6
4.2.1	Calculation Matrix Development.....	4-6
4.2.2	MELCOR Simulation Results	4-10
4.3	Loss-of-Main-Feedwater Sequence	4-14
4.3.1	Calculation Matrix Development.....	4-14
4.3.2	MELCOR Simulation Results	4-18
4.4	Conclusions Drawn from MELCOR Results	4-22
5	EMERGENCY CORE COOLING SYSTEM INJECTION FOLLOWING CONTAINMENT FAILURE OR VENTING.....	5-1
5.1	Issue Description.....	5-1
5.2	Station Blackout Sequence	5-3
5.2.1	Calculation Matrix Development.....	5-3
5.2.2	MELCOR Simulation Results	5-5
5.3	Loss-of-Main-Feedwater Scenario	5-10
5.3.1	Calculation Matrix Development.....	5-10
5.3.2	MELCOR Simulation Results	5-12
5.4	Conclusions Drawn from MELCOR Results	5-16
6	SAFE AND STABLE END-STATE CONSIDERATIONS	6-1
6.1	Issue Description.....	6-1
6.2	Station Blackout Sequence	6-2
6.2.1	Calculation Matrix Development.....	6-2
6.2.2	MELCOR Simulation Results	6-4
6.3	Loss-of-Main-Feedwater Scenario	6-7
6.3.1	Calculation Matrix Development.....	6-7
6.3.2	MELCOR Simulation Results	6-8
6.4	Conclusions Drawn from MELCOR Results	6-11
7	APPLICATION OF MELCOR RESULTS TO SPAR MODEL	7-1
8	CONCLUSIONS	8-1
9	REFERENCES	9-1
APPENDIX A	MELCOR VERSIONS.....	A-1
APPENDIX B	CONTAINMENT VENTING.....	B-1
APPENDIX C	CHAPTER 3 FIGURES.....	C-1
APPENDIX D	CHAPTER 4 FIGURES.....	D-1
APPENDIX E	CHAPTER 5 FIGURES	E-1
APPENDIX F	GRADUAL OVERPRESSURE FAILURE MODES AND LOCATIONS IN MARK I, MARK II, AND MARK III CONTAINMENT SYSTEMS	F-1
APPENDIX G	CHAPTER 6 FIGURES	G-1
APPENDIX H	EVENT TREES	H-1

LIST OF FIGURES

Figure 2-1 Recirculation Line Coolant Temperature during Controlled Depressurization of the RCS	2-14
Figure 2-2 RPV Pressure (Case 1)	2-16
Figure 2-3 RCIC Flow (Case 1)	2-16
Figure 2-4 Drywell Pressure (Case 1)	2-17
Figure 2-5 Wetwell Water Temperature (Case 1)	2-17
Figure 2-6 FLEX Pump Flow (Case 1)	2-18
Figure 2-7 Wetwell Water Temperature (NRC)	2-22
Figure 2-8 Containment Pressure (NRC)	2-22
Figure 2-9 Vessel Water Levels (NRC)	2-23
Figure 2-10 FLEX Pump Flow (NRC)	2-23
Figure 2-11 RPV Pressure (Case 1, Updated)	2-25
Figure 2-12 RCIC Flow (Case 1, Updated)	2-25
Figure 2-13 Drywell Pressure (Case 1, Updated)	2-26
Figure 2-14 Wetwell Water Temperature (Case 1, Updated)	2-26
Figure 2-15 FLEX Pump Flow (Case 1, Updated)	2-27

LIST OF TABLES

Table 1-1	Major Plant Characteristics for DAEC	1-3
Table 2-1	Major Assumptions in the MELCOR Calculations	2-1
Table 2-2	Structures Included in the DAECMELCOR Model.....	2-3
Table 2-3	Systems Included in the DAECMELCOR Model	2-4
Table 2-4	Other Components Included in the DAECMELCOR Model.....	2-5
Table 2-5	Operator Action Surrogates Included in the DAECMELCOR Model.....	2-5
Table 2-6	Default MELCOR Modeling Values	2-5
Table 2-7	Comparison of MELCOR-Predicted Steady-State to Plant Conditions.....	2-7
Table 2-8	Boundary Conditions for LOOP/SLOCA Validation Calculation.....	2-9
Table 2-9	Boundary Conditions for the FLEX Validation	2-13
Table 2-10	Boundary Conditions for the SBO Validation.....	2-14
Table 2-11	Timing of Important Events for SBO Validation	2-20
Table 3-1	PRA Sequences of Interest for Depressurization—TRANS	3-4
Table 3-2	Calculation Matrix—HPI and SRV Criteria for Non-ATWS—TRANS.....	3-4
Table 3-3	Initial and Boundary Conditions—HPI and SRV Criteria for Non-ATWS— TRANS	3-5
Table 3-4	Timing of Significant Events and the Maximal Peak Cladding Temperature Reached in the TRANS-30 with Nominal CRDHS Injection.....	3-8
Table 3-5	Sensitivity Study Matrix—HPI and SRV Criteria for Non-ATWS	3-10
Table 3-6	PRA Sequences of Interest for Depressurization—SLOCA	3-11
Table 3-7	Calculation Matrix—HPI and SRV Criteria for Non-ATWS—SLOCA	3-12
Table 3-8	Initial and Boundary Conditions—HPI and SRV Criteria for Non-ATWS— SLOCA.....	3-12
Table 3-9	Timing of Significant Events and the Maximal Peak Cladding Temperature Reached in the 1.8-Inch Recirculation Line SLOCA Cases.....	3-14
Table 3-10	Sensitivity Study Matrix—HPI and SRV Criteria for Non-ATWS	3-15
Table 4-1	SBO Sequence of Interest for FLEX-Based Diverse Injection	4-6
Table 4-2	Calculation Matrix—Mitigating Strategies—SBO	4-7
Table 4-3	Initial and Boundary Conditions—Mitigating Strategies—LOOPGR.....	4-10
Table 4-4	LOOPGR Results.....	4-10
Table 4-5	Sensitivity Study Matrix—Mitigating Strategies—SBO	4-13
Table 4-6	LOMF Sequence of Interest for FLEX-Based Diverse Injection	4-15
Table 4-7	Calculation Matrix—Mitigating Strategies—LOMF-25	4-15

Table 4-8	Initial and Boundary Conditions—Mitigating Strategies—LOMFW	4-17
Table 4-9	LOMFW Results and Key Timings	4-18
Table 4-10	Sensitivity Study Matrix—Mitigating Strategies—LOMFW	4-20
Table 5-1	Calculation Matrix—ECCS Injection—SBO Sequence.....	5-3
Table 5-2	Initial and Boundary Conditions—ECCS Injection—SBO Sequence.....	5-5
Table 5-3	LOOPGR Results	5-5
Table 5-4	Sensitivity Study Matrix—ECCS Injection—SBO Sequence	5-8
Table 5-5	Calculation Matrix—ECCS Injection—LOMFW Sequence.....	5-10
Table 5-6	Initial and Boundary Conditions—ECCS Injection—LOMFW Sequence	5-11
Table 5-7	LOMFW Results	5-12
Table 5-8	Sensitivity Study Matrix—ECCS Injection—LOMFW Sequence	5-14
Table 6-1	Calculation Matrix—Safe and Stable—SBO Sequence	6-2
Table 6-2	Initial and Boundary Conditions—Safe and Stable—SBO Sequence.....	6-4
Table 6-3	LOOPGR Results.....	6-4
Table 6-4	Sensitivity Study Matrix—Safe and Stable—SBO Scenario	6-6
Table 6-5	Calculation Matrix—Safe and Stable—LOMFW Sequence.....	6-7
Table 6-6	Initial and Boundary Conditions—Safe and Stable—LOMFW Sequence.....	6-8
Table 6-7	LOMFW Results	6-9
Table 6-8	Sensitivity Study Matrix—Safe and Stable—LOMFW Scenario	6-10
Table 7-1	Mapping of MELCOR Analyses to the DAEC SPAR(8.50) Model	7-1
Table 7-2	Potential Success Criteria Updates Based on DAEC Result.....	7-2

ACKNOWLEDGMENTS

This report is the result of the efforts of many members of the U.S. Nuclear Regulatory Commission staff and the staff of its contractors, Energy Research, Inc., and Idaho National Laboratory. Furthermore, the report benefited greatly from the contributions of senior risk analysts and other selected agency staff members in specific areas of the project. The authors would especially like to recognize the support from Mahesh Chawla, James Corson, Ron Harrington, Tarek Zaki, and Joseph Staudenmeier. The authors also appreciate the assistance provided by the licensee's staff at the Duane Arnold Energy Center.

ABBREVIATIONS AND ACRONYMS

ac	alternating current
ADAMS	Agencywide Documents Access and Management System
ADS	automatic depressurization system
AIP	alternate injection procedure (EOP)
ANS	American Nuclear Society
AOP	abnormal operating procedure
ASP	accident sequence precursor
ATWS	anticipated transient without scram
BWR	boiling-water reactor
C	Celsius
CD	core damage
CDF	core damage frequency
CDS	condensate system
CFR	<i>Code of Federal Regulations</i>
CRDHS	control rod drive hydraulics system
CST	condensate storage tank
DAEC	Duane Arnold Energy Center
dc	direct current
ECCS	emergency core cooling system
ED	emergency depressurization
EDG	emergency diesel generator
ELAP	extended loss of ac power
EOP	emergency operating procedure
ESF	engineered safety feature
ESFAS	engineered safety features actuation system
F	Fahrenheit
FLEX	diverse and flexible coping strategies
FSG	FLEX support guideline
HCL	heat capacity limit
HCV	hardened containment vent
HCVS	hardened containment vent system
HPCI	high-pressure coolant injection
HPI	high-pressure injection
IORV	inadvertent open relief valve
IPE	individual plant examination
ISG	interim staff guidance
LCO	limiting condition for operation
LOCA	loss-of-coolant accident
LOCHS	loss of condenser heat sink

LODCA	loss of vital dc bus A
LODCB	loss of vital dc bus B
LOIAS	loss of instrument air system
LOMFW	loss of main feedwater
LOOP	loss of offsite power
LOOPGR	loss of offsite power grid related
LOOPPPC	loss of offsite power plant centered
LOOPWR	loss of offsite power weather related
LORWS	loss of river water system
LPCI	low-pressure coolant injection
LPCS	low-pressure core spray
LPI	low-pressure injection
MAAP	modular accident analysis program
MFW	main feedwater
MLOCA	medium loss-of-coolant accident
MSIV	main steam isolation valve
MSL	main steamline
NCV	noncited violation
NEI	Nuclear Energy Institute
NPSH	net positive suction head
NRC	U.S. Nuclear Regulatory Commission
PB	Peach Bottom
PCPL	primary containment pressure limit
PCS	power conversion system
PCT	peak clad temperature
PID	proportional-integral-derivative
PRA	probabilistic risk assessment
RCIC	reactor core isolation cooling
RCS	reactor coolant system
RHR	residual heat removal
RPS	reactor protection system
RPV	reactor pressure vessel
RWCU	reactor water cleanup
SAMP	severe accident management procedure
SBO	station blackout
SC	success criterion/criteria
SDP	significance determination process
SEP	site emergency plan
SFP	spent fuel pool
SLC	standby liquid control
SLOCA	small loss-of-coolant accident

SNL	Sandia National Laboratories
SP	suppression pool
SPAR	standardized plant analysis risk
SRV	safety/relief valve
TAF	top of active fuel
TRANS	transient
UFSAR	updated final safety analysis report
UHS	ultimate heat sink
WW	wetwell

APPENDIX D
DETAILED CHAPTER 4 ANALYSIS RESULTS

DETAILED CHAPTER 4 ANALYSIS RESULTS

D.1 LOOP Scenarios

D.1.1 Case 1: LOOPGR-38-9, AC Loss at t=0, RCIC Loss at 4 hrs., CST Available, Perform Required Venting Only




Figure D - 1 RPV cooldown rate




Figure D - 2 Flow rate of the containment vents




Figure D - 3 Flow rate of the FLEXpump




Figure D - 4 Flow rate of the HPCI/RCIC pumps




Figure D - 5 Flow rate of the recirculating pump seal leakage




Figure D - 6 Flow rate of the SRVs




Figure D - 7 RPV down comer water level




Figure D - 8 Pressure in the RPV




Figure D - 9 Pressure in the wetwell




Figure D - 10 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 11 Water temperature in the wetwell




Figure D - 12 Peak temperature of the fuel cladding as a function of time
D.12 Case 2: LOOPGR-38-9, AC Loss at t=0, RCIC Loss at 4 hrs., CST Available, Perform Anticipatory Venting




Figure D - 13 RPV cooldown rate




Figure D - 14 Flow rate of the containment vents




Figure D - 15 Flow rate of the FLEX pump




Figure D - 16 Flow rate of the HPCI/RCIC pumps




Figure D - 17 Flow rate of the recirculating pump seal leakage




Figure D - 18 Flow rate of the SRVs




Figure D - 19 RPV down comer water level




Figure D - 20 Pressure in theRPV




Figure D - 21 Pressure in the wetwell




Figure D - 22 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 23 Water temperature in the wetwell




Figure D - 24 Peak temperature of the fuel cladding as a function of time
D.13 Case 3: LOOPGR-38-9, AC Loss at t=0, RCIC Loss at 4 hrs., CST Unavailable, Perform Required Venting Only




Figure D - 25 RPV cooldown rate




Figure D - 26 Flow rate of the containment vents




Figure D - 27 Flow rate of the FLEX pump




Figure D - 28 Flow rate of the HPCI/RCIC pumps




Figure D - 29 Flow rate of the recirculating pump seal leakage




Figure D - 30 Flow rate of the SRVs




Figure D - 31 RPV down comer water level




Figure D - 32 Pressure in theRPV




Figure D - 33 Pressure in the wetwell




Figure D - 34 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 35 Water temperature in the wetwell




Figure D - 36 Peak temperature of the fuel cladding as a function of time
D.14 Case 4: LOOPGR-38-9, AC Loss at t=0, RCIC Loss at 4 hrs., CST Unavailable, Perform Anticipatory Venting




Figure D - 37 RPV cooldown rate




Figure D - 38 Flow rate of the containment vents




Figure D - 39 Flow rate of the FLEX pump




Figure D - 40 Flow rate of the HPCI/RCIC pumps




Figure D - 41 Flow rate of the recirculating pump seal leakage




Figure D - 42 Flow rate of the SRVs




Figure D - 43 RPV down comer water level




Figure D - 44 Pressure in theRPV




Figure D - 45 Pressure in the wetwell




Figure D - 46 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 47 Water temperature in the wetwell




Figure D - 48 Peak temperature of the fuel cladding as a function of time
D.15 Case 5: LOOPGR-38-9, AC Loss at t=0, RCIC Loss at 8 hrs., CST Available, Perform Required Venting Only




Figure D - 49 RPV cooldown rate




Figure D - 50 Flow rate of the containment vents




Figure D - 51 Flow rate of the FLEXpump




Figure D – 52 Flow rate of the HPCI/RCIC pumps




Figure D – 53 Flow rate of the recirculating pump seal leakage




Figure D - 54 Flow rate of the SRVs




Figure D - 55 RPV down comer water level




Figure D - 56 Pressure in theRPV




Figure D - 57 Pressure in the wetwell




Figure D - 58 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 59 Water temperature in the wetwell




Figure D - 60 Peak temperature of the fuel cladding as a function of time
D.16 Case 6: LOOPGR-38-9, AC Loss at t=0, RCIC Loss at 8 hrs., CST Available, Perform Anticipatory Venting




Figure D - 61 RPV cooldown rate




Figure D - 62 Flow rate of the containment vents




Figure D - 63 Flow rate of the FLEXpump




Figure D – 64 Flow rate of the HPCI/RCIC pumps




Figure D - 65 Flow rate of the recirculating pump seal leakage




Figure D - 66 Flow rate of the SRVs




Figure D - 67 RPV down comer water level




Figure D - 68 Pressure in theRPV




Figure D - 69 Pressure in the wetwell




Figure D - 70 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 71 Water temperature in the wetwell




Figure D - 72 Peak temperature of the fuel cladding as a function of time
D.17 Case 7: LOOPGR-38-9, AC Loss at t=0, RCIC Loss at 8 hrs., CST Unavailable, Perform Required Venting Only




Figure D - 73 RPV cooldown rate




Figure D - 74 Flow rate of the containment vents




Figure D - 75 Flow rate of the FLEXpump




Figure D - 76 Flow rate of the HPCI/RCIC pumps




Figure D - 77 Flow rate of the recirculating pump seal leakage




Figure D - 78 Flow rate of the SRVs




Figure D - 79 RPV down comer water level




Figure D - 80 Pressure in the RPV




Figure D - 81 Pressure in the wetwell




Figure D - 82 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 83 Water temperature in the wetwell




Figure D - 84 Peak temperature of the fuel cladding as a function of time

D.1.8 Case 8: LOOPGR-38-9, AC Loss at t=0, RCIC Loss at 8 hrs., CST Unavailable, Perform Anticipatory Venting




Figure D - 85 RPV cooldown rate




Figure D - 86 Flow rate of the containment vents




Figure D - 87 Flow rate of the FLEXpump




Figure D - 88 Flow rate of the HPCI/RCIC pumps




Figure D - 89 Flow rate of the recirculating pump seal leakage




Figure D - 90 Flow rate of the SRVs




Figure D - 91 RPV down comer water level




Figure D - 92 Pressure in the RPV




Figure D - 93 Pressure in the wetwell




Figure D - 94 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 95 Water temperature in the wetwell




Figure D - 96 Peak temperature of the fuel cladding as a function of time
D.19 Case 9: LOOPGR-38-9, AC Loss at t=0, RCIC Available Indefinitely, CST Available, Perform Required Venting Only




Figure D - 97 RPV cooldown rate




Figure D - 98 Flow rate of the containment vents




Figure D - 99 Flow rate of the FLEXpump




Figure D - 100 Flow rate of the HPCI/RCIC pumps




Figure D - 101 Flow rate of the recirculating pump seal leakage




Figure D - 102 Flow rate of the SRVs




Figure D - 103 RPV down comer water level




Figure D - 104 Pressure in theRPV




Figure D - 105 Pressure in the wetwell




Figure D – 106 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 107 Water temperature in the wetwell




Figure D – 108 Peak temperature of the fuel cladding as a function of time
D.1.10 Case 10: LOOPGR-38-9, AC Loss at t=0, RCIC Available Indefinitely, CST Available, Perform Anticipatory Venting




Figure D - 109 RPV cooldown rate




Figure D - 110 Flow rate of the containment vents




Figure D - 111 Flow rate of the FLEX pump




Figure D - 112 Flow rate of the HPCI/RCIC pumps




Figure D - 113 Flow rate of the recirculating pump seal leakage




Figure D - 114 Flow rate of the SRVs




Figure D - 115 RPV down comer water level




Figure D - 116 Pressure in theRPV




Figure D - 117 Pressure in the wetwell




Figure D - 118 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 119 Water temperature in the wetwell




Figure D - 120 Peak temperature of the fuel cladding as a function of time

D.1.11 Case 11: LOOPGR-38-9, AC Loss at t=0, RCIC Available Indefinitely, CST Unavailable, Perform Required Venting Only




Figure D - 121 RPV cooldown rate




Figure D - 122 Flow rate of the containment vents




Figure D - 123 Flow rate of the FLEX pump




Figure D - 124 Flow rate of the HPCI/RCIC pumps




Figure D - 125 Flow rate of the recirculating pump seal leakage




Figure D - 126 Flow rate of the SRVs




Figure D - 127 RPV down comer water level




Figure D – 128 Pressure in theRPV




Figure D - 129 Pressure in the wetwell




Figure D - 130 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 131 Water temperature in the wetwell




Figure D – 132 Peak temperature of the fuel cladding as a function of time
D.1.12 Case 12: LOOPGR-38-9, AC Loss at t=0, RCIC Available Indefinitely, CST Unavailable, Perform Anticipatory Venting




Figure D - 133 RPV cooldown rate




Figure D - 134 Flow rate of the containment vents




Figure D - 135 Flow rate of the FLEX pump




Figure D - 136 Flow rate of the HPCI/RCIC pumps




Figure D - 137 Flow rate of the recirculating pump seal leakage




Figure D - 138 Flow rate of the SRVs




Figure D - 139 RPV down comer water level




Figure D - 140 Pressure in theRPV




Figure D - 141 Pressure in the wetwell




Figure D - 142 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 143 Water temperature in the wetwell




Figure D – 144 Peak temperature of the fuel cladding as a function of time
D.1.13 Case 13: LOOPGR-38-9, AC Loss at 2 hrs., RCIC Loss at 4 hrs., CST Available, Perform Required Venting Only




Figure D - 145 RPV cooldown rate




Figure D - 146 Flow rate of the containment vents




Figure D - 147 Flow rate of the FLEX pump




Figure D - 148 Flow rate of the HPCI/RCIC pumps




Figure D - 149 Flow rate of the recirculating pump seal leakage




Figure D - 150 Flow rate of the SRVs




Figure D - 151 RPV down comer water level




Figure D - 152 Pressure in theRPV




Figure D - 153 Pressure in the wetwell




Figure D - 154 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 155 Water temperature in the wetwell




Figure D – 156 Peak temperature of the fuel cladding as a function of time
D.1.14 Case 14: LOOPGR-38-9, AC Loss at 2 hrs., RCIC Loss at 8 hrs., CST Available, Perform Required Venting Only




Figure D - 157 RPV cooldown rate




Figure D - 158 Flow rate of the containment vents




Figure D - 159 Flow rate of the FLEX pump




Figure D - 160 Flow rate of the HPCI/RCIC pumps




Figure D - 161 Flow rate of the recirculating pump seal leakage




Figure D - 162 **Flow rate of the SRVs**




Figure D - 163 **RPV down comer water level**




Figure D - 164 Pressure in theRPV




Figure D - 165 Pressure in the wetwell




Figure D - 166 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 167 Water temperature in the wetwell




Figure D – 168 Peak temperature of the fuel cladding as a function of time
D.1.15 Case 15: LOOPGR-38-9, AC Loss at 2 hrs., RCIC Available Indefinitely, CST Available, Anticipatory Venting




Figure D - 169 RPV cooldown rate




Figure D - 170 Flow rate of the containment vents




Figure D - 171 Flow rate of the FLEX pump




Figure D - 172 Flow rate of the HPCI/RCIC pumps




Figure D - 173 Flow rate of the recirculating pump seal leakage




Figure D - 174 Flow rate of the SRVs




Figure D - 175 RPV down comer water level




Figure D - 176 Pressure in theRPV




Figure D - 177 Pressure in the wetwell




Figure D - 178 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 179 Water temperature in the wetwell




Figure D – 180 Peak temperature of the fuel cladding as a function of time
D.1.16 Case 16: LOOPGR-38-9, AC Loss at 2 hrs., RCIC Available Indefinitely, CST Unavailable, Anticipatory Venting




Figure D - 181 RPV cooldown rate




Figure D - 182 Flow rate of the containment vents




Figure D - 183 Flow rate of the FLEX pump




Figure D - 184 Flow rate of the HPCI/RCIC pumps




Figure D - 185 Flow rate of the recirculating pump seal leakage




Figure D - 186 Flow rate of the SRVs




Figure D - 187 RPV down comer water level




Figure D - 188 Pressure in theRPV




Figure D - 189 Pressure in the wetwell




Figure D - 190 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 191 Water temperature in the wetwell




Figure D – 192 Peak temperature of the fuel cladding as a function of time

D.2 LOMFW Scenarios

D.2.1 Case 17: LOMFW-25, RCIC Loss at 4 hrs., RPV Pressure Follows HCL Curve, FLEX injection at 5 hrs.




Figure D - 193 RPV cooldown rate




Figure D - 194 Flow rate of the containment vents




Figure D - 195 Flow rate of the FLEX pump




Figure D - 196 Flow rate of the HPCI/RCIC pumps




Figure D - 197 Flow rate of the recirculating pump seal leakage




Figure D - 198 Flow rate of the SRVs




Figure D - 199 RPV down comer water level




Figure D - 200 **Pressure in theRPV**




Figure D - 201 **Pressure in the wetwell**




Figure D – 202 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 203 Water temperature in the wetwell




Figure D – 204 Peak temperature of the fuel cladding as a function of time
D.2.2 Case 18: LOMFW-25, RCIC Loss at 4 hrs., RPV Pressure Follows HCL Curve, FLEX injection at 6 hrs.




Figure D - 205 RPV cooldown rate




Figure D - 206 Flow rate of the containment vents




Figure D - 207 Flow rate of the FLEX pump




Figure D - 208 Flow rate of the HPCI/RCIC pumps




Figure D - 209 Flow rate of the recirculating pump seal leakage




Figure D - 210 **Flow rate of the SRVs**




Figure D - 211 **RPV down comer water level**




Figure D - 212 Pressure in theRPV




Figure D - 213 Pressure in the wetwell




Figure D - 214 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 215 Water temperature in the wetwell




Figure D – 216 Peak temperature of the fuel cladding as a function of time
D.2.3 Case 19: LOMFW-25, RCIC Loss at 4 hrs., Emergency
Depressurization at HCL Curve, FLEX injection at 5 hrs.




Figure D - 217 RPV cooldown rate




Figure D - 218 Flow rate of the containment vents




Figure D - 219 Flow rate of the FLEX pump




Figure D - 220 Flow rate of the HPCI/RCIC pumps




Figure D - 221 Flow rate of the recirculating pump seal leakage




Figure D - 222 Flow rate of the SRVs




Figure D - 223 RPV down comer water level




Figure D - 224 Pressure in theRPV




Figure D - 225 Pressure in the wetwell




Figure D – 226 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 227 Water temperature in the wetwell




Figure D – 228 Peak temperature of the fuel cladding as a function of time
D.2.4 Case 20: LOMFW-25, RCIC Loss at 4 hrs., Emergency Depressurization at HCL Curve, FLEX injection at 5 hrs. at -25% flow rate




Figure D – 229 RPV cooldown rate




Figure D - 230 Flow rate of the containment vents




Figure D - 231 Flow rate of the FLEX pump




Figure D - 232 Flow rate of the HPCI/RCIC pumps




Figure D - 233 Flow rate of the recirculating pump seal leakage




Figure D - 234 Flow rate of the SRVs




Figure D - 235 RPV down comer water level




Figure D - 236 Pressure in theRPV




Figure D - 237 Pressure in the wetwell




Figure D – 238 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D – 239 Water temperature in the wetwell




Figure D – 240 Peak temperature of the fuel cladding as a function of time
**D.2.5 Case 21: LOMFW-25, RCIC Loss at 4 hrs., Emergency
 Depressurization at HCL Curve, FLEX injection at 6 hrs.**




Figure D - 241 RPV cooldown rate




Figure D - 242 Flow rate of the containment vents




Figure D - 243 Flow rate of the FLEX pump




Figure D - 244 Flow rate of the HPCI/RCIC pumps




Figure D - 245 Flow rate of the recirculating pump seal leakage




Figure D - 246 Flow rate of the SRVs




Figure D - 247 RPV down comer water level




Figure D - 248 Pressure in theRPV




Figure D - 249 Pressure in the wetwell




Figure D - 250 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 251 Water temperature in the wetwell




Figure D – 252 Peak temperature of the fuel cladding as a function of time
D.2.6 Case 22: LOMFW-25, RCIC Loss at 8 hrs., RPV Pressure Follows HCL Curve, FLEX injection at 9 hrs.




Figure D - 253 RPV cooldown rate




Figure D - 254 Flow rate of the containment vents




Figure D - 255 Flow rate of the FLEX pump




Figure D - 256 Flow rate of the HPCI/RCIC pumps




Figure D - 257 Flow rate of the recirculating pump seal leakage




Figure D - 258 Flow rate of the SRVs




Figure D - 259 RPV down comer water level




Figure D - 260 Pressure in theRPV




Figure D - 261 Pressure in the wetwell




Figure D – 262 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 263 Water temperature in the wetwell




Figure D – 264 Peak temperature of the fuel cladding as a function of time
D.2.7 Case 23: LOMFW-25, RCIC Loss at 8 hrs., Emergency
 Depressurization at HCL Curve, FLEX injection at 9 hrs.




Figure D - 265 RPV cooldown rate




Figure D - 266 Flow rate of the containment vents




Figure D - 267 Flow rate of the FLEX pump




Figure D - 268 Flow rate of the HPCI/RCIC pumps




Figure D - 269 Flow rate of the recirculating pump seal leakage




Figure D - 270 Flow rate of the SRVs




Figure D - 271 RPV down comer water level




Figure D - 272 **Pressure in theRPV**




Figure D - 273 **Pressure in the wetwell**




Figure D – 274 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 275 Water temperature in the wetwell




Figure D – 276 Peak temperature of the fuel cladding as a function of time
D.2.8 Case 24: LOMFW-25, RCIC Loss at 8 hrs., Emergency
Depressurization at HCL Curve, FLEX injection at 10 hrs.




Figure D – 277 RPV cooldown rate




Figure D - 278 Flow rate of the containment vents




Figure D - 279 Flow rate of the FLEX pump




Figure D - 280 Flow rate of the HPCI/RCIC pumps




Figure D - 281 Flow rate of the recirculating pump seal leakage




Figure D - 282 Flow rate of the SRVs




Figure D - 283 RPV down comer water level




Figure D - 284 Pressure in theRPV




Figure D - 285 Pressure in the wetwell




Figure D – 286 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 287 Water temperature in the wetwell




Figure D – 288 Peak temperature of the fuel cladding as a function of time
D.2.9 Case 25: LOMFW-25, RCIC Loss at 8 hrs., Emergency Depressurization at HCL
Curve, FLEX injection at 10 hrs. at -25% flow rate




Figure D - 289 RPV cooldown rate




Figure D - 290 Flow rate of the containment vents




Figure D - 291 Flow rate of the FLEX pump




Figure D - 292 Flow rate of the HPCI/RCIC pumps




Figure D - 293 Flow rate of the recirculating pump seal leakage




Figure D - 294 Flow rate of the SRVs




Figure D - 295 RPV down comer water level




Figure D - 296 Pressure in theRPV




Figure D - 297 Pressure in the wetwell




Figure D – 298 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 299 Water temperature in the wetwell




Figure D – 300 Peak temperature of the fuel cladding as a function of time

D.3 Sensitivity Analyses

D.3.1 Case 7a: Sensitivity to LOOPGR-38-9 Case 7 with HPCI Available Instead of RCIC




Figure D - 301 RPV cooldown rate




Figure D - 302 Flow rate of the containment vents




Figure D - 303 Flow rate of the FLEX pump




Figure D - 304 Flow rate of the HPCI/RCIC pumps




Figure D - 305 Flow rate of the recirculating pump seal leakage




Figure D - 306 Flow rate of the SRVs




Figure D - 307 RPV down comer water level




Figure D - 308 Pressure in theRPV




Figure D - 309 Pressure in the wetwell




Figure D – 310 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 311 Water temperature in the wetwell




Figure D – 312 Peak temperature of the fuel cladding as a function of time
D.3.2 Case 8a: Sensitivity to LOOPGR-38-9 Case 8 with HPCI Available Instead of RCIC




Figure D - 313 RPV cooldown rate




Figure D - 314 Flow rate of the containment vents




Figure D - 315 Flow rate of the FLEX pump




Figure D - 316 Flow rate of the HPCI/RCIC pumps




Figure D - 317 Flow rate of the recirculating pump seal leakage




Figure D - 318 Flow rate of the SRVs




Figure D - 319 RPV down comer water level




Figure D - 320 Pressure in theRPV




Figure D - 321 Pressure in the wetwell




Figure D - 322 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 323 Water temperature in the wetwell




Figure D – 324 Peak temperature of the fuel cladding as a function of time
D.3.3 Case 8b: Sensitivity to LOOPGR-38-9 Case 8 with FLEX Delivered Flow Reduced by 50%




Figure D - 325 RPV cooldown rate




Figure D - 326 Flow rate of the containment vents




Figure D - 327 Flow rate of the FLEX pump




Figure D - 328 Flow rate of the HPCI/RCIC pumps




Figure D - 329 Flow rate of the recirculating pump seal leakage




Figure D - 330 Flow rate of the SRVs




Figure D - 331 RPV down comer water level




Figure D - 332 Pressure in theRPV




Figure D - 333 Pressure in the wetwell




Figure D – 334 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 335 Water temperature in the wetwell




Figure D – 336 Peak temperature of the fuel cladding as a function of time
D.3.4 Case 8c: Sensitivity to LOOPGR-38-9 Case 8 with Increased RCP Seal Leakage (13m³/hr)




Figure D - 337 RPV cooldown rate




Figure D - 338 Flow rate of the containment vents




Figure D - 339 Flow rate of the FLEX pump




Figure D - 340 Flow rate of the HPCI/RCIC pumps




Figure D - 341 Flow rate of the recirculating pump seal leakage




Figure D - 342 Flow rate of the SRVs




Figure D - 343 RPV down comer water level




Figure D - 344 Pressure in theRPV




Figure D - 345 Pressure in the wetwell




Figure D – 346 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 347 Water temperature in the wetwell




Figure D – 348 Peak temperature of the fuel cladding as a function of time
D.3.5 Case 8d: Sensitivity to LOOPGR-38-9 Case 8 with No RCP Seal Leakage




Figure D - 349 RPV cooldown rate




Figure D - 350 Flow rate of the containment vents




Figure D - 351 Flow rate of the FLEX pump




Figure D - 352 Flow rate of the HPCI/RCIC pumps




Figure D - 353 Flow rate of the recirculating pump seal leakage




Figure D - 354 Flow rate of the SRVs




Figure D - 355 RPV down comer water level




Figure D - 356 Pressure in theRPV




Figure D - 357 Pressure in the wetwell




Figure D – 358 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 359 Water temperature in the wetwell




Figure D – 360 Peak temperature of the fuel cladding as a function of time
D.3.6 Case 8e: Sensitivity to LOOPGR-38-9 Case 8 with Water Level Run Up to the Steamlines Prior to FLEX Swap-Over




Figure D - 361 RPV cooldown rate




Figure D - 362 Flow rate of the containment vents




Figure D - 363 Flow rate of the FLEX pump




Figure D - 364 Flow rate of the HPCI/RCIC pumps




Figure D - 365 Flow rate of the recirculating pump seal leakage




Figure D - 366 **Flow rate of the SRVs**




Figure D - 367 **RPV down comer water level**




Figure D - 368 Pressure in theRPV




Figure D - 369 Pressure in the wetwell




Figure D – 370 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 371 Water temperature in the wetwell




Figure D – 372 Peak temperature of the fuel cladding as a function of time
D.3.7 Case 8f: Sensitivity to LOOPGR-38-9 Case 8 with Decay Heat Following Built-in ANS Standard




Figure D - 373 RPV cooldown rate




Figure D - 374 Flow rate of the containment vents




Figure D - 375 Flow rate of the FLEX pump




Figure D - 376 Flow rate of the HPCI/RCIC pumps




Figure D - 377 Flow rate of the recirculating pump seal leakage




Figure D - 378 Flow rate of the SRVs




Figure D - 379 RPV down comer water level




Figure D - 380 Pressure in theRPV




Figure D - 381 Pressure in the wetwell




Figure D – 382 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 383 Water temperature in the wetwell




Figure D – 384 Peak temperature of the fuel cladding as a function of time
D.3.8 Case 9a: Sensitivity to LOOPGR-38-9 Case 9 with HPCI Available Instead of RCIC




Figure D - 385 RPV cooldown rate




Figure D - 386 Flow rate of the containment vents




Figure D - 387 Flow rate of the FLEX pump




Figure D - 388 Flow rate of the HPCI/RCIC pumps




Figure D - 389 Flow rate of the recirculating pump seal leakage




Figure D - 390 Flow rate of the SRVs




Figure D - 391 RPV down comer water level




Figure D - 392 Pressure in theRPV




Figure D - 393 Pressure in the wetwell




Figure D – 394 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 395 Water temperature in the wetwell




Figure D – 396 Peak temperature of the fuel cladding as a function of time
D.3.9 Case 17a: Sensitivity to LOMFW-25 Case 17 with RPV Cooldown Beginning at 30 min. at Maximum Allowable Rate




Figure D - 397 RPV cooldown rate




Figure D - 398 Flow rate of the containment vents




Figure D - 399 Flow rate of the FLEX pump




Figure D - 400 Flow rate of the HPCI/RCIC pumps




Figure D - 401 Flow rate of the recirculating pump seal leakage




Figure D - 402 Flow rate of the SRVs




Figure D - 403 RPV down comer water level




Figure D - 404 Pressure in theRPV




Figure D - 405 Pressure in the wetwell




Figure D – 406 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 407 Water temperature in the wetwell




Figure D – 408 Peak temperature of the fuel cladding as a function of time
D.3.10 Case 19a: Sensitivity to LOMFW-25 Case 19 with HPCI Available Instead of RCIC




Figure D - 409 RPV cooldown rate




Figure D - 410 Flow rate of the containment vents




Figure D - 411 Flow rate of the FLEX pump




Figure D - 412 Flow rate of the HPCI/RCIC pumps




Figure D - 413 Flow rate of the recirculating pump seal leakage




Figure D - 414 Flow rate of the SRVs




Figure D - 415 RPV down comer water level




Figure D - 416 Pressure in theRPV




Figure D - 417 Pressure in the wetwell




Figure D - 418 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 419 Water temperature in the wetwell




Figure D - 420 Peak temperature of the fuel cladding as a function of time
D.3.11 Case 19b: Sensitivity to LOMFW-25 Case 19 with RCIC Lost at 5 hrs.




Figure D - 421 RPV cooldown rate




Figure D - 422 Flow rate of the containment vents




Figure D - 423 Flow rate of the FLEX pump




Figure D - 424 Flow rate of the HPCI/RCIC pumps




Figure D - 425 Flow rate of the recirculating pump seal leakage




Figure D - 426 Flow rate of the SRVs




Figure D - 427 RPV down comer water level




Figure D - 428 Pressure in theRPV




Figure D - 429 Pressure in the wetwell




Figure D – 430 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 431 Water temperature in the wetwell




Figure D – 432 Peak temperature of the fuel cladding as a function of time
D.3.12 Case 19c: Sensitivity to LOMFW-25 Case 19 with MSIV Closure at the start of the transient




Figure D - 433 RPV cooldown rate




Figure D - 434 Flow rate of the containment vents




Figure D - 435 Flow rate of the FLEX pump




Figure D - 436 Flow rate of the HPCI/RCIC pumps




Figure D - 437 Flow rate of the recirculating pump seal leakage




Figure D - 438 Flow rate of the SRVs




Figure D - 439 RPV down comer water level




Figure D - 440 Pressure in theRPV




Figure D - 441 Pressure in the wetwell




Figure D – 442 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 443 Water temperature in the wetwell




Figure D – 444 Peak temperature of the fuel cladding as a function of time
D.3.13 Case 21a: Sensitivity to LOMFW-25 Case 21 with RCIC lost at 6 hrs.




Figure D - 445 RPV cooldown rate




Figure D - 446 Flow rate of the containment vents




Figure D - 447 Flow rate of the FLEX pump




Figure D - 448 Flow rate of the HPCI/RCIC pumps




Figure D - 449 Flow rate of the recirculating pump seal leakage




Figure D - 450 Flow rate of the SRVs




Figure D - 451 RPV down comer water level




Figure D - 452 Pressure in theRPV




Figure D - 453 Pressure in the wetwell




Figure D – 454 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 455 Water temperature in the wetwell




Figure D – 456 Peak temperature of the fuel cladding as a function of time
D.3.14 Case 22a: Sensitivity to LOMFW-25 Case 22 with HPCI Available Instead of RCIC




Figure D - 457 RPV cooldown rate




Figure D - 458 Flow rate of the containment vents




Figure D - 459 Flow rate of the FLEX pump




Figure D - 460 Flow rate of the HPCI/RCIC pumps




Figure D - 461 Flow rate of the recirculating pump seal leakage




Figure D - 462 Flow rate of the SRVs




Figure D - 463 RPV down comer water level




Figure D - 464 Pressure in theRPV




Figure D - 465 Pressure in the wetwell




Figure D – 466 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 467 Water temperature in the wetwell




Figure D – 468 Peak temperature of the fuel cladding as a function of time
D.3.15 Case 22b: Sensitivity to LOMFW-25 Case 22 with FLEX Delivered Flow Reduced by 50%




Figure D - 469 RPV cooldown rate




Figure D - 470 Flow rate of the containment vents




Figure D - 471 Flow rate of the FLEX pump




Figure D - 472 Flow rate of the HPCI/RCIC pumps




Figure D - 473 Flow rate of the recirculating pump seal leakage




Figure D - 474 Flow rate of the SRVs




Figure D - 475 RPV down comer water level




Figure D - 476 Pressure in theRPV




Figure D - 477 Pressure in the wetwell




Figure D – 478 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 479 Water temperature in the wetwell




Figure D – 480 Peak temperature of the fuel cladding as a function of time
D.3.16 Case 22c: Sensitivity to LOMFW-25 Case 22 with RCIC Delivered Flow Reduced by 10%




Figure D - 481 RPV cooldown rate




Figure D - 482 Flow rate of the containment vents




Figure D - 483 Flow rate of the FLEX pump




Figure D - 484 Flow rate of the HPCI/RCIC pumps




Figure D - 485 Flow rate of the recirculating pump seal leakage




Figure D - 486 Flow rate of the SRVs




Figure D - 487 RPV down comer water level




Figure D - 488 Pressure in theRPV




Figure D - 489 Pressure in the wetwell




Figure D – 490 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 491 Water temperature in the wetwell




Figure D – 492 Peak temperature of the fuel cladding as a function of time
D.3.17 Case 22d: Sensitivity to LOMFW-25 Case 22 with FLEX Injection Failure at 24 hrs.




Figure D - 493 RPV cooldown rate




Figure D - 494 Flow rate of the containment vents




Figure D - 495 Flow rate of the FLEX pump




Figure D - 496 Flow rate of the HPCI/RCIC pumps




Figure D – 497 Flow rate of the recirculating pump seal leakage




Figure D - 498 Flow rate of the SRVs




Figure D - 499 RPV down comer water level




Figure D - 500 Pressure in theRPV




Figure D - 501 Pressure in the wetwell




Figure D – 502 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 503 Water temperature in the wetwell




Figure D – 504 Peak temperature of the fuel cladding as a function of time
D.3.18 Case 22e: Sensitivity to LOMFW-25 Case 22 with DecayHeat Following Built-in ANS Standard




Figure D – 505 RPV cooldown rate




Figure D - 506 Flow rate of the containment vents




Figure D - 507 Flow rate of the FLEX pump




Figure D - 508 Flow rate of the HPCI/RCIC pumps




Figure D - 509 Flow rate of the recirculating pump seal leakage




Figure D - 510 **Flow rate of the SRVs**




Figure D - 511 **RPV down comer water level**




Figure D - 512 Pressure in theRPV




Figure D - 513 Pressure in the wetwell




Figure D - 514 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 515 Water temperature in the wetwell




Figure D – 516 Peak temperature of the fuel cladding as a function of time
D.3.19 Case 22f: Sensitivity to LOMFW-25 Case 22 with Increased RCIC Operating Level Band and Loss of RCIC on Steamline Flooding




Figure D - 517 RPV cooldown rate




Figure D - 518 Flow rate of the containment vents




Figure D - 519 Flow rate of the FLEX pump




Figure D - 520 Flow rate of the HPCI/RCIC pumps




Figure D - 521 Flow rate of the recirculating pump seal leakage




Figure D - 522 Flow rate of the SRVs




Figure D – 523 RPV down comer water level




Figure D - 524 Pressure in theRPV




Figure D - 525 Pressure in the wetwell




Figure D – 526 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 527 Water temperature in the wetwell




Figure D – 528 Peak temperature of the fuel cladding as a function of time
D.3.20 Case 22g: Sensitivity to LOMFW-25 Case 22 with CST Unavailable




Figure D - 529 RPV cooldown rate




Figure D - 530 Flow rate of the containment vents




Figure D - 531 Flow rate of the FLEX pump




Figure D - 532 Flow rate of the HPCI/RCIC pumps




Figure D - 533 Flow rate of the recirculating pump seal leakage




Figure D - 534 Flow rate of the SRVs




Figure D - 535 RPV down comer water level




Figure D - 536 Pressure in theRPV




Figure D - 537 Pressure in the wetwell




Figure D – 538 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 539 Water temperature in the wetwell




Figure D – 540 Peak temperature of the fuel cladding as a function of time
D.3.21 Case 22h: Sensitivity to LOMFW-25 Case 22 with MSIV Closure at the Start of the Transient




Figure D - 541 RPV cooldown rate




Figure D - 542 Flow rate of the containment vents




Figure D - 543 Flow rate of the FLEX pump




Figure D - 544 Flow rate of the HPCI/RCIC pumps




Figure D - 545 Flow rate of the recirculating pump seal leakage




Figure D - 546 Flow rate of the SRVs




Figure D - 547 RPV down comer water level




Figure D - 548 Pressure in theRPV




Figure D - 549 Pressure in the wetwell




Figure D – 550 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 551 Water temperature in the wetwell




Figure D – 552 Peak temperature of the fuel cladding as a function of time
D.3.22 Case 23a: Sensitivity to LOMFW-25 Case 23 with SRV Failing Open at 270 Cycles




Figure D - 553 RPV cooldown rate




Figure D - 554 Flow rate of the containment vents




Figure D - 555 Flow rate of the FLEX pump




Figure D - 556 Flow rate of the HPCI/RCIC pumps




Figure D - 557 Flow rate of the recirculating pump seal leakage




Figure D - 558 Flow rate of the SRVs




Figure D - 559 RPV down comer water level




Figure D - 560 Pressure in theRPV




Figure D - 561 Pressure in the wetwell




Figure D – 562 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure D - 563 Water temperature in the wetwell




Figure D – 564 **Peak temperature of the fuel cladding as a function of time**

APPENDIX E
DETAILED CHAPTER 5 ANALYSIS RESULTS

DETAILED CHAPTER 5 ANALYSIS RESULTS

E.1 LOOP Scenarios

E.1.1 Case 1: LOOPGR-38-9, Perform Anticipatory Venting, Containment Venting via the 2-in. Drywell Bypass, RCIC Fully Functional




Figure E – 1 Flow rate of the containment vents




Figure E - 2 Flow rate of the HPCI/RCIC pumps




Figure E - 3 Flow rate of the recirculating pump seal leakage




Figure E - 4 Water level in the reactor building basement




Figure E - 5 RPV down comer water level




Figure E - 6 Pressure in theRPV




Figure E - 7 Pressure in the wetwell




Figure E - 8 Vapor temperature in the reactor building basement




Figure E - 9 Water temperature in the wetwell




Figure E - 10 Peak temperature of the fuel cladding as a function of time

E.1.2 Case 2: LOOPGR-38-9, Perform Anticipatory Venting, Containment Venting via the 2-in. Drywell Bypass, RCIC 50% Degraded




Figure E - 11 Flow rate of the containment vents




Figure E - 12 Flow rate of the HPCI/RCIC pumps




Figure E - 13 Flow rate of the recirculating pump seal leakage




Figure E - 14 Water level in the reactor building basement




Figure E - 15 RPV down comer water level




Figure E - 16 Pressure in theRPV




Figure E - 17 Pressure in the wetwell




Figure E - 18 Vapor temperature in the reactor building basement




Figure E - 19 Water temperature in the wetwell




Figure E - 20 Peak temperature of the fuel cladding as a function of time

E.1.3 Case 3: LOOPGR-38-9, Perform Anticipatory Venting, Containment Venting via the 18-in. Drywell Main Vent, RCIC Fully Functional




Figure E - 21 Flow rate of the containment vents




Figure E - 22 Flow rate of the HPCI/RCIC pumps




Figure E - 23 Flow rate of the recirculating pump seal leakage




Figure E - 24 Water level in the reactor building basement




Figure E - 25 RPV down comer water level




Figure E - 26 Pressure in theRPV




Figure E - 27 Pressure in the wetwell




Figure E - 28 Vapor temperature in the reactor building basement




Figure E - 29 Water temperature in the wetwell




Figure E - 30 Peak temperature of the fuel cladding as a function of time

E.1.4 Case 4: LOOPGR-38-9, Perform Anticipatory Venting, Containment Venting via the 18-in. Drywell Main Vent, RCIC 50%Degraded




Figure E - 31 Flow rate of the containment vents




Figure E - 32 Flow rate of the HPCI/RCIC pumps




Figure E - 33 Flow rate of the recirculating pump seal leakage




Figure E - 34 Water level in the reactor building basement




Figure E - 35 RPV down comer water level




Figure E - 36 Pressure in theRPV




Figure E - 37 Pressure in the wetwell




Figure E - 38 Vapor temperature in the reactor building basement




Figure E - 39 Water temperature in the wetwell




Figure E - 40 Peak temperature of the fuel cladding as a function of time

E.1.5 Case 5: LOOPGR-38-9, Perform Anticipatory Venting, Containment Venting via the HCV, ECCS Fully Functional




Figure E - 41 Flow rate of the containment vents




Figure E - 42 Flow rate of the HPCI/RCIC pumps




Figure E - 43 Flow rate of the recirculating pump seal leakage




Figure E - 44 Water level in the reactor building basement




Figure E - 45 RPV down comer water level




Figure E - 46 Pressure in theRPV




Figure E - 47 Pressure in the wetwell




Figure E - 48 Vapor temperature in the reactor building basement




Figure E - 49 Water temperature in the wetwell




Figure E - 50 Peak temperature of the fuel cladding as a function of time

E.1.6 Case 6: LOOPGR-38-9, Perform Anticipatory Venting, Containment Venting via the HCV, ECCS 50% Degraded




Figure E - 51 Flow rate of the containment vents




Figure E - 52 Flow rate of the HPCI/RCIC pumps




Figure E - 53 Flow rate of the recirculating pump seal leakage




Figure E - 54 Water level in the reactor building basement




Figure E - 55 RPV down comer water level




Figure E - 56 Pressure in theRPV




Figure E - 57 Pressure in the wetwell




Figure E - 58 Vaportemperature in the reactor building basement




Figure E - 59 Water temperature in the wetwell




Figure E - 60 Peak temperature of the fuel cladding as a function of time

E.1.7 Case 7: LOOPGR-38-9, Perform Anticipatory Venting, Containment Venting via the HCV, ECCS Non-functional




Figure E - 61 Flow rate of the containment vents




Figure E - 62 Flow rate of the HPCI/RCIC pumps




Figure E - 63 Flow rate of the recirculating pump seal leakage




Figure E - 64 Water level in the reactor building basement




Figure E - 65 RPV down comer water level




Figure E - 66 Pressure in theRPV




Figure E - 67 Pressure in the wetwell




Figure E - 68 Vaportemperature in the reactor building basement




Figure E - 69 Water temperature in the wetwell




Figure E - 70 Peak temperature of the fuel cladding as a function of time

E.1.8 Case 8: LOOPGR-38-9, Containment Failure at 53 psig, Containment Venting via the 2-in. Drywell Bypass, RCIC Fully Functional




Figure E - 71 Flow rate of the containment vents




Figure E - 72 Flow rate of the HPCI/RCIC pumps




Figure E - 73 Flow rate of the recirculating pump seal leakage




Figure E - 74 Water level in the reactor building basement




Figure E - 75 RPV down comer water level




Figure E - 76 Pressure in theRPV




Figure E - 77 Pressure in the wetwell




Figure E - 78 Vaportemperature in the reactor building basement




Figure E - 79 Water temperature in the wetwell




Figure E - 80 Peak temperature of the fuel cladding as a function of time

E.1.9 Case 9: LOOPGR-38-9, Containment Failure at 53 psig, Containment Venting via the 2-in. Drywell Bypass, RCIC 50% Degraded




Figure E - 81 Flow rate of the containment vents




Figure E - 82 Flow rate of the HPCI/RCIC pumps




Figure E - 83 Flow rate of the recirculating pump seal leakage




Figure E - 84 Water level in the reactor building basement




Figure E - 85 RPV down comer water level




Figure E - 86 Pressure in theRPV




Figure E - 87 Pressure in the wetwell




Figure E - 88 Vapor temperature in the reactor building basement




Figure E - 89 Water temperature in the wetwell




Figure E - 90 Peak temperature of the fuel cladding as a function of time

E.1.10 Case 10: LOOPGR-38-9, Containment Failure at 53 psig, Containment Venting via the 18-in. Drywell Main Vent, RCIC Fully Functional




Figure E - 91 Flow rate of the containment vents




Figure E - 92 Flow rate of the HPCI/RCIC pumps




Figure E - 93 Flow rate of the recirculating pump seal leakage




Figure E - 94 Water level in the reactor building basement




Figure E - 95 RPV down comer water level




Figure E - 96 Pressure in theRPV




Figure E - 97 Pressure in the wetwell




Figure E - 98 Vaportemperature in the reactor building basement




Figure E - 99 Water temperature in the wetwell




Figure E - 100 Peak temperature of the fuel cladding as a function of time

E.1.11 Case 11: LOOPGR-38-9, Containment Failure at 53 psig, Containment Venting via the 18-in. Drywell Main Vent, RCIC 50% Degraded




Figure E - 101 Flow rate of the containment vents




Figure E - 102 Flow rate of the HPCI/RCIC pumps




Figure E - 103 Flow rate of the recirculating pump seal leakage




Figure E - 104 Water level in the reactor building basement




Figure E - 105 RPV down comer water level




Figure E - 106 Pressure in theRPV




Figure E - 107 Pressure in the wetwell




Figure E - 108 Vaportemperature in the reactor building basement




Figure E - 109 Water temperature in the wetwell




Figure E - 110 Peak temperature of the fuel cladding as a function of time

E.1.12 Case 12: LOOPGR-38-9, Containment Failure at 53 psig, Containment Venting via the 18-in. Drywell Main Vent, RCIC Non-functional




Figure E - 111 Flow rate of the containment vents




Figure E - 112 Flow rate of the HPCI/RCIC pumps




Figure E - 113 Flow rate of the recirculating pump seal leakage




Figure E - 114 Water level in the reactor building basement




Figure E - 115 RPV down comer water level




Figure E - 116 Pressure in theRPV




Figure E - 117 Pressure in the wetwell




Figure E - 118 Vaportemperature in the reactor building basement




Figure E - 119 Water temperature in the wetwell




Figure E - 120 Peak temperature of the fuel cladding as a function of time

E.1.13 Case 13: LOOPGR-38-9, Containment Failure at 53 psig, Containment Venting via the HCV, RCIC Fully Functional




Figure E - 121 Flow rate of the containment vents




Figure E - 122 Flow rate of the HPCI/RCIC pumps




Figure E - 123 Flow rate of the recirculating pump seal leakage




Figure E - 124 Water level in the reactor building basement




Figure E - 125 RPV down comer water level




Figure E - 126 Pressure in theRPV




Figure E - 127 Pressure in the wetwell




Figure E - 128 Vaportemperature in the reactor building basement




Figure E - 129 Water temperature in the wetwell




Figure E - 130 Peak temperature of the fuel cladding as a function of time

E.1.14 Case 14: LOOPGR-38-9, Containment Failure at 53psig, Containment Venting via the HCV, RCIC 50% Degraded




Figure E - 131 Flow rate of the containment vents




Figure E - 132 Flow rate of the HPCI/RCIC pumps




Figure E - 133 Flow rate of the recirculating pump seal leakage




Figure E - 134 Water level in the reactor building basement




Figure E - 135 RPV down comer water level




Figure E - 136 Pressure in theRPV




Figure E - 137 Pressure in the wetwell




Figure E - 138 Vaportemperature in the reactor building basement




Figure E - 139 Water temperature in the wetwell




Figure E - 140 Peak temperature of the fuel cladding as a function of time

E.2 LOMFW Scenarios

E.2.1 Case 15: LOMFW-25, Perform Anticipatory Venting, Containment Venting via the 2-in. Torus Bypass, RCIC Fully Functional




Figure E - 141 Flow rate of the containment vents




Figure E - 142 Flow rate of the control rod drive hydraulic system




Figure E - 143 Flow rate of the HPCI/RCIC pumps




Figure E - 144 Water level in the reactor building basement




Figure E - 145 RPV down comer water level




Figure E - 146 Pressure in theRPV




Figure E - 147 Pressure in the wetwell




Figure E - 148 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 149 Vaportemperature in the reactor building basement




Figure E - 150 Water temperature in the wetwell




Figure E – 151 Peak temperature of the fuel cladding as a function of time
E.2.2 Case 16: LOMFW-25, Perform Anticipatory Venting, Containment Venting via the 2-in. Torus Bypass, RCIC 50% Degraded




Figure E - 152 Flow rate of the containment vents




Figure E - 153 Flow rate of the control rod drive hydraulic system




Figure E - 154 Flow rate of the HPCI/RCIC pumps




Figure E - 155 Water level in the reactor building basement




Figure E - 156 RPV down comer water level




Figure E - 157 Pressure in theRPV




Figure E - 158 Pressure in the wetwell




Figure E – 159 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 160 Vaportemperature in the reactor building basement




Figure E - 161 Water temperature in the wetwell




Figure E - 162 Peak temperature of the fuel cladding as a function of time

E.2.3 Case 17: LOMFW-25, Perform Anticipatory Venting, Containment Venting via the 18-in. Torus Vent, RCIC Fully Functional




Figure E - 163 Flow rate of the containment vents




Figure E - 164 Flow rate of the control rod drive hydraulic system




Figure E - 165 Flow rate of the HPCI/RCIC pumps




Figure E - 166 Water level in the reactor building basement




Figure E - 167 RPV down comer water level




Figure E - 168 Pressure in theRPV




Figure E - 169 Pressure in the wetwell




Figure E - 170 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 171 Vaportemperature in the reactor building basement




Figure E - 172 Water temperature in the wetwell




Figure E – 173 Peak temperature of the fuel cladding as a function of time
E.2.4 Case 18: LOMFW-25, Perform Anticipatory Venting, Containment Venting via the 18-in. Torus Vent, RCIC 50% Degraded




Figure E - 174 Flow rate of the containment vents




Figure E - 175 Flow rate of the control rod drive hydraulic system




Figure E - 176 Flow rate of the HPCI/RCIC pumps




Figure E - 177 Water level in the reactor building basement




Figure E - 178 RPV down comer water level




Figure E - 179 Pressure in theRPV




Figure E - 180 Pressure in the wetwell




Figure E – 181 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 182 Vaportemperature in the reactor building basement




Figure E - 183 Water temperature in the wetwell




Figure E - 184 Peak temperature of the fuel cladding as a function of time

E.2.5 Case 19: LOMFW-25, Perform Anticipatory Venting, Containment Venting via the 18-in. Torus Vent, RCIC Non-functional




Figure E - 185 Flow rate of the containment vents




Figure E - 186 Flow rate of the control rod drive hydraulic system




Figure E - 187 Flow rate of the HPCI/RCIC pumps




Figure E - 188 Water level in the reactor building basement




Figure E - 189 RPV down comer water level




Figure E - 190 Pressure in theRPV




Figure E - 191 Pressure in the wetwell




Figure E – 192 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E – 193 Vapor temperature in the reactor building basement




Figure E – 194 Water temperature in the wetwell




Figure E – 195 Peak temperature of the fuel cladding as a function of time
E.2.6 Case 20: LOMFW-25, Perform Anticipatory Venting, Containment Venting via the 2-in. Drywell Bypass, RCIC Fully Functional




Figure E – 196 Flow rate of the containment vents




Figure E – 197 Flow rate of the control rod drive hydraulicsystem




Figure E - 198 Flow rate of the HPCI/RCIC pumps




Figure E - 199 Water level in the reactor building basement




Figure E - 200 RPV down comer water level




Figure E - 201 Pressure in theRPV




Figure E - 202 Pressure in the wetwell




Figure E – 203 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E – 204 Vapor temperature in the reactor building basement




Figure E - 205 Water temperature in the wetwell




Figure E – 206 Peak temperature of the fuel cladding as a function of time

E.2.7 Case 21: LOMFW-25, Perform Anticipatory Venting, Containment Venting via the 2-in. Drywell Bypass, RCIC 50% Degraded




Figure E - 207 Flow rate of the containment vents




Figure E - 208 Flow rate of the control rod drive hydraulic system




Figure E - 209 Flow rate of the HPCI/RCIC pumps




Figure E - 210 Water level in the reactor building basement




Figure E - 211 RPV down comer water level




Figure E - 212 Pressure in theRPV




Figure E - 213 Pressure in the wetwell




Figure E - 214 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 215 Vaportemperature in the reactor building basement




Figure E - 216 Water temperature in the wetwell




Figure E - 217 Peak temperature of the fuel cladding as a function of time
E.2.8 Case 22: LOMFW-25, Perform Anticipatory Venting, Containment Venting via the 18-in. Drywell Vent, RCIC Fully Functional




Figure E - 218 Flow rate of the containment vents




Figure E - 219 Flow rate of the control rod drive hydraulic system




Figure E - 220 Flow rate of the HPCI/RCIC pumps




Figure E - 221 Water level in the reactor building basement




Figure E - 222 RPV down comer water level




Figure E - 223 Pressure in theRPV




Figure E - 224 Pressure in the wetwell




Figure E – 225 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 226 Vaportemperature in the reactor building basement




Figure E - 227 Water temperature in the wetwell




Figure E - 228 Peak temperature of the fuel cladding as a function of time

E.2.9 Case 23: LOMFW-25, Perform Anticipatory Venting, Containment Venting via the 18-in. Drywell Vent, RCIC 50% Degraded




Figure E - 229 Flow rate of the containment vents




Figure E - 230 Flow rate of the control rod drive hydraulic system




Figure E - 231 Flow rate of the HPCI/RCIC pumps




Figure E - 232 Water level in the reactor building basement




Figure E - 233 RPV down comer water level




Figure E - 234 Pressure in theRPV




Figure E - 235 Pressure in the wetwell




Figure E - 236 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 237 Vaportemperature in the reactor building basement




Figure E - 238 Water temperature in the wetwell




Figure E – 239 Peak temperature of the fuel cladding as a function of time
E.2.10 Case 24: LOMFW-25, Perform Anticipatory Venting, Containment Venting via the 18-in. Drywell Vent, RCIC Non-functional




Figure E - 240 Flow rate of the containment vents




Figure E - 241 Flow rate of the control rod drive hydraulic system




Figure E - 242 Flow rate of the HPCI/RCIC pumps




Figure E - 243 Water level in the reactor building basement




Figure E - 244 RPV down comer water level




Figure E - 245 Pressure in theRPV




Figure E - 246 Pressure in the wetwell




Figure E – 247 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 248 Vaportemperature in the reactor building basement




Figure E - 249 Water temperature in the wetwell




Figure E - 250 Peak temperature of the fuel cladding as a function of time

E.2.11 Case 25: LOMFW-25, Perform Anticipatory Venting, Containment Venting via the HCV, RCIC Fully Functional




Figure E - 251 Flow rate of the containment vents




Figure E - 252 Flow rate of the control rod drive hydraulic system




Figure E - 253 Flow rate of the HPCI/RCIC pumps




Figure E - 254 Water level in the reactor building basement




Figure E - 255 RPV down comer water level




Figure E - 256 Pressure in theRPV




Figure E - 257 Pressure in the wetwell




Figure E - 258 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 259 Vaportemperature in the reactor building basement




Figure E - 260 Water temperature in the wetwell




Figure E – 261 Peak temperature of the fuel cladding as a function of time
E.2.12 Case 26: LOMFW-25, Perform Anticipatory Venting, Containment Venting via the HCV, RCIC Non-functional




Figure E - 262 Flow rate of the containment vents




Figure E - 263 Flow rate of the control rod drive hydraulic system




Figure E - 264 Flow rate of the HPCI/RCIC pumps




Figure E – 265 Water level in the reactor building basement




Figure E – 266 RPV down comer water level




Figure E - 267 Pressure in theRPV




Figure E - 268 Pressure in the wetwell




Figure E – 269 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 270 Vaportemperature in the reactor building basement




Figure E - 271 Water temperature in the wetwell




Figure E - 272 Peak temperature of the fuel cladding as a function of time

E.2.13 Case 27: LOMFW-25, Containment Failure at 53 psig, Containment Venting via the 2-in. Torus Bypass, RCIC Fully Functional




Figure E - 273 Flow rate of the containment vents




Figure E - 274 Flow rate of the control rod drive hydraulic system




Figure E - 275 Flow rate of the HPCI/RCIC pumps




Figure E - 276 Water level in the reactor building basement




Figure E - 277 RPV down comer water level




Figure E - 278 Pressure in theRPV




Figure E - 279 Pressure in the wetwell




Figure E - 280 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 281 Vaportemperature in the reactor building basement




Figure E - 282 Water temperature in the wetwell




Figure E – 283 Peak temperature of the fuel cladding as a function of time
E.2.14 Case 28: LOMFW-25, Containment Failure at 53 psig, Containment Venting via the 2-in. Torus Bypass, RCIC 50% Degraded




Figure E - 284 Flow rate of the containment vents




Figure E – 285 Flow rate of the control rod drive hydraulicsystem




Figure E - 286 Flow rate of the HPCI/RCIC pumps




Figure E - 287 Water level in the reactor building basement




Figure E - 288 RPV down comer water level




Figure E - 289 Pressure in theRPV




Figure E - 290 Pressure in the wetwell




Figure E – 291 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 292 Vaportemperature in the reactor building basement




Figure E - 293 Water temperature in the wetwell




Figure E - 294 Peak temperature of the fuel cladding as a function of time

E.2.15 Case 29: LOMFW-25, Containment Failure at 53 psig, Containment Venting via the 18-in. Torus Vent, RCIC Fully Functional




Figure E - 295 Flow rate of the containment vents




Figure E - 296 Flow rate of the control rod drive hydraulic system




Figure E - 297 Flow rate of the HPCI/RCIC pumps




Figure E - 298 Water level in the reactor building basement




Figure E - 299 RPV down comer water level




Figure E - 300 Pressure in theRPV




Figure E - 301 Pressure in the wetwell




Figure E - 302 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 303 Vaportemperature in the reactor building basement




Figure E - 304 Water temperature in the wetwell




Figure E – 305 Peak temperature of the fuel cladding as a function of time
E.2.16 Case 30: LOMFW-25, Containment Failure at 53 psig, Containment Venting via the 18-in. Torus Vent, RCIC 50% Degraded




Figure E – 306 Flow rate of the containment vents




Figure E - 307 Flow rate of the control rod drive hydraulic system




Figure E - 308 Flow rate of the HPCI/RCIC pumps




Figure E - 309 Water level in the reactor building basement




Figure E - 310 RPV down comer water level




Figure E - 311 Pressure in theRPV




Figure E - 312 Pressure in the wetwell




Figure E – 313 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 314 Vapor temperature in the reactor building basement




Figure E - 315 Water temperature in the wetwell




Figure E - 316 Peak temperature of the fuel cladding as a function of time

E.2.17 Case 31: LOMFW-25, Containment Failure at 53 psig, Containment Venting via the 18-in. Torus Vent, RCIC Non-functional




Figure E - 317 Flow rate of the containment vents




Figure E - 318 Flow rate of the control rod drive hydraulic system




Figure E - 319 Flow rate of the HPCI/RCIC pumps




Figure E - 320 Water level in the reactor building basement




Figure E - 321 RPV down comer water level




Figure E - 322 Pressure in theRPV




Figure E - 323 Pressure in the wetwell




Figure E - 324 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 325 Vaportemperature in the reactor building basement




Figure E - 326 Water temperature in the wetwell




Figure E – 327 Peak temperature of the fuel cladding as a function of time
E.2.18 Case 32: LOMFW-25, Containment Failure at 53 psig, Containment Venting via the 2-in. Drywell Bypass, RCIC Fully Functional




Figure E - 328 Flow rate of the containment vents




Figure E - 329 Flow rate of the control rod drive hydraulic system




Figure E - 330 Flow rate of the HPCI/RCIC pumps




Figure E - 331 Water level in the reactor building basement




Figure E - 332 RPV down comer water level




Figure E - 333 Pressure in theRPV




Figure E - 334 Pressure in the wetwell




Figure E – 335 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 336 Vapor temperature in the reactor building basement




Figure E - 337 Water temperature in the wetwell




Figure E - 338 Peak temperature of the fuel cladding as a function of time

E.2.19 Case 33: LOMFW-25, Containment Failure at 53 psig, Containment Venting via the 2-in. Drywell Bypass, RCIC 50% Degraded




Figure E - 339 Flow rate of the containment vents




Figure E - 340 Flow rate of the control rod drive hydraulic system




Figure E - 341 Flow rate of the HPCI/RCIC pumps




Figure E - 342 Water level in the reactor building basement




Figure E - 343 RPV down comer water level




Figure E - 344 Pressure in theRPV




Figure E - 345 Pressure in the wetwell




Figure E – 346 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 347 Vaportemperature in the reactor building basement




Figure E - 348 Water temperature in the wetwell




Figure E – 349 Peak temperature of the fuel cladding as a function of time
E.2.20 Case 34: LOMFW-25, Containment Failure at 53 psig, Containment Venting via the 18-in. Drywell Vent, RCIC Fully Functional




Figure E - 350 Flow rate of the containment vents




Figure E - 351 Flow rate of the control rod drive hydraulic system




Figure E - 352 Flow rate of the HPCI/RCIC pumps




Figure E - 353 Water level in the reactor building basement




Figure E - 354 RPV down comer water level




Figure E - 355 Pressure in theRPV




Figure E - 356 Pressure in the wetwell




Figure E – 357 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E – 358 Vapor temperature in the reactor building basement




Figure E - 359 Water temperature in the wetwell




Figure E - 360 Peak temperature of the fuel cladding as a function of time

E.2.21 Case 35: LOMFW-25, Containment Failure at 53 psig, Containment Venting via the 18-in. Drywell Vent, RCIC 50% Degraded




Figure E - 361 Flow rate of the containment vents




Figure E - 362 Flow rate of the control rod drive hydraulic system




Figure E - 363 Flow rate of the HPCI/RCIC pumps




Figure E - 364 Water level in the reactor building basement




Figure E - 365 RPV down comer water level




Figure E - 366 Pressure in theRPV




Figure E - 367 Pressure in the wetwell




Figure E - 368 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 369 Vaportemperature in the reactor building basement




Figure E - 370 Water temperature in the wetwell




Figure E – 371 Peak temperature of the fuel cladding as a function of time
E.2.22 Case 36: LOMFW-25, Containment Failure at 53 psig, Containment Venting via the 18-in. Drywell Vent, RCIC Non-functional




Figure E - 372 Flow rate of the containment vents




Figure E - 373 Flow rate of the control rod drive hydraulic system




Figure E - 374 Flow rate of the HPCI/RCIC pumps




Figure E - 375 Water level in the reactor building basement




Figure E - 376 RPV down comer water level




Figure E - 377 Pressure in theRPV




Figure E - 378 Pressure in the wetwell




Figure E – 379 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E – 380 Vapor temperature in the reactor building basement




Figure E - 381 Water temperature in the wetwell




Figure E - 382 Peak temperature of the fuel cladding as a function of time

E.2.23 Case 37: LOMFW-25, Containment Failure at 53 psig, Containment Venting via the HCV, RCIC Fully Functional




Figure E – 383 Flow rate of the containment vents




Figure E – 384 Flow rate of the control rod drive hydraulic system




Figure E - 385 Flow rate of the HPCI/RCIC pumps




Figure E - 386 Water level in the reactor building basement




Figure E - 387 RPV down comer water level




Figure E - 388 Pressure in theRPV




Figure E - 389 Pressure in the wetwell




Figure E - 390P Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E – 391 Vapor temperature in the reactor building basement




Figure E - 392 Water temperature in the wetwell




Figure E – 393 Peak temperature of the fuel cladding as a function of time
E.2.24 Case 38: LOMFW-25, Containment Failure at 53 psig, Containment Venting via the HCV, RCIC Non-functional




Figure E - 394 Flow rate of the containment vents




Figure E - 395 Flow rate of the control rod drive hydraulic system




Figure E - 396 Flow rate of the HPCI/RCIC pumps




Figure E - 397 Water level in the reactor building basement




Figure E - 398 RPV down comer water level




Figure E - 399 Pressure in the RPV




Figure E - 400 Pressure in the wetwell




Figure E – 401 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 402 Vaportemperature in the reactor building basement




Figure E - 403 Water temperature in the wetwell




Figure E - 404 Peak temperature of the fuel cladding as a function of time

E.3 Sensitivity Analyses

E.3.1 Case 1a: Sensitivity to LOOPGR-38-9 Case 1 with CST Unavailable




Figure E - 405 Flow rate of the containment vents




Figure E - 406 Flow rate of the HPCI/RCIC pumps




Figure E - 407 Flow rate of the recirculating pump seal leakage




Figure E - 408 Water level in the reactor building basement




Figure E - 409 RPV down comer water level




Figure E - 410 Pressure in theRPV




Figure E – 411 Pressure in the wetwell




Figure E - 412 Vaportemperature in the reactor building basement




Figure E - 413 Water temperature in the wetwell




Figure E - 414 Peak temperature of the fuel cladding as a function of time

E.3.2 Case 3a: Sensitivity to LOOPGR-38-9 Case 3 with HPCI Available Instead of RCIC




Figure E - 415 Flow rate of the containment vents




Figure E - 416 Flow rate of the HPCI/RCIC pumps




Figure E - 417 Flow rate of the recirculating pump seal leakage




Figure E - 418 Water level in the reactor building basement




Figure E - 419 RPV down comer water level




Figure E - 420 Pressure in theRPV




Figure E - 421 Pressure in the wetwell




Figure E - 422 Vapor temperature in the reactor building basement




Figure E - 423 Water temperature in the wetwell




Figure E - 424 Peak temperature of the fuel cladding as a function of time

E.3.3 Case 3b: Sensitivity to LOOPGR-38-9 Case 3 with CST Unavailable




Figure E - 425 Flow rate of the containment vents




Figure E - 426 Flow rate of the HPCI/RCIC pumps




Figure E - 427 Flow rate of the recirculating pump seal leakage




Figure E - 428 Water level in the reactor building basement




Figure E - 429 **RPV down comer water level**




Figure E - 430 **Pressure in theRPV**




Figure E - 431 Pressure in the wetwell




Figure E - 432 Vapor temperature in the reactor building basement




Figure E - 433 Water temperature in the wetwell




Figure E - 434 Peak temperature of the fuel cladding as a function of time

E.3.4 Case 3c: Sensitivity to LOOPGR-38-9 Case 3 with NoContainmentventing




Figure E - 435 Flow rate of the containment vents




Figure E - 436 Flow rate of the HPCI/RCIC pumps




Figure E - 437 Flow rate of the recirculating pump seal leakage




Figure E - 438 Water level in the reactor building basement




Figure E - 439 RPV down comer water level




Figure E - 440 Pressure in theRPV




Figure E - 441 Pressure in the wetwell




Figure E - 442 Vapor temperature in the reactor building basement




Figure E - 443 Water temperature in the wetwell




Figure E - 444 Peak temperature of the fuel cladding as a function of time

E.3.5 Case 3d: Sensitivity to LOOPGR-38-9 Case 3 with Increased Seal Leakage (150 gpm Total)




Figure E - 445 Flow rate of the containment vents




Figure E - 446 Flow rate of the HPCI/RCIC pumps




Figure E - 447 Flow rate of the recirculating pump seal leakage




Figure E - 448 Water level in the reactor building basement




Figure E - 449 **RPV down comer water level**




Figure E - 450 **Pressure in theRPV**




Figure E - 451 Pressure in the wetwell




Figure E - 452 Vapor temperature in the reactor building basement




Figure E - 453 Water temperature in the wetwell




Figure E - 454 Peak temperature of the fuel cladding as a function of time

E.3.6 Case 3e: Sensitivity to LOOPGR-38-9 Case 3 with Increased Seal Leakage(300 gpm Total)




Figure E - 455 Flow rate of the containment vents




Figure E - 456 Flow rate of the HPCI/RCIC pumps




Figure E - 457 Flow rate of the recirculating pump seal leakage




Figure E - 458 Water level in the reactor building basement




Figure E - 459 RPV down comer water level




Figure E - 460 Pressure in theRPV




Figure E - 461 Pressure in the wetwell




Figure E - 462 Vapor temperature in the reactor building basement




Figure E - 463 Water temperature in the wetwell




Figure E - 464 Peak temperature of the fuel cladding as a function of time

E.3.7 Case 3f: Sensitivity to LOOPGR-38-9 Case 3 with Increased Seal Leakage (150 gpm Total) Starting at 17 min.




Figure E - 465 Flow rate of the containment vents




Figure E - 466 Flow rate of the HPCI/RCIC pumps




Figure E - 467 Flow rate of the recirculating pump seal leakage




Figure E - 468 Water level in the reactor building basement




Figure E - 469 RPV down comer water level




Figure E - 470 Pressure in theRPV




Figure E - 471 Pressure in the wetwell




Figure E - 472 Vaportemperature in the reactor building basement




Figure E - 473 Water temperature in the wetwell




Figure E - 474 Peak temperature of the fuel cladding as a function of time

E.3.8 Case 3g: Sensitivity to LOOPGR-38-9 Case 3 with Increased Seal Leakage (300 gpm Total) Starting at 17 min.




Figure E - 475 Flow rate of the containment vents




Figure E - 476 Flow rate of the HPCI/RCIC pumps




Figure E - 477 Flow rate of the recirculating pump seal leakage




Figure E - 478 Water level in the reactor building basement




Figure E - 479 RPV down comer water level




Figure E - 480 Pressure in theRPV




Figure E - 481 Pressure in the wetwell




Figure E - 482 Vapor temperature in the reactor building basement




Figure E - 483 Water temperature in the wetwell




Figure E - 484 Peak temperature of the fuel cladding as a function of time

E.3.9 Case 8a: Sensitivity to LOOPGR-38-9 Case 8 with CSTUnavailable




Figure E - 485 Flow rate of the containment vents




Figure E - 486 Flow rate of the HPCI/RCIC pumps




Figure E - 487 Flow rate of the recirculating pump seal leakage




Figure E - 488 Water level in the reactor building basement




Figure E - 489 RPV down comer water level




Figure E - 490 Pressure in theRPV




Figure E - 491 Pressure in the wetwell




Figure E - 492 Vaportemperature in the reactor building basement




Figure E - 493 Water temperature in the wetwell




Figure E - 494 Peak temperature of the fuel cladding as a function of time

E.3.10 Case 10a: Sensitivity to LOOPGR-38-9 Case 10 with HPCI Available Instead of RCIC




Figure E - 495 Flow rate of the containment vents




Figure E - 496 Flow rate of the HPCI/RCIC pumps




Figure E - 497 Flow rate of the recirculating pump seal leakage




Figure E - 498 Water level in the reactor building basement




Figure E - 499 **RPV down comer water level**




Figure E - 500 **Pressure in theRPV**




Figure E - 501 Pressure in the wetwell




Figure E - 502 Vaportemperature in the reactor building basement




Figure E - 503 Water temperature in the wetwell




Figure E - 504 Peak temperature of the fuel cladding as a function of time

E.3.11 Case 10b: Sensitivity to LOOPGR-38-9 Case 10 with CST Unavailable




Figure E - 505 Flow rate of the containment vents




Figure E - 506 Flow rate of the HPCI/RCIC pumps




Figure E - 507 Flow rate of the recirculating pump seal leakage




Figure E - 508 Water level in the reactor building basement




Figure E - 509 RPV down comer water level




Figure E - 510 Pressure in theRPV




Figure E - 511 Pressure in the wetwell




Figure E - 512 Vaportemperature in the reactor building basement




Figure E - 513 Water temperature in the wetwell




Figure E - 514 Peak temperature of the fuel cladding as a function of time

E.3.12 Case 15a: Sensitivity to LOMFW-25 Case 15 with CRDHS Unavailable




Figure E - 515 Flow rate of the containment vents




Figure E - 516 Flow rate of the control rod drive hydraulic system




Figure E - 517 Flow rate of the HPCI/RCIC pumps




Figure E - 518 Water level in the reactor building basement




Figure E - 519 RPV down comer water level




Figure E - 520 Pressure in theRPV




Figure E - 521 Pressure in the wetwell




Figure E - 522 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 523 Vaportemperature in the reactor building basement




Figure E - 524 Water temperature in the wetwell




Figure E - 525 Peak temperature of the fuel cladding as a function of time
E.3.13 Case 15b: Sensitivity to LOMFW-25 Case 15 with MSIV Closure at the Start of the Transient




Figure E - 526 Flow rate of the containment vents




Figure E - 527 Flow rate of the control rod drive hydraulic system




Figure E - 528 Flow rate of the HPCI/RCIC pumps




Figure E - 529 Water level in the reactor building basement




Figure E - 530 RPV down comer water level




Figure E - 531 Pressure in theRPV




Figure E - 532 Pressure in the wetwell




Figure E – 533 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 534 Vaportemperature in the reactor building basement




Figure E - 535 Water temperature in the wetwell




Figure E - 536 Peak temperature of the fuel cladding as a function of time

E.3.14 Case 17a: Sensitivity to LOMFW-25 Case 17 with HPCI Available Instead of RCIC




Figure E - 537 Flow rate of the containment vents




Figure E - 538 Flow rate of the control rod drive hydraulic system




Figure E - 539 Flow rate of the HPCI/RCIC pumps




Figure E - 540 Water level in the reactor building basement




Figure E – 541 RPV down comer water level




Figure E – 542 Pressure in theRPV




Figure E – 543 Pressure in the wetwell




Figure E – 544 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E – 545 **Vaportemperature in the reactor building basement**




Figure E – 546 **Water temperature in the wetwell**




Figure E - 547 Peak temperature of the fuel cladding as a function of time
E.3.15 Case 17b: Sensitivity to LOMFW-25 Case 17 with SRV Failing Open at 270 Cycles




Figure E - 548 Flow rate of the containment vents




Figure E - 549 Flow rate of the control rod drive hydraulic system




Figure E - 550 Flow rate of the HPCI/RCIC pumps




Figure E - 551 Water level in the reactor building basement




Figure E - 552 RPV down comer water level




Figure E - 553 Pressure in theRPV




Figure E - 554 Pressure in the wetwell




Figure E – 555 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E – 556 Vaportemperature in the reactor building basement




Figure E - 557 Water temperature in the wetwell




Figure E - 558 Peak temperature of the fuel cladding as a function of time

E.3.16 Case 17c: Sensitivity to LOMFW-25 Case 17 with RCIC Lost after Three Complete Cycles




Figure E - 559 Flow rate of the containment vents




Figure E - 560 Flow rate of the control rod drive hydraulic system




Figure E - 561 Flow rate of the HPCI/RCIC pumps




Figure E - 562 Water level in the reactor building basement




Figure E - 563 RPV down comer water level




Figure E - 564 Pressure in theRPV




Figure E - 565 Pressure in the wetwell




Figure E - 566 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 567 Vaportemperature in the reactor building basement




Figure E - 568 Water temperature in the wetwell




Figure E - 569 Peak temperature of the fuel cladding as a function of time
E.3.17 Case 17d: Sensitivity to LOMFW-25 Case 17 with RCIC Lost after Four Complete Cycles




Figure E - 570 Flow rate of the containment vents




Figure E - 571 Flow rate of the control rod drive hydraulic system




Figure E - 572 Flow rate of the HPCI/RCIC pumps




Figure E - 573 Water level in the reactor building basement




Figure E - 574 RPV down comer water level




Figure E - 575 Pressure in theRPV




Figure E - 576 Pressure in the wet well




Figure E – 577 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 578 Vaportemperature in the reactor building basement




Figure E - 579 Water temperature in the wetwell




Figure E - 580 Peak temperature of the fuel cladding as a function of time

E.3.18 Case 17e: Sensitivity to LOMFW-25 Case 17 with CST Unavailable




Figure E - 581 Flow rate of the containment vents




Figure E - 582 Flow rate of the control rod drive hydraulic system




Figure E - 583 Flow rate of the HPCI/RCIC pumps




Figure E - 584 Water level in the reactor building basement




Figure E – 585 RPV down comer water level




Figure E - 586 Pressure in theRPV




Figure E - 587 Pressure in the wetwell




Figure E - 588 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 589 **Vaportemperature in the reactor building basement**




Figure E - 590 **Water temperature in the wetwell**




Figure E – 591 Peak temperature of the fuel cladding as a function of time
E.3.19 Case 17f: Sensitivity to LOMFW-25 Case 17 with Nominal Seal Leakage




Figure E - 592 Flow rate of the containment vents




Figure E - 593 Flow rate of the control rod drive hydraulic system




Figure E - 594 Flow rate of the HPCI/RCIC pumps




Figure E - 595 Water level in the reactor building basement




Figure E - 596 RPV down comer water level




Figure E - 597 Pressure in theRPV




Figure E - 598 Pressure in the wetwell




Figure E – 599 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 600 Vaportemperature in the reactor building basement




Figure E - 601 Water temperature in the wetwell




Figure E - 602 Peak temperature of the fuel cladding as a function of time

E.3.20 Case 17g: Sensitivity to LOMFW-25 Case 17 with Increased Seal Leakage (150 gpm Total)




Figure E - 603 Flow rate of the containment vents




Figure E - 604 Flow rate of the control rod drive hydraulic system




Figure E - 605 Flow rate of the HPCI/RCIC pumps




Figure E - 606 Water level in the reactor building basement




Figure E - 607 RPV down comer water level




Figure E - 608 Pressure in theRPV




Figure E - 609 Pressure in the wetwell




Figure E - 610 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 611 Vaportemperature in the reactor building basement




Figure E - 612 Water temperature in the wetwell




Figure E – 613 Peak temperature of the fuel cladding as a function of time
E.3.21 Case 17h: Sensitivity to LOMFW-25 Case 17 with Rapid RPV Depressurization at HCL




Figure E - 614 Flow rate of the containment vents




Figure E - 615 Flow rate of the control rod drive hydraulic system




Figure E - 616 Flow rate of the HPCI/RCIC pumps




Figure E - 617 Water level in the reactor building basement




Figure E - 618 RPV down comer water level




Figure E - 619 Pressure in theRPV




Figure E - 620 Pressure in the wetwell




Figure E – 621 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 622 Vapor temperature in the reactor building basement




Figure E - 623 Water temperature in the wetwell




Figure E - 624 Peak temperature of the fuel cladding as a function of time

E.3.22 Case 17i: Sensitivity to LOMFW-25 Case 17 with MSIV Closure at the Start of the Transient




Figure E - 625 Flow rate of the containment vents




Figure E - 626 Flow rate of the control rod drive hydraulic system




Figure E - 627 Flow rate of the HPCI/RCIC pumps




Figure E - 628 Water level in the reactor building basement




Figure E - 629 RPV down comer water level




Figure E - 630 Pressure in theRPV




Figure E - 631 Pressure in the wetwell




Figure E - 632 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 633 **Vaportemperature in the reactor building basement**




Figure E - 634 **Water temperature in the wetwell**




Figure E - 635 Peak temperature of the fuel cladding as a function of time
E.3.23 Case 19a: Sensitivity to LOMFW-25 Case 19 with Nominal Seal Leakage




Figure E - 636 Flow rate of the containment vents




Figure E - 637 Flow rate of the control rod drive hydraulic system




Figure E - 638 Flow rate of the HPCI/RCIC pumps




Figure E - 639 Water level in the reactor building basement




Figure E - 640 RPV down comer water level




Figure E - 641 Pressure in theRPV




Figure E - 642 Pressure in the wetwell




Figure E – 643 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 644 Vaportemperature in the reactor building basement




Figure E - 645 Water temperature in the wetwell




Figure E - 646 Peak temperature of the fuel cladding as a function of time

E.3.24 Case 19b: Sensitivity to LOMFW-25 Case 19 with CRDHS Unavailable




Figure E - 647 Flow rate of the containment vents




Figure E - 648 Flow rate of the control rod drive hydraulic system




Figure E - 649 Flow rate of the HPCI/RCIC pumps




Figure E - 650 Water level in the reactor building basement




Figure E - 651 RPV down comer water level




Figure E - 652 Pressure in theRPV




Figure E - 653 Pressure in the wetwell




Figure E - 654 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 655 Vaportemperature in the reactor building basement




Figure E - 656 Water temperature in the wetwell




Figure E - 657 Peak temperature of the fuel cladding as a function of time
E.3.25 Case 19c: Sensitivity to LOMFW-25 Case 19 with MSIV Closure at the Start of the Transient




Figure E - 658 Flow rate of the containment vents




Figure E - 659 Flow rate of the control rod drive hydraulic system




Figure E - 660 Flow rate of the HPCI/RCIC pumps




Figure E - 661 Water level in the reactor building basement




Figure E - 662 RPV down comer water level




Figure E - 663 Pressure in theRPV




Figure E - 664 Pressure in the wetwell




Figure E – 665 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E - 666 Vaportemperature in the reactor building basement




Figure E - 667 Water temperature in the wetwell




Figure E - 668 Peak temperature of the fuel cladding as a function of time

E.3.26 Case 29a: Sensitivity to LOMFW-25 Case 29 with HPCI Available Instead of RCIC




Figure E – 669 Flow rate of the containment vents




Figure E – 670 Flow rate of the control rod drive hydraulics system




Figure E – 671 Flow rate of the HPCI/RCIC pumps




Figure E – 672 Water level in the reactor building basement




Figure E – 673 RPV down comer water level




Figure E – 674 Pressure in the RPV




Figure E – 675 Pressure in the wetwell




Figure E – 676 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E – 677 Vapor temperature in the reactor building basement




Figure E – 678 Water temperature in the wetwell




Figure E – 679 Peak temperature of the fuel cladding as a function of time
E.3.27 Case 29b: Sensitivity to LOMFW-25 Case 29 with CST Unavailable




Figure E – 680 Flow rate of the containment vents




Figure E – 681 Flow rate of the control rod drive hydraulicsystem




Figure E – 682 Flow rate of the HPCI/RCIC pumps




Figure E – 683 Water level in the reactor building basement




Figure E – 684 RPV down comer water level




Figure E – 685 Pressure in the RPV




Figure E – 686 Pressure in the wetwell




Figure E – 687 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E – 688 Vapor temperature in the reactor building basement




Figure E – 689 Water temperature in the wetwell




Figure E – 690 Peak temperature of the fuel cladding as a function of time

E.3.28 Case 31a: Sensitivity to LOMFW-25 Case 29 with CRDHS Unavailable




Figure E - 691 Flow rate of the containment vents




Figure E - 692 Flow rate of the control rod drive hydraulic system




Figure E – 693 Flow rate of the HPCI/RCIC pumps




Figure E – 694 Water level in the reactor building basement




Figure E - 695 RPV down comer water level




Figure E - 696 Pressure in the RPV




Figure E – 697 Pressure in the wetwell




Figure E – 698 Plant status relative to the HCL curve (Graph 4 of the EOPs)




Figure E – 699 Vapor temperature in the reactor building basement




Figure E – 700 Water temperature in the wetwell




Figure E – 701 Peak temperature of the fuel cladding as a function of time

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

NUREG-2236
Volume 2

2. TITLE AND SUBTITLE

Confirmatory Thermal-Hydraulic Analysis To Support Specific Success
Criteria in the Standardized Plant Analysis Risk Models—Duane Arnold

Appendices D - E

3. DATE REPORT PUBLISHED

MONTH	YEAR
October	2020

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

S. Campbell, S. Dennis, D. Helton, M. Khatib-Rahbar, A. Krall, L. Kozak,
R. Buell, F. Sock, J. Pires

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above", if contractor, provide NRC Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address.)

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

10. SUPPLEMENTARY NOTES

S. Dennis

11. ABSTRACT (200 words or less)

This report extends the work documented in NUREG-2187, "Confirmatory Thermal-Hydraulic Analysis to Support Specific Success Criteria in the Standardized Plant Analysis Risk Models—Byron Unit 1," issued January 2016, to the Duane Arnold Energy Center. Its purpose is to produce an additional set of best estimate thermal-hydraulic calculations that can be used to confirm or enhance specific success criteria for system performance and operator timing found in the agency's probabilistic risk assessment tools. Along with enhancing the technical basis for the agency's independent standardized plant analysis risk (SPAR) models, these calculations are expected to be a useful reference to model end users for specific regulatory applications.

This report first describes major assumptions used in this study. It then describes the major plant characteristics for the Duane Arnold Energy Center, in addition to the MELCOR model used to represent the plant. Finally, the report presents the results of MELCOR calculations for selected initiators and compares these results to SPAR success criteria, the licensee's success criteria, or other generic studies.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

PRA, Success Criteria, MELCOR, thermal-hydraulic

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)


unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, DC 20555-0001

OFFICIAL BUSINESS



@NRCgov

**NUREG-2236, Volume 2
Appendices D - E**

**Confirmatory Thermal-Hydraulic Analysis To Support Specific Success
Criteria in the Standardized Plant Analysis Risk Models—Duane Arnold**

October 2020