



Byron Generating Station

4450 North German Church Rd
Byron, IL 61010-9794

www.exeloncorp.com

May 6, 2021

LTR: BYRON 2021-0032
File: 1.10.0101 (1D.101)
2.12.1523 (2C.111)

United States Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Byron Station, Units 1 and 2
Renewed Facility Operating License Nos. NPF-37 and NPF-66
NRC Docket Nos. STN 50-454 and STN 50-455

Subject: 2020 Annual Radiological Environmental Operating Report (AREOR)

In accordance with Technical Specification 5.6.2, "Annual Radiological Environmental Operating Report," we are submitting the Annual Radiological Environmental Operating Report (AREOR) for Byron Station, Units 1 and 2. This report is required to be submitted to the NRC by May 15th of each year and contains the results of the radiological environmental and meteorological monitoring programs. The Radioactive Effluent Release Report was submitted under separate cover.

Also included are the results of groundwater monitoring conducted in accordance with Exelon's Radiological Groundwater Protection Program (RGPP), which is a voluntary program implemented in 2006. This information is being reported in accordance with a nuclear industry initiative.

If you have any questions regarding this information, please contact Ms. Lisa Zurawski, Regulatory Assurance Manager, at (815) 406-2800.

Respectfully,

A handwritten signature in black ink, appearing to read "JAK", written over a light blue horizontal line.

John J. Kowalski
Site Vice President
Byron Generating Station

JJK/AH/LZ/mf

Attachment: AREOR Report

cc: Regional Administrator – NRC Region III

NRC.Docket No: 50-454
50-455

BYRON NUCLEAR GENERATING STATION UNITS 1 and 2

Annual Radiological
Environmental Operating Report

1 January Through 31 December 2020

Prepared By

Teledyne Brown Engineering
Environmental Services



Byron Nuclear Generating Station
Byron, IL 61010

April 2021

Intentionally left blank

Table Of Contents

I. Summary and Conclusions	1
II. Introduction.....	2
A. Objectives of the REMP.....	2
B. Implementation of the Objectives	2
III. Program Description.....	3
A. Sample Collection.....	3
B. Sample Analysis	5
C. Data Interpretation.....	5
D. Program Exceptions	6
E. Program Changes	8
IV. Results and Discussion	9
A. Aquatic Environment	9
1. Surface Water	9
2. Ground Water	9
3. Fish	10
4. Sediment.....	10
B. Atmospheric Environment	10
1. Airborne	10
a. Air Particulates.....	10
b. Airborne Iodine.....	11
2. Terrestrial.....	11
a. Milk.....	11
b. Vegetation.....	12
C. Ambient Gamma Radiation	12
D. Land Use Survey.....	12
E. Errata Data	13
F. Summary of Results – Inter-laboratory Comparison Program.....	13

Appendices

Appendix A Radiological Environmental Monitoring Report Summary

Tables

Table A-1 Radiological Environmental Monitoring Program Annual Summary for Byron Nuclear Generating Station, 2020

Appendix B Location Designation, Distance & Direction, and Sample Collection & Analytical Methods

Tables

Table B-1 Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Byron Nuclear Generating Station, 2020

Table B-2 Radiological Environmental Monitoring Program - Summary of Sample Collection and Analytical Methods, Byron Nuclear Generating Station, 2020

Figures

Figure B-1 Inner Ring and Special Interest OSLD Locations of the Byron Nuclear Generating Station, 2020

Figure B-2 Outer Ring OSLD Locations of the Byron Nuclear Generating Station, 2020

Figure B-3 Onsite Air Sampling Locations of the Byron Nuclear Generating Station, 2020

Figure B-4 Offsite Air Sampling Locations of the Byron Nuclear Generating Station, 2020

Figure B-5 Ingestion and Waterborne Exposure Pathway Sampling Locations of the Byron Nuclear Generating Station, 2020

Appendix C Data Tables and Figures

Tables

Table C-I.1 Concentrations of Gross Beta in Surface Water Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020.

Table C-I.2 Concentrations of Tritium in Surface Water Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020.

Table C-I.3 Concentrations of Nickel-63 in Surface Water Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020

Table C-I.4 Concentrations of Gamma Emitters in Surface Water Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020

Table C-II.1	Concentrations of Tritium in Ground Water Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020
Table C-II.2	Concentrations of Gamma Emitters in Ground Water Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020
Table C-III.1	Concentrations of Nickel-63 and Gamma Emitters in Fish Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020
Table C-IV.1	Concentrations of Nickel-63 and Gamma Emitters in Sediment Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020
Table C-V.1	Concentrations of Gross Beta in Air Particulate Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020
Table C-V.2	Monthly and Yearly Mean Values of Gross Beta Concentrations in Air Particulate Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020
Table C-V.3	Concentrations of Gamma Emitters in Air Particulate Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020
Table C-VI.1	Concentrations of I-131 in Air Iodine Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020
Table C-VII.1	Concentrations of I-131 in Milk Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020
Table C-VII.2	Concentrations of Gamma Emitters in Milk Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020
Table C-VIII.1	Concentrations of Gamma Emitters in Vegetation Samples Collected in the Vicinity of Byron Nuclear Generating Station, 2020
Table C-IX.1	Quarterly OSLD Results for Byron Nuclear Generating Station, 2020
Table C-IX.2	Mean Quarterly OSLD Results for the Inner Ring, Outer Ring, Special Interest, Other and Control Locations for Byron Nuclear Generating Station, 2020
Table C-IX.3	Summary of the Ambient Dosimetry Program for Byron Nuclear Generating Station, 2020

Figures

Figure C-1	Surface Water - Gross Beta – Stations BY-12 and BY-29 (C) Collected in the Vicinity of BNGS, 2000 - 2020
Figure C-2	Surface Water - Tritium – Stations BY-12 and BY-29 (C) Collected in the Vicinity of BNGS, 2000 – 2020
Figure C-3	Ground Water - Tritium – Station BY-14-1 Collected in the Vicinity of BNGS, 2000 – 2020

Figure C-4	Ground Water - Tritium – Station BY-18-1 Collected in the Vicinity of BNGS, 2010 – 2020
Figure C-5	Ground Water - Tritium – Station BY-32 Collected in the Vicinity of BNGS, 2006 – 2020
Figure C-6	Ground Water - Tritium – Station BY-35 Collected in the Vicinity of BNGS, 2006 – 2020
Figure C-7	Ground Water - Tritium – Stations BY-37 and BY-38 Collected in the Vicinity of BNGS, 2006 – 2020
Figure C-8	Air Particulate – Gross Beta – Stations BY-08 (C) and BY-21 Collected in the Vicinity of BNGS, 2000 - 2020
Figure C-9	Air Particulate – Gross Beta – Stations BY-22 and BY-23 Collected in the Vicinity of BNGS, 2000 - 2020
Figure C-10	Air Particulate – Gross Beta – Station BY-24 Collected in the Vicinity of BNGS, 2000 - 2020
Figure C-11	Air Particulate – Gross Beta – Stations BY-01 and BY-04 Collected in the Vicinity of BNGS, 2005 - 2020
Figure C-12	Air Particulate – Gross Beta – Station BY-06 Collected in the Vicinity of BNGS, 2005 – 2020
Appendix D	Inter-Laboratory Comparison Program

Tables

Table D-1	Analytics Environmental Radioactivity Cross Check Program Teledyne Brown Engineering, 2020
Table D-2	DOE’s Mixed Analyte Performance Evaluation Program (MAPEP) Teledyne Brown Engineering, 2020
Table D-3	ERA Environmental Radioactivity Cross Check Program Teledyne Brown Engineering, 2020
Appendix E	Effluent Report
Appendix E-1	Data Tables and Figures
Appendix F	Meteorological Data
Appendix G	Errata data
Appendix H	Annual Radiological Groundwater Protection Program Report (ARGPPR)

I. Summary and Conclusions

This report on the Radiological Environmental Monitoring Program conducted for the Byron Nuclear Generating Station by Exelon covers the period 1 January 2020 through 31 December 2020. During that time period, 1,434 analyses were performed on 1,272 samples. In assessing all the data gathered for this report and comparing these results with preoperational data, it was concluded that the operation of BNGS had no adverse radiological impact on the environment.

Surface water samples were analyzed for concentrations of gross beta, tritium, nickel-63 (Ni-63), and gamma-emitting nuclides. Ground water samples were analyzed for concentrations of tritium and gamma-emitting nuclides. Gross beta activities detected were consistent with those detected in previous years. All surface water samples analyzed for Ni-63 were less than the minimum detectable concentration. Tritium detected in downstream surface water was well below reportable limits and consistent with expected levels as a result of permitted liquid discharges.

Fish (commercially and/or recreationally important species) and sediment samples were analyzed for concentrations of Ni-63 and gamma-emitting nuclides. No fission or activation products were detected.

Air particulate samples were analyzed for concentrations of gross beta and gamma-emitting nuclides. No fission or activation products were detected.

High sensitivity iodine-131 (I-131) analyses were performed on weekly air samples. All results were less than the minimum detectable concentration for I-131.

Cow milk samples were analyzed for concentrations of I-131 and gamma-emitting nuclides. All I-131 results were below the minimum detectable activity. No fission or activation products were found.

Food Product samples were analyzed for concentrations of gamma-emitting nuclides. No fission or activation products were detected.

Environmental gamma radiation measurements were performed quarterly using Optically Stimulated Luminescence Dosimeters (OSLD). Beginning in 2012, Exelon changed the type of dosimetry used for the Radiological Environmental Monitoring Program (REMP). Optically Stimulated Luminescent Dosimetry were deployed and Thermoluminescent Dosimetry (TLD) were discontinued. This change may have resulted in a step change in readings, up or down, depending on site characteristics. The relative comparison to control locations remains valid. OSLD technology is different than that used in a TLD but has the same purpose (to measure direct radiation).

Intentionally left blank

II. Introduction

Byron Station, a two-unit PWR station, is located about two miles east of the Rock River and approximately three miles southwest of Byron in Ogle County, Illinois. The reactors are designed to have capacities of 1,268 and 1,241 MW gross, respectively. Unit One loaded fuel in November 1984 and went online February 2, 1985. Unit Two went online January 9, 1987. The station has been designed to keep releases to the environment at levels below those specified in the codes of federal regulations.

This report covers those analyses performed by Teledyne Brown Engineering (TBE) and Landauer on samples collected during the period 1 January 2020 through 31 December 2020.

A. Objectives of the REMP

The objectives of the REMP are to:

1. Provide data on measurable levels of radiation and radioactive materials in the site environs.
2. Evaluate the relationship between quantities of radioactive material released from the plant and resultant radiation doses to individuals from principal pathways of exposure.

B. Implementation of the Objectives

The implementation of the objectives is accomplished by:

1. Identifying significant exposure pathways
2. Establishing baseline radiological data of media within those pathways
3. Continuously monitoring those media before and during Station operation to assess Station radiological effects (if any) on man and the environment

III. Program Description

A. Sample Collection

Samples for the BNGS REMP were collected for Exelon Nuclear by Environmental Inc. (Midwest Labs). This section describes the general collection methods used by Environmental Inc. to obtain environmental samples for the BNGS REMP in 2020. Sample locations and descriptions can be found in Table B–1 and Figures B–1 through B–5, Appendix B.

Aquatic Environment

The aquatic environment was evaluated by performing radiological analyses on samples of surface water, ground water, fish and sediment. Two gallon water samples were collected weekly from two surface water locations (BY-12 and BY-29 [Control location]) and quarterly from six ground water locations (BY-14-1, BY-18-1, BY-32, BY-35, BY-37 and BY-38). All samples were collected in new unused plastic bottles, which were rinsed with source water prior to collection. Fish samples comprising the flesh of silver redhorse, shorthead redhorse, freshwater drum, common carp and channel catfish were collected semiannually at two locations, BY-29 (control) and BY-31. Sediment samples composed of recently deposited substrate were collected at two locations semiannually, BY-12 and BY-34 (control).

Atmospheric Environment

The atmospheric environment was evaluated by performing radiological analyses on samples of air particulate, and airborne iodine. Airborne iodine and particulate samples were collected and analyzed weekly at eight locations (BY-01, BY-04, BY-06, BY-08, BY-21, BY-22, BY-23 and BY-24). The control location was BY-08. Airborne iodine and air particulate samples were obtained at each location, using a vacuum pump with charcoal and glass fiber filters attached. The pumps ran continuously and sampled air at the rate of approximately one cubic foot per minute. The air filters and air iodine samples were replaced weekly and sent to the laboratory for analysis.

Terrestrial Environment

The terrestrial environment was evaluated by performing radiological analyses on samples of milk and food products. Milk samples were collected monthly from January through April and November through December, and biweekly May through October. The control location was BY-26-2 and the indicator location was BY-20-1. All samples were collected in new unused two gallon plastic bottles from the bulk tank at each location, preserved with sodium bisulfite and shipped promptly to the laboratory.

Food products were collected annually in August and September at five locations (BY-Control, BY-Quad 1, BY-Quad 2, BY-Quad 3 and BY-Quad 4). Various types of samples were collected and placed in new unused plastic bags and sent to the laboratory for analysis.

Ambient Gamma Radiation

Beginning in 2012, Exelon changed the type of dosimetry used for the Radiological Environmental Monitoring Program (REMP). Optically Stimulated Luminescent Dosimetry (OSLD) were deployed and Thermoluminescent Dosimetry (TLD) were discontinued. This change may result in a step change in readings, up or down, depending on site characteristics. The relative comparison to control locations remains valid. OSLD technology is different than that used in a TLD but has the same purpose (to measure direct radiation).

In recent years, the industry recognized the need for a standard method of reporting environmental dosimetry results. In 2020, Exelon began assessing facility-related dose in accordance with ANSI N13.37-2014, Environmental Dosimetry – Criteria for System Design and Implementation. This standard is applicable to passive environmental dosimetry systems used to monitor areas surrounding radiological facilities to assess potential facility-related radiation doses and to verify compliance with public dose limits. Such environmental dosimetry systems include dosimeters which accumulate radiation dose and any readout device required to process the dosimeters. Passive dosimeters include optically stimulated luminescence (OSL) dosimeters which are deployed at field locations around a facility and exchanged periodically (e.g., quarterly). Facility-related dose is calculated using a statistical model that uses baseline historical data and accounts for transit and deploy dose. In 2020, none of the Byron Station field locations listed in this report exhibited facility-related dose as calculated in accordance with this standard.

Each location consisted of 2 OSLD sets. The OSLDs were exchanged quarterly and sent to Landauer for analysis. The OSLDs were placed at locations on and around the BNGS Station site as follows:

An inner ring consisting of 16 locations (BY-101, BY-102, BY-103, BY-104, BY-105, BY-106, BY-107, BY-108, BY-109, BY-110, BY-111, BY-112, BY-113, BY-114, BY-115 and BY-116) near and within the site perimeter representing fence post doses (i.e., at locations where the doses will be potentially greater than maximum annual off-site doses) from BNGS releases.

An outer ring consisting of 16 locations (BY-201, BY-202, BY-203, BY-204, BY-205, BY-206, BY-207, BY-208, BY-209, BY-210, BY-211, BY-212, BY-213, BY-214, BY-215 and BY-216) extending to approximately 5 miles from the site designed to measure possible exposures to close-in population.

A special interest set consisting of seven locations (BY-301-1, BY-301-2,

BY-309-1, BY-309-2, BY-309-3, BY-309-4, and BY-314-2) to measure possible exposures from on-site storage facilities.

An other set consisting of seven locations (BY-01, BY-04, BY-06, BY-21, BY-22, BY-23 and BY-24) at locations where air samplers are present.

The balance of one location (BY-08) representing the control area.

The specific OSLD locations were determined by the following criteria:

1. The presence of relatively dense population;
2. Site meteorological data taking into account distance and elevation for each of the sixteen–22 1/2 degree sectors around the site, where estimated annual dose from BNGS, if any, would be most significant;
3. On hills free from local obstructions and within sight of the vents (where practical);
4. And near the closest dwelling to the vents in the prevailing downwind direction if applicable.

Two OSLDs were placed at each location above ground level. The OSLDs were exchanged quarterly and sent to Landauer for analysis.

B. Sample Analysis

This section describes the general analytical methodologies used by TBE to analyze the environmental samples for radioactivity for the BNGS REMP in 2020. The analytical procedures used by the laboratory are listed in Table B-2.

In order to achieve the stated objectives, the current program includes the following analyses:

1. Concentrations of beta emitters in surface water and air particulates
2. Concentrations of gamma emitters in ground and surface water, air particulates, milk, fish, sediment and vegetation
3. Concentrations of tritium in ground and surface water
4. Concentrations of iodine-131 in air and milk
5. Concentrations of nickel-63 in surface water, fish and sediment
6. Ambient gamma radiation levels at various site environs

C. Data Interpretation

The radiological and direct radiation data collected prior to Byron Nuclear Generating Station becoming operational were used as a baseline with which these operational data were compared. For the purpose of this report, Byron Nuclear Generating Station was considered operational at initial criticality. In addition, data were compared to previous years'

operational data for consistency and trending. Several factors were important in the interpretation of the data:

1. Lower Limit of Detection and Minimum Detectable Concentration

The lower limit of detection (LLD) was defined as the smallest concentration of radioactive material in a sample that would yield a net count (above background) that would be detected with only a 5% probability of falsely concluding that a blank observation represents a "real" signal. The LLD was intended as a before-the-fact estimate of a system (including instrumentation, procedure and sample type) and not as an after-the-fact criteria for the presence of activity. All analyses were designed to achieve the required BNGS detection capabilities for environmental sample analysis.

The minimum detectable concentration (MDC) is defined above with the exception that the measurement is an after-the-fact estimate of the presence of activity.

2. Net Activity Calculation and Reporting of Results

Net activity for a sample was calculated by subtracting background activity from the sample activity. Since the REMP measures extremely small changes in radioactivity in the environment, background variations may result in sample activity being lower than the background activity, effecting a negative number. An MDC was reported in all cases where positive activity was not detected.

Gamma spectroscopy results for each type of sample were grouped as follows:

For surface water, ground water, milk and vegetation, twelve nuclides, Mn-54, Co-58, Fe-59, Co-60, Zn-65, Nb-95, Zr-95, I-131, Cs-134, Cs-137, Ba-140 and La-140 were reported.

For fish, sediment, and air particulates, eleven nuclides, Mn-54, Co-58, Fe-59, Co-60, Zn-65, Nb-95, Zr-95, Cs-134, Cs-137, Ba-140 and La-140 were reported.

Means and standard deviations of the results were calculated. The standard deviations represent the variability of measured results for different samples rather than single analysis uncertainty.

D. Program Exceptions

For 2020, the BNGS REMP had a sample recovery rate in excess of 99%. Sample anomalies and missed samples are listed in the tables below:

TABLE D-1 LISTING OF SAMPLE ANOMALIES

Sample Type	Location Code	Collection Date	Reason
AP	BY-01	01/28/20	Filter darker than usual, possibly due to the pump degrading; pump exchanged with 186
AP/AI	BY-21	02/25/20	Timer indicates approximately 4 hrs less than expected for the 7-day collection - power failure
AP/AI	BY-21	03/03/20	Timer indicates approximately 8 hrs less than expected for the 7-day collection due to power fluctuation - changed out 3/5
AP/AI	BY-21	03/10/20	Total run time 124 hrs during 7-day period due to timer failure and power outage caused by heavy winds; 3/17 indicated normal run time of 167.8 hrs
AP/AI	BY-23	03/10/20	Total run time 149 hrs during 7-day period due to power outage caused by heavy winds; next week indicated normal runtime of 167.8 hrs
AP/AI	ALL	03/31/20	Missing approximately 24 hrs due to extensive power failure caused by a tornado
SW	BY-12	04/15/20	1 st Quarter composite > LLD; positive result due to many liquid releases performed in support of B1R23
AP/AI	BY-21	05/05/20	Timer indicates approximately 5 hrs less than expected due to a power failure; pump found not running, was reset and restarted. NOTE: during the 05/12/20 collection, timer indicated 167.9 hrs - normal reading for the collection period
OSLD	BY-309-3	07/01/20	Both OSLD samples found on the ground
AP/AI	BY-01	08/11/20	Lower reading of 149.4 hrs during a 7-day collection due to storms
AP/AI	BY-06	08/11/20	Timer indicates 4.5 hrs less than expected due to power outage caused by storms
AP/AI	BY-24	08/11/20	Lower reading of 149.1 hrs during a 7-day period of collection; power outage at plant due to storms
AP/AI	BY-24	08/18/20	Lower reading of 121.4 hrs during a 7-day collection possibly caused by power outage; timer will be changed during next collection
AP/AI	BY-21	09/29/20	Lower reading of 152.7 hrs during a 7 day collection caused by power outage
AP/AI	BY-21	10/06/21	Lower reading of 158.5. NOTE: timer the week after indicated a normal reading
AP/AI	BY-01	11/17/21	Timer indicated 8 hrs less than expected due to widespread power failure caused by heavy winds. NOTE: during the 11/24 collection, the timer indicated correct hrs.
AP/AI	BY-04	11/17/21	Timer indicated 4.3 hrs less than expected due to widespread power failure caused by heavy winds. NOTE: during the 11/24 collection, the timer indicated correct hrs.
AP/AI	BY-06	11/17/21	Timer indicated 9 hrs less than expected due to widespread power failure caused by heavy winds. NOTE: during the 11/24 collection, the timer indicated correct hrs.

TABLE D-1 LISTING OF SAMPLE ANOMALIES (cont'd)

Sample Type	Location Code	Collection Date	Reason
AP/AI	BY-08	11/17/21	Timer indicated 12 hrs less than expected due to widespread power failure caused by heavy winds. NOTE: during the 11/24 collection, the timer indicated correct hrs.
AP/AI	BY-21	11/17/21	Timer indicated 26 hrs less than expected due to widespread power failure caused by heavy winds. NOTE: during the 11/24 collection, the timer indicated correct hrs.
AP/AI	BY-22	11/17/21	Timer indicated 4.4 hrs less than expected due to widespread power failure caused by heavy winds. NOTE: during the 11/24 collection, the timer indicated correct hrs.
AP/AI	BY-24	11/17/21	Timer indicated 4.3 hrs less than expected due to widespread power failure caused by heavy winds. NOTE: during the 11/24 collection, the timer indicated correct hrs.
AP/AI	BY-21	12/08/20	Lower reading of 109 hrs during a 7-day collection period due to a power outage. NOTE: during the collection of 12/15, the timer reading correct hrs.

TABLE D-2 LISTING OF MISSED SAMPLES

Sample Type	Location Code	Collection Date	Reason
OSLD	BY-104-1 BY-107-1 BY-109-1 BY-206-2 BY-207-2	04/01/20	OSLDs missing in quarterly exchange due to tornado in area
OSLD	BY-207-2	07/20/20	One OS LD missing during exchange
OSLD	BY-216-1 BY-314-2	12/01/20	OSLDs missing in quarterly exchange due to weather
SW	BY-29	12/29/20	Could not collect sample due to frozen river

Each program exception was reviewed to understand the causes of the program exception. Sampling and maintenance errors were reviewed with the personnel involved to prevent recurrence. Occasional equipment breakdowns and power outages were unavoidable.

The overall sample recovery rate indicates that the appropriate procedures and equipment are in place to assure reliable program implementation.

E. Program Changes

There were no program changes in 2020.

IV. Results and Discussion

A. Aquatic Environment

1. Surface Water

Samples were taken weekly and composited monthly at two locations (BY-12 and BY-29). Of these locations only BY-12 located downstream, could be affected by Byron Nuclear Generating Station's effluent releases. The following analyses were performed:

Gross Beta

Samples from both locations were analyzed for concentrations of gross beta (Table C-I.1, Appendix C). The values ranged from 2.5 to 7.7 pCi/L. Concentrations detected were consistent with those detected in previous years (Figure C-1, Appendix C).

Tritium

Quarterly composites of weekly collections were analyzed for tritium activity (Table C-I.2, Appendix C). Tritium was detected in four samples. (Figure C-2, Appendix C). The concentrations ranged from 419 to 4,700 pCi/L. Tritium detected in downstream surface water was well below reportable limits and consistent with expected levels as a result of permitted liquid discharges.

Nickel

Samples from both locations were analyzed for concentration of Ni-63 (Table C-I.3, Appendix C). All results were less than the minimum detectable concentration.

Gamma Spectrometry

Samples from both locations were analyzed for gamma-emitting nuclides (Table C-I.4, Appendix C). No nuclides were detected, and all required LLDs were met.

2. Ground Water

Quarterly grab samples were collected at six locations (BY-14-1, BY-18-1, BY-32, BY-35, BY-37 and BY-38). These locations could be affected by Byron Nuclear Generating Station's effluent releases. The following analyses were performed:

Tritium

Quarterly grab samples from the locations were analyzed for tritium activity (Table C-II.1, Appendix C). No tritium was detected, and the required LLD was met (Figures C-3 through C-7, Appendix C).

Gamma Spectrometry

Samples from all locations were analyzed for gamma-emitting nuclides (Table C–II.2 Appendix C). No nuclides were detected, and all required LLDs were met.

3. Fish

Fish samples comprised of quillback, shorthead redhorse, smallmouth bass, golden redhorse, silver redhorse, and common carp were collected at two locations (BY-29 and BY-31) semiannually. Location BY-31 could be affected by Byron Nuclear Generating Station's effluent releases. The following analyses were performed:

Nickel

The edible portion of fish samples from both locations was analyzed for Ni-63 (Table C–III.1, Appendix C). Nickel-63 was not detected and the required LLD was met.

Gamma Spectrometry

The edible portion of fish samples from both locations was analyzed for gamma-emitting nuclides (Table C–III.1, Appendix C). No nuclides were detected, and all required LLDs were met.

4. Sediment

Aquatic sediment samples were collected at two locations (BY-12 and BY-34) semiannually. BY-12, located downstream, could be affected by Byron Nuclear Generating Station's effluent releases. The following analyses were performed:

Nickel

Sediment samples from both locations were analyzed for Ni-63 (Table C–IV.1, Appendix C). Ni-63 was not detected and the required LLD was met.

Gamma Spectrometry

Sediment samples from both locations were analyzed for gamma-emitting nuclides (Table C–IV.1, Appendix C). No nuclides were detected, and all required LLDs were met.

B. Atmospheric Environment

1. Airborne

a. Air Particulates

Continuous air particulate samples were collected from eight locations on a weekly basis. The eight locations were separated

into three groups: Nearsite samplers within 4 km of the site (BY-21, BY-22, BY-23 and BY-24), Far Field samplers between 4 and 10 km of the site (BY-01, BY-04 and BY-06) and the Control sampler between 10 and 30 km from the site (BY-08). The following analyses were performed:

Gross Beta

Weekly samples were analyzed for concentrations of beta emitters (Table C–V.1 and C–V.2, Appendix C). Detectable gross beta activity was observed at all locations. Comparison of results among the three groups aid in determining the effects, if any, resulting from the operation of BNGS.

The results from the Nearsite locations (Group I) ranged from 5 to $33\text{E}-3$ pCi/m³ with a mean of $16\text{E}-3$ pCi/m³. The results from the Far Field locations (Group II) ranged from 6 to $32\text{E}-3$ pCi/m³ with a mean of $16\text{E}-3$ pCi/m³. The results from the Control location (Group III) ranged from 6 to $34\text{E}-3$ pCi/m³ with a mean of $15\text{E}-3$ pCi/m³. Comparison of the 2020 air particulate data with previous year's data indicate no effects from the operation of BNGS. In addition, a comparison of the weekly mean values for 2020 indicate no notable differences among the three groups. (Figures C–8 through C-12, Appendix C)

Gamma Spectrometry

Weekly samples were composited quarterly and analyzed for gamma-emitting nuclides (Table C–V.3, Appendix C). No nuclides were detected, and all required LLDs were met.

b. Airborne Iodine

Continuous air samples were collected from eight locations (BY-01, BY-04, BY-06, BY-08, BY-21, BY-22, BY-23 and BY-24) and analyzed weekly for I-131 (Table C–VI.1, Appendix C). All results were less than the minimum detectable concentration for I-131.

2. Terrestrial

a. Milk

Samples were collected from two locations (BY-20-1 and BY-26-2) monthly from January to April and November through December, and biweekly May through October. The following analyses were performed:

Iodine-131

Milk samples from all locations were analyzed for concentrations of I-131 (Table C–VII.1, Appendix C). No nuclides were detected, and all required LLDs were met.

Gamma Spectrometry

Each milk sample was analyzed for concentrations of gamma-emitting nuclides (Table C–VII.2, Appendix C). No nuclides were detected, and all required LLDs were met.

b. Vegetation

Vegetation samples were collected at five locations (BY-Control, BY-Quad 1, BY-Quad 2, BY-Quad 3 and BY-Quad 4). Four locations (BY-Quad 1, BY-Quad 2, BY-Quad 3 and BY-Quad 4) could be affected by Byron Nuclear Generating Station's effluent releases. The following analysis was performed:

Gamma Spectrometry

Samples from all locations were analyzed for gamma-emitting nuclides (Table C–VIII.1, Appendix C). No nuclides were detected, and all required LLDs were met.

C. Ambient Gamma Radiation

Ambient gamma radiation levels were measured utilizing OSLDs. Ninety-one OSLD locations were established around the site. Results of OSLD measurements are listed in Tables C–IX.1 to C–IX.3, Appendix C.

All OSLD measurements were below 28 mR/standard quarter, with a range of 15 to 27 mR/standard quarter. A comparison of the Inner Ring, Outer Ring, Special Interest, Other and Control Location data indicate that the ambient gamma radiation levels were comparable among the groups.

D. Land Use Survey

A Land Use Survey conducted during September 2020 around the Byron Nuclear Generating Station (BNGS) was performed by Environmental Inc. (Midwest Labs) for Exelon Nuclear to comply with the Byron Nuclear Generating Station's Offsite Dose Calculation Manual. The purpose of the survey was to document the nearest resident, livestock, and milk producing animals in each of the sixteen 22 ½ degree sectors. The results of this survey are summarized as follows:

Distance in Miles from the BNGS Vent Stacks				
Sector		Residence Miles	Livestock Miles	Milk Farm Miles
A	N	1.2	5.9	-
B	NNE	1.6	6.2	-
C	NE	1.1	2.0	-
D	ENE	1.4	3.7	-
E	E	1.0	4.2	-
F	ESE	1.5	1.5	-
G	SE	1.7	3.5	-
H	SSE	0.7	3.3	-
J	S	0.6	0.7	-
K	SSW	0.7	0.7	-
L	SW	0.8	2.0	-
M	WSW ^(a)	1.6	0.8	4.5
N	W	1.8	3.2	-
P	WNW	1.6	1.6	11.5
Q	NW	0.8	1.5	-
R	NNW	0.9	1.4	-

^(a) Denotes the nearest industrial facility located at 1.5 miles

E. Errata Data

Errata data in Appendix C includes erroneous sampling locations for vegetation and for gaseous release volume calculations.

F. Summary of Results – Inter-Laboratory Comparison Program

The TBE Laboratory analyzed Performance Evaluation (PE) samples of air particulate, air iodine (charcoal), milk, soil, vegetation and water (including fish) matrices (Appendix D). The PE sample matrices were chosen based on the types of samples submitted to the primary laboratory for analysis. The selected parameters for the PE samples are based on the appropriate matrices, methodologies and geometries, which include geometries that are comparable. The PE samples, supplied by Analytics Inc., Environmental Resource Associates (ERA) and DOE's Mixed Analyte Performance Program (MAPEP) were evaluated against the following pre-set acceptance criteria:

1. Analytics Evaluation Criteria

Analytics' evaluation report provides a ratio of laboratory results and Analytics' known value. Since flag values are not assigned by Analytics, TBE-ES evaluates the reported ratios based on internal QC requirements, which are based on the DOE MAPEP criteria.

2. ERA Evaluation Criteria

ERA's evaluation report provides an acceptance range for control and

warning limits with associated flag values. ERA's acceptance limits are established per the USEPA, NELAC, state specific PT program requirements or ERA's SOP for the Generation of Performance Acceptance Limits, as applicable. The acceptance limits are either determined by a regression equation specific to each analyte or a fixed percentage limit promulgated under the appropriate regulatory document.

3. DOE Evaluation Criteria

MAPEP's evaluation report provides an acceptance range with associated flag values. MAPEP defines three levels of performance:

- Acceptable (flag = "A") - result within $\pm 20\%$ of the reference value
- Acceptable with Warning (flag = "W") - result falls in the $\pm 20\%$ to $\pm 30\%$ of the reference value
- Not Acceptable (flag = "N") - bias is greater than 30% of the reference value

Note: The Department of Energy (DOE) Mixed Analyte Performance Evaluation Program (MAPEP) samples are created to mimic conditions found at DOE sites which do not resemble typical environmental samples obtained at commercial nuclear power facilities.

For the TBE laboratory, 126 out of 133 analyses performed met the specified acceptance criteria. Ten analyses did not meet the specified acceptance criteria for the following reasons and were addressed through the TBE Corrective Action Program. A summary is found below:

1. The MAPEP February 2020 AP U-233/234 and U-238 results were evaluated as *Not Acceptable*. The reported value for U-233/234 was 0.0416 ± 0.0102 Bq/sample and the known result was 0.075 Bq/sample (acceptance range 0.053 - 0.098). The reported value for U-238 was 0.0388 ± 0.00991 Bq/sample and the known result was 0.078 Bq/sample (acceptance range 0.055 - 0.101). This sample was run as the workgroup duplicate and had RPD's of 10.4% (U-234) and 11.7% (U-238). After the known results were obtained, the sample was relogged. The filter was completely digested with tracer added originally; the R1 results were almost identical. It was concluded that the recorded tracer amount was actually double, causing the results to be skewed. Lab worksheets have been modified to verify actual tracer amount vs. LIMS data. TBE changed vendors for this cross-check to ERA MRAD during the 2nd half of 2020. Results were acceptable at 97.8% for U-234 and 106% for U-238. (NCR 20-13)

2. The Analytics September 2020 milk Sr-89 result was evaluated as *Not Acceptable*. The reported value was 62.8 pCi/L and the known result was 95.4 (66%). All QC data was reviewed and there were no anomalies. This was the first failure for milk Sr-89 since 2013 and there have only been 3 upper/lower boundary warnings since that time. It is believed that there may have been some Sr-89 loss during sample prep. The December 2020 result was at 92% of the known. (NCR 20-19)
3. The ERA October 2020 water I-131 result was evaluated as *Not Acceptable*. The reported value was 22.9 pCi/L and the known result was 28.2 (acceptance range 23.5 - 33.1). The reported result was 81% of the known, which passes TBE QC criteria. This was the first failure for water I-131. (NCR 20-17)
4. The ERA October 2020 water Gross Alpha and Gross Beta results were evaluated as *Not Acceptable*. The reported/acceptable values and ranges are as follows:

	<u>Reported</u>	<u>Known</u>	<u>Range</u>
Gross Alpha	40.0	26.2	13.3 - 34.7
Gross Beta	47.5	69.1	48.0 - 76.0

All QC data was reviewed with no anomalies and a cause for failure could not be determined. This was the first failure for water Gross Beta. A Quick Response follow-up cross-check was analyzed as soon as possible with acceptable results at 96.8% for Gross Alpha and 102% for Gross Beta. (NCR 20-13)

5. The MAPEP August 2020 soil Ni-63 result was evaluated as *Not Acceptable*. The reported value was 438 ± 21.1 Bq/kg and the known result was 980 Bq/kg (acceptance range 686 - 1274). It is believed that some Ni-63 loss occurred during the sample prep step. (NCR 20-20)

The Inter-Laboratory Comparison Program provides evidence of “in control” counting systems and methods, and that the laboratories are producing accurate and reliable data.

APPENDIX A

RADIOLOGICAL ENVIRONMENTAL MONITORING REPORT SUMMARY

Intentionally left blank

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR
BYRON NUCLEAR GENERATING STATION, 2020**

NAME OF FACILITY:		BYRON NUCLEAR GENERATING STATION		DOCKET NUMBER: 50-454 & 50-455			
LOCATION OF FACILITY:		BYRON, IL		REPORTING PERIOD: 2020			
MEDIUM OR PATHWAY SAMPLED (Unit of Measurement)	TYPES OF ANALYSIS PERFORMED	NUMBER OF ANALYSES PERFORMED	REQUIRED LOWER LIMIT OF DETECTION (LLD)	INDICATOR		LOCATION WITH HIGHEST ANNUAL MEAN (M) STATION # NAME	NUMBER OF NONROUTINE REPORTED MEASUREMENTS
				LOCATIONS MEAN (M) (F) RANGE	CONTROL LOCATION MEAN (M) (F) RANGE		
SURFACE WATER (PC/LITER)		24	4	4.9 (11/12)	5 (12/12)	BY-29 CONTROL	0
GR-B				3.2 - 7.7	2.5 - 6.8	BYRON - UPSTREAM 3.0 MILES N OF SITE	
H-3		8	200	2037 (4/4)	2037 (4/4)	BY-12 INDICATOR	0
NI-63		24	30	419 - 4700	419 - 4700	OREGON POOL OF ROCK RIVER - DOWNSTREAM 4.5 MILES SSW OF SITE	0
GAMMA		24		<LLD	<LLD		0
	MN-54		15	<LLD	<LLD		0
	CO-58		15	<LLD	<LLD		0
	FE-59		30	<LLD	<LLD		0
	CO-60		15	<LLD	<LLD		0
	ZN-65		30	<LLD	<LLD		0
	NB-95		15	<LLD	<LLD		0
	ZR-95		30	<LLD	<LLD		0
	I-131		15	<LLD	<LLD		0
	CS-134		15	<LLD	<LLD		0
	CS-137		18	<LLD	<LLD		0
	BA-140		60	<LLD	<LLD		0
	LA-140		15	<LLD	<LLD		0
GROUND WATER (PC/LITER)		24	200	<LLD	NA		0
H-3							
GAMMA		24		<LLD	NA		0
	MN-54		15	<LLD	NA		0
	CO-58		15	<LLD	NA		0
	FE-59		30	<LLD	NA		0
	CO-60		15	<LLD	NA		0
	ZN-65		30	<LLD	NA		0
	NB-95		15	<LLD	NA		0
	ZR-95		30	<LLD	NA		0
	I-131		15	<LLD	NA		0
	CS-134		15	<LLD	NA		0
	CS-137		18	<LLD	NA		0
	BA-140		60	<LLD	NA		0
	LA-140		15	<LLD	NA		0

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR
BYRON NUCLEAR GENERATING STATION, 2020**

NAME OF FACILITY:		BYRON NUCLEAR GENERATING STATION		DOCKET NUMBER: 50-454 & 50-455		REPORTING PERIOD: 2020					
LOCATION OF FACILITY:		BYRON, IL									
MEDIUM OR PATHWAY SAMPLED (Unit of Measurement)	TYPES OF ANALYSIS PERFORMED	NUMBER OF ANALYSES PERFORMED	REQUIRED LOWER LIMIT OF DETECTION (LLD)	INDICATOR LOCATIONS MEAN (M) (F) RANGE	CONTROL LOCATION MEAN (M) (F) RANGE	LOCATION WITH HIGHEST ANNUAL MEAN (M) MEAN (M) (F) RANGE	STATION # NAME	DISTANCE AND DIRECTION	NUMBER OF NONROUTINE REPORTED MEASUREMENTS		
FISH	Ni-63	8	260	<LLD	<LLD	-			0		
(PC/LITER)	GAMMA	8									
	MN-54		130	<LLD	<LLD	-			0		
	CO-58		130	<LLD	<LLD	-			0		
	FE-59		260	<LLD	<LLD	-			0		
	CO-60		130	<LLD	<LLD	-			0		
	ZN-65		260	<LLD	<LLD	-			0		
	NB-95		NA	<LLD	<LLD	-			0		
	ZR-95		NA	<LLD	<LLD	-			0		
	CS-134		130	<LLD	<LLD	-			0		
	CS-137		150	<LLD	<LLD	-			0		
	BA-140		NA	<LLD	<LLD	-			0		
	LA-140		NA	<LLD	<LLD	-			0		
SEDIMENT	Ni-63	4	260	<LLD	<LLD	-			0		
(PC/KG DRY)	GAMMA	4									
	MN-54		NA	<LLD	<LLD	-			0		
	CO-58		NA	<LLD	<LLD	-			0		
	FE-59		NA	<LLD	<LLD	-			0		
	CO-60		NA	<LLD	<LLD	-			0		
	ZN-65		NA	<LLD	<LLD	-			0		
	NB-95		NA	<LLD	<LLD	-			0		
	ZR-95		NA	<LLD	<LLD	-			0		
	CS-134		150	<LLD	<LLD	-			0		
	CS-137		180	<LLD	<LLD	-			0		
	BA-140		NA	<LLD	<LLD	-			0		
	LA-140		NA	<LLD	<LLD	-			0		
AIR PARTICULATE	GR-B	416	10	16 (363/364)	15 (52/52)	17 (52/52)	BY-06 INDICATOR OREGON	4.7 MILES SSW OF SITE	0		
(E-3 PC/CUMETER)	GAMMA	32		5 - 33	6 - 34	9 - 32					
	MN-54		NA	<LLD	<LLD	-			0		
	CO-58		NA	<LLD	<LLD	-			0		
	FE-59		NA	<LLD	<LLD	-			0		
	CO-60		NA	<LLD	<LLD	-			0		
	ZN-65		NA	<LLD	<LLD	-			0		
	NB-95		NA	<LLD	<LLD	-			0		
	ZR-95		NA	<LLD	<LLD	-			0		
	CS-134		15	<LLD	<LLD	-			0		
	CS-137		18	<LLD	<LLD	-			0		
	BA-140		NA	<LLD	<LLD	-			0		
	LA-140		NA	<LLD	<LLD	-			0		

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR
BYRON NUCLEAR GENERATING STATION, 2020**

NAME OF FACILITY: BYRON NUCLEAR GENERATING STATION BYRON, IL		DOCKET NUMBER: 50-454 & 50-455		REPORTING PERIOD: 2020				
MEDIUM OR PATHWAY SAMPLED (Unit of Measurement)	TYPES OF ANALYSIS PERFORMED	NUMBER OF ANALYSES PERFORMED	REQUIRED LOWER LIMIT OF DETECTION (LLD)	INDICATOR LOCATIONS MEAN (M) (F) RANGE	CONTROL LOCATION MEAN (M) (F) RANGE	LOCATION WITH HIGHEST ANNUAL MEAN (M) MEAN (M) (F) RANGE	STATION # NAME DISTANCE AND DIRECTION	NUMBER OF NONROUTINE REPORTED MEASUREMENTS
AIR IODINE (E-3 PCI/CU.METER)	GAMMA I-131 (GEL)	416	70	<LLD	<LLD	-		0
MILK (PCI/LITER)	I-131 (LOW LVL)	38	1	<LLD	<LLD	-		0
	GAMMA	38	NA	<LLD	<LLD	-		0
	MN-54		NA	<LLD	<LLD	-		0
	CO-58		NA	<LLD	<LLD	-		0
	FE-59		NA	<LLD	<LLD	-		0
	CO-60		NA	<LLD	<LLD	-		0
	ZN-65		NA	<LLD	<LLD	-		0
	NB-95		NA	<LLD	<LLD	-		0
	ZR-95		NA	<LLD	<LLD	-		0
	CS-134		15	<LLD	<LLD	-		0
	CS-137		18	<LLD	<LLD	-		0
	BA-140		60	<LLD	<LLD	-		0
	LA-140		15	<LLD	<LLD	-		0
VEGETATION (PCI/KG WET)	GAMMA	10	NA	<LLD	<LLD	-		0
	MN-54		NA	<LLD	<LLD	-		0
	CO-58		NA	<LLD	<LLD	-		0
	FE-59		NA	<LLD	<LLD	-		0
	CO-60		NA	<LLD	<LLD	-		0
	ZN-65		NA	<LLD	<LLD	-		0
	NB-95		NA	<LLD	<LLD	-		0
	ZR-95		NA	<LLD	<LLD	-		0
	I-131		60	<LLD	<LLD	-		0
	CS-134		60	<LLD	<LLD	-		0
	CS-137		80	<LLD	<LLD	-		0
	BA-140		NA	<LLD	<LLD	-		0
	LA-140		NA	<LLD	<LLD	-		0
DIRECT RADIATION (MILLIREM/QTR.)	OSLD-QUARTERLY	332	NA	21.7 (328/328)	17.9 (4/4)	25.1 (4/4)	BY-216-1 INDICATOR	0
				15 - 26	17 - 19	23 - 27	4.6 MILES NNW	

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

Intentionally left blank

APPENDIX B

LOCATION DESIGNATION, DISTANCE & DIRECTION, AND SAMPLE COLLECTION & ANALYTICAL METHODS

Intentionally Left Blank

TABLE B-1: Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Byron Nuclear Generating Station, 2020

Location	Location Description	Distance & Direction From Site
A. <u>Surface Water</u>		
BY-12	Oregon Pool of Rock River, Downstream	4.5 miles SSW
BY-29	Byron, Upstream (control)	3.0 miles N
B. <u>Ground/Well Water</u>		
BY-14-1	3200 North German Church Road	1.0 miles SSE
BY-18-1	Calhoun	0.7 miles SSW
BY-32	Krueger Well	1.9 miles W
BY-35	Vancko Well	1.9 miles WNW
BY-37	Cavage Well	2.0 miles WNW
BY-38	Steve Storz Well	2.0 miles WNW
C. <u>Milk</u>		
BY-20-1	Ron Snodgrass Farm	4.8 miles WSW
BY-26-2	Joseph Akins Farm (control)	12.2 miles WNW
D. <u>Air Particulates / Air Iodine</u>		
BY-01	Byron	3.0 miles N
BY-04	Paynes Point	5.0 miles SE
BY-06	Oregon	4.7 miles SSW
BY-08	Leaf River (control)	7.0 miles WNW
BY-21	Byron Nearsite North	0.3 miles N
BY-22	Byron Nearsite Southeast	0.4 miles SE
BY-23	Byron Nearsite South	0.6 miles S
BY-24	Byron Nearsite Southwest	0.7 miles SW
E. <u>Fish</u>		
BY-29	Byron, Upstream (control)	3.0 miles N
BY-31	Byron, Discharge	2.6 miles WNW
F. <u>Sediment</u>		
BY-12	Oregon Pool of Rock River, Downstream	4.6 miles SSW
BY-34	Rock River, Upstream of Discharge (control)	2.6 miles WNW
G. <u>Vegetation</u>		
Quadrant 1	5186 Cox Road, Stillman Valley	4.6 miles E
Quadrant 2	6970 Linden Wood Road, Stillman Valley	4.9 miles SE
Quadrant 3	555 Park Rd, Oregon	3.7 miles SW
Quadrant 4	4615 N Razorville Road., Byron	2.7 miles SW
Control	2327 Route 251, Rochelle	20.7 miles SE

TABLE B-1: Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Byron Nuclear Generating Station, 2020

Location	Location Description	Distance & Direction From Site
<u>H. Environmental Dosimetry - OSLD</u>		
<u>Inner Ring</u>		
BY-101-1 and -2		0.3 miles N
BY-102-1		1.0 miles NNE
BY-102-2		1.0 miles NNE
BY-103-1 and -2		1.7 miles NE
BY-103-3		0.4 miles NE
BY-104-1 and -2		1.4 miles ENE
BY-104-3		0.3 miles ENE
BY-105-1 and -2		1.3 miles E
BY-106-1 and -2		1.4 miles ESE
BY-107-1 and -2		1.4 miles SE
BY-107-3		0.4 miles SE
BY-108-1		0.7 miles SSE
BY-108-2		0.6 miles SSE
BY-109-1 and -2		0.6 miles S
BY-110-1 and -2		0.7 miles SSW
BY-111-3		0.8 miles SW
BY-111-4		0.9 miles SW
BY-112-3 and -4		0.8 miles WSW
BY-113-1 and -2		0.7 miles W
BY-114-1 and -2		0.8 miles WNW
BY-115-1 and -2		1.0 miles NW
BY-116-1 and -2		1.4 miles NNW
BY-116-3		0.9 miles NNW
<u>Outer Ring</u>		
BY-201-3		4.4 miles N
BY-201-4		4.4 miles N
BY-202-1		4.4 miles NNE
BY-202-2		4.8 miles NNE
BY-203-1		4.8 miles NE
BY-203-2		4.7 miles NE
BY-204-1		4.1 miles ENE
BY-204-2		4.0 miles ENE
BY-205-1 and -2		3.8 miles E
BY-206-1		4.0 miles ESE
BY-206-2		4.3 miles ESE
BY-207-1		4.2 miles SE
BY-207-2		3.9 miles SE
BY-208-1		4.0 miles SSE
BY-208-2		3.8 miles SSE
BY-209-1 and -4		4.0 miles S
BY-210-3 and -4		3.9 miles SSW
BY-211-1 and -4		4.9 miles SW
BY-212-1 and -4		4.7 miles WSW
BY-213-1		4.7 miles W
BY-213-4		4.7 miles W
BY-214-1		4.7 miles WNW
BY-214-4		4.6 miles WNW
BY-215-1		4.2 miles NW
BY-215-4		4.2 miles NW
BY-216-1		4.5 miles NNW
BY-216-2		4.7 miles NNW

TABLE B-1: Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Byron Nuclear Generating Station, 2020

Location	Location Description	Distance & Direction From Site
<u>Special Interest</u>		
BY-301-1		0.3 miles N
BY-301-2		0.2 miles N
BY-309-1		0.3 miles S
BY-309-2		0.4 miles S
BY-309-3		0.4 miles S
BY-309-4		0.4 miles SSW
BY-314-2		0.3 miles WNW
<u>Other</u>		
BY-01-1 and -2		3.0 miles N
BY-04-1 and -2		5.0 miles SE
BY-06-1 and -2		4.7 miles SSW
BY-21-1 and -2		0.3 miles N
BY-22-1 and -2		0.4 miles SE
BY-23-1 and -2		0.6 miles S
BY-24-1 and -2		0.7 miles SW
<u>Control</u>		
BY-08-1 and -2		7.0 miles WNW

TABLE B-2: Radiological Environmental Monitoring Program – Summary of Sample Collection and Analytical Methods, Byron Nuclear Generating Station, 2020

Sample Medium	Analysis	Sampling Method	Analytical Procedure Number
Surface Water	Gamma Spectroscopy	Monthly composite from weekly grab samples.	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis
Surface Water	Gross Beta	Monthly composite from weekly grab samples.	TBE, TBE-2008 Gross Alpha and/or Gross Beta Activity in Various Matrices
Surface Water	Nickel-63	Monthly composite from weekly grab samples.	TBE, TBE-2013 Radionickel Activity in Various Matrices
Surface Water	Tritium	Quarterly composite from weekly grab samples.	TBE, TBE-2011 Tritium Analysis in Drinking Water by Liquid Scintillation
Ground Water	Gamma Spectroscopy	Quarterly grab samples.	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis
Ground Water	Tritium	Quarterly grab samples.	TBE, TBE-2011 Tritium Analysis in Drinking Water by Liquid Scintillation
Fish	Gamma Spectroscopy	Semi-annual samples collected via electroshocking or other techniques	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis
Fish	Nickel-63	Semi-annual samples collected via electroshocking or other techniques	TBE, TBE-2013 Radionickel Activity in Various Matrices
Sediment	Gamma Spectroscopy	Semi-annual grab samples	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis
Sediment	Nickel-63	Semi-annual grab samples	TBE, TBE-2013 Radionickel Activity in Various Matrices
Air Particulates	Gross Beta	One-week composite of continuous air sampling through glass fiber filter paper	TBE, TBE-2008 Gross Alpha and/or Gross Beta Activity in Various Matrices
Air Particulates	Gamma Spectroscopy	Quarterly composite of continuous air sampling through glass fiber filter paper	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis
Air Iodine	Gamma Spectroscopy	One-week composite of continuous air sampling through charcoal filter	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis
Milk	I-131	Bi-weekly grab sample when cows are on pasture. Monthly all other times	TBE, TBE-2012 Radioiodine in Various Matrices
Milk	Gamma Spectroscopy	Bi-weekly grab sample when cows are on pasture. Monthly all other times	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis
Vegetation	Gamma Spectroscopy	Annual grab samples.	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis
OSLD	Optically Stimulated Luminescence Dosimetry	Quarterly OSLDs comprised of two Al ₂ O ₃ :C Landauer Incorporated elements.	Landauer Incorporated




Figure B-1
 Inner Ring and Special Interest OSLD Locations of the
 Byron Nuclear Generating Station, 2020




Figure B-3
 Onsite Air Sampling Locations of the
 Byron Nuclear Generating Station, 2020




Figure B-4
 Offsite Air Sampling Locations of the
 Byron Nuclear Generating Station, 2020




Figure B-5
 Ingestion and Waterborne Exposure Pathway Sampling Locations
 of the Byron Nuclear Generating Station, 2020

Intentionally left blank

APPENDIX C

DATA TABLES AND FIGURES

Intentionally left blank

Table C-I.1

**CONCENTRATIONS OF GROSS BETA IN SURFACE WATER SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020**
RESULTS IN UNITS OF PCI/LITER \pm 2 SIGMA

COLLECTION PERIOD	BY-12	BY-29
01/07/20 - 01/28/20	5.4 \pm 2.2	3.4 \pm 2.0
02/04/20 - 02/25/20	4.0 \pm 2.1	5.4 \pm 2.2
03/03/20 - 03/31/20	7.7 \pm 2.5	4.7 \pm 2.2
04/07/20 - 04/28/20	4.8 \pm 2.1	5.3 \pm 2.0
05/05/20 - 05/26/20	5.0 \pm 2.7	6.8 \pm 2.9
06/02/20 - 06/30/20	3.6 \pm 1.8	2.5 \pm 1.7
07/07/20 - 07/28/20	4.9 \pm 2.1	5.2 \pm 2.1
08/04/20 - 08/25/20	< 4.0	4.9 \pm 2.8
09/01/20 - 09/29/20	4.0 \pm 2.2	6.1 \pm 2.4
10/06/20 - 10/27/20	3.2 \pm 2.0	3.5 \pm 2.0
11/03/20 - 11/24/20	7.1 \pm 2.4	6.5 \pm 2.2
12/01/20 - 12/22/20	4.2 \pm 2.2	5.2 \pm 2.3
<i>MEAN \pm 2 STD DEV</i>	4.9 \pm 2.8	5.0 \pm 2.6

Table C-I.2

**CONCENTRATIONS OF TRITIUM IN SURFACE WATER SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020**
RESULTS IN UNITS OF PCI/LITER \pm 2 SIGMA

COLLECTION PERIOD	BY-12	BY-29
01/07/20 - 03/31/20	4700 \pm 537	< 197
04/07/20 - 06/30/20	960 \pm 170	< 185
07/07/20 - 09/29/20	2070 \pm 275	< 189
10/06/20 - 12/22/20	419 \pm 131	< 184
<i>MEAN \pm 2 STD DEV</i>	2037 \pm 3807	-

Table C-I.3

**CONCENTRATIONS OF NI-63 IN SURFACE WATER SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020**
RESULTS IN UNITS OF PCI/LITER \pm 2 SIGMA

COLLECTION PERIOD	BY-12	BY-29
01/07/20 - 01/28/20	< 21	< 22
02/04/20 - 02/25/20	< 23	< 23
03/03/20 - 03/31/20	< 22	< 22
04/07/20 - 04/28/20	< 18	< 18
05/05/20 - 05/26/20	< 25	< 28
06/02/20 - 06/30/20	< 28	< 24
07/07/20 - 07/28/20	< 20	< 19
08/04/20 - 08/25/20	< 28	< 26
09/01/20 - 09/29/20	< 17	< 17
10/06/20 - 10/27/20	< 25	< 24
11/03/20 - 11/24/20	< 21	< 20
12/01/20 - 12/22/20	< 21	< 20
<i>MEAN</i>	-	-

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

Table C-I.4

**CONCENTRATIONS OF GAMMA EMITTERS IN SURFACE WATER SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020**
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

SITE	COLLECTION PERIOD	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	I-131	Cs-134	Cs-137	Ba-140	La-140
BY-12	01/07/20 - 01/28/20	< 5	< 5	< 11	< 5	< 11	< 6	< 9	< 14	< 5	< 5	< 32	< 12
	02/04/20 - 02/25/20	< 3	< 4	< 10	< 5	< 9	< 5	< 8	< 14	< 5	< 5	< 32	< 10
	03/03/20 - 03/31/20	< 4	< 4	< 9	< 4	< 10	< 5	< 8	< 15	< 5	< 4	< 34	< 10
	04/07/20 - 04/28/20	< 4	< 5	< 10	< 5	< 10	< 5	< 8	< 12	< 4	< 5	< 29	< 9
	05/05/20 - 05/26/20	< 5	< 5	< 11	< 6	< 9	< 6	< 8	< 13	< 6	< 6	< 37	< 8
	06/02/20 - 06/30/20	< 2	< 2	< 4	< 2	< 3	< 2	< 3	< 11	< 2	< 2	< 19	< 6
	07/07/20 - 07/28/20	< 2	< 3	< 6	< 3	< 5	< 3	< 4	< 7	< 3	< 3	< 17	< 6
	08/04/20 - 08/25/20	< 2	< 2	< 4	< 2	< 3	< 2	< 4	< 10	< 2	< 2	< 18	< 6
	09/01/20 - 09/29/20	< 3	< 4	< 8	< 4	< 6	< 4	< 6	< 14	< 4	< 4	< 29	< 8
	10/06/20 - 10/27/20	< 2	< 2	< 5	< 2	< 4	< 2	< 4	< 9	< 2	< 2	< 17	< 6
	11/03/20 - 11/24/20	< 2	< 2	< 4	< 2	< 4	< 2	< 4	< 8	< 2	< 2	< 16	< 5
	12/01/20 - 12/29/20	< 2	< 2	< 5	< 2	< 4	< 2	< 4	< 11	< 2	< 2	< 18	< 7
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-29	01/07/20 - 01/28/20	< 4	< 5	< 9	< 4	< 9	< 5	< 7	< 13	< 5	< 4	< 29	< 10
	02/04/20 - 02/25/20	< 4	< 5	< 9	< 5	< 10	< 5	< 8	< 13	< 4	< 5	< 31	< 9
	03/03/20 - 03/31/20	< 3	< 3	< 6	< 2	< 5	< 3	< 5	< 10	< 3	< 3	< 22	< 6
	04/07/20 - 04/28/20	< 4	< 4	< 8	< 4	< 6	< 3	< 6	< 10	< 4	< 3	< 22	< 8
	05/05/20 - 05/26/20	< 4	< 5	< 10	< 5	< 9	< 4	< 8	< 14	< 5	< 5	< 29	< 9
	06/02/20 - 06/30/20	< 2	< 2	< 4	< 2	< 3	< 2	< 3	< 10	< 2	< 2	< 17	< 5
	07/07/20 - 07/28/20	< 3	< 3	< 6	< 3	< 5	< 3	< 5	< 8	< 3	< 3	< 18	< 5
	08/04/20 - 08/25/20	< 2	< 2	< 5	< 2	< 4	< 2	< 4	< 11	< 2	< 2	< 19	< 7
	09/01/20 - 09/29/20	< 3	< 4	< 8	< 4	< 6	< 4	< 6	< 14	< 3	< 3	< 28	< 9
	10/06/20 - 10/27/20	< 2	< 2	< 5	< 2	< 4	< 2	< 4	< 8	< 2	< 2	< 17	< 6
	11/03/20 - 11/24/20	< 2	< 2	< 4	< 2	< 3	< 2	< 3	< 7	< 2	< 2	< 14	< 5
	12/01/20 - 12/22/20	< 2	< 2	< 5	< 2	< 4	< 2	< 4	< 13	< 2	< 2	< 22	< 7
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-

Table C-II.1

**CONCENTRATIONS OF TRITIUM IN GROUND WATER SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA**

COLLECTION PERIOD	BY-14-1	BY-18-1	BY-32	BY-35	BY-37	BY-38
01/14/20 - 01/14/20	< 190	< 188	< 189	< 190	< 190	< 192
04/14/20 - 04/14/20	< 185	< 181	< 185	< 176	< 175	< 179
07/14/20 - 07/14/20	< 181	< 179	< 177	< 176	< 178	< 179
10/13/20 - 10/13/20	< 186	< 184	< 184	< 181	< 181	< 182
<i>MEAN</i>	-	-	-	-	-	-

Table C-II.2

**CONCENTRATIONS OF GAMMA EMITTERS IN GROUND WATER SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020**
RESULTS IN UNITS OF PC/LITER ± 2 SIGMA

SITE	COLLECTION PERIOD	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	I-131	Cs-134	Cs-137	Ba-140	La-140
BY-14-1	01/14/20 - 01/14/20	< 7	< 8	< 15	< 9	< 14	< 10	< 13	< 10	< 8	< 8	< 31	< 11
	04/14/20 - 04/14/20	< 7	< 6	< 16	< 9	< 17	< 9	< 12	< 9	< 8	< 9	< 32	< 9
	07/14/20 - 07/14/20	< 5	< 6	< 13	< 7	< 15	< 8	< 12	< 11	< 8	< 6	< 26	< 9
	10/13/20 - 10/13/20	< 3	< 3	< 7	< 4	< 7	< 4	< 6	< 4	< 4	< 4	< 15	< 5
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-18-1	01/14/20 - 01/14/20	< 5	< 5	< 11	< 7	< 12	< 7	< 12	< 9	< 5	< 5	< 29	< 11
	04/14/20 - 04/14/20	< 6	< 5	< 14	< 7	< 16	< 9	< 12	< 8	< 7	< 7	< 29	< 9
	07/14/20 - 07/14/20	< 9	< 8	< 18	< 6	< 11	< 7	< 11	< 11	< 9	< 8	< 38	< 5
	10/13/20 - 10/13/20	< 4	< 4	< 6	< 4	< 7	< 4	< 6	< 5	< 4	< 4	< 16	< 5
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-32	01/14/20 - 01/14/20	< 6	< 5	< 10	< 6	< 13	< 7	< 9	< 5	< 6	< 6	< 26	< 5
	04/14/20 - 04/14/20	< 7	< 8	< 17	< 7	< 17	< 8	< 11	< 9	< 10	< 11	< 33	< 10
	07/14/20 - 07/14/20	< 6	< 6	< 9	< 6	< 13	< 7	< 11	< 9	< 6	< 7	< 29	< 9
	10/13/20 - 10/13/20	< 3	< 4	< 7	< 4	< 7	< 4	< 6	< 4	< 4	< 4	< 13	< 5
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-35	01/14/20 - 01/14/20	< 5	< 7	< 13	< 6	< 14	< 5	< 12	< 8	< 7	< 6	< 25	< 6
	04/14/20 - 04/14/20	< 5	< 4	< 11	< 8	< 12	< 6	< 12	< 8	< 8	< 6	< 26	< 5
	07/14/20 - 07/14/20	< 7	< 7	< 13	< 8	< 11	< 8	< 12	< 12	< 7	< 8	< 33	< 7
	10/13/20 - 10/13/20	< 3	< 3	< 6	< 3	< 6	< 3	< 5	< 4	< 4	< 3	< 11	< 4
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-37	01/14/20 - 01/14/20	< 7	< 6	< 10	< 6	< 14	< 7	< 11	< 9	< 9	< 7	< 27	< 5
	04/14/20 - 04/14/20	< 6	< 6	< 14	< 7	< 15	< 8	< 13	< 6	< 6	< 8	< 28	< 11
	07/14/20 - 07/14/20	< 7	< 6	< 13	< 9	< 14	< 7	< 10	< 11	< 8	< 6	< 32	< 10
	10/13/20 - 10/13/20	< 3	< 3	< 6	< 3	< 6	< 3	< 6	< 4	< 3	< 4	< 12	< 4
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-38	01/14/20 - 01/14/20	< 7	< 6	< 15	< 7	< 15	< 8	< 12	< 8	< 7	< 5	< 28	< 9
	04/14/20 - 04/14/20	< 5	< 6	< 13	< 6	< 13	< 7	< 14	< 7	< 6	< 8	< 23	< 8
	07/14/20 - 07/14/20	< 7	< 7	< 13	< 5	< 17	< 8	< 13	< 10	< 8	< 7	< 29	< 9
	10/13/20 - 10/13/20	< 3	< 3	< 6	< 3	< 7	< 3	< 6	< 4	< 4	< 4	< 13	< 5
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-

Table C-III.1

**CONCENTRATIONS OF NICKEL-63 AND GAMMA EMITTERS IN FISH SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020**

RESULTS IN UNITS OF PCI/KG WET ± 2 SIGMA

SITE	COLLECTION PERIOD	Ni-63	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	Cs-134	Cs-137	Ba-140	La-140
BY-29													
Quillback	05/21/20 - 05/21/20	< 88	< 62	< 53	< 40	< 39	< 118	< 58	< 96	< 57	< 54	< 287	< 117
Shorthead Redhorse	05/21/20 - 05/21/20	< 82	< 66	< 61	< 153	< 70	< 131	< 74	< 109	< 56	< 67	< 368	< 144
Smallmouth Bass	10/21/20 - 10/21/20	< 158	< 45	< 47	< 94	< 46	< 97	< 51	< 79	< 48	< 46	< 211	< 88
Golden Redhorse	10/21/20 - 10/21/20	< 179	< 31	< 36	< 65	< 34	< 66	< 34	< 55	< 39	< 33	< 156	< 62
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-
BY-31													
Quillback	05/21/20 - 05/21/20	< 118	< 69	< 58	< 108	< 54	< 108	< 54	< 99	< 68	< 48	< 408	< 109
Silver Redhorse	05/21/20 - 05/21/20	< 108	< 47	< 49	< 108	< 35	< 100	< 62	< 97	< 53	< 48	< 279	< 102
Common Carp	10/21/20 - 10/21/20	< 173	< 31	< 32	< 67	< 38	< 69	< 34	< 58	< 40	< 33	< 128	< 47
Smallmouth Bass	10/21/20 - 10/21/20	< 120	< 33	< 30	< 63	< 37	< 89	< 32	< 68	< 35	< 31	< 155	< 43
	MEAN	-	-	-	-	-	-	-	-	-	-	-	-

Table C-V.1

**CONCENTRATIONS OF GROSS BETA IN AIR PARTICULATE SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020
RESULTS IN UNITS OF E-3 PCI/CU METER \pm 2 SIGMA**

COLLECTION PERIOD	GROUP I				GROUP II			GROUP III
	BY-21	BY-22	BY-23	BY-24	BY-01	BY-04	BY-06	BY-08
12/30/19 - 01/07/20	16 \pm 4	15 \pm 4	13 \pm 4	15 \pm 4	11 \pm 3	9 \pm 3	14 \pm 4	16 \pm 4
01/07/20 - 01/14/20	18 \pm 4	12 \pm 4	17 \pm 4	17 \pm 4	17 \pm 4	12 \pm 4	17 \pm 4	12 \pm 4
01/14/20 - 01/21/20	22 \pm 4	24 \pm 4	21 \pm 4	20 \pm 4	18 \pm 4	23 \pm 4	23 \pm 4	17 \pm 4
01/21/20 - 01/28/20	18 \pm 4	21 \pm 4	16 \pm 4	18 \pm 4	19 \pm 4	18 \pm 4	17 \pm 4	14 \pm 4
01/28/20 - 02/04/20	8 \pm 4	11 \pm 4	8 \pm 4	11 \pm 4	11 \pm 4	9 \pm 4	11 \pm 4	9 \pm 4
02/04/20 - 02/11/20	17 \pm 4	12 \pm 4	10 \pm 4	14 \pm 4	13 \pm 4	13 \pm 4	12 \pm 4	8 \pm 3
02/11/20 - 02/18/20	13 \pm 4	15 \pm 4	12 \pm 4	12 \pm 4	15 \pm 4	15 \pm 4	15 \pm 4	16 \pm 4
02/18/20 - 02/25/20	20 \pm 5	17 \pm 4	19 \pm 5	19 \pm 5	17 \pm 4	20 \pm 5	22 \pm 5	20 \pm 5
02/25/20 - 03/03/20	14 \pm 4	16 \pm 4	16 \pm 4	16 \pm 4	13 \pm 4	14 \pm 4	16 \pm 4	19 \pm 4
03/03/20 - 03/10/20	7 \pm 4	9 \pm 4	8 \pm 4	11 \pm 4	9 \pm 4	6 \pm 3	12 \pm 4	6 \pm 3
03/10/20 - 03/17/20	12 \pm 4	16 \pm 4	18 \pm 4	15 \pm 4	15 \pm 4	17 \pm 4	18 \pm 4	11 \pm 4
03/17/20 - 03/24/20	9 \pm 4	14 \pm 4	12 \pm 4	15 \pm 4	13 \pm 4	17 \pm 4	11 \pm 4	14 \pm 4
03/24/20 - 03/31/20	13 \pm 4	15 \pm 5	11 \pm 4	13 \pm 5	9 \pm 4	13 \pm 4	12 \pm 4	13 \pm 4
03/31/20 - 04/07/20	13 \pm 4	12 \pm 4	11 \pm 4	12 \pm 4	13 \pm 4	13 \pm 4	14 \pm 4	11 \pm 4
04/07/20 - 04/14/20	15 \pm 4	16 \pm 4	16 \pm 4	14 \pm 4	12 \pm 4	16 \pm 4	13 \pm 4	11 \pm 4
04/14/20 - 04/21/20	14 \pm 4	18 \pm 4	16 \pm 4	18 \pm 4	15 \pm 4	15 \pm 4	15 \pm 4	13 \pm 4
04/21/20 - 04/28/20	15 \pm 4	14 \pm 4	16 \pm 4	20 \pm 4	11 \pm 3	15 \pm 4	17 \pm 4	10 \pm 3
04/28/20 - 05/05/20	10 \pm 4	15 \pm 4	11 \pm 4	12 \pm 4	8 \pm 4	8 \pm 4	13 \pm 4	9 \pm 4
05/05/20 - 05/12/20	7 \pm 3	9 \pm 4	8 \pm 3	10 \pm 4	9 \pm 4	9 \pm 4	9 \pm 4	8 \pm 3
05/12/20 - 05/19/20	15 \pm 4	10 \pm 3	11 \pm 3	11 \pm 3	12 \pm 4	14 \pm 4	14 \pm 4	12 \pm 4
05/19/20 - 05/26/20	6 \pm 4	7 \pm 4	< 5	5 \pm 4	6 \pm 4	6 \pm 4	10 \pm 4	8 \pm 4
05/26/20 - 06/02/20	7 \pm 4	9 \pm 4	11 \pm 4	7 \pm 4	8 \pm 4	9 \pm 4	10 \pm 4	12 \pm 4
06/02/20 - 06/09/20	14 \pm 4	11 \pm 4	17 \pm 4	18 \pm 4	13 \pm 4	14 \pm 4	16 \pm 4	14 \pm 4
06/09/20 - 06/16/20	9 \pm 4	8 \pm 3	11 \pm 4	9 \pm 4	7 \pm 3	10 \pm 4	9 \pm 4	12 \pm 4
06/16/20 - 06/23/20	16 \pm 4	17 \pm 4	17 \pm 4	22 \pm 4	20 \pm 4	13 \pm 4	18 \pm 4	20 \pm 4
06/23/20 - 06/30/20	14 \pm 4	13 \pm 4	9 \pm 4	18 \pm 4	12 \pm 4	12 \pm 4	18 \pm 4	13 \pm 4
06/30/20 - 07/07/20	20 \pm 4	25 \pm 4	23 \pm 4	21 \pm 4	21 \pm 4	22 \pm 4	22 \pm 4	25 \pm 4
07/07/20 - 07/14/20	14 \pm 4	15 \pm 4	14 \pm 4	19 \pm 4	16 \pm 4	17 \pm 4	15 \pm 4	11 \pm 4
07/14/20 - 07/21/20	13 \pm 4	15 \pm 4	17 \pm 4	13 \pm 4	12 \pm 4	15 \pm 4	14 \pm 4	15 \pm 4
07/21/20 - 07/28/20	16 \pm 4	13 \pm 4	11 \pm 4	13 \pm 4	14 \pm 4	14 \pm 4	15 \pm 4	14 \pm 4
07/28/20 - 08/04/20	13 \pm 4	12 \pm 4	11 \pm 3	9 \pm 3	11 \pm 3	13 \pm 4	11 \pm 3	11 \pm 3
08/04/20 - 08/11/20	20 \pm 5	20 \pm 4	18 \pm 4	20 \pm 5	18 \pm 5	20 \pm 4	22 \pm 5	20 \pm 4
08/11/20 - 08/18/20	12 \pm 4	19 \pm 5	11 \pm 4	13 \pm 5	13 \pm 4	16 \pm 4	16 \pm 4	18 \pm 4
08/18/20 - 08/25/20	20 \pm 4	23 \pm 4	21 \pm 4	21 \pm 4	21 \pm 4	22 \pm 4	26 \pm 5	24 \pm 4
08/25/20 - 09/01/20	24 \pm 4	18 \pm 4	17 \pm 4	19 \pm 4	23 \pm 4	21 \pm 4	24 \pm 4	19 \pm 4
09/01/20 - 09/08/20	15 \pm 4	20 \pm 4	17 \pm 4	18 \pm 4	16 \pm 4	22 \pm 4	20 \pm 4	17 \pm 4
09/08/20 - 09/15/20	8 \pm 3	10 \pm 3	8 \pm 3	11 \pm 3	10 \pm 3	9 \pm 3	12 \pm 3	7 \pm 3
09/15/20 - 09/22/20	26 \pm 5	27 \pm 5	26 \pm 5	27 \pm 5	25 \pm 5	24 \pm 5	27 \pm 5	23 \pm 4
09/22/20 - 09/29/20	33 \pm 6	29 \pm 5	25 \pm 5	28 \pm 5	26 \pm 5	25 \pm 5	32 \pm 5	27 \pm 5
09/29/20 - 10/06/20	14 \pm 4	7 \pm 4	11 \pm 4	12 \pm 4	10 \pm 4	6 \pm 4	10 \pm 4	10 \pm 4
10/06/20 - 10/13/20	19 \pm 4	18 \pm 4	21 \pm 4	20 \pm 4	18 \pm 4	16 \pm 4	19 \pm 4	18 \pm 4
10/13/20 - 10/20/20	13 \pm 4	15 \pm 5	12 \pm 4	14 \pm 4	15 \pm 5	7 \pm 4	15 \pm 5	13 \pm 4
10/20/20 - 10/27/20	16 \pm 4	13 \pm 4	14 \pm 4	14 \pm 4	15 \pm 4	11 \pm 4	14 \pm 4	14 \pm 4
10/27/20 - 11/03/20	23 \pm 5	22 \pm 5	23 \pm 5	23 \pm 5	18 \pm 4	21 \pm 5	25 \pm 5	23 \pm 5
11/03/20 - 11/10/20	17 \pm 4	20 \pm 4	20 \pm 4	19 \pm 4	20 \pm 4	19 \pm 4	19 \pm 4	19 \pm 4
11/10/20 - 11/17/20	25 \pm 5	22 \pm 5	20 \pm 5	23 \pm 5	23 \pm 5	20 \pm 5	19 \pm 5	23 \pm 5
11/17/20 - 11/24/20	22 \pm 5	21 \pm 5	22 \pm 5	24 \pm 5	25 \pm 5	19 \pm 5	23 \pm 5	21 \pm 5
11/24/20 - 12/01/20	21 \pm 4	18 \pm 4	16 \pm 4	16 \pm 4	18 \pm 4	19 \pm 4	15 \pm 4	17 \pm 4
12/01/20 - 12/08/20	29 \pm 7	21 \pm 5	23 \pm 5	19 \pm 4	21 \pm 5	17 \pm 4	25 \pm 5	17 \pm 4
12/08/20 - 12/15/20	28 \pm 5	27 \pm 5	22 \pm 5	28 \pm 5	31 \pm 5	26 \pm 5	29 \pm 5	34 \pm 6
12/15/20 - 12/22/20	27 \pm 4	25 \pm 4	24 \pm 4	30 \pm 5	23 \pm 4	27 \pm 5	28 \pm 5	19 \pm 4
12/22/20 - 12/29/20	18 \pm 4	17 \pm 4	21 \pm 4	21 \pm 4	16 \pm 4	15 \pm 4	21 \pm 4	19 \pm 4
MEAN \pm 2 STD DEV	16 \pm 12	16 \pm 11	16 \pm 10	17 \pm 11	15 \pm 11	15 \pm 11	17 \pm 11	15 \pm 11

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

Table C-V.2 MONTHLY AND YEARLY MEAN VALUES OF GROSS BETA CONCENTRATIONS IN AIR PARTICULATE SAMPLES COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020
 RESULTS IN UNITS OF E-3 PCI/CU METER ± 2 SIGMA

GROUP I - NEARSITE LOCATIONS					GROUP II - FAR FIELD LOCATIONS					GROUP III - CONTROL LOCATIONS				
COLLECTION PERIOD	MIN	MAX	MEAN ± 2SD		COLLECTION PERIOD	MIN	MAX	MEAN ± 2SD		COLLECTION PERIOD	MIN	MAX	MEAN ± 2SD	
12/30/19 - 02/04/20	8	24	16 ± 9		12/30/19 - 02/04/20	9	23	15 ± 9		12/30/19 - 02/04/20	9	17	14 ± 6	
02/04/20 - 03/03/20	10	20	15 ± 6		02/04/20 - 03/03/20	12	22	15 ± 6		02/04/20 - 03/03/20	8	20	16 ± 11	
03/03/20 - 03/31/20	7	18	12 ± 6		03/03/20 - 03/31/20	6	18	13 ± 7		03/03/20 - 03/31/20	6	14	11 ± 7	
03/31/20 - 04/28/20	11	20	15 ± 4		03/31/20 - 04/28/20	11	17	14 ± 3		03/31/20 - 04/28/20	10	13	11 ± 2	
04/28/20 - 06/02/20	5	15	10 ± 5		04/28/20 - 06/02/20	6	14	10 ± 5		04/28/20 - 06/02/20	8	12	10 ± 4	
06/02/20 - 06/30/20	8	22	14 ± 8		06/02/20 - 06/30/20	7	20	13 ± 8		06/02/20 - 06/30/20	12	20	15 ± 7	
06/30/20 - 08/04/20	9	25	15 ± 8		06/30/20 - 08/04/20	11	22	15 ± 7		06/30/20 - 08/04/20	11	25	15 ± 11	
08/04/20 - 09/01/20	11	24	18 ± 7		08/04/20 - 09/01/20	13	26	20 ± 8		08/04/20 - 09/01/20	18	24	20 ± 5	
09/01/20 - 09/29/20	8	33	20 ± 16		09/01/20 - 09/29/20	9	32	21 ± 15		09/01/20 - 09/29/20	7	27	19 ± 17	
09/29/20 - 11/03/20	7	23	16 ± 9		09/29/20 - 11/03/20	6	25	15 ± 11		09/29/20 - 11/03/20	10	23	15 ± 10	
11/03/20 - 12/01/20	16	25	20 ± 5		11/03/20 - 12/01/20	15	25	20 ± 5		11/03/20 - 12/01/20	17	23	20 ± 4	
12/01/20 - 12/29/20	17	30	24 ± 8		12/01/20 - 12/29/20	15	31	23 ± 11		12/01/20 - 12/29/20	17	34	22 ± 16	
12/30/19 - 12/29/20	5	33	16 ± 11		12/30/19 - 12/29/20	6	32	16 ± 11		12/30/19 - 12/29/20	6	34	15 ± 11	

Table C-V.3

**CONCENTRATIONS OF GAMMA EMITTERS IN AIR PARTICULATE SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020**
RESULTS IN UNITS OF E-3 PCI/CU METER ± 2 SIGMA

SITE	COLLECTION PERIOD	RESULTS IN UNITS OF E-3 PCI/CU METER ± 2 SIGMA										
		Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	Cs-134	Cs-137	Ba-140	La-140
BY-01	12/30/19 - 03/31/20	< 3	< 4	< 7	< 3	< 7	< 4	< 7	< 2	< 2	< 168	< 76
	03/31/20 - 06/30/20	< 3	< 4	< 12	< 3	< 5	< 3	< 9	< 2	< 2	< 194	< 69
	06/30/20 - 09/29/20	< 2	< 4	< 10	< 3	< 8	< 5	< 10	< 3	< 3	< 186	< 33
	09/29/20 - 12/29/20	< 2	< 4	< 10	< 3	< 7	< 4	< 5	< 3	< 2	< 153	< 54
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-04	12/30/19 - 03/31/20	< 2	< 3	< 10	< 2	< 5	< 4	< 6	< 2	< 2	< 170	< 50
	03/31/20 - 06/30/20	< 2	< 4	< 6	< 2	< 7	< 4	< 6	< 2	< 2	< 129	< 57
	06/30/20 - 09/29/20	< 2	< 3	< 11	< 3	< 6	< 4	< 5	< 2	< 2	< 165	< 74
	09/29/20 - 12/29/20	< 2	< 3	< 6	< 2	< 3	< 3	< 5	< 2	< 2	< 101	< 57
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-06	12/30/19 - 03/31/20	< 3	< 4	< 8	< 3	< 6	< 5	< 7	< 2	< 2	< 188	< 82
	03/31/20 - 06/30/20	< 3	< 4	< 14	< 3	< 6	< 5	< 7	< 3	< 2	< 250	< 72
	06/30/20 - 09/29/20	< 3	< 3	< 11	< 3	< 6	< 4	< 7	< 2	< 2	< 153	< 94
	09/29/20 - 12/29/20	< 2	< 3	< 3	< 3	< 6	< 3	< 7	< 2	< 2	< 108	< 50
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-08	12/30/19 - 03/31/20	< 2	< 2	< 6	< 2	< 5	< 3	< 5	< 2	< 2	< 159	< 57
	03/31/20 - 06/30/20	< 2	< 3	< 11	< 2	< 5	< 4	< 5	< 2	< 1	< 130	< 49
	06/30/20 - 09/29/20	< 2	< 3	< 7	< 2	< 5	< 3	< 5	< 2	< 2	< 133	< 31
	09/29/20 - 12/29/20	< 2	< 3	< 10	< 2	< 8	< 3	< 5	< 3	< 2	< 94	< 57
	MEAN	-	-	-	-	-	-	-	-	-	-	-

Table C-V.3

**CONCENTRATIONS OF GAMMA EMITTERS IN AIR PARTICULATE SAMPLES
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020**
RESULTS IN UNITS OF E-3 PCI/CU METER ± 2 SIGMA

SITE	COLLECTION PERIOD	RESULTS IN UNITS OF E-3 PCI/CU METER ± 2 SIGMA										
		Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	Cs-134	Cs-137	Ba-140	La-140
BY-21	12/30/19 - 03/31/20	< 2	< 3	< 10	< 3	< 7	< 4	< 5	< 2	< 2	< 125	< 55
	03/31/20 - 06/30/20	< 3	< 4	< 10	< 2	< 6	< 5	< 7	< 2	< 2	< 195	< 64
	06/30/20 - 09/29/20	< 3	< 3	< 9	< 3	< 8	< 5	< 7	< 2	< 3	< 243	< 65
	09/29/20 - 12/29/20	< 2	< 3	< 7	< 1	< 4	< 3	< 6	< 2	< 2	< 117	< 61
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-22	12/30/19 - 03/31/20	< 3	< 3	< 9	< 2	< 5	< 4	< 5	< 2	< 2	< 145	< 50
	03/31/20 - 06/30/20	< 4	< 6	< 17	< 5	< 9	< 7	< 12	< 4	< 3	< 278	< 138
	06/30/20 - 09/29/20	< 2	< 4	< 11	< 3	< 5	< 3	< 6	< 2	< 2	< 164	< 65
	09/29/20 - 12/29/20	< 3	< 4	< 11	< 2	< 8	< 4	< 7	< 3	< 3	< 124	< 49
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-23	12/30/19 - 03/31/20	< 2	< 3	< 7	< 2	< 4	< 3	< 5	< 2	< 2	< 142	< 43
	03/31/20 - 06/30/20	< 2	< 2	< 8	< 2	< 5	< 4	< 6	< 1	< 2	< 162	< 26
	06/30/20 - 09/29/20	< 2	< 4	< 11	< 3	< 8	< 5	< 8	< 3	< 3	< 203	< 72
	09/29/20 - 12/29/20	< 3	< 5	< 17	< 4	< 11	< 6	< 9	< 4	< 4	< 187	< 69
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-24	12/30/19 - 03/31/20	< 3	< 3	< 13	< 4	< 7	< 4	< 9	< 3	< 2	< 194	< 63
	03/31/20 - 06/30/20	< 3	< 4	< 12	< 3	< 6	< 4	< 8	< 2	< 3	< 197	< 108
	06/30/20 - 09/29/20	< 3	< 5	< 14	< 4	< 10	< 6	< 11	< 5	< 3	< 288	< 115
	09/29/20 - 12/29/20	< 3	< 4	< 10	< 3	< 6	< 3	< 6	< 2	< 2	< 146	< 50
	MEAN	-	-	-	-	-	-	-	-	-	-	-

Table C-VI.1

**CONCENTRATIONS OF I-131 IN AIR IODINE SAMPLES COLLECTED
IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020**
RESULTS IN UNITS OF E-3 PCI/CU METER \pm 2 SIGMA

COLLECTION PERIOD	GROUP I				GROUP II			GROUP III
	BY-21	BY-22	BY-23	BY-24	BY-01	BY-04	BY-06	BY-08
12/30/19 - 01/07/20	< 23	< 38	< 38	< 16	< 19	< 23	< 23	< 23
01/07/20 - 01/14/20	< 31	< 31	< 31	< 31	< 28	< 28	< 28	< 28
01/14/20 - 01/21/20	< 33	< 33	< 33	< 33	< 37	< 37	< 19	< 38
01/21/20 - 01/28/20	< 38	< 38	< 38	< 38	< 27	< 27	< 27	< 27
01/28/20 - 02/04/20	< 28	< 28	< 28	< 28	< 29	< 29	< 29	< 29
02/04/20 - 02/11/20	< 45	< 45	< 46	< 46	< 25	< 25	< 25	< 25
02/11/20 - 02/18/20	< 50	< 50	< 50	< 50	< 23	< 23	< 19	< 23
02/18/20 - 02/25/20	< 27	< 26	< 26	< 26	< 20	< 48	< 48	< 48
02/25/20 - 03/03/20	< 52	< 49	< 49	< 49	< 31	< 31	< 31	< 31
03/03/20 - 03/10/20	< 26	< 20	< 22	< 20	< 39	< 39	< 39	< 39
03/10/20 - 03/17/20	< 56	< 56	< 56	< 56	< 41	< 41	< 41	< 41
03/17/20 - 03/24/20	< 36	< 36	< 36	< 36	< 31	< 31	< 31	< 32
03/24/20 - 03/31/20	< 54	< 54	< 54	< 54	< 34	< 40	< 34	< 34
03/31/20 - 04/07/20	< 37	< 31	< 37	< 37	< 52	< 53	< 53	< 53
04/07/20 - 04/14/20	< 44	< 44	< 44	< 44	< 24	< 29	< 29	< 29
04/14/20 - 04/21/20	< 46	< 46	< 19	< 46	< 37	< 37	< 38	< 38
04/21/20 - 04/28/20	< 33	< 33	< 33	< 33	< 45	< 45	< 45	< 45
04/28/20 - 05/05/20	< 41	< 40	< 40	< 40	< 63	< 63	< 63	< 63
05/05/20 - 05/12/20	< 26	< 26	< 26	< 15	< 43	< 43	< 43	< 43
05/12/20 - 05/19/20	< 34	< 34	< 34	< 34	< 42	< 42	< 42	< 43
05/19/20 - 05/26/20	< 31	< 31	< 31	< 31	< 45	< 45	< 45	< 45
05/26/20 - 06/02/20	< 69	< 69	< 69	< 69	< 68	< 69	< 69	< 69
06/02/20 - 06/09/20	< 26	< 26	< 26	< 26	< 34	< 34	< 35	< 35
06/09/20 - 06/16/20	< 24	< 24	< 24	< 24	< 34	< 34	< 34	< 34
06/16/20 - 06/23/20	< 30	< 30	< 30	< 30	< 36	< 36	< 36	< 36
06/23/20 - 06/30/20	< 64	< 64	< 64	< 64	< 49	< 49	< 49	< 50
06/30/20 - 07/07/20	< 28	< 28	< 28	< 29	< 48	< 48	< 48	< 48
07/07/20 - 07/14/20	< 63	< 63	< 64	< 63	< 64	< 64	< 64	< 64
07/14/20 - 07/21/20	< 64	< 64	< 64	< 64	< 62	< 62	< 62	< 26
07/21/20 - 07/28/20	< 40	< 40	< 19	< 40	< 42	< 42	< 42	< 42
07/28/20 - 08/04/20	< 53	< 53	< 53	< 53	< 54	< 54	< 54	< 23
08/04/20 - 08/11/20	< 29	< 29	< 29	< 32	< 54	< 48	< 49	< 48
08/11/20 - 08/18/20	< 48	< 48	< 48	< 66	< 65	< 65	< 65	< 65
08/18/20 - 08/25/20	< 48	< 48	< 49	< 48	< 54	< 55	< 55	< 55
08/25/20 - 09/01/20	< 61	< 61	< 61	< 61	< 63	< 63	< 63	< 63
09/01/20 - 09/08/20	< 60	< 60	< 60	< 60	< 45	< 46	< 46	< 46
09/08/20 - 09/15/20	< 33	< 33	< 33	< 33	< 63	< 63	< 63	< 63
09/15/20 - 09/22/20	< 66	< 66	< 66	< 66	< 66	< 66	< 67	< 67
09/22/20 - 09/29/20	< 57	< 52	< 52	< 52	< 35	< 35	< 35	< 35
09/29/20 - 10/06/20	< 42	< 39	< 39	< 39	< 38	< 38	< 39	< 39
10/06/20 - 10/13/20	< 25	< 56	< 56	< 56	< 25	< 25	< 26	< 11
10/13/20 - 10/20/20	< 49	< 49	< 25	< 49	< 39	< 39	< 39	< 39
10/20/20 - 10/27/20	< 68	< 68	< 68	< 68	< 69	< 69	< 69	< 69
10/27/20 - 11/03/20	< 35	< 35	< 27	< 35	< 46	< 46	< 46	< 47
11/03/20 - 11/10/20	< 38	< 39	< 39	< 38	< 33	< 33	< 33	< 33
11/10/20 - 11/17/20	< 26	< 55	< 55	< 55	< 63	< 62	< 64	< 65
11/17/20 - 11/24/20	< 60	< 60	< 60	< 25	< 57	< 57	< 57	< 58
11/24/20 - 12/01/20	< 44	< 44	< 23	< 44	< 47	< 47	< 47	< 47
12/01/20 - 12/08/20	< 38	< 37	< 37	< 37	< 34	< 34	< 34	< 34
12/08/20 - 12/15/20	< 38	< 38	< 38	< 38	< 25	< 25	< 25	< 25
12/15/20 - 12/22/20	< 34	< 51	< 51	< 51	< 44	< 44	< 45	< 45
12/22/20 - 12/29/20	< 52	< 52	< 52	< 52	< 65	< 65	< 65	< 65
MEAN	-	-	-	-	-	-	-	-

**Table C-VII.1 CONCENTRATIONS OF I-131 IN MILK SAMPLES COLLECTED IN
THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020**
RESULTS IN UNITS OF PCI/LITER \pm 2 SIGMA

COLLECTION PERIOD	CONTROL FARM BY-26-2	INDICATOR FARM BY-20-1
01/07/20	< 0.6	< 0.7
02/04/20	< 0.6	< 0.6
03/03/20	< 0.6	< 0.5
04/07/20	< 0.6	< 0.7
05/05/20	< 0.6	< 0.7
05/19/20	< 0.7	< 0.7
06/02/20	< 0.6	< 0.7
06/16/20	< 0.5	< 0.8
06/30/20	< 0.8	< 0.8
07/14/20	< 0.9	< 0.8
07/28/20	< 0.9	< 0.9
08/11/20	< 0.8	< 0.9
08/25/20	< 0.8	< 0.7
09/08/20	< 0.8	< 0.8
09/22/20	< 0.5	< 0.6
10/06/20	< 0.7	< 0.6
10/20/20	< 0.7	< 0.9
11/03/20	< 0.8	< 0.9
12/01/20	< 0.8	< 0.9
<i>MEAN</i>	-	-

Table C-VII.2 **CONCENTRATIONS OF GAMMA EMITTERS IN MILK SAMPLES**
COLLECTED IN THE VICINITY OF BYRON NUCLEAR GENERATING STATION, 2020
 RESULTS IN UNITS OF PCILITER ± 2 SIGMA

SITE	COLLECTION PERIOD	RESULTS IN UNITS OF PCILITER ± 2 SIGMA										
		Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	Cs-134	Cs-137	Ba-140	La-140
BY-20-1	01/07/20	< 7	< 6	< 17	< 10	< 20	< 8	< 17	< 10	< 9	< 31	< 9
	02/04/20	< 7	< 8	< 17	< 8	< 18	< 9	< 12	< 10	< 8	< 31	< 10
	03/03/20	< 8	< 8	< 18	< 7	< 19	< 9	< 16	< 10	< 7	< 27	< 9
	04/07/20	< 8	< 7	< 19	< 8	< 17	< 8	< 14	< 9	< 9	< 35	< 13
	05/05/20	< 9	< 9	< 17	< 8	< 22	< 8	< 14	< 11	< 10	< 37	< 12
	05/19/20	< 8	< 6	< 18	< 7	< 21	< 9	< 16	< 9	< 10	< 34	< 12
	06/02/20	< 7	< 7	< 15	< 9	< 15	< 7	< 13	< 8	< 7	< 33	< 8
	06/16/20	< 7	< 7	< 14	< 8	< 14	< 7	< 12	< 8	< 7	< 23	< 7
	06/30/20	< 8	< 9	< 19	< 9	< 19	< 11	< 16	< 10	< 9	< 47	< 11
	07/14/20	< 8	< 9	< 14	< 8	< 20	< 9	< 14	< 9	< 6	< 36	< 6
	07/28/20	< 8	< 7	< 18	< 10	< 23	< 9	< 12	< 9	< 9	< 33	< 7
	08/11/20	< 8	< 8	< 20	< 10	< 14	< 8	< 14	< 9	< 8	< 37	< 10
	08/25/20	< 8	< 8	< 18	< 7	< 20	< 9	< 16	< 6	< 8	< 24	< 8
09/08/20	< 9	< 9	< 12	< 8	< 14	< 8	< 15	< 8	< 10	< 37	< 11	
09/22/20	< 7	< 7	< 19	< 8	< 20	< 9	< 13	< 9	< 8	< 32	< 9	
10/06/20	< 7	< 6	< 13	< 7	< 20	< 7	< 11	< 9	< 8	< 27	< 10	
10/20/20	< 6	< 5	< 15	< 6	< 15	< 6	< 10	< 6	< 6	< 21	< 7	
11/03/20	< 8	< 7	< 13	< 8	< 14	< 9	< 12	< 9	< 8	< 25	< 6	
12/01/20	< 8	< 7	< 19	< 9	< 17	< 8	< 13	< 9	< 8	< 31	< 10	
	MEAN	-	-	-	-	-	-	-	-	-	-	-
BY-26-2	01/07/20	< 9	< 9	< 19	< 11	< 20	< 9	< 14	< 11	< 9	< 38	< 10
	02/04/20	< 7	< 8	< 16	< 8	< 18	< 9	< 15	< 10	< 8	< 28	< 8
	03/03/20	< 7	< 7	< 18	< 14	< 28	< 10	< 14	< 7	< 11	< 35	< 12
	04/07/20	< 6	< 6	< 15	< 5	< 16	< 6	< 13	< 6	< 7	< 28	< 10
	05/05/20	< 11	< 8	< 24	< 12	< 18	< 10	< 16	< 11	< 9	< 32	< 10
	05/19/20	< 7	< 9	< 18	< 10	< 20	< 9	< 16	< 10	< 8	< 29	< 9
	06/02/20	< 7	< 7	< 16	< 8	< 13	< 7	< 14	< 8	< 8	< 32	< 7
	06/16/20	< 7	< 7	< 17	< 5	< 20	< 7	< 12	< 8	< 8	< 31	< 6
	06/30/20	< 6	< 8	< 13	< 6	< 16	< 5	< 10	< 6	< 5	< 28	< 10
	07/14/20	< 9	< 9	< 17	< 8	< 20	< 8	< 13	< 8	< 8	< 33	< 9
	07/28/20	< 8	< 8	< 18	< 10	< 16	< 7	< 14	< 7	< 9	< 29	< 8
	08/11/20	< 9	< 7	< 18	< 10	< 20	< 8	< 14	< 8	< 8	< 30	< 10
	08/25/20	< 6	< 7	< 14	< 7	< 15	< 7	< 12	< 7	< 7	< 29	< 8
09/08/20	< 8	< 8	< 20	< 9	< 17	< 8	< 14	< 9	< 9	< 37	< 11	
09/22/20	< 7	< 9	< 17	< 9	< 19	< 8	< 17	< 8	< 8	< 34	< 7	
10/06/20	< 6	< 6	< 13	< 8	< 16	< 6	< 11	< 7	< 7	< 23	< 9	
10/20/20	< 7	< 6	< 20	< 10	< 19	< 9	< 15	< 9	< 10	< 34	< 11	
11/03/20	< 8	< 7	< 13	< 7	< 22	< 7	< 12	< 9	< 8	< 33	< 9	
12/01/20	< 9	< 7	< 13	< 8	< 21	< 10	< 14	< 7	< 9	< 31	< 9	
	MEAN	-	-	-	-	-	-	-	-	-	-	-

Table C-IX.1 QUARTERLY OSLD RESULTS FOR BYRON NUCLEAR GENERATING STATION, 2020
 RESULTS IN UNITS OF MREM/QUARTER \pm 2 STANDARD DEVIATIONS

STATION CODE	MEAN \pm 2 S.D.	JAN - MAR	APR - JUN	JUL - SEP	OCT - DEC
BY-01-1	19 \pm 1	18	20	19	18
BY-04-1	22 \pm 3	20	23	23	22
BY-06-1	18 \pm 1	18	18	19	18
BY-08-1 (Ctrl)	18 \pm 2	17	17	18	19
BY-21-1	16 \pm 2	15	17	16	17
BY-22-1	23 \pm 0	23	23	23	23
BY-23-1	22 \pm 3	20	22	23	22
BY-24-2	19 \pm 2	19	19	19	20
BY-101-1	17 \pm 1	17	16	17	17
BY-101-2	17 \pm 3	16	16	17	18
BY-102-1	23 \pm 4	21	24	22	25
BY-102-2	23 \pm 6	19	24	25	24
BY-103-1	21 \pm 3	21	20	21	23
BY-103-2	23 \pm 2	23	23	25	23
BY-103-3	21 \pm 2	20	22	20	22
BY-104-1	23 \pm 3	21	24	22	23
BY-104-2	23 \pm 2	22	22	25	23
BY-104-3	20 \pm 3	20	21	18	21
BY-105-1	23 \pm 2	21	23	24	23
BY-105-2	24 \pm 3	23	25	25	23
BY-106-1	22 \pm 1	22	22	22	22
BY-106-2	22 \pm 3	20	23	21	22
BY-107-1	25 \pm 1	24	24	25	25
BY-107-2	25 \pm 1	24	24	25	25
BY-107-3	21 \pm 1	20	21	21	21
BY-108-1	23 \pm 3	21	25	22	24
BY-108-2	21 \pm 3	20	19	22	22
BY-109-1	21 \pm 4	19	20	23	23
BY-109-2	21 \pm 2	20	21	20	22
BY-110-1	20 \pm 1	20	21	20	21
BY-110-2	21 \pm 2	20	21	20	22
BY-111-3	23 \pm 3	22	25	21	24
BY-111-4	23 \pm 2	21	23	23	23
BY-112-3	22 \pm 1	22	22	23	22
BY-112-4	22 \pm 3	21	22	20	24
BY-113-1	22 \pm 3	20	23	23	24
BY-113-2	19 \pm 1	19	18	19	20
BY-114-1	19 \pm 1	18	19	19	19
BY-114-2	21 \pm 2	21	21	21	23
BY-115-1	22 \pm 3	20	21	23	23
BY-115-2	20 \pm 3	19	21	19	22
BY-116-1	20 \pm 2	19	21	20	21
BY-116-2	19 \pm 2	19	19	21	19
BY-116-3	20 \pm 2	19	21	21	21
BY-201-3	22 \pm 1	22	21	22	22
BY-201-4	23 \pm 4	22	26	22	23
BY-202-1	22 \pm 3	22	24	21	23
BY-202-2	24 \pm 1	25	25	25	24
BY-203-1	19 \pm 3	19	20	17	20

Table C-IX.1 QUARTERLY OSLD RESULTS FOR BYRON NUCLEAR GENERATING STATION, 2020
 RESULTS IN UNITS OF MREM/QUARTER \pm 2 STANDARD DEVIATIONS

STATION CODE	MEAN \pm 2 S.D.	JAN - MAR	APR - JUN	JUL - SEP	OCT - DEC
BY-203-2	21 \pm 3	20	22	21	23
BY-204-1	20 \pm 2	19	21	19	21
BY-204-2	23 \pm 1	22	23	23	24
BY-205-1	23 \pm 2	23	25	23	23
BY-205-2	21 \pm 3	21	23	19	22
BY-206-1	23 \pm 3	22	25	22	24
BY-206-2	23 \pm 4	21	26	24	23
BY-207-1	24 \pm 3	23	25	24	26
BY-207-2	23 \pm 1	23	24	23	22
BY-208-1	24 \pm 4	23	27	23	25
BY-208-2	23 \pm 4	22	25	21	24
BY-209-1	24 \pm 4	21	24	25	24
BY-209-4	24 \pm 0	24	25	24	25
BY-210-3	22 \pm 4	20	25	22	23
BY-210-4	22 \pm 2	20	23	22	22
BY-211-1	23 \pm 3	21	25	23	23
BY-211-4	23 \pm 3	22	25	23	24
BY-212-1	25 \pm 2	23	25	25	25
BY-212-4	24 \pm 2	24	26	23	25
BY-213-1	23 \pm 3	23	23	22	25
BY-213-4	24 \pm 1	23	24	24	23
BY-214-1	24 \pm 2	22	25	24	24
BY-214-4	23 \pm 1	22	23	23	23
BY-215-1	22 \pm 3	21	24	21	23
BY-215-4	23 \pm 2	23	24	22	23
BY-216-1	25 \pm 3	23	27	25	26
BY-216-2	23 \pm 3	22	24	21	24
BY-301-1	16 \pm 2	15	17	17	17
BY-301-2	20 \pm 3	19	21	18	20
BY-309-1	21 \pm 3	21	23	19	22
BY-309-2	23 \pm 2	21	23	23	23
BY-309-3	21 \pm 2	19	22	22	21
BY-309-4	20 \pm 1	19	20	20	19
BY-314-2	18 \pm 3	17	18	17	20

TABLE C-IX.2 MEAN QUARTERLY OSLD RESULTS FOR THE INNER RING, OUTER RING, OUTER RING, SPECIAL INTEREST, OTHER, AND CONTROL LOCATIONS FOR BYRON NUCLEAR GENERATING STATION, 2020
RESULTS IN UNITS OF MILLIREM/STD. QUARTER ± 2 STANDARD DEVIATION

COLLECTION PERIOD	INNER RING ± 2 S.D.	OUTER RING ± 2 S.D.	SPECIAL INTEREST ± 2 S.D.	OTHER ± 2 S.D.	CONTROL ± 2 S.D.
JAN-MAR	20 ± 4	22 ± 3	19 ± 4	19 ± 5	17 ± 0
APR-JUN	22 ± 4	24 ± 3	21 ± 5	20 ± 5	17 ± 0
JUL-SEP	21 ± 4	22 ± 4	20 ± 5	20 ± 6	18 ± 0
OCT-DEC	22 ± 4	23 ± 3	20 ± 4	20 ± 5	19 ± 0

TABLE C-IX.3 SUMMARY OF THE AMBIENT DOSIMETRY PROGRAM FOR BYRON NUCLEAR GENERATING STATION, 2020

RESULTS IN UNITS OF MILLIREM/STD. QUARTER ± 2 STANDARD DEVIATION

LOCATION	SAMPLES ANALYZED	PERIOD MINIMUM	PERIOD MAXIMUM	PERIOD MEAN ± 2 S.D.
INNER RING	144	16	25	21 ± 4
OUTER RING	128	17	27	23 ± 4
SPECIAL INTEREST	28	15	23	20 ± 4
OTHER	28	15	23	20 ± 5
CONTROL	4	17	19	18 ± 2

INNER RING STATIONS - BY-101-1, BY-101-2, BY-102-1, BY-102-2, BY-103-1, BY-103-2, BY-103-3, BY-104-1, BY-104-2, BY-104-3, BY-105-1, BY-105-2, BY-106-1, BY-106-2, BY-107-1, BY-107-2, BY-107-3, BY-108-1, BY-108-2, BY-109-1, BY-109-2, BY-110-1, BY-110-2, BY-111-3, BY-111-4, BY-112-3, BY-112-4, BY-113-1, BY-113-2, BY-114-1, BY-114-2, BY-115-1, BY-115-2, BY-116-1, BY-116-2, BY-116-3

OUTER RING STATIONS - BY-201-3, BY-201-4, BY-202-1, BY-202-2, BY-203-1, BY-203-2, BY-204-1, BY-204-2, BY-205-1, BY-205-2, BY-206-1, BY-206-2, BY-207-1, BY-207-2, BY-208-1, BY-208-2, BY-209-1, BY-209-4, BY-210-3, BY-210-4, BY-211-1, BY-211-4, BY-212-1, BY-212-4, BY-213-1, BY-213-4, BY-214-1, BY-214-4, BY-215-1, BY-215-4, BY-216-1, BY-216-2

SPECIAL INTEREST STATIONS - BY-301-1, BY-301-2, BY-309-1*, BY-309-2*, BY-309-3*, BY-309-4*, BY-314-2


OTHER STATIONS - BY-01-1, BY-04-1, BY-06-1, BY-21-1, BY-22-1, BY-23-1, BY-24

CONTROL STATION - BY-08-1


**For ISFSI Monitoring*

FIGURE C-1
Surface Water - Gross Beta - Stations BY-12 and BY-29 (C)
Collected in the Vicinity of BNGS, 2000 - 2020

BY-12 Oregon Pool of Rock River, Downstream




BY-29 (C) Byron, Rock River Upstream




*DUE TO VENDOR CHANGE IN 2005, < VALUES ARE LLD VALUES JANUARY THROUGH JUNE 2005
AND MDC VALUES AFTER JUNE 2005*

FIGURE C-2 Surface Water - Tritium - Stations BY-12 and BY-29 (C) Collected in the Vicinity of BNGS, 2000 - 2020

BY-12 Oregon Pool of Rock River, Downstream




BY-29 (C) Byron, Rock River Upstream



*DUE TO VENDOR CHANGE IN 2005, < VALUES ARE LLD VALUES JANUARY THROUGH JUNE 2005
AND MDC VALUES AFTER JUNE 2005*

FIGURE C-3 Ground Water - Tritium - Station BY-14-1 Collected in the Vicinity of BNGS, 2000 - 2020

BY-14-1 3200 N. German Church Road Well



DUE TO VENDOR CHANGE IN 2005, < VALUES ARE LLD VALUES JANUARY THROUGH JUNE 2005
AND MDC VALUES AFTER JUNE 2005

FIGURE C-4
Ground Water - Tritium - Station BY-18-1
Collected in the Vicinity of BNGS, 2010 - 2020

BY-18-1 Calhoun Well




FIGURE C-5
Ground Water - Tritium - Station BY-32
Collected in the Vicinity of BNGS, 2000 - 2020

BY-32 Krueger Well




FIGURE C-6
Ground Water - Tritium - Station BY-35
Collected in the Vicinity of BNGS, 2006 - 2020

BY-35 Vancko Well





FIGURE C-7
Ground Water - Tritium - Station BY-37
Collected in the Vicinity of BNGS, 2006 - 2020

BY-37 Cavage Well



Ground Water - Tritium - Station BY-38
Collected in the Vicinity of BNGS, 2006 - 2020

BY-38 Steve Storz Well





FIGURE C-8
Air Particulate - Gross Beta - Stations BY-08 (C) and BY-21
Collected in the Vicinity of BNGS, 2000 - 2020

BY-08 (C) Leaf River WNW



BY-21 Byron Nearsite N





FIGURE C-9
Air Particulate - Gross Beta - Stations BY-22 and BY-23
Collected in the Vicinity of BNGS, 2000 - 2020

BY-22 Byron Nearsite SE



BY-23 Byron Nearsite S




FIGURE C-10
Air Particulate - Gross Beta - Station BY-24
Collected in the Vicinity of BNGS, 2000 - 2020

BY-24 Byron Nearsite SW






FIGURE C-11
Air Particulate - Gross Beta - Stations BY-01 and BY-04
Collected in the Vicinity of BNGS, 2005 - 2020

BY-01 Byron N




BY-04 Paynes Point SE



Regular analysis of far field air particulate & gross beta did not take place prior to 2005

FIGURE C-12
Air Particulate - Gross Beta - Station BY-06
Collected in the Vicinity of BNGS, 2005 - 2020

BY-06 Oregon SSW



Regular analysis of far field air particulate & gross beta did not take place prior to 2005

Intentionally left blank

APPENDIX D

INTER-LABORATORY COMPARISON PROGRAM

Intentionally left blank

**Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering Environmental Services**

Table D.1

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Value	Known Value ^(a)	Ratio of TBE to Known Result	Evaluation ^(b)		
September 2020	E13247	Milk	Sr-89	pCi/L	62.8	95.4	0.66	N ⁽¹⁾		
			Sr-90	pCi/L	12.0	12.8	0.94	A		
	E13248	Milk	Ce-141	pCi/L	156	150	1.04	A		
			Co-58	pCi/L	172	180	0.96	A		
			Co-60	pCi/L	369	379	0.97	A		
			Cr-51	pCi/L	372	372	1.00	A		
			Cs-134	pCi/L	171	200	0.85	A		
			Cs-137	pCi/L	241	250	0.96	A		
			Fe-59	pCi/L	217	200	1.08	A		
			I-131	pCi/L	84.6	95.0	0.89	A		
			Mn-54	pCi/L	175	180	0.97	A		
			Zn-65	pCi/L	252	270	0.93	A		
			E13249	Charcoal	I-131	pCi	70.2	75.8	0.93	A
			E13250	AP	Ce-141	pCi	101	101	1.00	A
Co-58	pCi	111			120	0.92	A			
Co-60	pCi	249			254	0.98	A			
Cr-51	pCi	287			249	1.15	A			
Cs-134	pCi	114			134	0.85	A			
Cs-137	pCi	159			168	0.95	A			
Fe-59	pCi	127			134	0.95	A			
Mn-54	pCi	114			121	0.94	A			
E13251	Soil	Ce-141	pCi/g	0.241	0.191	1.26	W			
		Co-58	pCi/g	0.211	0.228	0.93	A			
		Co-60	pCi/g	0.466	0.481	0.97	A			
		Cr-51	pCi/g	0.450	0.472	0.95	A			
		Cs-134	pCi/g	0.273	0.254	1.07	A			
		Cs-137	pCi/g	0.370	0.390	0.95	A			
		Fe-59	pCi/g	0.233	0.254	0.92	A			
		Mn-54	pCi/g	0.217	0.229	0.95	A			
E13252	AP	Sr-89	pCi	79.9	100.0	0.80	A			
		Sr-90	pCi	12.1	13.4	0.90	A			

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

(1) See **NCR 20-19**

**Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering Environmental Services**

Table D.1

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Value	Known Value ^(a)	Ratio of TBE to Known Result	Evaluation ^(b)
December 2020	E13254	Milk	Sr-89	pCi/L	82.2	89.7	0.92	A
			Sr-90	pCi/L	12.4	13.0	0.96	A
	E13255	Milk	Ce-141	pCi/L	91.1	100	0.91	A
			Co-58	pCi/L	77.5	84.3	0.92	A
			Co-60	pCi/L	147	152	0.97	A
			Cr-51	pCi/L	259	253	1.02	A
			Cs-134	pCi/L	97.1	108	0.90	A
			Cs-137	pCi/L	117	127	0.92	A
			Fe-59	pCi/L	114	112	1.02	A
			I-131	pCi/L	84.3	91.9	0.92	A
			Mn-54	pCi/L	137	143	0.96	A
			Zn-65	pCi/L	175	190	0.92	A
				E13256	Charcoal	I-131	pCi	70.2
	E13257A	AP	Ce-141	pCi	67.4	74.6	0.90	A
			Co-58	pCi	57.9	62.9	0.92	A
			Co-60	pCi	108	113	0.95	A
			Cr-51	pCi	162	189	0.86	A
			Cs-134	pCi	68.1	80.4	0.85	A
			Cs-137	pCi	82.4	95.0	0.87	A
			Fe-59	pCi	80.5	83.7	0.96	A
			Mn-54	pCi	102	107	0.95	A
	E13258	Soil	Ce-141	pCi/g	0.167	0.170	0.98	A
			Co-58	pCi/g	0.125	0.143	0.87	A
			Co-60	pCi/g	0.245	0.257	0.95	A
			Cr-51	pCi/g	0.393	0.429	0.92	A
			Cs-134	pCi/g	0.147	0.183	0.80	A
			Cs-137	pCi/g	0.260	0.288	0.90	A
			Fe-59	pCi/g	0.199	0.190	1.05	A
			Mn-54	pCi/g	0.229	0.243	0.94	A
	E13259	AP	Sr-89	pCi	85.0	78.6	1.08	A
			Sr-90	pCi	13.1	11.4	1.15	A

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

DOE's Mixed Analyte Performance Evaluation Program (MAPEP)
Teledyne Brown Engineering Environmental Services

Table D.2

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Value	Known Value ^(a)	Acceptance Range	Evaluation ^(b)
February 2020	20-GrF42	AP	Gross Alpha	Bq/sample	0.676	1.24	0.37 - 2.11	A
			Gross Beta	Bq/sample	2.03	2.00	1.00 - 3.00	A
	20-MaS42	Soil	Ni-63	Bq/kg	0.01		(1)	A
			Sr-90	Bq/kg	348	340	238 - 442	A
	20-MaW42	Water	Ni-63	Bq/L	11.6	11.1	7.8 - 14.4	A
			Pu-238	Bq/L	0.926	0.94	0.66 - 1.22	A
			Pu-239/240	Bq/L	0.712	0.737	0.516 - 0.958	A
	20-RdF42	AP	U-234/233	Bq/sample	0.0416	0.075	0.053 - 0.098	N ⁽³⁾
			U-238	Bq/sample	0.0388	0.078	0.055 - 0.101	N ⁽³⁾
	20-RdV42	Vegetation	Cs-134	Bq/sample	3.23	3.82	2.67 - 4.97	A
			Cs-137	Bq/sample	2.64	2.77	1.94 - 3.60	A
			Co-57	Bq/sample	0.0281		(1)	A
			Co-60	Bq/sample	2.62	2.79	1.95 - 3.63	A
			Mn-54	Bq/sample	4.3	4.58	3.21 - 5.95	A
			Sr-90	Bq/sample	0.396	0.492	0.344 - 0.640	A
Zn-65			Bq/sample	3.93	3.79	2.65 - 4.93	A	
August 2020	20-GrF43	AP	Gross Alpha	Bq/sample	0.267	0.528	0.158 - 0.989	A
			Gross Beta	Bq/sample	0.939	0.915	0.458 - 1.373	A
	20-MaS43	Soil	Ni-63	Bq/kg	438	980	686 - 1274	N ⁽⁴⁾
			Tc-99	Bq/kg	1.11		(1)	A
	20-MaW43	Water	Ni-63	Bq/L	0.175		(1)	A
			Tc-99	Bq/L	8.8	9.4	6.6 - 12.2	A
	20-RdV43	Vegetation	Cs-134	Bq/sample	3.635	4.94	3.46 - 6.42	W
			Cs-137	Bq/sample	0.0341		(1)	A
			Co-57	Bq/sample	5.855	6.67	4.67 - 8.67	W
			Co-60	Bq/sample	3.122	4.13	2.89 - 5.37	W
			Mn-54	Bq/sample	4.524	5.84	4.09 - 7.59	A
			Sr-90	Bq/sample	1.01	1.39	0.97 - 1.81	W
	Zn-65	Bq/sample	4.706	6.38	4.47 - 8.29	W		

(a) The MAPEP known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) DOE/MAPEP evaluation:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

(1) False positive test

(2) Sensitivity evaluation

(3) See **NCR 20-13**

(4) See **NCR 20-20**

**ERA Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering Environmental Services**

Table D.3

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Value	Known Value ^(a)	Acceptance Limits	Evaluation ^(b)
March 2020	MRAD-32	Water	Am-241	pCi/L	52.5	45.3	31.1 - 57.9	A
			Fe-55	pCi/L	155	152	89.3 - 221	A
			Pu-238	pCi/L	34.0	36.4	21.9 - 47.2	A
			Pu-239	pCi/L	30.9	33.6	20.8 - 41.4	A
April 2020	RAD-121	Water	Ba-133	pCi/L	41.8	41.8	34.0 - 46.7	A
			Cs-134	pCi/L	42.9	46.3	37.1 - 50.9	A
			Cs-137	pCi/L	226	234	211 - 259	A
			Co-60	pCi/L	52.4	50.3	45.3 - 57.9	A
			Zn-65	pCi/L	83.3	86.8	78.1 - 104	A
			GR-A	pCi/L	20.1	23.6	11.9 - 31.6	A
			GR-B	pCi/L	45.6	60.5	41.7 - 67.2	A
			U-Nat	pCi/L	18.45	18.6	14.9 - 20.9	A
			H-3	pCi/L	14200	14100	12300 - 15500	A
			Sr-89	pCi/L	58.0	60.1	48.3 - 67.9	A
			Sr-90	pCi/L	34.1	44.7	33.0 - 51.2	A
			I-131	pCi/L	27.4	28.9	24.1 - 33.8	A
September 2020	MRAD-33	Soil	Sr-90	pCi/Kg	4360	4980	1550 - 7760	A
			AP					
		Water	Fe-55	pCi/Filter	189	407	149 - 649	A
			U-234	pCi/Filter	17.9	18.3	13.6 - 21.4	A
			U-238	pCi/Filter	19.1	18.1	13.7 - 21.6	A
			Am-241	pCi/L	160	176	121 - 225	A
			Fe-55	pCi/L	299	298	175 - 433	A
			Pu-238	pCi/L	200	191	115 - 247	A
Pu-239	pCi/L	105	100	61.9 - 123	A			
October 2020	RAD-123	Water	Ba-133	pCi/L	37.1	37.0	29.8 - 41.6	A
			Cs-134	pCi/L	50.6	52.7	42.5 - 58.0	A
			Cs-137	pCi/L	131	131	118 - 146	A
			Co-60	pCi/L	62.9	60.5	54.4 - 69.1	A
			Zn-65	pCi/L	167	162	146 - 191	A
			GR-A	pCi/L	40.0	26.2	13.3 - 34.7	N ⁽¹⁾
			GR-B	pCi/L	47.5	69.1	48.0 - 76.0	N ⁽¹⁾
			U-Nat	pCi/L	17.2	20.3	16.3 - 22.7	A
			H-3	pCi/L	23800	23200	20,300 - 25,500	A
			Sr-89	pCi/L	41.1	43.3	33.4 - 50.5	A
			Sr-90	pCi/L	28.5	30.2	22.0 - 35.0	A
			I-131	pCi/L	22.9	28.2	23.5 - 33.1	N ⁽²⁾
November 2020	QR111920K	Water	GR-A	pCi/L	50.7	52.4	27.3 - 65.6	A
			GR-B	pCi/L	24.9	24.3	15.0 - 32.3	A

(a) The ERA known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.

(b) ERA evaluation:

A = Acceptable - Reported value falls within the Acceptance Limits

N = Not Acceptable - Reported value falls outside of the Acceptance Limits

(1) See **NCR 20-18**

(2) See **NCR 20-17**

APPENDIX E

EFFLUENT REPORT

Intentionally left blank

TABLE OF CONTENTS

SUMMARY	1
INTRODUCTION	2
1.0. EFFLUENTS	3
1.1. Gaseous Effluents to the Atmosphere	3
1.2. Liquids Released to Rock River	3
2.0. SOLID RADIOACTIVE WASTE	3
3.0. DOSE TO MAN	4
3.1. Gaseous Effluent Pathways	4
3.1.1. Noble Gases	4
3.1.1.1. Gamma Dose Rates	4
3.1.1.2. Beta Air and Skin Dose Rate	4
3.1.2. Radioactive Iodine & Particulate	4
3.1.3. Gaseous Total Dose	5
3.2. Liquid Effluent Pathways	5
3.3. Total Dose	6
3.4. Assessment of Dose to Member of Public	6
4.0. SOLID RADIOACTIVE WASTE	6
APPENDIX E-1 DATA TABLES AND FIGURES	
Station Releases	
Table 1.1-1 Gaseous Effluents	E-1-1
Table 1.2-1 Liquid Effluents	E-1-3
Table 3.1-1 40CFR190 Maximum Doses Resulting from Liquid Releases	E-1-5
Table 3.2-1 40CFR190 Maximum Doses Resulting from Gaseous Releases	E-1-6
Table 3.3-1 40CFR190 Uranium Fuel Cycle Report – Total Dose	E-1-8
Table 3.4-1 Maximum Doses Resulting from Airborne Releases Based On Concurrent Meteorological Data	E-1-10

SUMMARY

Calculations based on gaseous and liquid effluents and meteorological data indicate that public dose due to radioactive material attributable to Byron Station during the period does not exceed regulatory or Offsite Dose Calculation Manual (ODCM) limits.

The Total Effective Dose Equivalent (TEDE) due to licensed activities at Byron Station calculated for the maximum exposed individual for the period is 3.14E-01 mrem. The annual limit on TEDE is 100 mrem.

The assessment of radiation doses to the public is performed in accordance with the ODCM. The results of these analyses confirm that the station is operating in compliance with 10CFR50 Appendix I, 10CFR20 and 40CFR190.

There were no additional operational controls implemented which affected the areas of radiological effluents in 2020.

There were no measurements which exceeded the reporting levels, including any which would not have been attributable to station effluents.

The results of the current radiological environmental monitoring program are approximately the same as those found during the pre-operational studies conducted at Byron Station.

INTRODUCTION

Liquid effluents from Byron Station are released to the Rock River in controlled batches after radioassay of each batch. Gaseous effluents are released to the atmosphere and are calculated on the basis of analyses of weekly grab samples and grab samples of batch releases prior to the release of noble gases as well as continuously collected composite samples of iodine and particulate radioactivity sampled during the course of the year. The results of effluent analyses are summarized on a monthly basis. Airborne concentrations of noble gases, I-131, and particulate radioactivity in offsite areas are calculated using isotopic composition of effluents and meteorological data. C-14 concentration in offsite areas is calculated based on industry-approved methodology for estimation of the amount released and meteorological data.

Environmental monitoring is conducted by sampling at indicator and control (background) locations in the vicinity of Byron Station to measure changes in radiation or radioactivity levels that may be attributable to station operation. If significant changes attributable to Byron Station are measured, these changes are correlated with effluent releases. An environmental monitoring program is conducted which also includes all potential pathways at the site. Gaseous pathways include ground plane (direct), inhalation, vegetation, meat, and milk. Liquid pathways include potable water and freshwater fish. The critical pathway for 2020 gaseous dose was vegetation. The critical pathway for 2020 liquid dose was freshwater fish.

1.0 RELEASES

1.1 Gaseous Effluents to the Atmosphere

Measured concentrations and isotopic composition of noble gases, radioiodine, tritium and particulate radioactivity released to the atmosphere during the year are listed in Table 1.1-1.

A total of 3.86E+00 curies of fission and activation gases were released with a maximum average quarterly release rate of 1.01E+00 $\mu\text{Ci}/\text{sec}$.

A total of 1.48E-06 curies of I-131 were released during the year with a maximum average quarterly release rate of 1.88E-07 $\mu\text{Ci}/\text{sec}$.

A total of 1.50E-04 curies were released as airborne particulate matter with a maximum average quarterly release rate of 9.93E-06 $\mu\text{Ci}/\text{sec}$.

A total of 8.91E+00 curies of other (C-14) radioisotopes were released with a maximum average quarterly release rate of 3.35E-01 $\mu\text{Ci}/\text{sec}$.

A total of 4.78E+01 curies of tritium were released with a maximum average quarterly release rate of 1.86E+00 $\mu\text{Ci}/\text{sec}$.

Gross alpha-emitting radionuclides were below detectable limits.

1.2 Liquids Released to Rock River

A total of 2.84E+10 liters of radioactive liquid wastes containing 1.04E-01 curies of fission and activation products were discharged with a maximum quarterly average concentration of 4.69E-09 $\mu\text{Ci}/\text{ml}$.

A total of 2.80E+03 curies of tritium were discharged with a maximum quarterly average concentration of 1.96E-04 $\mu\text{Ci}/\text{ml}$.

A total of 9.98E-04 curies of dissolved and entrained gases were discharged with a maximum quarterly average concentration of 8.50E-11 $\mu\text{Ci}/\text{ml}$.

Gross alpha-emitting radionuclides were below detectable limits.

Quarterly release totals of principal radionuclides in liquid effluents are given in Table 1.2-1.

2.0 SOLID RADIOACTIVE WASTE

Solid radioactive wastes were shipped by truck. For detail, refer to Byron Station 2020 Annual Radiological Effluent Release Report.

3.0 DOSE TO MAN

3.1 Gaseous Effluent Pathways

Table 3.2-1 summarizes the doses resulting from releases of airborne radioactivity via the different exposure pathways.

3.1.1 Noble Gas

3.1.1.1 Gamma Dose Rates

Offsite Gamma air and whole body dose rates are shown in Table 3.2-1 and were calculated based on measured release rates, isotopic composition of the noble gases, and average meteorological data for the period. Dose rates based on concurrent meteorological data are shown in Table 3.4-1. Based on measured effluents and average meteorological data, the maximum gamma air dose was $2.84\text{E-}04$ mrad based on measured effluents and average meteorological data, and $6.25\text{E-}05$ mrad based on measured effluents and concurrent meteorological data. (Table 3.4-1).

3.1.1.2 Beta Air and Skin Dose Rates

The range of beta particles in air is relatively small (on the order of a few meters or less); consequently, plumes of gaseous effluents may be considered "semi-infinite" for purpose of calculating the dose from beta radiation incident on the skin. However, the actual dose to sensitive skin tissues is difficult to calculate due to the effect of the beta particle energies, thickness of inert skin and clothing covering sensitive tissues. For purposes of this report the skin is taken to have a thickness of 7.0 mg/cm^2 and an occupancy factor of 1.0 is used. The skin dose based on measured effluents and average meteorological data was $7.90\text{E-}05$ mrem, and $8.38\text{E-}05$ mrem based on measured effluents and concurrent meteorological data.

The maximum offsite beta air dose for the year based on measured effluents and average meteorological data was $6.86\text{E-}05$ mrad. The beta air dose based on measured effluents and concurrent meteorological data was $5.46\text{E-}05$ mrad.

3.1.2 Radioactive Iodine & Particulate

The human thyroid exhibits a significant capacity to concentrate ingested or inhaled iodine. I-131 released during routine operation of the station may be made available to man resulting in a dose to

the thyroid. C-14 is also included in this category. C-14 exhibits a capacity to concentrate in bone. C-14 is released in gaseous form and is absorbed into vegetation through photosynthesis. The principal pathways of interest for C-14 are the consumption of vegetation by humans and milk from which animals have ingested C-14 through the consumption of vegetation. With the requirement to begin reporting C-14 dose in 2011 and the addition of C-14 to plant effluents, human dose in this category is primarily driven by the release of C-14 from the plant.

The hypothetical dose to the maximum exposed individual living near the station via ingestion of milk and vegetation was calculated. The source of milk and vegetation was assumed to be at the nearest site boundary with the cows pastured and vegetation grown from May through October. The maximum dose from radioactive iodine and particulate (including C-14) to any organ was $7.26\text{E-}01$ mrem (child/bone) based on measured effluents and average meteorological data and $6.84\text{E-}01$ mrem based on measured effluents and concurrent meteorological data. The maximum dose from radioactive iodine and particulate (including C-14) to the whole body was $1.48\text{E-}01$ mrem (child) based on measured effluents and average meteorological data and $1.40\text{E-}01$ mrem (child) based on measured effluents and concurrent meteorological data.

3.1.3 Gaseous Total Dose

The maximum total dose from gaseous releases to any organ was $7.26\text{E-}01$ mrem (child/bone) based on measured effluents and average meteorological data, and $6.84\text{E-}01$ mrem (child/bone) based on measured effluents and concurrent meteorological data. The maximum total dose from gaseous releases to the whole body was $1.48\text{E-}01$ mrem (child) based on measured effluents and average meteorological data, and $1.40\text{E-}01$ mrem (child) based on measured effluents and concurrent meteorological data.

3.2 Liquid Effluent Pathways

The principal pathways through the aquatic environment for potential doses to man from liquid waste are ingestion of potable water and eating aquatic foods. Liquid dose was calculated based on the ingestion of potable water and sport fish. It should be noted, however, there were no communities within 10 km downstream of the plant using the Rock River for drinking water. NRC-developed equations were used to calculate the doses to the whole body, bone, liver, thyroid, kidney, lung, lower GI tract, and skin. Specific parameters for use in the equations are given in the Exelon Offsite Dose Calculation Manual (ODCM).

The maximum dose from liquid releases to any organ was $6.74\text{E-}01$

mrem (Child/bone). The maximum dose from liquid releases to the whole body was 2.83E-01 mrem (adult).

3.3 Gaseous + Liquid Total Dose

The maximum total dose to any organ via both gaseous and liquid effluents to any organ is 1.40E+00 mrem (child/bone). The maximum dose to the whole body via both gaseous and liquid effluents is 3.26E-01 mrem (child).

3.4 Dose Limits to Members of the Public

Byron Station did not exceed any of the dose limits as shown below based on concurrent or historical meteorological data.

- The limits on dose or dose commitment to a member of the public due to radioactive materials in liquid effluents from each reactor is 1.5 mrem to the whole body or 5 mrem to any organ during any calendar quarter and 3 mrem to the whole body or 10 mrem to any organ during a calendar year.
- The limits on air dose in noble gases released in gaseous effluents to a member of the public from each reactor is 5 mrad for gamma radiation or 10 mrad for beta radiation during any calendar quarter and 10 mrad for gamma radiation or 20 mrad for beta radiation during a calendar year.
- The limits on dose to a member of the public due to radioactive iodine & particulate with half-lives greater than eight days in gaseous effluents released from each reactor is 7.5 mrem to any organ during any calendar quarter and 15 mrem during a calendar year.
- The annual 10CFR20 limit on Total Effective Dose Equivalent to individual members of the public is 100 mrem.
- The 40CFR190 limits on individual members of the public is 25 mrem to the whole body, 25 mrem to any organ (except thyroid), and 75 mrem to the thyroid.

4.0 SITE METEOROLOGY

Detailed records of the site meteorological measurements taken during each calendar quarter of the year are maintained by the meteorological vendor, retained on site, and are available upon request. The data are presented as cumulative joint frequency distributions of the wind direction for the 250' level and wind speed class by atmospheric stability class determined from the temperature difference between the 250' and 30' levels. Data recovery for all measurements on the meteorological tower was 99.7% during 2020.

Intentionally left blank

APPENDIX E-1

DATA TABLES AND FIGURES

Intentionally left blank

Table 1.1-1

RG 1.21 EFFLUENT AND WASTE DISPOSAL REPORT
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

Unit 1

<u>REPORT FOR 2020</u>	<u>Units</u>	<u>QTR 1</u>	<u>QTR 2</u>	<u>QTR 3</u>	<u>QTR 4</u>	<u>YEAR</u>
Fission and Activation Gases						
1. Total Release	Ci	2.95E+00	2.15E-01	9.06E-02	7.86E-02	3.33E+00
2. Avg. Release Rate	uCi/sec	3.75E-01	2.73E-02	1.14E-02	9.89E-01	1.05E-01
Iodine-131						
1. Total Release	Ci	(1)	(1)	(1)	(1)	(1)
2. Avg. Release Rate	uCi/sec	(1)	(1)	(1)	(1)	(1)
Particulates Half Life >= 8 days						
1. Total Release	Ci	2.74E-05	2.45E-05	(1)	3.22E-05	8.41E-05
2. Avg. Release Rate	uCi/sec	3.49E-06	3.11E-06	(1)	4.06E-06	2.66E-06
Others						
1. Total Release	Ci	8.02E-01	1.18E+00	1.12E+00	1.44E+00	4.55E+00
2. Avg. Release Rate	uCi/sec	1.02E-01	1.50E-01	1.41E-01	1.81E-01	1.44E-01
Tritium						
1. Total Release	Ci	2.61E+00	1.91E+00	1.98E+00	3.06E+00	9.57E+00
2. Avg. Release Rate	uCi/sec	3.32E-01	2.43E-01	2.50E-01	3.85E-01	3.03E-01
Gross Alpha Radioactivity						
1. Total Release	Ci	(1)	(1)	(1)	(1)	(1)
2. Avg. Release Rate	uCi/sec	(1)	(1)	(1)	(1)	(1)

(1) Less than minimum detectable activity which meets the lower limit of detection (LLD) requirements of TRM Section 3.11

Table 1.1-1 (cont.)

RG 1.21 EFFLUENT AND WASTE DISPOSAL REPORT
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

Unit 2

<u>REPORT FOR 2020</u>	<u>Units</u>	<u>QTR 1</u>	<u>QTR 2</u>	<u>QTR 3</u>	<u>QTR 4</u>	<u>YEAR</u>
Fission and Activation Gases						
1. Total Release	Ci	9.48E-02	1.63E-01	8.48E-02	1.90E-01	5.32E-01
2. Avg. Release Rate	uCi/sec	1.21E-02	2.07E-02	1.07E-02	2.39E-02	1.68E-02
Iodine-131						
1. Total Release	Ci	1.48E-06	(1)	(1)	(1)	1.48E-06
2. Avg. Release Rate	uCi/sec	1.88E-07	(1)	(1)	(1)	4.67E-08
Particulates Half Life >= 8 days						
1. Total Release	Ci	1.05E-05	8.72E-06	(1)	4.66E-05	6.58E-05
2. Avg. Release Rate	uCi/sec	1.33E-06	1.11E-06	(1)	5.87E-06	2.08E-06
Others						
1. Total Release	Ci	1.21E+00	1.10E+00	1.18E+00	8.77E-01	4.36E+00
2. Avg. Release Rate	uCi/sec	1.54E-01	1.40E-01	1.48E-01	1.10E-01	1.38E-01
Tritium						
1. Total Release	Ci	1.15E+01	7.13E+00	9.28E+00	1.03E+01	3.82E+01
2. Avg. Release Rate	uCi/sec	1.47E+00	9.07E-01	1.17E+00	1.29E+00	1.21E+00
Gross Alpha Radioactivity						
1. Total Release	Ci	(1)	(1)	(1)	(1)	(1)
2. Avg. Release Rate	uCi/sec	(1)	(1)	(1)	(1)	(1)

(1) Less than minimum detectable activity which meets the lower limit of detection (LLD) requirements of TRM Section 3.11

Table 1.2-1

RG 1.21 EFFLUENT AND WASTE DISPOSAL REPORT
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

Unit 1

<u>REPORT FOR 2020</u>	<u>Units</u>	<u>QTR 1</u>	<u>QTR 2</u>	<u>QTR 3</u>	<u>QTR 4</u>	<u>YEAR</u>
Fission and Activation Products						
1. Total Release	Ci	1.10E-02	9.42E-03	1.21E-02	1.86E-02	5.11E-02
2. Avg. Diluted Conc.	uCi/ml	3.60E-09	2.63E-09	3.11E-09	5.12E-09	3.61E-09
Tritium						
1. Total Release	Ci	5.98E+02	2.11E+02	4.52E+02	1.44E+02	1.40E+03
2. Avg. Diluted Conc.	uCi/ml	1.96E-04	5.88E-05	1.16E-04	3.97E-05	9.92E-05
Dissolved and Entrained Gases						
1. Total Release	Ci	2.60E-04	8.59E-06	2.18E-04	1.32E-05	4.99E-04
2. Avg. Diluted Conc.	uCi/ml	8.50E-11	2.39E-12	5.60E-11	3.65E-12	3.53E-11
Gross Alpha Radioactivity						
1. Total Release	Ci	(1)	(1)	(1)	(1)	(1)
Volume of liquid waste	liters	3.05E+09	3.59E+09	3.90E+09	3.63E+09	1.42E+10
Volume of dil. water	liters	(1)	(1)	(1)	(1)	(1)

(1) Less than minimum detectable activity which meets the lower limit of detection (LLD) requirements of TRM Section 3.11

Table 1.2-1 (cont.)

RG 1.21 EFFLUENT AND WASTE DISPOSAL REPORT
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

Unit 2

<u>REPORT FOR 2020</u>	<u>Units</u>	<u>QTR 1</u>	<u>QTR 2</u>	<u>QTR 3</u>	<u>QTR 4</u>	<u>YEAR</u>
Fission and Activation Products						
1. Total Release	Ci	1.10E-02	9.42E-03	1.21E-02	1.86E-02	5.11E-02
2. Avg. Diluted Conc.	uCi/ml	3.60E-09	2.63E-09	3.11E-09	5.12E-09	3.61E-09
Tritium						
1. Total Release	Ci	5.98E+02	2.11E+02	4.52E+02	1.44E+02	1.40E+03
2. Avg. Diluted Conc.	uCi/ml	1.96E-04	5.88E-05	1.16E-04	3.97E-05	9.92E-05
Dissolved and Entrained Gases						
1. Total Release	Ci	2.60E-04	8.59E-06	2.18E-04	1.32E-05	4.99E-04
2. Avg. Diluted Conc.	uCi/ml	8.50E-11	2.39E-12	5.60E-11	3.65E-12	3.53E-11
Gross Alpha Radioactivity						
1. Total Release	Ci	(1)	(1)	(1)	(1)	(1)
Volume of liquid waste	liters	3.05E+09	3.59E+09	3.90E+09	3.63E+09	1.42E+10
Volume of dil. water	liters	(1)	(1)	(1)	(1)	(1)

(1) Less than minimum detectable activity which meets the lower limit of detection (LLD) requirements of TRM Section 3.11

Table 3.1-1
40CFR190 URANIUM FUEL CYCLE DOSE REPORT
LIQUID DOSE SUMMARY

Units 1 & 2

Report for: 2020

Unit Range - From: 1 To: 2

Liquid Receptor

PERIOD DOSE BY ORGAN AND AGE GROUP (mrem) ANNUAL 2020

<u>Age Grp</u>	<u>Bone</u>	<u>Liver</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-LLI</u>	<u>Skin</u>	<u>TB</u>
ADULT	4.96E-01	3.65E-01	1.36E-01	2.25E-01	1.57E-01	4.24E-01	0.00E+00	2.83E-01
TEEN	5.19E-01	3.42E-01	1.02E-01	1.73E-01	1.29E-01	3.07E-01	0.00E+00	1.92E-01
CHILD	6.74E-01	3.32E-01	1.14E-01	1.75E-01	1.35E-01	1.88E-01	0.00E+00	1.64E-01
INFANT	2.78E-03	5.02E-02	4.99E-02	4.99E-02	4.99E-02	5.00E-02	0.00E+00	5.00E-02

SITE DOSE LIMIT ANALYSIS ANNUAL 2020

<u>Annual - Limit</u>	<u>Age Group</u>	<u>Organ</u>	<u>Dose (mrem)</u>	<u>Limit (mrem)</u>	<u>Max % of Limit</u>
2020 - Admin. Any Organ	CHILD	BONE	6.74E-01	7.50E+00	8.99E+00
2020 - Admin. Total Body	ADULT	TBODY	2.83E-01	2.25E+00	1.26E+01
2020 - T.Spc. Any Organ	CHILD	BONE	6.74E-01	1.00E+01	6.74E+00

Critical Pathway: Fresh

Major Contributors (0% or greater to total)

<u>Nuclide</u>	<u>Percentage</u>
FE-55	2.76E-01
FE-59	7.32E-03
NI-63	6.95E+01
ZN-65	1.18E-01
SR-89	2.48E-01
ZR-95	3.15E-06
NB-95	1.10E-02
NB-97	2.24E-06
AG-110M	2.14E-06
SB-124	1.48E-05
SB-125	1.18E-03
TE-125M	1.08E+00
TE-132	8.20E-03
I-132	4.93E-05
CS-134	2.24E-01
CS-137	2.85E+01

2020 - T.Spc. Total Body	ADULT	TBODY	2.83E-01	3.00E+00	9.43E+00
--------------------------	-------	-------	----------	----------	----------

Critical Pathway: Fresh

Table 3.1-1 (cont.)
40CFR190 URANIUM FUEL CYCLE DOSE REPORT
LIQUID DOSE SUMMARY

Units 1 & 2

Major Contributors (0% or greater to total)

<u>Nuclide</u>	<u>Percentage</u>
H-3	4.75E+01
CR-51	7.85E-04
MN-54	1.30E-01
MN-56	1.67E-05
FE-55	7.69E-02
FE-59	1.25E-02
CO-58	6.59E-01
CO-60	9.10E-01
NI-63	4.07E+00
ZN-65	4.36E-01
SR-89	1.19E-02
ZR-95	1.18E-06
NB-95	6.59E-03
NB-97	9.89E-07
AG-110M	2.20E-06
SB-124	8.32E-06
SB-125	3.93E-04
TE-125M	2.46E-01
TE-132	9.00E-03
I-132	8.28E-05
CS-134	8.40E-01
CS-137	4.51E+01

Table 3.2-1
40CFR190 URANIUM FUEL CYCLE DOSE REPORT
GASEOUS DOSE SUMMARY

Units 1 & 2

Report for: 2020
Unit Range - From: 1 To: 2

<u>Annual - Limit</u>	I&P DOSE LIMIT ANALYSIS		ANNUAL 2020		
	<u>Age Group</u>	<u>Organ</u>	<u>Dose (mrem)</u>	<u>Limit (mrem)</u>	<u>Max % of Limit</u>
2020 - Admin. Any Organ	CHILD	BONE	7.26E-01	1.13E+01	6.45E+00
2020 - Admin. Total Body	CHILD	TBODY	1.48E-01	1.05E+01	1.41E+00
2020 - T.Spc. Any Organ	CHILD	BONE	7.26E-01	1.50E+01	4.84E+00

Receptor: Composite Crit. Receptor - IP
Distance: 0.00 (meters) Compass Point: SNA
Critical Pathway: Vegetation
Major Contributors (0% or greater to total)

<u>Nuclide</u>	<u>Percentage</u>
H-3	0.00E+00
C-14	1.00E+02
CO-58	1.30E-04
CO-60	4.56E-02
I-131	3.60E-05

2020 - T.Spc. Total Body	CHILD	TBODY	1.48E-01	1.50E+01	9.88E-01
--------------------------	-------	-------	----------	----------	----------

Receptor: Composite Crit. Receptor - IP
Distance: 0.00 (meters) Compass Point: NA
Critical Pathway: Vegetation
Major Contributors (0% or greater to total)

<u>Nuclide</u>	<u>Percentage</u>
H-3	1.82E+00
C-14	9.79E+01
CO-58	1.11E-03
CO-60	2.39E-01
I-131	1.02E-04

Table 3.2-1 (cont.)

40CFR190 URANIUM FUEL CYCLE DOSE REPORT

GASEOUS DOSE SUMMARY

Units 1 & 2

Report for: 2020

Unit Range - From: 1 To: 2

NG DOSE LIMIT ANALYSIS ANNUAL 2020

<u>Annual - Limit</u>	<u>Dose (mrad)</u>	<u>Limit (mrad)</u>	<u>Max % of Limit</u>
2020 - Admin. Gamma	2.84E-04	7.50E+00	3.78E-03
2020 - Admin. Beta	6.86E-05	1.50E+01	4.58E-04
2020 - T.Spc. Gamma	2.84E-04	1.00E+01	2.84E-03

Receptor: 4 Composite Crit. Receptor - NG
Distance: 0.00 (meters) Compass Point: NA

<u>Nuclide</u>	<u>Percentage</u>
AR-41	7.58E+01
KR-85M	1.37E-03
XE-135	1.52E-01
XE-133M	3.50E-03
KR-88	8.85E-03
XE-131M	6.73E-04
XE-133	2.40E+01

2020 - T.Spc. Beta	6.86E-05	2.00E+01	3.43E-04
--------------------	----------	----------	----------

Receptor: 4 Composite Crit. Receptor - NG
Distance: 0.00 (meters) Compass Point: NA

<u>Nuclide</u>	<u>Percentage</u>
AR-41	2.72E+01
KR-85M	2.22E-03
XE-135	1.97E-01
XE-133M	1.61E-02
KR-88	1.73E-03
XE-131M	4.86E-03
XE-133	7.26E+01

Table 3.3-1

40CFR190 URANIUM FUEL CYCLE DOSE REPORT

Units 1 & 2

Report for: 2020

Unit Range - From: 1 To: 2

MAXIMUM DOSE ANALYSIS ANNUAL 2020

<u>Dose Type</u>	<u>Age Group</u>	<u>Organ</u>	<u>Dose (mrem)</u>
Any Organ	CHILD	BONE	1.40E+00
Liquid Receptor: Liquid Receptor			
Gaseous Receptor: 5 Composite Crit. Receptor - IP			
Distance: 0.00 (meters) Compass Point: NA			

Liquid Dose: 6.74E-01 % of Total: 4.81E+01

Critical Pathway: Fresh Water Fish - Sport (FFSP)

Major Contributors (0% or greater to total)

<u>Nuclide</u>	<u>Percentage</u>
H-3	0.00E+00
CR-51	0.00E+00
MN-54	0.00E+00
MN-56	0.00E+00
FE-55	2.76E-01
FE-59	7.32E-03
CO-58	0.00E+00
CO-60	0.00E+00
NI-63	6.95E+01
ZN-65	1.18E-01
SR-89	2.48E-01
ZR-95	3.15E-06
NB-95	1.10E-02
NB-97	2.24E-06
AG-110M	2.14E-06
SB-124	1.48E-05
SB-125	1.18E-03
TE-125M	1.08E+00
TE-132	8.20E-03
I-132	4.93E-05
CS-134	2.24E-01
CS-137	2.85E+01

Gaseous Dose: 7.26E-01 % of Total: 5.19E+01

Critical Pathway: Vegetation (VEG)

Major Contributors (0% or greater to total)

<u>Nuclide</u>	<u>Percentage</u>
H-3	0.00E+00
C-14	1.00E+02
CO-58	1.30E-04
CO-60	4.56E-02
I-131	3.60E-05

Table 3.3-1 (cont.)

40CFR190 URANIUM FUEL CYCLE DOSE REPORT

Units 1 & 2

MAXIMUM DOSE ANALYSIS ANNUAL 2020

<u>Dose Type</u>	<u>Age Group</u>	<u>Organ</u>	<u>Dose (mrem)</u>
Total Body	CHILD	TBODY	3.26E-01

Liquid Receptor: Liquid Receptor
 Gaseous Receptor: 5 Composite Crit. Receptor - IP
 Distance: 0.00 (meters) Compass Point: NA

Liquid Dose: 2.83E-01 % of Total: 8.68E+01
 Critical Pathway: Fresh Water Fish - Sport (FFSP)
 Major Contributors (0% or greater to total)

Nuclide Percentage

H-3	4.75E+01
CR-51	7.85E-04
MN-54	1.30E-01
MN-56	1.67E-05
FE-55	7.69E-02
FE-59	1.25E-02
CO-58	6.59E-01
CO-60	9.10E-01
NI-63	4.07E+00
ZN-65	4.36E-01
SR-89	1.19E-02
ZR-95	1.18E-06
NB-95	6.59E-03
NB-97	9.89E-07
AG-110M	2.20E-06
SB-124	8.32E-06
SB-125	3.93E-04
TE-125M	2.46E-01
TE-132	9.00E-03
I-132	8.28E-05
CS-134	8.40E-01
CS-137	4.51E+01

Gaseous Dose: 4.30E-02 % of Total: 1.32E+01
 Critical Pathway: Vegetation (VEG)
 Major Contributors (0% or greater to total)

Nuclide Percentage

H-3	4.16E+00
C-14	9.50E+01
CO-58	2.89E-03
CO-60	7.91E-01
I-131	1.38E-04

Table 3.4-1

The following are the maximum annual calculated cumulative offsite doses resulting from Byron airborne releases in 2020 based on concurrent meteorological data:

Unit 1:

<u>Dose</u>	<u>Maximum Value</u>	<u>Sector Affected</u>
gamma air ⁽¹⁾	3.32 x10 ⁻⁵ mrad	East-Southeast
beta air ⁽²⁾	4.20 x10 ⁻⁵ mrad	East-Southeast
whole body ⁽³⁾	7.06 x10 ⁻² mrem	East-Southeast
skin ⁽⁴⁾	4.21 x10 ⁻⁵ mrem	East-Southeast
organ ⁽⁵⁾ (child-bone)	3.49 x10 ⁻¹ mrem	East-Southeast

Unit 1 Compliance Status

10 CFR 50 Appendix I	Yearly Objective	% of Appendix I
gamma air	10.0 mrad	0.00
beta air	20.0 mrad	0.00
whole body	5.0 mrem	1.41
skin	15.0 mrem	0.00
organ	15.0 mrem	2.33

Unit 2:

<u>Dose</u>	<u>Maximum Value</u>	<u>Sector Affected</u>
gamma air ⁽¹⁾	2.93 x10 ⁻⁵ mrad	East-Southeast
beta air ⁽²⁾	1.26 x10 ⁻⁵ mrad	East-Southeast
whole body ⁽³⁾	6.94 x10 ⁻² mrem	East-Southeast
skin ⁽⁴⁾	3.17 x10 ⁻⁵ mrem	East-Southeast
organ ⁽⁵⁾ (child-bone)	3.35 x10 ⁻¹ mrem	East-Southeast

Unit 2 Compliance Status

10 CFR 50 Appendix I	Yearly Objective	% of Appendix I
gamma air	10.0 mrad	0.00
beta air	20.0 mrad	0.00
whole body	5.0 mrem	1.39
skin	15.0 mrem	0.00
organ	15.0 mrem	2.23

(1) Gamma Air Dose - GASPAR II, NUREG-0597
 (2) Beta Air Dose - GASPAR II, NUREG-0597
 (3) Whole Body Dose - GASPAR II, NUREG-0597
 (4) Skin Dose - GASPAR II, NUREG-0597
 (5) Inhalation and Food Pathways Dose - GASPAR II, NUREG-0597

Data recovery: 99.7%

Intentionally left blank

APPENDIX F

METEOROLOGICAL DATA

Intentionally left blank

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Extremely Unstable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	4	0	0	0	4
SSE	0	0	3	1	0	0	4
S	0	0	2	1	0	0	3
SSW	0	2	0	0	0	0	2
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	2	9	2	0	0	13

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Moderately Unstable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	1	0	0	0	0	1
SSW	0	0	1	0	0	0	1
SW	0	0	0	0	0	0	0
WSW	0	0	1	0	0	0	1
W	1	0	0	0	0	0	1
WNW	0	0	0	0	0	0	0
NW	1	1	1	0	0	0	3
NNW	0	1	0	1	0	0	2
Variable	0	0	0	0	0	0	0
Total	2	3	3	1	0	0	9

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Slightly Unstable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	1	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	0	1	0	0	0	0	1
E	0	1	0	0	0	0	1
ESE	0	0	1	0	0	0	1
SE	0	0	0	0	0	0	0
SSE	0	0	2	0	0	0	2
S	0	1	1	0	0	0	2
SSW	0	0	1	0	0	0	1
SW	0	0	0	0	0	0	0
WSW	0	1	1	0	0	0	2
W	0	0	0	2	0	0	2
WNW	0	0	0	1	0	0	1
NW	1	2	2	0	0	0	5
NNW	0	1	4	1	0	0	6
Variable	0	0	0	0	0	0	0
Total	1	7	12	4	0	0	24

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Neutral - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	21	49	51	0	0	122
NNE	5	28	22	32	0	0	87
NE	9	25	26	1	0	0	61
ENE	3	29	31	0	0	0	63
E	5	29	6	0	0	0	40
ESE	3	24	26	12	0	0	65
SE	0	18	19	13	0	0	50
SSE	3	23	39	13	0	0	78
S	2	34	39	23	1	0	99
SSW	4	23	15	13	4	0	59
SW	1	23	25	9	0	0	58
WSW	3	17	32	10	2	0	64
W	10	26	64	25	14	3	142
WNW	7	37	47	48	6	0	145
NW	1	66	42	34	0	0	143
NNW	3	28	48	28	6	0	113
Variable	0	0	0	0	0	0	0
Total	60	451	530	312	33	3	1389

Hours of calm in this stability class: 1
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Slightly Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	4	6	1	0	0	0	11
NNE	3	7	14	1	0	0	25
NE	3	7	8	2	0	0	20
ENE	1	4	7	1	0	0	13
E	6	13	1	0	0	0	20
ESE	5	15	11	8	3	0	42
SE	2	10	3	3	0	0	18
SSE	2	16	27	9	0	0	54
S	3	14	36	29	1	0	83
SSW	7	3	19	19	0	0	48
SW	9	28	21	9	0	0	67
WSW	4	26	5	5	1	0	41
W	11	30	19	8	0	0	68
WNW	7	30	17	10	1	0	65
NW	5	31	8	5	1	0	50
NNW	5	15	5	0	0	0	25
Variable	0	0	0	0	0	0	0
Total	77	255	202	109	7	0	650

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Moderately Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	3	0	0	0	0	3
NNE	2	1	0	0	0	0	3
NE	0	0	1	0	0	0	1
ENE	0	0	0	0	0	0	0
E	0	4	0	0	0	0	4
ESE	0	5	2	0	0	0	7
SE	0	6	0	0	0	0	6
SSE	0	7	3	2	0	0	12
S	2	6	1	0	0	0	9
SSW	1	1	0	0	0	0	2
SW	1	1	0	0	0	0	2
WSW	4	3	0	0	0	0	7
W	5	3	0	0	0	0	8
WNW	5	2	0	0	0	0	7
NW	4	4	0	0	0	0	8
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	24	46	7	2	0	0	79

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Extremely Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	2	0	0	0	0	2
SSE	0	0	1	0	0	0	1
S	0	1	0	0	0	0	1
SSW	3	0	0	0	0	0	3
SW	1	0	0	0	0	0	1
WSW	3	0	0	0	0	0	3
W	2	0	0	0	0	0	2
WNW	1	0	0	0	0	0	1
NW	1	0	0	0	0	0	1
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	11	3	1	0	0	0	15

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Extremely Unstable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	3	1	0	4
SSE	0	0	0	3	1	0	4
S	0	0	3	1	0	0	4
SSW	0	1	0	0	0	0	1
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	1	3	7	2	0	13

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Moderately Unstable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	2	0	0	0	2
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	1	0	0	1
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	1	2	0	0	0	3
NNW	0	1	1	1	0	0	3
Variable	0	0	0	0	0	0	0
Total	0	2	5	2	0	0	9

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Slightly Unstable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	1	0	0	0	1
E	0	0	1	0	0	0	1
ESE	0	0	0	1	0	0	1
SE	0	0	0	0	0	0	0
SSE	0	0	0	1	1	0	2
S	0	1	0	1	0	0	2
SSW	0	0	0	0	1	0	1
SW	0	0	0	0	0	0	0
WSW	0	0	2	0	0	0	2
W	0	0	0	0	2	0	2
WNW	0	0	0	1	0	0	1
NW	0	0	4	1	0	0	5
NNW	0	2	1	3	0	0	6
Variable	0	0	0	0	0	0	0
Total	0	3	9	8	4	0	24

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Neutral - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	6	29	22	19	0	77
NNE	0	21	20	26	30	1	98
NE	3	14	17	20	2	0	56
ENE	1	9	28	22	2	0	62
E	2	7	27	11	1	0	48
ESE	1	6	10	31	12	3	63
SE	1	5	7	13	8	4	38
SSE	2	9	12	24	7	3	57
S	1	15	28	24	30	2	100
SSW	1	9	21	8	12	4	55
SW	0	11	19	23	10	2	65
WSW	1	6	28	12	4	4	55
W	2	11	33	51	12	22	131
WNW	3	16	31	49	32	4	135
NW	3	39	49	45	19	0	155
NNW	2	19	25	39	19	6	110
Variable	0	0	0	0	0	0	0
Total	24	203	384	420	219	55	1305

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 85
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Slightly Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	4	8	5	0	0	18
NNE	2	6	6	2	8	0	24
NE	1	2	6	6	9	0	24
ENE	2	3	4	3	6	0	18
E	2	3	3	4	1	0	13
ESE	1	3	9	8	11	6	38
SE	0	2	10	7	2	2	23
SSE	0	1	10	5	10	8	34
S	0	0	9	23	28	28	88
SSW	0	2	6	11	29	11	59
SW	1	4	17	17	18	4	61
WSW	0	0	19	17	7	1	44
W	2	3	22	36	7	2	72
WNW	1	3	18	20	9	2	53
NW	0	1	25	25	6	1	58
NNW	0	4	12	7	0	0	23
Variable	0	0	0	0	0	0	0
Total	13	41	184	196	151	65	650

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Moderately Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	1	4	0	0	5
NNE	0	0	0	1	1	0	2
NE	0	1	1	0	0	0	2
ENE	0	0	1	1	0	0	2
E	0	0	1	0	0	0	1
ESE	1	0	0	7	1	0	9
SE	0	0	1	4	1	0	6
SSE	0	0	0	3	0	1	4
S	0	0	0	4	3	1	8
SSW	0	0	0	4	2	0	6
SW	0	1	2	2	0	0	5
WSW	0	0	0	3	0	0	3
W	1	1	2	4	0	0	8
WNW	0	0	5	0	0	0	5
NW	0	1	2	2	0	0	5
NNW	0	0	5	3	0	0	8
Variable	0	0	0	0	0	0	0
Total	2	4	21	42	8	2	79

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: January - March 2020
 Stability Class - Extremely Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	1	0	0	1
S	0	0	1	0	1	0	2
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	3	0	0	0	3
W	0	0	1	0	0	0	1
WNW	0	0	4	0	0	0	4
NW	0	0	2	0	0	0	2
NNW	0	0	1	1	0	0	2
Variable	0	0	0	0	0	0	0
Total	0	0	12	2	1	0	15

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 4

Byron Generating Station

Period of Record: April - June 2020

Stability Class - Extremely Unstable - 250Ft-30Ft Delta-T (F)

Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	7	0	0	0	0	7
NNE	0	5	0	0	0	0	5
NE	0	2	0	0	0	0	2
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	1	0	0	0	1
SSE	0	3	2	0	0	0	5
S	0	0	1	1	0	0	2
SSW	0	0	1	0	0	0	1
SW	0	2	0	0	0	0	2
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	1	0	0	0	1
NW	0	0	1	0	0	0	1
NNW	0	0	2	0	0	0	2
Variable	0	0	0	0	0	0	0
Total	0	19	9	1	0	0	29

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020

Stability Class - Moderately Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	1	0	0	0	1
E	0	0	2	0	0	0	2
ESE	0	0	0	0	0	0	0
SE	0	1	0	0	0	0	1
SSE	0	0	0	1	0	0	1
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	1	1	0	2
W	0	0	1	2	1	0	4
WNW	0	0	0	1	0	0	1
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	1	4	5	2	0	12

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020

Stability Class - Slightly Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	2	0	0	0	2
ENE	0	0	2	0	0	0	2
E	0	0	7	0	0	0	7
ESE	0	1	7	0	0	0	8
SE	0	1	2	4	0	0	7
SSE	0	1	2	4	1	0	8
S	0	0	1	1	0	0	2
SSW	0	2	0	0	0	0	2
SW	0	2	3	4	2	0	11
WSW	0	0	0	2	0	0	2
W	0	2	2	5	0	0	9
WNW	0	1	6	1	2	0	10
NW	0	0	6	4	0	0	10
NNW	0	1	0	0	0	0	1
Variable	0	0	0	0	0	0	0
Total	0	11	40	25	5	0	81

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020
 Stability Class - Neutral - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	3	14	25	17	5	0	64
NNE	2	23	17	6	0	0	48
NE	3	14	25	11	0	0	53
ENE	3	14	27	1	0	0	45
E	4	19	45	0	0	0	68
ESE	2	19	24	8	0	0	53
SE	2	11	28	12	5	0	58
SSE	1	16	44	18	1	0	80
S	2	19	41	9	1	0	72
SSW	1	20	17	13	4	0	55
SW	1	30	13	7	3	0	54
WSW	2	15	21	11	2	0	51
W	4	22	37	13	1	0	77
WNW	1	19	41	31	7	0	99
NW	1	21	57	23	12	1	115
NNW	2	12	25	30	4	0	73
Variable	0	0	0	0	0	0	0
Total	34	288	487	210	45	1	1065

Hours of calm in this stability class: 1
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020
 Stability Class - Slightly Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	7	15	5	0	0	0	27
NNE	2	3	7	1	0	0	13
NE	2	5	10	2	0	0	19
ENE	6	12	21	6	0	0	45
E	3	55	11	0	0	0	69
ESE	7	21	26	0	2	0	56
SE	7	27	29	1	2	0	66
SSE	1	26	25	2	0	0	54
S	9	24	19	0	0	0	52
SSW	12	10	11	2	0	0	35
SW	12	26	10	5	0	0	53
WSW	11	12	17	1	0	0	41
W	10	36	14	2	0	0	62
WNW	4	23	16	8	0	0	51
NW	5	23	10	0	0	0	38
NNW	6	17	9	6	1	0	39
Variable	0	0	0	0	0	0	0
Total	104	335	240	36	5	0	720

Hours of calm in this stability class: 1
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020

Stability Class - Moderately Stable - 250Ft-30Ft Delta-T (F)
Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	5	0	0	0	0	5
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	15	0	0	0	0	15
ESE	4	25	20	0	0	0	49
SE	5	31	9	0	0	0	45
SSE	1	11	3	0	0	0	15
S	9	7	1	0	0	0	17
SSW	12	1	0	0	0	0	13
SW	3	1	0	0	0	0	4
WSW	8	0	0	0	0	0	8
W	7	2	0	0	0	0	9
WNW	11	3	0	0	0	0	14
NW	7	9	0	0	0	0	16
NNW	2	11	0	0	0	0	13
Variable	0	0	0	0	0	0	0
Total	69	121	33	0	0	0	223

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020
 Stability Class - Extremely Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	3	0	0	0	0	3
ESE	0	5	8	0	0	0	13
SE	2	6	0	0	0	0	8
SSE	1	4	0	0	0	0	5
S	3	2	0	0	0	0	5
SSW	3	1	0	0	0	0	4
SW	0	0	0	0	0	0	0
WSW	2	0	0	0	0	0	2
W	3	0	0	0	0	0	3
WNW	2	0	0	0	0	0	2
NW	2	1	0	0	0	0	3
NNW	1	0	0	0	0	0	1
Variable	0	0	0	0	0	0	0
Total	19	22	8	0	0	0	49

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020

Stability Class - Extremely Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	1	0	0	0	3
NNE	0	2	7	0	0	0	9
NE	0	1	1	0	0	0	2
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	1	0	2	0	0	3
S	0	0	1	3	1	0	5
SSW	0	0	0	1	0	0	1
SW	0	1	0	1	0	0	2
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	1	0	0	0	1
NW	0	0	0	1	0	0	1
NNW	0	0	0	2	0	0	2
Variable	0	0	0	0	0	0	0
Total	0	7	11	10	1	0	29

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020

Stability Class - Moderately Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	1	0	0	0	1
E	0	0	2	0	0	0	2
ESE	0	0	0	0	0	0	0
SE	0	0	1	0	0	0	1
SSE	0	0	0	0	0	1	1
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	1	0	1	2
W	0	0	0	1	2	1	4
WNW	0	0	0	0	1	0	1
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	0	4	2	3	3	12

Hours of calm in this stability class: 0
Hours of missing wind measurements in this stability class: 0
Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020

Stability Class - Slightly Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	4	0	0	0	4
E	0	0	6	1	0	0	7
ESE	0	0	6	2	0	0	8
SE	0	0	2	3	2	0	7
SSE	0	0	2	3	1	1	7
S	0	0	0	2	1	0	3
SSW	0	0	1	0	0	0	1
SW	0	0	3	3	3	3	12
WSW	0	1	0	2	0	0	3
W	0	0	1	7	2	0	10
WNW	0	0	1	6	1	2	10
NW	0	0	1	3	4	0	8
NNW	0	0	1	0	0	0	1
Variable	0	0	0	0	0	0	0
Total	0	1	28	32	14	6	81

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020
 Stability Class - Neutral - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	10	19	9	11	3	52
NNE	0	12	15	16	7	0	50
NE	2	6	21	19	5	0	53
ENE	1	8	19	21	2	0	51
E	3	6	26	33	0	0	68
ESE	2	3	29	10	8	1	53
SE	3	5	12	20	7	5	52
SSE	0	8	34	33	11	3	89
S	1	7	31	16	7	3	65
SSW	0	14	17	14	10	4	59
SW	1	16	17	9	6	8	57
WSW	0	11	18	12	10	2	53
W	1	9	33	27	6	3	79
WNW	0	9	24	41	19	9	102
NW	0	11	36	40	10	11	108
NNW	3	3	22	24	12	11	75
Variable	0	0	0	0	0	0	0
Total	17	138	373	344	131	63	1066

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020
 Stability Class - Slightly Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	7	6	11	0	1	26
NNE	1	4	3	10	1	0	19
NE	1	2	8	3	1	0	15
ENE	0	2	4	22	13	0	41
E	0	8	26	26	4	0	64
ESE	0	3	8	23	11	2	47
SE	0	3	12	27	15	3	60
SSE	0	2	14	31	12	1	60
S	2	4	6	21	9	0	42
SSW	3	6	17	11	8	0	45
SW	1	3	22	12	12	2	52
WSW	0	5	21	18	0	0	44
W	1	8	22	35	2	0	68
WNW	1	4	18	20	11	0	54
NW	1	6	27	12	0	0	46
NNW	2	6	12	11	5	2	38
Variable	0	0	0	0	0	0	0
Total	14	73	226	293	104	11	721

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020

Stability Class - Moderately Stable - 250Ft-30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	8	9	0	0	17
NNE	0	0	1	1	0	0	2
NE	0	0	0	0	0	0	0
ENE	1	0	0	0	0	0	1
E	0	3	3	3	1	0	10
ESE	0	0	8	7	13	0	28
SE	0	1	6	26	10	0	43
SSE	0	1	4	18	4	0	27
S	0	0	5	5	2	0	12
SSW	0	1	8	3	0	0	12
SW	0	2	7	6	0	0	15
WSW	0	3	2	1	0	0	6
W	0	1	5	5	0	0	11
WNW	0	2	5	3	0	0	10
NW	0	1	6	5	0	0	12
NNW	0	1	7	9	0	0	17
Variable	0	0	0	0	0	0	0
Total	1	16	75	101	30	0	223

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: April - June 2020
 Stability Class - Extremely Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	1	0	0	1
NNE	1	0	0	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	0	1	0	0	0	0	1
E	0	0	0	0	0	0	0
ESE	0	1	1	1	6	0	9
SE	0	0	0	4	2	0	6
SSE	0	0	3	2	0	0	5
S	0	1	1	2	1	0	5
SSW	0	0	5	2	0	0	7
SW	0	1	1	3	0	0	5
WSW	0	0	1	0	0	0	1
W	0	0	4	0	0	0	4
WNW	0	0	2	0	0	0	2
NW	0	0	1	1	0	0	2
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	1	4	19	16	9	0	49

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020
 Stability Class - Extremely Unstable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	1	0	0	1
S	0	2	0	0	0	0	2
SSW	0	0	2	0	0	0	2
SW	0	1	1	0	0	0	2
WSW	0	0	2	0	0	0	2
W	0	0	6	0	0	0	6
WNW	0	1	1	0	0	0	2
NW	0	1	4	0	0	0	5
NNW	0	0	2	0	0	0	2
Variable	0	0	0	0	0	0	0
Total	0	5	18	1	0	0	24

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020

Stability Class - Moderately Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	1	0	0	0	1
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	2	0	0	0	0	2
SE	0	1	0	0	0	0	1
SSE	0	1	2	0	0	0	3
S	0	0	5	0	0	0	5
SSW	0	1	4	0	0	0	5
SW	0	1	6	0	0	0	7
WSW	0	0	1	0	0	0	1
W	0	1	3	0	0	0	4
WNW	0	0	0	4	0	0	4
NW	0	2	5	0	0	0	7
NNW	0	0	1	0	0	0	1
Variable	0	0	0	0	0	0	0
Total	0	9	28	4	0	0	41

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020
 Stability Class - Slightly Unstable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	1	0	0	0	2
NNE	0	1	1	0	0	0	2
NE	0	1	1	0	0	0	2
ENE	0	1	0	0	0	0	1
E	0	1	0	0	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	3	0	0	0	0	3
SSE	0	3	1	0	0	0	4
S	0	3	6	1	0	0	10
SSW	0	2	9	0	0	0	11
SW	0	6	3	0	0	0	9
WSW	0	3	4	0	0	0	7
W	0	3	5	0	0	0	8
WNW	0	1	2	0	0	0	3
NW	0	1	2	0	0	0	3
NNW	0	1	1	0	0	0	2
Variable	0	0	0	0	0	0	0
Total	0	31	36	1	0	0	68

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020
 Stability Class - Neutral - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	24	57	0	0	0	82
NNE	2	18	28	4	0	0	52
NE	3	21	11	1	0	0	36
ENE	7	22	15	0	0	0	44
E	13	25	1	0	0	0	39
ESE	7	28	3	0	0	0	38
SE	6	14	11	0	0	0	31
SSE	1	24	28	1	0	0	54
S	4	38	45	8	0	0	95
SSW	2	23	16	1	0	0	42
SW	3	47	19	2	0	0	71
WSW	5	33	11	0	0	0	49
W	3	53	12	2	1	0	71
WNW	3	28	20	9	2	0	62
NW	4	26	24	7	3	0	64
NNW	2	20	15	1	0	0	38
Variable	0	0	0	0	0	0	0
Total	66	444	316	36	6	0	868

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020
 Stability Class - Slightly Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	9	36	2	1	0	0	48
NNE	5	12	3	0	0	0	20
NE	10	9	2	0	0	0	21
ENE	5	17	1	0	0	0	23
E	11	22	0	0	0	0	33
ESE	7	5	3	0	0	0	15
SE	6	13	7	0	0	0	26
SSE	4	49	10	0	0	0	63
S	6	40	15	7	0	0	68
SSW	6	27	15	4	0	0	52
SW	7	30	21	1	0	0	59
WSW	15	16	3	0	0	0	34
W	11	26	5	0	0	0	42
WNW	9	17	4	1	0	0	31
NW	11	20	2	1	0	0	34
NNW	4	30	5	2	0	0	41
Variable	0	0	0	0	0	0	0
Total	126	369	98	17	0	0	610

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020
 Stability Class - Moderately Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	3	6	1	0	0	0	10
NNE	3	5	0	1	0	0	9
NE	1	0	0	0	0	0	1
ENE	2	7	0	0	0	0	9
E	11	13	0	0	0	0	24
ESE	10	17	1	0	0	0	28
SE	7	17	1	0	0	0	25
SSE	7	57	2	0	0	0	66
S	11	44	1	0	0	0	56
SSW	15	11	0	0	0	0	26
SW	11	4	0	0	0	0	15
WSW	7	1	0	0	0	0	8
W	15	12	0	0	0	0	27
WNW	14	4	0	0	0	0	18
NW	11	8	0	0	0	0	19
NNW	5	15	1	0	0	0	21
Variable	0	0	0	0	0	0	0
Total	133	221	7	1	0	0	362

Hours of calm in this stability class: 3
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020
 Stability Class - Extremely Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	1	0	0	0	0	0	1
NE	1	0	0	0	0	0	1
ENE	1	0	0	0	0	0	1
E	6	4	0	0	0	0	10
ESE	5	24	2	0	0	0	31
SE	7	17	3	0	0	0	27
SSE	9	20	0	0	0	0	29
S	22	23	0	0	0	0	45
SSW	18	2	0	0	0	0	20
SW	7	0	0	0	0	0	7
WSW	11	0	0	0	0	0	11
W	17	1	0	0	0	0	18
WNW	8	0	0	0	0	0	8
NW	4	2	0	0	0	0	6
NNW	5	0	0	0	0	0	5
Variable	0	0	0	0	0	0	0
Total	122	93	5	0	0	0	220

Hours of calm in this stability class: 9
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020

Stability Class - Extremely Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	1	0	1
S	0	0	0	2	0	0	2
SSW	0	0	1	1	0	0	2
SW	0	0	1	1	0	0	2
WSW	0	0	0	3	0	0	3
W	0	0	1	4	0	0	5
WNW	0	0	1	0	0	0	1
NW	0	0	2	5	0	0	7
NNW	0	0	0	1	0	0	1
Variable	0	0	0	0	0	0	0
Total	0	0	6	17	1	0	24

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020

Stability Class - Moderately Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	1	0	0	0	1
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	1	1	0	0	0	2
SE	0	0	1	0	0	0	1
SSE	0	0	1	2	0	0	3
S	0	0	0	5	0	0	5
SSW	0	0	2	4	0	0	6
SW	0	0	1	5	0	0	6
WSW	0	0	0	2	0	0	2
W	0	0	1	2	0	0	3
WNW	0	0	0	1	2	1	4
NW	0	0	4	3	0	0	7
NNW	0	0	0	1	0	0	1
Variable	0	0	0	0	0	0	0
Total	0	1	12	25	2	1	41

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020

Stability Class - Slightly Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	1	0	0	0	1
NNE	0	0	2	0	0	0	2
NE	0	1	2	0	0	0	3
ENE	0	0	1	0	0	0	1
E	0	1	0	0	0	0	1
ESE	0	1	0	0	0	0	1
SE	0	2	1	0	0	0	3
SSE	0	1	2	1	0	0	4
S	0	2	3	2	1	0	8
SSW	0	0	8	3	0	0	11
SW	0	2	8	3	0	0	13
WSW	0	0	3	2	0	0	5
W	0	1	3	3	0	0	7
WNW	0	1	1	2	0	0	4
NW	0	0	0	2	0	0	2
NNW	0	0	1	1	0	0	2
Variable	0	0	0	0	0	0	0
Total	0	12	36	19	1	0	68

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020
 Stability Class - Neutral - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	7	32	22	0	0	63
NNE	1	2	22	31	10	0	66
NE	1	9	12	17	2	1	42
ENE	4	5	14	17	1	0	41
E	2	21	15	2	0	0	40
ESE	4	23	13	6	0	0	46
SE	1	10	8	7	1	0	27
SSE	1	7	21	20	3	0	52
S	2	14	34	31	10	2	93
SSW	1	5	24	18	2	0	50
SW	0	20	32	17	5	0	74
WSW	1	18	17	8	2	0	46
W	0	28	30	9	2	3	72
WNW	0	12	28	15	7	2	64
NW	2	10	19	19	4	3	57
NNW	0	8	16	11	0	0	35
Variable	0	0	0	0	0	0	0
Total	22	199	337	250	49	11	868

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020
 Stability Class - Slightly Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	3	13	12	1	0	29
NNE	1	6	16	19	1	0	43
NE	0	9	10	12	1	0	32
ENE	3	4	10	5	0	0	22
E	2	9	18	3	0	0	32
ESE	1	1	6	2	1	0	11
SE	1	3	3	7	6	1	21
SSE	2	4	8	20	3	0	37
S	0	10	11	35	11	5	72
SSW	1	1	15	28	12	5	62
SW	0	3	15	33	23	1	75
WSW	0	7	13	6	1	0	27
W	0	5	16	10	0	0	31
WNW	0	5	18	17	2	0	42
NW	3	6	19	12	0	0	40
NNW	1	10	12	10	1	0	34
Variable	0	0	0	0	0	0	0
Total	15	86	203	231	63	12	610

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020
 Stability Class - Moderately Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	5	6	3	0	16
NNE	0	1	1	7	0	0	9
NE	0	4	1	5	0	0	10
ENE	2	1	3	2	0	0	8
E	1	5	10	7	2	0	25
ESE	0	0	12	11	4	0	27
SE	0	4	3	5	0	0	12
SSE	0	2	4	12	6	0	24
S	0	3	7	31	9	0	50
SSW	0	2	10	38	0	0	50
SW	1	1	8	20	1	0	31
WSW	0	4	7	13	0	0	24
W	0	5	4	6	0	0	15
WNW	0	1	18	6	0	0	25
NW	0	3	6	9	0	0	18
NNW	1	3	7	9	1	0	21
Variable	0	0	0	0	0	0	0
Total	5	41	106	187	26	0	365

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: July - September 2020
 Stability Class - Extremely Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	3	0	1	2	0	0	6
NNE	0	2	1	0	0	0	3
NE	1	2	1	0	0	0	4
ENE	2	1	2	0	0	0	5
E	4	4	2	2	0	0	12
ESE	1	7	5	11	4	0	28
SE	0	3	4	8	9	0	24
SSE	0	3	8	9	7	1	28
S	0	4	6	5	2	0	17
SSW	0	5	7	19	1	0	32
SW	0	4	6	22	0	0	32
WSW	0	1	8	4	0	0	13
W	1	6	3	0	0	0	10
WNW	0	1	3	3	0	0	7
NW	1	0	1	2	0	0	4
NNW	0	1	2	1	0	0	4
Variable	0	0	0	0	0	0	0
Total	13	44	60	88	23	1	229

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 3

Byron Generating Station

Period of Record: October - December 2020

Stability Class - Extremely Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020

Stability Class - Moderately Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	1	1	0	0	0	2
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	1	0	0	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	0	1	0	0	0	1
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	2	2	0	0	0	4

Hours of calm in this stability class: 0
Hours of missing wind measurements in this stability class: 0
Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020

Stability Class - Slightly Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	1	0	0	0	1
NNE	0	0	0	0	0	0	0
NE	0	1	0	0	0	0	1
ENE	0	2	1	0	0	0	3
E	0	2	0	0	0	0	2
ESE	0	0	1	0	0	0	1
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	2	0	0	2
SSW	0	0	0	3	0	0	3
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	1	0	2	0	0	3
WNW	0	0	0	2	0	0	2
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	6	3	9	0	0	18

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020
 Stability Class - Neutral - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	23	35	22	0	0	82
NNE	4	34	3	8	0	0	49
NE	0	5	2	13	0	0	20
ENE	1	9	8	0	0	0	18
E	4	19	5	1	0	0	29
ESE	1	7	4	5	0	0	17
SE	1	6	12	11	4	0	34
SSE	1	3	16	21	3	0	44
S	0	11	23	35	15	0	84
SSW	1	10	34	14	6	0	65
SW	5	18	49	5	1	0	78
WSW	7	27	31	8	5	7	85
W	3	24	39	38	15	2	121
WNW	4	28	45	30	10	0	117
NW	6	27	63	27	7	0	130
NNW	4	27	51	25	0	0	107
Variable	0	0	0	0	0	0	0
Total	44	278	420	263	66	9	1080

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020
 Stability Class - Slightly Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	5	20	3	1	0	0	29
NNE	7	10	6	0	0	0	23
NE	2	13	3	0	0	0	18
ENE	6	21	11	0	0	0	38
E	2	10	6	0	0	0	18
ESE	1	3	8	0	0	0	12
SE	3	5	23	5	1	0	37
SSE	4	11	38	29	1	0	83
S	3	20	27	23	3	0	76
SSW	6	26	45	14	3	0	94
SW	5	38	21	7	1	0	72
WSW	12	31	30	2	1	1	77
W	10	37	17	14	4	1	83
WNW	10	31	11	12	3	0	67
NW	19	32	15	4	0	0	70
NNW	4	30	3	1	0	0	38
Variable	0	0	0	0	0	0	0
Total	99	338	267	112	17	2	835

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020

Stability Class - Moderately Stable - 250Ft-30Ft Delta-T (F)
Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	1	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	2	4	1	0	0	0	7
ESE	1	6	5	0	0	0	12
SE	2	4	4	0	0	0	10
SSE	0	12	20	0	0	0	32
S	3	16	8	0	0	0	27
SSW	3	15	3	0	0	0	21
SW	6	2	0	0	0	0	8
WSW	5	3	0	0	0	0	8
W	12	15	1	0	0	0	28
WNW	10	4	0	0	0	0	14
NW	3	6	0	0	0	0	9
NNW	3	1	0	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	50	88	43	0	0	0	181

Hours of calm in this stability class: 1
Hours of missing wind measurements in this stability class: 0
Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020
 Stability Class - Extremely Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 30 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	3	0	0	0	0	0	3
NNE	0	1	0	0	0	0	1
NE	1	0	0	0	0	0	1
ENE	0	0	0	0	0	0	0
E	0	0	1	0	0	0	1
ESE	2	2	1	0	0	0	5
SE	2	4	2	0	0	0	8
SSE	2	7	2	0	0	0	11
S	4	12	1	0	0	0	17
SSW	3	6	0	0	0	0	9
SW	3	0	0	0	0	0	3
WSW	0	0	0	0	0	0	0
W	3	0	0	0	0	0	3
WNW	7	1	0	0	0	0	8
NW	10	3	0	0	0	0	13
NNW	5	0	0	0	0	0	5
Variable	0	0	0	0	0	0	0
Total	45	36	7	0	0	0	88

Hours of calm in this stability class: 1
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020

Stability Class - Extremely Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020

Stability Class - Moderately Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	2	0	0	2
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	1	0	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	1	0	0	1
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	0	1	3	0	0	4

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020

Stability Class - Slightly Unstable - 250Ft-30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	1	0	0	1
NE	0	0	0	0	0	0	0
ENE	0	1	0	1	0	0	2
E	0	0	3	0	0	0	3
ESE	0	0	0	2	0	0	2
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	5	0	5
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	1	1	1	0	3
WNW	0	0	0	2	0	0	2
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	1	4	7	6	0	18

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020
 Stability Class - Neutral - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	21	18	30	12	0	82
NNE	2	15	25	11	5	1	59
NE	0	5	5	1	9	10	30
ENE	0	5	6	8	3	0	22
E	1	10	9	4	2	0	26
ESE	1	2	5	4	1	2	15
SE	0	3	3	9	8	7	30
SSE	1	3	6	11	11	12	44
S	0	5	14	14	24	23	80
SSW	2	8	17	26	13	12	78
SW	2	6	16	42	4	4	74
WSW	6	9	38	16	6	11	86
W	3	10	34	22	28	19	116
WNW	1	18	38	28	22	11	118
NW	2	17	28	58	8	7	120
NNW	1	17	32	37	13	0	100
Variable	0	0	0	0	0	0	0
Total	23	154	294	321	169	119	1080

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020
 Stability Class - Slightly Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	5	21	4	1	0	32
NNE	2	2	12	8	1	0	25
NE	2	6	14	8	1	0	31
ENE	2	4	16	10	3	0	35
E	2	7	6	8	2	0	25
ESE	0	3	3	2	7	0	15
SE	0	0	3	7	14	0	24
SSE	0	2	2	12	29	17	62
S	1	2	3	14	42	18	80
SSW	0	1	11	22	38	14	86
SW	1	1	19	42	19	5	87
WSW	1	7	26	37	8	2	81
W	1	2	23	30	10	9	75
WNW	0	5	17	29	11	4	66
NW	1	7	25	20	4	1	58
NNW	2	11	33	6	1	0	53
Variable	0	0	0	0	0	0	0
Total	16	65	234	259	191	70	835

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020

Stability Class - Moderately Stable - 250Ft-30Ft Delta-T (F)
Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	3	0	0	0	5
NNE	0	1	1	0	0	0	2
NE	0	1	0	0	1	0	2
ENE	0	3	0	0	0	0	3
E	0	2	1	2	0	0	5
ESE	0	0	0	1	5	0	6
SE	0	1	2	3	2	0	8
SSE	0	0	1	3	7	0	11
S	1	1	2	9	15	0	28
SSW	0	0	2	11	10	0	23
SW	0	0	1	10	2	0	13
WSW	0	0	8	9	0	0	17
W	0	0	5	12	0	0	17
WNW	0	2	8	12	0	0	22
NW	0	2	1	4	0	0	7
NNW	0	0	9	4	0	0	13
Variable	0	0	0	0	0	0	0
Total	1	15	44	80	42	0	182

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

Byron Generating Station

Period of Record: October - December 2020
 Stability Class - Extremely Stable - 250Ft-30Ft Delta-T (F)
 Winds Measured at 250 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	5	0	0	0	5
NNE	0	5	1	1	0	0	7
NE	0	1	1	0	1	0	3
ENE	2	3	0	0	0	0	5
E	2	1	0	0	0	0	3
ESE	0	2	1	0	1	0	4
SE	0	1	1	1	2	0	5
SSE	0	0	1	3	1	0	5
S	1	1	0	3	6	0	11
SSW	0	0	0	3	3	0	6
SW	0	0	1	9	1	0	11
WSW	0	0	1	4	0	0	5
W	0	1	0	1	0	0	2
WNW	0	1	1	0	0	0	2
NW	1	2	2	0	0	0	5
NNW	0	1	6	3	0	0	10
Variable	0	0	0	0	0	0	0
Total	6	19	21	28	15	0	89

Hours of calm in this stability class: 0
 Hours of missing wind measurements in this stability class: 0
 Hours of missing stability measurements in all stability classes: 0

APPENDIX G

ERRATA DATA

Intentionally left blank

1. The 2019 AREOR Page B-1 referenced incorrect addresses for vegetation collection locations.

TABLE B-1: Radiological Environmental Monitoring Program - Sampling Locations, Distance and Direction, Byron Nuclear Generating Station, 2019

Location	Location Description	Distance & Direction From Site
<u>A. Surface Water</u>		
BY-12	Oregon Pool of Rock River, Downstream	4.5 miles SSW
BY-29	Byron, Upstream (control)	3.0 miles N
<u>B. Ground/Well Water</u>		
BY-14-1	3200 North German Church Road	1.0 miles SSE
BY-18-1	Calhoun	0.7 miles SSW
BY-32	Krueger Well	1.9 miles W
BY-35	Vancko Well	1.9 miles WNW
BY-37	Cavage Well	2.0 miles WNW
BY-38	Steve Storz Well	2.0 miles WNW
<u>C. Milk</u>		
BY-20-1	Ron Snodgrass Farm	4.8 miles WSW
BY-26-2	Joseph Akins Farm (control)	12.2 miles WNW
<u>D. Air Particulates / Air Iodine</u>		
BY-01	Byron	3.0 miles N
BY-04	Paynes Point	5.0 miles SE
BY-06	Oregon	4.7 miles SSW
BY-08	Leaf River (control)	7.0 miles WNW
BY-21	Byron Nearsite North	0.3 miles N
BY-22	Byron Nearsite Southeast	0.4 miles SE
BY-23	Byron Nearsite South	0.6 miles S
BY-24	Byron Nearsite Southwest	0.7 miles SW
<u>E. Fish</u>		
BY-29	Byron, Upstream (control)	3.0 miles N
BY-31	Byron, Discharge	2.6 miles WNW
<u>F. Sediment</u>		
BY-12	Oregon Pool of Rock River, Downstream	4.6 miles SSW
BY-34	Rock River, Upstream of Discharge (control)	2.6 miles WNW
<u>G. Vegetation</u>		
Quadrant 1	3989 Cox Road, Stillman Valley	4.8 miles E
Quadrant 2	6402 Brick Road, Oregon	4.8 miles SE
Quadrant 3	2002 Deer Path Road, Byron	1.0 miles SW
Quadrant 4	6315 River Rd., Byron	2.3 miles SW
Control	1725 Michigan Ave., Rockford	14.7 miles NNE
<u>H. Environmental Dosimetry - OSLD</u>		
<u>Inner Ring</u>		
BY-101-1 and -2		0.3 miles N
BY-102-1		1.0 miles NNE
BY-102-2		1.0 miles NNE

B-1

The correct locations were as follows:

- Quadrant 1 - 5186 Cox Road, Stillman Valley - 4.6 miles E
- Quadrant 2 - 6970 Linden Wood Road, Stillman Valley - 4.9 miles SE
- Quadrant 3 - 555 Park Road, Oregon - 3.7 miles SW
- Quadrant 4 - 4615 N. Razorville Road, Byron - 2.7 SW
- Control - 17311 Edison Road, Rockford - 14.8 miles ENE

2. The 2019 Effluent Report (Appendix E) contained erroneous calculations for the gaseous release volume.

During the review and approval process of transitioning the Offsite Dose Calculation from RETDAS to OpenEMS program, a discrepancy was identified with calculating the gaseous release volume using pressure differential methodology. The old methodology had the volume calculated using the ratio of the delta pressure change over the starting absolute pressure, measured in percent tank volume released. This calculation does not take into account that the sample of the tank is obtained and analyzed under close to atmospheric pressure conditions and therefore the volume of the gas released must be calculated under same conditions. Using the Boyles law for an ideal gas, the newly developed formula calculates the volume of the gas under standard atmospheric pressure. It should be noted that the RETDAS program calculations have been set in accordance with the Offsite Dose Calculation Manual and the calculation methodology most likely was set during initial implementation of RETDAS effluent software. It should also be noted that at no point the dose rate to the public had exceeded a TRM or station ODCM requirements. The discrepancy equated to approximately 10% of Waste Gas Decay Tank dose increase.

APPENDIX H

ANNUAL RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM REPORT (ARGPPR)

Intentionally left blank

NRC.Docket No: 50-454
50-455

BYRON NUCLEAR GENERATING STATION UNITS 1 and 2

Annual Radiological
Groundwater Protection Program Report

1 January Through 31 December 2020

Prepared By

Teledyne Brown Engineering
Environmental Services



Byron Nuclear Generating Station
Byron, IL 61010

April 2021

Intentionally left blank

Table Of Contents

I. Summary and Conclusions	1
II. Introduction.....	3
A. Objectives of the RGPP	3
B. Implementation of the Objectives	3
C. Program Description.....	4
D. Characteristics of Tritium (H-3).....	4
III. Program Description.....	6
A. Sample Analysis	6
B. Data Interpretation	6
C. Background Analysis.....	6
1. Background Concentrations of Tritium.....	7
IV. Results and discussion	9
A. Groundwater Results	9
B. Drinking Water Well Survey.....	9
C. Summary of Results – Inter-laboratory Comparison Program	9
D. Leaks, Spills, and Releases	9
E. Trends.....	9
F. Investigations	10
G. Actions Taken.....	10

Appendices

Appendix A Location Designation

Tables

Table A-1 Radiological Groundwater Protection Program - Sampling Locations,
Distance and Direction, Byron Nuclear Generating Station, 2020

Figures

Figure A-1 Monitoring Well Locations, Byron Nuclear Generating Station, 2020
(Extra wells noted on map are for reference only.)

Appendix B Data Tables

Tables

Table B-I.1 Concentrations of Tritium and Strontium in Groundwater Samples
Collected in the Vicinity of Byron Nuclear Generating Station, 2020

I. Summary and Conclusions

In 2006, Exelon instituted a comprehensive monitoring program to evaluate the impact of station operations on groundwater in the vicinity of Byron Nuclear Generating Station. The monitoring was conducted in two phases. Phase 1 of the monitoring was part of a comprehensive study initiated by Exelon to determine whether groundwater or surface water at and in the vicinity of Byron Nuclear Generating Station had been adversely impacted by any releases of radionuclides. Phase 1 was conducted by Conestoga Rovers and Associates (CRA) and the conclusions were made available to state and federal regulators as well as the public.

Phase 2 of the RGPP was conducted by Exelon corporate and station personnel to initiate follow up of Phase 1 and begin long-term monitoring at groundwater locations selected during Phase 1. This is the fifteenth in a series of annual reports on the status of the Radiological Groundwater Protection Program (RGPP) conducted at Byron Nuclear Generating Station. This report covers groundwater and surface water samples collected from the environment both on and off station property in 2020. During that time period, 129 analyses were performed on 62 samples from 18 locations.

In 2020, fourteen (14) Radiological Groundwater Protection Program (RGPP) monitoring wells were sampled in total. Groundwater samples were obtained in March, May, August, and November and analyzed for tritium.

Two wells contained levels of tritium above the lower limit of detection (LLD) of 200 pCi/L. They were: AR-7 (227 pCi/L in March, 289 pCi/L in June, 251 pCi/L in September, 313 pCi/L in November) and AR-11 (448 pCi/L in September, 459 pCi/L in November). Well AR-11 is near the Circulating Water Blowdown piping, where historical leakage through vacuum breakers was known to have occurred. Tritium in Well AR-7, located on-site just west of plant structures, has been measured in this well slightly above detection limits on an intermittent basis since the well was first drilled in 2006. The tritium present in this well is likely due to legacy tritium prior to 2006 or precipitation recapture and is not believed to be the result of new leaks. The tritium measured in this well has been at or below tritium levels that have been historically measured in rainwater as a result of precipitation recapture from permitted gaseous releases. In August 2014, a break in the well piping was discovered about six feet below the surface that could have served as the entry point for tritium in the recapture water. Tritium present in well AR-7 has shown a gradual decrease since 2014. Should the water in these aquifers migrate to off-site wells used for drinking, the off-site dose consequence from tritium present in any of these three wells would be negligible. There are no existing or new leaks evident at the site and all groundwater well sample results are well below the drinking water tritium standard of 20,000 pCi/L.

In December 2018, two new wells, AR-12 and AR-13, were installed near well AR-7. These wells were added to provide additional monitoring capabilities in

the area directly west of plant structures. No tritium was detected in these wells during 2020.

Strontium-89 (Sr-89) and Strontium-90 (Sr-90) were not detected in any samples above their respective LLDs of 10 and 1 pCi/L.

In assessing all the data gathered for this report, it was concluded that the operation of Byron Nuclear Generating Station had no adverse radiological impact on the environment, and there are no known active releases into the groundwater at Byron Nuclear Generating Station.

II. Introduction

The Byron Station, a two-unit PWR station, is located about two miles east of the Rock River and approximately three miles southwest of Byron in Ogle County, Illinois. The reactors are designed to have capacities of 1,268 and 1,241 MW gross, respectively. Unit One loaded fuel in November 1984 and went online February 2, 1985. Unit Two went online January 9, 1987.

This report covers those analyses performed by Teledyne Brown Engineering (TBE) on samples collected in 2020.

A. Objectives of the RGPP

The long-term objectives of the RGPP are as follows:

1. Identify suitable locations to monitor and evaluate potential impacts from station operations before significant radiological impact to the environment and potential drinking water sources
2. Understand the local hydrogeologic regime in the vicinity of the station and maintain up-to-date knowledge of flow patterns on the surface and shallow subsurface
3. Perform routine water sampling and radiological analysis of water from selected locations
4. Report new leaks, spills, or other detections with potential radiological significance to stakeholders in a timely manner
5. Regularly assess analytical results to identify adverse trends
6. Take necessary corrective actions to protect groundwater resources

B. Implementation of the Objectives

The objectives identified have been implemented at Byron Nuclear Generating Station as discussed below:

1. Exelon and its consultant identified locations as described in the Phase 1 study. Phase 1 studies were conducted by Conestoga Rovers and Associates (CRA) and the results and conclusions were made available to state and federal regulators as well as the public.
2. The Byron Nuclear Generating Station reports describe the local hydrogeologic regime. Periodically, the flow patterns on the surface and shallow subsurface are updated based on ongoing measurements.
3. Byron Nuclear Generating Station will continue to perform routine sampling and radiological analysis of water from selected locations.
4. Byron Nuclear Generating Station has implemented new procedures to identify and report new leaks, spills, or other detections with potential radiological significance in a timely manner.
5. Byron Nuclear Generating Station staff and consulting hydrogeologist

assess analytical results on an ongoing basis to identify adverse trends.

C. Program Description

Sample Collection

Sample locations can be found in Table A-1 and Figure A-1, Appendix A.

Groundwater/Surface Water

Samples of water are collected, managed, transported and analyzed in accordance with approved procedures following EPA methods. Groundwater is collected from drilled wells. Surface water is collected from the Construction Runoff Pond (CROP), which collects stormwater runoff from the site protected area prior to discharge offsite. Sample locations, sample collection frequencies and analytical frequencies are controlled in accordance with approved station procedures. Contractor and/or station personnel are trained in the collection, preservation management, and shipment of samples, as well as in documentation of sampling events. Analytical laboratories are subject to internal quality assurance programs, industry cross-check programs, as well as nuclear industry audits. Station personnel review and evaluate all analytical data deliverables as data are received.

Analytical data results are reviewed by both station personnel and an independent hydrogeologist for adverse trends or changes to hydrogeologic conditions.

D. Characteristics of Tritium (H-3)

Tritium (chemical symbol H-3) is a radioactive isotope of hydrogen. The most common form of tritium is tritium oxide, which is also called "tritiated water." The chemical properties of tritium are essentially those of ordinary hydrogen.

Tritiated water behaves the same as ordinary water in both the environment and the body. Tritium can be taken into the body by drinking water, breathing air, eating food, or absorption through skin. Once tritium enters the body, it disperses quickly and is uniformly distributed throughout the body. Tritium is excreted primarily through urine with a clearance rate characterized by an effective biological half-life of about 14 days. Within one month or so after ingestion, essentially all tritium is cleared. Organically bound tritium (tritium that is incorporated in organic compounds) can remain in the body for a longer period.

Tritium is produced naturally in the upper atmosphere when cosmic rays strike air molecules. Tritium is also produced during nuclear weapons explosions, as a by-product in reactors producing electricity, and in special production reactors, where the isotopes lithium-7 and/or boron-10 are activated to produce tritium. Like normal water, tritiated water is colorless and odorless. Tritiated water behaves chemically and physically like non-tritiated water in the subsurface, and therefore tritiated water will travel at

the same velocity as the average groundwater velocity.

Tritium has a half-life of approximately 12.3 years. It decays spontaneously to Helium-3 (^3He). This radioactive decay releases a beta particle (low-energy electron). The radioactive decay of tritium is the source of the health risk from exposure to tritium. Tritium is one of the least dangerous radionuclides because it emits very weak radiation and leaves the body relatively quickly. Since tritium is almost always found as water, it goes directly into soft tissues and organs. The associated dose to these tissues is generally uniform and is dependent on the water content of the specific tissue.

III. Program Description

A. Sample Analysis

This section describes the general analytical methodologies used by TBE to analyze the environmental samples for radioactivity for the Byron Nuclear Generating Station RGPP in 2020.

In order to achieve the stated objectives, the current program includes the following analyses (as required by procedure):

1. Concentrations of strontium in groundwater
2. Concentrations of tritium in groundwater/surface water

No gamma nuclide or gross alpha monitoring was performed in 2020.

B. Data Interpretation

The radiological data collected prior to Byron Nuclear Generating Station becoming operational were used as a baseline with which these operational data were compared. For the purpose of this report, Byron Nuclear Generating Station was considered operational at initial criticality. Several factors were important in the interpretation of the data:

1. Lower Limit of Detection and Minimum Detectable Concentration

The lower limit of detection (LLD) is specified by federal regulation as a minimum sensitivity value that must be achieved routinely by the analytical parameter.

2. Laboratory Measurements Uncertainty

The estimated uncertainty in measurement of tritium in environmental samples is frequently on the order of 50% of the measurement value.

Statistically, the exact value of a measurement is expressed as a range with a stated level of confidence. The convention is to report results with a 95% level of confidence. The uncertainty comes from calibration standards, sample volume or weight measurements, sampling uncertainty and other factors. Exelon reports the uncertainty of a measurement created by statistical process (counting error) as well as all sources of error (Total Propagated Uncertainty or TPU). Each result has two values calculated. Exelon reports the TPU by following the result with plus or minus \pm the estimated sample standard deviation, as TPU, that is obtained by propagating all sources of analytical uncertainty in measurements.

Analytical uncertainties are reported at the 95% confidence level in this report for reporting consistency with the AREOR.

C. Background Analysis

A pre-operational radiological environmental monitoring program (pre-operational REMP) was conducted to establish background radioactivity levels prior to operation of the Station. The environmental media sampled

and analyzed during the pre-operational REMP were atmospheric radiation, fall-out, domestic water, surface water, marine life, and foodstuffs. The results of the monitoring were detailed in the report entitled, *Environmental Radiological Monitoring for Byron Nuclear Generating Nuclear Power Station, Commonwealth Edison Company, Annual Report 1984, April, 1985*.

The pre-operational REMP contained analytical results from samples collected from the surface water and groundwater. All groundwater samples listed in the pre-Operational REMP report were <200 pCi/L.

1. Background Concentrations of Tritium

The purpose of the following discussion is to summarize background measurements of tritium in various media performed by others. Additional detail may be found by consulting references (CRA 2006).

a. Tritium Production

Tritium is created in the environment from naturally occurring processes both cosmic and subterranean, as well as from anthropogenic (i.e., man-made) sources. In the upper atmosphere, "Cosmogenic" tritium is produced from the bombardment of stable nuclides and combines with oxygen to form tritiated water, which will then enter the hydrologic cycle. Below ground, "lithogenic" tritium is produced by the bombardment of natural lithium present in crystalline rocks by neutrons produced by the radioactive decay of naturally abundant uranium and thorium. Lithogenic production of tritium is usually negligible compared to other sources due to the limited abundance of lithium in rock. The lithogenic tritium is introduced directly to groundwater.

A major anthropogenic source of tritium and Sr-90 comes from the former atmospheric testing of thermonuclear weapons. Levels of tritium in precipitation increased significantly during the 1950s and early 1960s, and later with additional testing, resulting in the release of significant amounts of tritium to the atmosphere. The Canadian heavy water nuclear power reactors, other commercial power reactors, nuclear research and weapons production continue to influence tritium concentrations in the environment.

b. Precipitation Data

Precipitation samples are routinely collected at stations around the world for the analysis of tritium and other radionuclides. Two publicly available databases that provide tritium concentrations in precipitation are Global Network of Isotopes in Precipitation (GNIP) and USEPA's RadNet database. GNIP provides tritium precipitation concentration data for samples collected worldwide from 1960 to 2006. RadNet provides tritium precipitation

concentration data for samples collected at stations throughout the U.S. from 1960 up to and including 2006. Based on GNIP data for sample stations located in the U.S. Midwest, tritium concentrations peaked around 1963. This peak, which approached 10,000 pCi/L for some stations, coincided with the atmospheric testing of thermonuclear weapons. Tritium concentrations in surface water showed a sharp decline up until 1975 followed by a gradual decline since that time. Tritium concentrations in Midwest precipitation have typically been below 100 pCi/L since around 1980. Tritium concentrations in wells may still be above the 200 pCi/L detection limit from the external causes described above. Water from previous years and decades is naturally captured in groundwater, so some well water sources today are affected by the surface water from the 1960s that was elevated in tritium.

c. Surface Water Data

Tritium concentrations are routinely measured in large surface water bodies, including Lake Michigan and the Mississippi River. Illinois surface water data were typically less than 100 pCi/L.

The USEPA RadNet surface water data typically has a reported 'Combined Standard Uncertainty' of 35 to 50 pCi/L. According to USEPA, this corresponds to a ± 70 to 100 pCi/L 95% confidence bound on each given measurement. Therefore, the typical background data provided may be subject to measurement uncertainty of approximately ± 70 to 100 pCi/L.

The radio-analytical laboratory is counting tritium results to an Exelon-specified LLD of 200 pCi/L. Typically, the lowest positive measurement will be reported within a range of 40 – 240 pCi/L or 140 ± 100 pCi/L. Clearly, these sample results cannot be distinguished as different from background at this concentration.

IV. Results and Discussion

A. Groundwater Results

Groundwater

Samples were collected from on- and off-site wells throughout the year in accordance with the station radiological groundwater protection program. Analytical results and anomalies are discussed below:

Tritium

Samples from all locations were analyzed for tritium activity (Table B-I.1, Appendix B). Tritium values ranged from less than the detection limit to 459 pCi/L. Outside of the station boundary, tritium concentrations were all less than detection limit (<200 pCi/L). The tritium detected in groundwater samples has been isolated to the Galena- Platteville aquifer, which is isolated from the deeper regional groundwater aquifer by the semi-confining Glenwood Formation. Groundwater quality data from production wells and monitoring wells at the station located below this aquifer do not indicate concentrations of tritium greater than the LLD of 200 pCi/L. As such, the tritium impact is limited to the Galena- Platteville aquifer.

Strontium

Strontium-89 (Sr-89) and Strontium-90 (Sr-90) were not detected in any samples above their respective LLDs of 10 and 1 pCi/L.

B. Drinking Water Well Survey

No drinking water well surveys were conducted in 2020.

C. Summary of Results – Inter-Laboratory Comparison Program

Inter-Laboratory Comparison Program results for TBE are presented in the AREOR.

D. Leaks, Spills, and Releases

There are no new previously unidentified leaks or plumes at Byron Station. There were no new leaks, spills or releases at Byron Station in 2020.

E. Trends

Wells AR-4 and AR-11 have shown an overall decrease in tritium concentration since first sampled in 2006. Tritium has been measured in Well AR-7 since 2012, however, tritium has been previously measured in this well and it is believed to be the result of legacy tritium prior to 2006 or precipitation recapture, not the result of a new spill or leak.

F. Investigations

There were no investigations that took place in 2020 as a result of groundwater sample results.

G. Actions Taken

1. Compensatory Actions

No compensatory actions were initiated in 2020.

2. Installation of Monitoring Wells

No new monitoring wells were installed in 2020.

3. Actions to Recover/Reverse Plumes

No actions were undertaken to recover/reverse plumes in 2020.

APPENDIX A

LOCATION DESIGNATION

Intentionally Left Blank

TABLE A-1: Radiological Groundwater Protection Program - Sampling Locations
Distance and Direction, Byron Nuclear Generating Station, 2020

<u>Site</u>	<u>Site Type</u>	<u>Temporary/Permanent</u>	<u>Distance and Direction</u>
AR-1	Monitoring Well	Permanent	0.36 miles/NNW
AR-2	Monitoring Well	Permanent	0.6 miles/NW
AR-3	Monitoring Well	Permanent	0.8 miles/NW
AR-4	Monitoring Well	Permanent	1.36 miles/WNW
AR-5	Monitoring Well	Permanent	1.92 miles/WNW
AR-6	Monitoring Well	Permanent	2.04 miles/WNW
AR-7	Monitoring Well	Permanent	0.04 miles/W
AR-8	Monitoring Well	Permanent	0.12 miles/S
AR-9	Monitoring Well	Permanent	0.24 miles/E
AR-10	Monitoring Well	Permanent	0.28 miles/NE
AR-11	Monitoring Well	Permanent	1.36 miles/WNW
AR-12	Monitoring Well	Permanent	366 feet/W
AR-13	Monitoring Well	Permanent	461 feet/WSW
CAR-1	Monitoring Well	Permanent	2.25 miles/WNW
CAR-3	Monitoring Well	Permanent	0.16 miles/SE
TW-13	Monitoring Well	Permanent	2.3 miles/WNW
CROP	Surface Water	Permanent	0.2 miles NE




Figure A-1
Monitoring Well Locations, Byron Nuclear Generating Station, 2020

APPENDIX B

DATA TABLES

Intentionally Left Blank

TABLE B-I.1

**CONCENTRATIONS OF TRITIUM AND STRONTIUM IN
GROUNDWATER SAMPLES COLLECTED IN THE VICINITY OF
BYRON NUCLEAR GENERATING STATION, 2020**
RESULTS IN UNITS OF PCI/LITER \pm 2 SIGMA

SITE	COLLECTION		H-3	Sr-89	Sr-90
	DATE				
AR-1	03/18/20		< 188		
AR-1	09/02/20		< 179	< 7.3	< 0.7
AR-1	11/03/20		< 190		
AR-2	09/02/20		< 179		
AR-3	03/18/20		< 185		
AR-3	09/02/20		< 182	< 6.8	< 0.8
AR-3	11/04/20		< 191		
AR-4	03/18/20		197 \pm 116		
AR-4	09/02/20		< 185	< 4.0	< 0.9
AR-4	11/04/20		< 190		
AR-7	03/17/20		227 \pm 122		
AR-7	06/03/20		289 \pm 124		
AR-7	09/03/20		251 \pm 120	< 7.5	< 0.8
AR-7	11/02/20		313 \pm 137		
AR-8	03/17/20		< 184		
AR-8	09/03/20		< 184	< 6.8	< 0.7
AR-8	11/02/20		< 183		
AR-9	03/17/20		< 183		
AR-9	09/04/20		< 178	< 6.9	< 0.9
AR-9	11/03/20		< 179		
AR-10	09/02/20		< 185		
AR-11	09/02/20		448 \pm 132		
AR-11	11/04/20		459 \pm 137		
AR-12	03/17/20		< 189		
AR-12	06/09/20		< 179		
AR-12	09/03/20		< 186	< 7.1	< 0.6
AR-12	11/02/20		< 176		
AR-13	03/17/20		< 183		
AR-13	09/03/20		< 179	< 7.9	< 0.7
AR-13	11/03/20		< 182		
CAR-1	09/02/20		< 183		
CAR-3	03/17/20		< 186		
CAR-3	09/03/20		< 179	< 6.9	< 0.9
CAR-3	11/03/20		< 180		
TW-13	09/02/20		< 181		
*CROP	03/17/20		< 182		
*CROP	09/03/20		< 190	< 7.7	< 0.9
*CROP	11/03/20		< 178		

*Surface Water Sample

Intentionally left blank