



Exelon Generation

May 24, 2021

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555-0001

Peach Bottom Atomic Power Station Units 2 and 3  
Independent Spent Fuel Storage Installation (ISFSI)  
Facility Operation License DPR-12, DPR-44 and DPR-56  
NRC Docket 50-171, 50-277 and 50-278 and ISFSI Docket 72-29

Subject: Annual Radiological Environmental Operating Report 76  
January 1, 2020 through December 31, 2020

In accordance with the requirements of Section 5.6.2 of the Peach Bottom Atomic Power Station (PBAPS), Units 2 and 3 Technical Specifications, this letter submits the Annual Radiological Environmental Operation Report 78. This report provides the 2020 results for the Radiological Environmental Monitoring Program (REMP) as called for in the Offsite Dose Calculation Manual.

In assessing the data collected for the REMP, we have concluded that the operation of PBAPS, Units 2 and 3, had no adverse impact on the environment. There are no commitments contained in this letter.

If you have any questions or require additional information, please do not hesitate to contact Dani Brookhart at 717-456-3056.

Sincerely,

A handwritten signature in black ink, appearing to read "David A. Henry".

David A. Henry, Plant Manager  
Peach Bottom Atomic Power Station

DAH/MR/SMO/TJH/KH/DLB

Enclosure (1)

Cc: Regional Administrator – NRC Region 1  
NRC Senior Resident Inspector – Peach Bottom Atomic Power Station

CCN 21-34

Docket No: 50-277  
50-278

# **PEACH BOTTOM ATOMIC POWER STATION**

## **UNITS 2 and 3**

Annual Radiological  
Environmental Operating Report

Report No. 77  
January 1 through December 31, 2020

**Prepared By**  
Teledyne Brown Engineering  
Environmental Services



Peach Bottom Atomic Power Station  
Delta, PA 17314

**May 2021**

Intentionally Left Blank

## TABLE OF CONTENTS

I. Executive Summary .....	1
II. Introduction.....	3
A. Objectives .....	3
B. Implementation of the Objectives .....	3
C. Radiation and Radioactivity .....	3
D. Sources of Radiation .....	4
III. Program Description.....	6
A. Sample Collection.....	6
B. Sample Analysis .....	8
C. Data Interpretation.....	8
D. Program Exceptions .....	10
IV. Program Changes.....	10
V. Results and Discussion .....	11
A. Aquatic Environment .....	11
B. Atmospheric Environment .....	13
C. Terrestrial .....	13
D. Ambient Gamma Radiation .....	14
E. Independent Spent Fuel Storage Installation (ISFSI) .....	15
F. Land Use Census .....	15
G. Errata Data .....	16
H. Secondary Laboratory Analysis.....	16
I. Summary of Results – Quality Control (QC) Laboratory Analysis.....	17
VI. References .....	19

## Appendices

### Appendix A Radiological Environmental Monitoring Report Summary

#### Tables

Table A-1 Radiological Environmental Monitoring Program Annual Summary for the Peach Bottom Atomic Power Station, 2020

### Appendix B Sample Designation and Locations

#### Tables

Table B-1 Radiological Environmental Monitoring Program – Sampling Locations, Distance and Direction from Reactor Buildings, Peach Bottom Atomic Power Station, 2020

Table B-2 Radiological Environmental Monitoring Program – Summary of Sample Collection and Analytical Methods, Peach Bottom Atomic Power Station, 2020

#### Figures

Figure B-1 Environmental Sampling Locations Within One Mile of Peach Bottom Atomic Power Station, 2020

Figure B-2 Environmental Sampling Locations Between One and Approximately Five Miles of Peach Bottom Atomic Power Station, 2020

Figure B-3 Environmental Sampling Locations Greater than Five Miles from Peach Bottom Atomic Power Station, 2020

### Appendix C Data Tables and Figures Primary Laboratory

#### Tables

Table C-I.1 Concentrations of Tritium in Surface Water Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020

Table C-I.2 Concentrations of Low Level I-131 in Surface Water Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020

Table C-I.3 Concentrations of Gamma Emitters in Surface Water Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020

Table C-II.1 Concentrations of Gross Beta in Drinking Water Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020

Table C-II.2 Concentrations of Tritium in Drinking Water Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020

Table C-II.3	Concentrations of Low Level I-131 in Drinking Water Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table C-II.4	Concentrations of Gamma Emitters in Drinking Water Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table C-III.1	Concentrations of Gamma Emitters in Predator and Bottom Feeder (Fish) Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table C-IV.1	Concentrations of Gamma Emitters in Sediment Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table C-V.1	Concentrations of Gross Beta in Air Particulate Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table C-V.2	Concentrations of Gamma Emitters in Air Particulate Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table C-VI.1	Concentrations of I-131 in Air Iodine Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table C-VII.1	Concentrations of Low Level I-131 in Milk Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table C-VII.2	Concentrations of Gamma Emitters in Milk Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table C-VIII.1	Concentrations of Gamma Emitters in Food Product Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table C-IX.1	Quarterly DLR Results for Peach Bottom Atomic Power Station, 2020
Table C-IX.2	Annual DLR Results for Peach Bottom Atomic Power Station, 2020

### Figures

Figure C-1	Monthly Total Gross Beta Concentrations in Drinking Water Samples Collected in the Vicinity of PBAPS, 2020
Figure C-2	MDC Results for Fish Sampling Collected in the Vicinity of PBAPS, 2020
Figure C-3	Semi-Annual Cs-137 Concentrations in Sediment Samples Collected in the Vicinity of PBAPS, 2020
Figure C-4	Mean Weekly Gross Beta Concentrations in Air Particulate Samples Collected in the Vicinity of PBAPS, 2020
Figure C-5	Average Monthly MDC for REMP Milk Samples Collected in the Vicinity of PBAPS, 2020
Figure C-6	Annual Normalized Gamma Radiation Results from Dosimeters Collected in the Vicinity of PBAPS, 2020

Appendix D Data Tables and Figures QC Laboratories

Tables

Table D-I.1	Concentrations of Gross Beta in Drinking Water Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table D-I.2	Concentrations of Tritium in Drinking Water Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table D-I.3	Concentrations of I-131 in Drinking Water Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table D-I.4	Concentrations of Gamma Emitters in Drinking Water Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table D-II.1	Concentrations of Gross Beta in Air Particulate and I-131 in Air Iodine Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table D-II.2	Concentrations of Gamma Emitters in Air Particulate Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020
Table D-III.1	Concentrations of I-131 and Gamma Emitters in Milk Samples Collected in the Vicinity of Peach Bottom Atomic Power Station, 2020

Figures

Figure D-1	Comparison of Monthly Total Gross Beta Concentrations in Drinking Water Samples from Station 4L Analyzed by the Primary and QC Laboratories, 2020
Figure D-2	Comparison of Weekly Gross Beta Concentrations from Co-Located Air Particulate Locations (1Z/1A) Analyzed by the Primary and QC Laboratories, 2020

Appendix E Errata Data

Appendix F Inter-Laboratory Comparison Program Acceptance Criteria and Results

Tables

Table F-1	Analytics Environmental Radioactivity Cross Check Program Teledyne Brown Engineering Environmental Services, 2020
Table F-2	DOE's Mixed Analyte Performance Evaluation Program (MAPEP) Teledyne Brown Engineering Environmental Services, 2020
Table F-3	ERA Environmental Radioactivity Cross Check Program Teledyne Brown Engineering Environmental Services, 2020

Table F-4	Analytics Environmental Radioactivity Cross Check Program Exelon Industrial Services, 2020
Table F-5	ERA Environmental Radioactivity Cross Check Program Exelon Industrial Services, 2020
Table F-6	Analytics Environmental Radioactivity Cross Check Program GEL Laboratories (Relevant Nuclides), 2020
Table F-7	DOE's Mixed Analyte Performance Evaluation Program (MAPEP) GEL Laboratories (Relevant Nuclides), 2020
Table F-8	ERA Environmental Radioactivity Cross Check Program GEL Laboratories (Relevant Nuclides), 2020
Appendix G	Annual Radiological Groundwater Protection Program Report (ARGPPR)



Intentionally Left Blank

## I. Executive Summary

The 2020 Annual Radiological Environmental Operating Report (AREOR) describes the results of the Radiological Environmental Monitoring Program (REMP) conducted for Peach Bottom Atomic Power Station (PBAPS) by Exelon Nuclear and covers the period of 1 January 2020 through 31 December 2020. Throughout that time period, 1,267 analyses were performed on 981 samples. In assessing all the data gathered for this report and comparing the results with preoperational data, it was evident that the operation of PBAPS had no adverse radiological impact on the environment.

The various media collected in the REMP include aquatic, terrestrial, airborne, and ambient radiation. The corresponding analyses performed on the collected specimen were:

### Aquatic:

- Surface water samples were analyzed for concentrations of Iodine-131 (I-131), tritium (H-3) and gamma-emitting nuclides. All nuclides were below minimum detectable activity.
- Drinking water samples were analyzed for concentrations of gross beta, I-131, H-3, and gamma-emitting nuclides. All nuclides were below minimum detectable activity. In some samples, gross beta activity detected was detected above the lower limit of detection (LLD) of 4 pCi/L, but not above the investigation level (15 pCi/L) and therefore, likely due to background radiation.
- Fish and sediment samples were analyzed for concentrations of gamma-emitting nuclides. All nuclides were below minimum detectable activity.

### Terrestrial:

- Milk samples were analyzed for low level concentrations of I-131 and gamma-emitting nuclides. Food product samples were analyzed for concentrations of gamma-emitting nuclides. All power production nuclides were below minimum detectable activity.

### Airborne:

- Air particulates and air iodine samples were analyzed for gross beta, gamma-emitting nuclides, and low level I-131. All nuclides were below minimum detectable activity. The gross beta results were less than the investigation level ( $1.60E-01$  pCi/m<sup>3</sup>) and there were no notable differences between control and indicator locations.

### Ambient Radiation:

- Ambient gamma radiation levels were measured quarterly. There was no detectable ambient gamma radiation levels to the members of the public at offsite locations, indicating no impact from plant operations. The nearest resident to the ISFSI saw no detectable ambient gamma radiation levels, therefore ISFSI operations did not have an impact to members of the public.

In 2020, the doses from both liquid and gaseous effluents were conservatively calculated for the Maximum Exposed Member of the Public due to PBAPS Operation. Doses calculated were well below all Offsite Dose Calculations Manual (ODCM) limits. The results of those calculations were as follows:

Effluent	Applicable Organ	Estimated Dose	Age Group	Location		% of Applicable Limit	Limit	Unit
				Distance (meters)	Direction (toward)			
Noble Gas	Gamma - Air Dose	1.60E-01	All	1.10E+03	SSE	8.00E-01	2.00E+01	mrad
Noble Gas	Beta - Air Dose	1.09E-01	All	1.10E+03	SSE	2.73E-01	4.00E+01	mrad
Noble Gas	Total Body (gamma)	1.55E-01	All	1.10E+03	SSE	1.55E+00	1.00E+01	mrem
Noble Gas	Skin (Beta)	2.04E-01	All	1.10E+03	SSE	6.80E-01	3.00E+01	mrem
Gaseous Iodine, Particulate, Carbon-14 & Tritium	Bone	1.40E-01	Child	1.50E+03	SW	4.67E-01	3.00E+01	mrem
Gaseous Iodine, Particulate, & Tritium	Thyroid	4.30E-03	Infant	1.50E+03	SW	1.43E-02	3.00E+01	mrem
Liquid	Total Body (gamma)	1.54E-04	Child	Site Boundary		2.57E-03	6.00E+00	mrem
Liquid	GI-LLI	3.47E-04	Adult			1.74E-03	2.00E+01	mrem
Direct Radiation	Total Body	0.00E+00	All	1.19E+03	SSE	0.00E+00	2.50E+01	mrem
40 CFR Part 190 Compliance								
Effluent	Applicable Organ	Estimated Dose	Age Group	Location		% of Applicable Limit	Limit	Unit
				Distance (meters)	Direction (toward)			
Total Dose	Total Body	1.55E-01	All	1.19E+03	SSE	6.21E-01	2.50E+01	mrem
Total Dose	Thyroid	4.30E-03	All	1.19E+03	SSE	5.73E-02	7.50E+01	mrem
Total Dose	Bone	1.40E-01	All	1.19E+03	SSE	5.61E-01	2.50E+01	mrem
Total Dose	Total Body	1.55E-01	All	1.19E+03	SSE	5.17E+00	3.00E+00	mrem
Total Dose	Bone	1.40E-01	All	1.19E+03	SSE	4.68E+00	3.00E+00	mrem
Total Dose	Thyroid	1.64E-01	All	1.19+03	SSE	2.99E-01	5.50E+01	mrem

## II. Introduction

PBAPS is located along the Susquehanna River between Holtwood and Conowingo Dams in Peach Bottom Township, York County, Pennsylvania. PBAPS Units 2 and 3 are boiling water reactors, each with a rated full-power output of approximately 4,016 MWth while Unit 1 is a decommissioned 115 MWth High Temperature, Gas-cooled Reactor (HTGR). The initial environmental monitoring program began 5 February 1966. A summary of the Unit 1 preoperational monitoring program was presented in a previous report<sup>(1)</sup>. Preoperational summary reports<sup>(2,3)</sup> for Units 2 and 3 have been previously issued and summarize the results of all analyses performed on samples collected from 5 February 1966 through 8 August 1973.

The sampling and analysis requirements are contained in the PBAPS ODCM and the ODCM Specifications (ODCMS). This AREOR covers those analyses performed by Teledyne Brown Engineering (TBE), Landauer, Exelon Industrial Services (EIS) and GEL Laboratories on samples collected during the period 01 January 2020 through 31 December 2020.

### A. Objectives

The objectives of the REMP are:

1. Provide data on measurable levels of radiation and radioactive materials in the publicly-used environs;
2. Evaluate the principal pathways of exposure to the public as described in the ODCM and determine the relationship between quantities of radioactive material released from the plant and resultant radiation doses to members of the public.

### B. Implementation of the Objectives

Implementation of the objectives is accomplished by:

1. Identifying significant exposure pathways,
2. Establishing baseline radiological data of media within those pathways,
3. Continuously monitoring those media before and during plant operation to assess station radiological effects (if any) on man and the environment.

As the REMP is established to measure the impact of power plant operations (release of radionuclides) on man and the environment; it is important to understand radiation/radioactivity, the units used to measure them, and natural sources of radiation in the environment. A brief explanation is provided to differentiate between radiation from nuclear power production and other sources, be they man-made or natural. The doses produced from the other sources of radiation can be compared to the data presented in this report.

### C. Radiation and Radioactivity

All matter is made of atoms. An atom is the smallest part into which matter can

be broken down and still maintain all its chemical properties. Nuclear radiation is energy, in the form of waves or particles that is given off by unstable, radioactive atoms. Radioactive material exists naturally and has always been a part of our environment. The earth's crust, for example, contains radioactive uranium, radium, thorium and potassium. Some radioactivity is a result of nuclear weapons testing. Examples of radioactive fallout that is normally present in environmental samples are Cesium-137 (Cs-137) and Strontium-90 (Sr-90). Some examples of radioactive materials released from a nuclear power plant are Cs-137, I-131, Sr-90 and Cobalt-60 (Co-60).

Radiation is measured in units of millirem (mrem); much like temperature is measured in degrees. A millirem is a measure of the biological effect of the energy deposited in tissue. The natural and man-made radiation dose received in one year by the average American is 300 to 400 mrem (References 5, 6, 7 in Table 1 below). Radioactivity is measured in curies. A curie is that amount of radioactive material needed to produce 3.70E+10 nuclear disintegrations per second. This is an extremely large amount of radioactivity in comparison to environmental radioactivity. That is why radioactivity in the environment is measured in picocuries. One picocurie is equal to 1.00E-12 (one trillionth) of a curie.

#### D. Sources of Radiation

As mentioned previously, naturally occurring radioactivity has always been a part of our environment. Table 1 shows the typical doses received from natural and man-made sources.

Table 1  
Radiation Sources and Corresponding Doses <sup>(4)</sup>

NATURAL		MAN-MADE	
Source	Radiation Dose (mrem/yr)	Source	Radiation Dose (mrem/yr)
Internal, inhalation <sup>(5)</sup>	228	Medical <sup>(6)</sup>	300
External, space	33	Consumer <sup>(7)</sup>	13
Internal, ingestion	29	Industrial <sup>(8)</sup>	0.3
External, terrestrial	21	Occupational	0.5
		Weapons Fallout	<1
		Nuclear Power Plants	<1
Approximate Total	311	Approximate Total	314

Cosmic radiation from the sun and outer space penetrates the earth's atmosphere and continuously bombards us with rays and charged particles. Some of this cosmic radiation interacts with gases and particles in the atmosphere, making them radioactive in turn. These radioactive byproducts from cosmic ray bombardment are referred to as cosmogenic radionuclides. Isotopes such as beryllium-7 (Be-7) and carbon-14 (C-14) are formed in this

way. Exposure to cosmic and cosmogenic sources of radioactivity results in a dose of 33 mrem/yr.

Additionally, natural radioactivity is in our body, in the food we eat (about 29 mrem/yr), in the ground we walk on (about 21 mrem/yr), and in the air we breathe (about 228 mrem/yr). One percent of all potassium in nature is the radioactive potassium-40 (K-40). The majority of a person's annual dose results from exposure to radon and thoron in the air we breathe. These gases and their radioactive decay products arise from the decay of naturally occurring uranium, thorium and radium in soil and in building products such as brick, stone and concrete. Radon and thoron levels vary greatly with location, primarily due to changes in the concentration of uranium and thorium in the soil. Residents at some locations in Colorado, New York, Pennsylvania, and New Jersey have a higher annual dose as a result of higher levels of radon/thoron gases in these areas. In total, these various sources of naturally occurring radiation and radioactivity contribute to a total dose of about 311 mrem per year (mrem/yr).

In addition to natural radiation, we are normally exposed to radiation from a number of man-made sources. The single largest dose from man-made sources result from therapeutic and diagnostic applications of x-rays and radiopharmaceuticals. The annual dose to an individual in the U.S. from medical and dental exposure is about 300 mrem. Consumer products, such as televisions and smoke detectors, contribute about 13 mrem/yr. Much smaller doses result from weapons fallout and nuclear power plants (less than 1 mrem/yr). Typically, the average person in the United States receives about 314 mrem/yr from man-made sources.

Some of the natural radioactive nuclides discussed above were identified in PBAPS REMP samples. The typical power production radionuclides, described in the next sections, were not identified and thus it can be concluded that PBAPS did not impact man and the environs during the 2020 operating period.

### III. Program Description

#### A. Sample Collection

Exelon Industrial Services (EIS) collected samples for the REMP for PBAPS Exelon Nuclear. This section describes the collection methods used by EIS to obtain environmental samples for the PBAPS REMP in 2020. Sample locations and descriptions can be found in Table B-1 and Figures B-1 through B-3, Appendix B. The collection procedures used by EIS are listed in Table B-2, Appendix B.

#### Aquatic Environment

The aquatic environment was evaluated by performing radiological analyses on samples of surface water, drinking water, fish and sediment. Surface water is sampled from two locations as prescribed by the ODCM: one upstream (1LL) and one downstream (1MM) of the plant discharge canal. Drinking water is sampled from a control location (6I) and up to 3 locations nearest to public drinking water supplies. Two locations are identified in the ODCM as the closest drinking water supplies, the Conowingo Dam (4L) and Chester Water Authority (13B). All samples were collected weekly by automatic sampling equipment or as grab samples. Weekly samples from each location were composited into two one-gallon monthly samples for analysis. A separate quarterly composite of the monthly samples was also collected.

Fish sample collection locations required by the ODCM are in an area close to the discharge of PBAPS (4) and a control location, unaffected by plant discharge (6). These samples were comprised of the flesh of commercially and recreationally important species specific to the environs around PBAPS. Fish samples were collected semiannually from two groups: Bottom Feeder (channel catfish, flathead catfish, carp and redhorse sucker) and Predator (smallmouth and largemouth bass), as these are the types of fish commonly collected by the public from the river around PBAPS. The total weight of fish flesh was approximately 1000 grams. The samples were preserved on ice for shipping to the laboratory.

The ODCM requires one sediment sample to be collected downstream of the plant in an area with existing or potential recreational value. The REMP collects samples from three locations (4J, 4T and 6F; 6F is the control). Sediment samples, composed of recently deposited substrate, were collected semiannually. Multiple grab samples of the sediment were collected to obtain an approximately homogenous, representative sample totaling 1000 grams.

#### Terrestrial Environment

The terrestrial environment was evaluated by performing radiological analyses on milk and food product samples. The ODCM requires milk samples at three locations with the highest dose potential, within three miles of PBAPS and one sample at a control location. The REMP meets these requirements and samples extra locations. Milk samples were collected biweekly at five locations (J, R, S, U, X and V; V is the control) from April through November, when the cows were on

pasture, and monthly from December through March, when the cows were primarily on feed. Six additional locations (C, D, E, P, W and Y; C and E are the controls) were sampled quarterly. Two-gallon samples were collected directly from the bulk tank at each location, preserved with sodium bisulfite, and shipped promptly to the laboratory.

The ODCM requires food products to be collected from the area of highest dose impact and a control location if milk sampling is unavailable in those locations. Milk sampling occurs in most every sector, except for SSE, S and WSW, where gardens are established for sampling. Food product samples, comprised of annual broad green leaf vegetation, were collected monthly at four locations (1C, 2Q, 3Q and 55; 55 is the control) from June through September. Typically, the 'planting' season starts late April/early May, with the plants gaining sufficient mass for collection in late June or July. Approximately 1000 g of unwashed samples were collected in plastic bags and shipped promptly to the laboratory, but sample size varied on garden production.

#### Airborne Environment

The airborne atmospheric environment was evaluated by performing radiological analyses on air particulate and radioiodine samples. The ODCM requires sampling from five locations, including three site boundary locations with greatest dose impact, one location within a local community with the highest dose impact, and one control location. Air particulate and radioiodine samples were collected and analyzed weekly from five locations (1B, 1C, 1Z/1A, 3A and 5H2; 5H2 is the control, 1A is the duplicate QA location). Airborne iodine and particulate samples were obtained at each location using a vacuum pump to pull air through a glass fiber filter and charcoal cartridge. The pumps were run continuously and sampled air at the rate of approximately 1 cubic foot per minute to obtain a minimum total volume of 280 cubic meters. The weekly filters were composited for a quarterly sample.

#### Ambient Gamma Radiation

The ambient gamma radiation in the areas surrounding PBAPS is measured using dosimeters, which are exposed to ambient radiation in the field and exchanged quarterly. The ODCM requires at least 40 routine monitoring stations with two or more dosimeters at each location for continuous monitoring. The REMP contains 48 dosimeter monitoring locations.

Optically-Stimulated Luminescent Dosimeters (OSLD) replaced the Thermo-Luminescent Dosimeter (TLD) starting in 2012. However, PBAPS continued using TLD in addition to OSLD to compare the two technologies, although only the OSLD data is reported. TLD field deployment will be discontinued starting in 2020.

The OSLD locations were placed on and around the PBAPS site as follows:

Site boundary monitoring consists of 19 locations (1A, 1B, 1C, 1D, 1E, 1F, 1G, 1H, 1I, 1J, 1K, 1L, 1M, 1NN, 1P, 1Q, 1R, 2, and 40), near and within the site perimeter



representing fence post doses (i.e., at locations where the doses will be potentially greater than maximum annual off-site doses).

Intermediate distance monitoring consists of 23 locations (14, 15, 17, 22, 23, 26, 27, 31A, 32, 3A, 42, 43, 44, 45, 46, 47, 48, 49, 4K, 5, 50, 51 and 6B), extending to approximately 5 miles from the site and designed to measure possible exposures to close-in population.

Six locations (16, 18, 19, 24, 2B and 1T) represent control and special interests areas such as population centers, schools, and nearest residents.

The specific dosimeter locations were determined by the following criteria:

1. The presence of relatively dense population, nearby residences, schools, and control locations;
2. Site meteorological data taking into account distance and elevation for each of the sixteen 22.5 degree sectors around the site, where estimated annual dose from PBAPS, if any, would be more significant;
3. And on hills free from local obstructions and within sight of the vents (where practical).

Each dosimetry location in the environment has 2 OSLD and 2 TLD dosimeters which were enclosed in plastic as a moisture barrier. Dosimeter housing are mesh plastic tubes, aligned horizontally and oriented such that dosimeter windows face the plant. Dosimeters themselves were placed vertically in the tubes so that no dosimeter was covered by another dosimeter and all dosimeters properly faced the plant.

## B. Sample Analysis

This section describes the analytical methods used by TBE, EIS and GEL Labs to analyze the environmental samples for radioactivity. The analytical procedures used by the laboratories are listed in Table B-2, Appendix B.

The required ODCM analyses include:

1. Concentrations of beta emitters in drinking water and air particulates;
2. Concentrations of gamma-emitting nuclides in surface and drinking water, air particulates, milk, fish, sediment and food products;
3. Concentrations of tritium in surface and drinking water;
4. Concentrations of I-131 in air, milk, and food products. Although not required by the ODCM, I-131 is also analyzed in drinking and surface water;
5. Ambient gamma radiation levels at various site environs.

## C. Data Interpretation

The radiological environmental and direct radiation data collected prior to PBAPS becoming operational was used as a baseline with which the 2020 operational

data were compared. In addition, data were compared to previous years' operational data for consistency and trending. Several factors are important in the interpretation of the data.

#### 1. Lower Limit of Detection and Minimum Detectable Concentration

The lower limit of detection (LLD) is defined as the smallest concentration of radioactive material in a sample that would yield a net count (above background) that would be detected with only a 5% probability of falsely concluding that a blank observation represents a "real" signal. The LLD is intended as a "before-the-fact" (*a priori*) estimate of a system (including instrumentation, procedure and sample type) and not as an "after-the-fact" (*a posteriori*) measurement. All analyses are designed to achieve the required detection limits for environmental samples, as described in the PBAPS ODCM.

The minimum detectable concentration or activity (MDC or MDA) is defined as the "after-the-fact" (*a posteriori*) estimate determined during the analysis of the sample.

#### 2. Net Activity Calculation and Reporting of Results

Net activity for a sample is calculated by subtracting background activity from the sample activity. Since the REMP measures extremely small changes in radioactivity in the environment, background variations can result in sample activity being lower than the background activity causing a negative number. MDC is reported in all cases where positive activity was not detected. In previous years, when net activity was reported, a lower baseline is seen in trending when compared to 2020 results.

Gamma spectroscopy results for each type of sample were grouped as follows:

- For surface and drinking water, twelve nuclides, manganese-54 (Mn-54), cobalt-58 (Co-58), iron-59 (Fe-59), cobalt-60 (Co-60), zinc-65 (Zn-65), zirconium-95 (Zr-95), niobium-95 (Nb-95), I-131, cesium-134 (Cs-134), Cs-137, barium-140 (Ba-140), and lanthanum-140 (La-140) were reported.
- For fish, eight nuclides, K-40, Mn-54, Co-58, Fe-59, Co-60, Zn-65, Cs-134 and Cs-137 were reported.
- For sediment, seven nuclides, K-40, Mn-54, Co-58, Co-60, I-131, Cs-134 and Cs-137 were reported.
- For air particulates, six nuclides, Be-7, Mn-54, Co-58, Co-60, Cs-134 and Cs-137 were reported.
- For milk, six nuclides, K-40, I-131, Cs-134, Cs-137, Ba-140 and La-140 were reported.

- For food products, eight nuclides, Be-7, K-40, Mn-54, Co-58, Co-60, I-131, Cs-134 and Cs-137 were reported.

Positive activity values (greater than MDC) were recorded and the mean and two standard deviation of the results were calculated. The standard deviation represents the variability of measured results for different samples of the same media rather than a single analysis uncertainty.

#### D. Program Exceptions

For 2020, the PBAPS REMP had a sample collection recovery rate of > 99%. The exceptions to this program are listed below:

Table 2 LIST OF SAMPLE ANOMALIES

Sample Type	Location Code	Collection Date	Reason
Food Products	All Locations	May, 2020	For gardens planted in May, there was insufficient volume for May collection
Food Products	1C	September, 2020	Only 2 of 3 samples could be collected due to end of season - normal occurrence. (IR 04371560)
Water	6I	10/10-11/04	Composite sampler timer out of service- grab sample obtained.

Table 3 LIST OF MISSING SAMPLES AND EQUIPMENT ISSUES

Sample Type	Location Code	Collection Date	Reason
AP/AI*	1B	05/20-06/06	Air sampler GFCI tripped, which led to a missed sample. (IR02701975 05)

\*AP/AI = Air Particulates/Air Iodine

Each program exception was reviewed to understand the causes of the program exception, and to implement corrective actions as necessary. Sampling and maintenance errors were reviewed with the personnel involved to prevent a recurrence. Occasional equipment breakdowns and power outages were unavoidable.

#### IV. Program Changes

There were no program changes in 2020.

## V. Results and Discussion

Appendix A contains a summary of all 2020 PBAPS REMP results which meets the requirement of Table 3 of NUREG 1302 'Branch Technical Position Paper'<sup>9</sup>. Table A-1 lists results by each sample media and analyses performed. The total number of analyses performed, required LLD, the number of positive results for each indicator and control location are also listed. From the positive results identified (greater than the MDA) the mean value, range and station locations with highest annual mean are listed. Commonly-identified nuclides are gross beta, K-40, and Be-7.

### A. Aquatic Environment

#### 1. Surface Water

A summary of the 2020 analysis results for surface water samples from stations 1LL and 1MM are listed below:

##### Tritium

Quarterly samples were analyzed for tritium activity. No tritium activity was detected and the required LLD was met. (Table C-I.1, Appendix C)

##### Iodine

Monthly samples were analyzed for low level I-131. All results were less than the MDC and the required LLD was met. (Table C-I.2, Appendix C)

##### Gamma Spectrometry

Monthly samples were analyzed for gamma-emitting nuclides. All nuclides were less than the MDC and all required LLDs were met. (Table C-I.3, Appendix C)

#### 2. Drinking Water

The results from the drinking water samples collected in 2020 from stations 13B, 4L and 6I are described below:

##### Gross Beta

Samples from all locations were analyzed monthly for concentrations of gross beta activity (Table C-II.1 and Figure C-1 Appendix C). Gross beta activity was detected in 18 of 36 samples. The values ranged from 1.7 to 4.5 pCi/L with a mean value of  $3.1 \pm 1.9$  pCi/L. The mean detected gross beta activity was less than the required LLD (4 pCi/L) which indicates that the measurement technique was even more sensitive than required. The detectable gross beta activity was well below the procedural investigation level (15 pCi/L). Concentrations detected were generally below those detected in previous years.

### Tritium

Monthly samples were composited quarterly and analyzed for tritium activity. Tritium activity was not detected in any samples and the required LLD was met. (Table C-II.2, Appendix C)

### Iodine

Monthly samples were analyzed for low level I-131. All results were less than the MDC and the required LLD was met. (Table C-II.3, Appendix C)

### Gamma Spectrometry

Samples from the three locations were analyzed monthly for gamma-emitting nuclides. All nuclides were less than the MDC and all required LLDs were met. (Table C-II.4, Appendix C)

## 3. Fish

Results from fish samples collected at locations 4 and 6 in 2020 are described below:

### Gamma Spectrometry

The edible portions of the collected fish samples were analyzed semiannually for gamma-emitting nuclides (Table C-III.1, Appendix C). Naturally-occurring K-40 was found at all stations and ranged from 3,101 to 3,631 pCi/kg (wet), with a mean value of  $3,271 \pm 382$  pCi/kg (wet), consistent with levels detected in previous years. No fission or activation products, due to plant operations were found in 2020 and all required LLDs were met. Figure C-2, Appendix C, displays the various gamma radionuclide MDC results for locations 4 and 6, based on the type of fish collected. All MDC results are less than the nuclide-specific LLDs. The last 15-year average Cs-137 MDC is also shown to trend 2020 results with historical results. There have been no detectable levels of Cs-137 in fish since 1983.

## 4. Sediment

Sediment samples were collected at locations 6F, 4J, and 4T and the results are described below:

### Gamma Spectrometry

Sediment samples were analyzed for gamma-emitting nuclides (Table C-IV.1, Appendix C). K-40 was found in all locations and ranged from 11,300 to 19,980 pCi/kg (dry) with a mean value of  $15,647 \pm 6,744$  pCi/kg (dry). No fission or activation products were found and all LLDs were met. The Cs-137 MDC results are displayed in Figure C-3, Appendix C, along with the 20-year average results.

## B. Atmospheric Environment

### 1. Airborne Particulates

Continuous air particulate samples were collected from five locations. The five locations were separated into three groups: Group I represents locations within the PBAPS site boundary (1B, 1C and 1Z/1A), Group II represents the location of the closest local community (3A) and Group III represents the control location at a remote distance from PBAPS (5H2). 1A results are discussed in Section H, Secondary Laboratory Analysis. The results from samples collected in 2020 are described below:

#### Gross Beta

Weekly samples were analyzed for concentrations of beta- emitters (Tables C-V.1, Appendix C). Detectable gross beta activity was observed at all locations. Onsite results ranged from  $6\text{E-}3$  to  $31\text{E-}3$  pCi/m<sup>3</sup>, with a mean of  $15\text{E-}3 \pm 11\text{E-}3$  pCi/m<sup>3</sup>. The results from local communities ranged from  $8\text{E-}3$  to  $30\text{E-}3$  pCi/m<sup>3</sup> with a mean of  $16\text{E-}3 \pm 12\text{E-}3$  pCi/m<sup>3</sup>. The control results ranged from  $7\text{E-}3$  to  $33\text{E-}3$  pCi/m<sup>3</sup> with a mean of  $16\text{E-}3 \pm 12\text{E-}3$  pCi/m<sup>3</sup>.

The range of detectable results and mean value from all locations are the same within error, indicating the gross beta activity is not a result of the operation of PBAPS, as shown in Figure C-4, Appendix C. In addition, a comparison of the 2020 air particulate data with historical data indicates a decreasing trend in gross beta activity since initial operation of the plant (Figure C-4, Appendix C).

#### Gamma Spectrometry

Quarterly samples were analyzed for gamma-emitting nuclides (Table C-V.2, Appendix C). Naturally-occurring Be-7 activity, from cosmic rays, was detected in all 20 samples. The values ranged from  $54\text{E-}3$  to  $116\text{E-}3$  pCi/m<sup>3</sup>, with a mean value of  $81\text{E-}3 \pm 23\text{E-}3$  pCi/m<sup>3</sup>. All power production nuclides were less than the MDC and all required LLDs were met.

### 2. Airborne Iodine

Weekly samples were also analyzed for low-level I-131. All results were less than the MDC for I-131 and the required LLD was met. (Table C-VI.1, Appendix C)

## C. Terrestrial

### 1. Milk

During 2020, 150 milk samples were collected and analyzed from the following locations: D, J, R, P, S, U, W, X, Y (indicators) and C, E, V (controls). The results are described below:

### Iodine-131

Milk samples from all locations were analyzed for concentrations of I-131 (Tables C-VII.1, Appendix C). All results were less than the MDC for I-131 and all required LLDs were met. Figure C-5 displays the 2020 milk I-131 results for both indicator and control locations. All results are less than the LLD (1 pCi/L) and much less than the reporting level (3 pCi/L).

### Gamma Spectrometry

Milk samples from all locations were analyzed for concentrations of gamma-emitting nuclides (Table C-VII.2, Appendix C). Naturally-occurring K-40 was found in all samples and ranged from 643 to 1,583 pCi/l, with a mean value of  $1249 \pm 270$  pCi/L. All other nuclides were less than the MDC and all required LLDs were met.

2020 Cs-134 and Cs-137 MDC results are plotted in Figure C-5 with the required LLDs and Reporting Levels. All results are much less than the LLDs and reporting levels. The last 15-year average MDC of Cs-137 in milk is also plotted in Figure C-5, Appendix C. There is no statistical difference between the 2020 MDC Cs-137 results and the 15-year historical MDC.

## 2. Food Products

Throughout 2020, 47 samples of various green leafy vegetation (swiss chard, cabbage, collards, kale, broccoli, etc.) were collected and analyzed for concentrations of gamma-emitting nuclides (Table C-VIII.1, Appendix C). The results are discussed below:

### Gamma Spectrometry

Naturally-occurring Be-7 activity was found in 18 of 47 samples and ranged from 370 to 3,534 pCi/kg (wet), with a mean of  $1,219 \pm 1,784$  pCi/kg (wet). Also, naturally-occurring K-40 activity was found in all samples and ranged from 1,380 to 7,608 pCi/kg (wet), with a mean of  $4,242 \pm 2,705$  pCi/kg (wet). All power production nuclides were less than the MDC and all required LLDs were met.

## D. Ambient Gamma Radiation

Results of OSLD measurements are listed in Tables C-IX.1 and C-IX.2 and Figure C-6, Appendix C.

In 2019, six years of OSLD data (2012-2018) were re-evaluated with the new methodology presented in Exelon corporate procedure CY-AA-170-1001, in order to determine a background dose and baseline for each location in the REMP. Detectable Facility Dose is any normalized net dose above the sum of the normalized mean background dose and minimum differential dose ( $B_{Q/A} + MDD_{Q/A}$ ) and is reported both quarterly and annually for each location. Therefore, mean gross dose of 'indicator' and 'control' locations will no longer be reported. Only Quarterly and Annual Normalized Net Dose for each location is reported in Table

## C-IX.1 and C-IX.2.

The net dose is calculated by subtracting a control transit dosimeter and extraneous dose rather than a control or background location dose. The net dose is normalized to a standard 91-day quarter rather than previously reported monthly doses. Figure C-6 displays the  $B_A + MDD_A$  for each location as a dash mark, and the annual normalized net dose is shown as a column graph. Any column above the dash mark, would indicate positive facility related dose.

All locations showed no normalized net quarterly dose above the  $B_A + MDD_A$ , therefore, there is no detectable ambient gamma radiation to the members of the public due to PBAPS operations

### E. Independent Spent Fuel Storage Installation (ISFSI)

ISFSI was initiated in June 2000. Three new casks were added to the ISFSI pad in 2020, filling the original ISFSI pad design requiring construction of a second pad, which completed in 2019. Site boundary OSLDs which measure the ambient gamma radiation closest to ISFSI are locations 1A, 1D, 1M, 1P, 1Q, 1R, with 1R being the closest. Location 2B is the nearest real resident which could be impacted by ISFSI. Location 1R showed positive facility-related dose (<25 mrem/yr) yet did not impact the nearest resident location (2B) as that location had no detectable facility-related dose. Location 2B, follows closely with values from locations 1A, 1D, and controls, indicating no impact from ISFSI on nearest real resident. Data from location 2B is used to demonstrate compliance to both 40CFR190 and 10CFR72.104 limits. All radiation levels are well below regulatory limits.

In 2019, a six year data set (2012-2018) was used to determine the background dose at each location. In 2020, there was no detectable facility-related dose at any location. Detectable facility-related dose at 1R in the 3Q of 2019 (6.4 mrem/std. qtr), leading to detectable annual facility-related dose (15.5 mrem/yr). This was the first time PB reported facility-related dose due to ISFSI, which was expected due to the increasing trends seen at 1R over the years.

Also in 2019, the ISFSI pad was filled with its last TN-68 cask. Construction began last year on a second ISFSI pad which was loaded with Holtec casks. Facility-related dose is expected to increase due to the second ISFSI pad, but still remain below the 40CFR190 and 10CFR72.104 limits.

### F. Land Use Census

A Land Use Survey, conducted during the fall of 2020, was performed by Exelon Industrial Services (EIS), to comply with Section 3.8.E.2 of PBAPS's ODCM Specifications. The survey documented the nearest milk-producing and meat animal, nearest residence, and garden larger than 500 square feet in each of the sixteen meteorological sectors out to five miles.

Also, because PBAPS is an elevated release facility, an additional requirement of identifying all gardens larger than 500 square feet and every dairy operation within



three (3) miles was included in the survey. The distance and direction of all locations were positioned using Global Positioning System (GPS) technology. The results of this survey are summarized below.

There was no change in nearest residents compared to the 2019 report. There were gardens identified in all sectors except the NNW sector. Eight (8) new gardens were located this year in NNE, NE, ENE, ESE, SW, WSW, WNW and NW sectors. The new gardens in the ESE and NW sectors were identified as the closest gardens for that sector. The nearest gardens in all other sectors are the same as in the 2019 report.

Animals used for meat consumption were identified in 15 of the 16 sectors (NNW sector had no animals identified this year). Seven (7) new sites were identified this year in NE, ESE, SSW, WSW, NW and NNW sectors, with the nearest meat animal in the WSW and NNW sectors. The nearest animal in all other sectors remains the same as in last year's report. Dairy sites were identified in 12 of 16 sectors. There were no new dairy sites there were no changes in nearest milk-producing animal in any sector.

Location of the Nearest Residence, Garden, Milk, Meat, Animal within a Five-Mile Radius of PBASP Reactor Building Exhaust Vents				
Sector	Residence Feet	Garden Feet	Milk Farm Feet	Meat Animal Feet
1 N	12,362	14,003	14,183	14,183
2 NNE	11,112	11,041	10,843	10,843
3 NE	10,080	10,004	10,492	10,080
4 ENE	10,495	11,554	10,925*	10,925
5 E	10,066	14,540	14,471	13,712
6 ESE	16,085	19,109	20,154	16,085
7 SE	10,772	10,772	19,134*	19,134
8 SSE	3,912	3,912	-	-
9 S	5,545	5,545	-	9,247
10 SSW	6,072	6,418	11,602	7,187
11 SW	4,755	4,865	4,860*	4,860
12 WSW	4,036	7,487	-	4,204
13 W	5,327	5,327	5,136*	5,136
14 WNW	2,928	4,192	22,124	3,926
15 NW	2,948	9,545	9,545	7,582
16 NNW	5,124	-	-	5,124

\*Farm included in the REMP

G. Errata Data

There was no errata data for 2020.

H. Secondary Laboratory Analysis

Appendix D of this report presents the results of data analyses performed by the QC laboratory, EIS and GEL. Duplicate samples were obtained from

several locations and analyzed by both the primary and QC laboratories. GEL was only used for H-3 analyses of water samples because EIS could not perform those analyses. Comparisons of the results for all media were within expected ranges. (Figures D-1 and D-2)

I. Summary of Results – Quality Control (QC) Laboratory Analysis

The primary and secondary laboratories analyzed Performance Evaluation (PE) samples of air particulate, air iodine, milk, soil, food products and water matrices (Appendix E). The PE samples, supplied by Eckert & Ziegler Analytcs, Inc., Environmental Resource Associates (ERA) and DOE's Mixed Analyte Performance Evaluation Program (MAPEP), were evaluated against a pre-set acceptance criteria described in Appendix F.

For the Teledyne Brown Engineering (TBE) laboratory, 126 out of 133 analyses performed met the specified acceptance criteria. Seven analyses (AP - U-233/234, U-238; milk Sr-89; water I-131, Gross Alpha, Gross Beta; soil - Ni-63) did not meet the specified acceptance criteria and are documented in Appendix F. TBE has addressed each issue through the TBE Corrective Action Program.

The EIS laboratory analyzed the following nuclides for PBAPS: gross beta, gamma and low-level iodine. For the EIS laboratory, 158 of 162 analyses met the specified acceptance criteria in 2020. Four (4) analyses did not meet the specified acceptance criteria: water matrix - gross beta; AP - Zn-65 (2 detectors); Milk - Zn-65. Failures were entered into the Corrective Action Program for tracking and to prevent future occurrence.

For the GEL laboratory, 76 of 79 analyses met the specified acceptance criteria. Tritium (water matrix) was the only nuclide analyzed for Peach Bottom REMP and all analyses met the specified acceptance criteria. Nuclides analyzed for Peach Bottom RGPP included H-3 and Gamma (water matrix). Three water nuclides (H-3, I-131 and Co-60) did not meet the specified acceptance criteria and is documented in Appendix F. All failures were addressed through GEL's Corrective Action Program.

The Inter-Laboratory Comparison Program provides evidence of "in control" counting systems and methods, and that the laboratories are producing accurate and reliable data.

## VI. References

1. Preoperational Environs Radioactivity Survey Summary Report, March 1960 through January 1966. (September 1967)
2. Interex Corporation, Peach Bottom Atomic Power Station Regional Environs Radiation Monitoring Program Preoperational Summary Report, Units 2 and 3, 5 February 1966 through 8 August 1973, June 1977, Natick, Massachusetts
3. Radiation Management Corporation Publication, Peach Bottom Atomic Power Station Preoperational Radiological Monitoring Report for Unit 2 and 3, January 1974, Philadelphia, Pennsylvania
4. Information from NCRP Reports 160 and 94
5. Primarily from airborne radon and its radioactive progeny
6. Includes CT (147 mrem), nuclear medicine (77 mrem), interventional fluoroscopy (43 mrem) and conventional radiography and fluoroscopy (33 mrem)
7. Primarily from cigarette smoking (4.6 mrem), commercial air travel (3.4 mrem), building materials (3.5 mrem), and mining and agriculture (0.8 mrem)
8. Industrial, security, medical, educational, and research
9. Offsite Dose Calculation Manual Guidance: Standard Radiological Effluent Controls for Boiling Water Reactors, Generic Letter 89-01, Supplement No. 1 (NUREG-1302), April 1991
10. American National Standards Institute/Health Physics Society, (ANSI/HPS) N13.37-2014, "Environmental Dosimetry – Criteria for System Design and Implementation"
11. U.S. Nuclear Regulatory Commission, Regulatory Guide 4.13, Revision 2, "Environmental Dosimetry - Performance, Specifications, Testing, and Data Analysis", June, 2020
12. Code of Federal Regulations 40 CFR 190, "Environmental Radiation Protection Standards for Nuclear Power Operations", 1977

## **APPENDIX A**

# **RADIOLOGICAL ENVIRONMENTAL MONITORING REPORT SUMMARY**

Intentionally left blank

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR  
PEACH BOTTOM ATOMIC POWER STATION, 2020**

NAME OF FACILITY:		PEACH BOTTOM ATOMIC POWER STATION		DOCKET NUMBER: 50-277 & 50-278		REPORTING PERIOD: 2020		LOCATION OF FACILITY:		YORK COUNTY, PA	
MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT)	TYPES OF ANALYSIS PERFORMED	NUMBER OF ANALYSIS PERFORMED	REQUIRED LOWER LIMIT OF DETECTION (LLD)	INDICATOR LOCATIONS MEAN (M) (F) RANGE	CONTROL LOCATION MEAN (M) (F) RANGE	LOCATION WITH HIGHEST ANNUAL MEAN (M) MEAN (M) (F) RANGE	STATION # NAME	DISTANCE AND DIRECTION	NUMBER OF NONROUTINE REPORTED MEASUREMENTS		
SURFACE WATER (PCI/LITER)	H-3	8	200	<LLD	<LLD	-			0		
	I-131	24	1	<LLD	<LLD	-			0		
	GAMMA	Mn-54	15	15	<LLD	<LLD	-			0	
		Co-58	15	30	<LLD	<LLD	-			0	
		Fe-59	15	30	<LLD	<LLD	-			0	
		Co-60	15	30	<LLD	<LLD	-			0	
		Zn-65	15	30	<LLD	<LLD	-			0	
		Nb-95	15	30	<LLD	<LLD	-			0	
		Zr-95	15	30	<LLD	<LLD	-			0	
		Cs-134	15	18	<LLD	<LLD	-			0	
		Cs-137	15	60	<LLD	<LLD	-			0	
		Ba-140	15	15	<LLD	<LLD	-			0	
		La-140	15	15	<LLD	<LLD	-			0	
		DRINKING WATER (PCI/LITER)	GR-B	36	4	3.2 (13/24) 1.7 - 4.5	2.8 (5/12) 1.9 - 3.6	3.5 (6/12) 1.7 - 4.5	4L INDICATOR CONOWINGO DAM EL 33' MSL 45900 FEET SE		0
H-3	12		200	<LLD	<LLD	-			0		
I-131 (LOW LVL)	36		1	<LLD	<LLD	-			0		
GAMMA	MN-54		15	15	<LLD	<LLD	-			0	
	CO-58		15	30	<LLD	<LLD	-			0	
	FE-59		15	30	<LLD	<LLD	-			0	
	CO-60		15	30	<LLD	<LLD	-			0	
	ZN-65		15	30	<LLD	<LLD	-			0	
	NB-95		15	30	<LLD	<LLD	-			0	
	ZR-95		15	30	<LLD	<LLD	-			0	
	CS-134		15	18	<LLD	<LLD	-			0	
	CS-137		15	60	<LLD	<LLD	-			0	
	BA-140		15	15	<LLD	<LLD	-			0	
	LA-140		15	15	<LLD	<LLD	-			0	

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR  
PEACH BOTTOM ATOMIC POWER STATION, 2020**

NAME OF FACILITY:		PEACH BOTTOM ATOMIC POWER STATION		DOCKET NUMBER:		50-277 & 50-278	
LOCATION OF FACILITY:		YORK COUNTY, PA		REPORTING PERIOD:		2020	
MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT)	TYPES OF ANALYSIS PERFORMED	NUMBER OF ANALYSIS PERFORMED	REQUIRED LOWER LIMIT OF DETECTION (LLD)	INDICATOR LOCATIONS MEAN (M) (F)	CONTROL LOCATION MEAN (M) (F)	LOCATION WITH HIGHEST ANNUAL MEAN (M)	NUMBER OF NONROUTINE REPORTED MEASUREMENTS
				RANGE	RANGE	MEAN (M) (F) RANGE	STATION # NAME DISTANCE AND DIRECTION
<b>BOTTOM FEEDER (PCI/KG WET)</b>	<b>GAMMA</b>	4					
	K-40		NA	3283 (2/2)	3106.5 (2/2)	3283 (2/2)	4 INDICATOR CONOWINGO POND
	MN-54		130	3210 - 3356	3101 - 3112	3210 - 3356	600-10000 FEET SE
	CO-58		130	<LLD	<LLD	-	
	FE-59		260	<LLD	<LLD	-	
	CO-60		130	<LLD	<LLD	-	
	ZN-65		260	<LLD	<LLD	-	
	CS-134		130	<LLD	<LLD	-	
	CS-137		150	<LLD	<LLD	-	
<b>PREDATOR (PCI/KG WET)</b>	<b>GAMMA</b>	4					
	K-40		NA	3537 (2/2)	3157.5 (2/2)	3537 (2/2)	4 INDICATOR CONOWINGO POND
	MN-54		130	3443 - 3631	3104 - 3211	3443 - 3631	600-10000 FEET SE
	CO-58		130	<LLD	<LLD	-	
	FE-59		260	<LLD	<LLD	-	
	CO-60		130	<LLD	<LLD	-	
	ZN-65		260	<LLD	<LLD	-	
	CS-134		130	<LLD	<LLD	-	
	CS-137		150	<LLD	<LLD	-	
<b>SEDIMENT (PCI/KG DRY)</b>	<b>GAMMA</b>	6					
	K-40		NA	15623 (4/4)	15695 (2/2)	19085 (2/2)	4T INDICATOR CONOWINGO POND NEAR CONOWINGO DAM
	MN-54		NA	11300 - 19980	13990 - 17400	18190 - 19980	41800 FEET SE
	CO-58		NA	<LLD	<LLD	-	
	CO-60		NA	<LLD	<LLD	-	
	CS-134		150	<LLD	<LLD	-	
	CS-137		180	<LLD	<LLD	-	

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR  
PEACH BOTTOM ATOMIC POWER STATION, 2020**

NAME OF FACILITY:		PEACH BOTTOM ATOMIC POWER STATION		DOCKET NUMBER:		50-277 & 50-278		
LOCATION OF FACILITY:		YORK COUNTY, PA		REPORTING PERIOD:		2020		
MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT)	TYPES OF ANALYSIS PERFORMED	NUMBER OF ANALYSIS PERFORMED	REQUIRED LOWER LIMIT OF DETECTION (LLD)	INDICATOR LOCATIONS MEAN (M) (F) RANGE	CONTROL LOCATION MEAN (M) (F) RANGE	LOCATION WITH HIGHEST ANNUAL MEAN (M) MEAN (M) (F) RANGE	STATION # NAME DISTANCE AND DIRECTION	NUMBER OF NONROUTINE REPORTED MEASUREMENTS
<b>AIR PARTICULATE (E-3 PCI/CU.METER)</b>	<b>GR-B</b>	259	10	15 (207/207) 6 - 31	16 (52/52) 7 - 33	17 (51/51) 9 - 31	1B INDICATOR WEATHER STATION #2 2500 FEET NW	0
<b>GAMMA</b>	<b>BE-7</b>	20	NA	77.8 (16/16) 54 - 98	91.7 (4/4) 69 - 116	91.7 (4/4) 69 - 116	5H2 CONTROL MANOR SUBSTATION 162400 FEET NE	0
	<b>MIN-54</b>		NA	<LLD	<LLD	-		0
	<b>CO-58</b>		NA	<LLD	<LLD	-		0
	<b>CO-60</b>		NA	<LLD	<LLD	-		0
	<b>CS-134</b>		50	<LLD	<LLD	-		0
	<b>CS-137</b>		60	<LLD	<LLD	-		0
<b>AIR IODINE (E-3 PCI/CU.METER)</b>	<b>GAMMA</b>	259	70	<LLD	<LLD	-		0
<b>MILK (PCI/LITER)</b>	<b>I-131 (LOW LVL)</b>	150	1	<LLD	<LLD	-		0
	<b>GAMMA</b>	150	NA	1214 (121/121) 643 - 1583	1238 (29/29) 1043 - 1404	1381 (4/4) 1261 - 1583	D INDICATOR 18500 FEET NE	0
	<b>CS-134</b>		15	<LLD	<LLD	-		0
	<b>CS-137</b>		18	<LLD	<LLD	-		0
	<b>BA-140</b>		60	<LLD	<LLD	-		0
	<b>LA-140</b>		15	<LLD	<LLD	-		0

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.



**TABLE A-1 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY FOR  
PEACH BOTTOM ATOMIC POWER STATION, 2020**

NAME OF FACILITY:		PEACH BOTTOM ATOMIC POWER STATION		DOCKET NUMBER:		50-277 & 50-278	
LOCATION OF FACILITY:		YORK COUNTY, PA		REPORTING PERIOD:		2020	
MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT)	TYPES OF ANALYSIS PERFORMED	NUMBER OF ANALYSIS PERFORMED	REQUIRED LOWER LIMIT OF DETECTION (LLD)	INDICATOR LOCATIONS MEAN (M) (F) RANGE	CONTROL LOCATION MEAN (M) (F) RANGE	LOCATION WITH HIGHEST ANNUAL MEAN (M)	NUMBER OF NONROUTINE REPORTED MEASUREMENTS
VEGETATION (PCI/KG WET)						STATION # NAME DISTANCE AND DIRECTION	
	<b>GAMMA</b>	47					
	BE-7		NA	1320 (13/35) 477 - 3534	959 (5/12) 370 - 1901	1849 (5/11) PEACH BOTTOM SOUTH SUB STATION 4700 FEET SSE	0
	K-40		NA	4056.2 (35/35) 1380 - 6678	4782.4 (12/12) 2728 - 7608	4888 (12/12) 3Q INDICATOR 103 FLINTVILLE RD. 9500 FEET W	0
	MN-54		NA	<LLD	<LLD	-	0
	CO-58		NA	<LLD	<LLD	-	0
	CO-60		NA	<LLD	<LLD	-	0
	I-131		60	<LLD	<LLD	-	0
	CS-134		60	<LLD	<LLD	-	0
	CS-137		80	<LLD	<LLD	-	0
<b>DIRECT RADIATION (MILLIROENTGEN/STD.MO.)</b>	<b>OSLD-QUARTERLY</b>	192	NA	ND* ND*	ND* ND*	N/A*	0

\*ND = Nondetectable; N/A = Mean no longer reported for direct radiation

(M) The Mean Values are calculated using the positive values. (F) Fraction of detectable measurement are indicated in parentheses.

## **APPENDIX B**

### **SAMPLE DESIGNATION AND LOCATIONS**

Intentionally left blank

TABLE B-1 Radiological Environmental Monitoring Program – Sampling Locations, Distance and Direction from Reactor Buildings, Peach Bottom Atomic Power Station, 2020

Location	Location Description	Distance & Direction From Site
<b>A. Surface Water</b>		
1LL	Peach Bottom Units 2 and 3 Intake - Composite (Control)	1,200 feet ENE
1MM	Peach Bottom Canal Discharge -Composite	5,500 feet SE
<b>B. Drinking (Potable) Water</b>		
4L	Conowingo Dam EL 33' MSL - Composite	45,900 feet SE
6I	Holtwood Dam Hydroelectric Station - Composite (Control)	30,500 feet NW
13B	Chester Water Authority (CWA) Susquehanna Pumping Station- Composite	13,300 feet ESE
<b>C. Fish</b>		
4	Conowingo Pond	6,000 – 10,000 feet SE
6	Holtwood Pond (Control)	50,000 – 70,000 feet NNW
<b>D. Sediment</b>		
4J	Conowingo Pond near Berkin's Run	7,400 feet SE
4T	Conowingo Pond near Conowingo Dam	41,800 feet SE
6F	Holtwood Dam (Control)	31,500 feet NW
<b>E. Air Particulate - Air Iodine</b>		
1B	Weather Station #2	2,500 feet NW
1Z	Weather Station #1	1,500 feet SE
1A	Weather Station #1	1,500 feet SE
1C	Peach Bottom South Sub Station	4,700 feet SSE
3A	Delta, PA – Substation	19,300 feet SW
5H2	Manor Substation (Control)	162,400 feet NE
<b>F. Milk - bi-weekly / monthly</b>		
J		5,100 feet W
R		4,900 feet SW
S		19,100 feet SE
U		11,200 feet SSW
V	(Control)	32,600 feet W
X		9,500 feet NW
<b>G. Milk - quarterly</b>		
C	(Control)	50,400 feet NW
D		18,500 feet NE
E	(Control)	46,100 feet N
P		11,000 feet ENE
W		89,200 feet S
Y		10,500 feet NE
<b>H. Food Products</b>		
1C		4,700 feet SSE
2Q		9,200 feet SW
3Q		9,500 feet W
55	(Control)	51,900 feet NE

TABLE B-1 Radiological Environmental Monitoring Program – Sampling Locations, Distance and Direction from Reactor Buildings, Peach Bottom Atomic Power Station, 2020

Location	Location Description	Distance & Direction From Site
<b>J. Environmental Dosimetry - OSLD</b>		
<u>Site Boundary</u>		
1A	Weather Station #1	1,500 feet SE
1B	Weather Station #2	2,500 feet NW
1C	Peach Bottom South Substation	4,700 feet SSE
1D	140 o Sector	3,500 feet SSE
1E	Peach Bottom 350o Sector Hill	3,000 feet NNW
1F	Peach Bottom 200o Sector Hill	2,900 feet SSW
1G	Peach Bottom North Substation	3,100 feet WNW
1H	Peach Bottom 270o Sector Hill	3,200 feet W
1I	Peach Bottom South Substation	2,900 feet S
1J	Peach Bottom 180o Sector Hill	4,000 feet S
1K	Peach Bottom Site Area	4,700 feet SW
1L	Peach Bottom Unit 3 Intake	1,100 feet NE
1M	Discharge	5,400 feet SE
1NN	Peach Bottom Site	2,700 feet WSW
1P	Tower B & C Fence	2,200 feet ESE
1Q	Tower D & E Fence	3,300 feet SE
1R	Transmission Line Hill/ISFSI Pad	2,800 feet SSE
2	Peach Bottom 130o Sector Hill	4,700 feet SE
2B*	Burk Property	3,900 feet SSE
40	Peach Bottom Site Area	8,000 feet SW
<u>Intermediate Distance</u>		
1T*	Lay Road/LLRWSF	3,100 feet WNW
3A	Delta, PA Substation	19,300 feet SW
4K	Conowingo Dam Power House Roof	45,900 feet SE
5	Wakefield, PA	24,400 feet E
6B	Holtwood Dam Power House Roof	30,400 feet NW
14	Peters Creek	10,300 feet E
15	Silver Spring Rd	19,300 feet N
17	Riverview Rd	21,500 feet ESE
22	Eagle Road	12,500 feet NNE
23	Peach Bottom 150° Sector Hill	5,500 feet SSE
26	Slab Road	21,800 feet NW
27	N. Cooper Road	14,400 feet S
31A	Eckman Rd	24,100 feet SE
32	Slate Hill Rd	14,400 feet ENE
42	Muddy Run Environ. Laboratory	21,600 feet NNW
43	Drumore Township School	26,200 feet NNE
44	Goshen Mill Rd	26,700 feet NE
45	PB-Keeney Line	18,500 feet ENE
46	Broad Creek	23,800 feet SSE
47	Broad Creek Scout Camp	22,700 feet S
48	Macton Substation	26,500 feet SSW
49	PB-Conastone Line	21,500 feet WSW
50	TRANSCO Pumping Station	26,400 feet W
51	Fin Substation	21,000 feet WNW
<u>Control</u>		
16	Nottingham, PA Substation (Control)	67,100 feet E
18	Fawn Grove, PA (Control)	52,200 feet W
19	Red Lion, PA (Control)	124,000 feet WNW
24	Harrisville, MD Substation (Control)	58,200 feet ESE

\*Nearest Residents

TABLE B-2 Radiological Environmental Monitoring Program – Summary of Sample Collection and Analytical Methods, Peach Bottom Atomic Power Station, 2020

Sample Medium	Analysis	Sampling Method	Collection Procedure Number	Sample Size	Analytical Procedure Number
Surface Water	Gamma Spectroscopy	Monthly composite from a continuous water compositor	CY-ES-240 Surface, Drinking, and Effluent Water Sample Collection for Radiological Analysis ST-C-095-835-2 Circulating Water Intake and Discharge Composite Sampling	2 gallon	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis EIS, CY-ES-205 Gamma Counting Using the HPGe Detector with the Genie PC Counting System
Surface Water	Tritium	Quarterly composite from a continuous water compositor	CY-ES-240 Surface, Drinking, and Effluent Water Sample Collection for Radiological Analysis ST-C-095-835-2 Circulating Water Intake and Discharge Composite Sampling	500 ml	TBE, TBE-2011 Tritium Analysis in Drinking Water by Liquid Scintillation GEL, EPA906.0 Mod, for Tritium analysis by Liquid Scintillation
Surface Water	I-131	Monthly composite from a continuous water compositor	CY-ES-240 Surface, Drinking, and Effluent Water Sample Collection for Radiological Analysis ST-C-095-835-2 Circulating Water Intake and Discharge Composite Sampling	2 gallon	TBE, TBE-2012 Radioiodine in Various Matrices EIS, CY-ES-205 Gamma Counting Using the HPGe Detector with the Genie PC Counting System
Drinking Water	Gross Beta	Monthly composite from a continuous water compositor	CY-ES-240 Surface, Drinking, and Effluent Water Sample Collection for Radiological Analysis	2 gallon	TBE, TBE-2008 Gross Alpha and/or Gross Beta Activity in Various Matrices CY-ES-206, Operation of the Tennelec S5E Proportional Counter
Drinking Water	I-131	Monthly composite from a continuous water compositor	CY-ES-240 Surface, Drinking, and Effluent Water Sample Collection for Radiological Analysis	2 gallon	TBE, TBE-2012 Radioiodine in Various Matrices EIS, CY-ES-205 Gamma Counting Using the HPGe Detector with the Genie PC Counting System
Drinking Water	Gamma Spectroscopy	Monthly composite from a continuous water compositor	CY-ES-240 Surface, Drinking, and Effluent Water Sample Collection for Radiological Analysis	2 gallon	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis EIS, CY-ES-205 Gamma Counting Using the HPGe Detector with the Genie PC Counting System
Drinking Water	Tritium	Quarterly composite from a continuous water compositor	CY-ES-240 Surface, Drinking, and Effluent Water Sample Collection for Radiological Analysis	500 ml	TBE, TBE-2011 Tritium Analysis in Drinking Water by Liquid Scintillation GEL, EPA906.0 Mod, for Tritium Analysis by Liquid Scintillation
Fish	Gamma Spectroscopy	Semi-annual samples collected via electroshocking or other techniques	NAI-ER3 Collection of fish samples for radiological analysis (PBAPS)	1000 grams (wet)	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis EIS, CY-ES-205 Gamma Counting Using the HPGe Detector with the Genie PC Counting System

TABLE B-2 Radiological Environmental Monitoring Program – Summary of Sample Collection and Analytical Methods, Peach Bottom Atomic Power Station, 2020

Sample Medium	Analysis	Sampling Method	Collection Procedure Number	Sample Size	Analytical Procedure Number
Sediment	Gamma Spectroscopy	Semi-annual grab samples	NAI-ER3 Collection of sediment samples for radiological analysis (PBAPS)	500 grams (dry)	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis EIS, CY-ES-205, Gamma Counting Using the HPGe Detector with the Genie PC Counting System
Air Particulates	Gross Beta	One-week composite of continuous air sampling through glass fiber filter paper	CY-ES-237 Air Iodine and Air Particulate Sample Collection for Radiological Analysis	1 filter (~280 cubic meters weekly)	TBE, TBE-2008 Gross Alpha and/or Gross Beta Activity in Various Matrices EIS, CY-ES-206, Operation of the Tennelec S5E Proportional Counter
Air Particulates	Gamma Spectroscopy	Quarterly composite of each station	TBE, TBE-2023 Compositing of samples CY-ES-204 Sample Preparation for Gamma and Beta Counting	13 filters (~3600 cubic meters)	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis EIS, CY-ES-205 Gamma Counting Using the HPGe Detector with the Genie PC Counting System
Air Iodine	Gamma Spectroscopy	One-week composite of continuous air sampling through charcoal filter	CY-ES-237 Air Iodine and Air Particulate Sample Collection for Radiological Analysis	1 filter (~280 cubic meters weekly)	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis EIS, CY-ES-205 Gamma Counting Using the HPGe Detector with the Genie PC Counting System
Milk	I-131	Bi-weekly grab sample when cows are on pasture. Monthly all other times	CY-ES-238 Milk Sample Collection for Radiological Analysis	2 gallon	TBE, TBE-2012 Radioiodine in Various Matrices EIS, CY-ES-205 Gamma Counting Using the HPGe Detector with the Genie PC Counting System
Milk	Gamma Spectroscopy	Bi-weekly grab sample when cows are on pasture; Monthly all other times	CY-ES-238 Milk Sample Collection for Radiological Analysis	2 gallon	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis EIS, CY-ES-205 Gamma Counting Using the HPGe Detector with the Genie PC Counting System
Food Products	Gamma Spectroscopy	Monthly when available	CY-ES-241 Vegetation Sample Collection for Radiological Analysis	1000 grams	TBE, TBE-2007 Gamma-Emitting Radioisotope Analysis EIS, CY-ES-205 Gamma Counting Using the HPGe Detector with the Genie PC Counting System
OSLD	Optically Stimulated Luminescence Dosimetry	Quarterly OSLDs comprised of two $Al_2O_3:C$ Landauer Incorporated elements.	CY-ES-239, Collection/Exchange of Field Dosimeters for Radiological Analysis	2 dosimeters	Landauer Incorporated




Figure B-1  
Environmental Sampling Locations Within One Mile  
of Peach Bottom Atomic Power Station, 2020






Figure B-2  
 Environmental Sampling Locations Between One and Approximately  
 Five Miles of Peach Bottom Atomic Power Station, 2020




Figure B-3  
 Environmental Sampling Locations Greater Than  
 Five Miles from Peach Bottom Atomic Power Station, 2020

Intentionally left blank

## **APPENDIX C**

### **DATA TABLES AND FIGURES PRIMARY LABORATORY**

Intentionally left blank

**Table C-I.1      CONCENTRATIONS OF TRITIUM IN SURFACE WATER  
 SAMPLES COLLECTED IN THE VICINITY OF  
 PEACH BOTTOM ATOMIC POWER STATION, 2020**  
 RESULTS IN UNITS OF PCI/LITER + 2 SIGMA

COLLECTION PERIOD	1LL	1MM
01/01/20 - 04/01/20	< 188	< 184
04/01/20 - 07/01/20	< 186	< 186
07/01/20 - 09/30/20	< 173	< 168
09/30/20 - 12/29/20	< 180	< 182
<i>MEAN</i>	-	-

**Table C-I.2      CONCENTRATIONS OF LOW LEVEL I-131 IN SURFACE WATER  
 SAMPLES COLLECTED IN THE VICINITY OF  
 PEACH BOTTOM ATOMIC POWER STATION, 2020**  
 RESULTS IN UNITS OF PCI/LITER + 2 SIGMA

COLLECTION PERIOD	1LL	1MM
01/01/20 - 01/29/20	< 0.9	< 0.8
01/29/20 - 02/26/20	< 1.0	< 0.8
02/26/20 - 04/01/20	< 0.6	< 0.6
04/01/20 - 04/29/20	< 0.7	< 0.6
04/29/20 - 05/27/20	< 0.8	< 0.8
05/27/20 - 07/01/20	< 0.7	< 0.8
07/01/20 - 07/29/20	< 0.6	< 0.6
07/29/20 - 09/02/20	< 0.7	< 0.7
09/02/20 - 09/30/20	< 0.7	< 0.8
09/30/20 - 10/28/20	< 0.9	< 0.6
10/28/20 - 12/02/20	< 0.9	< 0.8
12/02/20 - 12/29/20	< 0.8	< 0.9
<i>MEAN</i>	-	-

**Table C-I.3 CONCENTRATIONS OF GAMMA EMITTERS IN SURFACE WATER SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**

RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

SITE	COLLECTION PERIOD	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	Cs-134	Cs-137	Ba-140	La-140
1LL	01/01/20 - 01/29/20	< 7	< 6	< 11	< 6	< 8	< 6	< 9	< 6	< 6	< 22	< 10
	01/29/20 - 02/26/20	< 7	< 8	< 15	< 9	< 15	< 8	< 10	< 8	< 6	< 32	< 12
	02/26/20 - 04/01/20	< 6	< 5	< 12	< 6	< 12	< 5	< 10	< 7	< 5	< 25	< 8
	04/01/20 - 04/29/20	< 6	< 6	< 13	< 7	< 9	< 6	< 14	< 7	< 7	< 31	< 10
	04/29/20 - 05/27/20	< 4	< 4	< 11	< 5	< 5	< 5	< 9	< 4	< 4	< 25	< 8
	05/27/20 - 07/01/20	< 5	< 5	< 10	< 5	< 13	< 6	< 11	< 7	< 6	< 26	< 7
	07/01/20 - 07/29/20	< 6	< 7	< 18	< 9	< 9	< 7	< 13	< 8	< 8	< 30	< 11
	07/29/20 - 09/02/20	< 6	< 7	< 10	< 5	< 7	< 5	< 12	< 8	< 6	< 31	< 8
	09/02/20 - 09/30/20	< 5	< 4	< 11	< 6	< 8	< 6	< 10	< 6	< 5	< 21	< 8
	09/30/20 - 10/28/20	< 5	< 9	< 13	< 7	< 10	< 8	< 12	< 8	< 6	< 33	< 9
	10/28/20 - 12/02/20	< 5	< 6	< 9	< 6	< 6	< 5	< 9	< 5	< 5	< 27	< 6
	12/02/20 - 12/29/20	< 5	< 6	< 10	< 5	< 11	< 6	< 10	< 5	< 5	< 29	< 10
	MEAN	-	-	-	-	-	-	-	-	-	-	-
1MM	01/01/20 - 01/29/20	< 6	< 7	< 12	< 6	< 13	< 8	< 12	< 9	< 7	< 29	< 11
	01/29/20 - 02/26/20	< 6	< 6	< 12	< 6	< 11	< 7	< 11	< 7	< 7	< 32	< 9
	02/26/20 - 04/01/20	< 5	< 6	< 14	< 6	< 15	< 6	< 8	< 6	< 7	< 29	< 8
	04/01/20 - 04/29/20	< 5	< 7	< 12	< 6	< 13	< 6	< 13	< 8	< 5	< 32	< 13
	04/29/20 - 05/27/20	< 4	< 5	< 9	< 5	< 8	< 5	< 8	< 6	< 5	< 24	< 8
	05/27/20 - 07/01/20	< 5	< 8	< 11	< 8	< 12	< 7	< 9	< 9	< 5	< 28	< 9
	07/01/20 - 07/29/20	< 7	< 8	< 15	< 13	< 17	< 6	< 12	< 7	< 9	< 31	< 12
	07/29/20 - 09/02/20	< 6	< 7	< 13	< 6	< 12	< 7	< 11	< 7	< 6	< 29	< 11
	09/02/20 - 09/30/20	< 5	< 4	< 12	< 4	< 11	< 6	< 11	< 6	< 6	< 29	< 7
	09/30/20 - 10/28/20	< 7	< 6	< 15	< 8	< 11	< 6	< 13	< 5	< 8	< 33	< 11
	10/28/20 - 12/02/20	< 6	< 5	< 14	< 5	< 12	< 6	< 9	< 7	< 5	< 23	< 9
	12/02/20 - 12/29/20	< 8	< 7	< 15	< 10	< 14	< 8	< 14	< 10	< 7	< 27	< 11
	MEAN	-	-	-	-	-	-	-	-	-	-	-

**Table C-II.1 CONCENTRATIONS OF GROSS BETA IN DRINKING WATER SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

COLLECTION PERIOD	13B	4L	6I
12/30/19 - 01/30/20	< 1.8	< 1.8	2.6 $\pm$ 1.3
01/27/20 - 02/26/20	3.7 $\pm$ 1.4	2.0 $\pm$ 1.3	< 1.9
02/24/20 - 04/02/20	2.4 $\pm$ 1.2	1.7 $\pm$ 1.2	1.9 $\pm$ 1.2
03/30/20 - 04/30/20	< 1.7	< 1.7	< 1.7
04/27/20 - 05/27/20	< 1.9	< 1.9	< 2.0
05/26/20 - 07/01/20	2.1 $\pm$ 1.4	< 2.0	< 2.0
06/29/20 - 07/29/20	< 2.2	< 2.2	2.7 $\pm$ 1.6
07/27/20 - 09/02/20	< 2.4	< 2.5	< 2.6
08/31/20 - 10/01/20	2.7 $\pm$ 1.5	4.5 $\pm$ 1.7	3.6 $\pm$ 1.6
09/28/20 - 10/29/20	3.9 $\pm$ 1.7	4.0 $\pm$ 1.7	3.0 $\pm$ 1.6
10/26/20 - 12/02/20	3.2 $\pm$ 1.6	4.5 $\pm$ 1.7	< 2.2
11/30/20 - 12/29/20	2.4 $\pm$ 1.5	4.5 $\pm$ 1.5	< 2.0
MEAN $\pm$ 2 STD DEV	2.9 $\pm$ 1.4	3.5 $\pm$ 2.6	2.8 $\pm$ 1.3

**Table C-II.2 CONCENTRATIONS OF TRITIUM IN DRINKING WATER SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

COLLECTION PERIOD	13B	4L	6I
12/30/19 - 04/02/20	< 183	< 185	< 182
03/30/20 - 07/01/20	< 186	< 185	< 184
06/29/20 - 10/01/20	< 173	< 168	< 173
09/28/20 - 12/29/20	< 187	< 183	< 186
MEAN	-	-	-

**Table C-II.3 CONCENTRATIONS OF LOW LEVEL I-131 IN DRINKING WATER SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

COLLECTION PERIOD	13B	4L	6I
12/30/19 - 01/30/20	< 0.8	< 0.8	< 0.7
01/27/20 - 02/26/20	< 0.9	< 0.7	< 0.8
02/24/20 - 04/02/20	< 0.6	< 0.5	< 0.6
03/30/20 - 04/30/20	< 0.7	< 0.7	< 0.6
04/27/20 - 05/27/20	< 0.9	< 0.7	< 0.7
05/26/20 - 07/01/20	< 0.9	< 0.7	< 0.8
06/29/20 - 07/29/20	< 0.9	< 0.5	< 0.8
07/27/20 - 09/02/20	< 0.9	< 0.9	< 0.7
08/31/20 - 10/01/20	< 0.7	< 0.8	< 0.9
09/28/20 - 10/29/20	< 0.9	< 0.9	< 0.7
10/26/20 - 12/02/20	< 0.8	< 0.9	< 0.8
11/30/20 - 12/29/20	< 0.9	< 0.8	< 0.8
MEAN	-	-	-

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES



Table C-II.4

**CONCENTRATIONS OF GAMMA EMITTERS IN DRINKING WATER SAMPLES  
COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER + 2 SIGMA

SITE	COLLECTION PERIOD		Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	Cs-134	Cs-137	Ba-140	La-140
	13B	12/30/19 - 01/27/20	< 6	< 7	< 12	< 5	< 13	< 6	< 10	< 6	< 7	< 33	< 9
	01/27/20 - 02/24/20	< 6	< 5	< 12	< 6	< 10	< 6	< 9	< 6	< 5	< 27	< 7	
	02/24/20 - 03/30/20	< 6	< 5	< 12	< 8	< 10	< 5	< 9	< 5	< 6	< 24	< 6	
	03/30/20 - 04/27/20	< 5	< 6	< 10	< 6	< 14	< 6	< 9	< 7	< 7	< 25	< 12	
	04/27/20 - 05/26/20	< 6	< 7	< 12	< 8	< 9	< 7	< 12	< 7	< 7	< 36	< 10	
	05/26/20 - 06/29/20	< 4	< 4	< 10	< 5	< 8	< 5	< 8	< 5	< 4	< 21	< 6	
	06/29/20 - 07/27/20	< 6	< 5	< 10	< 6	< 10	< 7	< 12	< 5	< 6	< 25	< 8	
	07/27/20 - 08/31/20	< 7	< 8	< 11	< 9	< 13	< 7	< 12	< 8	< 6	< 35	< 12	
	08/31/20 - 09/28/20	< 5	< 6	< 10	< 5	< 10	< 6	< 11	< 6	< 5	< 31	< 9	
	09/28/20 - 10/26/20	< 8	< 4	< 14	< 7	< 9	< 5	< 12	< 8	< 6	< 36	< 9	
	10/26/20 - 11/30/20	< 4	< 5	< 10	< 6	< 10	< 6	< 8	< 6	< 5	< 24	< 7	
	11/30/20 - 12/28/20	< 6	< 6	< 12	< 7	< 14	< 7	< 11	< 7	< 6	< 27	< 13	
	MEAN	-	-	-	-	-	-	-	-	-	-	-	
4L	01/02/20 - 01/30/20	< 5	< 5	< 12	< 5	< 12	< 7	< 9	< 8	< 7	< 26	< 9	
	01/30/20 - 02/26/20	< 5	< 5	< 12	< 6	< 10	< 6	< 7	< 7	< 5	< 24	< 11	
	02/26/20 - 04/02/20	< 7	< 8	< 14	< 8	< 16	< 7	< 12	< 8	< 7	< 29	< 8	
	04/02/20 - 04/30/20	< 7	< 8	< 16	< 8	< 12	< 7	< 13	< 6	< 8	< 31	< 11	
	04/30/20 - 05/27/20	< 6	< 5	< 16	< 9	< 9	< 7	< 14	< 9	< 6	< 24	< 11	
	05/27/20 - 07/01/20	< 7	< 8	< 14	< 9	< 16	< 8	< 13	< 9	< 8	< 33	< 13	
	07/01/20 - 07/29/20	< 7	< 5	< 18	< 11	< 11	< 7	< 10	< 8	< 8	< 25	< 13	
	07/29/20 - 09/02/20	< 5	< 4	< 10	< 4	< 12	< 6	< 11	< 7	< 6	< 29	< 8	
	09/02/20 - 10/01/20	< 8	< 6	< 17	< 10	< 13	< 6	< 12	< 5	< 6	< 21	< 12	
	10/01/20 - 10/29/20	< 3	< 6	< 10	< 4	< 12	< 7	< 11	< 6	< 5	< 28	< 8	
	10/29/20 - 12/02/20	< 6	< 6	< 10	< 6	< 12	< 6	< 11	< 6	< 5	< 22	< 8	
	12/02/20 - 12/29/20	< 7	< 6	< 16	< 8	< 12	< 9	< 14	< 7	< 7	< 31	< 10	
	MEAN	-	-	-	-	-	-	-	-	-	-	-	
6I	01/02/20 - 01/30/20	< 7	< 8	< 15	< 9	< 13	< 7	< 15	< 7	< 8	< 34	< 9	
	01/30/20 - 02/26/20	< 6	< 6	< 13	< 7	< 15	< 8	< 12	< 6	< 6	< 27	< 13	
	02/26/20 - 04/01/20	< 7	< 6	< 14	< 5	< 14	< 6	< 11	< 4	< 7	< 25	< 8	
	04/01/20 - 04/30/20	< 7	< 6	< 16	< 8	< 14	< 7	< 15	< 6	< 9	< 36	< 9	
	04/30/20 - 05/27/20	< 4	< 5	< 10	< 5	< 7	< 4	< 10	< 5	< 5	< 20	< 7	
	05/27/20 - 07/01/20	< 5	< 8	< 16	< 9	< 13	< 8	< 13	< 8	< 7	< 36	< 11	
	07/01/20 - 07/29/20	< 7	< 8	< 16	< 11	< 13	< 7	< 14	< 8	< 8	< 28	< 10	
	07/29/20 - 09/02/20	< 6	< 6	< 12	< 8	< 11	< 6	< 11	< 6	< 5	< 24	< 7	
	09/02/20 - 10/01/20	< 5	< 6	< 8	< 7	< 9	< 6	< 11	< 7	< 6	< 31	< 11	
	10/01/20 - 10/29/20	< 6	< 6	< 12	< 7	< 11	< 6	< 8	< 5	< 6	< 27	< 8	
	10/29/20 - 12/02/20	< 8	< 7	< 12	< 8	< 4	< 7	< 12	< 7	< 6	< 22	< 10	
	12/02/20 - 12/29/20	< 6	< 7	< 15	< 8	< 16	< 7	< 13	< 8	< 6	< 29	< 9	
	MEAN	-	-	-	-	-	-	-	-	-	-	-	

**Table C-III.1 CONCENTRATIONS OF GAMMA EMITTERS IN PREDATOR AND BOTTOM FEEDER (FISH) SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/KG WET  $\pm$  2 SIGMA

SITE	COLLECTION PERIOD	K-40	Mn-54	Co-58	Fe-59	Co-60	Zn-65	Cs-134	Cs-137
4 PREDATOR	05/21/20	3443 $\pm$ 1024	< 80	< 62	< 159	< 90	< 152	< 71	< 73
	10/08/20	3631 $\pm$ 910	< 59	< 58	< 122	< 62	< 139	< 63	< 60
	MEAN $\pm$ 2 STD DEV	3537 $\pm$ 266	-	-	-	-	-	-	-
4 BOTTOM FEEDER	05/21/20	3210 $\pm$ 968	< 102	< 107	< 170	< 72	< 174	< 77	< 100
	10/08/20	3356 $\pm$ 1119	< 76	< 64	< 137	< 64	< 113	< 74	< 81
	MEAN $\pm$ 2 STD DEV	3283 $\pm$ 206	-	-	-	-	-	-	-
6 PREDATOR	06/03/20	3104 $\pm$ 992	< 59	< 64	< 136	< 65	< 131	< 79	< 56
	10/22/20	3211 $\pm$ 848	< 49	< 42	< 76	< 41	< 105	< 61	< 59
	MEAN $\pm$ 2 STD DEV	3158 $\pm$ 151	-	-	-	-	-	-	-
6 BOTTOM FEEDER	06/03/20	3101 $\pm$ 1006	< 57	< 42	< 82	< 54	< 106	< 50	< 61
	10/22/20	3112 $\pm$ 688	< 48	< 40	< 83	< 40	< 97	< 49	< 37
	MEAN $\pm$ 2 STD DEV	3107 $\pm$ 16	-	-	-	-	-	-	-

**Table C-IV.1 CONCENTRATIONS OF GAMMA EMITTERS IN SEDIMENT SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/KG DRY  $\pm$  2 SIGMA

SITE	COLLECTION	K-40	Mn-54	Co-58	Co-60	Cs-134	Cs-137
	PERIOD						
4J	06/17/20	11300 $\pm$ 1370	< 66	< 55	< 61	< 70	< 59
	12/03/20	13020 $\pm$ 1232	< 41	< 42	< 47	< 55	< 41
	<i>MEAN <math>\pm</math> 2 STD DEV</i>	12160 $\pm$ 2432	-	-	-	-	-
4T	06/17/20	19980 $\pm$ 2408	< 109	< 100	< 85	< 135	< 119
	12/03/20	18190 $\pm$ 2024	< 109	< 116	< 113	< 123	< 130
	<i>MEAN <math>\pm</math> 2 STD DEV</i>	19085 $\pm$ 2531	-	-	-	-	-
6F	06/17/20	17400 $\pm$ 2125	< 118	< 110	< 132	< 137	< 130
	12/03/20	13990 $\pm$ 1752	< 84	< 71	< 76	< 81	< 98
	<i>MEAN <math>\pm</math> 2 STD DEV</i>	15695 $\pm$ 4822	-	-	-	-	-

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

Table C-V.1

**CONCENTRATIONS OF GROSS BETA IN AIR PARTICULATE SAMPLES  
COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020  
RESULTS IN UNITS OF E-3 PCI/CUBIC METER  $\pm$  2 SIGMA**

COLLECTION PERIOD	GROUP I			GROUP II	GROUP III
	1B	1C	1Z	3A	5H2
12/30/19 - 01/06/20					12 $\pm$ 4
01/02/20 - 01/08/20	10 $\pm$ 4	18 $\pm$ 5	9 $\pm$ 4	12 $\pm$ 5	
01/06/20 - 01/13/20					14 $\pm$ 4
01/08/20 - 01/16/20	12 $\pm$ 4	16 $\pm$ 4	9 $\pm$ 3	15 $\pm$ 4	
01/13/20 - 01/21/20					18 $\pm$ 3
01/16/20 - 01/23/20	22 $\pm$ 5	15 $\pm$ 4	20 $\pm$ 5	25 $\pm$ 5	
01/21/20 - 01/27/20					15 $\pm$ 4
01/23/20 - 01/30/20	9 $\pm$ 3	10 $\pm$ 3	7 $\pm$ 3	10 $\pm$ 3	
01/27/20 - 02/03/20					12 $\pm$ 4
01/30/20 - 02/06/20	18 $\pm$ 4	17 $\pm$ 4	12 $\pm$ 4	15 $\pm$ 4	
02/03/20 - 02/10/20					13 $\pm$ 4
02/06/20 - 02/12/20	10 $\pm$ 5	13 $\pm$ 5	7 $\pm$ 4	9 $\pm$ 4	
02/10/20 - 02/17/20					12 $\pm$ 4
02/12/20 - 02/20/20	17 $\pm$ 4	11 $\pm$ 3	15 $\pm$ 3	18 $\pm$ 4	
02/17/20 - 02/24/20					26 $\pm$ 5
02/20/20 - 02/26/20	24 $\pm$ 5	25 $\pm$ 5	18 $\pm$ 5	26 $\pm$ 5	
02/24/20 - 03/02/20					16 $\pm$ 4
02/26/20 - 03/05/20	13 $\pm$ 3	13 $\pm$ 3	9 $\pm$ 3	14 $\pm$ 3	
03/02/20 - 03/09/20					11 $\pm$ 3
03/05/20 - 03/11/20	12 $\pm$ 5	14 $\pm$ 5	9 $\pm$ 4	13 $\pm$ 5	
03/09/20 - 03/16/20					17 $\pm$ 4
03/11/20 - 03/19/20	19 $\pm$ 4	16 $\pm$ 4	11 $\pm$ 3	18 $\pm$ 4	
03/16/20 - 03/23/20					15 $\pm$ 4
03/19/20 - 03/25/20	20 $\pm$ 5	18 $\pm$ 4	16 $\pm$ 4	15 $\pm$ 4	
03/23/20 - 03/30/20					7 $\pm$ 4
03/25/20 - 04/02/20	11 $\pm$ 3	11 $\pm$ 3	8 $\pm$ 3	11 $\pm$ 3	
03/30/20 - 04/06/20					12 $\pm$ 4
04/02/20 - 04/08/20	15 $\pm$ 5	12 $\pm$ 4	12 $\pm$ 4	11 $\pm$ 4	
04/06/20 - 04/13/20					15 $\pm$ 4
04/08/20 - 04/15/20	12 $\pm$ 4	11 $\pm$ 3	9 $\pm$ 3	12 $\pm$ 4	
04/13/20 - 04/20/20					14 $\pm$ 4
04/15/20 - 04/23/20	17 $\pm$ 4	17 $\pm$ 4	13 $\pm$ 3	14 $\pm$ 4	
04/20/20 - 04/27/20					10 $\pm$ 3
04/23/20 - 04/30/20	12 $\pm$ 4	13 $\pm$ 4	10 $\pm$ 3	9 $\pm$ 3	
04/27/20 - 05/04/20					13 $\pm$ 4
04/30/20 - 05/07/20	10 $\pm$ 3	10 $\pm$ 3	11 $\pm$ 4	11 $\pm$ 3	
05/04/20 - 05/11/20					12 $\pm$ 4
05/07/20 - 05/14/20	12 $\pm$ 4	10 $\pm$ 4	7 $\pm$ 4	10 $\pm$ 4	
05/11/20 - 05/18/20					19 $\pm$ 4
05/14/20 - 05/20/20	19 $\pm$ 5	17 $\pm$ 5	13 $\pm$ 4	16 $\pm$ 5	
05/18/20 - 05/26/20					9 $\pm$ 3
05/20/20 - 05/27/20	10 $\pm$ 4	7 $\pm$ 3	6 $\pm$ 3	9 $\pm$ 3	
05/26/20 - 06/02/20					10 $\pm$ 4
05/27/20 - 06/04/20	(1)	9 $\pm$ 3	8 $\pm$ 3	11 $\pm$ 4	
06/02/20 - 06/08/20					21 $\pm$ 5
06/04/20 - 06/11/20	12 $\pm$ 4	13 $\pm$ 4	6 $\pm$ 3	13 $\pm$ 4	
06/08/20 - 06/15/20					11 $\pm$ 3
06/11/20 - 06/18/20	11 $\pm$ 3	9 $\pm$ 3	6 $\pm$ 3	8 $\pm$ 3	
06/15/20 - 06/22/20					10 $\pm$ 4
06/18/20 - 06/25/20	16 $\pm$ 4	12 $\pm$ 4	9 $\pm$ 4	8 $\pm$ 3	
06/22/20 - 06/29/20					18 $\pm$ 4
06/25/20 - 07/01/20	15 $\pm$ 5	10 $\pm$ 5	< 6	9 $\pm$ 5	
06/29/20 - 07/06/20					15 $\pm$ 4

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES  
(1) SEE PROGRAM EXCEPTIONS SECTION FOR EXPLANATION

Table C-V.1

**CONCENTRATIONS OF GROSS BETA IN AIR PARTICULATE SAMPLES  
COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020  
RESULTS IN UNITS OF E-3 PCI/CUBIC METER  $\pm$  2 SIGMA**

COLLECTION PERIOD	GROUP I			GROUP II	GROUP III
	1B	1C	1Z	3A	5H2
07/01/20 - 07/09/20	12 $\pm$ 3	12 $\pm$ 3	9 $\pm$ 3	12 $\pm$ 3	
07/06/20 - 07/13/20					16 $\pm$ 4
07/09/20 - 07/16/20	14 $\pm$ 4	13 $\pm$ 4	7 $\pm$ 4	10 $\pm$ 4	
07/13/20 - 07/20/20					17 $\pm$ 4
07/16/20 - 07/23/20	20 $\pm$ 5	17 $\pm$ 4	11 $\pm$ 4	16 $\pm$ 4	
07/20/20 - 07/28/20					21 $\pm$ 4
07/23/20 - 07/29/20	18 $\pm$ 5	25 $\pm$ 5	12 $\pm$ 4	13 $\pm$ 5	
07/28/20 - 08/04/20					18 $\pm$ 4
07/29/20 - 08/06/20	19 $\pm$ 4	17 $\pm$ 4	12 $\pm$ 4	17 $\pm$ 5	
08/04/20 - 08/10/20					18 $\pm$ 5
08/06/20 - 08/13/20	25 $\pm$ 5	23 $\pm$ 5	20 $\pm$ 5	19 $\pm$ 4	
08/10/20 - 08/17/20					28 $\pm$ 5
08/13/20 - 08/20/20	19 $\pm$ 4	16 $\pm$ 4	14 $\pm$ 4	19 $\pm$ 5	
08/17/20 - 08/24/20					18 $\pm$ 4
08/20/20 - 08/27/20	29 $\pm$ 5	26 $\pm$ 5	18 $\pm$ 5	26 $\pm$ 5	
08/24/20 - 08/31/20					19 $\pm$ 5
08/27/20 - 09/02/20	14 $\pm$ 4	14 $\pm$ 4	11 $\pm$ 4	16 $\pm$ 5	
08/31/20 - 09/08/20					20 $\pm$ 4
09/02/20 - 09/10/20	17 $\pm$ 4	13 $\pm$ 4	14 $\pm$ 6	17 $\pm$ 4	
09/08/20 - 09/14/20					13 $\pm$ 4
09/10/20 - 09/16/20	10 $\pm$ 4	9 $\pm$ 4	8 $\pm$ 4	13 $\pm$ 4	
09/14/20 - 09/21/20					17 $\pm$ 4
09/16/20 - 09/24/20	31 $\pm$ 5	21 $\pm$ 4	18 $\pm$ 4	25 $\pm$ 4	
09/21/20 - 09/29/20					30 $\pm$ 4
09/24/20 - 10/01/20	24 $\pm$ 5	26 $\pm$ 5	18 $\pm$ 4	25 $\pm$ 5	
09/29/20 - 10/05/20					12 $\pm$ 4
10/01/20 - 10/08/20	27 $\pm$ 5	17 $\pm$ 4	16 $\pm$ 4	22 $\pm$ 4	
10/05/20 - 10/12/20					24 $\pm$ 4
10/08/20 - 10/14/20	17 $\pm$ 5	14 $\pm$ 4	10 $\pm$ 4	12 $\pm$ 5	
10/12/20 - 10/19/20					11 $\pm$ 4
10/14/20 - 10/21/20	19 $\pm$ 5	22 $\pm$ 5	14 $\pm$ 4	17 $\pm$ 5	
10/19/20 - 10/26/20					8 $\pm$ 4
10/21/20 - 10/29/20	12 $\pm$ 3	11 $\pm$ 3	10 $\pm$ 3	11 $\pm$ 3	
10/26/20 - 11/03/20					8 $\pm$ 3
10/29/20 - 11/05/20	16 $\pm$ 4	18 $\pm$ 4	17 $\pm$ 4	21 $\pm$ 4	
11/03/20 - 11/10/20					33 $\pm$ 5
11/05/20 - 11/12/20	21 $\pm$ 5	21 $\pm$ 5	25 $\pm$ 5	25 $\pm$ 5	
11/10/20 - 11/16/20					20 $\pm$ 5
11/12/20 - 11/18/20	20 $\pm$ 5	18 $\pm$ 5	19 $\pm$ 5	28 $\pm$ 5	
11/16/20 - 11/23/20					20 $\pm$ 4
11/18/20 - 11/25/20	17 $\pm$ 4	21 $\pm$ 5	19 $\pm$ 5	23 $\pm$ 5	
11/23/20 - 12/01/20					21 $\pm$ 4
11/25/20 - 12/02/20	20 $\pm$ 4	27 $\pm$ 5	24 $\pm$ 5	26 $\pm$ 5	
12/01/20 - 12/07/20					15 $\pm$ 5
12/02/20 - 12/09/20	10 $\pm$ 4	16 $\pm$ 4	15 $\pm$ 4	14 $\pm$ 4	
12/07/20 - 12/14/20					31 $\pm$ 5
12/09/20 - 12/15/20	25 $\pm$ 5	24 $\pm$ 5	28 $\pm$ 6	30 $\pm$ 6	
12/14/20 - 12/21/20					14 $\pm$ 4
12/15/20 - 12/22/20	15 $\pm$ 4	17 $\pm$ 4	17 $\pm$ 4	15 $\pm$ 4	
12/21/20 - 12/28/20					15 $\pm$ 4
12/22/20 - 12/29/20	15 $\pm$ 4	19 $\pm$ 4	19 $\pm$ 4	16 $\pm$ 4	
MEAN $\pm$ 2 STD DEV	17 $\pm$ 11	16 $\pm$ 10	13 $\pm$ 10	16 $\pm$ 12	16 $\pm$ 12

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**Table C-V.2 CONCENTRATIONS OF GAMMA EMITTERS IN AIR PARTICULATE SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF E-3 PCI/CUBIC METER  $\pm$  2 SIGMA

SITE	COLLECTION		Be-7	Mn-54	Co-58	Co-60	Cs-134	Cs-137
	PERIOD							
1B	01/02/20 - 04/02/20		80 $\pm$ 25	< 4	< 4	< 3	< 3	< 3
	04/02/20 - 07/01/20		69 $\pm$ 21	< 2	< 2	< 2	< 2	< 2
	07/01/20 - 10/01/20		83 $\pm$ 20	< 3	< 3	< 4	< 3	< 3
	10/01/20 - 12/29/20		80 $\pm$ 20	< 2	< 2	< 3	< 3	< 3
		<i>MEAN <math>\pm</math> 2 STD DEV</i>	78 $\pm$ 12	-	-	-	-	-
1C	01/02/20 - 04/02/20		80 $\pm$ 18	< 2	< 3	< 2	< 2	< 2
	04/02/20 - 07/01/20		93 $\pm$ 20	< 1	< 2	< 2	< 1	< 1
	07/01/20 - 10/01/20		85 $\pm$ 25	< 2	< 3	< 2	< 3	< 3
	10/01/20 - 12/29/20		85 $\pm$ 18	< 2	< 2	< 3	< 2	< 2
		<i>MEAN <math>\pm</math> 2 STD DEV</i>	86 $\pm$ 11	-	-	-	-	-
1Z	01/02/20 - 04/02/20		54 $\pm$ 16	< 2	< 2	< 3	< 3	< 2
	04/02/20 - 07/01/20		68 $\pm$ 17	< 2	< 2	< 2	< 3	< 2
	07/01/20 - 10/01/20		59 $\pm$ 17	< 2	< 2	< 2	< 2	< 2
	10/01/20 - 12/29/20		74 $\pm$ 17	< 2	< 2	< 2	< 2	< 2
		<i>MEAN <math>\pm</math> 2 STD DEV</i>	64 $\pm$ 18	-	-	-	-	-
3A	01/02/20 - 04/02/20		73 $\pm$ 17	< 2	< 2	< 2	< 3	< 3
	04/02/20 - 07/01/20		78 $\pm$ 18	< 2	< 1	< 2	< 2	< 2
	07/01/20 - 10/01/20		85 $\pm$ 22	< 2	< 2	< 2	< 2	< 2
	10/01/20 - 12/29/20		98 $\pm$ 23	< 2	< 3	< 3	< 2	< 2
		<i>MEAN <math>\pm</math> 2 STD DEV</i>	83 $\pm$ 22	-	-	-	-	-
5H2	12/30/19 - 03/30/20		85 $\pm$ 18	< 2	< 2	< 1	< 2	< 1
	03/30/20 - 06/29/20		96 $\pm$ 25	< 4	< 4	< 5	< 3	< 3
	06/29/20 - 09/29/20		116 $\pm$ 22	< 2	< 2	< 2	< 2	< 2
	09/29/20 - 12/28/20		69 $\pm$ 16	< 2	< 2	< 1	< 3	< 2
		<i>MEAN <math>\pm</math> 2 STD DEV</i>	92 $\pm$ 40	-	-	-	-	-

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**Table C-VI.1 CONCENTRATIONS OF I-131 IN AIR IODINE SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF E-3 PCI/CUBIC METER ± 2 SIGMA

COLLECTION PERIOD	GROUP I			GROUP II	GROUP III
	1B	1C	1Z	3A	5H2
12/30/19 - 01/06/20					< 15
01/02/20 - 01/08/20	< 56	< 56	< 56	< 57	
01/06/20 - 01/13/20					< 14
01/08/20 - 01/16/20	< 19	< 18	< 18	< 18	
01/13/20 - 01/21/20					< 11
01/16/20 - 01/23/20	< 54	< 55	< 55	< 55	
01/21/20 - 01/27/20					< 17
01/23/20 - 01/30/20	< 56	< 56	< 56	< 56	
01/27/20 - 02/03/20					< 12
01/30/20 - 02/06/20	< 25	< 25	< 25	< 25	
02/03/20 - 02/10/20					< 46
02/06/20 - 02/12/20	< 27	< 27	< 27	< 27	
02/10/20 - 02/17/20					< 21
02/12/20 - 02/20/20	< 24	< 24	< 24	< 24	
02/17/20 - 02/24/20					< 18
02/20/20 - 02/26/20	< 42	< 42	< 42	< 41	
02/24/20 - 03/02/20					< 31
02/26/20 - 03/05/20	< 25	< 25	< 25	< 25	
03/02/20 - 03/09/20					< 17
03/05/20 - 03/11/20	< 38	< 39	< 39	< 39	
03/09/20 - 03/16/20					< 20
03/11/20 - 03/19/20	< 61	< 59	< 59	< 58	
03/16/20 - 03/23/20					< 23
03/19/20 - 03/25/20	< 17	< 35	< 35	< 35	
03/23/20 - 03/30/20					< 20
03/25/20 - 04/02/20	< 47	< 47	< 47	< 47	
03/30/20 - 04/06/20					< 27
04/02/20 - 04/08/20	< 66	< 55	< 60	< 66	
04/06/20 - 04/13/20					< 17
04/08/20 - 04/15/20	< 57	< 45	< 50	< 56	
04/13/20 - 04/20/20					< 21
04/15/20 - 04/23/20	< 48	< 49	< 49	< 49	
04/20/20 - 04/27/20					< 11
04/23/20 - 04/30/20	< 29	< 29	< 29	< 16	
04/27/20 - 05/04/20					< 17
04/30/20 - 05/07/20	< 24	< 24	< 24	< 24	
05/04/20 - 05/11/20					< 15
05/07/20 - 05/14/20	< 24	< 24	< 24	< 24	
05/11/20 - 05/18/20					< 32
05/14/20 - 05/20/20	< 56	< 55	< 55	< 54	
05/18/20 - 05/26/20					< 24
05/20/20 - 05/27/20	< 22	< 33	< 33	< 33	
05/26/20 - 06/02/20					< 34
05/27/20 - 06/04/20	(1)	< 28	< 28	< 28	
06/02/20 - 06/08/20					< 17
06/04/20 - 06/11/20	< 35	< 35	< 35	< 35	
06/08/20 - 06/15/20					< 13
06/11/20 - 06/18/20	< 52	< 52	< 52	< 52	
06/15/20 - 06/22/20					< 26
06/18/20 - 06/25/20	< 18	< 32	< 32	< 32	
06/22/20 - 06/29/20					< 38
06/25/20 - 07/01/20	< 24	< 14	< 24	< 24	
06/29/20 - 07/06/20					< 27

(1) SEE PROGRAM EXCEPTIONS SECTION FOR EXPLANATION

**Table C-VI.1 CONCENTRATIONS OF I-131 IN AIR IODINE SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF E-3 PCI/CUBIC METER  $\pm$  2 SIGMA

COLLECTION PERIOD	GROUP I			GROUP II	GROUP III
	1B	1C	1Z	3A	5H2
07/01/20 - 07/09/20	< 48	< 49	< 49	< 20	
07/06/20 - 07/13/20					< 14
07/09/20 - 07/16/20	< 17	< 31	< 31	< 31	
07/13/20 - 07/20/20					< 10
07/16/20 - 07/23/20	< 40	< 41	< 40	< 41	
07/20/20 - 07/28/20					< 32
07/23/20 - 07/29/20	< 53	< 52	< 53	< 52	
07/28/20 - 08/04/20					< 17
07/29/20 - 08/06/20	< 33	< 27	< 38	< 43	
08/04/20 - 08/10/20					< 22
08/06/20 - 08/13/20	< 49	< 48	< 48	< 47	
08/10/20 - 08/17/20					< 17
08/13/20 - 08/20/20	< 48	< 48	< 49	< 27	
08/17/20 - 08/24/20					< 19
08/20/20 - 08/27/20	< 17	< 40	< 40	< 40	
08/24/20 - 08/31/20					< 17
08/27/20 - 09/02/20	< 48	< 23	< 48	< 51	
08/31/20 - 09/08/20					< 20
09/02/20 - 09/10/20	< 27	< 27	< 45	< 27	
09/08/20 - 09/14/20					< 20
09/10/20 - 09/16/20	< 36	< 33	< 33	< 33	
09/14/20 - 09/21/20					< 16
09/16/20 - 09/24/20	< 47	< 43	< 52	< 47	
09/21/20 - 09/29/20					< 13
09/24/20 - 10/01/20	< 25	< 23	< 23	< 25	
09/29/20 - 10/05/20					< 18
10/01/20 - 10/08/20	< 51	< 47	< 20	< 52	
10/05/20 - 10/12/20					< 37
10/08/20 - 10/14/20	< 59	< 54	< 22	< 59	
10/12/20 - 10/19/20					< 45
10/14/20 - 10/21/20	< 60	< 60	< 60	< 60	
10/19/20 - 10/26/20					< 13
10/21/20 - 10/29/20	< 51	< 46	< 51	< 51	
10/26/20 - 11/03/20					< 13
10/29/20 - 11/05/20	< 51	< 52	< 51	< 21	
11/03/20 - 11/10/20					< 15
11/05/20 - 11/12/20	< 41	< 41	< 41	< 41	
11/10/20 - 11/16/20					< 14
11/12/20 - 11/18/20	< 15	< 36	< 36	< 34	
11/16/20 - 11/23/20					< 64
11/18/20 - 11/25/20	< 34	< 37	< 37	< 34	
11/23/20 - 12/01/20					< 22
11/25/20 - 12/02/20	< 22	< 25	< 25	< 22	
12/01/20 - 12/07/20					< 38
12/02/20 - 12/09/20	< 59	< 59	< 59	< 60	
12/07/20 - 12/14/20					< 23
12/09/20 - 12/15/20	< 48	< 48	< 48	< 47	
12/14/20 - 12/21/20					< 53
12/15/20 - 12/22/20	< 36	< 36	< 35	< 29	
12/21/20 - 12/28/20					< 23
12/22/20 - 12/29/20	< 34	< 41	< 41	< 41	
MEAN	-	-	-	-	-



Table C-VII.1

CONCENTRATIONS OF LOW LEVEL I-131 IN MILK SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020

RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

COLLECTION WEEK	CONTROL FARMS					INDICATOR FARMS									
	C	E	V	D	J	P	R	S	U	W	X	Y			
01/13/20	< 0.9	< 0.5	< 0.5	< 0.6	< 0.6	< 0.8	< 0.6	< 0.8	< 0.7	< 0.7	< 0.5	< 0.5			
02/13/20	< 0.9	< 0.5	< 0.8	< 0.6	< 0.7	< 0.8	< 0.7	< 0.7	< 0.8	< 0.7	< 0.9	< 0.5			
03/10/20			< 0.7		< 0.7		< 0.8	< 0.6	< 0.7		< 0.8				
04/07/21			< 0.6		< 0.6		< 0.8	< 0.7	< 0.6		< 0.6				
04/21/20			< 0.7		< 0.7		< 0.7	< 0.7	< 0.7		< 0.7				
05/05/20	< 0.7	< 0.8	< 0.7	< 0.7	< 0.7	< 0.7	< 0.7	< 0.6	< 0.6	< 0.7	< 0.7	< 0.6			
05/19/20			< 0.7		< 0.7		< 0.7	< 0.7	< 0.7		< 0.6				
06/02/20			< 0.7		< 0.8		< 0.7	< 0.7	< 0.7		< 0.9				
06/16/20			< 0.9		< 0.8		< 0.8	< 0.8	< 0.9		< 1.0				
06/30/20			< 0.9		< 0.9		< 0.8	< 0.9	< 0.7		< 0.6				
07/14/20			< 0.7		< 0.8		< 0.8	< 0.6	< 0.6		< 0.9				
07/28/20			< 0.7		< 0.9		< 0.9	< 0.7	< 0.8		< 0.9				
08/11/20	< 0.8	< 0.9	< 0.9	< 0.8	< 0.9	< 0.8	< 0.7	< 0.8	< 0.9	< 0.7	< 0.9	< 0.7			
08/25/20			< 0.8		< 0.7		< 0.8	< 0.7	< 0.9		< 0.7				
09/09/20			< 0.8		< 0.9		< 0.8	< 0.9	< 0.8		< 0.8				
09/22/21			< 0.7		< 0.8		< 0.8	< 0.8	< 0.8		< 0.8				
10/05/20			< 0.9		< 0.8		< 0.8	< 0.9	< 1.0		< 0.8				
10/21/20			< 0.8		< 0.9		< 0.9	< 0.7	< 0.8		< 0.7				
11/02/20	< 0.7	< 0.8	< 0.8	< 0.8	< 0.9	< 0.5	< 0.9	< 0.9	< 0.8	< 0.9	< 0.7	< 0.8			
11/17/20			< 0.9		< 0.9		< 0.8	< 0.9	< 0.8		< 0.9				
12/15/20			< 0.9		< 0.9		< 0.8	< 0.9	< 0.8		< 0.9				
MEAN	-	-	-	-	-	-	-	-	-	-	-	-			

**Table C-VII.2 CONCENTRATIONS OF GAMMA EMITTERS IN MILK SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**

RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

COLLECTION		K-40	Cs-134	Cs-137	Ba-140	La-140
SITE	PERIOD					
C	02/13/20	1148 $\pm$ 174	< 9	< 7	< 36	< 8
	05/05/20	1270 $\pm$ 159	< 7	< 6	< 35	< 6
	08/11/20	1243 $\pm$ 175	< 7	< 7	< 33	< 11
	11/02/20	1134 $\pm$ 187	< 9	< 8	< 41	< 13
	<i>MEAN <math>\pm</math> 2 STD DEV</i>	1199 $\pm$ 136	-	-	-	-
E	02/14/20	1144 $\pm$ 183	< 6	< 8	< 27	< 7
	05/06/20	1391 $\pm$ 112	< 5	< 5	< 18	< 6
	08/11/20	1186 $\pm$ 187	< 10	< 9	< 42	< 12
	11/02/20	1328 $\pm$ 180	< 8	< 7	< 32	< 9
	<i>MEAN <math>\pm</math> 2 STD DEV</i>	1262 $\pm$ 233	-	-	-	-
V	01/13/20	1203 $\pm$ 123	< 5	< 4	< 14	< 5
	02/14/20	1195 $\pm$ 153	< 8	< 8	< 32	< 7
	03/10/20	1163 $\pm$ 173	< 7	< 7	< 22	< 8
	04/07/20	1315 $\pm$ 181	< 9	< 7	< 37	< 9
	04/21/20	1157 $\pm$ 164	< 8	< 7	< 28	< 10
	05/05/20	1266 $\pm$ 180	< 9	< 8	< 38	< 14
	05/19/20	1066 $\pm$ 151	< 9	< 7	< 35	< 13
	06/02/20	1244 $\pm$ 180	< 8	< 7	< 27	< 8
	06/16/20	1237 $\pm$ 150	< 8	< 9	< 37	< 11
	06/30/20	1166 $\pm$ 194	< 10	< 8	< 31	< 11
	07/14/20	1043 $\pm$ 166	< 9	< 9	< 44	< 13
	07/28/20	1152 $\pm$ 204	< 11	< 8	< 31	< 8
	08/11/20	1320 $\pm$ 165	< 9	< 8	< 36	< 8
	08/25/20	1299 $\pm$ 217	< 9	< 8	< 33	< 10
	09/09/20	1334 $\pm$ 182	< 8	< 6	< 30	< 9
	09/22/20	1284 $\pm$ 184	< 7	< 7	< 28	< 8
	10/05/20	1404 $\pm$ 174	< 8	< 7	< 28	< 10
	10/21/20	1360 $\pm$ 181	< 9	< 9	< 40	< 6
11/02/20	1239 $\pm$ 185	< 8	< 7	< 33	< 13	
11/17/20	1388 $\pm$ 224	< 8	< 10	< 28	< 10	
12/15/20	1229 $\pm$ 185	< 7	< 8	< 30	< 6	
<i>MEAN <math>\pm</math> 2 STD DEV</i>	1241 $\pm$ 194	-	-	-	-	
D	02/13/20	1415 $\pm$ 208	< 8	< 7	< 33	< 10
	05/05/20	1263 $\pm$ 160	< 9	< 8	< 34	< 12
	08/11/20	1261 $\pm$ 185	< 8	< 8	< 31	< 7
	11/02/20	1583 $\pm$ 191	< 12	< 8	< 46	< 12
	<i>MEAN <math>\pm</math> 2 STD DEV</i>	1381 $\pm$ 306	-	-	-	-

**Table C-VII.2 CONCENTRATIONS OF GAMMA EMITTERS IN MILK SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**

RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

COLLECTION						
SITE	PERIOD	K-40	Cs-134	Cs-137	Ba-140	La-140
J	01/14/20	1190 $\pm$ 127	< 6	< 6	< 23	< 6
	02/13/20	1159 $\pm$ 162	< 8	< 7	< 28	< 9
	03/10/20	1282 $\pm$ 186	< 8	< 8	< 31	< 5
	04/08/20	1231 $\pm$ 151	< 10	< 9	< 34	< 14
	04/23/20	1168 $\pm$ 149	< 8	< 7	< 29	< 7
	05/06/20	1229 $\pm$ 184	< 9	< 8	< 37	< 10
	05/20/20	1295 $\pm$ 156	< 7	< 8	< 31	< 9
	06/02/20	1179 $\pm$ 154	< 10	< 9	< 38	< 12
	06/17/20	1334 $\pm$ 172	< 8	< 7	< 31	< 10
	06/30/20	1181 $\pm$ 178	< 9	< 7	< 48	< 8
	07/14/20	1363 $\pm$ 195	< 8	< 8	< 38	< 15
	07/28/20	1123 $\pm$ 176	< 10	< 8	< 28	< 9
	08/11/20	1350 $\pm$ 198	< 8	< 10	< 34	< 12
	08/25/20	1183 $\pm$ 172	< 8	< 9	< 36	< 8
	09/09/20	1207 $\pm$ 191	< 12	< 7	< 37	< 5
	09/22/20	1190 $\pm$ 159	< 6	< 7	< 24	< 7
	10/05/20	1345 $\pm$ 157	< 8	< 7	< 24	< 9
10/21/20	1479 $\pm$ 181	< 9	< 8	< 36	< 9	
11/02/20	1226 $\pm$ 175	< 9	< 10	< 30	< 13	
11/17/20	1334 $\pm$ 163	< 9	< 9	< 36	< 11	
12/15/20	1373 $\pm$ 172	< 9	< 8	< 35	< 13	
<i>MEAN <math>\pm</math> 2 STD DEV</i>		1258 $\pm$ 185	-	-	-	-
P	02/13/20	1144 $\pm$ 148	< 7	< 6	< 26	< 9
	05/05/20	1246 $\pm$ 130	< 7	< 6	< 25	< 6
	08/11/20	1272 $\pm$ 159	< 8	< 7	< 27	< 5
	11/02/20	1294 $\pm$ 147	< 9	< 7	< 38	< 9
<i>MEAN <math>\pm</math> 2 STD DEV</i>		1239 $\pm$ 133	-	-	-	-
R	01/14/20	1161 $\pm$ 128	< 7	< 5	< 16	< 5
	02/13/20	1102 $\pm$ 126	< 7	< 7	< 28	< 6
	03/10/20	1265 $\pm$ 162	< 9	< 8	< 28	< 10
	04/08/20	1144 $\pm$ 217	< 11	< 10	< 36	< 11
	04/21/20	1357 $\pm$ 140	< 7	< 6	< 26	< 8
	05/05/20	1228 $\pm$ 212	< 8	< 8	< 37	< 9
	05/19/20	1254 $\pm$ 174	< 7	< 7	< 28	< 10
	06/02/20	1254 $\pm$ 167	< 7	< 6	< 30	< 7
	06/16/20	1349 $\pm$ 180	< 8	< 8	< 37	< 14
	06/30/20	1198 $\pm$ 156	< 7	< 6	< 26	< 5
	07/14/20	1385 $\pm$ 179	< 8	< 8	< 31	< 9
	07/28/20	1145 $\pm$ 158	< 8	< 7	< 27	< 8
	08/11/20	1249 $\pm$ 207	< 9	< 6	< 30	< 13
	08/25/20	1221 $\pm$ 194	< 10	< 8	< 33	< 9
	09/09/20	1292 $\pm$ 193	< 9	< 9	< 35	< 9
	09/22/20	1007 $\pm$ 178	< 9	< 9	< 26	< 8
	10/05/20	1386 $\pm$ 163	< 5	< 6	< 25	< 6
	10/21/20	1199 $\pm$ 208	< 8	< 9	< 40	< 11
	11/02/20	1159 $\pm$ 165	< 8	< 6	< 36	< 9
11/17/20	1065 $\pm$ 148	< 7	< 6	< 29	< 8	
12/15/20	1142 $\pm$ 145	< 7	< 6	< 31	< 9	
<i>MEAN <math>\pm</math> 2 STD DEV</i>		1217 $\pm$ 205	-	-	-	-

**Table C-VII.2 CONCENTRATIONS OF GAMMA EMITTERS IN MILK SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**

RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

COLLECTION		K-40	Cs-134	Cs-137	Ba-140	La-140
SITE	PERIOD					
S	01/14/20	1225 $\pm$ 119	< 6	< 6	< 16	< 6
	02/13/20	1198 $\pm$ 156	< 7	< 7	< 25	< 10
	03/10/20	1147 $\pm$ 149	< 7	< 6	< 26	< 7
	04/07/20	1298 $\pm$ 203	< 9	< 7	< 36	< 8
	04/21/20	1168 $\pm$ 147	< 8	< 7	< 33	< 13
	05/05/20	1323 $\pm$ 197	< 8	< 7	< 29	< 10
	05/19/20	1291 $\pm$ 147	< 7	< 6	< 31	< 11
	06/02/20	1286 $\pm$ 190	< 9	< 7	< 29	< 12
	06/16/20	1169 $\pm$ 183	< 8	< 8	< 39	< 8
	06/30/20	1298 $\pm$ 139	< 6	< 6	< 23	< 9
	07/14/20	1408 $\pm$ 196	< 11	< 9	< 40	< 13
	07/28/20	1257 $\pm$ 185	< 6	< 7	< 35	< 10
	08/11/20	1113 $\pm$ 174	< 8	< 9	< 40	< 9
	08/25/20	1085 $\pm$ 193	< 8	< 7	< 33	< 11
	09/09/20	1175 $\pm$ 152	< 9	< 9	< 35	< 11
	09/22/20	1186 $\pm$ 170	< 6	< 7	< 28	< 6
	10/05/20	1198 $\pm$ 198	< 6	< 7	< 32	< 10
10/21/20	1279 $\pm$ 171	< 8	< 10	< 38	< 10	
11/02/20	1436 $\pm$ 208	< 10	< 9	< 41	< 10	
11/17/20	1331 $\pm$ 177	< 8	< 6	< 36	< 9	
12/15/20	1272 $\pm$ 188	< 8	< 9	< 39	< 13	
<i>MEAN <math>\pm</math> 2 STD DEV</i>		1245 $\pm$ 182	-	-	-	-
U	01/14/20	1027 $\pm$ 93	< 5	< 4	< 14	< 4
	02/13/20	1369 $\pm$ 165	< 8	< 7	< 33	< 9
	03/10/20	1225 $\pm$ 143	< 8	< 7	< 22	< 9
	04/07/20	1130 $\pm$ 157	< 6	< 8	< 37	< 11
	04/21/20	1043 $\pm$ 169	< 7	< 6	< 26	< 8
	05/05/20	1043 $\pm$ 161	< 8	< 8	< 29	< 8
	05/19/20	885 $\pm$ 140	< 7	< 6	< 29	< 7
	06/02/20	1097 $\pm$ 162	< 8	< 7	< 22	< 3
	06/16/20	1431 $\pm$ 182	< 8	< 8	< 36	< 10
	06/30/20	955 $\pm$ 164	< 10	< 10	< 37	< 12
	07/14/20	868 $\pm$ 151	< 10	< 8	< 39	< 11
	07/28/20	1263 $\pm$ 178	< 8	< 9	< 31	< 8
	08/11/20	1014 $\pm$ 148	< 8	< 6	< 34	< 9
	08/25/20	643 $\pm$ 146	< 8	< 8	< 37	< 13
	09/09/20	1302 $\pm$ 169	< 9	< 7	< 32	< 12
	09/24/20	1101 $\pm$ 149	< 9	< 8	< 29	< 9
	10/08/20	1316 $\pm$ 190	< 7	< 9	< 39	< 11
10/21/20	1275 $\pm$ 199	< 9	< 8	< 33	< 11	
11/02/20	1314 $\pm$ 167	< 9	< 9	< 45	< 11	
11/17/20	1165 $\pm$ 182	< 8	< 9	< 30	< 12	
12/15/20	1357 $\pm$ 170	< 8	< 6	< 30	< 8	
<i>MEAN <math>\pm</math> 2 STD DEV</i>		1134 $\pm$ 396	-	-	-	-
W	02/13/20	1348 $\pm$ 171	< 8	< 7	< 32	< 8
	05/05/20	1164 $\pm$ 132	< 6	< 6	< 20	< 8
	08/11/20	1371 $\pm$ 156	< 7	< 6	< 34	< 9
	11/02/20	1307 $\pm$ 158	< 6	< 7	< 35	< 9
<i>MEAN <math>\pm</math> 2 STD DEV</i>		1298 $\pm$ 186	-	-	-	-

**Table C-VII.2 CONCENTRATIONS OF GAMMA EMITTERS IN MILK SAMPLES COLLECTED  
IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**

RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

COLLECTION		K-40	Cs-134	Cs-137	Ba-140	La-140
SITE	PERIOD					
X	01/14/20	1315 $\pm$ 103	< 4	< 4	< 13	< 3
	02/13/20	1073 $\pm$ 196	< 11	< 10	< 36	< 10
	03/10/20	1093 $\pm$ 150	< 7	< 6	< 31	< 10
	04/07/20	1273 $\pm$ 169	< 9	< 6	< 32	< 8
	04/21/20	1112 $\pm$ 139	< 7	< 7	< 28	< 10
	05/05/20	1250 $\pm$ 162	< 7	< 8	< 32	< 9
	05/19/20	1180 $\pm$ 209	< 9	< 8	< 42	< 13
	06/02/20	964 $\pm$ 138	< 6	< 7	< 24	< 10
	06/16/20	1343 $\pm$ 140	< 7	< 8	< 33	< 12
	06/30/20	1134 $\pm$ 167	< 10	< 9	< 35	< 10
	07/14/20	1235 $\pm$ 171	< 9	< 9	< 23	< 14
	07/28/20	1088 $\pm$ 175	< 8	< 7	< 29	< 6
	08/11/20	1108 $\pm$ 190	< 10	< 8	< 40	< 10
	08/25/20	1174 $\pm$ 179	< 7	< 6	< 31	< 12
	09/09/20	1252 $\pm$ 185	< 10	< 9	< 37	< 10
	09/22/20	1223 $\pm$ 152	< 7	< 8	< 27	< 7
	10/05/20	1046 $\pm$ 193	< 8	< 7	< 32	< 12
	10/21/20	951 $\pm$ 156	< 8	< 9	< 39	< 12
11/02/20	1100 $\pm$ 157	< 9	< 7	< 38	< 11	
11/17/20	1171 $\pm$ 156	< 7	< 8	< 31	< 8	
12/15/20	1127 $\pm$ 155	< 10	< 7	< 33	< 11	
<i>MEAN <math>\pm</math> 2 STD DEV</i>		1153 $\pm$ 209	-	-	-	-
Y	02/13/20	1337 $\pm$ 177	< 6	< 7	< 33	< 7
	05/05/20	1287 $\pm$ 103	< 5	< 5	< 21	< 6
	08/11/20	1207 $\pm$ 154	< 7	< 7	< 25	< 9
	11/03/20	1219 $\pm$ 182	< 8	< 9	< 31	< 11
<i>MEAN <math>\pm</math> 2 STD DEV</i>		1263 $\pm$ 122	-	-	-	-

**Table C-VIII.1 CONCENTRATIONS OF GAMMA EMITTERS IN FOOD PRODUCT SAMPLES COLLECTED  
IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/KG WET ± 2 SIGMA

SITE	COLLECTION PERIOD		Be-7	K-40	Mn-54	Co-58	Co-60	I-131	Cs-134	Cs-137	
1C	06/17/20	Swiss Chard	< 422	6117 ± 851	< 39	< 38	< 41	< 55	< 45	< 41	
	06/17/20	Cabbage	< 304	3829 ± 685	< 35	< 36	< 33	< 57	< 38	< 37	
	06/17/20	Collards	< 338	4025 ± 657	< 31	< 37	< 36	< 55	< 35	< 35	
	07/23/20	Swiss Chard	629 ± 357	4201 ± 641	< 32	< 32	< 34	< 53	< 38	< 48	
	07/23/20	Cabbage	< 381	3636 ± 615	< 43	< 35	< 40	< 57	< 44	< 37	
	07/23/20	Corn Leaves	1625 ± 348	2331 ± 507	< 36	< 31	< 31	< 43	< 33	< 30	
	08/11/20	Swiss Chard	633 ± 282	2331 ± 503	< 26	< 25	< 31	< 28	< 25	< 30	
	08/11/20	Collards	< 415	2545 ± 595	< 32	< 37	< 35	< 54	< 32	< 44	
	08/11/20	Corn Leaves	2822 ± 457	2119 ± 541	< 32	< 28	< 21	< 37	< 34	< 38	
	09/16/20	Cabbage	< 339	2703 ± 626	< 33	< 32	< 36	< 36	< 31	< 39	
	09/16/20	Corn Leaves	3534 ± 560	1380 ± 601	< 42	< 27	< 36	< 54	< 50	< 37	
			MEAN ± 2 STD DEV	1849 ± 2608	3202 ± 2642	-	-	-	-	-	-
	2Q	06/17/20	Broccoli Leaves	477 ± 249	3122 ± 530	< 20	< 22	< 25	< 43	< 28	< 25
06/17/20		Cabbage	< 288	3930 ± 628	< 28	< 26	< 30	< 43	< 28	< 31	
06/17/20		Squash Leaves	< 239	5008 ± 526	< 28	< 28	< 29	< 37	< 28	< 23	
07/23/20		Kale	< 355	3937 ± 675	< 32	< 33	< 31	< 39	< 38	< 32	
07/23/20		Cabbage	682 ± 221	4342 ± 677	< 20	< 24	< 35	< 30	< 34	< 26	
07/23/20		Squash Leaves	1424 ± 350	6027 ± 761	< 29	< 26	< 27	< 36	< 35	< 31	
08/11/20		Kale	505 ± 237	3677 ± 545	< 32	< 30	< 31	< 36	< 36	< 33	
08/11/20		Cabbage	1072 ± 267	3469 ± 555	< 34	< 26	< 27	< 40	< 38	< 29	
08/11/20		Squash Leaves	1294 ± 315	4038 ± 644	< 37	< 27	< 34	< 30	< 36	< 30	
09/15/20		Cauliflower	< 273	3314 ± 579	< 30	< 33	< 32	< 47	< 35	< 35	
09/15/20		Broccoli	< 412	3058 ± 643	< 37	< 33	< 37	< 56	< 37	< 33	
09/15/20		Brussels Sprouts	< 235	4171 ± 751	< 32	< 41	< 48	< 56	< 44	< 40	
			MEAN ± 2 STD DEV	909 ± 821	4008 ± 1684	-	-	-	-	-	-

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**Table C-VIII.1 CONCENTRATIONS OF GAMMA EMITTERS IN FOOD PRODUCT SAMPLES COLLECTED  
IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/KG WET ± 2 SIGMA

SITE	COLLECTION PERIOD		Be-7	K-40	Mn-54	Co-58	Co-60	I-131	Cs-134	Cs-137	
3Q	06/17/20	Kale	< 287	5210 ± 602	< 35	< 29	< 31	< 55	< 37	< 34	
	06/17/20	Cabbage	< 374	3547 ± 752	< 43	< 39	< 33	< 53	< 44	< 43	
	06/17/20	Collards	< 290	3593 ± 533	< 30	< 35	< 24	< 41	< 40	< 34	
	07/23/20	Kale	< 329	6678 ± 768	< 26	< 26	< 25	< 39	< 40	< 28	
	07/23/20	Broccoli Leaves	< 342	4538 ± 714	< 33	< 30	< 40	< 43	< 42	< 34	
	07/23/20	Collards	< 500	6015 ± 946	< 38	< 31	< 41	< 56	< 46	< 35	
	08/11/20	Kale	< 443	4583 ± 797	< 42	< 35	< 40	< 30	< 43	< 36	
	08/11/20	Collards	< 359	3920 ± 636	< 35	< 23	< 36	< 36	< 44	< 34	
	08/11/20	Broccoli Leaves	652 ± 324	5267 ± 780	< 24	< 29	< 24	< 32	< 42	< 25	
	09/15/20	Kale	< 362	6171 ± 720	< 38	< 35	< 39	< 54	< 42	< 39	
	09/15/20	Corn Leaves	1808 ± 332	5656 ± 621	< 30	< 30	< 37	< 52	< 30	< 31	
	09/15/20	Collards	< 313	3478 ± 704	< 34	< 31	< 35	< 54	< 38	< 36	
			MEAN ± 2 STD DEV	1230 ± 1635	-	-	-	-	-	-	-
	55	06/17/20	Collards	< 299	4094 ± 640	< 30	< 24	< 25	< 53	< 28	< 30
		06/17/20	Kale	< 324	4937 ± 708	< 24	< 32	< 30	< 41	< 35	< 36
06/17/20		Swiss Chard	< 285	7608 ± 702	< 27	< 28	< 31	< 37	< 29	< 29	
07/23/20		Kale	< 252	2728 ± 423	< 23	< 22	< 23	< 33	< 28	< 23	
07/23/20		Cabbage	379 ± 284	3687 ± 553	< 22	< 23	< 26	< 33	< 33	< 24	
07/23/20		Swiss Chard	< 351	5183 ± 693	< 29	< 31	< 29	< 42	< 33	< 25	
08/11/20		Swiss Chard	471 ± 255	7090 ± 843	< 26	< 31	< 30	< 36	< 34	< 32	
08/11/20		Collards	370 ± 168	3324 ± 556	< 25	< 22	< 28	< 26	< 31	< 24	
08/11/20		Corn Leaves	1674 ± 268	4357 ± 572	< 27	< 22	< 21	< 26	< 27	< 25	
09/16/20		Swiss Chard	< 413	6095 ± 823	< 35	< 44	< 41	< 54	< 43	< 33	
09/16/20		Collards	< 391	4057 ± 835	< 35	< 45	< 28	< 51	< 39	< 35	
09/16/20		Corn Leaves	1901 ± 244	4229 ± 430	< 17	< 19	< 19	< 28	< 23	< 22	
			MEAN ± 2 STD DEV	959 ± 1523	-	-	-	-	-	-	-

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**Table C-IX.1 QUARTERLY DLR RESULTS FOR PEACH BOTTOM ATOMIC POWER STATION, 2020**

Monitoring Location	Location Quarterly Baseline, B <sub>Q</sub> (mrem)	B <sub>Q</sub> + MDD <sub>Q</sub> <sup>(1)</sup> (mrem)	2020 Normalized Net Dose, M <sub>QX</sub> (mrem/std. qtr.)				Quarterly Facility Dose, F <sub>Q</sub> (mrem)			
			1	2	3	4	1	2	3	4
P-TLD-14	23.2	28.6	24.1	24.0	25.0	22.3	ND	ND	ND	ND
P-TLD-15	23.9	29.3	24.6	24.4	25.4	23.9	ND	ND	ND	ND
P-TLD-16	23.4	28.8	21.2	22.4	23.2	22.3	ND	ND	ND	ND
P-TLD-17	27.2	32.6	29.1	27.2	28.9	28.0	ND	ND	ND	ND
P-TLD-18	23.9	29.3	24.2	24.1	26.3	22.4	ND	ND	ND	ND
P-TLD-19	20.8	26.2	20.5	19.3	20.3	18.1	ND	ND	ND	ND
P-TLD-1A	23.8	29.2	26.1	26.2	24.1	23.8	ND	ND	ND	ND
P-TLD-1B	20.2	25.6	20.3	21.0	21.4	20.5	ND	ND	ND	ND
P-TLD-1C	24.1	29.5	25.3	24.5	26.2	22.9	ND	ND	ND	ND
P-TLD-1D	23.4	28.8	24.9	21.5	23.8	20.2	ND	ND	ND	ND
P-TLD-1E	22.8	28.2	22.8	23.1	24.3	22.3	ND	ND	ND	ND
P-TLD-1F	27	32.4	26.7	28.0	27.8	26.4	ND	ND	ND	ND
P-TLD-1G	15.9	21.3	15.9	15.1	14.8	13.4	ND	ND	ND	ND
P-TLD-1H	23.6	29.0	24.1	23.8	24.6	23.5	ND	ND	ND	ND
P-TLD-1I	21.4	26.8	22.9	22.1	22.7	20.5	ND	ND	ND	ND
P-TLD-1J	27.3	32.7	29.3	27.5	27.0	24.1	ND	ND	ND	ND
P-TLD-1K	26.4	31.8	27.3	28.4	28.3	26.4	ND	ND	ND	ND
P-TLD-1L	19.4	24.8	24.4	22.9	22.7	20.9	ND	ND	ND	ND
P-TLD-1M	14	19.4	13.5	13.6	14.5	14.6	ND	ND	ND	ND
P-TLD-1NN	25.5	30.9	27.1	25.4	27.7	25.3	ND	ND	ND	ND
P-TLD-1P	16.1	21.5	18.5	16.8	17.5	14.5	ND	ND	ND	ND
P-TLD-1Q	18.7	24.1	20.6	18.3	20.3	19.1	ND	ND	ND	ND
P-TLD-1R(*)	32.9	38.3	35.6	37.6	37.9	32.6	ND	ND	ND	ND
P-TLD-1T	24.7	30.1	25.2	24.5	25.9	22.9	ND	ND	ND	ND
P-TLD-2	23	28.4	24.4	24.9	24.8	23.3	ND	ND	ND	ND
P-TLD-22	24.3	29.7	23.2	25.3	26.1	24.4	ND	ND	ND	ND
P-TLD-23	24.9	30.3	25.0	25.7	26.5	24.6	ND	ND	ND	ND
P-TLD-24	18.1	23.5	16.6	17.0	17.3	16.7	ND	ND	ND	ND
P-TLD-26	26	31.4	23.7	24.9	25.1	24.6	ND	ND	ND	ND
P-TLD-27	24.7	30.1	26.1	25.5	25.6	22.8	ND	ND	ND	ND
P-TLD-2B(**)	22.1	27.5	23.4	23.6	25.6	22.9	ND	ND	ND	ND
P-TLD-31A	19.9	25.3	19.2	20.1	20.4	19.2	ND	ND	ND	ND
P-TLD-32	25.4	30.8	25.8	25.1	26.7	25.6	ND	ND	ND	ND
P-TLD-3A	17.3	22.7	18.4	17.4	18.3	17.0	ND	ND	ND	ND
P-TLD-40	27.8	33.2	27.7	28.5	31.7	26.8	ND	ND	ND	ND
P-TLD-42	21	26.4	18.9	21.4	22.1	21.7	ND	ND	ND	ND
P-TLD-43	26.5	31.9	26.8	27.2	28.0	26.5	ND	ND	ND	ND
P-TLD-44	22.8	28.2	24.4	23.5	23.4	22.0	ND	ND	ND	ND
P-TLD-45	24.5	29.9	25.4	22.8	25.7	22.8	ND	ND	ND	ND
P-TLD-46	21	26.4	22.5	21.2	22.1	20.1	ND	ND	ND	ND
P-TLD-47	26	31.4	28.5	28.6	27.7	26.2	ND	ND	ND	ND
P-TLD-48	24.3	29.7	24.2	26.3	25	24	ND	ND	ND	ND
P-TLD-49	24	29.4	23.9	24.8	23.5	22.3	ND	ND	ND	ND
P-TLD-4K	15.1	20.5	15.4	15.3	14	15	ND	ND	ND	ND
P-TLD-5	22	27.4	22.4	22.3	23.8	21.8	ND	ND	ND	ND
P-TLD-50	28.1	33.5	28.9	28.6	27.6	26.6	ND	ND	ND	ND
P-TLD-51	23.6	29.0	25.1	24.1	25	23.8	ND	ND	ND	ND
P-TLD-6B	19.8	25.2	19.6	20.8	19.7	19.7	ND	ND	ND	ND

<sup>(1)</sup> **Minimum Differential Dose (MDD<sub>Q</sub>):** The smallest amount of facility-related dose above the background dose (quarterly)

(\*) 1R is the dosimeter closest to the ISFSI (\*\*) 2B is the closest resident to the plant and ISFSI



**Table C-IX.2 ANNUAL DLR RESULTS FOR PEACH BOTTOM ATOMIC POWER STATION, 2020**


<b>Monitoring Location</b>	<b>Annual Baseline, B<sub>A</sub> (mrem)</b>	<b>B<sub>A</sub> + MDD<sub>A</sub><sup>(1)</sup> (mrem)</b>	<b>Normalized Annual Dose, M<sub>A</sub> (mrem/yr)</b>	<b>Annual Facility Dose, F<sub>A</sub></b>
P-TLD-14	92.8	108.9	95.4	ND
P-TLD-15	95.5	111.6	98.3	ND
P-TLD-16	93.7	109.8	89.1	ND
P-TLD-17	108.9	125.0	113.2	ND
P-TLD-18	95.5	111.6	97.0	ND
P-TLD-19	83.2	99.3	78.2	ND
P-TLD-1A	95	111.1	100.2	ND
P-TLD-1B	80.8	96.9	83.2	ND
P-TLD-1C	96.3	112.4	98.9	ND
P-TLD-1D	93.8	109.9	90.4	ND
P-TLD-1E	91.2	107.3	92.5	ND
P-TLD-1F	108	124.1	108.9	ND
P-TLD-1G	63.4	79.5	59.2	ND
P-TLD-1H	94.4	110.5	96.0	ND
P-TLD-1I	85.6	101.7	88.2	ND
P-TLD-1J	109	125.1	107.9	ND
P-TLD-1K	105.5	121.6	110.4	ND
P-TLD-1L	77.6	93.7	90.9	ND
P-TLD-1M	56.1	72.2	56.2	ND
P-TLD-1NN	102.1	118.2	105.5	ND
P-TLD-1P	64.6	80.7	67.3	ND
P-TLD-1Q	74.9	91.0	78.3	ND
P-TLD-1R(*)	131.7	147.8	143.7	ND
P-TLD-1T	104.7	120.8	98.5	ND
P-TLD-2	92.2	108.3	97.4	ND
P-TLD-22	97	113.1	99.0	ND
P-TLD-23	99.7	115.8	101.8	ND
P-TLD-24	72.3	88.4	67.6	ND
P-TLD-26	104.1	120.2	98.3	ND
P-TLD-27	98.8	114.9	100.0	ND
P-TLD-2B(**)	88.4	104.5	95.5	ND
P-TLD-31A	79.6	95.7	78.9	ND
P-TLD-32	101.7	117.8	103.2	ND
P-TLD-3A	69.3	85.4	71.1	ND
P-TLD-40	111.2	127.3	114.7	ND
P-TLD-42	84.2	100.3	84.1	ND
P-TLD-43	106.1	122.2	108.5	ND
P-TLD-44	91.3	107.4	93.3	ND
P-TLD-45	98.2	114.3	96.7	ND
P-TLD-46	84.2	100.3	85.9	ND
P-TLD-47	103.8	119.9	111	ND
P-TLD-48	97.1	113.2	99.5	ND
P-TLD-49	95.8	111.9	94.5	ND
P-TLD-4K	60.3	76.4	59.7	ND
P-TLD-5	87.8	103.9	90.3	ND
P-TLD-50	112.2	128.3	111.7	ND
P-TLD-51	94.5	110.6	98	ND
P-TLD-6B	79.1	95.2	79.8	ND

<sup>(1)</sup> **Minimum Differential Dose (MDD<sub>A</sub>):** The smallest amount of facility-related dose above the background dose (annually)

(\*) 1R is the dosimeter closest to the ISFSI (\*\*) 2B is the closest resident to the plant and ISFSI

FIGURE C-1

MONTHLY TOTAL GROSS BETA CONCENTRATIONS IN DRINKING WATER SAMPLES COLLECTED IN THE VICINITY OF PBAPS, 2020



Open data points are positive identification of gross beta activity

# FIGURE C-2 MDC RESULTS FOR FISH SAMPLING COLLECTED IN THE VICINITY OF PBAPS, 2020




FIGURE C-3  
 SEMI-ANNUAL CS-137 CONCENTRATIONS IN SEDIMENT SAMPLES  
 COLLECTED IN THE VICINITY OF PBAPS, 2020





FIGURE C-4  
 MEAN WEEKLY GROSS BETA CONCENTRATIONS IN AIR PARTICULATE  
 SAMPLES COLLECTED IN THE VICINITY OF PBAPS, 2020



No Required Reporting Level for Gross Beta Activities

FIGURE C-5  
 AVERAGE MONTHLY MDC FOR REMF MILK SAMPLES  
 COLLECTED IN THE VICINITY OF PBAPS, 2020





FIGURE C-6  
 ANNUAL NORMALIZED GAMMA RADIATION RESULTS FROM  
 DOSIMETERS COLLECTED IN THE VICINITY OF PBAPS, 2020



All  $M_A$  data less than  $B_A + MDDA$  Annual Facility Dose ( $F_A$ ) is reported as Non-Detectable (ND)

## **APPENDIX D**

### **DATA TABLES AND FIGURES QC LABORATORIES**



Intentionally left blank

TABLE D-I.1

**CONCENTRATIONS OF GROSS BETA IN DRINKING WATER  
SAMPLES COLLECTED IN THE VICINITY  
OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

COLLECTION PERIOD	4L *	Lab
12/30/19 - 01/30/20	1.6 $\pm$ 0.7	EIS
01/27/20 - 02/26/20	0.5 $\pm$ 0.6	EIS
02/26/20 - 04/02/20	1.2 $\pm$ 0.6	EIS
04/02/20 - 04/30/20	2.4 $\pm$ 0.7	EIS
04/30/20 - 05/27/20	1.9 $\pm$ 0.7	EIS
05/27/20 - 07/01/20	1.8 $\pm$ 0.7	EIS
07/01/20 - 07/29/20	2.4 $\pm$ 0.7	EIS
07/29/20 - 09/02/20	3.8 $\pm$ 0.8	EIS
09/02/20 - 10/01/20	2.8 $\pm$ 0.7	EIS
10/01/20 - 10/29/20	2.8 $\pm$ 0.7	EIS
10/29/20 - 12/02/20	4.0 $\pm$ 0.8	EIS
12/02/20 - 12/29/20	2.6 $\pm$ 0.8	EIS
<i>MEAN <math>\pm</math> 2 STD DEV</i>	2.3 $\pm$ 2.0	

TABLE D-I.2

**CONCENTRATIONS OF TRITIUM IN DRINKING WATER  
SAMPLES COLLECTED IN THE VICINITY OF  
PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

COLLECTION PERIOD	4L	Lab
12/30/19 - 04/02/20	< 151	GEL
03/30/20 - 07/01/20	< 145	GEL
06/29/20 - 10/01/20	< 184	GEL
09/28/20 - 12/29/20	< 106	GEL
<i>MEAN</i>	-	

TABLE D-I.3

**CONCENTRATIONS OF I-131 IN DRINKING WATER  
SAMPLES COLLECTED IN THE VICINITY OF  
PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

COLLECTION PERIOD	4L	Lab
12/30/19 - 01/30/20	< 0.5	EIS
01/27/20 - 02/26/20	< 0.6	EIS
02/26/20 - 04/02/20	< 0.7	EIS
04/02/20 - 04/30/20	< 0.6	EIS
04/30/20 - 05/27/20	< 0.7	EIS
05/27/20 - 07/01/20	< 0.8	EIS
07/01/20 - 07/29/20	< 0.8	EIS
07/29/20 - 09/02/20	< 0.6	EIS
09/02/20 - 10/01/20	< 0.7	EIS
10/01/20 - 10/29/20	< 0.7	EIS
10/29/20 - 12/02/20	< 0.7	EIS
12/02/20 - 12/29/20	< 0.8	EIS
<i>MEAN</i>	-	

\*All detectable results were less than the required LLD

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**TABLE D-I.4 CONCENTRATIONS OF GAMMA EMITTERS IN DRINKING WATER SAMPLES COLLECTED  
IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**

RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA  
(Analysis by EIS Laboratory)

SITE	COLLECTION PERIOD	Mn-54	Fe-59	Co-58	Co-60	Zn-65	Zr-95	Nb-95	Cs-134	Cs-137	Ba-140	La-140
4L	01/02/20 - 01/30/20	< 4	< 9	< 4	< 5	< 9	< 7	< 4	< 5	< 4	< 16	< 7
	01/30/20 - 02/26/20	< 4	< 8	< 4	< 4	< 8	< 7	< 4	< 4	< 5	< 17	< 6
	02/26/20 - 04/02/20	< 6	< 14	< 5	< 6	< 9	< 8	< 6	< 5	< 6	< 25	< 9
	04/02/20 - 04/30/20	< 5	< 9	< 4	< 5	< 10	< 7	< 5	< 5	< 4	< 20	< 8
	04/30/20 - 05/27/20	< 4	< 8	< 4	< 4	< 8	< 7	< 5	< 4	< 4	< 20	< 7
	05/27/20 - 07/01/20	< 3	< 6	< 3	< 3	< 7	< 6	< 4	< 3	< 3	< 16	< 5
	07/01/20 - 07/29/20	< 4	< 7	< 4	< 3	< 8	< 7	< 4	< 4	< 4	< 16	< 6
	07/29/20 - 09/02/20	< 6	< 13	< 6	< 6	< 10	< 9	< 5	< 6	< 6	< 22	< 8
	09/02/20 - 10/01/20	< 4	< 8	< 4	< 4	< 8	< 7	< 4	< 4	< 4	< 18	< 6
	10/01/20 - 10/29/20	< 6	< 11	< 6	< 6	< 9	< 11	< 6	< 5	< 5	< 28	< 11
	10/29/21 - 12/02/20	< 6	< 14	< 6	< 5	< 14	< 7	< 6	< 6	< 7	< 27	< 9
	12/02/20 - 12/29/20	< 6	< 11	< 6	< 6	< 13	< 10	< 7	< 5	< 6	< 28	< 10
	MEAN	-	-	-	-	-	-	-	-	-	-	-

**TABLE D-II.1 CONCENTRATIONS OF GROSS BETA IN AIR PARTICULATE AND I-131 IN AIR IODINE SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
 RESULTS IN UNITS OF E-3 PCI/CU METER  $\pm$  2 SIGMA  
 (Analysis by EIS Laboratory)

COLLECTION PERIOD	1A GROSS BETA	1A I-131
01/02/20 - 01/08/20	16 $\pm$ 2	< 15
01/08/20 - 01/16/20	18 $\pm$ 2	< 7
01/16/20 - 01/23/20	25 $\pm$ 2	< 11
01/23/20 - 01/30/20	13 $\pm$ 2	< 14
01/30/20 - 02/06/20	22 $\pm$ 2	< 11
02/06/20 - 02/12/20	13 $\pm$ 2	< 20
02/12/20 - 02/20/20	18 $\pm$ 2	< 14
02/20/20 - 02/26/20	23 $\pm$ 2	< 14
02/26/20 - 03/05/20	13 $\pm$ 2	< 8
03/05/20 - 03/11/20	14 $\pm$ 2	< 15
03/11/20 - 03/19/20	15 $\pm$ 2	< 14
03/19/20 - 03/25/20	16 $\pm$ 2	< 23
03/25/20 - 04/02/20	14 $\pm$ 2	< 18
04/02/20 - 04/08/20	17 $\pm$ 2	< 18
04/08/20 - 04/15/20	22 $\pm$ 2	< 13
04/15/20 - 04/23/20	26 $\pm$ 2	< 18
04/23/20 - 04/30/20	14 $\pm$ 2	< 18
04/30/20 - 05/07/20	14 $\pm$ 2	< 23
05/07/20 - 05/14/20	17 $\pm$ 2	< 19
05/14/20 - 05/20/20	21 $\pm$ 2	< 22
05/20/20 - 05/27/20	11 $\pm$ 2	< 20
05/27/20 - 06/04/20	15 $\pm$ 2	< 16
06/04/20 - 06/11/20	19 $\pm$ 2	< 12
06/11/20 - 06/18/20	12 $\pm$ 2	< 19
06/18/20 - 06/25/20	17 $\pm$ 2	< 15
06/25/20 - 07/01/20	23 $\pm$ 3	< 19
07/01/20 - 07/09/20	20 $\pm$ 2	< 16
07/09/20 - 07/16/20	16 $\pm$ 2	< 15
07/16/20 - 07/23/20	26 $\pm$ 2	< 13
07/23/20 - 07/29/20	27 $\pm$ 3	< 15
07/29/20 - 08/06/20	27 $\pm$ 3	< 15
08/06/20 - 08/13/20	28 $\pm$ 2	< 18
08/13/20 - 08/20/20	26 $\pm$ 2	< 20
08/20/20 - 08/27/20	32 $\pm$ 3	< 17
08/27/20 - 09/02/20	15 $\pm$ 2	< 18
09/02/20 - 09/10/20	35 $\pm$ 3	< 27
09/10/20 - 09/16/20	18 $\pm$ 2	< 13
09/16/20 - 09/24/20	31 $\pm$ 2	< 12
09/24/20 - 10/01/20	28 $\pm$ 2	< 17
10/01/20 - 10/08/20	25 $\pm$ 2	< 19
10/08/20 - 10/14/20	23 $\pm$ 2	< 24
10/14/20 - 10/21/20	26 $\pm$ 2	< 13
10/21/20 - 10/29/20	20 $\pm$ 2	< 15
10/29/20 - 11/05/20	33 $\pm$ 3	< 15
11/05/20 - 11/12/20	46 $\pm$ 3	< 18
11/12/20 - 11/18/20	32 $\pm$ 3	< 19
11/18/20 - 11/25/20	42 $\pm$ 3	< 21
11/25/20 - 12/02/20	37 $\pm$ 3	< 30
12/02/20 - 12/09/20	25 $\pm$ 2	< 29
12/09/20 - 12/15/20	72 $\pm$ 4	< 35
12/15/20 - 12/22/20	31 $\pm$ 2	< 14
12/22/20 - 12/29/20	36 $\pm$ 3	< 16
MEAN $\pm$ 2 STD DEV	24 $\pm$ 21	-

**TABLE D-II.2 CONCENTRATIONS OF GAMMA EMITTERS IN AIR PARTICULATE SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
 RESULTS IN UNITS OF E-3 PCI/CU METER  $\pm$  2 SIGMA  
 (Analysis by EIS Laboratory)


SITE	COLLECTION PERIOD		Be-7	Mn-54	Co-58	Co-60	Cs-134	Cs-137
	SITE	PERIOD						
1A		01/02/20 - 04/02/20	59 $\pm$ 12	< 2	< 2	< 1	< 1	< 1
		04/02/20 - 07/01/20	74 $\pm$ 14	< 1	< 2	< 1	< 1	< 1
		07/01/20 - 10/01/20	48 $\pm$ 13	< 2	< 2	< 2	< 2	< 2
		10/01/20 - 12/29/20	67 $\pm$ 16	< 2	< 3	< 2	< 2	< 2
		<i>MEAN <math>\pm</math> 2 STD DEV</i>	62 $\pm$ 23	-	-	-	-	-

**TABLE D-III.1 CONCENTRATIONS OF I-131 AND GAMMA EMITTERS IN MILK SAMPLES COLLECTED IN THE VICINITY OF PEACH BOTTOM ATOMIC POWER STATION, 2020**  
 RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA  
 (Analysis by EIS Laboratory)


SITE	COLLECTION PERIOD		I-131	K-40	Cs-134	Cs-137	Ba-140	La-140
	SITE	PERIOD						
J		02/13/20	< 0.7	1380 $\pm$ 93	< 4	< 5	< 18	< 6
		05/06/20	< 0.7	1420 $\pm$ 106	< 5	< 6	< 22	< 8
		08/11/20	< 0.6	1430 $\pm$ 107	< 4	< 5	< 18	< 5
		11/02/20	< 0.6	1430 $\pm$ 105	< 4	< 5	< 23	< 8
		<i>MEAN <math>\pm</math> 2 STD DEV</i>	-	1415 $\pm$ 48	-	-	-	-
S		02/13/20	< 0.6	1390 $\pm$ 92	< 4	< 5	< 18	< 5
		05/05/20	< 0.7	1430 $\pm$ 107	< 4	< 5	< 25	< 9
		08/11/20	< 0.6	1390 $\pm$ 106	< 4	< 5	< 19	< 6
		11/02/20	< 0.9	1500 $\pm$ 111	< 5	< 4	< 27	< 9
		<i>MEAN <math>\pm</math> 2 STD DEV</i>	-	1428 $\pm$ 104	-	-	-	-
V		02/13/20	< 0.7	1360 $\pm$ 93	< 5	< 5	< 17	< 7
		05/05/20	< 0.6	1430 $\pm$ 104	< 4	< 5	< 23	< 7
		08/11/20	< 0.4	1430 $\pm$ 106	< 5	< 5	< 16	< 6
		11/02/20	< 0.9	1410 $\pm$ 105	< 5	< 5	< 21	< 8
		<i>MEAN <math>\pm</math> 2 STD DEV</i>	-	1408 $\pm$ 66	-	-	-	-

THE MEAN AND TWO STANDARD DEVIATION ARE CALCULATED USING THE POSITIVE VALUES

**FIGURE D-1**  
**COMPARISON OF MONTHLY TOTAL GROSS BETA CONCENTRATIONS**  
**IN DRINKING WATER SAMPLES FROM STATION 4L**  
**ANALYZED BY THE PRIMARY AND QC LABORATORIES, 2020**



**FIGURE D-2**  
**COMPARISON OF WEEKLY GROSS BETA CONCENTRATIONS FROM**  
**CO-LOCATED AIR PARTICULATE LOCATIONS (1Z/1A) ANALYZED BY**  
**THE PRIMARY AND QC LABORATORIES, 2020**



## **APPENDIX E**

### **ERRATA DATA**



Intentionally left blank

There was no errata data for 2020.

Intentionally left blank

## **APPENDIX F**

# **INTER-LABORATORY COMPARISON PROGRAM ACCEPTANCE CRITERIA AND RESULTS**

Intentionally left blank

## A. Pre-set Acceptance Criteria

### 1. Analytics Evaluation Criteria

Analytics' evaluation report provides a ratio of laboratory results and Analytics' known value. Since flag values are not assigned by Analytics, TBE-ES evaluates the reported ratios based on internal QC requirements, which are based on the DOE MAPEP criteria.

### 2. ERA Evaluation Criteria

The Environmental Resource Associates' evaluation report provides an acceptance range for control and warning limits with associated flag values. The Environmental Resource Associates' acceptance limits are established per the United States Environmental Protection Agency (USEPA), National Environmental Laboratory Accreditation Conference (NELAC), state-specific performance testing program requirements or ERA's standard operating procedure for the Generation of Performance Acceptance Limits, as applicable. The acceptance limits are either determined by a regression equation specific to each analyte or a fixed percentage limit promulgated under the appropriate regulatory document.

### 3. DOE Evaluation Criteria

MAPEP's evaluation report provides an acceptance range with associated flag values. The MAPEP defines three levels of performance: Acceptable (flag = "A"), Acceptable with Warning (flag = "W"), and Not Acceptable (flag = "N"). Performance is considered acceptable when a mean result for the specified analyte is  $\pm 20\%$  of the reference value. Performance is acceptable with warning when a mean result falls in the range from  $\pm 20\%$  to  $\pm 30\%$  of the reference value (i.e.,  $20\% < \text{bias} < 30\%$ ). If the bias is greater than 30%, the results are deemed not acceptable.

Note: The Department of Energy (DOE) Mixed Analyte Performance Evaluation Program (MAPEP) samples are created to mimic conditions found at DOE sites which do not resemble typical environmental samples obtained at commercial nuclear power facilities.

### 3. Laboratory-Specific Criteria

Each analytical laboratory has a documentation system in place to address performance evaluation (PE) sample failures in the form of corrective actions. The TBE Laboratory initiates a Non-Conformance Report (NCR), which details the failure, performs a root cause investigation, and proposes a corrective and/or preventative action. The GEL Laboratory's system is documented via a Corrective Action Request and Report (CARR).

B. TBE PE Results and Discussion

1. The MAPEP February 2020 AP U-233/234 and U-238 results were evaluated as *Not Acceptable*. The reported value for U-233/234 was  $0.0416 \pm 0.0102$  Bq/sample and the known result was 0.075 Bq/sample (acceptance range 0.053 - 0.098). The reported value for U-238 was  $0.0388 \pm 0.00991$  Bq/sample and the known result was 0.078 Bq/sample (acceptance range 0.055 - 0.101). This sample was run as the workgroup duplicate and had RPD's of 10.4% (U-234) and 11.7% (U-238). After the known results were obtained, the sample was relogged. The filter was completely digested with tracer added originally; the R1 results were almost identical. It was concluded that the recorded tracer amount was actually double, causing the results to be skewed. Lab worksheets have been modified to verify actual tracer amount vs. LIMS data. TBE changed vendors for this cross-check to ERA MRAD during the 2<sup>nd</sup> half of 2020. Results were acceptable at 97.8% for U-234 and 106% for U-238. (NCR 20-13)
2. The Analytics September 2020 milk Sr-89 result was evaluated as *Not Acceptable*. The reported value was 62.8 pCi/L and the known result was 95.4 (66%). All QC data was reviewed and there were no anomalies. This was the first failure for milk Sr-89 since 2013 and there have only been 3 upper/lower boundary warnings since that time. It is believed that there may have been some Sr-89 loss during sample prep. The December 2020 result was at 92% of the known. (NCR 20-19)
3. The ERA October 2020 water I-131 result was evaluated as *Not Acceptable*. The reported value was 22.9 pCi/L and the known result was 28.2 (acceptance range 23.5 - 33.1). The reported result was 81% of the known, which passes TBE QC criteria. This was the first failure for water I-131. (NCR 20-17)
4. The ERA October 2020 water Gross Alpha and Gross Beta results were evaluated as *Not Acceptable*. The reported/acceptable values and ranges are as follows:

	<u>Reported</u>	<u>Known</u>	<u>Range</u>
Gross Alpha	40.0	26.2	13.3 - 34.7
Gross Beta	47.5	69.1	48.0 - 76.0

All QC data was reviewed with no anomalies and a cause for failure could not be determined. This was the first failure for water Gross Beta. A Quick Response follow-up cross-check was analyzed as soon as possible with acceptable results at 96.8% for Gross Alpha and 102% for Gross Beta. (NCR 20-18)
5. The MAPEP August 2020 soil Ni-63 result was evaluated as *Not Acceptable*. The reported value was  $438 \pm 21.1$  Bq/kg and the known result was 980 Bq/kg (acceptance range 686 - 1274). It is believed that some Ni-63 loss occurred during the sample prep step. (NCR 20-20)

### C. EIS Laboratory PE Results and Discussion

1. The ERA April 2020 reported Gross Beta result was 43.3 pCi/L and the known was 60.5 pCi/L (acceptance range was 41.7 - 67.2 pCi/L). Although the reported result passed the low end of the vendor acceptance criteria, but failed NRC Resolution Test Criteria. It was determined that glassware used in preparation is cleaned with nitric acid except for the volumetric pipets, which are rinsed with DI water only. The glass is potentially not as clean and could retain microdroplets of activity on the glass. Going forward, volumetric pipets are rinsed with nitric acid to remove mineral deposit and activity that might be retained on the glass during use and preventing a clean delivery of the sample.
2. The Analytics (EZA) December 2020 result for AP filter and milk Zn-65 were evaluated as failing. The reported result and known are :

	<u>Reported</u>	<u>Known</u>
AP (Detector 2)	105 pCi	149 pCi
AP (Detector 5)	111 pCi	149 pCi
Milk	135 pCi/L	190 pCi/L

The failure was due to an error in mapping the raw data cell to the calculated data cell in the evaluation spreadsheet. The spreadsheet was peer-reviewed and verified. The cell was mapped to the Co-60 raw data instead of the Zn-65 raw data. Had the cell been mapped correctly, the result and uncertainty would have passed NRC acceptance criteria with less than 10% difference from the true value.

### D. GEL Labs PE Results and Discussion

1. Two ERA CARR 190225-1192 - ERA 1<sup>st</sup> quarter 2020 (RAD-120) water:
  - a. The H-3 reported value of 15,200 pCi/L were evaluated as *Not Acceptable*. The known result was 17,800 pCi/L with an acceptance range of 15,600 - 19,600 pCi/L. All data and lab processes were evaluated and no errors were found. It was concluded that the low bias was an isolated occurrence and that the overall process is within control.
  - b. Two Sr-89 results were evaluated as *Not Acceptable*. The reported values were 73.3 pCi/L and 70.8 pCi/L. The known result was 59.3 pCi/L, with an acceptance range of 47.6 - 67.1 pCi/L. A review of the data as well as of the preparation processes did not reveal any errors or possible contributors to the high bias. In addition, the reported values are 117% and 114% of the reference value, which is within the lab's standard acceptance criteria of +/- 25% for Laboratory Control Samples.
  - c. The I-131 reported value of 23.7 pCi/L was evaluated as *Not Acceptable*. The known result was 29.9 pCi/L with an acceptance range of 24.9 - 34.9 pCi/L. The laboratory reviewed the data and



found no errors. All batch QA samples including a duplicate, met acceptability criteria. The lab will continue to investigate all steps of the analytical process.

No permanent corrective actions/preventative actions or improvements were needed at this time. The lab must assume unidentified random errors caused the biases because all quality control criteria were met in the batch. Subsequent analyses of these isotopes for drinking water were acceptable in other PT samples during the year.

2. Two ERA 2<sup>nd</sup> quarter 2020 water Sr-89 results were evaluated as *Not Acceptable*. The reported values were 68.8 and 71.6 pCi/L and the known result was 60.1 pCi/L (acceptance range of 48.3 - 67.9 pCi/L). No Corrective Action information was included in the 2020 QA Report.
3. CARR 200902-1287 - The ERA 3<sup>rd</sup> quarter 2020 water Co-60 result was evaluated as *Not Acceptable*. The reported value was 97.9 pCi/L and the known result was 86.1 pCi/L (acceptance range of 77.5 - 97.0 pCi/L). The data was reviewed and no anomalies were noted. The batch duplicate result from the original analysis met the acceptance criteria of the study and replication criteria of the lab with RPDs of <10%. Laboratory processes were evaluated and no gross errors were found. The other reported analytes for this method were within the limits of the study (except for Ba-133). A definitive contributor to the slightly high bias could not be identified, concluding that this was an isolated occurrence.

No permanent corrective actions/preventative actions or improvements were needed at this time. The lab will continue to monitor the recoveries to ensure that there are no continued process issues.

**Analytics Environmental Radioactivity Cross Check Program  
Teledyne Brown Engineering Environmental Services**

**Table F-1**

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Value	Known Value <sup>(a)</sup>	Ratio of TBE to Known Result	Evaluation <sup>(b)</sup>
September 2020	E13247	Milk	Sr-89	pCi/L	62.8	95.4	0.66	N <sup>(1)</sup>
			Sr-90	pCi/L	12.0	12.8	0.94	A
	E13248	Milk	Ce-141	pCi/L	156	150	1.04	A
			Co-58	pCi/L	172	180	0.96	A
			Co-60	pCi/L	369	379	0.97	A
			Cr-51	pCi/L	372	372	1.00	A
			Cs-134	pCi/L	171	200	0.85	A
			Cs-137	pCi/L	241	250	0.96	A
			Fe-59	pCi/L	217	200	1.08	A
			I-131	pCi/L	84.6	95.0	0.89	A
			Mn-54	pCi/L	175	180	0.97	A
			Zn-65	pCi/L	252	270	0.93	A
				E13249	Charcoal	I-131	pCi	70.2
	E13250	AP	Ce-141	pCi	101	101	1.00	A
			Co-58	pCi	111	120	0.92	A
			Co-60	pCi	249	254	0.98	A
			Cr-51	pCi	287	249	1.15	A
			Cs-134	pCi	114	134	0.85	A
			Cs-137	pCi	159	168	0.95	A
			Fe-59	pCi	127	134	0.95	A
			Mn-54	pCi	114	121	0.94	A
Zn-65	pCi	168	181	0.93	A			
	E13251	Soil	Ce-141	pCi/g	0.241	0.191	1.26	W
			Co-58	pCi/g	0.211	0.228	0.93	A
			Co-60	pCi/g	0.466	0.481	0.97	A
			Cr-51	pCi/g	0.450	0.472	0.95	A
			Cs-134	pCi/g	0.273	0.254	1.07	A
			Cs-137	pCi/g	0.370	0.390	0.95	A
			Fe-59	pCi/g	0.233	0.254	0.92	A
			Mn-54	pCi/g	0.217	0.229	0.95	A
Zn-65	pCi/g	0.368	0.343	1.07	A			
	E13252	AP	Sr-89	pCi	79.9	100.0	0.80	A
			Sr-90	pCi	12.1	13.4	0.90	A

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

(1) See **NCR 20-19**

**Analytics Environmental Radioactivity Cross Check Program  
Teledyne Brown Engineering Environmental Services**

**Table F-1**

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Value	Known Value <sup>(a)</sup>	Ratio of TBE to Known Result	Evaluation <sup>(b)</sup>
December 2020	E13254	Milk	Sr-89	pCi/L	82.2	89.7	0.92	A
			Sr-90	pCi/L	12.4	13.0	0.96	A
	E13255	Milk	Ce-141	pCi/L	91.1	100	0.91	A
			Co-58	pCi/L	77.5	84.3	0.92	A
			Co-60	pCi/L	147	152	0.97	A
			Cr-51	pCi/L	259	253	1.02	A
			Cs-134	pCi/L	97.1	108	0.90	A
			Cs-137	pCi/L	117	127	0.92	A
			Fe-59	pCi/L	114	112	1.02	A
			I-131	pCi/L	84.3	91.9	0.92	A
			Mn-54	pCi/L	137	143	0.96	A
			Zn-65	pCi/L	175	190	0.92	A
	E13256	Charcoal	I-131	pCi	70.2	78.2	0.90	A
	E13257A	AP	Ce-141	pCi	67.4	74.6	0.90	A
			Co-58	pCi	57.9	62.9	0.92	A
			Co-60	pCi	108	113	0.95	A
			Cr-51	pCi	162	189	0.86	A
			Cs-134	pCi	68.1	80.4	0.85	A
			Cs-137	pCi	82.4	95.0	0.87	A
			Fe-59	pCi	80.5	83.7	0.96	A
			Mn-54	pCi	102	107	0.95	A
	E13258	Soil	Ce-141	pCi/g	0.167	0.170	0.98	A
			Co-58	pCi/g	0.125	0.143	0.87	A
			Co-60	pCi/g	0.245	0.257	0.95	A
			Cr-51	pCi/g	0.393	0.429	0.92	A
			Cs-134	pCi/g	0.147	0.183	0.80	A
			Cs-137	pCi/g	0.260	0.288	0.90	A
			Fe-59	pCi/g	0.199	0.190	1.05	A
			Mn-54	pCi/g	0.229	0.243	0.94	A
	E13259	AP	Sr-89	pCi	85.0	78.6	1.08	A
Sr-90			pCi	13.1	11.4	1.15	A	

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

**DOE's Mixed Analyte Performance Evaluation Program (MAPEP)**  
**Teledyne Brown Engineering Environmental Services**

**Table F-2**

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Value	Known Value <sup>(a)</sup>	Acceptance Range	Evaluation <sup>(b)</sup>
February 2020	20-GrF42	AP	Gross Alpha	Bq/sample	0.676	1.24	0.37 - 2.11	A
			Gross Beta	Bq/sample	2.03	2.00	1.00 - 3.00	A
	20-MaS42	Soil	Ni-63	Bq/kg	0.01		(1)	A
			Sr-90	Bq/kg	348	340	238 - 442	A
	20-MaW42	Water	Ni-63	Bq/L	11.6	11.1	7.8 - 14.4	A
			Pu-238	Bq/L	0.926	0.94	0.66 - 1.22	A
			Pu-239/240	Bq/L	0.712	0.737	0.516 - 0.958	A
	20-RdF42	AP	U-234/233	Bq/sample	0.0416	0.075	0.053 - 0.098	N <sup>(3)</sup>
			U-238	Bq/sample	0.0388	0.078	0.055 - 0.101	N <sup>(3)</sup>
	20-RdV42	Vegetation	Cs-134	Bq/sample	3.23	3.82	2.67 - 4.97	A
			Cs-137	Bq/sample	2.64	2.77	1.94 - 3.60	A
			Co-57	Bq/sample	0.0281		(1)	A
			Co-60	Bq/sample	2.62	2.79	1.95 - 3.63	A
			Mn-54	Bq/sample	4.3	4.58	3.21 - 5.95	A
			Sr-90	Bq/sample	0.396	0.492	0.344 - 0.640	A
			Zn-65	Bq/sample	3.93	3.79	2.65 - 4.93	A
August 2020	20-GrF43	AP	Gross Alpha	Bq/sample	0.267	0.528	0.158 - 0.898	A
			Gross Beta	Bq/sample	0.939	0.915	0.458 - 1.373	A
	20-MaS43	Soil	Ni-63	Bq/kg	438	980	686 - 1274	N <sup>(4)</sup>
			Tc-99	Bq/kg	1.11		(1)	A
	20-MaW43	Water	Ni-63	Bq/L	0.175		(1)	A
			Tc-99	Bq/L	8.8	9.4	6.6 - 12.2	A
	20-RdV43	Vegetation	Cs-134	Bq/sample	3.635	4.94	3.46 - 6.42	W
			Cs-137	Bq/sample	0.0341		(1)	A
			Co-57	Bq/sample	5.855	6.67	4.67 - 8.67	W
			Co-60	Bq/sample	3.122	4.13	2.89 - 5.37	W
			Mn-54	Bq/sample	4.524	5.84	4.09 - 7.59	A
			Sr-90	Bq/sample	1.01	1.39	0.97 - 1.81	W
	Zn-65	Bq/sample	4.706	6.38	4.47 - 8.29	W		

(a) The MAPEP known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) DOE/MAPEP evaluation:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

(1) False positive test

(2) Sensitivity evaluation

(3) See **NCR 20-13**

(4) See **NCR 20-20**

**ERA Environmental Radioactivity Cross Check Program  
Teledyne Brown Engineering Environmental Services**

**Table F-3**

Month/Year	Identification Number	Matrix	Nuclide	Units	TBE Value	Known Value <sup>(a)</sup>	Acceptance Limits	Evaluation <sup>(b)</sup>
March 2020	MRAD-32	Water	Am-241	pCi/L	52.5	45.3	31.1 - 57.9	A
			Fe-55	pCi/L	155	152	89.3 - 221	A
			Pu-238	pCi/L	34.0	36.4	21.9 - 47.2	A
			Pu-239	pCi/L	30.9	33.6	20.8 - 41.4	A
April 2020	RAD-121	Water	Ba-133	pCi/L	41.8	41.8	34.0 - 46.7	A
			Cs-134	pCi/L	42.9	46.3	37.1 - 50.9	A
			Cs-137	pCi/L	226	234	211 - 259	A
			Co-60	pCi/L	52.4	50.3	45.3 - 57.9	A
			Zn-65	pCi/L	83.3	86.8	78.1 - 104	A
			GR-A	pCi/L	20.1	23.6	11.9 - 31.6	A
			GR-B	pCi/L	45.6	60.5	41.7 - 67.2	A
			U-Nat	pCi/L	18.45	18.6	14.9 - 20.9	A
			H-3	pCi/L	14200	14100	12300 - 15500	A
			Sr-89	pCi/L	58.0	60.1	48.3 - 67.9	A
			Sr-90	pCi/L	34.1	44.7	33.0 - 51.2	A
			I-131	pCi/L	27.4	28.9	24.1 - 33.8	A
September 2020	MRAD-33	Soil	Sr-90	pCi/Kg	4360	4980	1550 - 7760	A
			AP					
		AP	Fe-55	pCi/Filter	189	407	149 - 649	A
			U-234	pCi/Filter	17.9	18.3	13.6 - 21.4	A
			U-238	pCi/Filter	19.1	18.1	13.7 - 21.6	A
		Water	Am-241	pCi/L	160	176	121 - 225	A
			Fe-55	pCi/L	299	298	175 - 433	A
			Pu-238	pCi/L	200	191	115 - 247	A
		Pu-239	pCi/L	105	100	61.9 - 123	A	
October 2020	RAD-123	Water	Ba-133	pCi/L	37.1	37.0	29.8 - 41.6	A
			Cs-134	pCi/L	50.6	52.7	42.5 - 58.0	A
			Cs-137	pCi/L	131	131	118 - 146	A
			Co-60	pCi/L	62.9	60.5	54.4 - 69.1	A
			Zn-65	pCi/L	167	162	146 - 191	A
			GR-A	pCi/L	40.0	26.2	13.3 - 34.7	N <sup>(1)</sup>
			GR-B	pCi/L	47.5	69.1	48.0 - 76.0	N <sup>(1)</sup>
			U-Nat	pCi/L	17.2	20.3	16.3 - 22.7	A
			H-3	pCi/L	23800	23200	20,300 - 25,500	A
			Sr-89	pCi/L	41.1	43.3	33.4 - 50.5	A
			Sr-90	pCi/L	28.5	30.2	22.0 - 35.0	A
			I-131	pCi/L	22.9	28.2	23.5 - 33.1	N <sup>(2)</sup>
November 2020	QR111920K	Water	GR-A	pCi/L	50.7	52.4	27.3 - 65.6	A
			GR-B	pCi/L	24.9	24.3	15.0 - 32.3	A

(a) The ERA known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.

(b) ERA evaluation:

A = Acceptable - Reported value falls within the Acceptance Limits

N = Not Acceptable - Reported value falls outside of the Acceptance Limits

(1) See **NCR 20-18**

(2) See **NCR 20-17**

TABLE F-4

**Analytics Environmental Radioactivity Cross Check Program  
Exelon Industrial Services (2020)**

Month/Year	Identification Number	Matrix	Nuclide	Units	EIS Reported Value	Known Value <sup>(a)</sup>	Ratio of Analytics to EIS Result	Evaluation <sup>(b)</sup>
June 2020	E13065 Detector 2	AP	Ce-141	pCi/Filter	71.5	75.5	95	Pass
			Co-58	pCi/Filter	60.7	65.4	93	Pass
			Co-60	pCi/Filter	125	127	98	Pass
			Cr-51	pCi/Filter	115	167	69	Pass
			Cs-134	pCi/Filter	82.9	95.2	87	Pass
			Cs-137	pCi/Filter	64.0	67.5	95	Pass
			Fe-59	pCi/Filter	65.8	65.7	100	Pass
			Mn-54	pCi/Filter	87.3	87.0	100	Pass
			Zn-65	pCi/Filter	136	146	93	Pass
	E13065 Detector 3	AP	Ce-141	pCi/Filter	68.0	75.5	90	Pass
			Co-58	pCi/Filter	67.3	65.4	103	Pass
			Co-60	pCi/Filter	125	127	99	Pass
			Cr-51	pCi/Filter	135	167	81	Pass
			Cs-134	pCi/Filter	83.9	95.2	88	Pass
			Cs-137	pCi/Filter	70.9	67.5	105	Pass
			Fe-59	pCi/Filter	72.4	65.7	110	Pass
			Mn-54	pCi/Filter	91.8	87.0	106	Pass
			Zn-65	pCi/Filter	154	146	106	Pass
	E13065 Detector 4	AP	Ce-141	pCi/Filter	82.8	75.5	110	Pass
			Co-58	pCi/Filter	55.0	65.4	84	Pass
			Co-60	pCi/Filter	124	127	98	Pass
			Cr-51	pCi/Filter	159	167	95	Pass
			Cs-134	pCi/Filter	75.8	95.2	80	Pass
			Cs-137	pCi/Filter	64.2	67.5	95	Pass
			Fe-59	pCi/Filter	82.9	65.7	126	Pass
			Mn-54	pCi/Filter	88.3	87.0	102	Pass
			Zn-65	pCi/Filter	153	146	105	Pass
	E13065 Detector 5	AP	Ce-141	pCi/Filter	79.4	75.5	105	Pass
			Co-58	pCi/Filter	62.1	65.4	95	Pass
			Co-60	pCi/Filter	136	127	107	Pass
			Cr-51	pCi/Filter	179	167	107	Pass
			Cs-134	pCi/Filter	81.4	95.2	86	Pass
			Cs-137	pCi/Filter	71.8	67.5	106	Pass
			Fe-59	pCi/Filter	71.7	65.7	109	Pass
			Mn-54	pCi/Filter	94.1	87.0	108	Pass
			Zn-65	pCi/Filter	152	146	104	Pass
June 2020	E13062 Detectors 2,3,4,5	AP	I-131	pCi/Filter	82.5	91.7	90	Pass
			I-131	pCi/Filter	87.6	91.7	96	Pass
			I-131	pCi/Filter	88.1	91.7	96	Pass
			I-131	pCi/Filter	86.2	91.7	94	Pass
	E13063	Water	Gr-B	pCi/L	273	272	100	Pass
	E13060 Detector 2	Milk	I-131	pCi/L	80.8	81.5	99	Pass
			Ce-141	pCi/L	107	116	92	Pass
			Co-58	pCi/L	107	100	107	Pass
			Co-60	pCi/L	200	195	103	Pass
			Cr-51	pCi/L	223	256	87	Pass
			Cs-134	pCi/L	142	146	97	Pass
			Cs-137	pCi/L	97.9	104	94	Pass
			Fe-59	pCi/L	96.0	101	95	Pass
	Mn-54	pCi/L	154	134	115	Pass		
	Zn-65	pCi/L	225	225	100	Pass		

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on EIS internal QC limits in accordance with the NRC Resolution Test criteria

**TABLE F-4 Analytics Environmental Radioactivity Cross Check Program  
Exelon Industrial Services (2020)**

Month/Year	Identification Number	Matrix	Nuclide	Units	EIS Reported Value	Known Value <sup>(a)</sup>	Ratio of Analytics to EIS Result	Evaluation <sup>(b)</sup>
	E13060 Detector 3	Milk	I-131	pCi/L	81.2	81.5	100	Pass
			Ce-141	pCi/L	106	116	91	Pass
			Co-58	pCi/L	101	100	101	Pass
			Co-60	pCi/L	195	195	100	Pass
			Cr-51	pCi/L	250	256	98	Pass
			Cs-134	pCi/L	131	146	90	Pass
			Cs-137	pCi/L	102	104	98	Pass
			Fe-59	pCi/L	99.1	101	98	Pass
			Mn-54	pCi/L	133	134	99	Pass
	Zn-65	pCi/L	189	225	84	Pass		
	E13060 Detector 4	Milk	I-131	pCi/L	71.4	81.5	88	Pass
			Ce-141	pCi/L	114	116	98	Pass
			Co-58	pCi/L	99.2	100	99	Pass
			Co-60	pCi/L	199	195	102	Pass
			Cr-51	pCi/L	251	256	98	Pass
			Cs-134	pCi/L	125	146	86	Pass
			Cs-137	pCi/L	98.9	104	95	Pass
			Fe-59	pCi/L	104	101	103	Pass
			Mn-54	pCi/L	124	134	92	Pass
	Zn-65	pCi/L	211	225	94	Pass		
	E13060 Detector 5	Milk	I-131	pCi/L	87.3	81.5	107	Pass
			Ce-141	pCi/L	118	116	102	Pass
			Co-58	pCi/L	94.9	100	95	Pass
			Co-60	pCi/L	181	195	93	Pass
			Cr-51	pCi/L	231	256	90	Pass
			Cs-134	pCi/L	128	146	88	Pass
			Cs-137	pCi/L	101	104	97	Pass
			Fe-59	pCi/L	106	101	105	Pass
			Mn-54	pCi/L	130	134	97	Pass
	Zn-65	pCi/L	200	225	89	Pass		
	E13064 Detector 2	Water	I-131	pCi/L	63.9	80.5	79	Pass
			Ce-141	pCi/L	116	117	99	Pass
			Co-58	pCi/L	91.4	102	90	Pass
			Co-60	pCi/L	201	198	101	Pass
			Cr-51	pCi/L	208	259	80	Pass
			Cs-134	pCi/L	150	148	101	Pass
			Cs-137	pCi/L	109	105	104	Pass
			Fe-59	pCi/L	116	102	114	Pass
			Mn-54	pCi/L	129	135	95	Pass
	Zn-65	pCi/L	218	227	96	Pass		
	E13064 Detector 4	Water	I-131	pCi/L	67.4	80.5	84	Pass
			Ce-141	pCi/L	126	117	107	Pass
			Co-58	pCi/L	100	102	98	Pass
			Co-60	pCi/L	204	198	103	Pass
			Cr-51	pCi/L	216	259	83	Pass
			Cs-134	pCi/L	150	148	102	Pass
			Cs-137	pCi/L	106	105	101	Pass
			Fe-59	pCi/L	119	102	116	Pass
			Mn-54	pCi/L	159	135	117	Pass
	Zn-65	pCi/L	211	227	93	Pass		

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on EIS internal QC limits in accordance with the NRC Resolution Test criteria

TABLE F-4

**Analytics Environmental Radioactivity Cross Check Program  
Exelon Industrial Services (2020)**

Month/Year	Identification Number	Matrix	Nuclide	Units	EIS Reported Value	Known Value <sup>(a)</sup>	Ratio of Analytics to EIS Result	Evaluation <sup>(b)</sup>		
	E13064	Water	I-131	pCi/L	90.2	80.5	112	Pass		
			Ce-141	pCi/L	119	117	102	Pass		
			Co-58	pCi/L	110	102	108	Pass		
			Co-60	pCi/L	188	198	95	Pass		
			Cr-51	pCi/L	229	259	89	Pass		
			Cs-134	pCi/L	141	148	95	Pass		
			Cs-137	pCi/L	105	105	100	Pass		
			Fe-59	pCi/L	106	102	104	Pass		
			Mn-54	pCi/L	150	135	111	Pass		
			Zn-65	pCi/L	221	227	97	Pass		
September 2020	E13066	AP	Gr-B	pCi	174	162	107	Pass		
			Gr-B	pCi	175	162	108	Pass		
December 2020	E13067 Detector 2	AP	Ce-141	pCi/Filter	77.1	78.4	98.3	Pass		
			Co-58	pCi/Filter	64.3	66.1	97.2	Pass		
			Co-60	pCi/Filter	117	119	98.3	Pass		
			Cr-51	pCi/Filter	184	199	92.3	Pass		
			Cs-134	pCi/Filter	79.3	84.5	93.8	Pass		
			Cs-137	pCi/Filter	92.3	99.9	92.4	Pass		
			Fe-59	pCi/Filter	101	87.9	115	Pass		
			Mn-54	pCi/Filter	109	112	97.5	Pass		
			Zn-65	pCi/Filter	105	149	70.6	Fail <sup>(1)</sup>		
December 2020	E13067 Detector 5	AP	Ce-141	pCi/Filter	83.9	78.4	107	Pass		
			Co-58	pCi/Filter	63.0	66.1	95.3	Pass		
			Co-60	pCi/Filter	124	119	104	Pass		
			Cr-51	pCi/Filter	197	199	98.9	Pass		
			Cs-134	pCi/Filter	72.2	85	85.5	Pass		
			Cs-137	pCi/Filter	95.0	99.9	95.1	Pass		
			Fe-59	pCi/Filter	111	87.9	126	Pass		
			Mn-54	pCi/Filter	125	112	112	Pass		
			Zn-65	pCi/Filter	111	149	74.7	Fail <sup>(1)</sup>		
December 2020	E13068	Water	Gr-B	pCi/L	300	277	108	Pass		
			E13070 Detector 2, 5	Cartridge	I-131	pCi	73.4	78.3	93.7	Pass
						pCi	79.4	78.3	101	Pass
			E13070	Milk	I-131	pCi/L	83.3	91.9	90.6	Pass
					Ce-141	pCi/L	106	100	106	Pass
					Co-58	pCi/L	72.7	84.3	86.3	Pass
					Co-60	pCi/L	150	152	98.8	Pass
					Cr-51	pCi/L	231	253	91.4	Pass
					Cs-134	pCi/L	89.6	108	83.0	Pass
					Cs-137	pCi/L	120	127	94.6	Pass
Fe-59	pCi/L	116			112	103	Pass			
Mn-54	pCi/L	146	143	102	Pass					
			Zn-65	pCi/L	135	190	71.2	Fail <sup>(1)</sup>		

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on EIS internal QC limits in accordance with the NRC Resolution Test criteria

(1) Failures caused by clerical error in calculation spreadsheet



TABLE F-5

**ERA Environmental Radioactivity Cross Check Program  
Exelon Industrial Services (2020)**

Month/Year	ID Number	Matrix	Nuclide	Units	EIS Reported Value	Known Value <sup>(a)</sup>	Acceptance Ratio of ERA to EIS Result	Evaluation <sup>(b)</sup>
April 2020	RAD-121	Water	Ba-133	pCi/L	40.1	41.8	96	Pass
			Cs-134	pCi/L	46.5	46.3	100	Pass
			Cs-137	pCi/L	225	234	96	Pass
			Co-60	pCi/L	50.7	50.3	101	Pass
			Zn-65	pCi/L	87.8	86.8	101	Pass
			I-131	pCi/L	29.7	28.9	103	Pass
			GR-B	pCi/L	43.3	60.5	72	Fail <sup>(2)</sup>
September 2020	MRAD-33	AP	Am-241	pCi/Filter	26.1	22.2	118	Pass
			Cs-134	pCi/Filter	270	296	91	Pass
			Cs-137	pCi/Filter	439	413	106	Pass
			Co-60	pCi/Filter	528	497	106	Pass
			Zn-65	pCi/Filter	528	500	106	Pass
October 2020	RAD-123 Detector 2	Water	Ba-133	pCi/L	33.3	37.0	90	Pass
			Cs-134	pCi/L	53.7	52.7	102	Pass
			Cs-137	pCi/L	136	131	104	Pass
			Co-60	pCi/L	68.8	60.6	114	Pass
			Zn-65	pCi/L	150	162	93	Pass
			I-131	pCi/L	27.5	28.2	97	Pass

(a) The ERA known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.

(b) ERA evaluation based on EIS internal QC limits in accordance with the NRC Resolution Test criteria

(2) Passed vendor acceptance criteria, but failed NRC Resolution Test criteria

TABLE F-6

**DOE's Mixed Analyte Performance Evaluation Program (MAPEP)**  
**GEL Laboratories (Gamma, Gross Alpha/Beta, H-3 & Sr-90)**

Quarter/Year	Identification Number	Matrix	Nuclide	Units	Reported Value	Known Value <sup>(a)</sup>	Acceptance Range	Evaluation <sup>(b)</sup>
2nd/2020	20-GrW42	Water	Gr-A	Bq/L	1.01	1.03	0.31 - 1.75	A
			Gr-B	Bq/L	4.18	4.24	2.12- 6.36	A
2nd/2020	20-MaW42	Water	H-3	Bq/L	193	196	137 - 255	A
			Sr-90	Bq/L	0.0122		False Positive Test	A
			Cs-134	Bq/L	17	18.5	13.0 - 24.1	A
			Cs-137	Bq/L	12	11.3	7.9 - 14.7	A
			Co-60	Bq/L	11	10.6	7.4 - 13.8	A
			Fe-55	Bq/L	18.2	17.8	12.5 - 23.1	A
			K-40	Bq/L	-0.0485		False Positive Test	A
			Mn-54	Bq/L	20.6	19.6	13.7 - 25.5	A
			Zn-65	Bq/L	23.9	22.2	15.5 - 28.9	A
			4th/2020	20-MaW43	Water	H-3	Bq/L	330
Sr-90	Bq/L	9.97				11.6	8.1 - 15.1	A
Cs-134	Bq/L	13.9				15.2	10.6 - 19.8	A
Cs-137	Bq/L	15.1				14.3	10.0 - 18.6	A
Co-60	Bq/L	12.9				12.2	8.5 - 15.9	A
Fe-55	Bq/L	29.2				32.9	23.0 - 42.8	A
K-40	Bq/L	-0.763					False Positive Test	A
Mn-54	Bq/L	-0.0032					False Positive Test	A
Zn-65	Bq/L	18.9				16.9	11.8 - 22	A

(a) The MAPEP known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) DOE/MAPEP evaluation:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

TABLE F-7

**ERA Environmental Radioactivity Cross Check Program  
GEL Laboratories (Gamma, Gross Alpha/Beta, H-3 & Sr-89/90)**

Quarter/Year	Identification Number	Matrix	Nuclide	Units	Reported Value	Known Value <sup>(a)</sup>	Acceptance Limits	Evaluation <sup>(b)</sup>		
1st/2020	RAD-120	Water	Cs-134	pCi/L	21.5	22.9	17.5 - 25.6	A		
			Cs-137	pCi/L	217	220	198 - 244	A		
			Co-60	pCi/L	97.7	91.2	82.1 - 103	A		
			I-131	pCi/L	23.7	29.9	24.9 - 34.9	N <sup>(1)</sup>		
			I-131	pCi/L	31.8	29.9	24.9 - 34.9	A		
			Zn-65	pCi/L	332	298	268 - 348	A		
			Gr-A	pCi/L	67.1	58.9	30.8 - 73.3	A		
			Gr-A	pCi/L	55.4	58.9	30.8 - 73.3	A		
			Gr-B	pCi/L	20.0	21.0	12.6 - 29.1	A		
			H-3	pCi/L	15,200	17,800	15,600 - 19,600	N <sup>(1)</sup>		
			H-3	pCi/L	17,700	17,800	15,600 - 19,600	A		
			Sr-89	pCi/L	73.3	59.3	47.6 - 67.1	N <sup>(1)</sup>		
			Sr-89	pCi/L	70.8	59.3	47.6 - 67.1	N <sup>(1)</sup>		
			Sr-90	pCi/L	38.3	36.5	26.8 - 42.1	A		
Sr-90	pCi/L	30.6	36.5	26.8 - 42.1	A					
2nd/2020	MRAD-32	Water	Cs-134	pCi/L	1,420	1,520	1,150 - 1,670	A		
			Cs-137	pCi/L	2,440	2,390	2,050 - 2,720	A		
			Co-60	pCi/L	2,890	2,760	2,380 - 3,170	A		
			Fe-55	pCi/L	140	152	89.3 - 221	A		
			Mn-54	pCi/L	<6.25	<100	<100	A		
			Zn-65	pCi/L	1,330	1,190	1,060 - 1,500	A		
			Sr-90	pCi/L	426	447	322 - 552	A		
			Gr-A	pCi/L	67.6	165	60.2 - 228	A		
			Gr-B	pCi/L	143	158	79.0 - 217	A		
			H-3	pCi/L	5,990	6,280	4,730 - 7,640	A		
			RAD-121	Water	I-131	pCi/L	27.5	28.9	24.1 - 33.8	A
					Sr-89	pCi/L	68.8	60.1	48.3 - 67.9	N <sup>(2)</sup>
					Sr-89	pCi/L	71.6	60.1	48.3 - 67.9	N <sup>(2)</sup>
					H-3	pCi/L	13,100	14,100	12,300 - 15,500	A
3rd/2020	RAD-122	Water	Cs-134	pCi/L	23.0	22.3	17.0 - 25.0	A		
			Cs-137	pCi/L	76.5	73.0	65.7 - 83.0	A		
			Co-60	pCi/L	97.9	86.1	77.5 - 97.0	N <sup>(3)</sup>		
			I-131	pCi/L	29.9	26.1	21.7 - 30.8	A		
			Zn-65	pCi/L	96.3	82.9	74.6 - 99.6	A		
			Gr-A	pCi/L	54.3	52.4	27.3 - 65.6	A		
			Gr-B	pCi/L	24.7	24.3	15.0 - 32.3	A		
			H-3	pCi/L	17,800	20,300	17,800 - 22,300	A		
			H-3	pCi/L	20,200	20,300	17,800 - 22,300	A		
			Sr-89	pCi/L	61.7	68.9	56.2 - 77.1	A		
			Sr-90	pCi/L	18.2	19.5	13.9 - 23.1	A		
4th/2020	MRAD-31	Water	Cs-134	pCi/L	849	911	688 - 1,000	A		
			Cs-137	pCi/L	1,540	1,510	1,290 - 1,720	A		
			Co-60	pCi/L	1,660	1,560	1,350 - 1,790	A		
			Fe-55	pCi/L	267	298	175 - 433	A		
			Mn-54	pCi/L	<4.61	<100	<100	A		
			Zn-65	pCi/L	1,010	917	816 - 1,160	A		
			Sr-90	pCi/L	917	787	567 - 973	A		
			Gr-A	pCi/L	100	111	40.5 - 153	A		
			Gr-B	pCi/L	181	194	97.0 - 267	A		
			H-3	pCi/L	11,600	12,000	9,040 - 14,600	A		

(a) The ERA known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.

(b) ERA evaluation: A = Acceptable - Reported value falls within the Acceptance Limits

N = Not Acceptable - Reported value falls outside of the Acceptance Limits

(1) CARR200224-1274

(2) No Information

(3) CARR200902-1287

TABLE F-8

**Analytics Environmental Radioactivity Cross Check Program  
GEL Laboratories (Gamma only)**

Quarter/Year	Identification Number	Matrix	Nuclide	Units	Reported Value	Known Value <sup>(a)</sup>	Acceptance Limits	Evaluation <sup>(b)</sup>
1st/2020	E13170	Water	Cs-134	pCi/L	153	154	0.99	A
			Cs-137	pCi/L	208	185	1.12	A
			Co-58	pCi/L	221	196	1.13	A
			Co-60	pCi/L	259	236	1.10	A
			Fe-59	pCi/L	179	168	1.06	A
			I-131	pCi/L	102	93	1.10	A
			Mn-54	pCi/L	248	216	1.15	A
			Zn-65	pCi/L	305	261	1.17	A
2nd/2020	E13174	Water	Cs-134	pCi/L	136	148	0.92	A
			Cs-137	pCi/L	104	105	0.99	A
			Co-58	pCi/L	105	102	1.03	A
			Co-60	pCi/L	205	198	1.04	A
			Fe-59	pCi/L	91	81	1.13	A
			I-131	pCi/L	105	102	1.03	A
			Mn-54	pCi/L	147	135	1.09	A
			Zn-65	pCi/L	249	227	1.10	A
3rd/2020	E13178	Water	Cs-134	pCi/L	181	201	0.90	A
			Cs-137	pCi/L	263	251	1.05	A
			Co-58	pCi/L	190	180	1.05	A
			Co-60	pCi/L	404	380	1.06	A
			Fe-59	pCi/L	226	201	1.12	A
			I-131	pCi/L	98	98	1.00	A
			Mn-54	pCi/L	206	181	1.14	A
			Zn-65	pCi/L	302	271	1.12	A
4th/2020	E13182	Water	Cs-134	pCi/L	114	114	1.00	A
			Cs-137	pCi/L	137	135	1.02	A
			Co-58	pCi/L	95.4	89.2	1.07	A
			Co-60	pCi/L	174	161	1.08	A
			Fe-59	pCi/L	137	119	1.16	A
			I-131	pCi/L	97	96	1.02	A
			Mn-54	pCi/L	165	151	1.09	A
			Zn-65	pCi/L	229	201	1.14	A

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.

(b) Analytics evaluation based on laboratory's internal acceptance criteria of 75% - 125%:

A = Acceptable - Reported value falls within the Acceptance Limits

N = Not Acceptable - Reported value falls outside of the Acceptance Limits

Intentionally left blank

## **APPENDIX G**

# **ANNUAL RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM REPORT (ARGPPR)**

Docket No: 50-277  
50-278

# **PEACH BOTTOM ATOMIC POWER STATION UNITS 2 and 3**

Annual Radiological Groundwater  
Protection Program Report (ARGPPR)

January 1 through December 31, 2020

**Prepared By**  
Teledyne Brown Engineering  
Environmental Services



Peach Bottom Atomic Power Station  
Delta, PA 17314

**May 2021**

## Table of Contents

I. Summary and Conclusions .....	1
II. Introduction.....	2
A. Objectives of the RGPP.....	2
B. Implementation of the Objectives .....	3
C. Program Description.....	3
D. Characteristics of Tritium.....	4
III. Program Description.....	5
A. Sample Analysis .....	5
B. Data Interpretation .....	5
C. Background Analysis.....	6
1. Background Concentrations of Tritium.....	6
IV. Results and Discussion .....	8
A. Groundwater Results .....	8
B. Surface Water Results.....	9
C. Precipitation Water Results .....	9
D. Drinking Water Well Survey.....	9
E. Summary of Results – Inter-laboratory Comparison Program.....	10
F. Leaks, Spills and Releases.....	10
G. Trends .....	10
H. Investigations.....	10
I. Actions Taken .....	12
J. Deviations.....	12
V. References .....	12



## Appendices

### Appendix A Sampling Locations, Distance and Direction

#### Tables

Table A-1 Radiological Groundwater Protection Program - Sampling Locations, Distance and Direction, Peach Bottom Atomic Power Station, 2020

#### Figures

Figure A-1 Well Water Locations, Peach Bottom Atomic Power Station, 2020

Figure A-2 RGPP Monitoring Locations, Peach Bottom Atomic Power Station, 2020

Figure A-3 RGPP Precipitation Monitoring Locations, Peach Bottom Atomic Power Station, 2020

### Appendix B Data Tables

#### Tables

Table B-I.1 Concentrations of Tritium, Strontium, Gross Alpha and Gross Beta in Groundwater and Seep Samples Collected as Part of the Radiological Groundwater Protection Program, Peach Bottom Atomic Power Station, 2020

Table B-I.2 Concentrations of Gamma Emitters in Groundwater and Seep Water Samples Collected as Part of the Radiological Groundwater Protection Program, Peach Bottom Atomic Power Station, 2020

Table B-I.3 Concentrations of Hard-to-Detects in Groundwater Samples Collected as Part of the Radiological Groundwater Protection Program, Peach Bottom Atomic Power Station, 2020

Table B-II.1 Concentrations of Tritium in Surface Water Samples Collected as Part of the Radiological Groundwater Protection Program, Peach Bottom Atomic Power Station, 2020

Table B-II.2 Concentrations of Gamma Emitters in Surface Water Samples Collected as Part of the Radiological Groundwater Protection Program, Peach Bottom Atomic Power Station, 2020

Table B-III.1 Concentrations of Tritium in Precipitation Water Samples Collected as Part of the Radiological Groundwater Protection Program, Peach Bottom Atomic Power Station, 2020

## I. Summary and Conclusions

This report on the Radiological Groundwater Protection Program (RGPP) conducted for the Peach Bottom Atomic Power Station (PBAPS) by Exelon Nuclear covers the period 01 January 2020 through 31 December 2020. This evaluation involved numerous station personnel and contractor support personnel. At PBAPS, there are 31 permanent groundwater monitoring wells. Installation of the wells began in 2006. Of these monitoring locations, none are assigned to the station's Radiological Environmental Monitoring Program (REMP). This report covers groundwater, surface water, seep water, and precipitation water samples collected from the environment on station property in 2020. During that time period, 312 analyses were performed on 185 samples from 46 locations. These 46 locations include 24 groundwater monitoring wells, 3 surface water sample points, 3 groundwater seeps, 2 yard drain sumps, and 14 precipitation water sampling points. Phase 1 of the monitoring was part of a comprehensive study initiated by Exelon to determine whether groundwater or surface water in the vicinity of PBAPS had been adversely impacted by any releases of radionuclides. Phase 1 was conducted by Conestoga Rovers and Associates (CRA) and the conclusions were made available to state and federal regulators as well as the public. Phase 2 of the RGPP was conducted by Exelon corporate and station personnel to initiate follow up of Phase 1 and begin long-term monitoring at groundwater and surface water locations selected during Phase 1. All analytical results from Phase 2 monitoring are reported herein.

Samples supporting the RGPP were analyzed for tritium (H-3), strontium-89 (Sr-89), strontium-90 (Sr-90), gross alpha, gross beta, gamma-emitting radionuclides associated with licensed plant operations and isotopes known as 'hard to detects'.

In assessing all the data gathered for this report, it was concluded that the operation of PBAPS had no adverse radiological impact on the environment and there are currently no known active releases into the groundwater at PBAPS.

Tritium was not detected in any groundwater sample greater than the United States Environmental Protection Agency (USEPA) drinking water standard (and the Nuclear Regulatory Commission [NRC] Reporting Limit) of 20,000 pCi/L.

Tritium was not detected at concentrations greater than the minimum detectable concentration (MDC) in any surface water or seep water sample locations. Based on the sample data, tritium is not migrating off the station property at detectable concentrations. Tritium was detected in 2 precipitation water sample locations but below the 20,000 pCi/L limit.

## II. Introduction

PBAPS is located along the Susquehanna River between Holtwood and Conowingo Dams in Peach Bottom Township, York County, Pennsylvania. The initial loading of fuel into Unit 1, a 40 MWe (net) high temperature gas-cooled reactor, began on 5 February 1966, and initial criticality was achieved on 3 March 1966. Shutdown of Peach Bottom Unit 1 for decommissioning was on 31 October 1974. For the purposes of the monitoring program, the beginning of the operational period for Unit 1 was considered to be 5 February 1966. A summary of the Unit 1 preoperational monitoring program was presented in a previous report <sup>(1)</sup>. PBAPS Units 2 and 3 are boiling water reactors, each with a power output of approximately 1385 MWe. The first fuel was loaded into Peach Bottom Unit 2 on 9 August 1973. Criticality was achieved on 16 September 1973 and full power was reached on 16 June 1974. The first fuel was loaded into Peach Bottom Unit 3 on 5 July 1974. Criticality was achieved on 7 August 1974 and full power was first reached on 21 December 1974. Preoperational summary reports <sup>(2)(3)</sup> for Units 2 and 3 have been previously issued and summarize the results of all analyses performed on samples collected from 5 February 1966 through 8 August 1973.

This report covers those analyses performed by Teledyne Brown Engineering (TBE) on samples collected in 2020.

### A. Objective of the RGPP

The objectives of the RGPP are as follows:

1. Ensure that the site characterization of geology and hydrology provides an understanding of predominant groundwater gradients based upon current site conditions.
2. Identify site risk based on plant design and work practices.
3. Establish an on-site groundwater monitoring program to ensure timely detection of inadvertent radiological releases to ground water.
4. Establish a remediation protocol to prevent migration of licensed material off-site and to minimize decommissioning impacts.
5. Ensure that records of leaks, spills, remediation efforts are retained and retrievable to meet the requirements of 10 CFR 50.75(g).
6. Conduct initial and periodic briefings of their site specific Groundwater Protection Initiative (GPI) program with the designated State/Local officials.
7. Make informal communication as soon as practicable to appropriate State/Local officials, with follow-up notifications to the NRC, as appropriate, regarding significant on-site leaks/spills into groundwater and on-site or off-site water sample results exceeding the criteria in the REMP as described in the Offsite Dose Calculation Manual (ODCM).

8. Submit a written 30-day report to the NRC for any water sample result for on-site groundwater that is or may be used as a source of drinking water that exceeds any of the criteria in the licensee's existing REMP/ODCM for 30-day reporting of off-site water sample results.
9. Document all on-site groundwater sample results and a description of any significant on-site leaks/spills into groundwater for each calendar year in the Annual Radiological Environmental Operating Report (AREOR) for REMP or the Annual Radioactive Effluent Release Report (ARERR).
10. Perform a self-assessment of the GPI program.
11. Conduct a review of the GPI program, including at a minimum the licensee's self-assessments, under the auspices of the Nuclear Energy Institute (NEI).

B. Implementation of the Objectives

The objectives identified have been implemented at PBAPS via Exelon Corporate and Site specific procedures. These procedures include:

1. EN-AA-407, Response to Inadvertent Releases of Licensed Materials to Groundwater, Surface Water, Soil or Engineered Structures
2. EN-AA-408, Radiological Groundwater Protection Program
3. EN-AA-408-4000, Radiological Groundwater Protection Program Implementation
4. EN-PB-408-4160, RGPP Reference Material for Peach Bottom Atomic Power Station

C. Program Description

1. Sample Collection

Sample locations can be found in Table A-1 and Figures A-1, A-2 and A-3, Appendix A.

Groundwater, Surface Water and Precipitation Water

Samples of water are collected, managed, transported and analyzed in accordance with approved procedures. Sample locations, sample collection frequencies and analytical frequencies are controlled in accordance with approved station procedures. Contractor and/or station personnel are trained in the collection, preservation management and shipment of samples, as well as in documentation of sampling events. Analytical laboratories are subject to internal quality assurance programs, industry cross-check programs, as well as nuclear industry audits. Station personnel review and evaluate all analytical data deliverables as data are received.

Analytical data results are reviewed by both station personnel and an independent hydro geologist for adverse trends or changes to hydrogeologic conditions.

D. Characteristics of Tritium

Tritium is a radioactive isotope of hydrogen. The most common form of tritium is tritium oxide, which is also called "tritiated water." The chemical properties of tritium are essentially those of ordinary hydrogen.

Tritiated water behaves the same as ordinary water in both the environment and the body. Tritium can be taken into the body by drinking water, breathing air, eating food or absorption through skin. Once tritium enters the body it disperses quickly and is uniformly distributed throughout the body. Tritium is excreted primarily through urine with a clearance rate characterized by an effective biological half-life of about 14 days. Within one month or so after ingestion essentially all tritium is cleared. Organically bound tritium (tritium that is incorporated in organic compounds) can remain in the body for a longer period.

Tritium is produced naturally in the upper atmosphere when cosmic rays strike air molecules. Tritium is also produced during nuclear weapons explosions, as a by-product in reactors producing electricity and in special production reactors, where the isotopes lithium-7 (Li-7) and/or boron-10 (B-10) are activated to produce tritium. Like normal water, tritiated water is colorless and odorless. Tritiated water behaves chemically and physically like non-tritiated water in the subsurface and therefore tritiated water will travel at the same velocity as the average groundwater velocity.

Tritium has a half-life of approximately 12.3 years. It decays spontaneously to helium-3 (He-3). This radioactive decay releases a beta particle (low-energy electron). The radioactive decay of tritium is the source of the health risk from exposure to tritium. Tritium emits a low energy beta particle and leaves the body relatively quickly. Since tritium is almost always found as water, it goes directly into soft tissues and organs. The associated dose to these tissues is generally uniform and is dependent on the water content of the specific tissue.

### III. Program Description

#### A. Sample Analysis

This section describes the general analytical methodologies used by TBE, Exelon Industrial Services (EIS) and GEL Laboratories (GEL) to analyze the environmental samples for radioactivity for the PBAPS RGPP in 2020.

In order to achieve the stated objectives, the current program includes the following analyses:

1. Concentrations of gamma emitters in groundwater and surface water.
2. Concentrations of strontium in groundwater.
3. Concentrations of tritium in groundwater, surface water and precipitation water.
4. Concentrations of 'hard-to-detect' isotopes, americium-241 (Am-241), cerium-242/243/244 (Cm-242, Cm-243, Cm-244), plutonium-238/239/240 (Pu-238, Pu-239, Pu-240), uranium-233/234/235/238 (U-233, U-234, U-235, U-238), iron-55 (Fe-55), and nickel-63 (Ni-63) in groundwater. These analyses are required based on tritium results.

#### B. Data Interpretation

The radiological data collected prior to PBAPS becoming operational were used as a baseline for operational data comparison. For the purpose of this report, PBAPS was considered operational at initial criticality. Several factors were important in the interpretation of the data:

1. Lower Limit of Detection

The lower limit of detection (LLD) is a minimum sensitivity value that must be achieved routinely by the analytical parameter.

2. Laboratory Measurements Uncertainty

The estimated uncertainty in measurement of tritium in environmental samples is frequently on the order of 50% of the measurement value.

Statistically, the exact value of a measurement is expressed as a range with a stated level of confidence. The convention is to report results with a 95% level of confidence. The uncertainty comes from factors such as calibration standards, sample volume or weight measurements, and sampling uncertainty. Exelon reports the uncertainty of a measurement created by statistical process (counting error) as well as all sources of error (Total Propagated Uncertainty or TPU). Each result has two values calculated. Exelon reports the TPU by following the result with plus or minus ( $\pm$ ) the estimated sample standard deviation.

Analytical uncertainties are reported at the 95% confidence level in this

report for reporting consistency with the AREOR.

Gamma spectroscopy results for each type of sample were grouped as follows:

For groundwater and surface water 12 nuclides, Mn-54, Co-58, Co-60, Fe-59, Zn-65, Nb-95, Zr-95, I-131, Cs-134, Cs-137, Ba-140 and La-140 were measured.

### C. Background Analysis

A pre-operational REMP was conducted to establish background radioactivity levels prior to operation of the Station. The environmental media sampled and analyzed during the pre-operational REMP were atmospheric radiation, fall-out, domestic water, surface water, marine life and foodstuffs. The results of the monitoring were detailed in References 2 and 3. The pre-operational REMP contained analytical results from samples collected from the surface water, discharge, well water and rainwater.

#### 1. Background Concentrations of Tritium

The purpose of the following discussion is to summarize background measurements of tritium in various media performed by others. Additional detail may be found by consulting references (CRA 2006)<sup>(1)</sup>.

##### a. Tritium Production

Tritium is created in the environment from naturally occurring processes both cosmic and subterranean, as well as from anthropogenic (i.e., man-made) sources. In the upper atmosphere, "Cosmogenic" tritium is produced from the bombardment of stable nuclides and combines with oxygen to form tritiated water, which will then enter the hydrologic cycle. Below ground, "lithogenic" tritium is produced by the bombardment of natural Li present in crystalline rocks by neutrons produced by the radioactive decay of naturally abundant U and Th. Lithogenic production of tritium is usually negligible compared to other sources due to the limited abundance of Li in rock. The lithogenic tritium is introduced directly to groundwater.

A major anthropogenic source of tritium and Sr-90 comes from the former atmospheric testing of thermonuclear weapons. Levels of tritium in precipitation increased significantly during the 1950s and early 1960s and later with additional testing, resulting in the release of significant amounts of tritium to the atmosphere. The Canadian heavy water nuclear power reactors, other commercial power reactors, nuclear research and weapons production continue to influence tritium concentrations in the environment.

b. Precipitation Data

Precipitation monitoring was done at PBAPS until 2006. These types of samples are routinely collected at stations around the world for the analysis of tritium and other radionuclides. Two publicly available databases that provide tritium concentrations in precipitation are Global Network of Isotopes in Precipitation (GNIP) and USEPA's RadNet database. GNIP provides tritium precipitation concentration data for samples collected worldwide from 1960 to 2006. RadNet provides tritium precipitation concentration data for samples collected at stations throughout the U.S. from 1960 up to and including 2006. Based on GNIP data for sample stations located in the U.S. Midwest, tritium concentrations peaked around 1963. This peak, which approached 10,000 pCi/L for some stations, coincided with the atmospheric testing of thermonuclear weapons. Tritium concentrations in surface water showed a sharp decline until 1975. A gradual decline has followed since that time. Tritium concentrations have typically been below 100 pCi/L since around 1980. Tritium concentrations in wells may still be above the 200 pCi/L detection limit from the external causes described above. Water from previous years and decades is naturally captured in groundwater, so some well water sources today are affected by the surface water from the 1960s that was elevated in tritium.

c. Surface Water Data

Surface water level measurements were collected at the surface water monitoring locations during the groundwater level measurement event. The purpose of the surface water monitoring was to provide surface water elevation data to evaluate the groundwater/surface water interaction at the Station.

The USEPA RadNet surface water data typically has a reported 'Combined Standard Uncertainty' of 35 to 50 pCi/L. According to USEPA, this corresponds to a  $\pm 70$  to 100 pCi/L 95% confidence bound on each given measurement. Therefore, the typical background data provided may be subject to measurement uncertainty of approximately  $\pm 70$  to 100 pCi/L.

The radio-analytical laboratory is counting tritium results to an Exelon-specified LLD of 200 pCi/L. Typically, the lowest positive measurement will be reported within a range of 40 – 240 pCi/L or  $140 \pm 100$  pCi/L. Clearly, these sample results cannot be distinguished as different from background at this concentration.



#### IV. Results and Discussion

##### A. Groundwater Results

Groundwater samples were collected from on-site wells throughout the year in accordance with the station RGPP. Analytical results and anomalies are discussed below:

##### Tritium

Samples from 26 locations were analyzed for tritium activity. These locations include 24 wells and the 2 yard drains sampled during the quarterly sampling events as part of the RGPP program. Tritium was not detected in wells at or near the owner-controlled boundary. The location most representative of potential offsite user of drinking water is less than the MDC.

Low levels of tritium were detected at concentrations greater than the minimum detectable concentration (MDC) in 11 of the 26 locations (24 groundwater monitoring wells and the 2 yard drain locations). The tritium concentrations ranged from the detection limit to 12,800 pCi/L. (Table B-I.1, Appendix B)

##### Strontium

Sr-89 and Sr-90 were not detected in any of the samples. (Table B-I.1, Appendix B)

##### Gross Alpha (dissolved and suspended)

Gross Alpha analyses in the dissolved and suspended fractions were performed on 15 groundwater samples during 2020. Fifteen (15) groundwater locations refer to the 13 wells and the 2 yard drains sampled during the quarterly sampling events as part of the RGPP program.

Gross Alpha (dissolved) was detected in 3 of 15 groundwater locations analyzed. The concentrations ranged from 1.2 to 5.8 pCi/L.

Gross Alpha (suspended) was detected in 5 of 15 groundwater locations analyzed. The concentrations ranged from 1.3 to 5.4 pCi/L.

The activity detected is consistent with historical levels. The activity detected is naturally occurring and the levels are considered to be background. (Table B-I.1, Appendix B)

##### Hard-To-Detect

Hard-To-Detect analyses were performed on one groundwater location. The analyses included Am-241, Cm-242, Cm-243/244, Pu-238, Pu-239/240, U-234, U-235, U-238, Fe-55 and Ni-63.

U-234 was detected in the one location at a concentration of 0.23 pCi/L. The activity detected is naturally occurring and the levels are considered to be background. All other Hard-To-Detect analyses were less than the MDC. (Table B–I.3, Appendix B)

#### Gamma Emitters

No power-production gamma emitters were detected in any of the samples. (Table B–I.2, Appendix B)

### B. Surface Water Results

Surface Water samples were collected from six surface water locations throughout the year in accordance with the station RGPP. Analytical results are discussed below:

#### Tritium

Samples from six locations were analyzed for tritium activity. Tritium was not detected in any surface water locations greater than the MDC. (Table B–II.1, Appendix B)

#### Gamma Emitters

Samples from two locations were analyzed for gamma emitters. No gamma emitters were detected in any of the samples. (Table B–II.2, Appendix B).

### C. Precipitation Water Results

Samples were collected at fourteen locations (1A, 1B, 1S, 1SSE, 1Z, 4M, PB-P1, PB-P2, PB-P3, PB-P4, PB-P5, PB-P6, PB-P7, and PB-P8) in accordance with the station RGPP. The following analysis was performed:

#### Tritium

Samples from fourteen locations were analyzed for tritium activity. Tritium activity was detected in two locations greater than the MDC. The concentrations ranged from 400 to 518 pCi/L. (Table B–III.1, Appendix B)

### D. Drinking Water Well Survey

A drinking water well survey was conducted during the summer 2006 by CRA (CRA 2006)<sup>(1)</sup> around PBAPS. The water well inventory was updated in 2012<sup>(4)</sup>. The updated water well database search indicated a new water well off Station property within a one mile radius of the Station. The well is described as a “test” well and its use is listed as “unused”. In summary, there were no significant changes in off Station groundwater use from 2006-2012.

E. Summary of Results – Inter-Laboratory Comparison Program

Inter-Laboratory Comparison Program results for TBE and GEL are presented in the AREOR.

F. Leaks, Spills and Releases

There were no inadvertent leaks, spills or releases of water containing licensed material to the environment in 2020.

G. Trends

A tritium plume has been identified northeast of the Unit 3 Turbine Building. The plume extends eastward toward well MW-PB-4. The plume is bounded on the north by wells MW-PB-12 and MW-PB-22. The plume is bounded on the south by wells MW-PB-20 and MW-PB-21.

The tritium plume is a result of licensed material entering the groundwater through degraded floor seams and penetration seals in the Unit 3 Turbine Building. The activity currently detected in the Unit 3 Turbine Building monitoring wells, MW-PB-24, 25, 26 and 27, is the result of legacy licensed material under the turbine building being transported eastward by natural hydrogeologic groundwater flow.

Tritium activity in the Unit 3 Turbine Building monitoring wells are trended. Any adverse trend is captured in the Station's Corrective Action Program.

H. Investigations

MW-PB-4

In 2006, monitoring wells MW-PB-1 through MW-PB-14 were installed. Tritium activity was detected in MW-PB-4, located north of the Unit 3 Circulating Water Pump Structure and MW-PB-12, north of the Administration Building. Groundwater flow on site is from west to east. Monitoring wells were installed to the west, southwest and northwest of monitoring wells MW-PB-4 and MW-PB-12. The wells with the highest tritium activity are the wells installed directly east of and adjacent to the Unit 3 Turbine Building, wells MW-PB-24, 25, 26 and 27.

Investigation of potential sources identified that the likely source of groundwater contamination was due to degraded floor seams in the Unit 3 Turbine Building Moisture Separator area 116' elevation. Leaks internal to the building entered the groundwater through the degraded floor seams. The floor seams were repaired in August 2010. The floor in the Unit 3 Turbine Building Moisture Separator area 116' elevation was sealed and recoated in October 2011.

MW-PB-29, 30 and 31

An extent-of-condition inspection of the Unit 2 Turbine Building Moisture Separator area 116' elevation floor was performed in October 2010. Minor

degradation of the floor seams was identified and repaired. In May 2011, monitoring wells MW-PB-29 and 30 were installed directly east of and adjacent to the Unit 2 Turbine Building; MW-PB-31 was installed southeast of and adjacent to the Unit 2 Turbine Building. These wells were installed to determine if a condition existed east of the Unit 2 Turbine Building that is similar to the condition east of the Unit 3 Turbine Building.

Tritium activity in these wells ranged from less than the MDC to 2,720 pCi/L. Samples from these wells were also analyzed for gamma-emitting isotopes and hard-to-detect radionuclides. All results are less than the MDC for each isotope.

The Unit 2 Turbine Building Moisture Separator floor 116' elevation floor was sealed and recoated in October 2012. Groundwater intrusion into a ventilation pit on the east side of the area was identified. The groundwater was removed and degraded seams in the ventilation pit were successfully repaired.

MW-PB-24, 25, 26 and 27

Wells MW-PB-24, 25, 26 and 27 are considered the wells of primary interest. These wells were sampled on a frequency ranging from weekly to quarterly. Below are 3 tables. The first lists the highest tritium activity of the wells of primary interest and the date of the sampling. The second table lists the highest tritium activity of the wells during 2020. The third table lists the activity of the wells from the last sampling of 2020. The tritium activity is in pCi/L.

Well #	Tritium Activity	Date
MW-PB-24	1,530	06/06/2018
MW-PB-25	161,000	03/08/2010
MW-PB-26	196,000	03/08/2010
MW-PB-27	71,800	2/22/2010

Well #	Tritium Activity	Date
MW-PB-24	681	01/16/2020
MW-PB-25	12,800	02/28/2020
MW-PB-26	306	09/17/2020
MW-PB-27	507	09/15/2020

Well #	Tritium Activity	Date
MW-PB-24	267	12/10/2020
MW-PB-25	7,970	12/10/2020
MW-PB-26	245	12/10/2020
MW-PB-27	357	12/10/2020

Potential sources of tritium in the groundwater are investigated via procedural processes and documented in the corrective action program.

The most likely pathway for tritium to enter the groundwater has been determined to be leaks internal to the Unit 3 Turbine Building Moisture Separator 116', migrating through degraded floor seams or other unidentified openings in the floor.

I. Actions Taken

1. The Unit 3 Condensate storage tank moat, sump and valve pit were cleaned and recoated to eliminate a potential pathway for licensed material to enter the groundwater. These activities were completed under work order 04602739 and work request 01339203.
2. During P3R21, the Unit 3 Recombiner Jet Compressor room floor drains were found plugged. One plug was removed, and the second plug was modified to allow water to drain to the radwaste system in the event of a licensed material leak. This was completed under work request 01369404.
3. Installation of Monitoring Wells  
No groundwater monitoring wells were installed in 2020.
4. Actions to Recover/Reverse Plumes  
There were no actions to recover the plume.

J. Deviations

The data tables show that duplicate samples were obtained at several wells during 2020. These duplicate samples were obtained and analyzed for quality control purposes.

An exception was made, per Exelon, due to the COVID-19 pandemic. The quarterly sampling was waived for the 2<sup>nd</sup> quarter of 2020.

V. References

1. Conestoga Rovers and Associates, Fleetwide Assessment, Peach Bottom Atomic Power Station, Delta, PA, Fleetwide Assessment, Rev. 1, September 1, 2006.
2. Peach Bottom Atomic Power Station (PBAPS), Environs Radiation Monitoring Program, Preoperational Summary Report Units 2 and 3, June 1977.
3. Peach Bottom Atomic Power Station (PBAPS), Environs Radiation Monitoring Program, Preoperational Summary Report Units 2 and 3, September 1970-August 1973, January 1974.
4. Conestoga Rovers and Associates, Hydrogeologic Investigation Report, Peach Bottom Atomic Power Station, November 2012.
5. AMO Environmental Decisions, 2020 RGPP Summary Monitoring Reports, April 2020, August 2020, October 2020 and February 2020.

## **APPENDIX A**


### **SAMPLING LOCATIONS, DISTANCE AND DIRECTION**

Intentionally left blank

TABLE A-1: Radiological Groundwater Protection Program - Sampling Locations, Distance and Direction, Peach Bottom Atomic Power Station, 2020

Site	Site Type	Sector	Distance (ft.)
MW-PB-1	Groundwater Well	SW	1,166.6
MW-PB-2	Groundwater Well	WNW	309.0
MW-PB-3	Groundwater Well	SSE	709.7
MW-PB-4	Groundwater Well	ENE	350.2
MW-PB-5	Groundwater Well	NNW	1,146.1
MW-PB-6	Groundwater Well	NE	1,072.4
MW-PB-7	Groundwater Well	SE	813.9
MW-PB-8	Groundwater Well	SE	1,167.0
MW-PB-10	Groundwater Well	SSE	1,125.1
MW-PB-12	Groundwater Well	NNE	317.2
MW-PB-13	Groundwater Well	NW	329.4
MW-PB-15	Groundwater Well	SE	1,087.9
MW-PB-16	Groundwater Well	SE	1,101.6
MW-PB-18	Groundwater Well	SE	1,010.0
MW-PB-19	Groundwater Well	NW	226.8
MW-PB-20	Groundwater Well	E	260.5
MW-PB-22	Groundwater Well	NE	315.4
MW-PB-23	Groundwater Well	NW	249.6
MW-PB-24	Groundwater Well	N	185.9
MW-PB-25	Groundwater Well	N	159.7
MW-PB-26	Groundwater Well	NNE	121.1
MW-PB-27	Groundwater Well	NNE	139.1
MW-PB-28	Groundwater Well	NW	249.6
MW-PB-29	Groundwater Well	SE	325.0
MW-PB-30	Groundwater Well	SE	379.2
MW-PB-31	Groundwater Well	SE	450.1
SW-PB-1	Surface Water	NNW	2,850.5
SP-PB-1	Groundwater Seep	S	514.2
SP-PB-2	Groundwater Seep	WNW	311.6
SP-PB-3	Groundwater Seep	NNW	1,281.1
SW-PB-5	Surface Water	SE	675.1
SW-PB-6	Surface Water	SE	1,305.9
U/2 YARD DRAIN SUMP	Groundwater	SSE	498.7
U/3 YARD DRAIN SUMP	Groundwater	WSW	175.8
1A	Precipitation Water	ESE	1,271
1B	Precipitation Water	NW	2,587
1S	Precipitation Water	S	1,315
1SSE	Precipitation Water	SSE	1,312
1Z	Precipitation Water	SE	1,763
4M	Precipitation Water	SE	45,989
PB-P1	Precipitation Water		
PB-P2	Precipitation Water		
PB-P3	Precipitation Water		
PB-P4	Precipitation Water		
PB-P5	Precipitation Water		
PB-P6	Precipitation Water		
PB-P7	Precipitation Water		
PB-P8	Precipitation Water		





53539-12(005)GN-WA008 NOV 6/2012

Figure A-1  
Well Water Locations, Peach Bottom Atomic Power Station, 2020





Figure A-2  
 RGPP Monitoring Locations  
 Peach Bottom Atomic Power Station, 2020  
 A-3



Explanation:  
 ⊕ Groundwater Sample Location  
 ● Surface Water Sample Location

Figure 1a  
 RGPP Monitoring Locations  
 Surface Water and Overburden Aquifer  
 Exelon Corporation  
 Peach Bottom Generating Station

Figure A-3  
 RGPP Precipitation Monitoring Locations  
 Peach Bottom Atomic Power Station, 2020  
 A-4

## **APPENDIX B**

### **DATA TABLES**

Intentionally left blank

**TABLE B-1.1 CONCENTRATIONS OF TRITIUM, STRONTIUM AND GROSS ALPHA IN GROUNDWATER AND SEEP SAMPLES COLLECTED AS PART OF THE RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM, PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

SITE	COLLECTION		H-3	Sr-89	Sr-90	Gr-A (Dis)	Gr-A (Sus)
	DATE						
MW-PB-1	08/06/20		< 192				
MW-PB-1	08/06/20	DUP	< 198				
MW-PB-1	08/06/20	GEL	< 151				
MW-PB-2	02/18/20		< 183				
MW-PB-2	08/03/20		< 181				
MW-PB-3	02/18/20		< 180				
MW-PB-3	02/18/20	DUP	< 181				
MW-PB-3	02/18/20	GEL	< 189				
MW-PB-3	08/05/20		< 182				
MW-PB-4	02/18/20		< 182				
MW-PB-4	08/03/20		< 177				
MW-PB-5	08/06/20		< 195				
MW-PB-5	08/06/20	DUP	< 194				
MW-PB-5	08/06/20	GEL	< 144				
MW-PB-6	08/20/20		< 173				
MW-PB-7	02/19/20		< 178				
MW-PB-7	08/06/20		< 192				
MW-PB-7	08/06/20	DUP	< 178				
MW-PB-7	08/06/20	GEL	< 150				
MW-PB-8	02/19/20		< 181				
MW-PB-8	08/06/20		< 194	< 6.7	< 0.8	< 1.1	< 0.8
MW-PB-8	12/08/20		< 189				
MW-PB-8	12/08/20	DUP	< 191				
MW-PB-8	12/08/20	GEL	< 166				
MW-PB-10	02/19/20		< 180				
MW-PB-10	08/06/20		< 196	< 7.8	< 0.7	< 0.6	5.4 ± 1.5
MW-PB-10	12/08/20		< 186				
MW-PB-12	02/19/20		< 186				
MW-PB-12	02/19/20	DUP	< 185				
MW-PB-12	02/19/20	NP	< 180				
MW-PB-12	02/19/20	GEL	< 191				
MW-PB-12	08/03/20		< 181				
MW-PB-13	02/19/20		< 184				
MW-PB-13	08/03/20		< 180				
MW-PB-15	02/19/20		< 181				
MW-PB-15	08/06/20		< 177	< 8.1	< 0.7	< 1.3	< 1.1
MW-PB-15	12/08/20		< 191				
MW-PB-15	12/08/20	DUP	< 184				
MW-PB-15	12/08/20	GEL	< 169				
MW-PB-16	02/19/20		< 177				
MW-PB-16	08/06/20		< 193	< 5.9	< 0.6	5.8 ± 1.2	< 1.1
MW-PB-16	12/08/20		< 190				
MW-PB-19	02/18/20		< 179				
MW-PB-19	08/03/20		< 179	< 5.7	< 0.7	< 0.5	< 0.7
MW-PB-19	12/10/20		< 187				
MW-PB-20	02/18/20		< 180				
MW-PB-20	02/18/20	NP	< 177				
MW-PB-20	08/03/20		< 180	< 4.7	< 0.8	< 0.9	4.1 ± 1.7
MW-PB-20	12/10/20		< 188				
MW-PB-22	02/18/20		238 ± 120				
MW-PB-22	02/18/20	NP	315 ± 122				
MW-PB-22	08/03/20		295 ± 123				
MW-PB-24	01/16/20		681 ± 146				
MW-PB-24	02/18/20		602 ± 139				
MW-PB-24	02/18/20	NP	677 ± 137				

**TABLE B-1.1 CONCENTRATIONS OF TRITIUM, STRONTIUM AND GROSS ALPHA IN GROUNDWATER AND SEEP SAMPLES COLLECTED AS PART OF THE RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM, PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

SITE	COLLECTION DATE		H-3	Sr-89	Sr-90	Gr-A (Dis)	Gr-A (Sus)
MW-PB-24	03/19/20		267 ± 127				
MW-PB-24	04/15/20		< 195				
MW-PB-24	05/19/20		301 ± 122				
MW-PB-24	06/23/20		434 ± 132				
MW-PB-24	07/28/20		436 ± 144				
MW-PB-24	08/05/20		384 ± 136				
MW-PB-24	09/15/20		492 ± 132				
MW-PB-24	10/29/20		< 184				
MW-PB-24	11/18/20		< 175				
MW-PB-24	12/10/20		267 ± 129				
MW-PB-25	01/16/20		12400 ± 1290				
MW-PB-25	02/18/20		12800 ± 1330				
MW-PB-25	02/18/20	NP	11300 ± 1180				
MW-PB-25	03/19/20		2470 ± 311				
MW-PB-25	04/15/20		6940 ± 757				
MW-PB-25	05/19/20		12300 ± 1280				
MW-PB-25	06/23/20		10200 ± 1070				
MW-PB-25	07/28/20		12300 ± 1290				
MW-PB-25	08/05/20		839 ± 159	< 5.3	< 0.8	< 0.7	< 1.1
MW-PB-25	09/17/20		1300 ± 197				
MW-PB-25	10/29/20		6600 ± 718				
MW-PB-25	11/18/20		7690 ± 829				
MW-PB-25	12/10/20		7970 ± 855				
MW-PB-26	01/16/20		226 ± 129				
MW-PB-26	02/18/20		< 183				
MW-PB-26	02/18/20	NP	< 181				
MW-PB-26	03/19/20		214 ± 122				
MW-PB-26	04/15/20		< 188				
MW-PB-26	05/19/20		< 176				
MW-PB-26	06/23/20		< 181				
MW-PB-26	07/28/20		292 ± 135				
MW-PB-26	08/05/20		< 199	< 7.1	< 0.6	1.2 ± 0.8	< 1.1
MW-PB-26	09/17/20		306 ± 122				
MW-PB-26	10/29/20		211 ± 122				
MW-PB-26	11/18/20		< 175				
MW-PB-26	12/10/20		245 ± 127				
MW-PB-27	01/16/20		391 ± 134				
MW-PB-27	02/18/20		377 ± 129				
MW-PB-27	02/18/20	NP	323 ± 117				
MW-PB-27	03/19/20		369 ± 127				
MW-PB-27	04/15/20		< 192				
MW-PB-27	05/19/20		379 ± 124				
MW-PB-27	06/23/20		350 ± 126				
MW-PB-27	07/28/20		463 ± 142				
MW-PB-27	08/05/20		401 ± 139	< 7.1	< 0.7	2.3 ± 0.8	1.7 ± 0.8
MW-PB-27	09/15/20		507 ± 131				
MW-PB-27	10/29/20		339 ± 131				
MW-PB-27	11/18/20		226 ± 115				
MW-PB-27	12/10/20		357 ± 131				
MW-PB-28	02/18/20		1260 ± 196				
MW-PB-28	02/18/20	NP	943 ± 161				
MW-PB-28	08/03/20		190 ± 118	< 6.8	< 0.9	< 1.8	< 1.0
MW-PB-28	12/10/20		1540 ± 226				
MW-PB-28	12/10/20	R1	1670 ± 235				
MW-PB-29	02/18/20		350 ± 126				

**TABLE B-I.1 CONCENTRATIONS OF TRITIUM, STRONTIUM AND GROSS ALPHA IN GROUNDWATER AND SEEP SAMPLES COLLECTED AS PART OF THE RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM, PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

SITE	COLLECTION DATE		H-3	Sr-89	Sr-90	Gr-A (Dis)	Gr-A (Sus)
MW-PB-29	02/18/20	<i>NP</i>	335 ± 125				
MW-PB-29	08/05/20		532 ± 147	< 6.1	< 0.7	< 0.5	< 0.9
MW-PB-29	12/10/20		240 ± 124				
MW-PB-30	02/18/20		< 179				
MW-PB-30	02/18/20	<i>NP</i>	175 ± 111				
MW-PB-30	08/05/20		487 ± 143	< 6.2	< 0.7	< 0.5	1.8 ± 0.9
MW-PB-30	12/10/20		223 ± 123				
MW-PB-31	02/18/20		< 183				
MW-PB-31	08/05/20		315 ± 134	< 7.9	< 0.8	< 0.6	1.3 ± 0.8
MW-PB-31	12/10/20		< 186				
U/2 YARD DRAIN	03/12/20		< 194				
U/2 YARD DRAIN	08/19/20		237 ± 124	< 7.3	< 0.8	< 0.4	< 0.9
U/2 YARD DRAIN	12/11/20		364 ± 133				
U/3 YARD DRAIN	03/12/20		315 ± 131				
U/3 YARD DRAIN	08/19/20		< 178	< 9.4	< 0.8	< 0.2	< 0.9
U/3 YARD DRAIN	12/09/20		1670 ± 242				



**TABLE B-1.2 CONCENTRATIONS OF GAMMA EMITTERS IN GROUNDWATER AND SEEP WATER SAMPLES COLLECTED AS PART OF THE RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM, PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

SITE	COLLECTION		Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	I-131	Cs-134	Cs-137	Ba-140	La-140
	DATE													
MW-PB-1	08/06/20		< 2	< 2	< 5	< 2	< 5	< 3	< 4	< 4	< 2	< 2	< 11	< 3
MW-PB-1	08/06/20	DUP	< 2	< 2	< 5	< 2	< 5	< 3	< 4	< 4	< 2	< 2	< 11	< 4
MW-PB-1	08/06/20	GEL	< 1	< 1	< 4	< 1	< 3	< 2	< 3	< 1	< 1	< 1	< 16	< 5
MW-PB-2	08/03/20		< 2	< 2	< 3	< 2	< 3	< 2	< 3	< 3	< 2	< 2	< 8	< 3
MW-PB-3	08/05/20		< 2	< 2	< 4	< 2	< 3	< 2	< 3	< 3	< 2	< 2	< 8	< 3
MW-PB-4	08/03/20		< 2	< 2	< 4	< 2	< 4	< 2	< 3	< 3	< 2	< 2	< 10	< 3
MW-PB-5	08/06/20		< 2	< 2	< 4	< 2	< 4	< 3	< 4	< 4	< 2	< 2	< 11	< 3
MW-PB-5	08/06/20	DUP	< 2	< 2	< 4	< 2	< 4	< 2	< 3	< 4	< 2	< 2	< 10	< 3
MW-PB-5	08/06/20	GEL	< 1	< 1	< 3	< 1	< 2	< 1	< 2	< 7	< 1	< 1	< 12	< 4
MW-PB-6	08/20/20		< 2	< 2	< 4	< 2	< 3	< 2	< 3	< 5	< 2	< 2	< 12	< 4
MW-PB-7	08/06/20		< 2	< 2	< 4	< 2	< 3	< 2	< 3	< 3	< 2	< 2	< 9	< 3
MW-PB-7	08/06/20	DUP	< 1	< 2	< 4	< 1	< 3	< 2	< 3	< 3	< 2	< 2	< 9	< 3
MW-PB-7	08/06/20	GEL	< 5	< 4	< 10	< 5	< 9	< 6	< 8	< 9	< 5	< 5	< 15	< 4
MW-PB-8	02/19/20		< 2	< 2	< 5	< 2	< 5	< 3	< 4	< 4	< 2	< 2	< 12	< 4
MW-PB-10	02/19/20		< 5	< 5	< 11	< 5	< 12	< 6	< 9	< 10	< 5	< 5	< 21	< 7
MW-PB-10	08/06/20		< 2	< 2	< 4	< 2	< 4	< 2	< 3	< 3	< 2	< 2	< 9	< 3
MW-PB-12	08/03/20		< 2	< 2	< 4	< 2	< 4	< 3	< 4	< 4	< 2	< 2	< 11	< 4
MW-PB-13	08/03/20		< 2	< 2	< 4	< 2	< 4	< 3	< 3	< 4	< 2	< 2	< 10	< 3
MW-PB-15	02/19/20		< 6	< 6	< 13	< 6	< 15	< 8	< 11	< 9	< 7	< 6	< 33	< 11
MW-PB-15	08/06/20		< 2	< 2	< 4	< 2	< 4	< 2	< 4	< 4	< 2	< 2	< 11	< 4
MW-PB-16	02/19/20		< 6	< 6	< 12	< 6	< 13	< 7	< 10	< 11	< 7	< 6	< 30	< 11
MW-PB-16	08/06/20		< 2	< 2	< 4	< 2	< 4	< 3	< 4	< 4	< 2	< 2	< 12	< 4
MW-PB-19	08/03/20		< 2	< 2	< 4	< 2	< 4	< 2	< 3	< 4	< 2	< 2	< 9	< 3
MW-PB-20	08/03/20		< 2	< 2	< 4	< 2	< 4	< 2	< 3	< 4	< 2	< 2	< 10	< 3
MW-PB-22	08/03/20		< 2	< 2	< 4	< 2	< 4	< 2	< 4	< 4	< 2	< 2	< 11	< 3
MW-PB-24	08/05/20		< 2	< 2	< 4	< 2	< 3	< 2	< 3	< 3	< 2	< 2	< 8	< 2
MW-PB-25	08/05/20		< 2	< 2	< 4	< 2	< 4	< 2	< 4	< 4	< 2	< 2	< 10	< 3
MW-PB-26	08/05/20		< 2	< 2	< 4	< 2	< 4	< 2	< 3	< 3	< 2	< 2	< 9	< 3
MW-PB-27	08/05/20		< 2	< 2	< 4	< 2	< 5	< 3	< 4	< 4	< 2	< 2	< 12	< 4
MW-PB-28	08/03/20		< 2	< 2	< 4	< 2	< 4	< 2	< 3	< 4	< 2	< 2	< 10	< 3
MW-PB-29	08/05/20		< 2	< 2	< 3	< 2	< 3	< 2	< 3	< 3	< 2	< 2	< 8	< 3
MW-PB-30	08/05/20		< 2	< 2	< 4	< 2	< 4	< 2	< 3	< 3	< 2	< 2	< 9	< 3
MW-PB-31	08/05/20		< 2	< 2	< 5	< 3	< 5	< 3	< 4	< 5	< 3	< 2	< 13	< 5
U/2 YARD DRAIN	08/19/20		< 1	< 2	< 3	< 2	< 3	< 2	< 3	< 5	< 2	< 2	< 12	< 4
U/3 YARD DRAIN	08/19/20		< 2	< 2	< 4	< 2	< 3	< 2	< 3	< 6	< 2	< 2	< 12	< 4

**TABLE B-I.3 CONCENTRATIONS OF HARD-TO-DETECTS IN GROUNDWATER SAMPLES COLLECTED AS PART OF THE RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM, PEACH BOTTOM ATOMIC STATION, 2020**  
 RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

SITE	COLLECTION		Am-241	Cm-242	Cm-243/244	Pu-238	Pu-239/240	U-234	U-235	U-238	Fe-55	Ni-63
	DATE											
MW-PB-8	08/06/20										< 88	< 3.8
MW-PB-10	08/06/20										< 74	< 4.5
MW-PB-15	08/06/20										< 89	< 3.8
MW-PB-16	08/06/20										< 64	< 4.3
MW-PB-25	08/05/20		< 0.17	< 0.04	< 0.17	< 0.12	< 0.13	0.23 $\pm$ 0.12	< 0.06	< 0.09	< 86	< 4.3

**TABLE B-II.1      CONCENTRATIONS OF TRITIUM IN SURFACE WATER SAMPLES COLLECTED  
AS PART OF THE RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM,  
PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

SITE	COLLECTION DATE	H-3
SP-PB-1	02/18/20	< 180
SP-PB-1	12/08/20	< 188
SP-PB-2	02/18/20	< 181
SP-PB-2	08/05/20	< 193
SP-PB-3	02/19/20	< 176
SW-PB-1	02/19/20	< 180
SW-PB-1	DUP 02/19/20	< 184
SW-PB-1	GEL 02/19/20	< 187
SW-PB-5	02/19/20	< 183
SW-PB-6	02/19/20	< 180

**TABLE B-II.2 CONCENTRATIONS OF GAMMA EMITTERS IN SURFACE WATER SAMPLES COLLECTED  
AS PART OF THE RADIOLOGICAL GROUNDWATER PROTECTION PROGRAM,  
PEACH BOTTOM ATOMIC POWER STATION, 2020**

RESULTS IN UNITS OF PCI/LITER ± 2 SIGMA

SITE	COLLECTION		Mn-54	Co-58	Fe-59	Co-60	Zn-65	Nb-95	Zr-95	I-131	Cs-134	Cs-137	Ba-140	La-140
	DATE													
SP-PB-1	12/08/20		< 3	< 3	< 6	< 3	< 6	< 3	< 4	< 5	< 3	< 3	< 14	< 5
SP-PB-2	08/05/20		< 2	< 2	< 4	< 2	< 4	< 2	< 3	< 3	< 2	< 2	< 9	< 3

TABLE B-III.1

**CONCENTRATIONS OF TRITIUM IN PRECIPITATION WATER SAMPLES  
COLLECTED AS PART OF THE RADIOLOGICAL GROUNDWATER  
PROTECTION PROGRAM , PEACH BOTTOM ATOMIC POWER STATION, 2020**  
RESULTS IN UNITS OF PCI/LITER  $\pm$  2 SIGMA

SITE	COLLECTION	
	DATE	H-3
1A	01/02/20	< 175
1A	01/30/20	< 182
1A	02/26/20	< 177
1A	04/02/20	< 153
1A	04/30/20	< 180
1A	05/27/20	< 185
1A	07/01/20	< 155
1B	01/02/20	< 172
1B	01/30/20	< 176
1B	02/26/20	< 175
1B	04/02/20	< 153
1B	04/30/20	< 180
1B	05/27/20	< 184
1B	07/01/20	< 152
1S	01/02/20	< 175
1S	01/30/20	< 181
1S	02/26/20	< 185
1S	04/02/20	< 149
1S	04/30/20	< 180
1S	05/27/20	< 180
1S	07/01/20	< 150
1SSE	01/02/20	< 182
1SSE	01/30/20	< 179
1SSE	02/26/20	< 189
1SSE	04/02/20	< 151
1SSE	04/30/20	< 181
1SSE	05/27/20	< 184
1SSE	07/01/20	< 151
1Z	01/02/20	< 172
1Z	01/30/20	< 180
1Z	02/26/20	< 188
1Z	04/02/20	< 151
1Z	04/30/20	< 182
1Z	05/27/20	< 184
1Z	07/01/20	< 150
4M	01/02/20	< 174
4M	01/30/20	< 180
4M	02/26/20	< 187
4M	04/02/20	< 150
4M	04/30/20	< 180
4M	05/27/20	< 180
4M	07/01/20	< 154
PB-P1	09/17/20	< 185
PB-P1	11/25/20	< 191
PB-P2	09/17/20	< 184
PB-P2	11/25/20	< 191
PB-P3	09/17/20	< 186
PB-P3	11/25/20	< 192
PB-P4	09/17/20	< 179
PB-P4	11/25/20	< 193
PB-P5	09/17/20	< 182
PB-P5	11/25/20	< 191
PB-P6	09/17/20	400 $\pm$ 132
PB-P6	11/25/20	< 188
PB-P7	09/17/20	518 $\pm$ 135
PB-P7	11/25/20	< 192
PB-P8	09/17/20	< 180
PB-P8	11/25/20	< 193